



International Agreement Report

Analyses of KS Test Data on the Heated Rod Bundle Temperature Behavior in RBMK-1500 Core Model Under Stop and Recovery Flow Using RELAP5/MOD3.2 and RELAP5/MOD3.2.2 GAMMA

Prepared by
V.A. Vinogradov, A.Y. Balykin
Nuclear Reactor Institute, Russian Research Center
Kurchatov Institute
Kurchatov Square 1
123182, Moscow Russia

**Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001**

April 2001

Prepared as part of
The Agreement on Research Participation and Technical Exchange
under the International Code Application and Maintenance Program (CAMP)

**Published by
U.S. Nuclear Regulatory Commission**

AVAILABILITY OF REFERENCE MATERIALS IN NRC PUBLICATIONS

NRC Reference Material

As of November 1999, you may electronically access NUREG-series publications and other NRC records at NRC's Public Electronic Reading Room at www.nrc.gov/NRC/ADAMS/index.html.

Publicly released records include, to name a few, NUREG-series publications; *Federal Register* notices; applicant, licensee, and vendor documents and correspondence; NRC correspondence and internal memoranda; bulletins and information notices; inspection and investigative reports; licensee event reports; and Commission papers and their attachments.

NRC publications in the NUREG series, NRC regulations, and *Title 10, Energy*, in the Code of *Federal Regulations* may also be purchased from one of these two sources.

1. The Superintendent of Documents
U.S. Government Printing Office
Mail Stop SSOP
Washington, DC 20402-0001
Internet: bookstore.gpo.gov
Telephone: 202-512-1800
Fax: 202-512-2250
2. The National Technical Information Service
Springfield, VA 22161-0002
www.ntis.gov
1-800-553-6847 or, locally, 703-605-6000

A single copy of each NRC draft report for comment is available free, to the extent of supply, upon written request as follows:

Address: Office of the Chief Information Officer,
Reproduction and Distribution
Services Section

U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

E-mail: DISTRIBUTION@nrc.gov

Facsimile: 301-415-2289

Some publications in the NUREG series that are posted at NRC's Web site address www.nrc.gov/NRC/NUREGS/indexnum.html are updated periodically and may differ from the last printed version. Although references to material found on a Web site bear the date the material was accessed, the material available on the date cited may subsequently be removed from the site.

Non-NRC Reference Material

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, and transactions, *Federal Register* notices, Federal and State legislation, and congressional reports. Such documents as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings may be purchased from their sponsoring organization.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at—

The NRC Technical Library
Two White Flint North
11545 Rockville Pike
Rockville, MD 20852-2738

These standards are available in the library for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from—

American National Standards Institute
11 West 42nd Street
New York, NY 10036-8002
www.ansi.org
212-642-4900

Legally binding regulatory requirements are stated only in laws; NRC regulations; licenses, including technical specifications; or orders, not in NUREG-series publications. The views expressed in contractor-prepared publications in this series are not necessarily those of the NRC.

The NUREG series comprises (1) technical and administrative reports and books prepared by the staff (NUREG-XXXX) or agency contractors (NUREG/CR-XXXX), (2) proceedings of conferences (NUREG/CP-XXXX), (3) reports resulting from international agreements (NUREG/IA-XXXX), (4) brochures (NUREG/BR-XXXX), and (5) compilations of legal decisions and orders of the Commission and Atomic and Safety Licensing Boards and of Directors' decisions under Section 2.206 of NRC's regulations (NUREG-0750).

DISCLAIMER: This report was prepared under an international cooperative agreement for the exchange of technical information. Neither the U.S. Government nor any agency thereof, nor any employee, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus, product or process disclosed in this publication, or represents that its use by such third party would not infringe privately owned rights.

NUREG/IA-0202



International Agreement Report

Analyses of KS Test Data on the Heated Rod Bundle Temperature Behavior in RBMK-1500 Core Model Under Stop and Recovery Flow Using RELAP5/MOD3.2 and RELAP5/MOD3.2.2 GAMMA

Prepared by
V.A. Vinogradov, A.Y. Balykin
Nuclear Reactor Institute, Russian Research Center
Kurchatov Institute
Kurchatov Square 1
123182, Moscow Russia

**Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001**

April 2001

Prepared as part of
The Agreement on Research Participation and Technical Exchange
under the International Code Application and Maintenance Program (CAMP)

**Published by
U.S. Nuclear Regulatory Commission**

ABSTRACT

This report has been prepared as a part of the Agreement on Research Participation and Technical Exchange under the International Code Application and Maintenance Program.

KS experimental data on the behavior of the heated rod bundle temperature in the RBMK-1500 core model under stop and recovery flow conditions were simulated with RELAP5/MOD3.2 and RELAP5/MOD3.2.GAMMA to assess the codes suitability. Especially calculations were performed to estimate differences in the code version predictions for processes/phenomena, which could occur under specific conditions of RBMK type reactor during LOCA with MCP's pressure header rupture and subsequent ECCS water injection.

This problem addresses phenomena of high importance to RBMK-1500 safety including water discharge, critical heat flux, post dryout heat transfer, reflood and propagation of rewetting front in the fuel channel during an accident.

The test have been carried out at KS semi-integral test facility (Russian Research Center Kurchatov Institute) represented RBMK primary circuit. The main purpose of the experiment was investigation of temperature conditions in the fuel assembly under high power value, inlet flow rate being decreased drastically up to complete stop of the flow followed by pressure header rupture. A subsequent flow rate resumption was also assumed, the fuel assembly power high level being unchanged.

First a study of the effect of the hydraulic nodalization to the code calculations was performed using different number of hydraulic volumes for the fuel channel model. After the choice of proper nodalization and maximum user-specified time step, base case calculations were done for the test.

Sensitivity studies were carried out to investigate the effects of modeling on the behavior of the rod simulator temperatures along the height of the fuel assembly model.

TABLE OF CONTENTS

1. INTRODUCTION	1
1.1. Objectives	1
1.2. Background	1
1.3. Study Description	1
1.4. Report Organization	2
2. DESCRIPTION OF RBMK LOOP MODEL ON KS TEST FACILITY	3
3. DESCRIPTION OF THE TEST	6
4. DESCRIPTIONS OF RELAP5 MODEL AND BASE CASE INPUT DECKS FOR THE TEST	10
4.1. RELAP5/MOD3.2 Model and Assumptions	10
4.1.1. Main allowances for simulation of the test	10
4.1.2. KS RBMK MFCC model nodalization and input data description	10
4.1.3. Methods of computer modeling of the experiment	15
4.2. RELAP5/MOD3.2.2 GAMMA Model and Assumptions	16
5. RESULTS OF THE CODES ASSESSMENT	17
5.1. RELAP5/MOD3.2 Base Case Results, Comparisons to KS Test Data and Conclusions	17
5.2. RELAP5/MOD3.2.2 GAMMA Base Case Results, Comparisons to KS Test Data and Conclusions	22
6. SENSITIVITY STUDY	25
7. RUN STATISTICS	26
8. SUMMARY OF CONCLUSIONS	27
REFERENCES	28
Appendix- A : Original Data Plots from KS Test 5	A-1
Appendix- B : RELAP5/MOD3.2 Base Case Results	B-1
Appendix- C : RELAP5/MOD3.2.2 GAMMA Base Case Results	C-1

Appendix- D : Sensitivity Study Results	D-1
Appendix- E : Base Case RELAP5/MOD3.2 Input Deck Listing	E-1

LIST OF FIGURES

Fig.2.1. KS RBMK MFCC model	4
Fig. 2.2. Fuel channel model cross section	5
Fig. 2.3. Cable thermocouple placement into the wall of the fuel rod simulator	5
Fig. 3.1. Measurements scheme	9
Fig. 4.1. Nodalization scheme of the RBMK MFCC model at the KS test facility	11
Fig. 4.2. Nodalization scheme of the RBMK-1500 Fuel channel model.	13
Fig. 7.1. Execution time (CPU TIME) of the main variant computation for the experiment	26
Fig. 7.2. Integration step (dt) variations at the main variant computation for the experiment	27
Fig. A-1. Mass flow rate G history at the FC model inlet in experiment 5.	A-2
Fig.A-2. Pressure drop DP16-4 history along the FA model in experiment 5	A-2
Fig. A-3. Pressure Pin history in the lower part of the FA model in experiment 5	A-3
Fig. A-4. Fuel rod simulator temperature Tw1 (z=6.894 m) history in experiment 5	A-3
Fig. A-5. Fuel rod simulator temperature Tw2 (z=6.854 m) history in experiment 5	A-4
Fig. A-6. Fuel rod simulator temperature Tw3 (z=3.814 m) history in experiment 5	A-4
Fig. A-7. Fuel rod simulator temperature Tw4 (z=1.044 m) history in experiment 5	A-5
Fig. A-8. Behavior of measured wall temperatures Tw1, Tw2, Tw3 and Tw4 in experiment 5	A-6
Fig. B-1. Mass flow rate G (t) history at the FC model inlet	B-2
Fig. B-2. Coolant temperature Tin (t) history at the FC model inlet	B-2
Fig. B-3. Pressure Pin (t) history in the lower part of the FA model	B-3
Fig. B-4. Pressure drop DP16-4 (t) history along the FA model	B-3
Fig. B-5. Fuel rod simulator temperature Tw1 (t) history	B-4
Fig. B-6. Fuel rod simulator temperature Tw2 (t) history	B-4
Fig. B-7. Fuel rod simulator temperature Tw3 (t) history	B-5
Fig. B-8. Fuel rod simulator temperature Tw4 (t) history	B-5

Fig. C-1. Comparisons between test data and RELAP5/MOD3.2 and RELAP5/MOD3.2.2GAMMA predictions for the behaviors of the considered parameter G and rod's wall temperatures Tw1-Tw4 in the base case with "motor valve 2r"	C-2
Fig. C-2. Comparisons between test data and RELAP5/MOD3.2 and RELAP5/MOD3.2.2GAMMA predictions for the behaviors of the considered parameters Pin and DP16-4 in the base case with "motor valve 2r"	C-3
Fig. C-3. Comparisons between test data and RELAP5/MOD3.2 and RELAP5/MOD3.2.2 GAMMA predictions for the behaviors of the rod's wall temperatures Tw1 and Tw2 in the base case with "motor valve 2r"	C-4
Fig. C-4. Comparisons between test data and RELAP5/MOD3.2 and RELAP5/MOD3.2.2GAMMA predictions for the behaviors of the rod's wall temperatures Tw3 and Tw4 in the base case with "motor valve 2r".	C-5
Fig. C-5. Comparisons between test data and RELAP5/MOD3.2 and RELAP5/MOD3.2.2GAMMA predictions for the behaviors of the rod's wall temperatures Tw1 - Tw4 in the base case with "motor valve 2r"	C-6
Fig. D-1. Comparisons between test data and RELAP5/MOD3.2.2GAMMA predictions for the behaviors of the considered parameters G and P in the cases with "motor valve 2r" and Time Dependent Junction in LWC	D-2
Fig. D-2. Comparisons between test data and RELAP5/MOD3.2.2GAMMA predictions for the behaviors of the considered parameters DP16-4 and Tw1 in the cases with "motor valve 2r" and Time Dependent Junction in LWC	D-3
Fig. D-3. Comparisons between test data and RELAP5/MOD3.2.2GAMMA predictions for the behaviors of the rod's wall temperatures Tw2 and Tw3 in the cases with "motor valve 2r" and Time Dependent Junction in LWC	D-4
Fig. D-4. Comparisons between test data and RELAP5/MOD3.2.2GAMMA predictions for the behaviors of the rod's wall temperatures Tw4 and Tw1-Tw4 in the cases with "motor valve 2r" and Time Dependent Junction in LWC	D-5

LIST OF TABLES

Table 3.1. Parameters of the initial steady state for KS RBMK-1500 Test 5.	6
Table 3.2. List of measured parameters and measurement errors	8
Table 4.1. The alignment of the nodalization in the fuel channel with the grid spacers	12
Table 5.1. Comparison of the base case calculated, sensitivity studied and experimental values of the main mode parameters at the steady state	18
Table 5.2. The results of RELAP5/MOD3.2 code assessment (code performance for process/phenomenon)	21
Table 5.3. The results of RELAP5/MOD3.2.2 GAMMA code assessment (code performance for process/phenomenon)	24

EXECUTIVE SUMMARY

Analyses of KS test with stop and recovery flow in the RBMK-1500 core model are presented in the Report. The objective of the analyses is to assess the RELAP5/MOD3.2 and RELAP5/MOD3.2.2 GAMMA codes for covering thermal and hydrodynamic processes in RBMK type reactor under MCP's pressure header large break conditions. Especially calculations were performed to estimate differences in the code version predictions for phenomena/processes, which could occur during LOCA. This problem addresses phenomena of high importance to RBMK-1500 safety including water discharge, critical heat flux, post dryout heat transfer, reflood and propagation of rewetting front in the fuel channel during an accident.

The test have been carried out at the KS semi-integral test facility (RRC KI) represented RBMK primary circuit. The main purpose of the experiment was investigation of temperature conditions in the fuel assembly under high power value, inlet flow rate being decreased drastically up to complete stop of the flow followed pressure header rupture. A subsequent flow rate resumption was also assumed, the FA power high level being unchanged.

Full scale model of one fuel channel with RBMK-1500 fuel assembly was used in the test. An abrupt flow rate termination with a high FA power level conserving attributed to the emergency under consideration was modeled by the FC inlet valve closure. The flow rate was recovered as the heated rod temperature reached the limit value. To do this the FC inlet valve was opened. It was the way to simulate the ECCS water supply into the fuel channel. FA model power, FA inlet pressure, FC inlet flow rate and coolant temperature, pressure drop across the FC section with heated rod bundle, heated rod temperatures along the FA model were recorded during the test.

The models of RELAP5/MOD3.2 and RELAP5/MOD3.2.2 GAMMA codes were investigated. Special emphases were given to the codes performance for the following processes/phenomena:

- * Pressure drop and water release from the fuel channel model and rod bundle surface drying.
- * Dryout under sharp flow deceleration at the inlet of the RBMK-1500 fuel assembly model.
- * Post dryout heat transfer and heated rod's wall temperature behavior in the fuel assembly model under channel drying.
- * Propagation of the reflood and quench fronts in the fuel assembly model under water flow resumption at the channel inlet.

First a study of the effect of the hydraulic nodalization to the code results was performed using different number of hydraulic volumes for the fuel channel model. After the choice of proper

nodalization with 40 nodes for the FA channel and maximum user-specified time step $dt_{max}=0.01$ s, the base case calculations were done for the test.

Sensitivity studies were carried out to investigate the effects of modeling on the behaviors of the rod simulator temperatures along the heated bundle height using motor valve component or Time Dependent Junction in LWC. Use of TDJ to accurate code simulation of the real flow rate behavior at the channel inlet gives more realistic code results for the initial and boundary conditions in the fuel channel. In this case the code predicted time interval Δt_d from the moment $t(G0)$ of complete stop flow to the beginning t_d of the rod's wall temperature $Tw1(t)$ increase at the core outlet exceeds the experimental value Δt_d by about ~ 0.2 s. This indicates a reasonable adequacy of the code simulation of dryout initiation at rapid decrease of the coolant flow right down to its total termination. Also, sensitivity studies were performed with estimating what was the influence of various models applied in these codes on calculation accuracy.

Code results are presented as time-dependent curves: - pressure $P_{in}(t)$ in the lower part of the heated rod bundle, coolant temperature $T_{in}(t)$ and mass flow rate $G(t)$ at the FC model inlet, total pressure drop $DP_{16-4}(t)$ across the heated bundle height, heated rod temperatures $Tw1(t)$, $Tw2(t)$, $Tw3(t)$, $Tw4(t)$ along the FA model height.

The curves serve for comparison of the calculation results with test data to appreciate codes suitability.

- Comparison of RELAP5/MOD3.2 results allow to draw a conclusion on reasonable agreements of general pictures of simulated processes/phenomena with test data on the stage with the decrease and complete stop of flow.

At the same time, it was intimated that there is a need to modify RELAP5/MOD3.2 models used for interphase friction and critical heat flux in the channel with the RBMK-1500 fuel assembly under initial steady conditions with forced circulation.

- When simulating the recovery stage of water supply into the channel there were essential distinctions between RELAP5/MOD3.2 code results and test data on the behaviors of the rod wall temperatures along the FA height. The code does not give qualitative agreement between the curves for the rod temperatures along the FA height at the quenching in the test. The code gives insufficient agreements with test data concerning the time characteristics and conditions of the rod surface quenching in the upper and middle parts of the FA. The analysis results allow the code suitability being assessed as insufficient. This stems from the fact that RELAP5/MOD3.2 reflood

model has not been adequately worked through and the developers do not recommend it to use. Shown is a necessity and importance of a special reflood model to be used for suitable description of the reflood stage of the transient. At assessment of the advanced code version RELAP5/MOD3.2.2 GAMMA and its reflood model, it is necessary to achieve a suitable simulation of the initial conditions for the recovery stage of water supply into the channel during the transient.

- Comparison RELAP5/MOD3.2.2 GAMMA results allow to draw a conclusion on a reasonable agreement of general pictures for simulated processes/phenomena with test data on the stage of the decrease and complete stop of flow.

RELAP5/MOD3.2.2 GAMMA results obtained when simulating reflood and quench fronts in the fuel channel allow the code adequacy being assessed as reasonable for the upper part of RBMK-1500 fuel assembly and as insufficient for the lower part of the FA model.

- Shown is a necessity for formulation special Standard Problem “Propagation of the reflood and quench fronts in the lower and upper parts of the RBMK-1500 fuel assembly under flow resumption at the channel inlet” and its analysis using RELAP5/MOD3.2.2 GAMMA.

NOMENCLATURE

N - electrical power of the FA model, kW;

G - water flow rate at the fuel channel inlet, kg/s;

Pin - pressure in the sampling point 15 of the fuel channel model, MPa, bar;

DP16-4 - actual pressure drop between the pressure taps 16 and 4, Pa;

Tin - water temperature at the fuel channel inlet, K;

Tw1 - Tw4 - rod fuel simulator wall temperature, K;

RRC KI - Russian Research Centre "Kurchatov Institute"

LWC - lower water communication lines;

SWC - steam-vapor water pipelines;

GDH - group distribution header;

ICV - isolating-control valve;

MFCC - multiple forced circulation circuit;

MCP - main circulation pump;

DS - drum-separator;

DM - differential manometer;

ECCS - emergency core cooling system;

PH - pressure header;

FE - fuel element;

FA - fuel assembly;

FC - fuel channel;

TDJ - Time Dependent Junction;

exp - experimental value;

calc - calculated value.

1. INTRODUCTION

1.1. Objectives

The main goals of this work are:

- Analyses of the KS experimental data on the behavior of the heated rod temperatures in the RBMK-1500 core model under stop and recovery flow conditions using RELAP5/MOD3.2 and RELAP5/MOD3.2.2 GAMMA;
- Assessment of the codes suitability for description of thermal and hydraulic processes, which could occur under specific conditions of RBMK-1500 type reactor during an accident with MCP's pressure header rupture and subsequent ECCS water injection.

Especially calculations were performed to estimate differences in the code version predictions for phenomena/processes, which could occur during LOCA. This problem addresses phenomena of high importance to RBMK-1500 safety including water discharge, critical heat flux, post dryout heat transfer, reflood and propagation of rewetting front in the fuel channel during an accident.

1.2. Background

To help ensure RELAP5 code can be used with confidence, Russian Research Centre "Kurchatov Institute" has agreed to perform and document independent assessment of the code for a wide range of applications. These exercises are necessary to help identify and quantify any code shortcoming, in particular for the Russian types of reactors VVER and RBMK. This report has been prepared as a part of the Agreement on Research Participation and Technical Exchange under the International Code Application and Maintenance Program. Analyses of KS Test 5 with RBMK-1500 core model under stop and recovery flow conditions were performed using the latest versions of the codes RELAP5/MOD3.2 and RELAP5/MOD3.2.2 GAMMA.

1.3. Study Description

MCP's pressure header break is one of the design basis accidents in RBMK type reactor. KS RBMK MFCC model is semi-integral model of RBMK primary system for investigations hydrodynamics and heat transfer under normal and accident conditions of a reactor. In this facility series of the tests with RBMK-1500 core model under stop and recovery flow conditions were performed at Russian Research Centre "Kurchatov Institute" during 1977 year [1].

The aim of the chosen KS RBMK-1500 Test 5 was to investigate temperature mode of the fuel assembly under sharp decrease in coolant flow rate right down to its total termination and its

recovery at constant high FA power generation. A similar situation can take place in the FC of the reference RBMK when MCP's pressure header breaking. In this case all the group distribution headers connected to the pressure header are cut off by the check valves, which are installed at the inlet to these group headers. Water ceases to be delivered into the fuel channels. There begins steam filling in the channels. To prevent FA overheating, ECCS water is supplied into the core.

Phenomena of hydrodynamics and heat transfer in RBMK-1500 core under MCP's pressure header break conditions are specific. So, it is necessary to estimate adequacy of the models of the code versions for modeling of these phenomena, because there are specific features in design of the core and fuel assembly of RBMK-1500. These specific features are FA rod location, geometry of rod and FA elements, hydraulic diameters of rod bundle cells and number of space grids, which are equipped with heat exchange intensifiers in the FA upper part. The behaviors of the core pressure drop and temperatures of the rods directly depends on these factors during LOCA.

The code simulation results are presented as curves. Pressure at the inlet of the FC model with FA, coolant temperature and mass flow rate at the FC model inlet, total pressure drop across the FA height and rod simulator temperature along FA have been plotted as time-dependent parameters for the experiment. The curves serve for comparisons of calculation results with experimental data to appreciate code suitability. The differences between RELAP5/MOD3.2 and RELAP5/MOD3.2.2 GAMMA predictions for the behaviors of the rod simulator temperatures along the height of the FA model and test data are described and analyzed.

Sensitivity studies were performed to investigate the influence of various process/phenomenon models applied in the code on calculation accuracy as well as nodalization and integration time step.

1.4. Report Organization

The following sections present and describe the steps that were taken to facilitate the codes assessments. In Section 2 the RBMK MFCC model at the KS Test Facility is described, and KS RBMK-1500 Test 5 is described in Section 3. Descriptions of RELAP5 model and base case input decks for the test modeling are given in Section 4. The base case results of the codes simulations for the test, comparisons of the calculated and measured values and conclusions are presented in Section 5. Sensitivity studies results are presented in Section 6, and run statistics are given in Section 7. In Section 8 summary of conclusions is presented. In the Appendix E one finds the base case RELAP5/MOD3.2 input deck listing for KS RBMK-1500 Test 5.

2. DESCRIPTION OF RBMK LOOP MODEL ON KS TEST FACILITY

The KS test facility simulates the main forced circulation loop of RBMK primary circuit.

KS RBMK MFCC model (Fig. 2.1) includes models of all the main elements of RBMK multiple forced circulation circuit: - (1) pressure header (PH), (2) group distribution header (DH), (3) lower water communication lines (LWC), (4) an isolating control valve (ICV), (5) a full-size fuel channel (FC) with (6) an electrically heated fuel assembly (FA), (7) the lifting path with (8) assembly suspension, and (9) steam water communication lines (SWC). The SWC horizontal section has a slope of 0.7° . The upper horizontal header (10) and three vertical separators (11) do not model real drum separators (DS) but provide boundary conditions in the circuit outlet.

The model of RBMK-1500 fuel assembly (Fig. 2.2) includes 18 fuel element simulators made of stainless steel tubes of 13.5 mm OD and a central unheated rod (OD 15 mm) of the same steel. The radial power peaking in the fuel assembly is provided due to differences in wall thickness of the heated tubes: wall thickness of 12 tubes in the peripheral row is 4 mm and that of 6 tubes in the inner row is 3 mm. The FE power in the peripheral row is higher than that in the inner row being proportional to the ratio of cross section areas of FE simulator tube walls (~ 1.21), and it correlates as 1.061 to 0.878, if 1 is the average FE's power. The fuel assembly model is heated by the direct current passing through the fuel element simulators with uniform power density distribution along the FA height. Cable thermocouples of 1.5 mm OD are sealed in the fuel element simulator walls (Fig. 2.3).

Eleven RBMK-1500 reactor spacing grids-intensifiers with the full number of cells with pitch of 360 mm were installed in the upper part of the heated section along 3600 mm length. 20 grids-intensifiers of RBMK-1500 reactor were placed between them with 120 mm pitch, which served as spacers only for 6 fuel elements of the inner row. Nine authorized standard grids with 360 mm pitch were mounted in the lower part of the FA model.

The RBMK-1500 channel design differs from that of RBMK-1000 by spacer grids, which are equipped with heat exchange intensifiers in the FA upper part. Availability of these intensifiers in the upper part of the FA allows increasing in channel heat power.

The lower halves of RBMK-1500 and RBMK-1000 fuel assemblies are identical. Therefore some experimental results obtained in this experiment concerning the lower assembly half are applicable for RBMK-1000 (for instance, dryout onset, post dryout heat transfer...).




Fig. 2.1. KS RBMK MFCC model.




Fig. 2.2. Fuel channel model cross section.




Fig. 2.3. Cable thermocouple placement into the wall of the fuel rod simulator.

There is also equipment that simulates operation of reactor drum separators (DS), steam condensers, downcomers and main circulation pumps of the RBMK primary circuit. However, this equipment do not model the appropriate RBMK MFCC components. For this reason the RBMK primary circuit model at the KS test facility is considered as semi-integral one.

Processes in the parallel fuel channels are under consideration during this experiment. One of the channels is considered as a full-size model of RBMK fuel channel. Impact of the rest parallel channels is simulated with the FC bypass (18). A great flow rate through the FC bypass provides practically constant pressure drop between the upper and lower headers in the course of the experiment.

The pressurization system used in the experiment includes 6 pressurizers of 0.52 m³ in total volume connected to the 1-st collecting header. Nitrogen was used by way of gas medium.

More detailed description of RBMK MFCC model at the KS test facility is in [2].

3. DESCRIPTION OF THE TEST

The mode parameters in the course of the series of the tests were varied in the following ranges:

- FA model power: 1691 - 4566 kW;
- FA model inlet pressure: 7.68 - 8.74 MPa;
- FC model inlet temperature: 516 - 533 K;
- FC model inlet flow rate 3.9 – 6.27 kg/s.

Before the beginning chosen Test 5, the initial steady state with coolant forced circulation was set at given initial parameters outlined in Table 3.1.

Table 3.1. Parameters of the initial steady state for KS RBMK-1500 Test 5.

Designation of experiment	N kW	G Kg/s	Pin MPa	Tin K	DP16-4 MPa
KS RBMK-1500 Test 5	2486	4.70	8.40	527.4	0.2616

Given value of flow rate through the FC model was provided with an isolating control valve (see 4 in Fig.2.1). At given head-flow rate characteristic of the pumps a required total water flow rate through the FC model and FC bypass is provided with valve situated on the pump bypass.

Required flow rate distribution between MFCC and pump bypass is provided with matching local hydraulic resistance of the valve situated on the pump bypass at computer simulating of the test.

The FC model conditions during the experiment are nearly close to those when breaking the MCP's pressure header in the RBMK reactor and cutting off fuel channels with check valves.

When limiting temperature (this temperature mustn't be more than 870 K) is reached on the fuel rod simulator surface there is a resumption of flow rate through the fuel channel. Thus coolant circulation recovery on account of ECCS operation was simulated. The test is carried out at constant electrical power of the FA model.

Coolant been supplied from the pumps (13) went up through the riser of the fuel channel model (6, 7) and also through the FC bypass (17) up to the upper header (10) and then descended through four downcomers of RBMK MFCC model down to the suction side of the pumps.

Upon achieving a steady state, parameter recording began and an isolating control valve (4) at the inlet to the FC model closed completely and rapidly (during 3 s) causing the decrease in coolant flow rate down to zero. At achieving predetermined limit temperature of the rod simulators, an isolating control valve quickly opened and coolant flow rate recovered. In this case, temperature of the fuel element simulators decreased down to that close to saturation one.

States of the rest valve on the FC bypass and also the valves on the four downcomers and on the pump bypass were unchangeable during the transient.

During transient, a flow rate through the FC bypass remained practically constant (about 33.3 kg/s within the limits of experimental error). In the course of the experiment pressure in the upper header and separation columns was not maintained constant. The measurements scheme is shown in Fig.3.1.

The following parameters, outlined in Table 3.2, were measured and registered in the course of the experiment.

Table 3.2. List of measured parameters and measurement errors.

Parameter	Absolute measurement error
FA model electrical power N	± 60 kW
Water mass flow rate G at the FC inlet	± 0.14 kg/s
Pressure P_{in} at the FA model lower part	± 0.15 MPa
Pressure drop DP16-4 on the FA model height	± 0.1 KPa
Water temperature T_{in} at the FA model inlet	± 6 K
FE simulator wall temperatures $T_{w1} - T_{w4}$ along the height of the FA model	± 16.5 K

The range of non-sensibility of the differential pressure gage is 0 - 120 KPa, because the device for measuring the pressure drop DP16-4 reached its lower measurement limit equal to 120 KPa.

According to special tests, response time of the thermocouples was 0.3 s.




Fig. 3.1. Measurements scheme.

4. DESCRIPTIONS OF RELAP5 MODELS AND BASE CASE INPUT DECKS FOR THE TEST

4.1. RELAP5/MOD3.2 model and assumptions

4.1.1. Main allowances for simulation of the test

When calculating and assessing suitability of RELAP5/MOD3.2 and its modeling units for description of separate phenomena and complex processes, it is conventional in the first stage of the code simulation to use the options recommended by the code developers for actuating the code models under analogous conditions. The general modeling approaches recommended in the RELAP5 manuals [3, 4] should continue to be used.

The following assumptions were made:

- Volume Vertical Stratification, Water Packing, Abrupt Area Change, Branching, Noncondensables, Umbrella Model were process models activated for the corresponding circuit components;
- Process models such as an additional model of countercurrent flow limitation (CCFL Model), model of critical mass flow rate (Choked Model), and Reflood Model were not to be used in the corresponding circuit components.

To describe interphase friction in the coolant in the FC model with the FA, an option designating to rod bundle (with flag b=1) is applied. Semi-implicit scheme of numerical integration specified with the tt=3 option is used to calculate conjugate hydrodynamics and heat transfer/conduction processes.

4.1.2. KS RBMK MFCC model nodalization and input data description

RELAP5/MOD3.2 model simulates RBMK MFCC model at the KS test facility. This model includes a riser being investigated that contains two branches with models of the MFCC components, and auxiliary downcomer of four branches including components that ensure initial and boundary conditions in the MFCC part under consideration and also the test facility operation as a whole. Nodalization scheme for RBMK MFCC model at the KS test facility (in terms of RELAP5) is presented in Fig. 4.1. This nodalization scheme and input decks were developed with regard to the main assumptions when carrying out computer analysis of the test.




Fig. 4.1. Nodalization scheme of the RBMK MFCC model at the KS test facility.

To simulate operation of each pump when they activated simultaneously it was necessary to use conjectural homological head and torque curves for 8 single-phase modes of TsEN-146 pumps.

During the experiments the pumps operated continuously in single-phase flow at the wheel velocity of 3000 rpm.

At given head/flow characteristics of TsEN-146 pumps for normal operating conditions, required total water flow rate through the FC model and channel bypass is provided with the valve in the pumps bypass. This valve is modeled with component mtrvlv79. Given distribution of flow rates between MFCC model and pumps bypass is provided with choosing local hydraulic resistance of the valve component (mtrvlv79) during computer modeling of the experiment. Positions of the valve on the FC bypass (in Fig. 4.1 an orifice of constant local hydraulic resistance $\xi=135$ is shown instead of the FC bypass valve) and the valve on the pumps bypass were not changed during the transient under investigation.

Taking into account a great quantity of components in the primary and secondary circuits of the KS

test facility, it was used only one equivalent component when modeling each appropriate group of the typical components located in four branches of the downcomer. In particular, only one component vol. 20 is used to simulate three separators (11). Three condensers (14) are modeled with one component vol. 32. When developing these equivalent models, particular attention was given to parity between real volumes and lengths of the inlet and outlet pipelines and those of corresponding hydrodynamic components as well as between surface areas of heat transfer toward water in the second circuit. These conditions are necessary to bring about representation of experimental conditions of heat exchange between primary and secondary circuits and to ensure simulation of coolant pressure behavior in the primary circuit at transient under investigation. To do this the modeling of circuit volume sections with two-phase mixture and gas must be obviously suitable.


Coolant flow termination to the FC model inlet with successive flow resumption are simulated with closing and next opening of ICV that uses a component like “motor valve 2”. To control valve “close” and “open” procedures at given time moments Trip Input Data are used.

When modeling the section of the fuel channel with the FA model it was chosen a fine nodalization for hydrodynamic components and heat structures along the channel height that was connected to the pitches between spacer grids and grid-intensifiers (see Fig. 4.2).

The alignment of the nodalization in the fuel channel with the grid spacers is presented in Table 4.1. However, this resulting grid does not align well with some of the temperature and pressure measuring positions. This adds an uncertainty (< 1%) when comparing calculated and experimental values.

Table 4.1. The alignment of the nodalization in the fuel channel with the grid spacers.

Measurement	Experimental Height [m]	Closest Component in RELAP Model		
		Component Input Deck	Node Center Height [m]	Node Span Height [m]
DP16-4 bottom	0.186	vol. 5, node 3	0.340	0.160 – 0.520
PIN	1.586	vol. 5, node 6	1.420	1.240 – 1.600
DP16-4 top	6.836	vol. 5, node 40	6.820	6.760 – 6.880
TW4	1.044	ht. st. 51, node 4	1.060	0.880 – 1.240
TW3	3.814	ht. st. 51, node 14	3.820	3.760 – 3.880
TW2	6.854	ht. st. 51, node 39	6.820	6.760 – 6.880
TW1	6.894	ht. st. 51, node 40	6.940	6.880 – 7.000



1

Fig. 4.2. Nodalization scheme of the RBMK-1500 Fuel channel model.

Rod simulator walls were modeled with “heat structure” components with internal heat sources. Boundary conditions on the rod’s outer surfaces were set with Right Boundary Condition Cards with boundary condition type W3 (I)=110 (“Vertical bundle without cross flow” with $P/D = 16.5/13.5 = 1.222$ on 901-940 cards). Heat transfer hydraulic diameter (i.e., heated equivalent diameter) $De=11.92$ mm is used for fuel channel with the 19-rods bundle (with 18 heated rods).

To account the heat exchange processes to be impact by the grids, it were used “Additional Right Boundary Cards”. Local hydraulic resistance $\xi=0.55$ are to simulate 9 spacer grids arranged with the pitch of 360 mm in the lower part of the heated region. For 11 grid intensifiers situated with the pitch of 360 mm in the upper part of the heated region, local hydraulic resistance are defined to be $\xi=0.91$. As for 20 grid intensifiers, which are in the upper part of the heated region having the pitch of 120 mm, their local hydraulic resistance are equal to $\xi=0.28$.

In the “base case” calculations, power density distribution in the fuel rod simulators over the FA cross section was non-uniform. Power of 12 rods in the peripheral row was higher than rod power in the inner row of the bundle, because of the real radial power peaking factor of the FA model was 1.061.

The rod simulator wall is portioned in thickness into 4 layers so that the external layer thickness is 0.75 mm corresponding to the deepness at which the thermocouple’s hot junction is positioned in the wall. This enables a direct comparison of RELAP5/MOD3.2 calculation results for wall temperature at this depth with the test data on temperatures Tw_1 , Tw_2 , Tw_3 and Tw_4 .

Channel walls of the riser and descending circuit sections to the points of the condenser, heat exchanger and aftercooler were also modeled with “heat structure” components in order to simulate heat accumulation in the metal and external heat losses.

External heat losses from the primary circuit are modeled with setting up the heat transfer coefficient to be $K=10$ W/[m² K]. This value is constant in the region from the external surface of the heat structure which models the channel wall to the points of time-independent temperature of 295 K.

4.1.3. Methods of computer modeling of the experiment

This computer model makes it possible to simulate directly the experiment. When computer modeling the experiment the problem is setting up adequate thermal hydraulic characteristics of the components in the primary and secondary circuits (in the auxiliary section).

Using valve mtrvlv2, it is especially difficult to ensure experimental time-dependency of the coolant flow rate at the FC inlet obtained in the test. Because of it there was special computer simulation method and an Input Deck developed for the test.

When modeling the initial steady state with forced circulation, a balance between the FA power and heat removal in the condenser, heat exchanger and aftercooler was achieved with setting distribution of primary circuit coolant flows between descending branches and choosing water temperature in the secondary circuit. In this case, circuit pressure P_{in} , coolant temperature T_{in} and flow rate G through the FA model were stabilized after reaching the values equal to corresponding initial parameters obtained in the test at the moment $t_{exp}=0$ within the measurement error. Mass inventory in the primary circuit of MFCC was also stabilized. Water flow rate about 33.3 kg/s within the limits of experimental error through the bypass was set at a constant local hydraulic resistance $\xi=135$ of the valve on the FC bypass. Given flow rate at the FC inlet was ensured with the valve mtrvlv2, which local hydraulic resistance $\xi=770$ was chosen in the course of computer modeling for the test.

Calculations of this preset regime were run during $t_{calc}=1000$ seconds for stabilizing coolant parameters and heat structure temperatures in the primary circuit. Before this took place, the volume TDV100 containing subcooling water was connected to the primary circuit model. The water temperature equal to required value T_{in} at the FC inlet and also the pressure for supporting required pressure P_{in} in the channel at the moment $t_{exp}=0$ were set in this volume.

Vary small or close to zero values of water flow rates in the conjunctions SJ93 and SJ101 and, consequently, stabilization of mass inventory in the primary circuit were also demonstrations of stabilization of the processes in the primary and secondary circuits.

After achieving the steady state in the primary circuit at required coolant mode parameters at the FC inlet, the volume TDV100 was disconnected from the primary circuit of MFCC model and a closed primary circulation circuit including the pressurizer was formed. In so doing, only the pressurizer with subcooled water was connected to the primary circuit model. In the pressurizer, liquid level was preset to be in the middle of its vessel, as for liquid temperature its value was equal to T_{in} i.e.

the initial magnitude required at the FC inlet. Gas (nitrogen) pressure was specified to ensure a given FC pressure P_{in} at the moment $t_{exp}=0$ s. Stabilization of the calculated pressures $P(t)_{calc}$ and volume equilibrium qualities $X_e(t)_{calc}$ at the inlet and outlet of the FA model were also demonstrations of stabilization of the processes in the primary and secondary circuits during the time interval from $t_{calc}=1000$ s to $t_{calc}=1400$ s.

Simulation of the curve of sharp decrease in water flow rate down to zero at the FC model inlet with valve $mtrvlv2$ was performed by choosing its close rate and a related value of its initial position as well as moments to begin its opening and closing. The FA power was unchanged during the test.

When the rod simulator temperature preset limit was reached (it should not be above 870 K) valve $2r$ was quickly opened with coolant flow being recovered. In this case, the rod simulator temperatures were decreased down those closed to saturation temperature. Simulation of the curve of sharp increase in water flow rate at the FC model inlet up to a given value with valve $mtrvlv2$ was performed by choosing its opening rate as well as moments to begin its opening and closing. This flow rate was smaller than the initial one at the moment $t_{exp}=0$ s.

When modeling transient in the fuel channel with the FA model, it was chosen a maximum time step $dt_{max}=0.01$ s. This value is in agreement with the recommendations [3, 4] for calculating such processes.

4.2. RELAP5/MOD3.2.2 GAMMA model and assumptions

When calculating and assessing suitability of RELAP5/MOD3.2.2 GAMMA and its modeling units for description of separate phenomena and complex processes, it is conventional to use the options recommended by the code developers for actuating the code models under analogous conditions.

The following assumptions were made:

- Volume Vertical Stratification, Water Packing, Abrupt Area Change, Branching, Noncondensables, Umbrella Model and Reflood Model were process models activated for the corresponding circuit components;
- Process models such as an additional model of countercurrent flow limitation (CCFL Model), model of critical mass flow rate (Choked Model) were not to be used in the corresponding circuit components.

When modeling transient in the fuel channel with the FA model, it was chosen a maximum time step $dt_{max}=0.01$ s.

5. RESULTS OF THE CODES ASSESSMENT

5.1. RELAP5/MOD3.2 base case results, comparisons to KS test data and conclusions

Calculation of presetting mode with TDV100 been connected was performed during first 1000 s and then, after disconnecting TDV100, was continued up to 1400 s for achieving a steady state in the primary circuit. When calculating both preset mode and transient under investigation, option TRANSNT was used. To justify the basic nodalization scheme, methods for modeling of the test and corresponding input deck, preliminary calculations of the experiment were performed.

Calculation results and test data for the main mode parameters G_{in} , T_{in} , and P_{in} at the FC inlet under steady conditions with forced circulation are presented in Figures 1, 2 and 3, respectively, in Appendix B and in Table 5.1 to be compared. In these figures and in the table, one can see the calculated values of mentioned parameters at the steady state are close to the experimental ones or they lie within the range of measurement accuracy. During the test the steady state is considered a mode to be in the interval of time from $t_{exp}=0$ s to the moment when water flow rate begins to decrease.

To estimate suitability of computer modeling of complex thermal hydraulic processes in the FC with FA model at the steady state the base case calculation results of the total pressure drop DP16-4 and rod's wall temperatures T_{w1} , T_{w2} , T_{w3} , T_{w4} across the FA model height were used. These base case results are presented in Figures 4 - 8 in Appendix B and in Table 5.1 to be compared with test data, too.

As an integral criterion for the suitability assessment of simulation of thermal hydraulic processes in the channel with the RBMK-1500 fuel assembly, it was used the value of relative mismatching of total pressure drop DP16-4 along the FA model height which is determined as follows:

$$\Delta \equiv \frac{DP_{cdc} - DP_{exp}}{DP_{exp}} \cdot 100\%$$

For comparison, Table 5.1 lists calculation results and data for DP16-4 obtained during the test.

In the preliminary case with FC wall roughness $4 \cdot 10^{-6}$ m the code gives -9.7% underestimation in pressure drop DP16-4 relating to the measured value in the steady state. This discrepancy for total pressure drop DP16-4 may be resulted from inaccurate code description of the local losses of pressure on the spacer grids and grid-intensifiers as well as wall and interphase frictions in the two-

phase flow in the heated rod bundle. There needs to be some effort to address this error via parametric changes in the input. Therefore, sensitivity study was performed with different FC wall roughness for the test.

In the base case calculation with FC wall roughness $4 \cdot 10^{-5}$ m the code gives + 5.4 % overestimation in pressure drop DP16-4 relating to the measured value in the steady state. The increasing of the FC wall roughness in 10 times results in code over prediction for DP16-4 pressure drop, however the base case calculated value of pressure drop DP16-4 is in a satisfactory agreement with the measured one.

The calculated values of the rod temperatures Tw1, Tw2, Tw3, Tw4 along the FA height are in satisfactory agreements with the test data, too. In steady state the code describes with a reasonable suitability a heat transfer in two-phase flow in the channel with the RBMK-1500 fuel assembly.

Table 5.1. Comparison of the base case calculated, sensitivity studied and experimental values of the main mode parameters at the steady state.

Steady state parameters	N kW	G _{in} Kg/s	P _{in} MPa	T _{in} K	G _{bypass} Kg/s	Total pressure drop DP16-4, Pa	Mismatching $\pm \Delta$ (DP16-4), %
5 (experiment)	2486	4.70	8.40	527.4	33.3	261600	
5 (calculation with roughness 4·10 ⁻⁶ m)	2486	4.73	8.38	526.5	30.8	236290	- 9.7
5 (base case calculation with roughness 4·10 ⁻⁵ m)	2486	4.62	8.42	526.5	30.8	275820	+ 5.4

RELAP5/MOD3.2 describes with a reasonable suitability the complex processes at the stage of the transient in the test when the coolant flow rate decreases and completely terminates.

In particular, the pictures of the experimental and calculated pressures $P(t)$ are in a qualitative agreement, although at certain stages the calculated one is higher or lower than measured value in the transient. At the same time, the rates of the increase or decrease in pressures dP/dt as well as finally achieved pressure values are essentially different from those obtained experimentally (see Fig. B-3). Predicted pattern of the behavior of total pressure drop $DP_{16-4}(t)$ is in a qualitative agreement with experimental data. The reasons for these discrepancies when describing the 1-st stage of the transient may be a non-adequate code description of dynamic processes of steam generation in the FC with FA as well as steam condensation in the components of the closed circuit as a whole and, consequently, non-adequate description of the pressure behavior in the primary circuit and in the fuel channel.

RELAP5/MOD3.2 code reasonably describes the character and rate of the thermal and hydrodynamic processes and the behaviors of the parameters concerned in the first stage of the transient. To assess integrally an accuracy of the code simulation of the complex processes, the time interval Δt_d (from the moment of full stop of flow to the beginning of increase in wall temperature $Tw_1(t)$ at the FA outlet) was used. The value of the time interval $\Delta t_d = t_d - t(GO)$ been predicted for the test exceeds the experimental value Δt_d by about ~ 1.0 s. This indicates a reasonable suitability of the code simulation of the dryout initiation and its propagation along the FA height during the 1-st stage of the transient. The results would be still closer to the test data when simulating the flow rate behavior at the FC inlet as in a reality. Use of Time Dependent Junction to accurate code simulation of a real flow rate behavior at the channel inlet gives more realistic code results for the initial and boundary conditions for the fuel channel during the test.

The comparisons of the behaviors of rod's wall temperatures $Tw_1(t)$, $Tw_2(t)$, $Tw_3(t)$, and $Tw_4(t)$ been measured and also those of calculated wall temperatures during the transient in the experiment are presented in Figures B-5, B-6, B-7 and B-8, respectively.

When simulating the test, the dryout primarily happens at the FA outlet leading to an increase in temperatures $Tw_1(t)$ and $Tw_2(t)$, as evident from Fig. B-5, B-6. Then the dryout propagates with time from top to bottom along the FA height. This predicted picture of the dryout initiation and its propagation from the top down along the FA height is in a qualitative agreement with test data.

This indicates a reasonable suitability of the code simulation of the dryout initiation and its propagation along the FA height during the 1-st stage of the transient at FA power been constant.

It should be specially noticed that the maximum values $T_w(t)_{\max, \text{calc}}$ of the calculated wall temperatures exceed the maximum experimental magnitudes $T_w(t)_{\max, \text{exp}}$. It means that the code would be likely to overestimate the maximum cladding temperature, which would be a conservative result from a safety perspective.

The reflood model does not behave in RELAP5/MOD3.2, therefore the second stage of the investigated transient in the test was simulated under conditions when a special reflood model is not in usage. This allowed to make more exact the conditions for modeling the thermal and hydrodynamic processes as well as to estimate a necessity and importance of a special code model to be used for analyzing of reflood during the second stage of the transient.

The adequate code simulation of the complex processes at the first stage of the transient allow exactly modeling the initial conditions for the second stage of the transient.

The code gives an insufficient agreement with test data concerning the time characteristics and conditions of the rod surface quenching in the upper part of the FA model. The code gives only a qualitative agreement demonstrating a presence of rod surface quenching in the lower FA part in the cross-section where thermocouple Tw4 is installed (see Fig. B-8). At the same time, the rest of the cross-sections been positioned above (see thermocouples Tw1 (t), Tw2 (t), Tw3 (t) in Figures B-5, B-6, B-7) do not quench during the 2-nd stage when calculating the experiment during 40 seconds. Shown is that the calculated velocity of quench front propagation is less than that in the test at constant power $N=2486$ kW.

The analysis results obtained when modeling the reflooding of FC with RBMK-1500 fuel assembly allow RELAP5/MOD3.2 code suitability being assessed as insufficient. Shown is a necessity and importance of a special Reflood Model to be used for suitable description of the second stage of the transient. At validation of the advanced code version RELAP5/MOD3.2.2 GAMMA and assessment of its reflood model, it will be necessary to achieve a suitable simulation of the initial conditions for the second stage of the transient.

The results of RELAP5/MOD3.2 code assessment are presented in Table 5.2.

Table 5.2. The results of RELAP5/MOD3.2 code assessment (code performance for process/phenomenon).

<i>1. Process/Phenomenon in the steady state in Test 5</i>	<i>Results of RELAP5/MOD3.2 assessment</i>
1.1. Total pressure drop along the height of the channel with RBMK-1500 fuel assembly	Reasonable adequacy
1.2. Heat transfer in the two-phase flow in the channel with the RBMK-1500 fuel assembly	Reasonable adequacy
<i>2. Process/Phenomenon on the stage of decrease and full stop of flow in Test 5</i>	<i>Results of RELAP5/MOD3.2 assessment</i>
2.1. Total pressure drop and water release from the fuel channel model and heated rod surface dryout	Reasonable adequacy
2.2. Dryout under sharp flow deceleration at the inlet of the RBMK-1500 fuel assembly	Reasonable adequacy
2.4. Post dryout heat transfer and heated rod bundle temperature behavior in the lower and upper parts of RBMK-1500 fuel assembly under stop of flow and channel drying conditions	Reasonable adequacy
<i>3. Process/Phenomenon on the recovery stage of water supply into the fuel channel model</i>	<i>Results of RELAP5/MOD3.2 assessment</i>
3.1. Propagation of the reflood and quench fronts in the RBMK-1500 fuel assembly under flow resumption at the channel inlet	Insufficient adequacy

5.2. RELAP5/MOD3.2.2 GAMMA base case results, comparisons to KS test data and conclusions

Calculation of presetting mode with TDV100 been connected was performed during first 1000 s and then, after disconnecting TDV100, was continued up to 1400 s for achieving a steady state in the primary circuit.

RELAP5/MOD3.2.2 GAMMA results and test data for the main mode parameters G_{in} and P_{in} at the FC inlet under steady conditions with forced circulation are presented in Figures C-1 and C-2, respectively, in Appendix C to be compared. In these figures one can see the calculated values of mentioned parameters at the steady state are close to the experimental ones.

The base case results for total pressure drop DP16-4 and rod's wall temperatures Tw1, Tw2, Tw3, Tw4 across the FA model height are presented in Figures C-2, C-3, C-4 in Appendix C to be compared with test data. The code gives + 5.4 % overestimation in pressure drop DP16-4 relating to the measured value in the steady state. The calculated values of the rod's wall temperatures along the FA height are in satisfactory agreements with test data, too. In steady state the code describes with a reasonable suitability a heat transfer in two-phase flow in the channel with the RBMK-1500 fuel assembly.

RELAP5/MOD3.2.2 GAMMA describes with a reasonable suitability the complex processes at the first stage of the transient with stop of flow.

The pictures of the experimental and calculated pressures $P(t)$ are in a qualitative agreement, although at certain stages the calculated pressure is higher or lower than measured one in the transient (see Fig. C-2). Predicted pattern of the behavior of total pressure drop DP16-4 (t) is in a qualitative agreement with test data. The reasons for these discrepancies when describing the 1-st stage of the transient may be a non-adequate code description of dynamic processes of steam generation in the fuel channel as well as steam condensation in the components of the closed circuit as a whole and, consequently, non-adequate description of pressure behavior in the primary circuit and in the fuel channel.

RELAP5/MOD3.2.2 GAMMA code reasonably describes the character and rate of the thermal and hydrodynamic processes and the behaviors of the parameters concerned in the 1-st stage of the transient. Comparisons between test data and RELAP5/MOD3.2 and RELAP5/MOD3.2.2 GAMMA predictions for the behaviors of the considered parameters in the base case with "motor valve 2r" are presented in Appendix C. The comparisons of the behaviors of rod's wall temperatures Tw1 (t), Tw2 (t), Tw3 (t), and Tw4 (t) been measured and also those of calculated

temperatures during the transient are presented in Figures C-3, C-4 and C-5. These indicate a reasonable suitability of the code simulation of the dryout initiation and its propagation along the FA height during the 1-st stage of the transient at FA power been constant. The maximum values $T_w(t)_{\max \text{calc}}$ of the calculated wall temperatures exceed the maximum experimental magnitudes $T_w(t)_{\max \text{exp}}$. It means that RELAP5/MOD3.2.2 GAMMA code would be likely to overestimate the maximum cladding temperature, which would be a conservative result from a safety perspective.

The reflood model behaves in RELAP5/MOD3.2.2 GAMMA code, therefore the transient in the test was simulated using a special reflood model. This allowed to assess adequacy of a special model for analyzing of reflood during the second stage of the transient.

The adequate code simulation of the complex processes at the first stage of the transient allow exactly modeling the initial conditions for the second stage of the transient with FC reflood.

The code gives reasonable agreements with test data concerning the time characteristics and conditions of the rod surface quenching in the upper part of the FA model (see thermocouples Tw1 (t) and Tw2 (t) at the elevations 6.94 m and 6.82 m, respectively, in Figure C-3). The code gives only a qualitative agreement demonstrating a presence of rod surface quenching in the middle FA part (see thermocouple Tw3 (t) at the elevation 3.82 m in Figure C-4).

At the same time, the cross-section been positioned below does not quench during the 2-nd stage when calculating the experiment during 40 or 350 seconds (see temperatures $T_w(t)_{\text{calc}}$ at the elevation 1.04 m in Figures C-4 and C-5). Shown is an insufficient code adequacy for the lower FA model part

RELAP5/MOD3.2.2 GAMMA results obtained when simulating reflood and quench fronts in the fuel channel model allow the code adequacy being assessed as a reasonable adequacy for the upper part of RBMK-1500 fuel assembly model and an insufficient adequacy for its lower part.

Shown is a necessity for formulation special Standard Problem “Propagation of the reflood and quench fronts in the lower and upper parts of RBMK-1500 fuel assembly model under flow resumption at the channel inlet” and its analysis using RELAP5/MOD3.2.2 GAMMA

The results of RELAP5/MOD3.2.2 GAMMA code assessment are presented in Table 5.3.

Table 5.3. The results of RELAP5/MOD3.2.2 GAMMA code assessment (code performance for process/phenomenon)

<i>1. Process/Phenomenon in the steady state in Test 5</i>	<i>Results of RELAP5/MOD3.2.2 GAMMA assessment</i>
1.1. Total pressure drop along the height of the channel with RBMK-1500 fuel assembly model	Reasonable adequacy
1.2. Heat transfer in the two-phase flow in the channel with the RBMK-1500 fuel assembly model	Reasonable adequacy
<i>2. Process/Phenomenon on the stage of decrease and full stop of flow in Test 5</i>	<i>Results of RELAP5/MOD3.2.2 GAMMA assessment</i>
2.1. Total pressure drop and water release from the fuel channel model and heated rod surface dryout	Reasonable adequacy
2.2. Dryout under sharp flow deceleration at the inlet of the RBMK-1500 fuel assembly model	Reasonable adequacy
2.4. Post dryout heat transfer and heated rod bundle temperature behavior in the lower and upper parts of RBMK-1500 fuel assembly model under stop of flow and channel drying conditions	Reasonable adequacy
<i>3. Process/Phenomenon on the recovery stage of water supply into the fuel channel model</i>	<i>Results of RELAP5/MOD3.2.2 GAMMA assessment</i>
3.1. Propagation of the reflood and quench fronts in the lower and upper parts of RBMK-1500 fuel assembly model under flow resumption at the channel inlet	Reasonable adequacy for the upper FA model part Insufficient adequacy for the lower FA model part

6. SENSITIVITY STUDY

Sensitivity studies were performed with different FC wall roughness $4 \cdot 10^{-6}$ m and $4 \cdot 10^{-5}$ m in the FC model to estimate its influence on code simulation of complex thermal hydraulic processes in the FC. In steady conditions the increasing in FC wall roughness leads to a better agreement between experimental and calculated values of pressure drop DP16-4 across the FA model height with achieving good coincidence within the measurement accuracy for test 5 at FA power of 2486 kW.

The increased FC wall roughness weakly influences on the behavior of pressure drop DP16-4 (t), and also of the wall temperatures Tw1 (t), Tw2 (t), Tw3 (t), and Tw4 (t) during the 1-st and 2-nd stages of the transient.

Also, sensitivity study was carried out to investigate the effects of modeling on the behaviors of the rod simulator temperatures along the heated bundle height using motor valve component or Time Dependent Junction in LWC.

Comparisons between test data and RELAP5/MOD3.2.2 GAMMA predictions for the behaviors of the considered parameters G (t), Pin (t) and DP16-4 (t) in the base case with “motor valve 2r” and in the sensitivity study case with TDJ in LWC are presented in Figures D-1 and D-2 in Appendix D.

The comparisons of the behaviors of rod’s wall temperatures Tw1 (t), Tw2 (t), Tw3 (t), and Tw4 (t) been measured and also those of calculated temperatures during the transient are presented in Figures D-3 and D-4. These indicate a reasonable suitability of the code simulation of the dryout initiation and its propagation along the FA height during the 1-st stage of the transient at FA power been constant.

Using two lumped rod simulators ($K_r=1.061$) and TDJ to accurate code simulation of the real flow rate behavior at the channel inlet gives more realistic code results for the initial and boundary conditions in the fuel channel. In this case the code predicted time interval Δt_d from the moment $t(G_0)$ of complete stop flow to the beginning t_d of the rod’s wall temperature Tw1(t) increase at the core outlet exceeds the experimental value Δt_d by about ~ 0.2 s. The excess of calculated value Δt_d over that obtained experimentally decreases from ~ 1.0 s to ~ 0.2 s and the pictures of the dryout initiation and its propagation along the FA height become more resembling in this case.

7. RUN STATISTICS

The simulation model for KS Test 5 includes:

307 volumes, 311 junctions, 282 heat structures with 729 nodes.

There were the following resources been used for the calculation:

Run time – CPU = 855.13 s;

Step number – DT = 3751;

Volume number – C = 307.

Calculation results of **grind time** (program efficiency factor)

$$\text{Grind time} = \frac{\text{CPU} \cdot 10^3}{C \cdot \text{DT}} = 0.74259$$

For the calculations, it was used a computer IBM PC AT with processor INTEL Pentium-166MMX. Windows-95 was used as an operating system. CPU-time as well as the integration step variations are presented in Fig. 7.1 and 7.2, respectively.




Fig. 7.1. Execution time (CPU TIME) of the main variant computation for the experiment.




Fig. 7.2. Integration step (dt) variations at the main variant computation for the experiment.

8. SUMMARY OF CONCLUSIONS

KS test data on the behavior of the heated rod bundle temperature in the RBMK-1500 core model under stop and recovery flow conditions were simulated with RELAP5/MOD3.2 and RELAP5/MOD3.2.2GAMMA to assess these codes suitability. Especially calculations were performed to estimate differences in the code version predictions for processes/phenomena, which could occur under specific conditions of RBMK type reactor during LOCA with MCP's pressure header rupture and subsequent ECCS water injection. This problem addresses phenomena of high importance to RBMK-1500 safety including water discharge, critical heat flux, post dryout heat transfer, reflood and propagation of rewetting front in the fuel channel during an accident.

In this work some deficiencies of RELAP5/MOD3.2 and RELAP5/MOD3.2.2GAMMA in analyses of KS Test 5 could be identified, and the following conclusions can be drawn:

- RELAP5/MOD3.2 gives reasonable agreements of general pictures of simulated processes/phenomena with test data on the stage with the decrease and complete stop of flow at the FC inlet. At the same time, it was intimated that there is a need to modify RELAP5/MOD3.2 models used for interphase friction and critical heat flux in the channel with the RBMK-1500 fuel assembly under initial steady conditions with forced circulation.
- When simulating the recovery stage of water supply into the channel there were essential distinctions between RELAP5/MOD3.2 code results and test data on the behaviors of the rod's wall temperatures along the FA height. The code does not give qualitative agreements between the curves for the rod temperatures along the FA height at the quenching in the test. The code gives insufficient agreement with test data concerning the time characteristics and conditions of the rod

surface quenching in the upper and middle parts of the FA. The analysis results allow RELAP5/MOD3.2 code suitability being assessed as insufficient. Shown is a necessity and importance of a special reflood model to be used for suitable description of the reflood stage of the transient.

- RELAP5/MOD3.2.2 GAMMA gives reasonable agreements of general pictures of simulated processes/phenomena with test data on the transient stage with the decrease and complete stop of flow. Sensitivity study was carried out to investigate the effects of modeling on the behaviors of the rod simulator temperatures along the heated bundle height using motor valve component or Time Dependent Junction in LWC. Use of TDJ to accurate code simulation of the real flow rate behavior at the channel inlet gives more realistic code results for the initial and boundary conditions in the fuel channel. In this case the code predicted time interval Δt_d from the moment $t(G0)$ of complete stop flow to the beginning t_d of the rod's wall temperature $T_{w1}(t)$ increase at the core outlet exceeds the experimental value Δt_d by about ~ 0.2 s. This indicates a reasonable adequacy of the code simulation of dryout initiation at rapid decrease of the flow right down to its total termination.

- RELAP5/MOD3.2.2 GAMMA results obtained when simulating reflood and quench fronts in the fuel channel allow the code adequacy being assessed as reasonable only for the upper part of RBMK-1500 fuel assembly and as insufficient for the lower part of the FA model.

Shown is a necessity for formulation special Standard Problem "Propagation of the reflood and quench fronts in the lower and upper parts of RBMK-1500 fuel assembly under flow resumption at the channel inlet" and its analysis using RELAP5/MOD3.2.2 GAMMA.

REFERENCES

- 1 V.S.Osmachkin, V.A.Kapustin, L.L.Kobzar and others (RRC KI), O.Yu.Novoselsky (ENTEK). Results of investigation with KS test facility of temperature conditions of fuel channel model of NPP with RBMK-1500 accidents. RRC KI - ENTEK report, Reg.#32/345. 1977. 30p (58).
2. Computer code validation for transient analysis of VVER and RBMK reactors: Standard Problem INSCSP-R2 Definition "RBMK type reactor core thermal hydraulic processes investigation under pressure header break conditions", Experiments with KS RRC KI test facility, International Nuclear Center of Russia Minatom, Moscow, Russia (August 1999).
3. RELAP5/MOD3 Code Manual, Volume 4: Models and Correlations, INEL-95/0174, NUREG/CR-5535, 1995.
4. RELAP5/MOD3 Code Manual, Volume 2: User's Guide and Input Requirements, INEL-95/0174, NUREG/CR-5535, 1995.

APPENDIX-A

Original Data Plots From KS RBMK-1500 Test 5




Fig. A-1. Mass flow rate G history at the FC model inlet in experiment 5.




Fig. A-2. Pressure drop P16-4 history along the FA model in experiment 5.




Fig. A-3. Pressure Pin history in the lower part of the FA model in experiment 5.




Fig. A-4. Fuel rod simulator temperature Tw1 ($z=6.894$ m) history in experiment 5.




Fig. A-5. Fuel rod simulator temperature Tw2 (z=6.854 m) history in experiment 5.




Fig. A-6. Fuel rod simulator temperature Tw3 (z=3.814 m) history in experiment 5.




Fig. A-7. Fuel rod simulator temperature Tw4 (z=1.044 m) history in experiment 5.




Fig. A-8. Behavior of measured wall temperatures Tw1, Tw2, Tw3 and Tw4 in experiment 5.

Appendix B

Comparisons between Test Data and RELAP5/MOD3.2 Base Case Results




Fig. B-1. Mass flow rate $G(t)$ history at the FC model inlet.




Fig. B-2. Coolant temperature $T_{in}(t)$ history at the FC model inlet.




Fig. B-3. Pressure P (t) history in the lower part of the FA model.




Fig. B-4. Pressure drop DP16-4 (t) history along the FA model.




Fig. B-5. Fuel rod simulator temperature Tw1 (t) history.




Fig. B-6. Fuel rod simulator temperature Tw2 (t) history.




Fig. B-7. Fuel rod simulator temperature Tw3 (t) history.






Fig. B-8. Fuel rod simulator temperature Tw4 (t) history.

Appendix C


**Comparisons between Test Data and RELAP5/MOD3.2 and
RELAP5/MOD3.2.GAMMA Base Case Results**




Mass flow rate at the FC inlet



Mass flow rate at the FC inlet




FA rod's wall temperatures Tw1-Tw4




FA rod's wall temperatures Tw1-Tw4


Fig. C-1. Comparisons between test data and RELAP5/MOD3.2 and RELAP5/MOD3.2.2GAMMA predictions for the behaviors of the considered parameter G and rod's wall temperatures Tw1-Tw4 in the base case with "motor valve 2r".




Pressure P in the lower part of FA



Pressure P in the lower part of FA




Pressure drop DP16-4 along FA




Pressure drop P16-4 along FA


Fig. C-2. Comparisons between test data and RELAP5/MOD3.2 and RELAP5/MOD3.2GAMMA predictions for the behaviors of the considered parameters P and DP16-4 in the base case with "motor valve 2r".




Rod wall temperature Tw1 (z=6.94 m)



Rod wall temperature Tw2 (z=6.82 m)




Rod wall temperature Tw1(z=6.94 m)




Rod wall temperature Tw2 (z=6.82 m)


Fig. C-3. Comparisons between test data and RELAP5/MOD3.2 and RELAP5/MOD3.2GAMMA predictions for the behaviors of the the rod's wall temperatures Tw1 and Tw2 in the base case with "motor valve 2r".




Rod wall temperature Tw3 (z=3.82 m)



Rod wall temperature Tw4 (z=1.04 m)




Rod wall temperature Tw3 (z=3.82 m)




Rod wall temperature Tw4 (z=1.04 m)


Fig. C-4. Comparisons between test data and RELAP5/MOD3.2 and RELAP5/MOD3.2.GAMMA predictions for the behaviors of the the rod's wall temperatures Tw3 and Tw4 in the base case with "motor valve 2r".




Inner row rod's wall temperatures Tw1-Tw4



Outer row rod's wall temperatures Tw1-Tw4



Inner row rod's wall temperatures Tw1-Tw4




Outer row rod's wall temperatures Tw1-Tw4


Fig. C-5. Comparisons between RELAP5/MOD3.2 and RELAP5/MOD3.2.GAMMA predictions for the behaviors of the rod's wall temperatures Tw1-Tw4 in the base case with "motor valve 2r".

Appendix D


Comparisons between Test Data and RELAP5/MOD3.2.2GAMMA Sensitivity Study Results




Mass flow rate G at the FC inlet (motor valve 2r)



Pressure P in the lower part of FA (motor valve 2r)




Mass flow rate G at the FC inlet (TDJ)




Pressure P in the lower part of FA (TDJ)


Fig. D-1. Comparisons between test data and RELAP5/MOD3.2.2GAMMA predictions for the behaviors of the considered parameters G and P in the cases with "motor valve 2r" and Time Dependent Junction in LWC




Pressure drop DP16-4 along FA (motor valve 2r)



Rod wall temperature Tw1, z=6.94 m (motor valve 2r)




Pressure drop DP16-4 along FA (TDJ)




Rod wall temperature Tw1, z=6.94 m (TDJ)


Fig. D-2. Comparisons between test data and RELAP5/MOD3.2GAMMA predictions for the behaviors of the considered parameters DP16-4 and Tw1 in the cases with "motor valve 2r" and Time Dependent Junction in LWC.




Rod wall temperature Tw2, z=6.82 m (motor valve 2r)



Rod wall temperature Tw3, z=3.82 m (motor valve 2r)




Rod wall temperature Tw2, z=6.82 m (TDJ)




Rod wall temperature Tw3, z=3.82 m (TDJ)


Fig. D-3. Comparisons between test data and RELAP5/MOD3.2.GAMMA predictions for the behaviors of the rod's wall temperatures Tw2 and Tw3 in the cases with "motor valve 2r" and Time Dependent Junction in LWC.




Rod wall temperature Tw4, z=1.04 m (motor valve 2r)



FA rod's wall temperatures Tw1-Tw4 (motor valve 2r)



Rod wall temperature Tw4, z=1.04 m (TDJ)



FA rod's wall temperatures Tw1-Tw4 (TDJ)

Fig. D-4. Comparisons between test data and RELAP5/MOD3.2.2GAMMA predictions for the behaviors of the rod's wall temperatures Tw4 and Tw1-Tw4 in the cases with "motor valve 2r" and Time Dependent Junction in LWC.

Appendix E

Base Case RELAP5/MOD3.2 input deck listing

```

=ks2 05 test
*****
*RBMK-1500 Stop Flow Experiment at KS-2 Test Facility
*Base case input deck listing of KS2-05 test
*****
*   Assesment of RELAP5/MOD3.2 against KS2-05 test
*   Initial conditions
*   FA power = 2486.0 kWt
*   FA inlet pressure = 8.40 MPa
*   FA inlet mass flow = 4.70 kg/s
*   FA inlet water temperature = 527.45 K
*****
100 new transnt
*0000101 inp-chk
0000102 si si
0000110 nitrogen
*****
*   TIME STEPS CONTROL CARDS
*****
*crdno time min_dt max_dt ssdt minor major restart
0000201 1000.0 1.0-6 0.01 15003 500 10000 50000
*0000202 1400. 1.0-6 0.01 15003 200 40000 4000000
*0000203 1450. 1.0-6 0.01 15003 10 40000 4000000
*0000204 1600. 1.0-6 0.01 15003 100 40000 4000000
*****
*   HIDRODYNAMIC COMPONENTS
*****
*   PUMP 1 AND PUMP 2 PERFORMANCE DATA
*
*   Volume = 0.0587 m*m*m
*   rated pump velocity = 314 rad/s
*   rated flow = 0.158 m*m*m/s
*   rated head = 105.4 m
*   rated torque = 782.0 N*m
*   rated density 854.9 kg/m*m*m
*   moment of inertia = 11.2 kg*m*m*m
*   actual pump velocity = 314 rad/s
*-----
*   PUMP 1, component 71
*
0710000 pump1 pump
*   flow area length volume az inc dz tlpvbf
0710101 0.0214 0.0 0.0587 0.0 0.0 0.0 0000000
*   from area floss rloss efvcahs
0710108 047050002 0.0 0.1 0.1 0001120
*   to area floss rloss efvcahs
0710109 072010001 0.0 0.1 0.1 0001120
0710200 103 7.8+6 527.45
0710201 1 0.00 0.0 0.0
0710202 1 0.00 0.0 0.0
0710301 0 -1 -3 0 0 0 0
*   rad/s veloc rflow rhead rtorq inert rdens rmtorq
0710302 314.0 1.0 0.158 105.4 445.0 11.2 854.9 782.0 0.0 0.0 0.0 0.0
0716001 0.0 0.0
0716002 314.0 1.0
0716100 0 time
0716101 0.0 314.0
0716102 500. 314.0
0716103 4000. 314.0
*-----
*   SINGL PHASE HEAD AND TORQUE CURVES
*
*   head curve no 1 han
*
*crdno curve type curve regime
0711100 1 1
*   flow/rflow head/rhead
0711101 0.0 1.0700
0711102 0.3515 1.0721
0711103 0.5272 1.0816
0711104 0.7030 1.0721
0711105 0.8787 1.0436
0711106 1.0000 1.0000
*
*   torque curve no 1 ban
*

```

```

*crdno curve type curve regime
0711200 2 1
*   flow/rflow torque/rtorque
0711201 0.0 0.98
0711202 0.3515 0.693
0711203 0.5272 0.845
0711204 0.7030 0.955
0711205 0.8787 0.994
0711206 1.0000 1.000
*
*   Head curve no 2 HVN
*crdno type regime
0711300 1 2
*   gnom/g (h/hnom)/(g/gnom)**2
0711301 0.0 -1.584
0711302 0.221 -1.056
0711303 0.442 -0.528
0711304 0.663 0.0587
0711305 0.884 0.704
0711306 1.0 1.00
*
*   Torque curve no 2 HVN
*crdno type regime
0711400 2 2
*   gnom/g (m/mnom)/(g/gnom)**2
0711401 0.0 -1.148
0711402 0.221 -0.549
0711403 0.442 -0.075
0711404 0.663 0.349
0711405 0.884 0.749
0711406 1.000 1.000
*
*   Head curve no 3 HAD
*crdno type regime
0711500 1 3
*   g/gnom h/hnom
0711501 -1.0 5.5
0711502 -0.452 3.276
0711503 -0.362 2.928
0711504 -0.271 2.658
0711505 -0.181 2.430
0711506 -0.0905 2.244
0711507 0.000 2.058
*
*   Torque curve no 3 HAD
*crdno type regime
0711600 2 3
*   gnom/g (m/mnom)
0711601 -1.0 3.64
0711602 -0.995 3.612
0711603 -0.905 3.326
0711604 -0.814 2.96
0711605 -0.724 2.653
0711606 -0.633 2.388
0711607 -0.543 2.133
0711608 -0.452 1.888
0711609 -0.362 1.653
0711610 -0.271 1.449
0711611 -0.181 1.265
0711612 -0.0905 1.020
0711613 0.000 0.980
*
*   Head curve no 4 HVD
*crdno type regime
0711700 1 4
*   gnom/g (h/hnom)/(g/gnom)**2
0711701 -1.0 5.5
0711702 -0.884 4.869
0711703 -0.663 3.755
0711704 -0.442 2.992
0711705 -0.221 2.464
0711707 0.000 2.024
*
*   Torque curve no 4 HVD
*crdno type regime
0711800 2 4
*   gnom/g (m/mnom)/(g/gnom)**2

```

0711801 -1.0 3.64
 0711802 -0.884 3.343
 0711803 -0.663 2.644
 0711804 -0.442 2.095
 0711805 -0.221 1.746
 0711813 0.000 1.547

* Head curve no 5 HAT

*crdno type regime
 0711900 1 5
 * gnom/g (h/hnom)
 0711901 0.0 0.42
 0711902 0.0452 0.426
 0711903 0.0905 0.420
 0711904 0.181 0.444
 0711905 0.271 0.480
 0711906 0.362 0.504
 0711907 0.452 0.552
 0711908 0.543 0.600
 0711909 0.633 0.696
 0711910 0.724 0.828
 0711911 0.814 0.984
 0711912 0.905 1.188
 0711913 1.000 1.360

* Torque curve no 5 HAT

*crdno type regime
 0712000 2 5
 * gnom/g (m/mnom)/(g/gnom)**2
 0712001 0.0 -0.704
 0712002 0.0452 -0.684
 0712003 0.136 -0.684
 0712004 0.181 -0.612
 0712005 0.271 -0.449
 0712006 0.362 -0.255
 0712007 0.452 -0.122
 0712008 0.543 -0.0306
 0712009 0.633 0.0816
 0712010 0.724 0.224
 0712011 0.814 0.388
 0712012 0.905 0.592
 0712013 0.995 0.776
 0712014 1.000 0.790

* Head curve no 6 HVT

*crdno type regime
 0712100 1 6
 * gnom/g (h/hnom)/(g/gnom)**2
 0712101 0.0 2.024
 0712102 0.221 1.731
 0712103 0.442 1.525
 0712104 0.663 1.408
 0712105 0.884 1.379
 0712106 1.0 1.36

* Torque curve no 6 HVT

*crdno type regime
 0712200 2 6
 * gnom/g (m/mnom)/(g/gnom)**2
 0712201 0.0 1.547
 0712202 0.221 1.397
 0712203 0.442 1.197
 0712204 0.663 1.048
 0712205 0.884 0.848
 0712206 1.000 0.790

* Head curve no 7 HAR

*crdno type regime
 0712300 1 7
 * g/gnom h/hnom
 0712301 -1.0 -3.12
 0712302 -0.814 -2.016
 0712303 -0.724 -1.608
 0712304 -0.633 -1.296
 0712305 -0.543 -0.996
 0712306 -0.452 -0.672
 0712307 -0.362 -0.360
 0712308 -0.271 -0.072
 0712309 -0.181 0.216

0712310 -0.0905 0.360
 0712311 -0.0452 0.408
 0712312 0.000 0.420

* Torque curve no 7 HAR

*crdno type regime
 0712400 2 7
 * gnom/g (m/mnom)
 0712401 -1.0 -4.34
 0712402 -0.814 -3.142
 0712403 -0.724 -2.724
 0712404 -0.543 -2.286
 0712405 -0.452 -1.939
 0712406 -0.362 -1.592
 0712407 -0.271 -1.286
 0712408 -0.181 -1.000
 0712409 -0.0905 -0.796
 0712410 0.000 -0.704

* Head curve no 8 HVR

*crdno type regime
 0712500 1 8
 * gnom/g (h/hnom)/(g/gnom)**2
 0712501 -1.0 -3.12
 0712502 -0.884 -2.992
 0712503 -0.663 -2.757
 0712504 -0.442 -2.435
 0712505 -0.221 -2.053
 0712507 0.000 -1.584

* Torque curve no 8 HVR

*crdno type regime
 0712600 2 8
 * gnom/g (m/mnom)/(g/gnom)**2
 0712601 -1.0 -4.34
 0712602 -0.884 -3.941
 0712603 -0.663 -3.218
 0712604 -0.442 -2.495
 0712605 -0.221 -1.821
 0712613 0.000 -1.148

* PUMP 1 DISCHARGE PIPELINE, component v.72

0720000 disch2 pipe
 0720001 5
 0720101 28.65-3 5
 0720301 1.15 2, 1.85 4, 2.2 5
 0720601 0.0 5
 0720801 40.0-6 0.191 5

*crdno tlpvbf

0721001 0000000 5
 *crdno efvcahs
 0721101 0001000 4
 0721201 103 7.8+6 527.45 0.0 0.0 0.0 5
 0721300 1
 0721301 0.0 0.0 0.0 4

* PUMP 2, component 73

0730000 pump2 pump
 * flow area length volume az inc dz tlpvbf
 0730101 0.0214 0.0 0.0587 0.0 0.0 0.0 0000000
 * from area floss rloss efvcahs
 0730108 072050002 0.0 0.1 0.1 0001120
 * to area floss rloss efvcahs
 0730109 074010001 0.0 0.1 0.1 0001120
 0730200 103 8.5+6 527.45
 0730201 1 0.00 0.0 0.0
 0730202 1 0.00 0.0 0.0
 0730301 0 -1 -3 0 0 0 0
 * rad/s veloc rflow rhead rtorq inert rdens
 0730302 314.0 1.0 0.158 105.4 445.0 11.2 854.9 782.0 0.0 0.0 0.0 0.0

0736001 0.0 0.0
 0736002 314.0 1.0
 0736100 0 time
 0736101 0.0 314.0
 0736102 500. 314.0
 0736103 4000. 314.0

*-----
 * SINGL PHASE HEAD AND TORQUE CURVES
 *

* head curve no 1 han
 *
 *crdno curve type curve regime
 0731100 1 1
 * flow/rflow head/rhead
 0731101 0.3515 1.0721
 0731102 0.5272 1.0816
 0731103 0.7030 1.0721
 0731104 0.8787 1.0436
 0731105 1.0000 1.0000

* torque curve no 1 ban
 *
 *crdno curve type curve regime
 0731200 2 1
 * flow/rflow torque/rtorque
 0731201 0.0 0.693
 0731202 0.3515 0.693
 0731203 0.5272 0.845
 0731204 0.7030 0.955
 0731205 0.8787 0.994
 0731206 1.0000 1.000

* Head curve no 2 HVN
 *crdno type regime
 0731300 1 2
 * gnom/g (h/hnom)/(g/gnom)**2
 0731301 0.0 -1.584
 0731302 0.221 -1.056
 0731303 0.442 -0.528
 0731304 0.663 0.0587
 0731305 0.884 0.704
 0731306 1.0 1.00

* Torque curve no 2 HVN
 *crdno type regime
 0731400 2 2
 * gnom/g (m/mnom)/(g/gnom)**2
 0731401 0.0 -1.148
 0731402 0.221 -0.549
 0731403 0.442 -0.075
 0731404 0.663 0.349
 0731405 0.884 0.749
 0731406 1.000 1.000

* Head curve no 3 HAD
 *crdno type regime
 0731500 1 3
 * g/gnom h/hnom
 0731501 -1.0 5.5
 0731502 -0.452 3.276
 0731503 -0.362 2.928
 0731504 -0.271 2.658
 0731505 -0.181 2.430
 0731506 -0.0905 2.244
 0731507 0.000 2.058

* Torque curve no 3 HAD
 *crdno type regime
 0731600 2 3
 * gnom/g (m/mnom)
 0731601 -1.0 3.64
 0731602 -0.995 3.612
 0731603 -0.905 3.326
 0731604 -0.814 2.96
 0731605 -0.724 2.653
 0731606 -0.633 2.388
 0731607 -0.543 2.133
 0731608 -0.452 1.888

0731609 -0.362 1.653
 0731610 -0.271 1.449
 0731611 -0.181 1.265
 0731612 -0.0905 1.020
 0731613 0.000 0.980

* Head curve no 4 HVD
 *crdno type regime
 0731700 1 4
 * gnom/g (h/hnom)/(g/gnom)**2
 0731701 -1.0 5.5
 0731702 -0.884 4.869
 0731703 -0.663 3.755
 0731704 -0.442 2.992
 0731705 -0.221 2.464
 0731707 0.000 2.024

* Torque curve no 4 HVD
 *crdno type regime
 0731800 2 4
 * gnom/g (m/mnom)/(g/gnom)**2
 0731801 -1.0 3.64
 0731802 -0.884 3.343
 0731803 -0.663 2.644
 0731804 -0.442 2.095
 0731805 -0.221 1.746
 0731813 0.000 1.547

* Head curve no 5 HAT
 *crdno type regime
 0731900 1 5
 * gnom/g (h/hnom)
 0731901 0.0 0.42
 0731902 0.0452 0.426
 0731903 0.0905 0.420
 0731904 0.181 0.444
 0731905 0.271 0.480
 0731906 0.362 0.504
 0731907 0.452 0.552
 0731908 0.543 0.600
 0731909 0.633 0.696
 0731910 0.724 0.828
 0731911 0.814 0.984
 0731912 0.905 1.188
 0731913 1.000 1.360

* Torque curve no 5 HAT
 *crdno type regime
 0732000 2 5
 * gnom/g (m/mnom)/(g/gnom)**2
 0732001 0.0 -0.704
 0732002 0.0452 -0.684
 0732003 0.136 -0.684
 0732004 0.181 -0.612
 0732005 0.271 -0.449
 0732006 0.362 -0.255
 0732007 0.452 -0.122
 0732008 0.543 -0.0306
 0732009 0.633 0.0816
 0732010 0.724 0.224
 0732011 0.814 0.388
 0732012 0.905 0.592
 0732013 0.995 0.776
 0732014 1.000 0.790

* Head curve no 6 HVT
 *crdno type regime
 0732100 1 6
 * gnom/g (h/hnom)/(g/gnom)**2
 0732101 0.0 2.024
 0732102 0.221 1.731
 0732103 0.442 1.525
 0732104 0.663 1.408
 0732105 0.884 1.379
 0732106 1.0 1.36

* Torque curve no 6 HVT
 *crdno type regime
 0732200 2 6

* gnom/g (m/mnom)/(g/gnom)**2
 0732201 0.0 1.547
 0732202 0.221 1.397
 0732203 0.442 1.197
 0732204 0.663 1.048
 0732205 0.884 0.848
 0732206 1.000 0.790

* Head curve no 7 HAR
 *crdno type regime
 0732300 1 7

* g/gnom h/hnom
 0732301 -1.0 -3.12
 0732302 -0.814 -2.016
 0732303 -0.724 -1.608
 0732304 -0.633 -1.296
 0732305 -0.543 -0.996
 0732306 -0.452 -0.672
 0732307 -0.362 -0.360
 0732308 -0.271 -0.072
 0732309 -0.181 0.216
 0732310 -0.0905 0.360
 0732311 -0.0452 0.408
 0732312 0.000 0.420

* Torque curve no 7 HAR
 *crdno type regime
 0732400 2 7

* gnom/g (m/mnom)
 0732401 -1.0 -4.34
 0732402 -0.814 -3.142
 0732403 -0.724 -2.724
 0732404 -0.543 -2.286
 0732405 -0.452 -1.939
 0732406 -0.362 -1.592
 0732407 -0.271 -1.286
 0732408 -0.181 -1.000
 0732409 -0.0905 -0.796
 0732410 0.000 -0.704

* Head curve no 8 HVR
 *crdno type regime
 0732500 1 8

* gnom/g (h/hnom)/(g/gnom)**2
 0732501 -1.0 -3.12
 0732502 -0.884 -2.992
 0732503 -0.663 -2.757
 0732504 -0.442 -2.435
 0732505 -0.221 -2.053
 0732507 0.000 -1.584

* Torque curve no 8 HVR
 *crdno type regime
 0732600 2 8

* gnom/g (m/mnom)/(g/gnom)**2
 0732601 -1.0 -4.34
 0732602 -0.884 -3.941
 0732603 -0.663 -3.218
 0732604 -0.442 -2.495
 0732605 -0.221 -1.821
 0732613 0.000 -1.148

* PUMP 2 DISCHARGE PIPELINE, component v.74

0740000 disch2 pipe
 0740001 10
 0740101 28.65-3 10
 0740301 1.5 2, 2.4 4, 2.0 5, 2.25 9, 1.0 10
 0740601 0.0 10
 0740801 40.0-6 0.191 10

*
 0740901 0.0 0.0 1, 0.10 0.10 2
 0740902 0.0 0.0 3, 0.10 0.10 4
 0740903 0.10 0.10 5, 0.0 0.0 8
 0740904 0.10 0.10 9

*
 *crdno tipvbfe
 0741001 0000000 10

*crdno efvcahs
 0741101 0001000 9

*
 0741201 103 8.5+6 527.45 0.0 0.0 0.0 10
 0741300 1
 0741301 0.0 0.0 0.0 9

*-----
 0750000 sj75 sngljun
 *crdno from to area floss rloss efvcahs
 0750101 074010000 103000000 0.0 0.0 0.0 0001100
 0750201 1 2.7 0.0 0.0

*-----
 0760000 sj76 sngljun
 *crdno from to area floss rloss efvcahs
 0760101 074010000 078000000 0.0 0.5 0.5 0001100
 0760201 1 5.47 0.0 0.0

* PUMPS BYPASS, components v.78, valve jun.79, v.80

*
 0780000 pbypas1 pipe
 0780001 8
 0780101 28.65-3 8
 0780301 1.56 1, 1.2 2, 2.9 5, 2.5 6, 1.325 8
 0780601 0.0 8
 0780801 40.0-6 0.191 8

*
 0780901 0.10 0.10 2, 0.0 0.0 4
 0780902 0.10 0.10 6, 0.10 0.10 7

*
 *crdno tipvbfe
 0781001 0000000 8

*crdno efvcahs
 0781101 0001000 7
 *
 0781201 103 8.5+6 527.45 0.0 0.0 0.0 8
 0781300 1
 0781301 5.47 0.0 0.0 7

* pumps bypass motor valve 28

*
 0790000 valv28 valve
 *crdno from to area floss rloss efvcahs
 0790101 078010000 080000000 28.65-3 262.0 262.0 0001100
 0790201 1 0.0 0.0 0.0
 0790300 mtrvrv

* open close rate initl table
 0790301 428 628 0.0005 1.0 0

*
 438 time 0 ge null 0 500.0 n * close
 538 time 0 ge null 0 1000.0 n * stop
 628 438 and -538 n * close
 428 time 0 ge null 0 9999.0 n * open

*
 0800000 pbypas2 pipe
 0800001 7
 0800101 28.65-3 7
 0800301 1.5125 4, 1.6167 7
 0800601 0.0 7
 0800801 40.0-6 0.191 7

*
 0800901 0.0 0.0 3, 0.10 0.10 4
 0800902 0.0 0.0 6

*
 *crdno tipvbfe
 0801001 0000000 7

*crdno efvcahs
 0801101 0001000 6
 *
 0801201 103 7.65+6 527.45 0.0 0.0 0.0 7
 0801300 1
 0801301 5.47 0.0 0.0 6

*-----
 0810000 sj81 sngljun
 *crdno from to area floss rloss efvcahs
 0810101 080010000 47030002 0.0 0.5 0.5 0001100
 0810201 1 5.47 0.0 0.0

*-----
 * GAS PRESSURIZER, components sj.91, v.92, sj.93, v.94
 *

0910000 sj91 sngljun
 *crdno from to area floss rloss efvcchs
 0910101 041010000 092000000 0.0 0.0 0.0 0001100
 0910201 0.0 0.0 0.0
 *
 0920000 surge pipe
 0920001 12
 0920101 3.1416-4 12
 0920301 1.0 12
 0920601 0.0 12
 0920801 6.0-6 0.020 12
 0920901 0.0 0.0 11
 *
 *crdno tlpvbf
 0921001 0000000 12
 *crdno efvcchs
 0921101 0001000 11
 *
 0921201 103 7.65+6 527.45 0.0 0.0 0.0 12
 0921300 1
 0921301 0.0 0.0 0.0 11
 *-----

0930000 sj93 sngljun
 *crdno from to area floss rloss efvcchs
 0930101 092010000 094000000 0.0 0.0 0.0 0001100
 0930201 0.0 0.0 0.0
 *-----
 0940000 gasprz pipe
 0940001 4
 0940101 1.7349-1 4
 0940301 0.75 4
 0940601 90.0 4
 0940801 50.0-6 0.0 4
 0940901 0.0 0.0 3
 *
 *crdno tlpvbf
 0941001 0000000 4
 *crdno efvcchs
 0941101 0001000 3
 *
 0941201 103 7.85+6 527.45 0.0 0.0 0.0 2
 0941202 004 7.85+6 527.45 1.0 0.0 0.0 4
 0941300 1
 0941301 0.0 0.0 0.0 3
 *

*-----
 * PRESSURE HEADER, coponents no v.103, sj105
 *

1030000 pheader pipe
 1030001 8
 1030101 0.06835 8
 1030301 0.3 8
 1030601 0.0 8
 1030801 50.0-6 0.295 8
 1030901 0.0 0.0 7
 *
 *crdno tlpvbf
 1031001 0000000 8
 *crdno efvcchs
 1031101 0001000 7
 *
 1031201 103 9.2+6 527.45 0.0 0.0 0.0 8
 1031300 1
 1031301 3.33 0.0 0.0 7
 *-----

1050000 sj105 sngljun
 *crdno from to area floss rloss efvcchs
 1050101 103010000 106000000 0.0 0.0 0.0 0001100
 1050201 1.33.33 0.0 0.0
 *-----

* BYPASS, component v.106
 *

1060000 bypass pipe
 1060001 24
 1060101 8.171-3 24
 *

1060301 1.0 2, 1.511 3, 1.3 4, 1.137445 6
 1060302 1.55 7, 1.1425 11, 1.4 13, 1.7 14
 1060303 1.3 15, 1.4 17, 1.7292 22, 0.6 24
 *

1060601 0.0 2, 90.0 3, 23.0 4, 90.0 6
 1060602 0.0 7, 90.0 11, 0.0 13, 0.0 14
 1060603 90.0 15, 0.0 17, 90.0 22, 0.0 24
 *

1060801 30.0-6 0.102 24
 *

1060901 0.0 0.0 1
 1060902 0.15 0.15 4
 * floss rloss constant for valve 5

1060903 135.0 135.0 5
 1060904 0.15 0.15 7
 1060905 0.0 0.0 10
 1060906 0.15 0.15 11
 1060907 0.0 0.0 12
 1060908 0.15 0.15 14
 1060909 0.0 0.0 15
 1060910 0.15 0.15 16
 1060911 0.0 0.0 21
 1060912 0.15 0.15 22
 1060914 0.0 0.0 23
 *

*crdno tlpvbf
 1061001 0000000 24
 *crdno efvcchs
 1061101 0001000 23
 *

1061201 103 8.4+6 527.45 0.0 0.0 0.0 24
 1061300 1
 1061301 33.33 0.0 0.0 23
 *-----

1040000 sj104 sngljun
 *crdno from to area floss rloss efvcchs
 1040101 103050003 001010001 0.0 0.5 0.5 0001100
 1040201 1 3.9 0.0 0.0
 *-----

* GROUP DISTRIBUTION HEADER AND LOWER WATER
 * COMMUNICATION, components v.1, valve jun.2, v.3
 *

0010000 gdh pipe
 0010001 4
 0010101 3.32-3 4
 0010301 0.5 1, 0.95 3, 0.80 4
 0010601 0.0 1, 90.0 3, 0.0 4
 0010801 20.0-6 0.065 4
 0010901 0.5 0.5 1, 0.0 0.0 2, 0.5 0.5 3
 *

*crdno tlpvbf
 0011001 0000000 4
 *crdno efvcchs
 0011101 0001000 3
 *

0011201 103 9.2+6 527.45 0.0 0.0 0.0 4
 0011300 1
 0011301 3.9 0.0 0.0 3
 *

* isolating control valve 2r

0020000 valv2r valve
 *crdno from to area floss rloss efvcchs
 0020101 001010000 003000000 3.3183-3 770.0 770.0 0001100
 0020201 1 3.9 0.0 0.0
 0020300 mtrv1v
 * open close rate initl table
 0020301 702 602 0.25 1.0 0
 *

412 time 0 ge null 0 1400.5 n * close
 512 time 0 ge null 0 1406.0 n * stop
 602 412 and -512 n * close
 *

403 time 0 ge null 0 1410.00 n * open
 503 time 0 ge null 0 1410.12 n * stop
 702 403 and -503 n * open
 *

*-----
 * lower water communication

```

0030000 lwc pipe
0030001 7
0030101 3.3183-3 7
0030301 0.8 1, 1.7 2, 1.775 4, 1.6 5,0.85 7
0030601 0.0 1, -90.0 2, 0.0 4, 90.0 5, 0.0 7
0030801 20.0-6 0.065 7
0030901 0.5 0.5 2, 0.0 0.0 3, 0.5 0.5 6
*
*crdno tlpvbf
0031001 0000000 7
*crdno efvcahs
0031101 0001000 6
*
0031201 103 8.40+6 527.45 0.0 0.0 0.0 7
0031300 1
0031301 0.0 0.0 0.0 6
*
0040000 sj4 sngljun
*crdno from to area floss rloss efvcahs
0040101 003010000 005010003 0.0 0.5 0.5 0001100
0040201 1 3.9 0.0 0.0
*
* FUEL CHANNEL WITH FUEL ASSEMBLY, component v.5
*
0050000 fuelchn pipe
0050001 45
0050101 0.002273 1, 0.002273 41, 0.002273 45
0050301 0.578 1, 0.16 2, 0.36 11, 0.12 41
0050302 0.131 43, 0.098 44, 0.1 45
0050601 90.0 45
0050801 4.0-5 8.563-3 45
*
0050901 0.0 0.0 1, 0.55 0.55 10
0050902 0.91 0.91 11,0.28 0.28 13
0050903 0.91 0.91 14,0.28 0.28 16
0050904 0.91 0.91 17,0.28 0.28 19
0050905 0.91 0.91 20,0.28 0.28 22
0050906 0.91 0.91 23,0.28 0.28 25
0050907 0.91 0.91 26,0.28 0.28 28
0050908 0.91 0.91 29,0.28 0.28 31
0050909 0.91 0.91 32,0.28 0.28 34
0050910 0.91 0.91 35,0.28 0.28 37
0050911 0.91 0.91 38,0.28 0.28 40
0050912 0.91 0.91 41,0.0 0.0 43, 0.55 0.55 44
*
*crdno tlpvbf
0051001 0000100 45
*crdno efvcahs
0051101 0001000 44
*0051101 0101000 44
*
0051201 102 8.40+6 0.12 0.0 0.0 0.0 45
0051300 1
0051301 3.9 0.0 0.0 44
*
0060000 sj6 sngljun
*crdno from to area floss rloss efvcahs
0060101 005440003 007000000 0.0 1.74 1.74 0001100
0060201 1 3.9 0.0 0.0
*
* LIFTING PATH WITH FA SUSPENTION, component v.7
*
0070000 lftpath pipe
0070001 11
0070101 0.0041854 4
0070102 0.00721 7, 0.00488 8, 0.0076 11
*
0070301 0.38 1, 0.35 2, 0.7975 3, 0.795 4
0070302 1.635 7, 1.07 8, 0.68 9, 0.1 10, 0.24 11
*
0070601 0.0 1, 45.0 2, 90.0 11
*
0070801 25.0-6 0.073 4
0070802 20.0-6 0.067 7, 4.0-6 0.0299 8, 4.0-6 0.05288 11
*
0070901 0.07 0.07 2
0070902 0.00 0.00 3
0070903 0.50 0.20 4
0070904 0.00 0.00 6

```

```

0070905 0.16 0.24 7
0070906 0.24 0.16 8
0070907 0.0 0.0 10
*
*crdno tlpvbf
0071001 0000000 11
*crdno efvcahs
0071101 0001000 10
*0071101 0101000 10
*
0071201 102 8.0+6 0.12 0.0 0.0 0.0 11
0071300 1
0071301 3.9 0.0 0.0 10
*
0080000 sj8 sngljun
*crdno from to area floss rloss efvcahs
0080101 007100003 009000000 0.0 0.5 0.5 0001100
0080201 1 3.9 0.0 0.0
*
* STEAM WATER COMMUNICATION, component v.9
*
0090000 swc pipe
0090001 20
0090101 3.3183-3 20
0090301 0.75 2, 0.6 3, 1.375 5, 0.8 6, 1.3 7
0090302 1.4 8, 0.8 9, 2.15 10, 2.26 15
0090303 1.7175 17, 2.3 18, 0.7 19, 0.5 20
0090601 0.72 19, 90.0 20
0090801 20.0-6 0.065 20
*
0090901 0.5 0.5 3
0090902 0.0 0.0 4
0090904 0.5 0.5 9
0090905 0.0 0.0 14
0090908 0.5 0.5 15
0090909 0.0 0.0 16
0090910 0.5 0.5 19
*
*crdno tlpvbf
0091001 0000000 20
*crdno efvcahs
0091101 0001000 19
*0091101 0101000 19
*
0091201 102 8.0+6 0.11 0.0 0.0 0.0 20
0091300 1
0091301 3.9 0.0 0.0 19
*
* UPPER HEADER, components branch 10, v.11
*
0100000 dcclil branch
0100001 3 1
0100101 0.06835 0.7 0.0 0.0 0.0 0.0 4.0-5 0.295 0000000
0100200 003 8.0+6 527.45
0101101 010010003 009200002 0.0033183 0.0 0.0 0001000
0101201 0.0 0.0 0.0
0102101 010010002 011010001 0.0 0.0 0.0 0001000
0102201 0.0 0.0 0.0
0103101 106010000 010010001 0.0 0.0 0.0 0001000
0103201 0.0 0.0 0.0
*
0110000 upphdr pipe
0110001 5
0110101 68.35-3 5
0110301 0.7 4, 0.9 5
0110601 3.0 5
0110801 50.0-6 0.295 5
0110901 0.0 0.0 4
*
*crdno tlpvbf
0111001 0000000 5
*crdno efvcahs
0111101 0001000 4
*
0111201 103 8.0+6 539.0 0.0 0.0 0.0 5
0111300 1
0111301 37.23 0.0 0.0 4
*
0120000 sj12 sngljun

```

*crdno from to area floss rloss efvcahs
0120101 011050003 014010001 0.0 0.5 0.5 0001100
0120201 1 0.0 0.0 0.0

*
* STEAM WATER PIPELINE, component v.14
*

0140000 swpline pipe
0140001 8
0140101 7.7-3 8
0140301 0.9 1,1.0 2, 1.3 3, 1.5 4, 0.8 5
0140302 1.0 6, 1.5 7, 0.5 8
0140601 90.0 1,0.0 8
0140801 30.0-6 0.099 8
0140901 0.15 0.15 7

*
*crdno tlpvbf
0141001 0000000 8
*crdno efvcahs
0141101 0001000 7
*
0141201 102 8.0+6 0.05 0.0 0.0 0.0 8
0141300 1
0141301 0.0 0.0 0.0 7

*
0150000 sj15 sngljun
*crdno from to area floss rloss efvcahs
0150101 014010000 020030003 0.0 0.0 0.0 0001100
0150201 0 0.0 0.0 0.0

*
* SEPARATOR (1c,2c,3c), component v.20
*

0200000 seprt pipe
0200001 6
0200101 78.87-3 6
0200301 0.5 2, 0.7 3, 0.5 5, 0.4 6
0200601 90.0 6
0200801 50.0-6 0.317 6

*
*crdno tlpvbf
0201001 0000000 6
*crdno efvcahs
0201101 0001000 5
*
0201201 102 8.0+6 0.03 0.0 0.0 0.0 6
0201300 1
0201301 0.0 0.0 0.0 5

*
0210000 sj21 sngljun
*crdno from to area floss rloss efvcahs
0210101 020000000 022000000 0.0 0.0 0.0 0001100
0210201 0 0.0 0.0 0.0

*
* AFTER SEPARATOR WATER DOWNCOMER, component v.22,
* valve jun.23, v.25, sj.26
*

0220000 downcm22 pipe
0220001 14
0220101 8.171-3 14
0220301 1.15 2, 1.05 4, 1.425 6, 1.2 10, 1.325 12
0220302 1.3 13, 1.275 14
0220601 -90.0 2, 0.0 6, -90.0 10, 0.0 12
0220602 -90.0 14
0220801 30.0-6 0.102 14

*
0220901 0.0 0.0 1, 0.15 0.15 2
0220902 0.0 0.0 3, 0.15 0.15 4
0220903 0.0 0.0 5, 0.15 0.15 6
0220904 0.0 0.0 9, 0.15 0.15 10
0220905 0.0 0.0 11, 0.15 0.15 13

*
*crdno tlpvbf
0221001 0000000 14
*crdno efvcahs
0221101 0001000 13
*
0221201 102 8.0+6 0.01 0.0 0.0 0.0 14
0221300 1
0221301 0.0 0.0 0.0 13
*

* after separator water downcomer motor valve 22
0230000 valv22 valve
*crdno from to area floss rloss efvcahs
0230101 022010000 025000000 8.171-3 400.0 400.0 0001100

0230201 1 0.0 0.0 0.0
0230300 mtrvlv
* open close rate initl table
0230301 422 622 0.001 1.0 0
*
432 time 0 ge null 0 500.0 n * close
532 time 0 ge null 0 1000.0 n * stop
622 432 and -532 n * close
422 time 0 ge null 0 9999.0 n * open
*

*
0250000 downcm25 pipe
0250001 2
0250101 8.171-3 2
0250301 0.6375 2
0250601 -90.0 2
0250801 30.0-6 0.099 2
*
0250901 0.0 0.0 1

*
*crdno tlpvbf
0251001 0000000 2
*crdno efvcahs
0251101 0001000 1
*
0251201 102 8.0+6 0.01 0.0 0.0 0.0 2
0251300 1
0251301 0.0 0.0 0.0 1

*
0260000 sj26 sngljun
*crdno from to area floss rloss efvcahs
0260101 025010000 024000000 0.0 0.0 0.0 0001100
0260201 0 0.0 0.0 0.0

*
* AFTERCOOLER (7t,8t), component v.24
*

0240000 cooler pipe * 96 annulus (tube inside tube)
0240001 4
0240101 6.5563-3 4
0240301 0.275 4
0240601 -90.0 4
0240801 4.0-6 0.003 4

*
*crdno tlpvbf
0241001 0000000 4
*crdno efvcahs
0241101 0001000 3

*
0241201 102 7.5+6 0.01 0.0 0.0 0.0 4
0241300 1
0241301 0.0 0.0 0.0 3

*
0270000 sj27 sngljun
*crdno from to area floss rloss efvcahs
0270101 024010000 028000000 0.0 0.0 0.0 0001100
0270201 0 0.0 0.0 0.0

*
* AFTERCOOLER WATER DOWNCOMER, components v.28, sj.29
*

0280000 downcm28 pipe
0280001 6
0280101 8.171-3 6
0280301 0.95 2, 1.075 4, 1.215 6
0280601 -90.0 6
0280801 30.0-6 0.102 6
0280901 0.0 0.0 1,0.15 0.15 2, 0.0 0.0 5

*
*crdno tlpvbf
0281001 0000000 6
*crdno efvcahs
0281101 0101000 5
*
0281201 103 7.3+6 527.45 0.0 0.0 0.0 6
0281300 1
0281301 0.0 0.0 0.0 5

```

*-----
0290000 sj29 sngljun
*crdno from to area floss rloss efvcahs
0290101 028010000 041050003 0.0 0.0 0.0 0001100
0290201 0 0.0 0.0 0.0
*
* AFTER SEPARATOR STEAM PIPELINE, components sj.36, v.30,
*
0360000 sj36 sngljun
*crdno from to area floss rloss efvcahs
0360101 020010000 030000000 0.0 0.0 0.0 0101100
0360201 0 0.0 0.0 0.0
*
0300000 steam pipe
0300001 12
0300101 8.171-3 12
0300301 0.6 1, 0.8 2, 0.7 3, 0.95 4
0300302 1.475 6, 1.4 7, 1.7 8, 0.75 9
0300303 0.65 10, 0.75 12
0300601 90.0 1, 0.0 6, -45.0 7, 0.0 10, -90.0 12
0300801 30.0-6 0.102 12
*
0300901 0.15 0.15 1, 0.0 0.0 4
0300902 0.0 0.0 5, 0.15 0.15 10, 0.0 0.0 11
*
*crdno tlpvbf
0301001 0000000 12
*crdno efvcahs
0301101 0001000 11
*
0301201 102 8.0+6 0.03 0.0 0.0 0.0 12
0301300 1
0301301 0.0 0.0 0.0 11
*-----
* after separator steam downcomer motor valve 19
0310000 valv19 valve
*crdno from to area floss rloss efvcahs
0310101 030010000 032000000 8.171-3 400.0 400.0 0001100
0310201 1 0.0 0.0 0.0
0310300 mtrvlv
* open close rate initl table
0310301 419 619 0.001 1.0 0
*
439 time 0 ge null 0 500.0 n * close
539 time 0 ge null 0 1000.0 n * stop
619 439 and -539 n * close
419 time 0 ge null 0 9999.0 n * open
*
*-----
* CONDENSER (1k,2k,3k), component v.32
*
0320000 condens pipe * bundle of 72 U-tubes
0320001 4
0320101 81.804-3 4
0320301 0.60625 4
0320601 -90.0 4
0320801 4.0-6 46.73-3 4
*
*crdno tlpvbf
0321001 0000100 4
*0321001 0000000 4
*crdno efvcahs
0321101 0001000 3
*
0321201 102 7.9+6 0.03 0.0 0.0 0.0 4
0321300 1
0321301 0.0 0.0 0.0 3
*
*-----
0330000 sj33 sngljun
*crdno from to area floss rloss efvcahs
0330101 032010000 034000000 0.0 0.5 0.5 0001100
0330201 0 0.0 0.0 0.0
*
* AFTER CONDENSER WATER DOWNCOMER, component v.34
*
0340000 downcm34 pipe
0340001 15
0340101 8.171-3 15

```

```

0340301 0.85 1, 1.7 2, 0.85 3, 2.0 4, 1.7 5
0340302 1.843 8, 2.4 9, 1.85 11,
0340303 2.26725 12, 2.11625 13, 1.85125 15
*
0340601 0.0 1, -90.0 2, 0.0 3, -90.0 4, 0.0 5
0340602 -90.0 8, 0.0 11, -90.0 15
0340801 30.0-6 0.102 15
*
0340901 0.15 0.15 6, 0.0 0.0 8
0340902 0.15 0.15 9, 0.0 0.0 10
0340903 0.15 0.15 11, 0.0 0.0 12
0340904 0.15 0.15 13, 0.0 0.0 14
*
*crdno tlpvbf
0341001 0000000 15
*crdno efvcahs
0341101 0001000 14
*
0341201 103 7.9+6 527.45 0.0 0.0 0.0 15
0341300 1
0341301 0.0 0.0 0.0 14
*-----
0350000 sj35 sngljun
*crdno from to area floss rloss efvcahs
0350101 034010000 041040003 0.0 0.0 0.0 0001100
0350201 0 0.0 0.0 0.0
*-----
* FIRST INTAKE HEADER, component v.41
*
0410000 inthdr1 pipe
0410001 7
0410101 0.02865 7
0410301 0.5 1, 1.00 6, 0.5 7
0410601 0.0 7
0410701 0.0 7
0410801 40.0-6 0.191 7
0410901 0.0 0.0 6
*
*crdno tlpvbf
0411001 0000000 7
*crdno efvcahs
0411101 0001000 6
*
0411201 103 7.9+6 527.45 0.0 0.0 0.0 7
0411300 1
0411301 0.0 0.0 0.0 6
*-----
* MECHANICAL FILTERS, components sj.42, sj.43, sj.44
*
0420000 sj42 sngljun
*crdno from to area floss rloss efvcahs
0420101 041040004 045010003 6.6476-3 140.0 140.0 0001100
0420201 0 0.0 0.0 0.0
*
0430000 sj43 sngljun
*crdno from to area floss rloss efvcahs
0430101 041050004 045020003 6.6476-3 140.0 140.0 0001100
0430201 0 0.0 0.0 0.0
*
0440000 sj44 sngljun
*crdno from to area floss rloss efvcahs
0440101 041060004 045030003 6.6476-3 140.0 140.0 0001100
0440201 0 0.0 0.0 0.0
*-----
* SECOND INTAKE HEADER, component v.45
*
0450000 inthdr2 pipe
0450001 3
0450101 0.02865 3
0450301 1.00 2, 1.35 3
0450601 0.0 3
0450801 40.0-6 0.191 3
0450901 0.0 0.0 2
*
*crdno tlpvbf
0451001 0000000 3
*crdno efvcahs
0451101 0001000 2
*

```

0451201 103 7.5+6 527.45 0.0 0.0 0.0 3
0451300 1
0451301 0.0 0.0 0.0 2
*-----
0460000 sj46 sngljun
*crdno from to area floss rloss efvcahs
0460101 045010004 047000000 0.0 0.0 0.0 0001100
0460201 0 0.0 0.0 0.0
*-----
*
1000000 calcht tmdpvol
1000101 0.0 2.0 2.0 0.0 0.0 1.0-6 0.0 0
1000200 103
1000201 0.0 7.85+6 527.45
*
1010000 sj101 sngljun
*crdno from to area floss rloss efvcahs
1010101 100000000 045000000 0.0 0.0 0.0 0001100
1010201 0 0.0 0.0 0.0
*-----
*
*1010000 inventor tmdpjun
*1010101 100000000 045000000 0.0
*1010200 1
*1010201 0 0.0 0.0 0.0 0.0
*
*-----
* PUMP 1 SUCTION PIPELINE, component v.47
*
0470000 suctm1 pipe
0470001 5
0470101 28.65-3 5
0470301 1.95 2, 2.1 4, 2.2 5 * check 2.2 height for subvol 5
0470601 0.0 5
0470801 40.0-6 0.191 5
*
0470901 0.0 0.0 1, 0.10 0.10 2
0470902 0.0 0.0 3, 0.10 0.10 4
*
*crdno tlpvbf
0471001 0000000 5
*crdno efvcahs
0471101 0001000 4
*
0471201 103 7.5+6 527.45 0.0 0.0 0.0 5
0471300 1
0471301 0.0 0.0 0.0 4
*
*-----
* DOWNCOMER PAST SEPARATORS AND CONDENSERS,
* components sj.51, v.52
*
0510000 sj51 sngljun
*crdno from to area floss rloss efvcahs
0510101 011050003 052010001 0.0 0.0 0.0 0001100
0510201 0 0.0 0.0 0.0
*-----
*
0520000 downcm52 pipe
0520001 14
0520101 16.06-3 14
0520301 1.663 3, 2.2 4, 1.9 5, 1.6 6, 1.5 8
0520302 1.9 9, 2.45 10, 1.5 11, 2.091 12, 2.275 14
0520601 -90.0 3, 0.0 4, -90.0 5, 0.0 6, -90.0 8
0520602 0.0 9, -90.0 10, 0.0 11, -90.0 14
0520801 35.0-6 0.143 14
*
0520901 0.0 0.0 2, 0.15 0.15 6
0520902 0.0 0.0 7, 0.15 0.15 10
0520903 0.15 0.15 11
0520904 0.0 0.0 13
*
*crdno tlpvbf
0521001 0000000 14
*crdno efvcahs
0521101 0001000 13
*
0521201 103 8.0+6 538.0 0.0 0.0 0.0 14
0521300 1

0521301 0.0 0.0 0.0 13
*-----
*past separators and condensers downcomer motor valve 29
0530000 valv29 valve
*crdno from to area floss rloss efvcahs
0530101 052010000 041030003 16.06-3 1900.0 1900.0 0001100
0530201 1 0.0 0.0 0.0
0530300 mtrvlv
* open close rate initl table
0530301 429 629 0.001 1.0 0
*
449 time 0 ge null 0 500.0 n * close
549 time 0 ge null 0 1000.0 n * stop
629 449 and -549 n * close
429 time 0 ge null 0 9999. n * open
*
*-----
* DOWNCOMER FROM UPPER HEADER TO HEAT
EXCHANGERS (5t,6t),
* components sj.61, v.62
*
0610000 sj61 sngljun
*crdno from to area floss rloss efvcahs
0610101 052060001 062000000 0.0 0.0 0.0 0001100
0610201 0 0.0 0.0 0.0
*
0620000 downcm62 pipe
0620001 8
0620101 16.06-3 8
0620301 1.72 3, 1.375 4, 1.35 5, 1.325 6, 1.2 7, 1.2 8
0620601 0.0 3, -90.0 4, 0.0 5, -90.0 6, 0.0 7, -90.0 8
0620801 35.0-6 0.143 8
0620901 0.0 0.0 2, 0.15 0.15 7
*
*crdno tlpvbf
0621001 0000000 8
*crdno efvcahs
0621101 0001000 7
*
0621201 103 8.0+6 538.0 0.0 0.0 0.0 8
0621300 1
0621301 0.0 0.0 0.0 7
*
*-----
* heat exchanger downcomer motor valve 14
0630000 valv14 valve
*crdno from to area floss rloss efvcahs
0630101 062010000 064000000 16.06-3 1550.0 1550.0 0001100
0630201 1 0.0 0.0 0.0
0630300 mtrvlv
* open close rate initl table
0630301 414 614 0.001 1.0 0
*
424 time 0 ge null 0 500.0 n * close
524 time 0 ge null 0 1000.0 n * stop
614 424 and -524 n * close
414 time 0 ge null 0 9999.0 n * open
*
*-----
* HEAT EXCHANGER (5t, 6t), component v.64
*
0640000 htexch pipe * bundle of 48 U-tubes
0640001 4
0640101 54.536-3 4
0640301 0.60625 4
0640601 -90.0 4
0640801 4.0-6 45.09-3 4
*
*crdno tlpvbf
0641001 0000100 4
*crdno efvcahs
0641101 0001000 3
*
0641201 103 7.5+6 538.0 0.0 0.0 0.0 4
0641300 1
0641301 0.0 0.0 0.0 3
*-----
0650000 sj65 sngljun
*crdno from to area floss rloss efvcahs

```

0650101 064010000 066000000 0.0 0.0 0.0 0001100
0650201 0.0 0.0 0.0 0.0
*
* AFTER HEAT EXCHANGERER DOWNCOMER, component v.66
*
0660000 downcm66 pipe
0660001 9
0660101 0.016060 9
0660301 1.642 3, 1.649 4, 2.725 5, 2.637 7, 2.0585 9
0660601 0.0 3, -90.0 4, 0.0 7, -90.0 9
0660801 35.0-6 0.143 9
0660901 0.0 0.0 2.0.15 0.15 4, 0.0 0.0 6, 0.15 0.15 8
*
*crdno tlpvbf
0661001 0000000 9
*crdno efvcchs
0661101 0001000 8
*
0661201 103 7.5+6 527.45 0.0 0.0 0.0 9
0661300 1
0661301 0.0 0.0 0.0 8
*
0670000 sj67 sngljun
*crdno from to area floss rloss efvcchs
0670101 066010000 041000000 0.0 0.0 0.0 0001100
0670201 0.0 0.0 0.0 0.0
*
*
* SECOND CIRCUIT
*
2010000 tdv201 tmdpvvl
2010101 0.0 2.0 2.0 0.0 0.0 0.0 1.0-6 0.0 0
2010200 103
2010201 0.0 7.5+6 481.0
*
2020000 regul tmdpjun
2020101 201000000 203000000 0.0
2020200 1
2020201 0.0 9.50 0.0 0.0
*
2030000 htexch pipe * heat exchanger 5t,6t (bundle of 48 U-tubes)
2030001 8
2030101 3.768-3 8
2030301 0.60625 8
2030601 90.0 4, -90.0 8
2030801 2.0-6 0.01 8
2030901 0.0 0.0 7
*
*crdno tlpvbf
2031001 0000000 8
*crdno efvcchs
2031101 0001000 7
*
2031201 103 7.0+6 485.0 0.0 0.0 0.0 8
2031300 1
2031301 0.0 0.0 0.0 7
*
2040000 sj204 sngljun
2040101 203010000 205000000 0.0 0.0 0.0 001100
2040201 0.0 0.0 0.0 0.0
*
2050000 tdv205 tmdpvvl
2050101 0.0 2.0 2.0 0.0 0.0 0.0 1.0-6 0.0 0
2050200 103
2050201 0.0 7.0+6 500.0
*
10641000 8 2 2 0 0.005
10641100 0 1
10641101 1 0.0065
10641201 1 1
10641301 0. 1
10641401 507.0 2
10641501 203010000 10000 1 1 29.1 8
10641601 064040000 -10000 110 1 29.1 4
10641602 064010000 10000 110 1 29.1 8
10641701 0.0 0.0 0.0 0.0 8
10641801 0.0 20.0 20.0 0.0 0.0 0.0 1.0 8
10641901 0.0 20.0 20.0 0.0 0.0 0.0 1.0 8
*

```

```

*
2110000 tdv211 tmdpvvl
2110101 0.0 2.0 2.0 0.0 0.0 0.0 1.0-6 0.0 0
2110200 103
2110201 0.0 7.5+6 481.0
*
2120000 regul tmdpjun
2120101 211000000 214000000 0.0
2120200 1
2120201 0.0 9.50 0.0 0.0
*
2140000 htexch pipe * aftercooler 7t,8t (tube inside tube)
2140001 8
2140101 3.768-3 8
2140301 0.275 8
2140601 90.0 4, -90.0 8
2140801 2.0-6 0.01 8
2140901 0.0 0.0 7
*
*crdno tlpvbf
2141001 0000000 8
*crdno efvcchs
2141101 0001000 7
*
2141201 103 7.0+6 485.0 0.0 0.0 0.0 8
2141300 1
2141301 0.0 0.0 0.0 7
*
2150000 sj215 sngljun
2150101 214010000 216000000 0.0 0.0 0.0 001100
2150201 0.0 0.0 0.0 0.0
*
2160000 tdv216 tmdpvvl
2160101 0.0 2.0 2.0 0.0 0.0 0.0 1.0-6 0.0 0
2160200 103
2160201 0.0 7.0+6 500.0
*
10241000 8 2 2 0 0.005
10241100 0 1
10241101 1 0.0065
10241201 1 1
10241301 0. 1
10241401 507.0 2
10241501 214010000 10000 1 1 13.2 8
10241601 024040000 -10000 110 -1 13.2 4
10241602 024010000 10000 110 1 13.2 8
10241701 0.0 0.0 0.0 0.0 8
10241801 0.0 20.0 20.0 0.0 0.0 0.0 1.0 8
10241901 0.0 20.0 20.0 0.0 0.0 0.0 1.0 8
*
*
2210000 tdv221 tmdpvvl
2210101 0.0 2.0 2.0 0.0 0.0 0.0 1.0-6 0.0 0
2210200 103
2210201 0.0 7.5+6 481.0
*
2220000 regul tmdpjun
2220101 221000000 224000000 0.0
2220200 1
2220201 0.0 14.3 0.0 0.0
*
2240000 condens pipe * condenser 1k,2k,3k (bundle of 72 U-tubes)
2240001 8
2240101 5.652-3 8
2240301 0.0625 8
2240601 90.0 4, -90.0 8
2240801 2.0-6 0.01 8
2240901 0.0 0.0 7
*
*crdno tlpvbf
2241001 0000000 8
*crdno efvcchs
2241101 0001000 7
*
2241201 103 7.0+6 485.0 0.0 0.0 0.0 8
2241300 1
2241301 0.0 0.0 0.0 7
*
2250000 sj225 sngljun

```



```

2250101 224010000 226000000 0.0 0.0 0.0 001100
2250201 0 0.0 0.0 0.0
*
2260000 tdv226 tmdpv0l
2260101 0.0 2.0 2.0 0.0 0.0 1.0-6 0.0 0
2260200 103
2260201 0.0 7.0+6 500.0
*
10321000 8 2 2 0 0.005
10321100 0 1
10321101 1 0.0065
10321201 1 1
10321301 0. 1
10321401 507.0 2
10321501 224010000 10000 1 1 43.65 8
10321601 032040000 -10000 110 1 43.65 4
10321602 032010000 10000 110 1 43.65 8
10321701 0 0.0 0.0 0.0 8
10321801 0.0 20.0 20.0 0.0 0.0 0.0 1.0 8
10321901 0.0 20.0 20.0 0.0 0.0 0.0 1.0 8
*
*****
* HEAT STRUCTURES
*****
20800001 htemp 005100104
20800002 htemp 005100204
20800003 htemp 005100304
20800004 htemp 005100404
20800005 htemp 005100504
20800006 htemp 005100604
20800007 htemp 005100704
20800008 htemp 005100804
20800009 htemp 005100904
20800010 htemp 005101004
20800011 htemp 005101104
20800012 htemp 005101204
20800013 htemp 005101304
20800014 htemp 005101404
20800015 htemp 005101504
20800016 htemp 005101604
20800017 htemp 005101704
20800018 htemp 005101804
20800019 htemp 005101904
20800020 htemp 005102004
20800021 htemp 005102104
20800022 htemp 005102204
20800023 htemp 005102304
20800024 htemp 005102404
20800025 htemp 005102504
20800026 htemp 005102604
20800027 htemp 005102704
20800028 htemp 005102804
20800029 htemp 005102904
20800030 htemp 005103004
20800031 htemp 005103104
20800032 htemp 005103204
20800033 htemp 005103304
20800034 htemp 005103404
20800035 htemp 005103504
20800036 htemp 005103604
20800037 htemp 005103704
20800038 htemp 005103804
20800039 htemp 005103904
20800040 htemp 005104004
*
20800041 htemp 005200104
20800042 htemp 005200204
20800043 htemp 005200304
20800044 htemp 005200404
20800045 htemp 005200504
20800046 htemp 005200604
20800047 htemp 005200704
20800048 htemp 005200804
20800049 htemp 005200904
20800050 htemp 005201004
20800051 htemp 005201104
20800052 htemp 005201204
20800053 htemp 005201304
20800054 htemp 005201404

```

```

20800055 htemp 005201504
20800056 htemp 005201604
20800057 htemp 005201704
20800058 htemp 005201804
20800059 htemp 005201904
20800060 htemp 005202004
20800061 htemp 005202104
20800062 htemp 005202204
20800063 htemp 005202304
20800064 htemp 005202404
20800065 htemp 005202504
20800066 htemp 005202604
20800067 htemp 005202704
20800068 htemp 005202804
20800069 htemp 005202904
20800070 htemp 005203004
20800071 htemp 005203104
20800072 htemp 005203204
20800073 htemp 005203304
20800074 htemp 005203404
20800075 htemp 005203504
20800076 htemp 005203604
20800077 htemp 005203704
20800078 htemp 005203804
20800079 htemp 005203904
20800080 htemp 005204004
*
20800081 vgjj 005410000
20800082 dt 0
20800083 cputime 0
20800084 dcrmt 0
*
* fuel channel
*
*10051000 40 13 2 0 0.00375
*10051100 0 1
*10051101 1 0.004 1 0.00425 1 0.0045 1 0.00475
*10051102 1 0.005 1 0.00525 1 0.0055 1 0.00575
*10051103 1 0.006 1 0.00625 1 0.0065 1 0.00675
*10051201 1 12
*10051301 1. 12
*10051401 527.3 13
10051000 40 5 2 0 0.00375
10051100 0 1
10051101 1 0.004 1 0.005
10051102 1 0.006 1 0.00675
10051201 1 4
10051301 1. 4
10051401 527.3 5
10051501 0 0 0 1 0.96 1
10051502 0 0 0 1 2.16 10
10051503 0 0 0 1 0.72 40
10051601 005020000 10000 110 1 0.96 1
10051602 005030000 10000 110 1 2.16 10
10051603 005120000 10000 110 1 0.72 40
10051701 001 0.006689523559 0.0 0.0 1
10051702 001 0.015051428446 0.0 0.0 10
10051703 001 0.005017142815 0.0 0.0 40
10051900 1
10051901 0.03576 0.08 5.92 0.08 0.08 0.55 0.55 1.0 0.16 1.222 1.0 1
10051902 0.03576 0.34 6.66 0.18 0.18 0.55 0.55 1.0 0.36 1.222 1.0 2
10051903 0.03576 0.70 6.30 0.18 0.18 0.55 0.55 1.0 0.36 1.222 1.0 3
10051904 0.03576 1.06 5.94 0.18 0.18 0.55 0.55 1.0 0.36 1.222 1.0 4
10051905 0.03576 1.42 5.58 0.18 0.18 0.55 0.55 1.0 0.36 1.222 1.0 5
10051906 0.03576 1.78 5.22 0.18 0.18 0.55 0.55 1.0 0.36 1.222 1.0 6
10051907 0.03576 2.14 4.86 0.18 0.18 0.55 0.55 1.0 0.36 1.222 1.0 7
10051908 0.03576 2.50 4.50 0.18 0.18 0.55 0.55 1.0 0.36 1.222 1.0 8
10051909 0.03576 2.86 4.14 0.18 0.18 0.55 0.55 1.0 0.36 1.222 1.0 9
10051910 0.03576 3.22 3.78 0.18 0.18 0.55 0.91 1.0 0.36 1.222 1.0 10
10051911 0.03576 3.46 3.54 0.06 0.06 0.91 0.28 1.0 0.12 1.222 1.0 11
10051912 0.03576 3.58 3.42 0.06 0.06 0.25 0.28 1.0 0.12 1.222 1.0 12
10051913 0.03576 3.70 3.30 0.06 0.06 0.28 0.91 1.0 0.12 1.222 1.0 13
10051914 0.03576 3.82 3.18 0.06 0.06 0.91 0.28 1.0 0.12 1.222 1.0 14
10051915 0.03576 3.94 3.06 0.06 0.06 0.28 0.28 1.0 0.12 1.222 1.0 15
10051916 0.03576 4.06 2.94 0.06 0.06 0.28 0.91 1.0 0.12 1.222 1.0 16
10051917 0.03576 4.18 2.82 0.06 0.06 0.91 0.28 1.0 0.12 1.222 1.0 17
10051918 0.03576 4.30 2.70 0.06 0.06 0.28 0.28 1.0 0.12 1.222 1.0 18
10051919 0.03576 4.42 2.58 0.06 0.06 0.28 0.91 1.0 0.12 1.222 1.0 19
10051920 0.03576 4.54 2.46 0.06 0.06 0.91 0.28 1.0 0.12 1.222 1.0 20

```

10051921 0.03576 4.66 2.34 0.06 0.06 0.28 0.28 1.0 0.12 1.222 1.0 21
 10051922 0.03576 4.78 2.22 0.06 0.06 0.28 0.91 1.0 0.12 1.222 1.0 22
 10051923 0.03576 4.90 2.10 0.06 0.06 0.91 0.28 1.0 0.12 1.222 1.0 23
 10051924 0.03576 5.02 1.98 0.06 0.06 0.28 0.28 1.0 0.12 1.222 1.0 24
 10051925 0.03576 5.14 1.86 0.06 0.06 0.28 0.91 1.0 0.12 1.222 1.0 25
 10051926 0.03576 5.26 1.74 0.06 0.06 0.91 0.28 1.0 0.12 1.222 1.0 26
 10051927 0.03576 5.38 1.62 0.06 0.06 0.28 0.28 1.0 0.12 1.222 1.0 27
 10051928 0.03576 5.50 1.50 0.06 0.06 0.28 0.91 1.0 0.12 1.222 1.0 28
 10051929 0.03576 5.62 1.38 0.06 0.06 0.91 0.28 1.0 0.12 1.222 1.0 29
 10051930 0.03576 5.74 1.26 0.06 0.06 0.28 0.28 1.0 0.12 1.222 1.0 30
 10051931 0.03576 5.86 1.14 0.06 0.06 0.28 0.91 1.0 0.12 1.222 1.0 31
 10051932 0.03576 5.98 1.02 0.06 0.06 0.91 0.28 1.0 0.12 1.222 1.0 32
 10051933 0.03576 6.10 0.90 0.06 0.06 0.28 0.28 1.0 0.12 1.222 1.0 33
 10051934 0.03576 6.22 0.78 0.06 0.06 0.28 0.91 1.0 0.12 1.222 1.0 34
 10051935 0.03576 6.34 0.66 0.06 0.06 0.91 0.28 1.0 0.12 1.222 1.0 35
 10051936 0.03576 6.46 0.54 0.06 0.06 0.28 0.28 1.0 0.12 1.222 1.0 36
 10051937 0.03576 6.58 0.42 0.06 0.06 0.28 0.91 1.0 0.12 1.222 1.0 37
 10051938 0.03576 6.70 0.30 0.06 0.06 0.91 0.28 1.0 0.12 1.222 1.0 38
 10051939 0.03576 6.82 0.18 0.06 0.18 0.28 0.28 1.0 0.12 1.222 1.0 39
 10051940 0.03576 6.94 0.06 0.06 0.06 0.28 0.91 1.0 0.12 1.222 1.0 40
 *
 10052000 40 5 2 0 0.00275
 10052100 0 1
 10052101 1 0.004 1 0.005
 10052102 1 0.006 1 0.00675
 10052201 1 4
 10052301 1. 4
 10052401 527.3 5
 *10052000 40 17 2 0 0.00275
 *10052100 0 1
 *10052101 1 0.003 1 0.00325 1 0.0035 1 0.00375
 *10052102 1 0.004 1 0.00425 1 0.0045 1 0.00475
 *10052103 1 0.005 1 0.00525 1 0.0055 1 0.00575
 *10052104 1 0.006 1 0.00625 1 0.0065 1 0.00675
 *10052201 1 16
 *10052301 1. 16
 *10052401 527.3 17
 10052501 0 0 0 1 1.92 1
 10052502 0 0 0 1 4.32 10
 10052503 0 0 0 1 1.44 40
 10052601 005020000 10000 110 1 1.92 1
 10052602 005030000 10000 110 1 4.32 10
 10052603 005120000 10000 110 1 1.44 40
 10052701 001 0.016167618441 0.0 0.0 1
 10052702 001 0.036377142554 0.0 0.0 10
 10052703 001 0.012125714185 0.0 0.0 40
 10052900 1
 10052901 0.01788 0.08 5.92 0.08 0.08 0.55 0.55 1.0 0.16 1.222 1.0 1
 10052902 0.01788 0.34 6.66 0.18 0.18 0.55 0.55 1.0 0.36 1.222 1.0 2
 10052903 0.01788 0.70 6.30 0.18 0.18 0.55 0.55 1.0 0.36 1.222 1.0 3
 10052904 0.01788 1.06 5.94 0.18 0.18 0.55 0.55 1.0 0.36 1.222 1.0 4
 10052905 0.01788 1.42 5.58 0.18 0.18 0.55 0.55 1.0 0.36 1.222 1.0 5
 10052906 0.01788 1.78 5.22 0.18 0.18 0.55 0.55 1.0 0.36 1.222 1.0 6
 10052907 0.01788 2.14 4.86 0.18 0.18 0.55 0.55 1.0 0.36 1.222 1.0 7
 10052908 0.01788 2.50 4.50 0.18 0.18 0.55 0.55 1.0 0.36 1.222 1.0 8
 10052909 0.01788 2.86 4.14 0.18 0.18 0.55 0.55 1.0 0.36 1.222 1.0 9
 10052910 0.01788 3.22 3.78 0.18 0.18 0.55 0.91 1.0 0.36 1.222 1.0 10
 10052911 0.01788 3.46 3.54 0.06 0.06 0.91 0.28 1.0 0.12 1.222 1.0 11
 10052912 0.01788 3.58 3.42 0.06 0.06 0.25 0.28 1.0 0.12 1.222 1.0 12
 10052913 0.01788 3.70 3.30 0.06 0.06 0.28 0.91 1.0 0.12 1.222 1.0 13
 10052914 0.01788 3.82 3.18 0.06 0.06 0.91 0.28 1.0 0.12 1.222 1.0 14
 10052915 0.01788 3.94 3.06 0.06 0.06 0.28 0.28 1.0 0.12 1.222 1.0 15
 10052916 0.01788 4.06 2.94 0.06 0.06 0.28 0.91 1.0 0.12 1.222 1.0 16
 10052917 0.01788 4.18 2.82 0.06 0.06 0.91 0.28 1.0 0.12 1.222 1.0 17
 10052918 0.01788 4.30 2.70 0.06 0.06 0.28 0.28 1.0 0.12 1.222 1.0 18
 10052919 0.01788 4.42 2.58 0.06 0.06 0.28 0.91 1.0 0.12 1.222 1.0 19
 10052920 0.01788 4.54 2.46 0.06 0.06 0.91 0.28 1.0 0.12 1.222 1.0 20
 10052921 0.01788 4.66 2.34 0.06 0.06 0.28 0.28 1.0 0.12 1.222 1.0 21
 10052922 0.01788 4.78 2.22 0.06 0.06 0.28 0.91 1.0 0.12 1.222 1.0 22
 10052923 0.01788 4.90 2.10 0.06 0.06 0.91 0.28 1.0 0.12 1.222 1.0 23
 10052924 0.01788 5.02 1.98 0.06 0.06 0.28 0.28 1.0 0.12 1.222 1.0 24
 10052925 0.01788 5.14 1.86 0.06 0.06 0.28 0.91 1.0 0.12 1.222 1.0 25
 10052926 0.01788 5.26 1.74 0.06 0.06 0.91 0.28 1.0 0.12 1.222 1.0 26
 10052927 0.01788 5.38 1.62 0.06 0.06 0.28 0.28 1.0 0.12 1.222 1.0 27
 10052928 0.01788 5.50 1.50 0.06 0.06 0.28 0.91 1.0 0.12 1.222 1.0 28
 10052929 0.01788 5.62 1.38 0.06 0.06 0.91 0.28 1.0 0.12 1.222 1.0 29
 10052930 0.01788 5.74 1.26 0.06 0.06 0.28 0.28 1.0 0.12 1.222 1.0 30
 10052931 0.01788 5.86 1.14 0.06 0.06 0.28 0.91 1.0 0.12 1.222 1.0 31
 10052932 0.01788 5.98 1.02 0.06 0.06 0.91 0.28 1.0 0.12 1.222 1.0 32

10052933 0.01788 6.10 0.90 0.06 0.06 0.28 0.28 1.0 0.12 1.222 1.0 33
 10052934 0.01788 6.22 0.78 0.06 0.06 0.28 0.91 1.0 0.12 1.222 1.0 34
 10052935 0.01788 6.34 0.66 0.06 0.06 0.91 0.28 1.0 0.12 1.222 1.0 35
 10052936 0.01788 6.46 0.54 0.06 0.06 0.28 0.28 1.0 0.12 1.222 1.0 36
 10052937 0.01788 6.58 0.42 0.06 0.06 0.28 0.91 1.0 0.12 1.222 1.0 37
 10052938 0.01788 6.70 0.30 0.06 0.06 0.91 0.28 1.0 0.12 1.222 1.0 38
 10052939 0.01788 6.82 0.18 0.06 0.18 0.28 0.28 1.0 0.12 1.222 1.0 39
 10052940 0.01788 6.94 0.06 0.06 0.06 0.28 0.91 1.0 0.12 1.222 1.0 40
 *
 10053000 45 2 2 0 0.00
 10053100 0 1
 10053101 1 0.0075
 10053201 1 1
 10053301 0. 1
 10053401 527.45 2
 10053501 0 0 0 1 0.578 1
 10053502 0 0 0 1 0.16 2
 10053503 0 0 0 1 0.36 11
 10053504 0 0 0 1 0.12 41
 10053505 0 0 0 1 0.131 43
 10053506 0 0 0 1 0.098 44
 10053507 0 0 0 1 0.1 45
 10053601 005010000 10000 110 1 0.578 1
 10053602 005020000 10000 110 1 0.16 2
 10053603 005030000 10000 110 1 0.36 11
 10053604 005120000 10000 110 1 0.12 41
 10053605 005420000 10000 110 1 0.131 43
 10053606 005440000 10000 110 1 0.098 44
 10053607 005450000 10000 110 1 0.1 45
 10053701 0 0 0 0 0 0.0 45
 10053901 0 0 15.0 15.0 0.0 0.0 0.0 0.0 1.0 45
 *
 10054000 45 3 2 0 0.04
 10054100 0 1
 10054101 1 0.055
 10054102 1 0.0625
 10054201 3 1 2 2
 10054301 0 0 2
 10054401 530.0 3
 10054501 005010000 10000 110 1 0.578 1
 10054502 005020000 10000 110 1 0.16 2
 10054503 005030000 10000 110 1 0.36 11
 10054504 005120000 10000 110 1 0.12 41
 10054505 005420000 10000 110 1 0.131 43
 10054506 005440000 10000 110 1 0.098 44
 10054507 005450000 10000 110 1 0.1 45
 10054601 -12 0 3011 1 0.578 1
 10054602 -12 0 3011 1 0.16 2
 10054603 -12 0 3011 1 0.36 11
 10054604 -12 0 3011 1 0.12 41
 10054605 -12 0 3011 1 0.131 43
 10054606 -12 0 3011 1 0.098 44
 10054607 -12 0 3011 1 0.1 45
 10054701 0 0 0 0 0 0.0 45
 10054801 0 0 15.0 15.0 0.0 0.0 0.0 0.0 1.0 45
 *
 * lifting path tube
 10071000 4 2 2 0 0.0365
 10071100 0 1
 10071101 1 0.0445
 10071201 2 1
 10071301 0 0 1
 10071401 550.0 2
 10071501 007010000 00000 1 1 0.38 1
 10071502 007020000 00000 1 1 0.35 2
 10071503 007030000 10000 1 1 0.7975 3
 10071504 007040000 10000 1 1 0.795 4
 10071601 -12 0 3011 1 0.38 1
 10071602 -12 0 3011 1 0.35 2
 10071603 -12 0 3011 1 0.7975 3
 10071604 -12 0 3011 1 0.795 4
 10071701 0 0 0 0 0 0.0 4
 10071801 0 0 15.0 15.0 0.0 0.0 0.0 0.0 1.0 4
 *
 * lifting path tube
 10072000 7 2 2 0 0.051
 10072100 0 1
 10072101 1 0.057
 10072201 2 1

10072301 0.0 1
 10072401 550.0 2
 10072501 007050000 10000 1 1 1.635 3
 10072502 007080000 0 1 1 1.07 4
 10072503 007090000 0 1 1 0.68 5
 10072504 007100000 0 1 1 0.1 6
 10072505 007110000 0 1 1 0.24 7
 10072601 -12 0 3011 1 1.635 3
 10072602 -12 0 3011 1 1.07 4
 10072603 -12 0 3011 1 0.68 5
 10072604 -12 0 3011 1 0.1 6
 10072605 -12 0 3011 1 0.24 7
 10072701 0 0 0 0 0 0 7
 10072801 0.0 15.0 15.0 0.0 0.0 0.0 0.0 1.0 7

*

* swc tube

10091000 20 2 2 0 0.0325
 10091100 0 1
 10091101 1 0.0375
 10091201 2 1
 10091301 0.0 1
 10091401 550.0 2
 10091501 009010000 10000 1 1 0.75 2
 10091502 009030000 10000 1 1 0.6 3
 10091503 009050000 10000 1 1 1.375 5
 10091504 009060000 10000 1 1 0.8 6
 10091505 009070000 10000 1 1 1.3 7
 10091506 009080000 00000 1 1 1.4 8
 10091507 009090000 00000 1 1 0.8 9
 10091508 009100000 00000 1 1 2.15 10
 10091509 009150000 00000 1 1 2.26 15
 10091510 009170000 00000 1 1 1.7175 17
 10091511 009180000 00000 1 1 2.3 18
 10091512 009190000 00000 1 1 0.7 19
 10091513 009200000 00000 1 1 0.5 20
 10091601 -12 0 3011 1 0.75 2
 10091602 -12 0 3011 1 0.6 3
 10091603 -12 0 3011 1 1.375 5
 10091604 -12 0 3011 1 0.8 6
 10091605 -12 0 3011 1 1.3 7
 10091606 -12 0 3011 1 1.4 8
 10091607 -12 0 3011 1 0.8 9
 10091608 -12 0 3011 1 2.15 10
 10091609 -12 0 3011 1 2.26 15
 10091610 -12 0 3011 1 1.7175 17
 10091611 -12 0 3011 1 2.3 18
 10091612 -12 0 3011 1 0.7 19
 10091613 -12 0 3011 1 0.5 20
 10091701 0 0 0 0 0 0 20
 10091801 0.0 15.0 15.0 0.0 0.0 0.0 0.0 1.0 20

*

* upper header tube

10111000 6 2 2 0 0.1475
 10111100 0 1
 10111101 1 0.1635
 10111201 2 1
 10111301 0.0 1
 10111401 536.0 2
 10111501 010010000 00000 1 1 0.7 1
 10111502 011010000 10000 1 1 0.7 5
 10111503 011050000 00000 1 1 0.9 6
 10111601 -12 0 3011 1 0.7 1
 10111602 -12 0 3011 1 0.7 5
 10111603 -12 0 3011 1 0.9 6
 10111701 0 0 0 0 0 0 6
 10111801 0.0 15.0 15.0 0.0 0.0 0.0 0.0 1.0 6

*

* swpline pipe

10141000 8 2 2 0 0.05
 10141100 0 1
 10141101 1 0.06
 10141201 2 1
 10141301 0.0 1
 10141401 550.0 2
 10141501 014010000 00000 1 1 0.9 1
 10141502 014020000 10000 1 1 1.0 2
 10141503 014030000 10000 1 1 1.3 3
 10141504 014040000 10000 1 1 1.5 4
 10141505 014050000 10000 1 1 0.8 5

10141506 014060000 10000 1 1 1.0 6
 10141507 014070000 10000 1 1 1.5 7
 10141508 014080000 10000 1 1 0.5 8
 10141601 -12 0 3011 1 0.9 1
 10141602 -12 0 3011 1 1.0 2
 10141603 -12 0 3011 1 1.3 3
 10141604 -12 0 3011 1 1.5 4
 10141605 -12 0 3011 1 0.8 5
 10141606 -12 0 3011 1 1.0 6
 10141607 -12 0 3011 1 1.5 7
 10141608 -12 0 3011 1 0.5 8
 10141701 0 0 0 0 0 0 8
 10141801 0.0 15.0 15.0 0.0 0.0 0.0 0.0 1.0 8

*

* separator tube

10201000 8 2 2 0 0.091
 10201100 0 1
 10201101 1 0.111
 10201201 2 1
 10201301 0.0 1
 10201401 536.0 2
 10201501 020010000 10000 1 1 0.5 2
 10201502 020020000 10000 1 1 0.7 3
 10201503 020020000 10000 1 1 0.5 8
 10201601 -12 0 3011 1 0.5 2
 10201602 -12 0 3011 1 0.7 3
 10201603 -12 0 3011 1 0.5 8
 10201701 0 0 0 0 0 0 8
 10201801 0.0 15.0 15.0 0.0 0.0 0.0 0.0 1.0 8

*

* downcm22 pipe

10221000 14 2 2 0 0.051
 10221100 0 1
 10221101 1 0.057
 10221201 2 1
 10221301 0.0 1
 10221401 536.0 2
 10221501 022010000 10000 1 1 1.15 2
 10221502 022030000 10000 1 1 1.05 4
 10221503 022050000 10000 1 1 1.425 6
 10221504 022070000 10000 1 1 1.2 10
 10221505 022110000 10000 1 1 1.325 12
 10221506 022130000 10000 1 1 1.3 13
 10221507 022140000 10000 1 1 1.275 14
 10221601 -12 0 3011 1 1.15 2
 10221602 -12 0 3011 1 1.05 4
 10221603 -12 0 3011 1 1.425 6
 10221604 -12 0 3011 1 1.2 10
 10221605 -12 0 3011 1 1.325 12
 10221606 -12 0 3011 1 1.3 13
 10221607 -12 0 3011 1 1.275 14
 10221701 0 0 0 0 0 0 14
 10221801 0.0 15.0 15.0 0.0 0.0 0.0 0.0 1.0 14

*

* steam pipe

10301000 12 2 2 0 0.051
 10301100 0 1
 10301101 1 0.057
 10301201 2 1
 10301301 0.0 1
 10301401 550.0 2
 10301501 030010000 10000 1 1 0.6 1
 10301502 030020000 10000 1 1 0.8 2
 10301503 030030000 10000 1 1 0.7 3
 10301504 030040000 10000 1 1 0.95 4
 10301505 030050000 10000 1 1 1.475 6
 10301506 030070000 10000 1 1 1.4 7
 10301507 030080000 10000 1 1 1.7 8
 10301508 030090000 10000 1 1 0.75 9
 10301509 030100000 10000 1 1 0.65 10
 10301510 030110000 10000 1 1 0.7 12
 10301601 -12 0 3011 1 0.6 1
 10301602 -12 0 3011 1 0.8 2
 10301603 -12 0 3011 1 0.7 3
 10301604 -12 0 3011 1 0.95 4
 10301605 -12 0 3011 1 1.475 6
 10301606 -12 0 3011 1 1.4 7
 10301607 -12 0 3011 1 1.7 8
 10301608 -12 0 3011 1 0.75 9

```

10301609 -12 0 3011 1 0.65 10
10301610 -12 0 3011 1 0.7 12
10301701 0 0.0 0.0 0.0 12
10301801 0.0 15.0 15.0 0.0 0.0 0.0 0.0 1.0 12
*
* downcm34 pipe
10341000 15 2 2 0 0.051
10341100 0 1
10341101 1 0.057
10341201 2 1
10341301 0.0 1
10341401 527.45 2
10341501 034010000 10000 1 1 0.85 1
10341502 034020000 10000 1 1 1.7 2
10341503 034030000 10000 1 1 0.85 3
10341504 034040000 10000 1 1 2.0 4
10341505 034050000 10000 1 1 1.7 5
10341506 034060000 10000 1 1 1.843 8
10341507 034090000 10000 1 1 2.4 9
10341508 034100000 10000 1 1 1.85 11
10341509 034120000 10000 1 1 1.586 12
10341510 034130000 10000 1 1 1.435 13
10341511 034140000 10000 1 1 1.42 15
10341601 -12 0 3011 1 0.85 1
10341602 -12 0 3011 1 1.7 2
10341603 -12 0 3011 1 0.85 3
10341604 -12 0 3011 1 2.0 4
10341605 -12 0 3011 1 1.7 5
10341606 -12 0 3011 1 1.843 8
10341607 -12 0 3011 1 2.4 9
10341608 -12 0 3011 1 1.85 11
10341609 -12 0 3011 1 1.586 12
10341610 -12 0 3011 1 1.435 13
10341611 -12 0 3011 1 1.42 15
10341701 0 0.0 0.0 0.0 15
10341801 0.0 15.0 15.0 0.0 0.0 0.0 0.0 1.0 15
*
* downcm52 pipe
10521000 14 2 2 0 0.0715
10521100 0 1
10521101 1 0.0795
10521201 2 1
10521301 0.0 1
10521401 536.0 2
10521501 052010000 10000 1 1 1.663 3
10521502 052040000 10000 1 1 2.2 4
10521503 052050000 10000 1 1 1.9 5
10521504 052060000 10000 1 1 1.6 6
10521505 052070000 10000 1 1 1.5 8
10521506 052090000 10000 1 1 1.9 9
10521507 052100000 10000 1 1 2.45 10
10521508 052110000 10000 1 1 1.5 11
10521509 052120000 10000 1 1 1.516 12
10521510 052130000 10000 1 1 1.45 14
10521601 -12 0 3011 1 1.663 3
10521602 -12 0 3011 1 2.2 4
10521603 -12 0 3011 1 1.9 5
10521604 -12 0 3011 1 1.6 6
10521605 -12 0 3011 1 1.5 8
10521606 -12 0 3011 1 1.9 9
10521607 -12 0 3011 1 2.45 10
10521608 -12 0 3011 1 1.5 11
10521609 -12 0 3011 1 1.516 12
10521610 -12 0 3011 1 1.45 14
10521701 0 0.0 0.0 0.0 14
10521801 0.0 15.0 15.0 0.0 0.0 0.0 0.0 1.0 14
*
* downcm62 pipe
10621000 8 2 2 0 0.0715
10621100 0 1
10621101 1 0.0795
10621201 2 1
10621301 0.0 1
10621401 536.0 2
10621501 062010000 10000 1 1 1.72 3
10621502 062040000 10000 1 1 1.375 4
10621503 062050000 10000 1 1 1.35 5
10621504 062060000 10000 1 1 1.325 6
10621505 062070000 10000 1 1 1.2 7

```

```

10621506 062080000 10000 1 1 1.2 8
10621601 -12 0 3011 1 1.72 3
10621602 -12 0 3011 1 1.375 4
10621603 -12 0 3011 1 1.35 5
10621604 -12 0 3011 1 1.325 6
10621605 -12 0 3011 1 1.2 7
10621606 -12 0 3011 1 1.2 8
10621701 0 0.0 0.0 0.0 8
10621801 0.0 15.0 15.0 0.0 0.0 0.0 0.0 1.0 8
*
* bypass pipe
11061000 24 2 2 0 0.051
11061100 0 1
11061101 1 0.057
11061201 2 1
11061301 0.0 1
11061401 527.45 2
11061501 106010000 10000 1 1 1.0 2
11061502 106030000 10000 1 1 1.511 3
11061503 106040000 10000 1 1 1.3 4
11061504 106050000 10000 1 1 1.137445 6
11061505 106070000 10000 1 1 1.55 7
11061506 106080000 10000 1 1 1.1425 11
11061507 106120000 10000 1 1 1.4 13
11061508 106140000 10000 1 1 1.7 14
11061509 106150000 10000 1 1 1.3 15
11061510 106160000 10000 1 1 1.4 17
11061511 106180000 10000 1 1 1.3842 22
11061512 106230000 10000 1 1 0.6 24
11061601 -12 0 3011 1 1.0 2
11061602 -12 0 3011 1 1.511 3
11061603 -12 0 3011 1 1.3 4
11061604 -12 0 3011 1 1.137445 6
11061605 -12 0 3011 1 1.55 7
11061606 -12 0 3011 1 1.1425 11
11061607 -12 0 3011 1 1.4 13
11061608 -12 0 3011 1 1.7 14
11061609 -12 0 3011 1 1.3 15
11061610 -12 0 3011 1 1.4 17
11061611 -12 0 3011 1 1.3842 22
11061612 -12 0 3011 1 0.6 24
11061701 0 0.0 0.0 0.0 24
11061801 0.0 15.0 15.0 0.0 0.0 0.0 0.0 1.0 24
*****
* GENERAL TABLES
*****
* MATEREAL
*****
20100100 s-steel
20100200 s-steel
20100300 tbl/ftm 1 1
20100301 1.15
20100351 2.465+6
*****
* HEAT SOURCE
*****
20200100 power 0 1. 1000.0
20200101 0.00 0000.0
20200102 10.00 2486.0
*****
* HEAT LOSS
*****
20200200 htrnrate 0 1.0 1.0
20200201 0.0 2282.12
*
**heat
20200300 temp 0
20200301 0.00 560.0
*
20201100 htc-t 0
20201101 0.00 10.0
*
20201200 temp 0
20201201 0.00 295.0
*end of data set
=
0000100 restart transnt
*0000101 inp-chk

```

```

0000102 si si
0000103 198474 cmpress
0000202 1350. 1.0-6 0.01 15003 500 40000 4000000
0000203 1400. 1.0-6 0.01 15003 100 40000 4000000
*0000204 1460. 1.0-6 0.01 15003 10 40000 4000000
*0000205 1600. 1.0-6 0.01 15003 500 40000 4000000
*
1000000 tdv100 delete
*
1010000 outleg delete
*
.end data set

=
0000100 restart transnt
*0000101 inp-chk
0000102 si si
*0000103 198457 cmpress
0000103 278474 *1400 s
*0000103 297835 *1500 s
*0000202 1350. 1.0-6 0.01 15003 500 40000 4000000
0000203 1400. 1.0-6 0.01 15003 100 10000 10000
0000204 1800. 1.0-6 0.01 15003 10 10000 10000
*0000205 1500. 1.0-6 0.01 15003 500 40000 4000000
*
*1000000 tdv100 delete
*
*1010000 outleg delete
*
* isolating control valve 2r
0020000 valv2r valve
*crdno from to area floss rloss efvcahs
0020101 001010000 003000000 3.3183-3 775.0 775.0 0001100
0020201 1 3.9 0.0 0.0
0020300 mtrvlv
* open close rate initl table
0020301 702 602 0.25 1.0 0
*
412 time 0 ge null 0 1408.7 n * close
512 time 0 ge null 0 1416.0 n * stop
602 412 and -512 n * close
*
403 time 0 ge null 0 1420.00 n * open
503 time 0 ge null 0 1420.17 n * stop
702 403 and -503 n * open
*
.end data set

```

BIBLIOGRAPHIC DATA SHEET

(See instructions on the reverse)

1. REPORT NUMBER
(Assigned by NRC, Add Vol., Supp., Rev.,
and Addendum Numbers, if any.)

NUREG/IA-0202

2. TITLE AND SUBTITLE

Analyses of KS Test Data on the Heated Rod Bundle Temperature Behavior in RBMK-1500 Core Model Under Stop and Recovery Flow Using RELAP5/MOD3.2 and RELAP5/MOD3.2.2 GAMMA

3. DATE REPORT PUBLISHED

MONTH	YEAR
April	2001

4. FIN OR GRANT NUMBER

5. AUTHOR(S)

V.A. Vinogradov, A.Y. Balykin

6. TYPE OF REPORT

Technical

7. PERIOD COVERED (Inclusive Dates)

8. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC, provide Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)

Nuclear Reactor Institute, Russian Research Center
Kurchatov Institute
Kurchatov Square 1
123182, Moscow Russia

9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC, type "Same as above"; if contractor, provide NRC Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address.)

Division of Systems Analysis and Regulatory Effectiveness
Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

10. SUPPLEMENTARY NOTES

11. ABSTRACT (200 words or less)

This report has been prepared as a part of the Agreement on Research Participation and Technical Exchange under the International Code Application and Maintenance Program. KS experimental data on the behavior of the heated rod bundle temperature in the RBMK-1500 core model under stop and recovery flow conditions were simulated with RELAP5/MOD3.2 and RELAP5/MOD3.2.2 GAMMA to assess the codes suitability. Especially calculations were performed to estimate differences in the code version predictions for processes/phenomena, which could occur under specific conditions of RBMK type reactor during LOCA with MCP's pressure header rupture and subsequent ECCS water injection. This problem addresses phenomena of high importance to RBMK-1500 safety including water discharge, critical heat flux, post dryout heat transfer, reflood and propagation of rewetting front in the fuel channel during an accident. The tests has been carried out at KS semi-integral test facility (Russian Research Center Kurchatov Institute) represented RBMK primary circuit. The main purpose of the experiment was investigation of temperature conditions in the fuel assembly under high power value, inlet flow rate being decreased drastically up to complete stop of the flow followed by pressure header rupture. A subsequent flow rate resumption was also assumed, the fuel assembly power high level being unchanged. First, a study of the effect of the hydraulic nodalization to the code calculations was performed using different number of hydraulic volumes for the fuel channel model. After the choice of proper nodalization and maximum user-specified time step, base case calculations were done for the test. Sensitivity studies were carried out to investigate the effects of modeling on the behavior of the rod simulator temperatures along the height of the fuel assembly model.

12. KEY WORDS/DESCRIPTORS (List words or phrases that will assist researchers in locating the report.)

RELAP5
RBMK
LOCA

13. AVAILABILITY STATEMENT

unlimited

14. SECURITY CLASSIFICATION

(This Page)


unclassified

(This Report)

unclassified

15. NUMBER OF PAGES

16. PRICE



Federal Recycling Program

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, DC 20555-0001

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE, \$300