



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

JUNE 2002

SUPPLEMENT 26 TO NUREG-0933
"A PRIORITIZATION OF GENERIC SAFETY ISSUES"

REVISION INSERTION INSTRUCTIONS

| | <u>Remove</u> | <u>Insert</u> |
|---------------|---|---|
| Introduction: | pp. 29 to 68, Rev. 25 | pp. 29 to 68, Rev. 26 |
| Section 2: | p. 2.0-1 p. 2.A.1-1, Rev. 1 p. 2.A.2-1, Rev. 1 pp. 2.A.3-1 to 3, Rev. 1 p. 2.A.4-1, Rev. 1 p. 2.A.5-1, Rev. 1 p. 2.A.6-1, Rev. 1 p. 2.A.7-1, Rev. 1 p. 2.A.8-1, Rev. 1 p. 2.A.9-1, Rev. 1 p. 2.A.10-1, Rev. 1 p. 2.A.11-1, Rev. 1 p. 2.A.12-1, Rev. 1 pp. 2.A.13-1 to 2, Rev. 1 pp. 2.A.14-1 to 2 pp. 2.A.15-1 to 2 pp. 2.A.16-1 to 2 pp. 2.A.17-1 to 2, Rev. 1 pp. 2.A.18-1 to 4 pp. 2.A.19-1 to 2, Rev. 1 pp. 2.A.20-1 to 2 | p. 2.0-1, Rev. 1 p. 2.A.1-1, Rev. 2 p. 2.A.2-1, Rev. 2 pp. 2.A.3-1 to 3, Rev. 2 p. 2.A.4-1, Rev. 2 p. 2.A.5-1, Rev. 2 p. 2.A.6-1, Rev. 2 p. 2.A.7-1, Rev. 2 p. 2.A.8-1, Rev. 2 p. 2.A.9-1, Rev. 2 p. 2.A.10-1, Rev. 2 p. 2.A.11-1, Rev. 2 p. 2.A.12-1, Rev. 2 pp. 2.A.13-1 to 2, Rev. 2 pp. 2.A.14-1 to 2, Rev. 1 pp. 2.A.15-1 to 2, Rev. 1 pp. 2.A.16-1 to 2, Rev. 1 pp. 2.A.17-1 to 2, Rev. 2 pp. 2.A.18-1 to 4, Rev. 1 pp. 2.A.19-1 to 2, Rev. 2 pp. 2.A.20-1 to 2, Rev. 1 |
| Section 3: | pp. 3.172-1 to 17, Rev. 1 pp. 3.173-1 to 4, Rev. 3 - - | pp. 3.172-1 to 17, Rev. 2 pp. 3.173-1 to 5, Rev. 4 pp. 3.188-1 to 6 pp. 3.189-1 to 14 |
| References: | pp. R-1 to R-121, Rev. 15 | pp. R-1 to R-123, Rev. 16 |
| Appendix B: | pp. A.B-1 to 13, Rev. 16 | pp. A.B-1 to 13, Rev. 17 |
| Appendix F: | pp. A.F.0-1 to 3, Rev. 3 pp. A.F.10-1 | pp. A.F.0-1 to 3, Rev. 4 pp. A.F.10-1, Rev. 1 |

AVAILABILITY OF REFERENCE MATERIALS IN NRC PUBLICATIONS

NRC Reference Material

As of November 1999, you may electronically access NUREG-series publications and other NRC records at NRC's Public Electronic Reading Room at <http://www.nrc.gov/reading-rm.html>.

Publicly released records include, to name a few, NUREG-series publications; *Federal Register* notices; applicant, licensee, and vendor documents and correspondence; NRC correspondence and internal memoranda; bulletins and information notices; inspection and investigative reports; licensee event reports; and Commission papers and their attachments.

NRC publications in the NUREG series, NRC regulations, and *Title 10, Energy, in the Code of Federal Regulations* may also be purchased from one of these two sources.

1. The Superintendent of Documents
U.S. Government Printing Office
Mail Stop SSOP
Washington, DC 20402-0001
Internet: bookstore.gpo.gov
Telephone: 202-512-1800
Fax: 202-512-2250
2. The National Technical Information Service
Springfield, VA 22161-0002
www.ntis.gov
1-800-553-6847 or, locally, 703-605-6000

A single copy of each NRC draft report for comment is available free, to the extent of supply, upon written request as follows:

Address: Office of the Chief Information Officer,
Reproduction and Distribution
Services Section
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001
E-mail: DISTRIBUTION@nrc.gov
Facsimile: 301-415-2289

Some publications in the NUREG series that are posted at NRC's Web site address <http://www.nrc.gov/reading-rm/doc-collections/nuregs> are updated periodically and may differ from the last printed version. Although references to material found on a Web site bear the date the material was accessed, the material available on the date cited may subsequently be removed from the site.

Non-NRC Reference Material

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, and transactions, *Federal Register* notices, Federal and State legislation, and congressional reports. Such documents as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings may be purchased from their sponsoring organization.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at—

The NRC Technical Library
Two White Flint North
11545 Rockville Pike
Rockville, MD 20852-2738

These standards are available in the library for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from—

American National Standards Institute
11 West 42nd Street
New York, NY 10036-8002
www.ansi.org
212-642-4900

Legally binding regulatory requirements are stated only in laws; NRC regulations; licenses, including technical specifications; or orders, not in NUREG-series publications. The views expressed in contractor-prepared publications in this series are not necessarily those of the NRC.

The NUREG series comprises (1) technical and administrative reports and books prepared by the staff (NUREG-XXXX) or agency contractors (NUREG/CR-XXXX), (2) proceedings of conferences (NUREG/CP-XXXX), (3) reports resulting from international agreements (NUREG/IA-XXXX), (4) brochures (NUREG/BR-XXXX), and (5) compilations of legal decisions and orders of the Commission and Atomic and Safety Licensing Boards and of Directors' decisions under Section 2.206 of NRC's regulations (NUREG-0750).

TABLE IILISTING OF ALL TMI ACTION PLAN ITEMS, TASK ACTION PLAN ITEMS,
NEW GENERIC ISSUES, HUMAN FACTORS ISSUES, AND CHERNOBYL ISSUES

This table contains the priority designations for all issues listed in this report. For those issues found to be covered in other issues described in this document, the appropriate notations have been made in the Safety Priority Ranking column, e.g., I.A.2.2 in the Safety Priority Ranking column means that Item I.A.2.6(3) is covered in Item I.A.2.2. For those issues found to be covered in programs not described in this document, the notation (S) was made in the Safety Priority Ranking column. For resolved issues that have resulted in new requirements for operating plants, the appropriate multiplant licensing action number is listed. The licensing action numbering system bears no relationship to the numbering systems used for identifying the prioritized issues. An explanation of the classification and status of the issues is provided in the legend below.

Legend

NOTES:

- 1 - Possible Resolution Identified for Evaluation
- 2 - Resolution Available (Documented in NUREG, NRC Memorandum, SER, or equivalent)
- 3 - Resolution Resulted in either: (a) The Establishment of New Regulatory Requirements (By Rule, SRP Change, or equivalent) or (b) No New Requirements
- 4 - Issue to be Prioritized in the Future
- 5 - Issue that is not a Generic Safety Issue but should be Assigned Resources for Completion

HIGH

- High Safety Priority

MEDIUM

- Medium Safety Priority

LOW

- Low Safety Priority

DROP

- Issue Dropped as a Generic Issue

EI

- Environmental Issue

I

- Resolved TMI Action Plan Item with Implementation of Resolution Mandated by NUREG-0737

LI

- Licensing Issue

MPA

- Multiplant Action

NA

- Not Applicable

RI

- Regulatory Impact Issue

S

- Issue Covered in an NRC Program Outside the Scope of This Document

USI

- Unresolved Safety Issue

Continue

- As defined in NRC Management Directive 6.4

06/30/02

30

NUREG-0933

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------------|--|----------------------|-------------------------------------|-------------------------------|----------------|----------------------------|------------|
| <u>TMI ACTION PLAN ITEMS</u> | | | | | | | |
| <u>I.A</u> | <u>OPERATING PERSONNEL</u> | | | | | | |
| <u>I.A.1</u> | <u>Operating Personnel and Staffing</u> | | | | | | |
| I.A.1.1 | Shift Technical Advisor | - | NRR/DHFS/LQB | I | 3 | 12/31/97 | F-01 |
| I.A.1.2 | Shift Supervisor Administrative Duties | - | NRR/DHFS/LQB | I | 3 | 12/31/97 | |
| I.A.1.3 | Shift Manning | - | NRR/DHFS/LQB | I | 3 | 12/31/97 | F-02 |
| I.A.1.4 | Long-Term Upgrading | Colmar | RES/DFO/HFBR | NOTE 3(a) | 3 | 12/31/97 | |
| <u>I.A.2</u> | <u>Training and Qualifications of Operating Personnel</u> | | | | | | |
| I.A.2.1 | Immediate Upgrading of Operator and Senior Operator Training and Qualifications | - | - | - | | | |
| I.A.2.1(1) | Qualifications - Experience | - | NRR/DHFS/LQB | I | 6 | 12/31/97 | F-03 |
| I.A.2.1(2) | Training | - | NRR/DHFS/LQB | I | 6 | 12/31/97 | F-03 |
| I.A.2.1(3) | Facility Certification of Competence and Fitness of Applicants for Operator and Senior Operator Licenses | - | NRR/DHFS/LQB | I | 6 | 12/31/97 | F-03 |
| I.A.2.2 | Training and Qualifications of Operations Personnel | Colmar | NRR/DHFS/LQB | NOTE 3(b) | 6 | 12/31/97 | NA |
| I.A.2.3 | Administration of Training Programs | - | NRR/DHFS/LQB | I | 6 | 12/31/97 | |
| I.A.2.4 | NRR Participation in Inspector Training | Colmar | NRR/DHFS/LQB | LI (NOTE 3) | 6 | 12/31/97 | NA |
| I.A.2.5 | Plant Drills | Colmar | NRR/DHFS/LQB | NOTE 3(b) | 6 | 12/31/97 | NA |
| I.A.2.6 | Long-Term Upgrading of Training and Qualifications | - | - | - | | | |
| I.A.2.6(1) | Revise Regulatory Guide 1.8 | Colmar | NRR/DHFT/HFIB | NOTE 3(a) | 6 | 12/31/97 | NA |
| I.A.2.6(2) | Staff Review of NRR 80-117 | Colmar | NRR/DHFS/LQB | NOTE 3(b) | 6 | 12/31/97 | NA |
| I.A.2.6(3) | Revise 10 CFR 55 | Colmar | NRR/DHFS/LQB | I.A.2.2 | 6 | 12/31/97 | NA |
| I.A.2.6(4) | Operator Workshops | Colmar | NRR/DHFS/LQB | NOTE 3(b) | 6 | 12/31/97 | NA |
| I.A.2.6(5) | Develop Inspection Procedures for Training Program | Colmar | NRR/DHFS/LQB | NOTE 3(b) | 6 | 12/31/97 | NA |
| I.A.2.6(6) | Nuclear Power Fundamentals | Colmar | NRR/DHFS/LQB | DROP | 6 | 12/31/97 | NA |
| I.A.2.7 | Accreditation of Training Institutions | Colmar | NRR/DHFS/LQB | NOTE 3(b) | 6 | 12/31/97 | NA |
| <u>I.A.3</u> | <u>Licensing and Requalification of Operating Personnel</u> | | | | | | |
| I.A.3.1 | Revise Scope of Criteria for Licensing Examinations | Emrit | NRR/DHFS/LQB | I | 6 | 12/31/97 | |
| I.A.3.2 | Operator Licensing Program Changes | Emrit | NRR/DHFS/OLB | NOTE 3(b) | 6 | 12/31/97 | NA |
| I.A.3.3 | Requirements for Operator Fitness | Colmar | RES/DRAO/HFSB | NOTE 3(b) | 6 | 12/31/97 | NA |
| I.A.3.4 | Licensing of Additional Operations Personnel | Thatcher | NRR/DHFS/LQB | NOTE 3(b) | 6 | 12/31/97 | NA |
| I.A.3.5 | Establish Statement of Understanding with INPO and DOE | Thatcher | NRR/DHFS/HFEB | LI (NOTE 3) | 6 | 12/31/97 | NA |
| <u>I.A.4</u> | <u>Simulator Use and Development</u> | | | | | | |
| I.A.4.1 | Initial Simulator Improvement | - | - | - | | | |
| I.A.4.1(1) | Short-Term Study of Training Simulators | Thatcher | NRR/DHFS/OLB | NOTE 3(b) | 6 | 12/31/97 | NA |
| I.A.4.1(2) | Interim Changes in Training Simulators | Thatcher | NRR/DHFS/OLB | NOTE 3(a) | 6 | 12/31/97 | |

Revision 26

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------|--|-------------------|-------------------------------|-------------------------|-------------|----------------------|---------|
| I.A.4.2 | Long-Term Training Simulator Upgrade | - | - | - | | | |
| I.A.4.2(1) | Research on Training Simulators | Colmar | NRR/DHFT/HFIB | NOTE 3(a) | 6 | 12/31/97 | |
| I.A.4.2(2) | Upgrade Training Simulator Standards | Colmar | RES/DFO/HFBR | NOTE 3(a) | 6 | 12/31/97 | |
| I.A.4.2(3) | Regulatory Guide on Training Simulators | Colmar | RES/DFO/HFBR | NOTE 3(a) | 6 | 12/31/97 | |
| I.A.4.2(4) | Review Simulators for Conformance to Criteria | Colmar | NRR/DLPQ/LOLB | NOTE 3(a) | 6 | 12/31/97 | |
| I.A.4.3 | Feasibility Study of Procurement of NRC Training Simulator | Colmar | RES/DAE/RSRB | LI (NOTE 3) | 6 | 12/31/97 | NA |
| I.A.4.4 | Feasibility Study of NRC Engineering Computer | Colmar | RES/DAE/RSRB | LI (NOTE 3) | 6 | 12/31/97 | NA |
| <u>I.B.</u> | <u>SUPPORT PERSONNEL</u> | | | | | | |
| <u>I.B.1</u> | <u>Management for Operations</u> | | | | | | |
| I.B.1.1 | Organization and Management Long-Term Improvements | - | - | - | | | |
| I.B.1.1(1) | Prepare Draft Criteria | Colmar | NRR/DHFT/HFIB | NOTE 3(b) | 4 | 12/31/97 | NA |
| I.B.1.1(2) | Prepare Commission Paper | Colmar | NRR/DHFT/HFIB | NOTE 3(b) | 4 | 12/31/97 | NA |
| I.B.1.1(3) | Issue Requirements for the Upgrading of Management and Technical Resources | Colmar | NRR/DHFT/HFIB | NOTE 3(b) | 4 | 12/31/97 | NA |
| I.B.1.1(4) | Review Responses to Determine Acceptability | Colmar | NRR/DHFT/HFIB | NOTE 3(b) | 4 | 12/31/97 | NA |
| I.B.1.1(5) | Review Implementation of the Upgrading Activities | Colmar | OIE/DQASIP/ORPB | NOTE 3(b) | 4 | 12/31/97 | NA |
| I.B.1.1(6) | Prepare Revisions to Regulatory Guides 1.33 and 1.8 | Colmar | NRR/DHFS/LQB | I.A.2.6(1), 75 | 4 | 12/31/97 | NA |
| I.B.1.1(7) | Issue Regulatory Guides 1.33 and 1.8 | Colmar | NRR/DHFS/LQB | I.A.2.6(1), 75 | 4 | 12/31/97 | NA |
| I.B.1.2 | Evaluation of Organization and Management Improvements of Near-Term Operating License Applicants | - | - | - | | | |
| I.B.1.2(1) | Prepare Draft Criteria | - | NRR/DHFS/LQB | NOTE 3(b) | 4 | 12/31/97 | NA |
| I.B.1.2(2) | Review Near-Term Operating License Facilities | - | NRR/DHFS/LQB | NOTE 3(b) | 4 | 12/31/97 | NA |
| I.B.1.2(3) | Include Findings in the SER for Each Near-Term Operating License Facility | - | NRR/DL/ORAB | NOTE 3(b) | 4 | 12/13/97 | NA |
| I.B.1.3 | Loss of Safety Function | - | - | - | | | |
| I.B.1.3(1) | Require Licensees to Place Plant in Safest Shutdown Cooling Following a Loss of Safety Function Due to Personnel Error | Sege | RES | LI (NOTE 3) | 4 | 12/31/97 | NA |
| I.B.1.3(2) | Use Existing Enforcement Options to Accomplish Safest Shutdown Cooling | Sege | RES | LI (NOTE 3) | 4 | 12/31/97 | NA |
| I.B.1.3(3) | Use Non-Fiscal Approaches to Accomplish Safest Shutdown Cooling | Sege | RES | LI (NOTE 3) | 4 | 12/31/97 | NA |
| <u>I.B.2</u> | <u>Inspection of Operating Reactors</u> | | | | | | |
| I.B.2.1 | Revise OIE Inspection Program | - | - | - | | | |
| I.B.2.1(1) | Verify the Adequacy of Management and Procedural Controls and Staff Discipline | Sege | OIE/DQASIP/RCPB | LI (NOTE 3) | 1 | 12/31/97 | NA |

06/30/02

31

NUREG-0933

Revision 26

06/30/02

32

NUREG-0933

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------------|---|----------------------|-------------------------------------|-------------------------------|----------------|----------------------------|------------|
| I.B.2.1(2) | Verify that Systems Required to Be Operable Are Properly Aligned | Sege | OIE/DQASIP/RCPB | LI (NOTE 3) | 1 | 12/31/97 | NA |
| I.B.2.1(3) | Follow-up on Completed Maintenance Work Orders to Assure Proper Testing and Return to Service | Sege | OIE/DQASIP/RCPB | LI (NOTE 3) | 1 | 12/31/97 | NA |
| I.B.2.1(4) | Observe Surveillance Tests to Determine Whether Test Instruments Are Properly Calibrated | Sege | OIE/DQASIP/RCPB | LI (NOTE 3) | 1 | 12/31/97 | NA |
| I.B.2.1(5) | Verify that Licensees Are Complying with Technical Specifications | Sege | OIE/DQASIP/RCPB | LI (NOTE 3) | 1 | 12/31/97 | NA |
| I.B.2.1(6) | Observe Routine Maintenance | Sege | OIE/DQASIP/RCPB | LI (NOTE 3) | 1 | 12/31/97 | NA |
| I.B.2.1(7) | Inspect Terminal Boards, Panels, and Instrument Racks for Unauthorized Jumpers and Bypasses | Sege | OIE/DQASIP/RCPB | LI (NOTE 3) | 1 | 12/31/97 | NA |
| I.B.2.2 | Resident Inspector at Operating Reactors | Sege | OIE/DQASIP/ORPB | LI (NOTE 3) | 1 | 12/31/97 | NA |
| I.B.2.3 | Regional Evaluations | Sege | OIE/DQASIP/ORPB | LI (NOTE 3) | 1 | 12/31/97 | NA |
| I.B.2.4 | Overview of Licensee Performance | Sege | OIE/DQASIP/ORPB | LI (NOTE 3) | 1 | 12/31/97 | NA |
| <u>I.C</u> | <u>OPERATING PROCEDURES</u> | | | | | | |
| I.C.1 | Short-Term Accident Analysis and Procedures Revision | - | - | - | | | |
| I.C.1(1) | Small Break LOCAs | - | NRR | I | 4 | 12/31/97 | |
| I.C.1(2) | Inadequate Core Cooling | - | NRR | I | 4 | 12/31/97 | F-04 |
| I.C.1(3) | Transients and Accidents | - | NRR | I | 4 | 12/31/97 | F-05 |
| I.C.1(4) | Confirmatory Analyses of Selected Transients | Riggs | NRR/DSI/RSB | NOTE 3(b) | 4 | 12/31/97 | NA |
| I.C.2 | Shift and Relief Turnover Procedures | - | NRR | I | 4 | 12/31/97 | |
| I.C.3 | Shift Supervisor Responsibilities | - | NRR | I | 4 | 12/31/97 | |
| I.C.4 | Control Room Access | - | NRR | I | 4 | 12/31/97 | |
| I.C.5 | Procedures for Feedback of Operating Experience to Plant Staff | - | NRR/DL | I | 4 | 12/31/97 | F-06 |
| I.C.6 | Procedures for Verification of Correct Performance of Operating Activities | - | NRR/DL | I | 4 | 12/31/97 | F-07 |
| I.C.7 | NSSS Vendor Review of Procedures | - | NRR/DHFS/PSRB | I | 4 | 12/31/97 | |
| I.C.8 | Pilot Monitoring of Selected Emergency Procedures for Near-Term Operating License Applicants | - | NRR/DHFS/PSRB | I | 4 | 12/31/97 | |
| I.C.9 | Long-Term Program Plan for Upgrading of Procedures | Riggs | NRR/DHFS/PSRB | NOTE 3(b) | 4 | 12/31/97 | NA |
| <u>I.D</u> | <u>CONTROL ROOM DESIGN</u> | | | | | | |
| I.D.1 | Control Room Design Reviews | - | NRR/DL | I | 8 | 12/31/97 | F-08 |
| I.D.2 | Plant Safety Parameter Display Console | - | NRR/DL | I | 8 | 12/31/97 | F-09 |
| I.D.3 | Safety System Status Monitoring | Thatcher | RES/DE/MEB | NOTE 3(b) | 8 | 12/31/97 | NA |
| I.D.4 | Control Room Design Standard | Thatcher | RES/DRPS/RHFB | NOTE 3(b) | 8 | 12/31/97 | NA |
| I.D.5 | Improved Control Room Instrumentation Research | - | - | - | | | |

Revision 26

06/30/02

33

NUREG-0933

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------------|---|----------------------|-------------------------------------|-------------------------------|----------------|----------------------------|------------|
| I.D.5(1) | Operator-Process Communication | Thatcher | RES/DFO/HFBR | NOTE 3(b) | 8 | 12/31/97 | NA |
| I.D.5(2) | Plant Status and Post-Accident Monitoring | Thatcher | RES/DFO/HFBR | NOTE 3(a) | 8 | 12/31/97 | |
| I.D.5(3) | On-Line Reactor Surveillance System | Thatcher | RES/DE/MEB | NOTE 3(b) | 8 | 12/31/97 | NA |
| I.D.5(4) | Process Monitoring Instrumentation | Thatcher | RES/DFO/ICBR | NOTE 3(b) | 8 | 12/31/97 | NA |
| I.D.5(5) | Disturbance Analysis Systems | Thatcher | RES/DRPS/RHFB | LI (NOTE 3) | 8 | 12/31/97 | NA |
| I.D.6 | Technology Transfer Conference | Thatcher | RES/DFO/HFBR | LI (NOTE 3) | 8 | 12/31/97 | NA |
| <u>I.E</u> | <u>ANALYSIS AND DISSEMINATION OF OPERATING EXPERIENCE</u> | | | | | | |
| I.E.1 | Office for Analysis and Evaluation of Operational Data | Matthews | AEOD/PTB | LI (NOTE 3) | 3 | 12/31/97 | NA |
| I.E.2 | Program Office Operational Data Evaluation | Matthews | NRR/DL/ORAB | LI (NOTE 3) | 3 | 12/31/97 | NA |
| I.E.3 | Operational Safety Data Analysis | Matthews | RES/DRA/RRBR | LI (NOTE 3) | 3 | 12/31/97 | NA |
| I.E.4 | Coordination of Licensee, Industry, and Regulatory Programs | Matthews | AEOD/PTB | LI (NOTE 3) | 3 | 12/31/97 | NA |
| I.E.5 | Nuclear Plant Reliability Data System | Matthews | AEOD/PTB | LI (NOTE 3) | 3 | 12/31/97 | NA |
| I.E.6 | Reporting Requirements | Matthews | AEOD/PTB | LI (NOTE 3) | 3 | 12/31/97 | NA |
| I.E.7 | Foreign Sources | Matthews | IP | LI (NOTE 3) | 3 | 12/31/97 | NA |
| I.E.8 | Human Error Rate Analysis | Matthews | RES/DFO/HFBR | LI (NOTE 3) | 3 | 12/31/97 | NA |
| <u>I.F</u> | <u>QUALITY ASSURANCE</u> | | | | | | |
| I.F.1 | Expand QA List | Pittman | RES/DRA/ARGIB | NOTE 3(b) | 4 | 12/31/98 | NA |
| I.F.2 | Develop More Detailed QA Criteria | - | - | - | - | - | - |
| I.F.2(1) | Assure the Independence of the Organization Performing the Checking Function | Pittman | OIE/DQASIP/QUAB | LOW | 4 | 12/31/98 | NA |
| I.F.2(2) | Include QA Personnel in Review and Approval of Plant Procedures | Pittman | OIE/DQASIP/QUAB | NOTE 3(a) | 4 | 12/31/98 | NA |
| I.F.2(3) | Include QA Personnel in All Design, Construction, Installation, Testing, and Operation Activities | Pittman | OIE/DQASIP/QUAB | NOTE 3(a) | 4 | 12/31/98 | NA |
| I.F.2(4) | Establish Criteria for Determining QA Requirements for Specific Classes of Equipment | Pittman | OIE/DQASIP/QUAB | LOW | 4 | 12/31/98 | NA |
| I.F.2(5) | Establish Qualification Requirements for QA and QC Personnel | Pittman | OIE/DQASIP/QUAB | LOW | 4 | 12/31/98 | NA |
| I.F.2(6) | Increase the Size of Licensees' QA Staff | Pittman | OIE/DQASIP/QUAB | NOTE 3(a) | 4 | 12/31/98 | NA |
| I.F.2(7) | Clarify that the QA Program Is a Condition of the Construction Permit and Operating License | Pittman | OIE/DQASIP/QUAB | LOW | 4 | 12/31/98 | NA |
| I.F.2(8) | Compare NRC QA Requirements with Those of Other Agencies | Pittman | OIE/DQASIP/QUAB | LOW | 4 | 12/31/98 | NA |

Revision 26

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------|---|-------------------|-------------------------------|-------------------------|-------------|----------------------|---------|
| I.F.2(9) | Clarify Organizational Reporting Levels for the QA Organization | Pittman | OIE/DQASIP/QUAB | NOTE 3(a) | 4 | 12/31/98 | NA |
| I.F.2(10) | Clarify Requirements for Maintenance of "As-Built" Documentation | Pittman | OIE/DQASIP/QUAB | LOW | 4 | 12/30/98 | NA |
| I.F.2(11) | Define Role of QA in Design and Analysis Activities | Pittman | OIE/DQASIP/QUAB | LOW | 4 | 12/30/98 | NA |
| <u>I.G</u> | <u>PREOPERATIONAL AND LOW-POWER TESTING</u> | | | | | | |
| I.G.1 | Training Requirements | - | NRR/DHFS/PSRB | I | 3 | 12/31/97 | |
| I.G.2 | Scope of Test Program | Vandermolen | NRR/DHFS/PSRB | NOTE 3(a) | 3 | 12/31/97 | NA |
| <u>II.A</u> | <u>SITING</u> | | | | | | |
| II.A.1 | Siting Policy Reformulation | Vandermolen | NRR/DE/SAB | NOTE 3(b) | 2 | 12/31/97 | NA |
| II.A.2 | Site Evaluation of Existing Facilities | Vandermolen | NRR/DE/SAB | V.A.1 | 2 | 12/31/97 | NA |
| <u>II.B</u> | <u>CONSIDERATION OF DEGRADED OR MELTED CORES IN SAFETY REVIEW</u> | | | | | | |
| II.B.1 | Reactor Coolant System Vents | - | NRR/DL | I | 4 | 12/31/97 | F-10 |
| II.B.2 | Plant Shielding to Provide Access to Vital Areas and Protect Safety Equipment for Post-Accident Operation | - | NRR/DL | I | 4 | 12/31/97 | F-11 |
| II.B.3 | Post-Accident Sampling | - | NRR/DL | I | 4 | 12/31/97 | F-12 |
| II.B.4 | Training for Mitigating Core Damage | - | NRR/DL | I | 4 | 12/31/97 | F-13 |
| II.B.5 | Research on Phenomena Associated with Core Degradation and Fuel Melting | - | - | - | | | |
| II.B.5(1) | Behavior of Severely Damaged Fuel | Vandermolen | RES/DSR/AEB | LI (NOTE 5) | 4 | 12/31/97 | NA |
| II.B.5(2) | Behavior of Core-Melt | Vandermolen | RES/DSR/AEB | LI (NOTE 5) | 4 | 12/31/97 | NA |
| II.B.5(3) | Effect of Hydrogen Burning and Explosions on Containment Structure | Vandermolen | RES/DSR/AEB | LI (NOTE 5) | 4 | 12/31/97 | NA |
| II.B.6 | Risk Reduction for Operating Reactors at Sites with High Population Densities | Pittman | NRR/DST/RRAB | NOTE 3(a) | 4 | 12/31/97 | |
| II.B.7 | Analysis of Hydrogen Control | Matthews | NRR/DSI/CSB | II.B.8 | 4 | 12/31/97 | |
| II.B.8 | Rulemaking Proceeding on Degraded Core Accidents | Vandermolen | RES/DRAO/RAMR | NOTE 3(a) | 4 | 12/31/97 | |
| <u>II.C</u> | <u>RELIABILITY ENGINEERING AND RISK ASSESSMENT</u> | | | | | | |
| II.C.1 | Interim Reliability Evaluation Program | Pittman | RES/DRAO/RRB | NOTE 3(b) | 3 | 12/31/97 | NA |
| II.C.2 | Continuation of Interim Reliability Evaluation Program | Pittman | NRR/DST/RRAB | NOTE 3(b) | 3 | 12/31/97 | NA |
| II.C.3 | Systems Interaction | Pittman | NRR/DST/GIB | A-17 | 3 | 12/31/97 | NA |
| II.C.4 | Reliability Engineering | Pittman | RES/DRPS/RHFB | NOTE 3(b) | 3 | 12/31/97 | NA |

06/30/02

34

NUREG-0933

Revision 26

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|---|--|-------------------|-------------------------------|-------------------------|-------------|----------------------|------------|
| <u>II.D REACTOR COOLANT SYSTEM RELIEF AND SAFETY VALVES</u> | | | | | | | |
| II.D.1 | Testing Requirements | - | NRR/DL | I | 3 | 12/31/98 | F-14 |
| II.D.2 | Research on Relief and Safety Valve Test Requirements | Riggs | RES | LOW | 3 | 12/31/98 | NA |
| II.D.3 | Relief and Safety Valve Position Indication | - | NRR | I | 3 | 12/31/98 | |
| <u>II.E SYSTEM DESIGN</u> | | | | | | | |
| <u>II.E.1 Auxiliary Feedwater System</u> | | | | | | | |
| II.E.1.1 | Auxiliary Feedwater System Evaluation | - | NRR/DL | I | 2 | 12/31/97 | F-15 |
| II.E.1.2 | Auxiliary Feedwater System Automatic Initiation and Flow Indication | - | NRR/DL | I | 2 | 12/31/97 | F-16, F-17 |
| II.E.1.3 | Update Standard Review Plan and Develop Regulatory Guide | Riggs | RES/DRA/RRBR | NOTE 3(a) | 2 | 12/31/97 | |
| <u>II.E.2 Emergency Core Cooling System</u> | | | | | | | |
| II.E.2.1 | Reliance on ECCS | Riggs | NRR/DSI/RSB | II.K.3(17) | 3 | 12/31/98 | NA |
| II.E.2.2 | Research on Small Break LOCAs and Anomalous Transients | Riggs | RES/DAE/RSRB | NOTE 3(b) | 3 | 12/31/98 | NA |
| II.E.2.3 | Uncertainties in Performance Predictions | Vandermolen | NRR/DSI/RSB | LOW | 3 | 12/31/98 | NA |
| <u>II.E.3 Decay Heat Removal</u> | | | | | | | |
| II.E.3.1 | Reliability of Power Supplies for Natural Circulation | - | NRR/DL | I | 2 | 12/31/97 | |
| II.E.3.2 | Systems Reliability | Vandermolen | NRR/DST/GIB | A-45 | 2 | 12/31/97 | NA |
| II.E.3.3 | Coordinated Study of Shutdown Heat Removal Requirements | Vandermolen | NRR/DST/GIB | A-45 | 2 | 12/31/97 | NA |
| II.E.3.4 | Alternate Concepts Research | Riggs | RES/DAE/FBRB | NOTE 3(b) | 2 | 12/31/97 | NA |
| II.E.3.5 | Regulatory Guide | Riggs | NRR/DST/GIB | A-45 | 2 | 12/31/97 | NA |
| <u>II.E.4 Containment Design</u> | | | | | | | |
| II.E.4.1 | Dedicated Penetrations | - | NRR/DL | I | 2 | 12/31/97 | F-18 |
| II.E.4.2 | Isolation Dependability | - | NRR/DL | I | 2 | 12/31/97 | F-19 |
| II.E.4.3 | Integrity Check | Milstead | RES/DRPS/RPSI | NOTE 3(b) | 2 | 12/31/97 | NA |
| II.E.4.4 | Purging | - | - | - | | | |
| II.E.4.4(1) | Issue Letter to Licensees Requesting Limited Purging | Milstead | NRR/DSI/CSB | NOTE 3(a) | 2 | 12/31/97 | |
| II.E.4.4(2) | Issue Letter to Licensees Requesting Information on Isolation Letter | Milstead | NRR/DSI/CSB | NOTE 3(a) | 2 | 12/31/97 | |
| II.E.4.4(3) | Issue Letter to Licensees on Valve Operability | Milstead | NRR/DSI/CSB | NOTE 3(a) | 2 | 12/31/97 | |
| II.E.4.4(4) | Evaluate Purging and Venting During Normal Operation | Milstead | NRR/DSI/CSB | NOTE 3(b) | 2 | 12/31/97 | NA |
| II.E.4.4(5) | Issue Modified Purging and Venting Requirement | Milstead | NRR/DSI/CSB | NOTE 3(b) | 2 | 12/31/97 | NA |

06/30/02

35

NUREG-0933

Revision 26

06/30/02

36

NUREG-0933

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------------|---|----------------------|-------------------------------------|-------------------------------|----------------|----------------------------|--|
| <u>II.E.5</u> | <u>Design Sensitivity of B&W Reactors</u> | | | | | | |
| II.E.5.1 | Design Evaluation | Thatcher | NRR/DSI/RSB | NOTE 3(a) | 2 | 12/31/98 | |
| II.E.5.2 | B&W Reactor Transient Response Task Force | Thatcher | NRR/DL/ORAB | NOTE 3(a) | 2 | 12/31/98 | |
| <u>II.E.6</u> | <u>In Situ Testing of Valves</u> | | | | | | |
| II.E.6.1 | Test Adequacy Study | Thatcher | RES/DE/EIB | NOTE 3(a) | 2 | 12/31/98 | |
| <u>II.F</u> | <u>INSTRUMENTATION AND CONTROLS</u> | | | | | | |
| II.F.1 | Additional Accident Monitoring Instrumentation | - | NRR/DL | I | 3 | 12/31/98 | F-20, F-21, F-22, F-23, F-24, F-25, F-26 |
| II.F.2 | Identification of and Recovery from Conditions Leading to Inadequate Core Cooling | - | NRR/DL | I | 3 | 12/31/98 | |
| II.F.3 | Instruments for Monitoring Accident Conditions | Vandermolen | RES/DFO/ICBR | NOTE 3(a) | 3 | 12/31/98 | |
| II.F.4 | Study of Control and Protective Action Design Requirements | Thatcher | NRR/DSI/ICSB | DROP | 3 | 12/31/98 | NA |
| II.F.5 | Classification of Instrumentation, Control, and Electrical Equipment | Thatcher | RES/DE | LI (NOTE 3) | 3 | 12/31/98 | NA |
| <u>II.G</u> | <u>ELECTRICAL POWER</u> | | | | | | |
| II.G.1 | Power Supplies for Pressurizer Relief Valves, Block Valves, and Level Indicators | - | NRR | I | 1 | 12/31/98 | NA |
| <u>II.H</u> | <u>TMI-2 CLEANUP AND EXAMINATION</u> | | | | | | |
| II.H.1 | Maintain Safety of TMI-2 and Minimize Environmental Impact | Matthews | NRR/TMIPO | NOTE 3(b) | 3 | 12/31/98 | NA |
| II.H.2 | Obtain Technical Data on the Conditions Inside the TMI-2 Containment Structure | Milstead | RES/DRAA/AEB | NOTE 3(b) | 3 | 12/31/98 | NA |
| II.H.3 | Evaluate and Feed Back Information Obtained from TMI | Milstead | NRR/TMIPO | II.H.2 | 3 | 12/31/98 | NA |
| II.H.4 | Determine Impact of TMI on Socioeconomic and Real Property Values | Milstead | RES/DHSWM/SEBR | LI (NOTE 3) | 3 | 12/31/98 | NA |

Revision 26

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------------|--|----------------------|-------------------------------------|-------------------------------|----------------|----------------------------|------------|
| <u>II.J</u> | <u>GENERAL IMPLICATIONS OF TMI FOR DESIGN AND CONSTRUCTION ACTIVITIES</u> | | | | | | |
| <u>II.J.1</u> | <u>Vendor Inspection Program</u> | | | | | | |
| II.J.1.1 | Establish a Priority System for Conducting Vendor Inspections | Riani | OIE/DQASIP | LI (NOTE 3) | 1 | 12/31/98 | NA |
| II.J.1.2 | Modify Existing Vendor Inspection Program | Riani | OIE/DQASIP | LI (NOTE 3) | 1 | 12/31/98 | NA |
| II.J.1.3 | Increase Regulatory Control Over Present Non-Licensees | Riani | OIE/DQASIP | LI (NOTE 3) | 1 | 12/31/98 | NA |
| II.J.1.4 | Assign Resident Inspectors to Reactor Vendors and Architect-Engineers | Riani | OIE/DQASIP | LI (NOTE 3) | 1 | 12/31/98 | NA |
| <u>II.J.2</u> | <u>Construction Inspection Program</u> | | | | | | |
| II.J.2.1 | Reorient Construction Inspection Program | Riani | OIE/DQASIP | LI (NOTE 3) | 1 | 12/31/98 | NA |
| II.J.2.2 | Increase Emphasis on Independent Measurement in Construction Inspection Program | Riani | OIE/DQASIP | LI (NOTE 3) | 1 | 12/31/98 | NA |
| II.J.2.3 | Assign Resident Inspectors to All Construction Sites | Riani | OIE/DQASIP | LI (NOTE 3) | 1 | 12/31/98 | NA |
| <u>II.J.3</u> | <u>Management for Design and Construction</u> | | | | | | |
| II.J.3.1 | Organization and Staffing to Oversee Design and Construction | Pittman | NRR/DHFS/LQB | I.B.1.1 | 1 | 12/31/98 | NA |
| II.J.3.2 | Issue Regulatory Guide | Pittman | NRR/DHFS/LQB | I.B.1.1 | 1 | 12/31/98 | NA |
| <u>II.J.4</u> | <u>Revise Deficiency Reporting Requirements</u> | | | | | | |
| II.J.4.1 | Revise Deficiency Reporting Requirements | Riani | AEOD/DSP/ROAB | NOTE 3(a) | 3 | 12/31/98 | NA |
| <u>II.K</u> | <u>MEASURES TO MITIGATE SMALL-BREAK LOSS-OF-COOLANT ACCIDENTS AND LOSS-OF-FEEDWATER ACCIDENTS</u> | | | | | | |
| II.K.1 | IE Bulletins | - | - | - | - | - | - |
| II.K.1(1) | Review TMI-2 PNs and Detailed Chronology of the TMI-2 Accident | Emrit | NRR | NOTE 3(a) | - | 12/31/84 | - |
| II.K.1(2) | Review Transients Similar to TMI-2 That Have Occurred at Other Facilities and NRC Evaluation of Davis-Besse Event | Emrit | NRR | NOTE 3(a) | - | 12/31/84 | - |
| II.K.1(3) | Review Operating Procedures for Recognizing, Preventing, and Mitigating Void Formation in Transients and Accidents | Emrit | NRR | NOTE 3(a) | - | 12/31/84 | - |
| II.K.1(4) | Review Operating Procedures and Training Instructions | Emrit | NRR | NOTE 3(a) | - | 12/31/84 | - |
| II.K.1(5) | Safety-Related Valve Position Description | Emrit | NRR | NOTE 3(a) | - | 12/31/84 | - |

06/30/02

37

NUREG-0933

Revision 26

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------------|---|----------------------|-------------------------------------|-------------------------------|----------------|----------------------------|------------|
| II.K.1(6) | Review Containment Isolation Initiation Design and Procedures | Emrit | NRR | NOTE 3(a) | | 12/31/84 | - |
| II.K.1(7) | Implement Positive Position Controls on Valves That Could Compromise or Defeat AFW Flow | Emrit | NRR | NOTE 3(a) | | 12/31/84 | - |
| II.K.1(8) | Implement Procedures That Assure Two Independent 100% AFW Flow Paths | Emrit | NRR | NOTE 3(a) | | 12/31/84 | - |
| II.K.1(9) | Review Procedures to Assure That Radioactive Liquids and Gases Are Not Transferred out of Containment Inadvertently | Emrit | NRR | NOTE 3(a) | | 12/31/84 | - |
| II.K.1(10) | Review and Modify Procedures for Removing Safety-Related Systems from Service | Emrit | NRR | NOTE 3(a) | | 12/31/84 | - |
| II.K.1(11) | Make All Operating and Maintenance Personnel Aware of the Seriousness and Consequences of the Erroneous Actions Leading up to, and in Early Phases of, the TMI-2 Accident | Emrit | NRR | NOTE 3(a) | | 12/31/84 | - |
| II.K.1(12) | One Hour Notification Requirement and Continuous Communications Channels | Emrit | NRR | NOTE 3(a) | | 12/31/84 | - |
| II.K.1(13) | Propose Technical Specification Changes Reflecting Implementation of All Bulletin Items | Emrit | NRR | NOTE 3(a) | | 12/31/84 | - |
| II.K.1(14) | Review Operating Modes and Procedures to Deal with Significant Amounts of Hydrogen | Emrit | NRR | NOTE 3(a) | | 12/31/84 | - |
| II.K.1(15) | For Facilities with Non-Automatic AFW Initiation, Provide Dedicated Operator in Continuous Communication with CR to Operate AFW | Emrit | NRR | NOTE 3(a) | | 12/31/84 | - |
| II.K.1(16) | Implement Procedures That Identify PRZ PORV "Open" Indications and That Direct Operator to Close Manually at "Reset" Setpoint | Emrit | NRR | NOTE 3(a) | | 12/31/84 | - |
| II.K.1(17) | Trip PZR Level Bistable so That PZR Low Pressure Will Initiate Safety Injection | Emrit | NRR | NOTE 3(a) | | 12/31/84 | - |
| II.K.1(18) | Develop Procedures and Train Operators on Methods of Establishing and Maintaining Natural Circulation | Emrit | NRR | NOTE 3(a) | | 12/31/84 | - |
| II.K.1(19) | Describe Design and Procedure Modifications to Reduce Likelihood of Automatic PZR PORV Actuation in Transients | Emrit | NRR | NOTE 3(a) | | 12/31/84 | - |
| II.K.1(20) | Provide Procedures and Training to Operators for Prompt Manual Reactor Trip for LOFW, TT, MSIV Closure, LOOP, LOSG Level, and LO PZR Level | Emrit | NRR | NOTE 3(a) | | 12/31/84 | - |
| II.K.1(21) | Provide Automatic Safety-Grade Anticipatory Reactor Trip for LOFW, TT, or Significant Decrease in SG Level | Emrit | NRR | NOTE 3(a) | | 12/31/84 | - |

06/30/02

38

NUREG-0933

Revision 26

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------------|--|----------------------|-------------------------------------|-------------------------------|----------------|----------------------------|------------|
| II.K.1(22) | Describe Automatic and Manual Actions for Proper Functioning of Auxiliary Heat Removal Systems When FW System Not Operable | Emrit | NRR | NOTE 3(a) | | 12/31/84 | - |
| II.K.1(23) | Describe Uses and Types of RV Level Indication for Automatic and Manual Initiation Safety Systems | Emrit | NRR | NOTE 3(a) | | 12/31/84 | - |
| II.K.1(24) | Perform LOCA Analyses for a Range of Small-Break Sizes and a Range of Time Lapses Between Reactor Trip and RCP Trip | Emrit | NRR | NOTE 3(a) | | 12/31/84 | - |
| II.K.1(25) | Develop Operator Action Guidelines | Emrit | NRR | NOTE 3(a) | | 12/31/84 | - |
| II.K.1(26) | Revise Emergency Procedures and Train ROs and SROs | Emrit | NRR | NOTE 3(a) | | 12/31/84 | - |
| II.K.1(27) | Provide Analyses and Develop Guidelines and Procedures for Inadequate Core Cooling Conditions | Emrit | NRR | NOTE 3(a) | | 12/31/84 | - |
| II.K.1(28) | Provide Design That Will Assure Automatic RCP Trip for All Circumstances Where Required | Emrit | NRR | NOTE 3(a) | | 12/31/84 | - |
| II.K.2 | Commission Orders on B&W Plants | - | - | - | | | |
| II.K.2(1) | Upgrade Timeliness and Reliability of AFW System | Emrit | NRR/DSI | NOTE 3(a) | | 12/31/84 | - |
| II.K.2(2) | Procedures and Training to Initiate and Control AFW Independent of Integrated Control System | Emrit | NRR | NOTE 3(a) | | 12/31/84 | - |
| II.K.2(3) | Hard-Wired Control-Grade Anticipatory Reactor Trips | Emrit | NRR/DSI | NOTE 3(a) | | 12/31/84 | - |
| II.K.2(4) | Small-Break LOCA Analysis, Procedures and Operator Training | Emrit | NRR/DHFS/OLB | NOTE 3(a) | | 12/31/84 | - |
| II.K.2(5) | Complete TMI-2 Simulator Training for All Operators | Emrit | NRR | NOTE 3(a) | | 12/31/84 | - |
| II.K.2(6) | Reevaluate Analysis for Dual-Level Setpoint Control | Emrit | NRR/DSI | NOTE 3(a) | | 12/31/84 | - |
| II.K.2(7) | Reevaluate Transient of September 24, 1977 | Emrit | NRR/DSI | NOTE 3(a) | | 12/31/84 | - |
| II.K.2(8) | Continued Upgrading of AFW System | Emrit | NRR | II.E.1.1, II.E.1.2 | | 12/31/84 | NA |
| II.K.2(9) | Analysis and Upgrading of Integrated Control System | Emrit | NRR | I | | 12/31/84 | F-27 |
| II.K.2(10) | Hard-Wired Safety-Grade Anticipatory Reactor Trips | Emrit | NRR | I | | 12/31/84 | F-28 |
| II.K.2(11) | Operator Training and Drilling | Emrit | NRR | I | | 12/31/84 | F-29 |
| II.K.2(12) | Transient Analysis and Procedures for Management of Small Breaks | Emrit | NRR | I.C.1(3) | | 12/31/84 | NA |
| II.K.2(13) | Thermal-Mechanical Report on Effect of HPI on Vessel Integrity for Small-Break LOCA With No AFW | Emrit | NRR | I | | 12/31/84 | F-30 |
| II.K.2(14) | Demonstrate That Predicted Lift Frequency of PORVs and SVs Is Acceptable | Emrit | NRR | I | | 12/31/84 | F-31 |
| II.K.2(15) | Analysis of Effects of Slug Flow on Once-Through Steam Generator Tubes After Primary System Volding | Emrit | NRR | I | | 12/31/84 | - |
| II.K.2(16) | Impact of RCP Seal Damage Following Small-Break LOCA With Loss of Offsite Power | Emrit | NRR | I | | 12/31/84 | F-32 |
| II.K.2(17) | Analysis of Potential Volding in RCS During Anticipated Transients | Emrit | NRR | I | | 12/31/84 | F-33 |

06/30/02

39

NUREG-0933

Revision 26

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------------|--|----------------------|-------------------------------------|--------------------------------|----------------|----------------------------|---------------|
| II.K.2(18) | Analysis of Loss of Feedwater and Other Anticipated Transients | Emrit | NRR | I.C.1(3) | | 12/31/84 | NA |
| II.K.2(19) | Benchmark Analysis of Sequential AFW Flow to Once-Through Steam Generator | Emrit | NRR | I | | 12/31/84 | F-34 |
| II.K.2(20) | Analysis of Steam Response to Small-Break LOCA That Causes System Pressure to Exceed PORV Setpoint | Emrit | NRR | I | | 12/31/84 | F-35 |
| II.K.2(21) | LOFT L3-1 Predictions | Emrit | NRR/DSI | NOTE 3(a) | | 12/31/84 | - |
| II.K.3 | Final Recommendations of Bulletins and Orders Task Force | - | - | - | | | |
| II.K.3(1) | Install Automatic PORV Isolation System and Perform Operational Test | Emrit | NRR | I | | 12/31/84 | F-36 |
| II.K.3(2) | Report on Overall Safety Effect of PORV Isolation System | Emrit | NRR | I | | 12/31/84 | F-37 |
| II.K.3(3) | Report Safety and Relief Valve Failures Promptly and Challenges Annually | Emrit | NRR | I | | 12/31/84 | F-38 |
| II.K.3(4) | Review and Upgrade Reliability and Redundancy of Non-Safety Equipment for Small-Break LOCA Mitigation | Emrit | NRR | II.C.1, II.C.2, II.C.3 | | 12/31/84 | NA |
| II.K.3(5) | Automatic Trip of Reactor Coolant Pumps | Emrit | NRR | I | | 12/31/84 | F-39, G-01 |
| II.K.3(6) | Instrumentation to Verify Natural Circulation | Emrit | NRR/DSI | I.C.1(3), II.F.2, II.F.3 | | 12/31/84 | NA |
| II.K.3(7) | Evaluation of PORV Opening Probability During Overpressure Transient | Emrit | NRR | I | | 12/31/84 | - |
| II.K.3(8) | Further Staff Consideration of Need for Diverse Decay Heat Removal Method Independent of SGs | Emrit | NRR/DST/GIB | II.C.1, II.E.3.3 | | 12/31/84 | NA |
| II.K.3(9) | Proportional Integral Derivative Controller Modification | Emrit | NRR | I | | 12/31/84 | F-40 |
| II.K.3(10) | Anticipatory Trip Modification Proposed by Some Licensees to Confine Range of Use to High Power Levels | Emrit | NRR | I | | 12/31/84 | F-41 |
| II.K.3(11) | Control Use of PORV Supplied by Control Components, Inc. Until Further Review Complete | Emrit | NRR | I | | 12/31/84 | - |
| II.K.3(12) | Confirm Existence of Anticipatory Trip Upon Turbine Trip | Emrit | NRR | I | | 12/31/84 | F-42 |
| II.K.3(13) | Separation of HPCI and RCIC System Initiation Levels | Emrit | NRR | I | | 12/31/84 | F-43 |
| II.K.3(14) | Isolation of Isolation Condensers on High Radiation | Emrit | NRR | I | | 12/31/84 | F-44 |
| II.K.3(15) | Modify Break Detection Logic to Prevent Spurious Isolation of HPCI and RCIC Systems | Emrit | NRR | I | | 12/31/84 | F-45 |

06/30/02

40

NUREG-0933

Revision 26

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------------|---|----------------------|-------------------------------------|--------------------------------------|----------------|----------------------------|------------|
| II.K.3(16) | Reduction of Challenges and Failures of Relief Valves - Feasibility Study and System Modification | Emrit | NRR | I | | 12/31/84 | F-46 |
| II.K.3(17) | Report on Outage of ECC Systems - Licensee Report and Technical Specification Changes | Emrit | NRR | I | | 12/31/84 | F-47 |
| II.K.3(18) | Modification of ADS Logic - Feasibility Study and Modification for Increased Diversity for Some Event Sequences | Emrit | NRR | I | | 12/31/84 | F-48 |
| II.K.3(19) | Interlock on Recirculation Pump Loops | Emrit | NRR | I | | 12/31/84 | F-49 |
| II.K.3(20) | Loss of Service Water for Big Rock Point | Emrit | NRR | I | | 12/31/84 | - |
| II.K.3(21) | Restart of Core Spray and LPCI Systems on Low Level - Design and Modification | Emrit | NRR | I | | 12/31/84 | F-50 |
| II.K.3(22) | Automatic Switchover of RCIC System Suction - Verify Procedures and Modify Design | Emrit | NRR | I | | 12/31/84 | F-51 |
| II.K.3(23) | Central Water Level Recording | Emrit | NRR | I.D.2, III.A.1.2(1), III.A.3.4 | | 12/31/84 | NA |
| II.K.3(24) | Confirm Adequacy of Space Cooling for HPCI and RCIC Systems | Emrit | NRR | I | | 12/31/84 | F-52 |
| II.K.3(25) | Effect of Loss of AC Power on Pump Seals | Emrit | NRR | I | | 12/31/84 | F-53 |
| II.K.3(26) | Study Effect on RHR Reliability of Its Use for Fuel Pool Cooling | Emrit | NRR/DSI | II.E.2.1 | | 12/31/84 | NA |
| II.K.3(27) | Provide Common Reference Level for Vessel Level Instrumentation | Emrit | NRR | I | | 12/31/84 | F-54 |
| II.K.3(28) | Study and Verify Qualification of Accumulators on ADS Valves | Emrit | NRR | I | | 12/31/84 | F-55 |
| II.K.3(29) | Study to Demonstrate Performance of Isolation Condensers with Non-Condensibles | Emrit | NRR | I | | 12/31/84 | F-56 |
| II.K.3(30) | Revised Small-Break LOCA Methods to Show Compliance with 10 CFR 50, Appendix K | Emrit | NRR | I | | 12/31/84 | F-57 |
| II.K.3(31) | Plant-Specific Calculations to Show Compliance with 10 CFR 50.46 | Emrit | NRR | I | | 12/31/84 | F-58 |
| II.K.3(32) | Provide Experimental Verification of Two-Phase Natural Circulation Models | Emrit | NRR/DSI | II.E.2.2 | | 12/31/84 | NA |
| II.K.3(33) | Evaluate Elimination of PORV Function | Emrit | NRR | II.C.1 | | 12/31/84 | NA |
| II.K.3(34) | Relap-4 Model Development | Emrit | NRR/DSI | II.E.2.2 | | 12/31/84 | NA |
| II.K.3(35) | Evaluation of Effects of Core Flood Tank Injection on Small-Break LOCAs | Emrit | NRR | I.C.1(3) | | 12/31/84 | NA |
| II.K.3(36) | Additional Staff Audit Calculations of B&W Small-Break LOCA Analyses | Emrit | NRR | I.C.1(3) | | 12/31/84 | NA |

06/30/02

41

NUREG-0933

Revision 26

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------------|---|----------------------|-------------------------------------|-------------------------------|----------------|----------------------------|------------|
| II.K.3(37) | Analysis of B&W Response to Isolated Small-Break LOCA | Emrit | NRR | I.C.1(3) | | 12/31/84 | NA |
| II.K.3(38) | Analysis of Plant Response to a Small-Break LOCA in the Pressurizer Spray Line | Emrit | NRR | I.C.1(3) | | 12/31/84 | NA |
| II.K.3(39) | Evaluation of Effects of Water Slugs in Piping Caused by HPI and CFT Flows | Emrit | NRR | I.C.1(3) | | 12/31/84 | NA |
| II.K.3(40) | Evaluation of RCP Seal Damage and Leakage During a Small-Break LOCA | Emrit | NRR | II.K.2(16) | | 12/31/84 | NA |
| II.K.3(41) | Submit Predictions for LOFT Test L3-6 with RCPs Running | Emrit | NRR | I.C.1(3) | | 12/31/84 | NA |
| II.K.3(42) | Submit Requested Information on the Effects of Non-Condensable Gases | Emrit | NRR | I.C.1(3) | | 12/31/84 | NA |
| II.K.3(43) | Evaluation of Mechanical Effects of Slug Flow on Steam Generator Tubes | Emrit | NRR | II.K.2(15) | | 12/31/84 | NA |
| II.K.3(44) | Evaluation of Anticipated Transients with Single Failure to Verify No Significant Fuel Failure | Emrit | NRR | I | | 12/31/84 | F-59 |
| II.K.3(45) | Evaluate Depressurization with Other Than Full ADS | Emrit | NRR | I | | 12/31/84 | F-60 |
| II.K.3(46) | Response to List of Concerns from ACRS Consultant | Emrit | NRR | I | | 12/31/84 | F-61 |
| II.K.3(47) | Test Program for Small-Break LOCA Model Verification Pretest Prediction, Test Program, and Model Verification | Emrit | NRR | I.C.1(3), II.E.2.2 | | 12/31/84 | NA |
| II.K.3(48) | Assess Change in Safety Reliability as a Result of Implementing B&OTF Recommendations | Emrit | NRR | II.C.1, II.C.2 | | 12/31/84 | NA |
| II.K.3(49) | Review of Procedures (NRC) | Emrit | NRR/DHFS/PSRB | I.C.8, I.C.9 | | 12/31/84 | NA |
| II.K.3(50) | Review of Procedures (NSSS Vendors) | Emrit | NRR/DHFS/PSRB | I.C.7, I.C.9 | | 12/31/84 | NA |
| II.K.3(51) | Symptom-Based Emergency Procedures | Emrit | NRR/DHFS/PSRB | I.C.9 | | 12/31/84 | NA |
| II.K.3(52) | Operator Awareness of Revised Emergency Procedures | Emrit | NRR | I.B.1.1, I.C.2, I.C.5 | | 12/31/84 | NA |
| II.K.3(53) | Two Operators in Control Room | Emrit | NRR | I.A.1.3 | | 12/31/84 | NA |
| II.K.3(54) | Simulator Upgrade for Small-Break LOCAs | Emrit | NRR | I.A.4.1(2) | | 12/31/84 | NA |
| II.K.3(55) | Operator Monitoring of Control Board | Emrit | NRR | I.C.1(3), I.D.2, I.D.3 | | 12/31/84 | NA |
| II.K.3(56) | Simulator Training Requirements | Emrit | NRR/DHFS/OLB | I.A.2.6(3), I.A.3.1 | | 12/31/84 | NA |
| II.K.3(57) | Identify Water Sources Prior to Manual Activation of ADS | Emrit | NRR | I | | 12/31/84 | F-62 |

06/30/02

42

NUREG-0933

Revision 26

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------------|--|----------------------|-------------------------------------|-------------------------------|----------------|----------------------------|------------|
| <u>III.A</u> | <u>EMERGENCY PREPAREDNESS AND RADIATION EFFECTS</u> | | | | | | |
| <u>III.A.1</u> | <u>Improve Licensee Emergency Preparedness - Short-Term</u> | | | | | | |
| III.A.1.1 | Upgrade Emergency Preparedness | - | | - | | | |
| III.A.1.1(1) | Implement Action Plan Requirements for Promptly Improving Licensee Emergency Preparedness | - | OIE/DEPER/EPB I | | 2 | 06/30/91 | |
| III.A.1.1(2) | Perform an Integrated Assessment of the Implementation | - | OIE/DEPER/EPB | NOTE 3(b) | 2 | 06/30/91 | NA |
| III.A.1.2 | Upgrade Licensee Emergency Support Facilities | - | | - | 2 | 06/30/91 | |
| III.A.1.2(1) | Technical Support Center | - | OIE/DEPER/EPB | I | 2 | 06/30/91 | F-63 |
| III.A.1.2(2) | On-Site Operational Support Center | - | OIE/DEPER/EPB I | | 2 | 06/30/91 | F-64 |
| III.A.1.2(3) | Near-Site Emergency Operations Facility | - | OIE/DEPER/EPB I | | 2 | 06/30/91 | F-65 |
| III.A.1.3 | Maintain Supplies of Thyroid-Blocking Agent | - | | - | 2 | 06/30/91 | |
| III.A.1.3(1) | Workers | Riggs | OIE/DEPER/EPB | NOTE 3(b) | 2 | 06/30/91 | NA |
| III.A.1.3(2) | Public | Riggs | OIE/DEPER/EPB | NOTE 3(b) | 2 | 06/30/91 | NA |
| <u>III.A.2</u> | <u>Improving Licensee Emergency Preparedness - Long-Term</u> | | | | | | |
| III.A.2.1 | Amend 10 CFR 50 and 10 CFR 50, Appendix E | - | - | - | | | |
| III.A.2.1(1) | Publish Proposed Amendments to the Rules | - | RES | NOTE 3(a) | | 12/31/94 | NA |
| III.A.2.1(2) | Conduct Public Regional Meetings | - | RES | NOTE 3(b) | | 12/31/94 | NA |
| III.A.2.1(3) | Prepare Final Commission Paper Recommending Adoption of Rules | - | RES | NOTE 3(b) | | 12/31/94 | NA |
| III.A.2.1(4) | Revise Inspection Program to Cover Upgraded Requirements | - | OIE | I | | | F-67 |
| III.A.2.2 | Development of Guidance and Criteria | - | NRR/DL | I | | | F-68 |
| <u>III.A.3</u> | <u>Improving NRC Emergency Preparedness</u> | | | | | | |
| III.A.3.1 | NRC Role in Responding to Nuclear Emergencies | - | | - | | | |
| III.A.3.1(1) | Define NRC Role in Emergency Situations | Riggs | OIE/DEPER/IRDB | NOTE 3(b) | 1 | 06/30/85 | NA |
| III.A.3.1(2) | Revise and Upgrade Plans and Procedures for the NRC Emergency Operations Center | Riggs | OIE/DEPER/IRDB | NOTE 3(b) | 1 | 06/30/85 | NA |
| III.A.3.1(3) | Revise Manual Chapter 0502, Other Agency Procedures, and NUREG-0610 | Riggs | OIE/DEPER/IRDB | NOTE 3(b) | 1 | 06/30/85 | NA |
| III.A.3.1(4) | Prepare Commission Paper | Riggs | OIE/DEPER/IRDB | NOTE 3(b) | 1 | 06/30/85 | NA |
| III.A.3.1(5) | Revise Implementing Procedures and Instructions for Regional Offices | Riggs | OIE/DEPER/IRDB | NOTE 3(b) | 1 | 06/30/85 | NA |
| III.A.3.2 | Improve Operations Centers | Riggs | OIE/DEPER/IRDB | NOTE 3(b) | 1 | 06/30/85 | NA |
| III.A.3.3 | Communications | - | | - | | | |
| III.A.3.3(1) | Install Direct Dedicated Telephone Lines | Pittman | OIE/DEPER/IRDB | NOTE 3(a) | 1 | 06/30/85 | NA |
| III.A.3.3(2) | Obtain Dedicated, Short-Range Radio Communication Systems | Pittman | OIE/DEPER/IRDB | NOTE 3(a) | 1 | 06/30/85 | NA |

06/30/02

43

NUREG-0933

Revision 26

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|--------------------------------|---|-------------------|-------------------------------------|-------------------------------|----------------|----------------------------|------------|
| III.A.3.4 | Nuclear Data Link | Thatcher | OIE/DEPER/IRDB | NOTE 3(b) | 1 | 06/30/85 | |
| III.A.3.5 | Training, Drills, and Tests | Pittman | OIE/DEPER/IRDB | NOTE 3(b) | 1 | 06/30/85 | NA |
| III.A.3.6 | Interaction of NRC and Other Agencies | - | - | - | | | |
| III.A.3.6(1) | International | Pittman | OIE/DEPER/EPLB | NOTE 3(b) | 1 | 06/30/85 | NA |
| III.A.3.6(2) | Federal | Pittman | OIE/DEPER/EPLB | NOTE 3(b) | 1 | 06/30/85 | NA |
| III.A.3.6(3) | State and Local | Pittman | OIE/DEPER/EPLB | NOTE 3(b) | 1 | 06/30/85 | NA |
| <u>III.B</u> | <u>EMERGENCY PREPAREDNESS OF STATE AND LOCAL GOVERNMENTS</u> | | | | | | |
| III.B.1 | Transfer of Responsibilities to FEMA | Milstead | OIE/DEPER/IRDB | NOTE 3(b) | | 11/30/83 | NA |
| III.B.2 | Implementation of NRC and FEMA Responsibilities | - | - | - | | | |
| III.B.2(1) | The Licensing Process | Milstead | OIE/DEPER/IRDB | NOTE 3(b) | | 11/30/83 | NA |
| III.B.2(2) | Federal Guidance | Milstead | OIE/DEPER/IRDB | NOTE 3(b) | | 11/30/83 | NA |
| <u>III.C</u> | <u>PUBLIC INFORMATION</u> | | | | | | |
| III.C.1 | Have Information Available for the News Media and the Public | - | - | - | | | |
| III.C.1(1) | Review Publicly Available Documents | Pittman | PA | LI (NOTE 3) | | 11/30/83 | NA |
| III.C.1(2) | Recommend Publication of Additional Information | Pittman | PA | LI (NOTE 3) | | 11/30/83 | NA |
| III.C.1(3) | Program of Seminars for News Media Personnel | Pittman | PA | LI (NOTE 3) | | 11/30/83 | NA |
| III.C.2 | Develop Policy and Provide Training for Interfacing With the News Media | - | - | - | | | |
| III.C.2(1) | Develop Policy and Procedures for Dealing With Briefing Requests | Pittman | PA | LI (NOTE 3) | | 11/30/83 | NA |
| III.C.2(2) | Provide Training for Members of the Technical Staff | Pittman | PA | LI (NOTE 3) | | 11/30/83 | NA |
| <u>III.D</u> | <u>RADIATION PROTECTION</u> | | | | | | |
| <u>III.D.1</u> | <u>Radiation Source Control</u> | | | | | | |
| III.D.1.1 | Primary Coolant Sources Outside the Containment Structure | - | - | - | | | |
| III.D.1.1(1) | Review Information Submitted by Licensees Pertaining to Reducing Leakage from Operating Systems | - | NRR | I | 1 | 12/31/88 | |
| III.D.1.1(2) | Review Information on Provisions for Leak Detection | Emrit | RES/DRA/ARGIB | DROP | 1 | 12/31/88 | |
| III.D.1.1(3) | Develop Proposed System Acceptance Criteria | Emrit | RES/DRA/ARGIB | DROP | 1 | 12/31/88 | |
| III.D.1.2 | Radioactive Gas Management | Emrit | NRR/DSI/METB | DROP | 1 | 12/31/88 | NA |
| III.D.1.3 | Ventilation System and Radioiodine Adsorber Criteria | - | - | - | | | |
| III.D.1.3(1) | Decide Whether Licensees Should Perform Studies and Make Modifications | Emrit | NRR/DSI/METB | DROP | 1 | 12/31/88 | NA |

06/30/02

44

NUREG-0933

Revision 26

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------------|--|----------------------|-------------------------------------|-------------------------------|----------------|----------------------------|------------|
| III.D.1.3(2) | Review and Revise SRP | Emrit | NRR/DSI/METB | DROP | 1 | 12/31/88 | NA |
| III.D.1.3(3) | Require Licensees to Upgrade Filtration Systems | Emrit | NRR/DSI/METB | DROP | 1 | 12/31/88 | NA |
| III.D.1.3(4) | Sponsor Studies to Evaluate Charcoal Adsorber | Emrit | NRR/DSI/METB | NOTE 3(b) | 1 | 12/31/88 | NA |
| III.D.1.4 | Radwaste System Design Features to Aid in Accident Recovery and Decontamination | Emrit | NRR/DSI/METB | DROP | 1 | 12/31/88 | NA |
| <u>III.D.2</u> | <u>Public Radiation Protection Improvement</u> | | | | | | |
| III.D.2.1 | Radiological Monitoring of Effluents | - | - | - | | | |
| III.D.2.1(1) | Evaluate the Feasibility and Perform a Value-Impact Analysis of Modifying Effluent-Monitoring Design Criteria | Emrit | NRR/DSI/METB | LOW | 3 | 12/31/98 | NA |
| III.D.2.1(2) | Study the Feasibility of Requiring the Development of Effective Means for Monitoring and Sampling Noble Gases and Radioiodine Released to the Atmosphere | Emrit | NRR/DSI/METB | LOW | 3 | 12/31/98 | NA |
| III.D.2.1(3) | Revise Regulatory Guides | Emrit | NRR/DSI/METB | LOW | 3 | 12/31/98 | NA |
| III.D.2.2 | Radioiodine, Carbon-14, and Tritium Pathway Dose Analysis | - | - | - | | | |
| III.D.2.2(1) | Perform Study of Radioiodine, Carbon-14, and Tritium Behavior | Emrit | NRR/DSI/RAB | NOTE 3(b) | 3 | 12/31/98 | NA |
| III.D.2.2(2) | Evaluate Data Collected at Quad Cities | Emrit | NRR/DSI/RAB | III.D.2.5 | 3 | 12/31/98 | NA |
| III.D.2.2(3) | Determine the Distribution of the Chemical Species of Radioiodine in Air-Water-Steam Mixtures | Emrit | NRR/DSI/RAB | III.D.2.5 | 3 | 12/31/98 | NA |
| III.D.2.2(4) | Revise SRP and Regulatory Guides | Emrit | NRR/DSI/RAB | III.D.2.5 | 3 | 12/31/98 | NA |
| III.D.2.3 | Liquid Pathway Radiological Control | - | - | - | | | |
| III.D.2.3(1) | Develop Procedures to Discriminate Between Sites/Plants | Emrit | NRR/DE/EHEB | NOTE 3(b) | 3 | 12/31/98 | NA |
| III.D.2.3(2) | Discriminate Between Sites and Plants That Require Consideration of Liquid Pathway Interdiction Techniques | Emrit | NRR/DE/EHEB | NOTE 3(b) | 3 | 12/31/98 | NA |
| III.D.2.3(3) | Establish Feasible Method of Pathway Interdiction | Emrit | NRR/DE/EHEB | NOTE 3(b) | 3 | 12/31/98 | NA |
| III.D.2.3(4) | Prepare a Summary Assessment | Emrit | NRR/DE/EHEB | NOTE 3(b) | 3 | 12/31/98 | NA |
| III.D.2.4 | Offsite Dose Measurements | - | - | - | | | |
| III.D.2.4(1) | Study Feasibility of Environmental Monitors | Vandermolen | NRR/DSI/RAB | NOTE 3(b) | 3 | 12/31/98 | NA |
| III.D.2.4(2) | Place 50 TLDs Around Each Site | Vandermolen | OIE/DRP/ORPB | LI (NOTE 3) | 3 | 12/31/98 | NA |
| III.D.2.5 | Offsite Dose Calculation Manual | Vandermolen | NRR/DSI/RAB | NOTE 3(b) | 3 | 12/31/98 | NA |
| III.D.2.6 | Independent Radiological Measurements | Vandermolen | OIE/DRP/ORPB | LI (NOTE 3) | 3 | 12/31/98 | NA |
| <u>III.D.3</u> | <u>Worker Radiation Protection Improvement</u> | | | | | | |
| III.D.3.1 | Radiation Protection Plans | Vandermolen | NRR/DSI/RAB | NOTE 3(b) | 3 | 12/31/87 | NA |
| III.D.3.2 | Health Physics Improvements | - | - | - | | | |
| III.D.3.2(1) | Amend 10 CFR 20 | Vandermolen | RES/DFO/ORPBR | LI (NOTE 3) | 3 | 12/31/87 | NA |
| III.D.3.2(2) | Issue a Regulatory Guide | Vandermolen | RES/DFO/ORPBR | LI (NOTE 3) | 3 | 12/31/87 | NA |

06/30/02

45

NUREG-0933

Revision 26

06/30/02

46

NUREG-0933

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------------|--|----------------------|-------------------------------------|-------------------------------|----------------|----------------------------|------------|
| III.D.3.2(3) | Develop Standard Performance Criteria | Vandermolen | RES/DFO/ORPBR | LI (NOTE 3) | 3 | 12/31/87 | NA |
| III.D.3.2(4) | Develop Method for Testing and Certifying Air-Purifying Respirators | Vandermolen | RES/DFO/ORPBR | LI (NOTE 3) | 3 | 12/31/87 | NA |
| III.D.3.3 | In-plant Radiation Monitoring | - | - | - | | | |
| III.D.3.3(1) | Issue Letter Requiring Improved Radiation Sampling Instrumentation | - | NRR/DL | I | 2 | 12/31/86 | F-69 |
| III.D.3.3(2) | Set Criteria Requiring Licensees to Evaluate Need for Additional Survey Equipment | - | NRR | NOTE 3(a) | 2 | 12/31/86 | NA |
| III.D.3.3(3) | Issue a Rule Change Providing Acceptable Methods for Calibration of Radiation-Monitoring Instruments | - | RES | NOTE 3(a) | 2 | 12/31/86 | NA |
| III.D.3.3(4) | Issue a Regulatory Guide | - | RES | NOTE 3(a) | 2 | 12/31/86 | NA |
| III.D.3.4 | Control Room Habitability | - | NRR/DL | I | 2 | 12/31/86 | F-70 |
| III.D.3.5 | Radiation Worker Exposure | - | - | - | | | |
| III.D.3.5(1) | Develop Format for Data To Be Collected by Utilities Regarding Total Radiation Exposure to Workers | Vandermolen | DFO/ORPBR | LI (NOTE 3) | 2 | 12/31/86 | NA |
| III.D.3.5(2) | Investigative Methods of Obtaining Employee Health Data by Nonlegislative Means | Vandermolen | DFO/ORPBR | LI (NOTE 3) | 2 | 12/31/86 | NA |
| III.D.3.5(3) | Revise 10 CFR 20 | Vandermolen | DFO/ORPBR | LI (NOTE 3) | 2 | 12/31/86 | NA |
| <u>IV.A</u> | <u>STRENGTHEN ENFORCEMENT PROCESS</u> | | | | | | |
| IV.A.1 | Seek Legislative Authority | Emrit | GC | LI (NOTE 3) | | 11/30/83 | NA |
| IV.A.2 | Revise Enforcement Policy | Emrit | OIE/ES | LI (NOTE 3) | | 11/30/83 | NA |
| <u>IV.B</u> | <u>ISSUANCE OF INSTRUCTIONS AND INFORMATION TO LICENSEES</u> | | | | | | |
| IV.B.1 | Revise Practices for Issuance of Instructions and Information to Licensees | Emrit | OIE/DEPER | LI (NOTE 3) | | 11/30/83 | NA |
| <u>IV.C</u> | <u>EXTEND LESSONS LEARNED TO LICENSED ACTIVITIES OTHER THAN POWER REACTORS</u> | | | | | | |
| IV.C.1 | Extend Lessons Learned from TMI to Other NRC Programs | Emrit | NMSS/WM | NOTE 3(b) | | 11/30/83 | NA |
| <u>IV.D</u> | <u>NRC STAFF TRAINING</u> | | | | | | |
| IV.D.1 | NRC Staff Training | Emrit | ADM/MDTS | LI (NOTE 3) | | 11/30/83 | NA |

Revision 26

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------------|---|----------------------|-------------------------------------|-------------------------------|----------------|----------------------------|------------|
| <u>IV.E</u> | <u>SAFETY DECISION-MAKING</u> | | | | | | |
| IV.E.1 | Expand Research on Quantification of Safety Decision-Making | Colmar | RES/DRA/RABR | LI (NOTE 3) | 2 | 12/31/86 | NA |
| IV.E.2 | Plan for Early Resolution of Safety Issues | Emrit | NRR/DST/SPEB | LI (NOTE 3) | 2 | 12/31/86 | NA |
| IV.E.3 | Plan for Resolving Issues at the CP Stage | Colmar | RES/DRA/RABR | LI (NOTE 5) | 2 | 12/31/86 | NA |
| IV.E.4 | Resolve Generic Issues by Rulemaking | Colmar | RES/DRA/RABR | LI (NOTE 3) | 2 | 12/31/86 | NA |
| IV.E.5 | Assess Currently Operating Reactors | Matthews | NRR/DL/SEPB | NOTE 3(b) | 2 | 12/31/86 | NA |
| <u>IV.F</u> | <u>FINANCIAL DISINCENTIVES TO SAFETY</u> | | | | | | |
| IV.F.1 | Increased OIE Scrutiny of the Power-Ascension Test Program | Thatcher | OIE/DQASIP | NOTE 3(b) | 1 | 12/31/86 | NA |
| IV.F.2 | Evaluate the Impacts of Financial Disincentives to the Safety of Nuclear Power Plants | Matthews | SP | NOTE 3(b) | 1 | 12/31/86 | NA |
| <u>IV.G</u> | <u>IMPROVE SAFETY RULEMAKING PROCEDURES</u> | | | | | | |
| IV.G.1 | Develop a Public Agenda for Rulemaking | Emrit | ADM/RPB | LI (NOTE 3) | 1 | 12/31/86 | NA |
| IV.G.2 | Periodic and Systematic Reevaluation of Existing Rules | Milstead | RES/DRA/RABR | LI (NOTE 3) | 1 | 12/31/86 | NA |
| IV.G.3 | Improve Rulemaking Procedures | Milstead | RES/DRA/RABR | LI (NOTE 3) | 1 | 12/31/86 | NA |
| IV.G.4 | Study Alternatives for Improved Rulemaking Process | Milstead | RES/DRA/RABR | LI (NOTE 3) | 1 | 12/31/86 | NA |
| <u>IV.H</u> | <u>NRC PARTICIPATION IN THE RADIATION POLICY COUNCIL</u> | | | | | | |
| IV.H.1 | NRC Participation in the Radiation Policy Council | Sege | RES/DHSWM/HEBR | LI (NOTE 3) | | 11/30/83 | NA |
| <u>V.A</u> | <u>DEVELOPMENT OF SAFETY POLICY</u> | | | | | | |
| V.A.1 | Develop NRC Policy Statement on Safety | Emrit | GC | LI (NOTE 3) | | 12/31/86 | NA |
| <u>V.B</u> | <u>POSSIBLE ELIMINATION OF NONSAFETY RESPONSIBILITIES</u> | | | | | | |
| V.B.1 | Study and Recommend, as Appropriate, Elimination of Nonsafety Responsibilities | Emrit | GC | LI (NOTE 3) | | 12/31/86 | NA |

06/30/02

47

NUREG-0933

Revision 26

06/30/02

48

NUREG-0933

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|--------------------------------|--|-------------------|-------------------------------------|-------------------------|-------------|----------------------|---------|
| <u>V.C</u> | <u>ADVISORY COMMITTEES</u> | | | | | | |
| V.C.1 | Strengthen the Role of Advisory Committee on Reactor Safeguards | Emrit | GC | LI (NOTE 3) | | 12/31/86 | NA |
| V.C.2 | Study Need for Additional Advisory Committees | Emrit | GC | LI (NOTE 3) | | 12/31/86 | NA |
| V.C.3 | Study the Need to Establish an Independent Nuclear Safety Board | Emrit | GC | LI (NOTE 3) | | 12/31/86 | NA |
| <u>V.D</u> | <u>LICENSING PROCESS</u> | | | | | | |
| V.D.1 | Improve Public and Intervenor Participation in the Hearing Process | Emrit | GC | LI (NOTE 3) | | 12/31/86 | NA |
| V.D.2 | Study Construction-During-Adjudication Rules | Emrit | GC | LI (NOTE 5) | | 12/31/86 | NA |
| V.D.3 | Reexamine Commission Role in Adjudication | Emrit | GC | LI (NOTE 5) | | 12/31/86 | NA |
| V.D.4 | Study the Reform of the Licensing Process | Emrit | GC | LI (NOTE 5) | | 12/31/86 | NA |
| <u>V.E</u> | <u>LEGISLATIVE NEEDS</u> | | | | | | |
| V.E.1 | Study the Need for TMI-Related Legislation | Emrit | GC | LI (NOTE 5) | | 12/31/86 | NA |
| <u>V.F</u> | <u>ORGANIZATION AND MANAGEMENT</u> | | | | | | |
| V.F.1 | Study NRC Top Management Structure and Process | Emrit | GC | LI (NOTE 3) | | 12/31/86 | NA |
| V.F.2 | Reexamine Organization and Functions of the NRC Offices | Emrit | GC | LI (NOTE 3) | | 12/31/86 | NA |
| V.F.3 | Revise Delegations of Authority to Staff | Emrit | GC | LI (NOTE 3) | | 12/31/86 | NA |
| V.F.4 | Clarify and Strengthen the Respective Roles of Chairman, Commission, and Executive Director for Operations | Emrit | GC | LI (NOTE 3) | | 12/31/86 | NA |
| V.F.5 | Authority to Delegate Emergency Response Functions to a Single Commissioner | Emrit | GC | LI (NOTE 3) | | 12/31/86 | NA |
| <u>V.G</u> | <u>CONSOLIDATION OF NRC LOCATIONS</u> | | | | | | |
| V.G.1 | Achieve Single Location, Long-Term | Emrit | GC | LI (NOTE 3) | | 12/31/86 | NA |
| V.G.2 | Achieve Single Location, Interim | Emrit | GC | LI (NOTE 3) | | 12/31/86 | NA |
| <u>TASK ACTION PLAN ITEMS</u> | | | | | | | |
| A-1 | Water Hammer (former USI) | Emrit | NR/DST/GIB | NOTE 3(a) | 1 | 06/30/85 | NA |
| A-2 | Asymmetric Blowdown Loads on Reactor Primary Coolant Systems (former USI) | Emrit | NR/DST/GIB | NOTE 3(a) | 1 | 06/30/85 | D-10 |

Revision 26

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------|--|-------------------|-------------------------------|-------------------------|-------------|----------------------|------------|
| A-3 | Westinghouse Steam Generator Tube Integrity (former USI) | Emrit | NRR/DEST/EMTB | NOTE 3(a) | 1 | 12/31/88 | |
| A-4 | CE Steam Generator Tube Integrity (former USI) | Emrit | NRR/DEST/EMTB | NOTE 3(a) | 1 | 12/31/88 | |
| A-5 | B&W Steam Generator Tube Integrity (former USI) | Emrit | NRR/DEST/EMTB | NOTE 3(a) | 1 | 12/31/88 | |
| A-6 | Mark I Short-Term Program (former USI) | Emrit | NRR/DST/GIB | NOTE 3(a) | 1 | 06/30/85 | |
| A-7 | Mark I Long-Term Program (former USI) | Emrit | NRR/DST/GIB | NOTE 3(a) | 1 | 06/30/85 | D-01 |
| A-8 | Mark II Containment Pool Dynamic Loads Long-Term Program (former USI) | Emrit | NRR/DST/GIB | NOTE 3(a) | 1 | 06/30/85 | NA |
| A-9 | ATWS (former USI) | Emrit | NRR/DST/GIB | NOTE 3(a) | 1 | 06/30/85 | |
| A-10 | BWR Feedwater Nozzle Cracking (former USI) | Emrit | NRR/DST/GIB | NOTE 3(a) | 1 | 06/30/85 | B-25 |
| A-11 | Reactor Vessel Materials Toughness (former USI) | Emrit | NRR/DST/GIB | NOTE 3(a) | 1 | 06/30/85 | |
| A-12 | Fracture Toughness of Steam Generator and Reactor Coolant Pump Supports (former USI) | Emrit | NRR/DST/GIB | NOTE 3(a) | 1 | 06/30/85 | NA |
| A-13 | Snubber Operability Assurance | Emrit | NRR/DE/MEB | NOTE 3(a) | 1 | 06/30/91 | B-17, B-22 |
| A-14 | Flaw Detection | Matthews | NRR/DE/MTEB | DROP | | 11/30/83 | NA |
| A-15 | Primary Coolant System Decontamination and Steam Generator Chemical Cleaning | Pittman | NRR/DE/CHEB | NOTE 3(b) | | 11/30/83 | NA |
| A-16 | Steam Effects on BWR Core Spray Distribution | Emrit | NRR/DSI/CPB | NOTE 3(a) | | 11/30/83 | D-12 |
| A-17 | Systems Interactions in Nuclear Power Plants (former USI) | Emrit | RES/DSIR/EIB | NOTE 3(b) | 1 | 12/31/89 | NA |
| A-18 | Pipe Rupture Design Criteria | Emrit | NRR/DE/MEB | DROP | | 11/30/83 | NA |
| A-19 | Digital Computer Protection System | Milstead | RES/DSR/HFB | LI (NOTE 5) | 1 | 06/30/91 | NA |
| A-20 | Impacts of the Coal Fuel Cycle | - | NRR/DE/EHEB | LI (NOTE 5) | | 11/30/83 | NA |
| A-21 | Main Steamline Break Inside Containment - Evaluation of Environmental Conditions for Equipment Qualification | Vandermolen | NRR/DSI/CSB | DROP | 1 | 12/31/98 | NA |
| A-22 | PWR Main Steamline Break - Core, Reactor Vessel and Containment Building Response | V.Molen | NRR/DSI/CSB | DROP | | 11/30/83 | NA |
| A-23 | Containment Leak Testing | Matthews | NRR/DSI/CSB | RI (NOTE 5) | | 11/30/83 | |
| A-24 | Qualification of Class 1E Safety-Related Equipment (former USI) | Emrit | NRR/DST/GIB | NOTE 3(a) | 1 | 06/30/85 | B-60 |
| A-25 | Non-Safety Loads on Class 1E Power Sources | Thatcher | NRR/DSI/PSB | NOTE 3(a) | | 11/30/83 | |
| A-26 | Reactor Vessel Pressure Transient Protection (former USI) | Emrit | NRR/DST/GIB | NOTE 3(a) | 1 | 06/30/85 | B-04 |
| A-27 | Reload Applications | - | NRR/DSI/CPB | LI (NOTE 5) | | 11/30/83 | NA |
| A-28 | Increase in Spent Fuel Pool Storage Capacity | Colmar | NRR/DE/SGEB | NOTE 3(a) | | 11/30/83 | |
| A-29 | Nuclear Power Plant Design for the Reduction of Vulnerability to Industrial Sabotage | Colmar | RES/DRPS/RPSI | NOTE 3(b) | 1 | 12/31/89 | NA |
| A-30 | Adequacy of Safety-Related DC Power Supplies | Sege | NRR/DSI/PSB | 128 | 1 | 12/31/86 | NA |
| A-31 | RHR Shutdown Requirements (former USI) | Emrit | NRR/DST/GIB | NOTE 3(a) | 1 | 06/30/85 | |
| A-32 | Missile Effects | Pittman | NRR/DE/MTEB | A-37, A-38, B-68 | | 11/30/83 | NA |

06/30/02

49

NUREG-0933

Revision 26

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------|---|-------------------|-------------------------------|-------------------------|-------------|----------------------|------------|
| A-33 | NEPA Review of Accident Risks | - | NRR/DSI/AEB | EI(NOTE 3) | | 11/30/83 | NA |
| A-34 | Instruments for Monitoring Radiation and Process Variables During Accidents | V'Molen | NRR/DSI/ICSB | II.F.3 | | 11/30/83 | NA |
| A-35 | Adequacy of Offsite Power Systems | Emrit | NRR/DSI/PSB | NOTE 3(a) | 1 | 12/31/94 | B-23 |
| A-36 | Control of Heavy Loads Near Spent Fuel (former USI) | Emrit | NRR/DSI/GIB | NOTE 3(a) | 1 | 06/30/85 | C-10, C-15 |
| A-37 | Turbine Missiles | Pittman | NRR/DE/MTEB | DROP | | 11/30/83 | NA |
| A-38 | Tornado Missiles | Sege | NRR/DSI/ASB | DROP | 3 | 06/30/00 | NA |
| A-39 | Determination of Safety Relief Valve Pool Dynamic Loads and Temperature Limits (former USI) | Emrit | NRR/DST/GIB | NOTE 3(a) | 1 | 06/30/85 | |
| A-40 | Seismic Design Criteria (former USI) | Emrit | RES/DSIR/EIB | NOTE 3(a) | 1 | 12/31/89 | NA |
| A-41 | Long-Term Seismic Program | Colmar | NRR/DE/MEB | NOTE 3(b) | 1 | 12/31/84 | NA |
| A-42 | Pipe Cracks in Boiling Water Reactors (former USI) | Emrit | NRR/DST/GIB | NOTE 3(a) | 1 | 06/30/85 | B-05 |
| A-43 | Containment Emergency Sump Performance (former USI) | Emrit | NRR/DST/GIB | NOTE 3(a) | 1 | 12/31/87 | |
| A-44 | Station Blackout (former USI) | Emrit | RES/DRPS/RPSI | NOTE 3(a) | 1 | 06/30/88 | |
| A-45 | Shutdown Decay Heat Removal Requirements (former USI) | Emrit | RES/DRPS/RPSI | NOTE 3(b) | 1 | 12/31/88 | NA |
| A-46 | Seismic Qualification of Equipment in Operating Plants (former USI) | Emrit | NRR/DSRO/EIB | NOTE 3(a) | 2 | 06/30/00 | |
| A-47 | Safety Implications of Control Systems (former USI) | Emrit | RES/DSIR/EIB | NOTE 3(a) | 1 | 12/31/89 | |
| A-48 | Hydrogen Control Measures and Effects of Hydrogen Burns on Safety Equipment | Emrit | NRR/DSIR/SAIB | NOTE 3(a) | 1 | 06/30/89 | |
| A-49 | Pressurized Thermal Shock (former USI) | Emrit | NRR/DSRO/RSIB | NOTE 3(a) | 1 | 12/31/87 | A-21 |
| B-1 | Environmental Technical Specifications | - | NRR/DE/EHEB | EI (NOTE 3) | | 11/30/83 | NA |
| B-2 | Forecasting Electricity Demand | - | NRR | EI (NOTE 3) | | 11/30/83 | NA |
| B-3 | Event Categorization | - | NRR/DSI/RSB | LI (NOTE 3) | | 11/30/83 | NA |
| B-4 | ECCS Reliability | Emrit | NRR/DSI/RSB | II.E.3.2 | | 11/30/83 | NA |
| B-5 | Ductility of Two-Way Slabs and Shells and Buckling Behavior of Steel Containments | Thatcher | RES/DE/EIB | NOTE 3(b) | 1 | 06/30/88 | NA |
| B-6 | Loads, Load Combinations, Stress Limits | Pittman | NRR/DSRO/EIB | 119.1 | | 12/31/87 | NA |
| B-7 | Secondary Accident Consequence Modeling | - | NRR/DSI/AEB | LI (NOTE 3) | | 11/30/83 | NA |
| B-8 | Locking Out of ECCS Power Operated Valves | Riggs | NRR/DSI/RSB | DROP | 1 | 12/31/94 | NA |
| B-9 | Electrical Cable Penetrations of Containment | Emrit | NRR/DSI/PSB | NOTE 3(b) | | 11/30/83 | NA |
| B-10 | Behavior of BWR Mark III Containments | Vandermolen | NRR/DSI/CSB | NOTE 3(a) | 1 | 12/31/84 | NA |
| B-11 | Subcompartment Standard Problems | - | NRR/DSI/CSB | LI (NOTE 5) | | 11/30/83 | NA |
| B-12 | Containment Cooling Requirements (Non-LOCA) | Emrit | NRR/DSI/CSB | NOTE 3(b) | 1 | 12/31/86 | NA |
| B-13 | Marviken Test Data Evaluation | - | NRR/DSI/CSB | LI (NOTE 5) | | 11/30/83 | NA |
| B-14 | Study of Hydrogen Mixing Capability in Containment Post-LOCA | Emrit | NRR/DST/GIB | A-48 | | 11/30/83 | NA |
| B-15 | CONTEMPT Computer Code Maintenance | - | NRR/DSI/CSB | LI (NOTE 3) | | 11/30/83 | NA |
| B-16 | Protection Against Postulated Piping Failures in Fluid Systems Outside Containment | Emrit | NRR/DE/MEB | A-18 | | 11/30/83 | NA |

06/30/02

50

NUREG-0933

Revision 26

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------------|--|----------------------|-------------------------------------|-------------------------------|----------------|----------------------------|------------|
| B-17 | Criteria for Safety-Related Operator Actions | Milstead | RES/DST/CIHFB | NOTE 3(b) | 3 | 06/30/00 | |
| B-18 | Vortex Suppression Requirements for Containment Sumps | Emrit | NRR/DST/GIB | A-43 | | 11/30/83 | NA |
| B-19 | Thermal-Hydraulic Stability | Colmar | NRR/DSI/CPB | NOTE 3(b) | | 06/30/85 | NA |
| B-20 | Standard Problem Analysis | - | RES/DAE/AMBR | LI (NOTE 5) | | 11/30/83 | |
| B-21 | Core Physics | - | NRR/DSI/CPB | LI (NOTE 3) | | 11/30/83 | NA |
| B-22 | LWR Fuel | Emrit | RES/DSIR/RPSIB | DROP | 2 | 06/30/95 | NA |
| B-23 | LMFBR Fuel | - | NRR/DSI/CPB | LI (NOTE 3) | | 11/30/83 | NA |
| B-24 | Seismic Qualification of Electrical and Mechanical Equipment | Emrit | NRR | A-46 | | 11/30/83 | NA |
| B-25 | Piping Benchmark Problems | - | NRR/DE/MEB | LI (NOTE 5) | | 11/30/83 | |
| B-26 | Structural Integrity of Containment Penetrations | Riggs | NRR/DE/MTEB | NOTE 3(b) | 1 | 12/31/84 | NA |
| B-27 | Implementation and Use of Subsection NF | - | NRR/DE/MEB | LI (NOTE 5) | | 11/30/83 | |
| B-28 | Radionuclide/Sediment Transport Program | - | NRR/DE/EHEB | EI (NOTE 3) | | 11/30/83 | NA |
| B-29 | Effectiveness of Ultimate Heat Sinks | Pittman | NRR/DE/EHEB | LI (NOTE 3) | 1 | 06/30/91 | NA |
| B-30 | Design Basis Floods and Probability | - | NRR/DE/EHEB | LI (NOTE 5) | | 11/30/83 | |
| B-31 | Dam Failure Model | Milstead | NRR/DE/SGEB | LI (NOTE 3) | 1 | 06/30/89 | NA |
| B-32 | Ice Effects on Safety-Related Water Supplies | Pittman | NRR/DE/EHEB | 153 | 1 | 06/30/91 | NA |
| B-33 | Dose Assessment Methodology | - | NRR/DSI/RAB | LI (NOTE 3) | | 11/30/83 | NA |
| B-34 | Occupational Radiation Exposure Reduction | Emrit | NRR/DSI/RAB | III.D.3.1 | | 11/30/83 | NA |
| B-35 | Confirmation of Appendix I Models for Calculations of Releases of Radioactive Materials in Gaseous and Liquid Effluents from Light Water Cooled Power Reactors | - | NRR/DSI/METB | LI (NOTE 5) | | 11/30/83 | |
| B-36 | Develop Design, Testing, and Maintenance Criteria for Atmosphere Cleanup System Air Filtration and Adsorption Units for Engineered Safety Feature Systems and for Normal Ventilation Systems | Emrit | NRR/DSI/METB | NOTE 3(a) | | 11/30/83 | |
| B-37 | Chemical Discharges to Receiving Waters | - | NRR/DE/EHEB | EI (NOTE 5) | | 11/30/83 | |
| B-38 | Reconnaissance Level Investigations | - | NRR/DE/EHEB | EI (NOTE 3) | | 11/30/83 | NA |
| B-39 | Transmission Lines | - | NRR/DE/EHEB | EI (NOTE 3) | | 11/30/83 | NA |
| B-40 | Effects of Power Plant Entrainment on Plankton | - | NRR/DE/EHEB | EI (NOTE 3) | | 11/30/83 | NA |
| B-41 | Impacts on Fisheries | - | NRR/DE/EHEB | EI (NOTE 3) | | 11/30/83 | NA |
| B-42 | Socioeconomic Environmental Impacts | - | NRR/DE/SAB | EI (NOTE 3) | | 11/30/83 | NA |
| B-43 | Value of Aerial Photographs for Site Evaluation | - | NRR/DE/EHEB | EI (NOTE 5) | | 11/30/83 | |
| B-44 | Forecasts of Generating Costs of Coal and Nuclear Plants | - | NRR/DE/SAB | EI (NOTE 3) | | 11/30/83 | NA |
| B-45 | Need for Power - Energy Conservation | - | NRR/DE/SAB | EI (NOTE 3) | | 11/30/83 | NA |
| B-46 | Cost of Alternatives in Environmental Design | - | NRR/DE/SAB | EI (NOTE 3) | | 11/30/83 | NA |
| B-47 | Inservice Inspection of Supports - Classes 1, 2, 3, and MC Components | Colmar | NRR/DE/MTEB | DROP | | 11/30/83 | NA |
| B-48 | BWR Control Rod Drive Mechanical Failures | Emrit | NRR/DE/MTEB | NOTE 3(b) | | 11/30/83 | |
| B-49 | Inservice Inspection Criteria and Corrosion Prevention Criteria for Containments | - | NRR | LI (NOTE 5) | | 11/30/83 | |

06/30/02

51

NUREG-0933

Revision 26

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------------|--|----------------------|-------------------------------------|-------------------------------|----------------|----------------------------|------------|
| B-50 | Post-Operating Basis Earthquake Inspection | Colmar | NRR/DE/SGEB | RI (NOTE 3) | 1 | 06/30/85 | NA |
| B-51 | Assessment of Inelastic Analysis Techniques for Equipment and Components | Emrit | NRR/DE/MEB | A-40 | | 11/30/83 | NA |
| B-52 | Fuel Assembly Seismic and LOCA Responses | Emrit | NRR/DST/GIB | A-2 | | 11/30/83 | NA |
| B-53 | Load Break Switch | Sege | NRR/DSI/PSB | RI (NOTE 3) | | 11/30/83 | |
| B-54 | Ice Condenser Containments | Milstead | NRR/DSI/CSB | NOTE 3(b) | 1 | 12/31/84 | NA |
| B-55 | Improved Reliability of Target Rock Safety Relief Valves | Vandermolen | NRR/DE/EMEB | NOTE 3(b) | 1 | 06/30/00 | |
| B-56 | Diesel Reliability | Milstead | RES/DRPS/RPSI | NOTE 3(a) | 2 | 06/30/95 | D-19 |
| B-57 | Station Blackout | Emrit | NRR/DST/GIB | A-44 | | 11/30/83 | |
| B-58 | Passive Mechanical Failures | Colmar | NRR/DE/EQB | NOTE 3(b) | 1 | 12/31/85 | NA |
| B-59 | (N-1) Loop Operation in BWRs and PWRs | Colmar | NRR/DSI/RSB | RI (NOTE 3) | 1 | 06/30/85 | E-04,E-05 |
| B-60 | Loose Parts Monitoring Systems | Emrit | NRR/DSI/CPB | NOTE 3(b) | 1 | 12/31/84 | NA |
| B-61 | Allowable ECCS Equipment Outage Periods | Pittman | RES/DST/PRAB | NOTE 3(b) | 1 | 06/30/00 | |
| B-62 | Reexamination of Technical Bases for Establishing SLs, LSSs, and Reactor Protection System Trip Functions | - | NRR/DSI/CPB | LI (NOTE 3) | | 11/30/83 | NA |
| B-63 | Isolation of Low Pressure Systems Connected to the Reactor Coolant Pressure Boundary | Emrit | NRR/DE/MEB | NOTE 3(a) | | 11/30/83 | B-45 |
| B-64 | Decommissioning of Reactors | Colmar | RES/DE/MEB | NOTE 3(a) | 2 | 06/30/95 | NA |
| B-65 | Iodine Spiking | Milstead | NRR/DSI/AEB | DROP | 2 | 12/31/84 | NA |
| B-66 | Control Room Infiltration Measurements | Mathews | NRR/DSI/AEB | NOTE 3(a) | | 11/30/83 | |
| B-67 | Effluent and Process Monitoring Instrumentation | Colmar | NRR/DSI/METB | III.D.2.1 | | 11/30/83 | NA |
| B-68 | Pump Overspeed During LOCA | Riani | NRR/DSI/ASB | DROP | | 11/30/83 | NA |
| B-69 | ECCS Leakage Ex-Containment | Riani | NRR/DSI/METB | III.D.1.1(1) | | 11/30/83 | NA |
| B-70 | Power Grid Frequency Degradation and Effect on Primary Coolant Pumps | Emrit | NRR/DSI/PSB | NOTE 3(b) | | 11/30/83 | |
| B-71 | Incident Response | Riani | NRR | III.A.3.1 | | 11/30/83 | NA |
| B-72 | Health Effects and Life Shortening from Uranium and - Coal Fuel Cycles | | NRR/DSI/RAB | LI (NOTE 5) | | 11/30/83 | NA |
| B-73 | Monitoring for Excessive Vibration Inside the Reactor Pressure Vessel | Thatcher | NRR/DE/MEB | C-12 | | 11/30/83 | NA |
| C-1 | Assurance of Continuous Long Term Capability of Hermetic Seals on Instrumentation and Electrical Equipment | Milstead | NRR/DE/EQB | NOTE 3(a) | | 11/30/83 | |
| C-2 | Study of Containment Depressurization by Inadvertent Spray Operation to Determine Adequacy of Containment External Design Pressure | Emrit | NRR/DSI/CSB | NOTE 3(b) | | 11/30/83 | NA |
| C-3 | Insulation Usage Within Containment | Emrit | NRR/DST/GIB | A-43 | 1 | 06/30/91 | NA |
| C-4 | Statistical Methods for ECCS Analysis | Riggs | NRR/DSRO/SPEB | RI (NOTE 3) | 1 | 06/30/86 | NA |
| C-5 | Decay Heat Update | Riggs | NRR/DSRO/SPEB | RI (NOTE 3) | 1 | 06/30/86 | NA |
| C-6 | LOCA Heat Sources | Riggs | NRR/DSRO/SPEB | RI (NOTE 3) | 1 | 06/30/86 | NA |
| C-7 | PWR System Piping | Emrit | NRR/DE/MTEB | NOTE 3(b) | | 11/30/83 | NA |

06/30/02

52

NUREG-0933

Revision 26

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------------|--|----------------------|-------------------------------------|-------------------------------|----------------|----------------------------|------------|
| C-8 | Main Steam Line Leakage Control Systems | Milstead | RES/DRPS/RPSI | NOTE 3(b) | 1 | 06/30/90 | NA |
| C-9 | RHR Heat Exchanger Tube Failures | VMolen | NRR/DSI/RSB | DROP | | 11/30/83 | NA |
| C-10 | Effective Operation of Containment Sprays in a LOCA | Emrit | NRR/DSI/AEB | NOTE 3(a) | | 11/30/83 | NA |
| C-11 | Assessment of Failure and Reliability of Pumps and Valves | Emrit | NRR/DE/MEB | NOTE 3(b) | | 12/31/85 | NA |
| C-12 | Primary System Vibration Assessment | Thatcher | NRR/DE/MEB | NOTE 3(b) | | 11/30/83 | NA |
| C-13 | Non-Random Failures | Emrit | NRR/DST/GIB | A-17 | 1 | 06/30/91 | NA |
| C-14 | Storm Surge Model for Coastal Sites | Emrit | NRR/DE/EHEB | LI (NOTE 3) | | 06/30/88 | NA |
| C-15 | NUREG Report for Liquid Tank Failure Analysis | - | NRR/DE/EHEB | LI (NOTE 3) | | 11/30/83 | NA |
| C-16 | Assessment of Agricultural Land in Relation to Power Plant Siting and Cooling System Selection | - | NRR/DE/EHEB | EI (NOTE 3) | | 11/30/83 | NA |
| C-17 | Interim Acceptance Criteria for Solidification Agents for Radioactive Solid Wastes | Emrit | NRR/DSI/METB | NOTE 3(a) | | 11/30/83 | NA |
| D-1 | Advisability of a Seismic Scram | Thatcher | RES/DET/MSEB | DROP | 1 | 12/31/98 | NA |
| D-2 | Emergency Core Cooling System Capability for Future Plants | Emrit | RES/DRA/ARGIB | DROP | | 12/31/88 | NA |
| D-3 | Control Rod Drop Accident | Emrit | NRR/DSI/CPB | NOTE 3(b) | | 11/30/83 | NA |
| <u>NEW GENERIC ISSUES</u> | | | | | | | |
| 1. | Failures in Air-Monitoring, Air-Cleaning, and Ventilating Systems | Emrit | NRR/DSI/METB | DROP | | 11/30/83 | NA |
| 2. | Failure of Protective Devices on Essential Equipment | Diab | RES/DSIR/EIB | DROP | 2 | 06/30/95 | NA |
| 3. | Set Point Drift in Instrumentation | Emrit | NRR/DSIR/RPSIB | NOTE 3(b) | 1 | 06/30/86 | NA |
| 4. | End-of-Life and Maintenance Criteria | Thatcher | NRR/DE/EQB | NOTE 3(b) | | 11/30/83 | NA |
| 5. | Design Check and Audit of Balance-of-Plant Equipment | Pittman | NRR/DSI/ASB | I.F.1 | | 11/30/83 | NA |
| 6. | Separation of Control Rod from Its Drive and BWR High Rod Worth Events | Vandermolen | NRR/DSI/CPB | NOTE 3(b) | 1 | 12/31/94 | NA |
| 7. | Failures Due to Flow-Induced Vibrations | Vandermolen | NRR/DSI/RSB | DROP | 1 | 06/30/91 | NA |
| 8. | Inadvertent Actuation of Safety Injection in PWRs | Colmar | NRR/DSI/RSB | I.C.1 | | 11/30/83 | NA |
| 9. | Reevaluation of Reactor Coolant Pump Trip Criteria | Emrit | NRR/DSI/RSB | II.K.3(5) | | 11/30/83 | NA |
| 10. | Surveillance and Maintenance of TIP Isolation Valves and Squib Charges | Riggs | NRR/DSI/ICSB | DROP | | 11/30/83 | NA |
| 11. | Turbine Disc Cracking | Pittman | NRR/DE/MTEB | A-37 | | 11/30/83 | NA |
| 12. | BWR Jet Pump Integrity | Sege | NRR/DE/MTEB, MEB | NOTE 3(b) | 1 | 12/31/84 | NA |
| 13. | Small Break LOCA from Extended Overheating of Pressurizer Heaters | Riani | NRR/DSI/RSB | DROP | | 11/30/83 | NA |
| 14. | PWR Pipe Cracks | Emrit | NRR/DE/MTEB | NOTE 3(b) | 2 | 12/31/94 | NA |
| 15. | Radiation Effects on Reactor Vessel Supports | Emrit | RES/DET/EMMEB | NOTE 3(b) | 3 | 06/30/96 | NA |

06/30/02

53

NUREG-0933

Revision 26

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------|---|-------------------|-------------------------------|-------------------------|-------------|----------------------|---------|
| 16. | BWR Main Steam Isolation Valve Leakage Control Systems | Milstead | NRR/DSI/ASB | C-8 | | 11/30/83 | NA |
| 17. | Loss of Offsite Power Subsequent to a LOCA | Colmar | NRR/DSI/PSB, ICSB | DROP | | 11/30/83 | NA |
| 18. | Steam Line Break with Consequential Small LOCA | Riggs | NRR/DSI/RSB | I.C.1 | | 11/30/83 | NA |
| 19. | Safety Implications of Nonsafety Instrument and Control Power Supply Bus | Sege | NRR/DST/GIB | A-47 | | 11/30/83 | NA |
| 20. | Effects of Electromagnetic Pulse on Nuclear Power Plants | Thatcher | NRR/DSI/ICSB | NOTE 3(b) | 1 | 06/30/84 | NA |
| 21. | Vibration Qualification of Equipment | Riggs | NRR/DE/EIB | DROP | 2 | 06/30/91 | NA |
| 22. | Inadvertent Boron Dilution Events | Vandermolen | NRR/DSI/RSB | NOTE 3(b) | 2 | 12/31/94 | NA |
| 23. | Reactor Coolant Pump Seal Failures | Riggs | RES/DET/GSIB | NOTE 3(b) | 1 | 06/30/00 | NA |
| 24. | Automatic ECCS Switchover to Recirculation | Milstead | RES/DET/GSIB | NOTE 3(b) | 3 | 12/31/95 | NA |
| 25. | Automatic Air Header Dump on BWR Scram System | Milstead | NRR/DSI/RSB | NOTE 3(a) | | 11/30/83 | |
| 26. | Diesel Generator Loading Problems Related to SIS Reset on Loss of Offsite Power | Emrit | NRR/DSI/ASB | 17 | | 11/30/83 | NA |
| 27. | Manual vs. Automated Actions | Pittman | NRR/DSI/RSB | B-17 | | 11/30/83 | NA |
| 28. | Pressurized Thermal Shock | Emrit | NRR/DST/GIB | A-49 | | 11/30/83 | NA |
| 29. | Bolting Degradation or Failure in Nuclear Power Plants | Vandermolen | RES/DSIR/EIB | NOTE 3(b) | 2 | 06/30/95 | NA |
| 30. | Potential Generator Missiles - Generator Rotor Retaining Rings | Pittman | NRR/DE/MEB | DROP | 1 | 12/31/85 | NA |
| 31. | Natural Circulation Cooldown | Riggs | NRR/DSI/RSB | I.C.1 | | 11/30/83 | NA |
| 32. | Flow Blockage in Essential Equipment Caused by Corbicula | Emrit | NRR/DSI/ASB | 51 | | 11/30/83 | NA |
| 33. | Correcting Atmospheric Dump Valve Opening Upon Loss of Integrated Control System Power | Pittman | NRR/DSI/ICSB | A-47 | | 11/30/83 | NA |
| 34. | RCS Leak | Riggs | NRR/DHFS/PSRB | DROP | 1 | 06/30/84 | NA |
| 35. | Degradation of Internal Appurtenances in LWRs | Vandermolen | NRR/DSI/CPB, RSB | DROP | 2 | 12/31/98 | NA |
| 36. | Loss of Service Water | Colmar | NRR/DSI/ASB, AEB, RSB | NOTE 3(b) | 3 | 06/30/91 | NA |
| 37. | Steam Generator Overfill and Combined Primary and Secondary Blowdown | Colmar | NRR/DST/GIB, NRR/DSI/RSB | A-47, I.C.1(2) | 1 | 06/30/85 | NA |
| 38. | Potential Recirculation System Failure as a Consequence of Ingestion of Containment Paint Flakes or Other Fine Debris | Emrit | RES/DSIR/RPSIB | DROP | 2 | 06/30/95 | NA |
| 39. | Potential for Unacceptable Interaction Between the CRD System and Non-Essential Control Air System | Pittman | NRR/DSI/ASB | 25 | 1 | 06/30/95 | NA |
| 40. | Safety Concerns Associated with Pipe Breaks in the BWR Scram System | Colmar | NRR/DSI/ASB | NOTE 3(a) | 1 | 06/30/84 | B-65 |
| 41. | BWR Scram Discharge Volume Systems | Vandermolen | NRR/DSI/RSB | NOTE 3(a) | | 11/30/83 | B-58 |
| 42. | Combination Primary/Secondary System LOCA | Riggs | NRR/DSI/RSB | I.C.1 | 1 | 06/30/85 | NA |
| 43. | Reliability of Air Systems | Milstead | RES/DSIR/RPSI | NOTE 3(a) | 2 | 12/31/88 | B-107 |

06/30/02

54

NUREG-0933

Revision 26

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------------|--|----------------------|-------------------------------------|-------------------------------|----------------|----------------------------|------------|
| 44. | Failure of Saltwater Cooling System | Milstead | NRR/DSI/ASB | 43 | 1 | 12/31/88 | NA |
| 45. | Inoperability of Instrumentation Due to Extreme Cold Weather | Milstead | NRR/DSI/ICSB | NOTE 3(a) | 2 | 06/30/91 | NA |
| 46. | Loss of 125 Volt DC Bus | Sege | NRR/DSI/PSB | 76 | | 11/30/83 | NA |
| 47. | Loss of Offsite Power | Thatcher | NRR/DSI/RSB, ASB | NOTE 3(b) | | 11/30/83 | NA |
| 48. | LCO for Class 1E Vital Instrument Buses in Operating Reactors | Sege | NRR/DSI/PSB | 128 | 1 | 12/31/86 | NA |
| 49. | Interlocks and LCOs for Redundant Class 1E Tie-Breakers | Sege | NRR/DSI/PSB | 128 | 3 | 06/30/91 | NA |
| 50. | Reactor Vessel Level Instrumentation in BWRs | Thatcher | NRR/DSI/RSB, ICSB | NOTE 3(b) | 1 | 12/31/84 | NA |
| 51. | Proposed Requirements for Improving the Reliability of Open Cycle Service Water Systems | Emrit | RES/DE/EIB | NOTE 3(a) | 1 | 12/31/89 | L-913 |
| 52. | SSW Flow Blockage by Blue Mussels | Emrit | NRR/DSI/ASB | 51 | | 11/30/83 | NA |
| 53. | Consequences of a Postulated Flow Blockage Incident in a BWR | Vandermolen | NRR/DSI/CPB, RSB | DROP | 1 | 12/31/84 | NA |
| 54. | Valve Operator-Related Events Occurring During 1978, 1979, and 1980 | Colmar | NRR/DE/MEB | II.E.6.1 | 1 | 06/30/85 | NA |
| 55. | Failure of Class 1E Safety-Related Switchgear Circuit Breakers to Close on Demand | Emrit | NRR/DSI/PSB | DROP | 2 | 06/30/91 | NA |
| 56. | Abnormal Transient Operating Guidelines as Applied to a Steam Generator Overfill Event | Colmar | NRR/DHFS/HFEB | A-47, I.D.1 | | 11/30/83 | NA |
| 57. | Effects of Fire Protection System Actuation on Safety-Related Equipment | Milstead | RES/DRA/ARGIB | NOTE 3(b) | 3 | 06/30/95 | NA |
| 58. | Inadvertent Containment Flooding | Sege | NRR/DSI/ASB, CSB | DROP | | 11/30/83 | NA |
| 59. | Technical Specification Requirements for Plant Shutdown when Equipment for Safe Shutdown is Degraded or Inoperable | Emrit | NRR/DST/TSIP | RI (NOTE 5) | 1 | 06/30/85 | NA |
| 60. | Lamellar Tearing of Reactor Systems Structural Supports | Colmar | NRR/DST/GIB | A-12 | | 11/30/83 | NA |
| 61. | SRV Line Break Inside the BWR Wetwell Airspace of Mark I and II Containments | Milstead | NRR/DSI/CSB | NOTE 3(b) | 2 | 12/31/86 | NA |
| 62. | Reactor Systems Boiling Applications | Riggs | RES/DSIR/EIB | 29 | 1 | 12/31/88 | NA |
| 63. | Use of Equipment Not Classified as Essential to Safety in BWR Transient Analysis | Pittman | RES/DRA/ARGIB | DROP | 1 | 06/30/90 | NA |
| 64. | Identification of Protection System Instrument Sensing Lines | Thatcher | NRR/DSI/ICSB | NOTE 3(b) | | 11/30/83 | NA |
| 65. | Probability of Core-Melt Due to Component Cooling Water System Failures | Vandermolen | NRR/DSI/ASB | 23 | 1 | 12/31/86 | NA |
| 66. | Steam Generator Requirements | Riggs | NRR/DEST/EMTB | NOTE 3(b) | 2 | 12/31/88 | NA |
| 67. | <u>Steam Generator Staff Actions</u> | - | - | - | - | - | - |

06/30/02

55

NUREG-0933

Revision 26

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------------|--|----------------------|-------------------------------------|-------------------------------|----------------|----------------------------|---|
| 67.2.1 | Integrity of Steam Generator Tube Sleeves | Riggs | NRR/DE/MEB | 135 | 4 | 06/30/94 | NA |
| 67.3.1 | Steam Generator Overfill | Riggs | NRR/DST/GIB NRR/DSI/RSB | A-47, I.C.1 | 4 | 06/30/94 | NA |
| 67.3.2 | Pressurized Thermal Shock | Riggs | NRR/DST/GIB | A-49 | 4 | 06/30/94 | NA |
| 67.3.3 | Improved Accident Monitoring | Riggs | NRR/DSI/ICSB | NOTE 3(a) | 4 | 06/30/94 | A-17 |
| 67.3.4 | Reactor Vessel Inventory Measurement | Riggs | NRR/DSI/CPB | II.F.2 | 4 | 06/30/94 | NA |
| 67.4.1 | RCP Trip | Riggs | NRR/DSI/RSB | II.K.3(5) | 4 | 06/30/94 | G-01 |
| 67.4.2 | Control Room Design Review | Riggs | NRR/DHFS/HFEB | I.D.1 | 4 | 06/30/94 | F-08 |
| 67.4.3 | Emergency Operating Procedures | Riggs | NRC/DHFS/PSRB | I.C.1 | 4 | 06/30/94 | F-05 |
| 67.5.1 | Reassessment of Radiological Consequences | Riggs | RES/DRPS/RPSI | LI (NOTE 3) | 4 | 06/30/94 | NA |
| 67.5.2 | Reevaluation of SGTR Design Basis | Riggs | RES/DRPS/RPSI | LI (67.5.1) | 4 | 06/30/94 | NA |
| 67.5.3 | Secondary System Isolation | Riggs | NRR/DSI/RSB | DROP | 4 | 06/30/94 | NA |
| 67.6.0 | Organizational Responses | Riggs | OIE/DEPER/IRDB | III.A.3 | 4 | 06/30/94 | NA |
| 67.7.0 | Improved Eddy Current Tests | Riggs | RES/DE/EIB | 135 | 4 | 06/30/94 | NA |
| 67.8.0 | Denting Criteria | Riggs | NRR/DE/MTEB | 135 | 4 | 06/30/94 | NA |
| 67.9.0 | Reactor Coolant System Pressure Control | Riggs | NRR/DSI/GIB NRR/DSI/RSB | A-45, I.C.1 (2,3) | 4 | 06/30/94 | NA |
| 67.10.0 | Supplemental Tube Inspections | Riggs | NRR/DL/ORAB | LI (NOTE 5) | 4 | 06/30/94 | NA |
| 68. | Postulated Loss of Auxiliary Feedwater System Resulting from Turbine-Driven Auxiliary Feedwater Pump Steam Supply Line Rupture | Pittman | NRR/DSI/ASB | 124 | 3 | 06/30/91 | NA |
| 69. | Make-up Nozzle Cracking in B&W Plants | Colmar | NRR/DE/MEB, MTEB | NOTE 3(b) | 1 | 12/31/84 | B43 |
| 70. | PORV and Block Valve Reliability | Riggs | RES/DE/EIB | NOTE 3(a) | 3 | 06/30/91 | |
| 71. | Failure of Resin Demineralizer Systems and Their Effects on Nuclear Power Plant Safety | Pittman | RES/DRA/ARGIB | DROP | 3 | 06/30/01 | NA |
| 72. | Control Rod Drive Guide Tube Support Pin Failures | Riggs | RES | DROP | 1 | 06/30/91 | NA |
| 73. | Detached Thermal Sleeves | Emrit | RES/DSIR/EIB | NOTE 3(a) | 3 | 06/30/95 | NA |
| 74. | Reactor Coolant Activity Limits for Operating Reactors | Milstead | NRR/DSI/AEB | DROP | 1 | 06/30/86 | NA |
| 75. | Generic Implications of ATWS Events at the Salem Nuclear Plant | Emrit | RES/DRA/ARGIB | NOTE 3(a) | 1 | 06/30/90 | B-76, B-77, B-78, B-79, B-80, B-81, B-82, B-85 B-86, B-87, B-88, B-89, |

06/30/02

56

NUREG-0933

Revision 26

06/30/02

57

NUREG-0933

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------------|---|----------------------|-------------------------------------|-------------------------------|----------------|----------------------------|---------------------------------|
| 75. | (Cont.) | | | | | | B-90, B-91, B-92, B-93 |
| 76. | Instrumentation and Control Power Interactions | Zimmerman | RES/DSIR/EIB | DROP | 3 | 06/30/95 | NA |
| 77. | Flooding of Safety Equipment Compartments by Back-flow Through Floor Drains | Colmar | RES/DE/EIB | A-17 | | 12/31/87 | NA |
| 78. | Monitoring of Fatigue Transient Limits for Reactor Coolant System | Rourk | RES/DET/GSIB | NOTE 3(b) | 3 | 12/31/97 | |
| 79. | Unanalyzed Reactor Vessel Thermal Stress During Natural Convection Cooldown | Colmar | RES/DSIR/EIB | NOTE 3(b) | 3 | 06/30/95 | NA |
| 80. | Pipe Break Effects on Control Rod Drive Hydraulic Lines in the Drywells of BWR Mark I and II Containments | Vandermolen | NRR/DSI/RSB, ASB, CPB | DROP | 2 | 12/31/98 | NA |
| 81. | Impact of Locked Doors and Barriers on Plant and Personnel Safety | Rourk | RES/DSIR/EIB | LOW | 4 | 06/30/95 | NA |
| 82. | Beyond Design Basis Accidents in Spent Fuel Pools | Vandermolen | RES/DRPS/RPSI | NOTE 3(b) | 1 | 06/30/89 | NA |
| 83. | Control Room Habitability | Emrit | RES/DST/AEB | NOTE 3(b) | 2 | 06/30/96 | NA |
| 84. | CE PORVs | Riggs | RES/DSIR/RPSI | NOTE 3(b) | 2 | 06/30/90 | NA |
| 85. | Reliability of Vacuum Breakers Connected to Steam Discharge Lines Inside BWR Containments | Milstead | NRR/DSI/CSB | DROP | 2 | 06/30/91 | NA |
| 86. | Long Range Plan for Dealing with Stress Corrosion Cracking in BWR Piping | Emrit | NRR/DEST/EMTB | NOTE 3(a) | 1 | 06/30/88 | B-84 |
| 87. | Failure of HPCI Steam Line Without Isolation | Pittman | RES/DSIR/EIB | NOTE 3(a) | 2 | 06/30/95 | |
| 88. | Earthquakes and Emergency Planning | Riggs | RES/DRA/ARGIB | NOTE 3(b) | | 12/31/87 | NA |
| 89. | Stiff Pipe Clamps | Chang | RES/DSIR/EIB | LOW | 2 | 06/30/95 | NA |
| 90. | Technical Specifications for Anticipatory Trips | Vandermolen | NRR/DSI/RSB, ICSB | DROP | 2 | 12/31/98 | NA |
| 91. | Main Crankshaft Failures in Transamerica DeLaval Emergency Diesel Generators | Emrit | RES/DRA/ARGIB | NOTE 3(b) | | 12/31/87 | NA |
| 92. | Fuel Crumbling During LOCA | Vandermolen | NRR/DSI/RSB, CPB | DROP | 1 | 12/31/98 | NA |
| 93. | Steam Binding of Auxiliary Feedwater Pumps | Pittman | RES/DRPS/RPSI | NOTE 3(a) | | 06/30/88 | B-98 |
| 94. | Additional Low Temperature Overpressure Protection for Light Water Reactors | Pittman | RES/DSIR/RPSI | NOTE 3(a) | | 06/30/90 | |
| 95. | Loss of Effective Volume for Containment Recirculation Spray | Milstead | RES/DRA/ARGIB | NOTE 3(b) | | 06/30/90 | NA |
| 96. | RHR Suction Valve Testing | Milstead | RES/DRA/ARGIB | 105 | | 06/30/90 | NA |
| 97. | PWR Reactor Cavity Uncontrolled Exposures | Vandermolen | NRR/DSI/RAB | III.D.3.1 | | 06/30/85 | NA |
| 98. | CRD Accumulator Check Valve Leakage | Pittman | NRR/DSI/ASB | DROP | | 06/30/85 | NA |
| 99. | RCS/RHR Suction Line Valve Interlock on PWRs | Pittman | RES/DRPS/RPSI | NOTE 3(a) | 3 | 06/30/91 | L-817 |

Revision 26

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------------|---|----------------------|-------------------------------------|-------------------------------|----------------|----------------------------|------------|
| 100. | Once-Through Steam Generator Level | Jackson | RES/DSIR/EIB | DROP | 1 | 06/30/95 | NA |
| 101. | BWR Water Level Redundancy | Vandermolen | RES/DE/EIB | NOTE 3(b) | 1 | 06/30/89 | NA |
| 102. | Human Error in Events Involving Wrong Unit or Wrong Train | Emrit | NRR/DLPQ/LPEB | NOTE 3(b) | 2 | 12/31/88 | NA |
| 103. | Design for Probable Maximum Precipitation | Emrit | RES/DE/EIB | NOTE 3(a) | 1 | 12/31/89 | NA |
| 104. | Reduction of Boron Dilution Requirements | Pittman | RES/DRA/ARGIB | DROP | | 12/31/88 | NA |
| 105. | Interfacing Systems LOCA at LWRs | Milstead | RES/DE/EIB | NOTE 3(b) | 4 | 06/30/95 | NA |
| 106. | Piping and Use of Highly Combustible Gases in Vital Areas | Milstead | RES/DRPS | NOTE 3(b) | 2 | 06/30/95 | NA |
| 107. | Main Transformer Failures | Milstead | RES/DRA/ARGIB | DROP | 3 | 06/30/00 | NA |
| 108. | BWR Suppression Pool Temperature Limits | Colmar | NRR/DSI/CSB | RI (NOTE 3) | | 06/30/85 | NA |
| 109. | Reactor Vessel Closure Failure | Riggs | RES/DRA/ARGIB | DROP | | 06/30/90 | NA |
| 110. | Equipment Protective Devices on Engineered Safety Features | Diab | RES/DSIR/EIB | DROP | 1 | 06/30/95 | NA |
| 111. | Stress Corrosion Cracking of Pressure Boundary Ferritic Steels in Selected Environments | Riggs | NRR/DE/MTEB | LI (NOTE 5) | 1 | 06/30/91 | NA |
| 112. | Westinghouse RPS Surveillance Frequencies and Out-of-Service Times | Pittman | NRR/DSI/ICSB | RI (NOTE 3) | | 12/31/85 | NA |
| 113. | Dynamic Qualification Testing of Large Bore Hydraulic Snubbers | Riggs | RES/DSIR/EIB | NOTE 3(b) | 2 | 06/30/95 | NA |
| 114. | Seismic-Induced Relay Chatter | Riggs | NRR/DSRO/SPEB | A-46 | 1 | 06/30/91 | NA |
| 115. | Enhancement of the Reliability of Westinghouse Solid State Protection System | Milstead | RES/DRPS/RPSI | NOTE 3(b) | 2 | 06/30/00 | NA |
| 116. | Accident Management | Pittman | RES/DRA/ARGIB | S | | 06/30/91 | NA |
| 117. | Allowable Time for Diverse Simultaneous Equipment Outages | Pittman | RES/DRA/ARGIB | DROP | | 06/30/90 | NA |
| 118. | Tendon Anchorage Failure | Shaukat | RES/DSIR/EIB | NOTE 3(a) | 1 | 06/30/95 | NA |
| 119. | <u>Piping Review Committee Recommendations</u> | - | - | - | | | |
| 119.1 | Piping Rupture Requirements and Decoupling of Seismic and LOCA Loads | Riggs | NRR/DE | RI (NOTE 3) | 3 | 12/31/97 | NA |
| 119.2 | Piping Damping Values | Riggs | NRR/DE | RI (DROP) | 3 | 12/31/97 | NA |
| 119.3 | Decoupling the OBE from the SSE | Riggs | NRR/DE | RI (S) | 3 | 12/31/97 | NA |
| 119.4 | BWR Piping Materials | Riggs | NRR/DE | RI (NOTE 5) | 3 | 12/31/97 | NA |
| 119.5 | Leak Detection Requirements | Riggs | NRR/DE | RI (NOTE 5) | 3 | 12/31/97 | NA |
| 120. | On-Line Testability of Protection Systems | Milstead | RES/DRA/ARGIB | NOTE 3(b) | 2 | 06/30/95 | NA |
| 121. | Hydrogen Control for Large, Dry PWR Containments | Emrit | RES/DSIR/SAIB | NOTE 3(b) | 2 | 06/30/95 | NA |
| 122. | <u>Davis-Besse Loss of All Feedwater Event of June 9, 1985: Short-Term Actions</u> | | | | | | |
| 122.1 | Potential Inability to Remove Reactor Decay Heat | - | - | - | | | |
| 122.1.a | Failure of Isolation Valves in Closed Position | Vandermolen | NRR/DSRO/RSIB | 124 | 4 | 12/31/98 | NA |
| 122.1.b | Recovery of Auxiliary Feedwater | Vandermolen | NRR/DSRO/RSIB | 124 | 4 | 12/31/98 | NA |

06/30/02

58

NUREG-0933

Revision 26

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------------|--|----------------------|-------------------------------------|-------------------------------|----------------|----------------------------|------------|
| 122.1.c. | Interruption of Auxiliary Feedwater Flow | Vandermolen | NRR/DSRO/RSIB | 124 | 4 | 12/31/98 | NA |
| 122.2 | Initiating Feed-and-Bleed | Vandermolen | NRR/DEST/SRXB | NOTE 3(b) | 4 | 12/31/98 | NA |
| 122.3 | Physical Security System Constraints | Vandermolen | NRR/DSRO/SPEB | DROP | 4 | 12/31/98 | NA |
| 123. | Deficiencies in the Regulations Governing DBA and Single-Failure Criteria Suggested by the Davis-Besse Event of June 9, 1985 | Milstead | RES/DSIR/SAIB | DROP | 1 | 06/30/95 | NA |
| 124. | Auxiliary Feedwater System Reliability | Emrit | NRR/DEST/SRXB | NOTE 3(a) | 3 | 06/30/91 | |
| 125. | <u>Davis-Besse Loss of All Feedwater Event of June 9, 1985:</u> <u>Long-Term Actions</u> | - | - | - | | | |
| 125.I.1 | Availability of the Shift Technical Advisor | Vandermolen | RES/DRA/ARGIB | DROP | 7 | 12/31/98 | NA |
| 125.I.2 | PORV Reliability | - | - | - | 7 | 12/31/98 | |
| 125.I.2.a | Need for a Test Program to Establish Reliability of the PORV | Vandermolen | NRR/DSRO/SPEB | 70 | 7 | 12/31/98 | NA |
| 125.I.2.b | Need for PORV Surveillance Tests to Confirm Operational Readiness | Vandermolen | NRR/DSRO/SPEB | 70 | 7 | 12/31/98 | NA |
| 125.I.2.c | Need for Additional Protection Against PORV Failure | Vandermolen | NRR/DSRO/SPEB | DROP | 7 | 12/31/98 | NA |
| 125.I.2.d | Capability of the PORV to Support Feed-and-Bleed | Vandermolen | NRR/DSRO/SPEB | A-45 | 7 | 12/31/98 | NA |
| 125.I.3 | SPDS Availability | Milstead | RES/DRA/ARGIB | NOTE 3(b) | 7 | 12/31/98 | NA |
| 125.I.4 | Plant-Specific Simulator | Riggs | RES/DRA/ARGIB | DROP | 7 | 12/31/98 | NA |
| 125.I.5 | Safety Systems Tested in All Conditions Required by DBA | Riggs | RES/DRA/ARGIB | DROP | 7 | 12/31/98 | NA |
| 125.I.6 | Valve Torque Limit and Bypass Switch Settings | Vandermolen | RES/DRA/ARGIB | DROP | 7 | 12/31/98 | NA |
| 125.I.7 | Operator Training Adequacy | - | - | - | | | |
| 125.I.7.a | Recover Failed Equipment | Pittman | RES/DRA/ARGIB | DROP | 7 | 12/31/98 | NA |
| 125.I.7.b | Realistic Hands-On Training | Vandermolen | RES/DRA/ARGIB | DROP | 7 | 12/31/98 | NA |
| 125.I.8 | Procedures and Staffing for Reporting to NRC Emergency Response Center | Vandermolen | RES/DRA/ARGIB | DROP | 7 | 12/31/98 | NA |
| 125.II.1 | Need for Additional Actions on AFW Systems | - | - | - | | | |
| 125.II.1.a | Two-Train AFW Unavailability | Vandermolen | NRR/DSRO/SPEB | DROP | 7 | 12/31/98 | NA |
| 125.II.1.b | Review Existing AFW Systems for Single Failure | Vandermolen | NRR/DSRO/SPEB | 124 | 7 | 12/31/98 | NA |
| 125.II.1.c | NUREG-0737 Reliability Improvements | Vandermolen | NRR/DSRO/SPEB | DROP | 7 | 12/31/98 | NA |
| 125.II.1.d | AFW/Steam and Feedwater Rupture Control System/ICS Interactions in B&W Plants | Vandermolen | NRR/DSRO/SPEB | DROP | 7 | 12/31/98 | NA |
| 125.II.2 | Adequacy of Existing Maintenance Requirements for Safety-Related Systems | Riggs | RES/DRA/ARGIB | DROP | 7 | 12/31/98 | NA |
| 125.II.3 | Review Steam/Feedline Break Mitigation Systems for Single Failure | V'Molen | NRR/DSRO/SPEB | DROP | 7 | 12/31/98 | NA |
| 125.II.4 | Thermal Stress of OTSG Components | Riggs | NRR/DSRO/SPEB | DROP | 7 | 12/31/98 | NA |
| 125.II.5 | Thermal-Hydraulic Effects of Loss and Restoration of Feedwater on Primary System Components | Riggs | RES/DRA/ARGIB | DROP | 7 | 12/31/98 | NA |

06/30/02

59

NUREG-0933

Revision 26

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------------|---|----------------------|-------------------------------------|-------------------------------|----------------|----------------------------|------------|
| 125.II.6 | Reexamine PRA Estimates of Core Damage Risk from Loss of All Feedwater | Vandermolen | RES/DRA/ARGIB | DROP | 7 | 12/31/98 | NA |
| 125.II.7 | Reevaluate Provision to Automatically Isolate Feedwater from Steam Generator During a Line Break | Vandermolen | RES/DRPS/RPSI | NOTE 3(b) | 7 | 12/31/98 | NA |
| 125.II.8 | Reassess Criteria for Feed-and-Bleed Initiation | Vandermolen | RES/DRA/ARGIB | DROP | 7 | 12/31/98 | NA |
| 125.II.9 | Enhanced Feed-and-Bleed Capability | Vandermolen | NRR/DSRO/SPEB | DROP | 7 | 12/31/98 | NA |
| 125.II.10 | Hierarchy of Impromptu Operator Actions | Riggs | RES/DRA/ARGIB | DROP | 7 | 12/31/98 | NA |
| 125.II.11 | Recovery of Main Feedwater as Alternative to Auxiliary Feedwater | Riggs | RES/DRA/ARGIB | DROP | 7 | 12/31/98 | NA |
| 125.II.12 | Adequacy of Training Regarding PORV Operation | Riggs | RES/DRA/ARGIB | DROP | 7 | 12/31/98 | NA |
| 125.II.13 | Operator Job Aids | Pittman | NRR/DRA/ARGIB | DROP | 7 | 12/31/98 | NA |
| 125.II.14 | Remote Operation of Equipment Which Must Now Be Operated Locally | Vandermolen | NRR/DSRO/SPEB | DROP | 7 | 12/31/98 | NA |
| 126. | Reliability of PWR Main Steam Safety Valves | Riggs | RES/DRA/ARGIB | LI (NOTE 3) | | 06/30/88 | NA |
| 127. | Maintenance and Testing of Manual Valves in Safety-Related Systems | Pittman | RES/DRA/ARGIB | LOW | | 12/31/87 | NA |
| 128. | Electrical Power Reliability | Emrit | RES/DSIR/EIB | NOTE 3(a) | 2 | 06/30/95 | |
| 129. | Valve Interlocks to Prevent Vessel Drainage During Shutdown Cooling | Milstead | RES/DRA/ARGIB | DROP | | 06/30/90 | NA |
| 130. | Essential Service Water Pump Failures at Multiplant Sites | Riggs | RES/DSIR/RPSIB | NOTE 3(a) | 2 | 12/31/95 | |
| 131. | Potential Seismic Interaction Involving the Movable In-Core Flux Mapping System Used in Westinghouse-Designed Plants | Riggs | RES/DRA/ARGIB | S | 1 | 06/30/91 | NA |
| 132. | RHR System Inside Containment | Su | RES/DSIR/SAIB | DROP | 1 | 12/31/95 | NA |
| 133. | Update Policy Statement on Nuclear Plant Staff Working Hours | Pittman | NRR/DLPQ/LHFB | LI (NOTE 3) | 1 | 12/31/91 | NA |
| 134. | Rule on Degree and Experience Requirement | Pittman | RES/DRA/RDB | NOTE 3(b) | | 12/31/89 | NA |
| 135. | Steam Generator and Steam Line Overfill | Emrit | RES/DSIR/EIB | NOTE 3(b) | 3 | 06/30/95 | NA |
| 136. | Storage and Use of Large Quantities of Cryogenic Combustibles On Site | Milstead | RES/DRA/ARGIB | LI (NOTE 3) | | 06/30/88 | NA |
| 137. | Refueling Cavity Seal Failure | Milstead | RES/DRA/ARGIB | DROP | | 06/30/90 | NA |
| 138. | Deinerting of BWR Mark I and II Containments During Power Operations Upon Discovery of RCS Leakage or a Train of a Safety System Inoperable | Milstead | RES/DSIR/SAIB | DROP | 2 | 12/31/98 | NA |
| 139. | Thinning of Carbon Steel Piping in LWRs | Riggs | RES/DRA/ARGIB | RI (NOTE 3) | 1 | 06/30/95 | NA |
| 140. | Fission Product Removal Systems | Riggs | RES/DRA/ARGIB | DROP | | 06/30/90 | NA |
| 141. | Large-Break LOCA With Consequential SGTR | Riggs | RES/DRA/ARGIB | DROP | | 06/30/90 | NA |
| 142. | Leakage Through Electrical Isolators in Instrumentation Circuits | Milstead | RES/DSIR/EIB | NOTE 3(b) | 4 | 12/31/97 | NA |
| 143. | Availability of Chilled Water Systems and Room Cooling | Milstead | RES/DRA/ARGIB | NOTE 3(b) | 2 | 06/30/95 | NA |

06/30/02

60

NUREG-0933

Revision 26

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------------|--|----------------------|-------------------------------------|-------------------------------|----------------|----------------------------|------------|
| 144. | Scram Without a Turbine/Generator Trip | Hrabal | RES/DSIR/EIB | DROP | 2 | 12/31/98 | NA |
| 145. | Actions to Reduce Common Cause Failures | Rasmuson | RES/DST/PRAB | NOTE 3(b) | 3 | 06/30/00 | NA |
| 146. | Support Flexibility of Equipment and Components | Chang | RES/DSIR/EIB | NOTE 3(b) | 2 | 06/30/95 | NA |
| 147. | Fire-Induced Alternate Shutdown/Control Room Panel Interactions | Milstead | RES/DSIR/SAIB | LI (NOTE 3) | 1 | 06/30/94 | NA |
| 148. | Smoke Control and Manual Fire-Fighting Effectiveness | Basdekas | RES/DSIR/RPSIB | LI (NOTE 3) | 1 | 06/30/00 | NA |
| 149. | Adequacy of Fire Barriers | Emrit | RES/DSIR/EIB | DROP | 2 | 12/31/98 | NA |
| 150. | Overpressurization of Containment Penetrations | Milstead | RES/DSIR/SAIB | DROP | 1 | 06/30/95 | NA |
| 151. | Reliability of Anticipated Transient Without SCRAM Recirculation Pump Trip in BWRs | Milstead | RES/DSIR/SAIB | NOTE 3(b) | 2 | 06/30/95 | NA |
| 152. | Design Basis for Valves That Might Be Subjected to Significant Blowdown Loads | Emrit | RES/DSIR/EIB | DROP | 3 | 06/30/01 | NA |
| 153. | Loss of Essential Service Water in LWRs | Riggs | RES/DRA/ARGIB | NOTE 3(b) | 2 | 12/31/95 | NA |
| 154. | Adequacy of Emergency and Essential Lighting | Woods | RES/DSIR/SAIB | DROP | 2 | 12/31/98 | NA |
| 155. | <u>Generic Concerns Arising from TMI-2 Cleanup</u> | - | - | - | - | - | - |
| 155.1 | More Realistic Source Term Assumptions | Emrit | RES/DST/AEB | NOTE 3(a) | 2 | 06/30/95 | NA |
| 155.2 | Establish Licensing Requirements for Non-Operating Facilities | Emrit | RES/DSIR/EIB | RI (NOTE 5) | 2 | 06/30/95 | NA |
| 155.3 | Improve Design Requirements for Nuclear Facilities | Emrit | RES/DSIR/EIB | DROP | 2 | 06/30/95 | NA |
| 155.4 | Improve Criticality Calculations | Emrit | RES/DSIR/EIB | DROP | 2 | 06/30/95 | NA |
| 155.5 | More Realistic Severe Reactor Accident Scenario | Emrit | RES/DSIR/EIB | DROP | 2 | 06/30/95 | NA |
| 155.6 | Improve Decontamination Regulations | Emrit | RES/DSIR/EIB | DROP | 2 | 06/30/95 | NA |
| 155.7 | Improve Decommissioning Regulations | Emrit | RES/DSIR/EIB | DROP | 2 | 06/30/95 | NA |
| 156. | <u>Systematic Evaluation Program</u> | - | - | - | - | - | - |
| 156.1.1 | Settlement of Foundations and Buried Equipment | Chang | RES/DSIR/EIB | DROP | 7 | 06/30/01 | NA |
| 156.1.2 | Dam Integrity and Site Flooding | Chen | RES/DSIR/SAIB | DROP | 7 | 06/30/01 | NA |
| 156.1.3 | Site Hydrology and Ability to Withstand Floods | Chen | RES/DSIR/SAIB | DROP | 7 | 06/30/01 | NA |
| 156.1.4 | Industrial Hazards | Ferrell | RES/DSIR/SAIB | DROP | 7 | 06/30/01 | NA |
| 156.1.5 | Tomado Missiles | Chen | RES/DSIR/SAIB | DROP | 7 | 06/30/01 | NA |
| 156.1.6 | Turbine Missiles | Emrit | RES/DSIR/EIB | DROP | 7 | 06/30/01 | NA |
| 156.2.1 | Severe Weather Effects on Structures | Chen | RES/DSIR/SAIB | DROP | 7 | 06/30/01 | NA |
| 156.2.2 | Design Codes, Criteria, and Load Combinations | Kirkwood | RES/DSIR/EIB | DROP | 7 | 06/30/01 | NA |
| 156.2.3 | Containment Design and Inspection | Shaukat | RES/DSIR/EIB | DROP | 7 | 06/30/01 | NA |
| 156.2.4 | Seismic Design of Structures, Systems, and Components | Chen | RES/DSIR/SAIB | DROP | 7 | 06/30/01 | NA |
| 156.3.1.1 | Shutdown Systems | Woods | RES/DSIR/SAIB | DROP | 7 | 06/30/01 | NA |
| 156.3.1.2 | Electrical Instrumentation and Controls | Woods | RES/DSIR/SAIB | DROP | 7 | 06/30/01 | NA |
| 156.3.2 | Service and Cooling Water Systems | Su | RES/DSIR/SAIB | DROP | 7 | 06/30/01 | NA |
| 156.3.3 | Ventilation Systems | Burdick | RES/DSIR/SAIB | DROP | 7 | 06/30/01 | NA |
| 156.3.4 | Isolation of High and Low Pressure Systems | Burdick | RES/DSIR/SAIB | DROP | 7 | 06/30/01 | NA |
| 156.3.5 | Automatic ECCS Switchover | Milstead | RES/DSIR/SAIB | 24 | 7 | 06/30/01 | NA |
| 156.3.6.1 | Emergency AC Power | Emrit | RES/DSIR/EIB | DROP | 7 | 06/30/01 | NA |

06/30/02

61

NUREG-0933

Revision 26

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------------|---|----------------------|-------------------------------------|-------------------------------|----------------|----------------------------|------------|
| 156.3.6.2 | Emergency DC Power | Rourk | RES/DSIR/EIB | DROP | 7 | 06/30/01 | NA |
| 156.3.8 | Shared Systems | Emrit | RES/DSIR/EIB | DROP | 7 | 06/30/01 | NA |
| 156.4.1 | RPS and ESFS Isolation | Emrit | RES/DSIR/EIB | 142 | 7 | 06/30/01 | NA |
| 156.4.2 | Testing of the RPS and ESFS | Chang | RES/DSIR/SAIB | 120 | 7 | 06/30/01 | NA |
| 156.6.1 | Pipe Break Effects on Systems and Components | Page | RES/DET/GSIB | HIGH | 7 | 06/30/01 | |
| 157. | Containment Performance | Shaperow | RES/DSIR/SAIB | NOTE 3(b) | | 06/30/95 | NA |
| 158. | Performance of Power-Operated Valves Under Design Basis Conditions | Hrabal | RES/DET/GSIB | NOTE 3(b) | 2 | 06/30/00 | NA |
| 159. | Qualification of Safety-Related Pumps While Running on Minimum Flow | Su | RES/DSIR/SAIB | DROP | 1 | 06/30/95 | NA |
| 160. | Spurious Actions of Instrumentation Upon Restoration of Power | Rourk | RES/DSIR/EIB | DROP | 1 | 06/30/95 | NA |
| 161. | Use of Non-Safety-Related Power Supplies in Safety-Related Circuits | Rourk | RES/DSIR/EIB | DROP | 1 | 06/30/95 | NA |
| 162. | Inadequate Technical Specifications for Shared Systems at Multiplant Sites When One Unit Is Shut Down | Cheh | RES/DSIR/SAIB | DROP | 1 | 06/30/95 | NA |
| 163. | Multiple Steam Generator Tube Leakage | Coffman | RES/DET/GSIB | HIGH | | 12/31/97 | |
| 164. | Neutron Fluence in Reactor Vessel | Emrit | RES/DSIR/EIB | DROP | 1 | 06/30/95 | NA |
| 165. | Safety and Safety/Relief Valve Reliability | Hrabal | RES/DET/GSIB | NOTE 3(b) | 2 | 06/30/00 | NA |
| 166. | Adequacy of Fatigue Life of Metal Components | Emrit | NRR/DE/EMEB | NOTE 3(b) | 2 | 12/31/97 | NA |
| 167. | Hydrogen Storage Facility Separation | Burdick | RES/DSIR/SAIB | LOW | 1 | 06/30/95 | NA |
| 168. | Environmental Qualification of Electrical Equipment | Emrit | NRR/DSSA/SPLB | HIGH | 2 | 12/31/98 | |
| 169. | BWR MSIV Common Mode Failure Due to Loss of Accumulator Pressure | Emrit | RES/DET/GSIB | DROP | 1 | 06/30/00 | NA |
| 170. | Fuel Damage Criteria for High Burnup Fuel | Emrit | RES/DET/GSIB | NOTE 3(b) | 2 | 06/30/01 | NA |
| 171. | ESF Failure from LOOP Subsequent to a LOCA | Rourk | RES/DET/GSIB | NOTE 3(b) | 1 | 12/31/98 | NA |
| 172. | Multiple System Responses Program | Emrit | RES/DET/GSIB | NOTE 3(b) | 2 | 06/30/02 | NA |
| 173. | <u>Spent Fuel Storage Pool</u> | - | - | | | | |
| 173.A | Operating Facilities | Emrit | RES/DET/GSIB | NOTE 3(b) | 4 | 06/30/02 | NA |
| 173.B | Permanently Shutdown Facilities | Emrit | RES/DET/GSIB | NOTE 3(b) | 4 | 06/30/02 | NA |
| 174. | <u>Fastener Gaging Practices</u> | - | - | | | | |
| 174.A | SONGS Employees' Concern | Emrit | RES/DET/GSIB | NOTE 3(b) | 1 | 06/30/00 | NA |
| 174.B | Johnson Gage Company Concern | Emrit | RES/DET/GSIB | NOTE 3(b) | 1 | 06/30/00 | NA |
| 175. | Nuclear Power Plant Shift Staffing | Emrit | RES/DET/GSIB | NOTE 3(b) | 1 | 06/30/00 | NA |
| 176. | Loss of Fill-Oil in Rosemount Transmitters | Emrit | RES/DET/GSIB | NOTE 3(b) | 1 | 06/30/00 | NA |
| 177. | Vehicle Intrusion at TMI | Emrit | RES/DET/GSIB | NOTE 3(a) | 1 | 06/30/00 | NA |
| 178. | Effect of Hurricane Andrew on Turkey Point | Emrit | RES/DET/GSIB | LI (NOTE 3) | 2 | 06/30/00 | |
| 179. | Core Performance | Emrit | RES/DET/GSIB | LI (NOTE 5) | 1 | 06/30/00 | |
| 180. | Notice of Enforcement Discretion | Emrit | RES/DET/GSIB | LI (NOTE 3) | 1 | 06/30/00 | |
| 181. | Fire Protection | Emrit | RES/DET/GSIB | LI (NOTE 5) | 1 | 06/30/00 | |

06/30/02

62

NUREG-0933

Revision 26

06/30/02

63

NUREG-0933

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------|--|-------------------|-------------------------------|-------------------------|-------------|----------------------|---------|
| 182. | General Electric Extended Power Uprate | Emrit | RES/DET/GSIB | RI (NOTE 5) | 1 | 06/30/00 | |
| 183. | Cycle-Specific Parameter Limits in Technical Specifications | Emrit | RES/DET/GSIB | RI (NOTE 3) | 2 | 06/30/00 | |
| 184. | Endangered Species | Emrit | RES/DET/GSIB | EI (NOTE 5) | 1 | 06/30/00 | |
| 185. | Control of Recriticality Following Small-Break LOCA In PWRs | Vandermolen | RES/DSARE/REAHFB | HIGH | | 06/30/01 | |
| 186. | Potential Risk and Consequences of Heavy Load Drops | Lloyd | RES/DSARE/REAHFB | NOTE 4 | | (Later) | |
| 187. | The Potential Impact of Postulated Cesium Concentration on Equipment Qualification in the Containment Sump in Nuclear Power Plants | Vandermolen | RES/DSARE/REAHFB | DROP | | 06/30/01 | NA |
| 188. | Steam Generator Tube Leaks/Ruptures Concurrent with Containment Bypass | VanderMolen | RES/DSARE/REAHFB | Continue | | 06/30/02 | |
| 189. | Susceptibility of Ice Condenser Containments to Early Failure from Hydrogen Combustion During A Severe Accident | VanderMolen | RES/DSARE/REAHFB | Continue | | 06/30/02 | |
| 190. | Fatigue Evaluation of Metal Components for 60-Year Plant Life | Shaukat | RES/DET/GSIB | NOTE 3(b) | 2 | 06/30/00 | NA |
| 191. | Assessment of Debris Accumulation on PWR Sump Performance | Marshall | RES/DET/GSIB | HIGH | 1 | 12/31/98 | |
| 192. | Secondary Containment Drawdown Time | VanderMolen | RES/DSARE/REAHFB | NOTE 4 | | (Later) | |
| 193. | BWR ECCS Suction Concerns | TBD | RES/DSARE/REAHFB | NOTE 4 | | (Later) | |
| 194. | Implications of Updated Probabilistic Seismic Hazard Estimates | TBD | RES/DSARE/REAHFB | NOTE 4 | | (Later) | |

HUMAN FACTORS ISSUESHF1 STAFFING AND QUALIFICATIONS

| | | | | | | | |
|-------|---|---------|---------------|-----------|---|----------|--|
| HF1.1 | Shift Staffing | Pittman | RES/DRPS/RHFB | NOTE 3(a) | 2 | 06/30/89 | |
| HF1.2 | Engineering Expertise on Shift | Pittman | NRD/DHFT/HFIB | NOTE 3(b) | 2 | 06/30/89 | |
| HF1.3 | Guidance on Limits and Conditions of Shift Work | Pittman | NRD/DHFT/HFIB | NOTE 3(b) | 2 | 06/30/89 | |

HF2 TRAINING

| | | | | | | | |
|-------|-----------------------------|---------|---------------|-------------|---|----------|----|
| HF2.1 | Evaluate Industry Training | Pittman | NRD/DHFT/HFIB | LI (NOTE 5) | 1 | 12/31/86 | NA |
| HF2.2 | Evaluate INPO Accreditation | Pittman | NRD/DHFT/HFIB | LI (NOTE 5) | 1 | 12/31/86 | NA |
| HF2.3 | Revise SRP Section 13.2 | Pittman | NRD/DHFT/HFIB | LI (NOTE 5) | 1 | 12/31/86 | NA |

HF3 OPERATOR LICENSING EXAMINATIONS

| | | | | | | | |
|-------|-------------------------------|---------|---------------|-------------|---|----------|----|
| HF3.1 | Develop Job Knowledge Catalog | Pittman | NRD/DHFT/HFIB | LI (NOTE 3) | 2 | 12/31/87 | NA |
|-------|-------------------------------|---------|---------------|-------------|---|----------|----|

Revision 26

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------------|---|----------------------|-------------------------------------|-------------------------------|----------------|----------------------------|------------|
| HF3.2 | Develop License Examination Handbook | Pittman | NRR/DHFT/HFIB | LI (NOTE 3) | 2 | 12/31/87 | NA |
| HF3.3 | Develop Criteria for Nuclear Power Plant Simulators | Pittman | NRR/DHFT/HFIB | I.A.4.2(4) | 2 | 12/31/87 | NA |
| HF3.4 | Examination Requirements | Pittman | NRR/DHFT/HFIB | I.A.2.6(1) | 2 | 12/31/87 | NA |
| HF3.5 | Develop Computerized Exam System | Pittman | NRR/DHFT/HFIB | LI (NOTE 3) | 2 | 12/31/87 | NA |
| <u>HF4</u> | <u>PROCEDURES</u> | | | | | | |
| HF4.1 | Inspection Procedure for Upgraded Emergency Operating Procedures | Pittman | NRR/DLPQ/LHFB | NOTE 3(b) | 6 | 06/30/95 | NA |
| HF4.2 | Procedures Generation Package Effectiveness Evaluation | Pittman | NRR/DHFT/HFIB | LI (NOTE 5) | 6 | 06/30/95 | NA |
| HF4.3 | Criteria for Safety-Related Operator Actions | Pittman | NRR/DHFT/HFIB | B-17 | 6 | 06/30/95 | NA |
| HF4.4 | Guidelines for Upgrading Other Procedures | Pittman | RES/DRPS/RHFB | NOTE 3(b) | 6 | 06/30/95 | NA |
| HF4.5 | Application of Automation and Artificial Intelligence | Pittman | NRR/DHFT/HFIB | HF5.2 | 6 | 06/30/95 | NA |
| <u>HF5</u> | <u>MAN-MACHINE INTERFACE</u> | | | | | | |
| HF5.1 | Local Control Stations | Pittman | RES/DRPS/RHFB | NOTE 3(b) | 4 | 06/30/95 | NA |
| HF5.2 | Review Criteria for Human Factors Aspects of Advanced Controls and Instrumentation | Pittman | RES/DRPS/RHFB | NOTE 3(b) | 4 | 06/30/95 | NA |
| HF5.3 | Evaluation of Operational Aid Systems | Pittman | NRR/DHFT/HFIB | HF5.2 | 4 | 06/30/95 | NA |
| HF5.4 | Computers and Computer Displays | Pittman | NRR/DHFT/HFIB | HF5.2 | 4 | 06/30/95 | NA |
| <u>HF6</u> | <u>MANAGEMENT AND ORGANIZATION</u> | | | | | | |
| HF6.1 | Develop Regulatory Position on Management and Organization | Pittman | NRR/DHFT/HFIB | I.B.1.1 (1,2,3,4) | 1 | 12/31/86 | NA |
| HF6.2 | Regulatory Position on Management and Organization at Operating Reactors | Pittman | NRR/DHFT/HFIB | I.B.1.1 (1,2,3,4) | 1 | 12/31/86 | NA |
| <u>HF7</u> | <u>HUMAN RELIABILITY</u> | | | | | | |
| HF7.1 | Human Error Data Acquisition | Pittman | NRR/DHFT/HFIB | LI (NOTE 5) | 1 | 12/31/86 | NA |
| HF7.2 | Human Error Data Storage and Retrieval | Pittman | NRR/DHFT/HFIB | LI (NOTE 5) | 1 | 12/31/86 | NA |
| HF7.3 | Reliability Evaluation Specialist Aids | Pittman | NRR/DHFT/HFIB | LI (NOTE 5) | 1 | 12/31/86 | NA |
| HF7.4 | Safety Event Analysis Results Applications | Pittman | NRR/DHFT/HFIB | LI (NOTE 5) | 1 | 12/31/86 | NA |
| HF8 | Maintenance and Surveillance Program | Pittman | NRR/DLPQ/LPEB | NOTE 3(b) | 2 | 06/30/88 | NA |

CHERNOBYL ISSUES

06/30/02

64

NUREG-0933

Revision 26

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------------|---|----------------------|-------------------------------------|-------------------------------|----------------|----------------------------|------------|
| <u>CH1</u> | <u>ADMINISTRATIVE CONTROLS AND OPERATIONAL PRACTICES</u> | | | | | | |
| CH1.1 | Administrative Controls to Ensure That Procedures Are Followed and That Procedures Are Adequate | - | - | | | | |
| CH1.1A | Symptom-Based EOPs | Emrit | NRR/DLPQ/LHFB | LI (NOTE 5) | | 06/30/89 | NA |
| CH1.1B | Procedure Violations | Emrit | RES/DSR/HFRB | LI (NOTE 5) | | 06/30/89 | NA |
| CH1.2 | Approval of Tests and Other Unusual Operations | - | - | | | | |
| CH1.2A | Test, Change, and Experiment Review Guidelines | Emrit | NRR/DOEA/OTSB | LI (NOTE 5) | | 06/30/89 | NA |
| CH1.2B | NRC Testing Requirements | Emrit | RES/DSR/HFRB | LI (NOTE 5) | | 06/30/89 | NA |
| CH1.3 | Bypassing Safety Systems | - | - | | | | |
| CH1.3A | Revise Regulatory Guide 1.47 | Emrit | RES/DE/EMEB | LI (NOTE 5) | | 06/30/89 | NA |
| CH1.4 | Availability of Engineered Safety Features | - | - | | | | |
| CH1.4A | Engineered Safety Feature Availability | Emrit | NRR/DOEA/OTSB | LI (NOTE 5) | | 06/30/89 | NA |
| CH1.4B | Technical Specifications Bases | Emrit | NRR/DOEA/OTSB | LI (NOTE 5) | | 06/30/89 | NA |
| CH1.4C | Low Power and Shutdown | Emrit | RES/DSR/PRAB | LI (NOTE 5) | | 06/30/89 | NA |
| CH1.5 | Operating Staff Attitudes Toward Safety | Emrit | RES/DRA/ARGIB | LI (NOTE 3) | | 06/30/89 | NA |
| CH1.6 | Management Systems | - | - | | | | |
| CH1.6A | Assessment of NRC Requirements on Management | Emrit | RES/DSR/HFRB | LI (NOTE 5) | | 06/30/89 | NA |
| CH1.7 | Accident Management | - | - | | | | |
| CH1.7A | Accident Management | Emrit | RES/DSR/HFRB | LI (NOTE 5) | | 06/30/89 | NA |
| <u>CH2</u> | <u>DESIGN</u> | | | | | | |
| CH2.1 | Reactivity Accidents | - | - | | | | |
| CH2.1A | Reactivity Transients | Emrit | RES/DSR/RPSB | LI (NOTE 5) | | 06/30/89 | NA |
| CH2.2 | Accidents at Low Power and at Zero Power | Emrit | RES/DRA/ARGIB | CH1.4 | | 06/30/89 | NA |
| CH2.3 | Multiple-Unit Protection | - | - | | | | |
| CH2.3A | Control Room Habitability | Emrit | RES/DRA/ARGIB | 83 | | 06/30/89 | NA |
| CH2.3B | Contamination Outside Control Room | Emrit | RES/DRA/ARGIB | LI (NOTE 5) | | 06/30/89 | NA |
| CH2.3C | Smoke Control | Emrit | RES/DSIR/SAIB | LI (NOTE 5) | | 06/30/89 | NA |
| CH2.3D | Shared Shutdown Systems | Emrit | RES/DRA/ARGIB | LI (NOTE 5) | | 06/30/89 | NA |
| CH2.4 | Fire Protection | - | - | | | | |
| CH2.4A | Firefighting With Radiation Present | Emrit | RES/DSIR/SAIB | LI (NOTE 5) | | 06/30/89 | NA |
| <u>CH3</u> | <u>CONTAINMENT</u> | | | | | | |
| CH3.1 | Containment Performance During Severe Accidents | - | - | | | | |
| CH3.1A | Containment Performance | Emrit | RES/DSIR/SAIB | LI (NOTE 5) | | 06/30/89 | NA |
| CH3.2 | Filtered Venting | - | - | | | | |
| CH3.2A | Filtered Venting | Emrit | RES/DSIR/SAIB | LI (NOTE 5) | | 06/30/89 | NA |

06/30/02

65

NUREG-0933

Revision 26

06/30/02

66

NUREG-0933

Table II (Continued)

| Action Plan Item/ Issue No. | Title | Priority Engineer | Lead Office/ Division/ Branch | Safety Priority Ranking | Latest Rev. | Latest Issuance Date | MPA No. |
|-----------------------------------|---|----------------------|-------------------------------------|-------------------------------|----------------|----------------------------|------------|
| <u>CH4</u> | <u>EMERGENCY PLANNING</u> | | | | | | |
| CH4.1 | Size of the Emergency Planning Zones | Emrit | RES/DRA/ARGIB | LI (NOTE 3) | | 06/30/89 | NA |
| CH4.2 | Medical Services | Emrit | RES/DRA/ARGIB | LI (NOTE 3) | | 06/30/89 | NA |
| CH4.3 | Ingestion Pathway Measures | - | - | | | | |
| CH4.3A | Ingestion Pathway Protective Measures | Emrit | RES/DSIR/SAIB | LI (NOTE 5) | | 06/30/89 | NA |
| CH4.4 | Decontamination and Relocation | - | - | | | | |
| CH4.4A | Decontamination | Emrit | RES/DSIR/SAIB | LI (NOTE 5) | | 06/30/89 | NA |
| CH4.4B | Relocation | Emrit | RES/DSIR/SAIB | LI (NOTE 5) | | 06/30/89 | NA |
| <u>CH5</u> | <u>SEVERE ACCIDENT PHENOMENA</u> | | | | | | |
| CH5.1 | Source Term | - | - | | | | |
| CH5.1A | Mechanical Dispersal in Fission Product Release | Emrit | RES/DSR/AEB | LI (NOTE 5) | | 06/30/89 | NA |
| CH5.1B | Stripping in Fission Product Release | Emrit | RES/DSR/AEB | LI (NOTE 5) | | 06/30/89 | NA |
| CH5.2 | Steam Explosions | - | - | | | | |
| CH5.2A | Steam Explosions | Emrit | RES/DSR/AEB | LI (NOTE 5) | | 06/30/89 | NA |
| CH5.3 | Combustible Gas | Emrit | RES/DRA/ARGIB | LI (NOTE 3) | | 06/30/89 | NA |
| <u>CH6</u> | <u>GRAPHITE-MODERATED REACTORS</u> | | | | | | |
| CH6.1 | Graphite-Moderated Reactors | - | - | | | | |
| CH6.1A | The Fort St. Vrain Reactor and the Modular HTGR | Emrit | RES/DRA/ARGIB | LI (NOTE 3) | | 06/30/89 | NA |
| CH6.1B | Structural Graphite Experiments | Emrit | RES/DRA/ARGIB | LI (NOTE 3) | | 06/30/89 | NA |
| CH6.2 | Assessment | Emrit | RES/DRA/ARGIB | LI (NOTE 3) | | 06/30/89 | NA |

Revision 26

TABLE IIISUMMARY OF THE PRIORITIZATION OF ALL TMI ACTION PLAN ITEMS,
TASK ACTION PLAN ITEMS, NEW GENERIC ISSUES, HUMAN FACTORS ISSUES, AND CHERNOBYL ISSUESLegend

| | |
|-----------------|--|
| NOTES: | 1 - Possible Resolution Identified for Evaluation |
| | 2 - Resolution Available |
| | 3 - Resolution Resulted in either the Establishment of New Requirements or No New Requirements |
| | 4 - Issues to be Prioritized in the Future |
| | 5 - Issues that are not GSIs but Should be Assigned Resources for Completion |
| DROP | - GSI Dropped from Further Pursuit |
| EI | - Environmental Issue |
| GSI | - Generic Safety Issue |
| HIGH | - High Safety Priority |
| I | - TMI Action Plan Item with Implementation of Resolution Mandated by NUREG-0737 |
| LI | - Licensing Issue |
| LOW | - Low Safety Priority |
| MEDIUM | - Medium Safety Priority |
| RI | - Regulatory Impact Issue |
| USI | - Unresolved Safety Issue |
| Continue | - As defined in NRC Management Directive 6.4 |

TABLE III

TABLE III (Continued)

| ACTION ITEM/ISSUE GROUP | I | S | RESOLVED STAGES | | | USI | HIGH | MEDIUM | LOW | DROP | CONT. | NOTE 4 | NOTE 5 | TOTAL |
|-------------------------------------|-----------|------------|-----------------|-----------|------------|----------|----------|----------|-----------|------------|----------|-----------|-----------|------------|
| | | | NOTE 1 | NOTE 2 | NOTE 3 | | | | | | | | | |
| TMI ACTION PLAN ITEM (369) | | | | | | | | | | | | | | |
| GSI | 84 | 46 | 0 | 0 | 135 | 0 | 0 | 0 | 12 | 9 | - | - | - | 286 |
| LI | - | 0 | - | - | 75 | - | - | - | - | - | - | - | 8 | 83 |
| TASK ACTION PLAN ITEMS (142) | | | | | | | | | | | | | | |
| USI | - | - | - | - | 27 | 0 | - | - | - | - | - | - | - | 27 |
| GSI | - | 20 | 0 | 0 | 36 | - | 0 | 0 | 0 | 14 | - | - | - | 70 |
| RI | - | - | - | - | 6 | - | - | - | - | - | - | - | 1 | 7 |
| LI | - | - | - | - | 11 | - | - | - | - | - | - | - | 12 | 23 |
| EI | - | - | - | - | 13 | - | - | - | - | - | - | - | 2 | 15 |
| NEW GENERIC ISSUES (274) | | | | | | | | | | | | | | |
| GSI | - | 54 | 0 | 0 | 82 | 0 | 6 | 0 | 4 | 97 | 2 | 3 | - | 248 |
| RI | - | 1 | - | - | 5 | - | - | - | - | 1 | - | - | 5 | 12 |
| LI | - | 1 | - | - | 8 | - | - | - | - | - | - | - | 4 | 13 |
| EI | - | - | - | - | - | - | - | - | - | - | - | - | 1 | 1 |
| HUMAN FACTORS ISSUES (27) | | | | | | | | | | | | | | |
| GSI | - | 8 | 0 | 0 | 8 | 0 | 0 | 0 | 0 | 0 | - | - | - | 16 |
| LI | - | - | - | - | 3 | - | - | - | - | - | - | - | 8 | 11 |
| CHERNOBYL ISSUES (32) | | | | | | | | | | | | | | |
| LI | - | 2 | - | - | 7 | - | - | - | - | - | - | - | 23 | 32 |
| TOTAL: | 84 | 132 | 0 | 0 | 416 | 0 | 6 | 0 | 16 | 121 | 2 | 3 | 64 | 844 |

06/30/02

68

NUREG-0933

Revision 26

SECTION 2TASK ACTION PLAN ITEMS

This section contains all Task Action Plan Items documented in NUREG-0371² and NUREG-0471³ as well as all USIs documented in other NRC publications. Items A-1 through A-41 are listed in NUREG-0371² and all items with prefixes "B," "C," and "D" are listed in NUREG-0471.³ USIs identified after publication of NUREG-0371² and NUREG-0471³ are listed in the following documents: NUREG-0510¹⁸⁶ (A-42 through A-44); NUREG-0705⁴⁴ (A-45 through A-48); and NUREG-1090¹⁷⁸⁸ (A-49). A total of 142 items are listed in this section.

The Generic Issues Tracking System (GITS) Report³⁸ issued on December 17, 1981, provided a status report on the majority of the 142 items as well as their classification into four categories: Environmental, Licensing Improvement, Safety, and USI. The safety issues identified in the GITS Report³⁸ provided the basis for all prioritization work contained in this section. The lead responsibility and a summary of the findings for each item listed in this section can be found in Table II of the Introduction.

ITEM A-1: WATER HAMMERDESCRIPTION

The issue was raised after the occurrence of various incidents of water hammer that involved steam generator feedings and piping, emergency core cooling systems, RHR systems, containment spray, service water, feedwater, and steam lines. The incidents were attributed to such causes as rapid condensation of steam pockets, steam-driven slugs of water, pump startup with partially empty lines, and rapid valve motion. Most of the damage was relatively minor and involved pipe hangers and restraints. However, there were several incidents which resulted in piping and valve damage. This item was originally identified in NUREG-0371² and was later declared a USI in NUREG-0510.¹⁸⁶

No water hammer incident resulted in the release of radioactivity outside of plants. However, because of the continuing incidence of water hammer events, the number of phenomena, and the potential safety significance of the systems involved, the staff believed that systematic review procedures needed to be developed to ensure that water hammer would be given appropriate consideration in CP and OL reviews, and in the review of operating reactors.

CONCLUSION

This USI was RESOLVED with the publication of NUREG-0927, Rev. 1,⁶⁹⁸ and the following SRP¹¹ Sections: 3.9.3, Rev. 1; 3.9.4, Rev. 2; 5.4.6, Rev. 3; 5.4.7, Rev. 3; 6.3, Rev. 2; 9.2.1, Rev. 3; 9.2.2, Rev. 2; 10.3, Rev. 3; and 10.4.7, Rev. 3. The revised SRP Sections will be used only for the review of "custom plant" CP applications and for standard plant applications docketed after the issuance of these revised SRP Sections (which are intended for referencing in CP applications). Thus, this USI will affect all future plants only.

REFERENCES

2. NUREG-0371, "Task Action Plans for Generic Activities (Category A)," U.S. Nuclear Regulatory Commission, November 1978.
11. NUREG-0800, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants," U.S. Nuclear Regulatory Commission, (1st Edition) November 1975, (2nd Edition) March 1980, (3rd Edition) July 1981.
186. NUREG-0510, "Identification of Unresolved Safety Issues Relating to Nuclear Power Plants," U.S. Nuclear Regulatory Commission, January 1979.
698. NUREG-0927, Revision 1, "Evaluation of Water Hammer Occurrences in Nuclear Power Plants," U.S. Nuclear Regulatory Commission, March 1984.

ITEMA-2: ASYMMETRIC BLOWDOWN LOADS ON REACTOR PRIMARY COOLANT SYSTEMS

DESCRIPTION

On May 7, 1975, the NRC was informed by VEPCO that an asymmetric loading on the reactor vessel supports resulting from a postulated reactor coolant pipe rupture at a specific location (e.g., the vessel nozzle) had not been considered by W or S&W in the original design of the reactor vessel support systems for North Anna Units 1 and 2. This item was originally identified in NUREG-0371² and was later declared a USI in NUREG-0510.¹⁸⁶

In a postulated event at the vessel nozzle, asymmetric LOCA loading could result from forces induced on the reactor internals by transient differential pressures across the core barrel and by forces on the vessel due to transient differential pressures in the reactor cavity. With the advent of more sophisticated computer codes and the accompanying more-detailed analytical models, it became apparent to W that such differential pressures, although of short duration, could place a significant load on the reactor vessel supports, thereby affecting their integrity. This issue was determined by the NRC to have generic implications for all PWRs.

CONCLUSION

This USI was RESOLVED with the publication of NUREG-0609⁶⁹⁹ and affected all operating and future PWRs. For operating PWRs, MPA D-10 was established by DL/NRR for implementation purposes. Generic Letter 84-04⁷⁰⁰ was also issued by the staff.

REFERENCES

2. NUREG-0371, "Task Action Plans for Generic Activities (Category A)," U.S. Nuclear Regulatory Commission, November 1978.
186. NUREG-0510, "Identification of Unresolved Safety Issues Relating to Nuclear Power Plants," U.S. Nuclear Regulatory Commission, January 1979.
699. NUREG-0609, "Asymmetric Blowdown Loads on PWR Primary Systems," U.S. Nuclear Regulatory Commission, January 1981.
700. NRC Letter to All Operating PWR Licenses, Construction Permit Holders, and Applicants for Construction Permits, "Safety Evaluation of Westinghouse Topical Reports Dealing with Elimination of Postulated Pipe Breaks in PWR Primary Main Loops (Generic Letter 84-04)," February 1, 1984.

ITEM A-3: WESTINGHOUSE STEAM GENERATOR TUBE INTEGRITY

DESCRIPTION

Prior to 1978, operating experience with PWR steam generators was characterized by extensive corrosion and mechanically-induced degradation of the steam generator tubes, frequent plant shutdowns to repair primary-to-secondary leaks, and two SGTR events (Point Beach 1 in 1975 and Surry 2 in 1976). In 1978, Task Action Plans for Items A-3, A-4, and A-5 were established in NUREG-0371² to evaluate the safety significance of degradation in W, CE, and B&W steam generators, respectively. These items were later declared USIs in NUREG-0510¹⁸⁶ and were combined into one effort because many problems with PWR steam generators supplied by the three vendors were similar. Thus, an integrated program was developed for the resolution of USIs A-3, A-4, and A-5.

After SGTR events at Prairie Island 1 in 1979 and at Ginna in 1982, the staff initiated an integrated program to evaluate a number of recommendations stemming from the early USI effort and from lessons learned as a result of the SGTR events. The objective of the integrated program was to complete resolution of USIs A-3, A-4, and A-5, including identification of new requirements that could be imposed on OL applicants and licensees and identification of further efforts that should be undertaken by NRC. The results of this program were documented in NUREG-0844.⁶⁸¹

The staff's risk analysis, as described in Section 3 of NUREG-0844,⁶⁸¹ indicated that SGTR events beyond the design basis did not constitute a significant fraction of the early and latent cancer fatality risks associated with reactor events at a given site. Furthermore, the risk assessment indicated that the increment in risk associated with SGTR events was a small fraction of the accidental and latent cancer fatality risks to which the general public is routinely exposed. These findings reflected not just the effectiveness of NRC regulatory guidance and TS requirements, but very importantly also reflected industry efforts to improve steam generator reliability which was of significant economic importance to the industry, in addition to providing added assurance of public health and safety.

The risk estimates documented in NUREG-0844⁶⁸¹ were based on consequence calculations that employed population distributions, protective actions, and meteorological assumptions equivalent to those presented in the Byron final environmental statement (NUREG-0848).¹¹³⁵ The staff completed a comparative analysis which confirmed that the risk from SGTR-related causes did not exceed the Commission's safety goals on early or latent fatalities. Early fatality risks were estimated to be less than 10% of the safety goal, and the latent fatality risks were found to be a very small fraction of the safety goal.

In view of the relatively low risk estimates associated with SGTR events, the staff concluded that new generic requirements that had initially been proposed as part of the USI program were not warranted. However, the staff found in its value-impact analysis that a number of these proposals, as a group, were effective measures for significantly reducing the incidence of tube degradation, the frequency of SGTRs and the corresponding potential for significant non-core-melt release, and occupational exposures, and were consistent with good operating and engineering practice. As a group, these actions were considered to be effective measures for mitigating the consequences of SGTRs. Adoption of these actions by licensees would further reduce public risk (by as much as

70%) and provide added assurance that risk would continue to be small. These actions were designated as staff-recommended actions.

CONCLUSION

As part of the steam generator USI program, the staff issued Generic Letter 85-02¹¹³⁶ to all PWR licensees and applicants to inform them of the staff-recommended actions and to request a description of their overall programs for ensuring steam generator tube integrity and SGTR mitigation. The staff's assessment of the licensee and applicant responses to Generic Letter 85-02¹¹³⁶ was provided to the Commission in SECY-86-97¹¹³⁷ in March 1986. The staff concluded on the basis of this assessment that the large majority of the licensees and applicants were following programs, practices, and/or procedures that were partially to fully consistent with, or equivalent to, the staff-recommended actions.

Following the North Anna 1 SGTR event on July 15, 1987, NRC Bulletin No. 88-02¹¹³⁸ was issued requesting that licensees and OL applicants perform specified inspections and analyses to determine whether their plants were susceptible to the failure mechanism that led to the North Anna event, and that they implement corrective actions, if necessary.

The Commission's current regulations (10 CFR Part 50, Appendices A and B; 10 CFR 50.55a; 10 CFR 50.109; and 10 CFR Part 100) provide the staff with sufficient authority to ensure that licensees implement programs relating to steam generator tube integrity that provide adequate protection to public health and safety. The staff will continue to monitor steam generator experience as an indicator of the effectiveness of licensee programs for ensuring steam generator tube integrity. As exemplified by Bulletin 88-02,¹¹³⁸ the staff may impose additional requirements (pursuant to applicable regulations) to continue to ensure that licensees adequately implement effective programs where such action is determined to be necessary on the basis of operating experience, or as a result of ongoing staff studies. Thus, as stated in SECY-88-272,¹¹³⁹ USIs A-3, A-4, and A-5 were RESOLVED and requirements were established.

REFERENCES

2. NUREG-0371, "Task Action Plans for Generic Activities (Category A)," U.S. Nuclear Regulatory Commission, November 1978.
186. NUREG-0510, "Identification of Unresolved Safety Issues Relating to Nuclear Power Plants," U.S. Nuclear Regulatory Commission, January 1979.
681. NUREG-0844, "NRC Integrated Program for the Resolution of Unresolved Safety Issues A-3, A-4, A-5 Regarding Steam Generator Tube Integrity," U.S. Nuclear Regulatory Commission, September 1988.
1135. NUREG-0848, "Final Environmental Statement Related to the Operation of Byron Station Units 1 and 2," U.S. Nuclear Regulatory Commission, April 1982.
1136. NRC Letter to All PWR Licensees of Operating Reactors, Applicants for Operating Licenses, and Holders of Construction Permits, and Ft. St. Vrain, "Staff Recommended Actions Stemming from NRC Integrated Program for the Resolution of Unresolved Safety Issues Regarding Steam Generator Tube Integrity (Generic Letter 85-02)," April 17, 1985.

- 1137. SECY-86-97, "Steam Generator USI Program - Utility Responses to Staff Recommendations in Generic Letter 85-02," March 24, 1986.
- 1138. NRC Bulletin No. 88-02, "Rapidly Propagating Fatigue Cracks in Steam Generator Tubes," February 5, 1988.
- 1139. SECY-88-272, "Technical Resolution of Unresolved Safety Issues A-3, A-4, and A-5 Regarding Steam Generator Tube Integrity," September 27, 1988.

ITEM A-4: CE STEAM GENERATOR TUBE INTEGRITY

DESCRIPTION

This item was originally identified in NUREG-0371² and was later declared a USI in NUREG-0510.¹⁸⁶ (See Item A-3 for further details.)

CONCLUSION

This item was RESOLVED and requirements were established. (See Item A-3 for further details.)

REFERENCES

2. NUREG-0371, "Task Action Plans for Generic Activities (Category A)," U.S. Nuclear Regulatory Commission, November 1978.
186. NUREG-0510, "Identification of Unresolved Safety Issues Relating to Nuclear Power Plants," U.S. Nuclear Regulatory Commission, January 1979.

ITEM A-5: B&W STEAM GENERATOR TUBE INTEGRITY

DESCRIPTION

This item was originally identified in NUREG-0371² and was later declared a USI in NUREG-0510.¹⁸⁶ (See Item A-3 for further details.)

CONCLUSION

This item was RESOLVED and requirements were established. (See Item A-3 for further details.)

REFERENCES

2. NUREG-0371, "Task Action Plans for Generic Activities (Category A)," U.S. Nuclear Regulatory Commission, November 1978.
186. NUREG-0510, "Identification of Unresolved Safety Issues Relating to Nuclear Power Plants," U.S. Nuclear Regulatory Commission, January 1979.

ITEM A-6: MARK I SHORT-TERM PROGRAMDESCRIPTION

During the conduct of a large scale testing program for an advanced design BWR pressure suppression containment system (MARK III), new suppression pool hydrodynamic loads associated with a postulated LOCA were identified which had not been explicitly included in the original design of the MARK I containment systems. These additional loads result from the dynamic effects of drywell air and steam being rapidly forced into the suppression pool (Torus) during a postulated LOCA event. Consequently, it was determined that a reassessment of the MARK I containment system design would be required. This item was originally identified in NUREG 0371² and was later declared a USI in NUREG-0510.¹⁸⁶

CONCLUSION

This USI was RESOLVED with the publication of NUREG-0408.⁷⁰¹ All plant-unique analyses and required equipment modifications were reviewed and accepted by the staff and appropriate TS changes were made by the affected licensees.

REFERENCES

2. NUREG-0371, "Task Action Plans for Generic Activities (Category A)," U.S. Nuclear Regulatory Commission, November 1978.
186. NUREG-0510, "Identification of Unresolved Safety Issues Relating to Nuclear Power Plants," U.S. Nuclear Regulatory Commission, January 1979.
701. NUREG-0408, "MARK I Containment Short-Term Program Safety Evaluation Report," U.S. Nuclear Regulatory Commission, December 1977.

ITEM A-7: MARK I LONG-TERM PROGRAMDESCRIPTION

During testing for an advanced BWR containment system design (MARK III), suppression pool hydrodynamic loads were identified which had not been considered in the original design of the MARK I containment system. To address this issue, a MARK I Owners' Group was formed and the assessment was divided into a short-term and a long-term program. The results of the NRC staff's review of the MARK I Containment Short-Term Program were documented in NUREG-0408.⁷⁰¹ The long-term program was conducted to provide a generic basis to define suppression pool hydrodynamic loads and the related structural acceptance criteria, such that a comprehensive reassessment of each MARK I containment system could be performed.

A series of experimental and analytical programs were conducted by the MARK I Owners' Group to provide the necessary bases for the generic load definition and structural assessment techniques. The generic methods proposed by the MARK I Owners' Group, as modified by the NRC staff's requirements, were to be used to perform plant-unique analyses which would identify the plant modifications, if any, needed to restore the originally intended margin of safety in the MARK I containment designs. This item was originally identified in NUREG-0371² and was later declared a USI in NUREG-0510.¹⁸⁶

CONCLUSION

This USI was RESOLVED with the issuance of Supplement 1 to NUREG-0661⁷⁰² and SRP¹¹ Section 6.2.1.1C. For operating BWRs, MPA D-01 was established by DL/NRR for implementation purposes.

REFERENCES

2. NUREG-0371, "Task Action Plans for Generic Activities (Category A)," U.S. Nuclear Regulatory Commission, November 1978.
11. NUREG-0800, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants," U.S. Nuclear Regulatory Commission, (1st Edition) November 1975, (2nd Edition) March 1980, (3rd Edition) July 1981.
186. NUREG-0510, "Identification of Unresolved Safety Issues Relating to Nuclear Power Plants," U.S. Nuclear Regulatory Commission, January 1979.
701. NUREG-0408, "Mark I Containment Short-Term Program Safety Evaluation Report," U.S. Nuclear Regulatory Commission, December 1977.
702. NUREG-0661, "Mark I Containment Long Term Program Safety Evaluation Report, Resolution of Generic Technical Activity A-7," U.S. Nuclear Regulatory Commission, July 1980, (Supplement 1) August 1982.

ITEM A-8: MARK II CONTAINMENT POOL DYNAMIC LOADS LONG-TERM PROGRAMDESCRIPTION

As a result of the GE testing program for the MARK III pressure-suppression containment program, new containment loads associated with a postulated LOCA were identified in 1975 which had not been explicitly included in the original design of MARK I and MARK II containments. These loads resulted from the dynamic effects of drywell air and steam being rapidly forced into the suppression pool during a postulated LOCA event. Other pool dynamic loads previously unaccounted for resulted from the actuation of SRVs in the MARK II containment. The review and evaluation of the MARK I loads were addressed in USI A-7, and SRV loads for all suppression-type containments were addressed in USI A-39. This item was originally identified in NUREG-0371² and was later declared a USI in NUREG-0510.¹⁸⁶

CONCLUSION

This USI was RESOLVED with the issuance of NUREG-0808⁷⁰³ and SRP¹¹ Section 6.2.1.1C.

REFERENCES

2. NUREG-0371, "Task Action Plans for Generic Activities (Category A)," U.S. Nuclear Regulatory Commission, November 1978.
11. NUREG-0800, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants," U.S. Nuclear Regulatory Commission, (1st Edition) November 1975, (2nd Edition) March 1980, (3rd Edition) July 1981.
186. NUREG-0510, "Identification of Unresolved Safety Issues Relating to Nuclear Power Plants," U.S. Nuclear Regulatory Commission, January 1979.
703. NUREG-0808, "MARK II Containment Program Evaluation and Acceptance Criteria," U.S. Nuclear Regulatory Commission, August 1981.

ITEM A-9: ATWSDESCRIPTION

The technical report on ATWS for water-cooled reactors (WASH-1270)⁷⁵¹ discussed the probability of an ATWS event as well as an appropriate safety objective for the event. After several years of discussions with vendors and evaluations of vendor models and analyses, the staff published a status report on each vendor analysis in 1975. This report included detailed guidelines on analysis models and ATWS safety objectives. This item was originally identified in NUREG-0371² and was later declared a USI in NUREG-0510.¹⁸⁶

CONCLUSION

The staff's technical findings were published in Volume 4 of NUREG-0460⁷⁰⁴ and the USI was RESOLVED with the publication of a final rule.^{724,725}

REFERENCES

2. NUREG-0371, "Task Action Plans for Generic Activities (Category A)," U.S. Nuclear Regulatory Commission, March 1980.
186. NUREG-0510, "Identification of Unresolved Safety Issues Relating to Nuclear Power Plants," U.S. Nuclear Regulatory Commission, January 1979.
704. NUREG-0460, "Anticipated Transients Without Scram for Light Water Reactors," U.S. Nuclear Regulatory Commission, March 1980.
724. Memorandum for W. Dircks, et al., from S. Chilk, "Staff Requirements - Affirmation/Discussion and Vote, 11:30 a.m., Friday, June 1, 1984, Commissioners' Conference Room, D.C. Office (Open to Public Attendance)," June 1, 1984.
725. Federal Register Notice 49 FR 26036, "10 CFR Part 50, Reduction of Risk from Anticipated Transients Without Scram (ATWS) Events for Light-Water-Cooled Nuclear Power Plants," June 26, 1984.
751. WASH-1270, "Anticipated Transients Without Scram for Water-Cooled Reactors," U.S. Nuclear Regulatory Commission, September 1973.

ITEM A-10: BWR FEEDWATER NOZZLE CRACKINGDESCRIPTION

Inspections of operating BWRs conducted up to April 1978 revealed cracks in the feedwater nozzles of 20 reactor vessels. Most of these BWRs contained 4 nozzles with diameters ranging from 10 in. to 12 in. Although most cracks ranged from 1/2 in. to 3/4 in. in depth (including cladding), one crack penetrated the cladding into the base metal for a total depth of approximately 1.5 in. It was determined that cracking was due to high-cycle fatigue caused by fluctuations in water temperature within the vessel in the nozzle region. These fluctuations occurred during periods of low feedwater temperature when flow is unsteady and intermittent. Once initiated, the cracks enlarge from high pressure and thermal cycling associated with startups and shutdowns. This item was originally identified in NUREG-0371² and was later declared a USI in NUREG-0510.¹⁸⁶

CONCLUSION

This issue was RESOLVED with the issuance of NUREG-0619⁷⁴² and MPA B-25 was established by DL/NRR for implementation purposes.

REFERENCES

2. NUREG-0371, "Task Action Plans for Generic Activities (Category A)," U.S. Nuclear Regulatory Commission, November 1978.
186. NUREG-0510, "Identification of Unresolved Safety Issues Relating to Nuclear Power Plants," U.S. Nuclear Regulatory Commission, January 1979.
742. NUREG-0619, "BWR Feedwater Nozzle and Control Rod Drive Return Line Nozzle Cracking," U.S. Nuclear Regulatory Commission, November 1980.

ITEM A-11: REACTOR VESSEL MATERIALS TOUGHNESSDESCRIPTION

Because of the remote possibility of failure of nuclear reactor pressure vessels designed to the ASME Boiler and Pressure Vessel Code, the design of nuclear facilities does not provide protection against reactor vessel failure. Prevention of reactor vessel failure depends primarily on maintaining the reactor vessel material fracture toughness at levels that will resist brittle fracture during plant operation. At service times and operating conditions typical of existing operating plants, reactor vessel fracture toughness properties provide adequate margins of safety against vessel failure; however, as plants accumulate more and more service time, neutron irradiation reduces the material fracture toughness and initial safety margins. This item was originally identified in NUREG-0371² and was later declared a USI in NUREG-0510.¹⁸⁶

CONCLUSION

This USI was RESOLVED with the issuance of NUREG-0744,⁷⁴³ Revision 1, which was later transmitted to all licensees with Generic Letter 82-26.⁷⁴⁴

REFERENCES

2. NUREG-0371, "Task Action Plans for Generic Activities (Category A)," U.S. Nuclear Regulatory Commission, November 1978.
186. NUREG-0510, "Identification of Unresolved Safety Issues Relating to Nuclear Power Plants," U.S. Nuclear Regulatory Commission, January 1979.
743. NUREG-0744, "Resolution of the Task A-11 Reactor Vessel Materials Toughness Safety Issue," U.S. Nuclear Regulatory Commission, (Rev. 1) October 1982.
744. NRC Letter to All Power Reactor Licensees (Except Ft. St. Vrain), "NUREG-0744 Rev. 1; Generic Letter No. 82-26 - Pressure Vessel Material Fracture Toughness," November 12, 1982.

ITEM A-12: FRACTURE TOUGHNESS OF STEAM GENERATOR AND REACTOR COOLANT PUMP SUPPORTS

DESCRIPTION

During the course of the licensing action for North Anna Units 1 and 2, a number of questions were raised as to the potential for lamellar tearing and low fracture toughness of the steam generator and RCP support materials for these facilities. Two different steel specifications (ASTM A36 and ASTM A572) covered most of the material used for these supports. Toughness tests, not originally specified and not in the relevant ASTM specifications, were made at various temperatures. The toughness of the A36 steel was found to be adequate, but the toughness of the A572 steel was relatively poor at a temperature of 80°F. In the case of North Anna Units 1 and 2, the applicant agreed to raise the temperature of the A572 beams in the steam generator supports to a minimum temperature of 225°F, prior to reactor coolant system pressurization to levels above 1,000 psig. Auxiliary electrical heat was supplied as necessary to supplement the heat derived from the reactor coolant loop to obtain the required operating temperature of the support materials. Concerns regarding the supports at North Anna were applicable to all PWRs. This item was originally identified in NUREG-0371² and was later declared a USI in NUREG-0510.¹⁸⁶

CONCLUSION

This USI was RESOLVED with the publication of NUREG-0577,³⁸⁸ Revision 1. The resolution contained no backfit requirements and applied only to new construction after issuance of SRP¹¹ Section 5.3.4.

REFERENCES

2. NUREG-0371, "Task Action Plans for Generic Activities (Category A)," U.S. Nuclear Regulatory Commission, November 1978.
11. NUREG-0800, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants," U.S. Nuclear Regulatory Commission, (1st Edition) November 1975, (2nd Edition) March 1980, (3rd Edition) July 1981.
186. NUREG-0510, "Identification of Unresolved Safety Issues Relating to Nuclear Power Plants," U.S. Nuclear Regulatory Commission, January 1979.
388. NUREG-0577, "Potential for Low Fracture Toughness and Lamellar Tearing in PWR Steam Generator and Reactor Coolant Pump Supports," U.S. Nuclear Regulatory Commission, (Rev. 1) October 1983.

ITEM A-13: SNUBBER OPERABILITY ASSURANCE

DESCRIPTION

Historical Background

In May 1978, the ACRS and the staff expressed concern over the substantial number of LERs related to the malfunction of snubbers, the most frequent of which were: (1) seal leakage in hydraulic snubbers; and (2) high rejection rate during functional testing of snubbers. In reviewing these LERs, the staff noted differences in the numbers of snubbers utilized in systems of similar configurations and questioned the methodology used for determining the need for snubbers in any given system. As a result of these concerns and the desire to provide a significant increase in assurance of the health and safety of the public, snubber operability assurance was given a priority Category A designation and included in NUREG-0371.²

Safety Significance

Snubbers are utilized primarily as seismic and pipe whip restraints at nuclear power plants. Their safety function is to operate as rigid supports for restraining the motion of attached systems or components under rapidly applied load conditions such as earthquakes, pipe breaks, and severe hydraulic transients.

Possible Solutions

The solutions proposed in NUREG-0371² were as follows: (1) evaluation of industry practice associated with snubber qualification testing, design and analysis procedures, selection and specification criteria, and pre-service and in-service inspection programs; and (2) development of TS, SRP¹¹ revisions, and Regulatory Guides to assure a high level of snubber operability.

CONCLUSION

In 1980, the staff addressed the operation of snubbers with revisions to STS 3/4.7.9; SRP¹¹ Section 3.9.3 was later revised in 1981. A draft regulatory guide (Task SC-708-4)¹² on the qualification and acceptance tests for snubbers used in systems important to safety was issued by the staff, but was later withdrawn when it was determined that there were no plans for its use in the licensing process.⁹ Thus, with the SRP revision, this issue was RESOLVED and requirements were issued.

REFERENCES

2. NUREG-0371, "Task Action Plans for Generic Activities (Category A)," U.S. Nuclear Regulatory Commission, November 1978.
9. Federal Register Notice 54 FR 16030, "Draft Regulatory Guide; Withdrawal," April 20, 1989.
11. NUREG-0800, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants," U.S. Nuclear Regulatory Commission, (1st Edition) November 1975, (2nd Edition) March 1980, (3rd Edition) July 1981.

12. Draft Regulatory Guide and Value/Impact Statement, Task SC 708-4, "Qualification and Acceptance Tests for Snubbers Used in Systems Important to Safety," U.S. Nuclear Regulatory Commission, February 1981.

ITEM A-14: FLAW DETECTION

DESCRIPTION

Historical Background

After the 1970 issuance of inspection requirements in Section XI of the ASME Boiler and Pressure Vessel Code,¹⁴ the staff recognized the need to quantify the uncertainty in the existing inspection requirement techniques. Also, the staff recognized its responsibility to upgrade these requirements, if necessary, when improvements in inspection techniques became commercially available.

This item was identified in NUREG-0371² and consisted of quantifying and upgrading the reliability of existing ISI techniques and of developing, evaluating, and validating improved techniques for flaw detection and evaluation during ISI of primary system components. The results were to be used in improving ASME Code Section XI¹⁴ inspection provisions, and preparing Regulatory Guides as needed. At the time of the evaluation of this issue in 1983, a major part of the NRC effort on the issue was being carried out under the RES program on NDE (RES Long Range Research Plan, Program 6.3). This program resulted in the issuance of a new Regulatory Guide 1.150¹⁴¹ and preparation of improved piping inspection provisions which were to be incorporated into Section XI¹⁴ of the ASME Code.

Safety Significance

As part of the defense-in-depth approach, components and structures are inspected in order to detect and repair flaws well before they reach a critical size and lead to undesirable consequences ranging from small leaks to a large LOCA.

It was believed that improvements in flaw detection reliability and capability could contribute to reducing the risk associated with specific safety issues that were open at the time this issue was evaluated: Issue 15, "Radiation Effects on Reactor Vessel Supports," and Issue 29, "Bolting Degradation or Failure in Nuclear Power Plants." This issue was also part of USIs A-3, A-4, and A-5 which addressed steam generator tube integrity. It was believed that improved flaw detection would provide a longer-term contribution to the resolution of USI A-12, "Fracture Toughness of Steam Generator and Reactor Coolant Pump Supports," and USI A-49, "Pressurized Thermal Shock." Resolution of this issue was expected to provide the experimental basis for the technical position of a planned Regulatory Guide on ISI of austenitic stainless steel piping.

Possible Solution

If successfully resolved, this issue would quantify: (1) the uncertainties concerning the smallest size defect which could reliably be detected by required inspection techniques; and (2) the dimensions of identified defects. Thus, the uncertainty in the resolution of other safety issues could be reduced and, possibly, could allow for modifications of some inspection requirements.

CONCLUSION

This item was not a safety issue by itself but was only amenable to risk reduction value/impact assessment by reference to other issues. This was an ongoing task that was sponsored by RES, with the results of development efforts on the part of both NRC and industry (EPRI) to be used for improving the inspection provisions of Section XI¹⁴ of the ASME Code and for providing the technical basis for Regulatory Guides related to ISI. These efforts were to be closely monitored by the users of the results to ensure that they were directly applied to the resolution of the safety issues identified above. Since this item was largely an RES program which served a number of generic issues, it was DROPPED from further consideration as a separate issue.

REFERENCES

2. NUREG-0371, "Task Action Plans for Generic Activities (Category A)," U.S. Nuclear Regulatory Commission, November 1978.
14. ASME Boiler and Pressure Vessel Code, Section XI, "Rules for Inservice Inspection of Nuclear Power Plant Components," American Society of Mechanical Engineers, 1974.
141. Regulatory Guide 1.150, "Ultrasonic Testing of Reactor Vessel Welds During Preservice and Inservice Examinations," U.S. Nuclear Regulatory Commission, June 1981, (Rev. 1) February 1983.

ITEM A-15: PRIMARY COOLANT SYSTEM DECONTAMINATION AND STEAM GENERATOR CHEMICAL CLEANING

DESCRIPTION

Historical Background

Operation of a LWR results in slow corrosion of the interior metal surfaces of the primary coolant system. The resulting corrosion products circulate through the reactor core and are activated by neutron flux from the fissioning reactor fuel. While some of these activated corrosion products are removed by the reactor's water chemistry system, a small amount is continually deposited or plated out on the primary coolant system's internal surfaces. Once activated corrosion products are deposited or plated out, they are not removed by the reactor water cleanup system and continue to accumulate. As a direct result of this accumulation, radiation levels in the vicinity of the primary system rise, thus inhibiting or complicating routine inspection and maintenance of the primary system. This issue was identified in NUREG-0371² and, at the time of its evaluation in 1983, technical activities in pursuit of a solution were in progress by groups that were sponsored by government and private industry prior to 1977.

Safety Significance

Decontamination of primary coolant systems and steam generators is not a safety issue related to the health and safety of the general public but rather to the health and safety of workers in nuclear power plants. Annual occupational radiation doses from the operation and maintenance of nuclear reactors tend to increase with increasing reactor age.^{78,79} Much of this increase is due to the continued deposition of highly activated corrosion products, such as Co-60 and Co-58, in various locations in the primary coolant system. In 1979, the average occupational collective radiation dose per operating PWR was 510 man-rem and the corresponding figure per operating BWR was 733 man-rem.⁷⁸ Approximately 80% of the occupational radiation dose resulted from inspection and maintenance activities⁷⁸ which were mostly related to the primary coolant system.

Possible Solutions

Periodic removal of activated corrosion products would reduce occupational exposure due to maintenance and inspection activities. Two methods were proposed for decontaminating reactors intended to be returned to service: (1) strong solution decontamination, such as NS-1 (Dow Chemical); and (2) weak or dilute contamination solutions. Weak solutions are typically CAN-DECON (London Nuclear Limited), LOMI (Central Electric Generating Board), hydrogen peroxide/citric acid, and hydrazine/EDTA. Decontamination factors range from 2 to 5.⁸⁰ Weak solution decontamination was utilized at Nine Mile Point 1, Vermont Yankee, and Brunswick Units 1 and 2, while strong solutions were utilized at Peach Bottom Units 2 and 3. In these plants, decontamination solutions were used to decontaminate systems and components.

CONCLUSION

This issue was RESOLVED with the publication of decontamination criteria in NUREG/CR-2963.⁴⁸⁹

REFERENCES

2. NUREG-0371, "Task Action Plans for Generic Activities (Category A)," U.S. Nuclear Regulatory Commission, November 1978.
78. NUREG/CR-1496, "Nuclear Power Plant Operating Experience - 1979," U.S. Nuclear Regulatory Commission, May 1981.
79. NUREG-0109, "Occupational Radiation Exposure at Light Water Cooled Power Reactors 1969-1975," U.S. Nuclear Regulatory Commission, August 1976.
80. DOE/ET/34204-43, "Dilute Chemical Decontamination Program - Final Report," U.S. Department of Energy, August 1981.
489. NUREG/CR-2963, "Planning Guidance for Nuclear Power Plant Decontamination," U.S. Nuclear Regulatory Commission, June 1983.

ITEM A-16: STEAM EFFECTS ON BWR CORE SPRAY DISTRIBUTION

DESCRIPTION

Historical Background

Prior to May 1978, tests conducted by GE showed that the presence of steam and/or increased pressure in and above the upper core region of BWRs could adversely affect the distribution of flow from certain types of core spray nozzles. These nozzles are arranged to distribute water over the top of the reactor core in the event of a LOCA.

These new test data were collected from a reactor core spray system with a single nozzle spraying downward. However, spray flow in most domestic BWR core spray systems comes from many nozzles spraying approximately horizontally over the core from a sparger (or spargers) surrounding the core. Therefore, the degree of applicability of the new data to domestic BWRs was not known. As a result, this issue was included in NUREG-0371² to provide results which could be verified as being applicable to the size and design of each BWR in operation. In order to justify the preliminary acceptability of core spray cooling designs in operation, GE presented test results and calculations that were based on the separability of hydrodynamic phenomena (droplet-to-droplet interaction where spray patterns from two or more nozzles intersect) and thermal phenomena (steam condensation).

Safety Significance

If BWRs are to strictly conform to the post-LOCA requirements established by 10 CFR 50.46 to ensure the health and safety of the public, then their core spray systems must supply a specified minimum amount of coolant to each fuel bundle in their respective reactor cores. Therefore, core spray assumed in the LOCA analyses must be actually supplied in the post-LOCA steam environment. This issue was a topic in the SEP for both Millstone 1 and Dresden 2.

Possible Solution

The solution recommended in NUREG-0371² called for: (1) a series of tests on operating BWR/6 core spray distribution systems; and (2) a full-scale test of a 30° sector of a BWR/6 upper plenum, complete with spargers. Test results were to be reviewed by the NRC for acceptability of the analytical and experimental techniques used to determine the safety margin present in core spray distributions for all BWRs in operation and under construction.

CONCLUSION

Test results issued by GE in August 1979⁴⁰ compared favorably with the pre-test prediction, within defined acceptance limits, and confirmed the capability of the methodology to handle steam environment effects on spray performance. The results substantiated the key assumption of separability of thermodynamic and hydrodynamic effects. These test results were reviewed by the NRC and determined to "constitute an adequate confirmation of the GE spray distribution methodology for BWR/6-type spargers."¹⁰⁰ However, the NRC required additional tests to be performed to confirm the design methodology for other sparger designs. As a result, a test program

was initiated to provide core spray distribution data in a steam environment for a 30-degree sector of the BWR/4 and BWR/5 design. In March 1981, test results for this BWR design were published in NUREG/CR-1707.³⁹ These data demonstrated the applicability of the core spray methodology in this design which had nozzle types and sparger evaluations that were different from the BWR/6 design tested in 1979.

The BWR/1 core spray design was reviewed by DSI/NRR in 1979 and found to be acceptable. Following the review of GE test data for the BWR/3 core spray design, DSI/NRR concluded in March 1983 that the core spray distribution adequacy was not a safety concern for all BWR/3 reactors.⁴²⁷

MPA D-12 was established by DL/NRR for the review of the BWR/2 core spray system design, and for the preparation of an SER for each of the two domestic reactors of this design: Oyster Creek and Nine Mile Point, Unit 1.^{392,427} Based on the plant-specific reviews that were undertaken by the NRC, this issue was RESOLVED with no new requirements for licensees.

REFERENCES

2. NUREG-0371, "Task Action Plans for Generic Activities (Category A)," U.S. Nuclear Regulatory Commission, November 1978.
39. NUREG/CR-1707, "BWR Refill-Reflood Program, Task 4.2 - Core Spray Distribution Final Report," U.S. Nuclear Regulatory Commission, March 1981.
40. NEDO-24712, "Core Spray Design Methodology Confirmation Tests," General Electric Company, August 1979.
100. Letter to General Electric Company from R. Tedesco, "Acceptance for Referencing Topical Report, NEDO-24712: Core Spray Design Methodology Confirmation Tests," January 1981.
392. Memorandum for J. Funches from R. Mattson, "Request for Approval to Work on Low Priority Generic Safety Issues," November 5, 1982.
427. Memorandum for T. Speis from R. Mattson, "Close-out of TAP-A-16, Steam Effects on BWR Core Spray Distribution (TACS-40066)," March 29, 1983.

ITEM A-17: SYSTEMS INTERACTIONS IN NUCLEAR POWER PLANTSDESCRIPTION

Nuclear power plants contain many structures, systems, and components (SSCs), some of which are safety-related. Certain SSCs are designed to interact to perform their intended functions. These "systems interactions" are usually well recognized and, therefore, are accounted for in the evaluation of plant safety by designers and in plant safety assessments. However, prior to the time this issue was identified in 1978, a number of significant plant-specific events had occurred that involved unintended or unrecognized dependencies among the SSCs. Some of these events involved subtle dependencies between safety-related SCCs and other SCCs, while other events involved subtle dependencies between redundant safety-related SSCs that were believed to be independent. This issue was originally identified in NUREG-0371² and was later declared a USI in NUREG-0510.¹⁸⁶

CONCLUSION

The purpose of this issue was to investigate the potential that unrecognized, subtle dependencies among SSCs have remained hidden and that they could lead to safety-significant events. The term used to describe these unrecognized, subtle dependencies is adverse systems interactions (ASIs). In resolving this issue, the staff did not recommend that licensees conduct further broad searches specifically to identify all ASIs because such searches had not proved to be cost-effective in the past, and there was no guarantee after such studies that all ASIs had been uncovered. Rather, in its study, the staff concluded that certain more specific actions, together with other ongoing activities, could reduce the risk from ASIs.

The staff concluded from its investigations that the following actions should be taken:

- (1) Issuance of a generic letter that included: (a) the bases for resolution of USI A-17; and (b) a summary of information relevant to existing operating experience reviews.
- (2) Recognition that the IPE Program already included the evaluation of internal flooding and the insights from USI A-17 were to be referred to in the IPE guidance documents. If licensee action regarding flooding and water intrusion was implemented as proposed, there would be no further action on Issue 77 which was integrated into the resolution of USI A-17.
- (3) Recognition that the USI A-46 implementation was expected to address seismically-induced systems interactions to verify that components and systems needed to safely shut down a plant were protected, given a loss of offsite power. (New plants, not covered by USI A-46, were reviewed to existing requirements that addressed seismically-induced systems interactions.)
- (4) Communication of information regarding ASIs for staff review of PRAs and for staff evaluation of electric power supplies as part of Issue 128.
- (5) Identification and definition of concerns related to USI A-17 and other programs that had not been specifically addressed in this or other generic issues. The staff established the

Multiple System Responses Program (MSRP),¹²³⁷ the objective of which was to define the concerns with sufficient specificity to permit them to be evaluated as potential GSIs.

- (6) Development of an SRP for future plants that would include guidance regarding protection from internal flooding and water intrusion events.

The staff's technical findings were published in NUREG-1174¹²³² and the regulatory analysis associated with the resolution of this issue was published in NUREG-1229.¹²³³ The Commission was informed of the staff's resolution in SECY-89-230¹²³⁴ and Generic Letter 89-18¹²³⁵ was later issued to licensees. Thus, this issue was RESOLVED with no new or revised requirements for licensees.¹²³⁶

REFERENCES

2. NUREG-0371, "Task Action Plans for Generic Activities (Category A)," U.S. Nuclear Regulatory Commission, November 1978.
186. NUREG-0510, "Identification of Unresolved Safety Issues Relating to Nuclear Power Plants," U.S. Nuclear Regulatory Commission, January 1979.
1232. NUREG-1174, "Evaluation of Systems Interactions in Nuclear Power Plants," U.S. Nuclear Regulatory Commission, May 1989.
1233. NUREG-1229, "Regulatory Analysis for Resolution of USI A-17," U.S. Nuclear Regulatory Commission, August 1989.
1234. SECY-89-230, "Unresolved Safety Issue A-17, 'Systems Interactions in Nuclear Power Plants,'" August 1, 1989.
1235. NRC Letter to All Holders of Operating Licenses or Construction Permits for Nuclear Power Plants, "Resolution of Unresolved Safety Issue A-17, 'Systems Interactions in Nuclear Power Plants' (Generic Letter 89-18)," September 6, 1989.
1236. Federal Register Notice 54 FR 34836, "Issuance and Availability of NUREG-1174, 'Evaluation of Systems Interactions in Nuclear Power Plants: Technical Findings Related to Unresolved Safety Issue A-17,' and NUREG-1229, 'Regulatory Analysis for Resolution of USI A-17, - Systems Interactions in Nuclear Power Plants,'" August 22, 1989.
1237. NUREG/CR-5420, "Multiple System Responses Program - Identification of Concerns Related to a Number of Specific Regulatory Issues," U.S. Nuclear Regulatory Commission, October 1989.

ITEM A-18: PIPE RUPTURE DESIGN CRITERIA

DESCRIPTION

Historical Background

A major objective of this NUREG-0371² item was the development of consistent criteria for application in licensing processes. Additional research programs to implement licensing positions were to be conducted under separate issues. The problems specific to this issue were as follows:

- (1) Existing design criteria for the postulation of pipe breaks and protection therefrom had been developed over a period of time and lacked consistency when applied inside and outside containment. Regulatory Guide 1.46,¹⁸ issued in 1973, which addressed pipe breaks inside containment, was based on the concept of a limited number of design basis breaks. Section 3.6 of the SRP,¹¹ issued in 1975, which addressed pipe breaks outside containment, combined limited design basis breaks for mechanistic protection and unlimited breaks for non-mechanistic protection. At the time this issue was identified in 1978, staff efforts toward documentation of the rationale and engineering justification for existing pipe break criteria was ongoing. These efforts were expected to assist in focusing on areas requiring first attention and providing a valuable document for both public and staff use as bases for testimony before the ACRS and hearing boards. Work in this area was completed prior to 1983.
- (2) An evaluation of the pipe break exclusion concept in the containment penetration area of both PWRs and BWRs was required. The need to specify the extent of break exclusion regions, criteria for the use of guard pipes, and adequacy of design requirements for piping systems in break exclusion regions were topics for which improved guidance were to be developed.
- (3) The development of postulated pipe rupture criteria and the trend towards more conservative seismic criteria placed increased emphasis on piping system design to withstand these dynamic events. However, these criteria had also resulted in systems which were significantly more rigid. These more rigidly designed systems in the plants that were not in operating in 1978 had resulted in calculated stresses for normal operation which, although still within code limits, were significantly higher than in earlier plants. In addition, dynamic event devices, such as snubbers and pipe-whip restraints which had been added in increased numbers, had the potential for deleterious interaction with the piping system during its normal operation. It was believed that a balance in piping system design for both normal and abnormal situations should be achieved to ensure that consideration is given to the effects of abnormal situation design criteria on normal operation.

The evaluation of this issue included consideration of Item B-16.²

Possible Solutions

At the time of the evaluation of this issue in 1983, a study of the effects of abnormal loading scenario design criteria on normal operation had been completed. Determining licensing positions

and the consequences of implementing the results of this issue were not considered in this evaluation. Item B-6² more directly addressed: (1) the safety consequences of combining unusual dynamic events and normal plant operating conditions; and (2) the option of limiting the number of dynamic event devices.

The criteria used for designing and constructing containment penetrations were to be evaluated in this issue. Guidelines for limiting the extent of break exclusion areas, criteria for the use of guard pipes, and the adequacy of design requirements for piping systems in break exclusion areas were of concern. The consequences of implementing the resultant guidelines was expected to differ for various plant types and piping systems. It was assumed that the resolution would, in general, limit the number of break exclusion areas. It was further assumed that this limitation would affect only 60% of all forward-fit PWRs and BWRs.

PRIORITY DETERMINATION

Frequency/Consequence Estimate

The reduction in public risk was determined to be negligible (≤ 100 man-rem)⁶⁴ and limiting the extent of break exclusion areas did not increase or decrease the probability of a pipe rupture.

Cost Estimate

Industry Cost: It was estimated that only 60% of all forward-fit plants (43 PWRs and 20 BWRs) would be affected by limitations on break exclusion areas. Thus, the total number of affected plants was 38. The average remaining life of these affected plants was (38)(30) RY or 1,140 RY.

Labor included: (1) implementation of criteria for defining pipe break and crack locations and configurations; (2) implementation of criteria dealing with special features, such as augmented ISI or use of postulated event devices; and (3) the review of analysis results, including jet-thrust and impingement forcing functions, pipe-whip dynamic effects, and design adequacy of systems to ensure that function is not impaired as a result of pipe-whip or jet impingement loadings.

It was assumed that labor included the time required to analyze lines located outside the break exclusion regions and that analysis procedures, computer codes, applicable transient data, etc., were readily available. It was also assumed that only 50% of the 12 welds under investigation needed analysis (i.e., those excluded either already fell into an analyzed line or did not fall into a high energy/high stress area which required analysis). The total industry cost for implementing the possible solution was estimated to be \$2.07M.⁶⁴

Industry operation and maintenance costs associated with the solution would result in cost savings to the industry due to fewer ISI periods when weld design locations are shifted from a break exclusion area. Based on a labor decrease of 2.2 man-hours/RY at a cost of \$2,270/man-week, this cost saving was \$125/RY. The total industry cost savings that would result from reduced operation and maintenance at all affected plants were (\$125/RY x 1,140 RY) or \$143,000.

NRC Cost: It was assumed that NRC would provide the criteria to limit the extent of break exclusion regions for plant types and piping systems. Independent plant reviews with respect to new SRP¹¹ regulations would then be conducted. At the time this issue was evaluated in 1983, the resolution had been completed. Therefore, based on an implementation estimate of 3 man-weeks/plant, the total NRC cost was estimated to be (\$6,810/plant)(38 plants) or \$259,000.

NRC costs for reviewing piping systems were not expected to change. However, a review of the consequences of imposing limitations on break exclusion areas would result in NRC costs of approximately \$191/RY. Thus, the total NRC cost to support operation and maintenance was estimated to be (1,140 RY x \$191/RY) or \$220,000.

Total Cost: Summing all costs outlined above, the total cost associated with the possible solution was estimated to be \$[2.07 + 0.143 + 0.259 + 0.22]M or approximately \$2.7M.

Value/Impact Assessment

Based on an estimated public risk reduction of less than 100 man-rem and a cost of \$2.7M for a possible solution, the value/impact score was given by:

$$S \leq \frac{100 \text{ man-rem}}{\$2.7\text{M}}$$

$$\leq 37 \text{ man-rem}/\$M$$

Other Considerations

(1) Implementation Occupational Risk Increase

Implementation of the solution was estimated to occur during plant design stages. Therefore, any alterations made in break exclusion areas would occur before plant operation and startup. Thus, there was no occupational risk increase from implementation of the solution in the affected plants.

(2) Operation and Maintenance Occupational Risk Decrease

When a line is excluded from a break exclusion area, associated welds would no longer require a 100% volumetric inspection every 10 years. Instead, ISI of these welds would be scheduled once during the lifetime of a plant (i.e., 25% of welds would be inspected every 10 years).

Implementation of the possible solution was estimated to reduce operation and maintenance time in radiation zones by 2.2 man-hours/RY. Based on an average expected dose rate of 0.1 rem/hour for ISI, the total occupational risk reduction was estimated to be:

$$(2.2 \text{ man-hour/RY})(0.1 \text{ rem/hour})(1,140 \text{ RY}) = 251 \text{ man-rem}$$

(3) Accident Avoidance Occupational Risk Decrease

Implementation of the solution would not change the frequency of a core-melt accident. Thus, there was no occupational risk reduction associated with the solution.

Summing up the above three factors, the total occupational risk decrease was 251 man-rem. Inclusion of this factor in the value/impact score calculation would produce a value/impact score of $S \leq 130 \text{ man-rem}/\M .

CONCLUSION

Based on the estimated public risk reduction and the value/impact score, this issue was DROPPED from further consideration. Consideration of occupational risk decrease did not affect this conclusion.

REFERENCES

2. NUREG-0371, "Task Action Plans for Generic Activities (Category A)," U.S. Nuclear Regulatory Commission, November 1978.
11. NUREG-0800, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants," U.S. Nuclear Regulatory Commission, (1st Edition) November 1975, (2nd Edition) March 1980, (3rd Edition) July 1981.
18. Regulatory Guide 1.46, "Protection Against Pipe Whip Inside Containment," U.S. Nuclear Regulatory Commission, May 1973.
64. NUREG/CR-2800, "Guidelines for Nuclear Power Plant Safety Issue Prioritization Information Development," U.S. Nuclear Regulatory Commission, February 1983, (Supplement 1) May 1983, (Supplement 2) December 1983, (Supplement 3) September 1985, (Supplement 4) July 1986, (Supplement 5) July 1996.

ITEM A-19: DIGITAL COMPUTER PROTECTION SYSTEM

DESCRIPTION

At the time this issue was identified in NUREG-0371,² trends in the design of nuclear power plants showed an increase in the use of digital computer technology in safety-related instrumentation and control systems. The first application of this technology was Arkansas Nuclear One, Unit 2 (ANO-2), where digital computers were used in the initiating logic for two reactor trip parameters. After the ANO-2 application, other digital computers, such as core protection calculators, were installed by licensees to provide reactor trip signals.

Since digital technology is considerably different from analog technology, the criteria appropriate for the safety review of digital computer-based systems are different from those used for analog-based systems. Thus, in this issue, the staff identified the need to standardize the safety review of reactor protection systems that incorporated digital computers. It was believed that the results of such standardization would be: (1) the definition of the staff's requirements for the design, development, and qualification of digital computers for use by applicants; and (2) an SRP¹¹ that would define uniform and consistent guidelines for the conduct of the staff's safety review.

CONCLUSION

In 1982, ANS and IEEE jointly approved the standard ANSI/IEEE-ANS-7-4.3.2¹³²⁴ which established a method for designing, verifying, and implementing software, and validating computer systems used in the safety-related systems of nuclear power plants.¹²³⁷ In 1985, the NRC issued Regulatory Guide 1.152¹³²⁵ which endorsed the method in ANSI/IEEE-ANS-7-4.3.2-1982.¹³²⁴ At the time this issue was evaluated in 1991, the staff was conducting a research program to investigate the use of digital computer safety systems at nuclear power plants.¹²⁸⁶ In particular, specific licensing needs in the area of microcomputer and Artificial Intelligence Systems had been identified and were to be addressed. The desired end product of the research effort was a regulatory guide for the design, development, acceptance testing, and periodic functional verification of Class 1E computer safety systems, and an SRP¹¹ addendum providing review guidance for digital computer systems in nuclear power plant safety systems (by referencing Regulatory Guide 1.152¹³²⁵ and the new regulatory guide).

Since this issue addressed the use of alternative (i.e., digital instead of analog) technology for nuclear power plant safety systems, it was not intended that the use of digital technology would result in a change in the safety of existing nuclear power plants. Thus, the issue addressed the staff's efforts in improving its capability to make independent assessments of safety and was classified as a Licensing Issue.

REFERENCES

2. NUREG-0371, "Task Action Plans for Generic Activities (Category A)," U.S. Nuclear Regulatory Commission, November 1978.

11. NUREG-0800, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants," U.S. Nuclear Regulatory Commission, (1st Edition) November 1975, (2nd Edition) March 1980, (3rd Edition) July 1981.
1237. NUREG/CR-5420, "Multiple System Responses Program - Identification of Concerns Related to A Number of Specific Regulatory Issues," U.S. Nuclear Regulatory Commission, October 1989.
1286. Memorandum for M. Virgilio from S. Newberry, "Proposed Research Programs to Support SICB Regulation Needs," April 26, 1990.
1324. ANSI/IEEE-ANS-7-4.3.2-1982, "Application Criteria for Programmable Digital Computer Systems in Safety Systems of Nuclear Power Generating Stations," American Nuclear Society, July 6, 1982.
1325. Regulatory Guide 1.152, "Criteria for Programmable Digital Computer System Software in Safety-Related Systems of Nuclear Power Plants," U.S. Nuclear Regulatory Commission, November 1985.

ITEM A-20: IMPACTS OF THE COAL FUEL CYCLE

DESCRIPTION

At the time this issue was identified in NUREG-0371,² compliance with NEPA required that alternatives to a proposed Federal action be considered, and that required alternatives be balanced against the base case in terms of their associated environmental impacts. NRC had established, through its rulemaking authority, a generic description and evaluation of the environmental impacts of the uranium fuel cycle in WASH-1248,⁴⁵⁶ NUREG-0116,⁴⁵⁷ and NUREG-0216.⁴⁵⁸ Based on these studies, a summary table, Table S-3, had been prepared and promulgated as regulation in 10 CFR Part 51.20(e).

In 1978, a coal-fired plant was considered the only realistic alternative to a nuclear power plant. Existing treatment of the coal alternative was aimed essentially at economics and public health impacts; it was relatively incomplete in other areas of impact. It was believed that the comparison of the coal alternative to a proposed nuclear facility would be significantly improved, if a study were conducted for the coal fuel alternative that augmented the work that had been done by ANL in the area of health effects. Such a study would provide a comprehensive summary which evaluated the environmental effects of the coal fuel cycle in a form directly comparable to that for the uranium fuel cycle. In the absence of such a generic treatment of the effects of using coal for generating electric power, it was necessary for the staff to develop an analysis *de novo* for each licensing action, to present this individual analysis in detail in the EIS, and to defend it throughout the hearing process. It was believed that this repetitive staff effort could be avoided by preparing a generic statement suitable to support rulemaking proceedings. After the rulemaking procedure, such a statement would have the force of law necessary to avoid repetitive staff effort.

A thorough analysis of alternatives to a proposed nuclear power plant required an evaluation of the environmental effects of the coal fuel cycle to the same extent as the nuclear cycle. The environmental effects of the coal fuel cycle had long been recognized as being significant. There were deleterious effects to human health due to burning coal, but there were other significant socioeconomic and other environmental impacts at each stage of the cycle. For example, mining coal exacts a penalty in human health and safety, may require modification of large areas of land use requiring expensive reclamation and habitat restoration, and frequently produces polluting liquid and solid mine wastes. Environmental, social, economic, and health effects also accompany the transportation, storage, treatment, combustion, and waste management and disposal aspects of the fuel cycle. Failure to treat these factors had been criticized by ASLB and the ASLAB in the past, necessitating increased staff efforts in this direction.

CONCLUSION

This issue addressed the staff's efforts in improving its capability to make independent assessments of safety and, therefore, was considered a Licensing Issue. The issue had been covered extensively in NUREG-0252,⁴⁵⁹ NUREG/CR-1060,⁴⁶⁰ and NUREG-0332,⁴⁶¹ and further work on the subject had been discussed with personnel of the National Academy of Sciences who had expressed the view that adequate scientific bases for analyzing impacts of coal burning did not exist. It was thought that a workshop could be arranged to determine what the questions were and how they could be resolved. Definitive answers required an extensive program over a period of

years and the role of the NRC in carrying out such a program was expected to be determined by the Commission.⁴¹² The results of this issue were expected to be used in Item B-72.²

REFERENCES

2. NUREG-0371, "Task Action Plans for Generic Activities (Category A)," U.S. Nuclear Regulatory Commission, November 1978.
412. Memorandum for T. Speis from J. Funches, "Prioritization of Generic Issues - Environmental and Licensing Improvements," February 24, 1983.
456. WASH-1248, "Environmental Survey of the Uranium Fuel Cycle," U.S. Atomic Energy Commission, April 1974.
457. NUREG-0116, "Environmental Survey of the Reprocessing and Waste Management Portions of the LWR Fuel Cycle," U.S. Nuclear Regulatory Commission, October 1976.
458. NUREG-0216, "Public Comments on the Environmental Survey of the Reprocessing and Waste Management Portions of the LWR Fuel Cycle," U.S. Nuclear Regulatory Commission, March 1977.
459. NUREG-0252, "The Environmental Effects of Using Coal for Generating Electricity," U.S. Nuclear Regulatory Commission, June 1977.
460. NUREG/CR-1060, "Activities, Effects, and Impacts of the Coal Fuel Cycle for a 1,000 MWe Electric Power Generating Plant," U.S. Nuclear Regulatory Commission, February 1980.
461. NUREG-0332, "Health Effects Attributable to Coal and Nuclear Fuel Cycle Alternatives," U.S. Nuclear Regulatory Commission, November 1977.

ISSUE 172: MULTIPLE SYSTEM RESPONSES PROGRAM

In resolving GSIs over the years, the staff generally found it necessary to make assumptions and establish limitations on the scope of the issues. As a result of its review of the resolution of some GSIs, the ACRS expressed concerns that the assumptions and limitations on the scope of the issues, the lack of thorough coordination among issues, and the inconsistent assumptions for related issues may have resulted in some potentially significant safety concerns not being addressed. Specifically, these concerns were raised in ACRS meetings during the resolution of Issues A-17, A-46, and A-47. To address these concerns, RES initiated the Multiple System Responses Program (MSRP) program in 1986.

The purpose of the MSRP was to gather and review documentation (correspondence, meeting minutes, etc.) for the issues and other programs of interest and, from this documentation, describe potential safety concerns that were identified or expressed by the ACRS or NRC staff. The issues selected for the MSRP were A-17, A-46, and A-47. Issues that involved concerns similar to those addressed in the resolution of these three issues were also considered and included: (1) equipment qualification (10 CFR 50.49); (2) fire protection rules (10 CFR 50.48 and 10 CFR 50, Appendix R); and (3) related guidelines and reviews implemented based on the SRP.¹¹ In the MSRP, evaluations or judgments were not made regarding the validity of the concerns; rather, the concerns were examined, documented, and potential safety issues were defined as specifically as possible. The results of this effort were documented in NUREG/CR-5420.¹²³⁷

In NUREG/CR-5420,¹²³⁷ related concerns were grouped into defined potential safety issues and information was provided to assist the staff in evaluating them. This grouping was based on the following criteria: (1) concerns that had the same initiator (e.g., seismic event, flooding/moisture intrusion, fires); (2) concerns that related to a particular class of failures or failure modes (e.g., degradation of component performance rather than "failure," or common cause failures); (3) concerns that related to a particular group of components or systems (e.g., non-safety-related control system and safety-related protection system dependencies); (4) concerns that already existed as GSIs; and (5) concerns that were unrelated to other concerns or that were being evaluated through separate research activities and should be separate issues. Applying these criteria to the identified concerns yielded 21 potential safety issues.

Of the 21 MSRP concerns, the staff concluded that eleven were to be covered in the IPE or IPEEE Programs. The remaining ten concerns were dropped from further consideration as new and separate issues because eight were included in the scope of existing generic issues or other ongoing NRC programs, one (Item 4) had negligible risk reduction potential, and one (Item 9) was deemed to be a compliance concern. This conclusion was reached after several meetings between the ACRS and the staff and an extensive review¹⁵⁸¹ of the ACRS concerns by the staff. A comprehensive report¹⁵⁸⁰ on the staff's findings was submitted to the ACRS. The following is a summary of the staff's findings:

IPE/IPEEE Programs

- (1) Common Cause Failures Related to Human Errors (IPE)
- (2) Non-Safety-Related Control System/Safety-Related Protection System Dependencies (IPE)

- (13) Effects of Fire Suppression System Actuation on Non-Safety-Related and Safety-Related Equipment (IPEEE)
- (14) Effects of Flooding and/or Moisture Intrusion on Non-Safety-Related and Safety-Related Equipment (IPE/IPEEE)
- (15) Seismically-Induced Spatial and Functional Interactions ((IPEEE)
- (16) Seismically-Induced Fires (IPEEE)
- (17) Seismically-Induced Fire Suppression System Actuators (IPEEE)
- (18) Seismically-Induced Flooding (IPEEE)
- (19) Seismically-Induced Relay Chatter (IPEEE)
- (20) Evaluation of Earthquake Magnitudes Greater Than the Safe Shutdown Earthquake (IPEEE)
- (21) Effects of Hydrogen Line Ruptures (IPEEE)

DROP

- (3) Failure Modes of Digital Computer Control Systems
- (4) Specific Scenarios Not Considered in USI A-47
- (5) Effects of Degradation of HVAC Equipment on Control and Protection Systems
- (6) Failure Modes Resulting from Degraded Electric Power Sources
- (7) Failure Modes Resulting from Degraded Compressed Air Systems
- (8) Potential Effects of Untimely Component Operation
- (9) Propagation of Environments Associated with DBEs
- (10) Evaluation of Heat, Smoke, and Water Propagation Effects Resulting from Fires
- (11) Synergistic Effects of Harsh Environmental Conditions
- (12) Environmental Qualification of Seals, Gaskets, Packing, and Lubricating Fluids Associated with Mechanical Equipment

Based on the ongoing work to address the safety concerns, the issue was considered nearly-resolved in December 1995, but was later given a high priority ranking in SECY-98-166.¹⁷¹⁸ The MSRP was considered resolved at the conclusion of the IPE/IPEEE Programs when a summary report was issued¹⁸⁰⁶ on how the above eleven concerns were addressed. The staff's evaluations of the above 21 concerns are presented below:

(1) COMMON CAUSE FAILURES RELATED TO HUMAN ERRORS

DESCRIPTION

CCF resulting from human error include operator acts of commission or omission that could be initiating events or could affect redundant safety-related trains needed to mitigate the events. Other human errors that could initiate CCF include: (1) manufacturing errors in components that affect redundant trains; and (2) installation, maintenance, or testing errors that are repeated on redundant trains. Since personnel are always intimately involved in all phases of nuclear power plant planning, operation, testing, and maintenance, there is the potential for human errors which may contribute or lead to systems interaction events or CCF. This concern was identified as Item 7.4.1 in NUREG/CR-5420.¹²³⁷

CONCLUSION

While existing PRAs have identified human error possibilities to some extent, they are principally limited to errors of omission. The identification or the modeling of errors of commission is in the developmental stages and will continue to require further work. Efforts to increase understanding and preclude the occurrence of this type of human error will continue to be a priority research activity. With the use of NUREG/CR-5455,¹⁵⁸² the staff has been following the investigations of events at operating plants in recent years that involved human performance. In conducting control room design reviews, the staff uses the criteria documented in NUREG-0711¹⁵⁸³ and NUREG/CR-5908.¹⁵⁸⁴

The staff will continue the present approach of reducing human errors of all types through regulatory review, inspection, research, and the development of regulatory guidance based upon systematic application of human engineering principles, rather than attempting to identify and correct specific human errors that may lead to CCF. Additionally, potential CCFs resulting from human errors of omission in operation, maintenance, or testing are to be considered on a plant-specific basis by licensees in their IPEs. (CCFs resulting from human errors in installation and manufacturing of components are generally not explicitly considered in PRAs and hence would not be explicitly considered in the IPE process.)

The staff's approach will reduce the likelihood of human errors, including those that have not been identified thus far. The staff believes that the potentially significant generic issues associated with CCFs related to human errors are currently being addressed by this approach. Therefore, based on the existing IPE Program, this concern was not pursued as a new and separate issue.

(2) NON-SAFETY-RELATED CONTROL SYSTEM/SAFETY-RELATED PROTECTION SYSTEM DEPENDENCIES

DESCRIPTION

Multiple failures in non-safety-related control systems may have an adverse impact on safety-related protection systems as a result of potential unrecognized dependencies between control and protection systems. There is concern that plant-specific implementation of the regulations regarding separation and independence of control and protection systems may be inadequate. This concern was expressed by the ACRS during their review of the resolution of Issue A-47 and was identified as Item 7.4.2 in NUREG/CR-5420.¹²³⁷

CONCLUSION

The resolution of Issue A-17 stated that "[m]ethods are available (and some are under development) for searching out systems interactions on a plant-specific basis. Studies conducted by utilities and national laboratories indicate that a full-scope plant search takes considerable time and money. Even then, there is not a high degree of assurance that all, or even most, adverse systems interactions will be discovered." Thus, the staff concluded that the cost of a systematic search of systems interactions, such as non-safety-related control system/safety-related protection system dependencies, would produce very little safety benefit.

The summary of NUREG/CR-5420¹²³⁷ states that this issue "does not question regulations but addresses plant-specific implementation." As such, the licensees' IPE process should provide a framework for evaluating interdependence between safety-related and non-safety-related systems and identify potential sources of vulnerabilities. Continued notices, letters, and bulletins addressing

identified problems of this nature should aid in the identification and resolution at those plants where these or similar weaknesses may exist. Therefore, based on the existing IPE Program, this concern was not pursued as a new and separate issue.

(3) FAILURE MODES OF DIGITAL COMPUTER CONTROL SYSTEMS

DESCRIPTION

Two areas of concern were identified for digital computer control systems. The first is the potential for interactions between computerized non-safety-related control systems and safety-related protection systems. Use of computerized control systems presents the potential for complex or unexpected failure modes that might impact protection systems. The second area of concern is the use of digital control systems for safety-related purposes. The first OL application including this type of equipment for safety-related purposes (although on a small scale) was ANO Unit 2, where digital computers are used for the initiating logic for two reactor trip parameters. Several utilities are implementing core protection calculators (CPC), which are digital components, to provide trip signals. This concern was identified as Item 7.4.3 in NUREG/CR-5420.¹²³⁷

This ACRS concern was based on the potential failure of digital computer control systems which may affect the safe shutdown capability of a plant. It applies primarily to the adequacy of NRC regulations and the NRC's capability to review designs for such equipment.

CONCLUSION

For the review and evaluation of digital instrumentation and control systems (including the interface design and the software to drive them), methods and technical bases for guidelines and criteria are being developed in the ongoing NRC research on human-system interface. The many research issues include the potential for interactions between computerized non-safety related control systems and safety-related protection systems. The research also addresses the use of digital instrumentation and control systems for safety-related purposes. Additional work is being initiated with the National Academies of Sciences and Engineering under a study titled "Study and Workshop on Application of Digital Instrumentation and Control Systems to Nuclear Power Plants," to identify the important safety and reliability issues associated with the use of digital instrumentation and control systems, and to address what approach and criteria should be applied to ensure safe application and effective regulation of digital instrumentation and control systems.

In addition, potential failure modes and interactions in computer systems are being considered in the NRR review of digital systems in operating plants and advanced reactors. Based on the ongoing work, this concern was dropped from further consideration as a new and separate issue.

(4) SPECIFIC SCENARIOS NOT CONSIDERED IN USI A-47

DESCRIPTION

The staff identified two scenarios of concern that were not evaluated during the review of Issue 47: (1) scram without turbine trip, including return to criticality resulting from overcooling the primary system; and (2) steam generator overfill resulting from SGTR leading to an MSLB and more SGTRs that would involve the blowdown of more than one steam generator. The other potential

cause of steam generator overfill (excessive feedwater flow due to control system failure) and its consequences were analyzed in the resolution of Issue A-47. This concern was identified as Item 7.4.4 in NUREG/CR-5420.¹²³⁷

CONCLUSION

The first scenario was addressed in Issue 144 which was given a low priority ranking. The second scenario, along with other concerns, was addressed in Issue 135 which was given a medium priority ranking and resolved by the staff. In NUREG/CR-4893,¹⁴¹¹ the staff's technical findings report for Issue 135, it was stated that for steam generator overfill resulting from SGTR "[a]nalyzes for several plants on the increase in stress levels due to deadweight loading resulting from filling the steam lines indicate that, while in some cases the spring hangers may be loaded slightly beyond specification, they will not fail. The stress levels in the main steam line will remain within ASME Code limits in all cases. The NRC staff has concluded that the probability of failure of the main steam line is not increased by the deadweight loading. Further, because the water in the steam lines is essentially at saturation temperature and pressure, the potential for failure due to condensation-induced water hammer is considered insignificant ... there is no evidence of steam line failure from overstress, and dynamic loading from water hammer is not considered to be a problem."

Since steam generator overfill resulting from an SGTR is not likely to lead to an MSLB, an SGTR caused by an SGTR-induced MSLB and associated mechanical and thermal shock are also not very likely. Based on this low probability event, this concern was dropped from further consideration as a new and separate issue. Consideration of a 20-year license renewal period would not change this conclusion.

(5) EFFECTS OF DEGRADATION OF HVAC EQUIPMENT ON CONTROL AND PROTECTION SYSTEMS

DESCRIPTION

Instrumentation systems generally require a carefully controlled environment to function properly. Loss or degradation (i.e., partial loss) of either safety or non-safety-related HVAC systems could result in the failure of systems necessary to achieve and maintain safe shutdown. HVAC degradation can have a direct impact on safety-related equipment or an indirect impact through interactions with non-safety-related components. The possibility for HVAC degradation to have an undesirable impact on safety-related protection systems may not have been given adequate attention. This concern was identified as Item 7.4.5 in NUREG/CR-5420.¹²³⁷

CONCLUSION

The concern for the effects of loss of HVAC/chilled water systems on safety-related systems and components was addressed in the resolution of Issue 143. In the regulatory analysis for the resolution for this issue documented in NUREG/CR-6084,¹⁵⁵⁰ it was indicated that the reduction in annual CDF by eliminating (or decreasing) the dependence of safety systems on HVAC and room cooling was only on the order of 10^{-6} /RY, and all three proposed resolution strategies exceeded the \$1,000/man-rem cost-effectiveness ratio. Therefore, the staff did not recommend any new requirements in the resolution of Issue 143.

Although the effects of degradation (such as decrease in efficiency) of HVAC/chilled water systems were not considered in Issue 143, and only the effects of loss of HVAC/chilled water systems on safety-related systems and components were considered, Issue 143 did provide a worst-case scenario that enveloped the concerns of Item 7.4.5. This conclusion was based on the following: (1) the effects of degradation (partial loss) of HVAC/chilled water systems on systems and components will be less severe compared to those from the total loss of HVAC/chilled water systems; and (2) the indirect impact of HVAC degradation on safety-related equipment through interactions with non-safety-related components will lead to the same end results as the direct impact of loss of HVAC/chilled water systems on safety-related equipment. Therefore, the ACRS concerns were bounded by Issue 143 and were dropped from further consideration as a new and separate issue.

(6) FAILURE MODES RESULTING FROM DEGRADED ELECTRIC POWER SOURCES

DESCRIPTION

Electric power system degradation (i.e., undervoltage, overvoltage, underfrequency, overfrequency) has the potential for affecting multiple trains of safety-related equipment although it is not clear what failure modes could result from these types of events. The ACRS believed that, although Issue A-47 addressed sudden complete loss of electrical power, it did not address the effects of electric power system degradation on safety-related equipment. This concern was identified as Item 7.4.6 in NUREG/CR-5420.¹²³⁷

CONCLUSION

The concern for electrical power reliability was addressed in the resolution of Issue 128 which was established to integrate the resolution of 3 separate safety issues: 48, "Limiting Conditions for Operations (LCOs) for Class 1E Vital Instrument Buses"; 49, "Interlocks and LCOs for Class 1E Tie Breakers"; and A-30, "Adequacy of Safety-Related DC Power Supplies." However, the resolution of Issue 128 did not specifically address "degradation" of electrical power systems and its consequences. Issue A-35, "Adequacy of Offsite Power Systems," did address the concern for the vulnerability of safety-related equipment to sustained degraded voltage from offsite power sources. It also addressed the concern relating to a rapid rate of frequency decay of the offsite power system.

The concerns regarding the performance of MOVs under degraded electric power sources, among other things, were addressed in the resolution of Issue II.E.6.1, "In Situ Testing of Valves - Test Adequacy Study," and resulted in the issuance of Generic Letter 89-10¹²¹⁷ which required licensees to establish programs to ensure the operability of MOVs in safety-related systems. In the resolution of Issue 158, "Performance of Safety-Related Power-Operated Valves Under Design Basis Conditions," currently being resolved with a high priority, the staff will investigate the performance of safety-related, power-operated valves such as SOVs, AOVs, and HOVs under design basis conditions. Thus, Item 7.4.6 is being addressed for power-operated valves.

Lastly, there was an extensive inspection program initiated by NRR in the late 1980s entitled Electrical Distribution System Functional Inspections (EDSFI) where all operating plants were reviewed and inspected regarding the design, operation, maintenance, and testing of their electrical distribution systems; both offsite and onsite electrical power systems were included. A number of information notices were issued as a result of this inspection program and an EDSFI data bank is being maintained by RSIB/NRR. RES, in consultation with NRR, will consider the information in the

EDSFI data bank and other pertinent operational experiences, to determine the effects on component operation by degraded input power and if further NRC action is appropriate. With the completed and ongoing programs described above, this concern was dropped from further consideration as a new and separate issue.

(7) FAILURE MODES RESULTING FROM DEGRADED COMPRESSED AIR SYSTEMS

DESCRIPTION

Compressed air system degradation has the potential to affect multiple trains of safety-related equipment. Air system degradation includes: (1) gradual loss of air pressure; and (2) air underpressurization or overpressurization outside the design operating pressure range of the associated equipment dependent upon this system. It is not clear what failure modes could result from these types of events. Although Issue A-47 addressed sudden complete loss of air pressure, it did not specifically investigate the effects of compressed air system degradation on safety-related equipment. This concern was identified as Item 7.4.7 in NUREG/CR-5420.¹²³⁷

CONCLUSION

Issue 43, "Reliability of Air Systems," which was resolved with the issuance of Generic Letter 88-14,¹¹⁴¹ addressed, to a large extent, the ACRS concern on air system reliability. However, the ACRS stated¹⁵⁷⁹ that "we do not consider the resolution of Generic Issue 43 as adequate. We support what has been proposed or done by the staff and the industry as described in the resolution package for Generic Issue 43, but further work is needed to show that the gradual loss of air pressure issue is not a safety problem for any plant."

In AEOD/C701,¹⁰⁷⁸ five recommendations to address air systems problems were made. Recommendation 5 stated that "[a]ll operating plants should be required to perform gradual loss of instrument air system pressure tests." CRGR considered the five recommendations while deliberating on the issuance of Generic Letter 88-14¹¹⁴¹ and concluded that licensees should implement four of the five recommendations. Recommendation 5, pertaining to slow bleed-down testing, was not supported by CRGR because it was believed that the other four recommendations would be effective in correcting the problems.

The issuance of Generic Letter 88-14¹¹⁴¹ resulted in major utility efforts in which dozens of air system problems that had the potential to compromise public health and safety were found and corrected. In addition, AEOD now believes that the importance of the slow bleed-down test recommendation has actually diminished because of the efforts that many licensees have made to find and correct other air system problems and the aggressive industry initiatives to improve the reliability of air-operated equipment. Evidence of these activities are: (1) INPO and EPRI/NSAC issued reports encouraging utilities to take actions to correct problems noted in NUREG-1275,¹⁰⁷⁹ Vol. 2; (2) EPRI/NMAC issued maintenance guides on air systems and SOVs; (3) the Air Operated Valve Users' Group was formed and members meet on a regular basis to exchange information and promote reliable equipment operation; and (4) there is an ongoing process to establish an ASME O&M performance guide/standard for air systems.

The slow bleed-down test will require the determination of the range of credible blowdown rates, and the performance of sequential testing of individual branches of the air distribution system to avoid creating a challenge to plant safety. In addition, to fully implement the slow bleed-down test

recommendation could require expenditure of disproportionate amounts of resources and may also result in increased risk due to the introduction of unnecessary challenges to plant safety. AEOD is monitoring improvements in plant performance pursuant to Generic Letter 88-14.¹¹⁴¹ Based on the above actions that have been taken, this concern was dropped from further consideration as a new and separate issue.

(8) POTENTIAL EFFECTS OF UNTIMELY COMPONENT OPERATION

DESCRIPTION

This concern addressed the effects of components potentially changing state or actuating in an unanticipated sequence from spurious signals. This scenario can potentially cause damage to safety-related equipment. This concern was identified as Item 7.4.8 in NUREG/CR-5420.¹²³⁷

CONCLUSION

The staff reviewed existing programs and found that this concern has been adequately addressed by existing generic issues and other NRC programs. This review involved an evaluation of operational events studied under the Accident Sequence Precursors Program which indicated that the major cause of untimely equipment operation is human error which will be reduced by the application of human engineering principles (See Item 7.4.1). In addition, the only effects from the untimely operation of equipment in many of the events are spurious reactor, generator, or turbine trip. The remaining events involve accident sequences which are within the scope of existing generic issues, or involve accident sequences which are within the design basis of plants, such as loss of one out of two redundant ESF trains. Consequently, the staff believed that the potential effects of untimely component operation have been adequately addressed by existing generic issues and other NRC programs and this concern was dropped from further consideration as a new and separate issue.

(9) PROPAGATION OF ENVIRONMENTS ASSOCIATED WITH DBEs

DESCRIPTION

A harsh environment results from certain DBEs (i.e., MSLB, HELB, or LOCA). Equipment exposed to such environments must be qualified to withstand the severe conditions (e.g., the combined effects of high temperature, pressure, humidity/moisture, radiation, and submergence). The actual zone of influence for a particular environment can be larger than the zone used in the analysis if the harsh environment propagates by some unknown or unrecognized path (e.g., open floor drains) into another zone. The following scenario was to be considered:

Steam from an MSLB could travel from where it occurs into another area or zone. This could result in higher temperature, higher pressure, or higher humidity in the other zone. Equipment required for safe shutdown in this area may not be qualified to operate in such a harsh environment. Licensees may not have considered such pathways as HVAC ducts and electrical conduits to propagate harsh environments when performing their environmental qualification analyses.

This concern was identified as Item 7.4.9 in NUREG/CR-5420.¹²³⁷

CONCLUSION

10 CFR 50.49 requires that the DBE environmental conditions (e.g., the time-dependent temperature, pressure, humidity, radiation, chemicals, submergence, etc.) be specified in the qualification file at locations where equipment important to safety must perform and this equipment, in turn, must be qualified to these DBE environmental conditions. The staff considered the scenario described above to be an issue of compliance with 10 CFR 50.49 and this concern was dropped from further consideration as a new and separate issue.

(10) EVALUATION OF HEAT, SMOKE, AND WATER PROPAGATION EFFECTS RESULTING FROM FIRES

DESCRIPTION

Fire can damage one train of equipment in one fire zone while a redundant train could potentially be damaged in one of the following ways:

- (1) Heat, smoke, and water may propagate (e.g., through HVAC ducts or electrical conduit) into a second fire zone and damage a redundant train of equipment.
- (2) A random failure, not related to the fire, could damage a redundant train.
- (3) Multiple non-safety-related control systems could be damaged by the fire and their failure could affect safety-related protection equipment for a redundant train in a second zone.

A fire can cause unintended operation of equipment due to hot shorts, open circuits, and shorts to ground. Consequently, components could be energized or de-energized, valves could fail open or closed, pumps could continue to run or fail to run, and electrical breakers could fail open or closed. This concern was identified as Item 7.4.10 in NUREG/CR-5420.¹²³⁷

CONCLUSION

The concern of water propagation effects resulting from fire was partially addressed in the resolution of Issue 57. For operating and future plants having a greater reliance on advanced digital instrumentation and control (I&C) systems, there is a separate ongoing RES program to investigate the effects of smoke (SNL/FIN W6051) together with synergistic effects from temperature, moisture/humidity, electromagnetic interference/radio frequency interference (EMI/RFI), etc., (ORNL/FIN L1798, ORNL/FIN L1951) on these systems. This study will involve identifying all plausible environmental stressors associated with the advanced digital I&C systems, collecting reliability data for components that are unique for the advanced digital I&C systems, and prioritizing these environmental stressors (including the synergistic effects) based on their risk significance (BNL/FIN L1908). The results of this study will be incorporated into an ORNL program on Qualification of Advanced Instrumentation and Control Systems (See initial results in NUREG/CR-5904¹⁶⁶⁸ and NUREG/CR-5941¹⁶⁶⁹). Based on the above actions that have been taken, this concern was dropped from further consideration as a new and separate issue.

(11) SYNERGISTIC EFFECTS OF HARSH ENVIRONMENTAL CONDITIONSDESCRIPTION

A synergistic effect is one in which the presence of simultaneous combined environmental conditions has a greater impact on equipment than the sum of the individual environmental conditions taken independently or sequentially. The ACRS contends that a lack of regulatory guidance for analyzing synergistic effects makes it difficult to assess what licensees have done in this area and, therefore, some equipment important to safety may not be adequately qualified for the actual environments. This concern was not combined with other concerns because it relates to a specific part of the environmental qualification (EQ) issue, namely, synergistic environmental effects. This concern was identified as Item 7.4.11 in NUREG/CR-5420.¹²³⁷

CONCLUSION

10 CFR 50.49(e)(7) states that synergistic effects must be considered when these effects are believed to have a significant effect on equipment performance. The staff believed that, although regulatory guidance for analyzing synergistic effects is currently lacking, there is sufficient ongoing staff action to evaluate and resolve existing EQ concerns and to identify and resolve any other EQ issues that may exist. RES is currently working with NRR on the planned actions of the EQ 10 CFR 50.49 Task Action Plan (EQ-TAP) where the adequacy of existing EQ standards and regulations for operating reactors is to be evaluated. The EQ-TAP stated that "[a]lthough this TAP describes planned actions, it should be recognized that this is an evolving issue and the actions, as described, may be modified as additional information is obtained through further research and review of industry operating experience." The RES program plan for the EQ-TAP will include synergistic effects. Thus, the concerns of NUREG/CR-5420,¹²³⁷ Item 7.4.11 will be included in the EQ-TAP and additional guidance will be issued if appropriate. Therefore, this concern was dropped from further consideration as a new and separate issue.

(12) ENVIRONMENTAL QUALIFICATION OF SEALS, GASKETS, PACKING, AND LUBRICATING FLUIDS ASSOCIATED WITH MECHANICAL EQUIPMENTDESCRIPTION

Sub-components (seals, gaskets, packing materials, and lubricating fluids, etc.) in some mechanical equipment may not be adequately qualified to normal harsh environments due to the lack of concerted industry equipment qualification programs on mechanical equipment and NRC review. This is possible because currently no specific NRC guidelines equivalent to 10 CFR 50.49, "Environmental Qualification of Electric Equipment Important to Safety for Nuclear Power Plants," exist for mechanical equipment. This concern was identified as Item 7.4.12 in NUREG/CR-5420.¹²³⁷

CONCLUSION

Previously-identified generic issues addressed the operability and reliability of PORVs, MOVs, and other power-operated valves. Specifically, Generic Letter 89-10¹²¹⁷ was issued for Issue II.E.6.1; Generic Letter 90-06¹²⁹⁰ was issued for Issue 70; and Issue 158, "Performance of Safety-Related Power-Operated Valves Under Design Basis Conditions," is currently being resolved with a high priority and will address the operability and reliability of AOVs, HOVs and SOVs.

The EPRI-sponsored reliability-centered maintenance program (RCM) and the associated Users' Group have been in existence for some time and are now well-represented by the nuclear utilities. This maintenance program encompasses equipment and components (includes non-metallic parts which is the focus of concern of this issue), and regularly identifies and replaces unqualified or degraded components and sub-components. The Users' Group members meet on a regular basis (with participation from the NRC staff) to exchange information on RCM and promote reliability of equipment and components.

In addition, an ASME Standard on environmental qualification of mechanical equipment (QME) is scheduled for issuance. This document will help to address the concerns of this item for future plants and for replacements at operating plants. Based on the above actions that have been taken, this concern was dropped from further consideration as a new and separate issue.

(13) EFFECTS OF FIRE SUPPRESSION SYSTEM ACTUATION ON NON-SAFETY-RELATED AND SAFETY-RELATED EQUIPMENT

DESCRIPTION

Fire suppression system actuation events can have an adverse effect on safety-related components either through direct contact with suppression agents or through indirect interactions with non-safety-related components. This concern was identified as Item 7.4.13 in NUREG/CR-5420.¹²³⁷

CONCLUSION

This concern was addressed in the resolution of Issue 57 and will be considered by licensees on a plant-specific basis during implementation of the IPEEE Program. Supplement 4 to Generic Letter 88-20¹²²² and NUREG-1407¹³⁵⁴ provided procedural and submittal guidance for the IPEEE Program. As stated in NUREG-1407¹³⁵⁴ for internal fires, some fire issues identified in NUREG/CR-5088¹²¹¹ such as seismic/fire interaction, effects of fire suppressants on safety equipment, and control system interactions, should be addressed in the IPEEE. Based on the existing IPEEE Program, this concern was not pursued as a new and separate issue.

(14) EFFECTS OF FLOODING AND/OR MOISTURE INTRUSION ON NON-SAFETY-RELATED AND SAFETY-RELATED EQUIPMENT

DESCRIPTION

Flooding and/or water intrusion events can affect safety-related equipment either directly or indirectly through flooding or moisture intrusion of multiple trains of non-safety-related equipment.

This type of event can result from external flooding events, tank and pipe ruptures, actuations of fire suppression system, or backflow through part of the plant drainage system. This concern was identified as Item 7.4.14 in NUREG/CR-5420.¹²³⁷

CONCLUSION

The purpose of this concern was to determine whether additional regulations or more detailed requirements would result in a significant improvement in public health and safety. However, there is no evidence that this safety concern could be resolved in this manner. Instead, if a potential safety problem exists, it would appear to be a result of plant-specific vulnerabilities.

The IPE submittal guidance (Generic Letter 88-20¹²²² and NUREG-1335¹⁵⁸⁷) includes consideration of moisture intrusion and internal flooding. The concern for external flooding and/or moisture intrusion resulting from external events is being addressed in the IPEEE Program. Thus, the IPE/IPEEE process should detect plant-specific vulnerabilities identified in the ACRS concern. Based on the existing IPE and IPEEE Programs, this concern was not pursued as a new and separate issue.

(15) SEISMICALLY-INDUCED SPATIAL AND FUNCTIONAL INTERACTIONS

DESCRIPTION

Seismic events have the potential to cause multiple failures of safety-related systems through spatial and functional interactions. In particular, additional analyses may be necessary to ensure the following:

- (1) small piping (e.g., air, instrument, and water lines) is properly evaluated to prevent small pipe ruptures that may disable essential plant shutdown systems;
- (2) non-seismically qualified structures, systems and components cannot cause small piping failures from direct impact;
- (3) seismic activity will not adversely affect safety-related protection systems via multiple non-safety-related control system failures and/or functional interactions (excluding direct impact); and
- (4) indirect effects of seismic activity such as dust generation cannot affect essential plant shutdown systems.

The ACRS expressed concern that not all of the potential seismically-induced system interactions that could adversely affect safe shutdown of a plant have been thoroughly identified and investigated. This concern was identified as Item 7.4.15 in NUREG/CR-5420.¹²³⁷

CONCLUSION

The procedural and submittal guidance document¹³⁵⁴ for the IPEEE Program states that, for seismic review, plant walkdowns must be performed consistent with the intent of the guidelines described in Sections 5 and 8 and Appendices D and I of the EPRI Seismic Margins Methodology

(EPRI NP-6041). EPRI NP-6041 in turn states that seismic systems interactions reviews should be one of the items performed during a plant walkdown and guidelines on how to perform these reviews are provided. These guidelines address the concern for seismically-induced spatial interactions; it is expected that implementation of the IPEEE Program will identify any vulnerabilities to seismically-induced functional interactions. Thus, licensee evaluations of their plants for vulnerabilities to seismic events as part of the IPEEE Program are sufficient to address the ACRS concern. Based on the existing IPEEE Program, this concern was not pursued as a new and separate issue.

(16) SEISMICALLY-INDUCED FIRES

DESCRIPTION

Seismically-induced fires have the potential to cause multiple failures of safety-related systems. The occurrence of a seismic event could create fires in multiple locations, simultaneously degrade fire suppression capability (because fire suppression systems are not seismically-qualified), and, therefore, prevent mitigation of fire damage to multiple safety-related systems. The ACRS expressed concern that seismically-induced fires were not adequately addressed in the resolution of Issue A-46, other seismic requirements, or fire protection regulations. This concern was identified as Item 7.4.16 in NUREG/CR-5420.¹²³⁷

CONCLUSION

In resolving Issue 57, the staff considered the results of the PRA analyses for 4 operating plants (1 GE, 1 B&W, and 2 W plants) and these are summarized below.

The mean CDF from Issue 57 root causes for these 4 plants are in the range of $7.3 \times 10^{-6}/RY$ to $5.6 \times 10^{-5}/RY$. The dominant risk contributors were found to be: (1) seismic-induced fire plus seismic-induced suppressant diversion, i.e., the unsuppressed fire and/or the diverted suppressant incapacitate safety-related equipment needed to mitigate effects of the seismic event; and (2) seismic-induced actuation of the fire protection systems (i.e., the released suppressant damages safety-related equipment needed to mitigate the effects of the seismic event) which are both being addressed by IPEEE (See Supplement 4 to Generic Letter 88-20¹²²² and NUREG-1407¹³⁵⁴). After subtracting these two dominant risk contributors, the mean CDF of remaining contributors is less than $10^{-5}/RY$. Therefore, the staff recommended that, after considering credit for the IPEEE, generic backfit was not justifiable for Issue 57 and no new requirements were recommended.

Thus, the ACRS concern will be considered by licensees on a plant-specific basis during implementation of the IPEEE Program and this concern was not pursued as a new and separate issue.

(17) SEISMICALLY-INDUCED FIRE SUPPRESSION SYSTEM ACTUATIONS

DESCRIPTION

Seismic events can potentially cause multiple fire suppression system actuations which, in turn, can cause failures of redundant trains of safety-related systems. Analyses currently required by fire protection regulations generally only examine inadvertent actuations of fire suppression systems

as single, independent events whereas a seismic event could cause multiple actuations of fire suppression systems in various areas. This concern was identified as Item 7.4.17 in NUREG/CR-5420.¹²³⁷

CONCLUSION

As described in Item 7.4.16 above, the ACRS concern was addressed in the resolution of Issue 57 and will be considered by licensees on a plant-specific basis during implementation of the IPEEE Program. Therefore, this concern was not pursued as a new and separate issue.

(18) SEISMICALLY-INDUCED FLOODING

DESCRIPTION

Seismically-induced flooding events can potentially cause multiple failures of safety-related systems. The ACRS expressed several concerns related to seismically-induced flooding. First, although the ACRS believes that an SSE will likely not cause large-diameter piping to rupture, the ACRS feels that the seismic adequacy of smaller-diameter piping has not been adequately proven. Rupture of small piping could provide flood sources that could potentially affect multiple safety-related components simultaneously. Second, non-seismically qualified tanks are a potential source of flooding that the ACRS believes has not been adequately addressed. This concern was identified as Item 7.4.18 in NUREG/CR-5420.¹²³⁷

CONCLUSION

Licensee evaluations of their plants for vulnerabilities to seismic events as part of the implementation of the IPEEE Program (Supplement 4 to Generic Letter 88-20¹²²² and NUREG-1407¹³⁵⁴) will address the ACRS concern. Therefore, this concern was not pursued as a new and separate issue.

(19) SEISMICALLY-INDUCED RELAY CHATTER

DESCRIPTION

Essential relays must operate during and after an SSE and must meet either one of the following conditions: (1) remain functional without contact chattering; (2) be seismically-qualified; or (3) licensees must show that contact chatter of the relay(s) is acceptable. It is possible that contact chatter of relays not required to operate during seismic events may produce some unanalyzed faulting mode that may impact the operability of equipment required to mitigate the event. This concern was identified as Item 7.4.19 in NUREG/CR-5420.¹²³⁷

CONCLUSION

Licensee evaluations of their plants for vulnerabilities to seismic events as part of the implementation of the IPEEE Program (Supplement 4 to Generic Letter 88-20¹²²² and NUREG-1407¹³⁵⁴) will address the ACRS concern. Therefore, this concern was not pursued as a new and separate issue.

(20) EVALUATION OF EARTHQUAKE MAGNITUDES GREATER THAN THE SAFE
SHUTDOWN EARTHQUAKE

DESCRIPTION

The ACRS expressed concern that adequate seismic margins may not have been included in the design of some safety-related equipment. In this context, seismic margin is defined as the capability of a plant to sustain an earthquake larger than its SSE. This concern was identified as Item 7.4.20 in NUREG/CR-5420.¹²³⁷

CONCLUSION

Licensee evaluation of their plants for vulnerabilities to seismic events as part of the implementation of the IPEEE Program (Supplement 4 to Generic Letter 88-20¹²²² and NUREG-1407¹³⁵⁴) will address the ACRS concern. Therefore, this concern was not pursued as a new and separate issue.

(21) EFFECTS OF HYDROGEN LINE RUPTURES

DESCRIPTION

H₂ is used in electrical generators at nuclear plants to reduce windage losses and as a heat transfer agent. It is also used in some tanks (e.g., volume control tanks) as a cover gas. Leaks or breaks in H₂ supply piping could result in the accumulation of a combustible mixture of air and H₂ in vital areas, resulting in a fire and/or an explosion. This concern was identified as Item 7.4.21 in NUREG/CR-5420¹²³⁷ and addressed the potential for H₂ line ruptures to occur in the auxiliary building. Resulting fires and/or explosions could damage vital safety-related systems of the plant.

CONCLUSION

This concern was addressed in the resolution of Issue 106, "Piping and Use of Highly Combustible Gases in Vital Areas." The staff's technical findings and regulatory analysis were reported in NUREG/CR-5759¹⁵⁴⁴ and NUREG-1364,¹⁵⁴⁵ respectively. Generic Letter 93-06¹⁵⁴⁷ was issued to licensees and referred to new information developed in the resolution of Issue 106. This information was expected to be useful to licensees in performing their IPEEEs. Based on the above actions that have been taken, this concern was not pursued as a new and separate issue.

REFERENCES

1078. AEOD/C701, "Air Systems Problems at U.S. Light Water Reactors," Office for Analysis and Evaluation of Operational Data, U.S. Nuclear Regulatory Commission, March 1987.
1079. NUREG-1275, "Operating Experience Feedback Report," U.S. Nuclear Regulatory Commission, (Vol. 1) July 1987, (Vol. 2) December 1987, (Vol. 3) November 1988, (Vol. 4) March 1989, (Vol. 5) March 1989, (Vol. 5, Addendum) August 1989, (Vol. 6) February 1991, (Vol. 7) September 1992, (Vol. 8) December 1992, (Vol. 9) March 1993.

1141. NRC Letter to All Holders of Operating Licenses or Construction Permits for Nuclear Power Plants, 'Instrument Air Supply System Problems Affecting Safety-Related Equipment (Generic Letter 88-14),' August 8, 1988.
1211. NUREG/CR-5088, "Fire Risk Scoping Study: Investigation of Nuclear Power Plant Fire Risk, Including Previously Unaddressed Issues," U.S. Nuclear Regulatory Commission, January 1989.
1217. NRC Letter to All Licensees of Operating Power Plants and Holders of Construction Permits for Nuclear Power Plants, "Safety-Related Motor-Operated Valve Testing and Surveillance (Generic Letter No. 89-10) - 10 CFR 50.54(f)," June 28, 1989, (Supplement 1) June 13, 1990, (Supplement 2) August 3, 1990, (Supplement 3) October 25, 1990, (Supplement 4) February 12, 1992, (Supplement 5) June 28, 1993, (Supplement 6) March 8, 1994.
1222. NRC Letter to All Licensees Holding Operating Licenses and Construction Permits for Nuclear Power Reactor Facilities, "Individual Plant Examination for Severe Accident Vulnerabilities - 10 CFR § 50.54(f), (Generic Letter No. 88-20)," November 23, 1988, (Supplement 1) August 29, 1989, (Supplement 2) April 4, 1990, (Supplement 3) July 6, 1990, (Supplement 4) June 28, 1991.
1237. NUREG/CR-5420, "Multiple System Responses Program - Identification of Concerns Related to A Number of Specific Regulatory Issues," U.S. Nuclear Regulatory Commission, October 1989.
1290. NRC Letter to All Pressurized Water Reactor Licensees and Construction Permit Holders, "Resolution of Generic Issue 70, 'Power-Operated Relief Valve and Block Valve Reliability,' and Generic Issue 94, 'Additional Low-Temperature Overpressure Protection for Light-Water Reactors,' Pursuant to 10 CFR 50.54(f) (Generic Letter 90-06)," June 25, 1990.
1354. NUREG-1407, "Procedural and Submittal Guidance for the Individual Plant Examination of External Events (IPEEE) for Severe Accident Vulnerabilities," U.S. Nuclear Regulatory Commission, June 1991.
1411. NUREG/CR-4893, "Technical Findings Report for Generic Issue 135, Steam Generator and Steam Line Overfill Issues," U.S. Nuclear Regulatory Commission, May 1991.
1544. NUREG/CR-5759, "Risk Analysis of Highly Combustible Gas Storage, Supply, and Distribution Systems in Pressurized Water Reactor Plants," U.S. Nuclear Regulatory Commission, June 1993.
1545. NUREG-1364, "Regulatory Analysis for the Resolution of Generic Safety Issue 106: Piping and the Use of Highly Combustible Gases in Vital Areas," U.S. Nuclear Regulatory Commission, June 1993.
1547. Letter to All Holders of Operating Licenses or Construction Permits for Nuclear Power Reactors, "Research Results on Generic Safety Issue 106, 'Piping and the Use of Highly Combustible Gases in Vital Areas,' (Generic Letter 93-06)," U.S. Nuclear Regulatory Commission, October 25, 1993.

1550. NUREG/CR-6084, "Value Impact Analysis of Generic Issue 143, 'Availability of Heating, Ventilation, Air Conditioning (HVAC) and Chilled Water Systems,'" U.S. Nuclear Regulatory Commission, November 1993.
1579. Letter to L. Zech from F. Remick, "Resolution of Generic Issue 43, 'Air Systems Reliability,'" January 19, 1989.
1580. Memorandum for J. Larkins from E. Beckjord, "Evaluation of Potential Safety Issues from the Multiple System Responses Program," June 3, 1994.
1581. Memorandum for T. Speis from A. Thadani, "Review of NUREG/CR-5420," April 30, 1995.
1582. NUREG/CR-5455, "Development of NRC's Human Performance Investigation Process (HPIP)," U.S. Nuclear Regulatory Commission, (Vol. 1) October 1993, (Vol. 2) October 1993, (Vol. 3) October 1993.
1583. NUREG-0711, "Human Factors Engineering Program Review Model," U.S. Nuclear Regulatory Commission, July 1994.
1584. NUREG/CR-5908, "Advanced Human-System Interface Design Review Guideline," U.S. Nuclear Regulatory Commission, (Vol. 1) July 1994, (Vol. 2) July 1994.
1587. NUREG-1335, "Individual Plant Examination: Submittal Guidance," U.S. Nuclear Regulatory Commission, August 1989.
1668. NUREG/CR-5904, "Functional Issues and Environmental Qualification of Digital Protection Systems of Advanced Light-Water Nuclear Reactors," U.S. Nuclear Regulatory Commission, April 1994.
1669. NUREG/CR-5941, "Technical Basis for Evaluating Electromagnetic and Radio-Frequency Interference in Safety-Related I&C Systems," U.S. Nuclear Regulatory Commission, April 1994.
1718. SECY-98-166, "Summary of Activities Related to Generic Safety Issues," July 6, 1998.
1806. Memorandum to W. Travers from A. Thadani, "Closeout of Generic Safety Issue 172, 'Multiple System Responses Program,'" January 22, 2002.

ISSUE 173: SPENT FUEL STORAGE POOL

In November 1992, two engineers who had previously worked under contract for the Pennsylvania Power and Light Company (PP&L) filed a report contending that the design of the Susquehanna station failed to meet regulatory requirements with respect to sustained loss of the cooling function to the SFP that mechanistically results from a LOCA or a LOOP. PP&L and the engineers each made a series of additional submittals to the NRC and participated in public meetings with the NRC to describe their respective positions on a number of technical and licensing issues. In order to inform the nuclear power industry of the issues, NRC issued IN 93-83 on October 7, 1993. The staff evaluated the issues as they related to Susquehanna, using a probabilistic safety assessment, a deterministic engineering assessment and a licensing basis analysis, and issued an SER on June 19, 1995.

A generic action plan¹⁶²³ was developed with two parts: (1) Part A, which encompassed the staff's review of generic issues relating to the SFP at operating reactor facilities; and (2) Part B, which included applicable issues from the Part A review and concerns from the Dresden-1 special inspection,¹⁶⁰¹ particular to permanently shutdown facilities with stored, irradiated fuel to establish evaluation criteria for spent fuel pools at permanently shutdown facilities. Part B was included after the special inspection at Dresden-1 determined that problems in implementing the facility's decommissioning plan combined with certain SFP design features created the potential for a substantial loss of SFP water inventory. Dresden-1, which is permanently shutdown, experienced containment flooding due to freeze damage to the service water system on January 25, 1994, and the licensee for Dresden-1 reported a similar threat to SFP integrity. This licensee report resulted in the special inspections¹⁶⁰¹ of La Crosse, Humboldt Bay, Rancho Seco, Trojan, San Onofre-1, Yankee Rowe, and Indian Point-1. The two parts of this issue were evaluated separately.

ISSUE 173.A: OPERATING FACILITIES

DESCRIPTION

Historical Background

The principal concerns included in Part A of the generic action plan¹⁶²³ involved the potential for a sustained loss of SFP cooling capability, which was identified through the report filed with the NRC relating to Susquehanna, and the potential for a substantial loss of SFP coolant inventory, which was given renewed emphasis following the Dresden-1 special inspection. Postulated adverse conditions that may develop following a LOCA or a sustained loss of power to SFP cooling system components could prevent restoration of SFP decay heat removal. The heat and water vapor added to the building atmosphere by subsequent SFP boiling could cause failure of accident mitigation or other safety equipment and an associated increase in the consequences of the initiating event. Incomplete administrative controls combined with certain design features, particularly at the oldest facilities, may create the potential for a substantial loss of SFP coolant inventory and the associated consequences, which include high local radiation levels due to loss of shielding, unmonitored release of radiologically contaminated coolant, and inadequate cooling of stored fuel.

The action plan was intended to encompass SFP issues identified through a 1994 special inspection at Dresden-1, the staff's review of loss of SFP cooling concerns at Susquehanna, and other SFP concerns identified as part of this plan. Specific review areas identified through implementation of this action plan include plant design features and administrative controls that affect the probability of spent fuel pool boiling, adverse environmental effects on essential equipment due to boiling, significant loss of spent fuel pool coolant inventory, adverse radiological conditions, unplanned spent fuel pool reactivity changes, undetected spent fuel pool events, and adverse effects of control system actuations. This issue was identified in an NRR memorandum¹⁶⁰¹ to RES in February 1996.

Safety Significance

The postulated events do not pose an undue risk to the public based on the availability of design features that help protect stored irradiated fuel, protect essential reactor safety systems, and prevent development of adverse radiological conditions. These design features include the provision of diverse means of cooling, the strong structural design of the spent fuel pool, the absence of drainage paths from the pool, the anti-syphon protection on piping within the spent fuel pool, the availability of multiple sources of make-up water, spent fuel pool instrumentation with control room annunciation, the maintenance of a substantial shutdown reactivity margin in the pool, radiation shielding provided by coolant inventory, and spent fuel pool water purification systems. Additionally, the relatively slow evolution of these events in the spent fuel pool resulting from the initial large cooling water inventory creates significant opportunity for operator recovery prior to experiencing adverse conditions or consequences.

Possible Solutions

Specific actions include: (1) determination of the safety significance of identified concerns; (2) determination of the facilities where the concerns may be applicable; (3) evaluation of the adequacy of present SFP designs; (4) evaluation of the adequacy of current NRC guidance for SFP designs; and (5) evaluation of the need for generic actions to address significant issues at operating and permanently shutdown facilities. Based on findings from these review areas and their risk significance, the staff will develop criteria for specific spent fuel pool operations for potential use in formulating generic communications, revisions of regulatory guidance, and other appropriate regulatory actions.

CONCLUSION

This issue was considered nearly-resolved¹⁷³¹ since a solution had been identified and resolution was in progress with an approved Action Plan. It was later given a HIGH priority ranking in SECY-98-166.¹⁷¹⁸

In pursuing a resolution to this issue, the staff performed a comprehensive study of the Susquehanna SFP. The results of the special inspection of Dresden-1, after rupture of the SWS occurred inside containment, were transmitted to licensees in IN 94-38.¹⁶²⁴ The identification of concerns for evaluation and review of existing guidance were completed along with on-site safety assessments of spent fuel storage at Brunswick, Monticello, Comanche Peak, and Ginna. The assessment team concluded that the potential for a sustained loss of SFP cooling or a significant loss of SFP coolant inventory at the sites visited was remote, based on certain design features and operational controls. The team found that other concerns within the scope of the action plan review were much less significant in terms of risk at the plants visited. An FSAR-based review was

undertaken to identify facilities whose design was not well represented by any of the facilities reviewed through on-site assessments. As a result, approximately 26 concerns were identified in the major review areas; additional concerns associated with the Millstone-1 SFP (adequacy of SFP cooling during refueling with a full core off-load) were included. Each concern was to be addressed on the basis of a qualitative safety assessment. The concern for SFP criticality control (Boraflex degradation) was pursued through issuance of an information notice and a planned generic letter.

Following reports^{1693,1694} to the Commission on its findings, the staff committed to complete regulatory analyses associated with plant-specific backfits, implement plant-specific backfits, and complete revisions to Regulatory Guide 1.13¹⁶⁹⁷ and SRP¹¹ Sections 9.1.1 and 9.1.3. The regulatory analyses were pursued by NRR under the proposed rulemaking on shutdown and fuel storage pool operation. In July 1997, the staff's proposed rule was presented to the Commission in SECY-97-168¹⁶⁹⁵ following which, the Commission directed¹⁶⁹⁶ the staff not to issue the proposed rule. After performing plant-specific evaluations and considering a license renewal period of 20 years, the issue was RESOLVED with no new or revised requirements.¹⁸⁰⁷

ISSUE 173.B: PERMANENTLY SHUTDOWN FACILITIES

DESCRIPTION

Historical Background

The staff issued Bulletin 94-01¹⁶²⁵ requesting all holders of licenses for nuclear power reactors that were permanently shut down with spent fuel in the spent fuel pool to take actions to ensure the quality of the SFP coolant, the ability to maintain an adequate coolant inventory for cooling and shielding, and the necessary support systems were not degraded. In order to evaluate the management controls and SFP activities at permanently shutdown reactors, the NRC initiated a series of special team inspections at permanently shutdown facilities with stored, irradiated fuel in the SFP. This Part B effort was expected to use the results of Part A activities to establish evaluation criteria for SFPs at permanently shutdown plants to support rulemaking and other generic activities initiated by NRR. This issue was identified in an NRR memorandum¹⁶⁰¹ to RES in February 1996.

Safety Significance

The postulated events involving a loss of cooling do not pose undue risk to the public because of the low residual decay heat in the spent fuel at permanently shutdown reactors and the associated long period of time available for recovery. Concerns involving maintenance of the coolant quality and ability to control coolant inventory were addressed through the special inspection activities. Therefore, continued facility operation was justified.

Possible Solution

Specific actions included in Part B of the generic action plan¹⁶²³ were: (1) the determination of significant identified concerns from Part A applicable to permanently shutdown facilities; and (2) the evaluation and implementation of additional requirements specifically applicable to permanently shutdown facilities with stored, irradiated fuel.

CONCLUSION

This issue was considered nearly-resolved¹⁷³¹ since a solution had been identified and resolution is in progress with an approved Action Plan. The staff determined that all significant identified concerns from Part A applicable to permanently shutdown facilities were encompassed by the special inspection activities which showed no significant deficiencies other than at Dresden-1. In response to the Dresden-1 Special Inspection findings, NRR proceeded with issuance of a decommissioning action plan. Thus, this issue was RESOLVED with no new requirements.

REFERENCES

11. NUREG-0800, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants," U.S. Nuclear Regulatory Commission, (1st Edition) November 1975, (2nd Edition) March 1980, (3rd Edition) July 1981.
1601. Memorandum to C. Serpan from A. Chaffee, "Nuclear Reactor Regulation (NRR) Input into Research NUREG-0933 (WITS Item 9400213)," February 13, 1996.
1623. Memorandum to A. Thadani from G. Holahan, "Task Action Plan for Spent Fuel Storage Pool Safety," October 13, 1994.
1624. NRC Information Notice 94-38, "Results of a Special NRC Inspection at Dresden Nuclear Power Station Unit 1 Following a Rupture of Service Water Inside Containment," May 27, 1994.
1625. NRC Bulletin 94-01, "Potential Fuel Pool Draindown Caused by Inadequate Maintenance Practices at Dresden Unit 1," April 14, 1994.
1693. Memorandum to Chairman Jackson, et al., from J. Taylor, "Report on Survey of Refueling Practices," May 21, 1996.
1694. Memorandum to Chairman Jackson, et al., from J. Taylor, "Resolution of Spent Fuel Storage Pool Action Plan Issues," July 26, 1996.
1695. SECY-97-168, "Issuance for Public Comment of Proposed Rulemaking Package for Shutdown and Fuel Storage Pool Operation," July 30, 1997.
1696. Memorandum to L. Callan from J. Hoyle, "Staff Requirements - SECY-97-168 - Issuance for Public Comment of Proposed Rulemaking Package for Shutdown and Fuel Storage Pool Operation," December 11, 1997.
1697. Regulatory Guide 1.13, "Spent Fuel Storage Facility Design Basis," U.S. Nuclear Regulatory Commission, (Rev. 1) December 1975, (Draft Rev. 2) December 1981.
1718. SECY-98-166, "Summary of Activities Related to Generic Safety Issues," July 6, 1998.
1731. Memorandum for W. Russell from D. Morrison, "Prioritization of the NRR Action Plans Submitted to RES on February 13, 1996," June 24, 1996.

1807. Memorandum to W. Travers from S. Collins, "Resolution of Generic Safety Issue (GSI) 173A, 'Spent Fuel Storage Pool for Operating Facilities,'" December 19, 2001.

ISSUE 188: STEAM GENERATOR TUBE LEAKS OR RUPTURES, CONCURRENT WITH CONTAINMENT BYPASS FROM MAIN STEAM LINE OR FEEDWATER LINE BREACHES

DESCRIPTION

Historical Background

This issue was identified when it was believed¹⁷⁹⁹ that the validity of steam generator (SG) tube leak and rupture analyses could be affected by resonance vibrations in steam generator tubes during steam line break depressurization. The concern is that an unisolable secondary system opening outside containment coupled with multiple steam generator tube leaks or ruptures could result in releases in excess of 10 CFR Part 100. The related technical issues include the ability to correctly predict SG secondary side thermal-hydraulic behavior, physical loadings, component response, resonance vibrations within the tube bundles, eddy current testing, iodine spiking, operator response, and risk. The issue is related to Issue 163, "Multiple Steam Generator Tube Leakage."

Safety Significance

The issue raised the following two potentially risk-significant events that are not fully addressed as design basis accidents in FSARs, industry analyses, the SRP,¹¹ or staff reviews:

- (1) Operating experience and design information suggested that the potential existed for a line breach to significantly increase SG leakage, because resonant vibration of SG tubes from a secondary side blowdown could cause increased tube leakage.
- (2) Significant SG tube leakage could lead to secondary system breaches from a variety of causes. The resulting SG secondary side blowdown could further increase tube leakage due to resonance vibration within the affected SG tube bundle.

Such leakages, concurrent with containment bypass, might cause offsite radiation doses in excess of 10 CFR Part 100.

Main steam line break and steam generator tube rupture (SGTR) are both included as design basis accidents in Chapter 15 of most FSARs and the SRP,¹¹ and are addressed as accident initiators in most plant-specific PRAs. However, these accident initiators are generally assumed to occur independently unless there is severe core damage. Moreover, a SGTR is assumed to occur spontaneously in just one tube. This issue addresses the possibility of a causal relationship: a main steam or feedwater line break in an unisolable portion of the secondary system is postulated to cause a number of SG tubes to leak or rupture. Conversely, significant SG tube leakage or rupture is postulated to cause an unisolable secondary side breach which then may exacerbate the leakage.

Consequences of such an accident scenario are significant because primary coolant could be lost to the environment through the leaking or ruptured SG tubes and out the break in the secondary system. Given that the secondary side opening is outside containment but not isolable, the release

of radioactivity could be above 10 CFR Part 100 limits, depending upon the iodine spiking factor and the duration of blowdown. Further, the escaping coolant will not be returned to the containment sump. There is a high probability that the ECCS will successfully mitigate a LOCA during the injection phase. However, when the refueling water storage tank (RWST) is depleted, it may not be possible to use the recirculation mode, possibly resulting in core damage. Because the release path is open to the environment outside of the containment, the release of radioactivity from the postulated core damage event could have significant risk impacts.

The issue also includes the safety concerns of increased risk from degraded operator performance because of environmental conditions that can occur during the event. Eddy current testing and iodine spiking issues were not originally identified but were included in this evaluation to provide more complete bases for understanding the safety concerns.

PRIORITY DETERMINATION

The accident scenario of concern consists of two events: (1) a non-isolable secondary system break or rupture that is outside containment; and (2) a coupling of this break with the rupture of, or significantly increased leakage from, affected SG tubes.

Non-Isolable Main Steam Line Break Outside Containment: Main steam line breaks (or equivalent ruptures in attached piping or equipment) may be caused by a combination of stresses from restriction of pipe thermal expansion by pipe supports, weld defects, lack of pipe stress relief, age-related erosion/corrosion, vibration-induced cyclic fatigue, or repeated safety valve operation causing fatigue cycles to the piping and tubes and increasing the likelihood of a safety valve sticking open. Relatively large steam line breaks have occurred outside the containment, upstream of the MSIV, during hot functional testing at Robinson 2 and Turkey Point 3. These resulted in collateral valve, piping, and equipment damage; blowdown of the affected SGs; and excessive cooldown of the RCS. In addition, large amplitude vibrations of components and structures, water hammers, and sonic booms that affected operator communication and actions were observed. The Turkey Point 3 event involved SG re-pressurization shortly after the initial blowdown as a result of collateral damage.

Other Secondary System Breaks: It is also possible to initiate the accident scenario of interest with breaks in other parts of the secondary system such as a main feedwater line, steam line supplying steam-driven auxiliary feedwater, or other steam supply lines. These would be considered within the scope of this generic issue. Main and auxiliary feedwater systems generally have check valves located inside containment, which may also fail during the event. Steam supply lines other than main steam will have their own isolation valves, and because of their smaller diameter, rupture of these lines may not cause as severe a blowdown transient. However, a smaller opening may create resonance vibrations in the affected SG that would continue for a longer period of time.

Steam Generator Tube Cracks and Test Data: PWR SG tube cracks are caused by such common-mode failure mechanisms as outside diameter stress corrosion cracking, primary water stress corrosion cracking, fretting and wear, high cycle fatigue cracking, denting, pitting, and wastage. Plant TS require that a 3% sample of SG tubes undergo NDE periodically. The percentage of tubes inspected increases as more indications are found. Existing regulatory guidance would require tubes with greater than 40% through-wall cracks to be repaired or plugged.

Eddy current testing has a variable probability of detection that depends on: the type of probe; crack width, depth, length, and orientation; background interference; and human error. While crack

depth and length are the most important factors in determining SG tube integrity, accurate crack sizing by non-destructive means (eddy current, ultrasonics, etc.) remains challenging. Therefore, operation will likely occur with some degree of tube degradation at all times.

The NRC has approved several alternate repair criteria allowing small cracks to remain in service under certain conditions. Under the alternate repair criteria in Generic Letter 95-05¹⁸⁰⁴ for outside diameter stress corrosion cracks in intersections between tubes and tube support plates (TSPs), the industry must leak and burst test tube samples. However, the tubes are rigidly held in place during testing to avoid bending that would increase crack size. Tubes are tested under static conditions not subject to vibration and TSP movement that could be encountered during a main steam line break from differential pressure loadings and from vibrations at their lowest natural frequencies. Leak tests are not required to be performed at operating temperatures.

Resonance Vibrations: Resonance vibrations caused by a line break may develop in the SG internals through pressure pulses in the two-phase fluid and from pipe movement. Free span sections of tubes, portions of TSPs, and the U-tube assembly would vibrate from excitation frequencies emanating from the break. The tube/TSP movement from pressure pulses, resonance vibration, and potential steam chugging from possible recriticalities could destroy links between existing micro and macro cracks in SG tubes. Further, there has not been an integrated study of actual damage done to adjacent SG tubes following SGTRs, from steam line breaks, or from SG dry outs.

Neither resonance vibrations nor cross-flow forces can be calculated by the one-dimensional, RELAP thermal-hydraulic code. EPRI has developed multi-dimensional two-phase flow codes that are applicable only to steady-state conditions. The ACRS Ad Hoc DPO Subcommittee on SG integrity issues concluded¹⁸⁰⁰ that:

"... thermal-hydraulic codes usually employed by the staff for safety analyses are poorly suited to address the issues raised by this contention. The Subcommittee urges that investigation of this issue be completed expeditiously." (p. 10)

NRR's reviews in this area were consistent with the ACRS conclusion, since NRR has not relied upon licensee justifications based on such codes for SG secondary side analyses.

Tube Sheet Cladding Separation: Tube sheet cladding separation by the flow divider and cracks in first row tube welds and cladding may have occurred due to excessive primary-to-secondary tube sheet differential pressures during the primary system hydro at Robinson 2. The differential pressure across the tube sheet at Turkey Point 3 during its cold hydro was what could be expected from high head safety injection during main steam line break or stuck-open safety or atmospheric dump valve events, but this also caused cladding separation. Tube, tube sheet, and cladding stresses due to differential primary-to-secondary pressure and vibrations have not been modeled in an integrated risk assessment of a main steam line break.

Analysis and Understanding: The Ad Hoc DPO Subcommittee recommended¹⁸⁰⁰ that:

"Risk analyses that the staff considers need to account for progression of damage to steam generator tubes in a more rigorous way." They "... found that the staff did not have a technically defensible understanding of these processes to assess adequately the potential for progression of damage to steam generator tubes. Bending and flexion of the tubes produce conditions regarding crack growth, tube

leakage, and tube burst outside the range of analyses and experiments done by the staff." (p. 46) They concluded that the contention, "Depressurization of the reactor coolant system during a main steam line break will produce shock waves and violent, sympathetic vibrations that will cause cracks to form, to grow and to unplug, leading to much higher leakage from the primary-to-secondary sides of the reactor coolant system than has been considered by the NRC staff... has merit and deserves investigation." (p. 10) The Subcommittee concluded that "... there is an imperative for the staff to act expeditiously to develop a much better understanding of the dynamic processes associated with depressurization and how the processes could lead to damage progression." (p. 46) "Similarly, the Ad Hoc Subcommittee did not feel that the staff had developed an adequate understanding of how movement of the tube support plates during an event could damage the tubes and augment leakage from the primary side to the secondary side of the reactor coolant system. The staff needs to develop an understanding of how tube support plate movement could lead to unplugging of cracks occluded by corrosion products in the annular space between the tube support plate and the tubes." (p. 46) Also, "... the Ad Hoc Subcommittee has concluded that the staff has not adopted a technically defensible position on the choice of the iodine spiking factor to be used in the analysis of design basis accidents for compliance with the requirements of 10 CFR Part 100 or General Design Criterion (GDC) 19." (p. 48)

Operator Actions: The NRC has used estimates as low as 10^{-3} as the probability of the failure to depressurize and cool down the RCS in risk analyses of these containment bypass scenarios. The human error contribution to the estimated increment to core damage frequencies per year in these scenarios ranged from 29% to 93%. Operators have to identify the ruptured SG in order to isolate it, while primary and secondary temperature and pressure changes mask the diagnostic evidence they need to do so. There have been 10 SGTRs (or significant leaks) in U.S. PWRs from 1975 to 2000. Human performance weaknesses, such as mis-diagnoses, substantial delays in isolating the faulted steam generator, and delayed initiation of the residual heat removal system, have been identified in these events.^{1801, 1802} The events also involved unnecessary radiation releases, lack of RCS subcooled margin, excessive RCS cooldown rates, and overfilling the SG because of human or procedural problems.

The probability value can be significantly higher than 10^{-3} when performance shaping factors are incorporated for SGTRs concurrent with containment bypass based on operator performance as well as simulator experience. While one risk analysis that addressed a stuck open relief valve has a success path involving gagging the valve, this may be unrealistic given potential galling of the internals, steam release at the valve location, and the high radiation field at the valve created by a large tube leak. Additional complications would add to operator burdens. These include high noise levels preventing normal communications; RCS cooldown with potential recriticality; actions to recover RWST inventory; many radiation alarms, unexpected high radiation areas in the turbine building, and atmospheric releases; fire alarms and fires from steam and shrapnel from the break; and emergency communications with local, state, and Federal governments diverting operations personnel before the technical support center is manned or additional operations personnel arrive on site. The Halden Control Room Staffing study found poor operator performance in one of two simulations of a SG leak with a failed open SG safety relief valve, as well as simulations where crew size was decreased to attend to other duties.¹⁸⁰³ A model exists based on this simulation, but it has not been used in a sensitivity study to more accurately predict a probability of failure to depressurize and cool down the RCS under these circumstances.

The Ad Hoc DPO Subcommittee concluded¹⁸⁰⁰ that:

"... the [human performance] failure probabilities can rise from 10^{-3} to ~ 1 , depending on the number of failed steam generator tubes." They also said that "Risk evaluations should also include examination of the mechanisms for damage progression, which has not been observed in steam generator tube rupture accidents to date, but may occur as a result of dynamic processes during main steamline break depressurizations of the reactor coolant system. The effects of the dynamic events on operator performance both with respect to the time available for required responses and the level of operator distraction need to be evaluated." (p. 20) "In all cases, the staff needs to develop defensible analyses of the uncertainties in its risk assessments, including uncertainties in its assessments of human error probabilities. As the staff develops a better understanding of the dynamic processes associated with depressurization during a main steamline break, it may want to revisit estimates of operator error probability in light of the considerable operator distraction that might occur during such events." (p. 47)

CONCLUSION

The staff found that the accident scenarios were credible, and that the issue could not be addressed by the enforcement of existing regulations. Therefore, it was concluded that a technical assessment should be performed on the issue, in accordance with NRC Management Directive 6.4.

REFERENCES

11. NUREG-0800, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants," U.S. Nuclear Regulatory Commission, (1st Edition) November 1975, (2nd Edition) March 1980, (3rd Edition) July 1981.
1799. Memorandum for A. Thadani from J. Wiggins, "Staff Member Concern Regarding the Potential for Resonance Vibrations of Steam Generator Tubes During a Main Steam Line Break Event," June 27, 2000.
1800. Letter to W. Travers from D. Powers, "Differing Professional Opinion on Steam Generator Tube Integrity," February 1, 2001.
- 1801 Letter to W. F. Conway, (Arizona Public Service Company) from J. B. Martin (NRC), "NRC Inspection Report 50-529/93-14," April 16, 1993.
1802. Letter to A. A. Blind, (Consolidated Edison Company of New York, Inc.) from H. J. Miller (NRC), "NRC Augmented Inspection Team - Steam Generator Tube Failure - Report No. 05000247/2000-002," April 28, 2000.
1803. NUREG/IA-0137, "A Study of Control Room Staffing Levels for Advanced Reactors," U.S. Nuclear Regulatory Commission, November 2000.
1804. NRC Generic Letter 95-05, "Voltage-Based Repair Criteria for Westinghouse Steam Generator Tubes Affected by Outside Diameter Stress Corrosion Cracking," August 3, 1995.

1805. Memorandum to A. Thadani from N. Chokshi, "Initial Screening of Candidate Generic Issue 188, 'Steam Generator Tube Leaks or Ruptures, Concurrent with Containment Bypass from Main Steam Line or Feedwater Line Breaches,' May21, 2001.

ISSUE 189: SUSCEPTIBILITY OF ICE CONDENSER AND MARK III CONTAINMENTS TO
EARLY FAILURE FROM HYDROGEN COMBUSTION DURING A SEVERE
ACCIDENT

DESCRIPTION

Historical Background

This generic issue was proposed¹⁷⁹¹ in response to SECY-00-198¹⁷⁹² which explored means of making 10 CFR 50.44 risk-informed. As a part of this effort, the paper recommended that safety enhancements that have the potential to pass the backfit test be assessed for mandatory application through the generic issue program.

Safety Significance

Since the last revision of 10 CFR 50.44, "Standards for Combustible Gas Control System in Light-Water-Cooled Power Reactors," in 1987, there have been significant advances in the understanding of the risk associated with the production and combustion of hydrogen (and other combustible gases) during reactor accidents. The work discussed in SECY-00-198¹⁷⁹² was actually an investigation of relaxation of a number of requirements.

For the majority of PWRs with large dry or sub-atmospheric containments, direct containment heating (DCH) is the dominant mode of containment failure (a separate issue that was resolved by plant-specific comparison of DCH loads versus containment strengths), and the containment loads associated with hydrogen combustion are non-threatening.

However, it was discovered in the study associated with NUREG/CR-6427¹⁷⁹³ that, for ice condenser containments, the early containment failure probability is dominated by non-DCH hydrogen combustion events. This is not a surprising result, given the relatively low containment free volume and low containment strength in these designs. These containments rely on the pressure-suppression capability of their ice beds, and, for a design-basis accident, where the pressure is a result of the release of steam from blowdown of the primary (or secondary) system, an ability to withstand high internal pressures is not needed.

In a beyond-design-basis accident, where the core is severely damaged, significant quantities of hydrogen gas can be released. This hydrogen is generated by the exothermic chemical reaction of water and steam with metal (especially the Zircaloy cladding), and (to some extent) by radiolysis of water, where gamma rays actually split water molecules into hydrogen and oxygen.

To deal with large quantities of hydrogen, these containments are equipped with AC-powered igniters, which are intended to control hydrogen concentrations in the containment atmosphere by initiating limited "burns" before a large quantity accumulates. In essence, the igniters prevent the hydrogen (or any other combustible gas) from accumulating in large quantities and then suddenly burning (or detonating) all at once, which would pose a threat to containment integrity.

For most accident sequences, the hydrogen igniters can deal with the potential threat from combustible gas buildup. The situation of interest for this generic issue only occurs during accident

sequences associated with station blackouts, where the igniter systems are not available because they are AC-powered.

Thus, this does not affect the frequency of severe accidents, but does affect the likelihood of a significant release of radioactive material to the environment should such an accident occur.

The issue also applies to BWR MARK III containments, because they also have a relatively low free volume and low strength, comparable to those of the PWR ice condenser designs. The MARK I and MARK II designs are also pressure-suppression designs, but are operated with the containment "inerted," i.e., the drywell and the air space above the suppression pool are flooded with nitrogen gas, and a nitrogen makeup system maintains oxygen level below a set limit by maintaining a slight positive nitrogen pressure within the primary containment. The low oxygen concentration is sufficient to accommodate the hydrogen threat (except possibly for long-term radiolysis). In contrast, the MARK III designs are equipped with hydrogen igniters just as are the PWR ice condenser designs, and are similarly potentially vulnerable in an accident sequence associated with station blackout.

Possible Solution

The solution is to provide an independent power supply for the igniter systems for the subject containments. The igniters are, essentially, diesel engine glow plugs. If necessary, they could be powered by storage batteries or by a portable generator.

PRIORITY DETERMINATION

The two containment types, ice condenser and MARK III, will be examined separately. In each case, the objective is to calculate plausible estimates of risk parameters that represent the particular class of plants in question. These estimates are for prioritization purposes only, and are not intended to represent the best the state of the art can produce.

In addition to the generic estimate calculated here, an independent calculation has been performed¹⁷⁹⁴ by Energy Research, Inc. (ERI). The ERI study arose out of an investigation of possible risk-informed alternative approaches to 10 CFR 50.44, the same project that generated this generic issue. The ERI study is based on the IPE and IPEEE studies for Catawba and Grand Gulf. Although the ERI study is more plant-specific, it also avoids some of the more debatable assumptions that were necessary in the generic analysis presented here.

PWR Ice Condenser

We will examine the ice condenser plants first. The strategy will be to start with the NUREG-1150¹⁰⁸¹ Sequoyah Level II PRA, which should be reasonably representative and also has the advantage of being readily available, and modifying it in two ways. First, use plant damage state frequencies that are more generically representative, and second, change the probability of containment failure caused by hydrogen combustion to a value consistent with more modern investigations.

Frequency Estimate

The severe accident frequency of interest is the frequency of severe accidents associated with station blackout. Fortunately, this frequency is routinely calculated in PRAs, including the

NUREG-1150¹⁰⁸¹ PRA and NUREG/CR-4551¹⁷⁹⁵ for the Sequoyah plant (the only NUREG-1150 PRA for a PWR with an ice condenser containment). However, internal-events PRAs such as the NUREG-1150¹⁰⁸¹ Sequoyah study do not give the complete picture. Although these studies include station blackouts initiated by both plant-centered and grid-initiated losses of offsite power, external events are not included. In most external event studies, the principal accident sequence leading to severe core damage comes from a station blackout. In seismically-initiated sequences, the seismic event damages the ceramic insulators in the transmission lines, effectively disconnecting the plant from offsite power, and also increases the likelihood of a failure of onsite power. Similarly, the fire-initiated sequences may involve a fire in the electrical switchgear, again causing a total loss of AC power.

The following table summarizes estimates of this parameter from several sources:

| Site | NUREG-1150 Slow SBO | NUREG-1150 Fast SBO | IPE CDF | IPE SBO CDF | IPEEE Fire CDF | IPEEE Seismic CDF | IPEEE External CDF | Total IPE/IPEEE CDF |
|-----------|---------------------------------------|---------------------|-------------------|-------------|--|-------------------|--------------------|---------------------|
| Sequoyah | 4.58E-6 | 9.26E-6 | 1.70E-4 | 5.32E-6 | 1.6E-5 | [Margin] | [1.6E-5] | [1.86E-4] |
| Watts Bar | | | 8.00E-5 | 1.73E-5 | 7.0E-6 | [Margin] | [7.0E-6] | [8.70E-5] |
| Catawba | | | 5.80E-5 | 6.00E-7 | 4.7E-6 | 1.6E-5 | 2.1E-5 | 6.01E-5 |
| McGuire | | | 4.00E-5 | 9.32E-6 | 2.3E-7 | 1.1E-5 | 1.1E-5 | 5.1E-5 |
| DC Cook | | | 6.26E-5 | 1.13E-6 | 3.8E-6 | 3.2E-6 | 7.0E-6 | 7.0E-5 |
| "Average" | | | | 6.73E-6 | 6.34E-6 | 1.01E-6 | | |
| | From CRIC-ET database ¹⁷⁹⁶ | | From IPE database | | From NUREG/CR-6427 ¹⁷⁹³ (Table 7.5) | | | |

(The significant figures presented in this table are given for the convenience of the reader who wishes to duplicate the calculations, and are not intended to imply that these estimates are known to two or three significant figure accuracy.)

As can be seen from the IPE SBO column, the internal-events SBO-initiated CDF ranges over the decade from 10^{-6} to 10^{-5} . The fire- and seismically-initiated CDFs, which generally involve loss of all AC power, are in the same range. The row labeled "average" is a simple arithmetic mean average over the five sites, and is intended to provide a point estimate representative of this class of plants, recognizing that individual plants vary.

Of course, the fire and seismic initiator CDFs do not consist exclusively of sequences involving loss of all AC power, and the specifics of this breakdown will be plant-specific. To get a generically-representative number, it will be necessary to make some assumptions, recognizing that the result will be, at best, a rough estimate. The NUREG-1150¹⁰⁸¹ PRA for Sequoyah did not address external events. Thus, we will base these assumptions on the fire and seismic analyses of the NUREG-1150 Surry PRA (NUREG/CR-4551,¹⁷⁹⁵ Vol. 3, Rev. 1, Parts 1 and 3),¹⁷⁹⁵ which have the advantage of readily-available and abundant documentation. (Surry is not an ice condenser plant, but containment design should not greatly affect the frequency and course of fire and seismically initiated sequences.) This "hybridization" or use of one PRAs results in another PRA, results in, at best, a very rough approximation. However, it will be shown later that the conclusion is not greatly affected by this approximation.

In the Surry fire analysis, the principal fire-initiated plant damage states were associated with four locations:

| PDS for Surry Fire Initiators (NUREG/CR-4551, ¹⁷⁹⁵ Table 2.2-4, pp. 2 to 14) | |
|--|-------|
| Emergency Switchgear Room | 54.3% |
| Auxiliary Building | 20.0% |
| Cable Vault and Tunnel | 13.0% |
| Control Room | 12.7% |

Fires in the emergency switchgear room, control room or auxiliary building are not likely to disable the igniters. Even if such a fire disabled emergency power, normal power would be available. However, it will be assumed that fires in the cable vault and tunnel will also disable the igniters, and thus 13% of the fire frequency will be added to the internal SBO frequency.

The Surry seismic analysis can be used in a more straightforward manner, since the four seismic groups explicitly list station blackout.

| Plant Damage States for Seismic Initiators (NUREG/CR-4551, ¹⁷⁹⁵ Table 2.2-6, pp. 2.16 to 2.17) | | | |
|--|--------------------------------|------------------------------------|------------------------------------|
| Group | Description | LLNL-based fraction of seismic CDF | EPRI-based fraction of seismic CDF |
| EQ 1 | Loss of Station Power (no SBO) | 47.1% | 53.7% |
| EQ 2 | SBO | 41.1% | 33.7% |
| EQ 3 | LOCAs | 11.9% | 12.5% |

Here, we will use the EPRI-based estimate of 33.7%, as being more in line with modern analyses.

Large Early Release Frequency (LERF) Estimate

According to the studies presented in NUREG/CR-6427,¹⁷⁹³ the likelihood of early containment failure due to uncontrolled post-accident hydrogen combustion is significantly higher than the figure used in the NUREG-1150¹⁰⁸¹ PRA for Sequoyah. Table 7.3 of NUREG/CR-6427¹⁷⁹³ gives a non-DCH failure probability for both fast and slow station blackout sequences of 0.9021, which is essentially all due to hydrogen combustion. The non-DCH failure probability is given as zero for all other core damage initiators, presumably due to the availability of AC power for the igniters. Therefore, it can be assumed that providing an alternative power supply for the igniters would lower the total containment failure probability by about 0.9. With this, it is possible to estimate the change in large early release frequency (Δ LERF) associated with the issue:

| | CDF | SBO Fraction | SBO CDF | Change in Containment Failure Probability | Δ LERF |
|----------|---------|--------------|---------|---|---------------|
| Internal | | | 6.73E-6 | 0.90 | 6.06E-6 |
| Fire | 6.34E-6 | 13% | 8.24E-7 | 0.90 | 7.42E-7 |
| Seismic | 1.01E-6 | 33.7% | 3.40E-7 | 0.90 | 3.06E-6 |

Again, the significant figures are given for convenience in following these calculations, and are not intended to imply a high accuracy in the estimates.

The screening threshold for LERF given in Management Directive 6.4 (Appendix C, Figure C4) is any change in LERF greater than $10^{-6}/\text{RY}$, regardless of the initial LERF. Thus, for ice condenser plants, this issue passes this screening criterion. It should be noted that the criterion is met even without the external events.

Recoverability: The analysis above does not distinguish between recoverable and non-recoverable station blackout. This leads to some conservatism in the result, since the existing igniter system will become available if AC power is recovered after core melt, but before hydrogen ignition. It should be noted, however, that the efficacy of the igniters in preventing large scale burns depends on their availability early, before combustible gases have time to accumulate in large quantities. Once this accumulation occurs, turning on the igniters may be counterproductive.


Hybridization: The various core damage frequencies and associated changes in LERF are based on a hybridization of several PRAs. Moreover, the estimates of the station blackout portion of the seismic and fire CDFs are, at best, educated guesses. Nevertheless, if the change in containment failure probability is 90%, most of the IPE SBO core damage frequencies are high enough for the Δ LERF to pass the screening criterion even without the hybridization or addition of external events. The conclusion that this issue passes the screening criterion is reasonably robust.

Consequence Estimate

Estimating the risk to the population from these accident sequences is not as straightforward as estimating LERF. In the integrated risk analysis for the NUREG-1150¹⁰⁸¹ PRAs, the accident frequency analysis ("front end" analysis) produces an overall CDF, and also a set of plant damage states; each with its own frequency. For the Sequoyah PRA, the plant damage states are:

| PDS Index | Plant Damage State (PDS) |
|-----------|------------------------------------|
| 1 | Slow Station Blackout |
| 2 | Fast Station Blackout |
| 3 | LOCA |
| 4 | Event V (interfacing systems LOCA) |
| 5 | Transient |
| 6 | ATWS |
| 7 | Steam Generator Tube Rupture |

The sequences of interest here are in plant damage states 1 and 2. However, these plant damage states do not correlate one-to-one with a consequence analysis. A description of the integrated risk analysis can be found in Reference 6, from which the following figure is taken:



In the integrated risk analysis, the accident progression event tree analysis (a very extensive set of calculations) is used to calculate a set of accident progression bin frequencies from each PDS. The set of accident progression bins is then input into a partitioning analysis (also very extensive) to calculate source term groups and associated frequencies. Actual consequences (e.g., man-rem) are then calculated for each source term, and the total risk is calculated by multiplying each consequence by its source term frequency, and summing the products.

It is not practical to calculate the risk associated with this issue with a hand calculation. Instead, a sensitivity analysis computer code, the Computational Risk Integration and Conditional Evaluation Tool (CRIC-ET), was used.¹⁷⁹⁶

In order to use this code, it was necessary to "split" the generic station blackout frequency estimated above into "slow SBO" and "fast SBO." The IPE and IPEEE averages do not make this distinction, and thus some approximations must again be made. The three components, internal, seismic, and fire, were handled separately:

Internal - The internal SBO frequency contribution, based on the IPE average, was

subdivided into slow and fast based on the proportions in the Sequoyah NUREG-1150¹⁰⁸¹ PRA:

| | NUREG-1150 ¹⁰⁸¹ SBO CDF | Fractional Contribution | IPE-based SBO CDF | Proportioned SBO CDF |
|-------|---------------------------------------|----------------------------|----------------------|-------------------------|
| Slow | 4.58E-6 | 33.1% | 6.73E-6 | 2.23E-6 |
| Fast | 9.26E-6 | 66.9% | | 4.50E-6 |
| Total | 1.38E-5 | 100% | 6.73E-6 | 6.73E-6 |

Seismic - The seismic SBO contribution (33.7% of the total seismically-initiated CDF, as discussed under LERF above) was assumed to be entirely in the slow category. (Generally, the seismic event causes the station blackout and destroys the condensate storage tank, and eventually the steam generators dry out.)

Fire - The fire SBO contribution (13.0% of the fire-initiated CDF) was assumed to be entirely in the fast category. (Fires in the cable vault are likely to fail everything at once.)

Several other assumptions were necessary:

The other PDS frequencies were set to zero so that the analysis would only include the SBO plant damage states.

The sequences ending in no containment failure were re-directed to the early containment failure accident progression bin, to account for the high susceptibility of the containment to failure due to hydrogen combustion, as estimated in NUREG/CR-6427.¹⁷⁹³ This is a slight overestimate, in that the containment failure probability due to hydrogen combustion is 90% rather than 100%, but the CRIC-ET code does not have this flexibility.

A corrected consequence file for Sequoyah was used to correct a known error.¹⁷⁹⁷ The results of the calculation of population dose within 50 miles of a reactor, using 200 samples and the usual limited Latin Hypercube technique, were:

| | | |
|-----------------------------|---|---------------------------------|
| 5 th percentile | - | 3.86 x 10 ⁻³ man-rem |
| 95 th percentile | - | 20.3 man-rem |
| Median | - | 2.24 man-rem |
| Mean | - | 6.43 man-rem |

Again, as is obvious from the distribution, the two decimal places are not significant and are given only for purposes of reproducing the calculation. The error bounds reflect only the uncertainty associated with the Level II analysis, and do not include the uncertainty associated with the generic station blackout frequency or split of this frequency into the fast and slow SBO plant damage states.

Generic Population Distribution: The man-rem/RY figure above is based on the NUREG-1150¹⁰⁸¹ model which is specific to the Sequoyah site. For generic issue calculations, such figures are generally based on a uniform population density of 340 persons/square-mile and a typical central Midwest plains meteorology. It is not practical to re-run the consequence analysis for the generic site but, as a first approximation, the risk figures can be re-normalized to the generic population.

Interpolating between the 30- and 100-mile radius population figures given in NUREG/CR-4551¹⁷⁹⁵ (Volume 5, Rev. 1, Part 1, Page 4.2), the Sequoyah population density for a 50- mile radius is approximately 159 persons/square-mile. Thus, to get a generic risk figure, the 6.43 man-rem/RY (mean) figure should be multiplied by 340/159. This gives a generic estimate of 13.73 man-rem/RY.

Aggregated Risk Figure: There are nine reactors with an ice condenser containment. Thus, the aggregated risk figure is 13.73 man-rem/RY times 9 reactors or 124 man-rem/year.

The screening threshold for averted offsite risk given in Management Directive 6.4 (Appendix C, Figure C6) is an averted offsite man-rem/year greater than 100, if the cost/benefit ratio is favorable (i.e., less than \$2,000/man-rem).

Cost Estimate

A separate cost investigation will not be performed here. The ERI study¹⁷⁹⁴ concluded that the proposed fix is cost-beneficial. Therefore, it will be assumed here that the cost/benefit ratio is less than \$2,000/man-rem, and the issue passes the screening threshold for risk.

Other Considerations

Hybrid Models: The split of the generic station blackout frequency into the fast and slow station blackout plant damage states, as described above, is questionable at best, since it is based on a hybridization of several PRAs. Because of this, a sensitivity analysis was done to investigate how big an effect this was. First, the entire station blackout frequency was assigned to the slow SBO PDS and a mean man-rem/RY was calculated. Then, the entire frequency was assigned to the fast SBO PDS, and the calculation repeated. The results were:

| Split | Mean Risk (man-rem/RY) |
|---------------------------|------------------------|
| All in the slow SBO PDS | 5.38 |
| All in the fast SBO PDS | 6.94 |
| "Best guess" proportioned | 6.43 |

Based on these results, it seems safe to conclude that the results are not very sensitive to how the frequency is split between the two plant damage states.

Recoverable Station Blackout: The Sequoyah analysis, as modeled in CRIC-ET, does not distinguish between recoverable and non-recoverable station blackout. As was the case in the estimate of LERF, this leads to some conservatism in the result, since the existing igniter system will become available if AC power is recovered after core melt, but before hydrogen ignition. Once again, however, the efficacy of the igniters in preventing large scale burns depends on their availability early, before combustible gases have time to accumulate in large quantities. Once this accumulation occurs, a late initiation of the igniter systems may not have the desired result.

ERI study: The ERI study¹⁷⁹⁴ estimated a risk of 3 man-rem/RY using the Catawba site and a more sophisticated methodology, which is about a factor of two less than the estimate presented here. In the context of PRA studies, a factor of two is very good agreement.

BWR MARK III Containments

The strategy for MARK III BWR containments is similar to that for ice condensers. The NUREG-1150¹⁰⁸¹ Level II model for the Grand Gulf plant will be used, but will be modified to be more generic and to include a higher probability for containment failure due to hydrogen combustion.

The NUREG-1150¹⁰⁸¹ Level II model for Grand Gulf is described in detail in NUREG/CR-4551¹⁷⁹⁵ (Vol. 6, Rev. 1, Part 1). The general approach, using plant damage states, accident progression bins, and source term groups, is similar to that discussed above for the Sequoyah model. However, the individual plant damage states are defined differently.

The Grand Gulf model consists of twelve plant damage states. PDS 1 through 8 are associated with station blackout, PDS 9 and 10 are associated with ATWS, and PDS 11 and 12 are associated with non-ATWS transient-initiated sequences. Although the total CDF (as estimated in NUREG-1150¹⁰⁸¹) is rather low (about $4 \times 10^{-6}/\text{RY}$), about 97% of this CDF comes from the station blackout sequences NUREG/CR-4551¹⁷⁹⁵ (Vol. 6, Rev. 1, Part 1, Table 2.2-3).

Of the eight station blackout plant damage states, the first six are recoverable station blackouts, in which severe core damage occurs, but AC power is recovered in time for the "miscellaneous systems" - containment venting, standby gas treatment, containment isolation, and the hydrogen igniters - to be effective. (This explicit modeling avoids the problems with treating recoverable station blackouts in the ice condenser plants, discussed earlier.) Adding backup power to the hydrogen igniters will not affect the sequences in these plant damage states.

Thus, the plant damage states of interest are PDS 7, non-recoverable fast SBO, and PDS 8, non-recoverable slow SBO. These two plant damage states represent 11% and 2% of the total station blackout frequency, respectively (NUREG/CR-4551,¹⁷⁹⁵ Vol. 6, Rev. 1, Part 1).

Frequency Estimate

The NUREG-1150¹⁰⁸¹ estimate of CDF for Grand Gulf is $4 \times 10^{-6}/\text{RY}$, which is somewhat lower than the Grand Gulf IPE estimate of $1.72 \times 10^{-5}/\text{RY}$. Again, it is necessary to find a more generic number. For the IPEs' CDFs and, specifically, the IPE SBO CDFs, these figures are tabulated in the IPE Database.

As in the analysis of ice condenser plants, the fire-induced accident sequences are also significant. These are available from the IPEEE program, in NUREG-1742¹⁷⁹⁸ (Volume 2, Table 3.2).

Seismically-induced sequences are also a concern. However, there are no PRAs available for any plant with a MARK III containment. All four MARK III plants were analyzed with a seismic margins approach in the IPEEE program. Thus, once again it will be necessary to use a bit of improvisation.

The Grand Gulf and River Bend sites are in areas of low seismicity, and thus it is not anticipated that seismic sequences would be a significant contributor. The Clinton and Perry plants are located in areas of moderate seismicity, and thus may be of more concern. Given that there are no appropriate PRAs, the only recourse is to find a similar plant. The LaSalle plant is a reasonable choice, although it is a BWR/5 model with a Mark II containment, because the reactor systems (not containment systems) are similar, and the site is in the same general area (Great Lakes). The LaSalle seismic CDF, based on an existing simplified seismic PRA, is $7.6 \times 10^{-7}/\text{RY}$, as reported in NUREG-1742¹⁷⁹⁸ (Volume 2, Table 2.1). Although the use of this number is highly questionable

at best, the seismic contribution is expected to be relatively minor compared to the other contributors, and thus more uncertainty can be tolerated. The CDF figures are as follows:

| Site | NUREG-1150 Non-recoverable Fast SBO CDF | NUREG-1150 Non-recoverable Slow SBO CDF | IPE CDF | IPE SBO CDF | IPEEE Fire CDF | IPEEE Seismic CDF |
|------------|---|---|-------------------|----------------|---|----------------------|
| Clinton | | | 2.66E-5 | 9.80E-6 | 3.64E-6 | SMA |
| Grand Gulf | 4.3E-7 (11%) | 6.6E-8 (2%) | 1.72E-5 | 7.46E-6 | 8.89E-6 | SMA |
| Perry | | | 1.30E-5 | 2.25E-6 | 3.27E-5 | SMA |
| River Bend | | | 1.55E-5 | 1.35E-5 | 2.25E-5 | SMA |
| LaSalle | | | | | | 7.6E-7 |
| "Average" | | | | 8.25E-6 | 1.69E-5 | 7.6E-7 |
| | From CRIC-ET database ¹⁷⁹⁶ | | From IPE database | | From NUREG/CR-1742 ¹⁷⁹⁶ (Vol. 2, Table 3.2) | |

Large Early Release Frequency (LERF) Estimate

To get non-recoverable station blackout frequencies, it will be assumed that the same percentage of the total station blackout frequency is non-recoverable as was the case in the NUREG-1150¹⁰⁸¹ model, which is 13% (11% fast SBO plus 2% slow SBO). The generic estimate for the total non-recoverable SBO CDF is then:

$$[(8.25 \times 10^{-6} + 1.69 \times 10^{-5} + 7.6 \times 10^{-7}) \times 13\%] \text{ event/RY} = 3.37 \times 10^{-6} \text{ event/RY}$$

The response of the MARK III containments to an uncontrolled hydrogen containment is expected to be similar to that of an ice condenser containment. Thus, the change in large early release frequency (Δ LERF) will be approximately 90% of the CDF associated with unrecoverable station blackout:

$$\Delta \text{LERF} = 3.37 \times 10^{-6} \times 90\% = 3 \times 10^{-6} \text{ event/RY}$$

This is above the screening threshold given in Management Directive 6.4 (Appendix C, Figure C4), regardless of the initial LERF.

Other Considerations

As was the case with ice condenser containments, this generic estimate, the various CDFs and associated changes in LERF are based on a hybridization of several PRAs. Moreover, the estimates of the station blackout portion of the seismic and fire CDFs are, at best, educated guesses, and the fire contribution is the largest contributor. However, if the fire and seismic portions were not included, the Δ LERF would still be about 9.7×10^{-7} event/RY, very close to the cutoff of 10^{-6} event/RY.

If it is postulated that hydrogen combustion without igniters will result in containment failure 90% of the time, the robustness of the conclusion depends primarily on the SBO CDFs taken from the IPE submittals for the four plants, the assumption that about 13% will be non-recoverable

blackouts, and an assumption that there will be at least a small contribution from external events. Even though there are many approximations in the estimates calculated above, these points seem reasonable.

Consequence Estimate

The MARK III containment has two air spaces, the drywell free volume and the wetwell airspace above the suppression pool. Combustible gases generated in the vessel prior to vessel breach may be vented by the safety/relief valves and tailpipes through the suppression pool to the wetwell airspace. After vessel breach, combustible gases may accumulate in the drywell airspace, and may be forced through the weir wall to the wetwell airspace. Combustion may occur in either airspace. Both airspaces are equipped with igniters.

In the NUREG-1150¹⁰⁸¹ Grand Gulf analysis, the automatic depressurization system is not operable in a station blackout, and the vessel remains at high pressure. Moreover, depressurization of the vessel would have allowed the operators to use the firewater system to inject coolant. Thus, in the sequences of interest here, the vessel is likely to remain at high pressure until failure occurs at the bottom head.

The drywell is generally stronger than the wetwell. In most, but not all, cases, overpressurization will fail the containment in the wetwell airspace, which will cause radioactive releases to pass through (and be scrubbed by) the suppression pool. The accident progression event trees and source term analyses must account for all of this. A complete description can be found in NUREG/CR-4551¹⁷⁹⁵ (Volume 6, Rev. 1, Part 1).

To use the Grand Gulf model in the CRIC-ET code, the following assumptions were made:

11% of the generic internal SBO CDF frequency will be placed into PDS7 (non-recoverable fast blackout), and 2% will be placed into PDS8 (non-recoverable slow blackout), the proportions used in the Grand Gulf model.

The same 11%/2% split applies to the fire CDF frequency. Most dominant fire scenarios result in a plant transient, generally involving loss of electrical buses due to the fire (See NUREG/CR-4551,¹⁷⁹⁵ Volume 4, Rev. 1, Part 1, §3.3.2.3). There is no easy way to estimate the fraction of these which involve non-recoverable station blackouts, so the fractions used in the internal events analysis will be used.

All of the seismic sequences are slow, non-recoverable blackouts.

As in the calculation for the ice condenser containments, several other assumptions were necessary:

The other PDS frequencies were set to zero, so that the analysis would only include the non-recoverable station blackout plant damage states.

The sequences ending in no containment failure ("characteristic 6" in the Grand Gulf model - see NUREG/CR-4551¹⁷⁹⁵ (Volume 6, Rev. 1, Part 1, Table 2.4-1) were re-directed to the "rupture before vessel breach" accident progression bin, to account for the assumed high susceptibility of the containment to fail due to hydrogen combustion. This is a slight overestimate, since the model presumed that the igniters were not available in PDS 7 and

8 in any case. :

The results of the calculation of population dose within 50 miles per reactor, using 250 samples and the usual limited Latin Hypercube technique, were:

| | |
|-----------------------------|---------------------------------|
| 5 th percentile | 1.23 x 10 ⁻² man-rem |
| 95 th percentile | 1.35 man-rem |
| Median | 0.136 man-rem |
| Mean | 0.363 man-rem |

Again, as is obvious from the distribution, the two decimal places are not significant and are given only for purposes of reproducing the calculation. The error bounds reflect only the uncertainty associated with the Level II analysis, and do not include the uncertainty associated with the generic station blackout frequency or split of this frequency into the non-recoverable fast and slow SBO plant damage states.

Generic Population Distribution: The man-rem/Ry figure is based on the NUREG-1150¹⁰⁸¹ model which is specific to the Grand Gulf site. For generic issue calculations, such figures are generally based on a uniform population density of 340 persons/square-mile and a typical central Midwest plains meteorology. It is not currently practical to re-run the consequence analysis for the generic site, but as a first approximation, the risk figures can be re-normalized to the generic population. Interpolating between the 30- and 100-mile radius population figures given in NUREG/CR-4551¹⁷⁹⁵ (Volume 6, Rev. 1, Part 1, Page 4.3) the Grand Gulf population density for a 50-mile radius is approximately 39.3 persons/square-mile, much less than the generic figure. Thus, to get a generic risk figure, the 0.363 man-rem/Ry figure should be multiplied by 340/39.3, which gives a generic estimate of 3.14 man-rem/Ry.

Aggregated Risk Figure: There are only four reactors with a MARK III containment. Thus, the aggregated risk figure is 3.14 man-rem/Ry times 4 reactors or 12.6 man-rem/Ry.

Screening Threshold: The screening threshold for averted offsite risk given in Management Directive 6.4 (Appendix C, Figure C6) is an averted offsite man-rem/year greater than 100, if the cost/benefit ratio is less than \$2,000/man-rem. Thus, this criterion is not met for MARK III plants, regardless of cost.

Other Considerations

Hybrid Models: The split of the generic station blackout frequency into the fast and slow station blackout plant damage states, as described above, is questionable at best, since it is based on a hybridization of several PRAs. Because of this, a sensitivity analysis was done to investigate how big an effect this was. First, the entire station blackout frequency was assigned to the slow SBO PDS and a mean man-rem/Ry was calculated. Then, the entire frequency was assigned to the fast SBO PDS, and the calculation repeated. The results were:

| Split | Mean Risk (man-rem/Ry) |
|---------------------------|------------------------|
| All in the slow SBO PDS | 0.386 |
| All in the fast SBO PDS | 0.341 |
| "Best guess" proportioned | 0.363 |

Based on these results, it seems safe to conclude that the results are not very sensitive to how the frequency is split between the two plant damage states.

Re-Direction of Sequences Ending in No Containment Failure: A sensitivity analysis was performed to test the re-direction of the sequences that did not result in containment failure in the original model into failure before vessel breach. As was stated previously, the original model should have already accounted for the unavailability of the hydrogen igniters, so this was expected to be a minor effect. The sensitivity analysis calculated a population risk of 0.360 man-rem instead of 0.363 man-rem, which confirms the expectation.

ERI Study: The ERI study¹⁷⁹⁴ estimated a risk of 1.3 man-rem/R Y for Grand Gulf. This is roughly a factor of four larger than the estimate calculated here. In the context of PRA calculations, this is reasonable agreement. It should be noted that quadrupling the generic risk estimates would not change the conclusion.

CONCLUSION

Based on the change in large early containment failure frequency (LERF) for both PWR ice condenser and BWR Mark III containment designs and on the change in risk (as measured by man-rem/year) for the ice condenser designs, this issue passes the screening criteria and should go on to the technical assessment stage.

REFERENCES

1081. NUREG-1150, "Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants," U.S. Nuclear Regulatory Commission, (Vol. 1) December 1990, (Vol. 2) December 1990, (Vol. 3) January 1991.
1791. Memorandum to J. Flack from M. Cunningham, "Information Concerning Generic Issue on Combustible Gas Control for PWR Ice Condenser and BWR Mark III Containment Designs," August 15, 2001.
1792. SECY-00-0198, "Status Report on Study of Risk-Informed Changes to the Technical Requirements of 10 CFR Part 50 (Option 3) and Recommendations on Risk-Informed Changes to 10 CFR 50.44 (Combustible Gas Control)," September 14, 2000.
1793. NUREG/CR-6427, "Assessment of the DCH Issue for Plants with Ice Condenser Containments," U.S. Nuclear Regulatory Commission, April 2000.
1794. Memorandum to M. Snodderly (NRC) from M. Zavisca, et al. (ERI), "Combustible Gas Control Risk Calculations (DRAFT) for Risk-Informed Alternative to Combustible Gas Control Rule for PWR Ice Condenser, BWR Mark I, and BWR Mark III (10 CFR 50.44)," October 22, 2001.
1795. NUREG/CR-4551, "Evaluation of Severe Accident Risks: Methodology for the Containment, Source Term, Consequence, and Risk Integration Analyses," U.S. Nuclear Regulatory Commission, (Vol. 1, Rev. 1) December 1993, (Vol. 7, Rev. 1) March 1993
1796. T. D. Brown *et al.*, "NUREG-1150 Data Base Assessment Program: A Description of the Computational Risk Integration and Conditional Evaluation Tool (CRIC-ET) Software and

the NUREG-1150 Data Base," letter report, March 1995.

- 1797. Letter to H. VanderMolen (NRC) from V. Mubayi (BNL), "NUREG-1150 Consequence Calculations," July 20, 1994.
- 1798. NUREG-1742, "Perspectives Gained from the Individual Plant Examination of External Events (IPEEE) Program, Main Report," (Volumes 1 and 2) April 2002.

REFERENCES

- * [Accession Numbers] are provided for easy retrieval of those documents that are accessible from the NRC Nuclear Documents System Advanced Design (NUDOCS/AD) or the Agencywide Documents Access and Management Systems (ADAMS)
1. SECY-81-513, "Plan for Early Resolution of Safety Issues," August 25, 1981. [8109140067]
 2. NUREG-0371, "Task Action Plans for Generic Activities (Category A)," U.S. Nuclear Regulatory Commission, November 1978.
 3. NUREG-0471, "Generic Task Problem Descriptions (Categories B, C, and D)," U.S. Nuclear Regulatory Commission, June 1978.
 4. NUREG-0572, "Review of Licensee Event Reports (1976-1978)," U.S. Nuclear Regulatory Commission, September 1979.
 5. IE Circular No. 77-07, "Short Period During Reactor Startup," U.S. Nuclear Regulatory Commission, April 15, 1977. [9104240445]
 6. IE Bulletin No. 79-12, "Short Period Scrams at BWR Facilities," U.S. Nuclear Regulatory Commission, May 31, 1979. [7906060168]
 7. Memorandum for D. Ross from H. Richings, "RDA Statistical Analysis," June 17, 1975. [8105050833]
 8. SECY-80-325, "Special Report to Congress Identifying New Unresolved Safety Issues," July 9, 1980. [8103180932]
 9. Federal Register Notice 54 FR 16030, "Draft Regulatory Guide; Withdrawal," April 20, 1989.
 10. NUREG/CR-3992, "Collection and Evaluation of Complete and Partial Losses of Off-Site Power at Nuclear Power Plants," U.S. Nuclear Regulatory Commission, February 1985.
 11. NUREG-0800, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants," U.S. Nuclear Regulatory Commission, (1st Edition) November 1975, (2nd Edition) March 1980, (3rd Edition) July 1981.
 12. Draft Regulatory Guide and Value/Impact Statement, Task SC 708-4, "Qualification and Acceptance Tests for Snubbers Used in Systems Important to Safety," U.S. Nuclear Regulatory Commission, February 1981. [9503290322]
 13. NUREG-0691, "Investigation and Evaluation of Cracking Incidents in Piping in Pressurized Water Reactors," U.S. Nuclear Regulatory Commission, September 1980.
 14. ASME Boiler and Pressure Vessel Code, Section XI, "Rules for Inservice Inspection of Nuclear Power Plant Components," American Society of Mechanical Engineers, 1974.

15. Nuclear Safety, Vol. 14, No. 3, 'Probability of Damage to Nuclear Components Due to Turbine Failure," S. H. Busch, 1973.
16. WASH-1400 (NUREG-75/014), "Reactor Safety Study, An Assessment of Accident Risks in U.S. Commercial Nuclear Power Plants," U.S. Atomic Energy Commission, October 1975.
17. NUREG/CR-0255, "CONTEMPT-LT/028: A Computer Code for Predicting Containment Pressure-Temperature Response to a Loss-of-Coolant Accident," U.S. Nuclear Regulatory Commission, March 1979.
18. Regulatory Guide 1.46, "Protection Against Pipe Whip Inside Containment," U.S. Atomic Energy Commission, May 1973. [7907100189]
19. NUREG-0588, "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment," U.S. Nuclear Regulatory Commission, November 1979, (Rev. 1) July 1981.
20. Memorandum for R. Fraley from R. Mattson, "ACRS PWR Question Regarding Effect of Pressurizer Heater Uncovery on Pressurizer Pressure Boundary Integrity," November 5, 1979. [8004100530]
21. Regulatory Guide 1.96, "Design of Main Steam Isolation Valve Leakage Control Systems for Boiling Water Reactor Nuclear Power Plants," U.S. Nuclear Regulatory Commission, (Rev. 1) June 1976. [7907100349]
22. Memorandum for H. Denton from C. Michelson, "BWR Jet Pump Integrity," May 23, 1980. [8006180872]
23. Memorandum for Distribution from W. Minners, "Generic Issues Screening Activity," September 30, 1981. [8110190695]
24. IE Bulletin No. 79-27, "Loss of Non-Class IE Instrumentation and Control Power System Bus During Operation," U.S. Nuclear Regulatory Commission, November 30, 1979. [7910250499]
25. Memorandum for F. Schroeder from T. Novak, "Application of SRP 15.4.6 Acceptance Criteria to Operating Reactors," December 12, 1980. [8102260305]
26. IE Information Notice 80-34, "Boron Dilution of Reactor Coolant During Steam Generator Decontamination," U.S. Nuclear Regulatory Commission, September 26, 1980. [8008220239]
27. Memorandum for R. Baer from A. Thadani, "RRAB Preliminary Assessment of the Reactor Coolant Pump Seal Failure Problem," December 12, 1980. [8103050765]
28. Memorandum for T. Novak from P. Check, "Spurious Automatic Switchover of ECCS from the Injection Mode to the Recirculation Mode," January 21, 1981. [8102280446]

29. Memorandum for T. Novak, et al., from A. Thadani, "Comparative Risk Assessment of ECCS Functional Switchover Options," April 1, 1981. [8104130436]
30. Memorandum for G. Lainas, et al., from P. Check, "BWR Scram Discharge System Safety Evaluation," December 1, 1980. [8101190514]
31. Memorandum for H. Denton from M. Ernst, "DST Evaluation of the Automatic Air Header Dump on Boiling Water Reactors," December 8, 1980. [8101230203]
32. NUREG-0138, "Staff Discussion of Fifteen Technical Issues Listed in Attachment to November 3, 1976 Memorandum from Director, NRR to NRR Staff," U.S. Nuclear Regulatory Commission, November 1976.
33. Memorandum for B. Sheron from M. Srinivasan, "Probabilities and Consequences of LOCA/Loss of Offsite Power (LOOP) Sequences," April 13, 1982. [8206300420]
34. Memorandum for the Commissioners from W. Dircks, "Resolution of Issue Concerning Steam-line Break with Small LOCA," December 23, 1980. [8101150357]
35. Memorandum for S. Hanauer from T. Murley, "Diesel Generator Loading Problems Related to SIS Reset on Loss of Offsite Power," February 25, 1981. [8110190723]
36. Memorandum for C. Michelson from H. Denton, "Combination Primary/Secondary System LOCA," December 8, 1981. [8201200049]
37. NUREG/CR-2083, "Evaluation of the Threat to PWR Vessel Integrity Posed by Pressurized Thermal Shock Events," U.S. Nuclear Regulatory Commission, October 7, 1981.
38. "Generic Issues Tracking System Report," U.S. Nuclear Regulatory Commission, December 17, 1981.
39. NUREG/CR-1707, "BWR Refill-Reflood Program, Task 4.2 - Core Spray Distribution Final Report," U.S. Nuclear Regulatory Commission, March 1981.
40. NEDO-24712, "Core Spray Design Methodology Confirmation Tests," General Electric Company, August 1979.
41. Nuclear Safety, Vol. 11, No. 4, pp. 296-308, "Tornado Considerations for Nuclear Power Plant Structures Including the Spent Fuel Storage Pool," P. L. Doan, July 1970.
42. Regulatory Guide 1.76, "Design Basis Tornado for Nuclear Power Plants," U.S. Nuclear Regulatory Commission, April 1974. [7907100297]
43. Regulatory Guide 1.117, "Tornado Design Classification," U.S. Nuclear Regulatory Commission, June 1976, (Rev. 1) April 1978 [7907110104].
44. NUREG-0705, "Identification of New Unresolved Safety Issues Relating to Nuclear Power Plant Stations," U.S. Nuclear Regulatory Commission, March 1981.

45. ANSI/ANS-58.8, "Time Response Design Criteria for Nuclear Safety Related Operator Actions," American Nuclear Society, 1984.
46. NRC Memorandum and Order CLI-80-21, May 27, 1980. [8007280084]
47. Memorandum for H. Denton from C. Michelson, "Degradation of Internal Appurtenances in LWR Piping," January 19, 1981. [8102020069]
48. NUREG-0660, "NRC Action Plan Developed as a Result of the TMI-2 Accident," U.S. Nuclear Regulatory Commission, May 1980, (Rev. 1) August 1980.
49. ISA S67.04 (ANSI N719), Draft F, "Setpoints for Nuclear Safety-Related Instrumentation Used in Nuclear Power Plants," Instrument Society of America, May 22, 1979.
50. Draft Regulatory Guide and Value/Impact Statement, TASK IC 010-5, "Proposed Revision 2 to Regulatory Guide 1.105, Instrument Setpoints," U.S. Nuclear Regulatory Commission, December 1981. [8112230003]
51. Memorandum for C. Michelson from H. Denton, "BWR Jet Pump Integrity," July 11, 1980. [8009160606]
52. IE Bulletin No. 80-07, "BWR Jet Pump Assembly Failure," U.S. Nuclear Regulatory Commission, April 4, 1980. [8002280648]
53. SIL No. 330, "Jet Pump Beam Cracks," General Electric Company/BWR Product Service, June 9, 1980.
54. NUREG/CR-1659, "Reactor Safety Study Methodology Applications Program," U.S. Nuclear Regulatory Commission, (Vol. 1) April 1981, (Vol. 2) May 1981, (Vol. 3) June 1982, (Vol. 4) November 1981.
55. Regulatory Guide 1.97, "Instrumentation for Light-Water-Cooled Nuclear Power Plants to Assess Plant and Environs Conditions During and Following an Accident," U.S. Nuclear Regulatory Commission, December 1975, (Rev. 1) August 1977 [8001240572], (Rev. 2) December 1980 [7912310387], (Rev. 3) May 1983 [8502060303].
56. Memorandum for R. Mattson, et al., from R. DeYoung, "Draft Report of Completion of Generic Activity A-34," March 28, 1979. [7904180060]
57. NUREG-0578, "TMI-2 Lessons Learned Task Force Status Report and Short-Term Recommendations," U.S. Nuclear Regulatory Commission, July 1979.
58. Memorandum for Commissioner Ahearne from H. Denton, "Instrumentation to Follow the Course of an Accident," September 4, 1979. [8005140362]
59. NUREG-0422, "SER for McGuire Nuclear Station Units 1 and 2," U.S. Nuclear Regulatory Commission, March 1978.
60. NUREG-0606, "Unresolved Safety Issues Summary," U.S. Nuclear Regulatory Commission, Vol. 7 No. 3, August 1985.

61. Memorandum for J. Murphy from B. Sheron, "Documentation of Generic Safety Issues on Degraded Voltage Protection," July 13, 1994. [9407250133]
62. NUREG/CR-2136, "Effects of Postulated Event Devices on Normal Operation of Piping Systems in Nuclear Power Plants," U.S. Nuclear Regulatory Commission, May 1981.
63. NUREG/CR-2189, "Probability of Pipe Fracture in the Primary Coolant Loop of a PWR Plant," U.S. Nuclear Regulatory Commission, September 1981.
64. NUREG/CR-2800, "Guidelines for Nuclear Power Plant Safety Issue Prioritization Information Development," U.S. Nuclear Regulatory Commission, February 1983, (Supplement 1) May 1983, (Supplement 2) December 1983, (Supplement 3) September 1985, (Supplement 4) July 1986, (Supplement 5) July 1996.
65. Memorandum for H. Denton from R. Minogue, "Research Information Letter No. 117, 'Probability of Large LOCA Induced by Earthquakes,'" April 10, 1981. [8104220512]
66. Regulatory Guide 1.6, "Independence Between Redundant Standby (Onsite) Power Sources and Between Their Distribution Systems (Safety Guide 6)," U.S. Atomic Energy Commission, March 1971. [7907100064]
67. NRC Letter to All Power Reactor Licensees from B. Grimes, "OT Position for Review and Acceptance of Spent Fuel Storage and Handling Applications," April 14, 1978. [7910310568]
68. Memorandum for R. Fraley from K. Kniel, "Draft Task Action Plan for TASK A-45, Shutdown Decay Heat Removal Requirements," May 22, 1981. [8106010652]
69. NUREG-0880, "Safety Goals for Nuclear Power Plants: A Discussion Paper," U.S. Nuclear Regulatory Commission, February 1982, (Rev. 1) May 1983.
70. NUREG-0348, "Demographic Statistics Pertaining to Nuclear Power Reactor Sites," U.S. Nuclear Regulatory Commission, November 1979.
71. Memorandum for S. Hanauer from D. Eisenhut, "Proposed Recommendations for Improving the Reliability of Open Cycle Service Water Systems," March 19, 1982. [8204190039]
72. AEOD/C202, "Report on Service Water System Flow Blockages by Bivalve Mollusks at Arkansas Nuclear One and Brunswick," Office for Analysis and Evaluation of Operational Data, U.S. Nuclear Regulatory Commission, February 1982. [8202260124]
73. TID-14844, "Calculation of Distance Factors for Power and Test Reactor Sites," U.S. Atomic Energy Commission, March 23, 1962. [8202010067]
74. AEOD/C001, "Report on the Browns Ferry 3 Partial Failure to Scram Event on June 28, 1980," Office for Analysis and Evaluation of Operational Data, U.S. Nuclear Regulatory Commission, July 30, 1980. [8008140575]

75. Memorandum for H. Denton from C. Michelson, "Engineering Evaluation of the Salt Water System (SSWS) Flow Blockage at the Pilgrim Nuclear Power Station by Blue Mussels (*Mytilus Edilus*)," May 6, 1982. [8205130114]
76. NUREG/CR-2497, "Precursors to Potential Severe Core Damage Accidents: 1969-1979, A Status Report," U.S. Nuclear Regulatory Commission, June 1982.
77. IEEE Std 352, "IEEE Guide for General Principles of Reliability Analysis of Nuclear Power Generating Station Protection Systems," The Institute of Electrical and Electronics Engineers, Inc., 1976.
78. NUREG/CR-1496, "Nuclear Power Plant Operating Experience - 1979," U.S. Nuclear Regulatory Commission, May 1981.
79. NUREG-0109, "Occupational Radiation Exposure at Light Water Cooled Power Reactors 1969-1975," U.S. Nuclear Regulatory Commission, August 1976.
80. DOE/ET/34204-43, "Dilute Chemical Decontamination Program - Final Report," U.S. Department of Energy, August 1981.
81. IEEE Std 317, "Electrical Penetration Assemblies in Containment Structures for Nuclear Power Generating Stations," The Institute of Electrical and Electronics Engineers, Inc., 1976.
82. Regulatory Guide 1.63, "Electrical Penetration Assemblies in Containment Structures for Light-Water-Cooled Nuclear Power Plants," U.S. Nuclear Regulatory Commission, October 1973, (Rev. 1) May 1977, (Rev. 2) July 1978 [7907100240], (Rev. 3) February 1987.
83. Memorandum for K. Kniel from M. Srinivasan, "Generic Issues Tracking System (GITS) B-70; Power Grid Frequency Degradation and Effect on Primary Coolant Pumps," July 31, 1981. [8109140246]
84. Memorandum for C. Berlinger from E. Butcher, "Diagnostic Evaluation at Quad Cities Nuclear Power Station (TAC Nos. M88667/M88668)," June 8, 1994. [9406130249]
85. Regulatory Guide 1.86, "Termination of Operating Licenses for Nuclear Reactors," U.S. Nuclear Regulatory Commission, June 1974. [8404100042, 9009140263]
86. Memorandum for T. Murley from M. Ernst, "Prioritization of New Requirements for PWR Feedwater Line Cracks," June 30, 1981. [8108030041]
87. Memorandum for R. Tedesco from T. Speis, "Supplement 2 to the Safety Evaluation Report for Grand Gulf Nuclear Station, Units 1 and 2," March 25, 1982. [8204080127]
88. Memorandum for All NRR Employees from H. Denton, "Regionalization of Selected NRR Functions," June 15, 1982. [9507280052]
89. NUREG/CR-1750, "Analysis, Conclusions, and Recommendations Concerning Operator Licensing," U.S. Nuclear Regulatory Commission, January 1981.

90. IEEE Std 323, "Qualifying Class 1E Equipment for Nuclear Power Generating Stations," The Institute of Electrical and Electronics Engineers, Inc., 1974.
91. Regulatory Guide 1.89, "Environmental Qualification of Certain Electric Equipment Important to Safety for Nuclear Power Plants," U.S. Nuclear Regulatory Commission, November 1974 [7907100326], (Rev. 1) June 1984 [8407110475].
92. SECY-81-504, "Equipment Qualification Program Plan," August 20, 1981. [8109220949]
93. NUREG-0611, "Generic Evaluation of Feedwater Transients and Small-Break Loss-of-Coolant Accidents in Westinghouse Designed Operating Plants," U.S. Nuclear Regulatory Commission, January 1980.
94. NUREG-0626, "Generic Evaluation of Feedwater Transients and Small Break Loss-of-Coolant Accidents in GE-Designed Operating Plants and Near-Term Operating License Applications," U.S. Nuclear Regulatory Commission, January 1980.
95. NUREG-0635, "Generic Evaluation of Feedwater Transients and Small Break Loss-of-Coolant Accidents in Combustion Engineering-Designed Operating Plants," U.S. Nuclear Regulatory Commission, February 1980.
96. NUREG-0565, "Generic Evaluation of Small Break Loss-of-Coolant Accident Behavior in Babcock & Wilcox Designed 177-FA Operating Plant," U.S. Nuclear Regulatory Commission, January 1980.
97. NUREG-0623, "Generic Assessment of Delayed Reactor Coolant Pump Trip During Small Break Loss-of-Coolant Accidents in Pressurized Water Reactors," U.S. Nuclear Regulatory Commission, November 1979.
98. NUREG-0737, "Clarification of TMI Action Plan Requirements," U.S. Nuclear Regulatory Commission, November 1980, (Supplement 1) January 1983.
99. ANSI/ANS 56.8, "Containment System Leakage Testing Requirements," American National Standards Institute, 1981.
100. Letter to General Electric Company from R. Tedesco (NRC), "Acceptance for Reference Topical Report NEDO-24712: Core Spray Design Methodology Confirmation Tests," January 30, 1981. [8103270130]
101. SECY-82-475, "Staff Resolution of the Reactor Coolant Pump Trip Issue," November 30, 1982. [8306030370]
102. NUREG/CR-0848, "Summary and Bibliography of Operating Experience with Valves in Light-Water-Reactor Nuclear Power Plants for the Period 1965-1978," U.S. Nuclear Regulatory Commission, August 1979.
103. Memorandum for M. Ernst from B. Fourest, "Review of ECCS Actuations on U.S. PWRs," June 11, 1981. [8107160006]

104. Memorandum for C. Michelson from H. Denton, "NRR Responses to AEOD Recommendations on the Arkansas Nuclear One Loss of Offsite Power Event of April 7, 1980," February 13, 1981. [8102270127]
105. Nuclear Power Experience, Volume BWR-2, Book-2, Section IX.A, Nuclear Power Experience, Inc., May 1982.
106. Memorandum for H. Denton from C. Michelson, "Lessons Learned from the Crystal River Transient of February 26, 1980 - Correcting Atmospheric Dump Valve Opening Upon Loss of Integrated Control System Power," May 23, 1980. [8009150079]
107. Memorandum for H. Denton from C. Michelson, "Potential for Unacceptable Interaction Between the Control Rod Drive System and Non-Essential Control Air System at the Browns Ferry Nuclear Plant," August 18, 1980. [8210120129]
108. Memorandum for R. Mattson from S. Hanauer, "Inadvertent Boron Dilution," March 10, 1982. [8205130278]
109. Memorandum for T. Murley from R. Mattson, "Inadvertent Boron Dilution," September 15, 1981. [8110080185]
110. NUREG/CR-2798, "Evaluation of Events Involving Unplanned Boron Dilutions in Nuclear Power Plants," U.S. Nuclear Regulatory Commission, July 1982.
111. Letter to R. Curtis (NRC) from N. DeMuth (LANL), "Analysis of Unmitigated Boron Dilution Events," November 18, 1981. [9507280099]
112. Transactions of the American Nuclear Society and the European Nuclear Society, 1984 International Conference on Nuclear Power - A Global Reality, November 11-16, 1984, Volume 47, pp. 254-256, "Analysis of Unmitigated Boron Dilution Events in Pressurized Water Reactors During Shutdown," B. Nassersharif, J. Wing (LANL).
113. EPRI NP-1194, "Operation and Design Evaluation of Main Coolant Pumps for PWR and BWR Service," Electric Power Research Institute, September 1979.
114. EPRI NP-2092, "Nuclear Unit Operating Experience, 1978 and 1979 Update," Electric Power Research Institute, October 1981.
115. NUREG/CR-3069, "Interaction of Electromagnetic Pulse with Commercial Nuclear Power Plant Systems," U.S. Nuclear Regulatory Commission, February 1983.
116. Letter to D. Switzer (Northeast Nuclear Energy Company) from G. Lear (NRC), "Millstone Nuclear Power Station Units Nos. 1 and 2," June 2, 1977. [9507280126]
117. NRC Letter to All Power Reactor Licensees (Except Humboldt Bay), "Adequacy of Station Electric Distribution Systems Voltages," August 8, 1979. [8005120354]
118. Memorandum for V. Stello from H. Denton, "Guidelines for Evaluating Qualification of Class IE Electrical Equipment in Operating Reactors," November 13, 1979. [7912190733]

119. Memorandum for K. Kniel from W. Gammill, "Need for Generic Issue B-67, Control and Monitoring of Radioactive Materials Released in Effluents and Performance of Radwaste Systems," November 20, 1981. [8201130493]
120. NUREG-0442, "Technical Report on Operating Experience with BWR Offgas Systems," U.S. Nuclear Regulatory Commission, April 1978.
121. IE Bulletin No. 78-03, "Potential Explosive Gas Mixture Accumulations Associated with BWR Offgas System Operations," U.S. Nuclear Regulatory Commission, February 8, 1978. [7909050232]
122. NRC Working Paper on Appendix J to 10 CFR Part 50, "Leak Tests for Primary and Secondary Containments of Light-Water-Cooled Nuclear Power Plants," May 17, 1982. [8401040228]
123. NRC Working Paper on Draft Regulatory Guide (MS021-5), "Containment System Leakage Testing," May 1982. [8405240527]
124. NUREG-0193, "FRANTIC - A Computer Code for Time-Dependent Unavailability Analysis," U.S. Nuclear Regulatory Commission, October 1977.
125. NRC Letter to the Northern States Power Company, "Order for Modification of License Concerning BWR Scram Discharge Systems," January 9, 1981. [8103250282]
126. Memorandum for R. Vollmer from T. Murley, "PWR Feedwater Line Cracks - New Regulatory Requirements," March 10, 1981. [8103250569]
127. Memorandum for H. Kouts from B. Rusche, "Quantification of Inherent Safety Margins in Seismic Design (SAFER-76-5)," June 7, 1976. [8003100435]
128. Memorandum for S. Levine from E. Case, "Quantification of Inherent Safety Margins in Seismic Design," June 16, 1977. [8103270937]
129. Memorandum for H. Denton from S. Levine, "RES Response to NRR User Request on Quantification of Inherent Safety Margins to Seismic Design," November 1, 1978. [8003100425]
130. Memorandum for S. Levine from H. Denton, "Seismic Safety Margins Research Program," February 23, 1979. [8003280774]
131. NUREG/CR-2015, "SSMRP Phase I Final Report," U.S. Nuclear Regulatory Commission, (Vol. 1) April 1981, (Vol. 2) July 1981, (Vol. 3) January 1983, (Vol. 4) June 1982, (Vol. 5) August 1981, (Vol. 6) October 1981, (Vol. 8) September 1984, (Vol. 9) September 1981, (Vol. 10) July 1981.
132. Memorandum for R. Minogue from H. Denton, "NRR Research Needs in Seismic Analyses Methodology," April 8, 1982. [8706040051]
133. NUREG-0784, "Long Range Research Plan FY 1984-1988," U.S. Nuclear Regulatory Commission, August 1982.

134. SECY-82-53, "Possible Relocation of Design Controlling Earthquakes in the Eastern U.S.," U.S. Nuclear Regulatory Commission, February 5, 1982. [8203050077]
135. NUREG-0484, "Methodology for Combining Dynamic Responses," U.S. Nuclear Regulatory Commission, September 1978, (Rev. 1) May 1980.
136. Memorandum for W. Minners from R. Bosnak, "Comments on Generic Issue B-6," August 26, 1982. [8209280601]
137. Memorandum for W. Minners from F. Schauer, "Generic Issue B-6," September 2, 1982. [8401170090]
138. NUREG/CR-1924, "FRANTIC II - A Computer Code for Time Dependent Unavailability Analysis," U.S. Nuclear Regulatory Commission, April 1981.
139. Letter to W. Dickhoner (The Cincinnati Gas & Electric Company) from A. Giambusso (NRC), December 18, 1972. [8709240215]
140. Memorandum for R. Frahm from R. Emrit, "Summary Report on a Risk Based Categorization of NRC Technical and Generic Issues," June 30, 1989. [9507280169]
141. Regulatory Guide 1.150, "Ultrasonic Testing of Reactor Vessel Welds During Preservice and Inservice Examinations," U.S. Nuclear Regulatory Commission, June 1981 [8108040038], (Rev. 1) February 1983 [8808230046].
142. NRC Letter to Alabama Power Company, "Containment Purging During Normal Plant Operation," November 28, 1978. [7812140364]
143. NRC Letter to Nebraska Public Power District, "Containment Purging and Venting during Normal Operation," October 22, 1979. [7911190034]
144. Regulatory Guide 1.75, "Physical Independence of Electric Systems," U.S. Nuclear Regulatory Commission, February 1974, (Rev. 1) January 1975 [8605300425], (Rev. 2) September 1978 [7810050139].
145. Memorandum for D. Thatcher from R. Emrit, "Interim Criteria for Evaluating Steel Containment Buckling," June 21, 1982. [9507280196]
146. Regulatory Guide 1.133, "Loose-Part Detection Program for the Primary System of Light-Water-Cooled Reactors," U.S. Nuclear Regulatory Commission, September 1977, (Rev. 1) May 1981 [8106120320].
147. Regulatory Guide 1.20, "Comprehensive Vibration Assessment Program for Reactor Internals During Preoperational and Initial Startup Testing," U.S. Nuclear Regulatory Commission, December 1971, (Rev. 1) June 1975, (Rev. 2) May 1976 [7907100101].
148. "Memorandum of Agreement between the Institute of Nuclear Power Operations and the U.S. Nuclear Regulatory Commission," (Rev. 1) April 1, 1982. [8207010053]

149. Memorandum for J. Funches from R. Mattson, "Comments on Prioritization of Licensing Improvement Issues," February 2, 1983. [8401170099]
150. Regulatory Guide 1.47, "Bypassed and Inoperable Status Indication for Nuclear Power Plant Safety Systems," U.S. Atomic Energy Commission, May 1973. [7907100191]
151. SECY-82-111, "Requirements for Emergency Response Capability," March 11, 1982. [8203180409]
152. NUREG/CR-2417, "Identification and Analysis of Human Errors Underlying Pump and Valve Related Events Reported by Nuclear Power Plant Licensees," U.S. Nuclear Regulatory Commission, February 1982.
153. NUREG/CR-3621, "Safety System Status Monitoring," U.S. Nuclear Regulatory Commission, March 1984.
154. NRC Letter to Construction Permit Holders of B&W Designed Facilities, October 25, 1979.
155. NUREG-0667, "Transient Response of Babcock & Wilcox Designed Reactors," U.S. Nuclear Regulatory Commission, May 1980.
156. Memorandum for H. Denton from D. Eisenhut, "NUREG-0667, Transient Response of Babcock & Wilcox Designed Reactors, Implementation Plan," June 3, 1981. [8510070181]
157. Memorandum for D. Eisenhut from G. Lainas, "Status Report on Implementation of NUREG-0667 Category A Recommendations," December 15, 1981. [8201190550]
158. Memorandum for H. Denton from R. Mattson, "Review of Final Report of the B&W Reactor Transient Response Task Force (NUREG-0667)," August 8, 1980. [8010270109, 8010240413]
159. Memorandum for S. Hanauer from R. Mattson, "Design Sensitivity of B&W Reactors, Item II.E.5.1 of NUREG-0660," February 26, 1982. [8203170235]
160. Memorandum for R. Mattson from S. Hanauer, "Design Sensitivity of B&W Reactors," June 21, 1982. [8207150195]
161. NUREG/CR-1250, "Three Mile Island: A Report to the Commission and to the Public," U.S. Nuclear Regulatory Commission, January 1980.
162. NRC Letter to All Light Water Reactors, "Containment Purging and Venting During Normal Operation - Guidelines for Valve Operability," September 27, 1979. [9705190209]
163. NUREG-0305, "Technical Report on DC Power Supplies in Nuclear Power Plants," U.S. Nuclear Regulatory Commission, July 1977.
164. NUREG-0666, "A Probabilistic Safety Analysis of DC Power Supply Requirements for Nuclear Power Plants," U.S. Nuclear Regulatory Commission, April 1981.

165. Memorandum for M. Srinivasan from O. Parr and B. Sheron, "Generic Issue (GI) A-30, Adequacy of Safety Related DC Power Supplies, Development of Licensing Guidelines," March 12, 1982. [8401170018]
166. Memorandum for E. Case from R. Mattson, "Task No. D-3 Control Rod Drop Accident (BWRs)," March 6, 1978. [8001140319]
167. Federal Register Notice 44 FR 68307, "Decommissioning and Site Reclamation of Uranium and Thorium Mills," November 28, 1979.
168. NRC Letter to Arkansas Power & Light Company, "Order for Modification of License Concerning Primary Coolant System Pressure Isolation Valves," (Docket No. 50-313), April 20, 1981. [8104270071]
169. Memorandum for A. Ungaro (NRC) from F. Clark (ORNL), "Report on Standards and Requirements for Electrical Penetration Assemblies for Nuclear Reactor Containment Structures," December 13, 1978. [9507280225]
170. NUREG/CR-1345, "Nuclear Power Plant Design Concepts for Sabotage Protection," U.S. Nuclear Regulatory Commission, 1981.
171. Bulletin of the Atomic Scientists, Vol. 32, No. 8, pp. 29-36, "Nuclear Sabotage," M. Flood, October 1976.
172. Federal Register Notice 43 FR 10370, "[10 CFR Parts 30, 40, 50, and 70] Decommissioning Criteria for Nuclear Facilities, Advance Notice of Proposed Rulemaking," March 13, 1978.
173. NUREG-0586, "Final Generic Environmental Impact Statement on Decommissioning of Nuclear Facilities," U.S. Nuclear Regulatory Commission, August 1988.
174. NUREG-0585, "TMI Lessons Learned Task Force Final Report," U.S. Nuclear Regulatory Commission, October 1979.
175. ZAR-791030-01, "Report of the President's Commission on the Accident at Three Mile Island," J. G. Kemeny, et al., November 30, 1979.
176. Memorandum for J. Ahearne from M. Carbon, "Comments on the Pause in Licensing," December 11, 1979. [8001080218]
177. Memorandum for N. Moseley from J. Allan, "Operations Team Recommendations - IE/TMI Unit 2 Investigation," October 16, 1979. [8007160815]
178. EPRI NP-801, "ATWS: A Reappraisal, Part III, Frequency of Anticipated Transients," Electric Power Research Institute, July 1978.
179. NUREG-0020, "Licensed Operating Reactors, Status Summary Report," U.S. Nuclear Regulatory Commission, (Vol. 6, No. 2) February 1982.
180. NUREG-0580, "Regulatory Licensing Status Summary Report," U.S. Nuclear Regulatory Commission, (Vol. 11, No. 5) June 1982.

181. SECY-82-155, "Public Law 96-295, Section 307(B), Study of the Feasibility and Value of Licensing of Nuclear Plant Managers and Senior Licensee Officers," April 12, 1982. [8205050080]
182. NUREG/CR-0672, "Technology, Safety, and Costs of Decommissioning a Reference Boiling Water Reactor Power Station," U.S. Nuclear Regulatory Commission, June 1980.
183. NUREG-0153, "Staff Discussion of 12 Additional Technical Issues Raised by Responses to the November 3, 1976 Memorandum from Director, NRR to NRR Staff," December 1976.
184. Memorandum for R. Vollmer from D. Eisenhut, "Transmittal of Report on Threaded Fastener Experience in Nuclear Power Plants," August 25, 1982. [8209210482]
185. Memorandum for H. Denton from C. Michelson, "AEOD Report on the St. Lucie Natural Circulation Cooldown on June 11, 1980," December 24, 1980. [8101120011]
186. NUREG-0510, "Identification of Unresolved Safety Issues Relating to Nuclear Power Plants," U.S. Nuclear Regulatory Commission, January 1979.
187. NUREG/CR-2300, "PRA Procedures Guide," U.S. Nuclear Regulatory Commission, (Vols. 1 and 2) January 1983.
188. NUREG/CR-2644, "An Assessment of Offsite, Real-Time Dose Measurements for Emergency Situations," U.S. Nuclear Regulatory Commission, April 1982.
189. Memorandum for K. Goller from R. Mattson, "Proposed Changes to Regulatory Guide 1.97," July 29, 1982. [8208060339]
190. Memorandum for W. Dircks from S. Chilk, "Staff Requirements - Affirmative Session, 11:50 a.m., Friday July 16, 1982," July 20, 1982. [8208040248, 8209010068]
191. NUREG-0799, "Draft Criteria for Preparation of Emergency Operating Procedures," U.S. Nuclear Regulatory Commission, June 1981.
192. NUREG-0899, "Guidelines for Preparation of Emergency Operating Procedures - Resolution of Comments on NUREG-0799," U.S. Nuclear Regulatory Commission, September 3, 1982.
193. Memorandum for J. Martin, et al., from L. Shao, "Division Review Request: Amendments to 10 CFR Parts 30, 40, 50, 70, and 72 on Decommissioning Criteria for Nuclear Facilities," July 7, 1982. [8209140007]
194. IEEE Std 500, "IEEE Guide to the Collection and Presentation of Electrical, Electronic, and Sensing Component Reliability Data for Nuclear Power Generating Stations," The Institute of Electrical and Electronics Engineers, Inc., 1977.
195. Memorandum for E. Adensam from R. Riggs, "Status on Reactor Coolant Pump Seal Degradation Review," December 9, 1980. [8102280212]

196. Memorandum for H. Denton from S. Hanauer, "Preliminary Ranking of NRR Generic Safety Issues," March 26, 1982. [8204280036]
197. Federal Register Notice 45 FR 37011, "Decommissioning of Nuclear Facilities Regulation (10 CFR Parts 30, 40, 50, and 70)," May 30, 1980.
198. NUREG-0698, "NRC Plans for Cleanup Operations at Three Mile Island Unit 2," U.S. Nuclear Regulatory Commission, July 1980.
199. NUREG-0683, "Final Programmatic Environmental Impact Statement Related to Decontamination and Disposal of Radioactive Wastes Resulting from the March 28, 1979 Accident at Three Mile Island Nuclear Station, Unit 2," U.S. Nuclear Regulatory Commission, March 1981.
200. IEEE Std 603, "IEEE Standard Criteria for Safety Systems for Nuclear Power Generating Stations," The Institute of Electrical and Electronics Engineers, Inc., 1980.
201. IE Bulletin No. 80-24, "Prevention of Damage Due to Water Leakage Inside Containment (October 17, 1980 Indian Point 2 Event)," U.S. Nuclear Regulatory Commission, November 21, 1980. [8008220270]
202. Memorandum for G. Cunningham et al., from K. Goller, "Proposed Amendment to Part 50 on Radiation Programs, Including ALARA," September 10, 1982. [8209300046]
203. SECY-82-157A, "Status Report on the NRR Investigation of the Effects of Electromagnetic Pulse (EMP) on Nuclear Power Plants," July 16, 1982. [8205050108]
204. NUREG-0855, "Health Physics Appraisal Program," U.S. Nuclear Regulatory Commission, March 1982.
205. NUREG-0761, "Radiation Protection Plans for Nuclear Power Reactor Licensees," U.S. Nuclear Regulatory Commission, March 1981.
206. Memorandum for L. Rubenstein from M. Ernst, "Proposed Position Regarding Containment Purge/Vent Systems," April 17, 1981. [8105260251]
207. IE Bulletin No. 81-03, "Flow Blockage of Cooling Water to Safety System Components by CORBICULA SP. (Asiatic Clam) and MYTILUS SP. (Mussel)," U.S. Nuclear Regulatory Commission, April 10, 1981. [8011040289]
208. Regulatory Guide 1.52, "Design, Testing and Maintenance Criteria for Post Accident Engineered-Safety-Feature Atmosphere Cleanup System Air Filtration and Adsorption Units of Light-Water-Cooled Nuclear Power Plants," U.S. Nuclear Regulatory Commission, June 1973, (Rev. 1) July 1976, (Rev. 2) March 1978 [7907100211].
209. Regulatory Guide 1.140, "Design, Testing, and Maintenance Criteria for Normal Ventilation Exhaust System Air Filtration and Adsorption Units of Light-Water-Cooled Nuclear Power Plants," U.S. Nuclear Regulatory Commission, March 1978, (Rev. 1) October 1979 [7911090195].

210. NUREG-0885, "U.S. Nuclear Regulatory Commission Policy and Planning Guidance," U.S. Nuclear Regulatory Commission, (Issue 1) January 1982, (Issue 2) January 1983, (Issue 3) January 1984, (Issue 4) February 1985, (Issue 5) February 1986, (Issue 6) September 1987.
211. Federal Register Notice 46 FR 764, "NRC Policy Statement on Cleanup of the Three Mile Island Plant," May 1, 1981.
212. NUREG-0772, "Technical Bases for Estimating Fission Product Behavior During LWR Accidents," U.S. Nuclear Regulatory Commission, June 1981.
213. Regulatory Guide 1.3, "Assumptions Used for Evaluating the Potential Radiological Consequences of a Loss-of-Coolant Accident for Boiling Water Reactors," U.S. Nuclear Regulatory Commission, November 1970, (Rev. 1) June 1973, (Rev. 2) June 1974 [7907100054].
214. Regulatory Guide 1.4, "Assumptions Used for Evaluating the Potential Radiological Consequences of a Loss-of-Coolant Accident for Pressurized Water Reactors," U.S. Nuclear Regulatory Commission, November 1970, (Rev. 1) June 1973, (Rev. 2) June 1974 [7907100058].
215. Memorandum for E. Sullivan from R. Bosnak, "Generic Issues," September 17, 1982. [8312290147]
216. Regulatory Guide 1.108, "Periodic Testing of Diesel Generator Units Used as Onsite Electric Power Systems at Nuclear Power Plants," U.S. Nuclear Regulatory Commission, August 1976, (Rev. 1) August 1977. [7907100397]
217. NUREG/CR-0660, "Enhancement of On-site Emergency Diesel Generator Reliability," U.S. Nuclear Regulatory Commission, February 1979.
218. Memorandum for D. Eisenhut, et al., from S. Hanauer, "Diesel Generator Reliability at Operating Plants," May 6, 1982. [8205280490]
219. Memorandum for S. Hanauer from R. Mattson, "Request for Prioritization of BWR Main Steam Line Isolation Valve Leakage as a Generic Issue," July 30, 1982. [8209130423]
220. IE Bulletin No. 82-23, "Main Steam Isolation Valve (MSIV) Leakage," U.S. Nuclear Regulatory Commission, July 16, 1982. [8204210393]
221. Regulatory Guide 1.48, "Design Limits and Loading Combinations for Seismic Category 1 Fluid System Components," U.S. Atomic Energy Commission, May 1973. [7907100195]
222. NUREG-0479, "Report on BWR Control Rod Drive Mechanical Failures," U.S. Nuclear Regulatory Commission, January 1979.
223. NUREG-0462, "Technical Report on Operating Experience with BWR Pressure Relief Valves," U.S. Nuclear Regulatory Commission, July 1978.

224. NUREG-0654, "Criteria for Preparation and Evaluation of Radiological Emergency Response Plans and Preparedness in Support of Nuclear Power Plants," U.S. Nuclear Regulatory Commission, February 1980, (Rev. 1) November 1980.
225. Regulatory Guide 1.33, "Quality Assurance Program Requirements (Operation)," U.S. Nuclear Regulatory Commission, November 1972, (Rev. 1) February 1977, (Rev. 2) February 1978 [7907100144].
226. Regulatory Guide 1.8, "Qualification and Training of Personnel for Nuclear Power Plants," U.S. Nuclear Regulatory Commission, March 1971, (Rev. 1) September 1975 [8801130111], (Rev. 1-R) May 1977 [7907100073], (Rev. 2) April 1987 [8907180147].
227. NUREG/CR-0130, "Technology, Safety, and Costs of Decommissioning a Reference Pressurized Water Reactor Power Station," U.S. Nuclear Regulatory Commission, June 1978.
228. SECY-81-450, "Development of a Selective Absorption System Emergency Unit," July 27, 1981. [8108140094]
229. Memorandum for T. Speis from R. Houston, "Containment Venting and Purging - Completion of TMI Action Plan Item II.E.4.4(4)," March 3, 1982. [8401170023, 8203240149]
230. Memorandum for R. Mattson from T. Speis, "Containment Purge and Venting -Completion of TMI Action Plan Item II.E.4.4(5)," April 9, 1982. [8204260021]
231. Memorandum for W. Dircks from R. Mattson, "Status Report on Containment Purge Evaluations," May 13, 1982. [8401170021]
232. SECY-81-168B, "Response to Commission Request for Information on Financial Considerations in Licensing Proceedings," July 13, 1981. [8107310227]
233. Regulatory Guide 1.26, "Quality Group Classifications and Standards for Water-, Steam-, and Radioactive-Waste-Containing Components of Nuclear Power Plants," U.S. Nuclear Regulatory Commission, March 1972, (Rev. 1) September 1974, (Rev. 2) June 1975, (Rev. 3) February 1976.
234. Federal Register Notice 47 FR 9987, "10 CFR Part 2, General Statement of Policy and Procedure for Enforcement Actions," March 9, 1982.
235. Memorandum for H. Denton from R. DeYoung, "TMI Action Plan Items Still Pending," June 10, 1982. [8401170101]
236. Memorandum for W. Dircks from R. DeYoung, "TMI Action Plan - Completed Items," June 30, 1982. [8208110023]
237. SECY-80-366, "NRC Legislative Program for 97th Congress," August 6, 1980. [8101050634]

238. Memorandum for Chairman Hendrie, et al., from W. Dircks, "Memorandum of Agreement with INPO and NSAC on a Cooperative Relationship for the Collection and Feedback of Operational Data," June 16, 1981. [8106260511, 8106260514]
239. Memorandum for W. Dircks from V. Stello, "TMI Action Plan - Status Report," December 19, 1980. [8205260193]
240. SECY-81-153, "Nuclear Data Link," March 11, 1981. [8103240155]
241. NUREG/CR-1440, "Light Water Reactor Status Monitoring During Accident Conditions," U.S. Nuclear Regulatory Commission, May 1980.
242. NUREG/CR-2100, "Boiling Water Reactor Status Monitoring During Accident Conditions," U.S. Nuclear Regulatory Commission, May 1981.
243. NUREG/CR-2278, "Light Water Reactor Engineered Safety Features Status Monitoring," U.S. Nuclear Regulatory Commission, October 1981.
244. NUREG/CR-2147, "Nuclear Control Room Annunciators," U.S. Nuclear Regulatory Commission, October 1981.
245. Memorandum for H. Denton, et al., from R. Minogue, "Research Information Letter #RIL-124, 'Control Room Alarms and Annunciators,'" October 20, 1981. [8111130045]
246. RIL-98, "Light Water Reactor Status Monitoring During Accident Conditions," U.S. Nuclear Regulatory Commission, August 18, 1980. [8104230867]
247. NUREG/CR-5669, "Evaluation of Exposure Limits to Toxic Gases for Nuclear Reactor Control Room Operators," U.S. Nuclear Regulatory Commission, July 1991.
248. Memorandum for W. Dircks from R. DeYoung, "TMI Action Plan - Completed Items," December 28, 1981. [8205260197]
249. NUREG/CR-6210, "Computer Codes for Evaluation of Control Room Habitability (HABIT)," U.S. Nuclear Regulatory Commission, June 1996.
250. SECY-81-440, "Nuclear Power Plant Staff Working Hours," July 22, 1981. [8107290183]
251. SECY-79-330E, "Qualifications of Reactor Operators," July 30, 1979. [7910020256, 7910020279]
252. NRR-80-117, "Study of Requirements for Operator Licensing," February 4, 1982. [8203180234]
253. ANSI/ANS 3.1, "Selection, Qualification, and Training of Personnel for Nuclear Power Plants," American National Standards Institute, 1981.
254. Letter to N. Palladino (NRC) from M. Udall (Chairman, Committee on Interior and Insular Affairs, U.S. House of Representatives), June 4, 1982. [8207120246]

255. Letter to M. Udall (Chairman, Committee on Interior and Insular Affairs, U.S. House of Representatives) from N. Palladino (NRC), June 30, 1982. [8206130067]
256. Memorandum for W. Dircks from R. DeYoung, "TMI Action Plan - Completed Items," June 2, 1982. [8401170114]
257. NUREG-0728, "Report to Congress - NRC Incident Response Plan," U.S. Nuclear Regulatory Commission, September 1980.
258. NUREG-0845, "Agency Procedure for the NRC Incident Response Plan," U.S. Nuclear Regulatory Commission, March 1982.
259. Memorandum for J. Sniezek from J. Taylor, "TMI Action Plan Item II.J.1.2, Modification of Vendor Inspection Program," October 13, 1982. [8301050485]
260. SECY-81-494, "Integrated Operational Experience Reporting System," August 18, 1981. [8109110483]
261. Federal Register Notice 46 FR 53594, "NRC Regulatory Agenda," October 29, 1981.
262. BNL/NUREG-28955, "PWR Training Simulator and Evaluation of the Thermal-Hydraulic Models for Its Main Steam Supply System," Brookhaven National Laboratory, 1981.
263. BNL/NUREG-29815, "BWR Training Simulator and Evaluation of the Thermal-Hydraulic Models for Its Main Steam Supply System," Brookhaven National Laboratory, 1981.
264. BNL/NUREG-30602, "A PWR Training Simulator Comparison with RETRAN for a Reactor Trip from Full Power," Brookhaven National Laboratory, 1981.
265. Memorandum for the Commissioners from W. Dircks, "Enforcement Policy," March 18, 1980. [8005160508]
266. SECY-80-139A, "NRC Enforcement Program," August 27, 1980. [8009180277]
267. Memorandum for R. Purple from R. Minogue, "TMI Action Plan," October 24, 1980. [8011120511]
268. Memorandum for W. Dircks from V. Stello, "Assignment of Resident Inspectors to Nuclear Steam System Suppliers and Architect-Engineers," September 14, 1981. [8111030559]
269. IE Circular No. 80-15, "Loss of Reactor Coolant Pump Cooling and Natural Circulation Cooldown," U.S. Nuclear Regulatory Commission, June 20, 1980. [8005050073]
270. Memorandum for C. Michelson from H. Denton, "Report on St. Lucie Natural Circulation Cooldown," April 6, 1981. [8104150248]
271. Memorandum for J. Taylor from E. Beckjord, "Closeout of TMI Action Plan Task I.D.5(5), Research on Disturbance Analysis Systems," April 17, 1995. [9705190216]

272. Memorandum for J. Gagliardo from D. Eisenhut, "Potential Failure of Turbine Driven Auxiliary Feedwater Pump Steam Supply Line - Fort Calhoun," October 8, 1982. [8210290122]
273. Memorandum for H. Denton from C. Michelson, "Technical Review Report, Postulated Loss of Auxiliary Feedwater System Resulting from Turbine Driven Auxiliary Feedwater Pump Steam Supply Line Rupture," February 16, 1983. [8303040296]
274. Letter to G. Knighton (NRC) from K. Baskin (Southern California Edison Company), "Docket Nos. 50-361 and 50-362, San Onofre Nuclear Generating Station Units 2 and 3," October 29, 1982. [8211020483]
275. NUREG/CR-1614, "Approaches to Acceptable Risk: A Critical Guide," U.S. Nuclear Regulatory Commission, September 1980.
276. NUREG/CR-1539, "A Methodology and a Preliminary Data Base for Examining the Health Risks of Electricity Generation from Uranium and Coal Fuels," U.S. Nuclear Regulatory Commission, August 1980.
277. NUREG/CR-1930, "Index of Risk Exposure and Risk Acceptance Criteria," U.S. Nuclear Regulatory Commission, February 1981.
278. NUREG/CR-1916, "A Risk Comparison," U.S. Nuclear Regulatory Commission, February 1981.
279. NUREG/CR-2040, "A Study of the Implications of Applying Quantitative Risk Criteria in the Licensing of Nuclear Power Plants in the U.S.," U.S. Nuclear Regulatory Commission, March 1981.
280. SECY-80-331, "NRC Training Program," July 14, 1980. [8009100166]
281. Memorandum for H. Denton, et al., from C. Michelson, "Case Study Report - Failure of Class 1E Safety-Related Switchgear Circuit Breakers to Close on Demand," August 4, 1982. [8208240007]
282. Memorandum for C. Michelson from H. Denton, "AEOD Preliminary Report on Failures of Class 1E Safety-Related Switchgear Circuit Breakers to Close on Demand," September 23, 1982. [8210290150]
283. Federal Register Notice 47 FR 36099, "Executive Order 12379 of August 17, 1982, Termination of Boards, Committees, and Commissions," August 19, 1982.
284. Letter to N. Palladino (NRC) from G. Keyworth (OSTP), July 21, 1982. [9705190213]
285. Letter to G. Keyworth (OSTP) from N. Palladino (NRC), July 23, 1982. [9705190203]
286. Letter to T. Pestorius (OSTP) from R. Minogue (NRC), August 27, 1982. [9104170201]
287. SECY-81-600A, "Revised General Statement of Policy and Procedure for Enforcement Actions," December 14, 1981. [8201190600]

288. NEDO-10174, "Consequences of a Postulated Flow Blockage Incident in a Boiling Water Reactor," General Electric Company, October 1977, (Rev. 1) May 1980.
289. NUREG/CR-2075, "Standards for Psychological Assessment of Nuclear Facility Personnel," U.S. Nuclear Regulatory Commission, July 1981.
290. NUREG/CR-2076, "Behavioral Reliability Program for the Nuclear Industry," U.S. Nuclear Regulatory Commission, July 1981.
291. Memorandum for E. Jordan, et al., from R. Bernero, "Proposed Rule Review Request - 10 CFR Part 21, 'Reporting of Defects and Noncompliance,'" September 28, 1982. [8210150634]
292. Memorandum for R. Minogue from R. DeYoung, "Proposed Rule Amending 10 CFR Parts 50.55(e) and 21: RES Task Numbers RA 128-1 and RA 808-1," July 13, 1982.
293. Federal Register Notice 47 FR 18508, "NRC Regulatory Agenda," April 29, 1982.
294. Federal Register Notice 47 FR 48960, "NRC Regulatory Agenda," October 28, 1982.
295. BNL-NUREG-31940, "Postulated SRV Line Break in the Wetwell Airspace of Mark I and Mark II Containments - A Risk Assessment," Brookhaven National Laboratory, October 1982. [8212070471]
296. Letter to T. Kress from J. Taylor, "Resolution of Generic Safety Issue 83, 'Control Room Habitability,'" September 13, 1995. [9605130222, 9605150092]
297. Memorandum for W. Dircks from R. DeYoung, "TMI Action Plan - Completed Item," October 29, 1982. [8401170104]
298. Memorandum for W. Dircks from V. Stello, "TMI Action Plan - Status Report," April 17, 1981. [8205260194]
299. NUREG/CR-1482, "Nuclear Power Plant Simulators: Their Use in Operator Training and Requalification," U.S. Nuclear Regulatory Commission, August 1980.
300. NUREG/CR-2353, "Specification and Verification of Nuclear Power Plant Training Simulator Response Characteristics," U.S. Nuclear Regulatory Commission, (Vol. 1) January 1982, (Vol. 2) May 1982.
301. Memorandum for R. Emrit from P. Goldman, "Draft Report on the Prioritization of Non-NRR TMI Action Plan Items," December 29, 1982. [8312290171]
302. Memorandum for H. Denton from C. Michelson, "Operational Restrictions for Class IE 120 VAC Vital Instrument Buses," July 15, 1980. [8210120114]
303. Memorandum for C. Michelson from H. Denton, "LCO for Class IE Vital Instrument Buses in Operating Reactors," September 29, 1980. [8010220035]

304. UCID-19469, "120 VAC Vital Instrument Buses and Inverter Technical Specifications," Lawrence Livermore National Laboratory, October 28, 1982. [8405180177]
305. Memorandum to Distribution from J. Davis, "NMSS Procedure for Review of Routine Inspection Operational Data and Licensee Event Reports," March 9, 1982. [8312290164]
306. IEEE Catalog No. TH0073-7, "Record of the Working Conference on Advanced Electrotechnology Applications to Nuclear Power Plants, January 15-17, 1980, Washington, D.C.," The Institute of Electrical and Electronics Engineers, Inc.
307. EPRI NP-2230, "ATWS: A Reappraisal, Part 3," Electric Power Research Institute, 1982.
308. SECY-82-352, "Assurance of Quality," August 20, 1982. [8209160068]
309. SECY-82-1, "Severe Accident Rulemaking and Related Matters," January 4, 1982. [8201190416]
310. Memorandum for W. Dircks from S. Chilk, "Staff Requirements - Briefing on Status and Plan for Severe Accident Rulemaking (SECY-82-1)," January 29, 1982. [8202160202]
311. SECY-82-1A, "Proposed Commission Policy Statement on Severe Accidents and Related Views on Nuclear Reactor Regulation," July 16, 1982. [8208040432]
312. NUREG/CR-0165, "A Value-Impact Assessment of Alternate Containment Concepts," U.S. Nuclear Regulatory Commission, June 1978.
313. NUREG/CR-2063, "Effects of the Accident of Three Mile Island on Property Values and Sales," U.S. Nuclear Regulatory Commission, March 1981.
314. NUREG/CR-2749, "Socioeconomic Impacts of Nuclear Generating Stations - Three Mile Island Case Study," U.S. Nuclear Regulatory Commission, (Vol. 12) July 1982.
315. Memorandum of Understanding Between the Federal Emergency Management Agency and the Nuclear Regulatory Commission, "Incident Response," October 22, 1980. [8011170793]
316. Memorandum of Understanding Between the Nuclear Regulatory Commission and the Federal Emergency Management Agency, "Radiological Emergency Planning and Preparedness," November 4, 1980. [8012110538]
317. Memorandum for G. Lainas from F. Miraglia, "CRGR Package for MPA B-71, 120 VAC Vital Instrument Buses and Inverter Technical Specifications," November 23, 1982. [8212160596]
318. Memorandum for H. Denton, et al., from C. Michelson, "An Analysis of the Abnormal Transient Operating Guidelines (ATOG) as Applied to the April 1981 Overfill Event at Arkansas Nuclear One - Unit 1," April 9, 1982. [8204220005]
319. Memorandum for C. Michelson from D. Eisenhut, "Review of Abnormal Transient Operating Guidelines (ATOG) as Applied to the April 8, 1981 Overfill Event at Arkansas Nuclear One - Unit 1," July 30, 1982. [8208180173]

320. Memorandum for C. Michelson from H. Denton, "Review of the Case Study of the Abnormal Transient Operating Guidelines (ATOG) as Applied to the April 1981 Overfill Event at Arkansas Nuclear One - Unit 1," October 7, 1982. [8211030575]
321. Memorandum for Commissioner Ahearne from W. Dircks, "AEOD Report on Arkansas Unit 1 Overfill Event," November 1, 1982. [8211190330]
322. AEOD/C201, "Report on The Safety Concern Associated with Reactor Vessel Level Instrumentation in Boiling Water Reactors," Office for Analysis and Evaluation of Operational Data, U.S. Nuclear Regulatory Commission, January 1982. [8202180432]
323. Memorandum for C. Michelson from H. Denton, "AEOD January 1982 Report on Safety Concern Associated with Reactor Vessel Level Instrumentation in Boiling Water Reactors," March 19, 1982. [8204190068]
324. NUREG-0785, "Safety Concerns Associated with Pipe Breaks in the BWR Scram System," U.S. Nuclear Regulatory Commission, April 1981.
325. NRC Letter to All BWR Licensees, "Safety Concerns Associated with Pipe Breaks in the BWR Scram System (Generic Letter 81-20)," April 10, 1981. [8112170367]
326. NEDO-24342, "GE Evaluation in Response to NRC Request Regarding BWR Scram System Pipe Breaks," General Electric Company, April 1981. [8105070251]
327. Letter to D. Eisenhut (NRC) from G. Sherwood (GE), "NRC Report, 'Safety Concerns Associated with Pipe Breaks in the BWR Scram System,'" April 30, 1981. [8105070249]
328. NUREG-0803, "Generic Safety Evaluation Report Regarding Integrity of BWR Scram System Piping," U.S. Nuclear Regulatory Commission, August 1981.
329. NRC Letter to All GE BWR Licensees (Except Humboldt Bay), "Safety Concerns Associated with Pipe Breaks in the BWR Scram System (Generic Letter 81-34)," August 31, 1981. [8110150121]
330. AEOD/C003, "Report on Loss of Offsite Power Event at Arkansas Nuclear One, Units 1 and 2, on April 7, 1980," Office for Analysis and Evaluation of Operational Data, U.S. Nuclear Regulatory Commission, October 15, 1980. [8011170099]
331. Memorandum for C. Michelson from H. Denton, "NRR Responses to AEOD Recommendations on the Arkansas Loss of Offsite Power Event of April 7, 1980," February 13, 1981. [8102270127]
332. NRC Letter to All BWR Applicants for CPs, Holders of CPs, and Applicants for OLs, "Safety Concerns Associated with Pipe Breaks in the BWR Scram System (Generic Letter 81-35)," August 31, 1981. [8112170388]
333. SECY-82-445, "Proposal to Assign Two Resident Inspectors to Each Reactor Construction Site," November 1, 1982. [8211190003]
334. SECY-82-478, "Resident Inspection Program," December 6, 1982. [8401250359]

335. Memorandum for J. Taylor from D. Morrison, "Resolution of Generic Safety Issue 83, 'Control Room Habitability,'" June 17, 1996. [9607250277]
336. NUREG-0834, "NRC Licensee Assessments," U.S. Nuclear Regulatory Commission, August 1981.
337. NUREG/CR-2672, "SBLOCA Outside Containment at Browns Ferry Unit One - Accident Sequence Analysis," U.S. Nuclear Regulatory Commission, November 1982.
338. NUREG/CR-2744, "Human Reliability Data Bank for Nuclear Power Plant Operations," U.S. Nuclear Regulatory Commission, November 1982.
339. NUREG/CR-1278, "Handbook of Human Reliability Analysis with Emphasis on Nuclear Power Plant Applications," U.S. Nuclear Regulatory Commission, October 1983.
340. Memorandum for H. Denton from J. Fouchard, "Draft Report on the Prioritization of Non-NRR TMI Action Plan Items," January 17, 1983. [8302030055]
341. NUREG/CR-2255, "Expert Estimation of Human Error Probabilities in Nuclear Power Plant Operations: A Review of Probability Assessment and Scaling," U.S. Nuclear Regulatory Commission, May 1982.
342. NUREG/CR-2743, "Procedures for Using Expert Judgment to Estimate Human Error Probabilities in Nuclear Power Plant Operations," U.S. Nuclear Regulatory Commission, February 1983.
343. NUREG/CR-2254, "Workbook for Conducting Human Reliability Analysis," U.S. Nuclear Regulatory Commission, February 1983.
344. NUREG/CR-1205, "Data Summaries of Licensee Event Reports of Pumps at U.S. Commercial Nuclear Power Plants," U.S. Nuclear Regulatory Commission, January 1980, (Rev. 1) January 1982.
345. Memorandum for R. Vollmer from T. Murley, "Prioritization of New Requirements for PWR Feedwater Line Cracks," July 21, 1981. [8108180001]
346. NUREG/CR-1363, "Data Summaries of Licensee Event Reports of Valves at U.S. Commercial Nuclear Power Plants," U.S. Nuclear Regulatory Commission, June 1980, (Rev. 1) October 1982.
347. NUREG/CR-6316, "Guidelines for the Verification and Validation of Expert System Software and Conventional Software," U.S. Nuclear Regulatory Commission, (Vols. 1, 2, 3, 4, 5, 6, 7, and 8) March 1995.
348. NUREG/CR-1362, "Data Summaries of Licensee Event Reports of Diesel Generators at U.S. Commercial Nuclear Power Plants, January 1, 1976 through December 31, 1978," U.S. Nuclear Regulatory Commission, March 1980.

349. NUREG/CR-1331, "Data Summaries of Licensee Event Reports of Control Rods and Drive Mechanisms at U.S. Commercial Nuclear Power Plants, January 1, 1972 through April 30, 1978," U.S. Nuclear Regulatory Commission, February 1980.
350. NUREG/CR-1730, "Data Summaries of Licensee Event Reports of Primary Containment Penetrations at U.S. Commercial Nuclear Power Plants, January 1, 1972 through December 31, 1978," U.S. Nuclear Regulatory Commission, September 1980.
351. NUREG/CR-1740, "Data Summaries of Licensee Event Reports of Selected Instrumentation and Control Components at U.S. Commercial Nuclear Power Plants from January 1, 1976 to December 31, 1978," U.S. Nuclear Regulatory Commission, May 1981.
352. Memorandum for C. Michelson from E. Brown, "Internal Appurtenances in LWRs," December 24, 1980. [8101150319]
353. NUREG/CR-2641, "The In-Plant Reliability Data Base for Nuclear Power Plant Components: Data Collection and Methodology Report," U.S. Nuclear Regulatory Commission, July 1982.
354. NUREG/CR-2886, "The In-Plant Reliability Data Base for Nuclear Power Plant Components: Interim Data Report - The Pump Component," U.S. Nuclear Regulatory Commission, January 1983.
355. EGG-EA-5502, "User's Guide to BFR, A Computer Code Based on the Binomial Failure Rate Common Cause Model," EG&G, Inc., July 1982.
356. EGG-EA-5623, "Common Cause Fault Rates for Instrumentation and Control Assemblies: Estimates Based on Licensee Event Reports at U.S. Commercial Nuclear Power Plants, 1976-1978," EG&G, Inc., (Rev. 1) September 1982.
357. EGG-EA-5485, "Common Cause Fault Rates for Valves: Estimates Based on Licensee Event Reports at U.S. Commercial Nuclear Power Plants, 1976-1980," EG&G, Inc., (Rev. 1) September 1982.
358. NUREG/CR-2099, "Common Cause Fault Rates for Diesel Generators: Estimates Based on Licensee Event Reports at U.S. Commercial Nuclear Power Plants, 1976-1978," U.S. Nuclear Regulatory Commission, (Rev. 1) June 1982.
359. NUREG/CR-1401, "Estimators for the Binomial Failure Rate Common Cause Model," U.S. Nuclear Regulatory Commission, April 1980.
360. EGG-EA-5289, "Common Cause Fault Rates for Pumps: Estimates Based on Licensee Event Reports at U.S. Commercial Nuclear Power Plants, January 1, 1972 through September 30, 1980," EG&G, Inc., (Rev. 1) August 1982.
361. JBFA-101-82, "Common Cause Screening Methodology Project (FY 81 Technical Progress Report)," JBF Associates, Inc., February 1982.

362. NUREG/CR-2542, "Sensitivity Study Using the FRANTIC II Code for the Unavailability of a System to the Failure Characteristics of the Components and the Operating Conditions," U.S. Nuclear Regulatory Commission, February 1982.
363. NUREG/CR-2332, "Time Dependent Unavailability of a Continuously Monitored Component," U.S. Nuclear Regulatory Commission, August 1981.
364. Memorandum for W. Dircks from S. Chilk, "Systematic Assessment of Licensee Performance," October 20, 1981. [8210080207]
365. NUREG/CR-2515, "Crystal River 3 Safety Study," U.S. Nuclear Regulatory Commission, December 1981.
366. NUREG/CR-2787, "Interim Reliability Evaluation Program: Analysis of the Arkansas Nuclear One - Unit One Nuclear Power Plant," U.S. Nuclear Regulatory Commission, June 1982.
367. NUREG/CR-2802, "Interim Reliability Evaluation Program: Analysis of the Browns Ferry Unit 1 Nuclear Plant," U.S. Nuclear Regulatory Commission, August 1982, (Appendix A) August 1982, (Appendix B) August 1982, (Appendix C) August 1982.
368. Memorandum for ACRS Members from C. Michelson, "Failure of a Feedwater Flow Straightener at San Onofre Nuclear Station, Unit 1," June 13, 1979. [7910180473]
369. SECY-82-396A, "Withdrawal of SECY-82-396 (Federal Policy Statement on Use of Potassium Iodide)," October 15, 1982. [8211040047]
370. SECY-81-676, "Delegation of Rulemaking Authority to the EDO," December 3, 1981. [8201110403]
371. SECY-82-187, "Revised Guidelines for Value-Impact Analyses," May 7, 1982. [8205130275]
372. SECY-82-447, "Draft Report of the Regulatory Reform Task Force," November 3, 1982. [8211160547]
373. NUREG-0499, "Preliminary Statement on General Policy for Rulemaking to Improve Nuclear Power Plant Licensing," U.S. Nuclear Regulatory Commission, December 1978.
374. Memorandum for J. Hendrie from L. Bickwit, "Review of Commission Delegation of Authority," October 4, 1979. [8001150518]
375. Memorandum for R. Minogue from R. Bernero, "Charter of the Regulatory Analysis Branch," October 9, 1981. [8110280720]
376. NRC Letter to All Licensees of Operating Reactors, Applicants for Operating Licenses, and Holders of Construction Permits, "Supplement 1 to NUREG-0737, Requirements for Emergency Response Capability (Generic Letter No. 82-33)," December 17, 1982. [8212060349]

377. Memorandum for W. Minners from B. Snyder, "Schedule for Resolving and Completing Generic Issues," December 16, 1982. [8312290162]
378. Memorandum for S. Boyd from M. Srinivasan, "FY 1983-FY 1984 Office of Nuclear Reactor Regulation Operating Plan," November 17, 1982. [8301100332]
379. Memorandum for H. Denton from R. DeYoung, "Draft Report on the Prioritization of Non-NRR TMI Action Plan Items," January 24, 1983. [8401160474]
380. SECY-93-049, "Implementation of 10 CFR Part 54, 'Requirements for Renewal of Operating Licenses for Nuclear Power Plants,'" March 1, 1993. [9303030337, 9303100375].
381. Memorandum for W. Minners from O. Parr, "Prioritization of Proposed Generic Issue on CRD Accumulator Check Valve Leakage," August 13, 1984. [8408280264]
382. Memorandum for W. Minners from R. Mattson, "Schedules for Resolving and Completing Generic Issues," January 21, 1983. [8301260532]
383. Memorandum for W. Dircks from R. Mattson, "Closeout of TMI Action Plan I.C.1(4), Confirmatory Analyses of Selected Transients," November 12, 1982. [8212080586]
384. Memorandum for T. Speis from R. Vollmer, "Schedules for Resolving and Completing Generic Issues," February 1, 1983. [8401170076]
385. Memorandum for T. Murley from D. Ross, "Use of Equipment Not Classified as Essential to Safety in BWR Transient Analysis," March 10, 1981. [8103240798, 9804090138]
386. Memorandum for T. Novak from R. Frahm, "Summary of Meeting with General Electric on the Use of Non-Safety Grade Equipment," March 7, 1979. [7903220463]
387. NUREG-0410, "NRC Program for the Resolution of Generic Issues Related to Nuclear Power Plants," U.S. Nuclear Regulatory Commission, January 1978.
388. NUREG-0577, "Potential for Low Fracture Toughness and Lamellar Tearing in PWR Steam Generator and Reactor Coolant Pump Supports," U.S. Nuclear Regulatory Commission, (Rev. 1) October 1983.
389. "Indian Point Probabilistic Safety Study," Power Authority of the State of New York and Consolidated Edison Company of New York, Inc., 1982.
390. NUREG-0850, "Preliminary Assessment of Core Melt Accidents at the Zion and Indian Point Nuclear Power Plants and Strategies for Mitigating Their Effects," U.S. Nuclear Regulatory Commission, November 1981.
391. Memorandum for E. Reeves from J. Knight, "Zion Liquid Pathway Analysis," August 8, 1980. [8008210647]
392. Memorandum for J. Funches from R. Mattson, "Request for Approval to Work on Low Priority Generic Safety Issues," November 5, 1982. [8211160524]

393. "TMI-2 Recovery Program Estimate," General Public Utilities Corp., (Rev. 1) July 1981.
394. Memorandum for S. Hanauer, et al., from D. Eisenhut, "Operating Reactor Event Memorandum No. 81-31: Loss of Direct Current (DC) Bus at Millstone Unit 2," March 31, 1981. [8104100493]
395. Memorandum for H. Denton from C. Michelson, "Millstone Unit 2 - Reactor Trip Following De-Energization of a 125 V DC Bus," November 5, 1981. [8112010276]
396. Memorandum for C. Michelson from H. Denton, "AEOD November 1981 Report on the Millstone Unit 2 Loss of 125 V DC Bus Event," January 4, 1982. [8202040017]
397. IEEE Std 279, "Criteria for Protection Systems for Nuclear Power Generating Stations (ANSI N42.7-1972)," The Institute of Electrical and Electronics Engineers, Inc., 1971.
398. Memorandum for R. Tedesco from T. Speis, "Identification of Protection System Instrument Sensing Lines," April 29, 1982. [8205270511]
399. Memorandum to C. Rossi from A. Thadani, "Prioritization of and Transfer of Responsibility for Generic Safety Issue 156.6.1, 'Pipe Break Effects on Systems and Components Inside Containment,'" July 16, 1999. [9908300234]
400. Memorandum for V. Stello from H. Denton, "Standard Review Plan Guidance for Identification of Protection System Instrument Lines," December 29, 1982. [8301070067]
401. Memorandum for H. Denton from V. Stello, "Proposed Standard Review Plan Guidance for Identification of Protection System Instrument Lines," January 27, 1983. [8302180526]
402. Letter to D. Eisenhut (NRC) from T. Dente (BWR Owners' Group), "Analysis of Scram Discharge Volume System Piping Integrity, NEDO-22209 (Prepublication Form)," August 23, 1982. [8208310340]
403. Letter to K. Eccleston (NRC) from T. Dente (BWR Owners' Group), "Transmittal of Supporting Information on Application of Scram Time Fraction to Scram Discharge Volume (SDV) Pipe Break Probability as Used in NEDO-22209," January 28, 1983. [8302010525]
404. Letter to S. Israel (NRC) from J. Hickman (SNL), "Review and Evaluation of the Indian Point Probabilistic Safety Study," August 25, 1982. [8209230166]
405. Memorandum for W. Minners from A. Thadani, et al., "Probability of Core Melt Due to Component Cooling Water System Failures," January 19, 1983. [8301270522]
406. Memorandum for W. Dircks from R. DeYoung, "TMI Action Plan - Status Report," March 4, 1982. [8204290601]
407. Memorandum for W. Dircks from R. DeYoung, "TMI Action Plan - Completed Item," May 11, 1982. [8401170108]
408. NUREG-1509, "Radiation Effects on Reactor Pressure Vessel Supports," U.S. Nuclear Regulatory Commission, May 1996.

409. Memorandum for W. Minners from W. Mills, "Prioritization of Generic Issue III.D.3.5, Radiation Worker Data Base," February 22, 1983. [9705190229]
410. Memorandum for T. Speis from R. Browning, "Draft Report on the Prioritization of Non-NRR TMI Action Plan Items," April 1, 1983. [8304200629, 9705190233]
411. SLI-8211, "Review of BWR Reactor Vessel Water Level Measurement Systems," S. Levy, Inc., July 1982.
412. Memorandum for T. Speis from J. Funches, "Prioritization of Generic Issues - Environmental and Licensing Improvements," February 24, 1983. [8303090540]
413. Memorandum for D. Eisenhut from E. Jordan, "Main Steam Isolation Valve (MSIV) Survey," July 1, 1982. [8209240107]
414. Memorandum for W. Minners from L. Hulman, "Consequence Analyses for BWR Main Steam System Leakage Pathway Generic Issue Evaluation," December 9, 1982. [8301050058]
415. Memorandum for W. Minners from L. Hulman, "MSIV Leakage Consequences," December 23, 1982. [8312290172]
416. NUREG/CR-1908, "Criteria for Safety-Related Nuclear Power Plant Operator Actions: Initial Pressurized Water Reactor (PWR) Simulator Exercises," U.S. Nuclear Regulatory Commission, September 1981.
417. NUREG/CR-2598, "Nuclear Power Plant Control Room Task Analysis: Pilot Study for Pressurized Water Reactors," U.S. Nuclear Regulatory Commission, July 1982.
418. NUREG/CR-2534, "Criteria for Safety-Related Nuclear Power Plant Operator Actions: Initial Boiling Water Reactor (BWR) Simulated Exercises," U.S. Nuclear Regulatory Commission, November 1982.
419. NUREG/CR-3092, "Criteria for Safety-Related Nuclear Power Plant Operator Actions: Initial Simulator to Field Data Calibration," U.S. Nuclear Regulatory Commission, February 1983.
420. IE Bulletin No. 80-14, "Degradation of BWR Scram Discharge Volume Capability," U.S. Nuclear Regulatory Commission, June 12, 1980. [8005050056]
421. IE Bulletin No. 80-17, "Failure of 76 of 185 Control Rods to Fully Insert During Scram at BWR," U.S. Nuclear Regulatory Commission, July 3, 1980. [8005050076]
422. NRC Letter to All BWR Licensees, "BWR Scram Discharge System," December 9, 1980. [8102190299]
423. Memorandum for R. Mattson from D. Eisenhut, "Status of Long-Term Followup of the Indian Point Unit 2 Flooding Event," May 13, 1982. [8205240153]
424. Memorandum for F. Schroeder from T. Speis, "Designation of Inadvertent Containment Flooding as a Generic Issue," August 5, 1982. [8208120379]

425. "Zion Probabilistic Safety Study," Commonwealth Edison Company, 1981.
426. Memorandum for T. Novak from G. Lainas and V. Noonan, "NRR Input to SER on 'Indian Point Unit No. 2 Flood in Containment Due to Containment Cooler Service Water Leaks on 10/17/80,'" April 3, 1981. [8104090906]
427. Memorandum for T. Speis from R. Mattson, "Close-out of TAP-A-16, Steam Effects on BWR Core Spray Distribution (TACS-40066)," March 29, 1983. [8304130488]
428. Memorandum for W. Minners from P. Hayes, "Generic Safety Issue No. 51, Improved Reliability of Open Service Water Systems," April 5, 1983. [9705190249]
429. Memorandum for J. Knight from E. Sullivan, "Review ACRS Consultant Report," January 10, 1980. [8105150033]
430. Memorandum for K. Seyfrit from E. Imbro, "Flow Blockage in Essential Raw Cooling Water System Due to Asiatic Clam Intrusion," March 28, 1983. [8305230539]
431. EPRI NP-1138, "Limiting Factor Analysis of High-Availability Nuclear Plants," Electric Power Research Institute, September 1979.
432. SECY-82-296, "Resolution of AEOD Combination LOCA Concern," July 13, 1982. [8207230202]
433. Memorandum for C. Michelson from E. Brown, "Degradation of Internal Appurtenances and/or Loose Parts in LWRs," June 15, 1982. [8207280317]
434. Memorandum for H. Denton, et al., from C. Michelson, "Flow Blockage in Essential Equipment at ANO Caused by Corbicula sp. (Asiatic Clams)," October 21, 1980. [8011060029]
435. Letter to N. Palladino from P. Shewmon, "Control Room Habitability," August 18, 1982. [8207180073]
436. Letter to J. Ray from W. Dircks, "August 18, 1982, ACRS Letter on Control Room Habitability," January 31, 1983. [8302100196]
437. Memorandum for H. Denton from R. Minogue, "Draft Report on the Prioritization of Non-NRR TMI Action Plan Items," March 29, 1983. [8401160475]
438. Memorandum for G. Cunningham, et al., from W. Dircks, "NRC Actions Required by Enactment of the Nuclear Waste Policy Act of 1982," January 19, 1983. [8507110762]
439. Regulatory Guide 1.149, "Nuclear Power Plant Simulators for Use in Operator Training," U.S. Nuclear Regulatory Commission, April 1981 [8105220400], (Rev. 1) April 1987 [8704300503, 8601160291], (Rev. 2) April 1996 [9604170117].
440. Memorandum for W. Minners from D. Ziemann, "Schedules for Resolving and Completing Generic Issues," April 5, 1983. [8304180758]

441. Memorandum for H. Denton from R. DeYoung, "Commission Paper on the Prioritization of Generic Safety Issues," April 20, 1983. [9705190224]
442. Memorandum for R. Emrit from T. Rothschild, "Establishing Priorities for Generic Safety Issues," April 21, 1983. [8312290167]
443. Memorandum for W. Dircks from R. Mattson, "Closeout of NUREG-0660 Item II.E.5.1, Design Sensitivity of B&W Plants for Operating Plants," March 15, 1983. [8304080415]
444. "Letter to Public Service Electric and Gas Company from D. Fischer (NRC) 'Meeting Summary - Salem Unit - 1 Failure of Reactor Trip Breakers,'" March 14, 1983. [8303210160]
445. NUREG-1000, "Generic Implications of ATWS Events at the Salem Nuclear Power Plant," U.S. Nuclear Regulatory Commission, (Vol. 1) April 1983, (Vol. 2) August 1983.
446. Memorandum for Chairman Ahearne from C. Michelson, "New Unresolved Safety Issues," August 4, 1980. [8010240206]
447. NUREG-0977, "NRC Fact Finding Task Force Report on the ATWS Events at Salem Nuclear Generating Station Unit 1 on February 22 and 25, 1983," U.S. Nuclear Regulatory Commission, March 1983.
448. Memorandum for F. Rowsome from S. Bryan, "Reliability Assurance - Reactor Protection System," July 23, 1981. [8109100509]
449. Memorandum for S. Hanauer from D. Eisenhut, "Potential Generic Issue: BWR Control Rod Test Requirements Following Maintenance," November 26, 1982. [8212160790]
450. Memorandum for R. Mattson from T. Speis, "Potential Generic Issues Related to Scram Systems," April 7, 1983. [8304200351]
451. Memorandum for H. Denton from C. Heltemes, "Potential Design Deficiency in Westinghouse Reactor Protection System," March 10, 1983. [8303230335]
452. Memorandum for C. Heltemes from H. Denton, "Westinghouse Reactor Protection System Design Conformance to IEEE Standard 279," May 2, 1983. [8305180398]
453. Memorandum for H. Denton, et al., from R. Mattson, "Recommended Generic Actions," April 27, 1983. [8305250017]
454. SECY-83-98E, "Salem Restart Evaluation," April 11, 1983. [8304220308]
455. NUREG-0771, "Regulatory Impact of Nuclear Reactor Accident Source Term Assumptions," U.S. Nuclear Regulatory Commission, June 1981.
456. WASH-1248, "Environmental Survey of the Uranium Fuel Cycle," U.S. Atomic Energy Commission, April 1974.

457. NUREG-0116, "Environmental Survey of the Reprocessing and Waste Management Portions of the LWR Fuel Cycle," U.S. Nuclear Regulatory Commission, October 1976.
458. NUREG-0216, "Public Comments on the Environmental Survey of the Reprocessing and Waste Management Portions of the LWR Fuel Cycle," U.S. Nuclear Regulatory Commission, March 1977.
459. NUREG-0252, "The Environmental Effects of Using Coal for Generating Electricity," U.S. Nuclear Regulatory Commission, June 1977.
460. NUREG/CR-1060, "Activities, Effects, and Impacts of the Coal Fuel Cycle for a 1,000 MWe Electric Power Generating Plant," U.S. Nuclear Regulatory Commission, February 1980.
461. NUREG-0332, "Health Effects Attributable to Coal and Nuclear Fuel Cycle Alternatives," U.S. Nuclear Regulatory Commission, November 1977.
462. NUREG/CR-0022, "Need for Power: Determination in the State Decisionmaking Process," U.S. Nuclear Regulatory Commission, March 1978.
463. NUREG/CR-0250, "Regional Econometric Model for Forecasting Electricity Demand by Sector and State," U.S. Nuclear Regulatory Commission, October 1978.
464. NUREG-0555, "Environmental Standard Review Plans for the Environmental Review of Construction Permit Applications for Nuclear Power Plants," U.S. Nuclear Regulatory Commission, May 1979.
465. NUREG-0398, "Federal-State Cooperation in Nuclear Power Plant Licensing," U.S. Nuclear Regulatory Commission, March 1980.
466. NUREG-0942, "Conducting Need-for-Power Review for Nuclear Power Plants," U.S. Nuclear Regulatory Commission, December 1982.
467. NUREG/CR-2423, "Mathematical Simulation of Sediment and Radionuclide Transport in Estuaries," U.S. Nuclear Regulatory Commission, November 1982.
468. NUREG/CR-2823, "A Review of the Impact of Copper Released into Marine and Estuarine Environments," U.S. Nuclear Regulatory Commission, November 1982.
469. NUREG/CR-0892, "Chronic Effects of Chlorination Byproducts on Rainbow Trout, *Salmo gairdneri*," U.S. Nuclear Regulatory Commission, November 1980.
470. NUREG/CR-0893, "Acute Toxicity and Bioaccumulation of Chloroform to Four Species of Freshwater Fish," U.S. Nuclear Regulatory Commission, August 1980.
471. NUREG/CR-2750, "Socioeconomic Impacts of Nuclear Generating Stations," U.S. Nuclear Regulatory Commission, July 1982.
472. NUREG/CR-2861, "Image Analysis for Facility Siting: A Comparison of Low and High-Attitude Image Interpretability for Land Use/Land Cover Mapping," U.S. Nuclear Regulatory Commission, November 1982.

473. NUREG/CR-2550, "Charcoal Performance Under Simulated Accident Conditions," U.S. Nuclear Regulatory Commission, July 1982.
474. NUREG-0700, "Guidelines for Control Room Design Reviews," U.S. Nuclear Regulatory Commission, September 1981.
475. Memorandum for W. Minners from F. Congel, "Prioritization of Generic Issue 58, Containment Flooding," May 19, 1983. [8306080295]
476. Regulatory Guide 4.2, "Preparation of Environmental Reports for Nuclear Power Stations," U.S. Nuclear Regulatory Commission, July 1976. [7908310195]
477. NUREG/CR-2692, "An Integrated System for Forecasting Electric Energy and Load for States and Utility Service Areas," U.S. Nuclear Regulatory Commission, May 1982.
478. Regulatory Guide 1.57, "Design Limits and Loading Combinations for Metal Primary Reactor Containment System Components," U.S. Nuclear Regulatory Commission, June 1973. [7907100220]
479. Regulatory Guide 1.7, "Control of Combustible Gas Concentrations in Containment Following a Loss-of-Coolant Accident," U.S. Nuclear Regulatory Commission, November 1978. [7812270049]
480. Regulatory Guide 1.109, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I," U.S. Nuclear Regulatory Commission, October 1977. [7907100401]
481. Regulatory Guide 1.35, "Inservice Inspection of UngROUTED Tendons in Prestressed Concrete Containments," U.S. Nuclear Regulatory Commission, February 1973, (Rev. 1) June 1974, (Rev. 2) January 1976 [7907100149], (Rev. 3) July 1990 [7809180004].
482. Regulatory Guide 1.90, "Inservice Inspection of Prestressed Concrete Containment Structures with Grouted Tendons," U.S. Nuclear Regulatory Commission, August 1977. [7907100329]
483. ORNL-5470, "CONCEPT-5 User's Manual," Oak Ridge National Laboratory, December 1978.
484. ORNL/TM-6467, "A Procedure for Estimating Nonfuel Operation and Maintenance Costs for Large Steam-Electric Power Plants," Oak Ridge National Laboratory, January 1979.
485. NUREG/CR-2844, "Nonfuel Operation and Maintenance Costs for Large Steam-Electric Power Plants - 1982," U.S. Nuclear Regulatory Commission, September 1982.
486. Memorandum for Z. Rosztoczy, et al., from W. Anderson, "Seismic Scram," January 20, 1983. [8302100005]
487. Memorandum for G. Arndt from G. Burdick, "Review of Seismic Scram Report, UCRL-53037," March 3, 1983. [8303160092]

488. NUREG-0610, "Draft Emergency Action Level Guidelines for Nuclear Power Plants," U.S. Nuclear Regulatory Commission, September 1979.
489. NUREG/CR-2963, "Planning Guidance for Nuclear Power Plant Decontamination," U.S. Nuclear Regulatory Commission, June 1983.
490. Memorandum for H. Denton from C. Michelson, "Potential Generator Missiles - Generator Rotor Retaining Rings," March 16, 1982. [8203300270]
491. NRC Letter to All Licensees of Operating Westinghouse and CE PWRs (Except Arkansas Nuclear One - Unit 2 and San Onofre Units 2 and 3), "Inadequate Core Cooling Instrumentation System (Generic Letter No. 82-28)," December 10, 1982. [8212140103]
492. Memorandum for C. Michelson from H. Denton, "H. B. Robinson RCS Leak on January 29, 1981," June 15, 1981. [8107010140]
493. Memorandum for C. Michelson from H. Denton, "January 19, 1981, Memorandum on Degradation of Internal Appurtenances in LWR," April 30, 1981. [8105150032]
494. Memorandum for C. Michelson from H. Denton, "AEOD Preliminary Report on Calvert Cliffs Unit 1 Loss of Service Water," August 5, 1981. [8108170221]
495. Memorandum for C. Michelson from H. Denton, "Steam Generator Overfill and Combined Primary and Secondary Blowdown," May 27, 1981. [8106100241]
496. Memorandum for H. Denton from C. Michelson, "Concerns Relating to the Integrity of a Polymer Coating for Surfaces Inside Containment (IE Draft Bulletin No. 80-21)," August 29, 1980. [8210120370, 8009110599]
497. Memorandum for H. Denton and V. Stello from C. Michelson, "Immediate Action Memo: Common Cause Failure Potential at Rancho Seco - Desiccant Contamination of Air Lines," September 15, 1981. [8109280036]
498. Memorandum for C. Michelson from H. Denton, "AEOD Immediate Action Memo on Contamination of Instrument Air Lines at Rancho Seco," October 26, 1981. [8111300391]
499. Memorandum for H. Denton, et al., from C. Michelson, "Case Study Report on San Onofre Unit 1 Loss of Salt Water Cooling Event on March 10, 1980," August 12, 1980. [8208270684]
500. Memorandum for C. Michelson from H. Denton, "NRR Comments on AEOD Final Report: Case Study Report on San Onofre Unit 1 Loss of Salt Water Cooling Event of March 10, 1980," October 8, 1982. [8211030304]
501. IE Bulletin No. 79-24, "Frozen Lines," U.S. Nuclear Regulatory Commission, September 27, 1979. [7908220114]
502. Memorandum for H. Denton and V. Stello from C. Michelson, "Inoperability of Instrumentation Due to Extreme Cold Weather," June 15, 1981. [8107010161]

503. Memorandum for C. Michelson from H. Denton, "AEOD Memorandum on the Inoperability of Instrumentation Due to Extreme Cold Weather," August 14, 1981. [8109110138]
504. Draft Regulatory Guide and Value/Impact Statement, Task IC 126-5, "Instrument Sensing Lines," U.S. Nuclear Regulatory Commission, March 1982. [8204190028]
505. Regulatory Guide 1.151, "Instrument Sensing Lines," U.S. Nuclear Regulatory Commission, July 1983. [8808230051]
506. Federal Register Notice 48 FR 36029, "Regulatory Guide; Issuance, Availability," August 8, 1983.
507. Memorandum for C. Michelson from H. Denton, "Interlocks and LCO's for Redundant Class 1E Tie Breakers (Point Beach Nuclear Plant Units 1 and 2)," October 16, 1980. [8011050312]
508. Memorandum for F. Schroeder from L. Rubenstein, "Review of General Electric Topical Report NEDO-10174, Revision 1," August 18, 1982. [8209030003]
509. Memorandum for C. Michelson from H. Denton, "NRR Comments on AEOD Final Report: Survey of Valve Operator-Related Events Occurring During 1978, 1979, and 1980," August 19, 1982. [8404110426]
510. Memorandum for C. Michelson from H. Denton, "Effects of Fire Protection System Actuation on Safety-Related Equipment," August 27, 1982. [8506050357]
511. "Value-Impact Analysis of Recommendations Concerning Steam Generator Tube Degradations and Rupture Events," Science Applications, Inc., February 2, 1983.
512. Memorandum for D. Eisenhut from T. Speis, "DST Prioritization of Steam Generator Requirements," May 4, 1983. [8305230682]
513. SECY-82-186A, "Make-up Nozzle Cracking in Babcock and Wilcox (B&W) Plants," July 23, 1982. [8209300376]
514. Letter to J. Stolz (NRC) from G. Westafer (Florida Power Corporation), "Crystal River Unit 3, Docket No. 50-302, Operating License No. DPR-72, Safe End Task Force Action Plan," February 28, 1983. [8303040544]
515. Memorandum for W. Minners from D. Dilanni, "Proposed Generic Issue 'PORV and Block Valve Reliability,'" June 6, 1983. [8307050513]
516. Memorandum for W. Johnston and L. Rubenstein from T. Speis, "Failure of Resin Demineralizer Systems and Their Effects on Nuclear Power Plant Safety," August 6, 1982. [8208230475]
517. Memorandum for the Atomic Safety & Licensing Boards for: Callaway Plant, Unit 1; Comanche Peak Steam Electric Station, Units 1 & 2; and the Atomic Safety & Licensing Appeal Board for Virgil C. Summer Nuclear Station, Unit 1, from T. Novak, "Board

- Notification - Control Rod Drive Guide Tube Support Pin Failures at Westinghouse Plants (Board Notification No. 82-81)," August 16, 1982. [8209290318]
518. Memorandum for D. Eisenhut from J. Crews, "NRC Lead Responsibility for Possibly Detached Thermal Sleeves - Trojan Nuclear Plant - Docket No. 50-344," June 18, 1982. [8710220041]
 519. Memorandum for W. Minners from L. Hulman, "Generic Issue on Iodine Coolant Activity Limiting Conditions for Operation," June 10, 1983. [8307080562]
 520. NRC Letter to All Licensees of Operating Reactors, Applicants for Operating Licenses, and Holders of Construction Permits, "Required Actions Based on Generic Implications of Salem ATWS Events," (Generic Letter No. 83-28), July 8, 1983 [8307080169], (Supplement 1) October 7, 1992 [9210050243].
 521. SECY-83-248, "Generic Actions for Licensees and Staff in Response to the ATWS Events at Salem Unit 1," June 22, 1983. [8307110103]
 522. AEOD/P301, "Report on the Implications of the ATWS Events at the Salem Nuclear Power Plant on the NRC Program for Collection and Analysis of Operational Experience," Office for Analysis and Evaluation of Operational Data, U.S. Nuclear Regulatory Commission, July 1983. [8307140507]
 523. Memorandum for C. Heltemes from H. Denton, "AEOD Final Report on the Implications of the ATWS Events at the Salem Nuclear Power Plant on the NRC Program for Collection and Analysis of Operational Experience," July 21, 1983. [8307290045]
 524. Memorandum for R. Mattson from T. Speis, "Draft CRGR Package on A-30, DC Power," May 24, 1983. [8306030487]
 525. Memorandum for H. Denton from C. Heltemes, "Engineering Evaluation Report, Investigation of Backflow Protection in Common Equipment and Floor Drain Systems to Prevent Flooding of Vital Equipment in Safety-Related Compartments," March 11, 1983. [8303290078]
 526. NUREG/CR-3226, "Station Blackout Accident Analyses (Part of NRC Task Action Plan A-44)," U.S. Nuclear Regulatory Commission, May 1983.
 527. IE Information Notice No. 83-44, "Potential Damage to Redundant Safety Equipment as a Result of Backflow Through the Equipment and Floor Drain System," U.S. Nuclear Regulatory Commission, July 1, 1983 [8305110502], (Supplement 1) August 30, 1990 [9008240057].
 528. Memorandum for B. Liaw from H. Berkow, "OMB Clearance Renewal - Monitoring of Fatigue Transient Limits for Reactor Coolant System," May 13, 1983. [9705190223]
 529. Memorandum for H. Berkow from W. Minners, "OMB Clearance Renewal -Monitoring of Fatigue Transient Limits for Reactor Coolant System," June 1, 1983. [8306090456]

530. Letter to R. DeYoung (NRC) from J. Taylor (B&W), "Unanalyzed Reactor Vessel Thermal Stress During Cooldown," March 18, 1983. [8303250020]
531. Memorandum for R. Vollmer from W. Minners, "B&W Notification Concerning an Unanalyzed Reactor Vessel Thermal Stress During Cooldown," April 7, 1983. [8304140390]
532. Regulatory Guide 1.93, "Availability of Electric Power Sources," U.S. Nuclear Regulatory Commission, December 1974. [7907100337]
533. Memorandum for W. Minners from R. Bosnak, "B&W Notification Concerning an Unanalyzed Reactor Vessel Thermal Stress During Cooldown," April 26, 1983. [8305240235]
534. Memorandum for N. Palladino, et al., from D. Eisenhut, "Unanalyzed Reactor Vessel Thermal Stress During Cooldown (Board Notification #BN-83-42)," April 12, 1983. [8304220651]
535. CE-NPSD-154, "Natural Circulation Cooldown, Task 430 Final Report," Combustion Engineering, Inc., October 1981. [8304280091]
536. B&W Document No. 86-1140819-00, "Reactor Vessel Head Cooldown During Natural Circulation Cooldown Transients," Babcock & Wilcox Company, February 8, 1983. [8302160171]
537. Memorandum for W. Dircks from R. Fraley, August 18, 1982. [8207180092]
538. Memorandum for R. Fraley from H. Denton, "ACRS Inquiry on Pipe Break Effects on CRD Hydraulic Lines," October 29, 1982. [8211120045]
539. Letter to W. Dircks from J. Ebersole, "ACRS Comments Regarding Potential Pipe Break Effects on Control Rod Drive Hydraulic Lines in the Drywells of BWR Mark I and II Containments," March 16, 1983. [8303290428]
540. BNL-NUREG-28109, "Thermal-Hydraulic Effects on Center Rod Drop Accidents in a Boiling Water Reactor," Brookhaven National Laboratory, July 1980. [8101220642]
541. Memorandum for B. Sheron from C. Berlinger, "ACRS Request for Information Related to LOCA Effects on CRD Hydraulic Lines," October 19, 1982. [8211040446]
542. Memorandum for R. Mattson, et al., from D. Eisenhut, "Potential Safety Problems Associated With Locked Doors and Barriers in Nuclear Power Plants," May 31, 1983. [8306200435]
543. Memorandum for T. Speis from R. Mattson, "Proposed Generic Issue on Beyond Design Basis Accidents in Spent Fuel Pools," August 10, 1983. [8308180730]
544. NUREG/CR-0649, "Spent Fuel Heatup Following Loss of Water During Storage," U.S. Nuclear Regulatory Commission, May 1979.

545. Memorandum for Z. Rosztoczy from P. Williams, "Trip Report: International Meeting on Severe Fuel Damage and Visit to Power Burst Facility," April 25, 1983. [8305060661]
546. Memorandum to C. Rossi from D. Cool, "NMSS Input for Second Quarter FY-2000 Update of the Generic Issues Management Control System," April 18, 2000.
547. SECY-95-245, "Completion of the Fatigue Action Plan," September 25, 1995. [9509290040]
548. Memorandum for W. Dircks from R. DeYoung, "TMI Action Plan Completed Items," January 26, 1983. [8303090323]
549. NUREG/CR-2039, "Dynamic Combinations for Mark II Containment Structures," U.S. Nuclear Regulatory Commission, June 1982.
550. NUREG/CR-1890, "ABS, SRSS and CDF Response Combination Evaluation for Mark III Containment and Drywell Structures," U.S. Nuclear Regulatory Commission, June 1982.
551. Letter to N. Palladino from J. Ray, "Need for Rapid Depressurization Capability in Newer Combustion Engineering, Inc. Plants," October 18, 1983. [8311010118]
552. Memorandum for W. Minners from B. Siegel, "Proposed Generic Issue 'Reliability of Vacuum Breakers Connected to Steam Discharge Lines Inside BWR Containments,'" November 3, 1983. [8312140360]
553. Memorandum for D. Eisenhut from J. Olshinski, "Loss of High Head Injection Capability at McGuire Unit 1 and Reconsideration of Technical Specification 3.0.3 and 3.5.2," April 12, 1982. [8802120046]
554. Memorandum for D. Eisenhut, et al., from H. Denton, "Development of Generic Recommendations Based on the Review of the January 25, 1982 Steam Generator Tube Rupture at Ginna," May 3, 1982. [8205280089]
555. Letter to D. Eisenhut (NRC) from D. Waters (BWR Owners' Group), "BWR Owners' Group Evaluations of NUREG-0737 Requirements II.K.3.16 and II.K.3.18," March 31, 1981. [8104200300]
556. Memorandum for G. Lainas, et al., from W. Houston, "Evaluation of BWR Owners' Group Generic Response to Item II.K.3.16 of NUREG-0737, 'Reduction of Challenges and Failures of Relief Valves - Feasibility Study and System Modification,'" April 1, 1983. [8711060070]
557. Memorandum for H. Denton and V. Stello from C. Michelson, "Calvert Cliffs Unit 1 Loss of Service Water," June 19, 1981. [8107060505]
558. Memorandum for H. Denton and R. DeYoung from C. Michelson, "Calvert Cliffs Unit 1 Loss of Service Water on May 20, 1980," December 17, 1981. [8201150431]
559. Memorandum for C. Michelson from H. Denton, "NRR Comments on AEOD Final Report: Calvert Cliffs Unit 1 Loss of Service Water on May 20, 1980," September 23, 1982. [8210180230]

560. Memorandum for H. Denton from C. Heltemes, "Response to NRR Comments on AEOD Report, 'Calvert Cliffs Unit 1 Loss of Service Water on May 20, 1980,'" May 2, 1983. [8305110577]
561. Memorandum for W. Houston and L. Rubenstein from F. Miraglia, "Response to NRR Comments on AEOD Report, 'Calvert Cliffs Unit 1 Loss of Service Water on May 20, 1980,'" June 2, 1983. [8306080036]
562. Memorandum for F. Miraglia from W. Houston and L. Rubenstein, "Comments to AEOD Memo dated May 2, 1983, on Calvert Cliffs, Unit 1, Loss of Service Water on May 20, 1980," July 22, 1983. [8308030493]
563. Memorandum for C. Heltemes from H. Denton, "Response to NRR Comments on AEOD Report, 'Calvert Cliffs Unit 1 Loss of Service Water on May 20, 1980,'" September 15, 1983. [8309270470]
564. Memorandum for R. Baer from K. Seyfrit, "Case Study, 'Calvert Cliffs Unit 1 Loss of Service Water on May 29, 1980,'" August 18, 1983. [8308290487]
565. IE Information Notice No. 83-77, "Air/Gas Entrainment Events Resulting in System Failures," U.S. Nuclear Regulatory Commission, November 14, 1983. [8311010015]
566. Memorandum for G. Holahan from W. Minners, "Prioritization of Issue 36: Loss of Service Water at Calvert Cliffs Unit 1," November 10, 1983. [8311180373]
567. Letter to A. Lundvall (Baltimore Gas and Electric Company) from D. Eisenhut (NRC), Docket No. 50-317, September 15, 1983. [8309270504]
568. Memorandum for W. Houston and L. Rubenstein from F. Schroeder, "Request for Reactor Systems Branch and Auxiliary Systems Branch Support for Plant Visits on USI A-45," November 28, 1983. [8312150068]
569. AEOD/C102, "Engineering Evaluation of the H. B. Robinson Reactor Coolant System Leak on January 29, 1981," Office for Analysis and Evaluation of Operational Data, U.S. Nuclear Regulatory Commission, March 23, 1981. [8104150060]
570. Memorandum for V. Stello from H. Denton, "Issuance of Revised Section 7.1, Appendix A to this Section, Section 7.5 and Section 7.7 of the Standard Review Plan, NUREG-0800," March 9, 1984. [8404160228]
571. Memorandum for H. Denton from V. Stello, "SRP Changes Concerning Resolution of Generic Issue 45, Inoperability of Instrumentation due to Extreme Cold Weather," April 3, 1984. [8404180510]
572. Memorandum for G. Lainas from F. Rowsome, "Safety Evaluation of the Westinghouse Licensees' Responses to TMI Action Item II.K.3.2," July 22, 1983. [8308040054]
573. Memorandum for G. Lainas from F. Rowsome, "Safety Evaluation of the B&W Licensees' Responses to TMI Action Item II.K.3.2," August 24, 1983. [8308310422]

574. Memorandum for G. Lainas from F. Rowsome, "Safety Evaluation of the CE Licensees' Responses to TMI Action Item II.K.3.2," August 26, 1983. [8309060394]
575. Memorandum for W. Minners from B. Sheron, "Proposed Generic Issue on PORV and Block Valve Reliability," June 27, 1983. [8307180224]
576. Memorandum for R. Riggs from F. Cherny, "Comments on Draft Write-up of Prioritization of Generic Issue 70 'PORV and Block Valve Reliability,'" December 21, 1983. [8401030003]
577. Memorandum for H. Denton, et al., from C. Heltemes, "Case Study Report - Low Temperature Overpressure Events at Turkey Point Unit 4," September 26, 1983. [8310060171]
578. NUREG-0748, "Operating Reactors Licensing Actions Summary," U.S. Nuclear Regulatory Commission, (Vol. 5, No. 11) February 1986.
579. NUREG-0694, "TMI-Related Requirements for New Operating Licenses," U.S. Nuclear Regulatory Commission, June 1980.
580. NUREG-0645, "Report of the Bulletins & Orders Task Force of the Office of Nuclear Reactor Regulation," U.S. Nuclear Regulatory Commission, (Vol. 1) January 1980, (Vol. 2) January 1980.
581. NUREG-0909, "NRC Report on the January 25, 1982 Steam Generator Tube Rupture at R.E. Ginna Nuclear Power Plant," U.S. Nuclear Regulatory Commission, April 1982.
582. NUREG-0713, "Occupational Radiation Exposure at Commercial Nuclear Power Reactors - 1981," U.S. Nuclear Regulatory Commission, (Vol. 1) March 1981, (Vol. 2) December 1981, (Vol. 3) November 1982, (Vol. 4) November 1983, (Vol. 5) March 1985, (Vol. 6) September 1986, (Vol. 7) April 1988.
583. EPRI NP-2292, "PWR Safety and Relief Valve Test Program," Electric Power Research Institute, December 1982.
584. EPRI NP-1139, "Limiting Factor Analysis of High Availability Nuclear Plants," Electric Power Research Institute, August 1979.
585. EPRI P-2410-SR, "Technical Assessment Guide," Electric Power Research Institute, May 1982.
586. WCAP-9804, "Probabilistic Analysis and Operational Data in Response to NUREG-0737 Item II.K.3.2 for Westinghouse NSSS Plants," Westinghouse Electric Corporation, February 1981. [8103160257]
587. "Accident Sequence Evaluation Program, Phase II Workshop Report," Sandia National Laboratories, EG&G Idaho, Inc., and Science Applications, Inc., September 1982.
588. Letter to Director (NRR) from K. Cook (Louisiana Power & Light), "Waterford SES Unit 3, Docket No. 50-382, Depressurization and Decay Heat Removal," October 27, 1983. [8311010259]

589. Letter to W. Dircks (NRC) from E. Van Brunt (Arizona Public Service Company), "Palo Verde Nuclear Generating Station (PVNGS), Units 1, 2, and 3, Docket Nos. STN-50-528/529/530," November 7, 1983. [8312230233]
590. ALO-75 (TR-3459-1), "Pilot Program to Identify Valve Failures Which Impact the Safety and Operation of Light Water Nuclear Power Plants," Teledyne Engineering Services, January 11, 1980.
591. IE Information Notice No. 82-45, "PWR Low Temperature Overpressure Protection," U.S. Nuclear Regulatory Commission, November 19, 1982. [8208190253]
592. IE Information Notice No. 82-17, "Overpressurization of Reactor Coolant System," U.S. Nuclear Regulatory Commission, June 10, 1982. [8204210383]
593. SECY-84-76, "Proposed Rulemaking for Operator Licensing and for Training and Qualifications of Civilian Nuclear Power Plant Personnel," February 13, 1984. [8403260357]
594. Letter to E. Wilkinson (INPO) from W. Dircks (NRC), November 23, 1983. [8312090099]
595. SECY-83-52A, "Final Rulemaking Concerning Licensed Operator Staffing at Nuclear Power Units and Draft Policy Statement on Shift Crew Qualifications," March 14, 1983. [8304010029]
596. Memorandum for W. Dircks from S. Chilk, "Staff Requirements - Affirmation/ Discussion and Vote, 3:35 p.m., Thursday, April 21, 1983, Commissioners' Conference Room (Open to Public Attendance)," April 28, 1983. [9705190263]
597. Federal Register Notice 48 FR 33850, "Licensee Event Report System," July 26, 1983.
598. Memorandum for W. Dircks from R. Mattson, "Closeout of TMI Action Plan Task III.D.2.5, 'Offsite Dose Calculation Manual,'" January 17, 1984. [8402020114]
599. NUREG/CR-3332, "Radiological Assessment - A Textbook on Environmental Dose Analysis," U.S. Nuclear Regulatory Commission, September 1983.
600. NUREG-0978, "Mark III LOCA-Related Hydrodynamic Load Definition," U.S. Nuclear Regulatory Commission, August 1984.
601. Memorandum for T. Coombs from H. Denton, "Revised SRP Section 6.2.1.1.C of NUREG-0800," September 10, 1984. [8409180459]
602. Memorandum for T. Speis from R. Mattson, "Status of Generic Issues 40 and 65 Assigned to DSI," December 27, 1983. [8401170445]
603. Regulatory Guide 1.45, "Reactor Coolant Pressure Boundary Leakage Detection Systems," U.S. Nuclear Regulatory Commission, May 1973. [7907100185]
604. SECY-81-641, "Electromagnetic Pulse (EMP) - Effects on Nuclear Power Plants," November 5, 1981. [8202090418, 8111250553]

605. SECY-82-157, "Status Report on the Evaluation of the Effects of Electromagnetic Pulse (EMP) on Nuclear Power Plants," April 13, 1982. [8205050108]
606. SECY-83-367, "Staff Study of Electromagnetic Pulse (EMP) Effects on Nuclear Power Plants and Discussion of Related Petitions for Rulemaking (PRM-50-32, 32A, and 32B)," September 6, 1983. [8312210152]
607. Memorandum for W. Dircks from S. Chilk, "SECY-83-367 - Staff Study of Electromagnetic Pulse (EMP) Effects on Nuclear Power Plants and Discussion of Related Petition for Rulemaking (PRM-50-32, 32A, and 32B)," November 15, 1983. [8402270019]
608. IE Information Notice No. 82-39, "Service Degradation of Thick-Walled Stainless Steel Recirculation Systems at BWR Plants," U.S. Nuclear Regulatory Commission, September 21, 1982. [8208190229]
609. IE Bulletin No. 82-03, "Stress Corrosion Cracking in Thick-Wall Large Diameter, Stainless Steel Recirculation System Piping at BWR Plants," U.S. Nuclear Regulatory Commission, October 14, 1982 [8208190238], (Rev. 1) October 28, 1982 [8208190240].
610. IE Bulletin No. 83-02, "Stress Corrosion Cracking in Large Diameter Stainless Steel Recirculation System Piping at BWR Plants," U.S. Nuclear Regulatory Commission, March 4, 1983. [8212060368]
611. NUREG-1061, "Report of the U.S. Nuclear Regulatory Commission Piping Review Committee," U.S. Nuclear Regulatory Commission, (Vol. 1) August 1984, (Vol. 2) April 1985, (Vol. 3) November 1984, (Vol. 4) December 1984, (Vol. 5) April 1985.
612. SECY-83-267, "Status Report on Observation of Pipe Cracking at BWRs," July 1, 1983. [8307250565]
613. SECY-83-267A, "Update of Status Report on Observation of Pipe Cracking at BWRs (SECY-83-267)," July 11, 1983. [8307250578]
614. SECY-83-267B, "Update of Status Report on Observation of Pipe Cracking at BWRs (SECY-83-267 and 267A)," August 8, 1983. [8308230648]
615. SECY-83-267C, "Staff Requirements for Reinspection of BWR Piping and Repair of Cracked Piping," November 7, 1983. [8311160350]
616. SECY-84-9, "Report on the Long Term Approach for Dealing with Stress Corrosion Cracking in BWR Piping," January 10, 1984. [8402230344]
617. SECY-84-9A, "Update of Status Report on BWR Pipe Cracks and Projection of Upcoming Licensee Actions," January 27, 1984. [8402230347]
618. SECY-84-166, "Update of Status Report on BWR Pipe Cracks and Projection of Upcoming Licensee Actions," April 20, 1984. [8405180011]

619. SECY-84-301, "Staff Long Range Plan for Dealing with Stress Corrosion Cracking in BWR Piping," July 30, 1984. [8408090406]
620. NRC Letter to All Licensees of Operating Reactors, Applicants for Operating License, and Holders of Construction Permits for Boiling Water Reactors, "Inspections of BWR Stainless Steel Piping," (Generic Letter 84-11), April 19, 1984. [8404230029]
621. NUREG-0992, "Report of the Committee to Review Safeguards Requirements at Power Reactors," U.S. Nuclear Regulatory Commission, May 1983.
622. Memorandum for T. Speis from R. Mattson, "Fuel Crumbling During LOCA," February 2, 1983. [8302170511]
623. Memorandum for H. Denton from D. Eisenhut, "Potential Safety Problems Associated with Locked Doors and Barriers in Nuclear Power Plants," December 22, 1983. [8401130140]
624. Memorandum for D. Eisenhut from H. Denton, "Safety-Safeguards Interface," January 16, 1984. [8402010286]
625. Memorandum for H. Thompson from D. Eisenhut, "Potential Safety Problems Associated with Locked Doors and Barriers in Nuclear Power Plants," January 30, 1984. [8402140525]
626. Memorandum for T. Speis from H. Thompson, "Submittal of Potential Generic Issue Associated with Locked Doors and Barriers," June 8, 1984. [8407060042]
627. SECY-83-311, "Proposed Insider Safeguards Rules," July 29, 1983. [8308190179]
628. IE Information Notice No. 83-36, "Impact of Security Practices on Safe Operations," U.S. Nuclear Regulatory Commission, June 9, 1983. [8305110464]
629. Memorandum for H. Thompson from D. Morrison, "Closeout of Generic Safety Issue 78, 'Monitoring of Fatigue Transient Limits for Reactor Coolant System (RCS)' and Generic Safety Issue 166, 'Adequacy of Fatigue Life of Metal Components,'" February 5, 1997. [9703050391]
630. Memorandum for W. Minners from F. Miraglia, "Proposed Generic Issue - Technical Specifications for Anticipatory Trips," February 23, 1984. [8403080271]
631. Memorandum for F. Miraglia from W. Houston, "Task Interface Agreement Task No. 83-77 (TAC 40002, PA-157)," November 29, 1983. [8401060510]
632. NUREG/CR-6117, "Neutron Spectra at Different High Flux Isotope Reactor (HFIR) Pressure Vessel Surveillance Locations," U.S. Nuclear Regulatory Commission, December 1993.
633. Memorandum for P. Check from H. Richings, "Some Notes on PWR (W) Power Distribution Probabilities for LOCA Probabilistic Analyses," July 5, 1977.
634. NUREG-0630, "Cladding Swelling and Rupture Models for LOCA Analysis," U.S. Nuclear Regulatory Commission, April 1980.

635. Memorandum for G. Holahan and W. Minners from R. Mattson, "Disposition of AEOD Engineering and Technical Evaluation Reports," April 10, 1984. [9705190219]
636. Memorandum for R. DeYoung and H. Denton from C. Heltemes, "Vapor Binding of Auxiliary Feedwater Pumps," November 21, 1983. [8312070028]
637. AEOD/C404, "Steam Binding of Auxiliary Feedwater Pumps," Office for Analysis and Evaluation of Operational Data, U.S. Nuclear Regulatory Commission, July 1984. [8408060083]
638. Memorandum for H. Denton from C. Michelson, "Tie Breaker Between Redundant Class 1E Buses - Point Beach Nuclear Plant, Units 1 and 2," August 27, 1980. [8009150214, 8009160668]
639. Letter to J. Keppler (NRC) from C. Fay (Wisconsin Electric Power Company), "Docket No. 50-301, Point Beach Nuclear Plant Unit 2 Licensee Event Report No. 80-005/03L-0," June 27, 1980. [8007080381]
640. Memorandum for H. Denton from C. Heltemes, "Special Study Report - Human Error in Events Involving Wrong Unit or Wrong Train," January 13, 1984. [8401310079]
641. IE Information Notice No. 84-51, "Independent Verification," U.S. Nuclear Regulatory Commission, June 26, 1984. [8406250214]
642. IE Information Notice No. 84-58, "Inadvertent Defeat of Safety Function Caused by Human Error Involving Wrong Unit, Wrong Train, or Wrong System," U.S. Nuclear Regulatory Commission, July 25, 1984. [8407230079]
643. Memorandum for H. Denton from C. Heltemes, "Human Error in Events Involving Wrong Unit or Wrong Train," August 8, 1984. [9705190238]
644. Memorandum for D. Eisenhut, et al., from H. Thompson, "Maintenance and Surveillance Program Implementation Plan," July 7, 1984. [8407160259]
645. Memorandum for C. Heltemes from H. Denton, "Special Study Report - Human Errors in Events Involving Wrong Unit or Wrong Train," May 2, 1984. [8405170027]
646. Memorandum for C. Heltemes from H. Denton, "Human Error in Events Involving Wrong Unit or Wrong Train," September 17, 1984. [8410040282]
647. Memorandum for T. Speis from H. Denton, "Resolution of Generic Issue B-26, 'Structural Integrity of Containment Penetrations,'" September 27, 1984. [8410120090]
648. Memorandum for T. Speis from H. Denton, "Closeout of Generic Issue B-54, 'Ice Condenser Containments,'" October 22, 1984. [8411050142]
649. NUREG/CR-3716, "CONTEMPT 4/MOD 4," U.S. Nuclear Regulatory Commission, March 1984.

650. NUREG/CR-4001, "CONTEMPT 4/MOD 5," U.S. Nuclear Regulatory Commission, September 1984.
651. NUREG-0985, "U.S. Nuclear Regulatory Commission Human Factors Program Plan," U.S. Nuclear Regulatory Commission, August 1983, (Rev. 1) September 1984, (Rev. 2) April 1986.
652. Memorandum for W. Dircks from R. DeYoung, "Elimination of Duplicative Tracking Requirements for Revision of Regulatory Guide 1.33," July 26, 1984. [9705190264]
653. NUREG/CR-3123, "Criteria for Safety-Related Nuclear Power Plant Operator Actions: 1982 Pressurized Water Reactor (PWR) Simulator Exercises," U.S. Nuclear Regulatory Commission, June 1983.
654. Memorandum for W. Dircks from H. Thompson, "Closeout of TMI Action Plan Task I.G.2, 'Scope of Test Program,'" October 5, 1984. [8410160524]
655. Memorandum for W. Dircks from H. Denton, "Generic Issue II.A.1, 'Siting Policy Reformulation,'" September 17, 1984. [8410090175]
656. Memorandum for W. Dircks from H. Denton, "Closeout of TMI Action Plan Task II.E.5.2, Transient Response of B&W Designed Reactors," September 28, 1984. [8410110596]
657. Memorandum for D. Crutchfield from D. Eisenhut, "TMI Action Plan Task II.E.5.2," November 6, 1984. [8411270129]
658. NUREG-1054, "Simplified Analysis for Liquid Pathway Studies," U.S. Nuclear Regulatory Commission, August 1984.
659. Memorandum for H. Denton from R. Vollmer, "ESRP 7.1.1 'Environmental Impacts of Postulated Accidents Involving Radioactive Materials - Releases to Groundwater,'" September 25, 1984. [8410100758]
660. Memorandum for W. Dircks from H. Denton, "Generic Issue III.D.2.3 'Liquid Pathway Radiological Control,'" October 29, 1984. [8411190057]
661. Memorandum for H. Denton from C. Heltemes, "Failures of Class 1E Safety-Related Switchgear Circuit Breakers to Close on Demand," April 29, 1983. [8305230511]
662. Memorandum for C. Heltemes from H. Denton, "AEOD April 1983 Report on Failures of Class 1E Safety-Related Switch Gear Circuit Breakers to Close on Demand," June 17, 1983. [8306280125]
663. IE Information Notice No. 83-50, "Failures of Class 1E Safety-Related Switchgear Circuit Breakers to Close on Demand," August 1, 1983. [8306270418]
664. Memorandum for D. Eisenhut from R. Spessard, "Unmonitored Failures of Class 1E Safety-Related Switchgear Circuit Breakers and Power Supplies (AITS-F03052383)," June 1, 1984. [8408230490]

665. NUREG/CR-2989, "Reliability of Emergency AC Power System at Nuclear Power Plants," U.S. Nuclear Regulatory Commission, July 1983.
666. Memorandum for T. Speis from H. Denton, "Resolution of Generic Issue B-12: BWR Jet Pump Integrity," September 25, 1984. [8410030458]
667. Memorandum for T. Speis from H. Denton, "Resolution of Generic Issue 69: Make-up Nozzle Cracking in B&W Plants," September 27, 1984. [8410150536]
668. Memorandum for H. Denton from R. Minogue, "Comments on Generic Issue 79, 'Unanalyzed Reactor Vessel Thermal Stress During Natural Convection Cooldown,'" October 5, 1983. [8310260398]
669. Letter to P. Kadambi (NRC) from F. Miller (B&W Owners Group Analysis Committee), "Transmittal of RV Head Stress Evaluation Program Results," October 15, 1984. [8410190186]
670. Memorandum for H. Denton from R. Mattson, "Generic Issue B-60, Loose Parts Monitoring Systems for Operating Reactors (TACS 52325)," January 10, 1984. [8401180046]
671. Letter to N. Palladino from P. Shewmon, "Control Room Habitability," August 18, 1982. [8207180073]
672. Memorandum for J. Larkins from J. Murphy, "Proposed Resolution of GSI-15, 'Radiation Effects on Reactor Pressure Vessel Supports,'" June 22, 1994. [9407140032]
673. Letter to W. Dircks from J. Ebersole, "ACRS Subcommittee Report on Control Room Habitability," May 17, 1983. [8305260104]
674. Memorandum for W. Dircks from H. Denton, "Control Room Habitability," July 27, 1983. [8308180433]
675. Memorandum for H. Denton from W. Dircks, "Control Room Habitability," August 15, 1983. [8309160034]
676. Memorandum for T. Murley, et al., from H. Denton, "Control Room Habitability," September 19, 1983. [8310120463]
677. Letter to W. Milstead (NRC) from T. Powers (PNL), "A Probabilistic Examination of Nuclear Power Plant Control Room Habitability During Various Accident Scenarios," December 3, 1984. [8412050472]
678. Memorandum for W. Dircks from H. Denton, "Control Room Habitability," June 29, 1984. [8407100196]
679. Memorandum for T. Speis from R. Bernero, "Revised Schedule for Generic Issue 83, Control Room Habitability," September 28, 1984. [8410110484]
680. NUREG/CR-2258, "Fire Risk Analysis for Nuclear Power Plants," U.S. Nuclear Regulatory Commission, September 1981.

681. NUREG-0844, "NRC Integrated Program for the Resolution of Unresolved Safety Issues A-3, A-4, A-5 Regarding Steam Generator Tube Integrity," U.S. Nuclear Regulatory Commission, September 1988.
682. Note to W. Kane from G. Holahan, "Background Information Relating to the Assessment of the Offsite Consequences of Non-Core Melt, Steam Generator Tube Rupture Events," October 24, 1983. [9705190255]
683. Memorandum for W. Johnston from R. Ballard, "Disputed Procedures for Estimating Probable Maximum Precipitation," January 13, 1984. [8401260466]
684. Hydrometeorological Report No. 52, "Application of Probable Maximum Precipitation Estimates - United States East of the 105th Meridian," U.S. Department of Commerce, National Oceanic and Atmospheric Administration, August 1982.
685. Hydrometeorological Report No. 51, "Probable Maximum Precipitation Estimates, United States East of the 105th Meridian," U.S. Department of Commerce, National Oceanic and Atmospheric Administration, June 1978.
686. Hydrometeorological Report No. 33, "Seasonal Variation of the Probable Maximum Precipitation East of the 105th Meridian for Areas from 10 to 1,000 Square Miles and Durations of 6, 12, 24 and 48 Hours," U.S. Department of Commerce, April 1956.
687. Regulatory Guide 1.59, "Design Basis Floods for Nuclear Power Plants," U.S. Nuclear Regulatory Commission, (Rev. 2) August 1977. [7907100225]
688. Regulatory Guide 1.102, "Flood Protection for Nuclear Power Plants," U.S. Nuclear Regulatory Commission, (Rev. 1) September 1976. [7907100372]
689. Memorandum for V. Stello from H. Denton, "Potential Generic Requirement Concerning Design for Probable Maximum Precipitation," June 25, 1984. [8407100105]
690. Memorandum for V. Stello from H. Denton, "Generic Requirements Regarding Design for Probable Maximum Precipitation," October 10, 1984. [8503140522, 8410190029]
691. Memorandum for H. Denton from V. Stello, "Generic Requirements Regarding Design for Probable Maximum Precipitation," August 8, 1984. [8408160442]
692. Memorandum for T. Speis from H. Denton, "Generic Issue A-41; 'Long Term Seismic Program,'" October 10, 1984. [9705200066]
693. Memorandum for H. Denton from R. Bernero, "Resolution of Generic Issue No. 22, Inadvertent Boron Dilution Events (BDES)," September 17, 1984. [8410020424]
694. Memorandum for T. Speis from H. Denton, "Closeout of Generic Issue No. 22, 'Inadvertent Boron Dilution Events (BDE),' " October 15, 1984. [8410310592]
695. Memorandum for T. Speis from H. Denton, "Closeout of Generic Issue 50, 'Reactor Vessel Level Instrumentation in BWRs,'" October 17, 1984. [8411030745]

696. NRC Letter to All Boiling Water Reactor (BWR) Licensees of Operating Reactors (Except LaCrosse, Big Rock Point, Humboldt Bay and Dresden-1), "Reactor Vessel Water Level Instrumentation in BWRs (Generic Letter No. 84-23," October 26, 1984. [8410290050]
697. Memorandum for D. Eisenhut from R. Bernero, "Resolution of Generic Issue 50, Reactor Vessel Level Instrumentation in BWRs," September 6, 1984. [8410010093]
698. NUREG-0927, "Evaluation of Water Hammer Occurrence in Nuclear Power Plants," U.S. Nuclear Regulatory Commission, (Rev. 1) March 1984.
699. NUREG-0609, "Asymmetric Blowdown Loads on PWR Primary Systems," U.S. Nuclear Regulatory Commission, January 1981.
700. NRC Letter to All Operating PWR Licenses, Construction Permit Holders, and Applicants for Construction Permits, "Safety Evaluation of Westinghouse Topical Reports Dealing with Elimination of Postulated Pipe Breaks in PWR Primary Main Loops (Generic Letter 84-04)," February 1, 1984. [8402010410]
701. NUREG-0408, "Mark I Containment Short-Term Program Safety Evaluation Report," U.S. Nuclear Regulatory Commission, December 1977.
702. NUREG-0661, "Mark I Containment Long Term Program Safety Evaluation Report, Resolution of Generic Technical Activity A-7," U.S. Nuclear Regulatory Commission, July 1980, (Supplement 1) August 1982.
703. NUREG-0808, "Mark II Containment Program Evaluation and Acceptance Criteria," U.S. Nuclear Regulatory Commission, August 1981.
704. NUREG-0460, "Anticipated Transients Without Scram for Light Water Reactors," U.S. Nuclear Regulatory Commission, (Vol. 1) April 1978, (Vol. 2) April 1978, (Vol. 3) December 1978, (Vol. 4) March 1980.
705. Memorandum for C. Thomas from O. Parr, "CRD Accumulators - Proposed Improved Technical Specification," August 13, 1984. [8408270516]
706. NUREG-0123, "Standard Technical Specifications for General Electric Boiling Water Reactors (BWR/5)," U.S. Nuclear Regulatory Commission, (Rev. 3) December 1980.
707. Memorandum for H. Denton, et. al., from C. Michelson, "Survey of Valve Operator-Related Events Occurring During 1978, 1979, and 1980," December 23, 1981. [8202040039]
708. Memorandum for C. Michelson from H. Denton, "NRR Comments on AEOD Draft Report: Survey of Valve Operator-Related Events Occurring During 1978, 1979 and 1980," March 5, 1982. [8203240048]
709. AEOD/C203, "Survey of Valve Operator-Related Events Occurring During 1978, 1979, and 1980," Office for Analysis and Evaluation of Operational Data, U.S. Nuclear Regulatory Commission, May 1982. [8206180032]

710. Memorandum for C. Michelson from E. Brown and F. Ashe, "AEOD Assessment of Program Office Responses to the Report AEOD/C203, 'Survey of Valve Operator-Related Events Occurring During 1978, 1979, and 1980,'" December 23, 1982. [8301250189, 8301120496]
711. Memorandum for H. Denton from C. Michelson, "AEOD Assessment of Program Office Responses to AEOD Case Study (C-203), 'Survey of Valve Operator Related Events Occurring During 1973, 1979, and 1980,'" January 12, 1983. [8301250183]
712. Memorandum for C. Michelson from H. Denton, "AEOD Assessment of Program Office Responses to AEOD Case Study (C203), 'Survey of Valve Operator Related Events Occurring During 1978, 1979, and 1980,'" February 23, 1983. [8303100567]
713. Memorandum for K. Seyfrit from E. Brown and F. Ashe, "Engineering Evaluation Report AEOD/E305 Inoperable Motor Operated Valve Assemblies Due to Premature Degradation of Motors and/or Improper Limit Switch/Torque Switch Adjustment," April 13, 1983. [8305050353]
714. Memorandum for W. Minners from R. Bosnak, "Status of Potential Generic Issue 54, 'Valve Operator Related Events Occurring During 1978, 1979, and 1980,'" March 26, 1984. [8404110417]
715. Memorandum for R. Vollmer from R. Bosnak, "MEB Task Action Plan for Resolution of Generic Issue II.E.6.1, 'In Situ Testing of Valves,'" July 30, 1984. [8408070139]
716. Memorandum for D. Eisenhut from D. Muller, "PWR Reactor Cavity Uncontrolled Exposures, Generic Letter Implementing a Generic Technical Specification," July 12, 1984. [8407230356]
717. Memorandum for A. Thadani from W. Minners, "CRAC2 Computer Runs in Support of USI A-43," February 1, 1983. [8302090275]
718. Memorandum for W. Minners from F. Congel, "Prioritization of Generic Issue 97: PWR Reactor Cavity Uncontrolled Exposures," February 8, 1985. [8502250136]
719. Memorandum for H. Denton from R. Bernero, "PWR Reactor Cavity Uncontrolled Exposures," November 28, 1984. [8412180620]
720. Memorandum for T. Speis from R. Bernero, "Request for Prioritization of Generic Safety Issue - Break Plus Single Failure in BWR Water Level Instrumentation," October 10, 1984. [8410290282]
721. Memorandum for H. Denton and V. Stello from C. Michelson, "Case Study Report - Safety Concern Associated with Reactor Vessel Instrumentation in Boiling Water Reactors," September 2, 1981. [8109220940]
722. Memorandum for B. Sheron from A. Thadani, "Reactor Vessel Level Instrumentation in BWR's (Generic Issue 50)," August 2, 1984. [8408090089]

723. Memorandum for H. Denton from T. Speis, "Reactor Vessel Level Instrumentation in BWRs (Generic Issue 50)," August 2, 1984. [8408090386, 8408090094]
724. Memorandum for W. Dircks, et al., from S. Chilk, "Staff Requirements - Affirmation/Discussion and Vote, 11:30 a.m., Friday, June 1, 1984, Commissioners' Conference Room, D.C. Office (Open to Public Attendance)," June 1, 1984.
725. Federal Register Notice 49 FR 26036, "10 CFR Part 50, Reduction of Risk from Anticipated Transients Without Scram (ATWS) Events for Light-Water-Cooled Nuclear Power Plants," June 26, 1984.
726. NEDO-21506, "Stability and Dynamic Performance of the General Electric Boiling Water Reactor," General Electric Company, January 1977.
727. Memorandum for D. Crutchfield from L. Rubenstein, "Staff Evaluation of GE Topical Report NEDE-24011 (GESTAR) Amendment 8," April 17, 1985. [8504290470]
728. XN-NF-691(P)(A) & Supplement 1, "Stability Evaluation of Boiling Water Reactor Cores Sensitivity Analyses & Benchmark Analysis," Exxon Nuclear Company, Inc., August 22, 1984.
729. Memorandum for D. Eisenhut from R. Mattson, "Board Notification - BWR Core Thermal Hydraulic Stability," February 27, 1984. [8403020299]
730. Memorandum for T. Novak from L. Rubenstein, "Susquehanna 1 and 2 - Thermal Hydraulic Stability Technical Specification Change (TACS 55021 and 55022)," July 11, 1984. [8407170149]
731. Memorandum for G. Lainas from L. Rubenstein, "SER Input for Peach Bottom-3 Technical Specification Changes for Cycle 6 Operation with Increased Core Flows and Decreased Feedwater Temperatures (TACS #55123)," October 23, 1984. [8411010312]
732. NEDO-21078, "Test Results Employed by GE for BWR Containment and Vertical Vent Loads," General Electric Company, October 1975.
733. NUREG-0487, "Mark II Containment Lead Plant Program Load Evaluation and Acceptance Criteria," U.S. Nuclear Regulatory Commission, November 1978, (Supplement 1) September 1980.
734. NUREG-0783, "Suppression Pool Temperature Limits for BWR Containments," U.S. Nuclear Regulatory Commission, November 1981.
735. Letter to T. Novak (NRC) from T. Pickens (BWR Owners' Group), "Agreements from BWROG/NRC Meeting on Suppression Pool Temperature Limit," October 16, 1984. [8410220072]
736. Memorandum for T. Speis from R. Bernero, "Proposed Generic Issue 'BWR Suppression Pool Temperature Limits,'" November 21, 1984. [8412030526]

737. Memorandum for W. Minners from W. Butler, "Comments on Prioritization of Generic Issue 108, 'BWR Suppression Pool Temperature Limits,'" January 10, 1985. [8501160095]
738. NUREG-1044, "Evaluation of the Need for a Rapid Depressurization Capability for CE Plant," U.S. Nuclear Regulatory Commission, December 1984.
739. SECY-84-134, "Power Operated Relief Valves for Combustion Engineering Plants," March 23, 1984. [8404180339]
740. "Draft Maintenance Program Plan," U.S. Nuclear Regulatory Commission, May 8, 1984.
741. NUREG/CR-3543, "Survey of Operating Experience from LERs to Identify Aging Trend," U.S. Nuclear Regulatory Commission, January 1984.
742. NUREG-0619, "BWR Feedwater Nozzle and Control Rod Drive Return Line Nozzle Cracking," U.S. Nuclear Regulatory Commission, November 1980.
743. NUREG-0744, "Resolution of the Task A-11 Reactor Vessel Materials Toughness Safety Issue," U.S. Nuclear Regulatory Commission, (Rev. 1) October 1982.
744. NRC Letter to All Power Reactor Licensees (Except Ft. St. Vrain), "NUREG-0744 Rev. 1; Generic Letter No. 82-26) - Pressure Vessel Material Fracture Toughness," November 12, 1982. [8211160047]
745. EPRI NP-3967, "Classification and Analysis of Reactor Operating Experience Involving Dependent Events," Electric Power Research Institute, June 1985.
746. NUREG-0224, "Final Report on Reactor Vessel Pressure Transient Protection for Pressurized Water Reactors," U.S. Nuclear Regulatory Commission, September 1978.
747. NUREG-0612, "Control of Heavy Loads at Nuclear Power Plants Resolution of Generic Technical Activity A-36," U.S. Nuclear Regulatory Commission, July 1980.
748. NUREG-0763, "Guidelines for Confirmatory Inplant Tests of Safety Relief Valve Discharges for BWR Plants," U.S. Nuclear Regulatory Commission, May 1981.
749. NUREG-0802, "Safety/Relief Valve Quencher Loads: Evaluation for BWR Mark II and III Containments," U.S. Nuclear Regulatory Commission, October 1982.
750. NUREG-0313, "Technical Report on Material Selection and Processing Guidelines for BWR Coolant Pressure Boundary Piping," U.S. Nuclear Regulatory Commission, July 1977, (Rev. 1) July 1980, (Rev. 2) January 1988.
751. WASH-1270, "Anticipated Transients Without Scram for Water-Cooled Reactors," U.S. Atomic Energy Commission, September 1973.
752. Memorandum for S. Hanauer from D. Eisenhut, "Value/Impact Assessment of Proposed Steam Generator Generic Requirements," October 12, 1982. [8211110465]

753. SECY-84-13, "NRC Integrated Program for the Resolution of Steam Generator USI's," January 11, 1984. [8401310036]
754. NUREG-0916, "Safety Evaluation Report Related to Restart of R.E. Ginna Nuclear Power Plant," U.S. Nuclear Regulatory Commission, May 1982.
755. NUREG-0651, "Evaluation of Steam Generator Tube Rupture Events," U.S. Nuclear Regulatory Commission, March 1980.
756. Memorandum for D. Eisenhut from T. Speis, "Prioritization of Staff Actions Concerning S.G. Tube Degradation and Rupture Events," February 23, 1983. [8303090047]
757. SECY-84-13A, "NRC Integrated Program for the Resolution of Steam Generator USIs," September 7, 1984. [8409140060]
758. SECY-84-13B, "NRC Integrated Program for the Resolution of Steam Generator USI's - Response to Commissioner Comments (Memo from Chilk to Dircks dated September 13, 1984)," November 5, 1984. [8411210357]
759. AEOD/C005, "AEOD Observations and Recommendations Concerning the Problem of Steam Generator Overfill and Combined Primary and Secondary Blowdown," Office for Analysis and Evaluation of Operational Data, U.S. Nuclear Regulatory Commission, December 17, 1980. [8101150366]
760. NUREG/CR-2883, "Study of the Value and Impact of Alternative Decay Heat Removal Concepts for Light Water Reactors," U.S. Nuclear Regulatory Commission, (Vol. 1) June 1983, (Vol. 2) June 1983, (Vol. 3) June 1983.
761. AEOD/E414, "Stuck Open Isolation Check Valve on the Residual Heat Removal System at Hatch Unit 2," Office for Analysis and Evaluation of Operational Data, U.S. Nuclear Regulatory Commission, May 31, 1984. [8406190101]
762. Memorandum for W. Minners from G. Holahan, "Prioritization of Interfacing System LOCA at Boiling Water Reactors," October 25, 1984. [8411050292]
763. NUREG-0677, "The Probability of Intersystem LOCA: Impact Due to Leak Testing and Operational Changes," U.S. Nuclear Regulatory Commission, May 1980.
764. SECY-85-129, "Maintenance and Surveillance Program Plan," April 12, 1985. [8509190696]
765. SECY-85-62, "NRC Integrated Program for the Resolution of Steam Generator USI's - Response to Commissioner Comments (Memo from Chilk to Dircks Dated January 23, 1985)," February 22, 1985. [8504080388]
766. Memorandum for W. Dircks from S. Chilk, "SECY-85-62 - NRC Integrated Program for the Resolution of Steam Generator USIs - Response to Commissioners Comments (Memo from Chilk and Dircks Dated January 23, 1985)," March 15, 1985.

767. Memorandum for W. Dircks from H. Denton, "Final Rule - Applicability of License Conditions and Technical Specifications in an Emergency," February 17, 1983. [8303300333]
768. Memorandum for T. Speis from H. Denton, "Formation of a Technical Specification Improvement Project Group," December 31, 1984. [8501150417]
769. Memorandum for V. Stello from H. Denton, "Close Out Generic Issue #B-19 -Thermal-Hydraulic Stability," May 21, 1985. [8506040556]
770. Letter from P. Crane (Pacific Gas and Electric Company) to Director, Division of Licensing, U.S. Nuclear Regulatory Commission, "Report on June 7, 1975 Ferndale Earthquake," August 4, 1975. [8602070315, 993280104, ML993280111]
771. Memorandum for W. Minners from L. Reiter, "Generic Issue No. B-50 Post Operating Basis Earthquake Inspection," June 7, 1985.
772. Letter to A. Schwencer (NRC) from C. Dunn (Duquesne Light Company), "Beaver Valley Power Station, Unit No. 1, Docket No. 50-334, Request for Amendment to the Operating License - No. 35," October 27, 1978. [7811030107]
773. Letter to J. Carey (Duquesne Light Company) from S. Varga (NRC), "Beaver Valley Unit No. 1 - Operation With Two Out of Three Reactor Coolant Loops - Safety Evaluation," July 20, 1984. [8408010218]
774. Memorandum for D. Eisenhut from D. Wigginton, "Closeout of MPA E-05; Westinghouse N-1 Loop Operation," January 11, 1985. [8501300565]
775. Memorandum for R. Emrit from A. Murphy, "Generic Issue Management Control System, Issue No. 119.3, Decouple OBE from SSE," February 21, 1992. [9803260147]
776. Memorandum for R. Bernero from D. Eisenhut, "BWR Thermal-Hydraulic Stability Technical Specifications," November 16, 1984. [8411290326]
777. Memorandum for W. Dircks from H. Denton, "Closeout of TMI Action Plan Items I.A.2.2 and I.A.2.7 Training and Qualifications of Operating Personnel," June 24, 1985. [8507020587]
778. Memorandum for W. Dircks from H. Denton, "TMI Action Item I.A.3.4," February 12, 1985. [8502260084]
779. Memorandum for W. Dircks from J. Taylor, "TMI Action Plan - Completed Item," June 26, 1985. [8507080034]
780. IE Information Notice No. 83-58, "Transamerica DeLaval Diesel Generator Crankshaft Failure," U.S. Nuclear Regulatory Commission, August 30, 1983. [8308040044]
781. IE Information Notice No. 83-51, "Diesel Generator Events," U.S. Nuclear Regulatory Commission, August 5, 1983. [8306270425]

782. Memorandum for C. Berlinger from H. Denton, "Detail Assignment to DOL, Transamerica DeLaval Emergency Diesel Generator Project Group (TDI Project Group)," January 25, 1984. [8505130221]
783. SECY-84-34, "Emergency Diesel Generators Manufactured by Transamerica DeLaval, Inc.," January 25, 1984. [8403010451]
784. Letter to D. Bixby (TDI) from D. Eisenhut (NRC), February 14, 1984. [8402290333]
785. TDI Diesel Generators Owners' Group Program Plan, March 2, 1984.
786. SECY-84-155, "Section 208 Report to the Congress on Abnormal Occurrences for October-December, 1983," April 11, 1984. [8405140043]
787. Letter to J. George (Transamerica Delaval, Inc., Owners' Group) from D. Eisenhut (NRC), "Safety Evaluation Report, Transamerica Delaval, Inc. Diesel Generator Owners' Group Program Plan," August 13, 1984. [8408240115]
788. Memorandum for W. Minners from B. Sheron, "Additional Low-Temperature-Overpressure Protection Issues for Light-Water Reactors," August 1, 1984. [8408130012]
789. IE Information Notice No. 83-26, "Failure of Safety/Relief Valve Discharge Line Vacuum Breakers," U.S. Nuclear Regulatory Commission, May 3, 1983. [8303040028]
790. NUREG/CR-3384, "VISA - A Computer Code for Predicting the Probability of Reactor Pressure Vessel Failure," U.S. Nuclear Regulatory Commission, September 1983.
791. Memorandum for K. Seyfrit from C. Hsu, "EE No. AEOD/E322 Damage to Vacuum Breaker Valves as a Result of Relief Valve Lifting," September 21, 1983. [8310060353]
792. AEOD/C401, "Low Temperature Overpressure Events at Turkey Point Unit 4," Office for Analysis and Evaluation of Operational Data, U.S. Nuclear Regulatory Commission, March 1984. [8404050445]
793. Memorandum for B. Sheron from B. Liaw, "Additional Low-Temperature-Overpressure Protection (LTOP) Issues for Light-Water Reactors," August 30, 1984. [8409130397]
794. Memorandum for K. Seyfrit from E. Imbro, "Single Failure Vulnerability of Power Operated Relief Valve Actuation Circuitry for Low Temperature Overpressure Protection (LTOP)," October 24, 1984. [8411070245]
795. AEOD/C403, "Edwin I. Hatch Unit No. 2 Plant Systems Interaction Event on August 25, 1982," Office for Analysis and Evaluation of Operational Data, U.S. Nuclear Regulatory Commission, May 1984. [8405300746]
796. Memorandum for R. Mattson from T. Dunning, "RHR Interlocks for Westinghouse Plants," April 17, 1984. [8404300085]
797. Memorandum for F. Rowsome from W. Houston, "RCS/RHR Suction Line Valve Interlock on PWRs," August 27, 1984. [8409070331]

798. NSAC-52, "Residual Heat Removal Experience Review and Safety Analysis, Pressurized Water Reactor," Nuclear Safety Analysis Center, January 1983.
799. Memorandum for W. Dircks from H. Denton, "Resolution of Generic Issue III.D.2.3 -- Liquid Pathway Studies," August 28, 1985. [8509050212]
800. NUREG/CR-4258, "An Approach to Team Skills Training of Nuclear Power Plant Control Room Crews," U.S. Nuclear Regulatory Commission, July 1985.
801. Memorandum for W. Dircks from H. Denton, "Team Training for Nuclear Power Plant Control Room Crews," July 10, 1985. [8507220495]
802. NUREG/CR-3739, "The Operator Feedback Workshop: A Technique for Obtaining Feedback from Operations Personnel," U.S. Nuclear Regulatory Commission, September 1984.
803. NUREG/CR-4139, "The Mailed Survey: A Technique for Obtaining Feedback from Operations Personnel," U.S. Nuclear Regulatory Commission, May 1985.
804. Memorandum for W. Dircks from H. Denton, "TMI Action Plan Item I.A.2.6(4)," September 25, 1985. [8510030079]
805. Memorandum for T. Combs from H. Denton, "Revised SRP Section 13.5.2 and Appendix A to SRP Section 13.5.2 of NUREG-0800," July 17, 1985. [8508050283]
806. Memorandum for W. Dircks from H. Denton, "Closeout of TMI Action Plan, Task II.B.6, 'Risk Reduction for Operating Reactors at Sites With High Population Densities,'" September 25, 1985. [8510030342]
807. Memorandum for W. Dircks from R. Minogue, "Closeout of TMI Action Plan Task II.B.8 'Rulemaking Proceeding on Degraded Core Accidents - Hydrogen Control,'" July 19, 1985. [8508010066]
808. Memorandum for W. Dircks from H. Denton, "Close Out of TMI Action Plan, Task II.B.8," August 12, 1985. [8508210316]
809. NUREG-1070, "NRC Policy on Future Reactor Designs," U.S. Nuclear Regulatory Commission, July 1985.
810. NUREG/CR-3085, "Interim Reliability Evaluation Program: Analysis of the Millstone Point Unit 1 Nuclear Power Plant," U.S. Nuclear Regulatory Commission, (Vol. 1) April 1983, (Vol. 2) August 1983, (Vol. 3) July 1983, (Vol. 4) July 1983.
811. NUREG/CR-3511, "Interim Reliability Evaluation Program: Analysis of the Calvert Cliffs Unit 1 Nuclear Power Plant," U.S. Nuclear Regulatory Commission, (Vol. 1) May 1984, (Vol. 2) October 1984.
812. NUREG/CR-2728, "Interim Reliability Evaluation Program Procedures Guide," U.S. Nuclear Regulatory Commission, March 1983.

813. Memorandum for W. Dircks from R. Minogue, "Closeout of TMI Action Plan, Task II.C.1, 'Interim Reliability Evaluation Program,'" July 9, 1985. [8507180593]
814. SECY-84-133, "Integrated Safety Assessment Program (ISAP)," March 23, 1984. [8404100072]
815. SECY-85-160, "Integrated Safety Assessment Program - Implementation Plan," May 6, 1985. [8505230571]
816. Memorandum for W. Dircks from H. Denton, "Close-out of Generic Issues II.C.2, 'Continuation of IREP,' and IV.E.5, 'Assess Currently Operating Reactors,'" September 25, 1985. [9909290069]
817. Memorandum for W. Dircks from R. Minogue, "Closeout of TMI Action Plan Task II.E.2.2, 'Research on Small Break LOCA's and Anomalous Transients,'" July 25, 1985. [9909290072]
818. Memorandum for W. Dircks from J. Taylor, "TMI Action Plan - Completed Item," August 15, 1985. [8508200726]
819. EPRI EL-3209, "Workshop Proceedings: Retaining Rings for Electric Generators," Electric Power Research Institute, August 1983.
820. Memorandum for R. Fraley from R. Vollmer, "Proposed NRR Revisions to Review Procedures for Turbine Missile Issue," May 12, 1983. [8305250286]
821. Memorandum for W. Johnson from T. Novak, "Midland SSER #3 - Turbine Missile Review," November 1, 1983. [8311140470]
822. Memorandum for V. Stello from H. Denton, "NRR Plans for Approval of WCAP-10271," January 11, 1985. [8501220433, 8501220440]
823. Letter to J. Sheppard (Westinghouse Owners Group) from C. Thomas (NRC), "Acceptance for Referencing of Licensing Topical Report WCAP-10271, 'Evaluation of Surveillance Frequencies and Out of Service Times for the Reactor Protection Instrumentation Systems,'" February 21, 1985. [8503010427]
824. Memorandum for T. Speis from R. Mattson, "Request for Prioritization of Generic Safety Issue - Failure of HPCI Steam Line Without Isolation," October 18, 1983. [8311020209]
825. Memorandum for K. Seyfrit from P. Lam, "Failure of an Isolation Valve of the Reactor Core Isolation Cooling System to Open Against Operating Reactor Pressure," August 23, 1984. [8411010554, 8411010453]
826. Letter to A. Schwencer (NRC) from J. Kemper (Philadelphia Electric Company), "Limerick Generating Station, Units 1 & 2, Request for Additional Information from NRC Equipment Qualification Branch (EQB)," February 27, 1984. [9909290076]

827. NEDO-24708A, "Additional Information Required for NRC Staff Generic Report on Boiling Water Reactors," General Electric Company, August 1979 [7909130302, 7909130304], December 1980.
828. NUREG/CR-3933, "Risk Related Reliability Requirements for BWR Safety-Important Systems with Emphasis on the Residual Heat Removal System," U.S. Nuclear Regulatory Commission, August 1984.
829. "An Evaluation of Unisolated LOCA Outside the Drywell in the Shoreham Nuclear Power Station," Brookhaven National Laboratory, June 1985. [9909290080]
830. Memorandum for W. Minners from A. Thadani, "Comments on Generic Issue No. 87 - Failure of HPCI Steam Line Without Isolation," June 28, 1985. [8507170422]
831. NUREG/CR-1433, "Examination of the Use of Potassium Iodide (KI) as an Emergency Protective Measure for Nuclear Reactor Accidents," U.S. Nuclear Regulatory Commission, October 1980.
832. SECY-83-362, "Emergency Planning - Predistribution/Stockpiling of Potassium Iodide for the General Public," August 30, 1983. [8309080120]
833. SECY-85-167, "Federal Policy Statement on the Distribution and Use of Potassium Iodide," May 13, 1985. [8505310621]
834. Memorandum for H. Denton and R. Minogue from W. Dircks, "Review of NRC Requirements for Nuclear Power Plant Piping," August 1, 1983. [8308300212]
835. Memorandum for W. Dircks from R. Minogue, "Plan to Implement Piping Review Committee Recommendations," July 30, 1985. [9705050005]
836. Memorandum for T. Murley, et al., from J. Taylor, "Results of Regional Survey of Plant Specific Information Relating to the Potential for Uncontrolled Radiation Exposures in PWR Reactor Cavities," June 18, 1985. [8506250113]
837. Note to R. Vollmer from T. Speis, "Proposed Request to Perform Research on the Stress Corrosion Cracking of Pressure Boundary Ferritic Steels in Selected Environments," January 7, 1985. [9909290082]
838. NUREG-1165, "Environmental Standard Review Plan for ES Section 7.1.1," U.S. Nuclear Regulatory Commission, November 1985.
839. Letter to J. Bayne (PASNY) from S. Varga (NRC), "Steam Generator Tube and Girth Weld Repairs at the Indian Point Nuclear Generating Plant, Unit No. 3 (IP-3)," May 27, 1983. [8306150627]
840. "Value-Impact Analysis of Recommendations Concerning Steam Generator Tube Degradations and Rupture Events," Science Applications, Inc., February 2, 1983.

841. Regulatory Guide 1.99, "Effects of Residual Elements on Predicted Radiation Damage to Reactor Vessel Materials," U.S. Nuclear Regulatory Commission, July 1975, (Rev. 1) April 1977 [7907100362], (Rev. 2) May 1988 [8907270187].
842. IE Information Notice No. 82-37, "Cracking in the Upper Shell to Transition Cone Girth Weld of a Steam Generator at an Operating Pressurized Water Reactor," U.S. Nuclear Regulatory Commission, September 16, 1982. [8208190220]
843. Letter to D. Smith (NRC) from E. Rahe (Westinghouse), January 17, 1982. [9909290085]
844. NUREG/CR-3281, "Investigation of Shell Cracking on the Steam Generators at Indian Point Unit No. 3," U.S. Nuclear Regulatory Commission, June 1983.
845. NUREG/CR-3614, "Constant Extension Rate Testing of SA302 Grade B Material in Neutral and Chloride Solutions," U.S. Nuclear Regulatory Commission, February 1984.
846. Letter to W. Hazelton (NRC) from H. Watanabe (GE), "Laboratory Examination of Garigliano Secondary Steam Generator-B Core Samples," NEDE-25162, July 1979," December 13, 1979. [7912130566]
847. EPRI NP-1136, "Limiting Factor Analysis of High Availability Nuclear Plants (Boiling Water Reactors)," Electric Power Research Institute, (Vol. 1) August 1979.
848. Regulatory Guide 1.56, "Maintenance of Water Purity in Boiling Water Reactors," U.S. Nuclear Regulatory Commission, (Rev. 1) July 1978.
849. NUREG/CR-3842, "Steam Generator Group Project Task 8 - Selective Tube Unplugging," U.S. Nuclear Regulator Commission, July 1984.
850. NRC Letter to All PWR Licensees of Operating Reactors, Applicants for Operating Licenses, and Holders of Construction Permits, and Ft. St. Vrain, "Staff Recommended Actions Stemming from NRC Integrated Program for the Resolution of Unresolved Safety Issues Regarding Steam Generator Tube Integrity (Generic Letter 85-02)," April 17, 1985. [8504120031]
851. NUREG/CP-0058, "Twelfth Water Reactor Safety Research Information Meeting," U.S. Nuclear Regulatory Commission, (Vol. 4) January 1985.
852. NUREG/CP-0044, "Proceedings of the International Atomic Energy Agency Specialists' Meeting on Subcritical Crack Growth," U.S. Nuclear Regulatory Commission, (Vol. 1) May 1983, (Vol. 2) May 1983.
853. "Corrosion Fatigue Crack Growth in Reactor Pressure Vessel Steels - Structural Integrity of Light Water Reactor Components," Scott, P. et al., Elsevier Science Publishing Co., Inc., 1982.
854. NUREG/CR-4121, "The Effects of Sulfur Chemistry and Flow Rate on Fatigue Crack Growth Rates in LWR Environments," U.S. Nuclear Regulatory Commission, February 1985.

855. NUREG-0975, "Compilation of Contract Research for the Materials Engineering Branch, Division of Engineering Technology," U.S. Nuclear Regulatory Commission, (Vol. 2) March 1984.
856. PNO-II-85-41, "Small Steam Generator Surface Cracks," U.S. Nuclear Regulatory Commission, April 23, 1985. [8504290412]
857. Memorandum for W. Minners from B. Liaw, "Prioritization of Generic Issue No. (111) Stress Corrosion Cracking of RCPB Ferritic Steels and Steam Generator Vessels," June 7, 1985. [8506170320]
858. IE Information Notice No. 85-65, "Crack Growth in Steam Generator Girth Welds," U.S. Nuclear Regulatory Commission, July 31, 1985. [8507290456]
859. Memorandum for H. Thompson from J. Knight, "Steam Generator Shell Transition Joint Cracking," July 10, 1985. [8507190409]
860. NUREG-0937, "Evaluation of PWR Response to Main Steamline Break With Concurrent Steam Generator Tube Rupture and Small-Break LOCA," U.S. Nuclear Regulatory Commission, December 1982. [8412190335]
861. SECY-83-357B, "Status of Hydrogen Control Issue and Rulemaking Recommendations in SECY-83-357A," December 3, 1984. [8412190335]
862. IE Bulletin No. 79-13, "Cracking in Feedwater System Piping," June 25, 1979 [7906250348], (Rev. 1) August 29, 1979 [7908220101], (Rev. 2) October 17, 1979 [7908220135].
863. Memorandum for T. Speis from H. Denton, "Closeout of Generic Issues B-58 and C-11," July 9, 1985. [8507180530]
864. AEOD/C301, "Failures of Class 1E Safety-Related Switchgear Circuit Breakers to Close on Demand," Office for Analysis and Evaluation of Operational Data, U.S. Nuclear Regulatory Commission, April 1983. [8305230531]
865. Memorandum for T. Speis from H. Denton, "Resolution of Generic Issue 14, 'PWR Pipe Cracks,'" October 4, 1985. [9909290092]
866. Federal Register Notice 47 FR 7023, "Proposed Policy Statement on Safety Goals for Nuclear Power Plants," February 17, 1982.
867. Federal Register Notice 48 FR 10772, "Safety Goal Development Program," March 14, 1983.
868. Letter to J. Ahearne from M. Plesset, "Recommendations of President's Commission on ACRS Role," January 15, 1980. [8002150071]
869. Federal Register Notice 46 FR 22358, "10 CFR Part 2, ACRS Participation in NRC Rulemaking," April 17, 1981.

870. Memorandum for Commissioner Ahearne, et al.; from L. Bickwit, et al., "TMI Action Plan, Chapter V, Formal Procedures for Ensuring Periodic Public Interaction," October 2, 1980.
871. Memorandum for W. Dircks, et al., from J. Hoyle, "Staff Requirements - Discussion of Action Plan, Chapter V (See SECY-80-230B), 2:00 p.m. Monday, July 7, 1980, Commissioners' Conference Room, D.C. Office (Open to Public Attendance)," July 9, 1980. [8012030928]
872. Federal Register Notice 45 FR 49535, "10 CFR Part 2, Procedural Assistance in Adjudicatory Licensing Proceedings," July 25, 1980.
873. Federal Register Notice 46 FR 13681, "10 CFR Part 2, Domestic Licensing Proceedings; Procedural Assistance Program," February 24, 1981.
874. Memorandum for L. Bickwit from S. Chilk, "SECY-81-391 - Provision of Free Transcripts to All Full Participants in Adjudicatory Proceedings: May 11, 1981 Comptroller General Decision," February 25, 1982.
875. Federal Register Notice 45 FR 34279, "10 CFR Parts 2, 50, Possible Amendments to 'Immediate Effectiveness Rule,'" May 22, 1980.
876. Federal Register Notice 47 FR 47260, "10 CFR Part 2, Commission Review Procedures for Power Reactor Construction Permits; Immediate Effectiveness Rule," October 25, 1982.
877. Federal Register Notice 51 FR 10393, "10 CFR Parts 0 and 2, Revision of Ex Parte and Separation of Functions Rules Applicable to Formal Adjudicatory Proceedings," March 26, 1986.
878. NUREG-0632, "NRC Views and Analysis of the Recommendations of the President's Commission on the Accident at Three Mile Island," U.S. Nuclear Regulatory Commission, November 1979.
879. Federal Register Notice 46 FR 28533, "Statement of Policy on Conduct of Licensing Proceedings," May 27, 1981.
880. Memorandum to All Employees from N. Palladino, "Regulatory Reform Task Force," November 17, 1981.
881. Letter to the Honorable Thomas P. O'Neill, Jr. from N. Palladino, February 21, 1983.
882. Federal Register Notice 48 FR 44173, "10 CFR Part 50, Revision of Backfitting Process for Power Reactors," September 28, 1983.
883. Federal Register Notice 48 FR 44217, "10 CFR Part 50, Revision of Backfitting Process for Power Reactors," September 28, 1983.
884. Federal Register Notice 50 FR 38097, "10 CFR Parts 2 and 50, Revision of Backfitting Process for Power Reactors," September 20, 1985.

885. Memorandum for H. Thompson from D. Crutchfield, "Potential Immediate Generic Actions as a Result of the Davis-Besse Event of June 9, 1985," August 5, 1985. [8508090679]
886. NUREG-1154, "Loss of Main and Auxiliary Feedwater Event at the Davis-Besse Plant on June 9, 1985," U.S. Nuclear Regulatory Commission, July 1985.
887. Memorandum for T. Speis from H. Thompson, "Short Term Generic Actions as a Result of the Davis-Besse Event of June 9, 1985," August 19, 1985. [8508270246]
888. Memorandum for H. Denton from T. Speis, "Adequacy of the Auxiliary Feedwater System at Davis-Besse," July 23, 1985. [8508010086]
889. NSAC-60, "A Probabilistic Risk Assessment of Oconee Unit 3," Electric Power Research Institute, June 1984.
890. NUREG-1032, "Evaluation of Station Blackout Accidents at Nuclear Power Plants," U.S. Nuclear Regulatory Commission, June 1988.
891. Letter to T. Novak (NRC) from R. Crouse (Toledo Edison Company), December 31, 1981. [8201060607]
892. NUREG/CR-2770, "Common Cause Fault Rates for Valves," U.S. Nuclear Regulatory Commission, February 1983.
893. NUREG/CR-2098, "Common Cause Fault Rates for Pumps," U.S. Nuclear Regulatory Commission, February 1983.
894. Memorandum for O. Parr from A. Thadani, "Auxiliary Feedwater System - CRGR Package," November 9, 1984. [8411280233]
895. Memorandum for H. Denton, et al., from W. Dircks, "Staff Actions Resulting from the Investigation of the June 9 Davis-Besse Event (NUREG-1154)," August 5, 1985. [8508090534]
896. SECY-86-56, "Status of Staff Study to Determine if PORVs Should be Safety Grade," February 18, 1986. [8611100428]
897. Memorandum for G. Lainas from F. Rowsome, "Safety Evaluation of the CE Licensees' Responses to TMI Action Item II.K.3.2," August 26, 1983. [8309060394]
898. Memorandum for G. Lainas from F. Rowsome, "Safety Evaluation of the B&W Licensees' Responses to TMI Action Item II.K.3.2," August 24, 1983. [8308310422]
899. Memorandum for G. Lainas from F. Rowsome, "Safety Evaluation of the Westinghouse Licensees' Responses to TMI Action Item II.K.3.2," July 22, 1983. [8308040054]
900. Memorandum for H. Thompson from W. Russell, "Comments on Draft List of Longer Term Generic Actions as a Result of the Davis-Besse Event of June 9, 1985," September 19, 1985. [8509240326]

901. Memorandum for T. Combs from H. Denton, "Revised SRP Section 9.2.1 and SRP Section 9.2.2 of NUREG-0800," June 24, 1986. [8607080481]
902. Memorandum for J. Sniezek and R. Fraley from H. Denton, "Resolution of Generic Issue No. 36, 'Loss of Service Water,'" May 13, 1986. [8605300159]
903. Memorandum for T. Speis from H. Denton, "Resolution of Generic Issue 3, 'Setpoint Drift in Instrumentation,'" May 19, 1986. [8606110638]
904. SECY-83-293, "Amendments to 10 CFR 50 Related to Anticipated Transients Without Scram (ATWS) Events," July 9, 1983. [8308080642]
905. Memorandum for T. Speis from R. Bernero, "Enhancement of the Reliability of Westinghouse Solid State Protection System (SSPS)," April 5, 1985. [8504160610]
906. NUREG/CR-3971, "A Handbook for Cost Estimating," U.S. Nuclear Regulatory Commission, October 1984.
907. Memorandum for W. Minners from B. Sheron, "Generic Issues C-4, C-5, C-6," May 29, 1985. [8506100882]
908. SECY-83-472, "Emergency Core Cooling System Analysis Methods," November 17, 1983. [8401060169]
909. AEOD/C503, "Decay Heat Removal Problems at U.S. Pressurized Water Reactors," Office for Analysis and Evaluation of Operational Data, U.S. Nuclear Regulatory Commission, December 1985. [8601060316]
910. Memorandum for H. Denton from C. Heltemes, "Case Study Report - Decay Heat Removal Problems at U.S. Pressurized Water Reactors," December 23, 1985. [8601060315]
911. Memorandum for C. Heltemes from H. Denton, "AEOD's Report on Decay Heat Removal Problems at U.S. PWRs," February 10, 1986. [8602200004]
912. Memorandum to T. Murley, et al., from H. Denton, "Evaluation of Industry Success in Achieving ALARA-Integrated Radiation Protection Plans - Data Trend Assessments," May 19, 1986.
913. Memorandum for V. Stello from H. Denton, "Resolution of Generic Issue III.D.3.1, 'Radiation Protection Plans,'" May 19, 1986.
914. Memorandum for H. Thompson and T. Speis from R. Bernero, "Request for Comments on Draft CRGR Package with Requirements for Upgrading Auxiliary Feedwater Systems in Certain Operating Plants," October 3, 1985. [8510090228]
915. Memorandum for W. Minners from A. Thadani, "Seismic Induced Relay Chatter Issue," March 22, 1985.

916. Regulatory Guide 1.29, "Seismic Design Classification," U.S. Nuclear Regulatory Commission, June 1972, (Rev. 1) August 1973 [8003280778], (Rev. 2) February 1976, (Rev. 3) September 1978 [7810030052].
917. Regulatory Guide 1.100, "Seismic Qualification of Electrical Equipment for Nuclear Power Plants," U.S. Nuclear Regulatory Commission, March 1976, (Rev. 1) August 1977.
918. NUREG/CP-0070, "Proceeding of the Workshop on Seismic and Dynamic Fragility of Nuclear Power Plant Components," U.S. Nuclear Regulatory Commission, August 1985.
919. NUREG-1030, "Seismic Qualification of Equipment in Operating Nuclear Power Plants," U.S. Nuclear Regulatory Commission, February 1987.
920. ANSI/ANS 5.1, "Decay Heat Power in Light Water Reactors," American National Standards Institute, 1979.
921. Letter to the Honorable Morris K. Udall from Joseph M. Hendrie, August 7, 1978. [7901030172, 8001230259]
922. Letter to Joseph Hendrie from Morris K. Udall, January 27, 1978. [8007210279, 8007180431]
923. Memorandum for J. Taylor from D. Morrison, "Resolution of Generic Safety Issue 15, 'Radiation Effects on Reactor Vessel Supports,'" May 29, 1996. [9606190081]
924. SECY-96-107, "Uniform Tracking of Agency Generic Technical Issues," May 14, 1996. [9605230140]
925. Memorandum for E. Beckjord from T. Murley, "Regulatory Guide 1.44," April 30, 1992. [9205110015]
926. Memorandum for Record from E. McGregor, "SECY-80-366 - NRC Legislative Program for 97th Congress," April 8, 1981.
927. Memorandum for Chairman Palladino, et al., from A. Kenneke, "TMI Action Plan, Chapter V," May 18, 1984.
928. Memorandum for A. Thadani from T. Speis, "Generic Safety Issue (GSI)-166, 'Adequacy of Fatigue Life of Metal Components,'" August 26, 1996. [9808210022]
929. Regulatory Guide 1.139, "Guidance for Residual Heat Removal," U.S. Nuclear Regulatory Commission, May 1978.
930. NUREG-0957, "The Price-Anderson Act - The Third Decade," U.S. Nuclear Regulatory Commission, December 1983.
931. NUREG-0689, "Potential Impact of Licensee Default on Cleanup of TMI-2," U.S. Nuclear Regulatory Commission, November 1980.

932. SECY-83-64A, "10 CFR 140: Proposed Rule to Revise the Criteria for Determination of an Extraordinary Nuclear Occurrence," August 9, 1983. [8308250291]
933. Memorandum for A. Kenneke from W. Olmstead, "Chapter 5 of TMI Action Plan," March 16, 1984. [8404040211]
934. Letter to the Honorable Alan Simpson from Joseph Hendrie, March 24, 1981. [8104030556]
935. NUREG/CR-1368, "Development of a Checklist for Evaluating Maintenance, Test and Calibration Procedures Used in Nuclear Power Plants," U.S. Nuclear Regulatory Commission, May 1980.
936. NUREG/CR-1369, "Procedures Evaluation Checklist for Maintenance, Test and Calibration Procedures," U.S. Nuclear Regulatory Commission, May 1980.
937. Memorandum for Chairman Ahearne from W. Dircks, "Manual Chapters Delegation of Authority to Staff Office Directors," December 23, 1980.
938. SECY-80-497, "Review of Delegations of Authority and Other Documentation," November 10, 1980. [8011190612]
939. Federal Register Notice 51 FR 28044, "Safety Goals for the Operations of Nuclear Power Plants," August 4, 1986.
940. Memorandum for T. Speis from H. Thompson, "Longer-Term Generic Actions as a Result of the Davis-Besse Event of June 9, 1985," November 6, 1985. [8511120162]
941. Memorandum for B. Morris from D. Basdekas, "Concerns Related to the Davis-Besse Incident on June 9, 1985," August 13, 1985. [8508230349]
942. Memorandum for F. Gillespie from D. Basdekas, "Concerns Related to the Davis-Besse Incident on June 9, 1985," September 27, 1985. [9909290115]
943. Memorandum for A. DeAgazio from D. Crutchfield, "Davis-Besse Restart Safety Evaluation (TAC No. 59702)," December 17, 1985. [8512230373]
944. Letter to G. Ogeka (BNL) from T. Speis (NRC), "BNL Technical Assistance to the Division of Safety Review and Oversight, Office of Nuclear Reactor Regulation, NRC - 'Reduction of Risk Uncertainty' (FIN A-3846)," April 28, 1986. [9909290117]
945. Memorandum for K. Kniel from R. Riggs, "OTSG Thermal Stress (GI-125.II.4)," June 17, 1986. [8608070348]
946. Memorandum for H. Thompson from R. Bernero, "Auxiliary Feedwater Systems," August 23, 1985. [8509030040]
947. Memorandum for B. Boger from A. Gody, "Implementation of the Resolution for Generic Issue 142, 'Leakage Through Electrical Isolators,'" May 28, 1993. [9803260145]

948. Memorandum for H. Thompson from G. Edison, "Recommendation for Longer Term Generic Action as a Result of Davis-Besse Event of June 9, 1985," September 11, 1985. [9909290121]
949. Memorandum for F. Miraglia from G. Edison, "Prioritization of Generic Issue 125.II.I.D," April 25, 1986. [8605050358]
950. BAW-1919, "B&W Owners' Group Trip Reduction and Transient Response Improvement Program," May 31, 1986. [8606020079, 8605190153]
951. Memorandum for H. Thompson and W. Minners from F. Rowsome, "Another Generic Safety Issue Suggested by the Davis-Besse Incident of June 9, 1985," September 9, 1985. [8509110328]
952. Memorandum for W. Minners from K. Kniel, "Value/Impact Assessment for Draft CRGR Package Requiring Upgrading of Auxiliary Feedwater Systems in Certain Operating Plants," January 16, 1986. [8601240311]
953. Memorandum for G. Mazetis from A. Marchese, "Revised Outline of Regulatory Analysis for USI A-45," January 14, 1986. [9909290124]
954. Memorandum for V. Stello from E. Beckjord, "Closeout of TMI Action Plan Items," November 13, 1986.
955. Memorandum for W. Dircks from H. Denton, "Close Out of Completed TMI Action Plan Item I.C.9, 'Long-Term Program Plan for Upgrading of Procedures,'" June 7, 1985. [8506200155]
956. Memorandum for V. Stello from H. Denton, "Close-out of the Division of Human Factors Technology TMI Action Plan Items," January 6, 1987. [8701140115]
957. Federal Register Notice 49 FR 46428, "10 CFR Parts 50 and 55, Operator's Licenses and Conforming Amendment," November 26, 1984.
958. Memorandum for T. Speis from T. Novak, "Need for Oversight Guidance - Byron 2-Pump Service Water Issue and Related Generic Issues," May 6, 1986. [8605130362]
959. EGG-EA-5524, "Data Summaries of Licensee Event Reports of Pumps at U.S. Commercial Nuclear Power Plants from January 1, 1972, to September 30, 1980," Idaho National Engineering Laboratory, September 1981.
960. Letter to D. Ericson (Sandia National Laboratories) from J. Mulligan (United Engineers & Constructors), "Decay Heat Removal Systems Evaluations Feasibility and Cost Evaluations of Special Issues Related to Decay Heat Removal," January 20, 1986. [9910200312]
961. NUREG/CR-4627, "Generic Cost Estimates," U.S. Nuclear Regulatory Commission, June 1986, (Rev. 1) February 1989, (Rev. 2) February 1992.
962. NUREG-1021, "Operator Licensing Examiner Standards," U.S. Nuclear Regulatory Commission, October 1983.

963. SECY-85-21, "Policy Statement on Fitness for Duty of Nuclear Power Plant Personnel," January 17, 1985. [8502280427]
964. SECY-85-21A, "Withdrawal Notice: Fitness for Duty of Nuclear Power Plant Personnel," April 12, 1985. [8505030703]
965. SECY-85-21B, "Fitness for Duty of Nuclear Power Plant Personnel," August 26, 1985. [8510150472]
966. Federal Register Notice 50 FR 11147, "10 CFR Ch. 1, Commission Policy Statement on Training and Qualification of Nuclear Power Plant Personnel," March 20, 1985.
967. Federal Register Notice 51 FR 27921, "Commission Policy Statement on Fitness for Duty of Nuclear Power Plant Personnel," August 4, 1986.
968. Memorandum for J. Roe from R. Minogue, "Nuclear Plant Analyzer (NPA) Management Plan," December 12, 1985. [9909290129]
969. NUREG/CR-3403, "Criteria and Test Method for Certifying Air-Purifying Respirator Cartridges and Canisters Against Radioiodine," U.S. Nuclear Regulatory Commission, November 1983.
970. NUREG/CR-3568, "A Handbook for Value-Impact Assessment," U.S. Nuclear Regulatory Commission, December 1983.
971. NUREG/CR-4330, "Review of Light Water Reactor Regulatory Requirements," U.S. Nuclear Regulatory Commission, (Vol. 1) April 1986, (Vol. 2) June 1986.
972. SECY-80-230B, "Update of Chapter V of TMI Action Plan: NRC Policy, Organization, and Management," June 20, 1980. [8009160065]
973. Memorandum for T. Speis from W. Minners, "Schedule for Resolving Generic Issue No. 125.II.1.b, 'Review Existing AFW Systems for Single Failure,'" December 10, 1986. [8612180094]
974. NUREG-1122, "Knowledges and Abilities Catalog for Nuclear Power Plant Operators: Pressurized Water Reactors," U.S. Nuclear Regulatory Commission, July 1985.
975. IE Circular No. 80-02, "Nuclear Power Plant Staff Work Hours," U.S. Nuclear Regulatory Commission, February 1, 1980. [7912190657]
976. NRC Letter to All Licensees of Operating Plants and Applicants for Operating Licenses and Holders of Construction Permits, "Interim Criteria for Shift Staffing (Generic Letter 80-72)," July 31, 1980. [8009020297]
977. Federal Register Notice 47 FR 7352, "Nuclear Power Plant Staff Working Hours," February 18, 1982.
978. Federal Register Notice 47 FR 23836, "Nuclear Power Plant Staff Working Hours," June 1, 1982.

979. NRC Letter to All Licensees of Operating Plants, Applicants for an Operating License, and Holders of Construction Permits, "Nuclear Power Plant Staff Working Hours (Generic Letter No. 82-12)," June 15, 1982. [8206160341]
980. NRC Letter to All Pressurized Power Reactor Licensees, "NUREG-0737 Technical Specifications (Generic Letter No. 82-16)," September 20, 1982. [8209210027]
981. NRC Letter to All Boiling Water Reactor Licensees, "NUREG-0737 Technical Specifications (Generic Letter No. 83-02)," January 10, 1983. [8301110134]
982. NRC Letter to All Licensees of Operating Plants, Applicants for Operating Licenses, and Holders of Construction Permits, "Definition of 'Key Maintenance Personnel,' Clarification of Generic Letter 82-12 (Generic Letter 83-14)," March 7, 1983. [8303040005]
983. Memorandum for W. Dircks from J. Hoyle, "Updating NRC Policy Statements," September 30, 1985. [8611190084]
984. Memorandum for J. Tourtelotte, et al., from S. Chilk, "Addendum to SRM M841218 - Briefing and Discussion on the Hearing Process, 2:00 p.m., Tuesday, December 18, 1984, Commissioners' Conference Room, D.C. Office (Open to Public Attendance)," January 31, 1985. [8502060511]
985. Federal Register Notice 48 FR 50550, "10 CFR Part 2, Rules of Practice for Domestic Licensing Proceedings; Role of NRC Staff in Adjudicatory Licensing Hearings," November 2, 1983.
986. Federal Register Notice 51 FR 36811, "10 CFR Part 2, Rules of Practice for Domestic Licensing Proceedings; Role of NRC Staff in Adjudicatory Licensing Hearings," October 16, 1986.
987. Federal Register Notice 49 FR 14698, "10 CFR Parts 2 and 50, Request for Public Comment on Regulatory Reform Proposal Concerning the Rules of Practice, Rules for Licensing of Production and Utilization Facilities," April 12, 1984.
988. Federal Register Notice 51 FR 24365, "10 CFR Part 2, Rules of Practice for Domestic Licensing Proceedings - Procedural Changes in the Hearing Process," July 3, 1986.
989. Federal Register Notice 50 FR 13978, "10 CFR Part 140, Criteria for an Extraordinary Nuclear Occurrence," April 9, 1985.
990. Memorandum for J. Funches from F. Rowsome, "Handling of DHFT Issues in GIMCS," June 6, 1986. [8606120789]
991. Memorandum for T. Speis from R. Bernero, "Resolution of Comment No. 9 of CRGR/OIA Issues on Potential Generic Concerns Regarding BWR Drywell Coolers," July 31, 1986. [8608190656]
992. Federal Register Notice 50 FR 42145, "10 CFR Part 1, Statement of Organization and General Information," October 18, 1985.

993. NUREG-1220, "Training Review Criteria and Procedures," U.S. Nuclear Regulatory Commission, July 1986.
994. Federal Register Notice 48 FR 31611, "10 CFR Part 50, Licensed Operator Staffing at Nuclear Power Plants," July 11, 1983.
995. Regulatory Guide 1.114, "Guidance on Being Operator at the Controls of a Nuclear Power Plant," U.S. Nuclear Regulatory Commission, February 1976 [8012110846], (Rev. 1) November 1976 [8307070393], (Rev. 2) May 1989 [8906200342].
996. Federal Register Notice 50 FR 43621, "Commission Policy Statement on Engineering Expertise on Shift," October 28, 1985.
997. Memorandum for W. Dircks from H. Denton, "Human Factors Program Plan (HFPP)," December 6, 1984. [8501080482]
998. Memorandum for T. Speis from H. Denton, "Resolution of Generic Safety Issue 61, 'SRV Line Break Inside the Wetwell Airspace of Mark I and II Containments,'" August 8, 1986. [8608180209]
999. NUREG/CR-4594, "Estimated Safety Significance of Generic Safety Issue 61," U.S. Nuclear Regulatory Commission, June 1986.
1000. Memorandum for T. Speis, et al., from R. Mattson, "Generic Issue 23, 'Reactor Coolant Pump Seal Failures' - Task Action Plan," October 26, 1983. [8311080469]
1001. Memorandum for H. Denton from T. Speis, "Integration of Electrical Power Issues into Proposed Generic Issue 128, 'Electrical Power Reliability,'" November 28, 1986. [8612080528]
1002. Memorandum for H. Clayton from B. Sheron, "Criteria for Initiating Feed and Bleed," September 13, 1985. [8509180314]
1003. Memorandum for W. Russell from K. Perkins, "Generic Issue 125.I.8, 'Procedures and Staffing for Reporting to NRC Operations Center,'" November 25, 1986. [8612050442]
1004. Memorandum for G. Lainas and D. Crutchfield from F. Rowsome, "Davis-Besse Restart Considerations," August 13, 1985. [8508210208]
1005. Memorandum for V. Stello from D. Ward, "ACRS Comments on Proposed Resolution of Generic Issue 124, 'Auxiliary Feedwater System Reliability,'" September 17, 1986. [8609230137]
1006. NUREG-1195, "Loss of Integrated Control System Power and Overcooling Transient at Rancho Seco on December 26, 1985," U.S. Nuclear Regulatory Commission, February 1986.
1007. Memorandum for T. Speis from F. Miraglia, "Generic Action as a Result of the Rancho Seco Event of December 26, 1985," May 14, 1986. [8605200493]

1008. Memorandum for E. Jordan from G. Holahan, "Proposed IE Information Notice," June 6, 1986. [8606110821]
1009. NUREG/CR-4568, "A Handbook for Quick Cost Estimates," U.S. Nuclear Regulatory Commission, April 1986.
1010. IE Information Notice No. 86-61, "Failure of Auxiliary Feedwater Manual Isolation Valve," U.S. Nuclear Regulatory Commission, July 28, 1986. [8607240026]
1011. NUREG-1177, "Safety Evaluation Report Related to the Restart of Davis-Besse Nuclear Power Station, Unit 1, Following the Event of June 9, 1985," U.S. Nuclear Regulatory Commission, June 1986.
1012. Federal Register Notice 50 FR 29937, "10 CFR Part 50, Analysis of Potential Pressurized Thermal Shock Events," July 23, 1985.
1013. NUREG-1212, "Status of Maintenance in the U.S. Nuclear Power Industry 1985," U.S. Nuclear Regulatory Commission, (Volumes 1 and 2), June 1986.
1014. Memorandum for F. Schroeder from D. Crutchfield, "Dynamic Qualification Testing of Large Bore Hydraulic Snubbers," March 6, 1985. [8503180471]
1015. Memorandum for R. DeYoung, et al., from C. Heltemes, "Failure of Large Hydraulic Snubbers to Lock-up," September 21, 1984. [8410290312, 8410290114]
1016. NUREG/CR-4334, "An Approach to the Quantification of Seismic Margins in Nuclear Power Plants," U.S. Nuclear Regulatory Commission, August 1985.
1017. NUREG/CR-4279, "Aging and Service Wear of Hydraulic and Mechanical Snubbers Used on Safety-Related Piping and Components of Nuclear Power Plants," U.S. Nuclear Regulatory Commission, February 1986.
1018. NUREG/CR-4263, "Reliability Analysis of Stiff Versus Flexible Piping Final Project Report," U.S. Nuclear Regulatory Commission, May 1985.
1019. NUREG/CR-3756, "Seismic Hazard Characterization of the Eastern United States," U.S. Nuclear Regulatory Commission, April 1984.
1020. NRC Letter to All Power Reactor Licensees (Except SEP Licensees) and All Applicants for Licenses to Operate Power Reactors, "Technical Specification for Snubbers (Generic Letter 84-13)," May 3, 1984. [8405040043]
1021. EPRI NP-2297, "Snubber Reliability Improvement Study," Electric Power Research Institute, March 1982.
1022. NUREG-1144, "Nuclear Plant Aging Research (NPAR) Program Plan," U.S. Nuclear Regulatory Commission, July 1985.
1023. SECY-86-231, "Survey on Engineering Expertise on Shift," August 6, 1986. [8608200375]

1024. Memorandum for K. Kniel from C. Ferrell, "Modification of Generic Issue No. 106, 'Highly Combustible Gases in Vital Areas,'" February 20, 1986. [8602280811]
1025. IE Information Notice No. 83-41, "Actuation of Fire Suppression System Causing Inoperability of Safety-Related Equipment," U.S. Nuclear Regulatory Commission, June 22, 1983. [8305110477]
1026. Letter to D. Farrar (Commonwealth Edison Co.) from J. Zwolinski (NRC), "Technical Specifications Relating to the Use of a Mobile Volume Reduction System (MVRS) at Dresden Station (TAC 56373, 56374)," August 13, 1986. [8608210177]
1027. Memorandum for D. Eisenhut from G. Lainas, "Summary of the Operating Reactor Events Meeting," January 28, 1982. [8310260053]
1028. Memorandum for R. Vollmer and E. Jordan from C. Michelson, "Effects of Fire Protection System Actuation on Safety Related Equipment," January 28, 1982. [8202220663]
1029. "Guidelines for Permanent BWR Hydrogen Water Chemistry Installations," BWR Owners Group for IGSCC Research, Hydrogen Installation Subcommittee, Electric Power Research Institute, 1987.
1030. NASA TMX-71565, "Review of Hydrogen Accidents and Incidents in NASA Operation," National Aeronautics and Space Administration, August 1974.
1031. Memorandum for T. Murley from E. Beckjord, "A New Generic Issue: Multiple Steam Generator Tube Leakage," June 16, 1992. [9212040356]
1032. Memorandum for H. Denton from T. Speis, "Earthquakes and Emergency Planning," January 18, 1984. [8402020014]
1033. Letter to W. Dircks (NRC) from S. Sholly (Union of Concerned Scientists), December 22, 1983. [8502270371]
1034. Letter to J. Asselstine (NRC) from S. Sholly (Union of Concerned Scientists), December 22, 1983. [8502090516]
1035. SECY-85-283, "Final Amendments to 10 CFR Part 50, Appendix E; Consideration of Earthquakes in Emergency Planning," August 21, 1985. [8508300319]
1036. IE Bulletin No. 85-03, "Motor-Operated Valve Common Mode Failures During Plant Transients Due to Improper Switch Settings," U.S. Nuclear Regulatory Commission, November 15, 1985 [8511130441], (Supplement 1) April 27, 1988 [8804210018].
1037. SECY-83-484, "Requirements for Emergency Response Capability," November 29, 1983. [8312130459]
1038. IE Information Notice No. 86-10, "Safety Parameter Display System Malfunctions," U.S. Nuclear Regulatory Commission, February 13, 1986. [8602100408]

1039. Memorandum for H. Denton from T. Speis, "Prioritization of Selected MPAs (Operating Plan, Item VI.B.6.b)," October 19, 1984. [8411010640]
1040. NUREG/CR-3246, "The Effect of Some Operations and Control Room Improvements on the Safety of the Arkansas Nuclear One, Unit One, Nuclear Power Plant," U.S. Nuclear Regulatory Commission, June 1983.
1041. Memorandum for K. Kniel from R. Bosnak, "Request for Subsumption of Generic Issue B-6 (GI B-6) Into Generic Issue 119.1 (GI 119.1)," January 8, 1987. [8701200186]
1042. SECY-87-101, "Issues and Proposed Options Concerning Degree Requirement for Senior Operators," April 16, 1987. [8706030157]
1043. SECY-86-348, "Final Rulemaking for Revisions to Operator Licensing - 10 CFR 55 and Conforming Amendments," November 21, 1986. [8701020003]
1044. Federal Register Notice 52 FR 16007, "Regulatory Guides; Issuance and Availability," May 1, 1987.
1045. Memorandum for V. Stello from E. Beckjord, "Resolution of TMI Action Plan Items and Human Factors Issues," May 18, 1987. [8710280270]
1046. Memorandum for V. Stello from E. Beckjord, "Closeout of TMI Action Plan Item," February 27, 1987. [9704150146]
1047. Memorandum for K. Kniel from B. Sheron, "Request for the Prioritization of a Generic Issue on the Reliability of PWR Main Steam Safety Valves," May 27, 1986. [8604030313]
1048. IE Information Notice No. 86-05, "Main Steam Safety Valve Test Failures and Ring Setting Adjustments," U.S. Nuclear Regulatory Commission, January 31, 1986 [8601290054], (Supplement 1) October 16, 1986 [8610100107].
1049. Memorandum for F. Cherny from R. Baer, "50.55(e) Report on Crosby Main Steam Valve Ring Settings," February 5, 1985. [8502140267, 9704090262]
1050. Memorandum for R. Bosnak from F. Cherny, "Trip Report - Meeting of ASME Section III Subgroup on Pressure Relief, February 11, 1987," March 13, 1987. [8703190114]
1051. INPO 82-025, "Review of NRC Report: Precursors to Potential Severe Core Damage Accidents: 1969-1979 A Status Report, NUREG/CR-2497," Institute for Nuclear Power Operations, September 1982.
1052. NUREG/CR-2228, "Containment Response During Degraded Core Accidents Initiated by Transients and Small Break LOCA in the Zion/Indian Point Reactor Plants," U.S. Nuclear Regulatory Commission, July 1981.
1053. NUREG/CR-4752, "Coincident Steam Generator Tube Rupture and Stuck-Open Safety Relief Valve Carryover Test," U.S. Nuclear Regulatory Commission, March 1987.

1054. Memorandum for W. Russell, et al., from R. Starostecki, "Request for Regional Inspection to Verify Adequate Flow Capacity of Main Steam Code Safety Valves and Proper Ring Adjustments," November 8, 1987. [8711120155]
1055. AEOD/C204, "San Onofre Unit 1 Loss of Salt Water Cooling Event on March 10, 1980," Office for Analysis and Evaluation of Operational Data, U.S. Nuclear Regulatory Commission, July 1982. [8208260403]
1056. NUREG-0869, "USIA-43 Regulatory Analysis," U.S. Nuclear Regulatory Commission, (Rev. 1) October 1985.
1057. NUREG-0897, "Containment Emergency Sump Performance," U.S. Nuclear Regulatory Commission, (Rev. 1) October 1985.
1058. Regulatory Guide 1.82, "Water Sources for Long-Term Recirculation Cooling Following a Loss-of-Coolant Accident," U.S. Nuclear Regulatory Commission, June 30, 1974 [7902090041], (Rev. 1) November 30, 1985 [8512100138], (Rev. 2) May 31, 1996 [9605210504].
1059. NRC Letter to All Licensees of Operating Reactors, Applicants for Operating Licenses, and Holders of Construction Permits, "Potential for Loss of Post-LOCA Recirculation Capability Due to Insulation Debris Blockage (Generic Letter 85-22)," December 3, 1985. [8511270253]
1060. SECY-85-349, "Resolution of Unresolved Safety Issue A-43, 'Containment Emergency Sump Performance,'" October 31, 1985. [8511070302]
1061. NUREG-0649, "Task Action Plans for Unresolved Safety Issues Related to Nuclear Power Plants," U.S. Nuclear Regulatory Commission, February 1980, (Rev. 1) September 1984.
1062. Federal Register Notice 51 FR 39390, "10 CFR Part 50, Emergency Planning and Preparedness; Withdrawal," October 28, 1986.
1063. NUREG/CR-3017, "Correlation of Seismic Experience Data in Non-Nuclear Facilities with Seismic Equipment Qualification in Nuclear Plants (A-46)," U.S. Nuclear Regulatory Commission, August 1983.
1064. NUREG/CR-3875, "The Use of In-Situ Procedures for Seismic Qualification of Equipment in Currently Operating Plants," U.S. Nuclear Regulatory Commission, June 1984.
1065. NUREG/CR-3357, "Identification of Seismically Risk Sensitive Systems and Components in Nuclear Power Plants," U.S. Nuclear Regulatory Commission, June 1983.
1066. NUREG/CR-3266, "Seismic and Dynamic Qualification of Safety-Related Electrical and Mechanical Equipment in Operating Nuclear Power Plants," U.S. Nuclear Regulatory Commission, September 1983.
1067. NUREG-1211, "Regulatory Analysis for Resolution of Unresolved Safety Issue A-46, 'Seismic Qualification of Equipment in Operating Plants,'" U.S. Nuclear Regulatory Commission, February 1987.

1068. Regulatory Guide 1.154, "Format and Content of Plant-Specific Pressurized Thermal Shock Safety Analysis Reports for Pressurized Water Reactors," U.S. Nuclear Regulatory Commission, January 1987.
1069. NRC Letter to All Holders of Operating Licenses Not Reviewed to Current Licensing Criteria on Seismic Qualification of Equipment, "Verification of Seismic Adequacy of Mechanical and Electrical Equipment in Operating Reactors, Unresolved Safety Issue (USI) A-46 (Generic Letter 87-02)," February 19, 1987. [8702200135]
1070. NUREG-1216, "Safety Evaluation Report Related to the Operability and Reliability of Emergency Diesel Generators Manufactured by Transamerica Delaval, Inc.," U.S. Nuclear Regulatory Commission, August 1986.
1071. Memorandum for T. Speis, et al., from C. Berlinger, "Closeout of Generic Issue 91 - TDI Emergency Diesel Generator Reliability," September 3, 1987. [8709080427]
1072. Memorandum for W. Russell from T. Speis, "Generic Issue 125.II.13 - Operator Job Aids," June 12, 1986. [8606250128]
1073. SECY-83-288, "Pressurized Thermal Shock (PTS) Rule," July 15, 1983. [8307270206]
1074. Memorandum for W. Dircks from S. Chilk, "SECY-83-288, 'Proposed Pressurized Thermal Shock (PTS) Rule,'" January 13, 1984. [8402100267]
1075. Memorandum for K. Kniel from R. Bosnak, "Integration of NUREG-0933 Issues," May 27, 1986. [8606090491]
1076. NUREG-1230, "Compendium of ECCS Research for Realistic LOCA Analysis," U.S. Nuclear Regulatory Commission, December 1988. [8903030340]
1077. Federal Register Notice 52 FR 9453, "10 CFR Parts 50 and 55, Operators' Licenses and Conforming Amendments," March 25, 1987.
1078. AEOD/C701, "Air Systems Problems at U.S. Light Water Reactors," Office for Analysis and Evaluation of Operational Data, U.S. Nuclear Regulatory Commission, March 1987. [8707240066]
1079. NUREG-1275, "Operating Experience Feedback Report," U.S. Nuclear Regulatory Commission, (Vol. 1) July 1987, (Vol. 2) December 1987, (Vol. 3) November 1988, (Vol. 4) March 1989, (Vol. 5) March 1989, (Vol. 5, Addendum) August 1989, (Vol. 6) February 1991, (Vol. 7) September 1992, (Vol. 8) December 1992, (Vol. 9) March 1993.
1080. NUREG/CR-4374, "A Review of the Oconee-3 Probabilistic Risk Assessment," U.S. Nuclear Regulatory Commission, (Vol. 1) March 1986, (Vol. 2) March 1986, (Vol. 3) June 1986.
1081. NUREG-1150, "Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants," U.S. Nuclear Regulatory Commission, (Vol. 1) December 1990, (Vol. 2) December 1990, (Vol. 3) January 1991.

1082. NUREG/CR-3673, "Economic Risks of Nuclear Power Reactor Accidents," U.S. Nuclear Regulatory Commission, May 1984.
1083. Memorandum for T. Speis from F. Gillespie, "Review of RES Proposed Prioritization of Generic Issue (GI) 125.II.11, 'Recovery of Main Feedwater as an Alternative to Auxiliary Feedwater,'" April 27, 1988. [8805120322]
1084. NUREG-1258, "Evaluation Procedure for Simulation Facilities Certified Under 10 CFR 55," U.S. Nuclear Regulatory Commission, December 1987.
1085. NRC Letter to All Operating Reactor Licensees, Applicants for an Operating License and Holders of Construction Permits for Babcock & Wilcox Pressurized Water Reactors, "Safety Evaluation of 'Abnormal Transient Operating Guidelines,' (Generic Letter 83-31)," September 19, 1983. [8309190017]
1086. Memorandum for B. Morris from B. Sheron, "LOCA Concern of SCE Employee," April 28, 1987. [9704150141]
1087. Federal Register Notice 50 FR 27006, "10 CFR Part 50, Modification of General Design Criterion 4 Requirements for Protection Against Dynamic Effects of Postulated Pipe Ruptures," July 1, 1985.
1088. UCID-20397, "Assessment of Value-Impact Associated with the Elimination of Postulated Pipe Ruptures from the Design Basis for Nuclear Power Plants," Lawrence Livermore National Laboratory, March 29, 1985.
1089. Letter to the Honorable Edward J. Markey (Committee on Energy and Commerce, U.S. House of Representatives) from L. Zech (NRC), March 20, 1987. [8703270224]
1090. GAO/RCED-88-73, "Nuclear Regulation - Action Needed to Ensure that Utilities Monitor and Repair Pipe Damage," U.S. General Accounting Office, March 1988.
1091. Memorandum for D. Morrison from H. Thompson, "Generic Issue Management Control System," January 17, 1997. [9803260111]
1092. EPRI NP-5410, "Nondestructive Evaluation of Ferritic Piping for Erosion-Corrosion," Electric Power Research Institute, September 1987.
1093. NRC Bulletin No. 87-01, "Thinning of Pipe Walls in Nuclear Power Plants," U.S. Nuclear Regulatory Commission, July 9, 1987. [8707020018]
1094. SECY-88-50, "Status Report on Pipe Wall Thinning (Responses to NRC Bulletin 87-01 on Pipe Wall Thinning in Nuclear Power Plants)," February 22, 1988. [8809090066]
1095. NRC Information Notice No. 88-17, "Summary of Responses to NRC Bulletin 87-01, Thinning of Pipe Walls in Nuclear Power Plants," U.S. Nuclear Regulatory Commission, April 22, 1988. [8804180039]
1096. SECY-88-50A, "Report on the Meeting with NUMARC, EPRI, and INPO on Status of Industry's Erosion/Corrosion Program," May 10, 1988. [8805230074]

1097. Memorandum to J. Taylor and W. Parler from S. Chilk, "COMSECY-93-029 - Draft Rulemaking Package on License Renewal; SECY-93-049 - Implementation of 10 CFR Part 54, 'Requirements for Renewal of Operating Licenses for Nuclear Power Plants'; SECY-93-113 - Additional Implementation Information for 10 CFR Part 54, 'Requirements for Renewal of Operating Licenses for Nuclear Power Plants,'" June 28, 1993. [9409010107]
1098. Memorandum for V. Stello from T. Murley, "Resolution of Generic Issue I.A.4.2(4) 'Review Simulators for Conformance to Criteria,'" May 28, 1988. [8806020275]
1099. Memorandum for B. Morris from B. Sheron, "Updated GIMCS for GI I.D.5(5)," February 2, 1988. [9704150145]
1100. Memorandum for V. Stello from E. Beckjord, "Redesignation of Generic Issue I.D.5(5), 'Disturbance Analysis Systems,'" February 22, 1988. [8809190312]
1101. Memorandum for V. Stello from E. Beckjord, "Closure of Generic Issue I.D.4 'Control Room Design Standard,'" March 28, 1988. [9704160014]
1102. Memorandum for T. Speis from R. Houston, "Integration of Generic Issue Resolution," November 4, 1987. [9704150161]
1103. Memorandum for V. Stello from E. Beckjord, "Resolution of Generic Safety Issue II.E.4.3, 'Containment Integrity Check,'" March 22, 1988. [8809150125]
1104. NUREG-1273, "Technical Findings and Regulatory Analysis for Generic Safety Issue II.E.4.3, 'Containment Integrity Check,'" U.S. Nuclear Regulatory Commission, April 1988.
1105. Memorandum for T. Speis from G. Arlotto, "Generic Issues Program," January 14, 1988. [9704160053]
1106. Memorandum for R. Baer from G. Bagchi, "Proposed Resolution of Generic Issue B-5, 'Buckling of Steel Containment,'" March 1, 1988. [8804270290]
1107. Memorandum for E. Beckjord from G. Arlotto, "Closeout of Generic Issue B-5, Buckling Behavior of Steel Containments," April 28, 1988. [8805050117]
1108. NUREG-1109, "Regulatory/Backfit Analysis for the Resolution of Unresolved Safety Issue A-44, Station Blackout," U.S. Nuclear Regulatory Commission, June 1988.
1109. Federal Register Notice 53 FR 23203, "10 CFR 50, Station Blackout," June 21, 1988.
1110. Regulatory Guide 1.155, "Station Blackout," U.S. Nuclear Regulatory Commission, June 1988. [8907270193]
1111. NRC Letter to All Licensees of Operating Boiling Water Reactors (BWRs), and Holders of Construction Permits, "NRC Position on IGSCC in BWR Austenitic Stainless Steel Piping (Generic Letter 88-01)," January 25, 1988. [8801260537]
1112. IE Bulletin No. 85-01, "Steam Binding of Auxiliary Feedwater Pumps," U.S. Nuclear Regulatory Commission, October 29, 1985. [8510250539]

1113. NRC Letter to All Licensees, Applicants for Operating Licenses, and Holders of Construction Permits for Pressurized Water Reactors, "Resolution of Generic Safety Issue 93, 'Steam Binding of Auxiliary Feedwater Pumps' (Generic Letter 88-03)," February 17, 1988. [8802180267]
1114. Memorandum for E. Beckjord from T. Murley, "Resolution of Generic Safety Issue 93, 'Steam Binding of Auxiliary Feedwater Pumps,'" August 14, 1987. [8708210408]
1115. Memorandum for E. Beckjord from F. Gillespie, "Review of RES-Proposed Prioritization of Generic Issue No. 136, 'Storage and Use of Large Quantities of Cryogenic Combustibles on Site,'" March 25, 1988. [8804050182]
1116. Federal Register Notice 53 FR 9430, "Final Commission Policy Statement on Maintenance of Nuclear Power Plants," March 23, 1988.
1117. Memorandum for V. Stello from T. Murley, "Closeout of Generic Issue HF-08, 'Maintenance and Surveillance Program,'" May 4, 1988. [8805160004]
1118. SECY-88-248, "Implementation of the Severe Accident Policy for Future Light Water Reactors," September 6, 1988. [8809160019]
1119. NUREG/CR-4780, "Procedures for Treating Common Cause Failures in Safety and Reliability Studies," U.S. Nuclear Regulatory Commission, (Vol. 1) January 1988, (Vol. 2) January 1989.
1120. NUREG-1192, "An Investigation of the Contributors to Wrong Unit or Wrong Train Events," U.S. Nuclear Regulatory Commission, April 1986.
1121. Information Notice No. 87-25, "Potentially Significant Problems Resulting from Human Error Involving Wrong Unit, Wrong Train, or Wrong Components," U.S. Nuclear Regulatory Commission, June 11, 1987. [8706050211]
1122. Memorandum for V. Stello from T. Murley, "Final Resolution of Generic Issue (GI) 102: Human Error in Events Involving Wrong Unit or Wrong Train," September 12, 1988. [8810070118]
1123. Dam Failure Model, Pacific Northwest Laboratories, October 1983.
1124. "Analysis of Gradual Earth-Dam Failure," Journal of Hydraulic Engineering, Volume 114, No. 1, American Society of Civil Engineers, January 1988.
1125. "Use of A Dam Break Model to Assess Flooding at Haddam Neck Nuclear Power Plant," Water Resources Bulletin, Vol. 20, No. 6, American Water Resources Association, December 1984.
1126. Technical Evaluation Report, "Quabbin Dam Failure Flooding Consequences at Haddam Neck Plant," Franklin Research Center, August 25, 1983.
1127. "Dam Breach Parameters, Outflow Peaks, and Flood Stages," International Symposium on Hydrometeorology, American Water Resources Association, June 1982.

1128. PB82-224577, "Application of and Guidelines for Using Available DAM Break Models," Tennessee Water Resources Research Center, May 1981.
1129. IE Bulletin No. 82-02, "Degradation of Threaded Fasteners in the Reactor Coolant Pressure Boundary of PWR Plants," U.S. Nuclear Regulatory Commission, June 2, 1982. [8204210380]
1130. RIL 158, "Operational Safety Reliability Program," U.S. Nuclear Regulatory Commission, October 31, 1988. [8811070111]
1131. Memorandum for V. Stello from E. Beckjord, "Closure of Generic Issue II.C.4, 'Reliability Engineering,'" October 31, 1988. [8811150124]
1132. Memorandum for E. Beckjord from F. Gillespie, "Generic Issue 139, 'Thinning of Carbon Steel Piping in LWRs,'" December 27, 1988. [8901130015]
1133. NUREG-1332, "Regulatory Analysis for the Resolution of Generic Issue 125.II.7, 'Reevaluate Provision to Automatically Isolate Feedwater from Steam Generator During a Line Break,'" U.S. Nuclear Regulatory Commission, September 1988.
1134. Memorandum for V. Stello from E. Beckjord, "Resolution of Generic Issue 125.II.7, 'Reevaluate Provision to Automatically Isolate Feedwater from Steam Generator During a Line Break,'" September 9, 1988. [8811290524]
1135. NUREG-0848, "Final Environmental Statement Related to the Operation of Byron Station Units 1 and 2," U.S. Nuclear Regulatory Commission, April 1982.
1136. Memorandum to C. Miller from R. Borchardt, "Review of Temporary Instruction 2515/131, 'Licensee Offsite Communication Capabilities,' for Deletion from the NRC Inspection Manual," December 3, 1996. [9612060074]
1137. SECY-86-97, "Steam Generator USI Program - Utility Responses to Staff Recommendations in Generic Letter 85-02," March 24, 1986. [8609160048]
1138. NRC Bulletin No. 88-02, "Rapidly Propagating Fatigue Cracks in Steam Generator Tubes," February 5, 1988. [8802020035]
1139. SECY-88-272, "Technical Resolution of Unresolved Safety Issues A-3, A-4, and A-5 Regarding Steam Generator Tube Integrity," September 27, 1988. [8811040042]
1140. NRC Information Notice No. 87-28, "Air Systems Problems at U.S. Light Water Reactors," June 22, 1987 [8706170115], (Supplement 1) December 28, 1987 [8712230003].
1141. NRC Letter to All Holders of Operating Licenses or Construction Permits for Nuclear Power Plants, "Instrument Air Supply System Problems Affecting Safety-Related Equipment (Generic Letter 88-14)," August 8, 1988. [8808120294]
1142. Memorandum for V. Stello from E. Beckjord, "Resolution of Generic Issue 43, Air Systems Reliability," September 30, 1988. [9704160039]

1143. SECY-88-260, "Shutdown Decay Heat Removal Requirements (USI A-45)," September 13, 1988. [8811040098]
1144. NUREG/CR-5015, "Improved Reliability of Residual Heat Removal Capability in PWRs as Related to Resolution of Generic Issue 99," U.S. Nuclear Regulatory Commission, May 1988.
1145. NRC Letter to All Holders of Operating Licenses or Construction Permits for Pressurized Water Reactors (PWRs), "Loss of Decay Heat Removal (Generic Letter No. 88-17) 10 CFR 50.54f," October 17, 1988. [8810180350]
1146. Memorandum for V. Stello from E. Beckjord, "Resolution of Generic Issue 99, 'Loss of RHR Capability in PWRs,'" November 2, 1988. [8811290361]
1147. Memorandum for V. Stello from T. Murley, "Final Resolution of Generic Issue (GI) 66, 'Steam Generator Requirements,'" November 28, 1988. [8812010081]
1148. Memorandum for W. Minners from F. Rowsome, "A Candidate Generic Issue," December 11, 1984. [8501080138]
1149. Regulatory Guide 1.65, "Materials and Inspections for Reactor Vessel Closure Studs," U.S. Atomic Energy Commission, October 1973. [7907100246]
1150. Memorandum for W. Minners from A. Thadani, "Prioritization of RHR Suction Valve Testing," May 7, 1984. [8405180403]
1151. NUREG/CR-2934, "Review and Evaluation of the Indian Point Probabilistic Safety Study," U.S. Nuclear Regulatory Commission, December 1982.
1152. NUREG/CR-3300, "Review and Evaluation of the Zion Probabilistic Safety Study," U.S. Nuclear Regulatory Commission, (Vol. 1) May 1984.
1153. Memorandum for F. Cherny from W. Minners, "Reactor Coolant System Pressure Isolation Valve (PIV) Leak Test Requirements," July 2, 1985. [8507120595]
1154. Regulatory Guide 1.25, "Assumptions Used for Evaluating the Potential Radiological Consequences of a Fuel Handling Accident in the Fuel Handling and Storage Facility for Boiling and Pressurized Water Reactors," U.S. Atomic Energy Commission, March 1972. [7907100118]
1155. Memorandum for R. Bernero from T. Speis, "Relationship of TIA 84-72 (Haddam Neck Refueling Cavity Seal Failure) to Generic Issue No. 82 (Beyond Design Basis Accidents in Spent Fuel Pools)," April 11, 1985. [8504240705]
1156. Memorandum for K. Kniel from W. Minners, "Refueling Cavity Seal Failure," April 1, 1986. [8604080427]
1157. NUREG/CR-4982, "Severe Accidents in Spent Fuel Pools in Support of Generic Safety Issue 82," U.S. Nuclear Regulatory Commission, July 1987.

1158. IE Bulletin No. 84-03, "Refueling Cavity Seal Failure," U.S. Nuclear Regulatory Commission, August 24, 1984. [8408240358]
1159. Letter to D. Crutchfield (NRC) from W. Council (Connecticut Yankee Atomic Power Company), "Haddam Neck Plant Reactor Cavity Seal Ring Failure," September 12, 1984. [8409250335]
1160. Memorandum for K. Kniel from W. Minners, "Refueling Cavity Seal Failure," May 8, 1986. [8605210217]
1161. Memorandum for K. Kniel from W. Minners, "Proposed Generic Issue - Fission Product Removal by Containment Sprays or Pools," March 10, 1987. [8703170451]
1162. Federal Register Notice 54 FR 3701, "[NUREG-0800] Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants; Issuance and Availability," January 25, 1989.
1163. Memorandum for T. Speis from K. Kniel, "Treatment of Lessons-Learned from Surry Event as Related to Generic Issues," March 31, 1987. [8704030542]
1164. Memorandum for T. Speis from R. Bernero, "Prioritization of Generic Issue - Valve Interlocks to Prevent Vessel Draining During Shutdown Cooling," May 21, 1986. [8606120635]
1165. AEOD/E609, "Inadvertent Draining of Reactor Vessel During Shutdown Cooling Operation," Office for Analysis and Evaluation of Operational Data, U.S. Nuclear Regulatory Commission, August 1986. [8608290176, 8608290040]
1166. Memorandum for T. King from K. Kniel, "Additional Comments Regarding Prioritization of Generic Issue-129, 'Residual Heat Removal System Valve Mis-alignment during Shutdown Cooling Operations,'" December 7, 1988. [8812210402]
1167. Memorandum for W. Minners from B. Sheron, "Proposed Generic Issue, 'Potential Seismic Interaction Involving the Movable In-Core Flux Mapping System Used in Westinghouse Designed Plants,'" August 27, 1985. [8509050358]
1168. Letter to F. Miraglia (NRC) from G. Goering (Westinghouse Owners Group), "Potential Seismic Interaction Associated with the Flux Mapping System in Westinghouse Plants," June 10, 1985. [8509050363]
1169. NUREG/CR-2000, "Licensee Event Report (LER) Compilation," U.S. Nuclear Regulatory Commission, (Vol. 3, No. 7) August 1984.
1170. Memorandum for T. King from R. Riggs, "Computer Program 'SEALCOM' Used in Generic Issue 131," May 1, 1989. [9704160010]
1171. IE Information Notice No. 85-45, "Potential Seismic Interaction Involving the Movable In-Core Flux Mapping System Used in Westinghouse Designed Plants," U.S. Nuclear Regulatory Commission, June 6, 1985. [8506060677]

1172. Letter to R. Engelken (NRC) from H. Ray (Southern California Edison Company), "Docket No. 50-361, Licensee Event Report, Numbers 82-002 and 82-003, San Onofre Nuclear Generating Station, Unit 2," March 30, 1982. [8204140262]
1173. Letter to R. Haynes (NRC) from C. Mathis (Boston Edison Company), "Docket No. 50-293, License DPR-35," September 15, 1982. [8209280087]
1174. NUREG-1251, "Implications of the Accident at Chernobyl for Safety Regulation of Commercial Nuclear Power Plants in the United States," U.S. Nuclear Regulatory Commission, (Vols. I and II) April 1989.
1175. SECY-89-081, "Final Report on Chernobyl Implications," March 7, 1989. [8903200205]
1176. AEOD/S801, "Significant Events that Involved Procedures," Office for Analysis and Evaluation of Operational Data, U.S. Nuclear Regulatory Commission, March 1988. [8907310351, 8906090032]
1177. NRC Letter to All Holders of Operating Licenses, Applicants for Operating Licenses and Holders of Construction Permits for Power Reactors, "NRC Use of the Terms, 'Important to Safety' and 'Safety Related' (Generic Letter 84-01)," January 5, 1984. [8401050382]
1178. NRC Memorandum and Order CLI-84-9, June 6, 1984. [8406070146]
1179. SECY-85-119, "Issuance of Proposed Rule on the Important-to-Safety Issue," April 5, 1985. [8505030656]
1180. Memorandum for W. Dircks from S. Chilk, "Staff Requirements -- SECY-85-119 - 'Issuance of Proposed Rule on the Important-to-Safety Issue,'" December 31, 1985. [8601160559]
1181. SECY-86-164, "Proposed Rule on the Important-to-Safety Issue," May 29, 1986. [8607010004]
1182. Memorandum for V. Stello from E. Beckjord, "Resolution of Generic Issue I.F.1, "Expand QA List," January 12, 1989. [9704150147]
1183. Memorandum for W. Minners from L. Engle, "Generic Implications/LLNL Technical Evaluation Report on Seven Main Transformer Failures at the North Anna Power Station, Units 1 and 2," November 16, 1984. [8411270057]
1184. UCID-20053, "Technical Evaluation Report on the Seven Main Transformer Failures at the North Anna Power Station, Units 1 and 2," Lawrence Livermore National Laboratory, March 29, 1984. [8412120181, 8412070065]
1185. Regulatory Guide 1.120, "Fire Protection Guidelines for Nuclear Power Plants," U.S. Nuclear Regulatory Commission, (Draft) June 1976, (Draft) November 1977.
1186. NUREG/CR-3862, "Development of Transient Initiating Event Frequencies for Use in Probabilistic Risk Assessments," U.S. Nuclear Regulatory Commission, May 1985.

1187. Memorandum for V. Stello from E. Beckjord, "Closeout of Generic Issue II.F.5, 'Classification of Instrumentation, Control and Electrical Equipment,'" May 5, 1989. [8906270390]
1188. SECY-83-221, "Prioritization of Generic Safety Issues," June 7, 1983. [8306150099]
1189. Memorandum for W. Dircks from S. Chilk, "SECY-83-221 - Prioritization of Generic Safety Issues," December 9, 1983. [9704150148]
1190. Federal Register Notice 43 FR 1565, "Program for Resolution of Generic Issues Related to Nuclear Power Plants," January 10, 1978.
1191. Federal Register Notice 54 FR 24432, "Program for Resolution of Generic Issues Related to Nuclear Power Plants; Policy Statement," June 7, 1989.
1192. RES Office Letter No. 1, "Procedure for Identification, Prioritization, Resolution, and Tracking of Generic Issues," Office of Nuclear Regulatory Research, December 3, 1987 [9704150149], (Rev. 1) March 22, 1989 [9609200344], (Rev. 2) July 12, 1991 [9107250098], (Rev. 3) November 26, 1991 [9704150154], (Rev. 4) June 2, 1994 [9704150218].
1193. RES Office Letter No. 2, "Procedures for Obtaining Regulatory Impact Analysis Review and Support," Office of Nuclear Regulatory Research, November 18, 1988. [8901180069]
1194. RES Office Letter No. 3, "Procedure and Guidance for the Resolution of Generic Issues," May 10, 1988 [8809220069], (Rev. 1) December 21, 1988 [9704100054], (Rev. 2) March 27, 1989 [9609200351].
1195. NUREG/CR-1251, "Implications of the Accident at Chernobyl for Safety Regulation of Commercial Nuclear Power Plants in the United States," U.S. Nuclear Regulatory Commission, (Vol. 1) April 1989, (Vol. 2) April 1989.
1196. NUREG/CR-5176, "Seismic Failure and Cask Drop Analyses of the Spent Fuel Pools at Two Representative Nuclear Power Plants," U.S. Nuclear Regulatory Commission, January 1989.
1197. NUREG/CR-5281, "Value/Impact Analyses of Accident Preventive and Mitigative Options for Spent Fuel Pools," U.S. Nuclear Regulatory Commission, March 1989.
1198. NUREG/CR-1353, "Regulatory Analysis for the Resolution of Generic Issue 82 'Beyond Design Basis Accidents in Spent Fuel Pools,'" U.S. Nuclear Regulatory Commission, April 1989.
1199. Memorandum for V. Stello from E. Beckjord, "Resolution of Generic Issue, 'Beyond Design Basis Accidents in Spent Fuel Pools,'" April 24, 1989. [9704100053]
1200. NUREG/CR-5197, "Evaluation of Generic Issue 115, 'Enhancement of the Reliability of Westinghouse Solid State Protection System,'" U.S. Nuclear Regulatory Commission, January 1989.

1201. NUREG-1341, "Regulatory Analysis for the Resolution of Generic Issue 115, 'Enhancement of the Reliability of the Westinghouse Solid State Protection System,'" U.S. Nuclear Regulatory Commission, May 1989.
1202. Memorandum for V. Stello from E. Beckjord, "Resolution of Generic Issue 115, 'Enhancement of the Reliability of Westinghouse Solid State Protection Systems,' NUREG-1341," April 17, 1989. [9608210072]
1203. Memorandum for V. Stello from T. Murley, "Plant-Specific Backfit for Improved Auxiliary Feedwater System Reliability at Arkansas Nuclear One, Unit 2 and Rancho Seco," January 31, 1989. [8902030163]
1204. Memorandum for V. Stello from T. Murley, "Final Resolution of Generic Issue (GI) 122.2, 'Initiating Feed and Bleed,'" April 26, 1989. [8905090075]
1205. NRC Letter to All Licensees of Operating Plants, Applicants for Operating Licenses, and Holders of Construction Permits, "Task Action Plan I.D.2 - Safety Parameter Display System - 10 CFR §50.54(f) - (Generic Letter No. 89-06)," April 12, 1989. [8904120042]
1206. NUREG-1342, "A Status Report Regarding Industry Implementation of Safety Parameter Display Systems," U.S. Nuclear Regulatory Commission, April 1989.
1207. Memorandum for V. Stello from T. Murley, "Final Resolution of Generic Issue 125.I.3, 'SPDS Availability,'" April 26, 1989. [8905050362]
1208. Memorandum for V. Stello from T. Murley, "Final Resolution of Generic Issue (GI) HF4.1, Inspection Procedure for Upgraded Emergency Operating Procedures," October 17, 1988. [8811070169]
1209. NUREG-1358, "Lessons Learned from the Special Inspection Program for Emergency Operating Procedures," U.S. Nuclear Regulatory Commission, April 1989.
1210. NRC Information Notice No. 86-64, "Deficiencies in Upgrade Programs for Plant Emergency Operating Procedures," August 14, 1986 [8608120028], (Supplement 1) April 20, 1987 [8704160062].
1211. NUREG/CR-5088, "Fire Risk Scoping Study: Investigation of Nuclear Power Plant Fire Risk, Including Previously Unaddressed Issues," U.S. Nuclear Regulatory Commission, January 1989.
1212. NUREG/CR-5112, "Evaluation of Boiling Water Reactor Water-Level Sensing Line Break and Single Failure," U.S. Nuclear Regulatory Commission, March 1989.
1213. NRC Letter to All Holders of Operating Licenses or Construction Permits for Boiling Water Reactors, "Resolution of Generic Issue 101, 'Boiling Water Reactor Water Level Redundancy' (Generic Letter 89-11)," June 30, 1989. [8906300178]
1214. Memorandum for V. Stello from E. Beckjord, "Closeout of GI 101, 'Boiling Water Reactor Water Level Redundancy,'" April 24, 1989. [9704100038]

1215. Regulatory Guide 1.106, "Thermal Overload Protection for Electric Motors on Motor-Operated Valves," U.S. Nuclear Regulatory Commission, November 1975, (Rev. 1) March 1977. [7907100392]
1216. NUREG-1296, "Thermal Overload Protection for Electric Motors on Safety-Related Motor-Operated Valves - Generic Issue II.E.6.1," U.S. Nuclear Regulatory Commission, June 1988.
1217. NRC Letter to All Licensees of Operating Power Plants and Holders of Construction Permits for Nuclear Power Plants, "Safety-Related Motor-Operated Valve Testing and Surveillance (Generic Letter No. 89-10) - 10 CFR 50.54(f)," June 28, 1989 [8906290082], (Supplement 1) June 13, 1990 [9201300217], (Supplement 2) August 3, 1990 [9007310052], (Supplement 3) October 25, 1990 [9010220146], (Supplement 4) February 12, 1992 [9202250311], (Supplement 5) June 28, 1993 [9306230099], (Supplement 6) March 8, 1994 [9402280155].
1218. Memorandum for V. Stello from E. Beckjord, "Close-out of Generic Issue II.E.6.1, 'In Situ Testing of Valves,'" June 30, 1989. [8907100275]
1219. Memorandum for F. Rowsome from D. Crutchfield, "Potential Generic Issue: Loss of Effective Volume for Containment Recirculation Spray," July 13, 1984. [8407240406]
1220. Memorandum for G. Lainas from R. Houston, "Task Interface Agreement (TIA) #83-144: Loss of Effective Volume for Containment Recirculation Spray for H.B. Robinson, Unit 2 (TAC #53223)," August 6, 1984. [8408130232]
1221. Memorandum for W. Minners from F. Rowsome, "Candidate Generic Safety Issue: Allowable Outage Times for Diverse, Simultaneous Equipment Outages," May 9, 1985. [8506030097]
1222. NRC Letter to All Licensees Holding Operating Licenses and Construction Permits for Nuclear Power Reactor Facilities, "Individual Plant Examination for Severe Accident Vulnerabilities - 10 CFR § 50.54(f), (Generic Letter No. 88-20)," November 23, 1988 [8811280048], (Supplement 1) August 29, 1989 [8908300001], (Supplement 2) April 4, 1990 [9003300127], (Supplement 3) July 6, 1990 [9007020114], (Supplement 4) June 28, 1991 [9106270324], (Supplement 5) September 8, 1995.
1223. Proceedings of the International Topical Meeting on Probability, Reliability, and Safety Assessment, PSA '89, p.48, "Potential Underestimation of Test and Maintenance Unavailabilities in Probabilistic Risk Assessments," American Nuclear Society, April 2-7, 1989.
1224. Memorandum for B. Morris from F. Gillespie, "Prioritization of GI-117, 'Allowable Outage Times for Diverse Simultaneous Equipment Outages,'" August 4, 1989. [9704100058]
1225. Federal Register Notice 46 FR 58484, "10 CFR Part 50, Interim Requirements Related to Hydrogen Control," December 2, 1981.
1226. Federal Register Notice 50 FR 3498, "10 CFR Part 50, Hydrogen Control Requirements," January 25, 1985.

1227. SECY-89-122, "Resolution of Unresolved Safety Issue (USI) A-48, 'Hydrogen Control Measures and Effects of Hydrogen Burns on Safety Equipment,'" April 19, 1989. [8905010149]
1228. NUREG-0943, "Threaded-Fastener Experience in Nuclear Power Plants," U.S. Nuclear Regulatory Commission, January 1983.
1229. EPRI NP-3784, "A Survey of the Literature on Low-Alloy Steel Fastener Corrosion in PWR Power Plants," Electric Power Research Institute, December 1984.
1230. EPRI RP 2520-7, "Degradation and Failure of Bolting in Nuclear Power Plants," Electric Power Research Institute, June 1987.
1231. EPRI NP-2174, "A Study of Bolting Problems, Tools, and Practices in the Nuclear Industry," Electric Power Research Institute, December 1981.
1232. NUREG-1174, "Evaluation of Systems Interactions in Nuclear Power Plants," U.S. Nuclear Regulatory Commission, May 1989.
1233. NUREG-1229, "Regulatory Analysis for Resolution for USI A-17," U.S. Nuclear Regulatory Commission, August 1989.
1234. SECY-89-230, "Unresolved Safety Issue A-17, 'Systems Interactions in Nuclear Power Plants,'" August 1, 1989. [8908140127]
1235. NRC Letter to All Holders of Operating Licenses or Construction Permits for Nuclear Power Plants, "Resolution of Unresolved Safety Issue A-17, 'Systems Interactions in Nuclear Power Plants' (Generic Letter 89-18)," September 6, 1989. [8909070029]
1236. Federal Register Notice 54 FR 34836, "Issuance and Availability of NUREG-1174, 'Evaluation of Systems Interactions in Nuclear Power Plants: Technical Findings Related to Unresolved Safety Issue A17,' and NUREG-1229, 'Regulatory Analysis for Resolution of USI A-17, - Systems Interactions in Nuclear Power Plants,'" August 22, 1989.
1237. NUREG/CR-5420, "Multiple System Responses Program - Identification of Concerns Related to A Number of Specific Regulatory Issues," U.S. Nuclear Regulatory Commission, October 1989.
1238. NUREG/CR-5437, "Recommendations for Resolution of Public Comments on USI A-40, 'Seismic Design Criteria,'" U.S. Nuclear Regulatory Commission, June 1989.
1239. IE Bulletin No. 79-02, "Pipe Support Base Plate Designs Using Concrete Expansion Anchor Bolts," U.S. Nuclear Regulatory Commission, March 8, 1979 [7903140038], (Rev. 1) June 20, 1979 [7906200183], (Rev. 2) November 8, 1979 [7908220136].
1240. IE Bulletin No. 79-14, "Seismic Analysis for As-Built Safety-Related Piping Systems," U.S. Nuclear Regulatory Commission, July 2, 1979 [7907060295], (Rev. 1) July 18, 1979 [7907250430].

1241. IE Bulletin No. 80-11, "Masonry Wall Design," U.S. Nuclear Regulatory Commission, May 8, 1980. [7912190695]
1242. NUREG/CR-1161, "Recommended Revisions to Nuclear Regulatory Commission Seismic Design Criteria," U.S. Nuclear Regulatory Commission, May 1980.
1243. NUREG/CR-3480, "Value/Impact Assessment for Seismic Design Criteria USI A-40," U.S. Nuclear Regulatory Commission, August 1984.
1244. NUREG-1233, "Regulatory Analysis for USI A-40, 'Seismic Design Criteria,'" U.S. Nuclear Regulatory Commission, September 1989.
1245. SECY-89-296, "Unresolved Safety Issue A-40, 'Seismic Design Criteria,'" September 22, 1989. [8910060116]
1246. Federal Register Notice 54 FR 40220, "Issuance and Availability Final Resolution of Unresolved Safety Issue (USI) A-40; Seismic Design Criteria," September 29, 1989.
1247. NUREG-1217, "Evaluation of Safety Implications of Control Systems in LWR Nuclear Power Plants," U.S. Nuclear Regulatory Commission, June 1989.
1248. NUREG-1218, "Regulatory Analysis for Resolution of USI A-47," U.S. Nuclear Regulatory Commission, July 1989.
1249. SECY-89-255, "Unresolved Safety Issue A-47, 'Safety Implications of Control Systems,'" August 23, 1989. [8908250318]
1250. NRC Letter to All Licensees of Operating Reactors, Applicants for Operating Licenses and Holders of Construction Permits for Light Water Reactor Nuclear Power Plants, "Request for Action Related to Resolution of Unresolved Safety Issue A-47, 'Safety Implication of Control Systems in LWR Nuclear Power Plants' Pursuant to 10 CFR 50.54(f) - Generic Letter 89-19," September 20, 1989. [8909200223]
1251. Federal Register Notice 54 FR 36922, "Issuance and Availability of NUREG-1217, 'Evaluation of Safety Implications of Control Systems in LWR Nuclear Power Plants - Technical Findings Related to USI A-47,' and NUREG-1218, 'Regulatory Analysis for Resolution of USI A-47,'" September 5, 1989.
1252. Memorandum for T. King from C. Serpan, "Reevaluation of Issue 15, 'Radiation Effects on Reactor Vessel Supports,'" September 30, 1988. [9704100071]
1253. ORNL/TM-10444, "Evaluation of HFIR Pressure-Vessel Integrity Considering Radiation Embrittlement," Oak Ridge National Laboratory, April 1988.
1254. NUREG/CR-5320, "Impact of Radiation Embrittlement on Integrity of Pressure Vessel Supports for Two PWR Plants," U.S. Nuclear Regulatory Commission, January 1989.
1255. UCLA-ENG-76113, "Some Probabilistic Aspects of the Seismic Risk of Nuclear Reactors," University of California, Los Angeles, December 1976.

1256. SECY-89-180, "Generic Safety Issue 15, 'Radiation Effects on Reactor Vessel Supports,'" June 13, 1989. [8906190110]
1257. NUREG/CR-5210, "Technical Findings Document for Generic Issue 51: Improving the Reliability of Open-Cycle Service-Water Systems," U.S. Nuclear Regulatory Commission, August 1988.
1258. NUREG/CR-5234, "Value/Impact Analysis for Generic Issue 51: Improving the Reliability of Open-Cycle Service-Water Systems," U.S. Nuclear Regulatory Commission, February 1989.
1259. NRC Letter to All Holders of Operating Licenses or Construction Permits for Nuclear Power Plants, "Service Water System Problems Affecting Safety-Related Equipment (Generic Letter 89-13)," July 18, 1989. [8907180211]
1260. Memorandum for J. Taylor from E. Beckjord, "Closeout of GI-51, 'Improving the Reliability of Open-Cycle Service Water Systems,'" August 10, 1989. [9704100044]
1261. Federal Register Notice 54 FR 31268, "'Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants'; Issuance and Availability Revised SRP Sections 2.4.2 and 2.4.3," July 27, 1989.
1262. NRC Letter to All Licensees of Operating Reactors and Holders of Construction Permits, "Potential for Increased Roof Loads and Plant Area Flood Runoff Depth at Licensed Nuclear Power Plants Due to Recent Change in Probable Maximum Precipitation Criteria Developed by the National Weather Service (Generic Letter 89-22)," October 19, 1989. [8910180273]
1263. Memorandum for J. Taylor from E. Beckjord, "Close-out of Generic Safety Issue No. 103, 'Design for Probable Maximum Precipitation,'" November 28, 1989. [8912180025]
1264. Memorandum for V. Stello from S. Chilk, "Degree Operators: Advance Notice of Rulemaking," January 23, 1986. [8601280245]
1265. Federal Register Notice 54 FR 33639, "Education for Senior Reactor Operators and Shift Supervisors at Nuclear Power Plants; Policy Statement," August 15, 1989.
1266. Federal Register Notice 54 FR 33568, "Education and Experience Requirements for Senior Reactor Operators and Supervisors at Nuclear Power Plants; Withdrawal of Proposed Rulemaking," August 15, 1989.
1267. NUREG-1267, "Technical Resolution of Generic Safety Issue A-29," U.S. Nuclear Regulatory Commission, September 1989.
1268. Memorandum for J. Taylor from E. Beckjord, "Resolution of Generic Safety Issue A-29, 'Nuclear Power Plant Design for Reduction of Vulnerability to Industrial Sabotage,'" October 6, 1989. [8910190129]
1269. NUREG/CR-3453, "Electronic Isolators Used in Safety Systems of U.S. Nuclear Power Plants," U.S. Nuclear Regulatory Commission, March 1986.

1270. Memorandum for B. Morris from B. Sheron, "Proposed Generic Issue on Leakage Through Electrical Isolators," June 23, 1987. [9704100047]
1271. Memorandum for T. Speis from R. Bernero, "Request for Prioritization of Potential Generic Issue Per Office Letter No. 40," August 4, 1985. [8508120299]
1272. Memorandum for R. Mattson from F. Rosa, "Combustion Engineering Standard Technical Specifications (NUREG-0212) - Proposed Revision 3 - Relay Testing," October 8, 1982. [8211030387]
1273. NUREG-0693, "Analysis of Ultimate Heat Sink Cooling Ponds," U.S. Nuclear Regulatory Commission, November 1980.
1274. NUREG-0733, "Analysis of Ultimate Heat-Sink Spray Ponds," U.S. Nuclear Regulatory Commission, August 1981.
1275. NUREG-0858, "Comparison Between Field Data and Ultimate Heat Sink Cooling Pond and Spray Pond Models," U.S. Nuclear Regulatory Commission, September 1982.
1276. Regulatory Guide 1.27, "Ultimate Heat Sink for Nuclear Power Plants," U.S. Nuclear Regulatory Commission, (Rev. 2) January 1976.
1277. NUREG/CR-4120, "Mathematical Modeling of Ultimate Heat Sink Cooling Ponds," U.S. Nuclear Regulatory Commission, March 1985.
1278. "Performance Model for Ultimate Heat Spray Ponds," Journal of Energy Engineering, Vol. 112, No. 2, August 1986.
1279. "Method for Analysis of Ultimate Heat Sink Cooling Tower Performance," University of Illinois at Urbana-Champaign, April 1986. [9704090166]
1280. Memorandum for C. Ader from K. Kniel, "Request for Prioritization of New Generic Safety Issue 'Loss of Essential Service Water in LWRs,'" May 2, 1990. [9704090120]
1281. Memorandum for W. Minners from F. Rowsome, "A New Generic Safety Issue: Accident Management," April 16, 1985. [8505080417]
1282. SECY-88-147, "Integration Plan for Closure of Severe Accident Issues," May 25, 1988. [8806030338]
1283. Memorandum for C. Ader from W. Minners, "GI 116, Accident Management," May 9, 1990. [9704090138]
1284. Memorandum for J. Olshinski from D. Eisenhut, "Control Rod Guide Tube Pin Failures and Peening Damage on Integrity of Steam Generator Tube to Tubesheet Welds and Tube Ends -- North Anna Power Station, Unit No. 1 (NA-1)," December 13, 1982. [8212270164]
1285. EPRI NP-5544, "Nuclear Unit Operating Experience: 1985-1986 Update," Electric Power Research Institute, December 1987.

1286. Memorandum for M. Virgilio from S. Newberry, "Proposed Research Programs to Support SICB Regulation Needs," April 26, 1990. [9005090104]
1287. Memorandum for F. Gillespie, et. al., from T. Speis, "CRGR Combined Packages for the Proposed Resolution of Generic Issue 70, 'Power Operated Relief Valve and Block Valve Reliability,' and Generic Issue 94, 'Additional Low-Temperature Overpressure Protection for Light-Water Reactors,'" December 7, 1988. [9507280258]
1288. SECY-90-232, "Evaluation of the Need for Primary System High Capacity Manual Venting Capability on Combustion Engineering (CE) Plants Without PORVs (GI-84)," June 28, 1990. [9007020274]
1289. Letter to K. Carr from C. Michelson, "Generic Issue - 84, Combustion Engineering Plants Without Power Operated Relief Valves," June 12, 1990. [9006220172]
1290. NRC Letter to All Pressurized Water Reactor Licensees and Construction Permit Holders, "Resolution of Generic Issue 70, 'Power-Operated Relief Valve and Block Valve Reliability,' and Generic Issue 94, 'Additional Low-Temperature Overpressure Protection for Light-Water Reactors,' Pursuant to 10 CFR 50.54(f) (Generic Letter 90-06)," June 25, 1990. [9006200120]
1291. NUREG-1326, "Regulatory Analysis for the Resolution of Generic Issue 94, 'Additional Low-Temperature Overpressure Protection for Light-Water Reactors,'" U.S. Nuclear Regulatory Commission, December 1989.
1292. Memorandum for J. Taylor from E. Beckjord, "Close-out of Generic Issue 70, 'Power-Operated Relief Valve and Block Valve Reliability,' and Generic Issue 94, 'Additional Low-Temperature Overpressure Protection for Light-Water Reactors,'" July 26, 1990. [9507280267]
1293. NUREG-1316, "Technical Findings and Regulatory Analysis Related to Generic Issue 70," U.S. Nuclear Regulatory Commission, December 1989.
1294. Memorandum for F. Gillespie from E. Beckjord, "Resolutions of Generic Issue 70, 'Power Operated Relief Valve and Block Valve Reliability,' and Generic Issue 94, 'Additional Low-Temperature Overpressure Protection for Light-Water Reactors,'" November 16, 1989. [8911290064]
1295. SECY-90-153, "Staff Conclusions Relative to the Classification of PORVs as Safety Grade," April 27, 1990. [9005030123]
1296. Information Notice No. 90-19, "Potential Loss of Effective Volume for Containment Recirculation Spray at PWR Facilities," U.S. Nuclear Regulatory Commission, March 14, 1990. [9003080213]
1297. IE Bulletin No. 83-01, "Failure of Reactor Trip Breakers (Westinghouse DB-50) to Open on Automatic Trip Signal," U.S. Nuclear Regulatory Commission, February 25, 1983. [8212060367]

1298. IE Bulletin No. 83-04, "Failure of the Undervoltage Trip Function of Reactor Trip Breakers," U.S. Nuclear Regulatory Commission, March 11, 1983. [8212060380]
1299. IE Bulletin No. 83-08, "Electrical Circuit Breakers With an Undervoltage Trip Feature in Use in Safety-Related Applications Other than the Reactor Trip System," U.S. Nuclear Regulatory Commission, December 28, 1983. [8312120090]
1300. Memorandum for J. Taylor from E. Beckjord, "Resolution of Generic Safety Issue 75, 'Generic Implications of Salem ATWS - QA,'" May 18, 1990. [9507280290]
1301. Memorandum for W. Dircks from R. Minogue, "Preliminary Survey of Requirements and Guidance by Functional Areas for Operating Nuclear Power Plants, Dated February 1984," August 21, 1984. [8409110305]
1302. Memorandum for E. Beckjord from W. Minners, "Generic Issue 131, 'Potential Seismic Interaction Involving the Movable In-Core Flux Mapping System Used in Westinghouse Plants,'" July 18, 1990. [9007240192]
1303. NRC Letter to All Power Reactor Licensees and Applicants, "Relaxation of Staff Position in Generic Letter 83-28, Item 2.2 Part 2, 'Vendor Interface for Safety-Related Components' (Generic Letter No. 90-03)," March 20, 1990. [9003140089]
1304. IE Bulletin No. 77-02, "Potential Failure Mechanism in Certain Westinghouse (W) AR Relays With Latch Attachments," U.S. Nuclear Regulatory Commission, September 12, 1977. [7909050215]
1305. IE Bulletin No. 79-09, "Failures of GE Type AK-2 Circuit Breaker in Safety Related Systems," U.S. Nuclear Regulatory Commission, April 17, 1979. [7905010083]
1306. IE Circular No. 81-12, "Inadequate Periodic Test Procedure of PWR Protection System," U.S. Nuclear Regulatory Commission, July 22, 1981. [8103300406]
1307. NUREG-1372, "Regulatory Analysis for the Resolution of Generic Issue C-8: 'Main Steam Isolation Valve Leakage and LCS Failure,'" U.S. Nuclear Regulatory Commission, June 1990.
1308. NUREG-1169, "Resolution of Generic Issue C-8," U.S. Nuclear Regulatory Commission, August 1986.
1309. NUREG/CR-5397, "Value-Impact Analysis of Regulatory Options for Resolution of Generic Issue C-8: MSIV Leakage and LCS Failure," U.S. Nuclear Regulatory Commission, May 1990.
1310. Memorandum for J. Taylor from E. Beckjord, "Resolution of Generic Safety Issue C-8," March 15, 1990. [9507280304]
1311. IE Information Notice No. 82-09, "Cracking in Piping of Makeup Coolant Lines at B&W Plants," U.S. Nuclear Regulatory Commission, March 31, 1982. [8202040131]

1312. IE Information No. 82-30, "Loss of Thermal Sleeves in Reactor Coolant System Piping at Certain Westinghouse PWR Power Plants," U.S. Nuclear Regulatory Commission, July 26, 1982. [8204210403]
1313. SECY-82-186, "Status of Make-up Nozzle Cracking in Babcock & Wilcox (B&W) Plants," May 7, 1982. [8205280495]
1314. Letter to R. Gridley (General Electric Company) from D. Eisenhut, "Safety Evaluation for the General Electric Topical Report NEDE-218121-02, 'BWR Feedwater Nozzle/Sparger Final Report, Supplement 2,'" January 14, 1980. [8002070141]
1315. Memorandum for D. Sternberg from R. Clark, "Degradation of Thermal Sleeves - Trojan Nuclear Plant," August 11, 1982. [8208250478]
1316. Memorandum for T. Novak, et al., from J. Knight, "Evaluation of Thermal Sleeve Problems in Westinghouse Plants," October 28, 1983. [8311140192]
1317. Letter to V. Stello from W. Kerr, "ACRS Comments on Nuclear Power Plant Air Cooling Systems," October 15, 1987. [8710210001]
1318. NUREG/CR-4550, "Analysis of Core Damage Frequency from Internal Events," U.S. Nuclear Regulatory Commission, (Vol. 1, Rev. 1) January 1990, (Vol. 2) April 1989, (Vol. 3, Rev. 1) April 1990, (Vol. 4, Rev. 1) August 1989, (Vol. 5, Rev. 1) April 1990, (Vol. 6) April 1987, (Vol. 7, Rev. 1) May 1990.
1319. NRC Information Notice 92-18, "Potential for Loss of Remote Shutdown Capability During a Control Room Fire," U.S. Nuclear Regulatory Commission, February 28, 1992. [9202240025]
1320. SECY-89-170, "Fire Risk Scoping Study: Summary of Results and Proposed Staff Actions," June 7, 1989. [8906260024]
1321. NRC Information Notice 91-53, "Failure of Remote Shutdown System Instrumentation Because of Incorrectly Installed Components," U.S. Nuclear Regulatory Commission, September 4, 1991. [9108280089]
1322. IE Information Notice 87-12, "Potential Problems with Metal Clad Circuit Breakers, General Electric Type AKF-2-25," U.S. Nuclear Regulatory Commission, February 13, 1987. [8702110132]
1323. Memorandum for W. Minners, et al., from F. Rowsome, "Generic Issue 123, 'Deficiencies in the Regulations Suggested by the Davis-Besse Incident,'" November 21, 1985. [8512100189]
1324. ANSI/IEEE-ANS-7-4.3.2-1982, "Application Criteria for Programmable Digital Computer Systems in Safety Systems of Nuclear Power Generating Stations," American Nuclear Society, July 6, 1982.

1325. Regulatory Guide 1.152, "Criteria for Programmable Digital Computer System Software in Safety-Related Systems of Nuclear Power Plants," U.S. Nuclear Regulatory Commission, November 1985. [8511220286]
1326. NUREG-1289, "Regulatory and Backfit Analysis: Unresolved Safety Issue A-45, Shutdown Decay Heat Removal Requirements," U.S. Nuclear Regulatory Commission, November 1988.
1327. NUREG/CR-4639, "Nuclear Computerized Library for Assessing Reactor Reliability (NUCLARR)," U.S. Nuclear Regulatory Commission, (Vol. 1) February 1988, (Vol. 2) September 1988, (Vol. 3) November 1988, (Vol. 4) June 1988, (Vol. 5) June 1988.
1328. AEOD/E804, "Reliability of Non-Safety Related Field Breakers During ATWS Events," Office for Analysis and Evaluation of Operational Data, U.S. Nuclear Regulatory Commission, July 26, 1988. [8905020208]
1329. Memorandum for T. King from K. Kniel, "Request for Prioritization of New Generic Safety Issue 'Reliability of Recirculation Pump Trip (RPT) During an ATWS,'" March 17, 1989. [9507280112]
1330. Memorandum for T. King from W. Minners, "Overpressurization of Containment Penetrations," March 16, 1989. [9507280122]
1331. NUREG/CR-4220, "Reliability Analysis of Containment Isolation Systems," U.S. Nuclear Regulatory Commission, June 1985.
1332. NUREG-0797, "Safety Evaluation Report Related to the Operation of Comanche Peak Steam Electric Station, Units 1 and 2," U.S. Nuclear Regulatory Commission, (Supplement 9) March 1985.
1333. NSAC-148, "Service Water Systems and Nuclear Plant Safety," Electric Power Research Institute, May 1990.
1334. NUREG/CR-2797, "Evaluation of Events Involving Service Water Systems in Nuclear Power Plants," U.S. Nuclear Regulatory Commission, November 1982.
1335. Memorandum for W. Minners from F. Rowsome, "A Candidate Generic Safety Issue," December 11, 1984. [8501090105]
1336. Memorandum for B. Morris from L. Shao, "Resolution of Generic Issue 119.2," July 16, 1990. [9507280130]
1337. Memorandum for J. Taylor from E. Beckjord, "Proposed Resolution and Closeout of Generic Issue 135, 'Steam Generator and Steam Line Overfill Issues,'" March 29, 1991. [9507280149]
1338. RES Office Letter No. 7, "Procedures for Identification, Prioritization, Resolution, and Tracking of Generic Issues," February 16, 1996. [9608070117]

1339. Memorandum for All RES Employees from E. Beckjord, "Withdrawal of RES Office Letter No. 3, 'Procedure and Guidance for the Resolution of Generic Issues,'" June 2, 1994. [9704100042]
1340. Federal Register Notice 51 FR 12502, "10 CFR Part 50, Modification of General Design Criterion 4 Requirements for Protection Against Dynamic Effects of Postulated Pipe Ruptures," April 11, 1986.
1341. Federal Register Notice 51 FR 26393, "10 CFR Part 50, Modification of General Design Criterion 4 Requirements for Protection Against Dynamic Effects of Postulated Pipe Ruptures," July 23, 1986.
1342. Federal Register Notice 52 FR 41288, "10 CFR Part 50, Modification of General Design Criterion 4 Requirements for Protection Against Dynamic Effects of Postulated Pipe Ruptures," October 27, 1987.
1343. Federal Register Notice 53 FR 1968, "Standard Review Plan Revision," January 25, 1988.
1344. Federal Register Notice 52 FR 23376, "Standard Review Plan Issuance," June 19, 1987.
1345. NRC Letter to All Operating Licensees, Construction Permit Holders and Applicants for Construction Permits, "Relaxation in Arbitrary Intermediate Pipe Rupture Requirements (Generic Letter 87-11)," June 19, 1987. [8706230486]
1346. Memorandum for Distribution from G. Arlotto, "Termination of Proposed Revision to SRP 3.9.3," October 2, 1986. [8811180136]
1347. Regulatory Guide 1.84, "Design and Fabrication Code Case Acceptability -- ASME III, Division 1," U.S. Nuclear Regulatory Commission, (Rev. 30) October 31, 1994. [9411040236]
1348. Regulatory Guide 1.61, "Damping Values for Seismic Design of Nuclear Power Plants," U.S. Nuclear Regulatory Commission, October 1973. [7907100231]
1349. Memorandum for J. Roe from J. Wermiel, "Closure of Generic Issue No. 133, 'Update Policy on Nuclear Plant Staff Working Hours,'" July 10, 1991. [9107230263]
1350. NRC Information Notice No. 91-36, "Nuclear Plant Staff Working Hours," June 10, 1991. [9106040339]
1351. SECY-90-343, "Status of the Staff Program to Determine How the Lessons Learned from the Systematic Evaluation Program Have Been Factored into the Licensing Bases of Operating Plants," October 4, 1990. [9010150030]
1352. Memorandum for J. Knight, et al., from H. Thompson, "Action Plan for Resolving Failure of Tendon Anchorage at Farley 2 and for Determining Need for Immediate Licensing Action on Other Facilities," June 25, 1985. [8507030479]

1353. NUREG/CR-4712, "Regulatory Analysis of Regulatory Guide 1.35 (Revision 3, Draft 2) - In-Service Inspection of UngROUTED Tendons in Prestressed Concrete Containments," U.S. Nuclear Regulatory Commission, February 1987.
1354. NUREG-1407, "Procedural and Submittal Guidance for the Individual Plant Examination of External Events (IPEEE) for Severe Accident Vulnerabilities," U.S. Nuclear Regulatory Commission, June 1991.
1355. NRC Letter to All Licensees of Operating Pressurized Water Nuclear Power Reactors and Applicants for Operating Licenses (Except for St. Lucie, Unit No. 1), "Natural Circulation Cooldown (Generic Letter No. 81-21)," May 5, 1981. [8105140267]
1356. NRC Letter to All Operating Pressurized Water Reactors (PWR's) (Generic Letter 80-53), June 11, 1980. [8007230099]
1357. ANSI/ANS 2.3, "Estimating Tornado and Extreme Wind Characteristics at Nuclear Power Sites," American National Standards Institute, Inc., October 17, 1983.
1358. Memorandum for H. Thompson from G. Arlotto, "RES Input - Action Plan for Resolving Failure of Tendon Anchorage at Farley-2 and for Determining Need for Immediate Licensing Action on Other Facilities," July 31, 1985. [9312220342]
1359. Memorandum for T. Speis and E. Jordan from J. Knight, "Tendon Anchor Head Failure - Needed Licensing Action at Other Facilities," December 6, 1985. [8512240278]
1360. Regulatory Guide 1.35.1, "Determining Prestressing Forces for Inspection of Prestressed Concrete Containments," U.S. Nuclear Regulatory Commission, July 1990. [9503290310]
1361. Memorandum for E. Jordan from E. Beckjord, "CRGR Review of: 1. Regulatory Guide 1.35, Rev. 3, 'Inservice Inspection of UngROUTED Tendons in Prestressed Concrete Containments,' 2. Regulatory Guide 1.35.1, 'Determining Prestressing Forces for Inspection of Prestressed Concrete Containments,'" July 28, 1989. [8908100273]
1362. Memorandum for E. Beckjord from F. Gillespie, "Generic Concerns Arising from TMI-2 Cleanup," February 21, 1991. [9103010101]
1363. Memorandum for E. Beckjord from F. Gillespie, "Request for Generic Rulemaking Concerning Decommissioning Issues," January 7, 1992. [9201150209]
1364. Federal Register Notice 53 FR 24018, "10 CFR Parts 30, 40, 50, 51, 70, and 72, General Requirements for Decommissioning Nuclear Facilities," June 27, 1988.
1365. Memorandum for Z. Rosztoczy from S. Bajwa, "Generic Issue 148: Smoke Control and Manual Fire Fighting Effectiveness; Generic Issue 149: Adequacy of Fire Barriers," April 3, 1991. [9104080111]
1366. NUREG-1286, "Safety Evaluation Report Related to the Restart of Rancho Seco Nuclear Generating Station, Unit 1 Following the Event of December 26, 1985," U.S. Nuclear Regulatory Commission, October 1987.

1367. Memorandum for W. Russell from A. Thadani, "Task Action Plan for Resolution of Service Water System Problems," June 27, 1991. [9107120290]
1368. NRC Letter to Licensees and Applicants of the Following Pressurized-Water Reactor Nuclear Power Plants: 1. Braidwood Units 1 and 2; 2. Byron Units 1 and 2; 3. Catawba Units 1 and 2; 4. Comanche Peak Units 1 and 2; 5. Cook Units 1 and 2; 6. Diablo Canyon Units 1 and 2; 7. McGuire Units 1 and 2, "Request for Information Related to the Resolution of Generic Issue 130, 'Essential Service Water System Failures at Multi-Unit Sites,' Pursuant to 10 CFR 50.54(f) - Generic Letter 91-13," September 19, 1991. [9109160253]
1369. NUREG-1269, "Loss of Residual Heat Removal System, Diablo Canyon Unit 2, April 10, 1987," U.S. Nuclear Regulatory Commission, June 1987.
1370. SECY-91-283, "Evaluation of Shutdown and Low Power Risk Issues," September 9, 1991. [9109120134]
1371. NUREG/CR-4960, "Control Room Habitability Survey of Licensed Commercial Nuclear Power Generating Stations," U.S. Nuclear Regulatory Commission, October 1988.
1372. Regulatory Guide 4.7, "General Site Suitability Criteria for Nuclear Power Stations," U.S. Nuclear Regulatory Commission, September 1974, (Rev. 1) November 1975. [7907200072]
1373. Regulatory Guide 1.78, "Assumptions for Evaluating the Habitability of a Nuclear Power Plant Control Room During a Postulated Hazardous Chemical Release," U.S. Nuclear Regulatory Commission, June 1974. [8001240567]
1374. Regulatory Guide 1.91, "Evaluations of Explosions Postulated to Occur on Transportation Routes Near Nuclear Power Plants," U. S. Nuclear Regulatory Commission, January 1975, (Rev. 1) February 1978 [8808230010].
1375. Regulatory Guide 1.95, "Protection of Nuclear Power Plant Control Room Operators Against an Accidental Chlorine Release," U.S. Nuclear Regulatory Commission, February 1975, (Rev. 1) January 1977 [8001240569].
1376. Letter to D. Solberg (NRC) from T. Charlton (INEL), "Transmittal of Letter Report on Turbine Trip Failure Events - TRC-28-88," April 27, 1988. [9502070128]
1377. Memorandum for R. Baer from C. Hrabal, "Prioritization of GI-144, 'SCRAM Without a Turbine/Generator Trip,'" September 24, 1991. [9312220339]
1378. Memorandum for T. King from K. Kniel, "Request for Prioritization of New Generic Safety Issue 'SCRAM Without a Turbine/Generator Trip,'" March 22, 1988. [9312220315]
1379. NUREG/CR-5653, "Recriticality in a BWR Following a Core Damage Event," U.S. Nuclear Regulatory Commission, November 1990.
1380. Memorandum for W. Minners from B. Sheron, "Request for Prioritization of Potential Generic Issues," September 4, 1984. [8409170085]

1381. Memorandum for W. Minners from B. Sheron, "Update of Generic Issue Management Control System (GIMCS)," July 5, 1991. [9312220300]
1382. NUREG-1365, "Revised Severe Accident Research Program Plan," U.S. Nuclear Regulatory Commission, August 1989, (Rev. 1) December 1992.
1383. Memorandum for R. Baer from S. Diab, "Supporting Analyses for Prioritization of Issue 110, 'Equipment Protective Devices on Engineered Safety Features,'" April 16, 1992. [9312220226]
1384. Memorandum for W. Dircks for R. Fraley, "Bolt Failures in Nuclear Power Plants," October 20, 1981. [8201200698]
1385. NRC Letter to All Holders of Operating Licenses or Construction Permits for Nuclear Power Plants, "Generic Safety Issue 29, 'Bolting Degradation or Failure in Nuclear Power Plants,' (Generic Letter 91-17)," October 17, 1991. [9110150302]
1386. NRC Letter to All Licensees of Operating PWRs and Holders of Construction Permits for PWRs, "Boric Acid Corrosion of Carbon Steel Reactor Pressure Boundary Components in PWR Plants (Generic Letter 88-05)," March 17, 1988. [8803220364]
1387. NRC Letter to All Licensees, Applicants and Holders of Operating Licenses Not Required to be Reviewed for Seismic Adequacy of Equipment Under the Provisions of USI A-46, 'Seismic Qualification of Equipment in Operating Plants,' "Verification of Seismic Adequacy of Mechanical and Electrical Equipment in Operating Reactors, Unresolved Safety Issue (USI) A-46 (Generic Letter 87-03)," February 27, 1987. [8703060307]
1388. NRC Bulletin No. 89-02, "Stress Corrosion Cracking of High-Hardness Type 410 Stainless Steel Internal Preloaded Bolting in Anchor Darling Model S350W Swing Check Valves or Valves of Similar Design," U.S. Nuclear Regulatory Commission, July 19, 1989. [8907110441]
1389. NRC Compliance Bulletin No. 87-02, "Fastener Testing to Determine Conformance with Applicable Material Specifications," U.S. Nuclear Regulatory Commission, November 6, 1987 [8711050040], (Supplement 1) April 22, 1988 [8804180142], (Supplement 2) June 10, 1988 [8806090301].
1390. NRC Information Notice No. 89-22, "Questionable Certification of Fasteners," U.S. Nuclear Regulatory Commission, March 3, 1989. [8902270158]
1391. NRC Information Notice No. 89-56, "Questionable Certification of Material Supplied to the Defense Department by Nuclear Suppliers," U.S. Nuclear Regulatory Commission, July 20, 1989 [8907140274], (Supplement 1) November 22, 1989 [8911160058], (Supplement 2) July 19, 1991 [9107120259].
1392. NRC Information Notice No. 89-70, "Possible Indications of Misrepresented Vendor Products," U.S. Nuclear Regulatory Commission, October 11, 1989 [8910040381], (Supplement 1) April 26, 1990 [9004200525].

1393. IE Information Notice No. 86-25, "Traceability and Material Control of Material and Equipment, Particularly Fasteners," U.S. Nuclear Regulatory Commission, April 11, 1986. [8604090451]
1394. Memorandum for J. Taylor from E. Beckjord, "Resolution of Generic Safety Issue 29, 'Bolting Degradation or Failure in Nuclear Power Plants,'" October 25, 1991. [9312220296]
1395. NUREG-1339, "Resolution of Generic Safety Issue 29: Bolting Degradation or Failure in Nuclear Power Plants," U.S. Nuclear Regulatory Commission, June 1990.
1396. Federal Register Notice 56 FR 36081, "10 CFR Parts 21 and 50, Criteria and Procedures for the Reporting of Defects and Conditions of Construction Permits," July 31, 1991.
1397. SECY-91-150, "Proposed Amendments to 10 CFR Part 21, 'Reporting of Defects and Noncompliance' and 10 CFR 50.55(e), 'Conditions of Construction Permits,'" May 22, 1991. [9106040262]
1398. NUREG-1445, "Regulatory Analysis for the Resolution of Generic Safety Issue-29: Bolting Degradation or Failure in Nuclear Power Plants," U.S. Nuclear Regulatory Commission, September 1991.
1399. NRC Letter to All Holders of Operating Licenses, "Resolution of Generic Issue A-30, 'Adequacy of Safety-Related DC Power Supplies,' Pursuant to 10 CFR 50.54(f) (Generic Letter 91-06)," April 29, 1991. [9104170256]
1400. NRC Letter to All Holders of Operating Licenses, "Resolution of Generic Issues 48, 'LCOs for Class 1E Vital Instrument Buses,' and 49, 'Interlocks and LCOs for Class 1E Tie Breakers' Pursuant to 10 CFR 50.54(f) (Generic Letter 91-11)," July 18, 1991. [9107160296]
1401. NUREG/CR-5414, "Technical Findings for Proposed Integrated Resolution of Generic Issue 128, Electric Power Reliability," U.S. Nuclear Regulatory Commission, November 1989.
1402. Memorandum for J. Taylor from E. Beckjord, "Resolution of GI-128, Electrical Power Reliability," September 12, 1991. [9312220229]
1403. NUREG/CR-5406, "BWR Reactor Water Cleanup System Flexible Wedge Gate Isolation Valve Qualification and High Energy Flow Interruption Test," U.S. Nuclear Regulatory Commission, (Vol. 1) October 1989, (Vol. 2) October 1989, (Vol. 3) October 1989.
1404. NUREG/CR-5558, "Generic Issue 87: Flexible Wedge Gate Valve Test Program," U.S. Nuclear Regulatory Commission, January 1991.
1405. SECY-82-1B, "Proposed Commission Policy Statement on Severe Accidents and Related Views on Nuclear Reactor Regulation," November 24, 1982. [8301120513]
1406. Memorandum for J. Taylor from E. Beckjord, "Technical Resolution of Generic Issue 87, 'Failure of HPCI Steam Line Without Isolation,'" December 9, 1991. [9312220344]

1407. NUREG/CR-4681, "Enclosure Environment Characterization Testing for the Base Line Validation of Computer Fire Simulation Codes," U.S. Nuclear Regulatory Commission, March 1987.
1408. NUREG/CR-5526, "Analysis of Risk Reduction Measures Applied to Shared Essential Service Water Systems at Multi-Unit Sites," U.S. Nuclear Regulatory Commission, June 1991.
1409. NUREG-1421, "Regulatory Analysis for the Resolution of Generic Issue 130: Essential Service Water System Failures at Multi-Unit Sites," U.S. Nuclear Regulatory Commission, June 1991.
1410. Memorandum for J. Taylor from E. Beckjord, "Resolution of Generic Issue 130, 'Essential Service Water System Failures at Multi-Unit Sites,'" September 23, 1991. [9312220347]
1411. NUREG/CR-4893, "Technical Findings Report for Generic Issue 135, Steam Generator and Steam Line Overfill Issues," U.S. Nuclear Regulatory Commission, May 1991.
1412. Memorandum for J. Taylor, et al., from S. Chilk "SECY-91-132 - Evaluation of the Feasibility of Initiating a Consensus Process to Address Issues Related to the Below Regulatory Concern Policy," June 28, 1991. [9109060094]
1413. SECY-92-045, "Enhanced Participatory Rulemaking Process," February 7, 1992. [9202130092]
1414. Memorandum for K. Kniel from G. Lainas, "Proposed Generic Issue Deintering Upon Discovery of Reactor Coolant System Leakage," August 1, 1986. [8608110015]
1415. Letter to D. Basdekas (NRC) from J. Lambright (SNL), "Generic Issue 148, 'Smoke Control and Manual Fire Fighting Effectiveness,'" March 4, 1992. [9502070165]
1416. Memorandum for B. Morris from W. Minners, "Prioritization of Proposed New Generic Issue," December 4, 1989. [9312220350]
1417. NUREG/CR-5856 "Identification and Evaluation of PWR In-Vessel Severe Accident Management Strategies," U.S. Nuclear Regulatory Commission, March 1992.
1418. Memorandum for T. Murley from E. Beckjord, "A New Generic Issue: Multiple Steam Generator Tube Leakage," June 16, 1992. [9212040356]
1419. Memorandum for C. Serpan from J. Muscara, "Steam Generator Tube Inspection, Integrity and Plugging Issues," March 16, 1992. [9212040327]
1420. Letter to J. Cross (Portland General Electric Company) from L. Kokajko (NRC), "Issuance of Amendment for Trojan Nuclear Plant (TAC No. M82287)," February 5, 1992. [9202130137]
1421. Letter to the NRC from J. Cross (Portland General Electric Company), "Request for Additional Information Regarding Trojan Steam Generator Tube Structural Integrity Report

- and License Change Application (LCA) 219 Dated January 3, 1992 (TAC No. M82287)," January 16, 1992. [9201220023]
1422. NUREG/CR-0718, "Steam Generator Tube Integrity Program Phase I Report," U.S. Nuclear Regulatory Commission, September 1979.
1423. NUREG-1350, "Nuclear Regulatory Commission Information Digest," U.S. Nuclear Regulatory Commission, (Vol. 4) March 1992, (Vol. 7) March 1995.
1424. EGG-PE-6670, "Generic Cost Analysis for Steam Generator Repairs and Replacement," Idaho National Engineering Laboratory, August 1984.
1425. SECY-91-270, "Interim Guidance on Staff Implementation of the Commission's Safety Goal Policy," August 27, 1991. [9109030213]
1426. Memorandum for R. Emrit from G. Burdick, "Multiple Steam Generator Tube Leakage," October 30, 1992. [9502070227]
1427. SECY-92-292, "Advance Notice of Proposed Rulemaking on Severe Accident Plant Performance Criteria for Future LWRs," August 21, 1992. [9208250010]
1428. NUREG/CR-4470, "Survey and Evaluation of Vital Instrumentation and Control Power Supply Events," U.S. Nuclear Regulatory Commission, August 1986.
1429. NUREG-1455, "Transformer Failure and Common-Mode Loss of Instrument Power at Nine Mile Point Unit 2 on August 13, 1991," U.S. Nuclear Regulatory Commission, October 1991.
1430. Memorandum for T. Martin et al., from T. Murley, "Preliminary Results from Individual Plant Examinations (IPE)," April 22, 1991. [9105020194]
1431. NRC Letter to All Holders of Operating Licenses or Construction Permits for Pressurized Water Reactors (PWRs), "Resolution of Generic Issue 79, 'Unanalyzed Reactor Vessel (PWR) Thermal Stress During Natural Convection Cooldown' (Generic Letter 92-02)," March 6, 1992. [9203030209]
1432. Memorandum for J. Taylor from E. Beckjord, "Resolution of Generic Issue 79, 'Unanalyzed Reactor Vessel (PWR) Thermal Stress During Natural Convection Cooldown,'" May 4, 1992. [9312220157]
1433. Memorandum for C. Heltemes from F. Gillespie, "Generic Issue 163, 'Multiple Steam Generator Tube Leakage,'" November 24, 1992. [9212040320]
1434. Memorandum for E. Beckjord from L. Shao, "Interim Plugging Criteria for Trojan Nuclear Plant," December 9, 1992. [9212140066]
1435. Memorandum for F. Gillespie from C. Heltemes, "GI-163, 'Multiple Steam Generator Tube Leakage,'" September 28, 1992. [9212040379]
1436. Federal Register Notice 51 FR 27817, "10 CFR Parts 50 and 73, Miscellaneous Amendments Concerning Physical Protection of Nuclear Power Plants," August 4, 1986.

1437. NRC Letter to All Power Reactor Licensees, "Implementation of 10 CFR 73.55 Miscellaneous Amendments and Search Requirements (Generic Letter 87-08)," May 11, 1987. [8705110372]
1438. Regulatory Guide 5.65, "Vital Area Access Controls, Protection of Physical Security Equipment, and Key and Lock Controls," U.S. Nuclear Regulatory Commission, September 1986. [8610030129]
1439. Memorandum for J. Taylor from E. Beckjord, "Resolution of Generic Issue 151 'Reliability of ATWS Recirculation Pump Trip in BWRs,'" September 29, 1992. [9312220159]
1440. NUREG/CR-2336, "Steam Generator Tube Integrity Program," U.S. Nuclear Regulatory Commission, August 1988.
1441. Memorandum for T. Murley from E. Beckjord, "Interim Plugging Criteria for Trojan Nuclear Plant," January 5, 1993. [9301110331]
1442. Memorandum for T. Murley from E. Beckjord, "Interim Plugging Criteria for Trojan Nuclear Plant," January 15, 1993. [9301250251]
1443. SECY-90-160, "Proposed Rule on Nuclear Power Plant License Renewal," May 3, 1990. [9005080305]
1444. NUREG-1412, "Foundation for the Adequacy of the Licensing Bases," U.S. Nuclear Regulatory Commission, December 1991.
1445. NUREG/CR-6010, "History and Current Status of Generation 3 Thermal Sleeves in Westinghouse Nuclear Power Plants," U.S. Nuclear Regulatory Commission, July 1992.
1446. Memorandum for J. Taylor from E. Beckjord, "Technical Resolution of Generic Issue 73, 'Detached Thermal Sleeves,'" September 2, 1992. [9210070203]
1447. Memorandum for D. Eisenhut, et al., from R. Vollmer, "Evaluation of Allegations Regarding Class 1 Piping Design Deficiencies (TAC #49242)," September 1, 1983. [8309210477]
1448. IE Information Notice No. 83-80, "Use of Specialized 'Stiff' Pipe Clamps," November 23, 1983. [8311010020]
1449. NUREG/CR-2405, "Subsystem Fragility - Seismic Safety Margins Research Program (Phase 1)," U.S. Nuclear Regulatory Commission, February 1982.
1450. Memorandum for J. Taylor from E. Beckjord, "Resolution of Generic Issue 113, 'Dynamic Qualification and Testing of Large Bore Hydraulic Snubbers,'" August 27, 1992. [9312220197]
1451. Memorandum for J. Taylor from E. Beckjord, "Resolution of Generic Issue (GI) 121, 'Hydrogen Control for PWR Dry Containments,'" March 24, 1992. [9312220194]

1452. Memorandum for W. Minners from F. Gillespie, "Prioritization of Generic Issue 78, 'Monitoring of Design Basis Transient Fatigue Limits for Reactor Coolant System,'" June 10, 1992. [9312220188]
1453. NRC Information Notice 92-06, "Reliability of ATWS Mitigation System and Other NRC Required Equipment Not Controlled by Plant Technical Specifications," January 15, 1992 [9201080305], (Supplement 1) July 1, 1993 [9306250303].
1454. Memorandum for W. Minners from B. Sheron, "Proposed Generic Issue 'RHR Pumps Inside Containment,'" August 23, 1985. [8508290373]
1455. NUREG/CR-5300, "Integrated Reliability and Risk Analysis System (IRRAS) Version 2.5," U.S. Nuclear Regulatory Commission, (Vol. 1) March 1991.
1456. NUREG/CR-5303, "System Analysis and Risk Assessment System (SARA) Version 4.0," U.S. Nuclear Regulatory Commission, (Vol. 1) February 1992, (Vol. 2) January 1992.
1457. Letter to C. Rourke (NRC) from N. Anderson (INEL), "Transmittal of Final Report, 'Analysis of Plant Specific Responses for the Resolution of Generic Issue A-30, Adequacy of Safety-Related DC Power Supplies,' (FIN D6025) NRA-20-92," July 9, 1992. [9502070242]
1458. SECY-87-297, "MARK I Containment Performance Program Plan," December 8, 1987. [8803080354]
1459. SECY-89-017, "MARK I Containment Performance Improvement Program," January 23, 1989. [8903090205]
1460. Memorandum for V. Stello from S. Chilk, "SECY-89-017 - MARK I Containment Performance Improvement Program," July 11, 1989. [8907270013]
1461. SECY-91-316, "Status of Severe Accident Research," October 7, 1991. [9110160271]
1462. Letter to D. Grace (BWR Owners Group) from A. Thadani (NRC), "Safety Evaluation of 'BWR Owners' Group - Emergency Procedure Guidelines, Revision 4,' NEDO-31331, March 1987," September 12, 1988. [8809190198]
1463. NRC Letter to All Holders of Operating Licenses for Nuclear Power Reactors With Mark I Containments, "Installation of a Hardened Wetwell Vent (Generic Letter No. 89-16)," September 1, 1989. [8909010375]
1464. NUREG/CR-5662, "Hydrogen Combustion, Control, and Value-Impact Analysis for PWR Dry Containments," U.S. Nuclear Regulatory Commission, June 1991.
1465. NUREG-1465, "Accident Source Terms for Light-Water Nuclear Power Plants," U.S. Nuclear Regulatory Commission, February 1995.
1466. NUREG/CR-5460, "A Cause-Defense Approach to the Understanding and Analysis of Common Cause Failures," U.S. Nuclear Regulatory Commission, March 1990.

1467. Federal Register Notice 56 FR 31306, "10 CFR 50, RIN 3150-AD00, Monitoring the Effectiveness of Maintenance at Nuclear Power Plants," July 10, 1991.
1468. Memorandum for E. Beckjord from F. Gillespie, "Potential Generic Issue - Adequacy of Emergency and Essential Lighting - (RES Office Letter No. 1, Rev. 1)," September 14, 1990. [9009210192]
1469. NUREG/CR-4834, "Recovery Actions in PRA for the Risk Methods Integration and Evaluation Program (RMIEP)," U.S. Nuclear Regulatory Commission, (Vol. 1) June 1987.
1470. NUREG/CR-4674, "Precursors to Potential Severe Core Damage Accidents," U.S. Nuclear Regulatory Commission, (Vols. 15 and 16) September 1992.
1471. NRC Information Notice No. 90-69, "Adequacy of Emergency and Essential Lighting," U.S. Nuclear Regulatory Commission, October 31, 1990. [9010250054]
1472. NUREG-1272, "Office for Analysis and Evaluation of Operational Data 1991 Annual Report," U.S. Nuclear Regulatory Commission, (Vol. 6, No. 1) August 1992.
1473. Memorandum for J. Taylor from S. Chilk, "SECY-89-102 - Implementation of the Safety Goals," June 15, 1990. [9007090094]
1474. Letter to W. Conway (Arizona Public Service Company) from C. Trammell (NRC), "Review of Eddy-Current Inspections of Steam Generator Tubes - Palo Verde Nuclear Generating Station, Unit No. 2 (TAC No. M86178)," June 8, 1993. [9306100267]
1475. NUREG-1477, "Voltage-Based Interim Plugging Criteria for Steam Generator Tubes," U.S. Nuclear Regulatory Commission, (Draft) June 1993.
1476. Memorandum for T. Murley from E. Beckjord, "Recommendations Regarding Revision of Standard Review Plan Sections Related to 'Stiff Pipe Clamps,'" August 12, 1992. [9312220199]
1477. Memorandum for T. Speis from F. Gillespie, "Consideration of New Generic Issue on 'Support Flexibility of Equipment and Components,'" January 30, 1989. [8903010215]
1478. NUREG/CR-2999, "Final Report USNRC Anchor Bolt Study: Data Survey and Dynamic Testing," U.S. Nuclear Regulatory Commission, December 1982.
1479. SECY-93-108, "Revised Guidelines for Prioritization of Generic Safety Issues," April 28, 1993. [9308230261]
1480. EPRI NP-6154, "Proceedings: EPRI/NRC/TPC Workshop on Seismic Soil-Structure Interaction Analysis Techniques Using Data From Lotung, Taiwan," Electric Power Research Institute, (Vol. 1) March 1989, (Vol. 2) March 1989.
1481. Memorandum for E. Beckjord from T. Murley, "Potential New Generic Issues," September 25, 1991. [9110250132]

1482. Memorandum for T. Murley from E. Beckjord, "Prioritization of Generic Issue 161, 'Associated Circuits,'" March 12, 1993. [9312220201]
1483. Regulatory Guide 1.9, "Selection, Design, and Qualification of Diesel-Generator Units Used as Standby (Onsite) Electric Power Systems at Nuclear Power Plants," March 1971, (Rev. 1) November 1978, (Rev. 2) December 1979 [8001220580], (Rev. 3) July 1993 [9308180045].
1484. Regulatory Guide 1.160, "Monitoring the Effectiveness of Maintenance at Nuclear Power Plants," U.S. Nuclear Regulatory Commission, June 1993 [9306250035], (Rev. 1) January 1995 [9501300137].
1485. Federal Register Notice 58 FR 41813, "Regulatory Guide; Withdrawal," August 5, 1993.
1486. Memorandum for J. Taylor from E. Beckjord, "Resolution of Generic Safety Issue B-56, 'Diesel Generator Reliability,'" June 29, 1993. [9312220205]
1487. NRC Letter to All Licensees of Operating Reactors, Applicants for An Operating License, and Holders of Construction Permits, "Proposed Staff Actions to Improve and Maintain Diesel Generator Reliability (Generic Letter 84-15)," July 2, 1984. [8407020206]
1488. Memorandum for E. Jordan from T. Novak, "Engineering Evaluation Report - Pump Damage Due to Low Flow Cavitation (AEOD/E807)," October 18, 1988. [9312220206, 8811170140, 8810250191]
1489. NRC Bulletin No. 88-04, "Potential Safety-Related Pump Loss," U.S. Nuclear Regulatory Commission, May 5, 1988. [8804290177]
1490. NUREG/CR-5706, "Potential Safety-Related Pump Loss: An Assessment of Industry Data," U.S. Nuclear Regulatory Commission, June 1991.
1491. Memorandum for J. Norberg from R. Jones, "Review of Responses to Bulletin 88-04," July 22, 1991. [9108010062]
1492. NUREG/CR-5404, "Auxiliary Feedwater System Aging Study," U.S. Nuclear Regulatory Commission, (Vol. 1) March 1990, (Vol. 2) July 1993.
1493. Memorandum for V. Stello from S. Chilk, "Staff Requirements - Briefing on Status of Unresolved Safety/Generic Issues, 10:00 a.m., Wednesday, October 21, 1987, Commissioners' Conference Room, D. C. Office (Open to Public Attendance)," November 6, 1987. [8711100418]
1494. NUREG/CR-5604, "Assessment of ISLOCA Risk - Methodology and Application to a Babcock and Wilcox Nuclear Power Plant," U.S. Nuclear Regulatory Commission, (Vol. 1) April 1992, (Vol. 2) April 1992, (Vol. 3) April 1992.
1495. NUREG/CR-5744, "Assessment of ISLOCA Risk - Methodology and Application to a Westinghouse Four-Loop Ice Condenser Plant," U.S. Nuclear Regulatory Commission, April 1992.

1496. NUREG/CR-5745, "Assessment of ISLOCA Risk - Methodology and Application to a Combustion Engineering Plant," U.S. Nuclear Regulatory Commission, April 1992.
1497. NUREG/CR-5603, "Pressure-Dependent Fragilities for Piping Components," U.S. Nuclear Regulatory Commission, October 1990.
1498. NUREG/CR-5862, "Screening Methods for Developing Internal Pressure Capacities for Components in Systems Interfacing With Nuclear Power Plant Reactor Coolant Systems," U.S. Nuclear Regulatory Commission, May 1992.
1499. NUREG/CR-5928, "ISLOCA Research Program Final Report," U.S. Nuclear Regulatory Commission, July 1993.
1500. NUREG/CR-5102, "Interfacing System LOCA: Pressurized Water Reactors," U.S. Nuclear Regulatory Commission, February 1989.
1501. NUREG-1463, "Regulatory Analysis for the Resolution of Generic Safety Issue 105: Interfacing System Loss-of-Coolant Accident in Light-Water Reactors," U.S. Nuclear Regulatory Commission, July 1993.
1502. NRC Information Notice 92-36, "Intersystem LOCA Outside Containment," May 7, 1992 [9205010045], (Supplement 1) February 22, 1994 [9402150320].
1503. Memorandum for F. Gillespie from W. Minners, "Proposed Resolution of Generic Issue 105, 'Interfacing Systems LOCA in LWRs,'" April 2, 1993. [9312220208]
1504. Memorandum for J. Taylor from E. Beckjord, "Technical Resolution of Generic Issue 105 (GI-105) 'Interfacing Systems Loss of Coolant Accident (ISLOCA) in LWRs,'" June 3, 1993. [9312220210]
1505. Memorandum for J. Taylor from S. Chilk, "SECY-93-108 - Revised Guidelines for Prioritization of Generic Safety Issues," July 23, 1993. [9308270094]
1506. Memorandum for W. Minners from L. Shao, "Closeout of GSI 119.4," July 17, 1992. [9312220212]
1507. Regulatory Guide 1.44, "Control of the Use of Sensitized Stainless Steel," U.S. Atomic Energy Commission, May 1973. [7907100182]
1508. Memorandum for J. Taylor from E. Beckjord, "Final Technical Resolution of Generic Safety Issue 120, 'On-Line Testability of Protection System,'" March 4, 1993. [9502070269]
1509. Letter to J. Taylor from P. Shewmon, "Prioritization of Generic Issue 152, 'Design Basis for Valves that Might Be Subjected to Significant Blowdown Loads,'" April 23, 1993. [9305060143]
1510. Letter to J. Wilkins (ACRS) from J. Taylor (EDO) June 8, 1993. [9306210081, 9305200137]
1511. Memorandum for J. Taylor from E. Beckjord, "Resolution of GI-142, 'Leakage Through Electrical Isolators,'" March 9, 1993. [9312220214]

1512. NUREG-1461, "Regulatory Analysis for the Resolution of Generic Issue 153: Loss of Essential Service Water in LWRs," U.S. Nuclear Regulatory Commission, August 1993.
1513. Memorandum for J. Taylor from E. Beckjord, "Resolution of Generic Issue 153 (GI-153), 'Loss of Essential Service Water in LWRs,'" June 14, 1993. [9312220216]
1514. NUREG/CR-5910, "Loss of Essential Service Water in LWRs (GI-153)," U.S. Nuclear Regulatory Commission, August 1992.
1515. Memorandum for E. Beckjord from T. Murley, "Proposed New Generic Issue: 'Determination of Neutron Fluence to PWR Pressure Vessels,'" October 8, 1992. [9210190215]
1516. Memorandum for T. Murley from E. Beckjord, "Proposed New Generic Issue: Determination of Neutron Fluence to PWR Pressure Vessels," November 30, 1992. [9312220218]
1517. Memorandum for J. Sniezek from T. Murley and E. Beckjord, "Resolution of Fatigue and Environmental Qualification Issues Related to License Renewal," April 1, 1993. [9304270324]
1518. Memorandum for The Chairman, et al., from J. Taylor, "Environmental Qualification of Electric Equipment," May 27, 1993. [9308180153]
1519. SEASF-LR-92-022, "Supplemental Study of Generic Issue No. 153, 'Loss of Essential Service Water in LWRs,'" Science and Engineering Associates, Inc., (Rev. 1) January 1993. [9502070279]
1520. Memorandum for E. Beckjord from T. Murley, "Request to Prioritize a New Generic Issue for Spring-Actuated Safety and Relief Valve Reliability," October 8, 1992. [9312280153]
1521. NUREG/CR-3696, "Potential Human Factors Deficiencies in the Design of Local Control Stations and Operator Interfaces in Nuclear Power Plants," U.S. Nuclear Regulatory Commission, April 1984.
1522. NUREG/CR-3217, "Near-Term Improvements for Nuclear Power Plant Control Room Annunciator Systems," U.S. Nuclear Regulatory Commission, April 1983.
1523. NUREG/CR-3987, "Computerized Annunciator Systems," U.S. Nuclear Regulatory Commission, June 1985.
1524. NUREG/CR-5572, "An Evaluation of the Effects of Local Control Station Design Configurations on Human Performance and Nuclear Power Plant Risk," U.S. Nuclear Regulatory Commission, September 1990.
1525. Memorandum for J. Taylor from E. Beckjord, "Termination of Work on Generic Safety Issue HF5.1 'Local Control Stations,'" June 29, 1993. [9312220224]
1526. Memorandum for J. Taylor from E. Beckjord, "Resolution of Human Factors Generic Issue 5.2, 'Review Criteria for Human Factors Aspects of Advanced Controls and Instrumentation,'" June 29, 1993. [9312220225]

1527. NUREG/CR-5186, "Value/Impact Analysis of Generic Issue 94, 'Additional Low Temperature Overpressure Protection for Light Water Reactors,'" U.S. Nuclear Regulatory Commission, November 1988.
1528. NRC Information Notice No. 90-22, "Unanticipated Equipment Actuations Following Restoration of Power to Rosemount Transmitter Trip Units," U.S. Nuclear Regulatory Commission, March 23, 1990. [9003190349]
1529. NUREG-1422, "Summary of Chernobyl Followup Research Activities," U.S. Nuclear Regulatory Commission, June 1992.
1530. Memorandum for J. Taylor from E. Beckjord, "Resolution of Generic Issue 155.1, 'More Realistic Source Term Assumptions,'" March 13, 1995. [9511090074]
1531. NUREG-0940, "Enforcement Actions: Significant Actions Resolved," U.S. Nuclear Regulatory Commission, (Vol. 14, No. 2, Parts 1, 2, and 3) August 1995.
1532. Memorandum for C. Serpan from W. Minners, "Identification of New Generic Issue: Hydrogen Storage Facility Separation," December 16, 1993. [9312290134]
1533. Letter to the NRC from M. Tuckman (Duke Power Company), "Oconee Nuclear Station, Docket Nos. 50-269, 50-270, and 50-287, Generic Letter 88-20," November 30, 1990. [9012060005]
1534. EGG-SSRE-9747, "Improved Estimates of Separation Distances to Prevent Unacceptable Damage to Nuclear Power Plant Structures from Hydrogen Detonation for Gaseous Hydrogen Storage," Idaho National Engineering Laboratory, (Draft) November 1993. [9502070287]
1535. SCIE-EGG-103-89, "Draft Technical Evaluation Report on U.S. Commercial Power Reactor Hydrogen Tank Farms and Their Compliance With Separation Distance Safety Criteria," Scientech, Inc., March 1990. [9502070289]
1536. Memorandum for J. Taylor from E. Beckjord, "Resolution of GI-I.D.3, 'Safety System Status Monitoring,'" August 20, 1993. [9502070295]
1537. Memorandum for T. Murley from E. Beckjord, "Research Information Letter Number 171, 'Continuous On-Line Reactor Surveillance System,'" May 4, 1993. [9305100271]
1538. Memorandum for J. Taylor from E. Beckjord, "Closure of Generic Issue I.D.5(3), 'On-Line Automated Continuous Reactor Surveillance Systems,'" November 12, 1993. [9502070301]
1539. SECY-93-119, "TMI-2 Vessel Investigation Project," May 5, 1993. [9305100253]
1540. Memorandum for J. Taylor from E. Beckjord, "Closure of Generic Issue II.H.2, 'Obtain Data on Conditions Inside TMI-2 Containment,'" February 9, 1994. [9502070304]
1541. NUREG-1472, "Regulatory Analysis for the Resolution of Generic Issue 57: Effects of Fire Protection System Actuation on Safety-Related Equipment," U.S. Nuclear Regulatory Commission, October 1993.

1542. Memorandum for J. Taylor from E. Beckjord, "Resolution of Generic Safety Issue (GSI)-57, 'Effects of Fire Protection System Actuation on Safety-Related Equipment,'" September 30, 1993. [9502070315]
1543. NRC Information Notice 94-12, "Insights Gained from Resolving Generic Issue 57: Effects of Fire Protection System Actuation on Safety-Related Equipment," U.S. Nuclear Regulatory Commission, February 9, 1994. [9402030011]
1544. NUREG/CR-5759, "Risk Analysis of Highly Combustible Gas Storage, Supply, and Distribution Systems in Pressurized Water Reactor Plants," U.S. Nuclear Regulatory Commission, June 1993.
1545. NUREG-1364, "Regulatory Analysis for the Resolution of Generic Safety Issue 106: Piping and the Use of Highly Combustible Gases in Vital Areas," U.S. Nuclear Regulatory Commission, June 1993.
1546. Memorandum for J. Taylor from E. Beckjord, "Proposed Resolution of GSI-106, 'Piping and the Use of Highly Combustible Gases in Vital Areas,'" November 3, 1993. [9502070320]
1547. Letter to All Holders of Operating Licenses or Construction Permits for Nuclear Power Reactors, "Research Results on Generic Safety Issue 106, 'Piping and the Use of Highly Combustible Gases in Vital Areas,' (Generic Letter 93-06)," U.S. Nuclear Regulatory Commission, October 25, 1993. [9310200286]
1548. Memorandum for F. Gillespie from E. Beckjord, "Generic Letter for Implementation of Resolution of Generic Safety Issue 106, 'Piping and the Use of Highly Combustible Gases in Vital Areas,'" December 14, 1992. [9502070322]
1549. NUREG-1427, "Regulatory Analysis for the Resolution of Generic Issue 143: Availability of Chilled Water System and Room Cooling," U.S. Nuclear Regulatory Commission, December 1993.
1550. NUREG/CR-6084, "Value Impact Analysis of Generic Issue 143, 'Availability of Heating, Ventilation, Air Conditioning (HVAC) and Chilled Water Systems,'" U.S. Nuclear Regulatory Commission, November 1993.
1551. Memorandum for J. Taylor from E. Beckjord, "Resolution of Generic Issue 143 (GI-143), 'Availability of Chilled Water System and Room Cooling,'" September 30, 1993. [9502070325]
1552. NRC Information Notice No. 89-44, "Hydrogen Storage on the Roof of the Control Room," U.S. Nuclear Regulatory Commission, April 27, 1989. [8904260247]
1553. Memorandum for A. Gody from G. Holahan, "Prioritization of Proposed Generic Issue 162, 'Inadequate Technical Specifications for Shared Systems at Multi-plant Sites When One Unit Is Shut Down,'" March 20, 1993. [9304070074]
1554. Memorandum for J. Taylor from E. Beckjord, "Resolution of GI 67.5.1, 'Reassessment of SGTR Radiological Consequences,'" June 30, 1994. [9407130262]

1555. Memorandum for E. Beckjord from J. Murphy, "Staff Review Guidance for Generic Safety Issue (GSI) 147, 'Fire-Induced Alternate Shutdown/Control Room Panel Interactions,'" March 9, 1994. [9502070329]
1556. Memorandum for C. Rossi, et al., from T. Novak, "Safety and Safety/Relief Valve Reliability," April 24, 1992. [9205060277]
1557. NRC Information Notice No. 90-05, "Inter-System Discharge of Reactor Coolant," U.S. Nuclear Regulatory Commission, January 29, 1990. [9001230126]
1558. NRC Information Notice 92-64, "Nozzle Ring Settings on Low Pressure Water-Relief Valves," U.S. Nuclear Regulatory Commission, August 28, 1992. [9208240139]
1559. NRC Information Notice 92-61, "Loss of High Head Safety Injection," U.S. Nuclear Regulatory Commission, August 20, 1992 [9208180039], (Supplement 1) November 6, 1992 [9211020211].
1560. NUREG/CR-6001, "Aging Assessment of BWR Standby Liquid Control Systems," U.S. Nuclear Regulatory Commission, August 1992.
1561. NRC Information Notice No. 90-18, "Potential Problems With Crosby Safety Relief Valves Used on Diesel Generator Air Start Receiver Tanks," U.S. Nuclear Regulatory Commission, March 9, 1990. [9003050043]
1562. Memorandum for J. Taylor from E. Beckjord, "Resolution of Human Factors Generic Issue 4.4, 'Guidelines for Upgrading Other Procedures,'" July 29, 1993. [9502070331]
1563. NUREG/CR-5382, "Screening of Generic Safety Issues for License Renewal Considerations," U.S. Nuclear Regulatory Commission, December 1991.
1564. Memorandum for W. Russell from E. Beckjord, "License Renewal Implications of Generic Safety Issues (GSIs) Prioritized and/or Resolved Between October 1990 and March 1994," May 5, 1994. [9406170365]
1565. Memorandum for T. Murley from W. Russell and J. Partlow, "Closeout of TMI Action Plan Items III.A.1.2 and III.A.2.2 (Multi-Plant Actions F-63, F-64, F-65, and F-68)," October 2, 1990. [9010160111]
1566. SECY-80-275, "Final Rulemaking on Emergency Preparedness," June 3, 1980. [8007090015]
1567. NUREG/CP-0011, "Proceedings to Workshops Held on Proposed Rulemaking on Emergency Planning for Nuclear Power Plants," U.S. Nuclear Regulatory Commission, April 1980.
1568. Federal Register Notice 46 FR 11666, "10 CFR Parts 30, 40, 50, 70 and 72 Decommissioning Criteria for Nuclear Facilities; Notice of Availability of Draft Generic Environment Impact Statement," February 10, 1981.

1569. SECY-87-309, "Final Rule Amendments to 10 CFR Parts 30, 40, 50, 51, 70, and 72: General Requirements for Decommissioning Nuclear Facilities," December 17, 1987. [8801130361]
1570. SECY-88-94, "Final Rule Amendments to 10 CFR Parts 30, 40, 50, 51, 70, and 72: General Requirements for Decommissioning Nuclear Facilities (SECY-87-309)," April 5, 1988. [8804120065]
1571. SECY-94-179, "Notice of Proposed Rulemaking on Decommissioning of Nuclear Power Reactors," July 7, 1994. [9407180100]
1572. Memorandum for J. Taylor and K. Cyr from J. Hoyle, "SECY-94-179 - Notice of Proposed Rulemaking on Decommissioning of Nuclear Power Reactors and COMKR-94-002 - Decommissioning of Nuclear Power Reactors and Comments on SECY-94-179," October 5, 1994. [9410270085]
1573. NRC Letter to All Pressurized Water Reactor Licensees, "Inadvertent Boron Dilution Events (Generic Letter 85-05)," January 31, 1985. [8502010366]
1574. Memorandum for J. Taylor from R. Bernero, "Resolution of Issue Number B-64, 'Decommissioning of Reactors,' of the Generic Issue Management Control System," September 26, 1994. [9410110028]
1575. Memorandum for C. Serpan and C. Ader from J. Greeves, "Reference to the U.S. Nuclear Regulatory Commission Dam Safety Program in NUREG-0933," August 12, 1994. [9409060217]
1576. "Approaches to Upgrading Procedures in Nuclear Power Plants," Pacific Northwest Laboratory, August 1994. [9507280167]
1577. NUREG/CR-6146, "Local Control Stations: Human Engineering Issues and Insights," U.S. Nuclear Regulatory Commission, September 1994.
1578. NUREG/CR-6105, "Human Factors Engineering Guidance for the Review of Advanced Alarm Systems," U.S. Nuclear Regulatory Commission, September 1994.
1579. Letter to L. Zech from F. Remick, "Resolution of Generic Issue 43, 'Air Systems Reliability,'" January 19, 1989. [8901260092]
1580. Memorandum for J. Larkins from E. Beckjord, "Evaluation of Potential Safety Issues from the Multiple System Responses Program," June 3, 1994. [9406230143]
1581. Memorandum for T. Speis from A. Thadani, "Review of NUREG/CR-5420," April 30, 1995. [9505230058]
1582. NUREG/CR-5455, "Development of NRC's Human Performance Investigation Process (HPIP)," U.S. Nuclear Regulatory Commission, (Vol. 1) October 1993, (Vol. 2) October 1993, (Vol. 3) October 1993.

1583. NUREG-0711, "Human Factors Engineering Program Review Model," U.S. Nuclear Regulatory Commission, July 1994.
1584. NUREG/CR-5908, "Advanced Human-System Interface Design Review Guideline," U.S. Nuclear Regulatory Commission, (Vol. 1) July 1994, (Vol. 2) July 1994.
1585. Memorandum for L. Shao from B. Sheron, "Proposed Generic Issue on Safety Systems' Response to the Sequential Occurrence of LOCA and Loss of Offsite Power Events," February 17, 1995. [9502270179]
1586. NRC Information Notice 93-17, "Safety Systems Response to Loss of Coolant and Loss of Offsite Power," March 8, 1993 [9303020536], (Rev. 1) March 25, 1994 [9403220236].
1587. NUREG-1335, "Individual Plant Examination: Submittal Guidance," U.S. Nuclear Regulatory Commission, August 1989.
1588. NUREG/CR-5580, "Evaluation of Generic Issue 57: Effects of Fire Protection System Actuation on Safety-Related Equipment," (Vol. 1) December 1992, (Vol. 2) December 1992, (Vol. 3) December 1992, (Vol. 4) December 1992, (Vol. 5) December 1992.
1589. NUREG/CR-5720, "Motor-Operated Valve Research Update," U.S. Nuclear Regulatory Commission, June 1992.
1590. EGG-REQ-7297, "Summary of Valve Assemblies in High Energy BWR Systems Outside of Containment -- Interim Report," EG&G Idaho, Inc., June 1986. [9511090106]
1591. Regulatory Guide 1.22, "Periodic Testing of Protection System Actuation Functions," U.S. Nuclear Regulatory Commission, February 1972. [7907100108]
1592. Regulatory Guide 1.118, "Periodic Testing of Electric Power and Protection Systems," U.S. Nuclear Regulatory Commission, June 1976, (Rev. 1) November 1977, (Rev. 2) June 1978 [7907110110], (Rev. 3) April 1995 [9505030214].
1593. NUREG-1453, "Regulatory Analysis for the Resolution of Generic Issue 142: Leakage Through Electrical Isolators in Instrumentation Circuits," U.S. Nuclear Regulatory Commission, September 1993.
1594. Regulatory Guide 1.77, "Assumptions Used for Evaluating a Control Rod Ejection Accident for Pressurized Water Reactors," U.S. Nuclear Regulatory Commission, May 1974. [7907100299]
1595. Memorandum for E. Beckjord from T. Murley, "User Need for Assistance on High Burnup Fuels," October 4, 1993. [9310270186]
1596. Memorandum for W. Russell from E. Beckjord, "Fuel Damage Criteria for Reactivity Transients," April 29, 1994. [9511090065]
1597. NRC Information Notice 94-64, "Reactivity Insertion Transient and Accident Limits for High Burnup Fuel," August 31, 1994 [9408250234], (Supplement 1) April 6, 1995 [9503310049].

1598. Memorandum to the Chairman, et al., from J. Taylor, "Reactivity Transients and High-Burnup Fuel," September 13, 1994. [9409300142]
1599. Memorandum to the Chairman, et al., from J. Taylor, "Reactivity Transients and Fuel Damage Criteria for High Burnup Fuel," November 9, 1994. [9511090217]
1600. NUREG/CP-0139, "Transactions of the Twenty-Second Water Reactor Safety Information Meeting," U.S. Nuclear Regulatory Commission, October 1994.
1601. Memorandum to C. Serpan from A. Chaffee, "Nuclear Reactor Regulation (NRR) Input Into Research NUREG-0933 (WITS Item 9400213)," February 13, 1996. [9602260124]
1602. NUREG-1352, "Action Plans for Motor-Operated Valves and Check Valves," U.S. Nuclear Regulatory Commission, June 1990.
1603. Memorandum to A. Thadani from J. Strosnider, "Plan for Addressing Generic Reactor Pressure Vessel Issues," August 9, 1995. [9508150078]
1604. NUREG-1511, "Reactor Pressure Vessel Status Report," U.S. Nuclear Regulatory Commission, December 1994.
1605. Memorandum to A. Thadani from J. Strosnider, "Assessment of Impact of Increased Variability in Chemistry on the RT_{PTS} Value of PWR Reactor Vessels," May 5, 1995 [9505100187]
1606. SECY-91-161, "Schedules for the Advanced Reactor Reviews and Regulatory Guidance Revisions," May 31, 1991. [9106050174]
1607. Memorandum for W. Russell from F. Gillespie, "Action Plan for the Development of Draft SRP Revisions in the SRP-UDP," May 17, 1994. [9406280148, 9405270273]
1608. Memorandum to J. Taylor from C. Paperiello and W. Russell, "Dry Cask Storage Action Plan," July 28, 1995. [9508250186]
1609. Memorandum to J. Taylor from W. Russell and R. Bernero, "Realignment of Reactor Decommissioning Program," March 15, 1995. [9508250180]
1610. NUREG-1474, "Effect of Hurricane Andrew on the Turkey Point Nuclear Generating Station from August 20 - 30, 1992," U.S. Nuclear Regulatory Commission and the Institute of Nuclear Power Operations, March 1993. [9307060041]
1611. Memorandum for J. Taylor from T. Murley, "Office of Nuclear Reactor Regulation (NRR) Plan for Generic Follow-on Actions - 'Report on the Effect of Hurricane Andrew on the Turkey Point Nuclear Generating Station from August 20 - 30, 1992,'" July 22, 1993. [9308160297]
1612. NRC Information Notice 93-53, "Effect of Hurricane Andrew on Turkey Point Nuclear Generating Station and Lessons Learned," July 20, 1993 [9307140056], (Supplement 1) April 29, 1994 [9404280023].

1613. NUREG/CR-6224, "Parametric Study of the Potential for BWR ECCS Strainer Blockage Due to LOCA Generated Debris," U.S. Nuclear Regulatory Commission, October 1995.
1614. NRC Information Notice 92-71, "Partial Plugging of Suppression Pool Strainers at a Foreign BWR," September 30, 1992. [9209290014]
1615. NRC Bulletin No. 93-02, "Debris Plugging of Emergency Core Cooling Suction Strainers," May 11, 1993. [9305110015]
1616. NRC Information Notice 93-34, "Potential for Loss of Emergency Cooling Function Due to a Combination of Operational and Post-LOCA Debris in Containment," April 26, 1993 [9304260085], (Supplement 1) May 6, 1993 [9305050002].
1617. NRC Bulletin 95-02, "Unexpected Clogging of a Residual Heat Removal (RHR) Pump Strainer While Operating in Suppression Pool Cooling Mode," October 17, 1995. [9510040059]
1618. NRC Information Notice No. 88-28, "Potential for Loss of Post-LOCA Recirculation Capability Due to Insulation Debris Blockage," May 19, 1988. [8805130108]
1619. NRC Information Notice 92-85, "Potential Failures of Emergency Core Cooling Systems Caused by Foreign Material Blockage," December 23, 1992. [9212170209]
1620. NRC Information Notice 94-57, "Debris in Containment and the Residual Heat Removal System," August 12, 1994. [9408080111]
1621. NRC Information Notice 95-06, "Potential Blockage of Safety-Related Strainers by Material Brought Inside Containment," January 25, 1995. [9501190091]
1622. NRC Information Notice 95-47, "Unexpected Opening of a Safety/Relief Valve and Complications Involving Suppression Pool Cooling Strainer Blockage," October 4, 1995 [9510030107], (Rev. 1) November 30, 1995 [9511270084].
1623. Memorandum to A. Thadani from G. Holahan, "Task Action Plan for Spent Fuel Storage Pool Safety," October 13, 1994. [9410190155]
1624. NRC Information Notice 94-38, "Results of a Special NRC Inspection at Dresden Nuclear Power Station Unit 1 Following a Rupture of Service Water Inside Containment," May 27, 1994. [9405240025]
1625. NRC Bulletin 94-01, "Potential Fuel Pool Draindown Caused by Inadequate Maintenance Practices at Dresden Unit 1," April 14, 1994. [9404120041]
1626. Memorandum for A. Thadani from G. Holahan, "Revision to Report on the Re-Assessment of the NRC Fire Protection Program," February 27, 1993. [9504190319]
1627. SECY-93-143, "NRC Staff Actions to Address the Recommendations in the Report on the Reassessment of the NRC Fire Protection Program," May 21, 1993. [9306030231]

1628. SECY-95-034, "Status of Recommendations Resulting from the Reassessment of the NRC Fire Protection Program," February 13, 1995. [9503060019]
1629. Memorandum for Chairman Jackson, et al., from J. Taylor, "Semiannual Report on the Status of the Thermo-Lag Action Plan and Fire Protection Task Action Plan," September 20, 1995. [9509250375]
1630. SECY-94-219, "Proposed Agency-Wide Implementation Plan for Probabilistic Risk Assessment (PRA)," August 19, 1994. [9409090234]
1631. SECY-95-079, "Status Update of the Agency-Wide Implementation Plan for Probabilistic Risk Assessment," March 30, 1995. [9504100180]
1632. SECY-95-126, "Final Policy Statement on the Use of Probabilistic Risk Assessment Methods in Nuclear Regulatory Activities," May 18, 1995. [9506020152]
1633. SECY-95-280, "Framework for Applying Probabilistic Risk Analysis in Reactor Regulation," November 27, 1995. [9512180168, 9512040133]
1634. Memorandum to Chairman Jackson from J. Taylor, "Improvements Associated With Managing the Utilization of Probabilistic Risk Assessment (PRA) and Digital Instrumentation and Control Technology," January 3, 1996. [9601180203]
1635. Memorandum for J. Taylor from T. Murley, et al., "Agency Directions for Current and Future Uses of Probabilistic Risk Assessment (PRA)," November 2, 1993. [9311100145]
1636. Memorandum to A. Thadani from G. Holahan and R. Spessard, "Action Plan to Monitor, Review, and Improve Fuel and Core Components Operating Performance," October 7, 1994. [9411040040]
1637. NRC Letter to All Operating Reactor Licensees, "Licensee Qualification for Performing Safety Analyses in Support of Licensing Actions (Generic Letter No. 83-11)," February 4, 1983. [8302080304]
1638. NRC Letter to All Power Reactor Licensees and Applicants, "Removal of Cycle-Specific Parameter Limits from Technical Specifications (Generic Letter 88-16)," October 4, 1988. [8810050058, 8810140007]
1639. NRC Information Notice No. 91-47, "Failure of Thermo-Lag Fire Barrier Material to Pass Fire Endurance Test," August 6, 1991. [9108020180]
1640. NRC Information Notice 91-79, "Deficiencies in the Procedures for Installing Thermo-Lag Fire Barrier Materials," December 6, 1991 [9112020091], (Supplement 1) August 4, 1994 [9408030006].
1641. NRC Information Notice 92-55, "Current Fire Endurance Test Results for Thermo-Lag Fire Barrier Material," July 27, 1992. [9207270345]
1642. NRC Information Notice 92-82, "Results of Thermo-Lag 330-1 Combustibility Testing," December 15, 1992. [9212090211]

1643. NRC Information Notice 94-22, "Fire Endurance and Ampacity Derating Test Results for 3-Hour Fire-Rated Thermo-Lag 330-1 Fire Barriers," March 16, 1994. [9403150511]
1644. NRC Information Notice 94-34, "Thermo-Lag 330-660 Flexi-Blanket Ampacity Derating Concerns," May 13, 1994. [9405090108]
1645. NRC Information Notice 94-86, "Legal Actions Against Thermal Science, Inc., Manufacturer of Thermo-Lag," December 22, 1994. [9412160132]
1646. NRC Information Notice 95-27, "NRC Review of Nuclear Energy Institute, 'Thermo-Lag 330-1 Combustibility Evaluation Methodology Plant Screening Guide,'" May 31, 1995. [9505240424]
1647. NRC Information Notice 95-32, "Thermo-Lag 330-1 Flame Spread Test Results," August 10, 1995. [9508040074]
1648. NRC Information Notice 95-49, "Seismic Adequacy of Thermo-Lag Panels," October 27, 1995. [9510240388]
1649. NRC Information Notice 95-03, "Loss of Reactor Coolant Inventory and Potential Loss of Emergency Mitigation Functions While in a Shutdown Condition," January 18, 1995 [9501110412], (Supplement 1) March 25, 1996 [9602050208].
1650. NRC Letter to All Power Reactor Licensees and Applicants for Power Reactor Licenses, "Policy Statement on Engineering Expertise on Shift (Generic Letter 86-04)," February 13, 1986. [8602240459]
1651. NRC Information Notice 91-77, "Shift Staffing at Nuclear Power Plants," November 26, 1991. [9111200123]
1652. NRC Information Notice 93-44, "Operational Challenges During a Dual-Unit Transient," June 15, 1993. [9306030170]
1653. NRC Information Notice 93-81, "Implementation of Engineering Expertise on Shift," October 12, 1993. [9310060239]
1654. NRC Information Notice 95-48, "Results of Shift Staffing Study," October 10, 1995. [9510040181]
1655. Letter to B. Boger (NRC) from R. Whitesel (NUMARC), December 29, 1992. [9301080124]
1656. SECY-93-184, "Shift Staffing at Nuclear Power Plants," June 29, 1993. [9307080273]
1657. SECY-93-193, "Policy on Shift Technical Advisor Position at Nuclear Power Plants," July 13, 1993. [9307200065]
1658. NRC Bulletin No. 90-01, "Loss of Fill-Oil in Transmitters Manufactured by Rosemount," March 9, 1990 [9003050148], (Supplement 1) December 22, 1992 [9212170002].

1659. Memorandum for R. Zimmerman, et al., from J. Sniezek, "Review of Rosemount Transmitter Issues," May 21, 1993. [9308090287, 9310010241]
1660. SECY-95-078, "Staff Actions to Address Recommendations Resulting from Recent Evaluations of the Notice of Enforcement Discretion (NOED) Policy and Process," March 29, 1995. [9504100173]
1661. NUREG-1600, "General Statement of Policy and Procedures for NRC Enforcement Actions," U.S. Nuclear Regulatory Commission, July 1995.
1662. Memorandum for E. Jordan, et al., from J. Taylor, "Unauthorized Forced Entry Into the Protected Area at Three Mile Island Unit 1 on February 7, 1993 (NUREG-1485)," June 18, 1993. [9308110317]
1663. NRC Letter to All Holders of Operating Licenses or Construction or Construction Permits for Nuclear Power Reactors, Except for Big Rock Point and Facilities Permanently or Indefinitely Shut Down, "Emergency Response Data System Test Program (Generic Letter 93-01)," March 3, 1993. [9302240242]
1664. NRC Information Notice 93-94, "Unauthorized Forced Entry Into the Protected Area at Three Mile Island Unit 1 on February 7, 1993," December 9, 1993. [9312030104]
1665. NUREG-1485, "Unauthorized Forced Entry Into the Protected Area at Three Mile Island Unit 1 on February 7, 1993," U.S. Nuclear Regulatory Commission, April 1993.
1666. NUREG/CR-6432, "Estimated Net Value and Uncertainty for Automating ECCS Switchover at PWRs," U.S. Nuclear Regulatory Commission, February 1996.
1667. Memorandum for J. Taylor from D. Morrison, "Technical Resolution of Generic Issue 24 (GI-24), 'Automatic ECCS Switch to Recirculation,'" October 31, 1995. [9511140037]
1668. NUREG/CR-5904, "Functional Issues and Environmental Qualification of Digital Protection Systems of Advanced Light-Water Nuclear Reactors," U.S. Nuclear Regulatory Commission, April 1994.
1669. NUREG/CR-5941, "Technical Basis for Evaluating Electromagnetic and Radio-Frequency Interference in Safety-Related I&C Systems," U.S. Nuclear Regulatory Commission, April 1994.
1670. NRC Generic Letter 94-03, "Intergranular Stress Corrosion Cracking of Core Shrouds in Boiling Water Reactors," July 25, 1994. [9407210200]
1671. Memorandum for A. Thadani from B. Sheron, "Staff Action Plan for the Resolution of Issues Associated With Boiling Water Reactor Internals Cracking," April 26, 1995. [9505220070]
1672. NRC Letter to All Holders of Operating Licenses or Construction Permits for Nuclear Power Plants (Except Yankee Atomic Electric Company, Licensee for the Yankee Nuclear Power Station), "Reactor Vessel Structural Integrity, 10 CFR 50.54(f) (Generic Letter 92-01)," February 28, 1992, (Rev. 1) March 6, 1992 [9203060147], (Rev. 1, Supplement 1) May 19, 1995 [9505090312].

1673. Memorandum for E. Beckjord from W. Russell, "NRR User Need Request for Support of Resolving Problem of Stress Corrosion Cracking of Reactor Vessel Internal Components," December 2, 1994. [9505090299]
1674. Memorandum for D. Morrison from W. Russell, "Request for Research on Reactor Pressure Vessel Integrity," August 11, 1995. [9508220323]
1675. Memorandum to L. Shao from M. Mayfield, "Summary, NRC/NEI Workshop on Nuclear RPV Integrity," September 6, 1995. [9509200141]
1676. NRC Administrative Letter 95-03, "Availability of Reactor Vessel Integrity Database," August 4, 1995. [9508010148]
1677. AEOD/S95-01, "Reactor Coolant System Blowdown at Wolf Creek on September 17, 1994," Office for Analysis and Evaluation of Operational Data, U.S. Nuclear Regulatory Commission, March 1995. [9503310036]
1678. Memorandum to A. Thadani from R. Jones, "Proposed Action Plan for the 'Wolf Creek Draindown Event,'" September 8, 1995. [9509140225]
1679. Memorandum for the Chairman from J. Taylor, "Commercial Contract for Technical Assistance to Support the Standard Review Plan Update and Development Program," November 18, 1991.
1680. Memorandum for J. Taylor from I. Selin, "Commercial Contract for Technical Assistance to Support the Standard Review Plan Update and Development Program," December 13, 1991.
1681. Memorandum for J. Taylor from T. Murley, "Planned Actions to Address the Issues from the Office of Inspector General's Report on the NRC Staff's Review and Acceptance of Thermo-Lag 330-1 Fire Barrier Material," August 21, 1992. [9209250288]
1682. NRC Bulletin No. 92-01, "Failure of Thermo-Lag 330 Fire Barrier System to Maintain Cabling in Wide Cable Trays and Small Conduits Free from Fire Damage," June 24, 1992. [9206240122]
1683. Memorandum for W. Russell from T. Murley, "Final Report - Special Review Team for the Review of Thermo-Lag Fire Barrier Performance," April 21, 1992. [9205120277]
1684. Memorandum for E. Beckjord from T. Murley, "Request for Prioritization of Potential Generic Safety Issue - BWR MSIV Common Mode Failure Due to Loss of Accumulator Pressure," May 25, 1993. [9308160285]
1685. Memorandum for T. Murley from E. Beckjord, "Request for Prioritization of Potential Generic Safety Issue - BWR MSIV Common Mode Failure Due to Loss of Accumulator Pressure," June 29, 1993. [9509050193]
1686. SEA No. 95-3101-01-A:1, "Technical Information for Prioritization of Generic Safety Issues," Science and Engineering Associates, Inc., June 1996. [9704090123]

1687. SEA No. 97-3701-010-A:1, "Issue 107, Main Transformer Failures," Science and Engineering Associates, Inc., March 28, 1997. [9704090149]
1688. NUREG/CR-5595, "FORECAST: Regulatory Effects Cost Analysis Software Manual," (Rev. 1) July 1996.
1689. Memorandum to J. Taylor from J. Hoyle, "COMSECY-95-033 - Proposed Dollar per Person-Rem Conversion Factor; Response to SRM Concerning Issuance of Regulatory Analysis Guidelines of the U.S. Nuclear Regulatory Commission and SRM Concerning the Need for a Backfit Rule for Materials Licensees (RES-950225) (WITS-9100294)," September 18, 1995. [9803260148]
1690. Memorandum for All RES Employees from D. Morrison, "RES Office Letter No. 3C -- Procedures for Obtaining Regulatory Impact Analysis Review and Support," February 23, 1996. [9803260238]
1691. Memorandum to D. Morrison from W. Russell, "Third Supplemental User Need Request Regarding Potential for Loss of Emergency Core Cooling in a Boiling Water Reactor due to Clogging of the Suction Strainers by Loss-of-Coolant Accident Generated Debris," December 7, 1995. [9512140237]
1692. Memorandum to L. Shao from M. Marshall, "Expansion of Work Being Performed Under GSI-191, 'Assessment of Debris Accumulation on Pressurized Water Reactors Sump Performance,'" May 14, 1997. [9706060061]
1693. Memorandum to Chairman Jackson, et al., from J. Taylor, "Report on Survey of Refueling Practices," May 21, 1996. [9606030213]
1694. Memorandum to Chairman Jackson, et al., from J. Taylor, "Resolution of Spent Fuel Storage Pool Action Plan Issues," July 26, 1996. [9611180017]
1695. SECY-97-168, "Issuance for Public Comment of Proposed Rulemaking Package for Shutdown and Fuel Storage Pool Operation," July 30, 1997. [9708150168]
1696. Memorandum to L. Callan from J. Hoyle, "Staff Requirements - SECY-97-168 - Issuance for Public Comment of Proposed Rulemaking Package for Shutdown and Fuel Storage Pool Operation," December 11, 1997. [9712180222]
1697. Regulatory Guide 1.13, "Spent Fuel Storage Facility Design Basis," U.S. Nuclear Regulatory Commission, (Rev. 1) December 1975 [7907100079], (Draft Rev. 2) December 1981 [9803260142].
1698. Memorandum to E. Beckjord from E. Jordan, "Periodic Review of Low Priority Generic Safety Issues," April 7, 1995. [9701230176]
1699. Memorandum to D. Morrison from W. Russell, "Periodic Review of Low-Priority Generic Issues," April 11, 1996. [9604240169]
1700. Memorandum to L. Shao from D. Cool, "Submittal of Generic Safety Issues," April 12, 1996. [9605170029]

1701. Memorandum to F. Coffman from J. Piccone, "Status of NMSS Generic Safety Issues," December 15, 1997. [9712180068]
1702. NRC Information Notice 96-21, "Safety Concerns Related to the Design of the Door Interlock Circuit on Nucletron High-Dose Rate and Pulsed Dose Rate Remote Afterloading Brachytherapy Devices," April 10, 1996. [9604040106]
1703. NRC Information Notice 96-51, "Residual Contamination Remaining in Krypton-85 Handling System After Venting," September 11, 1996. [9609050281]
1704. NRC Information Notice 96-54, "Vulnerability of Stainless Steel to Corrosion When Sensitized," October 17, 1996. [9610100212]
1705. Memorandum to L. Shao from D. Cool, "Submittal of Generic Safety Issue," June 18, 1997. [9706240185]
1706. NRC Bulletin 97-01, "Potential for Erroneous Calibration, Dose Rate, or Radiation Exposure Measurements With Certain Victoreen Model 530 and 530SI Electrometer/ Dosemeters," April 30, 1997. [9704300128]
1707. Memorandum to R. Bangart, et al., from D. Cool, "Closeout Report for Bulletin 97-01, Potential for Erroneous Measurements With Certain Victoreen Electrometers," September 8, 1997. [9709170137]
1708. Memorandum to L. Shao from D. Cool, "Submittal of Generic Safety Issue," August 5, 1997. [9708130432]
1709. Memorandum to J. Craig from F. Combs, "Submittal of New Generic Issues for Tracking in the Generic Issues Management and Control System (GIMCS)," June 4, 1998. [9806090180]
1710. NRC Information Notice 96-70, "Year 2000 Effect on Computer System Software," December 24, 1996. [9612200319]
1711. NRC Information Notice 97-61, "U.S. Department of Health and Human Services Letter to Medical Device Manufacturers on the Year 2000 Problem," August 6, 1997. [9707310130]
1712. NRC Information Notice 97-91, "Recent Failures of Control Cables Used on Amersham Model 660 Posilock Radiography Systems," December 31, 1997 [9712310254], (Supplement 1) August 10, 1998 [9808050063].
1713. NRC Information Notice 96-52, "Cracked Insertion Rods on Troxler Model 3400 Series Portable Moisture Density Gauges," September 26, 1996. [9609200181]
1714. NRC Bulletin 97-02, "Puncture Testing of Shipping Packages Under 10 CFR Part 71," September 23, 1997. [9709180179]
1715. Memorandum to D. Morrison from T. Gwynn, "Periodic Review of Low-Priority Generic Safety Issues," April 16, 1997. [9909290132]

1716. Memorandum to T. Gwynn from T. Martin, "Periodic Review of Low-Priority Generic Safety Issues," July 13, 1998. [9909290134]
1717. UCRL-52156, "Advisability of Seismic Scram," Lawrence Livermore Laboratory, June 30, 1976. [8103270386]
1718. SECY-98-166, "Summary of Activities Related to Generic Safety Issues," July 6, 1998. [9807220129, 9807170226]
1719. NUREG-1631, "Source Disconnects Resulting from Radiography Drive Cable Failures," U.S. Nuclear Regulatory Commission, June 1998.
1720. Memorandum to J. Craig from F. Combs, "Closure of NMSS Generic Issues," October 13, 1998. [9810160185]
1721. NUREG-1536, "Standard Review Plan for Dry Cask Storage Systems," U.S. Nuclear Regulatory Commission, January 1997.
1722. Letter to E. Fuller (Sierra Nuclear Corporation) from M. Knapp (NRC), "Closure of Confirmatory Action Letter 97-7-001," July 22, 1998. [9807290363]
1723. Memorandum to J. Craig from F. Combs, "Submittal of New Generic Issues for Tracking in the Generic Issues Management and Control System (GIMCS)," July 23, 1998. [9807280039]
1724. SECY-98-001, "Staff Requirements Memorandum 951219A - Briefing on Mechanisms for Addressing Generic Safety Issues," January 2, 1998. [9801230188, 9801140109]
1725. Memorandum to E. Ten Eyck, et al., from C. Paperiello, "NMSS Policy and Procedures Letter 1-57, Rev. 1, 'NMSS Generic Issues Program,'" October 30, 1997. [9711050048]
1726. NUREG/CR-6538, "Evaluation of LOCA With Delayed Loop and Loop With Delayed LOCA Accident Scenarios," U.S. Nuclear Regulatory Commission, July 1997.
1727. Memorandum to W. Travers from A. Thadani, "Resolution of Generic Safety Issue (GSI) - 171, 'ESF Failure from LOOP Subsequent to LOCA,'" December 9, 1998. [9909290137]
1728. Letter to J. Birmingham, et al., (NRC) from W. Foster (The B&W Owners' Group), "Submittal of B&WOG Report 'Evaluation of Potential Boron Dilution following Small Break Loss of Coolant Accident,' 77-5002260-00, September 1998," September 11, 1998. [9809150094]
1729. Letter to W. Lyon (NRC) from J. Link (The B&W Owners' Group), "Transmittal of Report 'Status Report on Return to Criticality Following Small Break Loss of Coolant Accident,' June 1998, Document No. 47-5001848-00," June 15, 1998. [9806220211]
1730. Memorandum to A. Thadani from S. Collins, "Potential Need to Reprioritize/Reopen Aspects of Generic Safety Issue (GSI) 22 Pertaining to Boron Dilution Following Loss-of-Coolant Accidents," February 1, 1999. [9902160085]

1731. Memorandum for W. Russell from D. Morrison, "Prioritization of the NRR Action Plans Submitted to RES on February 13, 1996," June 24, 1996. [9606260260]
1732. Memorandum for W. Minners from E. Beckjord, "Generic Issue No. 165, 'Spring-Actuated Safety and Relief Valve Reliability,'" November 26, 1993. [9312090116]
1733. Memorandum to W. Travers from A. Thadani, "Closeout of Generic Safety Issue 165, Spring-Actuated Safety and Relief Valve Reliability," June 18, 1999.
1734. Memorandum for W. Travers from A. Thadani, "Resolution of Generic Safety Issue B-61, 'Analytically Derived Allowable Equipment Outage Periods,'" March 2, 1999. [9904050209]
1735. Regulatory Guide 1.177, "An Approach for Plant-Specific, Risk-Informed Decisionmaking: Technical Specifications," U.S. Nuclear Regulatory Commission, August 1998. [9809110028]
1736. Memorandum to M. Knapp from L. Shao, "Generic Issue No. 169, 'BWR MSIV Common Mode Failure Due to Loss of Accumulator Pressure,'" March 10, 1998. [9804070430]
1737. Memorandum to NRR Division Directors from D. Matthews, "Director's Quarterly Status Report," January 26, 1999. [9902040247]
1738. Memorandum to L. Shao from D. Morrison, "Generic Issue No. 171, 'ESF Failure from LOOP Subsequent to LOCA,'" June 16, 1995. [9507030081]
1739. Memorandum for J. Murphy from E. Beckjord, "Generic Issue No. 158, 'Performance of Safety-Related Power-Operated Valves Under Design Basis Conditions,'" January 26, 1994. [9402040031]
1740. Memorandum to J. Murphy from E. Beckjord, "Generic Issue No. 167, 'Hydrogen Storage Facility Separation,'" September 29, 1994. [9410250044]
1741. NUREG/CP-0123, "Proceedings of the Second NRC/ASME Symposium on Pump and Valve Testing," U.S. Nuclear Regulatory Commission, July 1992.
1742. AEOD/C603, "A Review of Motor-Operated Valve Performance," Office for Analysis and Evaluation of Operational Data, U.S. Nuclear Regulatory Commission, December 1986. [8612150167]
1743. Memorandum for Chairman Zech, et al., from V. Stello, "Case Study Report - A Review of Motor-Operated Valve Performance (AEOD/C603)," December 10, 1986.
1744. Memorandum to W. Travers from A. Thadani, "Closeout of Generic Safety Issue (GSI) - 158, 'Performance of Safety-Related Power-Operated Valves Under Design Basis Conditions,'" August 2, 1999. [9910040224]
1745. Memorandum for W. Minners from E. Beckjord, "Generic Issue No. 148, 'Smoke Control and Manual Fire-Fighting Effectiveness,'" August 26, 1992. [9208310325]

1746. Memorandum to A. Thadani from T. King, "Staff Review Guidance for Generic Safety Issue (GSI) 148, 'Smoke Control and Manual Fire-Fighting Effectiveness,'" July 22, 1999. [9907270312]
1747. Memorandum to G. Holahan from J. Wermeil, "Closeout of Core Performance Action Plan (TAC Nos. M91256, M91602)," February 16, 1999. [9902190260]
1748. Memorandum to Chairman Jackson, et al., from L. Callan, "Agency Program Plan for High-Burnup Fuel," July 6, 1998. [9808060096]
1749. Memorandum to D. Morrison from W. Russell, "Periodic Review of Low-Priority Generic Issues," April 11, 1996. [9604240169]
1750. Memorandum to B. Sheron from J. Craig, "Periodic Review of Low-Priority Generic Safety Issues," March 5, 1999. [9904060275]
1751. Letter to Seismic Qualification Advisory Committee (SQAC) and Meeting Attendees from G. Sliter and R. Vasudevan (EPRI), "Summary of the EPRI Seismic Equipment Qualification Research Coordination Meeting at ANCO Engineers, Inc., Los Angeles, California, September 19 & 20, 1984," October 10, 1984.
1752. NUREG/CR-5500, "Reliability Study: Westinghouse Reactor Protection System, 1984-1995," U.S. Nuclear Regulatory Commission, (Vol. 2) April 1999.
1753. Memorandum to D. Matthews from E. Rossi, "Issue of Final Report - System Reliability: Westinghouse Reactor Protection System, 1984-1995 (NUREG/CR-5500, Volume 2)," March 24, 1999. [9904060063]
1754. Memorandum for W. Minners from E. Beckjord, "Generic Issue No. 145, 'Actions to Reduce Common Cause Failures,'" February 11, 1992. [9203170332]
1755. NUREG/CR-6268, "Common-Cause Failure Database and Analysis System," U.S. Nuclear Regulatory Commission, (Vols. 1, 2, 3, and 4) June 1998.
1756. NRC Administrative Letter 98-04, "Availability of Common-Cause Failure Database," July 30, 1998. [9807240296]
1757. NRC Regulatory Issue Summary 99-03, "Resolution of Generic Issue 145, Actions to Reduce Common-Cause Failures," October 13, 1999. [9910060044]
1758. Memorandum to W. Travers from A. Thadani, "Resolution of Generic Safety Issue 145, 'Actions to Reduce Common Cause Failures,'" October 18, 1999.
1759. NUREG/CR-5640, "Overview and Comparison of U.S. Commercial Nuclear Power Plants," U.S. Nuclear Regulatory Commission, September 1990.
1760. NUREG/CR-5750, "Rates of Initiating Events at U.S. Nuclear Power Plants: 1987-1995," U.S. Nuclear Regulatory Commission, February 1999.

1761. Memorandum to A. Thadani from E. Beckjord, "Generic Issue 156-6.1, 'Pipe Break Effects on Systems and Components,'" October 31, 1994. [9412070254]
1762. Memorandum for J. Murphy from E. Beckjord, "Generic Issue No. 156.6.1, 'Pipe Break Effects on Systems and Components,'" April 29, 1994. [9406200193]
1763. Memorandum to W. Travers from A. Thadani, "Closeout of Generic Safety Issue 23, 'Reactor Coolant Pump Seal Failure,'" November 8, 1999. [ML993370509]
1764. Memorandum to W. Travers from A. Thadani, "Closeout of Generic Safety Issue 190, 'Fatigue Evaluation of Metal Components for 60-Year Plant Life,'" December 26, 1999.
1765. Memorandum to W. Travers from S. Collins, "Closeout of Generic Safety Issue B-55, 'Improved Reliability of Target Rock Safety Relief Valves,'" December 17, 1999.
1766. Memorandum to W. Travers from A. Thadani, "Proposed Resolution of Generic Issue B-17, 'Criteria for Safety-Related Operator Actions,'" March 27, 2000. [ML003695959]
1767. NRC Regulatory Issue Summary 2000-02, "Closure of Generic Safety Issue 23, Reactor Coolant Pump Seal Failure," February 15, 2000. [ML003680402]
1768. NRC Regulatory Issue Summary 2000-03, "Resolution of Generic Safety Issue 158: Performance of Safety-Related Power-Operated Valves Under Design Basis Conditions," March 15, 2000. [ML003686003]
1769. NRC Regulatory Issue Summary 2000-05, "Resolution of Generic Safety Issue 165, Spring-Actuated Safety and Relief Valve Reliability," March 16, 2000. [ML003689694]
1770. Memorandum for W. Russell from C. Miller, "Licensee Offsite Communication Capabilities; Results of Information Gathering Using Temporary Instruction," September 26, 1996.
1771. Memorandum to C. Rossi from D. Cool, "Status of NMSS Issues in the Generic Issue Management and Control System," June 25, 1999. [9907010194]
1772. Memorandum to C. Rossi from D. Cool, "Closure of NMSS Generic Issue," May 18, 1999.
1773. Memorandum for E. Beckjord from J. Milhoan, "Periodic Review of Low-Priority Generic Safety Issues," June 4, 1993.
1774. Memorandum to A. Thadani from S. Bahadur, "Reprioritization of GSI-71, 'Failure of Resin Demineralizer Systems and Their Effects on Nuclear Power Plant Safety,'" December 20, 2000. [ML003779066]
1775. Memorandum to A. Thadani from M. Mayfield, "Closeout of GSI-152, 'Design Basis for Valves That Might Be Subjected to Significant Blowdown Loads,'" April 4, 2001. [ML010740024]
1776. Memorandum to A. Thadani from J. Rosenthal, "Initial Screening of Candidate Generic Issue 187, 'The Potential Impact of Postulated Cesium Concentration on Equipment Qualification in the Containment Sump,'" April 30, 2001. [ML011210348]

1777. Memorandum to A. Thadani from B. Sheron, "Proposed Generic Safety Issue - The Potential Impact of Postulated Cesium Concentration on Equipment Qualification in the Containment Sump," December 16, 1999. [ML993610109]
1778. Memorandum to W. Travers from A. Thadani, "Closure of Generic Issue 170, Reactivity Transients and Fuel Damage Criteria for High Burnup Fuel," May 4, 2001. [ML011280414]
1779. NUREG/CR-6395, "Enhanced Prioritization of Generic Safety Issue 156-6.1 Pipe Break Effects on Systems and Components Inside Containment," (Draft) September 1999. [ML010460480]
1780. Memorandum to F. Eltawila from D. Cool, "Submittal of Generic Issues for Tracking in the Generic Issue Management Control System (GIMCS)," November 14, 2000. [ML003763127]
1781. NRC Information Notice 99-26, "Safety and Economic Consequences of Misleading Marketing Information," August 24, 1999. [9908180183]
1782. NRC Information Notice 99-09, "Problems Encountered When Manually Editing Treatment Data on the Nucletron MicroSelectron-HDR (New) Model 105.999," March 24, 1999. [9903190227]
1783. NRC Information Notice 99-23, "Safety Concerns Related to Repeated Control Unit Failures of the Nucletron Classic Model High-Dose-Rate Remote Afterloading Brachytherapy Devices," July 6, 1999. [9907010001]
1784. Memorandum to W. Travers from W. Kane, "Closure of Two NMSS Generic Issues," January 26, 2001. [ML010240165]
1785. Memorandum to W. Travers from W. Kane, "Closure of NMSS Generic Issue Relating to Gamma Stereotactic Radiosurgery," February 12, 2001. [ML010390357]
1786. NRC Information Notice 2000-22, "Medical Misadministrations Caused by Human Errors Involving Gamma Stereotactic Radiosurgery (Gamma Knife)," December 18, 2000. [ML003761619]
1787. Memorandum to F. Eltawila from D. Cool, "NMSS Input for Second Quarter FY-2001 Update of the Generic Issue Management Control System," April 12, 2001. [ML011000117]
1788. NUREG-1090, "U.S. Nuclear Regulatory Commission 1983 Annual Report," June 1984.
1789. Memorandum to A. Thadani from S. Collins, "Proposed Generic Safety Issue Related to Secondary Containment Drawdown Time," December 3, 2001. [ML013330114]
1790. NUREG/CR-5640, "Overview and Comparison of U.S. Commercial Nuclear Power Plants," U.S. Nuclear Regulatory Commission, September 1990.

1791. Memorandum to J. Flack from M. Cunningham, "Information Concerning Generic Issue on Combustible Gas Control for PWR Ice Condenser and BWR Mark III Containment Designs," August 15, 2001. [ML012330522]
1792. SECY-00-0198, "Status Report on Study of Risk-Informed Changes to the Technical Requirements of 10 CFR Part 50 (Option 3) and Recommendations on Risk-Informed Changes to 10 CFR 50.44 (Combustible Gas Control)," September 14, 2000. [ML003747699]
1793. NUREG/CR-6427, "Assessment of the DCH Issue for Plants with Ice Condenser Containments," U.S. Nuclear Regulatory Commission, April 2000.
1794. Memorandum to M. Snodderly (NRC) from M. Zavisca, et al. (ERI), "Combustible Gas Control Risk Calculations (DRAFT) for Risk-Informed Alternative to Combustible Gas Control Rule for PWR Ice Condenser, BWR Mark I, and BWR Mark III (10 CFR 50.44)," October 22, 2001.
1795. NUREG/CR-4551, "Evaluation of Severe Accident Risks," U.S. Nuclear Regulatory Commission, (Vol. 1, Rev. 1) December 1993, (Vol. 4, Rev. 1, Part 1) December 1990, (Vol. 7, Rev. 1) March 1993.
1796. Letter Report, "NUREG-1150 Data Base Assessment Program: A Description of the Computational Risk Integration and Conditional Evaluation Tool (CRIC-ET) Software and the NUREG-1150 Data Base," T. D. Brown *et. al.*, March 1995.
1797. Letter to H. VanderMolen (NRC) from V. Mubayi (BNL), "NUREG-1150 Consequence Calculations," July 20, 1994.
1798. NUREG-1742, "Perspectives Gained from the Individual Plant Examination of External Events (IPEEE) Program, Main Report," (Volumes 1 and 2) April 2002.
1799. Memorandum for A. Thadani from J. Wiggins, "Staff Member Concern Regarding the Potential for Resonance Vibrations of Steam Generator Tubes During a Main Steam Line Break Event," June 27, 2000.
1800. Letter to W. Travers from D. Powers, "Differing Professional Opinion on Steam Generator Tube Integrity," February 1, 2001. [ML010780125]
1801. Letter to W. F. Conway (Arizona Public Service Company) from J. B. Martin (NRC), "NRC Inspection Report 50-529/93-14," April 16, 1993. [9305030083]
1802. Letter to A. A. Blind (Consolidated Edison Company of New York, Inc.) from H. J. Miller (NRC), "NRC Augmented Inspection Team - Steam Generator Tube Failure - Report No. 05000247/2000-002," April 28, 2000.
1803. NUREG/IA-0137, "A Study of Control Room Staffing Levels for Advanced Reactors," U.S. Nuclear Regulatory Commission, November 2000. [ML003774060]

1804. NRC Generic Letter 95-05, "Voltage-Based Repair Criteria for Westinghouse Steam Generator Tubes Affected by Outside Diameter Stress Corrosion Cracking," August 3, 1995. [9507310085]
1805. Memorandum to A. Thadani from N. Chokshi, "Initial Screening of Candidate Generic Issue 188, 'Steam Generator Tube Leaks or Ruptures, Concurrent with Containment Bypass from Main Steam Line or Feedwater Line Breaches,'" May 21, 2001. [ML011410572]
1806. Memorandum to W. Travers from A. Thadani, "Closeout of Generic Safety Issue 172, 'Multiple System Responses Program,'" January 22, 2002. [ML020230162]
1807. Memorandum to W. Travers from S. Collins, "Resolution of Generic Safety Issue (GSI) 173A, 'Spent Fuel Storage Pool for Operating Facilities,'" December 19, 2001. [ML013520142]
1808. Memorandum to T. King from D. Cool, "NMSS Input for First Quarter FY-2002 Update of the Generic Issue Management Control System," January 16, 2002.

APPENDIX B
APPLICABILITY OF NUREG-0933 ISSUES TO OPERATING AND FUTURE REACTOR PLANTS

This appendix contains a listing of those residual GSIs that are applicable to operating and future reactor plants and includes: issues that have been resolved with requirements [I, NOTE 3(a)]; USI, HIGH- and MEDIUM-priority issues scheduled for resolution; nearly-resolved issues scheduled for resolution (NOTES 1 and 2); and issues that are scheduled for prioritization (NOTE 4). The priority designations for all issues are consistent with those listed in Table II of the Introduction. In accordance with 10 CFR 52.47(a)(1)(iv), any future application for design certification must contain proposed technical resolutions for the issues in this listing that are designated USI, HIGH, MEDIUM, NOTE 1, and NOTE 2. (In July 1998, the priority categories NOTES 1 and 2 were eliminated and all GSIs in these categories were given a HIGH priority ranking.¹⁷¹⁸) Also included in this listing are those GSIs that were either prioritized or resolved with no impact on operating reactor plants but contain recommendations for future reactor plants (NOTE 6).

Legend

| | |
|----------|---|
| NOTES: 1 | - Possible Resolution Identified for Evaluation (Discontinued 07-06-98) |
| 2 | - Resolution Available [Documented in NUREG, NRC Memorandum, SER or equivalent] (Discontinued 07-06-98) |
| 3(a) | - Resolution Resulted in the Establishment of New Regulatory Requirements [Rule, Regulatory Guide, SRP Change, or equivalent] |
| 4 | - Issue to be Prioritized in the Future |
| 6 | - New Requirements for Future Plants Recommended |
| B&W | - Babcock & Wilcox Company |
| CE | - Combustion Engineering Company |
| GE | - General Electric Company |
| CONT. | - Work on the issue continues in accordance NRC Management Directive 6.4 |
| HIGH | - High Safety Priority |
| I | - Resolved TMI Action Plan Item with Implementation of Resolution Mandated by NUREG-0737 |
| MEDIUM | - Medium Safety Priority |
| MPA | - Multiplant Action |
| NA | - Not Applicable |
| TBD | - To Be Determined |
| USI | - Unresolved Safety Issue |
| W | - Westinghouse Electric Corporation |

Appendix B (Continued)

06/30/02

| Action Plan Item/Issue No. | Title | Safety Priority/Status | Affected NSSS Vendor | | Operating Plants- MPA No | Operating Plants - Effective Date | Future Plants- Effective Date |
|----------------------------|-------|------------------------|----------------------|-----|--------------------------|-----------------------------------|-------------------------------|
| | | | BWR | PWR | | | |

TMI ACTION PLAN ITEMS

I.A OPERATING PERSONNEL

I.A.1 Operating Personnel and Staffing

| | | | | | | | |
|---------|--|-----------|-----|-----|------|----------|----------|
| I.A.1.2 | Shift Technical Advisor | I | All | All | F-01 | 09/13/79 | 09/27/79 |
| I.A.1.2 | Shift Supervisor Administrative Duties | I | All | All | | 09/13/79 | 09/27/79 |
| I.A.1.3 | Shift Manning | I | All | All | F-02 | 07/31/80 | 06/26/80 |
| I.A.1.4 | Long-Term Upgrading | NOTE 3(a) | All | All | | 04/28/83 | 04/28/83 |

I.A.2 Training and Qualifications of Operating Personnel

| | | | | | | | |
|------------|--|-----------|-----|-----|------|----------|----------|
| I.A.2.1 | Immediate Upgrading of Operator and Senior Operator Training and Qualifications | - | - | - | - | - | - |
| I.A.2.1(1) | Qualifications - Experience | I | All | All | F-03 | 03/28/80 | 03/28/80 |
| I.A.2.1(2) | Training | I | All | All | F-03 | 03/28/80 | 03/28/80 |
| I.A.2.1(3) | Facility Certification of Competence and Fitness of Applicants for Operator and Senior Operator Licenses | I | All | All | F-03 | 03/28/80 | 03/28/80 |
| I.A.2.3 | Administration of Training Programs | I | All | All | | 03/28/80 | 03/28/80 |
| I.A.2.6 | Long-Term Upgrading of Training and Qualifications | - | - | - | - | - | - |
| I.A.2.6(1) | Revise Regulatory Guide 1.8 | NOTE 3(a) | All | All | | TBD | 05/--/87 |

I.A.3 Licensing and Requalification of Operating Personnel

| | | | | | | | |
|---------|---|---|-----|-----|--|----------|----------|
| I.A.3.1 | Revise Scope of Criteria for Licensing Examinations | I | All | All | | 03/28/80 | 03/28/80 |
|---------|---|---|-----|-----|--|----------|----------|

I.A.4 Simulator Use and Development

| | | | | | | | |
|------------|---|-----------|-----|-----|---|----------|----------|
| I.A.4.1 | Initial Simulator Improvement | - | - | - | - | - | - |
| I.A.4.1(2) | Interim Changes in Training Simulators | NOTE 3(a) | All | All | | 04/--/81 | 03/28/81 |
| I.A.4.2 | Long-Term Training Simulator Upgrade | - | - | - | - | - | - |
| I.A.4.2(1) | Research on Training Simulators | NOTE 3(a) | All | All | | 04/--/87 | 04/--/87 |
| I.A.4.2(2) | Upgrade Training Simulator Standards | NOTE 3(a) | All | All | | 04/--/81 | 04/--/81 |
| I.A.4.2(3) | Regulatory Guide on Training Simulators | NOTE 3(a) | All | All | | 04/--/81 | 04/--/81 |
| I.A.4.2(4) | Review Simulators for Conformance to Criteria | NOTE 3(a) | All | All | | 03/25/87 | 03/25/87 |

A.B-2

NUREG-0933

Revision 17

Appendix B (Continued)

06/30/02

| Action Plan Item/Issue No. | Title | Safety Priority/Status | Affected NSSS Vendor | | Operating Plants- MPA No | Operating Plants - Effective Date | Future Plants- Effective Date |
|----------------------------|-------|------------------------|----------------------|-----|--------------------------|-----------------------------------|-------------------------------|
| | | | BWR | PWR | | | |

I.C OPERATING PROCEDURES

| | | | | | | | |
|----------|--|-----------|-----|-----|------|----------|----------|
| I.C.1 | Short-Term Accident Analysis and Procedures Revision | - | - | - | - | - | - |
| I.C.1(1) | Small Break LOCAs | I | All | All | | 09/13/79 | 09/13/79 |
| I.C.1(2) | Inadequate Core Cooling | I | All | All | F-04 | 09/13/79 | 09/13/79 |
| I.C.1(3) | Transients and Accidents | I | All | All | F-05 | 09/13/79 | 09/27/79 |
| I.C.2 | Shift and Relief Turnover Procedures | I | All | All | | 09/13/79 | 09/27/79 |
| I.C.3 | Shift Supervisor Responsibilities | I | All | All | | 09/13/79 | 09/27/79 |
| I.C.4 | Control Room Access | I | All | All | | 09/13/79 | 09/27/79 |
| I.C.5 | Procedures for Feedback of Operating Experience to Plant Staff | I | All | All | F-06 | 05/07/80 | 06/26/80 |
| I.C.6 | Procedures for Verification of Correct Performance of Operating Activities | I | All | All | F-07 | 10/31/80 | 10/31/80 |
| I.C.7 | NSSS Vendor Review of Procedures | I | All | All | | NA | 06/26/80 |
| I.C.8 | Pilot Monitoring of Selected Emergency Procedures for Near-Term Operating License Applicants | I | All | All | | NA | 06/26/80 |
| I.C.9 | Long-Term Program Plan for Upgrading of Procedures | NOTE 3(a) | All | All | | 09/13/79 | 06/-/85 |

A.B-3

I.D CONTROL ROOM DESIGN

| | | | | | | | |
|----------|--|-----------|-----|-----|------|----------|----------|
| I.D.1 | Control Room Design Reviews | I | All | All | F-08 | 06/26/80 | 06/26/80 |
| I.D.2 | Plant Safety Parameter Display Console | I | All | All | F-09 | 06/26/80 | 06/26/80 |
| I.D.5 | Improved Control Room Instrumentation Research | - | - | - | - | - | - |
| I.D.5(2) | Plant Status and Post-Accident Monitoring | NOTE 3(a) | All | All | | NA | 12/-/80 |

I.F QUALITY ASSURANCE

| | | | | | | | |
|----------|---|-----------|-----|-----|---|----|---------|
| I.F.2 | Develop More Detailed QA Criteria | - | - | - | - | - | - |
| I.F.2(2) | Include QA Personnel in Review and Approval of Plant Procedures | NOTE 3(a) | All | All | | NA | 07/-/81 |
| I.F.2(3) | Include QA Personnel in All Design, Construction, Installation, Testing, and Operation Activities | NOTE 3(a) | All | All | | NA | 07/-/81 |
| I.F.2(6) | Increase the Size of Licensees' QA Staff | NOTE 3(a) | All | All | | NA | 07/-/81 |
| I.F.2(9) | Clarify Organizational Reporting Levels for the QA Organization | NOTE 3(a) | All | All | | NA | 07/-/81 |

NUREG-0933

I.G PREOPERATIONAL AND LOW-POWER TESTING

| | | | | | | | |
|-------|-----------------------|-----------|-----|-----|--|----|----------|
| I.G.1 | Training Requirements | I | All | All | | NA | 06/26/80 |
| I.G.2 | Scope of Test Program | NOTE 3(a) | All | All | | NA | 07/-/81 |

Revision 17

Appendix B (Continued)

06/30/02

| Action Plan Item/Issue No. | Title | Safety Priority/Status | Affected NSSS Vendor | | Operating Plants- MPA No | Operating Plants - Effective Date | Future Plants- Effective Date |
|----------------------------|---|------------------------|----------------------|-----|--------------------------|-----------------------------------|-------------------------------|
| | | | BWR | PWR | | | |
| <u>II.B</u> | <u>CONSIDERATION OF DEGRADED OR MELTED CORES IN SAFETY REVIEW</u> | | | | | | |
| II.B.1 | Reactor Coolant System Vents | I | All | All | F-10 | 09/13/79 | 09/27/79 |
| II.B.2 | Plant Shielding to Provide Access to Vital Areas and Protect Safety Equipment for Post-Accident Operation | I | All | All | F-11 | 09/13/79 | 09/27/79 |
| II.B.3 | Post-Accident Sampling | I | All | All | F-12 | 09/13/79 | 09/27/79 |
| II.B.4 | Training for Mitigating Core Damage | I | All | All | F-13 | 03/28/80 | 03/28/80 |
| II.B.6 | Risk Reduction for Operating Reactors at Sites with High Population Densities | NOTE 3(a) | All | All | | TBD | NA |
| II.B.8 | Rulemaking Proceeding on Degraded Core Accidents | NOTE 3(a) | All | All | | TBD | 01/25/85 |
| <u>II.D</u> | <u>REACTOR COOLANT SYSTEM RELIEF AND SAFETY VALVES</u> | | | | | | |
| II.D.1 | Testing Requirements | I | All | All | F-14 | 09/13/79 | 09/27/79 |
| II.D.3 | Relief and Safety Valve Position Indication | I | All | All | | 07/21/79 | 09/27/79 |
| <u>II.E</u> | <u>SYSTEM DESIGN</u> | | | | | | |
| <u>II.E.1</u> | <u>Auxiliary Feedwater System</u> | | | | | | |
| II.E.1.1 | Auxiliary Feedwater System Evaluation | I | NA | All | F-15 | 03/10/80 | 03/10/80 |
| II.E.1.2 | Auxiliary Feedwater System Automatic Initiation and Flow Indication | I | NA | All | F-16, F-17 | 09/13/79 | 09/27/79 |
| II.E.1.3 | Update Standard Review Plan and Develop Regulatory Guide | NOTE 3(a) | All | All | | NA | 07/-/81 |
| <u>II.E.3</u> | <u>Decay Heat Removal</u> | | | | | | |
| II.E.3.1 | Reliability of Power Supplies for Natural Circulation | I | NA | All | | 09/13/79 | 09/27/79 |
| <u>II.E.4</u> | <u>Containment Design</u> | | | | | | |
| II.E.4.1 | Dedicated Penetrations | I | All | All | F-18 | 09/13/79 | 09/27/79 |
| II.E.4.2 | Isolation Dependability | I | All | All | F-19 | 09/13/79 | 09/27/79 |
| II.E.4.4 | Purging | - | - | - | - | - | - |
| II.E.4.4(1) | Issue Letter to Licensees Requesting Limited Purging | NOTE 3(a) | All | All | | 11/28/78 | NA |
| II.E.4.4(2) | Issue Letter to Licensees Requesting Information on Isolation Letter | NOTE 3(a) | All | All | | 10/22/79 | NA |
| II.E.4.4(3) | Issue Letter to Licensees on Valve Operability | NOTE 3(a) | All | All | | 09/27/79 | NA |

A.B-4

NUREG-0933

Revision 17

Appendix B (Continued)

06/30/02

| Action Plan Item/Issue No. | Title | Safety Priority/Status | Affected NSSS Vendor | | Operating Plants- MPA No | Operating Plants - Effective Date | Future Plants- Effective Date |
|----------------------------|--|------------------------|----------------------|-----|--|-----------------------------------|-------------------------------|
| | | | BWR | PWR | | | |
| <u>II.E.5</u> | <u>Design Sensitivity of B&W Reactors</u> | | | | | | |
| II.E.5.1 | Design Evaluation | NOTE 3(a) | NA | B&W | | | |
| II.E.5.2 | B&W Reactor Transient Response Task Force | NOTE 3(a) | NA | B&W | | | |
| <u>II.E.6</u> | <u>In Situ Testing of Valves</u> | | | | | | |
| II.E.6.1 | Test Adequacy Study | NOTE 3(a) | All | All | | 06/--/89 | 06/--/89 |
| <u>II.F</u> | <u>INSTRUMENTATION AND CONTROLS</u> | | | | | | |
| II.F.1 | Additional Accident Monitoring Instrumentation | I | All | All | F-20, F-21 F-22, F-23 F-24, F-25 | 09/13/79 | 09/27/79 |
| II.F.2 | Identification of and Recovery from Conditions Leading to Inadequate Core Cooling | I | All | All | F-26 | 07/02/79 | 09/27/79 |
| II.F.3 | Instruments for Monitoring Accident Conditions | NOTE 3(a) | All | All | | NA | 12/--/80 |
| <u>II.G</u> | <u>ELECTRICAL POWER</u> | | | | | | |
| II.G.1 | Power Supplies for Pressurizer Relief Valves, Block Valves, and Level Indicators | I | NA | All | | 09/13/79 | 09/27/79 |
| <u>II.J</u> | <u>GENERAL IMPLICATIONS OF TMI FOR DESIGN AND CONSTRUCTION ACTIVITIES</u> | | | | | | |
| <u>II.J.4</u> | <u>Revise Deficiency Reporting Requirements</u> | | | | | | |
| II.J.4.1 | Revise Deficiency Reporting Requirements | NOTE 3(a) | All | All | | 07/31/91 | 07/31/91 |
| <u>II.K</u> | <u>MEASURES TO MITIGATE SMALL-BREAK LOSS-OF-COOLANT ACCIDENTS AND LOSS-OF-FEEDWATER ACCIDENTS</u> | | | | | | |
| II.K.1 | IE Bulletins | - | - | - | | | |
| II.K.1(1) | Review TMI-2 PNs and Detailed Chronology of the TMI-2 Accident | NOTE 3(a) | All | All | | 03/31/80 | NA |
| II.K.1(2) | Review Transients Similar to TMI-2 That Have Occurred at Other Facilities and NRC Evaluation of Davis-Besse Event | NOTE 3(a) | NA | B&W | | 03/31/80 | NA |
| II.K.1(3) | Review Operating Procedures for Recognizing, Preventing, and Mitigating Void Formation in Transients and Accidents | NOTE 3(a) | NA | All | | 03/31/80 | NA |

A.B-5

NUREG-0933

Revision 17

Appendix B (Continued)

06/30/02

| Action Plan Item/Issue No. | Title | Safety Priority/Status | Affected NSSS Vendor | | Operating Plants- MPA No | Operating Plants - Effective Date | Future Plants- Effective Date |
|----------------------------|---|------------------------|----------------------|--------------|--------------------------|-----------------------------------|-------------------------------|
| | | | BWR | PWR | | | |
| II.K.1(4) | Review Operating Procedures and Training Instructions | NOTE 3(a) | All | All | | 03/31/80 | NA |
| II.K.1(5) | Safety-Related Valve Position Description | NOTE 3(a) | All | All | | 03/31/80 | 03/31/80 |
| II.K.1(6) | Review Containment Isolation Initiation Design and Procedures | NOTE 3(a) | All | All | | 03/31/80 | NA |
| II.K.1(7) | Implement Positive Position Controls on Valves That Could Compromise or Defeat AFW Flow | NOTE 3(a) | NA | B&W | | 03/31/80 | NA |
| II.K.1(8) | Implement Procedures That Assure Two Independent 100% AFW Flow Paths | NOTE 3(a) | NA | B&W | | 03/31/80 | NA |
| II.K.1(9) | Review Procedures to Assure That Radioactive Liquids and Gases Are Not Transferred out of Containment Inadvertently | NOTE 3(a) | All | All | | 03/31/80 | NA |
| II.K.1(10) | Review and Modify Procedures for Removing Safety-Related Systems from Service | NOTE 3(a) | All | All | | 03/31/80 | 03/31/80 |
| II.K.1(11) | Make All Operating and Maintenance Personnel Aware of the Seriousness and Consequences of the Erroneous Actions Leading up to, and in Early Phases of, the TMI-2 Accident | NOTE 3(a) | All | All | | 03/31/80 | NA |
| II.K.1(12) | One Hour Notification Requirement and Continuous Communications Channels | NOTE 3(a) | All | All | | | NA |
| II.K.1(13) | Propose Technical Specification Changes Reflecting Implementation of All Bulletin Items | NOTE 3(a) | All | All | | 01/01/81 | 01/01/81 |
| II.K.1(14) | Review Operating Modes and Procedures to Deal with Significant Amounts of Hydrogen | NOTE 3(a) | GE | CE, <u>W</u> | | 03/31/80 | NA |
| II.K.1(15) | For Facilities with Non-Automatic AFW Initiation, Provide Dedicated Operator in Continuous Communication with CR to Operate AFW | NOTE 3(a) | NA | CE, <u>W</u> | | NA | |
| II.K.1(16) | Implement Procedures That Identify PRZ PORV "Open" Indications and That Direct Operator to Close Manually at "Reset" Setpoint | NOTE 3(a) | NA | CE, <u>W</u> | | NA | |
| II.K.1(17) | Trip PZR Level Bistable so That PZR Low Pressure Will Initiate Safety Injection | NOTE 3(a) | NA | <u>W</u> | | | |
| II.K.1(18) | Develop Procedures and Train Operators on Methods of Establishing and Maintaining Natural Circulation | NOTE 3(a) | NA | B&W | | NA | |
| II.K.1(19) | Describe Design and Procedure Modifications to Reduce Likelihood of Automatic PZR PORV Actuation in Transients | NOTE 3(a) | NA | B&W | | 03/31/80 | NA |
| II.K.1(20) | Provide Procedures and Training to Operators for Prompt Manual Reactor Trip for LOFW, TT, MSIV Closure, LOOP, LOSG Level, and LO PZR Level | NOTE 3(a) | NA | B&W | | 03/31/80 | 03/31/80 |

A.B-6

NUREG-0933

Revision 17

Appendix B (Continued)

06/30/02

| Action Plan Item/Issue No. | Title | Safety Priority/Status | Affected NSSS Vendor | | Operating Plants- MPA No | Operating Plants - Effective Date | Future Plants- Effective Date |
|----------------------------|--|------------------------|----------------------|-----|--------------------------|-----------------------------------|-------------------------------|
| | | | BWR | PWR | | | |
| II.K.1(21) | Provide Automatic Safety-Grade Anticipatory Reactor Trip for LOFW, TT, or Significant Decrease in SG Level | NOTE 3(a) | NA | B&W | | 03/31/80 | 03/31/80 |
| II.K.1(22) | Describe Automatic and Manual Actions for Proper Functioning of Auxiliary Heat Removal Systems When FW System Not Operable | NOTE 3(a) | All | NA | | 03/31/80 | 03/31/80 |
| II.K.1(23) | Describe Uses and Types of RV Level Indication for Automatic and Manual Initiation Safety Systems | NOTE 3(a) | All | NA | | 03/31/80 | 03/31/80 |
| II.K.1(24) | Perform LOCA Analyses for a Range of Small-Break Sizes and a Range of Time Lapses Between Reactor Trip and RCP Trip | NOTE 3(a) | NA | All | | NA | |
| II.K.1(25) | Develop Operator Action Guidelines | NOTE 3(a) | NA | All | | NA | |
| II.K.1(26) | Revise Emergency Procedures and Train ROs and SROs | NOTE 3(a) | NA | All | | NA | |
| II.K.1(27) | Provide Analyses and Develop Guidelines and Procedures for Inadequate Core Cooling Conditions | NOTE 3(a) | NA | All | | NA | |
| II.K.1(28) | Provide Design That Will Assure Automatic RCP Trip for All Circumstances Where Required | NOTE 3(a) | NA | All | | 01/01/81 | 01/01/82 |
| II.K.2 | Commission Orders on B&W Plants | - | - | - | | - | - |
| II.K.2(1) | Upgrade Timeliness and Reliability of AFW System | NOTE 3(a) | NA | B&W | | NA | |
| II.K.2(2) | Procedures and Training to Initiate and Control AFW Independent of Integrated Control System | NOTE 3(a) | NA | B&W | | NA | |
| II.K.2(3) | Hard-Wired Control-Grade Anticipatory Reactor Trips | NOTE 3(a) | NA | B&W | | NA | |
| II.K.2(4) | Small-Break LOCA Analysis, Procedures and Operator Training | NOTE 3(a) | NA | B&W | | NA | |
| II.K.2(5) | Complete TMI-2 Simulator Training for All Operators | NOTE 3(a) | NA | B&W | | NA | |
| II.K.2(6) | Reevaluate Analysis for Dual-Level Setpoint Control | NOTE 3(a) | NA | B&W | | NA | |
| II.K.2(7) | Reevaluate Transient of September 24, 1977 | NOTE 3(a) | NA | B&W | | NA | |
| II.K.2(9) | Analysis and Upgrading of Integrated Control System | I | NA | B&W | F-27 | 01/01/81 | 01/01/81 |
| II.K.2(10) | Hard-Wired Safety-Grade Anticipatory Reactor Trips | I | NA | B&W | F-28 | 01/01/81 | 01/01/81 |
| II.K.2(11) | Operator Training and Drilling | I | NA | B&W | F-29 | 01/01/81 | 01/01/81 |
| II.K.2(13) | Thermal-Mechanical Report on Effect of HPI on Vessel Integrity for Small-Break LOCA With No AFW | I | NA | B&W | F-30 | 01/01/81 | 01/01/81 |
| II.K.2(14) | Demonstrate That Predicted Lift Frequency of PORVs and SVs Is Acceptable | I | NA | B&W | F-31 | 01/01/81 | 01/01/81 |
| II.K.2(15) | Analysis of Effects of Slug Flow on Once-Through Steam Generator Tubes After Primary System Voiding | I | NA | B&W | | 06/01/80 | 06/01/80 |
| II.K.2(16) | Impact of RCP Seal Damage Following Small-Break LOCA With Loss of Offsite Power | I | NA | B&W | F-32 | 06/01/80 | 06/01/80 |

A.B-7

NUREG-0933

Revision 17

Appendix B (Continued)

06/30/02

| Action Plan Item/Issue No. | Title | Safety Priority/Status | Affected NSSS Vendor | | Operating Plants- MPA No | Operating Plants - Effective Date | Future Plants- Effective Date |
|----------------------------|---|------------------------|----------------------|----------|--------------------------|-----------------------------------|-------------------------------|
| | | | BWR | PWR | | | |
| II.K.2(17) | Analysis of Potential Voiding in RCS During Anticipated Transients | I | NA | B&W | F-33 | NA | |
| II.K.2(19) | Benchmark Analysis of Sequential AFW Flow to Once-Through Steam Generator | I | NA | B&W | F-34 | 01/01/81 | NA |
| II.K.2(20) | Analysis of Steam Response to Small-Break LOCA That Causes System Pressure to Exceed PORV Setpoint | I | NA | B&W | F-35 | 01/01/81 | NA |
| II.K.2(21) | LOFT L3-1 Predictions | NOTE 3(a) | NA | B&W | | NA | |
| II.K.3 | Final Recommendations of Bulletins and Orders Task Force | - | - | - | - | - | - |
| II.K.3(1) | Install Automatic PORV Isolation System and Perform Operational Test | I | NA | All | F-36 | 07/01/81 | 07/01/81 |
| II.K.3(2) | Report on Overall Safety Effect of PORV Isolation System | I | NA | All | F-37 | 01/01/81 | 01/01/81 |
| II.K.3(3) | Report Safety and Relief Valve Failures Promptly and Challenges Annually | I | All | All | F-38 | 04/01/80 | 04/01/80 |
| II.K.3(5) | Automatic Trip of Reactor Coolant Pumps | I | NA | All | F-39, G-01 | 01/01/81 | 01/01/81 |
| II.K.3(7) | Evaluation of PORV Opening Probability During Overpressure Transient | I | NA | B&W | | 01/01/81 | 01/01/81 |
| II.K.3(9) | Proportional Integral Derivative Controller Modification | I | NA | <u>W</u> | F-40 | 07/01/80 | 07/01/80 |
| II.K.3(10) | Anticipatory Trip Modification Proposed by Some Licensees to Confine Range of Use to High Power Levels | I | NA | <u>W</u> | F-41 | | |
| II.K.3(11) | Control Use of PORV Supplied by Control Components, Inc. Until Further Review Complete | I | All | All | | | |
| II.K.3(12) | Confirm Existence of Anticipatory Trip Upon Turbine Trip | I | NA | <u>W</u> | F-42 | 07/01/80 | 07/01/80 |
| II.K.3(13) | Separation of HPCI and RCIC System Initiation Levels | I | GE | NA | F-43 | 10/01/80 | 10/01/80 |
| II.K.3(14) | Isolation of Isolation Condensers on High Radiation | I | GE | NA | F-44 | 01/01/81 | NA |
| II.K.3(15) | Modify Break Detection Logic to Prevent Spurious Isolation of HPCI and RCIC Systems | I | GE | NA | F-45 | 01/01/81 | 01/01/81 |
| II.K.3(16) | Reduction of Challenges and Failures of Relief Valves - Feasibility Study and System Modification | I | GE | NA | F-46 | 01/01/81 | 01/01/81 |
| II.K.3(17) | Report on Outage of ECC Systems - Licensee Report and Technical Specification Changes | I | GE | NA | F-47 | 01/01/81 | 01/01/81 |
| II.K.3(18) | Modification of ADS Logic - Feasibility Study and Modification for Increased Diversity for Some Event Sequences | I | GE | NA | F-48 | 01/01/81 | 01/01/81 |
| II.K.3(19) | Interlock on Recirculation Pump Loops | I | GE | NA | F-49 | 01/01/81 | NA |
| II.K.3(20) | Loss of Service Water for Big Rock Point | I | GE | NA | | 01/01/81 | NA |

A.B-8

NUREG-0933

Revision 17

Appendix B (Continued)

06/30/02

| Action Plan Item/Issue No. | Title | Safety Priority/Status | Affected NSSS Vendor | | Operating Plants- MPA No | Operating Plants - Effective Date | Future Plants- Effective Date |
|----------------------------|--|------------------------|----------------------|-----|--------------------------|-----------------------------------|-------------------------------|
| | | | BWR | PWR | | | |
| II.K.3(21) | Restart of Core Spray and LPCI Systems on Low Level - Design and Modification | I | GE | NA | F-50 | 01/01/81 | 01/01/81 |
| II.K.3(22) | Automatic Switchover of RCIC System Suction - Verify Procedures and Modify Design | I | GE | NA | F-51 | 01/01/81 | 01/01/81 |
| II.K.3(24) | Confirm Adequacy of Space Cooling for HPCI and RCIC Systems | I | GE | NA | F-52 | 01/01/82 | 01/01/82 |
| II.K.3(25) | Effect of Loss of AC Power on Pump Seals | I | GE | NA | F-53 | 01/01/82 | 01/01/82 |
| II.K.3(27) | Provide Common Reference Level for Vessel Level Instrumentation | I | GE | NA | F-54 | 10/01/80 | 10/01/80 |
| II.K.3(28) | Study and Verify Qualification of Accumulators on ADS Valves | I | GE | NA | F-55 | 01/01/82 | 01/01/82 |
| II.K.3(29) | Study to Demonstrate Performance of Isolation Condensers with Non-Condensibles | I | GE | NA | F-56 | 04/01/81 | NA |
| II.K.3(30) | Revised Small-Break LOCA Methods to Show Compliance with 10 CFR 50, Appendix K | I | All | All | F-57 | 01/01/83 | 01/01/83 |
| II.K.3(31) | Plant-Specific Calculations to Show Compliance with 10 CFR 50.46 | I | All | All | F-58 | 01/01/83 | 01/01/83 |
| II.K.3(44) | Evaluation of Anticipated Transients with Single Failure to Verify No Significant Fuel Failure | I | GE | NA | F-59 | 01/01/81 | 01/01/81 |
| II.K.3(45) | Evaluate Depressurization with Other Than Full ADS | I | GE | NA | F-60 | 01/01/81 | 01/01/81 |
| II.K.3(46) | Response to List of Concerns from ACRS Consultant | I | GE | NA | F-61 | 07/01/80 | 07/01/80 |
| II.K.3(57) | Identify Water Sources Prior to Manual Activation of ADS | I | GE | NA | F-62 | 10/01/80 | NA |

A.B.9

III.A EMERGENCY PREPAREDNESS AND RADIATION EFFECTS

III.A.1 Improve Licensee Emergency Preparedness - Short Term

| | | | | | | | |
|--------------|---|---|-----|-----|------|----------|----------|
| III.A.1.1 | Upgrade Emergency Preparedness | - | - | - | - | - | - |
| III.A.1.1(1) | Implement Action Plan Requirements for Promptly Improving Licensee Emergency Preparedness | I | All | All | - | 10/10/79 | 08/19/80 |
| III.A.1.2 | Upgrade Licensee Emergency Support Facilities | - | - | - | - | - | - |
| III.A.1.2(1) | Technical Support Center | I | All | All | F-63 | 09/13/79 | 09/27/79 |
| III.A.1.2(2) | On-Site Operational Support Center | I | All | All | F-64 | 09/13/79 | 09/27/79 |
| III.A.1.2(3) | Near-Site Emergency Operations Facility | I | All | All | F-65 | 09/13/79 | 09/27/79 |

III.A.2 Improving Licensee Emergency Preparedness-Long Term

| | | | | | | | |
|--------------|--|-----------|-----|-----|------|---|---|
| III.A.2.1 | Amend 10 CFR 50 and 10 CFR 50, Appendix E | - | - | - | - | - | - |
| III.A.2.1(1) | Publish Proposed Amendments to the Rules | NOTE 3(a) | All | All | - | - | - |
| III.A.2.1(4) | Revise Inspection Program to Cover Upgraded Requirements | I | All | All | F-67 | - | - |

NUREG-0933

Revision 17

Appendix B (Continued)

06/30/02

| Action Plan Item/Issue No. | Title | Safety Priority/Status | Affected NSSS Vendor | | Operating Plants-MPA No | Operating Plants - Effective Date | Future Plants-Effective Date |
|----------------------------|--|------------------------|----------------------|-----|-------------------------|-----------------------------------|------------------------------|
| | | | BWR | PWR | | | |
| III.A.2.2 | Development of Guidance and Criteria | I | All | All | F-68 | | |
| <u>III.A.3</u> | <u>Improving NRC Emergency Preparedness Communications</u> | | | | | | |
| III.A.3.3 | Communications | - | - | - | - | - | - |
| III.A.3.3(1) | Install Direct Dedicated Telephone Lines | NOTE 3(a) | All | All | | | |
| III.A.3.3(2) | Obtain Dedicated, Short-Range Radio Communication Systems | NOTE 3(a) | All | All | | | |
| <u>III.D</u> | <u>RADIATION PROTECTION</u> | | | | | | |
| <u>III.D.1</u> | <u>Radiation Source Control</u> | | | | | | |
| III.D.1.1 | Primary Coolant Sources Outside the Containment Structure | - | - | - | - | - | - |
| III.D.1.1(1) | Review Information Submitted by Licensees Pertaining to Reducing Leakage from Operating Systems | I | All | All | | 07/02/79 | 09/27/79 |
| <u>III.D.3</u> | <u>Worker Radiation Protection Improvement</u> | | | | | | |
| III.D.3.3 | Implant Radiation Monitoring | - | - | - | - | - | - |
| III.D.3.3(1) | Issue Letter Requiring Improved Radiation Sampling Instrumentation | I | All | All | F-69 | 09/13/79 | 09/27/79 |
| III.D.3.3(2) | Set Criteria Requiring Licensees to Evaluate Need for Additional Survey Equipment | NOTE 3(a) | All | All | | 09/13/79 | 09/27/79 |
| III.D.3.3(3) | Issue a Rule Change Providing Acceptable Methods for Calibration of Radiation-Monitoring Instruments | NOTE 3(a) | All | All | | 09/13/79 | 09/27/79 |
| III.D.3.3(4) | Issue a Regulatory Guide | NOTE 3(a) | All | All | | 09/13/79 | 09/27/79 |
| III.D.3.4 | Control Room Habitability | I | All | All | F-70 | 05/07/80 | 06/26/80 |

TASK ACTION PLAN ITEMS

A.B-10

NUREG-0933

| | | | | | | | |
|-----|---|-----------|-----|----------|------|----------|----------|
| A-1 | Water Hammer (former USI) | NOTE 3(a) | All | All | | NA | 03/15/84 |
| A-2 | Asymmetric Blowdown Loads on Reactor Primary Coolant Systems (former USI) | NOTE 3(a) | NA | All | D-10 | 01/-/81 | 01/-/81 |
| A-3 | Westinghouse Steam Generator Tube Integrity (former USI) | NOTE 3(a) | NA | <u>W</u> | | 04/17/85 | 04/17/85 |
| A-4 | CE Steam Generator Tube Integrity (former USI) | NOTE 3(a) | NA | CE | | 04/17/85 | 04/17/85 |
| A-5 | B&W Steam Generator Tube Integrity (former USI) | NOTE 3(a) | NA | B&W | | 04/17/85 | 04/17/85 |
| A-6 | Mark I Short-Term Program (former USI) | NOTE 3(a) | GE | NA | | 12/-/77 | NA |
| A-7 | Mark I Long-Term Program (former USI) | NOTE 3(a) | GE | NA | D-01 | 08/-/82 | 08/-/82 |
| A-8 | Mark II Containment Pool Dynamic Loads - Long Term Program (former USI) | NOTE 3(a) | GE | NA | | 08/-/81 | 08/-/81 |
| A-9 | ATWS (former USI) | NOTE 3(a) | All | All | | 06/26/84 | 06/26/84 |

Revision 17

Appendix B (Continued)

06/30/02

A.B-11

NUREG-0933

| Action Plan Item/Issue No. | Title | Safety Priority/Status | Affected NSSS Vendor | | Operating Plants- MPA No | Operating Plants - Effective Date | Future Plants- Effective Date |
|----------------------------|--|------------------------|----------------------|----------|--------------------------|-----------------------------------|-------------------------------|
| | | | BWR | PWR | | | |
| A-10 | BWR Feedwater Nozzle Cracking (former USI) | NOTE 3(a) | All | NA | B-25 | 11/--/80 | 11/--/80 |
| A-11 | Reactor Vessel Materials Toughness (former USI) | NOTE 3(a) | All | All | | 10/--/82 | NA |
| A-12 | Fracture Toughness of Steam Generator and Reactor Coolant Pump Supports (former USI) | NOTE 3(a) | NA | All | | NA | TBD |
| A-13 | Snubber Operability Assurance | NOTE 3(a) | All | All | B-17, B-22 | 1980 | 1980 |
| A-16 | Steam Effects on BWR Core Spray Distribution | NOTE 3(a) | GE | NA | D-12 | NA | |
| A-24 | Qualification of Class 1E Safety Related Equipment (former USI) | NOTE 3(a) | All | All | B-60 | 08/--/81 | 08/--/81 |
| A-25 | Non-Safety Loads on Class 1E Power Sources | NOTE 3(a) | All | All | | 09/--/78 | |
| A-26 | Reactor Vessel Pressure Transient Protection (former USI) | NOTE 3(a) | NA | All | B-04 | 09/--/78 | 09/--/78 |
| A-28 | Increase in Spent Fuel Pool Storage Capacity | NOTE 3(a) | All | All | | 04/17/78 | NA |
| A-31 | RHR Shutdown Requirements (former USI) | NOTE 3(a) | All | All | | 05/--/78 | 10/01/78 |
| A-35 | Adequacy of Offsite Power Systems | NOTE 3(a) | All | All | B-23 | 06/02/77 | 1980 |
| A-36 | Control of Heavy Loads Near Spent Fuel (former USI) | NOTE 3(a) | All | All | C-10, C-15 | 07/--/80 | 07/--/80 |
| A-39 | Determination of Safety Relief Valve Pool Dynamic Loads and Temperature Limits (former USI) | NOTE 3(a) | GE | NA | | 02/29/80 | 09/30/80 |
| A-40 | Seismic Design Criteria (former USI) | NOTE 3(a) | All | All | | TBD | 09/--/89 |
| A-42 | Pipe Cracks in Boiling Water Reactors (former USI) | NOTE 3(a) | All | NA | B-05 | 02/--/81 | 02/--/81 |
| A-43 | Containment Emergency Sump Performance (former USI) | NOTE 3(a) | NA | All | | NA | 11/--/85 |
| A-44 | Station Blackout (former USI) | NOTE 3(a) | All | All | | TBD | 06/--/88 |
| A-46 | Seismic Qualification of Equipment in Operating Plants (former USI) | NOTE 3(a) | All | All | | 02/--/87 | NA |
| A-47 | Safety Implications of Control Systems (former USI) | NOTE 3(a) | All | All | | 09/20/89 | 09/20/89 |
| A-48 | Hydrogen Control Measures and Effects of Hydrogen Burns on Safety Equipment | NOTE 3(a) | All | <u>W</u> | | 12/--/81 | 12/--/81 |
| A-49 | Pressurized Thermal Shock (former USI) | NOTE 3(a) | NA | All | A-21 | TBD | 07/--/85 |
| B-10 | Behavior of BWR Mark III Containments | NOTE 3(a) | GE | NA | | NA | 09/--/84 |
| B-36 | Develop Design, Testing, and Maintenance Criteria for Atmosphere Cleanup System Air Filtration and Adsorption Units for Engineered Safety Feature Systems and for Normal Ventilation Systems | NOTE 3(a) | All | All | | 03/--/78 | |
| B-56 | Diesel Reliability | NOTE 3(a) | All | All | D-19 | 06/--/93 | 06/--/93 |
| B-63 | Isolation of Low Pressure Systems Connected to the Reactor Coolant Pressure Boundary | NOTE 3(a) | All | All | B-45 | 04/20/81 | |
| B-64 | Decommissioning of Reactors | NOTE 3(a) | All | All | | 06/27/88 | NA |
| B-66 | Control Room Infiltration Measurements | NOTE 3(a) | All | All | | NA | 07/--/81 |
| C-1 | Assurance of Continuous Long Term Capability of Hermetic Seals on Instrumentation and Electrical Equipment | NOTE 3(a) | All | All | | 05/27/80 | 05/27/80 |

Appendix B (Continued)

06/30/02

| Action Plan Item/Issue No. | Title | Safety Priority/Status | Affected NSSS Vendor | | Operating Plants- MPA No | Operating Plants - Effective Date | Future Plants- Effective Date |
|----------------------------|--|------------------------|----------------------|--------------|--|-----------------------------------|-------------------------------|
| | | | BWR | PWR | | | |
| C-10 | Effective Operation of Containment Sprays in a LOCA Interim Acceptance Criteria for Solidification Agents for Radioactive Solid Wastes | NOTE 3(a) | All | All | | NA | |
| C-17 | | NOTE 3(a) | All | All | | 12/27/82 | 12/27/82 |
| <u>NEW GENERIC ISSUES</u> | | | | | | | |
| 25. | Automatic Air Header Dump on BWR Scram System | NOTE 3(a) | All | NA | | 01/09/81 | 01/09/81 |
| 40. | Safety Concerns Associated with Pipe Breaks in the BWR Scram System | NOTE 3(a) | All | NA | B-65 | 08/31/81 | 08/31/81 |
| 41. | BWR Scram Discharge Volume Systems | NOTE 3(a) | All | NA | B-58 | 12/09/80 | NA |
| 43. | Reliability of Air Systems | NOTE 3(a) | All | All | B-107 | 08/08/88 | 08/08/88 |
| 45 | Inoperability of Instrumentation Due to Extreme Cold Weather | NOTE 3(a) | All | All | | NA | 09/01/83 |
| 51. | Proposed Requirements for Improving the Reliability of Open Cycle Service Water Systems | NOTE 3(a) | All | All | L-913 | 07/18/89 | 07/18/89 |
| 67. | <u>Steam Generator Staff Actions</u> | - | - | - | - | - | - |
| 67.3.3 | Improved Accident Monitoring | NOTE 3(a) | All | All | A-17 | 12/17/82 | 12/17/82 |
| 70. | PORV and Block Valve Reliability | NOTE 3(a) | NA | All | | 06/25/90 | 06/25/90 |
| 73. | Detached Thermal Sleeves | NOTE 3(a) | NA | <u>W</u> | | NA | |
| 75. | Generic Implications of ATWS Events at the Salem Nuclear Plant | NOTE 3(a) | All | All | B-76, B-77, B-78, B-79, B-80, B-81, B-82, B-85, B-86, B-87, B-88, B-89, B-90, B-91, B-92, B-93 | 07/08/83 | TBD |
| 86. | Long Range Plan for Dealing with Stress Corrosion Cracking in BWR Piping | NOTE 3(a) | All | NA | B-84 | TBD | TBD |
| 87. | Failure of HPCI Steam Line Without Isolation | NOTE 3(a) | All | All | | 06/28/89 | 06/28/89 |
| 89. | Stiff Pipe Clamps | NOTE 6 | All | All | NA | NA | TBD |
| 93 | Steam Binding of Auxiliary Feedwater Pumps | NOTE 3(a) | NA | All | B-98 | 10/-/85 | 10/-/85 |
| 94 | Additional Low Temperature Overpressure Protection for Light Water Reactors | NOTE 3(a) | NA | CE, <u>W</u> | | 06/25/90 | 06/25/90 |
| 99 | RCS/RHR Suction Line Valve Interlock on PWRs | NOTE 3(a) | NA | All | L-817 | 10/17/88 | 10/17/88 |
| 103 | Design for Probable Maximum Precipitation | NOTE 3(a) | All | All | | 10/19/89 | 10/19/89 |
| 118 | Tendon Anchorage Failure | NOTE 3(a) | All | All | NA | NA | 07/-/90 |
| 124 | Auxiliary Feedwater System Reliability | NOTE 3(a) | All | All | | TBD | TBD |
| 128 | Electrical Power Reliability | NOTE 3(a) | All | All | | 04/29/91 | 04/29/91 |
| 130 | Essential Service Water Pump Failures at Multiplant | NOTE 3(a) | NA | All | | 09/19/91 | 09/19/91 |

A.B-12

NUREG-0933

Revision 17

Appendix B (Continued)

06/30/02

| Action Plan Item/Issue No. | Title | Safety Priority/Status | Affected NSSS Vendor | | Operating Plants- MPA No | Operating Plants - Effective Date | Future Plants- Effective Date |
|----------------------------|---|------------------------|----------------------|-----|--------------------------|-----------------------------------|-------------------------------|
| | | | BWR | PWR | | | |
| | <u>Sites</u> | | | | | | |
| 155 | <u>Generic Concerns Arising from TMI-2 Cleanup</u> | - | - | - | - | - | - |
| 155.1 | More Realistic Source Term Assumptions | NOTE 3(a) | All | All | NA | NA | 02/--/95 |
| 156 | <u>Systematic Evaluation Program</u> | - | - | - | - | - | - |
| 156.6.1 | Pipe Break Effects on Systems and Components | HIGH | All | All | | TBD | TBD |
| 163 | Multiple Steam Generator Tube Leakage | HIGH | NA | All | | TBD | TBD |
| 168 | Environmental Qualification of Electrical Equipment | HIGH | All | All | | TBD | TBD |
| 177 | Vehicle Intrusion at TMI | NOTE 3(a) | All | All | | 08/01/94 | 08/01/94 |
| 185 | Control of Recriticality Following Small-Break LOCA in PWRs | HIGH | All | All | | TBD | TBD |
| 186 | Potential Risk and Consequences of Heavy Load Drops in Nuclear Power Plants | NOTE 4 | All | All | | TBD | TBD |
| 188 | Steam Generator Tube Leaks/Ruptures Concurrent With Containment Bypass | CONT. | All | All | | TBD | TBD |
| 189 | Susceptibility of Ice Condenser Containments to Early Failure from Hydrogen Combustion During A Severe Accident | CONT. | All | All | | TBD | TBD |
| 191 | Assessment of Debris Accumulation on PWR Sump Performance | HIGH | NA | All | | TBD | TBD |
| 192 | Secondary Containment Drawdown Time | NOTE 4 | All | NA | | TBD | TBD |
| 193 | BWR ECCS Suction Concerns | NOTE 4 | All | NA | | TBD | TBD |
| 194 | Implications of Updated Probabilistic Seismic Hazard Estimates | NOTE 4 | All | All | | TBD | TBD |
| | <u>HUMAN FACTORS ISSUES</u> | | | | | | |
| <u>HF1</u> | <u>STAFFING AND QUALIFICATIONS</u> | | | | | | |
| HF.1.1 | Shift Staffing | NOTE 3(a) | All | All | | 01/--/84 | 01/--/84 |

A.B-13

NUREG-0933

Revision 17

APPENDIX F

NUCLEAR MATERIAL SAFETY AND SAFEGUARDS GSIs

This appendix documents those non-reactor GSIs identified, prioritized, and resolved by NMSS. As stated in SECY-98-001,¹⁷²⁴ the prioritization procedure for these issues is contained in NMSS Policy and Procedures Letter 1-57,¹⁷²⁵ "NMSS Generic Issues Program."

TABLE F.1
LISTING OF NMSS GSIs

This table contains the priority designations for all NMSS GSIs listed in Appendix F.

Legend

NOTES: 3(a) - Resolution Resulted in the Establishment of New Requirements
 3(b) - Resolution Resulted in the Establishment of No New Requirements
 4 - Issue to be Prioritized in the Future
 HIGH - High Safety Priority
 MEDIUM - Medium Safety Priority
 LOW - Low Safety Priority

| Issue No. | Title | Priority Engineer | LeadOffice/ Division/Branch | Safety Priority Ranking | Latest Revision | Latest Issuance Date |
|-----------|---|-------------------|--------------------------------|-------------------------------|--------------------|----------------------------|
| NMSS-0001 | Door Interlock Failure Resulting from Faulty MicroSelectron-High Dose Rate Remote Afterloader | Ramsey | NMSS/IMNS/IMOB | NOTE 3(b) | | 12/31/1998 |
| NMSS-0002 | Significant Quantities of Fixed Contamination Remain in Krypton-85 Leak-Detection Devices After Venting | Ramsey | NMSS/IMNS/IMOB | NOTE 3(b) | | 12/31/1998 |
| NMSS-0003 | Corrosion of Sealed Sources Caused by Sensitization of Stainless Steel Source Capsules During Shipment | Ramsey | NMSS/IMNS/IMOB | NOTE 3(b) | | 12/31/1998 |
| NMSS-0004 | Overexposures Caused by Sources Stolen from Facility of Bankrupt Licensee | Ramsey | NMSS/IMNS/IMOB | NOTE 3(b) | | 12/31/1998 |
| NMSS-0005 | Potential for Erroneous Calibration, Dose Rate, or Radiation Exposure Measurements With Victoreen Electrometers | Ramsey | NMSS/IMNS/IMOB | NOTE 3(a) | | 12/31/1998 |
| NMSS-0006 | Criticality in Low-Level Waste | Ramsey | NMSS/IMNS/IMOB | NOTE 3(b) | 1 | 06/30/2000 |
| NMSS-0007 | Criticality Benchmarks Greater Than 5% Enrichment | Ramsey | NMSS/FCSS | HIGH | 1 | 06/30/2001 |
| NMSS-0008 | Year 2000 Computer Problem - Non-Reactor Licensees | Ramsey | NMSS/IMNS | NOTE 3(b) | 1 | 06/30/2000 |
| NMSS-0009 | Amersham Radiography Source Cable Failures | Ramsey | NMSS/IMNS | NOTE 3(b) | | 12/31/1998 |

06/30/02

A.F.0-3

NUREG-0933

| Issue No. | Title | Priority Engineer | LeadOffice/ Division/Branch | Safety Priority Ranking | Latest Revision | Latest Issuance Date |
|-----------|--|-------------------|--------------------------------|-------------------------------|--------------------|----------------------------|
| NMSS-0010 | Troxler Gauge Source Rod Weld Failures | Ramsey | NMSS/IMNS | NOTE 3(b) | 1 | 06/30/2002 |
| NMSS-0011 | Spent Fuel Dry Cask Weld Cracks | Ramsey | NMSS/SFPO | NOTE 3(b) | | 12/31/1998 |
| NMSS-0012 | Inadequate Transportation Packaging Puncture Tests | Ramsey | NMSS/SFPO | NOTE 3(b) | 1 | 06/30/2000 |
| NMSS-0013 | Use of Different Dose Equivalent Models to Show Compliance | Ramsey | NMSS/IMNS | NOTE 3(b) | 1 | 06/30/2000 |
| NMSS-0014 | Surety Estimates for Groundwater Restoration at In-Situ Leach Fields | Ramsey | NMSS/DWM | MEDIUM | | 12/31/1998 |
| NMSS-0015 | Adequacy of 10 CFR 150 Criticality Requirements | Ramsey | NMSS/DWM | NOTE 3(b) | 1 | 06/30/2000 |
| NMSS-0016 | Adequacy of 0.05 Weight Percent Limit in 10 CFR 40 | Ramsey | NMSS/IMNS | MEDIUM | | 12/31/1998 |
| NMSS-0017 | Misleading Marketing Information to General Licensees | C. Mattsen | NMSS/IMNS | NOTE 3(a) | | 06/30/2001 |
| NMSS-0018 | Problems Encountered When Manually Editing Treatment Planning Data on Nucletron MicroSelectron-HDR Model 105.999 | B. Ayres | NMSS/IMNS | NOTE 3(b) | | 06/30/2001 |
| NMSS-0019 | Control Unit Failures of Classic Nucletron HDR Units | B. Ayres | NMSS/IMNS | NOTE 3(b) | | 06/30/2001 |
| NMSS-0020 | Leaking Pools | M. Sitek | NMSS/IMNS | DROP | | 06/30/2001 |
| NMSS-0021 | Unlikely Events | M. Sitek | NMSS/IMNS | DROP | | 06/30/2001 |
| NMSS-0022 | Gamma Stereotactic Radiosurgery | M. Sitek | NMSS/IMNS | DROP | | 06/30/2001 |

Revision 4

NMSS-0010: TROXLER GAUGE SOURCE ROD WELD FAILURESDESCRIPTION

This issue was identified¹⁷⁰⁹ by NMSS after it was reported in June 1997 that the source from a Troxler moisture density gauge broke off the source rod and was left at a temporary job site. Prior to this event, there had been 6 known disconnects and 57 additional devices with cracked welds since 1996, and NRC Information Notice 96-52¹⁷¹³ had been issued to alert portable gauge licensees and vendors to the potential for cracks to develop in the insertion rod of Troxler Model 3400 portable moisture density gauges. If not detected early, the cracks may propagate, eventually leading to complete failure of the insertion rod and release of the contained radioactive material.

CONCLUSION

In July 1997, NMSS and representatives from the state of North Carolina met with Troxler to discuss the continuing problem of cracked and broken source rods. Between July 1997 and April 1998, the staff worked with the state of North Carolina on a Consent Order to Troxler which required Troxler to issue a customer bulletin, conduct accelerated device inspections, revise procedures, and perform additional tests. It is expected that the customer bulletin will address the problem and that Troxler will request their customers to have their gauges inspected. The issue was given a medium priority ranking¹⁷⁰⁹ and was later closed out after an NRC study showed that the gauge failure rate was low and Troxler had corrected its design.¹⁸⁰⁸

REFERENCES

- 1709. Memorandum to J. Craig from F. Combs, "Submittal of New Generic Issues for Tracking in the Generic Issues Management and Control System (GIMCS)," June 4, 1998.
- 1713. NRC Information Notice 96-52, "Cracked Insertion Rods on Troxler Model 3400 Series Portable Moisture Density Gauges," September 26, 1996.
- 1808. Memorandum to T. King from D. Cool, "NMSS Input for First Quarter FY-2002 Update of the Generic Issue Management Control System," January 16, 2002.

BIBLIOGRAPHIC DATA SHEET

(See instructions on the reverse)

1. REPORT NUMBER
*(Assigned by NRC, Add Vol., Supp., Rev.,
and Addendum Numbers, if any.)*

NUREG-0933
Supplement 26

2. TITLE AND SUBTITLE

A Prioritization of Generic Safety Issues

3. DATE REPORT PUBLISHED

MONTH | YEAR

October | 2003

4. FIN OR GRANT NUMBER

5. AUTHOR(S)

R. Emrit, et al.

6. TYPE OF REPORT

7. PERIOD COVERED *(Inclusive Dates)*

07-01-2001 to 06-30-2002

8. PERFORMING ORGANIZATION - NAME AND ADDRESS *(If NRC, provide Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)*

Division of Systems Analysis and Regulatory Effectiveness
Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

9. SPONSORING ORGANIZATION - NAME AND ADDRESS *(If NRC, type "Same as above"; if contractor, provide NRC Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address.)*

Division of Systems Analysis and Regulatory Effectiveness
Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

10. SUPPLEMENTARY NOTES

11. ABSTRACT *(200 words or less)*

The report presents the safety priority rankings for generic safety issues related to nuclear power plants. The purpose of these rankings is to assist in the timely and efficient allocation of NRC resources for the resolution of those safety issues that have a significant potential for reducing risk. The safety priority rankings are HIGH, MEDIUM, LOW, and DROP, and have been assigned on the basis of risk significance estimates, the ratio of risk to costs and other impacts estimated to result if resolution of the safety issues were implemented, and the consideration of uncertainties and other quantitative and qualitative factors. To the extent practical, estimates are quantitative.

12. KEY WORDS/DESCRIPTORS *(List words or phrases that will assist researchers in locating the report.)*

generic safety issues

13. AVAILABILITY STATEMENT

unlimited

14. SECURITY CLASSIFICATION

(This Page)


unclassified

(This Report)

unclassified

15. NUMBER OF PAGES

16. PRICE



Federal Recycling Program