

APPENDIX D - TECHNICAL SPECIFICATION CHANGES

10 CFR 54.22 requires that an application for license renewal include any technical specification changes or additions necessary to manage the effects of aging during the period of extended operation. NMPNS has not identified the need to add new Technical Specifications for license renewal. NMPNS has identified the need to modify existing NMP1 and NMP2 Technical Specifications to address Time Limited Aging Analyses as discussed in [Section 4.2.2](#), Pressure - Temperature (P – T) limits. Additionally, NMP1 Technical Specification 5.3, Reactor Vessel, will need to be revised prior to expiration of the current NMP1 operating license since it states that the Reactor Pressure Vessel design lifetime is 40 years. These changes to the NMP1 and NMP2 Technical Specifications will be submitted, when appropriate, under the normal license amendment process.