




Generic Environmental Impact Statement for License Renewal of Nuclear Plants




Supplement 21



Regarding
Browns Ferry Nuclear Plant, Units 1, 2, and 3



Draft Report for Comment



U.S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, DC 20555-0001



AVAILABILITY OF REFERENCE MATERIALS IN NRC PUBLICATIONS

NRC Reference Material

As of November 1999, you may electronically access NUREG-series publications and other NRC records at NRC's Public Electronic Reading Room at <http://www.nrc.gov/reading-rm.html>.

Publicly released records include, to name a few, NUREG-series publications; *Federal Register* notices; applicant, licensee, and vendor documents and correspondence; NRC correspondence and internal memoranda; bulletins and information notices; inspection and investigative reports; licensee event reports; and Commission papers and their attachments.

NRC publications in the NUREG series, NRC regulations, and *Title 10, Energy*, in the Code of *Federal Regulations* may also be purchased from one of these two sources.

1. The Superintendent of Documents
U.S. Government Printing Office
Mail Stop SSOP
Washington, DC 20402-0001
Internet: bookstore.gpo.gov
Telephone: 202-512-1800
Fax: 202-512-2250
2. The National Technical Information Service
Springfield, VA 22161-0002
www.ntis.gov
1-800-553-6847 or, locally, 703-605-6000

A single copy of each NRC draft report for comment is available free, to the extent of supply, upon written request as follows:

Address: Office of the Chief Information Officer,
Reproduction and Distribution
Services Section
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001
E-mail: DISTRIBUTION@nrc.gov
Facsimile: 301-415-2289

Some publications in the NUREG series that are posted at NRC's Web site address <http://www.nrc.gov/reading-rm/doc-collections/nuregs> are updated periodically and may differ from the last printed version. Although references to material found on a Web site bear the date the material was accessed, the material available on the date cited may subsequently be removed from the site.

Non-NRC Reference Material

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, and transactions, *Federal Register* notices, Federal and State legislation, and congressional reports. Such documents as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings may be purchased from their sponsoring organization.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at—

The NRC Technical Library
Two White Flint North
11545 Rockville Pike
Rockville, MD 20852-2738

These standards are available in the library for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from—

American National Standards Institute
11 West 42nd Street
New York, NY 10036-8002
www.ansi.org
212-642-4900

Legally binding regulatory requirements are stated only in laws; NRC regulations; licenses, including technical specifications; or orders, not in NUREG-series publications. The views expressed in contractor-prepared publications in this series are not necessarily those of the NRC.

The NUREG series comprises (1) technical and administrative reports and books prepared by the staff (NUREG-XXXX) or agency contractors (NUREG/CR-XXXX), (2) proceedings of conferences (NUREG/CP-XXXX), (3) reports resulting from international agreements (NUREG/IA-XXXX), (4) brochures (NUREG/BR-XXXX), and (5) compilations of legal decisions and orders of the Commission and Atomic and Safety Licensing Boards and of Directors' decisions under Section 2.206 of NRC's regulations (NUREG-0750).

**Generic Environmental
Impact Statement for
License Renewal of
Nuclear Plants**

Supplement 21

**Regarding
Browns Ferry Nuclear Plant, Units 1, 2, and 3**

Draft Report for Comment

Manuscript Completed: October 2004
Date Published: November 2004

**Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001**



Abstract

1
2
3
4 The U.S. Nuclear Regulatory Commission (NRC or Commission) considered the environmental
5 impacts of renewing nuclear power plant operating licenses (OLs) for a 20-year period in its
6 *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS),
7 NUREG-1437, Volumes 1 and 2, and codified the results in Title 10 of the Code of Federal
8 Regulations (CFR) Part 51. In the GEIS (and its Addendum 1), the staff identifies
9 92 environmental issues and reaches generic conclusions related to environmental impacts for
10 69 of these issues that apply to all plants or to plants with specific design or site characteristics.
11 Additional plant-specific review is required for the remaining 23 issues. These plant-specific
12 reviews are to be included in a supplement to the GEIS.
13

14 This supplemental environmental impact statement (SEIS) has been prepared in response to
15 an application submitted to NRC by the Tennessee Valley Authority (TVA) to renew the OLs for
16 Browns Ferry Nuclear Plant, Units 1, 2, and 3 (BFN) for an additional 20 years under 10 CFR
17 Part 54. The SEIS includes the NRC staff's analysis that considers and weighs the environ-
18 mental impacts of the proposed action, the environmental impacts of alternatives to the
19 proposed action, and mitigation measures available for reducing or avoiding adverse impacts.
20 It also includes the staff's recommendation regarding the proposed action.
21

22 Regarding the 69 issues for which the GEIS reached generic conclusions, neither TVA nor the
23 staff has identified information that is both new and significant for any issue that applies to BFN.
24 In addition, the staff determined that information provided during the scoping process did not
25 call into question the conclusions in the GEIS. Therefore, the staff concludes that the impacts
26 of renewing the BFN OLs will not be greater than impacts identified for these issues in the
27 GEIS. For each of these issues, the staff's conclusion in the GEIS is that the impact is of
28 SMALL^(a) significance (except for collective offsite radiological impacts from the fuel cycle and
29 high-level waste and spent fuel, which were not assigned a single significance level).
30

31 The remaining 23 issues that apply to BFN are addressed in this SEIS. For each applicable
32 issue, the staff concludes that the significance of the potential environmental impacts of
33 renewal of the OLs is SMALL. The staff also concludes that additional mitigation measures are
34 not likely to be sufficiently beneficial as to be warranted. The staff determined that information
35 provided during the scoping process did not identify any new issue that has a significant
36 environmental impact.
37

38 The NRC staff recommends that the Commission determine that the adverse environmental
39 impacts of license renewal for BFN are not so great that preserving the option of license

(a) Environmental effects are not detectable or are so minor that they will neither destabilize nor noticeably alter any important attribute of the resource.

Abstract

1 renewal for energy-planning decisionmakers would be unreasonable. This recommendation is
2 based on (1) the analysis and findings in the GEIS; (2) the Environmental Report submitted by
3 TVA; (3) consultation and discussions with Federal, State, and local agencies; (4) the staff's
4 own independent review; and (5) the staff's consideration of public comments.

Contents

1		
2		
3		
4	Abstract	iii
5		
6	Executive Summary	xvii
7		
8	Abbreviations/Acronyms	xxiii
9		
10	1.0 Introduction	1-1
11		
12	1.1 Report Contents	1-2
13	1.2 Background	1-3
14		
15	1.2.1 Generic Environmental Impact Statement	1-3
16	1.2.2 License Renewal Evaluation Process	1-5
17		
18	1.3 The Proposed Federal Action	1-8
19	1.4 The Purpose and Need for the Proposed Action	1-9
20	1.5 Compliance and Consultations	1-10
21	1.6 References	1-10
22		
23	2.0 Description of Nuclear Power Plant and Site and Plant Interaction	
24	with the Environment	2-1
25		
26	2.1 Plant and Site Description and Proposed Plant Operation During the	
27	License Renewal Term	2-1
28		
29	2.1.1 External Appearance and Setting	2-4
30	2.1.2 Reactor Systems	2-4
31	2.1.3 Cooling and Auxiliary Water Systems	2-6
32	2.1.4 Radioactive Waste Management Systems and Effluent	
33	Control Systems	2-9
34		
35	2.1.4.1 Liquid Waste Processing Systems and Effluent Controls	2-10
36	2.1.4.2 Gaseous Waste Processing Systems and	
37	Effluent Controls	2-11
38	2.1.4.3 Solid Waste Processing	2-12
39		
40	2.1.5 Nonradioactive Waste Systems	2-13
41	2.1.6 Plant Operation and Maintenance	2-15
42	2.1.7 Power Transmission System	2-15
43		
44	2.2 Plant Interaction with the Environment	2-17

Contents

1	2.2.1	Land Use	2-18
2	2.2.2	Water Use	2-18
3	2.2.3	Water Quality	2-21
4	2.2.4	Air Quality	2-21
5	2.2.5	Aquatic Resources	2-23
6	2.2.6	Terrestrial Resources	2-44
7	2.2.7	Radiological Impacts	2-56
8	2.2.8	Socioeconomic Factors	2-57
9			
10	2.2.8.1	Housing	2-58
11	2.2.8.2	Public Services	2-60
12	2.2.8.3	Offsite Land Use	2-64
13	2.2.8.4	Visual Aesthetics and Noise	2-65
14	2.2.8.5	Demography	2-67
15			
16	2.2.9	Historic and Archaeological Resources	2-71
17			
18	2.2.9.1	Prehistoric Period	2-71
19	2.2.9.2	Native American Historic Period	2-72
20	2.2.9.3	Euro-American Historic Period	2-72
21	2.2.9.4	Historic and Archaeological Resources at BFN	2-73
22			
23	2.2.10	Related Federal Project Activities and Consultations	2-74
24			
25	2.3	References	2-75
26			
27	3.0	Environmental Impacts of Refurbishment	3-1
28			
29	3.1	References	3-4
30			
31	4.0	Environmental Impacts of Operation	4-1
32			
33	4.1	Cooling System	4-2
34			
35	4.1.1	Water-Use Conflicts (Makeup Water from a Small River)	4-13
36	4.1.2	Entrainment of Fish and Shellfish in Early Life Stages	4-14
37	4.1.3	Impingement of Fish and Shellfish	4-17
38	4.1.4	Heat Shock	4-21
39	4.1.5	Microbiological Organisms (Public Health)	4-24
40			
41	4.2	Transmission Lines	4-26

1	4.2.1	Electromagnetic Fields – Acute Effects	4-30
2	4.2.2	Electromagnetic Fields – Chronic Effects	4-31
3			
4	4.3	Radiological Impacts of Normal Operations	4-32
5	4.4	Socioeconomic Impacts of Plant Operations During the License	
6		Renewal Term	4-33
7			
8	4.4.1	Housing Impacts	4-35
9	4.4.2	Public Services: Public Utilities	4-36
10	4.4.3	Offsite Land Use	4-37
11	4.4.4	Public Services: Transportation	4-39
12	4.4.5	Historic and Archaeological Resources	4-40
13	4.4.6	Environmental Justice	4-41
14			
15	4.5	Groundwater Use and Quality	4-46
16			
17	4.5.1	Groundwater Use Conflicts (plants using cooling towers and	
18		withdrawing make-up water from a small river)	4-47
19			
20	4.6	Threatened or Endangered Species	4-48
21			
22	4.6.1	Aquatic Species	4-49
23	4.6.2	Terrestrial Species	4-50
24			
25	4.7	Evaluation of Potential New and Significant Information on Impacts of	
26		Operations During the License Renewal Term	4-51
27	4.8	Cumulative Impacts of Operations During the License Renewal Term	4-65
28			
29	4.8.1	Cumulative Impacts Resulting from Operation of the	
30		Plant Cooling System	4-65
31	4.8.2	Cumulative Impacts Resulting from Continued Operation of the	
32		Transmission Lines	4-69
33	4.8.3	Cumulative Radiological Impacts	4-70
34	4.8.4	Cumulative Socioeconomic Impacts	4-70
35	4.8.5	Cumulative Impacts on Groundwater Use and Quality	4-71
36	4.8.6	Cumulative Impacts on Threatened or Endangered Species	4-72
37			
38	4.9	Summary of Impacts of Operations During the License Renewal Term	4-74
39	4.10	References	4-74
40			
41	5.0	Environmental Impacts of Postulated Accidents	5-1

Contents

1		
2	5.1	Postulated Plant Accidents 5-1
3		
4	5.1.1	Design-Basis Accidents 5-2
5	5.1.2	Severe Accidents 5-3
6		
7	5.2	Severe Accident Mitigation Alternatives 5-4
8		
9	5.2.1	Introduction 5-4
10	5.2.2	Estimate of Risk 5-5
11	5.2.3	Potential Plant Improvements 5-7
12	5.2.4	Evaluation of Risk Reduction and Costs of Improvements 5-8
13	5.2.5	Cost/Benefit Comparisons 5-9
14	5.2.6	Conclusions 5-10
15		
16	5.3	References 5-10
17		
18	6.0	Environmental Impacts of the Uranium Fuel Cycle and Solid Waste
19		Management 6-1
20		
21	6.1	The Uranium Fuel Cycle 6-2
22	6.2	References 6-9
23		
24	7.0	Environmental Impacts of Decommissioning 7-1
25		
26	7.1	Decommissioning 7-2
27	7.2	References 7-4
28		
29	8.0	Environmental Impacts of Alternatives to Operating License Renewal 8-1
30		
31	8.1	No-Action Alternative 8-1
32		
33	8.1.1	Land Use 8-3
34	8.1.2	Ecology 8-3
35	8.1.3	Water Use and Quality 8-4
36	8.1.4	Air Quality 8-4
37	8.1.5	Waste 8-4
38	8.1.6	Human Health 8-4
39	8.1.7	Socioeconomics 8-5
40	8.1.8	Aesthetics 8-6
41	8.1.9	Historic and Archaeological Resources 8-6

1	8.1.10 Environmental Justice	8-6
2		
3	8.2 Alternative Energy Sources	8-7
4		
5	8.2.1 Pulverized Coal-Fired Generation	8-9
6		
7	8.2.1.1 Closed-Cycle Cooling System	8-9
8	8.2.1.2 Once-Through Cooling System	8-20
9		
10	8.2.2 Coal Gasification	8-20
11		
12	8.2.2.1 Closed-Cycle Cooling System	8-21
13	8.2.2.2 Once-Through Cooling System	8-30
14		
15	8.2.3 Natural Gas Combined-Cycle Generation	8-31
16		
17	8.2.3.1 Closed-Cycle Cooling System	8-31
18	8.2.3.2 Once-Through Cooling System	8-37
19		
20	8.2.4 Nuclear Power Generation	8-38
21		
22	8.2.4.1 Closed-Cycle Cooling System	8-39
23	8.2.4.2 Once-Through Cooling System	8-47
24		
25	8.2.5 Purchased Electrical Power	8-48
26	8.2.6 Other Alternatives	8-48
27		
28	8.2.6.1 Oil-Fired Generation	8-49
29	8.2.6.2 Wind Power	8-49
30	8.2.6.3 Solar Power	8-49
31	8.2.6.4 Hydropower	8-50
32	8.2.6.5 Geothermal Energy	8-50
33	8.2.6.6 Wood Waste	8-51
34	8.2.6.7 Municipal Solid Waste	8-51
35	8.2.6.8 Other Biomass-Derived Fuels	8-52
36	8.2.6.9 Fuel Cells	8-52
37	8.2.6.10 Delayed Retirement	8-53
38	8.2.6.11 Utility-Sponsored Conservation	8-53
39		
40	8.2.7 Combination of Alternatives	8-54
41		

Contents

1	8.3 Summary of Alternatives Considered	8-55
2	8.4 References	8-56
3		
4	9.0 Summary and Conclusions	9-1
5		
6	9.1 Environmental Impacts of the Proposed Action – License Renewal	9-4
7		
8	9.1.1 Unavoidable Adverse Impacts	9-5
9	9.1.2 Irreversible or Irretrievable Resource Commitments	9-6
10	9.1.3 Short-Term Use Versus Long-Term Productivity	9-6
11		
12	9.2 Relative Significance of the Environmental Impacts of License Renewal	
13	and Alternatives	9-7
14	9.3 Staff Conclusions and Recommendations	9-7
15	9.4 References	9-9
16		
17	Appendix A - Comments Received on the Environmental Review	A-1
18	Appendix B - Contributors to the Supplement	B-1
19	Appendix C - Chronology of NRC Staff Environmental Review Correspondence	
20	Related to the Tennessee Valley Authority Application for	
21	License Renewal of Browns Ferry Nuclear Power Plant,	
22	Units 1, 2, and 3	C-1
23	Appendix D - Organizations Contacted	D-1
24	Appendix E - Brown's Ferry Compliance Status and Consultation Correspondence ...	E-1
25	Appendix F - GEIS Environmental Issues Not Applicable to Brown's Ferry	
26	Nuclear Power Plant, Units 1, 2, and 3	F-1
27	Appendix G - NRC Staff Safety Evaluation of Severe Accident Mitigation Alternatives	
28	for Browns Ferry Nuclear Power Plant, Units 1, 2, and 3, in Support	
29	of License Renewal Application	G-1
30		

Figures

1		
2		
3		
4	2-1	Location of Browns Ferry Nuclear Power Plant, Units 1, 2, and 3,
5		80-km (50-mi) Region 2-2
6	2-2	Location of Browns Ferry Nuclear Power Plant, Units 1, 2, and 3,
7		10-km (6-mi) Region 2-3
8	2-3	Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 Site Features 2-5
9	2-4	Map of Transmission Line Rights-of-Way for Browns Ferry Nuclear Power Plant,
10		Units 1, 2, and 3 2-16
11	2-5	Local Road Network for Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 2-63
12		
13	4-1	Geographic Distribution of Minority Populations (shaded areas) Within 80 km (50 mi)
14		of Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 Based on 2000 Census
15		Block Group Data 4-44
16	4-2	Geographic Distribution of Low-Income Populations (shaded areas) Within 80 km
17		(50 mi) of Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 Based on
18		2000 Census Block Group Data 4-45

Tables

1			
2			
3			
4			
5	2-1	Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 Transmission Line	
6		Rights-of-Way	2-17
7	2-2	Federally and State-Listed Aquatic Species Potentially Occurring in Colbert,	
8		Franklin, Lawrence, Limestone, or Morgan Counties, Alabama and/or Itawamba,	
9		Lee, Tishomingo, or Union Counties, Mississippi	2-29
10	2-3	Federally Listed Terrestrial Species Reported at the Browns Ferry	
11		Nuclear Plant, Units 1, 2, and 3 Site and Counties Associated with	
12		Transmission Line Rights-of-Way	2-46
13	2-4	Alabama State-Listed Terrestrial Species Reported from the Browns Ferry	
14		Nuclear Power Plant, Units 1, 2, and 3 and Associated Transmission Line	
15		Rights-of-Way	2-47
16	2-5	Mississippi State-Listed Terrestrial Species Reported from the Browns Ferry	
17		Nuclear Power Plant, Units 1, 2, and 3 Associated Transmission Line	
18		Rights-of-Way	2-50
19	2-6	Residence by County for Browns Ferry Nuclear Power Plant, Units 1, 2, and 3	
20		Tennessee Valley Authority and Contract Employees	2-58
21	2-7	Total Occupied and Vacant (Available) Housing Units by County,	
22		1990 and 2000	2-59
23	2-8	Population Growth in Lauderdale, Limestone, Madison and Morgan Counties,	
24		Alabama – 1980 to 2020	2-60
25	2-9	Public Water Supply Systems in Limestone County, Alabama	2-61
26	2-10	Number of Jobs by County in the Vicinity of Browns Ferry Nuclear Power Plant,	
27		Units 1, 2, and 3	2-68
28	2-11	Major Employment Sectors in Counties Surrounding Browns Ferry	
29		Nuclear Power Plant, Units 1, 2, and 3 and in Alabama – 2001	2-68
30	2-12	Limestone County Distribution of Tax-Equivalent Payments Made by	
31		Tennessee Valley Authority in Fiscal Year 2003	2-71
32			
33	3-1	Category 1 Issues for Refurbishment Evaluation	3-2
34	3-2	Category 2 Issues for Refurbishment Evaluation	3-3
35			
36	4-1	Category 1 Issues Applicable to the Operation of the Browns Ferry Nuclear	
37		Power Plant, Units 1, 2, and 3 Cooling System During the License	
38		Renewal Term	4-3
39	4-2	Category 2 Issues Applicable to the Operation of the Browns Ferry Nuclear	
40		Power Plant, Units 1, 2, and 3 Cooling System During the License	
41		Renewal Term	4-12
42	4-3	Calculated Entrainment of Fish Eggs and Larvae at Browns Ferry	
43		Nuclear Power Plant, Units 1, 2, and 3 – 1974 to 1979	4-15

1	4-4	Calculated Total Number and Percent of Total Impingement for the Most	
2		Prevalent Fish Species Impinged at Browns Ferry Nuclear Power Plant,	
3		Units 1, 2, and 3 – 1974 to 1977	4-19
4	4-5	Category 1 Issues Applicable to the Browns Ferry Nuclear Power Plant,	
5		Units 1, 2 and 3 Transmission Lines During the License Renewal Term	4-27
6	4-6	Category 2 and Uncategorized Issues Applicable to the Browns Ferry	
7		Nuclear Power Plant, Units 1, 2, and 3 Transmission Lines During the	
8		Renewal Term	4-30
9	4-7	Category 1 Issues Applicable to Radiological Impacts of Normal Operations	
10		During the License Renewal Term	4-32
11	4-8	Category 1 Issues Applicable to Socioeconomics During the	
12		License Renewal Term	4-33
13	4-9	Environmental Justice and GEIS Category 2 Issues Applicable to	
14		Socioeconomics During the License Renewal Term	4-35
15	4-10	Category 1 Issues Applicable to Groundwater Use Conflicts of Browns Ferry,	
16		Nuclear Power Plant, Units 1, 2, and 3 During the License Renewal Term	4-46
17	4-11	Category 2 Issue Applicable to Groundwater Use Conflicts of Browns Ferry	
18		Nuclear Power Plant, Units 1, 2, and 3 During the License Renewal Term	4-47
19	4-12	Category 2 Issue Applicable to Threatened or Endangered Species in the	
20		Vicinity of Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 During the	
21		License Renewal Term	4-48
22	4-13	Cooling System Related Category 1 Issues that are Potentially Affected by	
23		Proposed Extended Power Uprates at Browns Ferry Nuclear Power Plant,	
24		Units 1, 2, and 3	4-52
25	4-14	Radiological Impacts of Normal Operations-Related Category 1 Issues	
26		that are Potentially Affected by Proposed Extended Power Uprates at	
27		Browns Ferry Nuclear Power Plant, Units 1, 2, and 3	4-59
28	4-15	Socioeconomic-Related Category 1 Issue Potentially Affected by Proposed	
29		Extended Power Uprates at Browns Ferry Nuclear Power Plant,	
30		Units 1, 2, and 3	4-60
31	4-16	Postulated Accident-Related Category 1 Issue Potentially Affected by	
32		Proposed Extended Power Uprates at Browns Ferry Nuclear Power Plant,	
33		Units 1, 2, and 3	4-61
34	4-17	Uranium Fuel Cycle and Waste Management-Related Category 1 Issues	
35		Potentially Affected by Proposed Extended Power Uprates at Browns Ferry	
36		Nuclear Power Plant, Units 1, 2, and 3	4-61
37			
38	5-1	Category 1 Issue Applicable to Postulated Accidents During the	
39		License Renewal Term	5-3
40	5-2	Category 2 Issue Applicable to Postulated Accidents During the License	
41		Renewal Term	5-4

Contents

1	5-3	BFN Core Damage Frequency	5-6
2	5-4	Breakdown of Population Dose by Containment Release Mode	5-7
3			
4	6-1	Category 1 Issues Applicable to the Uranium Fuel Cycle and Solid Waste Management During the License Renewal Term	6-2
5			
6			
7	7-1	Category 1 Issues Applicable to the Decommissioning of Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 Following the License Renewal Term	7-2
8			
9			
10	8-1	Summary of Environmental Impacts of the No-Action Alternative at Browns Ferry Nuclear Power Plant, Units 1, 2, and 3	8-2
11			
12	8-2	Summary of Environmental Impacts of Pulverized Coal-Fired Generation Using Closed-Cycle Cooling	8-10
13			
14	8-3	Summary of Environmental Impacts of Pulverized Coal-Fired Generation with Once-Through Cooling	8-20
15			
16	8-4	Summary of Environmental Impacts of Coal Gasification Using Closed-Cycle Cooling	8-22
17			
18	8-5	Summary of Environmental Impacts of a Coal Gasification Plant with Once-Through Cooling	8-30
19			
20	8-6	Summary of Environmental Impacts of Natural Gas Combined-Cycle Generation Using Closed-Cycle Cooling	8-31
21			
22	8-7	Summary of Environmental Impacts of a Natural Gas Combined-Cycle Plant with Once-Through Cooling	8-38
23			
24	8-8	Summary of Environmental Impacts of New ABWR Units Using Closed-Cycle Cooling	8-40
25			
26	8-9	Summary of Environmental Impacts of a New Nuclear Plant with Once-Through Cooling	8-47
27			
28	8-10	Summary of Environmental Impacts of an Assumed Combination of Generation and Acquisition Alternatives	8-54
29			
30			
31	9-1	Summary of Environmental Significance of License Renewal, the No-Action Alternative, and Alternative Methods of Generation Using Closed-Cycle Cooling .	9-8
32			
33			
34	A-1	Individuals Providing Comments During Scoping Comment Period	A-3
35			
36	E-1	Consultation Correspondence Regarding License Renewal for Browns Ferry Nuclear Power Plant, Units 1, 2, and 3	E-1
37			
38	E-2	Federal, State, and Local Licenses, Permits, Consultations, and Other Approvals for the Browns Ferry Nuclear Power Plant, Units 1, 2, and 3	E-2
39			
40			
41			

Contents

1	F-1	GEIS Environmental Issues Not Applicable to Browns Ferry Nuclear Power,	
2		Plant, Units 1, 2, and 3	F-1
3			
4	G-1	BFN Core Damage Frequency	G-3
5	G-2	Breakdown of Population Dose by Containment Release Mode for BFN	G-4
6	G-3	Level 1 PSA Summary	G-7
7	G-4	SAMA Cost/Benefit Screening Analysis	G17

Executive Summary

1
2
3
4 By letter dated December 31, 2003, the Tennessee Valley Authority (TVA) submitted an
5 application to the U.S. Nuclear Regulatory Commission (NRC) to renew the operating licenses
6 (OLs) for Browns Ferry Nuclear Plant, Units 1, 2, and 3 (BFN) for additional 20-year periods. If
7 the OLs are renewed, State regulatory agencies and TVA will ultimately decide whether the plant
8 will continue to operate based on factors such as the need for power or other matters within the
9 State's jurisdiction or the purview of the owners. If the OLs are not renewed, then the plant must
10 be shut down at or before the expiration dates of the current OLs, which are December 20,
11 2013, for Unit 1, June 28, 2014, for Unit 2, and July 2, 2016, for Unit 3.

12
13 The NRC has issued regulations implementing Section 102 of the National Environmental Policy
14 Act of 1969 (NEPA) (42 USC 4321) in Title 10 of the Code of Federal Regulations (CFR)
15 Part 51. Section 102 of NEPA directs that an environmental impact statement (EIS) is required
16 for major Federal actions that significantly affect the quality of the human environment. In
17 10 CFR 51.20(b)(2), the Commission requires preparation of an EIS or a supplement to an EIS
18 for renewal of a reactor OL. In addition, 10 CFR 51.95(c) states that the EIS prepared at the OL
19 renewal stage will be a supplement to the *Generic Environmental Impact Statement for License
20 Renewal of Nuclear Plants (GEIS)*, NUREG-1437, Volumes 1 and 2.^(a)

21
22 Upon acceptance of the TVA application, the NRC began the environmental review process
23 described in 10 CFR Part 51 by publishing a Notice of Intent to prepare an EIS and conduct
24 scoping. The staff visited the BFN site in March 2004 and held public scoping meetings on
25 April 1, 2004, in Athens, Alabama. In the preparation of this supplemental environmental impact
26 statement (SEIS) for BFN, the staff reviewed the TVA Environmental Report and compared it to
27 the GEIS, consulted with other agencies, conducted an independent review of the issues
28 following the guidance set forth in NUREG-1555, Supplement 1, *Standard Review Plans for
29 Environmental Reviews for Nuclear Power Plants, Supplement 1: Operating License Renewal*,
30 and considered the public comments received during the scoping process. The public
31 comments received during the scoping process that were considered to be within the scope of
32 the environmental review are provided in Appendix A, Part 1, of this SEIS.

33
34 TVA, a federal corporation wholly owned by the U.S. Government, is subject to the requirements
35 for Federal agencies in NEPA. In compliance with NEPA, TVA prepared an SEIS to provide the
36 public and TVA decisionmakers with an assessment of the environmental impacts of extending
37 the operating life of the BFN nuclear units. This NRC SEIS draws upon the content of the TVA
38 SEIS, but was prepared by NRC staff independently.

39

(a) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and its Addendum 1.

Executive Summary

1 The staff will hold two public meetings in Athens, Alabama, during January 2005 to describe the
2 results of the NRC environmental review, answer questions, and provide members of the public
3 with information to assist them in formulating comments on this SEIS. When the comment
4 period ends, the staff will consider and address all of the comments received. These comments
5 will be addressed in Appendix A, Part 2, of the final SEIS.
6

7 This SEIS includes the NRC staff's analysis that considers and weighs the environmental effects
8 of the proposed action, the environmental impacts of alternatives to the proposed action, and
9 mitigation measures for reducing or avoiding adverse effects. It also includes the staff's
10 recommendations regarding the proposed action.
11

12 The Commission has adopted the following statement of purpose and need for license renewal
13 from the GEIS:
14

15 The purpose and need for the proposed action (renewal of an operating license) is to provide
16 an option that allows for power generation capability beyond the term of a current nuclear
17 power plant operating license to meet future system generating needs, as such needs may
18 be determined by State, utility, and, where authorized, Federal (other than NRC)
19 decisionmakers.
20

21 The goal of the staff's environmental review, as defined in 10 CFR 51.95(c)(4) and the GEIS, is
22 to determine
23

24 ... whether or not the adverse environmental impacts of license renewal are so great that
25 preserving the option of license renewal for energy planning decisionmakers would be
26 unreasonable.
27

28 Both the statement of purpose and need and the evaluation criterion implicitly acknowledge that
29 there are factors, in addition to license renewal, that will ultimately determine whether an existing
30 nuclear power plant continues to operate beyond the period of the current OL.
31

32 NRC regulations at 10 CFR 51.95(c)(2) contain the following statement regarding the content of
33 SEISs prepared at the license renewal stage:
34

35 The supplemental environmental impact statement for license renewal is not required to
36 include discussion of need for power or the economic costs and economic benefits of the
37 proposed action or of alternatives to the proposed action except insofar as such benefits and
38 costs are either essential for a determination regarding the inclusion of an alternative in the
39 range of alternatives considered or relevant to mitigation. In addition, the supplemental
40 environmental impact statement prepared at the license renewal stage need not discuss
41 other issues not related to the environmental effects of the proposed action and the

1 alternatives, or any aspect of the storage of spent fuel for the facility within the scope of the
2 generic determination in § 51.23(a) ["Temporary storage of spent fuel after cessation of
3 reactor operation—generic determination of no significant environmental impact"] and in
4 accordance with § 51.23(b).
5

6 The GEIS contains the results of a systematic evaluation of the consequences of renewing
7 an OL and operating a nuclear power plant for an additional 20 years. It evaluates
8 92 environmental issues using the NRC's three-level standard of significance – SMALL,
9 MODERATE, or LARGE – developed using the Council on Environmental Quality guidelines.
10 The following definitions of the three significance levels are set forth in footnotes to Table B-1 of
11 10 CFR Part 51, Subpart A, Appendix B:
12

13 SMALL – Environmental effects are not detectable or are so minor that they will neither
14 destabilize nor noticeably alter any important attribute of the resource.
15

16 MODERATE – Environmental effects are sufficient to alter noticeably, but not to
17 destabilize, important attributes of the resource.
18

19 LARGE – Environmental effects are clearly noticeable and are sufficient to destabilize
20 important attributes of the resource.
21

22 For 69 of the 92 issues considered in the GEIS, the analysis in the GEIS reached the following
23 conclusions:
24

- 25 (1) The environmental impacts associated with the issue have been determined to apply either
26 to all plants or, for some issues, to plants having a specific type of cooling system or other
27 specified plant or site characteristics.
28
- 29 (2) A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to the
30 impacts (except for collective offsite radiological impacts from the fuel cycle and from high-
31 level waste and spent fuel disposal).
32
- 33 (3) Mitigation of adverse impacts associated with the issue has been considered in the analysis,
34 and it has been determined that additional plant-specific mitigation measures are not likely to
35 be sufficiently beneficial to warrant implementation.
36

37 These 69 issues were identified in the GEIS as Category 1 issues. In the absence of new and
38 significant information, the staff relied on conclusions as amplified by supporting information in
39 the GEIS for issues designated as Category 1 in Table B-1 of 10 CFR Part 51, Subpart A,
40 Appendix B.
41

Executive Summary

1 Of the 23 issues that do not meet the criteria set forth above, 21 are classified as Category 2
2 issues requiring analysis in a plant-specific supplement to the GEIS. The remaining two issues,
3 environmental justice and chronic effects of electromagnetic fields, were not categorized.
4 Environmental justice was not evaluated on a generic basis and must be addressed in a
5 plant-specific supplement to the GEIS. Information on the chronic effects of electromagnetic
6 fields was not conclusive at the time the GEIS was prepared.

7
8 This SEIS documents the staff's consideration of all 92 environmental issues identified in the
9 GEIS. The staff considered the environmental impacts associated with alternatives to license
10 renewal and compared the environmental impacts of license renewal and the alternatives. The
11 alternatives to license renewal that were considered include the no-action alternative (not
12 renewing the BFN OLS) and alternative methods of power generation. Based on projections
13 made by the U.S. Department of Energy's Energy Information Administration, gas- and coal-fired
14 generation appear to be the most likely power-generation alternatives if the power from BFN is
15 replaced. These alternatives are evaluated assuming that the replacement power generation
16 plant is located at either the BFN site or some other unspecified alternative location.

17
18 TVA and the staff established independent processes for identifying and evaluating the
19 significance of any new information on the environmental impacts of license renewal. Neither
20 TVA nor the staff identified information that is both new and significant related to Category 1
21 issues that would call the conclusions in the GEIS into question. Similarly, neither the scoping
22 process nor the staff identified any new issue applicable to BFN that has a significant environ-
23 mental impact.

24
25 In July 2004, TVA submitted extended power uprate (EPU) applications to increase the licensed
26 power levels of each of the three units to 3952 MW(t), or 120 percent of the originally licensed
27 power levels, for a total power level of 11,856 MW(t). If approved, the EPUs would take effect
28 during the existing license term. NRC will evaluate the potential environmental impacts of an
29 EPU in a separate Environmental Assessment. Therefore, the impacts associated with the
30 increase in thermal power level from the currently licensed value to the EPU value is not
31 evaluated in this SEIS. However, the staff performed its evaluation of impacts for the license
32 renewal term in this SEIS assuming all three units are operating at 120 percent of the original
33 licensed power level.

34
35 The staff determined that there is a potential, at the higher power levels, that BFN may no longer
36 be within the envelope of impacts defined by the GEIS for some Category 1 issues. If the
37 potential impacts are beyond the defined envelope, then the generic conclusions concerning
38 these Category 1 issues may no longer be valid. The staff examined each of the 54 Category 1
39 issues applicable to BFN and determined that the level of impact for 34 of the Category 1 issues
40 could be influenced by the thermal power level of the reactors. The staff then evaluated each of
41 the 34 issues to determine if increasing the unit power level above the levels considered in the

1 GEIS would affect the generic conclusions. After evaluating all 34 issues the staff determined
2 that the generic conclusions reached in the GEIS are still valid and none of the GEIS
3 conclusions were changed based on the staff's analysis. Therefore, the proposed EPU does not
4 constitute new and significant information and the staff could continue to rely upon the
5 conclusions of the GEIS for all Category 1 issues applicable to BFN.
6

7 TVA's license renewal application presents an analysis of the Category 2 issues plus
8 environmental justice and chronic effects from electromagnetic fields. The staff reviewed the
9 TVA analysis for each issue and conducted an independent review of each issue. Three
10 Category 2 issues are not applicable because they are related to plant design features or site
11 characteristics not found at BFN. Four Category 2 issues are not discussed in this SEIS
12 because they are specifically related to refurbishment. TVA has stated that its evaluation of
13 structures and components, as required by 10 CFR 54.21, did not identify any major plant
14 refurbishment activities or modifications as necessary to support the continued operation of BFN
15 for the license renewal term. In addition, any replacement of components or additional
16 inspection activities are within the bounds of normal plant operation, and are not expected to
17 affect the environment beyond the bounds of the plant operations evaluated in TVA's 1972 Final
18 Environmental Statement Related to Operation of BFN.
19

20 Fourteen Category 2 issues related to operational impacts and postulated accidents during the
21 license renewal term, as well as environmental justice and chronic effects of electromagnetic
22 fields, are discussed in detail in this SEIS. Five of the Category 2 issues and environmental
23 justice apply to both refurbishment and operation during the license renewal term and are only
24 discussed in this SEIS in relation to operation during the license renewal term. For all 14
25 Category 2 issues and environmental justice, the staff concludes that the potential environmental
26 effects are of SMALL significance in the context of the standards set forth in the GEIS. In
27 addition, the staff determined that appropriate Federal health agencies have not reached a
28 consensus on the existence of chronic adverse effects from electromagnetic fields. Therefore,
29 no further evaluation of this issue is required. For severe accident mitigation alternatives
30 (SAMAs), the staff concludes that a reasonable, comprehensive effort was made to identify and
31 evaluate SAMAs. Based on its review of the SAMAs for BFN, and the plant improvements
32 already made, the staff concludes that none of the candidate SAMAs are cost-beneficial.
33

34 Mitigation measures were considered for each Category 2 issue. Current measures to mitigate
35 the environmental impacts of plant operation were found to be adequate, and no additional
36 mitigation measures were deemed sufficiently beneficial to be warranted.
37

38 If the BFN OLS are not renewed and Units 1, 2, and 3 cease operation on or before the
39 expiration of their current licenses, then the adverse impacts of likely alternatives will not be
40 smaller than those associated with continued operation of BFN. The impacts may, in fact, be
41 greater in some areas.

Executive Summary

1 Unit 1 has not operated since 1985, and the applicant is currently engaged in activities
2 necessary to return it to service. Almost all of the activities associated with this effort are
3 confined to existing onsite structures, and little new construction is necessary. Impacts arising
4 from these activities are outside the scope of the license renewal review. Any impacts
5 associated with this effort would be bounded by the EIS prepared by TVA when the plant was
6 originally licensed.

7
8 The NRC staff recommends that the Commission determine that the adverse environmental
9 impacts of license renewal for BFN are not so great that preserving the option of license renewal
10 for energy-planning decisionmakers would be unreasonable. This recommendation is based on
11 (1) the analysis and findings in the GEIS; (2) the Environmental Report submitted by TVA;
12 (3) consultation and discussions with other Federal, State, and local agencies; (4) the staff's own
13 independent review; and (5) the staff's consideration of public comments.

Abbreviations/Acronyms

1		
2		
3		
4	°	degree
5	μCi	microcurie(s)
6	μCi/ml	microcuries per milliliter
7	μGy	microgray(s)
8	μm	micrometer(s)
9	μSv	microsieverts
10		
11	ac	acre(s)
12	ABWR	Advanced Boiling Water Reactor
13	ACC	averted cleanup and decontamination costs
14	ADCNR	Alabama Department of Conservation and Natural Resources
15	ADEM	Alabama Department of Environmental Management
16	ADPH	Alabama Department of Public Health
17	ADWFF	Alabama Division of Wildlife and Freshwater Fisheries
18	AEA	Atomic Energy Act of 1954
19	ALARA	As Low As Reasonably Achievable
20	ANHP	Alabama Natural Heritage Program
21	AOC	present value of averted offsite property damage costs
22	AOE	present value of averted occupational exposure
23	AOSC	present value of averted onsite costs
24	APE	present value of averted public exposure
25	ATWS	anticipated transient without scram
26		
27	BA	Biological Assessment
28	BFN	Brown's Ferry Nuclear Power Plant, Units 1, 2, and 3
29	Bq	becquerel(s)
30	BMT	basemat melt-through
31	Btu	British thermal unit(s)
32	BWR	boiling water reactor
33	BWROG	Boiling Water Reactor Owners Group
34		
35	C	Celsius
36	CCDP	conditional core damage probability
37	CCW	condenser circulating water
38	CDF	core damage frequency
39	CEQ	Council on Environmental Quality
40	CFR	Code of Federal Regulations
41	cfs	cubic feet per second
42	CHRS	containment heat removal system
43	Ci	curie(s)
44	cm	centimeter(s)

Abbreviations/Acronyms

1	COE	cost of enhancement
2	COPC	chemicals of potential concern
3	CS	core spray
4	CVCS	chemical and volume control system
5		
6	dba	decibel(s)
7	DBA	design-basis accident
8	DC	direct current
9	DCH	direct containment heating
10	DMR	Discharge Monitoring Report
11	DOE	U.S. Department of Energy
12	DPR	demonstration project reactor
13	DSM	demand-side management
14		
15	EECU	emergency equipment cooling water
16	EIA	Energy Information Administration (of DOE)
17	EIS	environmental impact statement
18	ELF-EMF	extremely low frequency-electromagnetic field
19	EOP	Emergency Operating Procedure
20	EPA	U.S. Environmental Protection Agency
21	EPRI	Electric Power Research Institute
22	EPU	extended power uprate
23	EQ	equipment qualification
24	ER	Environmental Report
25	ESRP	Environmental Standard Review Plan, NUREG-1555, Supplement 1, Operating License Renewal
26		
27		
28	F	Fahrenheit
29	FAA	Federal Aviation Administration
30	FIVE	fire induced vulnerability evaluation
31	FR	Federal Register
32	FPS	feet per second
33	FSAR	Final Safety Analysis Report
34	ft	foot/feet
35	FWPCA	Federal Water Pollution Control Act of 1972
36	FWS	U.S. Fish and Wildlife Service
37		
38	gal	gallon
39	GDC	general design criteria
40	GEIS	Generic Environmental Impact Statement for License Renewal of Nuclear Plants, NUREG-1437
41		

Abbreviations/Acronyms

1	gpm	gallons per minute
2		
3	ha	hectare(s)
4	HCLPE	high confidence low probability of failure
5	HHSI	high head safety injection
6	HLW	high-level radioactive waste
7	HPCI	high pressure coolant injection
8	hr	hour(s)
9	Hz	Hertz
10		
11	in.	inch(es)
12	IPE	Individual plant examination
13	IPEEE	individual plant examination of external events
14	ISFSI	independent spent fuel storage installation
15	ISLOCA	interfacing systems loss-of-coolant accident
16		
17	kg	kilogram(s)
18	km	kilometer(s)
19	KPDS	key plant damage states
20	kV	kilovolt(s)
21	kV/m	kilovolt per meter
22	kWh	kilowatt hour(s)
23		
24	L	liter(s)
25	lb	pound
26	LERF	large early release frequency
27	LLW	low level waste
28	LNG	liquefied natural gas
29	LOCA	loss-of-coolant accident
30	LOOP	loss of offsite power
31	LWR	light-water reactor
32		
33	m	meter(s)
34	m/s	meter(s) per second
35	m ³ /d	cubic meters per day
36	m ³ /s	cubic meter(s) per second
37	mA	milliampere(s)
38	MAAP	Modular Accident Analysis Program
39	MACCS2	MELCOR Accident Consequence Code System 2
40	mi	mile(s)
41	min	minutes

Abbreviations/Acronyms

1	MGD	millions of gallons per day
2	mGy	milligray(s)
3	mL	milliliter(s)
4	MMNS	Mississippi Museum of Natural Science
5	MNHP	Mississippi Natural Heritage Program
6	mph	miles per hour
7	mrad	millirad(s)
8	mrem	millirem(s)
9	mSv	millisievert(s)
10	MT	metric ton(s) (or tonne[s])
11	MTU	metric ton(s)-uranium
12	MW	megawatt(s)
13	MWd/MTU	megawatt-days per metric ton of uranium
14	MWh	megawatt hours
15	MW(e)	megawatt(s) electric
16	MW(t)	megawatt(s) thermal
17	MWh	megawatt hour(s)
18		
19	NA	not applicable
20	NAS	National Academy of Sciences
21	NCI	National Cancer Institute
22	NCWRC	North Carolina Wildlife Resources Commission
23	NEPA	National Environmental Policy Act of 1969
24	NESC	National Electric Safety Code
25	ng/J	nanogram per joule
26	NHPA	National Historic Preservation Act
27	NIEHS	National Institute of Environmental Health Sciences
28	NO _x	nitrogen oxide(s)
29	NPDES	National Pollutant Discharge Elimination System
30	NRC	U.S. Nuclear Regulatory Commission
31	NWPPC	Northwest Power Planning Council
32		
33	ODCM	Offsite Dose Calculation Manual
34	OL	operating license
35	OLTP	original licensed thermal power
36		
37	PAR	passive autocatalytic recombiners
38	PDS	plant damage state
39	PM ₁₀	particulate matter, 10 microns or less in diameter
40	ppt	parts per thousand
41	PRA	Probabilistic Risk Assessment

Abbreviations/Acronyms

1	PSA	Probabilistic Safety Assessment
2	PSD	prevention of significant deterioration
3	PSW	plant service water
4	PWR	pressurized water reactor
5		
6	RAB	reactor auxiliary building
7	RAI	request for additional information
8	RCIC	reactor core isolation cooling
9	RCP	reactor coolant pump
10	RCRA	Resource Conservation and Recovery Act
11	RCS	Reactor Coolant System
12	REM	radiological environmental monitoring
13	REMP	radiological environmental monitoring program
14	RHR	residual heat removal
15	RHRSW	residual heat removal service water (system)
16	rms	root mean square
17	RWST	Refueling Water Storage Tank
18	ry	reactor year
19		
20	s	second(s)
21	SAG	Severe Accident Guideline
22	SAMA	Severe Accident Mitigation Alternative
23	SAMG	Severe Accident Management Guideline
24	SAR	Safety Analysis Report
25	SBO	station blackout
26	SCR	selective catalytic reduction
27	SEIS	Supplemental Environmental Impact Statement
28	SER	Safety Evaluation Report
29	SGTR	steam generator tube rupture
30	SHPO	State Historic Preservation Office
31	SO ₂	sulfur dioxide
32	SO _x	sulfur oxide(s)
33	Sv	sievert(s)
34	SW	service water
35		
36	TBq	terrabecquerel
37	TRM	Tennessee River Mile
38	TVA	Tennessee Valley Authority
39		
40	UDB	urban development boundary
41	UFSAR	Updated Final Safety Analysis Report

Abbreviations/Acronyms

1	U.S.	United States
2	USC	United States Code
3	USCB	U.S. Census Bureau
4	USDA	U.S. Department of Agriculture
5	USFWS	United States Fish and Wildlife Service
6		
7	yd	yard
8	yr	year

1.0 Introduction

1
2
3
4 Under the Nuclear Regulatory Commission's (NRC's) environmental protection regulations in
5 Title 10 of the Code of Federal Regulations (CFR) Part 51, which implement the National
6 Environmental Policy Act of 1969 (NEPA), renewal of a nuclear power plant operating license
7 (OL) requires the preparation of an environmental impact statement (EIS). In preparing the
8 EIS, the NRC staff is required first to issue the statement in draft form for public comment, and
9 then issue a final statement after considering public comments on the draft. To support the
10 preparation of the EIS, the staff has prepared a *Generic Environmental Impact Statement for*
11 *License Renewal of Nuclear Plants* (GEIS), NUREG-1437, Volumes 1 and 2 (NRC 1996,
12 1999)^(a). The GEIS is intended to (1) provide an understanding of the types and severity of
13 environmental impacts that may occur as a result of license renewal of nuclear power plants
14 under 10 CFR Part 54, (2) identify and assess the impacts that are expected to be generic to
15 license renewal, and (3) support 10 CFR Part 51 to define the number and scope of issues that
16 need to be addressed by the applicants in plant-by-plant license renewal proceedings. Use of
17 the GEIS guides the preparation of complete plant-specific information in support of the OL
18 renewal process.

19
20 The Tennessee Valley Authority (TVA) operates Browns Ferry Nuclear Plant, Units 1, 2, and 3
21 (BFN) in northern Alabama under OLs 50-259, 50-260, and 50-296, respectively, which were
22 issued by the NRC. These OLs will expire in December 2013 for Unit 1, June 2014 for Unit 2,
23 and July 2016 for Unit 3. On December 31, 2003, TVA submitted an application to NRC to
24 renew the OLs for BFN for an additional 20 years under 10 CFR Part 54 (TVA 2003a). TVA is
25 a *licensee* for the purposes of its current OLs and an *applicant* for the renewal of the OLs.
26 Pursuant to 10 CFR 54.23 and 51.53(c), TVA submitted an Environmental Report (ER)
27 (TVA 2003b) in which it analyzed the environmental impacts associated with the proposed
28 license renewal action, considered alternatives to the proposed action, and evaluated mitigation
29 measures for reducing adverse environmental effects.

30
31 TVA, a federal corporation wholly owned by the U.S. Government, is subject to the
32 requirements for Federal agencies in NEPA. In compliance with NEPA, TVA prepared a
33 supplemental EIS (SEIS) to provide the public and TVA decisionmakers with an assessment of
34 the environmental impacts of extending the operating life of the BFN nuclear units (TVA 2002).
35 This NRC SEIS draws upon the content of the TVA SEIS, but was prepared by NRC staff
36 independently.
37

(a) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and its Addendum 1.

Introduction

1 This report is the plant-specific supplement to the GEIS (the supplemental EIS [SEIS]) for the
2 TVA license renewal application. This SEIS is a supplement to the GEIS because it relies, in
3 part, on the findings of the GEIS. The staff will also prepare a separate safety evaluation report
4 in accordance with 10 CFR Part 54.
5

6 **1.1 Report Contents**

7
8 The following sections of this introduction (1) describe the background for the preparation of
9 this SEIS, including the development of the GEIS and the process used by the staff to assess
10 the environmental impacts associated with license renewal; (2) describe the proposed Federal
11 action to renew the BFN OLS; (3) discuss the purpose and need for the proposed action; and
12 (4) present the status of TVA's compliance with environmental quality standards and require-
13 ments that have been imposed by Federal, State, regional, and local agencies that are respon-
14 sible for environmental protection.
15

16 The ensuing chapters of this SEIS closely parallel the contents and organization of the GEIS.
17 Chapter 2 describes the site, power plant, and interactions of the plant with the environment.
18 Chapters 3 and 4, respectively, discuss the potential environmental impacts of plant refurbish-
19 ment and plant operation during the license renewal term. Chapter 5 contains an evaluation of
20 potential environmental impacts of plant accidents and includes consideration of severe
21 accident mitigation alternatives. Chapter 6 discusses the uranium fuel cycle and solid waste
22 management. Chapter 7 discusses decommissioning, and Chapter 8 discusses alternatives to
23 license renewal. Finally, Chapter 9 summarizes the findings of the preceding chapters and
24 draws conclusions about the adverse impacts that cannot be avoided, the relationship between
25 short-term uses of man's environment and the maintenance and enhancement of long-term
26 productivity, and the irreversible or irretrievable commitment of resources. Chapter 9 also
27 presents the staff's recommendation with respect to the proposed license renewal action.
28

29 Additional information is included in the appendixes. Appendix A contains public comments
30 related to the environmental review for license renewal and staff responses to those comments.
31 Appendixes B through G, respectively, list the following:
32

- 33 • the preparers of the supplement
- 34
- 35 • the chronology of NRC staff's environmental review correspondence related to this SEIS
- 36
- 37 • the organizations contacted during the development of this SEIS
- 38
- 39 • TVA's compliance status in Table E-1 (this appendix also contains copies of consultation
40 correspondence prepared and sent during the evaluation process)

- 1 • GEIS environmental issues that are not applicable to BFN
- 2
- 3 • severe accident mitigation alternatives.
- 4

5 1.2 Background

6
7 Use of the GEIS, which examines the possible environmental impacts that could occur as a
8 result of renewing individual nuclear power plant OLs under 10 CFR Part 54 and the
9 established license renewal evaluation process, supports the thorough evaluation of the
10 impacts of renewal of OLs.

11 1.2.1 Generic Environmental Impact Statement

12
13
14 NRC initiated a generic assessment of the environmental impacts associated with the license
15 renewal term to improve the efficiency of the license renewal process by documenting the
16 assessment results and codifying the results in the Commission's regulations. This assessment
17 is provided in the GEIS, which serves as the principal reference for all nuclear power plant
18 license renewal EISs.

19
20 The GEIS documents the results of the systematic approach that was taken to evaluate the
21 environmental consequences of renewing the licenses of individual nuclear power plants and
22 operating them for an additional 20 years. For each potential environmental issue, the GEIS
23 (1) describes the activity that affects the environment, (2) identifies the population or resource
24 that is affected, (3) assesses the nature and magnitude of the impact on the affected population
25 or resource, (4) characterizes the significance of the effect for both beneficial and adverse
26 effects, (5) determines whether the results of the analysis apply to all plants, and (6) considers
27 whether additional mitigation measures would be warranted for impacts that would have the
28 same significance level for all plants.

29
30 NRC's standard of significance for impacts was established using the Council on Environmental
31 Quality (CEQ) terminology for "significantly" (40 CFR 1508.27, which requires consideration of
32 both "context" and "intensity"). Using the CEQ terminology, NRC established three significance
33 levels – SMALL, MODERATE, or LARGE. The definitions of the three significance levels are
34 set forth in the footnotes to Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, as follows:

35
36 **SMALL** – Environmental effects are not detectable or are so minor that they will neither
37 destabilize nor noticeably alter any important attribute of the resource.

38
39 **MODERATE** – Environmental effects are sufficient to alter noticeably, but not to destabilize,
40 important attributes of the resource.

Introduction

1 **LARGE** – Environmental effects are clearly noticeable and are sufficient to destabilize
2 important attributes of the resource.

3
4 The GEIS assigns a significance level to each environmental issue, assuming that ongoing
5 mitigation measures would continue.

6
7 The GEIS includes a determination of whether the analysis of the environmental issue could be
8 applied to all plants and whether additional mitigation measures would be warranted. Issues
9 are assigned a Category 1 or a Category 2 designation. As set forth in the GEIS, Category 1
10 issues are those that meet all of the following criteria:

- 11
12 (1) The environmental impacts associated with the issue have been determined to apply either
13 to all plants or, for some issues, to plants having a specific type of cooling system or other
14 specified plant or site characteristics.
- 15
16 (2) A single significance level (i.e., **SMALL**, **MODERATE**, or **LARGE**) has been assigned to the
17 impacts (except for collective offsite radiological impacts from the fuel cycle and from high-
18 level waste and spent fuel disposal).
- 19
20 (3) Mitigation of adverse impacts associated with the issue has been considered in the analysis,
21 and it has been determined that additional plant-specific mitigation measures are likely not
22 to be sufficiently beneficial to warrant implementation.

23
24 For issues that meet the three Category 1 criteria, no additional plant-specific analysis is
25 required in this SEIS unless new and significant information is identified.

26
27 Category 2 issues are those that do not meet one or more of the criteria of Category 1, and
28 therefore, additional plant-specific review for these issues is required.

29
30 In the GEIS, the staff assessed 92 environmental issues and determined that 69 qualified as
31 Category 1 issues, 21 qualified as Category 2 issues, and 2 issues, environmental justice and
32 chronic effects of electromagnetic fields, were not categorized. Environmental justice was not
33 evaluated on a generic basis and must be addressed in a plant-specific supplement to the
34 GEIS. Information on the chronic effects of electromagnetic fields was not conclusive at the
35 time the GEIS was prepared.

36
37 Of the 92 issues, 11 are related only to refurbishment, 6 are related only to decommissioning,
38 67 apply only to operation during the license renewal term, and 8 apply to both refurbishment
39 and operation during the renewal term. A summary of the findings for all 92 issues in the GEIS
40 is codified in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B.

1.2.2 License Renewal Evaluation Process

An applicant seeking to renew its OLS is required to submit an ER as part of its application. The license renewal evaluation process involves careful review of the applicant's ER and assurance that all new and potentially significant information not already addressed in or available during the GEIS evaluation is identified, reviewed, and assessed to verify the environmental impacts of the proposed license renewal.

In accordance with 10 CFR 51.53(c)(2) and (3), the ER submitted by the applicant must

- provide an analysis of the Category 2 issues in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B in accordance with 10 CFR 51.53(c)(3)(ii)
- discuss actions to mitigate any adverse impacts associated with the proposed action and environmental impacts of alternatives to the proposed action.

In accordance with 10 CFR 51.53(c)(2), the ER does not need to

- consider the economic benefits and costs of the proposed action and alternatives to the proposed action except insofar as such benefits and costs are either (1) essential for making a determination regarding the inclusion of an alternative in the range of alternatives considered, or (2) relevant to mitigation
- consider the need for power and other issues not related to the environmental effects of the proposed action and the alternatives
- discuss any aspect of the storage of spent fuel within the scope of the generic determination in 10 CFR 51.23(a) in accordance with 10 CFR 51.23(b)
- contain an analysis of any Category 1 issue unless there is significant new information on a specific issue – this is pursuant to 10 CFR 51.53(c)(3)(i) and (iv).

New and significant information is (1) information that identifies a significant environmental issue not covered in the GEIS and codified in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, or (2) information that was not considered in the analyses summarized in the GEIS and that leads to an impact finding that is different from the finding presented in the GEIS and codified in 10 CFR Part 51.

In preparing to submit its application to renew the BFN OLS, TVA developed a process to ensure that information not addressed in or available during the GEIS evaluation regarding the

Introduction

1 environmental impacts of license renewal for BFN would be properly reviewed before submitting
2 the ER, and to ensure that such new and potentially significant information related to renewal of
3 the licenses for Units 1, 2, and 3 would be identified, reviewed, and assessed during the period
4 of the NRC review. TVA reviewed the Category 1 issues that appear in Table B-1 of 10 CFR
5 Part 51, Subpart A, Appendix B, to verify that the conclusions of the GEIS remained valid with
6 respect to BFN. This review was performed by personnel from TVA and its support
7 organization who were familiar with NEPA issues and the scientific disciplines involved in the
8 preparation of a license renewal ER.

9
10 The NRC staff also has a process for identifying new and significant information. That process
11 is described in detail in NUREG-1555, Supplement 1, *Standard Review Plans for Environmental*
12 *Reviews for Nuclear Power Plants, Supplement 1: Operating License Renewal*, (NRC 2000).
13 The search for new information includes (1) review of an applicant's ER and the process for
14 discovering and evaluating the significance of new information; (2) review of records of public
15 comments; (3) review of environmental quality standards and regulations; (4) coordination with
16 Federal, State, and local environmental protection and resource agencies; and (5) review of the
17 technical literature. New information discovered by the staff is evaluated for significance using
18 the criteria set forth in the GEIS. For Category 1 issues where new and significant information
19 is identified, reconsideration of the conclusions for those issues is limited in scope to the
20 assessment of the relevant new and significant information; the scope of the assessment does
21 not include other facets of the issue that are not affected by the new information.

22
23 Chapters 3 through 7 discuss the environmental issues considered in the GEIS that are
24 applicable to BFN. At the beginning of the discussion of each set of issues, there is a table that
25 identifies the issues to be addressed and lists the sections in the GEIS where the issue is
26 discussed. Category 1 and Category 2 issues are listed in separate tables. For Category 1
27 issues for which there is no new and significant information, the table is followed by a set of
28 short paragraphs that state the GEIS conclusion codified in Table B-1 of 10 CFR Part 51,
29 Subpart A, Appendix B, followed by the staff's analysis and conclusion. For Category 2 issues,
30 in addition to the list of GEIS sections where the issue is discussed, the tables list the
31 subparagraph of 10 CFR 51.53(c)(3)(ii) that describes the analysis required and the SEIS
32 sections where the analysis is presented. The SEIS sections that discuss the Category 2
33 issues are presented immediately following the table.

34
35 Section 4.7 addresses potential new and significant information. In July 2004, TVA submitted
36 extended power uprate (EPU) applications (TVA 2004a, b) to increase the licensed power
37 levels of each of the three units to 3952 megawatts-thermal (MW[t]), or 120 percent of the
38 originally licensed power levels, for a total power level of 11,856 MW(t). The staff determined
39 that there is a potential, at the uprated power level, that BFN may no longer be within the
40 envelope of impacts defined by the GEIS, as amended, for some Category 1 issues.

1 To address this concern, the staff examined each of the 54 Category 1 issues applicable to
2 BFN and determined that 34 of the Category 1 issues could be influenced by the thermal power
3 level of the reactors. The staff then evaluated each of the 34 issues to determine if increasing
4 the unit power level above the levels considered during the development of the GEIS would
5 affect the specific generic conclusions. After evaluating all 34 issues the staff determined that
6 the generic conclusions reached in the GEIS are still valid and none of the GEIS conclusions
7 were changed based on the staff's analysis. Therefore, the proposed EPU does not constitute
8 new and significant information and the staff could continue to rely upon the conclusions of the
9 GEIS for all Category 1 issues applicable to BFN.

10
11 NRC prepares an independent analysis of the environmental impacts of license renewal and
12 compares these impacts to the environmental impacts of alternatives. Evaluation of the TVA
13 license renewal application began with publication of a notice of acceptance for docketing and
14 opportunity for a hearing in the *Federal Register* (69 FR 11460) on March 10, 2004. The staff
15 published a notice of intent to prepare an EIS and conduct scoping (69 FR 11462) on
16 March 10, 2004. Two public scoping meetings were held on April 1, 2004, in Athens, Alabama.
17 Comments received during the scoping period were summarized in the Environmental Impact
18 Statement Scoping Process: *Environmental Scoping Summary Report – Browns Ferry Nuclear*
19 *Plant, Units 1, 2, and 3, Limestone County, Alabama* (NRC 2004) dated July 2004. Comments
20 applicable to this environmental review are presented in Part 1 of Appendix A.

21
22 The staff followed the review guidance contained in NUREG-1555, Supplement 1, *Standard*
23 *Review Plans for Environmental Reviews for Nuclear Power Plants, Supplement 1: Operating*
24 *License Renewal* (NRC 2000). The staff and its contractors visited the BFN site on March 30
25 and 31, 2004, to gather information and to become familiar with the site and its environs. The
26 staff also reviewed the comments received during scoping, and consulted with Federal, State,
27 regional, and local agencies. A list of the organizations consulted is provided in Appendix D.
28 Other documents related to BFN were reviewed and are referenced.

29
30 This SEIS presents the staff's analysis that considers and weighs the environmental effects of
31 the proposed renewal of the OLS for BFN, the environmental impacts of alternatives to license
32 renewal, and mitigation measures available for avoiding adverse environmental effects.
33 Chapter 9, "Summary and Conclusions," provides the NRC staff's recommendation to the
34 Commission on whether or not the adverse environmental impacts of license renewal are so
35 great that preserving the option of license renewal for energy-planning decisionmakers would
36 be unreasonable.

37
38 A 75-day comment period begins on the date of publication of the U.S. Environmental
39 Protection Agency Notice of Filing of the draft SEIS to allow members of the public to comment
40 on the results of the NRC staff's review. During this comment period, two public meetings will

Introduction

1 be held in Athens, Alabama, in January 2005. During these meetings, the staff will describe the
2 preliminary results of the NRC environmental review and answer questions to provide members
3 of the public with information to assist them in formulating their comments.
4
5

6 **1.3 The Proposed Federal Action**

7
8 The proposed Federal action is renewal of the OLs for BFN. BFN is located in northern
9 Alabama on the north shore of Wheeler Reservoir, an impoundment of the Tennessee River.
10 The BFN site is approximately 16 km (10 mi) south of Athens, Alabama; 16 km (10 mi)
11 northwest of Decatur, Alabama; and 48 km (30 mi) west of Huntsville, Alabama. The plant has
12 three General Electric-designed boiling water reactors. Unit 1 is currently licensed at its original
13 power level of 3293 MW(t) and a net power output of 1065 megawatts-electric (MW[e]). Units 2
14 and 3 were granted a license amendment during 1998 that raised their authorized thermal
15 power levels by 5% to 3458 MW(t) and each unit currently has a net power output of
16 1118 MW(e). Plant cooling is normally provided by a once-through cooling system that draws
17 water from the Tennessee River. The plant also has mechanical draft cooling towers that are
18 used when needed to provide additional heat dissipation before the cooling water is returned to
19 the river. With all three units operating, enough electricity would be produced to supply the
20 needs of nearly two million homes. The current OL for Unit 1 expires on December 20, 2013;
21 the license for Unit 2 expires on June 28, 2014; and the license for Unit 3 expires on July 2,
22 2016. By letter dated December 31, 2003, TVA submitted an application to the NRC (TVA
23 2003a) to renew these OLs for an additional 20 years of operation (i.e., until December 20,
24 2033, June 28, 2034, and July 2, 2036, for Units 1, 2, and 3, respectively).
25

26 All three of the BFN units were shut down in 1985 to review the TVA nuclear power program
27 and to correct significant weaknesses (TVA 2003b). Unit 2 was returned to service in 1991,
28 and Unit 3 was returned to service in 1995. In 2002, TVA began the process of returning Unit 1
29 to service, with operation expected to resume in 2007. Almost all the activities associated with
30 this effort are confined to existing onsite structures and little new construction is necessary. No
31 licensing action by NRC is required for the restart of Unit 1, and many of the activities that could
32 have had some environmental impact have already been completed. TVA considered these
33 impacts in a separate SEIS (TVA 2002). Therefore, the effects of Unit 1 restart are outside the
34 scope of license renewal and are not considered in this SEIS, although the potential effects of
35 continued operation of Unit 1 are considered in this analysis.
36

37 In July 2004, TVA submitted EPU applications (TVA 2004a, b) to increase the licensed power
38 levels of each of the three units to 3952 MW(t), or 120 percent of the originally licensed power
39 levels, for a total station power level of 11,856 MW(t). NRC will evaluate the potential
40 environmental impacts of an EPU in a separate Environmental Assessment. Therefore, the

1 impacts associated with the increase in thermal power level from the currently licensed value to
2 the EPU value is not evaluated in this SEIS. However, the staff performed its evaluation of
3 impacts for the license renewal term in this SEIS assuming all three units are operating at 120
4 percent of the original licensed power level.
5

6 This SEIS was prepared to evaluate the potential environmental impacts of operating the BFN
7 units at 120 percent of their originally licensed power levels for an additional 20 years beyond
8 the current license terms for each unit.
9

10 **1.4 The Purpose and Need for the Proposed Action**

11
12 Although a licensee must have a renewed license to operate a reactor beyond the term of the
13 existing OL, the possession of that license is just one of a number of conditions that must be
14 met for the licensee to continue plant operation during the term of the renewed license. Once
15 an OL is renewed, State regulatory agencies and the owners of the plant will ultimately decide
16 whether the plant will continue to operate based on factors such as the need for power or other
17 matters within the State's jurisdiction or the purview of the owners.
18

19 Thus, for license renewal reviews, the NRC has adopted the following definition of purpose and
20 need (GEIS Section 1.3):
21

22 The purpose and need for the proposed action (renewal of an operating license) is to
23 provide an option that allows for power generation capability beyond the term of a
24 current nuclear power plant operating license to meet future system generating needs,
25 as such needs may be determined by State, utility, and where authorized, Federal (other
26 than NRC) decisionmakers.
27

28 This definition of purpose and need reflects the Commission's recognition that, unless there are
29 findings in the safety review required by the Atomic Energy Act of 1954 or findings in the NEPA
30 environmental analysis that would lead the NRC to reject a license renewal application, the
31 NRC does not have a role in the energy-planning decisions of State regulators and utility
32 officials as to whether a particular nuclear power plant should continue to operate. From the
33 perspective of the licensee and the State regulatory authority, the purpose of renewing an OL is
34 to maintain the availability of the nuclear plant to meet system energy requirements beyond the
35 current term of the plant's license.
36

1.5 Compliance and Consultations

TVA is required to hold certain Federal, State, and local environmental permits, as well as meet relevant Federal and State statutory requirements. In its ER, TVA provided a list of the authorizations from Federal, State, and local authorities for current operations as well as environmental approvals and consultations associated with BFN license renewal. Authorizations and consultations relevant to the proposed OL renewal action are included in Appendix E.

The staff has reviewed the list and consulted with the appropriate Federal, State, and local agencies to identify any compliance or permit issues or significant environmental issues of concern to the reviewing agencies. These agencies did not identify any new and significant environmental issues. The ER states that TVA is in compliance with applicable environmental standards and requirements for BFN. The staff has not identified any environmental issues that are both new and significant.

1.6 References

10 CFR Part 51. Code of Federal Regulations, Title 10, *Energy*, Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions."

10 CFR Part 54. Code of Federal Regulations, Title 10, *Energy*, Part 54, "Requirements for Renewal of Operating Licenses for Nuclear Power Plants."

40 CFR Part 1508. Code of Federal Regulations, Title 40, *Protection of Environment*, Part 1508, "Terminology and Index."

69 FR 11460. March 10, 2004. "Notice of Acceptance for Docketing of the Application and Notice of Opportunity for a Hearing Regarding Renewal of License Nos. DPR-33, DPR-52 and DPR-68 for an Additional Twenty-Year Period." *Federal Register*, U.S. Nuclear Regulatory Commission.

69 FR 11462. March 10, 2004. "Notice of Intent to Prepare an Environmental Impact Statement and Conduct Scoping Process." *Federal Register*, U.S. Nuclear Regulatory Commission.

Atomic Energy Act of 1954. 42 USC 2011, et seq.

National Environmental Policy Act of 1969 (NEPA). 42 USC 4321, et seq.

1 Tennessee Valley Authority (TVA). 2002. *Final Supplemental Environmental Impact Statement*
2 *for Operating License Renewal of the Browns Ferry Nuclear Plant in Athens, Alabama.*
3 Knoxville, Tennessee.

4
5 Tennessee Valley Authority (TVA). 2003a. *Application for Renewed Operating Licenses,*
6 *Browns Ferry Units 1, 2, and 3.* Knoxville, Tennessee.

7
8 Tennessee Valley Authority (TVA). 2003b. *Applicant's Environmental Report – Operating*
9 *License Renewal Stage, Browns Ferry Units 1, 2, and 3.* Knoxville, Tennessee.

10
11 Tennessee Valley Authority (TVA). 2004a. *Tennessee Valley Authority Browns Ferry Nuclear*
12 *Plant (BFN), Unit 1, Proposed Technical Specifications (TS) Change TS-431 – Request for*
13 *License Amendment for Extended Power Uprate Operation, Browns Ferry Unit 1 Extended*
14 *Power Uprate Environmental Report.* Tennessee Valley Authority, Decatur, Alabama.

15
16 Tennessee Valley Authority (TVA). 2004b. *Tennessee Valley Authority Browns Ferry Nuclear*
17 *Plant (BFN), Units 2 and 3, Proposed Technical Specifications (TS) Change TS-418 – Request*
18 *for License Amendment for Extended Power Uprate Operation, Browns Ferry Units 2 and 3*
19 *Extended Power Uprate Environmental Report.* Tennessee Valley Authority, Decatur,
20 Alabama.

21
22 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement*
23 *for License Renewal of Nuclear Plants.* NUREG-1437, Volumes 1 and 2, Washington, D.C.

24
25 U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement*
26 *for License Renewal of Nuclear Plants Main Report*, "Section 6.3 – Transportation, Table 9.1,
27 Summary of findings on NEPA issues for license renewal of nuclear power plants, Final
28 Report." NUREG-1437, Volume 1, Addendum 1, Washington, D.C.

29
30 U.S. Nuclear Regulatory Commission (NRC). 2000. *Standard Review Plans for Environmental*
31 *Reviews for Nuclear Power Plants, Supplement 1: Operating License Renewal.* NUREG-1555,
32 Supplement 1, Washington, D.C.

33
34 U.S. Nuclear Regulatory Commission (NRC). 2004. *Environmental Scoping Summary*
35 *Report – Browns Ferry Nuclear Plant, Units 1, 2, and 3, Limestone County, Alabama.*
36 Washington, D.C.

37


2.0 Description of Nuclear Power Plant and Site and Plant Interaction with the Environment

The Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 (BFN) site is located on the north shore of Wheeler Reservoir in Limestone County, Alabama, at Tennessee River Mile (TRM) 294. The plant consists of three boiling water reactors (BWRs) that produce steam, which passes through a turbine to generate electricity. In addition to the nuclear units, the major features of the site are intake and discharge canals, switchyards, a training center, an employee physical fitness center, a materials storage and procurement complex, and structures from a former aquatic research laboratory. The plant and its environment are described in Section 2.1, and the interaction of the plant with the environment is presented in Section 2.2.

2.1 Plant and Site Description and Proposed Plant Operation During the License Renewal Term


BFN is located on approximately 340 ha (840 ac) of Federally owned land that is under the custody of the Tennessee Valley Authority (TVA). TVA is a corporate agency and instrumentality of the United States, as described in the TVA Environmental Report (ER) (TVA 2003a). The site is approximately 48 km (30 mi) west of Huntsville, Alabama; 16 km (10 mi) northwest of Decatur, Alabama; and 16 km (10 mi) southwest of Athens, Alabama. Figures 2-1 and 2-2 show the location of BFN and features within an 80-km and 10-km (50-mi and 6-mi) radius of the site.

Land in the vicinity of BFN is used primarily for agriculture. Population densities are low, with no population centers of significance within 16 km (10 mi) of the plant. The site is surrounded to the north and east by rural countryside. It includes open pasture lands, scattered farmsteads, few residents, and little industry within several miles. The terrain is gently rolling with open views to higher elevations to the north. The south and west side of the plant site abuts Wheeler Reservoir, which is a wide expanse of open river used for a variety of recreational purposes. The reservoir in the vicinity of the plant site is moderately used by recreational boaters and fishermen. There are no homes within the foreground viewing distance to the north and east. However, adjacent to the plant site several developments have partial views of the site – a small residential development is sited to the northwest and another across Wheeler Reservoir to the southwest, and the Mallard Creek public use area is directly across the reservoir. A berm, graded during the initial construction of the plant site and containing approximately 2.5 million m³ (3.3 million yd³) of earth excavated to make cooling water channels, lies adjacent to the cooling tower complex and blocks views of the northern and eastern plant areas. Two wildlife management areas – Swan Creek State Wildlife Management



1
2

Figure 2-1. Location of Browns Ferry Nuclear Power Plant, Units 1, 2, and 3, 80-km (50-mi) Region



1
2

Figure 2-2. Location of Browns Ferry Nuclear Power Plant, Units 1, 2, and 3, 10-km (6-mi) Region

1 Area and Mallard-Fox Creek State Wildlife Management Area – are within 5 km (3 mi) of the
2 BFN site (TVA 2003a). The Swan Creek Wildlife Management Area includes more than 1200
3 ha (3000 ac) of land and more than 2000 ha (5000 ac) of water surrounded by numerous
4 industrial facilities. The Mallard-Fox Creek State Wildlife Management Area encompasses
5 approximately 280 ha (700 ac) of land and 690 ha (1700 ac) of water and is primarily used for
6 small game hunting. The Round Island Recreation Area is located approximately 5.6 km (3.5
7 mi) upstream of BFN.
8

9 **2.1.1 External Appearance and Setting**

10
11 The three-unit BFN plant, including the intake and discharge canals, is enclosed by a security
12 fence. Primary access to the plant area is by way of an access road through a security gate.
13 The plant has the following principal physical structures in the central site area: reactor
14 containment building, turbine building, radioactive waste building, service building, intake
15 pumping station, transformer yard, 161-kV and 500-kV switchyards, off-gas stack, sewage
16 treatment facilities, and administration and maintenance buildings. The hot and cold water
17 discharge channels and mechanical draft cooling towers are located northwest of the central
18 site area, while the training center, employee physical fitness center, materials storage and
19 procurement complex, and structures from a former aquatic research laboratory are located to
20 the east of the central site area.
21

22 **2.1.2 Reactor Systems**

23
24 BFN has two active nuclear reactor units (Units 2 and 3) and one inactive unit (Unit 1) as shown
25 in Figure 2-3. Each unit includes a BWR and a steam-driven turbine generator manufactured
26 by General Electric Company. Each unit was licensed for an output of 3293 megawatts-thermal
27 (MW[t]), with a design net electric rating of 1065 megawatts-electric (MW[e]). Major construc-
28 tion on BFN, TVA's first nuclear power plant, began in 1967. Commercial operation began in
29 1974 for Unit 1, in 1975 for Unit 2, and in 1977 for Unit 3. All three units were shut down in
30 1985 during a review of the TVA nuclear power program. Unit 2 returned to service in May
31 1991, and Unit 3 resumed operation in November 1995. Work began in 2002 to bring Unit 1 up
32 to current standards, and operation of the reactor is currently scheduled to resume in 2007.
33

34 In 1998, BFN completed an Integrated Plant Improvement Project for Units 2 and 3. Among the
35 improvements made was a 5 percent uprate of the original licensed thermal power (OLTP) for
36 both units from 3293 to 3458 MW(t). The impacts of this action were evaluated in an Environ-
37 mental Assessment. The U.S. Nuclear Regulatory Commission (NRC) issued the Environmen-
38 tal Assessment and Finding of No Significant Impact related to the October 1, 1997, application
39 for a five-percent power uprate on August 26, 1998 (NRC 1998). An amendment to the BFN
40 OL was approved by NRC for the five percent uprate on September 8, 1998. During




Figure 2-3. Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 Site Features

1 June 2004, TVA submitted applications for extended power uprates (EPUs) to 120 percent of
2 OLTP at each of the three BFN units (TVA 2004a, b). These applications, if approved by the
3 staff, will take effect during the existing license term. The impacts evaluated in this SEIS
4 include those from operation of all three of the BFN reactor units, each at 120 percent of the
5 OLTP.
6

7 The nuclear steam supply system at BFN is typical of General Electric BWRs. Each nuclear
8 system includes a single-cycle, forced-circulation, General Electric BWR that produces steam
9 for direct use in a steam turbine. The design employs a pressure suppression primary contain-
10 ment that houses the reactor vessel, the reactor coolant recirculating loops, and other branch
11 connections of the reactor primary system. The pressure suppression system consists of a
12 drywell, a pressure suppression chamber that stores a large volume of water, connecting vents
13 between the drywell and the pressure suppression chamber, isolation valves, containment
14 cooling systems, and other service equipment. Cooling systems are provided to remove heat
15 from the reactor core, the drywell, and the water in the pressure suppression chamber, thus
16 providing continuous cooling of the primary containment under accident conditions. Appropriate
17 isolation valves are actuated during this period to ensure confinement of radioactive material,
18 which might otherwise be released from the reactor containment during the course of an
19 accident.
20

21 The secondary containment substructure consists of poured-in-place, reinforced concrete
22 exterior walls that extend up to the refueling floor. The refueling room floor is also constructed
23 of reinforced, poured-in-place concrete. The secondary containment structure completely
24 encloses the primary containment dry wells, fuel storage and handling facilities, and essentially
25 all of the core standby cooling systems for the three units. During normal operation and when
26 isolated, the secondary containment is maintained at a negative pressure relative to the building
27 exterior.
28

29 **2.1.3 Cooling and Auxiliary Water Systems**

30

31 Wheeler Reservoir on the Tennessee River is the source for cooling water and most of the
32 auxiliary water systems for BFN (see Figure 2-3). Potable water is supplied by the City of
33 Athens Utilities Water Department in Athens, Alabama. Groundwater is not used at the site.
34 Figure 2-3 shows the general layout of the buildings and structures at the site.
35

36 The intake forebay is separated from Wheeler Reservoir by a gate structure with three bays
37 that are each 12 m (40 ft) wide by about 7.3 m (24 ft) high (TVA 1972). Each bay includes a
38 6-m (20-ft)-high gate that can be raised or lowered depending on the operational requirements
39 of the plant. The flow velocity through the openings varies depending on the gate position.
40 When the gates are in their full open position and the plant is operated in either the open or

1 helper modes, the average flow velocity through the openings is about 0.2 m/s (0.6 fps) for the
2 operation of one unit, 0.34 m/s (1.1 fps) for the operation of two units, and 0.52 m/s (1.7 fps) for
3 the operation of all three units (TVA 2003a). These flow velocities are based on an intake flow
4 per unit of about 46,300 L/s (734,000 gpm), which is 46.3 m³/s (1635 cfs).

5
6 The intake pumping station includes 18 bays (i.e., six bays per reactor unit), each with a
7 traveling screen. Each bay has a net opening size of about 2.6 m by 6 m (8.75 ft by 20 ft). The
8 maximum average flow velocity through each bay is about 0.49 m/s (1.6 fps) and is
9 independent of the reservoir surface elevation. The maximum average velocity through a clean
10 screen with net openings of 0.95 cm by 0.95 cm (3/8 in. by 3/8 in.) is about 0.64 m/s (2.1 fps)
11 (TVA 2003a). Flow velocities through the intake pump station bays and traveling screens are
12 independent of the number of units in operation and the reservoir elevation.

13
14 The BFN units are normally cooled by pumping water from Wheeler Reservoir into the turbine
15 generator condensers and discharging it back to the reservoir via three large submerged
16 diffuser pipes that are perforated to maximize uniform mixing into the flow stream. These pipes
17 range in diameter from 5.2 m to 6.2 m (17 ft to 20.5 ft). The flow exits each discharge pipe
18 through 7800 5-cm (2-in.) ports (TVA 2003a). This straight-through flow path is known as
19 "open cycle" or "open mode" operation. As originally designed, the maximum thermal discharge
20 from the once-through cooling water system is directed into the Wheeler Reservoir, with a
21 temperature increase across the intake and discharge of 13.9°C (25°F) (TVA 1972). The flow
22 exits the diffusers and mixes with the reservoir flow. At the edge of the discharge mixing zone,
23 the water temperature is required to be less than 5.6°C (10°F) above ambient (ADEM 2003).

24
25 Through various gates, some of this cooling water can also be directed through cooling towers
26 to reduce its temperature as necessary to comply with environmental regulations. This flow
27 path is known as the "helper mode."

28
29 The capacity also exists to recycle cooling water from the cooling towers directly back to the
30 intake structure without being discharged to the reservoir. This flow path, known as the "closed
31 mode" of operation, has not been used since the restart of Units 2 and 3 because of difficulties
32 in achieving temperature limits in summer months and problems with equipment reliability. TVA
33 does not anticipate using this mode in the future, and no procedures for operating in this mode
34 currently exist.

35
36 In recent years, only Units 2 and 3 have been operated, but because of a combination of
37 system upgrades and improved flow calibrations, the measured total per-unit condenser
38 circulating water (CCW) flow rate in open mode (with three CCW water pumps per unit) has
39 increased. The condenser tubes were replaced with stainless steel tubing that have a larger
40 internal diameter and lower flow resistance. This modification increased flow through the

Plant and the Environment

1 condenser by approximately 6 percent. TVA estimates total intake for three-unit operation in
2 open mode to be 139 m³/s (4907 cfs) or 12,000 m³/d (3171 MGD) (TVA 2003a).

3
4 Because of various system limitations, BFN cannot pass all the CCW through the cooling
5 towers when operating in the helper mode. The fraction of cooling water that cannot be passed
6 through the cooling towers is routed directly to the river. Almost all of the cooling water that
7 passes through the cooling towers is returned to the river, but a small amount is lost to the
8 atmosphere during operation. If cooling tower capacity is increased during the license renewal
9 term, this consumptive use could increase proportionately. The cooling towers are only
10 operated when necessary to meet thermal discharge temperature limits specified in the
11 National Pollutant Discharge Elimination System (NPDES) permit, typically a few weeks during
12 the hottest part of the summer (typically July and August).

13
14 For the last 6 years, during which Units 2 and 3 have both been in service, the greatest amount
15 of time cooling tower operation has been required has been about 8 percent of a year
16 (TVA 2003a). Increased thermal power proposed for Units 2 and 3 will result in an additional
17 increase of approximately 2.2°C (4°F) in the circulating water temperature leaving the main
18 condenser (for each operating unit) (Hopping 2004). This increase in water discharge
19 temperature would result in increased use of the cooling tower during summer periods to
20 maintain compliance with discharge limitations. No changes to the plant intake system or to the
21 individual unit intake flow rates are expected to be required as a result of the Unit 2 and 3 EPU
22 project, and operations will continue to meet regulatory limits established in the existing NPDES
23 permit.

24
25 Simulations with the near-field hydrothermal model were conducted for the period 1985 through
26 2002, excluding 2 years (1989 and 1990) for which no river ambient temperature data are
27 available (TVA 2003a). Model results showed that, with Units 2 and 3 operating at 120 percent
28 power, on average the cooling towers will be used approximately 5.3 percent of the time, and
29 derating will be required approximately 0.10 percent of the time (i.e., 6.2 days over the 16-year
30 simulation period). On average, with all three units at 120 percent power, use of the cooling
31 towers will increase to approximately 7.2 percent of the time and derating will increase to
32 approximately 0.29 percent of the time (i.e., 17 days over the 16-year simulation).

33
34 The residual heat removal service water (RHRSW) system consists of four pairs of pumps
35 located on the intake structure for pumping raw river water to the heat exchangers in the
36 RHRSW system and four additional pumps for supplying water to the emergency equipment
37 cooling water (EECU) system. The EECU system distributes cooling water supplied by the
38 RHRSW system to essential equipment during normal and accident conditions.

39
40 In June 2004, TVA submitted applications for EPUs for the three BFN units (TVA 2004a, b).
41 TVA has stated (TVA 2002a) that "no changes are expected to be required to the plant intake

1 system or to the individual unit intake flow rates as a result of the EPU project.” TVA also
2 indicated that existing thermal discharge limits would be met by increased use of the helper
3 towers, and if necessary, derating one or more units. The EPU environmental report for BFN,
4 Unit 1 stated that an additional sixth cooling tower, consisting of 20 cells would be built. This
5 sixth cooling tower would be associated only with returning Unit 1 to service (TVA 2004a).
6

7 **2.1.4 Radioactive Waste Management Systems and Effluent Control Systems**

8

9 BFN uses various radioactive waste management systems to collect and process the liquid,
10 gaseous, and solid wastes produced during reactor operations. These systems reduce the
11 quantities of radioactive liquid, gaseous, and solid effluents released to the environment. The
12 waste disposal systems meet the design objectives of Title 10 of the Code of Federal
13 Regulations (CFR) Part 50, Appendix I (*Numerical Guide for Design Objectives and Limiting*
14 *Conditions for Operation to Meet the Criterion “As Low As is Reasonably Achievable” for*
15 *Radioactive Material in Light-Water-Cooled Nuclear Power Reactor Effluents*), and controls the
16 release of radioactive material to within the limits specified in the Offsite Dose Calculation
17 Manual (ODCM) and NPDES permits. The methods employed for the controlled release of
18 those contaminants depend primarily on the physical state of material (i.e., solid, liquid, or
19 gaseous) (TVA 2004c).
20

21 The liquid and solid wastes from BFN are routed to a common radioactive waste building for
22 collection, treatment, sampling, and disposal. Packaged solid wastes and reusable radioactive
23 material may be temporarily stored in the onsite radioactive waste storage facility or in approved
24 outside storage locations. Gaseous wastes are processed and routed to a common tall stack
25 for release to the atmosphere. The liquid and gaseous radioactive waste systems are designed
26 to reduce the activity in the liquid and gaseous wastes such that the concentrations in routine
27 discharges are below the applicable regulatory limits. The liquid and gaseous effluents are
28 continuously monitored, and the discharge is stopped if the effluent concentrations exceed
29 predetermined levels.
30

31 Radioactive fission products build up within the fuel as a consequence of the fission process.
32 These fission products are contained in the sealed fuel rods, but small quantities may escape
33 from the fuel rods into the reactor coolant. Neutron activation of components in the primary
34 coolant system also results in release of radioactive material into the coolant. Non-fuel solid
35 wastes result from treating and separating radionuclides from gaseous and liquid effluents and
36 from removing contaminated material from various reactor areas. Solid wastes also consist of
37 reactor components, equipment, and tools removed from service, as well as contaminated
38 protective clothing, paper, rags, and other trash generated from plant operations, design
39 modifications, and routine maintenance activities. Solid wastes may be shipped to a waste

Plant and the Environment

1 processor for volume reduction before disposal, or they may be sent directly to a licensed burial
2 site. Spent resins and filters are stored or packaged for shipment to an offsite processing or
3 disposal facility.

4
5 Spent fuel consists of fuel rods that have exhausted a certain percentage of their fissile fuel
6 material; they are periodically removed from the reactor core for disposal. Units 2 and 3
7 currently operate on a 24-month refueling cycle per unit, with one unit refueling every year.
8 Spent fuel is stored onsite in the spent fuel pool. TVA is constructing an independent spent fuel
9 storage installation (ISFSI) for storage of spent fuel in dry storage casks.

10
11 The ODCM for BFN (TVA 2004c) is subject to NRC inspection and describes the methods and
12 parameters used for calculating offsite doses resulting from radioactive gaseous and liquid
13 effluents. It is also used for calculating gaseous and liquid effluent monitoring alarm/trip
14 setpoints for release of effluents from BFN. Operational limits for releasing liquid and gaseous
15 effluents are specified to ensure compliance with NRC regulations.

16
17 In June 2004, TVA submitted a request for a license amendment for a power uprate at BFN
18 Units 2 and 3 from 3458 MW(t) to 3952 MW(t) (TVA 2004b). Also, TVA plans to return Unit 1 to
19 commercial operation and increase the power level from 3293 MW(t) to 3952 MW(t)
20 (TVA 2004a). The net result of these plans is that TVA intends to operate all three units at the
21 combined total power level of 11,856 MW(t) during the license renewal term. TVA has
22 estimated that operation at the combined total power level of 11,856 MW(t) could increase the
23 amount of radioactive material released in liquid and gaseous effluents and solid radioactive
24 wastes by as much as a factor of 1.8 over the current operation.

2.1.4.1 Liquid Waste Processing Systems and Effluent Controls

25
26
27
28 The function of the liquid radioactive waste control system is to collect, treat, store, and dispose
29 of all radioactive liquid wastes. Liquid waste is collected in sumps and drain tanks at various
30 locations throughout the plant and are then transferred to the appropriate collection tanks in the
31 Radwaste Building for treatment, storage, and disposal. Waste to be discharged from the
32 system is processed on a batch basis, with each batch being processed by such method or
33 methods appropriate for the quality and quantity of materials determined to be present.
34 Processed liquid waste may be returned to the condensate system for reuse within the plant, or
35 it may be discharged to the environment through the circulating water discharge canal. The
36 liquid waste in the discharge canal is diluted with condenser effluent circulating water to achieve
37 permissible radionuclide concentrations at the site boundary.

38
39 Batches of low-conductivity liquid waste are processed through a filter and a waste deminer-
40 alizer. Demineralizer effluent is sent to a waste sample tank. Depending on the conductivity

1 and level of radioactivity, the liquid may then be discharged to the circulating water discharge
2 canal or the cooling tower blowdown line, transferred to condensate storage tanks, or returned
3 for further processing through the demineralizer.
4

5 High-conductivity liquids are processed through a filter and are collected in a floor drain sample
6 tank. If the concentration after dilution is within the applicable limits, the filtered liquid may be
7 discharged.
8

9 An alternate method of processing low- and high-conductivity liquid is the use of vendor-
10 supplied, portable equipment that can be interconnected to the permanent radioactive waste
11 system. Depending on effluent quality and plant needs, the liquid can either be transferred to
12 the waste sample tank or the floor drain sample tank. Processing from the waste sample tank
13 or floor drain sample tank is identical to that described above.
14

15 All systems are protected against overflow and other unplanned releases by appropriate alarms
16 and shutdown devices. The ODCM prescribes the alarm/trip setpoints for the liquid effluent
17 radiation monitors (TVA 2004c).
18

19 During the years 1999 through 2003, the volume of liquid effluents from Units 2 and 3 ranged
20 from 0 to 4.9 million L (0 to 1.3 million gal) per year, including a total of 79 batch releases
21 (TVA 2000, 2001, 2002b, 2003b, 2004c). During 3 of those 5 years, there were no batch
22 releases because liquids were processed and returned to the condensate system for reuse
23 within the plant. The total radioactivity released in liquid effluents during that time was
24 6.3×10^{11} Bq (17 Ci). The largest annual release during this period was 4.1×10^{11} Bq (11 Ci),
25 which occurred in 1999. Section 2.2.7 describes the hypothetical doses to a maximally
26 exposed individual as a result of those releases.
27

28 These liquid radiological effluent releases are typical of the annual releases for operation of
29 BFN, Units 2 and 3 without the power uprates. As discussed earlier, operation at the combined
30 total power level of 11,856 MW(t) during the license renewal term could increase liquid effluent
31 releases by as much as a factor of 1.8 over these typical values.
32

33 **2.1.4.2 Gaseous Waste Processing Systems and Effluent Controls** 34

35 Radioactive gaseous effluents include low concentrations of fission-product noble gases (such
36 as krypton and xenon), halogens (mainly iodines), tritium in the form of water vapor, and
37 particulate material containing both fission products and activated corrosion products. The
38 gaseous radioactive waste system is designed to collect and process potentially radioactive
39 effluents prior to discharge through the elevated main plant stack. The system receives
40 gaseous discharges from each main condenser air ejector, startup vacuum pump, condensate

1 drain tank vent, and steam packing exhauster. Gases from each main condenser air ejector
2 are passed through a preheater, catalytic recombiner, condenser, moisture separator, and
3 dehumidification coil. The gases then enter a decay pipe that provides a retention time of
4 approximately 6 hours, during which nitrogen-16 and oxygen-19 decay to negligible levels. The
5 gases are then passed through a cooler condenser, moisture separator, reheater, prefilter, six
6 charcoal beds, and an afterfilter before they are mixed with dilution air and exhausted to the
7 main stack. The charcoal beds provide about 9.7 hours of retention time for krypton isotopes
8 and 7.3 days of retention time for xenon isotopes. Gases from the gland seals and startup
9 vacuum pumps are held for approximately 1.75 minutes, to allow for decay of nitrogen-16 and
10 oxygen-19, and then are passed directly to the stack for release.

11
12 The ODCM prescribes alarm/trip setpoints for the gaseous effluent radiation monitors
13 (TVA 2004c). The actual gaseous effluents for the period from 1999 to 2003 averaged about
14 6.7×10^{13} Bq (1800 Ci) per year, with a maximum of 1.8×10^{14} Bq (4900 Ci) in 2003 (TVA 2000,
15 2001, 2002b, 2003b, 2004c). Section 2.2.7 describes hypothetical doses to a maximally
16 exposed individual as a result of these releases.

17
18 These gaseous radiological effluent releases are typical of the annual releases for operation of
19 Units 2 and 3 without the power uprates. As discussed earlier, operation at the combined total
20 power level of 11,856 MW(t) during the license renewal term could increase gaseous effluent
21 releases by as much as a factor of 1.8 over these typical values.

22 23 **2.1.4.3 Solid Waste Processing**

24
25 Solid waste from routine operations at Units 2 and 3 consists of spent (dewatered) resin, solid-
26 ified resin, filters, sludge, evaporator bottoms, dry compressible waste, irradiated components
27 (control rods, etc.), and other non-compressible waste. The solid radioactive waste system
28 consists of systems and components that are used to process and package wet and dry solid
29 wastes so that the waste is suitable for transport and disposal. The system is not used for
30 spent fuel storage and shipment.

31
32 Solid waste is typically stored onsite for a period of time to allow for decay of short-lived
33 radionuclides. Solid wastes from equipment originating in the nuclear system is stored in the
34 fuel storage pool to allow for radioactive decay before they are prepared for reprocessing or
35 offsite storage. Examples of the waste include components such as activated control rods and
36 in-core instrumentation.

37
38 Methods used for processing and packaging solid radioactive waste depend primarily on the
39 waste characteristics. Process solid waste such as spent demineralizer resins and filter
40 materials is collected and dewatered to meet burial site and 10 CFR 61.56 requirements. It is

1 either temporarily stored onsite in concrete storage modules or shipped directly for burial offsite
2 in a licensed disposal facility. High-integrity containers are used to package waste when the
3 waste classification requires that it meet stability requirements. High-integrity containers used
4 for disposal of this waste are certified for acceptance at the disposal facility to which the waste
5 is shipped.

6
7 Dry active waste from operation and maintenance activities is collected throughout the
8 radiologically controlled areas of the facility. Dry active waste such as paper, rags, or used
9 clothing is either placed into containers for storage or shipped directly to a waste processor for
10 volume reduction and subsequent transport to an offsite licensed disposal facility. Most dry
11 active waste has relatively low radionuclide content and may be handled manually. Dry active
12 waste that does not meet the criteria for processing by the offsite processor may be packaged
13 for direct shipment to a disposal facility. Where practical, selected items may be
14 decontaminated onsite for reuse or release. Dry active waste is monitored during packaging to
15 ensure applicable controls are maintained.

16
17 Disposal and transportation of solid radioactive waste are performed in accordance with the
18 applicable requirements of 10 CFR Parts 61 and 71, respectively. During the period from 1999
19 to 2002, generation rates for radioactive solid wastes from routine operation and maintenance
20 activities at Units 2 and 3 ranged from 514 to 654 m³ (18,200 to 23,100 ft³) per year
21 (Pierce 2004). During the period from 1999 to 2002, Units 2 and 3 made 133 shipments of
22 solid radioactive waste with a total activity of 3.0 x 10¹³ Bq (820 Ci) (TVA 2000, 2001, 2002b,
23 2003b).

24
25 These quantities of solid radioactive waste are typical for operation of BFN, Units 2 and 3
26 without the power uprates. As discussed earlier, operation at the combined total power level of
27 11,856 MW(t) during the license renewal term could increase the quantities of solid radioactive
28 waste by as much as a factor of 1.8 over these typical values.

30 2.1.5 Nonradioactive Waste Systems

31
32 The principal nonradioactive effluents from BFN consist of hazardous (chemical), lubrication oil,
33 construction, and sanitary wastes. As is the case with any large industrial facility, BFN
34 generates a variety of wastes that are classified as hazardous under the Resource
35 Conservation and Recovery Act (RCRA). Such wastes include paint-related materials, spent
36 solvents used for cleaning and degreasing, and universal wastes such as batteries, fluorescent
37 light tubes, etc. TVA operates a Hazardous Waste Storage Facility in Muscle Shoals, Alabama,
38 that holds a RCRA Part B permit for temporary storage of hazardous waste. The Hazardous
39 Waste Storage Facility serves as a central collection point for TVA-generated hazardous
40 wastes, and maintains contracts with facilities used to process and dispose of the waste. All

Plant and the Environment

1 hazardous waste generated at BFN is shipped to the Hazardous Waste Storage Facility for
2 consolidation, storage, and transfer to licensed facilities for treatment and disposal. BFN
3 recycles paint solvents (primarily methyl ethyl ketone) using an onsite still. Universal wastes
4 are collected and shipped to recycling firms. Hazardous waste generation rates for BFN
5 average approximately 1540 kg (3400 lbs) per calendar year. Although it is not a hazardous
6 waste as defined in the RCRA regulations, used oil also is generated at BFN as a result of
7 maintenance activities on plant equipment. All used oil is collected, stored onsite, and shipped
8 to an approved recycling center for energy recovery.

9
10 Following restart of Unit 1, hazardous waste generation rates during routine operation of all
11 three units are expected to fall within the normal year-to-year variation currently experienced
12 with two unit operation. Existing waste management systems are capable of handling the
13 hazardous wastes anticipated from operation of all three units at the uprated power level
14 throughout the license renewal period.

15
16 General plant trash such as paper, metals, garbage, and other items collected as part of routine
17 plant operation activities is managed through a TVA system-wide contract with a licensed waste
18 disposal company. This waste material is collected and transported to a State-licensed regional
19 landfill. Generation rates for this type of material are currently approximately 45 MT (50 tons)
20 per month. BFN has an active recycling program to segregate and recycle scrap metal,
21 cardboard, paper, batteries, and aluminum cans at approved State and local recycling facilities
22 (TVA 2003a)

23
24 Once Unit 1 is operational, the amount of trash generated would be similar to that of the other
25 operating units, and the overall amount generated would increase slightly (approximately
26 12.5 percent) from the current level because of the incremental increase in permanent plant
27 staff necessary to operate three units. The existing contractor is capable of handling the
28 increased waste volumes anticipated. Landfill capacity and projections for availability of landfill
29 space in Alabama indicate that sufficient space to accommodate this material from BFN should
30 be available for the duration of the license renewal term (TVA 2003a).

31
32 For construction and demolition debris associated with ongoing site activities, such as
33 modifications and additions to facilities, BFN operates a State-permitted construction/demolition
34 landfill within the confines of the BFN site. This landfill is permitted to accept non-hazardous,
35 non-radioactive solid wastes at an average volume of 4.5 MT (5 tons) per day from the BFN
36 site. Materials permitted for disposal include scrap lumber, bricks, sandblast grit, crushed metal
37 drums, glass, wiring, non-asbestos insulation, roofing materials, building siding, scrap metal,
38 concrete with reinforcing steel, and similar construction and demolition wastes. The landfill
39 occupies approximately 3.1 ha (7.7 ac). The generation rate for this type of material over the
40 past 2 years is approximately 0.036 MT (0.04 tons) per day (TVA 2003a).

41

1 Once Unit 1 resumes operation, the amount of construction/demolition waste generated as a
2 result of the three-unit operation would not be expected to increase substantially over the rates
3 experienced for two-unit operations.
4

5 **2.1.6 Plant Operation and Maintenance**

6

7 The BFN maintenance and modification program supports operation of the nuclear power plant
8 and ensures that equipment, systems, and structures are maintained and modified in accor-
9 dance with applicable requirements and at a quality level required for them to perform their
10 intended functions as specified in the original design, material specifications, and inspection
11 requirements. Additionally, the following guidance from the Institute of Nuclear Power
12 Operations has been incorporated into the maintenance and modification program as
13 appropriate:
14

- 15 • Inspections are performed by qualified individuals in nuclear assurance or other TVA
16 nuclear organizations where necessary to ensure quality.
- 17
- 18 • Inspections are performed by individuals other than those who performed or directly
19 supervised the activity being inspected. Inspection results are documented and
20 maintained as records.
- 21
- 22 • The inspection program provides assurance that plant quality-related items and activities
23 within the scope of the Nuclear Quality Assurance Plan conform to predetermined
24 quality requirements called for in specifications, procedures, and drawings.
- 25
- 26 • The inspection program includes quality control inspections, nondestructive
27 examinations, line verifications, and special inspections.
- 28

29 TVA Nuclear Standard Programs and Processes address procedural requirements for material
30 receipt and inspection, the American Society of Mechanical Engineers Section XI in-service
31 inspection program, special nuclear material control, and nuclear fuel management
32 (TVA 2003a).
33

34 **2.1.7 Power Transmission System**

35

36 BFN is connected into the TVA system network by seven 500-kilovolt (kV) lines via the 500-kV
37 switchyard (Figure 2-4). One line is to the Madison substation, two lines are to the Trinity
38 substation, one line each are to the West Point, Maury, and Union substations, and one line is
39 to the Limestone 500-kV substation (TVA 2003a). In addition, there are two 161-kV lines, one
40 to the Athens substation and one to the Trinity substation. All lines occupy portions of four




Figure 2-4. Map of Transmission Line Rights-of-Way for Browns Ferry Nuclear Power Plant, Units 1, 2, and 3

Table 2-1. Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 Transmission Line Rights-of-Way

Right-of Way	Line	kV	Year Completed	Length	
				km	mi
BFN to Trinity	BFN-Trinity	500	1968	17.8	11.1
	BFN-Trico	500	1996		
BFN-Maury	Trinity-BFN	161	1968	37.2	23.1
	BFN-Madison	500	1968		
	BFN-West Point	500	1968		
	BFN-Maury	500	1968		
	BFN-Limestone	500	1995		
BFN-Athens	BFN-Athens	161	1968	23.1	14.3
BFN to Union	BFN-Union	500	1980	176.8	109.9

transmission line rights-of-way, one to the Maury substation, one to the Trinity substation, one to the Athens substation, and one to the Union, Mississippi, substation (Figure 2-4, Table 2-1). There are portions of other transmission lines within these rights-of-way that were not constructed specifically to connect BFN to the TVA power system. However, for the sake of simplicity and a comprehensive analysis, all the rights-of-way are included in the assessment.

Maintenance of the transmission line rights-of-way is the responsibility of the TVA Transmission and Power Supply – Transmission Operations and Maintenance organization (TVA 2003a). Maintenance activities include vegetation management, pole replacement, installation of lightning arresters and counterpoise, and equipment upgrades. Regular maintenance activities are conducted on a 3- to 5-year cycle. Detailed discussion on transmission line maintenance activities is found in Section 4.2. All activities are reviewed by specialists in the TVA Regional Natural Heritage and Cultural Resources Program. The TVA program maintains a detailed Geographic Information System database of natural and cultural resources along the entire TVA distribution system. The database includes daily updates of Federally and State-listed species habitat and occurrence records (TVA 2003a). Maintenance activities that have the potential to impact sensitive resources are carefully planned and implemented to minimize disturbance.

2.2 Plant Interaction with the Environment

Sections 2.2.1 through 2.2.8 provide general descriptions of the environment near BFN as background information. They also provide detailed descriptions where needed to support the analysis of potential environmental impacts of refurbishment and operation during the license

Plant and the Environment

1 renewal term, as discussed in Chapters 3 and 4. Section 2.2.9 describes the historic and
2 archaeological resources in the area, and Section 2.2.10 describes possible impacts associated
3 with other Federal project activities.
4

5 **2.2.1 Land Use**

6
7 BFN is located on the north shore of Wheeler Reservoir in an unincorporated portion of
8 Limestone County, Alabama. Limestone County does not have land-use zoning applicable to
9 unincorporated portions of the county. Wheeler Reservoir is formed by Wheeler Dam, which is
10 owned and operated by TVA and is approximately 32 km (20 mi) downriver from BFN. The
11 reservoir is 119 km (74 mi) long (TVA 2003a).
12

13 BFN is approximately 48 km (30 mi) west of Huntsville, Alabama; 16 km (10 mi) northwest of
14 Decatur, Alabama; and 16 km (10 mi) southwest of Athens, Alabama. The site is a 340 ha
15 (840 ac) tract just south of U.S. Highway 72 and is directly accessible from County Road 25
16 (Nuclear Plant Road). County Road 25 intersects U.S. Highway 72 approximately 10 km (6 mi)
17 north of the site; it also intersects U.S. Highway 31 approximately 14 km (9 mi) east of the site.
18

19 The Swan Creek State Wildlife and Mallard-Fox Creek State Wildlife Management Areas are
20 within 5 km (3 mi) of the plant site. The Swan Creek Wildlife Management Area includes more
21 than 1200 ha (3000 ac) of land and more than 2000 ha (5000 ac) of water surrounded by
22 numerous industrial facilities. The Mallard-Fox Creek State Wildlife Management Area includes
23 approximately 280 ha (700 ac) of land and 690 ha (1700 ac) of water, and is primarily used for
24 small game hunting (TVA 2003a).
25

26 **2.2.2 Water Use**

27
28 At the BFN site, the Tennessee River flows from southeast to northwest; and the average width
29 in Wheeler Reservoir ranges from 1.6 to 2.4 km (1 to 1.5 mi). Wheeler Reservoir extends from
30 Guntersville Dam at TRM 349 downstream to Wheeler Dam at TRM 274.9. The drainage area
31 upstream of Wheeler Dam is 76,640 km² (29,590 mi²). The reservoir was created in 1936 as
32 one of the first major dam projects on the Tennessee River for flood control, power generation,
33 and navigation. Wheeler Reservoir has a normal summer pool elevation of 169.5 m (556 ft)
34 above mean sea level and a minimum water elevation of 168 m (550 ft). The lake usually
35 reaches its summer pool elevation by mid-April. Fall drawdown, in anticipation of winter rains,
36 usually begins around August 1. At summer pool elevation, the reservoir has an area of
37 27,140 ha (67,070 ac), a volume of 1290 million m³ (1.05 million ac-ft), a mean depth of 4.8 m
38 (15.7 ft), and a hydraulic residence time of 10.7 days (TVA 2002a).
39

1 The most recent total BFN intake flow reported to the Alabama Department of Environmental
2 Management (ADEM) in the monthly Discharge Monitoring Report (December 2003) and to the
3 Alabama Department of Economic and Community Affairs in the Annual Certificate of Use
4 Report is 8 million m³/d (2114 MGD), which is approximately 46.3 m³/s (734,000 gpm) per unit.
5 With the return of Unit 1, the total intake flow would then become approximately 12 million m³/d
6 (3171 MGD) or 139 m³/s (4907 cfs), which represents an increase over the previous high
7 reported number (10.8 million m³/d or 2855 million gpm) of 11 percent.

8
9 TVA is pursuing EPUs, which would increase the total combined power level to 11,856 MW(t)
10 with no further increase in intake flows. The additional heat would be routed through the
11 diffusers for discharge. TVA has modeled the mixing zone and believes BFN can continue to
12 meet current ADEM regulatory limits of the NPDES permit by employing various mitigating
13 measures such as derating and use of the cooling tower helper mode of operation.

14
15 BFN cannot put all the CCW through the cooling towers when operating in the helper mode
16 because of various system limitations. TVA reports the maximum practical throughput for the
17 six cooling towers as 105.5 m³/s (3725 cfs) (TVA 2004a). Remaining CCW flow bypasses the
18 cooling towers and is routed directly to the river. Almost all the cooling tower flow is also
19 returned to the river, but there is a small amount lost into the air during operation. When
20 evaporation and "drift" are considered, these losses can approach 2 percent of the total cooling
21 tower flow. TVA estimates 1.53 m³/s (54 cfs) at 105 percent and 1.76 m³/s (62 cfs) at
22 120 percent EPU for Units 2 and 3 (Hopping 2004). TVA has committed to rebuild the sixth
23 cooling tower; therefore, the consumptive use of cooling water would increase. TVA estimates
24 2.01 m³/s (71 cfs) at 105 percent and 2.32 m³/s (82 cfs) at 120 percent EPU for all three units
25 (Hopping 2004). The cooling towers are only operated when necessary to meet thermal
26 discharge temperature limits specified in the NPDES permit, typically a few weeks during the
27 hottest part of the summer (usually during July and August).

28
29 Although most of the intake water is used for condenser cooling, a small amount (approximately
30 3 percent) of it is used for other plant uses such as emergency equipment cooling water,
31 residual heat removal, raw cooling water, fire protection, and raw service water systems
32 (TVA 2003a). Almost all of this water is ultimately returned to the river, either directly or
33 indirectly through leakage drains. The only consumption of this water at the site would be from
34 a negligible and unquantifiable amount of evaporation when the water is exposed to air.

35
36 BFN also consumes a relatively small amount of river water for use in making highly purified or
37 "demineralized" water for various uses in the plant that require high-grade water. On average,
38 this consumptive rate is approximately 5.7 million L/month (1.5 million gal/month) in the
39 summer, which is somewhat higher than the winter consumption because of running the turbine
40 building air wash system to keep equipment operating temperatures down. This consumptive
41 rate is equivalent to 2.2 L/s (0.077 cfs) (TVA 2003a).

Plant and the Environment

1 Using an unsteady flow model of Wheeler Reservoir, the measured releases from Guntersville
2 Dam and Wheeler Dam were used to compute the hourly flow in Wheeler Reservoir at BFN
3 (TVA 1977a). TVA analyzed these data to obtain a time series of the daily average flow for the
4 period 1976 to 2002. For this period, the following statistical properties are identified for the
5 flow at BFN: the average daily flow was 1320 m³/s (46,606 cfs), ranging from 10,700 m³/s
6 (378,742 cfs) to 75 m³/s (2638 cfs) (TVA 2003a). The total intake water flow of 139 m³/s
7 (4907 cfs) can encompass a significant fraction of the daily average river flow past the plant.
8

9 Target minimum flows currently used for TVA river operations were established by an environ-
10 mental impact statement in 1990 (TVA 1990). The minimum daily average flows in the
11 Tennessee River at BFN are 280 m³/s (10,000 cfs) for July through September, 230 m³/s
12 (8000 cfs) for December through February, and 140 m³/s (5000 cfs) otherwise.
13

14 Based on the information given above, the Tennessee River average annual flow at BFN for the
15 period 1976 to 2002 equates to 4.16×10^{10} m³/yr (1.47×10^{12} ft³/yr). This is less than the
16 9×10^{10} m³/yr (3.15×10^{12} ft³/yr) criterion stated by NRC in 10 CFR 51.53(c)(3)(ii)(A) as the
17 value beneath which "an assessment of the impact of the proposed action on the flow of the
18 river and related impacts on in-stream and riparian ecological communities must be provided."
19

20 The critical time for approaching the maximum river water temperature limits specified in the
21 BFN NPDES permit, and therefore requiring the use of cooling towers or plant derates, is July
22 and August. Based on the time series data from 1976 to 2002, the average flow in Wheeler
23 Reservoir at BFN was 963.57 m³/s (34,028 cfs) during July and August (TVA 2003a). During
24 these same months and same period, the minimum daily average flow observed at BFN was
25 79.71 m³/s (2815 cfs), occurring on July 1, 1987. For comparison, the "7Q10" low flow value
26 (i.e., the lowest average flow for 7 consecutive days that has an average recurrence interval of
27 10 years) given in the rationale for the BFN NPDES permit is 246 m³/s (8700 cfs) (ADEM 2003).
28 The daily average flow exceeded the 7Q10 low flow value 98.6 percent of the time in July and
29 98.8 percent of the time in August.
30

31 The Athens Utilities Water Department supplies potable water to BFN. Potable water
32 consumption at the site is partly a function of the number of people working at the site. Besides
33 drinking fountains and bathrooms, potable water is also used for fire protection, supplied to a
34 1.9-million-L (500,000-gal) fire protection water bladder tank, and for various clean water uses,
35 such as window and building wash water and pressurized spray water for equipment cleaning.
36 Some flow is lost to occasional leaks. BFN typically uses 15,000 to more than 30,000 m³ per
37 month (4 to 8 million gal per month) of potable water (TVA 2003a).
38

39 There is no groundwater use at BFN.
40

2.2.3 Water Quality

Pursuant to the Federal Water Pollution Control Act Amendments of 1972 (FWPCA), the water quality of the plant effluents is regulated through the NPDES, and ADEM is delegated to issue NPDES permits in Alabama. The current permit (AL0022080) was issued December 29, 2000, and is due to expire January 31, 2006. The NPDES permit specifies the discharge standards and monitoring requirements for each discharge. This permit specifies effluent limits for pH, total residual chlorine, oil, grease, biological oxygen demand, fecal coliform, total suspended solids, temperature, naphthalene, and BETX (i.e., benzene, ethyl benzene, toluene, and xylene isomers). Any new regulations promulgated by the U.S. Environmental Protection Agency (EPA) or the State of Alabama would be reflected in future permits.

Compliance with the NPDES process, other provisions of the FWPCA (e.g., Sections 316 (a), 316 (b), 401, 404), and other regulatory requirements are expected to adequately control potential chemical effluent effects. In general, under these regulatory programs, TVA treats waste water effluents, collects and properly disposes of potential contaminants, and undertakes pollution prevention activities that comply with regulatory requirements and minimize the risk of adverse environmental impacts. The NPDES permit contains temperature limits based on a 316(a) demonstration that EPA approved in June 1977. The NPDES permit can be re-opened and modified in the event ADEM determines, through biological and/or water quality monitoring, that more stringent limitations and/or monitoring requirements are necessary to ensure the protection and propagation of aquatic life in the Tennessee River.

Effluent discharges from plant systems such as yard drains, station sumps, and sanitary waste water would not be expected to change significantly through the license renewal term. Considering that the plant waste water lagoons and sedimentation ponds possess clay and Hypalon liners, respectively, no impacts to groundwater resources are anticipated. The changes in pond/lagoon discharges to the river would remain within the bounding conditions established in the NPDES.

2.2.4 Air Quality

The climate at the BFN site varies between continental in the fall to maritime in the summer. During the winter and spring seasons, the climate is variable between the two classifications. The climate at Huntsville, Alabama, which is well documented, is generally considered representative of the BFN site^(a). Climatological records for Huntsville indicate that precipitation is fairly evenly distributed among all months, but the winter and spring seasons are wetter than the fall and summer. Normal monthly precipitation ranges from 17 cm (6.7 in.) in March to

(a) Climatological data for Huntsville is available at <http://www.ncdc.noaa.gov/ol/climate/climatedata.html>

Plant and the Environment

1 8.4 cm (3.3 in.) in August. Normal daily maximum temperatures for Huntsville range from 9.4°C
2 (48.9°F) in January to a high of slightly more than 32°C (89°F) in July. Normal minimum
3 temperatures range from almost -0.6°C (31°F) in January to almost 21°C (70°F) in July. During
4 the period from 1968 to 2002, the highest recorded temperature at Huntsville was
5 40°C (104°F), which occurred in July, while the lowest temperature recorded temperature is
6 -24°C (-11°F), which occurred in January. The temperatures generally drop below 0°C (32°F)
7 about 63 days annually.

8
9 Thunderstorms are reported about 57 days annually in the Huntsville area. Although thunder-
10 storms occur in all months of the year, most occur during the months of May, June, July, and
11 August. Thunderstorms can have windstorms and sometimes hail associated with them, and in
12 some cases produce tornadoes. The highest reported wind speed at Huntsville during the
13 period from 1968 to 2002 was 28.2 m/s (63 mph) from the north-northeast direction. During the
14 period from January 1, 1950, to December 31, 2003, 50 days of hail events were reported in
15 Limestone County. The largest reported hailstones were 9.5 cm (3.75 in.), which fell on the City
16 of Athens, Alabama, on May 18, 1995 (NOAA 2004). During the same time period, 24 tornados
17 were reported in Limestone County. The most violent storm occurred on April 3, 1974, when
18 11 deaths were reported and 80 people were injured. The most property damage occurred
19 during a tornado on May 18, 1995, when property damage amounting to \$5 million was
20 reported along with one death and 55 injuries (NOAA 2004).

21
22 The National Severe Storms Laboratory in Kansas City, Missouri, calculated the tornado return
23 probability for the BFN site based on tornado occurrences within a 55.6-km (30-nautical-mi)
24 radius during the period from 1950 to 1986. Based on 48 tornado occurrences having path size
25 estimates during that 37-year period, the return probability for the site is 6.979×10^{-4} with a
26 mean return interval of 1433 years.

27
28 The wind energy resource in northern Alabama is limited. The annual average wind power
29 density in Alabama is almost exclusively Class 1 on a scale of 1 through 7 (Elliott et al. 1987).
30 Areas suitable for wind turbine applications have a rating of 3 or higher. The only areas that
31 meet this criterion are ridge tops in northeastern Alabama where the Appalachian foothills
32 begin, along the exposed Gulf Coast shoreline of Alabama, and in the Mobile Bay area during
33 the winter and spring seasons.

34
35 The BFN site is located within the Tennessee River Valley-Cumberland Mountains Interstate Air
36 Quality Control Region (40 CFR 81.72). Presently, this region is considered in attainment for all
37 criteria pollutants (40 CFR 81.301). The EPA is in the process of promulgating new, more
38 restrictive standards for ozone and particulate matter. For ozone, the current 1-hour ozone
39 standard will be replaced by an 8-hour standard. Once these new standards are implemented,
40 several counties that are part of the control region may not be in compliance.

1 The Sipsey Wilderness area is the only area in Alabama designated in 40 CFR 81.401 as a
2 mandatory Class 1 Federal area in which visibility is an important value. The Wilderness area
3 is located about 45 km (28 mi) southwest of the BFN site. All other Class 1 areas located in
4 Tennessee or Mississippi are greater than 80 km (50 mi) from BFN.
5

6 Diesel-power auxiliary (emergency) generators, auxiliary boilers, and other small sources such
7 as fuel storage facilities emit various non-radiological pollutants. Emissions from these sources
8 are regulated by ADEM under a Synthetic Minor Operating Permit (ADEM Administrative Code
9 335-3-15-02-10). This permit remains in effect until the existing administrative code is
10 amended. The terms of that permit require the site to track actual emissions. The most recent
11 report (for 2003) indicated that a total of 35.3 MT (38.9 tons) of pollutants were discharged to
12 the atmosphere from these sources (TVA 2004d). For the period from 1998 to 2003, annual
13 emissions have varied between 27.2 and 40.8 MT (30 and 45 tons).
14

15 2.2.5 Aquatic Resources

16

17 The aquatic resources in the vicinity of the BFN site are associated primarily with the Wheeler
18 Reservoir portion of the Tennessee River. Wheeler Reservoir is the source and receiving body
19 for the BFN cooling system. The BFN site has about 3772 m (12,375 ft) of Wheeler Reservoir
20 frontage (TVA 2003a). Other nearby aquatic habitats include the following tributaries to
21 Wheeler Reservoir: Paint Rock and Flint Rivers in the upper reach; Indian, Cotaco, and Flint
22 Creeks in the middle reach; and Limestone, Piney, Swan, Fox, Mallard, Spring, First, and
23 Second Creeks and the Elk River in the lower section. Elk River is the largest of these
24 tributaries, and flows into Wheeler Reservoir about 16 km (10 mi) downstream of BFN.
25 Gunterville Reservoir is located upstream of Wheeler Reservoir, while Wilson Reservoir is
26 located downstream from Wheeler Reservoir.
27

28 The seven transmission lines associated with BFN cross a number of streams ranging in size
29 from small intermittent streams to the Tennessee River. Rivers and larger streams crossed by
30 or near the transmission lines include Limestone, Piney, Round Island, Swan, Big Nance, Town,
31 Spring, Cedar, Little Bear, and Bear Creeks in Alabama, and Bear, Little Brown, Donivan,
32 Twentymile, Mantachie, Mud, and Bridge Creeks and the Tennessee-Tombigbee Waterway in
33 Mississippi.
34

35 TVA began its Vital Signs Monitoring Program in 1990 to systematically monitor key physical,
36 chemical, and biological indicators (i.e., dissolved oxygen, chlorophyll, sediments, benthic
37 macroinvertebrates, and fish) to evaluate the ecological conditions of its reservoirs and to target
38 detailed assessment studies if significant problems are found (Dycus 1998). Monitoring is done
39 in the inflow area (generally riverine in nature), transition zone (mid-reservoir area), and forebay
40 area (generally lacustrine or lake-like in nature). The Vital Signs Monitoring Program transition

Plant and the Environment

1 zone sampling station for Wheeler Reservoir is located at TRM 295.9, a short distance
2 upstream of BFN (TVA 2003a). The ecological health rating for a sample site can range from a
3 minimum of 4.5 (all indicators poor) to 22.5 (all indicators excellent). The overall health
4 evaluation for a reservoir is determined by summing the ratings from all sites and dividing by
5 the maximum possible rating for the sites, expressed as a percentage. This approach provides
6 a potential range of scores from 20 to 100 percent and applies to all reservoirs regardless of the
7 number of indicators or sample sites. The percent scoring range is then divided into categories
8 representing good (greater than 72 percent), fair (52 to 72 percent), and poor (less than
9 52 percent) ecological health conditions for run-of-the-river reservoirs (the cut off between a
10 poor and fair rating for tributary and storage reservoirs is 57 percent rather than 52 percent)
11 (Dycus 1998). Between 1991 and 2003, the ecological health scores for Wheeler Reservoir
12 ranged from a low of 61 (fair) in 1999 to a high of 76 (good) in 1997, with a 1993 to 1997
13 average of 73 (good) (Dycus 1998). Ecological health scores in 2001 and 2003 were 65 and
14 72, respectively, indicating a continuing fair rating in recent years (TVA 2004e).

15
16 A total of 63 fish species plus hybrid sunfish, hybrid striped bass x white bass (*Morone*
17 *saxatilis* x *M. chrysops*), and hybrid walleye x sauger (*Stizostedion vitreum* x *S. canadense*)
18 were collected from 1995 through 2002 in the vicinity of BFN (TVA 2002a, 2003a). A total of
19 72 fish species were collected in impingement samples between 1974 and 1977 (TVA 1978).
20 Important commercial fish species that occur in Wheeler Reservoir include blue catfish
21 (*Ictalurus furcatus*), channel catfish (*I. punctatus*), flathead catfish (*Pylodictis olivaris*), bigmouth
22 buffalo (*Ictiobus cyprinellus*), smallmouth buffalo (*I. bubalus*), and common carp (*Cyprinus*
23 *carpio*). Gizzard shad (*Dorosoma cepedianum*) and threadfin shad (*D. petenense*) are the
24 dominant forage species in Wheeler Reservoir (TVA 2003a). Threadfin shad has been the
25 dominant species numerically in Wheeler Reservoir since 1990 (Baxter and Buchanan 1998).

26
27 Game fish species include largemouth bass (*Micropterus salmoides*), smallmouth bass
28 (*M. dolomieu*), spotted bass (*M. punctulatus*), black crappie (*Pomoxis nigromaculatus*), white
29 crappie (*P. annularis*), bluegill (*Lepomis macrochirus*), longear sunfish (*L. megalotis*), redear
30 sunfish (*L. microlophus*), sauger, striped bass, hybrid striped bass, yellow bass (*Morone*
31 *mississippiensis*), and yellow perch (*Perca flavescens*). Largemouth bass is the species most
32 often sought by sport fishermen, followed by crappie. Bluegill are the most numerous game
33 fish in Wheeler Reservoir (Baxter and Buchanan 1998). The sport fishery is supplemented by
34 stockings of striped bass, hybrid striped bass, largemouth bass, and channel catfish.

35
36 The Vital Signs Monitoring Reservoir Fish Assemblage Index metric scores are based primarily
37 on fish community structure and function; but also consider percentage of sample represented
38 by omnivores and insectivores, overall number of fish collected, and the occurrence of fish with
39 anomalies (e.g., diseases, lesions, parasites, and deformities). The Reservoir Fish
40 Assemblage Index scores from 1993 to 2002 have equated to a rating of fair upstream of BFN
41 (TRM 295.9) and good downstream of BFN at TRM 277. Monitoring done at TRM 292.5 just

1 downstream of BFN from 2000 through 2002 have equated to a rating of good (Baxter and
2 Gardner 2003). There are no health advisories against the consumption of fish from Wheeler
3 Reservoir. However, there are advisories against consuming bigmouth and smallmouth buffalo
4 from two tributaries of upper Wheeler Reservoir (Indian Creek and Huntsville Spring Branch
5 from Redstone Arsenal to the Tennessee River) because of DDT contamination (ADPH 2002,
6 2003).

7
8 The Sport Fishing Index was developed to quantify sport fishing quality for individual sport fish
9 species. The Sport Fishing Index uses information from population sampling (e.g., catch per
10 unit effort from electrofishing and gill netting) and creel results (e.g., angler success) to
11 describe the quality of the resident fishery. Parameters measured include the length and
12 weight of fish in various categories (e.g., preferred-size fish, memorable-size fish, and trophy-
13 size fish). The Sport Fishing Index can range from 20 (very poor) to 60 (excellent) (Hickman
14 2000). The 2002 scores for Wheeler Reservoir and the TVA system-wide average (given in
15 parentheses) were Florida largemouth bass, *Micropterus salmoides floridanus*, 38 (37); bluegill,
16 26 (29); channel catfish, 28 (26); hybrid striped bass, 44 (40); northern largemouth bass
17 (*M. s. salmoides*), 34 (33); sauger, 42 (30); smallmouth bass, 36 (35); and spotted bass,
18 42 (35) (TVA 2002c). While the sport fishery in Wheeler Reservoir cannot be considered
19 excellent, these scores do indicate that, except for bluegill, the quality of the sport fishery in the
20 reservoir is slightly above average for the TVA system.

21
22 Currently, seven invasive aquatic animal species pose a threat to aquatic communities in the
23 TVA reservoir system: common carp, grass carp (*Ctenopharyngodon idella*), alewife (*Alosa*
24 *pseudoharengus*), blueback herring (*A. aestivalis*), rusty crayfish (*Orconectes rusticus*), Asiatic
25 clam (*Corbicula fluminea*), and zebra mussel (*Dreissena polymorpha*). The Asiatic clam and
26 zebra mussel are the most problematic of these species due to their impacts on power plants
27 and city water supplies, as well as to their potential ecological impacts (TVA 2004f). The grass
28 carp has been introduced into TVA reservoirs to control heavy infestations of aquatic
29 vegetation. The introduced grass carp are sterile, and the population can be maintained at
30 desired levels by adjusting stocking rates. Grass carp have been collected infrequently in gill
31 net and electroshock samples at TRM 295.9 (TVA 2002a). Other non-native species such as
32 the striped bass, hybrid striped bass, and yellow perch have become popular game species in
33 the Wheeler Reservoir (Baxter and Buchanan 1998).

34
35 The phytoplankton of Wheeler Reservoir is diverse. As many as 27 Chrysophyta (yellow-green
36 or yellow-brown algae), 52 Chlorophyta (green algae), and 17 Cyanophyta (blue-green algae)
37 taxa have been documented (TVA 1977b). The zooplankton assemblage is also diverse, with
38 32 cladoceran, 24 copepod, and 47 rotifer taxa having been reported (TVA 1977b). The non-
39 native cladoceran *Daphnia lumholtzi* has been documented throughout the Tennessee River
40 system (Baker 2001), and is therefore expected to occur in Wheeler Reservoir (TVA 2003a). It

1 may eventually become a dominant zooplankton species in the southern United States (CARS 2004).

2
3 In 2002, there were an estimated 1820 ha (4500 ac) of aquatic plant coverage in Wheeler
4 Reservoir. Between 1976 and 2002, this has varied from a low of 8 ha (20 ac) (1976 to 1978)
5 representing a trace percentage of the reservoir to a high of 3983 ha (9843 ac) (in 1988) or
6 about 14 percent of the reservoir (TVA 2004f). The aquatic plants that commonly occur in
7 Wheeler Reservoir include the invasive exotic Eurasian watermilfoil (*Myriophyllum spicatum*),
8 hydrilla (*Hydrilla verticillata*), spinyleaf naiad (*Najas minor*), the invasive native coontail
9 (*Ceratophyllum demersum*), and southern naiad (*N. guadalupensis*). Most of these plants
10 occur in the broad, shallow overbank habitat upstream of BFN between TRM 296 and 305
11 (TVA 2002a). Eurasian watermilfoil, hydrilla, and spinyleaf naiad are submersed aquatic plants
12 that can be severely problematic to reservoir use, while the submersed aquatic southern naiad
13 and the free-floating coontail are generally considered beneficial species, they can occasionally
14 reach nuisance levels (TVA 2004f).

15
16 The overbank areas support communities of Asiatic clams, fingernail clams, burrowing mayflies,
17 aquatic worms, and chironomids, while cobble and bedrock areas (found mainly in the old
18 channel) support Asiatic clams, bryozoans, sponges, caddisflies, snails, and some leeches
19 (TVA 2002a). The Vital Signs Monitoring Program transition station at TRM 295.5 had benthic
20 community scores of excellent in 1994, good in 1995, and excellent in both 1997 and 1999
21 (Dycus and Baker 2000). Benthic macroinvertebrate monitoring was initiated in 2000 in support
22 of the BFN thermal variance monitoring. The benthic community was rated excellent at
23 TRM 295.9 (upstream of the BFN diffusers) in 2000 and in good condition in 2001 and 2002.
24 At TRM 291.7 (downstream of the BFN diffusers) the rating was excellent in 2001 and good in
25 2002 (Baxter and Gardner 2003). The average mean density of benthic macroinvertebrates
26 collected upstream (TRM 295.9) and downstream (TRM 291.7) of BFN in November 2002 were
27 473 and 445/m² (5091 and 4790/ft²), respectively (Baxter and Gardner 2003). In comparison,
28 downstream reaches of Wheeler Reservoir at TRM 277 and Elk River had average ratings of
29 poor between 1994 and 2002, while the upstream reach of Wheeler Reservoir at TRM 347 had
30 an average rating of good over this time period (Baxter and Gardner 2003).

31
32 Historically, 39 mussel species occurred in Wheeler Reservoir. Thirty-one of these species
33 were considered riverine (i.e., those that evolved in free-flowing reaches), with 19 of these
34 species now considered non-reproducing riverine species within Wheeler Reservoir (Ahlstedt
35 and McDonough 1992). In 1982, 12 mussel species were collected during a survey for the
36 proposed barge facility at BFN (Pryor 1982), and 11 species were collected across the river
37 during a survey for a proposed barge terminal for the Mallard-Fox Creek Development Project
38 (Carroll 1982). The washboard (*Megaloniaias nervosa*) was the most common species
39 collected during both surveys. It is currently the predominant species that is commercially
40 harvested (TVA 2003a). The Ohio pigtoe (*Pleurobema cordatum*) was previously the most
41 valuable commercial species, but its numbers have decreased because of habitat alterations

1 due to impoundment (Ahlstedt and McDonough 1992). None of the species collected were
2 Federally or State protected.

3
4 In 1991, 24 species of mussels were collected from Wheeler Reservoir, with six species
5 represented by weathered, empty shells (Ahlstedt and McDonough 1992). The 24 species
6 included all species previously collected near BFN in the two 1982 collections by Pryor and
7 Carroll. It was estimated that 460 million mussels or 2.33 mussels/m² (0.22 mussels/ft²)
8 occurred in the reservoir in 1991 (Ahlstedt and McDonough 1992). The most common species
9 (and estimated number within Wheeler Reservoir) collected in 1991 were the elephant-ear
10 (*Elliptio crassidens*, 116 million), washboard (88 million), pink heelsplitter (*Potamilus alatus*,
11 56 million), and threehorn wartyback (*Oblivaria reflexa*, 44 million) (Ahlstedt and McDonough
12 1992). In addition to the habitat alteration resulting from reservoir creation, over-harvesting and
13 periods of drought (e.g., from 1983 to 1988) may have affected reproduction and/or survival of
14 most thick-shelled mussel species in Wheeler Reservoir (Ahlstedt and McDonough 1992).
15 Water-quality impairments and loss of necessary fish hosts have also contributed to the decline
16 of mussel populations. The biodiversity of mussel communities in the mainstem Tennessee
17 River reservoirs is anticipated to continue the long-term downward trend in terms of abundance
18 and diversity (TVA 2004f).

19
20 In 1998, 17 mussel species were collected on the east channel of Wheeler Reservoir near
21 Hobbs Island, over 64 river kilometers (40 river miles) upstream of BFN, between TRMs 336.4
22 and 335.5. The two most common mussel species were the elephant-ear and the Ohio pigtoe.
23 Two Federally endangered species were also collected: one specimen of the rough pigtoe
24 (*Pleurobema plenum*) and 16 specimens of the pink mucket (*Lampsilis abrupta*) (Yokely 1998).
25 In 1999, 16 native mussel species were collected in the vicinity of BFN: 14 species at
26 (TRM) 298 upstream of BFN and 12 species at TRM 292 downstream of BFN. None of these
27 were Federally listed species (TVA 2003a). Eleven commercial mussel species have been
28 reported near BFN from TRM 305 to TRM 275 (Ahlstedt and McDonough 1992).

29
30 Two areas of Wheeler Reservoir are designated as State-protected mussel sanctuaries where
31 commercial mussel fishing is not permitted. One sanctuary extends from Guntersville Dam
32 (TRM 349) downstream to the mouth of Shoal Creek (TRM 347); the second extends from the
33 upstream end of Hobbs Island (TRM 337) downstream to Whitesburg Bridge (TRM 333)
34 (TVA 2003). In the reservoir overbanks, mussels are generally spread over large areas and are
35 not concentrated in mussel beds (TVA 2003a).

36
37 The Asiatic clam was first reported in Alabama in 1962, and is now widespread throughout the
38 state (Foster et al. 2000). It inhabits lakes and streams of all sizes and occurs in silt, mud,
39 sand, or gravel substrates (Cummings and Mayer 1992). The major impact caused by the
40 Asiatic clam is biofouling, particularly of power plant and industrial water systems. It also
41 modifies benthic substrates and competes with native species (Foster et al. 2000). The Asiatic

Plant and the Environment

1 clam is consumed by a number of fish, birds, and mammals. Its population density and
2 distribution can be affected by excessively high or low temperatures, salinity, drying, low pH,
3 silt, low dissolved oxygen, and diseases and parasites. The Asiatic clam can often dominate
4 the benthic community, occurring at densities of thousands per square meter (Foster et al.
5 2000).

6
7 Between 1969 and 1976, densities of the Asiatic clam between TRM 307.5 and TRM 278
8 ranged from 103 to 167 clams/m² (9.6 to 15.5 clams/ft²) (TVA 1977b). The Asiatic clam
9 competes with native mussels for food, nutrients, and space. Dense populations of the Asiatic
10 clam may ingest large numbers of unionid sperm, glochidia, and newly metamorphosed
11 juveniles. They may also actively disturb sediments; therefore, dense populations may reduce
12 suitable habitat space for juvenile native mussels. Periodic die-offs may produce enough
13 ammonia and consume enough oxygen to kill native mussels (Butler 2002).

14
15 The zebra mussel had established populations in the Tennessee River by 1992 and had been
16 reported in Alabama by 1994 (Benson 2004). It has continued to spread throughout the river
17 system. Zebra mussel densities in the Tennessee River have remained low, but are now
18 abundant enough below Wilson Dam that they can be measured quantitatively (Butler 2002).
19 The zebra mussel inhabits lakes and streams of all sizes, attaching to rocks, freshwater
20 mussels, or almost any other hard surface (Cummings and Mayer 1992). Their increase
21 causes a decline among many native mussels, as it can out-compete native species for oxygen
22 and food and is so prolific that it can smother native mussel beds (GSMFC 2003).

23
24 The raw water intake for BFN is treated biannually with a molluscicide to control biofouling by
25 zebra mussels and Asiatic clams. Also, biweekly raw water samples are analyzed from April
26 through October for zebra mussel veligers as an early warning for potential biofouling
27 (TVA 2002a). Data from these samples indicate that zebra mussel reproduction near BFN
28 remains at a low level and that the zebra mussel should not pose a threat to plant operations in
29 the immediate future (TVA 2003a). However, the primary means of keeping the condenser
30 tubes clear of Asiatic clams is the use of a system that uses small sponge rubber balls that are
31 continuously recirculated through the condenser tubes (TVA 1972).

32
33 There are 38 Federally listed aquatic species (including three candidate species) whose distri-
34 bution includes, or has historically included, the Wheeler Reservoir portion of the Tennessee
35 River or its tributaries, or other streams, rivers, or caves within the counties of Alabama and
36 Mississippi through which the BFN transmission line rights-of-way pass (Table 2-2). One of the
37 BFN transmission lines crosses designated critical habitat for one federally protected species of
38 freshwater mussel. All but nine of the Federally protected 38 species would not currently be
39 expected to occur within Wheeler Reservoir or the streams crossed by the transmission line
40 rights-of-way associated with BFN for the following reasons: (1) the species are presumed to

Table 2-2. Federally and State-Listed Aquatic Species Potentially Occurring in Colbert, Franklin, Lawrence, Limestone, or Morgan Counties, Alabama and/or Itawamba, Lee, Tishomingo, or Union Counties, Mississippi

Scientific Name	Common Name	Status ^(a)			Habitat
		Federal	AL	MS	
Aquatic Snails					
<i>Athearnia anthonyi</i>	Anthony's riversnail	E	P	--	Large rivers and lower reaches of large creeks on cobble/boulder substrates near riffles
<i>Campeloma decampi</i>	slender campeloma	E	P	--	Large creeks in soft sediments (sand or mud) or detritus
<i>Lithasia lima</i>	warty rocksnail	--	NOST	--	Rocky riffles of low gradient large-sized rivers or moderate gradient medium-sized rivers
<i>Lithasia verrucosa</i>	varicose rocksnail	--	NOST	--	Rocky shoals and riffles in moderate currents of medium to large rivers at depths up to 1 m (3 ft)
<i>Pyrgulopsis pachyta</i>	armored snail (armored marstonia)	E	P	--	Shallow, still water along the edge of pools on tree roots and detritus of creeks
Mussels					
<i>Cumberlandia monodonta</i>	spectaclecase	C	P	--	Large rivers with swiftly flowing water, among boulders in patches of sand, cobble, or gravel in areas where current is reduced
<i>Cyclonaias tuberculata</i>	purple wartyback	--	--	S1	Medium or large rivers in gravel or mixed sand and gravel
<i>Cyprogenia stegaria</i>	fanshell	E	P	--	Medium to large rivers
<i>Dromus dromas</i>	dromedary pearlymussel	E	P	--	Sand and gravel substrates in riffles and shoals of medium to large rivers
<i>Ellipsaria lineolata</i>	butterfly	--	NOST	S3	Large rivers in sand or gravel
<i>Elliptio arca</i>	Alabama spike	--	--	S3	Shoreline of rivers in sand, sand and gravel, or rock substrates

Table 2-2. (contd)

	Scientific Name	Common Name	Status ^(a)			Habitat
			Federal	AL	MS	
1 2 3 4 5	<i>Epioblasma brevidens</i>	Cumberlandian combshell	E	P	S1	Coarse sand to mixtures of gravel, cobble and boulder-sized rocks in medium to large rivers; tends to occur at depths <1m (3 ft)
6 7	<i>Epioblasma capsaeformis</i>	oyster mussel	E	P	-	Usually in small- to medium-sized rivers in the substrates of coarse sand to boulder substrates and moderate to swift currents
8 9 10	<i>Epioblasma florentina florentina</i>	yellow-blossom pearlymussel	E	P	-	Riffle and shoal areas of small- to medium-sized streams
11 12	<i>Epioblasma florentina walkeri</i>	tan riffleshell	E	X	-	Headwaters, riffles, and shoals in sand and gravel substrates
13	<i>Epioblasma penita</i>	southern combshell	E	--	S1	Riffles or shoals of medium-sized rivers with sandy gravel to gravel-cobble substrates in moderate to swift current
14 15	<i>Epioblasma torulosa torulosa</i>	tubercled blossom	E	P	--	Sandy gravel substrates in riffles and shoals in rapid currents of medium to large rivers
16 17	<i>Epioblasma triquetra</i>	snuffbox	--	--	S1	Medium to large rivers in clear, gravel riffles
18 19	<i>Epioblasma turgidula</i>	turgid blossom pearlymussel	E	P	-	Sand and gravel substrates of shallow, fast-flowing streams
20 21	<i>Fusconaia barnesiana</i>	Tennessee pigtoe	--	NOST	S1	Cracks in bedrock to mixtures of coarse sand, gravel, cobble and boulders in riffle and shoal areas with moderate to swift currents of medium to large rivers; seldom in depths >1m (3 ft)
22	<i>Fusconaia cor</i>	shiny pigtoe	E	P	-	Shoals and riffles in clear streams with moderate to fast current
23 24	<i>Fusconaia cuneolus</i>	fine-rayed pigtoe	E	P	--	Firm cobble and gravel substrates of clear, high gradient streams

Table 2-2. (contd)

	Scientific Name	Common Name	Status ^(a)			Habitat
			Federal	AL	MS	
1	<i>Hemistena lata</i>	cracking pearlymussel	E	P	--	Sand, gravel and cobble substrates in swift currents or mud and sand in slower currents of medium to large rivers
2	<i>Lampsilis abrupta</i>	pink mucket	E	P	--	Larger rivers in gravel or sand
3	<i>Lampsilis cardium</i>	plain pocketbook	--	--	S3S4	Small creeks to large rivers in mud, sand or gravel
4	<i>Lampsilis ovata</i>	pocketbook	--	NOST	--	Large rivers in coarse sand or gravel
5	<i>Lampsilis perovalis</i>	orangenacre mucket	T	--	S1	Medium and large rivers in gravel/cobble or gravel/coarse sand substrates
7	<i>Lampsilis virescens</i>	Alabama lampmussel	E	P	--	Sand and gravel substrates in shoal areas of medium to large rivers
8						
9	<i>Lemiox rimosus</i>	birdwing pearlymussel	E	NOST	--	Riffle areas with sand and gravel substrates in moderate to fast currents of creeks to medium-sized rivers
10	<i>Lexingtonia dolabelloides</i>	slabside pearlymussel	C	P	S1	Moderate to high gradient riffles in medium to large rivers
11						
12	<i>Ligumia recta</i>	black sandshell	--	--	S2	Gravel-cobble and possibly coarse sand substrates in shoals in medium to large rivers
13	<i>Medionidus conradicus</i>	Cumberland moccasinshell	--	NOST	--	Sand and gravel substrates or in cracks or under rocks in creeks to medium-sized rivers
14						
15	<i>Obovaria jacksoniana</i>	southern hickorynut	--	--	S2	Medium-sized gravel substrates in river areas of low to moderate currents
16						
17	<i>Obovaria retusa</i>	ring pink	E	P	--	Gravel and sand bars of large rivers
18	<i>Obovaria unicolor</i>	Alabama hickorynut	--	--	S3	Sand/gravel substrates in river areas of moderate current
19	<i>Plethobasus cicatricosus</i>	white wartyback pearlymussel	E	P	--	Gravel substrates of large rivers
20						

Table 2-2. (contd)

	Scientific Name	Common Name	Status ^(a)			Habitat
			Federal	AL	MS	
1 2	<i>Plethobasus cooperianus</i>	orangefoot pimpleback	E	P	--	Sand, gravel and cobble substrates in riffles and shoals in deep water and steady current of large rivers
3	<i>Pleurobema clava</i>	clubshell	E	P	--	Medium to large rivers in gravel or mixed gravel and sand
4 5	<i>Pleurobema curtum</i>	black clubshell	E	--	SH	Sandy gravel to gravel-cobble substrates in riffles and shoals with moderate to fast currents in medium to large rivers
6 7	<i>Pleurobema decisum</i>	southern clubshell	E	--	S1S2	Sand and gravel substrates of medium to large rivers
8 9	<i>Pleurobema oviforme</i>	Tennessee clubshell	--	NOST	--	Sand and gravel substrates (occasionally mud or cracks between bedrock slabs) in vicinity of riffles and shoals of medium to large rivers
10 11	<i>Pleurobema perovatum</i>	ovate clubshell	E	--	S1	Moderate gradient pools and riffles of medium to large rivers
12 13	<i>Pleurobema plenum</i>	rough pigtoe	E	P	--	Medium to large rivers in sand or gravel
14 15	<i>Pleurobema taitianum</i>	heavy pigtoe	E	--	SH	Riffles and shoals on sandy gravel to gravel-cobble substrates in areas of moderate to fast currents of medium to large rivers
16	<i>Potamilus alatus</i>	pink heelsplitter	--	--	S2	Medium to large rivers in mud or mixed mud, sand and gravel
17 18	<i>Potamilus ohioensis</i>	pink papershell	--	NOST	--	Medium to large rivers in silt, mud or sand
19 20	<i>Ptychobranchnus fasciolaris</i>	kidneyshell	--	NOST	S1	Rivers with coarse sand and gravel substrates
21 22	<i>Ptychobranchnus subtentum</i>	fluted kidneyshell	C	NOST	--	Small to medium rivers in areas with swift current or riffles; larger rivers in shoal areas
23 24	<i>Quadrula intermedia</i>	Cumberland monkeyface	E	P	--	Sand and gravel substrates in shallow riffle and shoal areas of headwater streams to bigger rivers at depths to 0.6 m (2 ft)

Table 2-2. (contd)

	Scientific Name	Common Name	Status ^(a)			Habitat
			Federal	AL	MS	
1	<i>Quadrula</i>	monkeyface	–	NOST	SH	Gravel or mixed sand and gravel substrates in medium to large rivers
2	<i>metanevra</i>					
3	<i>Quadrula</i>	ridged	–	–	S2	Medium-sized rivers in sand/gravel substrates in moderately silty waters of moderate gradient
4	<i>rumphiana</i>	mapleleaf				
5	<i>Strophitus</i>	southern	–	–	S2	Small to large creeks in sand or sandy mud substrates in areas of low to no current
6	<i>subvexus</i>	creekmussel				
7	<i>Toxolasma</i>	pale lilliput	E	P	--	Firm rubble, gravel, and sand substrates in shallow riffles and shoals of clean, fast-flowing streams
8	<i>cylindrellus</i>					
9	<i>Toxolasma lividus</i>	purple lilliput	–	NOST	–	Small to medium-sized rivers in mud, sand and gravel substrates
10	<i>Truncilla truncata</i>	deertoe	–	–	S3	Medium to large rivers in mud, sand or gravel substrates
11	<i>Villosa taeniata</i>	painted creekshell	–	NOST	–	Smaller streams in sand/gravel substrates
12	<i>Villosa trabalis</i>	Cumberland bean	E	NOST	–	Sand, gravel, and cobble substrates in waters of moderate to swift currents and depths <1m (3 ft) in medium to large rivers
13	<i>Villosa</i>	mountain	–	NOST	–	Smaller streams in sand/gravel substrates
14	<i>vanuxemensis</i>	creeksheel				
15	Crayfish and Shrimp					
16	<i>Palaemonias</i>	Alabama cave	E	S1	--	Silt-bottom pools in caves
17	<i>alabamae</i>	shrimp				
18	<i>Cambarus jonesi</i>	Alabama cave crayfish	--	NOST	–	Subterranean pools
19	<i>Cambarus</i>	White Spring	--	NOST	–	Subterranean pools
20	<i>veitchorum</i>	Cave crayfish				
21	<i>Hobbseus petilus</i>	Tombigbee riverlet crayfish	--	--	S2	Slow to moderately flowing small, shallow streams in sand/gravel substrates

Table 2-2. (contd)

	Scientific Name	Common Name	Status ^(a)			Habitat
			Federal	AL	MS	
1	<i>Procambarus</i>	crayfish	--	--	S3	Streams
2	<i>ablusus</i>					
3	<i>Procambarus</i>	phantom cave	--	NOST	--	Subterranean pools with silty
4	<i>pecki</i>	crayfish				bottoms
5	Fishes					
6	<i>Clinostomus</i>	rosyside dace	--	--	S2	Rocky flowing pools of
7	<i>funduloides</i>					headwaters, creeks and small rivers
8	<i>Cottus carolinae</i>	banded sculpin	--	--	S1	Gravel and rubble riffles of headwaters, creeks and small rivers; springs and their effluents
9	<i>Crystallaria</i>	crystal darter	--	--	S1	Clean sand and gravel runs of small to medium rivers
10	<i>asprella</i>					
11	<i>Cyprinella callistia</i>	Alabama shiner	--	--	S2	Gravel- and rubble-bottomed pools and runs of creeks and small to medium rivers
12	<i>Cyprinella</i>	spotfin chub	E	P	--	Rocky riffles and runs of clean small to medium riffles
13	<i>monacha</i>					
14	<i>Cyprinella</i>	spotfin shiner	--	--	S2	Sand and gravel runs and pools of creeks and small, medium and sometimes large rivers
15	<i>spiloptera</i>					
16	<i>Cyprinella</i>	steelcolor shiner	--	--	S3	Rocky and sandy runs and, less often, pools of creeks and small to medium rivers
17	<i>whipplei</i>					
18	<i>Elassoma</i>	spring pygmy sunfish	--	P	--	Spring systems
19	<i>alabamae</i>					
20	<i>Etheostoma</i>	greenside darter	--	--	SH	Rocky riffles of creeks and small to medium rivers; shores of large lakes
21	<i>blennioides</i>					
22	<i>Etheostoma</i>	slackwater darter	T	P	--	Gravel-bottomed pools and runs of creeks and small rivers
23	<i>boschungii</i>					
24	<i>Etheostoma</i>	Tuskaloosa darter	--	NOST	--	Fast rocky riffles of creeks and small to medium rivers
25	<i>douglasi</i>					
26	<i>Etheostoma</i>	fantail darter	--	--	S2	Rocky riffles of creeks and small to medium rivers
27	<i>flabellare</i>					
28	<i>Etheostoma</i>	stripetail darter	--	--	S2	Rocky pools of headwaters, creeks and small rivers
29	<i>kennicotti</i>					

Table 2-2. (contd)

	Scientific Name	Common Name	Status ^(a)			Habitat
			Federal	AL	MS	
1 2	<i>Etheostoma nigripinne</i>	blackfin darter	--	--	S2	Rocky pools and adjacent riffles of headwaters, creeks and small rivers
3 4	<i>Etheostoma rufilineatum</i>	redline darter	--	--	S2	Clear, fast rocky riffles of creeks and small to medium rivers
5 6	<i>Etheostoma tuscumbia</i>	Tuscumbia darter	--	P	--	Springs and spring runs
7	<i>Etheostoma wapiti</i>	boulder darter	E	P	--	Fast, rocky riffles of small to medium rivers
8 9	<i>Etheostoma zonistium</i>	bandfin darter	--	--	S2	Sand- and gravel-bottomed pools of headwaters, creeks and small rivers
10 11	<i>Ichthyomyzon castaneus</i>	chestnut lamprey	--	--	S3	Lakes and streams
12	<i>Ictiobus niger</i>	black buffalo	--	--	S3	Pools and backwaters of small to large rivers, impoundments and lakes
13	<i>Lythrurus ardens</i>	rosefin shiner	--	--	S2	Rocky pools and runs of clear, fairly fast headwaters, creeks and small rivers
14 15	<i>Moxostoma duquesnei</i>	black redhorse	--	--	S1	Sand- to rock-bottomed pools and runs of creeks and small to medium rivers; impoundments
16 17	<i>Moxostoma macrolepidotum</i>	shorthead redhorse	--	--	S1	Rocky pools, runs and riffles in small to large rivers; lakes
18	<i>Notropis boops</i>	bigeye shiner	--	--	S1	Flowing, usually clear and rocky, pools of creeks and small to medium rivers
19	<i>Notropis rubellus</i>	rosyface shiner	--	--	S1	Rocky runs and flowing pools of small to medium rivers
20	<i>Noturus exilis</i>	slender madtom	--	--	S1	Rocky riffles, runs and flowing pools of clear creeks and small rivers; rarely along wave-swept margins of large impoundments
21	<i>Noturus munitus</i>	frecklebelly madtom	--	--	S2	Rocky riffles and runs of medium to large rivers, often near vegetation

Table 2-2. (contd)

	Scientific Name	Common Name	Status ^(a)			Habitat
			Federal	AL	MS	
1	<i>Percina evides</i>	gilt darter	--	--	S1	Rocky riffles of small to medium riffles
2	<i>Percina lenticula</i>	freckled darter	--	--	S2	Fast, deep rocky riffles of small to medium rivers
3	<i>Percina</i>	slenderhead	--	--	S1	Gravel runs and riffles of creeks and small to medium rivers
4	<i>phoxocephala</i>	darter				
5	<i>Phenacobius</i>	suckermouth	--	--	S1	Gravel and rubble riffles and runs of creeks and small to medium, sometimes large, rivers.
6	<i>mirabilis</i>	minnow				
7	<i>Phoxinus</i>	southern	--	--	S2	Rocky, usually spring-fed pools of headwaters and creeks
8	<i>erythrogaster</i>	redbelly dace				
9	<i>Polyodon spathula</i>	paddlefish	--	NOST	S3	Slow-moving water of large rivers
10	<i>Rhinichthys</i>	blacknose	--	--	S1	Rocky pools of headwaters and creeks
11	<i>atratus</i>	dace				
12	<i>Typhlichthys</i>	southern	--	P	--	Subterranean waters
13	<i>subterraneus</i>	cavefish				
14	Amphibians					
15	<i>Cryptobranchus</i>	eastern	--	P	S1	Rocky, clear creeks and rivers with large shelter rocks
16	<i>alleganiensis</i>	hellbender				
17	<i>alleganiensis</i>					
18	<i>Gyrinophilus</i>	Tennessee	--	P	--	Clean, permanent streams and pools of limestone caves
19	<i>palleucus</i>	cave salamander				

(a) candidate; E = endangered; NOST (State ranking developed by Alabama National Heritage Program) = considered rare or sensitive, but has no official status; P = protected; S1 = critically imperiled; S2 = imperiled; S3 = rare or uncommon; S4 = widespread, abundant and apparently secure; SH = of historical occurrence; T = threatened, X = extirpated; -- = not listed.

Sources: ADCNR 2003; Cummings and Mayer 1992; FWS 1990a, 2000a, b, 2004a,b; Johnson and Wehrle 2004; MMNS 2002; MNHP 2002; NatureServe 2004; NCWRC 2004; Page and Burr 1991; TVA 2003a.

be extinct, (2) the species are presumed to be extirpated in the region, (3) there are no recent records for the species in the region, (4) there are no collection records for the species from pertinent locations, and/or (5) project areas of concern do not have appropriate habitat for the species (e.g., county records are for streams or caves that are not crossed by the BFN transmission lines). Additional information on these 29 Federally listed species are provided in the Biological Assessment in Appendix E.

1 The following discussion first addresses the nine Federally listed species that are known to
2 presently occur in Wheeler Reservoir or one or more of the streams crossed by the
3 transmission line rights-of-way associated with BFN. However, no Federally protected aquatic
4 species have been collected, or are currently known to occur, in the immediate vicinity of the
5 BFN site based on TVA's Vital Signs Monitoring Program data and Regional Natural Heritage
6 Programs database (Baxter and Gardner 2003). Following the discussion of the Federally
7 listed aquatic species is a discussion of the aquatic species that are only State-listed for
8 Alabama or Mississippi.

9
10 • **Federally Listed Species**

11
12 Anthony's riversnail (*Athearnia anthonyi*) is Federally listed as endangered (FWS 1994). It was
13 known to occur in Alabama, Georgia, and Tennessee (FWS 2004c). It has been extirpated
14 from most of its historic range because of pollution, siltation, and habitat modification or
15 destruction. Many populations were lost when the Tennessee River and the lower reaches of
16 its tributaries were impounded (FWS 1994). Only two populations of Anthony's riversnail are
17 known to survive. The largest of these occurs in the Tennessee River in Jackson County,
18 Alabama, and Marion County, Tennessee, a short distance downstream of Nickajack Dam.
19 This population also extends a short distance into the lower sections of the Sequatchie River,
20 Marion County, Tennessee. The other surviving population is restricted to a relatively short
21 reach of lower Limestone Creek, Limestone County, Alabama (FWS 1997a). Limestone Creek
22 is crossed three times by a BFN transmission line and is closely paralleled by the transmission
23 line along two stream segments. However, the BFN transmission line does not cross or parallel
24 the lower section of Limestone Creek where the snail is known to occur. Anthony's riversnail
25 inhabits large rivers and the lower reaches of larger creeks, and occurs on cobble/boulder
26 substrates in the vicinity of riffles. However, it does not always occur in strongly flowing
27 sections (NatureServe 2004). At the two sites in Limestone Creek where Anthony's riversnail
28 occurs, its density ranges up to several hundred individuals per square meter. However,
29 Limestone Creek has been severely impacted in the past by heavy siltation and probably other
30 sources of pollution (e.g., pesticide spraying and mining effluents). A single catastrophic
31 pollution event could potentially destroy all populations of the snail in the creek (FWS 1994;
32 NatureServe 2004). A recovery plan for the Anthony's riversnail has been prepared (FWS
33 1997a).

34
35 The slender campeloma (*Campeloma decampi*) is Federally listed as endangered
36 (FWS 2000b). It is known to exist in only several isolated populations along Limestone, Piney,
37 and Round Island Creeks in northern Alabama (NatureServe 2004). All three creeks are
38 crossed by BFN transmission lines. The slender campeloma typically burrows in soft sediments
39 or detritus. Impacts to the slender campeloma include siltation and other pollutants from poor
40 land-use practices and waste discharges (FWS 2000b).

Plant and the Environment

1 The armored snail (or armored marstonia) (*Pyrgulopsis pachyta*) is Federally listed as
2 endangered (FWS 2000b). It is known to occur in Alabama from several isolated sites in
3 Limestone and Piney Creeks near Mooresville, Alabama (NatureServe 2004). Piney Creek was
4 formerly a tributary of Limestone Creek before the construction of Wheeler Reservoir
5 (NatureServe 2004). Both creeks are crossed by a BFN transmission line; however, these
6 crossings occur several miles upstream from Mooresville. The armored snail is found in
7 shallow, still water along the edge of pools on tree roots and detritus. It probably also occurs on
8 mud substrates (NatureServe 2004). Impacts to the armored snail include siltation and other
9 pollutants from poor land-use practices and waste discharges (FWS 2000b).

10
11 The spectaclecase (*Cumberlandia monodonta*) is a candidate for Federal listing. Its historic
12 range includes Alabama, Arkansas, Iowa, Indiana, Illinois, Kentucky, Missouri, Nebraska, Ohio,
13 Tennessee, Virginia, and Wisconsin (FWS 2004a). It has been largely reduced to a relatively
14 few disjunct sites. The spectaclecase at some of the sites may no longer be capable of
15 reproduction due to loss of fish hosts or due to adverse environmental conditions (e.g.,
16 hypolimnetic releases from reservoirs) (NatureServe 2004). In Alabama, the spectaclecase is
17 known in Limestone and Morgan Counties. The spectaclecase is usually found in areas with a
18 strong current. In medium-size rivers, it prefers coarse substrates such as cobble, gravel, or
19 cracks in bedrock. In large rivers; substrates used are typically finer and include sand or mud.
20 It may be associated with shoals, bars, and islands (NatureServe 2004). The spectaclecase is
21 often found in small clusters of the same-aged individuals. Other than burrowing deeper into
22 the substrate, adults are essentially sessile (NatureServe 2004). Fish hosts for the
23 spectaclecase are unknown (Schulz and Marbain 1998). Live specimens of the spectaclecase
24 have been collected in the main stem of the Tennessee River in Colbert, Lauderdale,
25 Limestone, and Morgan Counties as recently as 2000. Recent collections in the mainstream of
26 the Tennessee River have been made in the tailwaters downstream of dams. Relic specimens
27 (i.e., present only as weathered shells) were collected in the Elk River, Limestone County,
28 Alabama in 1998 and 1974 (Butler 2002).

29
30 The Cumberlandian combshell (*Epioblasma brevidens*) is Federally listed as endangered, within
31 its entire range (FWS 1997b), except where proposed for establishment as a nonessential
32 experimental population in the free-flowing reach of the Tennessee River from the base of
33 Wilson Dam downstream to the backwaters of Pickwick Reservoir (about 19 km [12 mi]) and
34 the lower 8 km (5 mi) of all tributaries to this reach in Colbert and Lauderdale counties,
35 Alabama (FWS 2001). A draft recovery plan has been prepared for the species (FWS 2003).
36 It is known to occur in Alabama, Kentucky, Tennessee and Virginia (FWS 2004d). The
37 Cumberlandian combshell is now restricted to populations in limited areas of five drainages,
38 and some of these may no longer be reproducing. The species was eliminated from much of its
39 historic range by impoundments. Existing populations are in decline due to pollution (especially
40 from mining activities), impoundments, and siltation (FWS 1997b). It was last collected from
41 Muscle Shoals (the area now incorporated within the upper reaches of Pickwick Reservoir

1 through Wilson Reservoir and into Wheeler Reservoir) in 1925 (Garner 1997). The
2 Cumberlandian combshell is typically associated with riffle and shoal areas in medium and large
3 rivers in substrates of coarse sand to cobble. It has been apparently eliminated from the
4 mainstems of the Tennessee and Cumberland Rivers (FWS 2004e). In Alabama, moribund
5 specimens were found in the late 1990s in Bear Creek, a tributary of the Tennessee River
6 (NatureServe 2004). Fish hosts for the Cumberlandian combshell include darters and sculpins
7 (Schulz and Marbain 1998). Critical habitat has been designated for the species within the
8 Tennessee and Cumberland River Basins, including a portion of Bear Creek that flows through
9 Colbert County, Alabama, and Tishomingo County, Mississippi (FWS 2004e). One of the BFN
10 transmission lines crosses Bear Creek in Tishomingo County, Mississippi, within the reach of
11 designated critical habitat.

12
13 The pink mucket (*Lampsilis abrupta*) is Federally listed as endangered (FWS 1976). It is known
14 to occur in Alabama, Arkansas, Illinois, Indiana, Kentucky, Louisiana, Missouri, Ohio,
15 Pennsylvania, Tennessee, Virginia, and West Virginia (FWS 2004f). It seems to be surviving
16 and reproducing in sections of river that have been altered by impoundments. However, its
17 range has diminished (e.g., extirpated from Ohio, Pennsylvania, and Illinois) (NatureServe
18 2004). Within Alabama, the pink mucket occurs in Colbert, Lauderdale, Limestone, Madison,
19 Marshall, and Morgan Counties (NatureServe 2004). Suitable hosts for the glochidia of the pink
20 mucket include freshwater drum (*Aplodinotus grunniens*), largemouth bass, smallmouth bass,
21 spotted bass, sauger, and walleye (Fuller 1974; Barnhart et al. 1997). The pink mucket inhabits
22 areas of large rivers with swift currents, at depths ranging from 0.5 to 8.0 m (1.6 to 26.2 ft) and
23 a mixed sand/gravel/cobble substrate (Barclay 2004). Therefore, it is unlikely that the pink
24 mucket exists in Wheeler Reservoir in the areas near or downstream from BFN. They are
25 generally collected in the tailwater areas downstream from the Tennessee River drainage dams
26 (Barclay 2004). Sixteen individual pink muckets were collected near Hobbs Island (more than
27 64 km [40 mi] upstream of BFN) in 1998 (Yokely 1998). Past and ongoing threats to the pink
28 mucket include habitat loss and modification from dams and dredging, water-quality
29 degradation, and commercial overharvesting (NatureServe 2004). The zebra mussel would
30 also pose a threat to the pink mucket in areas where they co-exist.

31
32 The slabside pearl mussel (*Lexingtonia dolabelloides*) is a candidate for Federal listing. Its
33 historic range includes Alabama, Kentucky, Tennessee, and Virginia (FWS 2004b). Most
34 surviving individuals are restricted to two or three populations, and the long-term viability of all
35 extant occurrences is questionable (NatureServe 2004). It historically occurred in the
36 Cumberland River, although it is now extirpated from the entire Cumberland River system. The
37 slabside pearl mussel was more prevalent in the Tennessee River system. Historically, it was
38 fairly common from Muscle Shoals (the area now incorporated within the upper reaches of
39 Pockwick Reservoir through Wilson Reservoir and into Wheeler Reservoir) to the Tennessee
40 River headwater tributaries in Virginia and the Duck River drainage. It was last collected from
41 Muscle Shoals in 1963 (Garner 1997). Remaining populations occur in a number of tributary

Plant and the Environment

1 streams of the Tennessee River system, but not in the main stem of the river
2 (NatureServe 2004). Bear Creek is the only one of these streams that is crossed by a BFN
3 transmission line. Fish hosts for the slabside pearl mussel include the smallmouth bass and,
4 possibly, various minnow species (Schulz and Marbain 1998). Threats to the species include
5 channel alterations, impoundments, siltation, pollution, commercial clamming, and gravel and
6 coal mining (NatureServe 2004). It is generally found in areas of moderate to swift current
7 velocities with substrates ranging from coarse sand to heterogeneous assemblages for larger-
8 sized particles (NatureServe 2004).

9
10 The rough pigtoe (*Pleurobema plenum*) is Federally listed as endangered (FWS 1976). It is
11 known to occur in Alabama, Indiana, Kentucky, Pennsylvania, Tennessee, and Virginia
12 (FWS 2004g), and it has a wide, but very fragmented, distribution that includes Colbert,
13 Lauderdale, Limestone, and Morgan Counties in Alabama. Within the Tennessee River, the
14 rough pigtoe is currently present in an undetermined number of miles downstream of Pickwick,
15 Wilson, and Gunter Dams (NatureServe 2004). The rough pigtoe occurs in medium to
16 large rivers in sand, gravel, and cobble substrates in shoals, although it is occasionally found on
17 flats and muddy sand (NatureServe 2004). It does not occur in the impounded sections of
18 rivers (FWIE 1996). Therefore, it is unlikely that the rough pigtoe exists in Wheeler Reservoir in
19 the areas near or downstream from BFN. One individual was collected near Hobbs Island
20 (more than 64 km [40 mi] upstream of BFN) in 1998 (Yokely 1998). Possible host fish for the
21 rough pigtoe are bluegill and rosefin shiner (*Lythrurus ardens*) (Schulz and Marbain 1998). The
22 long-term viability of most populations is in jeopardy, particularly for those in large rivers where
23 zebra mussels are established (NatureServe 2004). Threats to the rough pigtoe include
24 impoundments, channelization, dredging, industrial and residential discharges, siltation,
25 herbicide and fertilizer run-off, zebra mussels, loss of glochidial hosts, and natural predators
26 (NatureServe 2004).

27
28 The slackwater darter (*Etheostoma boschungii*) is Federally listed as threatened (FWS 1977a).
29 Critical habitat was also designated for the species (FWS 1977a, b). It is known to occur in
30 Alabama and Tennessee (FWS 2004h). The slackwater darter occupies the following five
31 tributaries of the Tennessee River: Buffalo River and upper Shoal Creek in Lawrence County,
32 Tennessee; the Flint River in Madison County, Alabama; Swan Creek in Limestone County,
33 Alabama; and Cypress Creek in Lauderdale County, Alabama (NatureServe 2004). Swan
34 Creek is crossed by one of the BFN transmission lines. Critical habitat for the slackwater darter
35 includes many of the permanent and intermittent streams that are tributaries to Cypress Creek
36 in Lauderdale County, Alabama, and Wayne County, Tennessee (FWS 1977b). None of these
37 streams are located near BFN transmission lines. The slackwater darter typically occurs in
38 gravel-bottomed pools and sluggish areas of creeks and small rivers that are not more than
39 12 m (39 ft) wide and 2 m (6.6 ft) deep. They often inhabit slow waters beneath undercut banks
40 or accumulations of leaf litter or detritus. Spawning occurs in very shallow (5 to 10 cm [2 to
41 4 in.]) clear, flowing seepage water characterized by the presence of rushes and sedges in

1 fields and open woods. Threats to the species include habitat loss and degradation. The
2 heavy use of groundwater dries seepage areas used for spawning (NatureServe 2004).

3
4 • **State-Listed Species**

5
6 In addition to the 31 Federally listed mussel species, an additional 22 mussel species are State-
7 listed within one or more of the counties of concern in Alabama and Mississippi (Table 2-2). As
8 for the Federally listed mussel species, the State-listed species have been primarily impacted
9 by impoundments. Some of the species listed for Mississippi have also been affected by
10 habitat modifications created by the Tennessee-Tombigbee Waterway. The mussel species
11 have also been variously impacted by water-quality degradation (e.g., siltation and chemical
12 contamination). Continued declines in some of these species could be expected in the future,
13 which may lead to their becoming Federally listed species. Several of the species may be listed
14 in one state or the other due to natural constraints in distribution (e.g., a mussel species may be
15 primarily associated with either the Mobile River or the Tennessee River system). For example,
16 the pink heelsplitter is considered imperiled in Mississippi, but is considered a commercial
17 species in Alabama (Ahlstedt and McDonough 1992).

18
19 The Alabama cave shrimp (*Palaemonias alabamae*) is Federally listed as endangered (FWS
20 1988). It is known only from two caves in Madison County, Alabama (NatureServe 2004).
21 Habitat for the cave shrimp is silt-bottom pools in caves (FWS 1990b). Degradation of habitat
22 and groundwater contamination are the major threats to this species (FWS 1990b).

23
24 Three Alabama-listed troglobitic crayfish (Alabama cave crayfish [*Cambarus jonesi*], White
25 Spring Cave crayfish [*C. veitchorum*], and phantom cave crayfish [*Procambarus peckii*]) occur in
26 the project area. The Alabama cave crayfish is endemic to Alabama. It is known to occur in
27 caves between Florence and Guntersville, Alabama (NatureServe 2004). The White Spring
28 Cave crayfish is endemic to White Spring Cave in Limestone County, Alabama. It has a very
29 small population size and a low reproductive potential (NatureServe 2004). The phantom cave
30 crayfish is known from only three cave locations in Colbert, Lauderdale, and Morgan Counties,
31 Alabama (NatureServe 2004). Degradation of habitat and groundwater contamination are the
32 major threats to these species (NatureServe 2004).

33
34 Two Mississippi-listed crayfish species occur within several of the counties of concern. The
35 Tombigbee riverlet crayfish (*Hobbseus petilus*) is considered imperiled in Itawamba and Lee
36 Counties, while the crayfish *Procambarus ablusus* is considered rare or uncommon in
37 Tishomingo County (MMNS 2002). The imperiled status of the Tombigbee riverlet crayfish
38 results from its restricted range and potential habitat impacts related to the Tennessee-
39 Tombigbee Waterway. There are no existing threats to *P. ablusus* (NatureServe 2004). Its

Plant and the Environment

1 status in Mississippi is based more on Tishomingo County being at the edge of the species
2 range. The species is considered to be apparently secure within Tennessee (NatureServe 2004):

3
4 The spring pygmy sunfish (*Elassoma alabamae*) is known in several spring systems in
5 Alabama. Its status has improved as a result of introductions and discoveries of additional
6 populations (NatureServe 2004). It is currently known to occur in Limestone County, Alabama,
7 in the Beaverdam Moss Spring complex (most of Moss Spring and its spring run to Beaverdam
8 Creek, the areas within Beaverdam Swamp, and Lowe's Ditch) and in the Pryor Springs
9 system. It was extirpated from Cave Spring in Lauderdale County, Alabama, because of habitat
10 inundation by Pickwick Reservoir (NatureServe 2004). In Beaverdam Creek, the range of the
11 spring pygmy sunfish extends downstream to the impounded section of Wheeler Reservoir
12 (Floyd 1999). The species has been negatively impacted by impoundments and water-quality
13 degradation from poor land-use practices (e.g., crop-dusting, vegetation control, and
14 agricultural practices). They are also vulnerable to wetland alterations and chemical spills
15 (NatureServe 2004). The spring pygmy sunfish occurs in areas of clear water with fine sand or
16 mud substrates and abundant and thickly matted vegetation along the shoreline. It apparently
17 uses different spring and swamp microhabitats at different times of the year (NatureServe
18 2004). Spawning occurs in March and April. Adults spawn at one year of age and die within a
19 few days to months after spawning. The eggs are attached to aquatic vegetation above the
20 substrate (NatureServe 2004).

21
22 The Tuskaloosa darter (*Etheostoma douglasii*) has a small range, but occurs in a number of
23 areas in the upper Black Warrior system (Locust Fork and Sipsey Fork systems) in Alabama.
24 It is moderately threatened by timber practices and coal mining, siltation, and proposed
25 reservoirs on Locust Fork (NatureServe 2004). A portion of the Sipsey Fork system occurs in
26 the southern portion of Lawrence County that is not crossed by the BFN transmission lines.

27
28 Fewer than 15 populations of the Tuscumbia darter (*Etheostoma tuscumbia*) are known to
29 occur in springs and spring runs along the Tennessee River in Alabama. It is extirpated from
30 Tennessee (NatureServe 2004). Threats to the Tuscumbia darter include changes in the water
31 table, siltation, predation, and loss of aquatic vegetation (NatureServe 2004). Structures such
32 as low dams that are larger than 1.2- to 1.5-m (4- to 5-ft) high pose a barrier to dispersal.
33 Warm summer temperatures in waters surrounding springs are also believed to preclude
34 dispersal (NatureServe 2004). It feeds on invertebrates such as amphipods, snails, and midge
35 larvae, with reduced feeding in winter (NatureServe 2004).

36
37 The paddlefish (*Polyodon spathula*) is widespread in rivers in the eastern and central United
38 States. While populations are faring well in some areas, they are declining or of unknown trend
39 over much of the range. Threats to the species include habitat alteration (e.g., dams and
40 impoundments), pollution, siltation, and overharvesting. States stock paddlefish to compensate
41 for destruction or unavailability of spawning habitat (NatureServe 2004). While notable

1 increases in paddlefish have been documented in portions of the Tennessee, Cumberland, and
2 Arkansas rivers, they have all but disappeared from the Tennessee River in Alabama
3 (NatureServe 2004).

4
5 The southern cavefish (*Typhlichthys subterraneus*) has a discontinuous range in subterranean
6 waters of Alabama, Arkansas, Georgia, Indiana, Kentucky, Missouri, and Tennessee. The
7 species is apparently stable, but individual populations are vulnerable to habitat alteration and
8 pollution of groundwater (NatureServe 2004).

9
10 In addition to the fish species already discussed, 27 other fish species (10 minnows, 10 darters,
11 three suckers, two madtoms, one sculpin, and one lamprey) are listed as species of special
12 concern within one or more of the Mississippi counties within which BFN transmission line
13 rights-of-way occur (Table 2-2). However, no fish species are listed for Lee County, and only
14 the spotfin shiner (*Cyprinella spiloptera*) and steelcolor shiner (*C. whipplei*) are listed for Union
15 County. Both species, plus the other 25 fish species, occur in Itawamba and/or Tishomingo
16 Counties where they occur in the Tennessee and/or the Tennessee-Tombigbee Waterway
17 systems. The frecklebelly madtom (*Noturus munitus*) has a discontinuous distribution
18 (Page and Burr 1991), and within the Tennessee drainage is only known from an upper
19 tributary above Wheeler Reservoir. Twenty-five of the fish species are at the edge of their
20 natural distribution and are more common elsewhere. Water pollution, sedimentation, or
21 habitat loss, modification, or fragmentation could have a localized impact on some of these
22 species. Similarly, siltation pollution or habitat fragmentation (e.g., between adult habitat and
23 spawning streams) account for the rare or uncommon status of the chestnut lamprey
24 (*Ichthyomyzon castaneus*) within Itawamba County, Mississippi.

25
26 The eastern hellbender (*Cryptobranchus alleganiensis alleganiensis*) ranges widely within the
27 central interior portion of the eastern United States (NatureServe 2004). Northern Alabama and
28 extreme northeastern Mississippi are at the southeastern edge of the eastern hellbender's
29 range (NYSDEC 2003). Within Alabama, the eastern hellbender occurs in Colbert, Franklin,
30 Lauderdale, Limestone, Madison, Marshall, and Morgan Counties (NatureServe 2004). It has
31 been collected in Bear Creek in Tishomingo County in Mississippi and the Tennessee River,
32 and may also occur in Cedar Creek in Mississippi (Mayasich et al. 2003). While the species is
33 apparently secure, populations have declined or been eliminated in many areas due to
34 impoundments, sedimentation, water pollution, overharvesting, and heavy recreational use of
35 habitat (NatureServe 2004). Degradation of habitat is the principal threat to the eastern
36 hellbender. As it primarily "breathes" through its skin, the eastern hellbender requires cool,
37 well-oxygenated, flowing water (NatureServe 2004). The hellbender inhabits rocky, clear
38 creeks and rivers that usually have large rock shelters. They tend to avoid temperatures
39 greater than 20°C (68°F). Males prepare nests beneath large flat rocks or submerged logs,
40 and attend to the eggs. Crayfish are the primary prey, but they also eat other invertebrates and
41 fishes (often scavenged) (NatureServe 2004).

Plant and the Environment

1 The Tennessee cave salamander (*Gyrinophilus palleucus*) has a small range in Alabama,
2 Tennessee, and Georgia. Threats to the species include flooding of caves because of dams,
3 pollution, siltation, mining, and dumping (NatureServe 2004).
4

5 2.2.6 Terrestrial Resources

6

7 BFN is located within the Highland Rim section of the Interior Low Plateau Physiographic
8 Province on the north shore of Wheeler Reservoir in Limestone County, Alabama. Botanically,
9 the project site occurs within the Mississippian Plateau section of the Western Mesophytic
10 Forest Region (EPA 2004). In this region of northern Alabama, native forest communities
11 generally consist of mixed oak forests of varying composition in relation to topography and
12 soils. Historically, upland forests in the project area were characterized by mixtures of southern
13 red oak (*Quercus falcata*), black oak (*Q. velutina*), post oak (*Q. stellata*), and white oak (*Q.*
14 *alba*) with dogwood (*Cornus* spp.) commonly present in the understory. The clearing of
15 forested lands for agriculture has converted many of these forest communities to early
16 successional habitats, allowing representative native plant communities to become replaced by
17 introduced plant species.
18

19 The site is a 340-ha (840-ac) tract situated in an area where the land is used primarily for
20 agriculture. The countryside includes open pasture lands, scattered farmsteads, few residents,
21 and little industry within several miles. The south and west side of the plant site abuts Wheeler
22 Reservoir. The shoreline is approximately 3772 m (12,375 ft) with 58 percent stabilized with
23 riprap; the remaining 42 percent of the shoreline of the site is partially eroded and is composed
24 of mixed upland forest vegetation. The stabilized shoreline is adjacent to BFN and is primarily
25 vegetated by young (approximately 4- to 5-year-old) black willow (*Salix nigra*), common
26 hackberry (*Celtis occidentalis*), sumac (*Rhus* spp.), and exotic species such as Chinese privet
27 (*Ligustrum sinense*), Japanese honeysuckle (*Lonicera japonica*), and trumpet creeper (*Campsis*
28 *radicans*). The remainder of the shoreline is just west of the facility and is a young mixed
29 upland forest scattered with a few large specimens (approximately more than 80 years old) of
30 oak and loblolly pine (*Pinus taeda*). Young plants associated with the upland forest include
31 black locust (*Robinia pseudoacacia*), sweetgum (*Liquidambar styraciflua*), sassafras (*Sassafras*
32 *albidum*), cottonwood (*Populus* spp.), elm (*Ulmus* spp.), common hackberry, and black cherry
33 (*Prunus serotina*). Common understory vegetation in the forested area includes Chinese privet,
34 spleenwort (*Asplenium* spp.), Virginia creeper (*Parthenocissus quinquefolia*), and poison ivy
35 (*Toxicodendron radicans*).
36

37 Invasive exotic plant species are an issue in the area. There are approximately 19 invasive
38 plant species in the area (TVA 2003a) with a special emphasis on Chinese privet, Japanese
39 honeysuckle, Japanese knotweed (*Polygonum cuspidatum*), and Nepal grass (*Microstegium*
40 *vimineum*). There are approximately 10 ha (25 ac) and 5 ha (12 ac) of National Wetlands

1 Inventory and U.S. Army Corps of Engineers-classified wetlands, respectively, occurring within
2 the BFN site. This includes forested wetlands, emergent (marsh) wetlands, and scrub-
3 shrub/emergent wetlands (based on 1980s aerial photography). The wetland ecological
4 communities identified on the BFN site are dominated by plant species that are common in the
5 region. These include black willow, buttonbush (*Cephalanthus occidentalis*), sedges (*Carex*
6 *lupulina*, *C. vulpinoidea*, *Rhynchospora corniculata*), rushes (*Juncus* spp.), water hemlock
7 (*Conium maculatum*), and smartweeds (*Polygonum* spp.). These wetlands occur in areas that
8 have been previously disturbed by clearing and agriculture, and parts that are currently
9 maintained by periodic mowing. These types of wetlands are on land that was previously used
10 or is currently being used for agriculture. The dominant vegetation species occurring within
11 them are common in the region.

12
13 The vegetation communities described above are not unusual for the area and provide no
14 uncommon forms of wildlife habitat. Animal species commonly associated with upland
15 communities include white-tailed deer (*Odocoileus virginianus*), cottontail rabbit (*Sylvilagus*
16 *floridanus*), Virginia opossum (*Didelphis virginiana*), hispid cotton rat (*Sigmodon hispidus*), song
17 sparrow (*Melospiza melodia*), eastern bluebird (*Sialia sialis*), northern mockingbird (*Mimus*
18 *polyglottus*), turkey vulture (*Cathartes aura*), tufted titmouse (*Baeolophus bicolor*), American
19 toad (*Bufo americanus*), spring peeper (*Pseudacis crucifer*), black racer (*Coluber constrictor*
20 *constrictor*), and eastern box turtle (*Terrapene carolina*) (TVA 2003a). Riparian communities
21 can support a unique assemblage of wildlife including muskrat (*Ondatra zibethicus*), beaver
22 (*Castor canadensis*), raccoon (*Procyon lotor*), wood duck (*Aix sponsa*), belted kingfisher
23 (*Ceryle alcyon*), barred owl (*Strix varia*), American woodcock (*Scolopax minor*), Carolina wren
24 (*Thryothorus ludovicianus*), prothonotary warbler (*Protonotaria citrea*), eastern phoebe
25 (*Sayornis phoebe*), bullfrog (*Rana catesbeiana*), green frog (*Rana clamitans*), eastern newt
26 (*Notophthalmus viridescens*), southern two-lined salamander (*Eurycea cirrigera*), common
27 snapping turtle (*Chelydra serpentina serpentina*), and northern water snake (*Nerodia sipedon*)
28 (TVA 2003a). Some waterholes along Wheeler Reservoir are used by American alligators
29 (*Alligator mississippiensis*) in the winter. Invasive terrestrial animals that are expected to occur
30 in the project vicinity include European starling (*Sturnus vulgaris*), house sparrow (*Passer*
31 *domesticus*), and rock dove (*Columba livia*).

32
33 Two wildlife management areas – Swan Creek State Wildlife Management Area and Mallard-
34 Fox Creek State Wildlife Management Area – are within 5 km (3 mi) of the BFN site (TVA
35 2003a). The Swan Creek Wildlife Management Area includes more than 1200 ha (3000 ac) of
36 land and more than 2000 ha (5000 ac) of water surrounded by numerous industrial facilities.
37 The Mallard-Fox Creek State Wildlife Management Area encompasses approximately 280 ha
38 (700 ac) of land and 690 ha (1700 ac) of water and is primarily used for small game hunting.
39 The Round Island Recreation Area is located approximately 5.6 km (3.5 mi) upstream of BFN.
40 The BFN-to-Maury, Alabama, transmission line right-of-way crosses the Duck River State
41 Wildlife Management Area, the Duck River Unit 1 Proposed Designated Critical Habitat, and Elk

Plant and the Environment

1 River and Richland Creek, both of which are listed on the Nationwide Rivers Inventory. The
 2 BFN-to-Union, Mississippi, transmission line right-of-way crosses the John Bell Williams State
 3 Wildlife Management Area, the Natchez Trace National Parkway, the Tennessee-Tombigbee
 4 Waterway, and the Foxtrap Creek Ravine Potential National Natural Landmark.

5
 6 Terrestrial species listed by the FWS that have the potential to occur in the vicinity of the BFN
 7 site or along the transmission line rights-of-way are presented in Table 2-3. State-listed species
 8 (excluding Federally listed species) that have the potential to occur in the vicinity of the BFN
 9

10 **Table 2-3. Federally Listed Terrestrial Species Reported at the Browns Ferry Nuclear Power**
 11 **Plant, Units 1, 2, and 3 Site and Counties Associated with Transmission Line**
 12 **Rights-of-Way**
 13

14	Scientific Name	Common Name	Federal Status ^(a)
15	Birds		
16	<i>Haliaeetus leucocephalus</i>	bald eagle	T
17	<i>Picoides borealis</i>	red-cockaded woodpecker	E
18	Mammals		
19	<i>Myotis grisescens</i>	gray bat	E
20	<i>Myotis sodalis</i>	Indiana bat	E
21	Plants		
22	<i>Apios priceana</i>	Price's potato bean	T
23	<i>Asplenium scolopendrium</i> var. 24 <i>americanum</i>	American hart's-tongue fern	T
25	<i>Dalea foliosa</i>	leafy prairie clover	E
26	<i>Helianthus eggertii</i>	Eggert's sunflower	T
27	<i>Leavenworthia crassa</i>	fleshy-fruited gladececross	C
28	<i>Lesquerella lyrata</i>	lyrate bladder-pod	T
29	<i>Xyris tennesseensis</i>	Tennessee yellow-eyed grass	E
30	(a) E = endangered, T = Threatened, C = Candidate, (FWS 2004a).		

31
 32 site or along the transmission line rights-of-way are presented in Table 2-4 for Alabama
 33 (ANHP 2003) and Table 2-5 for Mississippi (MMNS 2002). A review of the TVA Regional
 34 Natural Heritage database indicates that no Federally or State-listed species of animals or
 35 plants have been reported from areas within 5 km (3 mi) of the BFN (TVA 2003a). BFN
 36 transmission line rights-of-way pass through Limestone, Morgan, Lawrence, Colbert, and
 37 Franklin Counties in Alabama and Tishomingo, Itawamba, Lee, and Union Counties in

1 Mississippi.^(a) Eleven Federally listed terrestrial species have been reported from these
 2 counties. There are 89 species listed for the State of Alabama and 116 species listed for
 3 Mississippi.^(a)
 4

5 **Table 2-4. Alabama State-Listed Terrestrial Species Reported from the Browns Ferry Nuclear**
 6 **Power Plant, Units 1, 2, and 3 and Associated Transmission Line Rights-of-Way**
 7

8	Scientific Name	Common Name	State Status ^(a)
9	Insects		
10	<i>Batrisesodes jonesi</i>	beetle	NOST
11	<i>Batrisesodes specus</i>	beetle	NOST
12	<i>Batrisesodes tumoris</i>	beetle	NOST
13	<i>Batrisesodes valentinei</i>	beetle	NOST
14	<i>Pseudanophthalmus distinguens</i>	ground beetle	NOST
15	<i>Pseudanophthalmus fluviatilis</i>	cave beetle	NOST
16	<i>Pseudanophthalmus lodingi</i>	ground beetle	NOST
17	<i>Pseudosinella hirsuta</i>	springtail	NOST
18	<i>Pseudosinella spinosa</i>	cave springtail	NOST
19	<i>Rhadine caudata</i>	ground beetle	NOST
20	Arachnids		
21	<i>Nesticus jonesi</i>	cave spring cave spider	P
22	Amphibians		
23	<i>Aneides aeneus</i>	green salamander	P
24	Reptiles		
25	<i>Eumeces authracinus pluvialis</i>	southern coal skink	NOST
26	<i>Lampropeltis triangulum sypila</i>	red milk snake	NOST
27	Birds		
28	<i>Accipiter cooperii</i>	Cooper's hawk	P
29	<i>Thryomanes bewickii bewickii</i>	Bewick's wren	P
30	Mammals		
31	<i>Corynorhinus rafinesquii</i>	eastern big-eared bat	P
32	<i>Myotis austroriparium</i>	southeastern bat	P

(a) Prentiss County, Mississippi is not included. Species are accounted for in adjacent counties.

Table 2-4. (contd)

	<i>Scientific Name</i>	<i>Common Name</i>	<i>State Status^(a)</i>
1			
2			
3			
4	<i>Myotis septentrionalis</i>	northern long-eared bat	NOST
5	Plants		
6	<i>Acorus calamus</i>	sweetflag	NOST
7	<i>Aplectrum hyemale</i>	puttyroot	NOST
8	<i>Asplenium ruta-muraria</i>	wall-rue spleenwort	NOST
9	<i>Astragalus tennesseensis</i>	Tennessee milk-vetch	NOST
10	<i>Boykinia aconitifolia</i>	brook saxifrage	NOST
11	<i>Bryoxiphium norvegicum</i>	sword moss	NOST
12	<i>Cotinus obovatus</i>	American smoke-tree	NOST
13	<i>Cuscuta harperi</i>	Harper's dodder	NOST
14	<i>Cypripedium candidum</i>	white lady-slipper	NOST
15	<i>Cystopteris tennesseensis</i>	Tennessee bladderfern	NOST
16	<i>Dalea gattingeri</i>	Gattinger prairie-clover	NOST
17	<i>Delphinium alabamicum</i>	Alabama larkspur	NOST
18	<i>Delphinium exaltatum</i>	tall larkspur	NOST
19	<i>Dicentra cucullaria</i>	Dutchman's breeches	NOST
20	<i>Dodecatheon frenchii</i>	French's shootingstar	NOST
21	<i>Elodea canadensis</i>	waterweed	NOST
22	<i>Enemion biternatum</i>	false rue-anemone	NOST
23	<i>Equisetum arevense</i>	common horsetail	NOST
24	<i>Eriogonum longifolium</i> var. <i>harperi</i>	Harper's umbrella-plant	NOST
25	<i>Erythronium albidum</i>	white trout-lily	NOST
26	<i>Frasera caroliniensis</i>	American columbo	NOST
27	<i>Huperzia lucidula</i>	shining clubmoss	NOST
28	<i>Huperzia porophila</i>	rock clubmoss	NOST
29	<i>Hydrastis canadensis</i>	goldenseal	NOST
30	<i>Hymenophyllum tayloriae</i>	gorge filmy fern	NOST
31	<i>Isoetes butleri</i>	Butler's quillwort	NOST
32	<i>Jamesianthus alabamensis</i>	Alabama warbonnet	NOST
33	<i>Leavenworthia alabamica</i>	Alabama glade-cress	NOST

Table 2-4. (contd)

	<i>Scientific Name</i>	<i>Common Name</i>	<i>State Status</i> ^(a)
1	<i>Leavenworthia uniflora</i>	Michaux leavenworthia	NOST
2	<i>Lesquerella densipila</i>	Duck River bladderpod	NOST
3	<i>Linum sulcatum</i> var. <i>harperi</i>	Harper's grooved-yellow flax	NOST
4	<i>Listera australis</i>	southern twayblade	NOST
5	<i>Mirabilis albida</i>	pale umbrella-wort	NOST
6	<i>Monotropsis odorata</i> var. <i>odorata</i>	sweet pinesap	NOST
7	<i>Neobeckia aquatica</i>	lake-cress	NOST
8	<i>Neviusia alabamensis</i>	Alabama snow-wreath	NOST
9	<i>Onosmodium molle</i> ssp. <i>molle</i>	soft false gromwell	NOST
10	<i>Ophioglossum engelmannii</i>	limestone adder's tongue	NOST
11	<i>Oxalis grandis</i>	great yellow wood-sorrel	NOST
12	<i>Pachysandra procumbens</i>	Allegheny-spurge	NOST
13	<i>Pediomelum subacaule</i>	tuberous scurfpea	NOST
14	<i>Phlox pulchra</i>	Wherry's phlox	NOST
15	<i>Plantago cordata</i>	heartleaved plantain	NOST
16	<i>Platanthera lacera</i>	ragged fringed orchid	NOST
17	<i>Schoenolirion croceum</i>	sunnybell	NOST
18	<i>Selaginella arenicola</i> ssp. <i>riddellii</i>	spikemoss	NOST
19	<i>Selaginella rupestris</i>	spikemoss	NOST
20	<i>Sida elliotii</i>	Elliot sida	NOST
21	<i>Silene rotundifolia</i>	roundleaf catchfly	NOST
22	<i>Silphium brachiatum</i>	Cumberland rosinweed	NOST
23	<i>Spiranthes magnicamporum</i>	Great Plains ladies'-tresses	NOST
24	<i>Stewartia ovata</i>	mountain camellia	NOST
25	<i>Talinum calcaricum</i>	limestone flame-flower	NOST
26	<i>Talinum mengesii</i>	flame-flower	NOST
27	<i>Thalictrum debile</i>	southern meadow-rue	NOST
28	<i>Thalictrum mirabile</i>	little mountain meadow-rue	NOST
29	<i>Trichomanes petersonii</i>	dwarf filmy-fern	NOST
30	<i>Trichostomum crispulum</i>	moss	NOST

Table 2-4. (contd)

	<i>Scientific Name</i>	<i>Common Name</i>	<i>State Status^(a)</i>
1	<i>Trillium flexipes</i>	nodding trillium	NOST
2	<i>Trillium pusillum</i> var. 1	interior least trillium	NOST
3	<i>Trillium recuvatum</i>	prairie trillium	NOST
4	<i>Trillium sessile</i>	sessile trillium	NOST
5	<i>Triosteum angustifolium</i>	horse-gentian	NOST
6	<i>Viola eglestonii</i>	Egleston's violet	NOST
7	(a) Status rankings developed by Alabama Natural Heritage Program. P = protected, NOST = no official status,		
8	but species are tracked by the Alabama Natural Heritage Program due to rarity in the state (ADCNR 2003).		

9

10 **Table 2-5.** Mississippi State-Listed Terrestrial Species Reported from the Browns Ferry
 11 Nuclear Power Plant, Units 1, 2, and 3 Associated Transmission Line
 12 Rights-of-Way

13

	<i>Scientific Name</i>	<i>Common Name</i>	<i>State Status^(a)</i>
14	Amphibians		
15	<i>Aneides aeneus</i>	green salamander	S1
16	<i>Eurycea lucifuga</i>	cave salamander	S1
17	<i>Gyrinophilus porphyriticus</i>	spring salamander	S1
18	<i>Hemidactylium scutatum</i>	four-toed salamander	S1
19	<i>Pseudacris brachyphona</i>	mountain chorus frog	S3
20	<i>Pseudotriton ruber</i>	red salamander	S3
21	Reptiles		
22	<i>Lampropeltis calligaster</i>	mole kingsnake	S2
23	<i>rhombomaculata</i>		
24	<i>Lampropeltis getula nigra</i>	black kingsnake	S3
25	<i>Regina septemvittata</i>	queen snake	S3
26	Insects		
27	<i>Ellipsaria lineolata</i>	butterfly	S3
28	Birds		
29	<i>Accipiter striatus</i>	sharp-shinned hawk	S1
30	<i>Aimophila aestivalis</i>	Bachman's sparrow	S3
31	<i>Petrochelidon pyrrhonota</i>	cliff swallow	S3
32			

Table 2-5. (contd)

	Scientific Name	Common Name	State Status ^(a)
1			
2			
3			
4	Mammals		
5	<i>Myotis septentrionalis</i>	northern myotis	S3
6	<i>Peromyscus ploionotus</i>	oldfield mouse	S2S3
7	Plants		
8	<i>Anemone quinquefolia</i>	wood anemone	S1S2
9	<i>Antennaria solitaria</i>	single-headed pussytoes	S3
10	<i>Aplectrum hyemale</i>	puttyroot	S1
11	<i>Aquilegia canadensis</i>	wild columbine	S1S2
12	<i>Arabis canadensis</i>	sicklepod	S2S3
13	<i>Asarum canadense</i>	Canada wild-ginger	S2S3
14	<i>Asplenium pinnatifidum</i>	lobed spleenwort	S1
15	<i>Asplenium resiliens</i>	black-stem spleenwort	S1
16	<i>Asplenium rhizophyllum</i>	walking-fern spleenwort	S1S2
17	<i>Asplenium trichomanes</i>	maidenhair spleenwort	S1
18	<i>Astragalus canadensis</i>	rattle-vetch	S2
19	<i>Aster ericoides</i>	white heath aster	S2
20	<i>Athyrium thelypteroides</i>	silvery spleenwort	S2S3
21	<i>Cacalia muehlenbergii</i>	great Indian-plantain	S1
22	<i>Callirhoe triangulata</i>	clustered poppy-mallow	S1S2
23	<i>Camassia scilloides</i>	wild hyacinth	S2S3
24	<i>Carex jamesii</i>	Nebraska sedge	S1S2
25	<i>Carex oligocarpa</i>	eastern few-fruit sedge	S1
26	<i>Carex picta</i>	painted sedge	S2S3
27	<i>Carex prasina</i>	drooping sedge	S1
28	<i>Carex seorsa</i>	separated sedge	S1S2
29	<i>Carex stricta</i>	uptight sedge	S2
30	<i>Carex virescens</i>	ribbed sedge	S1
31	<i>Carya laciniosa</i>	big shellbark hickory	S2S3
32	<i>Carya leiodermis</i>	swamp hickory	S2S3
33	<i>Cheilanthes lanosa</i>	hairy lipfern	S2

Table 2-5. (contd)

	Scientific Name	Common Name	State Status ^(a)
1	<i>Chelone glabra</i>	white turtlehead	S3
2	<i>Chelone lyonii</i>	pink turtlehead	S1
3	<i>Chelone obliqua</i>	red turtlehead	SH
4	<i>Chimaphila maculata</i>	spotted wintergreen	S2
5	<i>Cimifuga racemosa</i>	black bugbane	S1S2
6	<i>Cladrastis kentukea</i>	yellowwood	S2
7	<i>Clematis beadlei</i>	vase-vine leather-flower	S1
8	<i>Coreopsis auriculata</i>	lobed tickseed	S2S3
9	<i>Cypripedium pubescens</i>	yellow lady's-slipper	SU
10	<i>Decodon verticillatus</i>	hairy swamp loosestrife	S2S3
11	<i>Delphinium tricorne</i>	dwarf larkspur	S2
12	<i>Dentaria diphylla</i>	pepper-root	S1S2
13	<i>Dentaria heterophylla</i>	slender toothwort	S2S3
14	<i>Dicentra cucullaria</i>	Dutchman's breeches	S1
15	<i>Dirca palustris</i>	eastern leatherwood	S2
16	<i>Dodecatheon meadia</i>	shooting star	S2
17	<i>Erythronium albidum</i>	white dog's tooth violet	S2
18	<i>Erythronium americanum</i>	yellow dog's tooth violet	S1S2
19	<i>Erythronium rostratum</i>	beaked dog's tooth violet	S1S2
20	<i>Euonymus atropurpureus</i>	burning bush	S2S3
21	<i>Fraxinus quadrangulata</i>	blue ash	S2
22	<i>Gymnocladus dioicus</i>	Kentucky coffee-tree	S2
23	<i>Heuchera villosa</i> var. <i>macrorhiza</i>	giant alumroot	S1
24	<i>Hexalectris spicata</i>	crested coralroot	S2
25	<i>Hexastylis shuttleworthii</i>	large-flowered heartleaf	S1
26	<i>Hybanthus concolor</i>	green violet	S2
27	<i>Hydrophyllum appendiculatum</i>	appendaged waterleaf	S1
28	<i>Hydrophyllum macrophyllum</i>	large-leaf waterleaf	S1
29	<i>Ilex montana</i>	mountain holly	S3
30	<i>Isoetes engelmannii</i>	Appalachian quillwort	S1S2

Table 2-5. (contd)

	Scientific Name	Common Name	State Status ^(a)
1	<i>Juglans cineria</i>	white walnut	S2
2	<i>Lesquerella gracilis</i>	spreading bladder-pod	S2
3	<i>Ligusticum canadense</i>	nondo lovage	S1S2
4	<i>Luzula acuminata</i>	hairy woodrush	S3
5	<i>Melanthium virginicum</i>	Virginia bunchflower	S2S3
6	<i>Mertensia virginica</i>	Virginia bluebells	S1S2
7	<i>Muhlenbergia tenuiflora</i>	slender muhly	S1S2
8	<i>Nemastylis geminiflora</i>	prairie-iris	S2
9	<i>Neviusia alabamensis</i>	Alabama snow-wreath	S1
10	<i>Osmorhiza longistylis</i>	smoother sweet-cicely	S3
11	<i>Pachysandra procumbens</i>	Allegheny-spurge	S3
12	<i>Panax quinquefolius</i>	American ginseng	S3
13	<i>Pellaea atropurpurea</i>	purple-stem cliff-brake	S1S2
14	<i>Penstemon tenuiflorus</i>	narrow flowered beard tongue	S2S3
15	<i>Perideridia americana</i>	eastern eulophus	S1S2
16	<i>Phacelia bipinnatifida</i>	fernleaf phacelia	S1
17	<i>Philadelphus hirsutus</i>	hairy mock-orange	S1
18	<i>Pinus virginiana</i>	Virginia pine	S2
19	<i>Platanthera cristata</i>	crested fringed orchid	S3
20	<i>Platanthera integrilabia</i>	white fringeless orchid	S1
21	<i>Platanthera lacera</i>	green fringed-orchid	S1S2
22	<i>Platanthera peramoena</i>	purple fringeless orchid	S2S3
23	<i>Polemonium reptans</i>	Jacob's ladder	S2S3
24	<i>Rhamnus lanceolata</i>	lance-leaved buckthorn	S2
25	<i>Rhododendron arborescens</i>	smooth azalea	S1
26	<i>Sabatia campestris</i>	prairie pink	S2S3
27	<i>Salvia urticifolia</i>	nettle-leaf sage	S2S3
28	<i>Sedum ternatum</i>	wood stonecrop	S2
29	<i>Solidago flaccidifolia</i>	Appalachian goldenrod	S1S2
30	<i>Solidago sphacelata</i>	false goldenrod	S1S2

Table 2-5. (contd)

	Scientific Name	Common Name	State Status ^(a)
1	<i>Spiraea tomentosa</i>	hardhack spiraea	SH
2	<i>Spiranthes ovalis</i>	lesser ladies-tresses	S2S3
3	<i>Staphylea trifolia</i>	American bladdernut	S3
4	<i>Stellaria pubera</i>	giant chickweed	S2S3
5	<i>Stewartia ovata</i>	mountain camellia	S1
6	<i>Swertia caroliniensis</i>	American colombo	S2S3
7	<i>Tiarella cordifolia</i>	heart-leaved foam-flower	S2
8	<i>Tomanthera auriculata</i>	earleaf false-foxglove	S1
9	<i>Tradescantia ernestiana</i>	Palmer's spiderwort	S1
10	<i>Trautvetteria caroliniensis</i>	Carolina tassel-rue	S1
11	<i>Trichomanes boschianum</i>	bristle-fern	S1
12	<i>Trillium flexipes</i>	drooping trillium	S1
13	<i>Triosteum angustifolium</i>	narrow-leaf fever root	S3
14	<i>Triphora trianthophora</i>	three birds orchid	S2S3
15	<i>Viola pubescens</i> var. <i>eriocarpon</i>	smooth yellow violet	S1S2
16	(a) Status rankings developed by the Natural Heritage Inventory; S1 = critically imperiled because of extreme		
17	rarity; S2 = Imperiled because of rarity; S3 = rare or uncommon; SH = historically extant; SU = status		
18	uncertain (MMNS 2002; MNHP 2002).		

19

20 The bald eagle (*Haliaeetus leucocephalus*) is listed as threatened by the FWS for Franklin
 21 County, Alabama, and Itawamba and Tishomingo Counties, Mississippi. Bald eagles prefer
 22 habitat along coastlines, lakes, rivers, and other water bodies that provide their primary food
 23 source (i.e., fish and waterfowl) (NatureServe 2004). Eagles generally nest in tall trees or cliff
 24 faces near water and away from human disturbance. Bald eagles are known in the area around
 25 BFN, but there is no known nesting habitat within 5 km (3 mi) of the site. BFN transmission line
 26 rights-of-way are likely to be within foraging areas for this species.

27

28 The red-cockaded woodpecker (*Picoides borealis*) is listed as endangered by the FWS for
 29 Lawrence County, Alabama. Red-cockaded woodpeckers inhabit older open pine forests,
 30 (generally at least 80 to 120 years old) (FWS 2004d). Hardwood forests or pine forests with a
 31 hardwood understory are usually avoided. There is no woodpecker habitat within 5 km (3 mi) of
 32 the BFN site, and it is unlikely that there is any suitable habitat along the BFN transmission line
 33 rights-of-way.

34

1 Gray bats (*Myotis grisescens*) are listed by the FWS as endangered in Colbert, Franklin,
2 Lawrence, Limestone, and Morgan Counties, Alabama, and Tishomingo County, Mississippi.
3 Gray bats are colonial and are restricted to cave or cave-like habitats (FWS 2004d). Gray bats
4 roost and females form maternity colonies in caves located along rivers and reservoirs over
5 which they feed. In the winter, gray bats congregate and hibernate in a limited number of caves
6 across the southeast (FWS 2004d, i). Roosting and foraging habitat for gray bats is very
7 limited on the BFN site. Water sources for the bats include lagoons, sedimentation ponds,
8 drainage canals, and forested habitats are primarily small woodlots of poor quality. Although no
9 suitable habitats for these species occur on the BFN site, gray bats likely forage along the
10 Tennessee River, adjacent to the site. BFN transmission line rights-of-way are also likely to be
11 within foraging areas for this species.

12
13 Indiana bats (*Myotis sodalis*) are listed by the FWS as endangered in Colbert, Lawrence,
14 Limestone, and Morgan Counties, Alabama and Tishomingo County, Mississippi. Indiana bats
15 are highly colonial and hibernate in caves during winter months but can be found in hollow trees
16 and under loose tree bark during the summer, where they form small maternity colonies
17 (FWS 2004d). Indiana bats forage for insects primarily in riparian and upland forests. Roosting
18 and foraging habitat for Indiana bats is very limited on the BFN site. Water sources for the bats
19 include lagoons, sedimentation ponds, drainage canals, and forested habitats are primarily
20 small woodlots of poor quality. BFN transmission line rights-of-way are also likely to be within
21 foraging areas for this species.

22
23 Price's potato bean (*Apios priceana*) is listed as threatened by the FWS in Lee County,
24 Mississippi. This species is found in open mixed hardwood forests often on floodplains in or
25 near riparian areas (NatureServe 2004). Although thought to be somewhat dependent on
26 disturbances that maintain an early succession environment, it is also reported to be sensitive
27 to some management activities such as logging, cattle grazing, and highway right-of-way
28 maintenance. No populations of Price's potato bean are known within 5 km (3 mi) of the BFN
29 site, but suitable habitat could be found along the BFN transmission line rights-of-way.

30
31 American hart's-tongue fern (*Asplenium scolopendrium* var. *americanum*) is listed as
32 threatened by the FWS in Morgan County, Alabama (FWS 2004d). In the southern portions of
33 its range (Alabama), this fern is found only around the openings to limestone caves and
34 sinkholes. No populations have been recorded within 5 km (3 mi) of the BFN site; no suitable
35 habitat could be found along the BFN transmission line rights-of-way.

36
37 Leafy prairie clover (*Dalea foliosa*) is listed as endangered by the FWS in Franklin, Lawrence,
38 and Morgan Counties, Alabama (FWS 2004d). This species is found in association with cedar
39 glades in northern Alabama and central Tennessee. No populations of leafy prairie clover are
40 known to occur from within 5 km (3 mi) of the BFN site, and no suitable habitat could be found
41 along the BFN transmission line rights-of-way.

Plant and the Environment

1 Eggert's sunflower (*Helianthus eggertii*) is listed as threatened by the FWS in Colbert, Franklin,
2 Lawrence, Limestone, and Morgan Counties, Alabama. This species is found in barren habitats
3 within the Interior Plateau Ecoregion of Kentucky, Tennessee, and Alabama (NatureServe
4 2004). No populations are recorded within 5 km (3 mi) of the BFN site. Populations may occur
5 along the BFN transmission line rights-of-way because the species is reported to respond
6 favorably to management activities such as burning and mowing (NatureServe 2004).

7
8 Fleshy-fruited gladeceess (*Leavenworthia crassa*) is listed as a candidate species by the FWS
9 for Lawrence and Morgan Counties, Alabama. Reportedly endemic to Lawrence and Morgan
10 Counties, this species inhabits limestone glades and has been identified in only six sites
11 (NatureServe 2004). No populations have been recorded within 5 km (3 mi) of the BFN site,
12 but suitable habitat could be found along the BFN transmission line rights-of-way.

13
14 The lyrate bladder-pod (*Lesquerella lyrata*) is listed as threatened by the FWS in Colbert,
15 Franklin, and Lawrence Counties, Alabama. The species is known in only two populations in
16 Franklin and Colbert Counties (FWS 2004d). The plant is an annual in the mustard family and
17 is found in disturbed glade habitats. No populations exist within 5 km (3 mi) of the BFN site, but
18 suitable habitat could be found along the BFN transmission line rights-of-way.

19
20 Tennessee yellow-eyed grass (*Xyris tennesseensis*) is listed as endangered by the FWS in
21 Franklin County, Alabama. This species is found in moist-to-wet, limestone-derived soils in
22 open or lightly wooded sites (FWS 2004d). No populations are known to exist within 5 km
23 (3 mi) of the BFN site, but suitable habitat could be found along the BFN transmission line
24 rights-of-way.

25 26 **2.2.7 Radiological Impacts**

27
28 TVA has conducted a radiological environmental monitoring program (REMP) around the BFN
29 site since 1968. Through this program, radiological impacts to workers, the public, and the
30 environment are monitored, documented, and compared to the appropriate standards. The
31 objectives of the REMP are described below:

- 32
- 33 • Provide representative measurements of radiation and radioactive materials in the
34 exposure pathways and of the radionuclides that have the highest potential for radiation
35 exposures to members of the public.
 - 36
 - 37 • Supplement the radiological effluent monitoring program by verifying that the
38 measurable concentrations of radioactive materials and levels of radiation are not higher
39 than expected on the basis of the effluent measurements and the modeling of the
40 environmental exposure pathways.

1 Results of measurements of radiological releases and environmental monitoring are
2 summarized in annual reports (TVA 2004c, g). The limits for all radiological releases are
3 specified in the Browns Ferry ODCM, and these limits are designed to meet Federal standards
4 and requirements (TVA 2004c). The REMP includes monitoring of the aquatic environment
5 (fish, invertebrates, and shoreline sediment), the atmospheric environment (airborne
6 radioiodine, gross beta, and gamma), the terrestrial environment (vegetation), and direct
7 radiation (TVA 2004g).

8
9 Review of historical data on releases and the resultant dose calculations indicated that the
10 doses to maximally exposed individuals in the vicinity of the BFN site were a small fraction of
11 the limits specified in EPA's environmental radiation standards 40 CFR Part 190 as required by
12 10 CFR 20.1301(d). Dose estimates are calculated for a hypothetical maximally exposed
13 individual, based on monitored liquid and gaseous effluent release data, onsite meteorological
14 data, local river flow data, and appropriate pathways identified in the ODCM (TVA 2004c).

15
16 The dose from all pathways during the period from 1999 to 2003 to a maximally exposed
17 individual was less than 0.0035 mSv (0.35 mrem) per year to the body or organ other than the
18 thyroid. To calculate the dose to the maximally exposed individual, the calculated doses from
19 the liquid and gaseous effluent exposure pathways are summed. For the liquid effluent
20 pathway the whole body dose was calculated to be 0.0013 mSv (0.13 mrem) per year. The
21 liquid exposure pathways included drinking water, fish ingestion, and direct radiation from
22 shoreline sediment during recreation such as boating. For the gaseous effluent pathways, the
23 whole body dose was calculated to be 0.0022 mSv (0.22 mrem) per year; the gaseous
24 exposure pathways included inhalation, ingestion of milk and crops, and direct radiation from
25 the airborne radioactive material. The thyroid dose from all pathways was less than 0.0096
26 mSv (0.96 mrem) per year (TVA 2000, 2001, 2002b, 2003b, 2004c).

27
28 These doses are typical of the annual dose for operation of BFN, Units 2 and 3 without the
29 power uprates. As discussed earlier, operation at the combined total power level of
30 11,856 MW(t) during the license renewal term could increase doses by as much as a factor of
31 1.8 over these typical values. Historically doses to the population from BFN are well below
32 NRC and EPA limits and would continue to be well below NRC and EPA limits during operation
33 at the combined total power level of 11,856 MW(t) during the license renewal term.

34 35 **2.2.8 Socioeconomic Factors**

36
37 The staff reviewed the TVA ER and information obtained from several county, city, and
38 economic development staff during a site visit to Limestone and Morgan counties in the
39 spring 2004. The following information describes the economy, population, and communities
40 near BFN.

2.2.8.1 Housing

BFN employs approximately 1000 people on a full-time basis, with an additional 2475 contract employees who are primarily working on the restart of Unit 1 (TVA 2004h). About 300 contract employees who are not affiliated with the restart of Unit 1 support the non-outage operations at Units 2 and 3. Approximately 26 percent of these employees (both plant and contract) live in Lauderdale County, while an additional 21 percent live in Limestone County, 16 percent live in Madison County, and 14 percent live in Morgan County, with the remainder living in other locations (see Table 2-6). Although the employee residences are widely dispersed, the socioeconomic analysis primarily focuses on Lauderdale, Limestone, Madison, and Morgan counties, because more than 75 percent of the BFN employees live in these counties, and Limestone County is where BFN is located (TVA 2004h).

Table 2-6. Residence by County for Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 Tennessee Valley Authority and Contract Employees

County	Tennessee Valley Authority Employees		Contract Employees		Total (Employees and Contractors)	
Colbert	71	6.9%	261	10.5%	332	9.5%
Cullman	4	0.4%	13	0.5%	17	0.5%
Franklin	13	1.3%	68	2.7%	81	2.3%
Giles, TN	5	0.5%	4	0.2%	9	0.3%
Jackson	11	1.1%	32	1.3%	43	1.2%
Lauderdale	306	29.6%	617	24.9%	923	26.3%
Lawrence, AL	18	1.8%	94	3.8%	112	3.2%
Lawrence, TN	21	2.0%	60	2.4%	81	2.3%
Limestone	251	24.3%	496	20.0%	747	21.3%
Madison	137	13.2%	419	16.9%	556	15.8%
Marshall, AL	8	0.8%	13	0.5%	21	0.6%
Morgan	172	16.6%	312	12.6%	484	13.8%
Wayne	0	0.0%	23	0.9%	23	0.7%
Other	18	1.7%	63	2.5%	81	2.3%
Total	1035		2475		3510	

Source: TVA 2004h.

1 BFN is currently in the process of restarting Unit 1. There are presently more than 2000
 2 temporary workers onsite who are working on the restart of Unit 1. In addition, the units are on
 3 a schedule to refuel in alternate years. During refueling, the number of employees increases by
 4 as many as 900 temporary workers for a period of 30 to 40 days. Most of the temporary
 5 employees appear to primarily reside in surrounding counties and commute to the plant rather
 6 than make use of temporary rental housing available in Limestone County (TVA 2003a). Local
 7 real estate agents in Athens also confirmed this trend despite the recent increase in employ-
 8 ment at the plant, resulting from Unit 1 restart activities. The local real estate market has
 9 remained relatively unaffected and rental rates have not significantly increased.^(a)

10
 11 Table 2-7 provides the number of housing units and housing unit vacancies for Lauderdale,
 12 Limestone, Madison, and Morgan counties for 1990 and 2000. Limestone County, where BFN
 13 is located, had 26,897 housing units in 2000, with a vacancy rate around 8 percent. Lauderdale
 14 County, in which the greatest number of TVA plant and contract employees reside, had

15
 16 **Table 2-7. Total Occupied and Vacant (Available) Housing Units by County, 1990 and 2000**

	1990	2000	Approximate Percentage Change
LAUDERDALE COUNTY			
Housing Units	33,522	40,424	21%
Occupied Units	30,905	36,088	17%
Vacant Units	2,617	4,336	66%
LIMESTONE COUNTY			
Housing Units	21,455	26,897	25%
Occupied Units	19,685	24,688	25%
Vacant Units	1,770	2,209	25%
MADISON COUNTY			
Housing Units	97,855	120,288	23%
Occupied Units	91,208	109,955	21%
Vacant Units	6,647	10,333	55%
MORGAN COUNTY			
Housing Units	40,419	47,388	17%
Occupied Units	37,799	43,602	15%
Vacant Units	2,620	3,786	45%
Sources: U.S. Census Bureau (USCB) 2000, 1990.			

17
 18
 19
 20
 21
 22
 23
 24
 25
 26
 27
 28
 29
 30
 31
 32
 33
 34
 35
 (a) Personal communication (discussion) with L. McBay and L. Smith, Century 21 Realtors, Athens, Alabama (March 31, 2004).

Plant and the Environment

40,424 housing units and a vacancy rate of just over 10 percent. Madison and Morgan counties, both of which have a larger population base and a relatively more diverse employment market, had vacancy rates in 2000 of nine and eight percent, respectively (USCB 2000). These counties are not subject to restrictive growth control measures that limit housing development (TVA 2003a).

Table 2-8 contains data on population, estimated population, and annual population growth rates for Lauderdale, Limestone, Madison, and Morgan counties. All counties experienced positive population growth in the 1990s, with Limestone's rate of increase exceeding 20 percent (TVA 2003a).

Table 2-8. Population Growth in Lauderdale, Limestone, Madison and Morgan Counties, Alabama – 1980 to 2020

	Lauderdale County		Limestone County		Madison County		Morgan County	
	Population	% Change (each decade)	Population	% Change (each decade)	Population	% Change (each decade)	Population	% Change (each decade)
1980	80,546	--	46,005	--	196,966	--	90,231	--
1990	79,661	(-1.1)	54,135	17.7	238,912	21.3	100,043	10.9
2000	87,966	10.4	65,676	21.3	276,700	15.8	111,064	11.0
2015	98,015*	11.4	81,747*	24.5	324,153*	17.1	124,358*	12.0
2025	103,176*	5.3	90,865*	11.2	349,713*	7.9	131,112*	5.4

-- = No data available.

* population estimated

Sources: TVA 2003a.

2.2.8.2 Public Services

Public services include water supply, education, and transportation.

• Water Supply

The City of Athens Water Services and the Limestone County Water Authority are the primary sources of potable water in Limestone County. The City of Athens Water Services draws water from the Elk River and currently has a Safe Yield from the River of $21.3 \times 10^4 \text{ m}^3/\text{day}$ (56 MGD) (TVA 2004i). Limestone County Water Authority draws water from the Elk River and four wells. Both of these water systems operate with excess capacity, and currently meet water demands for Unit 1 restart activities, and normal BFN operations. As shown in Table 2-9, the average total daily water demand on the City of Athens system is about $2.5 \times 10^4 \text{ m}^3/\text{day}$ (6.5 MGD),

1 which is less than half the permitted capacity of 5.1×10^4 m³/day (13.5 MGD). Athens City
 2 Water Services has plans to upgrade its intake structure to accommodate an increased intake
 3 rate of 6.8×10^4 m³/day (18 MGD) to ensure supply reliability. This system upgrade is
 4 scheduled for implementation during 2004. BFN typically uses 500 to 1000 m³/day (0.13 to
 5 0.26 MGD).
 6

7 **Table 2-9. Public Water Supply Systems in Limestone County, Alabama**
 8

9	Water System	Source	Permitted Capacity m ³ /d (MGD)	Average Daily Demand m ³ /d (MGD)	Peak Demand Per Day m ³ /d (MGD)	Area Served
10	City of Athens Water Services	Elk River and wells	5.1×10^4 (13.5)	2.5×10^4 (6.5)	4.1×10^4 (10.7)	City of Athens/ Limestone County
11	Limestone County Water Authority	Elk River and wells	3.0×10^4 (8)	2.4×10^5 (6.25)	2.6×10^4 (6.75)	Limestone County
12	Source: TVA 2003a, 2004i					

15
 16 • **Transportation**
 17

18 The BFN site is located approximately 16 km (10 mi) southwest of Athens in northern Alabama
 19 in Limestone County and is located just south of U.S. Highway 72, which runs from South
 20 Pittsburg, Tennessee, west to Memphis, Tennessee. The site is directly accessible from
 21 County Road 25 (Shaw Road), which intersects U.S. Highway 72 approximately 10 km (6 mi)
 22 north of the site. County Road 25 (Nuclear Plant Road) also intersects U.S. Highway 31
 23 approximately 14 km (9 mi) east of the site. U.S. Highway 31 intersects U.S. Highway 72
 24 northeast of the site. Browns Ferry Road to County Road 25 just east of the site provides a
 25 more direct route to the site from Athens. U.S. Highways 72 and 31 are both high-quality,
 26 four-lane roads with adequate lane widths, alignments, turning lanes, and speed limits of
 27 80 km/hr (50 mph) through Athens and increasing away from the city.
 28

29 County Road 25 and Browns Ferry Road are medium-quality, two-lane roads with level align-
 30 ment, some passing zones, and speed limits of 72 km/hr (45 mph). There is direct accessibility
 31 to BFN off County Road 25. The large diamond intersection at one entrance allows for smooth
 32 turning movements into and out of the BFN site. Another access road into the plant commonly
 33 used by contractors uses a traffic light at the intersection with Nuclear Plant Road. BFN, which
 34 is the primary traffic generator in the vicinity of the site, currently averages a daily site
 35 population of approximately 1200 persons. The population currently peaks at approximately
 36 2000 people during outages, which occur every 24 months (per unit) for approximately
 37 2 months. Current truck deliveries are minimal (less than 10 per week) and include hydrogen
 38 trucks, Calgon™ water chemistry trucks, and occasional diesel fuel deliveries during peak

Plant and the Environment


1 months. Rural residences located along the county roads that provide access to the site are
2 also sources of traffic in the area (TVA 2003).

3
4 Figure 2-5 shows a map of the local road network for the area. The latest available (1998)
5 average daily traffic counts in proximity to the site indicate approximately 13,440 vehicles per
6 day on U.S. Highway 72 north of the site and 16,260 vehicles per day on U.S. Highway 31
7 south of U.S. Highway 72. There are no available traffic counts on the county roads; however,
8 TVA estimates approximately 1600 vehicles per day on Shaw Road, Browns Ferry Road, and
9 Nuclear Plant Road.

10
11 BFN does not have direct rail service; however, a railway spur track with an unloading area is
12 located off the CSX (Louisville and Nashville Railroad) mainline that runs north and south in
13 Tanner, Alabama, approximately 13 km (8 mi) east of BFN. TVA leased this small parcel of
14 land from CSX and used it for offloading during construction of BFN; however, TVA has not
15 used the spur and unloading area for offloading and transporting materials to the plant since
16 then. After offloading, heavy items were transported on heavy trucks via a "hardened" pathway
17 to the site. This pathway included shallow fords through creek beds along the way. At the site,
18 a short railroad spur runs into the turbine building for transport into the plant (TVA 2003a).

19
20 TVA plans to use the railroad spur track and unloading area for future removal of dry cask
21 spent fuel storage canisters from the site. There are no plans to use it for Unit 1 restart
22 activities or regular plant operations. Traffic on the Tennessee River near BFN includes both
23 commercial and recreational vessels. The river channels and the locks at Guntersville Lock
24 and Dam and at Wheeler Dam are more than adequate for handling river traffic. Both
25 Guntersville Lock and Wheeler Lock are operating below their utilization capacity (TVA 2003a).

26
27 BFN has a qualified barge facility near the northwest corner of the site. Currently it consists of
28 barge tie points and a wide ramp going down into the water. The ramp was used during initial
29 plant construction to transport very heavy loads such as reactor vessels. The barge facility is
30 currently used several times per year, but a temporary crane has to be brought in to unload the
31 barge each time. The roadbed from the plant to the barge facility is "hardened" for heavy loads.
32 Future work is contemplated to upgrade the barge facility by stabilizing the riverbank and
33 installing anchoring cells and a permanent dock (so that the facility will no longer require use of
34 a temporary crane). An upgraded barge facility could eventually be used to facilitate transport
35 of spent fuel canisters offsite for disposal in a national repository. The barge facility would likely
36 be used for some heavy items during Unit 1 restart; however, its use for this purpose and the
37 proposed facility upgrade is independent of the decision to restart Unit 1. Appropriate
38 environmental analyses would be done if TVA decides to propose upgrading the barge facility.
39



1 Figure 2-5. Local Road Network for Browns Ferry Nuclear Power Plant, Units 1, 2, and 3

Plant and the Environment

1 Three pipelines pass within 8 km (5 mi) of the center of the BFN plant site. One pipeline that
2 carries xylene runs north and south about 3.9 km (2.4 mi) east of the plant. The other two
3 pipelines carry natural gas in a common right-of-way about 6.1 km (3.8 mi) south-southwest of
4 the plant. The natural gas pipelines generally run east-west. The only pipeline crossing the
5 BFN site boundary is a potable water line from the Athens Water District. There are no plans to
6 install or connect to any pipelines in the foreseeable future. BFN is connected to the TVA
7 system network by seven 500-kV lines: one line to Madison substation; two lines to Trinity
8 substation; one line each to the West Point, Maury, and Union substations; and one line to
9 Limestone substation.

10
11 Normal station power is from the unit station service transformers connected between the
12 generator breaker and main transformer of each unit. Startup power is from the TVA 500-kV
13 system network through the 500-kV to 20.7-kV main and 20.7 kV to 4.16-kV unit station service
14 transformers. Auxiliary power is available through the two common station service transformers
15 that are fed from two 161-kV lines supplying the 161-kV switchyard, one line each from the
16 Athens and Trinity substations.

17 18 **2.2.8.3 Offsite Land Use**

19
20 BFN is located in northern Alabama on the north shore of Wheeler Reservoir in an unincorporated
21 portion of Limestone County. Madison, Morgan, Lawrence, and Lauderdale Counties also
22 are in the vicinity of BFN. The largest city in Limestone County is Athens, and the population in
23 the county is approximately 67,000, with approximately 19,000 residing in Athens.

24
25 BFN is located in an agricultural area, surrounded by cropland principally planted with cotton.
26 Limestone County is ranked first in Alabama for the most cotton grown. About 89,000 ha
27 (220,000 ac) or 66.8 percent of the total acreage in Limestone County is used for agriculture
28 (TVA 2003a). In addition, there are approximately 31,930 ha (78,900 ac) of forested land in the
29 county, constituting approximately 23.9 percent of total county acreage. The majority of the
30 forested land is located in the northern two-thirds of the county. Trends show that the amount
31 of forested land has been declining since the early 1960s (TVA 2003a). The amount of land
32 devoted to agriculture has been gradually increasing.

33
34 Only about two percent of Limestone County is urban development; however, the current trend
35 in population growth will likely result in more land becoming urbanized (TVA 2003a). Population
36 in Limestone County has been gradually increasing because of increased employment
37 opportunities in the county as well as in nearby Huntsville and Decatur. It is expected that the
38 majority of residential growth will occur around Athens and in the Elkmont Village area

1 (TVA 2003a). Development of commercial property is rapidly occurring in the area of the
2 intersection of U.S. Highway 72 and Interstate 65 and along the U.S. Highway 72 corridor to
3 Huntsville.

4 5 **2.2.8.4 Visual Aesthetics and Noise**

6 7 • **Visual Aesthetics**

8
9 BFN is situated in an area where the land is used primarily for agriculture. Population densities
10 are low, with no population centers of significance within 16 km (10 mi) of the plant. The site is
11 surrounded to the north and east by rural countryside. It includes open pasture lands, scattered
12 farmsteads, few residents, and little industry within several miles. The terrain is gently rolling
13 with open views to higher elevations to the north. The south and west sides of the plant abut
14 Wheeler Reservoir, which is a wide expanse of open river used for an array of recreational
15 purposes. The reservoir in the vicinity of BFN is moderately used by recreational boaters and
16 fishermen (TVA 2003a).

17
18 There are no homes within foreground viewing distance to the north and east. Adjacent to the
19 site however, is a small residential development located to the northwest. Another residential
20 development is located across Wheeler Reservoir to the southwest, and the Mallard Creek
21 public use area is directly across the reservoir. These developments have at least partial views
22 of the plant site. A berm, graded during the initial construction of the plant and containing
23 approximately 2.5 million m³ (3.3 million yd³) of earth excavated to make cooling water
24 channels, lies adjacent to the cooling tower complex and blocks views of the northern and
25 eastern plant area (TVA 2003a).

26
27 Two wildlife management areas – Swan Creek State Wildlife Management Area and Mallard-
28 Fox Creek State Wildlife Management Area – are within 5 km (3 mi) of the BFN site (TVA
29 2003a). The Swan Creek Wildlife Management Area includes more than 1200 ha (3000 ac) of
30 land and more than 2000 ha (5000 ac) of water surrounded by numerous industrial facilities.
31 The Mallard-Fox Creek State Wildlife Management Area encompasses approximately 280 ha
32 (700 ac) of land and 690 ha (1700 ac) of water and is primarily used for small game hunting.
33 The Round Island Recreation Area is located approximately 5.6 km (3.5 mi) upstream of BFN
34 (TVA 2003a).

35 36 • **Noise**

37
38 Several communities near BFN are exposed to noise from plant operations. The two areas
39 considered to be most susceptible are the Paradise Shores and the Lakeview communities.
40 Paradise Shores is located downstream and adjacent to the BFN site, while Lakeview is located
41 across the river and about 2591 m (8500 ft) from the center of the cooling tower area

Plant and the Environment

1 (TVA 2002a). Upstream and adjacent to the site are two new subdivisions of waterfront homes
2 – Pointe Westmoreland and Lookingbill. Given the distance and buildings and terrain features
3 between BFN and its cooling tower area, Pointe Westmoreland and Lookingbill are not con-
4 sidered to be sensitive to the current noise environment. Given the growth that has occurred
5 around BFN since it first became operational, the initial background noise estimates for both the
6 Paradise Shores and Lakeview communities were not considered representative of present-day
7 conditions.

8
9 In June 2001, TVA conducted a new background noise survey (TVA 2002a). For the Paradise
10 Shores community, the 15-hour daytime (7:00 a.m. to 10:00 p.m.) average noise value was
11 45.7 decibels, while the nighttime (10:00 p.m. to 7:00 a.m.) average was 43.1 decibels. Similar
12 data for the Lakeview community for the same time periods was 44.1 and 38.7 decibels. The
13 predominant noise sources were traffic, lawn mowers, home air-conditioners, and children's
14 activities. At night, insects, frogs, air-conditioners, and traffic were the dominating noises
15 (TVA 2002a). Lakeview has posted traffic restrictions that reduced traffic, thus reducing the
16 recorded background noise values.

17
18 In July 2001, a daytime noise survey was conducted while the three cooling towers closest to
19 Paradise Shores were operating. Measurements taken at the same locations used for the
20 background noise survey indicated a total noise level of 45.8 decibels, while the calculated total
21 noise level value for this location was 46.4 decibels, based on noise measurements taken from
22 another location closer to the cooling towers. If the other two operating cooling towers were
23 used, the estimated background noise level would increase by less than 1 decibel. For six
24 cooling towers (assumes the replacement and operation of the sixth cooling tower), the
25 additional total noise level would be 1 to 2 decibels greater than the levels measured during the
26 July 2001 survey. On the day of the testing, noise from the existing five operating cooling
27 towers was not detected in the Lakeview community.

28
29 Currently, there are no Federal, State, or local municipal noise standards, or regulations
30 (TVA 2002a). The utility uses the EPA-recommended level of 55 decibels for the annual
31 equivalent sound level day/night as the basis for acceptable noise level for residential areas
32 before noise reduction measures would be considered (TVA 2002a). While the measured
33 noise levels obtained both for the background and during cooling tower operation were discrete
34 measurements, that information can be used to calculate the average annual day/night level.
35 TVA estimated these values to be 50 decibels for Paradise Shores and 46 decibels for
36 Lakeview (TVA 2002a). Therefore, the current estimated noise levels for both communities is
37 below the recommended EPA level. However, this does not preclude the potential for
38 annoyance and complaints from some members of either the Paradise Shores or Lakeview
39 communities because of disturbances of communication, relaxation, and concentration.
40

2.2.8.5 Demography

• Resident Population Within 80 km (50 mi)

Population within 80 km (50 mi) (in 16-km [10-mi] annular rings) of BFN was estimated (TVA 2003). An estimated 164,936 people live within 32 km (20 mi) of BFN, and 872,478 live within 80 km (50 mi) (TVA 2003a). The largest population centers within a portion of the 16-km (10-mi) area are Athens (located in Limestone County with a population 18,967) and Decatur (located in Morgan County with a population of 53,929) (USCB 2000).

Between 1990 and 2000, the population of Lauderdale County grew by 10 percent, Limestone County population grew by 21 percent, Madison County grew by 16 percent, and Morgan County grew by 11 percent. All the population growth of these counties, which surround the plant, were equal to or greater than the growth of the State of Alabama between these same years (10 percent). As a group, these four counties have been growing faster than the State of Alabama, and projections indicate that this trend is expected to continue for the next several years. The faster growth however, is limited to Limestone and Madison counties, which constitute the Huntsville metropolitan area (TVA 2003a).

• Workforce

The economy of Limestone County is more closely linked to BFN activities than are the economies of Lauderdale, Madison, and Morgan counties, because TVA is one of the largest sources of employment for Limestone County residents and contributes a greater share to the county's revenue relative to the share contributed by other neighboring counties.

The largest single employer in Limestone County is Delphi Saginaw Steering Systems, which has approximately 2600 employees. The next largest employers include the TVA BFN site and the County Board of Education, each of which employs approximately 1200 people throughout the year. Other major employers in the county include Target Distribution (retail distribution), Federal Mogul Sealing Systems (production of automotive gaskets), Steelcase, Inc., (production of office furniture), and ConAgra Poultry (poultry processing) (Athens-Limestone Chamber of Commerce 2004).

The number of jobs in Limestone County has more than doubled since 1970, reaching a total of 32,068 jobs in 2001 (Table 2-10). The 2001 level is 17.9 percent higher than the 1990 level. During this same time period, the population grew by 24.5 percent, suggesting that Limestone County has become more of a bedroom community to Huntsville as its growth has continued to spread toward the west. With the exception of Colbert and Lawrence Counties, the employment market for the surrounding counties listed in Table 2-10 has been strong during the past three decades relative to State and U.S. growth rates. Based on TVA forecasts of employment for the TVA Power Service Area, employment in Limestone County is expected to

Plant and the Environment

1 be around 41,000 in 2015 and about 53,000 in 2035, which is approximately 2 percent growth
 2 per year for the next 30 years (TVA 2003a). Limestone County is more dependent on
 3 manufacturing, government, and farm employment than other neighboring counties, as is
 4 presented in Table 2-11. The region around BFN has an industrial distribution similar to that of
 5 the state as a whole, although it is slightly more dependent on manufacturing. The state, as
 6 well as the region surrounding BFN, is more dependent on manufacturing and less on trade and
 7 service employment than is the nation as a whole.
 8

9 **Table 2-10.** Number of Jobs by County in the Vicinity of Browns Ferry Nuclear Power Plant,
 10 Units 1, 2, and 3
 11

County	1970	1980	1990	2001	Average Annual Percent Change 1970-2001	Percent Change, 1990-2001
Colbert	25,045	29,775	28,594	28,292	0.4%	(-1.1%)
Lauderdale	20,518	29,126	36,579	43,171	3.6%	18.0%
Lawrence	7,289	8,905	11,445	11,766	2.0%	2.8
Limestone	14,056	18,300	27,188	32,068	4.1%	17.9%
Madison	93,110	108,507	165,710	194,841	3.5%	17.6%
Morgan	34,144	42,699	54,151	64,473	2.9%	19.1%
Alabama (x 1000)	1,413	1,736	2,062	2,410	2.3%	16.9%
United States (x 1000)	91,282	114,231	139,427	167,536	2.7%	20.2%

12 Source: TVA 2003a
 13
 14
 15
 16
 17
 18
 19
 20
 21
 22

23
 24 **Table 2-11.** Major Employment Sectors in Counties Surrounding Browns Ferry Nuclear Power
 25 Plant, Units 1, 2, and 3 and in Alabama – 2001
 26

Employment Sector	Colbert	Lauderdale	Lawrence	Limestone	Madison	Morgan	Alabama
Trade and Services	12,391	21,197	4,165	13,180	103,266	28,626	1,151,833
Manufacturing	4,272	6,087	1,883	6,381	27,278	13,797	334,947
Agriculture	849	2,159	1,953	2,149	3,117	1,612	84,339
Government	5,885	7,382	1,753	5,836	37,604	7,930	383,141
Other	4,895	6,346	2,012	4,522	23,576	12,508	455,433
Total Jobs	28,292	43,171	11,766	32,068	194,841	64,473	2,409,693
Unemployment (Rate)	2,082 (8.2%)	3,260 (8.0%)	1,115 (6.6%)	1,299 (4.1%)	4,880 (3.4%)	3,083 (5.4%)	112,004 (5.3%)

27 Source: TVA 2003a; U.S. Bureau of Labor Statistics (BLS 2004)
 28
 29
 30
 31
 32
 33
 34
 35
 36
 37
 38

1 • **Transient Populations**

2
3 There appears to be very little seasonal fluctuation in local populations around BFN caused by
4 transient populations moving through the area. Because migratory workers travel and can
5 spend a significant amount of time in an area without being actual residents, they may be
6 unavailable for census takers to count. If this occurs, these workers would be "under-
7 represented" in U.S. Census Bureau (USCB) population counts. Although migrant workers are
8 commonly found in rural agriculturally productive areas and a significant portion of Limestone
9 County is made up of agricultural land, the farming in this area is less labor-intensive than other
10 regions because of the types of crops that are raised (primarily cotton and soy beans) and the
11 lack of irrigation requirements. There appear to be no significant concentrations of migrant
12 workers in areas surrounding BFN (TVA 2003a).^(a)

13
14 • **Taxes**

15
16 Property taxes are used to fund schools, police and fire protection, road maintenance, and
17 other municipal services. Property taxes may be levied by counties, cities, towns, villages,
18 school districts, and special districts. BFN is located in Limestone County, which generates
19 most of its tax revenues through *ad valorem* taxes, which are taxes levied on the value of real
20 estate. The commercial and industrial sectors generate relatively more of the tax revenues in
21 Limestone County than the residential sector.^(b)

22
23 Although TVA is a nonprofit entity, which is not subject to conventional state and local taxation,
24 it makes in-lieu-of-taxation payments to states in which its power operations are carried on and
25 in which it has acquired properties previously subject to State and local taxation in accordance
26 with federal law, Section 13 of the TVA Act, 16 U.S.C. §831i. Under Section 13, TVA pays
27 five percent of its gross power revenues to such states and counties (TVA 2004h).

28
29 TVA makes tax-equivalent payments to eight states, including Alabama. The State of Alabama
30 then allocates its tax-equivalent payments from TVA in accordance with Title 40 "Revenue and
31 Taxation," Chapter 28 "Distribution of Payments Made In Lieu of Taxes," Sections 40-28-1
32 through 40-28-4. Alabama distributes 75 percent of the TVA tax-equivalent payments to the
33 16 TVA-served counties based on a formula from TVA's book value of power property and
34 sales in each of these counties. These counties then share a portion of their payment with
35 cities, the school systems, hospitals, etc., within their boundaries. The remainder of the tax-

(a) Personal Communication (discussion) with M. Jordan and A. Stover, community Development Department, Decatur, Alabama (March 31, 2004).

(b) Personal Communication (discussion) with M. Cole, D. Seibert, T. Hill, P. Ball, E. Ezzell, Limestone County Commission (March 31, 2004).

Plant and the Environment

1 equivalent payments are either retained for the State's general fund or are distributed to
2 counties not served by TVA. During FY 2003, the State of Alabama allocated \$15 million to the
3 general fund, \$58 million to TVA-served counties, and nearly \$4 million to counties not served
4 by TVA (TVA 2004h).

5
6 TVA tax-equivalent payments that are distributed to Limestone County, the City of Athens, and
7 school districts within Limestone County are included in Table 2-12. Because of the series of
8 tax payment formulas and distribution policies, the total amount of the TVA tax-equivalent
9 payment listed in the third column of Table 2-12 is not solely attributable to the existence and
10 operation of BFN. The TVA allocation paid to Limestone County is however, largely attributed
11 to TVA's fixed assets. An estimated portion of the tax-equivalent payment to the local
12 jurisdictions that could reasonably be attributed to the existence and operation of BFN in
13 Limestone County is provided in Table 2-12, Column 5.

14
15 In fiscal year 2003, Limestone County received just over \$4.5 million from the State as
16 redistribution of TVA's tax-equivalent payment. Approximately \$2 million of this payment to
17 Limestone County could be attributed to the presence of BFN in the county. Tax-equivalent
18 payments for BFN that were retained by Limestone County average about eight percent of the
19 total revenue taken in by the county. The distribution of these payments to various county
20 funds (e.g., general fund, building fund, hospital), school districts, and local municipalities is
21 included in Table 2-12. BFN accounted for a smaller proportion of the City of Athens' total
22 revenue (only 2.0 percent) and even less for the local school districts (one percent) during this
23 same period. Although Morgan County also relies on the significant tax-equivalent payments
24 from TVA (approximately \$10 million, \$2 million of which is retained by the county) (MCC 2004),
25 the amount directly attributable to BFN operations and asset value is far less than the share
26 contributed to Limestone County revenues (TVA 2004h).

27

1 **Table 2-12. Limestone-County Distribution of Tax-Equivalent Payments Made by Tennessee**
 2 **Valley Authority in Fiscal Year 2003**
 3

4	Fund	Total Fund Revenue (\$)	Tax Equivalent Payment by TVA (\$)	Percent of Total Revenues	Estimated TVA Payment Attributable to BFN ^(a) (\$)	Percent of Total Revenue
5	Limestone County	6,372,000	1,110,276	17%	488,521	8%
6	General Fund					
7	Limestone Hospital Fund	1,471,000	221,955	15%	97,660	7%
8	Limestone Public Buildings, Roads and Bridges	1,850,000	443,536	24%	195,156	11%
9	City of Athens (less utilities)	17,073,000	884,817	5%	389,320	2%
10	Athens City School District	23,946,000	545,406	2%	239,979	1%
11	Limestone County School District	49,547,000	1,157,867	2%	509,462	1%
12	Other (e.g., libraries and other towns)	NA	166,361	NA	73,199	NA

13 (a) It is estimated that 44 percent of the TVA tax-equivalent payment is attributable to BFN; thus, all distributions were adjusted proportionately to estimate the BFN portion.

14 NA = Not Available

15 Source: City of Athens 2004; LCC 2004; NCES 2004; and TVA 2004h, I.

26 2.2.9 Historic and Archaeological Resources

27
 28 The area around BFN is rich in prehistoric and historic resources. Recent literature provided
 29 adequate background information for the area. Consequently, only a brief summary is provided
 30 here. Prehistoric and historic period overviews for Alabama are provided by U.S. National Park
 31 Service (2004), Hudson (1999), and Walthall (1980).

32 2.2.9.1 Prehistoric Period

33
 34
 35 Archaeological research has indicated that prehistoric Native American occupation of the region
 36 around BFN occurred from the Paleo-Indian period (about 10,000 to 8000 B.C.) to the
 37 Mississippian period (about A.D. 900 to 1500). Archaeological periods are based on changing
 38 settlement and land-use patterns and artifact styles. In Alabama, prehistoric chronology is
 39 divided into five broad time periods: Paleo-Indian, Archaic, Gulf Formational, Woodland, and
 40 Mississippian.
 41

Plant and the Environment

1 The prehistoric periods were marked by initial reliance on big game hunting for subsistence,
2 followed by increased use of smaller game animals and plant foods in the Archaic period, more
3 sedentary villages, and an increased reliance on cultivated crops. Through the Mississippian
4 period, the Native American population occupied larger base camps in the river valleys, with
5 subsistence based on agriculture, hunting and gathering, and intergroup trade. The late
6 prehistoric period is primarily identified by the introduction of European trade goods.
7

8 2.2.9.2 Native American Historic Period 9

10 Prior to the early 18th Century, most of Alabama was home to Native Americans belonging to a
11 southeastern alliance known as the Creek Confederacy. Today's Creek Nation, also known as
12 the Muskogee, were the major tribe in that alliance. The Confederacy consisted of separate
13 and independent tribes that gradually became, over a long period of time, a single political
14 organization. Throughout most of its history however, the Confederacy was a dynamic
15 institution, constantly changing in size as tribes, for whatever reason, entered or left the
16 alliance.
17

18 At the time of historic European contact, the ancestors of the modern Creek Indians lived in a
19 number of small distinct Mississippian-related societies in Alabama and Georgia. The dominant
20 group, sharing a common language or dialects, was the Muskogee. The Muskogee consisted
21 of 12 bands including the Kasihta, Coweta, Coossa, Abihka, Wakokai, Eufaula, Hilibi, Atasi,
22 Kolomi, Tukabahchee, Pakana, and the Okchai. The bands situated to the north along the
23 Coosa, Tallapoosa, and Alabama Rivers became known as the Upper Creek, while those along
24 the Chattahoochee and Flint Rivers collectively became known as the Lower Creek.
25

26 In the early 1800s, a population of Creek Indians and other groups (such as the Yemassee)
27 were still present in Alabama. However, in 1830 the American Congress passed the Indian
28 Removal Act. Within a couple of years from this date, virtually the entire expanse of Alabama
29 was devoid of Indian settlements.
30

31 2.2.9.3 Euro-American Historic Period 32

33 The Alabama territory was first explored by the Spanish in 1540. Their immediate objective was
34 to create settlements along the Gulf of Mexico. Entering Pensacola Bay, they failed to establish
35 a permanent settlement, but explored parts of Alabama. The first settlement was built in 1720
36 in the Mobile area by the French under the command of Baptiste le Moyne Bienville, who was a
37 colonizer and the governor of Louisiana for France. The Alabama territory was later ceded to
38 Great Britain in 1763 after the French and Indian Wars.
39

1 After the American Revolution in 1783, the Alabama territory came under the possession of the
2 United States. The defeat of the Creek Indians by Andrew Jackson in 1814 spurred settlement
3 and Alabama became a territory in 1817. Alabama was admitted to the Union in 1819. Late in
4 1819, the Missouri Territory embraced all of the Louisiana Purchase and the question was
5 raised as to the legal status of slavery in Missouri and the rest of the territory west of the
6 Mississippi. This debate led to the beginning of the Civil War. Alabama was one of several
7 southern states that ceded from the union on January 11, 1861. The Confederate government
8 was organized at Montgomery on February 4, 1861. After the Civil War in 1868, Alabama was
9 readmitted to the Union. Both world wars stimulated industrialization and crop diversification in
10 the State of Alabama.

11
12 TVA began major construction on BFN in 1967. Unit 1 began commercial operation in
13 August 1974, Unit 2 in 1975, and Unit 3 in 1977. BFN was TVA's first nuclear power plant.

14 **2.2.9.4 Historic and Archaeological Resources at BFN**

15
16
17 Much of the BFN site has been disturbed by construction of the nuclear power plant facilities
18 and related infrastructure, including roads, parking lots, and the cooling towers. Some previous
19 disturbance has also occurred along the transmission line rights-of-way. However, there are a
20 few small areas on the site that remain undeveloped. Intact archaeological sites may be
21 present within these undeveloped areas.

22
23 The final environmental impact statement for the construction of BFN (TVA 1972) listed one site
24 on the National Register of Historic Places, which is the TVA Wilson Dam located 31 km (19 mi)
25 downstream from BFN. Prior to construction, TVA relocated the Cox Cemetery that involved
26 moving more than 50 graves. Complete records of the grave relocation activities were filed with
27 the Alabama Historical Commission.

28
29 TVA has an extensive cultural resource program that works to protect historic resources, as
30 required by Federal law. Staff are responsible for the identification, evaluation, and protection
31 of cultural resources on TVA lands and land affected by TVA actions (TVA 2004j). The majority
32 of undisturbed land at BFN was surveyed in 2001 as part of the review for license renewal. The
33 survey identified two historic properties. The first property identified was a prehistoric
34 archaeological site (1Li535) with an Early-to-Middle Woodland period occupation. The site is
35 considered potentially eligible for listing in the National Register of Historic Places (TVA 2002a).
36 The second historic property identified was the Cox Cemetery. This cemetery was relocated
37 during the initial construction of BFN. No historic structures were identified during the historic
38 structures survey.
39

Plant and the Environment

1 Cultural resources location information is protected by the Archaeological Resources Protection
2 Act of 1979 and by 36 CFR Part 800. Therefore, no maps, photos, or figures of historic
3 properties are provided in this draft SEIS.
4

5 **2.2.10 Related Federal Project Activities and Consultations**

6

7 The staff reviewed the possibility that activities of other Federal agencies might impact the
8 renewal of the OLS for BFN. Any such activities could result in cumulative environmental
9 impacts and the possible need for a Federal agency to become a cooperating agency for
10 preparation of this SEIS (10 CFR 51.10(b)(2)).
11

12 TVA, a federal corporation wholly owned by the U.S. Government, is subject to the
13 requirements for Federal agencies in the National Environmental Policy Act of 1969 (NEPA). In
14 compliance with NEPA, TVA prepared a SEIS to provide the public and TVA decisionmakers
15 with an assessment of the environmental impacts of extending the operating life of the BFN
16 nuclear units (TVA 2002a). This NRC draft SEIS draws upon the content of the TVA SEIS, but
17 was prepared by NRC staff independently.
18

19 BFN is located on the north bank of Wheeler Reservoir on the Tennessee River. The reservoir
20 is created by Wheeler Dam, which is approximately 32 km (20 mi) downriver from the plant.
21 Wheeler Dam was constructed and is operated by TVA for flood control, power generation, and
22 navigation.
23

24 The Mallard Creek Recreation Area is located directly across the Tennessee River from BFN.
25 This is a TVA developed and operated area. It includes developed areas for camping,
26 picnicking, swimming, and boat launching. Approximately 5.6 km (3.5 mi) upstream of the plant
27 is Round Island Recreation Area, also developed and operated by TVA. It also features
28 facilities for camping, swimming, picnicking, and boat launching. The reservoir in the vicinity of
29 the plant site is moderately used by recreational boaters and fishermen. Wheeler National
30 Wildlife Refuge, operated by FWS, is located upstream from BFN. It is one of the
31 southern-most wintering areas for ducks and geese in the southeastern United States.
32

33 After reviewing the Federal activities in the vicinity of the BFN site, the staff determined that
34 there were no Federal project activities that would make it desirable for another Federal agency
35 to become a cooperating agency for preparation of the SEIS.
36

37 NRC is required under Section 102(C) of NEPA to consult with and obtain the comments of any
38 Federal agency that has jurisdiction by law or special expertise with respect to any environ-
39 mental impact involved in the subject matter of the SEIS. During the course of preparing this

1 draft SEIS, NRC consulted with TVA, FWS, and the National Marine Fisheries Service (NOAA
2 Fisheries). Consultation correspondence with these agencies is included in Appendix E.
3

4 2.3 References

5
6 10 CFR Part 20. Code of Federal Regulations, Title 10, *Energy*, Part 20, "Standards for
7 Protection Against Radiation."
8

9 10 CFR Part 50. Code of Federal Regulations, Title 10, *Energy*, Part 50, "Domestic Licensing
10 of Production and Utilization Facilities."
11

12 10 CFR Part 51. Code of Federal Regulations, Title 10, *Energy*, Part 51, "Environmental
13 Protection Regulations for Domestic Licensing and Related Regulatory Functions."
14

15 10 CFR Part 61. Code of Federal Regulations, Title 10, *Energy*, Part 61, "Licensing
16 Requirements for Land Disposal of Radioactive Waste."
17

18 10 CFR Part 71. Code of Federal Regulations, Title 10, *Energy*, Part 71; "Packaging and
19 Transportation of Radioactive Material."
20

21 36 CFR Part 800. Code of Federal Regulations, Title 36, *Parks, Forest, and Public Property*,
22 Part 800, "Protection of Historic Properties."
23

24 40 CFR Part 81. Code of Federal Regulations, Title 40, *Protection of the Environment*, Part 81,
25 "Designations of Areas for Air Quality Planning Purposes."
26

27 40 CFR Part 190. Code of Federal Regulations, Title 40, *Protection of the Environment*,
28 Part 190, "Environmental Radiation Protection Standards for Nuclear Power Operations."
29

30 Ahlstedt, S.A. and T.A. McDonough. 1992. *Quantitative Evaluation of Commercial Mussel*
31 *Populations in the Tennessee River Portion of Wheeler Reservoir of Wheeler Reservoir,*
32 *Alabama.* Tennessee Valley Authority, Norris and Knoxville, Tennessee, October 1992.
33 Available on the Internet under Accession No. ML041530161, dated May 27, 2004, at
34 <http://www.nrc.gov/reading-rm/adams.html>
35

36 Alabama Department of Environmental Management (ADEM). 2003. NPDES Permit
37 Modification Rationale Fact Sheet. Revised August, 13, 2003, Montgomery, Alabama.
38

39 Alabama Department of Conservation and Natural Resources (ADCNR). 2003. "County by
40 County Listing of Alabama Species on the Federal List for Threatened and Endangered

Plant and the Environment

1 Species or Whose Status Is a Concern." Montgomery, Alabama. Accessed on the Internet
2 March 25, 2004 at <http://dncr.state.al.us/watchable-wildlife/regulations/endangered-county.cfm>

3
4 Alabama Department of Public Health (ADPH). 2002. "2002 Alabama Fish Consumption
5 Advisories." Montgomery, Alabama. Accessed on the Internet March 15, 2004 at
6 <http://www.adph.org/administration/fishadv.pdf>

7
8 Alabama Department of Public Health (ADPH). 2003. "Alabama Fish Consumption Advisories
9 March 2003." Montgomery, Alabama. Accessed on the Internet March 15, 2004 at
10 <http://www.adph.org/RISK/Alabama%20Fish%Consumption%20Advisories%2003.pdf>

11
12 Alabama Natural Heritage Program (ANHP). 2003. *Alabama Inventory List: The Rare,
13 Threatened and Endangered Plants, Animals, and Natural Communities of Alabama*. Privately
14 printed by the Alabama Natural Heritage Program, 1500 East Fairview Avenue, Montgomery,
15 Alabama.

16
17 Archaeological Resources Protection Act (ARPA) of 1979. 16 USC 470, et seq.

18
19 Athens-Limestone Chamber of Commerce. 2004. *Industrial Directory 2004*. October 1, 2003.
20 Athens, Alabama.

21
22 Baker, T.F. 2001. E-mail from T.F. Baker to K. Gardner, TVA Heritage Resources, Norris,
23 Tennessee, Subject: "*Daphnia lumholtzi*." March 15, 2001.

24
25 Barclay, L.A. 2004. *Biological Opinion of the Tennessee Valley Authority's Proposed Reservoir
26 Operation Study*. U.S. Fish and Wildlife Service, Tennessee Ecological Services Field Office,
27 Cookeville, Tennessee.

28
29 Barnhart, M.C., F.A. Riusech, and A.D. Roberts. 1997. "Fish Hosts of the Federally
30 Endangered Pink Mucket, *Lampsilis abrupta*." Triannual Unionid Report No. 13, November
31 1997. Accessed on the Internet January 19, 2004 at
32 <http://ellipse.inhs.uiuc.edu/FMCS/TUR/TUR13.html>

33
34 Baxter, D.S. and J.P. Buchanan. 1998. *Browns Ferry Nuclear Plant Thermal Variance
35 Monitoring Program Including Statistical Analyses. Final Report*. Tennessee Valley Authority,
36 Water Management Environmental Compliance, Norris, Tennessee. Available on the Internet
37 under Accession No. ML041530161, dated May 27, 2004 at
38 <http://www.nrc.gov/readingrm/adams.html>

39
40 Baxter, D.S. and K.D. Gardner. 2003. *Biological Monitoring of the Tennessee River near
41 Browns Ferry Nuclear Plant Discharge 2002 Final*. Tennessee Valley Authority, Aquatic Biology

1 Lab, Norris, Tennessee. Available on the Internet under Accession No. ML041530161, dated
2 May 27, 2004 at <http://www.nrc.gov/reading-rm/adams.html>

3
4 Benson, A.J. 2004. "The Exotic Zebra Mussel." U.S. Fish and Wildlife Service, Region 3,
5 Division of Endangered Species, Fort Snelling, Minnesota. Accessed on the Internet
6 June 4, 2004 at <http://midwest.fws.gov/endangered/clams/zebra.html>

7
8 Butler, R.S. 2002. Status Assessment Report for the Spectaclecase, *Cumberlandia*
9 *monodonta*, Occurring in the Mississippi River System (U.S. Fish and Wildlife Service
10 Regions 3, 4, 4, and 6). U.S. Fish and Wildlife Service, Ohio River Valley Ecosystem Team,
11 Mollusk Subgroup, Asheville, North Carolina. Accessed on the Internet January 20, 2004 at
12 <http://midwest.fws.gov/endangered/clams/spectaclecase-sa.pdf>

13
14 Carroll, B.B. 1982. Letter from B.B. Carroll, Chief, Fisheries and Aquatic Ecology Branch,
15 Division of Water Resources, to L.W. Colaw, Assistant Director, Industrial Development, Office
16 of Economic and Community Development, Subject: "Mallard-Fox Mussel Survey – Report."
17 September 30, 1982. Available on the Internet under Accession No. ML041530161, dated
18 May 27, 2004 at <http://www.nrc.gov/reading-rm/adams.html>

19
20 Center for Aquatic Resource Studies (CARS). 2004. "*Daphnia lumholtzi*." USGS, Center for
21 Aquatic Resource Studies, Gainesville, Florida. Accessed on the Internet March 25, 2004 at
22 <http://nas.er.usgs.gov/crustaceans/docs/dlumholtzi.html>

23
24 City of Athens. 2004. Personal correspondence through e-mail and phone with J. Hamilton,
25 City Clerk, May 20, 2004, Athens, Alabama.

26
27 Cummings, K.S. and C.A. Mayer. 1992. "Field Guide to Freshwater Mussels of the Midwest."
28 Illinois Natural History Survey Manual 5. Illinois Natural History Survey, Urbana, Illinois.
29 Accessed on the Internet March 15, 2004 at
30 http://www.inhs.uiuc.edu/chf/pub/mussel_man/cover.html

31
32 Dycus, D.L. 1998. "Indicators of Reservoir Ecological Condition." Tennessee Valley Authority,
33 Chattanooga, Tennessee. Accessed on the Internet January 19, 2004 at
34 <http://www.nwqmc.org/98proceedings/Papers/45-DYCU.html>

35
36 Dycus, D.L. and T.F. Baker. 2000. *Aquatic Ecological Health Determinations for TVA*
37 *Reservoirs – 1999*. Tennessee Valley Authority, Water Management, Chattanooga,
38 Tennessee. Available on the Internet under Accession No. ML041530161, dated May 27, 2004
39 at <http://www.nrc.gov/reading-rm/adams.html>

Plant and the Environment

1 Elliott, D.L., C.G. Holladay, W.R. Barchet, H.P. Foote, and W.F. Sandusky. 1987. *Wind*
2 *Energy Resource Atlas of the United States*. DOE/CH 10093-4, U.S. Department of Energy.
3 Washington, D.C.

4
5 Federal Water Pollution Control Act Amendments of 1972 (FWPCA) (also known as the Clean
6 Water Act). 33 USC 1251, et seq.

7
8 Fish and Wildlife Information Exchange (FWIE). 1996. "Endangered Species Information
9 System." Virginia Polytechnic Institute and State University, Blacksburg, Virginia. Accessed on
10 the Internet, May 20, 2004 at <http://fwie.fw.vt.edu/WWW/esis/index.htm>

11
12 Floyd, K.B. 1999. "Spring Pygmy Sunfish, One of Alabama's Rare Fishes." Alabama
13 Department of Conservation and Natural Resources, District 1, Decatur, Alabama. Accessed
14 on the Internet January 20, 2004 at
15 <http://www.dcnr.state.al.us/agfd/FNASpringPygmySunfish.htm>

16
17 Foster, A.M., P. Fuller, and A. Benson. 2000. "*Corbicula fluminea* Muller 1774." U.S
18 Geographic Survey, Center for Aquatic Resource Studies, Gainesville, Florida. Accessed on
19 the Internet January 20, 2004 at http://nas.er.sugs.gov/mollusks/docs/co_flumi.html

20
21 Fuller, S.L.H. 1974. "Clams and Mussels (Mollusca: Bivalvia)." In *Pollution Ecology of*
22 *Freshwater Invertebrates*, eds., C.W. Hart, Jr., and S.L.H. Fuller, pp. 215-273, Academic Press,
23 Inc., New York.

24
25 Garner, J.T. 1997. "Mussels of Muscle Shoals." *Triannual Unionid Report*, Number 13.
26 Accessed on the Internet, March 25, 2004 at
27 <http://ellipse.inhs.uiuc.edu/FMCS/TUR/TUR13.html>

28
29 Gulf States Marine Fisheries Commission (GSMFC). 2003. "*Dreissena polymorpha*
30 (Pallas 1771)." Gulf States Marine Fisheries Commission, Ocean Springs, Mississippi.
31 Accessed on the Internet January 20, 2004 at
32 http://nis.gsmfc.org/nis_factsheet.php?toc_id=131

33
34 Hickman, G.D. 2000. Sport Fishing Index (SFI): *A Method to Quantify Sport Fishing Quality*.
35 Tennessee Valley Authority, Aquatic Biology Laboratory, Norris, Tennessee. Available on the
36 Internet under Accession No. ML041530161, dated May 27, 2004 at
37 <http://www.nrc.gov/reading-rm/adams.html>

38
39 Hopping, P.N. 2004. "Heat Rejection and Water Flows." Email of model results to C.L. Wilson
40 and A. Stegen, Tennessee Valley Authority Environmental Hydraulics, May 2004, Knoxville,

1 Tennessee. Available on the Internet under Accession No. ML041530161, dated May 27, 2004
 2 at <http://www.nrc.gov/reading-rm/adams.html>
 3
 4 Hudson, C. 1999. *The Southeastern Indians*. The University of Tennessee Press, Knoxville,
 5 Tennessee.
 6
 7 Johnson, R. and B. Wehrle. 2004. "Threatened and Endangered Species of Alabama: A
 8 Guide to Assist with Forestry Activities. Invertebrates." Private Forest Management Team,
 9 Auburn University, Auburn, Alabama. Accessed on the Internet January 20, 2004 at
 10 <http://www.pfmt.org/wildlife/endangered/invertebrates.htm>
 11
 12 Limestone County Commission (LCC). 2004. Interview with Limestone County Administrators:
 13 M. Cole, Attorney; D. Seibert, Chairman; T. Hill, Economic Development; P. Ball, Finance;
 14 E. Ezzell, Finance. March 31, 2004. Athens, Alabama.
 15
 16 Mayasich, J., C.D. Grandmaison, and C. Phillips. 2003. *Eastern Hellbender Status*
 17 *Assessment Report*. NRRI/TR-2003/09. U.S. Fish and Wildlife Service, Region 3, Fort
 18 Snelling, Minnesota.
 19
 20 Mississippi Museum of Natural Science (MMNS). 2002. "Natural Heritage Inventory: Search
 21 Animal Database." Jackson, Mississippi. Accessed on the Internet March 17, 2004 at
 22 http://www.mdwfp.com/museum/html/research/query_animals.asp?cntyID=71
 23
 24 Mississippi Natural Heritage Program (MNHP). 2002. "Endangered Species of Mississippi."
 25 Museum of Natural Science, Mississippi Department of Wildlife, Fisheries, and Parks, Jackson,
 26 Mississippi. Accessed on the Internet March 25, 2004 at [http://www.mdwfp.com/museum/html/](http://www.mdwfp.com/museum/html/heritage/tandelist.pdf)
 27 [heritage/tandelist.pdf](http://www.mdwfp.com/museum/html/heritage/tandelist.pdf)
 28
 29 Morgan County Commission (MCC). 2004. Interview with Morgan County Administrators:
 30 C. Long, Accountant; L. Bennich, Morgan County Chair; and W. Dockery, County Administrator.
 31 April 1, 2004. Decatur, Alabama.
 32
 33 National Center for Education Statistics (NCES). 2004. "Search for Public School Districts."
 34 Accessed on the Internet May 19, 2004 at <http://nces.ed.gov/ccd/districtsearch/>
 35
 36 National Environmental Policy Act of 1969 (NEPA). 42 USC 4321 et Seq.
 37
 38 National Oceanic and Atmospheric Administration (NOAA). 2004. "Storm Events for Alabama."
 39 Environmental Data Service, Asheville, North Carolina. Accessed on the Internet March 3,
 40 2004 at <http://www.ncdc.noaa.gov/oa/ncdc.html>
 41

Plant and the Environment

1 NatureServe. 2004. "NatureServe Explorer: An Online Encyclopedia of Life (Web
2 Application)."
3 Version 3.1. Arlington, Virginia. Accessed on the Internet May 26, 2004 at
4 <http://www.natureserve.org/explorer>

5
6 New York State Department of Environmental Conservation (NYSDEC). 2003. "Eastern
7 Hellbender Fact Sheet." Endangered Species Unit, Albany, New York. Accessed on the
8 Internet March 15, 2004 at
9 <http://www.dec.state.ny.us/website/dfwmr/wildlife/endspec/hellfs.html>

10
11 North Carolina Wildlife Resources Commission (NCWRC). 2004. "North Carolina Freshwater
12 Mussels – Species Information and Status." Nongame and Endangered Wildlife Program,
13 Raleigh, North Carolina. Accessed on the Internet March 26, 2004 at
14 http://www.ncwildlife.org/fs_index_07_conservation.htm

15
16 Page, L.M. and B.M. Burr. 1991. *A Field Guide to Freshwater Fishes*. Houghton Mifflin
17 Company, Boston, Massachusetts.

18
19 Pierce, B.W. 2004. Radwaste Generation from 1998 to 2003. Available on the Internet under
20 Accession No. ML041530161, dated May 27, 2004 at [http://www.nrc.gov/reading-](http://www.nrc.gov/reading-rm/adams.html)
21 [rm/adams.html](http://www.nrc.gov/reading-rm/adams.html)

22
23 Pryor, R.J. 1982. Letter from R.J. Pryor, Program Manager, Aquatic Resource Protection,
24 Fisheries and Aquatic Ecology Branch, Division of Water Resources (TVA) to J.D. Henson,
25 Supervisor, Radiological and Environmental Protection Section, Controls and Test Branch,
26 Division of Nuclear Power (TVA), Subject: "Browns Ferry Nuclear Plant (BFNP) - Proposed
27 Barge Facility." April 13, 1982. Available on the Internet under Accession No. ML041530161,
28 dated May 27, 2004 at <http://www.nrc.gov/reading-rm/adams.html>

29
30 Schulz, C. and K. Marbian. 1998. "A List of Host Species for Rare Freshwater Mussels in
31 Virginia." *Triannual Unionid* Report No. 15, July, 1998. Accessed on the Internet
32 January 19, 2004 at <http://ellipse.inhs.uiuc.edu/FMCS/TUR/TUR15.html>

33
34 Tennessee Valley Authority (TVA). 1972. *Final Environmental Statement Browns Ferry
35 Nuclear Plant Units 1, 2, and 3*. Office of Health and Environmental Science, Chattanooga,
36 Tennessee.

37
38 Tennessee Valley Authority (TVA). 1977a. *Two Techniques for Flow Routing with Applications
39 to Wheeler Reservoir*. Division of Water Management, Water Systems Development Branch,
40 Engineering Laboratory, Report No. 3-519, July 1977, Norris, Tennessee.

1 Tennessee Valley Authority (TVA). 1977b. *Water Quality and Biological Conditions in Wheeler*
2 *Reservoir During Operation of Browns Ferry Nuclear Plant January 1, 1976 to*
3 *December 31, 1976*. Division of Environmental Planning, Environmental Assessment and
4 Compliance Staff, Chattanooga, Tennessee. Available on the Internet under Accession No.
5 ML041530161, dated May 27, 2004 at <http://www.nrc.gov/reading-rm/adams.html>

6
7 Tennessee Valley Authority (TVA). 1978. *Biological Effects of Intake Browns Ferry Nuclear*
8 *Plant. Volume 4: Effects of the Browns Ferry Nuclear Plant Cooling Water Intake on the Fish*
9 *Populations of Wheeler Reservoir*. Division of Forestry, Fisheries, and Wildlife Development;
10 Fisheries and Waterfowl Resources Branch, Norris, Tennessee. Available on the Internet
11 under Accession No. ML041530161, dated May 27, 2004 at
12 <http://www.nrc.gov/readingrm/adams.html>

13
14 Tennessee Valley Authority (TVA). 1990. *Tennessee River and Reservoir System Operation*
15 *and Planning Review*. Report No. TVA/RDG/EQS-91/1, December 1990, Knoxville,
16 Tennessee.

17
18 Tennessee Valley Authority (TVA). 2000. *Browns Ferry Nuclear Plant (BFN), Units 1, 2, and 3,*
19 *Annual Radioactive Effluent Release (ARER) Report – January through December 1999.*
20 Tennessee Valley Authority, Decatur, Alabama

21
22 Tennessee Valley Authority (TVA). 2001. *Browns Ferry Nuclear Plant (BFN), Units 1, 2, and 3,*
23 *Annual Radioactive Effluent Release (ARER) Report – January through December 2000.*
24 Tennessee Valley Authority, Decatur, Alabama.

25
26 Tennessee Valley Authority (TVA). 2002a. *Final Supplemental Environmental Impact*
27 *Statement for Operating License Renewal of the Browns Ferry Nuclear Plant in Athens,*
28 *Alabama*. Tennessee Valley Authority. Chattanooga, Tennessee.

29
30 Tennessee Valley Authority (TVA). 2002b. *Browns Ferry Nuclear Plant (BFN), Units 1, 2, and*
31 *3, Update to the Annual Radiological Effluent Report (ARER) – January through December*
32 *2001*. Tennessee Valley Authority, Decatur, Alabama

33
34 Tennessee Valley Authority (TVA). 2002c. "Sport Fishing Index Ratings." Tennessee Valley
35 Authority. Accessed on the Internet January 19, 2004 at
36 <http://www.tva.gov/environment/water/sportfish.htm>

37
38 Tennessee Valley Authority (TVA). 2003a. *Applicant's Environmental Report – Operating*
39 *License Renewal Stage Browns Ferry Nuclear Plant, Units 1, 2, and 3*. License Nos. 50-259,
40 50-260, and 50-296. Tennessee Valley Authority, Knoxville, Tennessee.

Plant and the Environment

1 Tennessee Valley Authority (TVA). 2003b. *Browns Ferry Nuclear Plant (BFN), Units 1, 2, and*
2 *3, Liquid Release Update to the 2002 Annual Radioactive Effluent Release (ARER) Report.*
3 Tennessee Valley Authority, Decatur, Alabama

4
5 Tennessee Valley Authority (TVA). 2004a. *Browns Ferry Nuclear Plant (BFN), Unit 1,*
6 *Proposed Technical Specifications (TS) Change TS-431, Request for License Amendment for*
7 *Extended Power Uprate Operation, Browns Ferry Unit 1 Extended Power Uprate Environmental*
8 *Report.* Tennessee Valley Authority, Decatur, Alabama.

9
10 Tennessee Valley Authority (TVA). 2004b. *Browns Ferry Nuclear Plant (BFN), Units 2 and 3,*
11 *Proposed Technical Specifications (TS) Change TS-418, Request for License Amendment for*
12 *Extended Power Uprate Operation, Browns Ferry Units 2 and 3 Extended Power Uprate*
13 *Environmental Report.* Tennessee Valley Authority, Decatur, Alabama.

14
15 Tennessee Valley Authority (TVA). 2004c. *Browns Ferry Nuclear Plant (BFN), Units 1, 2, and*
16 *3, Annual Radioactive Effluent Release (ARER) Report, January Through December 2003.*
17 Tennessee Valley Authority, Decatur, Alabama

18
19 Tennessee Valley Authority (TVA). 2004d. Letter from C. Cooper to ADEM regarding 2003
20 Non-Radiological Emissions. Available on the Internet under Accession No. ML041530161,
21 dated May 27, 2004 at <http://www.nrc.gov/reading-rm/adams.html>

22
23 Tennessee Valley Authority (TVA). 2004e. "Wheeler Reservoir." Tennessee Valley Authority,
24 Chattanooga, Tennessee. Accessed on the Internet August 24, 2004 at
25 <http://www.tva.com/environment/ecohealth/wheeler.htm>

26
27 Tennessee Valley Authority (TVA). 2004f. *Final Environmental Impact Statement for Reservoir*
28 *Operations Study,* Tennessee Valley Authority. Chattanooga, Tennessee.

29
30 Tennessee Valley Authority (TVA). 2004g. *Browns Ferry Nuclear Plant (BFN), Units 1, 2, and*
31 *3, Annual Radiological Environmental Operating Report (AREOR), January through*
32 *December 2003.* Tennessee Valley Authority, Decatur, Alabama.

33
34 Tennessee Valley Authority (TVA). 2004h. *BFN Relicensing ER Information Needs:*
35 *Socioeconomics and Environmental Justice.* Available on the Internet under Accession
36 No. ML041530161, dated May 27, 2004 at <http://www.nrc.gov/reading-rm/adams.html>

37
38 Tennessee Valley Authority (TVA). 2004i. *Socioeconomic and Environmental Justice*
39 *Questions.* Available on the Internet under Accession No. ML041530161, dated May 27, 2004
40 at <http://www.nrc.gov/reading-rm/adams.html>

41

1 Tennessee Valley Authority (TVA). 2004j. *Cultural Resources*. Accessed on the Internet May
2 1, 2004 at [http://www.tva.com/river/landandshore/cultural resources/index.htm](http://www.tva.com/river/landandshore/cultural%20resources/index.htm)

3
4 U.S. Bureau of Labor Statistics (BLS). 2004. "Bureau of Labor Statistics Data." Accessed on
5 the Internet July 22, 2004 at <http://data.bls.gov/labjava/outside.jsp?survey=1a>

6
7 U.S. Census Bureau (USCB). 1990. "U.S. Bureau of Census, 1990 Census of Population and
8 Housing, Table DP-1." Accessed on the Internet April 19, 2004 at <http://factfinder.census.gov>

9
10 U.S. Census Bureau (USCB). 2000. "U.S. Bureau of Census, Census 2000, State and County
11 Quick Facts." Accessed on the Internet April 19, 2004 at <http://quickfacts.census.gov/qfd/>

12
13 U.S. Environmental Protection Agency (EPA). 2004. "Ecoregions of Alabama and Georgia."
14 Accessed on the Internet May 11, 2004 at
15 http://www.epa.gov/wed/pages/ecoregions/alga_eco.htm

16
17 U.S. Fish and Wildlife Service (FWS). 1976. "Endangered and Threatened Wildlife and Plants;
18 Endangered Status for 159 Taxa of Animals." *Federal Register* 41(115):24062-24067.

19
20 U.S. Fish and Wildlife Service (FWS). 1977a. "Final Threatened Status and Critical Habitat for
21 Five Species of Southeastern Fishes." *Federal Register* 42(175):45526-45530.

22
23 U.S. Fish and Wildlife Service (FWS). 1977b. "Final Correction and Augmentation of Critical
24 Habitat Reorganization." *Federal Register* 42(184):47840-47845.

25
26 U.S. Fish and Wildlife Service (FWS). 1988. "Endangered and Threatened Wildlife and Plants;
27 Endangered Status for the Alabama Cave Shrimp, *Palaemonias alabamae*." *Federal Register*
28 53(173):34696-34698.

29
30 U.S. Fish and Wildlife Service (FWS). 1990a. "Endangered and Threatened Wildlife and
31 Plants; Designation of the Freshwater Mussel, the Fanshell as an Endangered Species."
32 *Federal Register* 55(120):25591-25596.

33
34 U.S. Fish and Wildlife Service (FWS). 1990b. "Species Accounts: Alabama Cave Shrimp
35 *Palaemonias* [sic] *alabamae*." U.S. Fish and Wildlife Service, Jackson, Mississippi. Accessed
36 on the Internet May 20, 2004 at <http://endangered.fws.gov/i/k/sak07.html>

37
38 U.S. Fish and Wildlife Service (FWS). 1994. "Endangered and Threatened Wildlife and Plants;
39 Determination of Endangered Status for the Royal Snail and Anthony's Riversnail." *Federal*
40 *Register* 59:17994-17998.

Plant and the Environment

1 U.S. Fish and Wildlife Service (FWS). 1997a. *Recovery Plan for Anthony's Riversnail*.
2 U.S. Fish and Wildlife Service, Region 4 (Southeast Region), Atlanta, Georgia.

3
4 U.S. Fish and Wildlife Service (FWS). 1997b. "Endangered and Threatened Wildlife and
5 Plants; Determination of Endangered Status for the Cumberland Elktoe, Oyster Mussel,
6 Cumberlandian Combshell, Purple Bean, and Rough Rabbitsfoot." *Federal Register*
7 62(7):1647-1658.

8
9 U.S. Fish and Wildlife Service (FWS). 2000a. "Endangered and Threatened Species of
10 Mississippi (Federally Listed Species by County)." Mississippi Ecological Service's Field Office,
11 Jackson, Mississippi. Accessed on the Internet March 25, 2004 at
12 http://southeast.fws.gov/jackson/MsCo_TE.html

13
14 U.S. Fish and Wildlife Service (FWS). 2000b. "Endangered and Threatened Wildlife and
15 Plants; Endangered Status for the Armored Snail and Slender Campeloma." *Federal Register*
16 65(38):10,033-10,039.

17
18 U.S. Fish and Wildlife Service (FWS). 2001. "Endangered and Threatened Wildlife and Plants:
19 Establishment of Nonessential Experimental Population Status for 16 Freshwater Mussels and
20 1 Freshwater Snail (Anthony's Riversnail) in the Free-Flowing Reach of the Tennessee River
21 below the Wilson Dam, Colbert and Lauderdale Counties, Alabama." *Federal Register*
22 66(115):32250-32264.

23
24 U.S. Fish and Wildlife Service (FWS). 2003. *Agency Draft Recovery Plan for Cumberland*
25 *Elktoe (Alasmidonta atropurpurea), Oyster Mussel (Epioblasma capsaeformis), Cumberlandian*
26 *Combshell (Epioblasma brevidens), Purple bean (Villosa perpurpurea), and Rough Rabbitsfoot*
27 *(Quadrula cylindrica strigillata)*. Prepared by R.S. Butler and R.G. Biggins, Asheville Field
28 Office, U.S. Fish and Wildlife Service, Asheville, North Carolina for U.S. Fish and Wildlife
29 Service, Southeast Region, Atlanta, Georgia.

30
31 U.S. Fish and Wildlife Service (FWS). 2004a. "Alabama's Federally Listed Species." U.S. Fish
32 and Wildlife Service, Daphne Ecological Services Field Office, Daphne, Alabama. Accessed on
33 the Internet January 20, 2004, at <http://daphne.fws.gov/es/specieslst.htm>

34
35 U.S. Fish and Wildlife Service (FWS). 2004b. "Endangered and Threatened Wildlife and
36 Plants: Review of Species that are Candidates or Proposed for Listing as Endangered or
37 Threatened; Annual Notice of Findings on Resubmitted Petitions; Annual Description of
38 Progress on Listing Actions." *Federal Register* 69(86):24876-24904.

- 1 U.S. Fish and Wildlife Service (FWS). 2004c. "Species Profile for Anthony's Riversnail."
2 U.S. Fish and Wildlife Service, Washington, D.C. Accessed on the Internet May 24, 2004 at
3 http://ecos.fws.gov/species_profile/SpeciesProfile?spcode=GO16
4
- 5 U.S. Fish and Wildlife Service (FWS). 2004d. "U.S. Fish and Wildlife, Species Information,
6 Threatened and Endangered Animals and Plants." Accessed on the Internet May 26, 2004 at
7 <http://endangered.fws.gov/wildlife.html>
8
- 9 U.S. Fish and Wildlife Service (FWS). 2004e. "Endangered and Threatened Wildlife and
10 Plants; Designation of Critical Habitat for Five Endangered Mussels in the Tennessee and
11 Cumberland River Basins." *Federal Register* 69(168):53136-53180.
12
- 13 U.S. Fish and Wildlife Service (FWS). 2004f. "Species Profile for Pink Mucket (Pearlymussel)."
14 U.S. Fish and Wildlife Service, Washington, D.C. Accessed on the Internet May 24, 2004 at
15 http://ecos.fws.gov/species_profile/SpeciesProfile?spcode=FOOG
16
- 17 U.S. Fish and Wildlife Service (FWS). 2004g. "Species Profile for Rough Pigtoe." U.S. Fish
18 and Wildlife Service, Washington, D.C. Accessed on the Internet May 24, 2004 at
19 http://ecos.fws.gov/species_profile/SpeciesProfile?spcode=FOOP
20
- 21 U.S. Fish and Wildlife Service (FWS). 2004h. "Species Profile for Slackwater Darter."
22 U.S. Fish and Wildlife Service, Washington, D.C. Accessed on the Internet May 24, 2004 at
23 http://ecos.fws.gov/species_profile/SpeciesProfile?spcode=E01B
24
- 25 U.S. Fish and Wildlife Service (FWS). 2004i. *USFWS Southeast Region*. Accessed on the
26 Internet May 25, 2004 at <http://southeast.fws.gov>
27
- 28 U.S. National Park Service (NPS). 2004. "Outline of Prehistory and History, Southeastern
29 North America and the Caribbean." Southeast Archaeology Center. Accessed on the Internet
30 June 2, 2004 at <http://www.cr.nps.gov/seac/outline/ondex.htm>
31
- 32 U.S. Nuclear Regulatory Commission (NRC). 1998. *Browns Ferry Nuclear Plant, Units 2 and*
33 *3. Environmental Assessment and Finding of No Significant Impact*. Washington, D.C.
34
- 35 Walthall, J.A. 1980. *Prehistoric Indians of the Southeast: Archaeology of Alabama and the*
36 *Middle South*. University of Alabama Press, University of Alabama, Tuscaloosa, Alabama.
37
- 38 Yokely, P., Jr. 1998. *Mussel Study near Hobbs Island on the Tennessee River for Butler Basin*
39 *Marina*. Unpublished report prepared for MST Engineering, Decatur, Alabama. Available on
40 the Internet under Accession No. ML041530161, dated May 27, 2004 at
41 <http://www.nrc.gov/reading-rm/adams.html>

3.0 Environmental Impacts of Refurbishment

Environmental issues associated with refurbishment activities are discussed in the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437, Volumes 1 and 2 (NRC 1996, 1999).^(a) The GEIS includes a determination of whether the analysis of the environmental issues could be applied to all plants and whether additional mitigation measures would be warranted. Issues are then assigned a Category 1 or a Category 2 designation. As set forth in the GEIS, Category 1 issues are those that meet all of the following criteria:

- (1) The environmental impacts associated with the issue have been determined to apply either to all plants or, for some issues, to plants having a specific type of cooling system or other specified plant or site characteristics.
- (2) A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to the impacts (except for collective offsite radiological impacts from the fuel cycle and from high-level waste and spent fuel disposal).
- (3) Mitigation of adverse impacts associated with the issue has been considered in the analysis, and it has been determined that additional plant-specific mitigation measures are likely not to be sufficiently beneficial to warrant implementation.

For issues that meet the three Category 1 criteria, no additional plant-specific analysis is required in this supplemental environmental impact statement unless new and significant information is identified.

Category 2 issues are those that do not meet one or more of the criteria for Category 1 and therefore, additional plant-specific review of these issues is required.

License renewal actions may require refurbishment activities for the extended plant life. These actions may have an impact on the environment that requires evaluation, depending on the type of action and the plant-specific design. Environmental issues associated with refurbishment that were determined to be Category 1 issues are listed in Table 3-1.

Environmental issues related to refurbishment considered in the GEIS for which these conclusions could not be reached for all plants or for specific classes of plants, are Category 2 issues. These are listed in Table 3-2.

(a) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and its Addendum 1.

Environmental Impacts of Refurbishment

Table 3-1. Category 1 Issues for Refurbishment Evaluation

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Sections
SURFACE-WATER QUALITY, HYDROLOGY, AND USE (FOR ALL PLANTS)	
Impacts of refurbishment on surface-water quality	3.4.1
Impacts of refurbishment on surface-water use	3.4.1
AQUATIC ECOLOGY (FOR ALL PLANTS)	
Refurbishment	3.5
GROUNDWATER USE AND QUALITY	
Impacts of refurbishment on groundwater use and quality	3.4.2
LAND USE	
Onsite land use	3.2
HUMAN HEALTH	
Radiation exposures to the public during refurbishment	3.8.1
Occupational radiation exposures during refurbishment	3.8.2
SOCIOECONOMICS	
Public services: public safety, social services, and tourism and recreation	3.7.4; 3.7.4.3; 3.7.4.4; 3.7.4.6
Aesthetic impacts (refurbishment)	3.7.8

The potential environmental effects of refurbishment actions would be identified, and the analysis would be summarized within this section, if such actions were planned. The Tennessee Valley Authority (TVA) indicated that it has performed an evaluation of structures and components pursuant to Title 10 of the Code of Federal Regulations (CFR) 54.21 to identify activities that are necessary to continue operation of Browns Ferry Nuclear Plant, Units 1, 2, and 3 during the requested 20-year period of extended operation. These activities include replacement of certain components as well as new inspection activities and are described in the Environmental Report (TVA 2003).

However, TVA stated that the replacement of these components and the additional inspection activities are within the bounds of normal plant component replacement and inspections (TVA 2003). Therefore, they are not expected to affect the environment outside the bounds of plant operations as evaluated in TVA's final environmental statement (TVA 1972). In addition, TVA's evaluation of structures and components as required by 10 CFR 54.21 did not identify any major plant refurbishment activities or modifications necessary to support the continued

Table 3-2. Category 2 Issues for Refurbishment Evaluation

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Sections	10 CFR 51.53 (c)(3)(ii) Subparagraph
TERRESTRIAL RESOURCES		
Refurbishment impacts	3.6	E
THREATENED OR ENDANGERED SPECIES (FOR ALL PLANTS)		
Threatened or endangered species	3.9	E
AIR QUALITY		
Air quality during refurbishment (nonattainment and maintenance areas)	3.3	F
SOCIOECONOMICS		
Housing impacts	3.7.2	I
Public services: public utilities	3.7.4.5	I
Public services: education (refurbishment)	3.7.4.1	I
Offsite land use (refurbishment)	3.7.5	I
Public services, transportation	3.7.4.2	J
Historic and archaeological resources	3.7.7	K
ENVIRONMENTAL JUSTICE		
Environmental justice	Not addressed ^(a)	Not addressed ^(a)
(a) Guidance related to environmental justice was not in place at the time the GEIS and the associated revision to 10 CFR Part 51 were prepared. If an applicant plans to undertake refurbishment activities for license renewal, environmental justice must be addressed in the applicant's Environmental Report and the staff's environmental impact statement.		

operation of Browns Ferry Nuclear Plant, Units 1, 2, and 3 beyond the end of the existing operating licenses. Therefore, refurbishment is not considered in this supplemental environmental impact statement.

The applicant is in the process of restarting Browns Ferry Nuclear Plant, Unit 1, and used the term "refurbishment" within the Environmental Report (TVA 2003) when discussing some of the impacts of restart. The staff determined that all of the activities associated with the restart of Unit 1 can, and are, being conducted within the scope of the existing operating license as

Environmental Impacts of Refurbishment

1 reviewed previously (TVA 1972, 2002). Therefore, these activities are not considered
2 refurbishment for the purposes of license renewal, and are not being evaluated within the scope
3 of the license renewal application.
4

5 **3.1 References**

6
7 10 CFR Part 51. Code of Federal Regulations, Title 10, *Energy*, Part 51, "Environmental
8 Protection Regulations for Domestic Licensing and Related Regulatory Functions."

9
10 10 CFR Part 54. Code of Federal Regulations, Title 10, *Energy*, Part 54, "Requirements for
11 Renewal of Operating Licenses for Nuclear Power Plants."

12
13 Tennessee Valley Authority (TVA). 1972. *Final Environmental Statement, Browns Ferry
14 Nuclear Plant, Units 1, 2, and 3*. Knoxville, Tennessee.

15
16 Tennessee Valley Authority (TVA). 2002. *Final Supplemental Environmental Impact Statement
17 (SEIS) for Operating License Renewal of the Browns Ferry Nuclear Plant in Athens, Alabama*.
18 Knoxville, Tennessee.

19
20 Tennessee Valley Authority (TVA). 2003. *Applicant's Environmental Report – Operating
21 License Renewal Stage, Browns Ferry Nuclear Power Plant Units 1, 2, and 3*. Knoxville,
22 Tennessee.

23
24 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement
25 for License Renewal of Nuclear Plants*. NUREG-1437, Volumes 1 and 2, Washington, D.C.

26
27 U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement
28 for License Renewal of Nuclear Plants, Main Report*, "Section 6.3 – Transportation, Table 9.1,
29 Summary of findings on NEPA issues for license renewal of nuclear power plants, Final
30 Report." NUREG-1437, Volume 1, Addendum 1, Washington, D.C.
31

4.0 Environmental Impacts of Operation

Environmental issues associated with operation of a nuclear power plant during the license renewal term are discussed in the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437, Volumes 1 and 2 (NRC 1996, 1999)^(a). The GEIS includes a determination of whether the analysis of the environmental issues could be applied to all plants and whether additional mitigation measures would be warranted. Issues are then assigned a Category 1 or a Category 2 designation. As set forth in the GEIS, Category 1 issues are those that meet all of the following criteria:

- (1) The environmental impacts associated with the issue have been determined to apply either to all plants or, for some issues, to plants having a specific type of cooling system or other specified plant or site characteristics.
- (2) A single significance level (i.e., SMALL, MODERATE, OR LARGE) has been assigned to the impacts (except for collective offsite radiological impacts from the fuel cycle and from high-level waste and spent fuel disposal).
- (3) Mitigation of adverse impacts associated with the issue has been considered in the analysis, and it has been determined that additional plant-specific mitigation measures are likely not to be sufficiently beneficial to warrant implementation.

For issues that meet the three Category 1 criteria, no additional plant-specific analysis is required unless new and significant information is identified.

Category 2 issues are those that do not meet one or more of the criteria for Category 1, and therefore, additional plant-specific review of these issues is required.

This chapter addresses the issues related to operation during the license renewal term that are listed in Table B-1 of Title 10 of the Code of Federal Regulations (CFR) Part 51, Subpart A, Appendix B, and are applicable to the Browns Ferry Nuclear Plant, Units 1, 2, and 3 (BFN). Section 4.1 addresses issues applicable to the BFN cooling system. Section 4.2 addresses issues related to transmission lines and onsite land use. Section 4.3 addresses the radiological impacts of normal operation, and Section 4.4 addresses issues related to the socioeconomic impacts of normal operation during the license renewal term. Section 4.5 addresses issues related to groundwater use and quality, while Section 4.6 discusses the impacts of license renewal-term operations on threatened and endangered species. Section 4.7 addresses potential new information that was raised during the scoping period, and Section 4.8 discusses

(a) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and its Addendum 1.

Environmental Impacts of Operation

1 cumulative impacts. The results of the evaluation of environmental issues related to operation
2 during the license renewal term are summarized in Section 4.9. Finally, Section 4.10 lists the
3 references for Chapter 4. Category 1 and Category 2 issues that are not applicable because
4 they are related to plant design features or site characteristics not found at BFN are listed in
5 Appendix F.
6

7 **4.1 Cooling System**

8
9 Resumption of three-unit operation after restart of Unit 1 will require upgrading the cooling
10 tower system by constructing a 20-cell cooling tower on the foundation of the original cooling
11 tower number four, and increasing the water intake flow rates by approximately 11 percent
12 above those of past three-unit operation (TVA 2003b). The facility would be operated to ensure
13 that the maximum discharge water temperature and the temperature increase between the
14 intake and discharge points remain within approved regulatory limits. Use of cooling towers
15 would increase, and on rare occasions when the cooling towers are unable to meet thermal
16 limits, the facility would be derated to remain in compliance. Although significant impacts are
17 not anticipated, Tennessee Valley Authority (TVA) will also confirm expected levels of
18 impingement and entrainment resulting from increased intake water flow rates by monitoring
19 during current two-unit operation and following resumption of three-unit operations
20 (TVA 2003b).
21

22 Category 1 issues in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, which are applicable
23 to cooling system operation for BFN during the license renewal term, are listed in Table 4-1
24 (NRC 1996). TVA stated in its environmental report (ER) that no new information existed for
25 the issues that would invalidate the GEIS conclusions (TVA 2003b). Additionally, the staff has
26 not identified any new and significant information during its independent review of the ER
27 (TVA 2003b), the staff's site visit, the scoping process, or its evaluation of other available infor-
28 mation, such as operation at a combined total power level of 11,856 megawatts-
29 thermal (MW[t]). Therefore, the staff concludes that there are no impacts related to these
30 issues beyond those discussed in the GEIS. For all of the issues, the staff concluded in the
31 GEIS that the impacts are SMALL, and additional plant-specific mitigation measures are not
32 likely to be sufficiently beneficial to be warranted.

Table 4-1. Category 1 Issues Applicable to the Operation of the Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 Cooling System During the License Renewal Term

ISSUE 10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Sections
SURFACE WATER QUALITY, HYDROLOGY, AND USE (FOR ALL PLANTS)	
Altered current patterns at intake and discharge structures	4.2.1.2.1; 4.3.2.2; 4.4.2
Altered thermal stratification of lakes	4.2.1.2.3; 4.4.4.2
Temperature effects on sediment transport capacity	4.2.1.2.3; 4.4.2.2
Scouring caused by discharged cooling water	4.2.1.2.3; 4.4.2.2
Eutrophication	4.2.1.2.3; 4.4.2.2
Discharge of chlorine or other biocides	4.2.1.2.4; 4.4.2.2
Discharge of sanitary wastes and minor chemical spills	4.2.1.2.4; 4.4.2.2
Discharge of other metals in wastewater	4.2.1.2.4; 4.3.2.2; 4.4.2.2
Water use conflicts (plants with once-through cooling systems)	4.2.1.3
AQUATIC ECOLOGY (FOR ALL PLANTS)	
Accumulation of contaminants in sediments or biota	4.2.1.2.4; 4.3.3; 4.4.3; 4.4.2.2
Entrainment of phytoplankton and zooplankton	4.2.2.1.1; 4.3.3; 4.4.3
Cold shock	4.2.2.1.5; 4.3.3; 4.4.3
Thermal plume barrier to migrating fish	4.2.2.1.6; 4.4.3
Distribution of aquatic organisms	4.2.2.1.6; 4.4.3
Premature emergence of aquatic insects	4.2.2.1.7; 4.4.3
Gas supersaturation (gas bubble disease)	4.2.2.1.8; 4.4.3
Low dissolved oxygen in the discharge	4.2.2.1.9; 4.3.3; 4.4.3
Losses from predation, parasitism, and disease among organisms exposed to sublethal stresses	4.2.2.1.10; 4.4.3
Stimulation of nuisance organisms	4.2.2.1.11; 4.4.3

Environmental Impacts of Operation

Table 4-1.(contd)

ISSUE 10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Sections
Terrestrial Resources	
Cooling tower impacts on crops and ornamental vegetation	4.3.4
Cooling tower impacts on native plants	4.3.5.1
Bird collisions with cooling towers	4.3.5.2
Human Health	
Microbiological organisms (occupational health)	4.3.6
Noise	4.3.7

A brief description of the staff's review and the GEIS conclusions, as codified in Table B-1, for each of these issues follows:

- Altered current patterns at intake and discharge structures. Based on information in the GEIS, the Commission found that

Altered current patterns have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.

The staff has not identified any new and significant information during its independent review of the TVA ER, the scoping process, the staff's site visit, and the staff's evaluation of other available information, such as operation at a combined total power level of 11,856 MW(t). Therefore, the staff concludes that there are no impacts of altered current patterns during the license renewal term beyond those discussed in the GEIS.

- Altered thermal stratification of lakes. Based on information in the GEIS, the Commission found that

These effects have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.

The staff has not identified any new and significant information during its independent review of the TVA ER, the scoping process, the staff's site visit, and the staff's evaluation of other available information, such as operation at a combined total power level of 11,856 MW(t). Therefore, the staff concludes that there are no impacts of altered thermal stratification of lakes beyond those discussed in the GEIS.

- 1 • Temperature effects on sediment transport capacity. Based on information in the GEIS,
2 the Commission found that

3
4 These effects have not been found to be a problem at operating nuclear power
5 plants and are not expected to be a problem during the license renewal term.
6

7 The staff has not identified any new and significant information during its independent review of
8 the TVA ER, the scoping process, the staff's site visit, and the staff's evaluation of other
9 available information, such as operation at a combined total power level of 11,856 MW(t).
10 Therefore, the staff concludes that there are no impacts of temperature on sediment transport
11 capacity during the license renewal term beyond those discussed in the GEIS.
12

- 13 • Scouring caused by discharged cooling water. Based on information in the GEIS, the
14 Commission found that

15
16 Scouring has not been found to be a problem at most operating nuclear power
17 plants and has caused only localized effects at a few plants. It is not expected to
18 be a problem during the license renewal term.
19

20 The staff has not identified any new and significant information during its independent review of
21 the TVA ER, the scoping process, the staff's site visit, and the staff's evaluation of other
22 available information, such as operation at a combined total power level of 11,856 MW(t).
23 Therefore, the staff concludes that there are no impacts of scouring during the license renewal
24 term beyond those discussed in the GEIS.
25

- 26 • Eutrophication. Based on information in the GEIS, the Commission found that

27
28 Eutrophication has not been found to be a problem at operating nuclear power
29 plants and is not expected to be a problem during the license renewal term.
30

31 The staff has not identified any new and significant information during its independent review of
32 the TVA ER, the scoping process, the staff's site visit, and the staff's evaluation of other
33 available information, such as operation at a combined total power level of 11,856 MW(t).
34 Therefore, the staff concludes that there are no impacts of eutrophication during the license
35 renewal term beyond those discussed in the GEIS.
36

Environmental Impacts of Operation

- 1 • Discharge of chlorine or other biocides. Based on information in the GEIS, the
2 Commission found that

3
4 Effects are not a concern among regulatory and resource agencies and are not
5 expected to be a problem during the license renewal term.
6

7 The staff has not identified any new and significant information during its independent review of
8 the TVA ER, the staff's site visit, the scoping process, its evaluation of other available informa-
9 tion, such as the National Pollutant Discharge Elimination System (NPDES) permit for BFN,
10 Discharge Monitoring Reports (DMRs), discussion with the NPDES compliance office, and
11 operation at a combined total power level of 11,856 MW(t). Therefore, the staff concludes that
12 there are no impacts of discharge of chlorine or other biocides during the license renewal term
13 beyond those discussed in the GEIS.

- 14
15 • Discharge of sanitary wastes and minor chemical spills. Based on information in the
16 GEIS, the Commission found that

17
18 Effects are readily controlled through NPDES permit and periodic modifications,
19 and are not expected to be a problem during the license renewal term.
20

21 The staff has not identified any new and significant information during its independent review of
22 the TVA ER, the staff's site visit, the scoping process, its evaluation of other available informa-
23 tion, including the NPDES permit for BFN, DMRs, discussion with the NPDES compliance
24 office, and operation at a combined total power level of 11,856 MW(t). Therefore, the staff
25 concludes that there are no impacts of discharges of sanitary wastes and minor chemical spills
26 during the license renewal term beyond those discussed in the GEIS.
27

- 28 • Discharge of other metals in wastewater. Based on information in the GEIS, the
29 Commission found that

30
31 These discharges have not been found to be a problem at operating nuclear
32 power plants with cooling-tower-based heat dissipation systems and have been
33 satisfactorily mitigated at other plants. They are not expected to be a problem
34 during the license renewal term.
35

36 The staff has not identified any new and significant information during its independent review of
37 the TVA ER, the staff's site visit, the scoping process, its evaluation of other available informa-
38 tion, such as the NPDES permit for BFN, DMRs, discussion with the NPDES compliance office,
39 and operation at a combined total power level of 11,856 MW(t). Therefore, the staff concludes
40 that there are no impacts of discharges of other metals in waste water during the license
41 renewal term beyond those discussed in the GEIS.

- 1 • Water-use conflicts (plants with once-through cooling systems). Based on information
2 in the GEIS, the Commission found that

3
4 These conflicts have not been found to be a problem at operating nuclear power
5 plants with once-through heat dissipation systems.
6

7 The staff has not identified any new and significant information during its independent review of
8 the TVA ER, the scoping process, the staff's site visit, and the staff's evaluation of other avail-
9 able information, such as operation at a combined total power level of 11,856 MW(t).
10 Therefore, the staff concludes that there are no water-use conflicts during the license renewal
11 term beyond those discussed in the GEIS.
12

- 13 • Accumulation of contaminants in sediments or biota. Based on information in the GEIS,
14 the Commission found that

15
16 Accumulation of contaminants has been a concern at a few nuclear power plants
17 but has been satisfactorily mitigated by replacing copper alloy condenser tubes
18 with those of another metal. It is not expected to be a problem during the license
19 renewal term.
20

21 The staff has not identified any new and significant information during its independent review of
22 the TVA ER, the scoping process, the staff's site visit, and the staff's evaluation of other avail-
23 able information, such as operation at a combined total power level of 11,856 MW(t).
24 Therefore, the staff concludes that there are no impacts of accumulation of contaminants in
25 sediments or biota during the license renewal term beyond those discussed in the GEIS.
26

- 27 • Entrainment of phytoplankton and zooplankton. Based on information in the GEIS, the
28 Commission found that

29
30 Entrainment of phytoplankton and zooplankton has not been found to be a
31 problem at operating nuclear power plants and is not expected to be a problem
32 during the license renewal term.
33

34 The staff has not identified any new and significant information during its independent review of
35 the TVA ER, the staff's site visit, the scoping process, its review of monitoring programs, or its
36 evaluation of other available information, such as operation at a combined total power level of
37 11,856 MW(t). Therefore, the staff concludes that there are no impacts of entrainment of
38 phytoplankton and zooplankton during the license renewal term beyond those discussed in the
39 GEIS.
40

Environmental Impacts of Operation

- 1 • Cold shock. Based on information in the GEIS, the Commission found that

2
3 Cold shock has been satisfactorily mitigated at operating nuclear plants with
4 once-through cooling systems, has not endangered fish populations or been
5 found to be a problem at operating nuclear power plants with cooling towers or
6 cooling ponds, and is not expected to be a problem during the license renewal
7 term.

8
9 The staff has not identified any new and significant information during its independent review of
10 the TVA ER, the scoping process, the staff's site visit, and the staff's evaluation of other avail-
11 able information, such as operation at a combined total power level of 11,856 MW(t).
12 Therefore, the staff concludes that there are no impacts of cold shock during the license
13 renewal term beyond those discussed in the GEIS.

- 14
15 • Thermal plume barrier to migrating fish. Based on information in the GEIS, the
16 Commission found that

17
18 Thermal plumes have not been found to be a problem at operating nuclear
19 power plants and are not expected to be a problem during the license renewal
20 term.

21
22 The staff has not identified any new and significant information during its independent review of
23 the TVA ER, the scoping process, the staff's site visit, and the staff's evaluation of other avail-
24 able information, such as operation at a combined total power level of 11,856 MW(t).
25 Therefore, the staff concludes that there are no impacts of thermal plumes to migrating fish
26 during the license renewal term beyond those discussed in the GEIS.

- 27
28 • Distribution of aquatic organisms. Based on information in the GEIS, the Commission
29 found that

30
31 Thermal discharge may have localized effects but is not expected to effect the
32 larger geographical distribution of aquatic organisms.

33
34 The staff has not identified any new and significant information during its independent review of
35 the TVA ER, the staff's site visit, the scoping process, its review of monitoring programs, or its
36 evaluation of other available information, such as operation at a combined total power level of
37 11,856 MW(t). Therefore, the staff concludes that there are no impacts on the distribution of
38 aquatic organisms during the license renewal term beyond those discussed in the GEIS.

- 1 • Premature emergence of aquatic insects. Based on information in the GEIS, the
2 Commission found that

3
4 Premature emergence has been found to be a localized effect at some operating
5 nuclear power plants but has not been a problem and is not expected to be a
6 problem during the license renewal term.
7

8 The staff has not identified any new and significant information during its independent review of
9 the TVA ER, the staff's site visit, the scoping process, or its evaluation of other available
10 information, such as operation at a combined total power level of 11,856 MW(t). Therefore, the
11 staff concludes that there are no impacts of premature emergence during the license renewal
12 term beyond those discussed in the GEIS.
13

- 14 • Gas supersaturation (gas bubble disease). Based on information in the GEIS, the
15 Commission found that

16
17 Gas supersaturation was a concern at a small number of operating nuclear
18 power plants with once-through cooling systems but has been satisfactorily
19 mitigated. It has not been found to be a problem at operating nuclear power
20 plants with cooling towers or cooling ponds and is not expected to be a problem
21 during the license renewal term.
22

23 The staff has not identified any new and significant information during its independent review of
24 the TVA ER, the scoping process, the staff's site visit, and the staff's evaluation of other avail-
25 able information, such as operation at a combined total power level of 11,856 MW(t).
26 Therefore, the staff concludes that there are no impacts of gas supersaturation during the
27 license renewal term beyond those discussed in the GEIS.
28

- 29 • Low dissolved oxygen in the discharge. Based on information in the GEIS, the
30 Commission found that

31
32 Low dissolved oxygen has been a concern at one nuclear power plant with a
33 once-through cooling system but has been effectively mitigated. It has not been
34 found to be a problem at operating nuclear power plants with cooling towers or
35 cooling ponds and is not expected to be a problem during the license renewal
36 term.
37

38 The staff has not identified any new and significant information during its independent review of
39 the TVA ER, the staff's site visit, the scoping process, its review of monitoring programs, or its
40 evaluation of other available information, such as operation at a combined total power level of

Environmental Impacts of Operation

1 11,856 MW(t). Therefore, the staff concludes that there are no impacts of low dissolved
2 oxygen during the license renewal term beyond those discussed in the GEIS.

- 3
4 • Losses from predation, parasitism, and disease among organisms exposed to sublethal
5 stresses. Based on information in the GEIS, the Commission found that

6
7 These types of losses have not been found to be a problem at operating nuclear
8 power plants and are not expected to be a problem during the license renewal
9 term.

10
11 The staff has not identified any new and significant information during its independent review of
12 the TVA ER, the scoping process, the staff's site visit, and the staff's evaluation of other avail-
13 able information, such as operation at a combined total power level of 11,856 MW(t).

14 Therefore, the staff concludes that there are no impacts of losses from predation, parasitism,
15 and disease among organisms exposed to sublethal stresses during the license renewal term
16 beyond those discussed in the GEIS.

- 17
18 • Stimulation of nuisance organisms. Based on information in the GEIS, the Commission
19 found that

20
21 Stimulation of nuisance organisms has been satisfactorily mitigated at the single
22 nuclear power plant with a once-through cooling system where previously it was
23 a problem. It has not been found to be a problem at operating nuclear power
24 plants with cooling towers or cooling ponds and is not expected to be a problem
25 during the license renewal term.

26
27 The staff has not identified any new and significant information during its independent review of
28 the TVA ER, the scoping process, the staff's site visit, and the staff's evaluation of other avail-
29 able information, such as operation at a combined total power level of 11,856 MW(t).

30 Therefore, the staff concludes that there are no impacts of stimulation of nuisance organisms
31 during the license renewal term beyond those discussed in the GEIS.

- 32
33 • Cooling tower impacts on crops and ornamental vegetation. Based on information in the
34 GEIS, the Commission found that

35
36 Impacts from salt drift, icing, fogging, or increased humidity associated with
37 cooling tower operation have not been found to be a problem at operating
38 nuclear power plants and are not expected to be a problem during the renewal
39 term.

40
41 The staff has not identified any new and significant information during its independent review of
42 the TVA ER, the staff's site visit, the scoping process, or its evaluation of other available

1 information, such as operation at a combined total power level of 11,856 MW(t). Therefore, the
2 staff concludes that there are no cooling tower impacts on crops and ornamental vegetation
3 during the license renewal term beyond those discussed in the GEIS.

- 4
5 • Cooling tower impacts on native plants. Based on information in the GEIS, the
6 Commission found that

7
8 Impacts from salt drift, icing, fogging, or increased humidity associated with
9 cooling tower operation have not been found to be a problem at operating
10 nuclear power plants and are not expected to be a problem during the license
11 renewal term.

12
13 The staff has not identified any new and significant information during its independent review of
14 the TVA ER, the staff's site visit, the scoping process, or its evaluation of other available
15 information, such as operation at a combined total power level of 11,856 MW(t). Therefore, the
16 staff concludes that there are no cooling tower impacts on native plants during the license
17 renewal term beyond those discussed in the GEIS.

- 18
19 • Bird collisions with cooling towers. Based on information in the GEIS, the Commission
20 found that

21
22 These collisions have not been found to be a problem at operating nuclear power
23 plants and are not expected to be a problem during the license renewal term.

24
25 The staff has not identified any new and significant information during its independent review of
26 the TVA ER, the staff's site visit, the scoping process, or its evaluation of other available
27 information, such as operation at a combined total power level of 11,856 MW(t). Therefore, the
28 staff concludes that there are no impacts of bird collisions with cooling towers during the license
29 renewal term beyond those discussed in the GEIS.

- 30
31 • Microbiological organisms (occupational health). Based on information in the GEIS, the
32 Commission found that

33
34 Occupational health impacts are expected to be controlled by continued
35 application of accepted industrial hygiene practices to minimize worker
36 exposures.

37
38 The staff has not identified any new and significant information during its independent review of
39 the TVA ER, the staff's site visit, the scoping process, or its evaluation of other available
40 information, such as operation at a combined total power level of 11,856 MW(t). Therefore, the

Environmental Impacts of Operation

1 staff concludes that there are no impacts of microbiological organisms on occupational health
 2 during the license renewal term beyond those discussed in the GEIS.

- 3
- 4 • Noise. Based on information in the GEIS, the Commission found that

5
 6 Noise has not been found to be a problem at operating plants and is not
 7 expected to be a problem at any plant during the license renewal term.

8
 9 The staff has not identified any new and significant information during its independent review of
 10 the TVA ER, the scoping process, the staff's site visit, and the staff's evaluation of other avail-
 11 able information, such as operation at a combined total power level of 11,856 MW(t).
 12 Therefore, the staff concludes that there are no impacts of noise during the license renewal
 13 term beyond those discussed in the GEIS.

14
 15 The Category 2 issues related to cooling system operation during the license renewal term that
 16 are applicable to BFN are listed in Table 4-2 and discussed in Sections 4.1.1, through 4.1.5.

17
 18 **Table 4-2. Category 2 Issues Applicable to the Operation of the Browns Ferry Nuclear Power**
 19 **Plant, Units 1, 2, and 3 Cooling System During the License Renewal Term**
 20

ISSUE 10 CFR Part 51, Subpart A, Appendix B, Table B	GEIS Sections	10 CFR 51.53(c)(3)(II) Subparagraph	SEIS Section
WATER USE			
(FOR PLANTS WITH ONCE-THROUGH AND COOLING POND HEAT-DISSIPATION SYSTEMS)			
Water use conflicts (plants with cooling ponds or cooling towers using make-up water from a small river with low flow)	4.3.2.1; 4.4.2.1	B	4.1.1
AQUATIC ECOLOGY			
Entrainment of fish and shellfish in early life stages	4.2.2.1.2; 4.4.3	B	4.1.2
Impingement of fish and shellfish	4.2.2.1.3; 4.3.3; 4.4.3	B	4.1.3
Heat shock	4.2.2.1.4; 4.4.3	B	4.1.4
HUMAN HEALTH			
Microbiological organisms (public health)(plants using lakes or canals, or cooling towers or cooling ponds that discharge into a small river)	4.3.6	G	4.1.5

4.1.1 Water-Use Conflicts (Make-up Water from a Small River)

The Tennessee River average annual flow at BFN for 1976 through 2002 was 4.16×10^{10} m³/yr (1.47×10^{12} ft³/yr). This annual flow is less than the 9×10^{10} m³/yr (3.15×10^{12} ft³/yr) criterion stated by the Nuclear Regulatory Commission (NRC) in 10 CFR 51.53(c)(3)(ii)(A) as the value below which "an assessment of the impact of the proposed action on the flow of the river and related impacts on instream and riparian ecological communities must be provided" (NRC 1996).

NRC made water use and water availability issues a Category 2 issue because two factors may cause them to become important for some nuclear power plants that use cooling towers (NRC 1996). First, the relatively small rates of cooling water withdrawal and discharge allows some power plants with cooling towers to be located on small bodies of water that are susceptible to droughts or competing water uses. Second, closed-cycle cooling systems evaporate cooling water, and this consumptive water loss may represent a substantial proportion of the flow in small rivers. Loss of a substantial portion of flow from a small stream as a result of evaporative losses from a cooling tower will reduce the amount of habitat for fish and aquatic invertebrates. Off-stream water uses, such as power plant consumption, must be regulated to ensure that important in-stream uses, such as habitat for aquatic organisms, boating, sport fishing, and waste assimilation, are not compromised.

BFN normally operates in open mode using once-through cooling. Modeling (TVA 2003b) predicts that, on average, BFN will operate in the open mode 93 percent of the time. Cooling towers are not used during open mode operations and consumptive water use is reduced.

For three units operating at a combined total power level of 11,856 MW(t), modeling shows the cooling towers would only be used on average 7 percent of the time in what is called "helper mode" (TVA 2003b). During these times, the total BFN intake water flow for three-unit operation of 12 million m³/d (3171 MGD) or 139 m³/s (4907 cfs) can be a significant fraction of the river flow past the plant (7Q10 of 250 m³/s or 8700 cfs in NPDES permit rationale). However, even when operating in helper mode, consumptive water use is negligible and is expected to remain so throughout the license renewal term.

Cooling tower consumptive water use is not expected to exceed 2.3 m³/s (82 cfs) (Hopping 2004), which is less than one percent of the 7Q10. For a two-unit operation cooling tower use is even less frequent with modeling predicting tower use, on average, only 5 percent of the time (TVA 2003b).

Consumptive and off-stream water use has not resulted in significant use conflicts due to the large volume of reservoir water available, the high river flow rate, and the return of most of the water withdrawn (TVA 2003b). Regulatory control of withdrawal rates and NPDES permit limits

Environmental Impacts of Operation

1 for return water quality also mitigate potential conflicts. Potential trade-offs can occur with
2 instream water uses (e.g., in-stream use conflicts among aquatic life, waste assimilation,
3 navigation, power generation, flood control, and lake levels). These potential conflicts are
4 addressed by historic operating procedures, legal requirements, and regulatory procedures.
5

6 The staff independently reviewed the TVA ER and visited the site. The staff determined that
7 water-use conflicts would be SMALL and could be mitigated by derating the plant.
8

9 4.1.2 Entrainment of Fish and Shellfish in Early Life Stages

10
11 For power plants with once-through cooling systems, entrainment of fish and shellfish in early
12 life stages into cooling water systems is considered a Category 2 issue, requiring a site-specific
13 assessment before license renewal. To perform this evaluation, the staff reviewed the TVA ER
14 and other TVA environmentally related documents, visited the BFN site, and reviewed the appli-
15 cant's State of Alabama NPDES Permit AL0022080, which was issued on December 29, 2000,
16 became effective on February 1, 2001, and will remain in force until January 31, 2006
17 (ADEM 2000).
18

19 Section 316(b) of the Federal Water Pollution Control Act of 1972 (FWPCA) (also referred to
20 as the Clean Water Act) requires that the location, design, construction, and capacity of cooling
21 water intake structures reflect the best technology available for minimizing adverse
22 environmental impacts. Entrainment of fish and shellfish into the cooling water system is a
23 potential adverse environmental impact that can be minimized by use of the best available
24 technology.
25

26 On July 9, 2004, the U.S. Environmental Protection Agency (EPA) published a final rule in the
27 *Federal Register* (69 FR 41575) (EPA 2004) addressing cooling water intake structures at
28 existing power plants where flow levels exceed a minimum threshold value of 190,000 m³/d
29 (50 MGD). The rule is Phase II in EPA's development of 316(b) regulations that establish
30 national requirements applicable to the location, design, construction, and capacity of cooling
31 water intake structures at existing facilities that exceed the threshold value for water
32 withdrawals. The national requirements, which are implemented through NPDES permits,
33 minimize the adverse environmental impacts associated with the continued use of the intake
34 systems. Licensees are required to demonstrate compliance with the Phase II performance
35 standards at the time of renewal of their NPDES permit. Licensees may be required as part of
36 the NPDES renewal to alter the intake structure, redesign the cooling system, modify station
37 operation, or take other mitigative measures as a result of this regulation. The new
38 performance standards are designed to significantly reduce entrainment losses due to plant
39 operation. Any required site-specific mitigation would result in less impact from entrainment
40 during the license renewal period.
41
42

1 For all three units operating at a combined total power level of 11,856 MW(t), the total BFN
 2 intake water flow would be 139 m³/s (2.2 million gpm), which can be a significant fraction of the
 3 river flow past the plant, especially during the lowest average flow for 7 consecutive days that
 4 can have a recurrence of 10 years (7Q10 low-flow value), of 246 m³/s (3.9 million gpm)
 5 (Section 2.2.2). This intake flow represents an 11 percent increase over the original
 6 100 percent power load of 124.9 m³/s (1.98 million gpm) (Buchanan 1980).

7
 8 The critical time of year for approaching the maximum river water temperature limits specified in
 9 the BFN NPDES Permit (ADEM 2000), and therefore requiring the use of cooling towers or
 10 plant de-rates, is July and August. The average flow in Wheeler Reservoir at BFN during these
 11 months is 965 m³/s (15.3 million gpm) during July and August (TVA 2003b). During these same
 12 months the daily average flow exceeds the 7Q10 low-flow value 98.6 percent of the time in July
 13 and 98.8 percent of the time in August.

14
 15 Characterization of the ichthyoplankton of Wheeler Reservoir was initiated prior to startup of
 16 BFN, and continued during the initial years of operations (1974 through 1979). From 80 to
 17 98 percent of the larval fish populations were composed of clupeids (e.g., threadfin shad
 18 [*Dorosoma petenense*] and gizzard shad [*D. cepedianum*]). Fish larvae entrainment during the
 19 initial 6 years of operation ranged from 1.0 to 9.0 percent of the total number of larval fish in the
 20 reservoir passing by the plant (Table 4-3). During this same period, the mean hydraulic
 21 entrainment (portion of the river flow passing through the plant) varied from 3.0 to 13.3 percent
 22 (TVA 1978a; Buchanan 1980). During all years, percent entrainment of larval fish was less
 23 than hydraulic entrainment (Table 4-3). In addition to shad, other fish comprising greater than
 24

25 **Table 4-3. Calculated Entrainment of Fish Eggs and Larvae at Browns Ferry Nuclear Power**
 26 **Plant, Units 1, 2, and 3 – 1974 to 1979**

28	Year	Fish Egg Entrainment Percent (Number)	Larval Fish Entrainment Percent (Number)	Percent Mean Hydraulic Entrainment
29	1974	13.3 (459 million)	1.0 (125 million)	3.0
30	1975	1.3 (50 million)	3.3 (770 million)	4.4
31	1976	3.8 (143 million)	6.3 (1.3 billion)	8.4
32	1977	2.7 (149 million)	9.0 (3.7 billion)	12.0
33	1978	3.6 (50 million)	5.4 (2.92 billion)	13.3
34	1979	8.1 (188 million)	4.5 (1.34 billion)	9.0

35 Sources: Buchanan 1980; TVA 1978a.

Environmental Impacts of Operation

1 1 percent of the total number of entrained larvae included suckers, minnows, freshwater drum
2 (*Aplodinotus grunniens*), and white and yellow basses (*Morone chrysops* and
3 *M. mississippiensis*) (TVA 1978a). The three fish families with the highest estimated
4 entrainment (i.e., percent loss of larvae passing BFN) during three-unit operation at BFN in
5 1977 were Clupeidae (12.1 percent), Catostomidae (4.5 percent), and Sciaenidae (6.1 percent)
6 (TVA 2002).

7
8 Taxa that exhibited increases in larval entrainment percentage over the period of study
9 (1974 through 1977, which coincided with an increase from one- to three-unit operation)
10 included those known to be widely distributed in the water column and essentially planktonic
11 (e.g., Clupeidae, Moronidae, Cyprinidae, and Percidae). Those not exhibiting this trend
12 included fishes that have nest-inhabiting or parental-care characteristics in early life (e.g.,
13 Ictaluridae and Centrarchidae) and are thus unlikely to be as planktonic or uniformly distributed
14 in the water column (TVA 1978a). Fish entrainment was generally lower than hydraulic
15 entrainment (the amount of river flow that passes through the plant) because fish larvae are not
16 truly planktonic except at very early stages (TVA 1978a).

17
18 Fish egg entrainment during the initial six years of operation ranged from 1.3 to 13.3 percent of
19 the total number of eggs in the reservoir passing by the plant. During 1974, the percent egg
20 entrainment was much higher than hydraulic entrainment. During 1979, the percent egg
21 entrainment was similar to hydraulic entrainment, and from 1975 through 1978, percent egg
22 entrainment was much lower than hydraulic entrainment (Table 4-3). The only two commonly
23 occurring species in Wheeler Reservoir that have buoyant or semibuoyant eggs are freshwater
24 drum and mooneye (*Hiodon tergisus*), although the skipjack herring (*Alosa chrysochloris*) may
25 also have buoyant eggs (TVA 1972). It was speculated that conditions were favorable in 1974
26 for spawning freshwater drum to be attracted to or near the plant intake resulting in the release
27 of large numbers of eggs into the cooling water source (TVA 1978a). A similar speculation
28 accounts for the large percentage of catfish larvae that were entrained in 1975 (TVA 1978a).

29
30 Under the original operating mode of 100 percent power load, entrained organisms were
31 subject to a 13.9°C (25°F) temperature rise (TVA 2003b). Under 120 percent power load this
32 increase in temperature could be as high as 15.9°C (28.7°F) (Hopping 2004). Total duration of
33 cooling system passage is estimated at 7 to 11 minutes, with 5 to 9 minutes spent in heated
34 waters (TVA 2003b). When discharge temperatures do not exceed 37.8°C (100°F), some
35 entrainment survival would be expected (LaJeone and Monzingo 2000). Under a very
36 conservative scenario, total mortality of all entrained ichthyoplankton occurs. Three-unit
37 operation at 120 percent power load would increase intake flow rates by approximately
38 11 percent (TVA 2003b). Therefore, the amount of entrainment would be expected to increase,
39 but the percent increase would be expected to be lower than the hydraulic entrainment
40 increase.

1 Flow studies conducted at BFN have indicated that the majority of the water hydraulically
2 entrained by the plant comes from the right side of the main river channel. This pelagic area
3 contains significantly lower densities of drifting fish larvae than found in the overbank areas.
4 Higher densities of fish eggs (mostly freshwater drum) are transported in the channel portion of
5 the river, but entrainment of freshwater drum eggs and larvae have not resulted in noticeable
6 decreases in abundance of this species, nor is it expected under return to three-unit operation
7 at increased operational rates (TVA 2003b). There are no specific or unique spawning or
8 nursery areas or migration routes for any fish species located upstream of BFN that would
9 make eggs or larvae of these species unusually susceptible to entrainment (TVA 2003b). No
10 obvious declines in these fish species have been noticed based on collection of adults in
11 Wheeler Reservoir (TVA 2003b). Because ichthyoplankton in Wheeler Reservoir are produced
12 upstream and downstream of BFN, it was concluded that entrainment would not add
13 significantly to expected natural mortality of fish eggs and larvae in the reservoir
14 (Buchanan 1980).

15
16 The staff reviewed the available information in the TVA ER (TVA 2003b) and in other BFN
17 documents related to the FWPCA 316(b) permitting process. Based on the results of past
18 entrainment studies and the operating history of BFN intake structure, the staff concludes that
19 the potential impacts of entrainment of fish and shellfish in the early life stages into the cooling
20 water intake system are SMALL, and further mitigation measures should not be warranted.
21 Nevertheless, TVA will evaluate levels of entrainment by monitoring under current two-unit
22 operation and following the return of three-unit operation. Analysis of current and future
23 entrainment data collected at BFN will use modeling techniques designed to extrapolate from
24 the lost production of eggs and larvae of forage species (e.g., clupeids) to more effectively
25 assess overall potential entrainment impacts (TVA 2003b). TVA's Vital Signs Monitoring
26 Program would also continue to assess aquatic communities in Wheeler Reservoir. If it is
27 determined that increased entrainment is resulting in unacceptable environmental impacts, TVA
28 would assess technologies, operational measures, and restoration measures that could be
29 undertaken to remedy the impacts, and institute appropriate mitigation measures in consultation
30 with appropriate Federal and State of Alabama agencies (TVA 2003b).

31 32 **4.1.3 Impingement of Fish and Shellfish**

33
34 For plants with once-through cooling systems, impingement of fish and shellfish on debris
35 screens of cooling water system intakes is considered a Category 2 issue, which requires a
36 site-specific assessment before license renewal. To perform this evaluation, the staff reviewed
37 the TVA ER and other TVA environmentally related documents, visited the BFN site, and
38 reviewed the applicant's State of Alabama NPDES Permit AL0022080, issued on
39 December 29, 2000, which became effective on February 1, 2001, and will remain in force until
40 January 31, 2006 (ADEM 2000).

Environmental Impacts of Operation

1 Section 316(b) of the FWPCA requires the location, design, construction, and capacity of
2 cooling-water intake structures reflect the best technology available for minimizing adverse
3 environmental impacts. Impingement of fish and shellfish on the debris screens of the cooling
4 water intake system is a potential adverse environmental impact that can be minimized by use
5 of the best available technology.
6

7 On July 9, 2004, EPA published a final rule in the *Federal Register* (69 FR 41575) (EPA 2004)
8 addressing cooling water intake structures at existing power plants whose flow levels exceed a
9 minimum threshold value of 190,000 m³/d (50 MGD). The rule is Phase II in EPA's
10 development of 316(b) regulations that establish national requirements applicable to the
11 location, design, construction, and capacity of cooling water intake structures at existing
12 facilities that exceed the threshold value for water withdrawals. The national requirements,
13 which are implemented through NPDES permits, minimize the adverse environmental impacts
14 associated with the continued use of the intake systems. Licensees are required to
15 demonstrate compliance with the Phase II performance standards at the time of renewal of their
16 NPDES permit. Licensees may be required as part of the NPDES renewal to alter the intake
17 structure, redesign the cooling system, modify station operation, or take other mitigative
18 measures as a result of this regulation. The new performance standards are designed to
19 significantly reduce impingement losses due to plant operation. Any required site-specific
20 mitigation would result in less impact from impingement during the license renewal period.
21

22 During the initial years of plant operation (1974 through 1977), 72 species of fish were collected
23 in impingement samples (TVA 1978a). Four species comprised 95.8 percent of the impinged
24 fish: threadfin shad (76.5 percent), gizzard shad (12.3 percent), freshwater drum (4.3 percent),
25 and skipjack herring (2.7 percent). Each of the remaining 68 species comprised less than
26 1.0 percent of the total fish impinged; many less than 0.01 percent. Forty-two of the species
27 were impinged at rates estimated to be one fish or less per day (TVA 1978a). Juvenile fish
28 occurred more often than adults in impingement samples. This is attributed to (1) the greater
29 relative abundance of these age classes, (2) juvenile fish of some species may concentrate in
30 the shoreline areas, and (3) juveniles are weaker swimmers than adults (TVA 1978a).
31

32 Table 4-4 provides the impingement information for the most prevalent species during initial
33 years of BFN operation (1974 to 1977). Overall, there was a positive relationship between the
34 level of plant operation and impingement. However, for several species (e.g., spotted sucker
35 [*Minytrema melanops*], silver chub [*Macrhybopsis storeriana*], white crappie [*Pomoxis*
36 *annularis*], and sauger [*Stizostedion canadense*]) impingement levels may have reflected year
37 class variation of the species within the reservoir rather than the level of plant operation
38 (TVA 1978a). Nuclear generating stations are typically operated as baseload facilities and daily
39 changes in the operational mode are minimal. Also, there is usually only a minor variation in
40 cooling water use between years as long as all units are operating at normal levels. Therefore,

when there are dramatic fluctuations in impingement collections from week to week or from year to year, they generally reflect prevailing conditions in the river and changes in the fish community (Bowzer and Lippincott 2000).

Table 4-4. Calculated Total Number and Percent of Total Impingement for the Most Prevalent Fish Species Impinged at Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 – 1974 to 1977

Common Name (Scientific Name)	March 1974 - March 1975	March 1975 - March 1976	Sept 1976 - Aug 1977
skipjack herring (<i>Alosa chrysochloris</i>)	220,964 (4.2 %)	98,751 (3.7 %)	110,487 (1.7 %)
gizzard shad (<i>Dorosoma cepedianum</i>)	188,300 ^(a) (3.5 %)	343,312 (12.8 %)	1,353,913 (20.3 %)
threadfin shad (<i>Dorosoma petenense</i>)	4,552,208 ^(a) (86.5 %)	1,909,492 (71.0 %)	4,635,290 (69.5 %)
channel catfish (<i>Ictalurus punctatus</i>)	21,716 (0.4 %)	11,435 (0.4 %)	24,719 (0.4 %)
white bass (<i>Morone chrysops</i>)	14,126 (0.3 %)	13,408 (0.5 %)	50,681 (0.8 %)
yellow bass (<i>Morone mississippiensis</i>)	14,453 (0.3 %)	29,936 (1.1 %)	67,005 (1.0 %)
green sunfish (<i>Lepomis cyanellus</i>)	10,154 (0.2 %)	3115 (0.1 %)	39,210 (0.6 %)
bluegill (<i>Lepomis macrochirus</i>)	17,556 (0.3 %)	9423 (0.4 %)	84,977 (1.3 %)
reardear sunfish (<i>Lepomis microlophus</i>)	7910 (0.2 %)	2561 (0.1 %)	27,625 (0.4 %)
freshwater drum (<i>Aplodinotus grunniens</i>)	179,501 (3.4 %)	233,902 (8.7 %)	215,783 (3.2 %)
Total number impinged (Number of species impinged)	5,263,546 (51 species)	2,688,498 (52 species)	6,673,488 (61 species)

(a) The 48,937 individuals identified as only *Dorosoma* spp. were proportionally split between gizzard and threadfin shad.
Source: TVA 1978a.

The number of fish impinged between 1974 and 1977 were compared to the estimated standing stock of fish within Wheeler Reservoir (TVA 1978a). For the species listed in Table 4-4, the percent standing stock impinged between September 1976 and August 1977 were skipjack

Environmental Impacts of Operation

1 herring, 5.39 percent; gizzard shad, 0.40 percent; threadfin shad, 0.66 percent; channel catfish
2 (*Ictalurus punctatus*), 1.35 percent; white bass, 5.56 percent; yellow bass, 11.72 percent; green
3 sunfish (*Lepomis cyanellus*), 3.49 percent; bluegill (*L. macrochirus*), 0.04 percent; redear
4 sunfish (*Lepomis microlophus*) 0.21 percent; and freshwater drum, 3.32 percent (TVA 1978a).
5 The estimated number of fish that occur in Wheeler Reservoir was based on densities of fish
6 collected in three coves. The coves are located in Second Creek near the Wheeler Dam (1.1
7 ha [2.7 ac] in area and 1.8 m [5.9 ft] deep), a cove at Lawrence County Park (1.4 ha [3.5 ac] in
8 area and 1.3 m [4.3 ft] deep), and a cove on Elk River (0.6 ha [1.5 ac] in area and 1.4 m deep
9 [4.6 ft]) (TVA 1978b).

10
11 No major or significant spawning areas, nursery grounds, feeding areas, wintering areas, or
12 migration routes are located near BFN that would result in an increased potential for impinge-
13 ment (Baxter and Buchanan 1998; TVA 2003b). The intake channel at BFN is 150 m (492 ft),
14 long from the skimmer wall to the pumping station. At normal maximum pool, the water depth
15 along a 6.1-m (20.0-ft)-wide area in the middle of the intake channel is 10.1 m (33.1 ft). From
16 there the sides of the channel slope at a 3-to-1 ratio. Directly in front of the pumping station the
17 bottom slopes down an additional 1.5 m (4.9 ft) to the bottom of the intake opening, resulting in
18 a maximum depth of 11.6 m (38.1 ft) at the intake screen at normal maximum pool
19 (TVA 1978a). Fish have free access to the intake channel and can reside within this area
20 without necessarily succumbing to impingement.

21
22 During original operations, the intake screens were cleaned either on a regular basis (e.g., at
23 shift changes or daily) or when a pressure differential value is exceeded across the screens due
24 to fouling. The often long impingement time, in addition to exposure to high-pressure spray
25 system during the cleaning process, essentially resulted in a 100 percent mortality of impinged
26 fish (TVA 1978a). The intake screens are now continuously backwashed as they are rotated,
27 so impingement loss is not 100 percent. However, the survival rate has not been determined.

28
29 The paddlefish (*Polyodon spathula*) is the only State-listed fish species that has been collected
30 in impingement samples (TVA 1978a). An estimated 168 specimens were collected between
31 March 1974 and March 1975; 15 between March 1975 and March 1976; and 14 specimens
32 between September 1976 and August 1977. They comprised less than 0.01 percent of the
33 number of fish impinged in those years (TVA 1978a).

34
35 During the course of preparing this draft Supplemental Environmental Impact Statement (SEIS),
36 the staff considered mitigation measures for the continued operation of BFN. Based on the
37 assessment to date, the staff expects that the measures in place at BFN (e.g., shoreline intake,
38 escape passages, and a fish return system), provide mitigation for impacts related to impinge-
39 ment, and no new mitigation measures are warranted. There have been no measurable
40 changes to the fish community of Wheeler Reservoir related to the BFN, and no indications that
41 impingement has had a destabilizing impact on fish populations (TVA 2003b). The direct and
42 indirect effects associated with the modification of the Tennessee River through creation of

1 reservoirs has had the greatest influence on fish populations (see Section 2.2.5 of this draft
2 SEIS).

3
4 The staff reviewed the available information in the TVA ER, other BFN documents related to the
5 FWPCA 316(b) permitting process, and TVA's Vital Signs Monitoring Program evaluations and
6 other documents related to the fish community of Wheeler Reservoir. Based on the results of
7 past impingement studies and the operating history of BFN intake structure, the staff concludes
8 that the potential impacts of impingement of fish and shellfish are SMALL, and further mitigation
9 measures should not be warranted. Nevertheless, the TVA will evaluate the levels of
10 impingement by monitoring under current two-unit operation and following the return of three-
11 unit operation at 120 percent power load, which will increase intake flow rates by approximately
12 11 percent over those of past three-unit operation (TVA 2003b). Modeling techniques are
13 currently being refined, which will allow more realistic analysis of the effects of impingement
14 and allow extrapolation of impingement losses to production foregone for forage fish. These or
15 similar modeling techniques will be employed to analyze future impingement data from BFN to
16 better quantify long-term, far-field effects of impingement to the reservoir fish community
17 (TVA 2003b). TVA's Vital Signs Monitoring Program would also continue to assess aquatic
18 communities in Wheeler Reservoir. If it is determined that increased impingement is resulting
19 in unacceptable environmental impacts, TVA would assess technologies, operational measures,
20 and restoration measures that could be undertaken to remedy the impacts, and institute
21 appropriate mitigation measures in consultation with appropriate Federal and State of Alabama
22 agencies (TVA 2003b).

23 24 4.1.4 Heat Shock

25
26 For plants with once-through cooling systems, the effects of heat shock are listed as a
27 Category 2 issue and require plant-specific evaluation before license renewal. The staff made
28 impacts on fish and shellfish resources resulting from heat shock a Category 2 issue because
29 of continuing concerns about thermal-discharge effects and the possible need to modify thermal
30 discharges in the future in response to changing environmental conditions (NRC 1996).
31 Information to be considered includes (1) the type of cooling system (whether once-through or
32 cooling pond) and (2) evidence of a FWPCA Section 316(a) variance or equivalent state
33 documentation. To perform this evaluation, the staff reviewed the TVA ER and other TVA
34 environmentally related documents, visited the BFN site, reviewed the facilities thermal variance
35 monitoring and 316(a) studies, and reviewed the applicant's State of Alabama NPDES Permit
36 No. AL0022080, which was issued on December 29, 2000, became effective on February 1,
37 2001, and will remain in force until January 31, 2006 (ADEM 2000).

38
39 BFN has a once-through heat dissipation system. Water is discharged back to the river
40 through submerged diffusers located on the river bottom and oriented perpendicular to the river

Environmental Impacts of Operation

1 flow. The diffusers for each unit have 7800 5-cm (2-in.)-diameter ports located on the
2 downstream-facing portion of the diffuser pipe and angled to force the heated effluent up into
3 the water column (TVA 2003a). BFN also currently has five mechanical draft cooling towers,
4 with a sixth to be added, which can be operated to assist in heat dissipation (helper mode)
5 primarily during summer (July and August) hot-weather periods (TVA 2003b). BFN has been
6 able to operate at full power in the open-cycle mode, while still meeting state water temperature
7 standards under most river flow and temperature conditions. Under the original three-unit
8 operation at 100 percent power levels, BFN used river water at the rate of 124.9 m³/s (1.98
9 million gpm) and condenser cooling water was warmed a maximum of 13.9°C (25°F) above
10 ambient temperature before being discharged to the river (Buchanan 1990). Under three-unit
11 operation at a combined total power level of 11,856 MW(t), BFN would use river water at the
12 rate of 139 m³/s (2.20 million gpm) (an 11 percent increase). The maximum temperature
13 increases above ambient temperature would be 15.9°C (28.7°F) under open mode for each
14 unit's diffuser. Under helper mode, the diffuser discharge temperature would be 10.7°C
15 (19.3°F) above ambient temperature for Unit 1 and 3.8°C (6.8°F) above ambient temperature
16 for both Units 2 and 3 (Hopping 2004).

17
18 Based on results of a supplemental 316(a) demonstration for alternative thermal discharge
19 limits for BFN (TVA 1983), the thermal limitations that have been in place for BFN since 1984
20 are a maximum 1-hour average of 33.9°C (93°F), a maximum 24-hour average of 32.2°C
21 (90°F), and a maximum 24-hour average temperature increase of 5.6°C (10°F) over ambient
22 conditions. This varies from the more stringent thermal criteria established in 1972 of a
23 maximum temperature at the edge of the mixing zone of 30°C (86°F) and a maximum
24 temperature increase of 2.8°C (5°F) (TVA 1983). These limitations are applied at the edges of
25 a mixing zone with the following dimensions: (1) a maximum length of 730 m (2400 ft)
26 downstream of the diffusers, (2) a maximum width of 600 m (2000 ft), and (3) a maximum
27 length of 46 m (150 ft) upstream of the diffusers to the top of the diffuser pipes and extends to
28 the bottom downstream of the diffusers (TVA 2003b). Annual ambient maximum temperatures
29 in Wheeler Reservoir rarely exceed 31.7°C (89°F) in the main channel, but often exceed this
30 temperature in the shallow areas of embayments and coves (TVA 2002). If the upstream
31 24-hour temperature exceeds 32.2°C (90°F), the 24-hour downstream temperature may equal,
32 but not exceed, the upstream value. This type of operation is acceptable until the 1-hour
33 average limit of 33.9°C (93°F) is obtained (TVA 2003b).

34
35 The BFN discharge diffusers are located such that fish would not become entrapped in areas of
36 elevated temperatures. Acute thermal impacts to aquatic organisms (e.g., immediate death or
37 disability) are unlikely (TVA 2003b). However, larval fish that pass through the mixing zone
38 may be stunned by exposure to elevated temperatures, making them more susceptible to
39 predation (TVA 1972). No heat-related fish kills have been reported for BFN. Thermal
40 discharges related to the operation of BFN affect a relatively small area of Wheeler Reservoir.
41 The required thermal mixing zone does not exceed a surface area of 47.3 ha (117 ac). This is
42 less than 0.2 percent of the surface area of Wheeler Reservoir.

1 Maximum temperatures at the edge of the thermal mixing zone do not exceed the upper
2 thermal limits for species such as bluegill; black and white crappie (*Pomoxis annularis* and *P.*
3 *nigromaculatus* respectively); largemouth (*Micropterus salmoides*), smallmouth (*M. dolomieu*),
4 and Florida largemouth bass (*M. s. floridanus*); channel catfish (*Ictalurus punctatus*), and
5 golden shiner (*Notemigonus crysoleucas*) (TVA 2002). For example, the upper temperature
6 avoided by fish acclimated to 30°C (86°F) were 35°C (95°F) for spotfin shiner (*Cyprinella*
7 *spiloptera*), 35°C (95°F) for bluegill, 33°C (91.4°F) for green sunfish, 33°C (91.4°F) for
8 smallmouth bass, 34.0°C (93.2°F) for spotted bass (*Micropterus punctulatus*), and 35°C
9 (93.2°F) for channel catfish (Cherry et al. 1975). However, the thermal tolerance of some
10 species such as yellow perch (*Perca flavescens*), white sucker (*Catostomus commersoni*),
11 walleye (*Stizostedion vitreum*), sauger, and emerald shiner (*Notropis atherinoides*) could be
12 exceeded during annual extreme water temperatures (TVA 2002). Nevertheless, species such
13 as sauger are reported to disperse throughout the reservoir and are not found in the vicinity of
14 the BFN during extreme ambient water temperatures (Baxter and Buchanan 1998).

15
16 Although individual fish may occasionally be found in thermal effluents at lethal temperatures,
17 populations as a whole avoid such conditions (Talmage and Opresko 1981). The thermal
18 preference for relatively large numbers of species common to Wheeler Reservoir (e.g., shad,
19 bass, crappie, sunfish, freshwater drum, and some minnows) have been found to be in the
20 range of 28 to 32°C (82.4 to 89.6°F); while some fish such as gar, carp, catfish, and minnows
21 have been observed in thermal effluents in summer that range from 32 to 36°C (89.6 to 96.8°F)
22 (Talmage and Opresko 1981). Young fish generally have a higher thermal preference and
23 greater tolerance to elevated temperatures than older fish (Talmage and Opresko 1981).
24 Therefore, although younger fish may not be as capable of avoiding the thermal plume as older
25 fish, they may not experience thermal shock during passage through the plume.

26
27 Thermal releases from BFN have not had a significant impact on the aquatic community of
28 Wheeler Reservoir (TVA 1983; Baxter and Buchanan 1998; Buchanan 1990; Lowery and
29 Poppe 1992). From 1985 through 1992, a biological monitoring program was conducted to
30 evaluate the effects of thermal discharges from BFN on phytoplankton and on total standing
31 stocks and selected fish species in Wheeler Reservoir. Algal surveys were conducted in 1989
32 (during plant shutdown) and in 1991 (during plant operation). The only consistent observation
33 was that the planktonic community varied on a daily basis regardless of location and habitat
34 type. There was no indication that operation of BFN, even with the revised thermal limits, had
35 influenced the phytoplankton community in Wheeler Reservoir (Lowery and Poppe 1992).
36 Special attention was focused on sauger and yellow perch for BFN thermal variance studies
37 because these cool water species would be more susceptible to elevated water temperatures
38 than would most of the warmwater fish species that occur in the reservoir. Survey results
39 indicated that BFN had no adverse impact on the reproductive success of either species nor on
40 the movement of sauger past BFN (Baxter and Buchanan 1998). The tailwater of Guntersville
41 Dam are the primary spawning location for sauger in Wheeler Reservoir (Buchanan 1990) and

Environmental Impacts of Operation

1 therefore, are not influenced by thermal discharges from BFN. Overfishing for sauger in
2 Wheeler Reservoir and drought conditions (e.g., low flows and decreased turbidity) in the
3 Tennessee Valley from 1985 through 1988 had adverse impacts on sauger spawning success
4 (Maceina et al. 1998; Baxter and Buchanan 1998).
5

6 Currently, TVA operates cooling towers at BFN only when the water temperature of discharges
7 approaches and presents the potential for exceeding the NPDES thermal limit. When this
8 situation occurs, not all cooling towers are necessarily placed in service. To maximize the net
9 generation of the plant, only those towers necessary to keep the water temperature below the
10 thermal limits are operated. Thus, as long as derating is part of the operational strategy for
11 maintaining the NPDES limits, there is no significant difference in the hottest average thermal
12 discharge for any of the cooling tower options. Additionally, TVA is working towards improving
13 its methods of predicting water temperatures in Wheeler Reservoir and optimizing the operation
14 of the cooling system provided at BFN. Computer simulations indicate that the combination of
15 using existing cooling towers, the addition of a new cooling tower, and derating the plant, when
16 necessary, would allow compliance with the current NPDES permit when all three units are
17 operating at 120 percent of original licensed thermal power (TVA 2003b). In-stream tempera-
18 tures at the end of the mixing zone would remain within NPDES-permitted limits; thus, heat
19 shock impacts would not be expected (TVA 2003b). To maintain temperatures within thermal
20 limitation requirements, BFN would utilize its cooling towers, on average, about 5.3 percent of
21 the time, and derating will be required approximately 0.1 percent of the time when Units 2 and 3
22 are operating at 120 percent power levels. When all three units are operating at 120 percent
23 power levels, on average the cooling towers would be required about 7.2 percent of the time,
24 and derating would occur approximately 0.29 percent of the time (TVA 2003b).
25

26 The staff reviewed the available information, including that provided by the applicant, the staff's
27 site visit, the State of Alabama NPDES permit, the thermal variance monitoring and 316(a)
28 studies, and other public sources. The staff evaluated the potential impacts to aquatic
29 resources caused by heat shock during continued operation. Discharge temperatures would
30 remain within the NPDES limits; thus, heat shock impacts are not anticipated (TVA 2003b). It is
31 the staff's conclusion that the potential impacts to fish and shellfish due to heat shock during
32 the license renewal term are SMALL and further mitigation measures are not warranted.
33

34 4.1.5 Microbiological Organisms (Public Health)

35
36 The effects of microbiological organisms on human health are listed as a Category 2 issue and
37 require plant-specific evaluation before license renewal. The average annual flow of Wheeler
38 Reservoir near the BFN site is 4.16×10^{10} m³/yr (1.47×10^{12} ft³/yr), which is less than the
39 9×10^{10} m³/yr (3.15×10^{12} ft³/yr) threshold value in 10 CFR 51.53(c)(3)(ii)(G) for thermal dis-
40 charge to a small river. Thus, the effects of its discharge on microbiological organisms must be
41 addressed for BFN.
42

1 The Category 2 designation is based on the magnitude of the potential public-health impacts
2 associated with thermal enhancement of the enteric pathogens *Salmonella* spp. and
3 *Shigella* spp., the bacterium *Pseudomonas aeruginos*, thermophilic fungi, a number of species
4 from the Genus *Legionella* and pathogenic strains of the free-living amoebae *Naegleria* spp.
5 and *Acanthamoeba* spp. (NRC 1999). The BFN diffuser discharge temperatures would not
6 exceed 44.4°C (112°F) under three-unit operation at 120 percent power level. The maximum
7 diffuser discharge temperature would be 44.61°C (112.3°F) with just Units 2 and 3 in operation
8 at 120 percent power level (Hopping 2004). Except under rare, extreme ambient water
9 temperatures, the discharge temperatures at the edge of the thermal discharge plume would
10 not exceed the maximum 1-hour average of 33.9°C (93°F) or the maximum 24-hour average of
11 32.2°C (90°F). The annual ambient maximum temperature in Wheeler Reservoir seldom
12 exceeds 31.7°C (89°F).

13
14 Thermophilic microorganisms can have optimum growth temperatures of 50°C (122°F) or more,
15 a maximum temperature tolerance of up to 70°C (158°F), and a minimum tolerance of about
16 20°C (68°F) (Deacon 2004). However, thermal preferences and tolerances vary among the
17 various microorganisms and environmental conditions. *Pseudomonas aeruginosa* has an
18 optimum temperature for growth of 37°C (98.6°F) and can tolerate a temperature as high as
19 42°C (107.6°F) (Todar 2002). A water temperature range of 32.2 to 40.6°C (90 to 105°F)
20 provide ideal conditions for *Legionella* spp. bacterial growth (CDC 2004). *Salmonella* spp. can
21 thrive at temperatures between 4.4 to 60°C (40 to 140°F) (Kendall 2003), whereas
22 *Acanthamoeba* spp. and *Naegleria* spp. were not found to colonize hot water systems of 40°C
23 (104°F) or higher (Rohr et al. 1998).

24
25 Based on maximum temperatures at the diffusers and the edge of the permitted thermal plume,
26 coupled with the dilution provided by Wheeler Reservoir and the short period of time for water
27 to pass through the cooling system (i.e., 7 to 11 minutes, with 5 to 9 minutes of this spent in
28 heated water), the thermophilic microorganisms are not expected to cause any appreciable
29 public health risk (TVA 2003b). The Alabama Department of Public Health (Lofgren 2003)
30 agreed that there is no significant threat to the public from thermophilic microorganisms
31 attributable to operation of BFN (see Appendix E). Disinfection of the BFN sewage treatment
32 plant effluent and NPDES permit requirements to monitor fecal coliforms in this effluent
33 (ADEM 2000) further reduces the potential for the heated discharge to be a seed source or
34 inoculant for pathogenic micro-organisms.

35
36 The staff independently reviewed the TVA ER, visited the BFN site, and reviewed the
37 applicant's State of Alabama NPDES Permit AL0022080 (ADEM 2000). Based on its review of
38 this information, coupled with the fact that BFN operations and cooling systems are not
39 expected to change significantly over the license renewal term, the staff concludes that the
40 potential impacts to public health from microbiological organisms resulting from the BFN
41 cooling-water discharges are SMALL. Therefore, additional mitigation is not warranted.

4.2 Transmission Lines

BFN is connected into the TVA system network by seven 500-kV lines via the 500-kV switchyard. One line is to the Madison substation; two lines are to the Trinity substation; one line each is to the West Point, Maury, and Union, Mississippi substations, and one line is to the Limestone 500-kV substation (TVA 2003b). In addition, there are two 161-kV lines, one to the Athens substation and one to the Trinity substation. All lines occupy portions of four rights-of-way: one to Maury substation, one to the Trinity substation, one to the Athens substation, and one to the Union, Mississippi, substation. There are portions of transmission lines within these rights-of-way that were not constructed specifically to connect BFN to the TVA power system. However, for the sake of simplicity and a comprehensive analysis, the entire right-of-way is included in this assessment. The 260 km (160 mi) of transmission line rights-of-way cross 10 counties in Alabama and Mississippi.

Continued maintenance activities on the transmission line rights-of-way that are used to connect BFN to the electric power grid will be required if the proposed action is adopted. The TVA Transmission and Power Supply-Transmission Operations and Maintenance organization conducts maintenance activities on transmission lines and rights-of-way in the TVA system. These activities include, but are not restricted to, maintenance of vegetation in each right-of-way, replacement of poles or towers, installation of lightning arresters and counterpoise, and upgrading of existing equipment. Regular maintenance activities are conducted on a 3-to-5 year cycle (Muncy et al. 1999).

Transmission line maintenance activities are reviewed for potential resource issues by technical specialists in the TVA Regional Natural Heritage and Cultural Resources programs (Muncy et al. 1999). A 1.6-km (1.0-mi) buffer area is reviewed for the presence of terrestrial species, while a 16.1-km (10-mi) buffer area is used for aquatic species (TVA 2003b). The TVA Regional Natural Heritage program maintains a database of some 27,000-plus occurrence records for protected plants, animals, caves, National Wetland Inventory wetlands, cultural resources, and areas of management concern for the entire TVA Power Service Area. TVA also conducts fieldwork to inventory and protect threatened and endangered species and environmentally sensitive areas on public lands that it administers. Activities carried out by project staff members include monitoring species populations, educating the public, and managing and maintaining habitats (including caves) at TVA-managed sites.

Transmission line rights-of-way are regularly surveyed and video taped from helicopter. Video tapes can be used to search for sensitive habitat types before field crews are dispatched. Access routes and restrictions for maintenance activities are determined based on knowledge of the species or resources to be protected. Vehicles and equipment are restricted from the site when habitat/sensitive resources are present (Class 2 restrictions). Within Class 2 restricted areas, all vegetation clearing and herbicide applications are done by hand. Class 1

1 restrictions allow hand or mechanical clearing and herbicides use for vegetation control on
 2 transmission line rights-of-way. There is no broadcast application of herbicides. Herbicide
 3 application is carefully controlled, personnel are trained, licensed, and follow manufacturer's
 4 guidelines, EPA guidance, and State regulations.

5
 6 The streamside management zone is maintained to slow and spread surface water flow, to trap
 7 and filter suspended particulates before they reach the stream channel, protect stream bank
 8 integrity, and protect stream water temperature.

9
 10 Category 1 issues in 10 CFR Part 51, Subpart A, Appendix B, Table B-1 that are applicable to
 11 transmission lines from BFN are listed in Table 4-5. The staff has not identified any new and
 12 significant information during its independent review of the TVA ER, the staff's site visit, the
 13 scoping process, consultation with the U.S. Fish and Wildlife Service (FWS) and the Alabama
 14 Division of Wildlife and Freshwater Fisheries (ADWFF), and the staff's evaluation of other
 15 information, such as operation at a combined total of 11,856 MW(t). Therefore, the staff
 16 concludes that there are no impacts related to these issues beyond those discussed in the
 17 GEIS. For all of those issues, the staff concluded in the GEIS that the impacts are SMALL, and
 18 additional plant-specific mitigation measures are not likely to be sufficiently beneficial to be
 19 warranted.

20
 21 **Table 4-5. Category 1 Issues Applicable to the Browns Ferry Nuclear Power Plant, Units 1, 2,**
 22 **and 3 Transmission Lines During the License Renewal Term**

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Sections
TERRESTRIAL RESOURCES	
Power line right-of-way management (cutting and herbicide application)	4.5.6.1
Bird collisions with power lines	4.5.6.2
Impacts of electromagnetic fields on flora and fauna (plants, agricultural crops, honeybees, wildlife, livestock)	4.5.6.3
Flood plains and wetlands on power line right-of-way	4.5.7
AIR QUALITY	
Air-quality effects of transmission lines	4.5.2
LAND USE	
Onsite land use	4.5.3
Power line right-of-way	4.5.3

23
 24
 25
 26
 27
 28
 29
 30
 31
 32
 33
 34
 35
 36
 37 A brief description of the staff's review and GEIS conclusions, as codified in Table B-1, for each
 38 of these issues follows:

Environmental Impacts of Operation

- 1 • Power line right-of-way management (cutting and herbicide application). Based on
2 information in the GEIS, the Commission found that

3
4 The impacts of right-of-way maintenance on wildlife are expected to be of small
5 significance at all sites.
6

7 The staff has not identified any new and significant information during its independent
8 review of the TVA ER, the staff's site visit, the scoping process, consultation with the
9 FWS and ADWFF, and the staff's evaluation of other information, such as operation at a
10 combined total of 11,856 MW(t). Therefore, the staff concludes that there are no
11 impacts of transmission line rights-of-way maintenance during the license renewal term
12 beyond those discussed in the GEIS.
13

- 14 • Bird collisions with power lines. Based on information in the GEIS, the Commission
15 found that

16
17 Impacts are expected to be of small significance at all sites.
18

19 The staff has not identified any new and significant information during its independent
20 review of the TVA ER, the staff's site visit, the scoping process, consultation with the
21 FWS and ADWFF, and the staff's evaluation of other information, such as operation at a
22 combined total power level of 11,856 MW(t). Therefore, the staff concludes that there
23 are no impacts of bird collisions with power lines during the license renewal term beyond
24 those discussed in the GEIS.
25

- 26 • Impacts of electromagnetic fields on flora and fauna (plants, agricultural crops,
27 honeybees, wildlife, livestock). Based on information in the GEIS, the Commission
28 found that

29
30 No significant impacts of electromagnetic fields on terrestrial flora and fauna
31 have been identified. Such effects are not expected to be a problem during the
32 license renewal term.
33

34 The staff has not identified any new and significant information during its independent
35 review of the TVA ER, the staff's site visit, the scoping process, consultation with the FWS
36 and ADWFF, and the staff's evaluation of other information, such as operation at a
37 combined total power level of 11,856 MW(t). Therefore, the staff concludes that there are
38 no impacts of electromagnetic fields on flora and fauna during the license renewal term
39 beyond those discussed in the GEIS.
40
41

- 1 • Flood plains and wetlands on power line right-of-way. Based on information in the
2 GEIS, the Commission found that

3
4 Periodic vegetation control is necessary in forested wetlands underneath power
5 lines and can be achieved with minimal damage to the wetland. No significant
6 impact is expected at any nuclear power plant during the license renewal term.
7

8 The staff has not identified any new and significant information during its independent
9 review of the TVA ER, the staff's site visit, the scoping process, consultation with the FWS
10 and ADWFF, and the staff's evaluation of other information, such as operation at a
11 combined total power level of 11,856 MW(t). Therefore, the staff concludes that there are
12 no impacts of transmission line rights-of-way on flood plains and wetlands during the license
13 renewal term beyond those discussed in the GEIS.
14

- 15 • Air-quality effects of transmission lines. Based on information in the GEIS, the
16 Commission found that

17
18 Production of ozone and oxides of nitrogen is insignificant and does not
19 contribute measurably to ambient levels of these gases.
20

21 The staff has not identified any new and significant information during its independent
22 review of the TVA ER, the scoping process, the staff's site visit, and the staff's evaluation of
23 other available information, such as operation at a combined total power level of
24 11,856 MW(t). Therefore, the staff concludes that there are no air-quality impacts of
25 transmission lines during the renewal term beyond those discussed in the GEIS.
26

- 27 • Onsite land use. Based on information in the GEIS, the Commission found that

28
29 Projected onsite land use changes required during ... the renewal period would
30 be a small fraction of any nuclear power plant site and would involve land that is
31 controlled by the applicant.
32

33 The staff has not identified any new and significant information during its independent
34 review of the TVA ER, the scoping process, the staff's site visit, and the staff's evaluation of
35 other available information, such as operation at a combined total power level of
36 11,856 MW(t). Therefore, the staff concludes that there are no onsite land-use impacts
37 during the license renewal term beyond those discussed in the GEIS.
38
39
40
41

Environmental Impacts of Operation

- Power line right-of-way. Based on information in the GEIS, the Commission found that Ongoing use of power line right of ways would continue with no change in restrictions. The effects of these restrictions are of small significance.

The staff has not identified any new and significant information during its independent review of the TVA ER, the scoping process, the staff's site visit, and the staff's evaluation of other available information, such as operation at a combined total power level of 11,856 MW(t). Therefore, the staff concludes that there are no impacts of power line rights-of-way on land use during the license renewal term beyond those discussed in the GEIS.

Category 2 and uncategorized issues in 10 CFR Part 51, Subpart A, Appendix B, Table B-1, that are applicable to transmission lines from BFN are listed in Table 4-6, and are discussed in Sections 4.2.1 and 4.2.2.

Table 4-6. Category 2 and Uncategorized Issues Applicable to the Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 Transmission Lines During the Renewal Term

ISSUE – 10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Section	10 CFR 51.53(c)(3)(ii) Subparagraph	SEIS Section
HUMAN HEALTH			
Electromagnetic fields, acute effects (electric shock)	4.5.4.1	H	4.2.1
Electromagnetic fields, chronic effects	4.5.4.2	NA	4.2.2

4.2.1 Electromagnetic Fields – Acute Effects

In the GEIS (NRC 1996), the staff found that without a review of the conformance of each nuclear plant transmission line with National Electrical Safety Code (NESC) (IEEE1997) criteria it was not possible to determine the significance of the electric shock potential. Evaluation of individual plant transmission lines is necessary because the issue of electric shock safety was not addressed in the licensing process for some plants. For other plants, land use in the vicinity of transmission lines may have changed, or power distribution companies may have chosen to upgrade line voltage. To comply with 10 CFR 51.53(c)(3)(ii)(H), the applicant must provide an assessment of the potential shock hazard if the transmission lines that were constructed for the specific purpose of connecting the plant to the transmission system do not meet the recommendations of the NESC standard of 5 mA for preventing electric shock from induced currents.

The BFN site is connected to the TVA power system via seven 500-kV lines and two 161-kV lines. A study was completed by the applicant to evaluate the transmission system against

1 current NESC requirements (IEEE 2002). That study included evaluation of both the vertical
2 clearance requirements and potential for shock from steady-state current due to electrostatic
3 effects for the largest equipment under the lines that could be short-circuited to ground.
4 Drawings for each transmission line were reviewed and wire elevations were noted for road
5 crossings under each line. Two types of roadways that passed under the lines were evaluated.
6 These were unpaved roadways where harvesting equipment might travel and paved roadways
7 (city, county, State, and Federal). The reference vehicles evaluated for electric field effects
8 included a standard trailer, a cotton harvester, and an automobile. The electric field
9 calculations were made using Version 3.1 of ENVIRO, which is a module of the Electric Power
10 Research Institute (EPRI) electromagnetic field workstation. Steady-state current calculations
11 were then made using procedures outlined in the EPRI Transmission Line Reference Book.
12 Upon review of this study completed by the utility, the staff concluded that the maximum steady-
13 state current was less than the 2002 NESC standard of 5 mA; therefore, the assessment was
14 adequate to meet the requirements of 10 CFR 51.53. The staff concludes that the impact of
15 the potential shock is SMALL, and additional mitigation measures are not warranted.
16

17 **4.2.2 Electromagnetic Fields – Chronic Effects**

18
19 In the GEIS, the chronic effects of 60-Hz electromagnetic fields from power lines were not
20 designated as Category 1 or 2, and will not be until a scientific consensus is reached on the
21 health implications of these fields.
22

23 The potential for chronic effects from these fields continues to be studied and is not known at
24 this time. The National Institute of Environmental Health Sciences (NIEHS) directs related
25 research through the U.S. Department of Energy (DOE). A NIES report (NIEHS 1999) contains
26 the following conclusion:
27

28 The NIEHS concludes that ELF-EMF [extremely low frequency-electromagnetic field]
29 exposure cannot be recognized as entirely safe because of weak scientific evidence that
30 exposure may pose a leukemia hazard. In our opinion, this finding is insufficient to
31 warrant aggressive regulatory concern. However, because virtually everyone in the
32 United States uses electricity and therefore is routinely exposed to ELF-EMF, passive
33 regulatory action is warranted such as a continued emphasis on educating both the
34 public and the regulated community on means aimed at reducing exposures. The
35 NIEHS does not believe that other cancers or non-cancer health outcomes provide
36 sufficient evidence of a risk to currently warrant concern.
37

38 This statement is not sufficient to cause the staff to change its position with respect to the
39 chronic effects of electromagnetic fields. The staff considers the GEIS finding of “not
40 applicable” still appropriate and will continue to follow developments on this issue.
41
42

4.3 Radiological Impacts of Normal Operations

Category 1 issues in 10 CFR Part 51, Subpart A, Appendix B, Table B-1, that are applicable to BFN in regard to radiological impacts are listed in Table 4-7. TVA stated in its ER (TVA 2003b) that it is not aware of any new and significant information associated with renewal of the BFN operating licenses (OLs).

Table 4-7. Category 1 Issues Applicable to Radiological Impacts of Normal Operations During the License Renewal Term

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Sections
HUMAN HEALTH	
Radiation exposures to public (license renewal term)	4.6.2
Occupational radiation exposures (license renewal term)	4.6.3

The staff has not identified any new and significant information during its independent review of the TVA ER, the staff's site visit, the scoping process, or its evaluation of other available information, such as operation at a combined total power level of 11,856 MW(t). Therefore, the staff concludes that there are no impacts related to these issues beyond those discussed in the GEIS. For these issues, the staff concluded in the GEIS that the impacts are SMALL, and additional plant-specific mitigation measures are not likely to be sufficiently beneficial to be warranted.

A brief description of the staff's review and the GEIS conclusions, as codified in Table B-1, for each of these issues follows:

- Radiation exposures to public (license renewal term). Based on information in the GEIS, the Commission found that

Radiation doses to the public will continue at current levels associated with normal operations.

The staff has not identified any new and significant information during its independent review of the TVA ER, the staff's site visit, the scoping process, or its evaluation of other available information, such as operation at a combined total power level of 11,856 MW(t). Any increases in radioactive effluents associated with plant operation at a combined total power level of 11,856 MW(t) for an additional 20 years would result in radiation doses to the public that would remain well within regulatory limits. These doses are not expected to result in health impacts to individuals or populations near the plant. Therefore, the staff concludes that there are no impacts of radiation exposures to the public during the license renewal term beyond those discussed in the GEIS.

- Occupational radiation exposures (license renewal term). Based on information in the GEIS, the Commission found that

Projected maximum occupational doses during the license renewal term are within the range of doses experienced during normal operations and normal maintenance outages, and would be well below regulatory limits.

The staff has not identified any new and significant information during its independent review of the TVA ER, the staff's site visit, the scoping process, or its evaluation of other available information, such as operation at a combined total power level of 11,856 MW(t). Additional staff will be required to operate BFN at a combined total power level of 11,856 MW(t); however, the doses to individual plant workers would remain within regulatory limits. Therefore, the staff concludes that there are no impacts of occupational radiation exposures during the license renewal term beyond those discussed in the GEIS.

There are no Category 2 issues related to radiological impacts of routine operations.

4.4 Socioeconomic Impacts of Plant Operations During the License Renewal Term

Category 1 issues in 10 CFR Part 51, Subpart A, Appendix B, Table B-1, that are applicable to socioeconomic impacts during the license renewal term are listed in Table 4-8. In its ER (TVA 2003b), TVA stated that it is not aware of any new and significant information associated with the license renewal of the BFN OLS. The staff has not identified any new and significant information during its independent review of the ER, the staff's site visit, the scoping process, or its evaluation of other information, such as operation at a combined total of 11,856 MW(t).

Table 4-8. Category 1 Issues Applicable to Socioeconomics During the License Renewal Term

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Section
SOCIOECONOMIC	
Public services: public safety, social services, and tourism and recreation	4.7.3; 4.7.3.3; 4.7.3.4; 4.7.3.6
Public services: education (license renewal term)	4.7.3.1
Aesthetic impacts (license renewal term)	4.7.6
Aesthetic impacts of transmission lines (license renewal term)	4.5.8

Therefore, the staff concludes that there are no impacts related to these issues beyond those discussed in the GEIS (NRC 1996). For these issues, the staff concluded in the GEIS that the impacts are SMALL, and additional plant-specific mitigation measures are not likely to be sufficiently beneficial to be warranted.

Environmental Impacts of Operation

1 A brief description of the staff's review and the GEIS conclusions, as codified in Table B-1, for
2 each of these issues follows:

- 3
4 • Public services – public safety, social services, and tourism and recreation. Based on
5 information in the GEIS, the Commission found that

6
7 Impacts to public safety, social services, and tourism and recreation are
8 expected to be of small significance at all sites.

9
10 The staff has not identified any new and significant information during its independent
11 review of the TVA ER, the scoping process, the staff's site visit, and the staff's evaluation of
12 other available information, such as operation at a combined total power level of
13 11,856 MW(t). Therefore, the staff concludes that there are no impacts on public safety,
14 social services, and tourism and recreation during the license renewal term beyond those
15 discussed in the GEIS.

- 16
17 • Public services – education (license renewal term). Based on information in the GEIS,
18 the Commission found that

19
20 Only impacts of small significance are expected.

21
22 The staff has not identified any new and significant information during its independent
23 review of the TVA ER, the scoping process, the staff's site visit, and the staff's evaluation of
24 other available information, such as operation at a combined total power level of
25 11,856 MW(t). Therefore, the staff concludes that there are no impacts on education during
26 the license renewal term beyond those discussed in the GEIS.

- 27
28 • Aesthetic impacts (license renewal term). Based on information in the GEIS, the
29 Commission found that

30
31 No significant impacts are expected during the license renewal term.

32
33 The staff has not identified any new and significant information during its independent
34 review of the TVA ER, the scoping process, the staff's site visit, and the staff's evaluation of
35 other available information, such as operation at a combined total power level of
36 11,856 MW(t). Therefore, the staff concludes that there are no aesthetic impacts during the
37 license renewal term beyond those discussed in the GEIS.

- 38
39 • Aesthetic impacts of transmission lines (license renewal term). Based on information in
40 the GEIS, the Commission found that

41
42 No significant impacts are expected during the license renewal term.

The staff has not identified any new and significant information during its independent review of the TVA ER, the scoping process, the staff's site visit, and the staff's evaluation of other available information, such as operation at a combined total power level of 11,856 MW(t). Therefore, the staff concludes that there are no aesthetic impacts of transmission lines during the license renewal term beyond those discussed in the GEIS.

Table 4-9 lists the Category 2 socioeconomic issues that require plant-specific analysis and environmental justice, which was not addressed in the GEIS. These issues are discussed in Sections 4.4.1 through 4.4.6.

Table 4-9. Environmental Justice and GEIS Category 2 Issues Applicable to Socioeconomics During the License Renewal Term

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Section	10 CFR 51.53(c)(3)(ii) Subparagraph	SEIS Section
SOCIOECONOMIC			
Housing impacts	4.7.1	I	4.4.1
Public services: public utilities	4.7.3.5	I	4.4.2
Offsite land use (license renewal term)	4.7.4	I	4.4.3
Public services: transportation	4.7.3.2	J	4.4.4
Historic and archaeological resources	4.7.7	K	4.4.5
Environmental justice ^(a)	Not addressed	Not addressed	4.4.6

(a) Guidance related to environmental justice was not in place at the time the GEIS and the associated revision to 10 CFR Part 51 were prepared. Therefore, environmental justice must be addressed in the licensee's ER and the staff's environmental impact statement.

4.4.1 Housing Impacts

Impacts on housing are considered SMALL when a small or not easily discernible change in housing availability occurs. Impacts are considered MODERATE when there is discernible but short-lived reduction in available housing units because of project-induced migration. Impacts are considered LARGE when project-related housing demands result in very limited housing availability and would increase rental rates and housing values well above normal inflation (NRC 1996).

In determining housing impacts, the applicant chose to follow Appendix C of the GEIS (NRC 1996), which presents a population characterization method that is based on two factors, "sparseness" and "proximity." Sparseness measures population density within 32 km (20 mi) of the site, and proximity measures population density and city size within 80 km (50 mi). Each factor has categories of density and size (NRC 1996, Table C.1), and a matrix is used to rank the population category as low, medium, or high (NRC 1996, Figure C.1).

Environmental Impacts of Operation

1 In 2000, the population living within 32 km (20 mi) of BFN was estimated to be approximately
2 164,936 (TVA 2003b). This total converts to a population density of about 52 persons/km²
3 (136 persons/mi²) living within a 32-km (20-mi) radius of BFN. This concentration falls into the
4 GEIS sparseness Category 4 (i.e., having greater than or equal to 46 persons/km²
5 [120 persons/mi²]).
6

7 An estimated 872,478 people live within 80 km (50 mi) of the BFN site (TVA 2003b), equating
8 to a population density of around 43 persons/km² (112 persons/mi²). In addition, the City of
9 Huntsville, which has a population of 158,216, is located about 48 km (30 miles) to the east of
10 the site (TVA 2003b). Applying the GEIS proximity measures (NRC 1996), BFN is classified as
11 Category 3 (i.e., having one or more cities with 100,000 or more persons and less than
12 73 persons/km² [190 persons/mi²] within 80 km [50 mi] of the site). According to the GEIS,
13 these sparseness and proximity scores identify the BFN nuclear units as being located in a
14 high-population area.
15

16 10 CFR Part 51, Subpart A, Appendix B, Table B-1, states that impacts on housing availability
17 are expected to be of SMALL significance at plants located in a high-population area where
18 growth-control measures are not in effect. The BFN site is located in a high-population area.
19 There are no restrictive growth-control measures that would limit housing development in
20 Limestone County or any of its neighboring counties (Lawrence, Lauderdale, Madison, or
21 Morgan Counties) (TVA 2003b).
22

23 SMALL impacts result when no discernible change in housing availability occurs, changes in
24 rental rates and housing values are similar to those occurring statewide, and no housing
25 construction or conversion is required to meet new demand (NRC 1996). The GEIS assumes
26 that an additional staff of 60 permanent per-unit workers might be needed during the license
27 renewal term to perform routine maintenance and other activities.
28

29 TVA plans no refurbishment activities as part of the license renewal process; therefore,
30 employment will not change significantly in the area as a result of the license renewal of the
31 plant. Activities related to the replacement of a cooling tower are outside the scope of license
32 renewal because they are related to current operations and the restart of Unit 1.
33

34 The staff reviewed the available information relative to housing impacts and TVA's conclusions.
35 Based on this review, including interviews with local real estate agents, the staff concludes that
36 the impact on housing during the license renewal term would be SMALL, and additional
37 mitigation is not warranted.
38

39 4.4.2 Public Services: Public Utilities

40
41 Impacts on public utility services are considered SMALL if there is little or no change in the
42 ability of the system to respond to the level of demand, and thus there is no need to add capita

1 facilities. Impacts are considered MODERATE if overtaxing of service capabilities occurs
2 during periods of peak demand. Impacts are considered LARGE if existing levels of service
3 (e.g., water or sewer services) are substantially degraded and additional capacity is needed to
4 meet ongoing demands for services. The GEIS indicates that, in the absence of new and
5 significant information to the contrary, the only impacts on public utilities that could be
6 significant are impacts on public water supplies (NRC 1996).

7
8 Analysis of impacts on the public water supply system considered both plant demand and plant-
9 related population growth. Section 2.2.2 describes the BFN-permitted withdrawal rate and
10 actual use of water. TVA plans no refurbishment activities at BFN, and none of the
11 refurbishment activities would require staffing that would exceed BFN's current level of staffing,
12 so plant demand would not change beyond current demands (TVA 2004a).

13
14 For the sake of evaluation, the staff assumed a possible increase of 100 new jobs (including
15 60 employees), and an overall population increase of approximately 249 as a result of those
16 jobs.^(a) The plant-related population increase would require an additional 49 to 68 m³/d
17 (0.013 to 0.018 MGD) of water. This amount is within the total residual capacity of the water
18 treatment plants serving BFN (Table 2-9). Thus, the staff concludes that the impact of
19 increased water use resulting from the potential increase in employment is SMALL, and
20 mitigation is not warranted.

21 22 4.4.3 Offsite Land Use

23
24 Offsite land use during the license renewal term is a Category 2 issue. Table B-1 of 10 CFR
25 Part 51, Subpart A, Appendix B, notes that "significant changes in land use may be associated
26 with population and tax revenue changes resulting from license renewal."

27
28 Section 4.7.4 of the GEIS defines the magnitude of land-use changes as a result of plant
29 operation during the license renewal term as follows:

30
31 SMALL – Little new development and minimal changes to an area's land-use pattern.

32
33 MODERATE – Considerable new development and some changes to the land-use pattern

34
35 LARGE – Large-scale new development and major changes in the land-use pattern.

36
37 The current OLs for Units 1, 2, and 3 expire in 2013, 2014, and 2016, respectively. Unit 1 is
38 currently not operating; however, TVA projects that operation will resume in 2007 (TVA 2003b).

(a) Calculated by assuming that the average number of persons per household is 2.49 in the state of
Alabama (100 jobs x 2.49 = 249) (USCB 2000).

Environmental Impacts of Operation

1 When Unit 1 resumes operation, the total permanent employment at the BFN site is expected to
2 increase by 150 workers (TVA 2003b). TVA determined that no additional plant workers will be
3 required during the license renewal term (TVA 2003b). Section 3.7.5 of the GEIS states that if
4 plant-related population growth is less than 5 percent of the study area's total population, offsite
5 land use changes would be small, especially if the study area has established patterns of
6 residential and commercial development, a population density of at least 23 persons/km²
7 (60 persons/mi²), and at least one urban area with a population of 100,000 or more within
8 80 km (50 mi). For BFN, there is no expected population growth as a result of renewal of the
9 three OLs. Consequently, the staff concludes that population changes resulting from license
10 renewal are likely to result in minimal change to the land-use pattern in the area.

11
12 Tax revenue can affect land use because it enables local jurisdictions to be able to provide the
13 public services (e.g., transportation and utilities) necessary to support development.
14 Section 4.7.4.1 of the GEIS states that the assessment of tax-driven, land-use impacts during
15 the license renewal term should consider (1) the size of the plant's payments relative to the
16 community's total revenues, (2) the nature of the community's existing land-use pattern, and
17 (3) the extent to which the community already has public services in place to support and guide
18 development. If the plant's tax payments are projected to be small relative to the community's
19 total revenue, tax-driven land-use changes during the plant's license renewal term would be
20 small, especially where the community has pre-established patterns of development and has
21 provided adequate public services to support and guide development. Section 4.7.2.1 of the
22 GEIS states that if tax payments by the plant owner are less than 10 percent of the taxing
23 jurisdiction's revenue, the significance level would be small. If the plant's tax payments are
24 projected to be medium to large (10 to 20 percent) relative to the community's total revenue,
25 new tax-driven, land-use changes would be moderate. This is most likely to be true where the
26 community has no pre-established patterns of development (i.e., land-use plans or controls) or
27 has not provided adequate public services to support and guide development in the past,
28 especially infrastructure that would allow industrial development. If the plant's tax payments are
29 projected to be a dominant source of the community's total revenue, new tax-driven, land-use
30 changes would be large. This would be especially true where the community has no pre-
31 established pattern of development or has not provided adequate public services to support and
32 guide development in the past.

33
34 TVA makes tax-equivalent payments to the State of Alabama and local governments in eight
35 states. These payments are redistributed to the counties that are served by TVA power. See
36 Section 2.2.8 for a discussion on the distribution of tax-equivalent payments to affected
37 counties. A certain amount of this revenue is used for development and infrastructure within
38 the community. It is not expected that this percentage will vary significantly in the future
39 (TVA 2003b). Consequently, the staff concludes that tax-driven land-use impacts resulting from
40 license renewal are likely to be minimal. Overall, changes in land use associated with
41 population and tax revenue changes resulting from license renewal are likely to be SMALL.
42

4.4.4 Public Services: Transportation

On October 4, 1999, 10 CFR 51.53(c)(3)(ii)(J) and 10 CFR Part 51, Subpart A, Appendix B, Table B-1, were revised to state that "Public Services: Transportation Impacts During Operations" is a Category 2 issue (see NRC 1999 for more discussion of this clarification). The issue is treated as such in this SEIS.

As noted in Section 2.2.8.2., BFN is located approximately 16 km (10 mi) southwest of Athens in Limestone County and is located just south of U.S. Highway 72. The site is directly accessible from County Road 25. One portion of County Road 25 (Shaw Road) serves as a primary north-south corridor in the vicinity of the plant and intersects U.S. Highway 31 approximately 14.4 km (9 mi) east of the site. Browns Ferry Road, which intersects County Road 25 just east of the site, runs northeast from BFN and provides a direct route to BFN from Athens. The latest available 1998 average daily traffic counts in proximity to BFN indicate approximately 13,440 vehicles per day on U.S. Highway 72 north of the site and 16,260 vehicles per day on U.S. Highway 31 south of U.S. Highway 72. There are no available traffic counts on the county roads; however, TVA estimates approximately 1600 vehicles per day on Shaw Road, Browns Ferry Road, and Nuclear Plant Road. BFN is currently a primary source of traffic on these county roads (TVA 2003b).

The bounding scenario of 60 additional license renewal staff plus an additional 150 staff for expanded ongoing operation of the plant represents approximately one to two percent of the traffic volume on U.S. Highways 72 and 31. If it is assumed that traffic is split equally in three directions on Shaw Road, Nuclear Plant Road, and Browns Ferry Road, the average daily traffic on these county roads would increase to approximately 1810 (assuming no carpooling), which represents a 13 percent increase in average daily traffic.

To alleviate peak congestion and degradation of county roads in the vicinity of BFN, TVA identified specific site mitigation measures to improve the local roadway during peak periods. These mitigation measures include flexible working hours to reduce peak hours, delayed shift changes, restrictions for trucks traveling during peak hours, roadway improvements, which would include lane widening, realignment and lane addition, and repaving (TVA 2003b).

The staff reviewed the available information, including that provided by TVA, the staff's site visit, the scoping process, discussions with other agencies, and other public sources. Using this information, the staff evaluated the potential impacts to transportation service resulting from operation of BFN. It is the staff's conclusion that the potential impacts to transportation service degradation during the license renewal term are SMALL, considering that no additional staff are expected for renewal refurbishment activities. During the course of preparing this draft SEIS, the staff considered mitigation measures for the continued operation of BFN. When continued operation for an additional 20 years is considered as a whole, all the specific effects on the environment (whether or not "significant") were considered. Based on this assessment, the

Environmental Impacts of Operation

1 staff expects that the measures identified by BFN provide mitigation for all impacts related to
2 transportation, and no new mitigation measures are warranted.
3

4 **4.4.5 Historic and Archaeological Resources**

5
6 The National Historic Preservation Act of 1966 (NHPA), as amended, requires Federal
7 agencies to take into account the effects of their undertakings on historic properties. The
8 historic preservation review process mandated by Section 106 of NHPA is outlined in
9 regulations issued by the Advisory Council on Historic Preservation at 36 CFR Part 800.
10 License renewal of an OL could potentially affect historic properties that may be located at the
11 site. Therefore, in accordance with NHPA, NRC must make a reasonable effort to identify
12 historic properties in the areas of potential effects. If no historic properties are present or
13 affected, NRC is required to notify the State Historic Preservation Officer (SHPO) before
14 proceeding. If it is determined that historic properties are present, NRC is required to assess
15 and resolve possible adverse effects of the undertaking.
16

17 In 1972, TVA consulted with the Alabama Historical Commission for the construction of BFN as
18 required by NHPA. In a letter dated March 16, 1972, the Alabama Historical Commission
19 concluded that in the area of BFN nothing was found that would be adversely affected by the
20 addition of the plant (AHC 1972). The original construction of the plant required the relocation
21 of the Cox Cemetery. It was the opinion of the SHPO that the relocation of the cemetery
22 occurred with considerable care.
23

24 In 2002, TVA prepared an SEIS for renewal of the BFN OLs (TVA 2002). In addition to the EIS,
25 TVA consulted with the Alabama SHPO regarding renewal of the BFN OLs. On April 24, 2002,
26 the Alabama SHPO concurred with TVA that the project activities associated with license
27 renewal at BFN will have no effect on significant cultural resources provided that site 1Li535
28 and the Cox Cemetery are avoided (SHPO 2002).
29

30 The NRC sent a letter to the Alabama SHPO, dated March 8, 2004 (NRC 2004b), and stated
31 that in accordance with 36 CFR 800.8, the SEIS will include analyses of potential impacts to
32 historic and archaeological resources. In the context of the NHPA, the NRC staff determined
33 that the area of potential effect for license renewal action is the area at the power plant site and
34 its immediate environs, which may be impacted by post-license renewal land-disturbing
35 operation or by projected refurbishment activities associated with the proposed action.
36

37 Seventeen Native American Tribes were sent letters on March 23, 2004, providing them with an
38 opportunity to provide input regarding cultural resource issues in the vicinity of BFN and inviting
39 them to participate in the National Environmental Policy Act (NEPA) process. Several Federal
40 and State agencies were contacted to identify tribes that may have a potential interest in the
41 lands at BFN including the Alabama SHPO, the Advisory Council on Historic Preservation, the
42 Bureau of Indian Affairs, the Alabama Department of Transportation, and the U.S. Forest

1 Service. The Tribes contacted were the Poarch Creek Indians, Miccosukee Indian Tribe,
2 Seminole Indian Tribe, Coushatta Indian Tribe, Jena Band of Choctaw Indians, Mississippi
3 Band of Choctaw Indians, Eastern Band of Cherokee Indians, Alabama-Coushatta Tribe of
4 Texas, Alabama-Quassarte Tribal Town, Cherokee Nation of Oklahoma, Chickasaw Nation,
5 Choctaw Nation of Oklahoma, Kialegee Tribal Town, Muscogee (Creek) Nation, Seminole
6 Nation of Oklahoma, Thlopthlocco Tribal Town, and United Keetoowah Band of Cherokee
7 Indians. An example of one of the letters sent to the Tribes is included in Appendix E.
8

9 Operation of BFN, as planned under the application for license renewal, would protect undis-
10 covered historic or archaeological resources on the site because the undeveloped natural
11 landscape and vegetation would remain undisturbed, and access to the site would remain
12 restricted.
13

14 TVA operating procedures take into account the inadvertent discovery of historic and archaeo-
15 logical remains at BFN. However, care should be taken during normal operational and mainte-
16 nance conditions to ensure that historic resources are not inadvertently impacted. These
17 activities may include not only operation of BFN itself but also land management-related actions
18 such as recreation, wildlife habitat enhancement, and maintaining/upgrading BFN access roads
19 through the site and on transmission line rights-of-way.
20

21 TVA recently conducted a study to determine if changes in the operating policies for TVA's
22 reservoirs would produce greater overall public value. TVA prepared a programmatic EIS for
23 the Reservoirs Operation Study (TVA 2004b). Consultations with seven SHPOs, including the
24 Alabama Historical Commission, and other consulting parties under the requirements of Sec-
25 tion 106 of NHPA, have resulted in agreement(s) stipulating the actions TVA will take to avoid
26 or reduce the adverse effects of the selected alternative on historic properties. The factors that
27 were analyzed by TVA include shoreline erosion, exposure by elevation fluctuations, land
28 development, and visual impacts. The agreement(s) developed can be found in the
29 programmatic EIS for the Reservoirs Operation Study (TVA 2004b).
30

31 Based on the staff's archaeological and historic resources analysis and the consultation that
32 has occurred, on TVA commitment that 1Li535 and the Cox Cemetery will be avoided, and the
33 fact that operation will continue within the bounds of station operations as evaluated in the final
34 EIS (TVA 1972), the staff concludes that the potential impacts on historic and archaeological
35 resources are expected to be SMALL, and mitigation is not warranted.
36

37 **4.4.6 Environmental Justice**

38

39 Environmental justice refers to a Federal policy that requires Federal agencies to identify and
40 address, as appropriate, disproportionately high and adverse human health or environmental

Environmental Impacts of Operation

1 effects of its actions on minority^(a) or low-income populations. The memorandum accompanying
2 Executive Order 12898 (59 FR 7629) directs Federal executive branch agencies to consider
3 environmental justice under NEPA. The Commission's "Policy Statement on the Treatment of
4 Environmental Justice Matters in NRC Regulatory and Licensing Actions" contains guidance
5 and information for addressing environmental justice (69 FR 52040). Although the Executive
6 Order is not mandatory for independent agencies, NRC has voluntarily committed to undertake
7 environmental justice reviews. Specific guidance is provided in NRC Office of Nuclear Reactor
8 Regulation Office Instruction LIC-203, Rev. 1 "Procedural Guidance for Preparing
9 Environmental Assessments and Considering Environmental Issues" (NRC 2004a).

10
11 The staff examined the geographic distribution of minority and low-income populations within
12 80 km (50 mi) of the BFN site, employing the 2000 census (USCB 2000) for low-income
13 populations and minority populations. The populations within an 80-km (50-mi) radius of BFN
14 encompassed all or parts of 19 counties. The staff supplemented its analysis through the
15 scoping process and by field inquiries to county planning departments, social service agencies,
16 and local real estate agents.

17
18 For purposes of the staff's review, a minority population is defined to exist if the percentage of
19 each minority, or aggregated minority category within the census tract or block group^(b)
20 potentially affected by the license renewal of BFN, exceeds the corresponding percentage of
21 minorities in the entire state by 20 percent, or if the corresponding percentage of minorities
22 within the census tract or block group is at least 50 percent. A low-income population is defined
23 to exist if the percentage of low-income population within a census tract or block group exceeds
24 the corresponding percentage of low-income population in the entire state by 20 percent, or if
25 the corresponding percentage of low-income population within a census tract or block group is
26 at least 50 percent. The minority population in the State of Alabama makes up 30 percent of
27 the population and the low-income population makes up 16 percent of the total population in the
28 state. The minority population in the State of Tennessee makes up 20 percent of the
29 population and the low-income population makes up 14 percent of the total population in the
30 state.

31
32 TVA used 2000 census data for identifying minority and low-income populations within 80 km
33 (50 mi) of the BFN site. TVA also followed the convention of employing census tracts within the

(a) The NRC Guidance for performing environmental justice reviews defines "minority" as American Indian or Alaskan Native, Asian or Pacific Islander, Black not of Hispanic Origin, or Hispanic (NRC 2004a).

(b) A census block group is a combination of census blocks, which are statistical subdivisions of a census tract. A census block is the smallest geographic entity for which the U.S. Census Bureau (USCB) collects and tabulates decennial census information. A census tract is a small, relatively permanent statistical subdivision of counties delineated by local committees of census data users in accordance with USCB guidelines for the purpose of collecting and presenting decennial census data. Census block groups are subsets of census tracts (USCB 2001).


1 80-km (50-mi) radius of BFN (TVA 2003b), and staff confirmed these results by examining the
2 minority and low-income populations by census block group within the 80-km (50-mi) radius of
3 the site. If the census tract or block group minority or low-income percentage exceeded the
4 state by 20 percent then the census tract or block group was counted (TVA 2003b). Using this
5 convention, the 80-km (50-mi) radius includes 74 census block groups for minority populations
6 and 27 census block groups for low-income populations. Figure 4-1 shows the distribution of
7 minority populations within the 80-km (50-mi) radius. The shaded areas in Figure 4-1 indicate
8 census block groups where the aggregate percentage of minorities is at least 20 percentage
9 points above the percentage of minorities in the States of Alabama and Tennessee or greater
10 than 50 percent.

11
12 Minority population concentrations are present in eight counties within the 80-km (50-mi) radius
13 of the BFN site. Minority populations are primarily concentrated in the urban center of
14 Huntsville. Madison County contains 43 of the 74 block groups containing significant minority
15 populations. The next greatest concentration of minority populations lives in Colbert and
16 Morgan counties, which each have six block groups with significant minority populations.
17 Lauderdale and Lawrence, Alabama each have five minority block groups. Limestone County,
18 where BFN is located, has four minority block groups. The minority block groups in Morgan
19 County are predominantly composed of black/African-American concentrations and are within
20 the 16-km (10-mi) radius evacuation zone of BFN (USCB 2000; CDD 2004).

21
22 Data from the 2000 census characterize low-income populations within the 80-km (50-mi)
23 radius of the BFN site (USCB 2000). Applying the NRC criterion of "more than 20 percent
24 greater" than the state average or "greater than 50 percent," the census block groups
25 containing low-income populations were identified. Figure 4-2 shows the locations of the low-
26 income populations within 80 km (50 mi) of the BFN site. The lower income populations are
27 concentrated around the urban center of Huntsville, where 11 of the 27 low-income block
28 groups are found. Lauderdale County has seven additional low-income block groups, while
29 Colbert County has four block groups. Franklin, Morgan, and Winston counties in Alabama,
30 and Lawrence and Lincoln counties in Tennessee only have 1 low-income block group each.


31
32 With the locations of minority and low-income populations identified, the staff proceeded to
33 evaluate whether any of the environmental impacts of the proposed action could affect these
34 populations in a disproportionately high and adverse manner. Based on staff guidance
35 (NRC 2004a), air, land, and water resources within about 80 km (50 mi) of the BFN site were
36 examined. Within that area, a few potential environmental impacts could affect human
37 populations; all of these impacts were considered minimal for the general population.

Environmental Impacts of Operation



1
2
3

Figure 4-1. Geographic Distribution of Minority Populations (shaded areas) Within 80 km (50 mi) of Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 Based on 2000 Census Block Group Data



1 **Figure 4-2. Geographic Distribution of Low-Income Populations (shaded areas) Within 80 km**
2 **(50 mi) of Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 Based on 2000**
3 **Census Block Group Data**

Environmental Impacts of Operation

1 The environmental impacts associated with BFN license renewal that could affect human
2 populations are discussed in each associated section. The staff found no unusual resource
3 dependencies or practices such as subsistence agriculture, hunting, or fishing through which
4 minority and/or low-income populations could be disproportionately highly and adversely
5 affected. In addition, the staff did not identify any location-dependent disproportionately high
6 and adverse impacts affecting these minority and low-income populations. The staff concludes
7 that offsite impacts from BFN to minority and low-income populations are SMALL, and no
8 special mitigation actions are warranted.
9

10 4.5 Groundwater Use and Quality

11
12 The Category 1 issues related to groundwater use conflicts during the license renewal term that
13 are applicable to BFN are discussed in the section that follows, and are listed in Table 4-10.
14

15 **Table 4-10. Category 1 Issues Applicable to Groundwater Use Conflicts of Browns Ferry**
16 **Nuclear Power Plant, Units 1, 2, and 3 During the License Renewal Term**
17

ISSUE 10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Sections
(FOR POTABLE AND SERVICE WATER PLANTS USING < 100 GPM)	
Groundwater use conflicts (potable and service water plants that use <100 gpm)	4.8.1.1

- 18
19
20
21
22
23 • Groundwater use conflicts (potable and service water plants using < 100 gpm). Based
24 on information in the GEIS, the Commission found that

25
26 Groundwater use conflicts related to potable and service water plants using
27 <100 gpm have not been found to be a problem at operating nuclear power
28 plants and are not expected to be a problem during the license renewal term.
29

30 BFN does not withdraw groundwater for potable or service water use. The staff has not
31 identified any new and significant information during its independent review of the TVA ER, the
32 scoping process, the staff's site visit, and the staff's evaluation of other available information,
33 such as operation at a combined total power level of 11,856 MW(t). Therefore, the staff
34 concludes that there are no impacts of groundwater use conflicts related to potable and service
35 water plants using less than 100 gpm during the license renewal term beyond those discussed
36 in the GEIS.
37

38 The Category 2 issues related to groundwater-use conflicts during the license renewal term that
39 are applicable to BFN are listed in Table 4-11 and are discussed in Section 4.5.1.
40

Table 4-11. Category 2 Issue Applicable to Groundwater Use Conflicts of Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 During the License Renewal Term

ISSUE 10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Sections	10 CFR 51.53(c)(3)(ii) Subparagraph	SEIS Section
AQUATIC ECOLOGY			
(FOR PLANTS WITH COOLING TOWERS WITHDRAWING MAKEUP WATER FROM A SMALL RIVER)			
Groundwater use conflicts (plants using cooling towers and withdrawing makeup water from a small river)	4.8.1.3	B	4.5.1

4.5.1 Groundwater Use Conflicts (plants using cooling towers and withdrawing make-up water from a small river)

For plants using make-up water from a small river, potential use conflicts is a Category 2 issue, which requires a site-specific assessment prior to license renewal. The Tennessee River average annual flow at BFN for the period from 1976 through 2002 was 1320 m³/s (46,606 ft³/s) or 4.16 x 10¹⁰ m³/yr (1.47 x 10¹² ft³/yr). This is less than the 9 x 10¹⁰ m³/yr (3.15 x 10¹² ft³/yr) criterion stated by NRC in 10 CFR 51.53(c)(3)(ii)(A) as the value beneath which an assessment of the impact of the proposed action must be provided.

NRC has determined that indirect groundwater-use conflict can result from surface water withdrawal from a small river (NRC 1996). It is a potentially important concern that has been designated a Category 2 issue. Rivers often supply alluvial aquifers, and large-scale withdrawals of make-up water for evaporative loss could impact an alluvial aquifer during periods of low flow.

BFN uses cooling towers and withdraws make-up water from the Tennessee River; however, there are no existing or proposed offsite or onsite groundwater supply wells. Rights to "use" of groundwater at BFN were acquired by ownership of property overlying aquifers. There are no future water rights to groundwater underlying BFN (including Native American tribal rights).

Although shallow groundwater at BFN can occur within unconsolidated terrace deposits of alluvial origin, the terrace deposits are not recognized as an aquifer at the site. This is primarily due to the limited permeability and spatial extent of the terrace deposits. Therefore, groundwater-use conflicts associated with surface water withdrawals are small and may only occur during low flow conditions, which may affect aquifer recharge.

A total of 18 environmental monitoring wells have been installed at the BFN site since 1980, and groundwater level measurements were monitored on a monthly basis through 1989. The

Environmental Impacts of Operation

1 water levels in those wells have fluctuated throughout the year; however, there is no decreasing
2 trend (Julian 2004). This indicates that site surface water consumption had not indirectly
3 lowered groundwater levels or created conflicts through 1989.

4
5 The water levels in Wheeler Reservoir throughout 2003, and for the period from 1991 to 1997,
6 were both consistent with the period from 1972 to 1990 (Julian 2004). This indicates that
7 reservoir levels have had consistent annual profiles since routine site groundwater monitoring
8 ceased in 1989. Furthermore, because the lake levels have not dropped since 1991, site
9 surface water consumption has not indirectly lowered groundwater levels or created
10 groundwater conflicts since site monitoring ceased in 1989.

11
12 An offsite well survey was conducted in May 1995 to identify groundwater supplies within a
13 3.2-km (2-mi) radius of the BFN site (TVA 1999). The closest known public groundwater supply
14 (Limestone County Water System, Well G-1) resides approximately 3.2 km (2 mi) north of BFN
15 (Bohac 2004). There is no groundwater use by BFN, and site dewatering wells have been
16 inactive since the 1980s. All wells at the site are used for environmental monitoring purposes
17 only.

18
19 The staff independently reviewed the TVA ER (TVA 2003b) and visited the site. Also, the
20 potential for water-use conflicts was reviewed directly with respect to surface water withdrawals
21 in Section 4.1.1 and was found to be SMALL. Because no groundwater is used at the plant,
22 and the terrace deposits are characterized by limited permeability, the indirect use of
23 groundwater by surface water withdrawal is even more remote. Surface water withdrawals for
24 cooling system make-up water is not expected to affect groundwater levels. Therefore, the
25 staff concludes that groundwater use conflicts would be SMALL.

26 27 4.6 Threatened or Endangered Species

28
29 Threatened or endangered species are listed as a Category 2 issue in 10 CFR Part 51,
30 Subpart A, Appendix B, Table B-1. This issue is listed in Table 4-12.

31
32
33 **Table 4-12. Category 2 Issue Applicable to Threatened or Endangered Species in the**
34 **Vicinity of Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 During the**
35 **License Renewal Term**

37 38	ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Section	10 CFR 51.53(c)(3)(ii) Subparagraph	SEIS Section
39	THREATENED OR ENDANGERED SPECIES (FOR ALL PLANTS)			
40 41	Threatened or endangered species	4.1	E	4.6

1 This issue requires consultation with appropriate agencies to determine whether threatened or
2 endangered species are present and whether they would be adversely affected by continued
3 operation of the nuclear plant during the license renewal term. The presence of threatened or
4 endangered species in the vicinity of the BFN site is discussed in Sections 2.2.5 and 2.2.6. On
5 March 4, 2004, the staff contacted the FWS to request information on threatened and
6 endangered species and the impacts of license renewal (NRC 2004c). In response, on May 19,
7 2004, the FWS provided additional information regarding Federally listed species that have
8 been observed or may occur in the vicinity of the BFN site and its associated transmission lines,
9 as well as the concerns that the FWS have regarding those species (Goldman 2004). On
10 October 25, 2004 the staff sent (NRC 2004d) a biological assessment (BA) (see Appendix E) to
11 the FWS for concurrence.
12

13 4.6.1 Aquatic Species

14
15 As described in Section 2.2.5, there are 38 Federally listed aquatic species (including three
16 candidate species) that occur in either Wheeler Reservoir or its tributaries or in other streams,
17 rivers, or caves within the counties of Alabama and Mississippi through which the BFN
18 transmission lines pass. The species that occur in Wheeler Reservoir and its tributaries are not
19 impacted by plant operations. During BFN's thermal variance monitoring (1985 to 1998) and
20 current Vital Signs Monitoring Programs, no threatened or endangered aquatic species were
21 found within the area that would be affected by operational changes at BFN (TVA 2003b).
22 Additionally, cooling water intake and discharge are closely monitored under the NPDES
23 program, and permit limits are reviewed on a regular basis by State regulatory agencies to
24 ensure the protection of aquatic biota.
25

26 A number of listed species occur in the counties crossed by the BFN transmission lines;
27 however, this does not imply that they occur under or near the transmission lines. The TVA
28 Regional Natural Heritage Program keeps track of Federally and State-protected species.
29 Aquatic animal occurrence records are maintained and updated by TVA staff on a regular
30 basis. Each sensitive area review project is reviewed for the known or likely occurrence of
31 protected aquatic species in streams in or adjacent to the transmission line rights-of-way.
32 A 16-km (10-mi) buffer area around the transmission line being reviewed is examined to
33 determine the likely occurrence of protected aquatic animals. Once an occurrence is located,
34 appropriate class restrictions are applied. Furthermore, best management practices, outlined
35 by Muncy et al. (1999), are employed to protect listed species and their habitats while carrying
36 out vegetation management activities along the transmission lines (TVA 2003b).
37

38 The staff concluded in its BA (NRC 2004d) that continued operation of BFN, including return to
39 three-unit operation at a total combined power level of 11,856 MW(t) and the associated
40 transmission line rights-of-way maintenance activities during the license renewal term, will have
41 no effect, or is not likely to adversely affect any Federally listed aquatic species, nor will it

Environmental Impacts of Operation

1 adversely impact any designated critical habitat. Thus, the staff concludes that the impact on
2 threatened or endangered aquatic species from an additional 20 years of operation would be
3 SMALL, and additional mitigation is not warranted.
4

5 4.6.2 Terrestrial Species 6

7 No Federally listed species are known to occur within 5 km (3 mi) of the BFN site (TVA 2003b).
8 Although no Federally or State-listed species have been reported from areas within 5 km (3 mi)
9 of BFN, a total of 11 Federally listed species have been identified from counties traversed by
10 transmission line rights-of-way along with over 200 State-listed species. Federally listed
11 species reported to occur from Limestone, Morgan, Lawrence, Colbert, and Franklin counties in
12 Alabama and Tishomingo, Itawamba, Lee, and Union Counties in Mississippi are the bald
13 eagle, red-cockaded woodpecker, gray bat, Indiana bat, Price's potato-bean, American hart's
14 tongue fern, leafy prairie clover, Eggert's sunflower, fleshy-fruited gladecress, lyrate bladder-
15 pod, and the Tennessee yellow-eyed grass.
16

17 Habitat for some of the Federally listed species and some of the State-listed species could
18 potentially be found within or traversed by BFN transmission line rights-of-way. Two wildlife
19 management areas occur within 5 km (3 mi) of the BFN site – Swan Creek State Wildlife
20 Management Area and Mallard-Fox Creek State Wildlife Management Area (TVA 2003b).
21 Approximately 5.6 km (3.5 mi) upstream of BFN is the Round Island Recreation Area. The
22 BFN-to-Maury, Alabama, transmission line right-of-way cross the Duck River State Wildlife
23 Management Area, the Duck River Unit 1 Proposed Designated Critical Habitat, and Elk River
24 and Richland Creek, both of which are listed on the Nationwide Rivers Inventory. The
25 BFN-to-Union, Mississippi, transmission line right-of-way cross the John Bell Williams State
26 Wildlife Management Area, the Natchez Trace National Parkway, the Tennessee-Tombigbee
27 Waterway, and the Foxtrap Creek Ravine Potential National Natural Landmark.
28

29 TVA monitors and tracks populations of Federally and State-sensitive terrestrial species on the
30 BFN site and within transmission line rights-of-way. In addition, TVA works with their contract
31 personnel and appropriate Federal and State agencies to develop and implement restrictions
32 and safeguards to protect threatened and endangered species and their habitats during
33 maintenance of transmission line rights-of-way (Muncy et al. 1999).
34

35 The staff concluded in its BA (NRC 2004d) that continued operation of BFN, including return to
36 three-unit operation at a total combined power level of 11,856 MW(t) and the associated
37 transmission line rights-of-way maintenance activities during the license renewal term, will have
38 no effect, or is not likely to adversely affect any Federally listed terrestrial species, nor will it
39 adversely impact any designated critical habitat. Thus, the staff concludes that the impact on
40 threatened or endangered terrestrial species from an additional 20 years of operation would be
41 SMALL, and additional mitigation is not warranted.
42

4.7 Evaluation of Potential New and Significant Information on Impacts of Operations During the License Renewal Term

The GEIS assesses 92 environmental issues. Sixty-nine of these issues were found to be Category 1 issues, and are identified in 10 CFR Part 51 as not requiring additional plant-specific analysis in the absence of new and significant information. The staff reviewed the list and consulted with the appropriate Federal, State, and local agencies to identify any compliance or permit issues or significant environmental issues of concern to the reviewing agencies. These agencies did not identify any new and significant environmental issues. The ER states that TVA is in compliance with applicable environmental standards and requirements for BFN. The staff has not identified any environmental issues that are both new and significant.

The staff identified one potential issue that required further analysis. Category 1 issues were established by the GEIS after a review of data from existing operating nuclear plants. The analysis established an envelope of impact for each of the Category 1 issues that were based on the impacts that were identified at nuclear power plants throughout the United States at the time the GEIS was prepared. TVA has applied for extended power uprate (EPU) for the three BFN units. These EPUs would eventually increase thermal power levels from the initially licensed levels of 3293 MW(t)/unit to 3952 MW(t)/unit. This represents a total power increase of 20 percent. Once the uprate has been achieved, BFN will have a combined total power level of 11,856 MW(t), and will become the largest nuclear power plant in the United States.

For this reason, the staff determined that there is a potential that, at the uprated power level, BFN may no longer be within the envelope of impacts defined by the GEIS, as amended, for some Category 1 issues. If the potential impacts are beyond the defined envelope, the generic conclusions concerning these Category 1 issues may no longer be valid, and the power uprate could therefore represent new and significant information regarding some of the Category 1 issues. Category 2 issues are not a concern in this regard because all applicable Category 2 issues are evaluated on a site-specific basis for each facility undergoing license renewal.

To address this concern, the staff examined each of the 54 Category 1 issues applicable to BFN and determined that 34 of the Category 1 issues could be influenced by the station thermal power level. The staff then evaluated each of the 34 issues to determine if increasing the unit power level above the levels considered during the development of the GEIS would affect the specific generic conclusions. After evaluating all 34 issues the staff determined that the generic conclusions reached in the GEIS are still valid and that no additional analysis or evaluation of these issues is necessary. The 34 issues evaluated are listed in Tables 4-13 through 4-17. An explanation of why the GEIS conclusion is still valid for the uprated BFN site is provided following each table.

Environmental Impacts of Operation

Table 4-13. Cooling System-Related Category 1 Issues that are Potentially Affected by Proposed Extended Power Uprates at Browns Ferry Nuclear Power Plant, Units 1, 2, and 3

ISSUE 10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Sections
SURFACE WATER QUALITY, HYDROLOGY, AND USE (for all plants)	
Altered current patterns at intake and discharge structures	4.2.1.2.1; 4.3.2.2; 4.4.2
Altered thermal stratification of lakes	4.2.1.2.3; 4.4.4.2

Table 4-13. (contd)

ISSUE 10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Sections
Temperature effects on sediment transport capacity	4.2.1.2.3; 4.4.2.2
Scouring caused by discharged cooling water	4.2.1.2.3; 4.4.2.2
Eutrophication	4.2.1.2.3; 4.4.2.2
Discharge of chlorine or other biocides	4.2.1.2.4; 4.4.2.2
Discharge of other metals in wastewater	4.2.1.2.4; 4.3.2.2; 4.4.2.2
Water use conflicts (plants with once-through cooling systems)	4.2.1.3

AQUATIC ECOLOGY (for all plants)

Accumulation of contaminants in sediments or biota	4.2.1.2.4; 4.3.3; 4.4.3; 4.4.2.2
Entrainment of phytoplankton and zooplankton	4.2.2.1.1; 4.3.3; 4.4.3
Cold shock	4.2.2.1.5; 4.3.3; 4.4.3
Thermal plume barrier to migrating fish	4.2.2.1.6; 4.4.3
Distribution of aquatic organisms	4.2.2.1.6; 4.4.3
Low dissolved oxygen in the discharge	4.2.2.1.9; 4.3.3; 4.4.3

Table 4-13. (contd)

Losses from predation, parasitism, and disease among organisms exposed to sublethal stresses	4.2.2.1.10; 4.4.3
Stimulation of nuisance organisms	4.2.2.1.11; 4.4.3
Premature emergence of aquatic insects	4.2.2.1.7; 4.4.3

TERRESTRIAL RESOURCES

Cooling tower impacts on crops and ornamental vegetation	4.3.4
Cooling tower impacts on native plants	4.3.5.1

Table 4-13. (Contd)

SURFACE WATER QUALITY, HYDROLOGY, AND USE (FOR ALL PLANTS)	
HUMAN HEALTH	
Microbiological organisms (occupational health)	4.3.6
Noise	4.3.7

Altered current patterns at intake and discharge structures

Any localized effects on current patterns would have been manifest during the initial stages of three-unit operation and would have been mitigated, if necessary, at that time. Three-unit operation at BFN, at the combined total power level of 11,856 WM (t) expected during the license renewal term, uses existing intake and discharge structures and “no changes are expected to the individual unit flow rates as a result of EPU” (TVA 2002). Total intake flow is expected to be a maximum of 139 m³/s (4907 cfs) or 12 million m³/d (3171 MGD) (TVA 2003b). The staff concludes that the cooling system operation on current patterns is within the envelope of impacts considered in the GEIS as a Category 1 issue.

- Altered thermal stratification of lakes

TVA has modeled temperature stratification in Wheeler Reservoir with near- and far-field modeling. Three-unit operation at BFN, at the combined total power level of 11,856 MW (t) expected during the license renewal term, will increase the water discharge temperature and resulting thermal stratification; however, it will not exceed temperature limits set by the NPDES permit (Hopping 2004). The licensee will be required to operate within the limits of the NPDES permit during the license renewal term. The limits impose the most severe restrictions in the late summer when thermal stratification is most pronounced at the reservoir. The staff concludes that the effect of the cooling system operation on altered thermal stratification is within the envelope of impacts considered in the GEIS as a Category 1 issue.

- Temperature effects on sediment transport capacity

Three-unit operation at BFN, at the combined total power level of 11,856 MW(t) expected during the license renewal term, will increase the water discharge temperature and theoretically could decrease viscosity and change the sediment transport capacity within the Tennessee River. The difference in the discharge temperature is not significant relative to changing the viscosity of the water, and the area of the reservoir affected by elevated temperature is small. This would not result in a detectable change in sediment transport capacity. The staff concludes that the effect of the cooling system operation on temperature effects on sediment transport capacity is within the envelope of impacts considered in the GEIS as a Category 1 issue.

Environmental Impacts of Operation

- 1 • Scouring caused by discharged cooling water

2
3 Three-unit operation at BFN, even at the combined total power level of 11,856 MW(t) expected
4 during the license renewal term, uses existing intake and discharge structures and "no changes
5 are expected to the individual unit flow rates as a result of EPU" (TVA 2002). Total intake flow
6 is expected to be a maximum of 139 m³/s (4907 cfs) or 12 million m³/d (3171 MGD) (TVA
7 2003b). The staff concludes that the effect of the cooling system operation on scouring is
8 within the envelope of impacts considered in the GEIS as a Category 1 issue.

- 9
10 • Eutrophication

11
12 Three-unit operation at BFN, at the combined total power level of 11,856 MW(t) expected
13 during the license renewal term, will increase water discharge temperature, but all discharges
14 will continue to be within the thermal limits established in the NPDES permit. The licensee will
15 be required to operate within the limits of the NPDES permit during the license renewal term.
16 The limits impose the most severe restrictions in the late summer when thermal stratification is
17 most pronounced in the reservoir. The staff concludes that the effect of the cooling system
18 operation on eutrophication is within the envelope of impacts considered in the GEIS as a
19 Category 1 issue.

- 20
21 • Discharge of chlorine or other biocides

22
23 BFN uses some biocides in parts of the service water system, but currently does not use
24 chlorine or other biocides in the cooling water system. Therefore, resumption of three-unit
25 operation at BFN, even at the 120 percent EPU expected during the license renewal term, is
26 not likely to alter the quantity of biocides released from the station. Based on the need to stay
27 within NPDES limits, no additional mitigation measures to reduce the discharge of biocides are
28 necessary during the license renewal term. The effect of the cooling system operation on
29 discharge of biocides is within the envelope of impacts considered in the GEIS as a Category 1
30 issue.

- 31
32 • Discharge of other metals in waste water

33
34 Three-unit operation at BFN at the combined total power level of 11,856 MW(t) expected during
35 the license renewal uses existing intake and discharge structures and "no changes are
36 expected to the individual unit flow rates as a result of EPU" (TVA 2002). Total intake flow is
37 expected to be a maximum of 139 m³/s (4907 cfs) or 12 million m³/d (3171 MGD) (TVA 2003b).
38 Discharges of heavy metals are controlled under the NPDES permitting system administered by
39 the State of Alabama. The current NPDES permit restricts the discharge of heavy metals.
40 Furthermore, the main condensers of all three units will be re-tubed with stainless steel prior to
41 the license renewal term. The staff concludes that the effect of the cooling system operation on

1 discharge of metals in waste water is within the envelope of impacts considered in the GEIS as
2 a Category 1 issue.

3
4 • Water-use conflicts (plants with once-through cooling systems)

5
6 Three-unit operation at BFN, at the combined total power level of 11,856 MW(t) expected
7 during the license renewal term, uses existing intake and discharge structures and "no changes
8 are expected to the individual unit flow rates as a result of EPU" (TVA 2002). Consumptive and
9 off-stream water uses have not resulted in significant water-use conflicts because of the large
10 volume of the Wheeler Reservoir water available, the high river flow rate, and the return of most
11 of the water withdrawn (TVA 2003b). Regulatory control of withdrawal rates and NPDES permit
12 limits for return water quality also mitigate potential conflicts. The staff concludes that the effect
13 of water-use conflicts is within the envelope of impacts considered in the GEIS as a Category 1
14 issue.

15
16 • Accumulation of contaminants in sediments or biota

17
18 The three-unit operation at BFN, at the combined total power level of 11,856 WM(t) expected
19 during the license renewal term, uses existing intake and discharge structures and "no changes
20 are expected to the individual unit flow rates as a result of EPU" (TVA 2002). The condensers
21 at BFN are being re-tubed with stainless steel tubing (TVA 2003b). Therefore, accumulation of
22 contaminants associated with the condenser tubes in sediment or biota would not be expected
23 to be a concern during the license renewal term. Furthermore, compliance with the NPDES
24 permit, other provisions of the FWPCA (e.g., Sections 316(a) and 316(b), 401, and 404), and
25 other regulatory requirements are expected to adequately control potential chemical effluent
26 effects (TVA 2003b). The staff concludes that the effect of the accumulation of contaminants in
27 sediments or biota is within the envelope of impacts considered in the GEIS as a Category 1
28 issue.

29
30 • Entrainment of phytoplankton and zooplankton

31
32 Because of the large numbers and short generation times of phytoplankton and zooplankton,
33 impacts of entrainment on these organisms have rarely been documented outside the
34 immediate vicinity of the plant and are considered to be of little consequence (NRC 1996).
35 Algal surveys conducted in 1989 (during plant shutdown) and again in 1991 (during plant
36 operation) did not indicate that operation of BFN under current thermal plume criteria had any
37 impact on the phytoplankton community of Wheeler Reservoir (Lowery and Poppe 1992).
38 Results from a two-dimensional, far-field model that included an assessment of the effects on
39 reservoir algal biomass were essentially unchanged with all three units operating at a combined

Environmental Impacts of Operation

1 total power level of 11,856 MW(t) (TVA 2003b). The staff concludes that the effect on
2 entrainment of phytoplankton or zooplankton is within the envelope of impacts considered in the
3 GEIS as a Category 1 issue.

4
5 • Cold shock
6

7 It would not be expected that all three units would go off-line at the same time. Cold-shock
8 mortalities, even at one-unit plants, are relatively rare and usually involve small numbers of fish.
9 No population-level impacts have been observed (NRC 1996). Therefore, any fish that do
10 occupy the thermal plume during winter conditions would still have areas of above-ambient
11 temperatures to occupy during one- or two-unit operation. Furthermore, the high-velocity
12 diffusers provide for rapid mixing of the heated discharge waters with ambient-temperature river
13 water and discourage fish from residing in the warmest portion of the plume. The staff
14 concludes that the effect of cold shock from operation is within the envelope of impacts
15 considered in the GEIS as a Category 1 issue.

16
17 • Thermal plume barrier to migrating fish
18

19 The impact of the thermal plume is constrained by the NPDES permit. The NPDES permit
20 limits are designed to protect aquatic species, in particular, to prevent the establishment of a
21 thermal plume barrier to fish migration. The licensee will be required to operate within the limits
22 of the NPDES permit during the license renewal term. Furthermore, fish species typical of
23 those that predominate Wheeler Reservoir have a range difference of at least 5°C (9°F) to over
24 10°C (18°F) between their acclimation temperature and upper avoidance temperature (Cherry
25 et al. 1975). The staff concludes the effect of the thermal plume as a barrier to migrating fish is
26 within the envelope of impacts considered in the GEIS as a Category 1 issue.

27
28 • Distribution of aquatic organisms
29

30 Past operations of BFN have not been shown to affect the distribution of aquatic organisms in
31 Wheeler Reservoir (TVA 2003b). As discussed in Section 2.2.5, the aquatic biota are primarily
32 affected by physical and chemical changes to the Tennessee River that have occurred from its
33 modification from a free-flowing river to a series of run-of-the-river reservoirs. Within the
34 reservoir, there are three somewhat distinct zones: the tailwaters of the upstream dam, the
35 transition area (within which BFN is located), and the more lacustrine (lake-like) conditions in
36 the area upstream of the reservoir dam. The distribution of aquatic biota in Wheeler Reservoir
37 is primarily influenced by the habitats and physicochemical conditions within each zone. The
38 staff concludes the effect of the distribution of aquatic organisms is within the envelope of
39 impacts considered in the GEIS as a Category 1 issue.
40

1 • Premature emergence of aquatic insects

2
3 The discharge diffusers will ensure adequate mixing of the discharge flow and the receiving
4 waters. Typically, the warmer water is buoyant and does not impinge directly on the reservoir
5 substrate. The licensee has a considerable amount of benthic data from Wheeler Reservoir
6 that show no impact related to premature emergence of insects. The additional heat
7 associated with the combined total power level of 11,856 MW(t) is not expected to significantly
8 increase the amount of benthic invertebrate habitat that is subject to elevated temperatures.
9 The staff concludes the effect of thermal discharge on premature emergence of aquatic insects
10 is within the envelope of impacts considered in the GEIS as a Category 1 issue.

11
12 • Low dissolved oxygen in the discharge

13
14 Current dissolved oxygen levels near the BFN site is rated "good" by TVA (TVA 2004b).
15 Results from simulations using a two-dimensional, far-field model that included an assessment
16 of the effects on reservoir dissolved oxygen concentrations were essentially unchanged under
17 all three units operating at a combined total power level of 11,856 MW(t) (TVA 2003b). Thus,
18 as long as the licensee maintains compliance with the NPDES regulatory requirements,
19 operation of all three units at a combined total power level of 11,856 MW(t) of original power is
20 expected to have insignificant effects on dissolved oxygen concentrations. The staff concludes
21 the effect of low dissolved oxygen discharges is within the envelope of impacts considered in
22 the GEIS as a Category 1 issue.

23
24 • Losses from predation, parasitism, and disease among organisms exposed to sublethal
25 stresses

26
27 Although it is likely that operation of a once-through cooling system will cause some changes in
28 predator-prey relationships, the fact that no long-term changes in population- or community-
29 level effects from operation of BFN have been observed (TVA 2003b) is evidence that losses
30 from predation, parasitism, and disease are not occurring from sublethal stresses (NRC 1996).
31 The Vital Signs Monitoring Program and other assessments of aquatic biota in Wheeler
32 Reservoir have not demonstrated any changes to aquatic organisms related to predation,
33 parasitism, or disease that could be attributable to sublethal stresses (thermal, physical, or
34 chemical) caused by operations of BFN. The Vital Signs Monitoring Reservoir Fish
35 Assemblage Index has been determined for fish in Wheeler Reservoir since the early 1990s.
36 This index considers fish disease, lesions, parasites, and abnormalities as factors in
37 determining the index. The index value downstream of BFN has been as good as or better than
38 other portions of the reservoir (Section 2.2.5). No fish consumption advisories exist for the
39 mainstream of Wheeler Reservoir (Section 2.2.5). Thermal and chemical discharges from BFN
40 are governed by the NPDES permit. Thermal and chemical discharges can stress aquatic
41 organisms leading to increased parasitism and disease. Discharge limits are established at

Environmental Impacts of Operation

1 levels that are protective of aquatic biota. As permit conditions would not change, the effects of
2 BFN operation at a combined total power level of 11,856 MW(t) on predation, parasitism, and
3 disease on organisms exposed to sublethal stresses would likely remain the same. The staff
4 concludes that the effect of predation, parasitism, and disease among organisms exposed to
5 sublethal stresses is within the envelope of impacts considered in the GEIS as a Category 1
6 issue.

7
8 • Stimulation of nuisance organisms

9
10 Past operations of BFN have not been shown to stimulate nuisance organisms. Water levels in
11 Wheeler Reservoir are actively managed during the summer to limit mosquito breeding habitat
12 (Section 2.2.5). Physical and chemical treatment of the cooling system has had a controlling
13 influence on the Asiatic clam (*Corbicula fluminea*) in the immediate plant area. Thermal dis-
14 charges in the immediate area of the diffusers are at a level that can adversely impact Asiatic
15 clams. When ambient reservoir temperatures are 22.4°C (72.4°F) or more, the maximum
16 24-hour average temperature rise of 5.6°C (10°F) would be above the optimum summer
17 temperatures for the zebra mussel (*Dreissena polymorpha*). Therefore, increased thermal
18 loading associated with operation of the plant at 120 percent power levels would have a further
19 localized controlling influence over these nuisance species. The staff concludes that the effect
20 on the stimulation of nuisance organisms is within the envelope of impacts considered in the
21 GEIS as a Category 1 issue.

22
23 • Cooling tower impacts on crops and ornamental vegetation

24
25 Although the cooling towers are likely to be operated more frequently with three units operating
26 at a combined total power level of 11,856 MW(t) (TVA 2003b), because they are helper towers,
27 they will be operated less frequently than those located at plants with closed-cycle cooling
28 systems. The staff determined in the GEIS that cooling tower impacts on crops and ornamental
29 vegetation at plants where the cooling towers are operated continuously was not significant.
30 The staff concludes that the effect of cooling towers impacts on crops and ornamental
31 vegetation is within the envelope of impacts considered in the GEIS as a Category 1 issue.

32
33 • Cooling tower impacts on native vegetation

34
35 Although the cooling towers are likely to be operated more frequently with three units operating
36 at a combined total power level of 11,856 MW(t) (TVA 2003b), because they are helper towers,
37 they will be operated less frequently than those located at plants with a closed-cycle cooling
38 system. The staff determined in the GEIS that cooling tower impacts on native vegetation at
39 plants where the cooling towers are operated continuously was not significant. The staff
40 concludes that the effect of cooling towers on native vegetation is within the envelope of
41 impacts considered in the GEIS as a Category 1 issue.
42

1 • Microbial organisms (occupational health)

2
3 As discussed in Section 4.1.5, some thermophilic microbiological organisms have a range of
4 optimum conditions within the range of temperatures that would occur at either 100 percent or
5 120 percent power levels. BFN was one of nine power plants that participated in a study in the
6 early 1980s on the presence of *Legionella* spp. in power plant cooling systems. As with most
7 locations studied, *Legionella* spp. bacteria were found in ambient-temperature (intake), pre-
8 condenser, post-condenser, and outfall (discharge) waters, though not in concentrations
9 sufficiently high to be a health concern. Subsequent studies determined that concentrated
10 *Legionella* spp. aerosols could present a health concern for workers cleaning condenser tubes
11 and cooling towers. As a precaution, BFN has adopted the practice of having workers engaged
12 in these activities wear appropriate respiratory protection (TVA 2003b). Therefore, even though
13 condenser tube and cooling tower cleaning requirements for a three-unit operation may
14 increase, the potential for occupational health risks would still be negligible, because health
15 risks would not increase due to of the use of appropriate respiratory protection. The staff
16 concludes the effect of microbial organisms on occupational health is within the envelope of
17 impacts considered in the GEIS as a Category 1 issue.

18
19 • Noise

20
21 The cooling towers are likely to be operated more often when there are three units operating at
22 a combined total power level of 11,856 MW(t) (TVA 2003b), and thus there would be more days
23 per year when noise from tower operations could affect onsite personnel or be detected offsite.
24 However, because these are helper towers, they will be operated intermittently, and not
25 continuously as they are at plants with closed-cycle cooling systems. The staff determined in
26 the GEIS that the impacts of cooling tower noise at plants with continuously operated towers
27 are not significant. The staff concludes the effect of noise from the cooling towers is within the
28 envelope of impacts considered in the GEIS as a Category 1 issue.

29
30
31 **Table 4-14. Radiological Impacts of Normal Operations-Related Category 1 Issues that are**
32 **Potentially Affected by Proposed Extended Power Uprates at Browns Ferry**
33 **Nuclear Power Plant, Units 1, 2, and 3**

34

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Sections
HUMAN HEALTH	
Radiation exposures to public (license renewal term)	4.6.2
Occupational radiation exposures (license renewal term)	4.6.3

35
36
37
38
39
40
41

Environmental Impacts of Operation

- Radiation exposures to public (license renewal term)

Some increase in radionuclide emissions might occur as a result of the combined total power level of 11,856 MW(t) (TVA 2003b); the increase would be up to a factor of 1.8 over current two unit operations if the increase is proportional to the power level. Recent routine emissions at the site have been well below regulatory limits. Furthermore, BFN, regardless of the thermal power level, will be required to operate during the license renewal term within the regulatory limits. The staff concludes that the effects of radiation exposure to the public is within the envelope of impacts considered in the GEIS as a Category 1 issue provided that releases are maintained within the regulatory limits.

- Occupational radiation exposures (license renewal term)

Some increase in worker dose rates might occur as a result of the combined total power level of 11,856 MW(t) (TVA 2003b); the increase would be up to a factor of 1.8 over current two unit operations if the increase is proportional to the power level. However, application of as low as reasonably achievable (ALARA) principles has reduced worker exposures relative to historic levels, and doses to individual workers at the site would be controlled to remain below regulatory limits. The staff determined in the GEIS that the dose-related impacts to workers are of small significance if doses and releases do not exceed permissible levels in the Commission's Regulations. BFN, regardless of the thermal power level, will be required to operate within the regulatory limits. The staff concludes the effect of occupational radiation exposure is within the envelope of impacts considered in the GEIS as a Category 1 issue provided that the exposure to workers is maintained within the regulatory limits.

Table 4-15. Socioeconomic-Related Category 1 Issue Potentially Affected by Proposed Extended Power Uprates at Browns Ferry Nuclear Power Plant, Units 1, 2, and 3

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Section
SOCIOECONOMIC	
Aesthetic impacts (license renewal term)	4.7.6

- Aesthetic impacts (license renewal term)

The cooling towers are likely to be operated more often when there are three units operating at a combined total power level of 11,856 MW(t) (TVA 2003b); thus, there would be more days per year when there is a visible steam plume, and when noise from tower operations could be detected offsite. However, because these are helper towers, they will be operated intermittently, and not continuously as they are located at plants with closed-cycle cooling systems. The staff determined in the GEIS that the aesthetic impacts of cooling tower plumes at plants with continuously operated towers are not significant. The staff concludes the effects of aesthetic impacts of cooling tower plumes is within the envelope of impacts considered in the GEIS as a Category 1 issue.

Table 4-16. Postulated Accident-Related Category 1 Issue Potentially Affected by Proposed Extended Power Uprates at Browns Ferry Nuclear Power Plant, Units 1, 2, and 3

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Section
Design basis accidents	5.3.2, 5.5.1

- Design-basis accidents

TVA is required to submit an updated Final Safety Analysis Report as part of the EPU license amendment application. NRC staff evaluates this Final Safety Analysis Report, the application, and the design of the facility prior to granting or denying the EPU application. If the EPU is granted, the staff will have evaluated design-basis accidents (DBAs) in light of the new power level, and will have determined that postulated DBA doses continue to meet NRC regulations. Therefore, the environmental impacts of DBAs will continue to be small. The staff concludes that the effect of the cooling system operation on DBAs is within the envelope of impacts considered in the GEIS as a Category 1 issue.

Table 4-17. Uranium Fuel Cycle and Waste Management-Related Category 1 Issues Potentially Affected by Proposed Extended Power Uprates at Browns Ferry Nuclear Plant, Units 1, 2, and 3

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Sections
Offsite radiological impacts (individual effects from other than the disposal of spent fuel and high-level waste)	6.1; 6.2.1; 6.2.2.1; 6.2.2.3; 6.2.3; 6.2.4; 6.6
Offsite radiological impacts (collective effects)	6.1; 6.2.2.1; 6.2.3; 6.2.4; 6.6
Offsite radiological impacts (spent fuel and high-level waste)	6.1; 6.2.2.1; 6.2.3; 6.2.4; 6.6
Nonradiological impacts of the uranium fuel cycle	6.1; 6.2.2.6; 6.2.2.7; 6.2.2.8; 6.2.2.9; 6.2.3; 6.2.4; 6.6
Low-level waste storage and disposal	6.1; 6.2.2.2; 6.4.2; 6.4.3; 6.4.3.1; 6.4.3.2; 6.4.3.3; 6.4.4; 6.4.4.1; 6.4.4.2; 6.4.4.3; 6.4.4.4; 6.4.4.5; 6.4.4.5.1; 6.4.4.5.2; 6.4.4.5.3; 6.4.4.5.4; 6.4.4.6; 6.6
Mixed waste storage and disposal	6.4.5.1; 6.4.5.2; 6.4.5.3; 6.4.5.4; 6.4.5.5; 6.4.5.6; 6.4.5.6.1; 6.4.5.6.2; 6.4.5.6.3; 6.4.5.6.4; 6.6

Environmental Impacts of Operation

Table 4-17. (Contd)

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Sections
Onsite spent fuel	6.1; 6.4.6; 6.4.6.1; 6.4.6.2; 6.4.6.3; 6.4.6.4; 6.4.6.5; 6.4.6.6; 6.4.6.7; 6.6
Nonradiological waste	6.1; 6.5; 6.5.1; 6.5.2; 6.5.3; 6.6
Transportation	6.1; 6.3.1; 6.3.2.3; 6.3.3; 6.3.4; 6.6, Addendum 1

- Offsite radiological impacts (individual effects from other than the disposal of spent fuel and high-level waste)

Offsite impacts of the uranium fuel cycle have been considered by the Commission in Table S-3 in 10 CFR 51.51(b). Based on information in the GEIS, impacts on individuals from radioactive gaseous and liquid releases including radon-222 and technetium-99 are small. There may be some local increase in radiological emissions in the immediate vicinity of the facility; however, the impact on the entire uranium fuel cycle would be negligible. Regardless of the combined total power level at BFN, the plant and fuel cycle facilities will continue to be required to operate within applicable regulatory limits. The staff concludes the effect of offsite radiological impacts (individual effects from other than the disposal of spent fuel and high-level waste) is within the envelope of impacts considered in the GEIS as a Category 1 issue.

- Offsite radiological impacts (collective effects)

Some increase in radionuclide emissions might occur at BFN as a result of increased fuel requirements for the combined total power level of 11,856 MW(t); the increase would be up to a factor of 1.8 over current two unit operations if the increase is proportional to the power level. Nevertheless, releases would continue to be required to be within regulatory limits. Collective doses to the population in the vicinity of BFN have been well below levels that would result in estimated health effects; therefore, collective dose to the BFN surrounding population would remain small. Nationwide, a potential increase in annual radiation exposures to the public from BFN would be inconsequential and not substantially change the GEIS conclusions. The staff concludes that the effect of offsite radiological impacts (collective effects) is within the envelope of impacts considered in the GEIS as a Category 1 issue provided that the releases are maintained to within the regulatory limits.

- Offsite radiological impacts (spent fuel and high-level waste)

Some increase in radiation dose to members of the public might result from increased spent fuel generation during reactor operations at a combined total power level of 11,856 MW(t); the increase would be up to a factor of 1.8 over current two unit operations if the increase is proportional to the power level. During the uprated operational period, public exposures from

1 spent fuel disposal would be maintained within regulatory limits and are expected to remain
2 small. The staff concludes that the effect of offsite impacts (spent fuel and high-level waste) is
3 within the envelope of impacts considered in the GEIS as a Category 1 issue provided that
4 exposure to the public is maintained to within the regulatory limits.

5
6 • Nonradiological impacts of the uranium fuel cycle

7
8 Uprate of the power level at BFN would result in needs for somewhat larger quantities of fuel,
9 as well as increased need for spent fuel and waste storage and disposal. The nonradiological
10 impacts of these activities would be reflected in needs for additional workforce to carry out fuel
11 manufacturing and waste and spent fuel management activities. Those activities could also
12 result in an additional potential for industrial accidents and illnesses. However, they would not
13 necessarily entail a higher risk than alternative occupations in which the workforce might be
14 engaged. Other nonradiological impacts, such as land use, fugitive dust generation, air-quality
15 impacts, erosion, sedimentation, and disturbance of ecosystems, are unlikely to increase
16 substantially. The effect on the entire United States uranium fuel cycle from the additional fuel
17 utilization at BFN would be negligible. The staff concludes that the effect of nonradiological
18 impacts of the uranium fuel cycle is within the envelope of impacts considered in the GEIS as a
19 Category 1 issue.

20
21 • Low-level waste storage and disposal

22
23 Some increase in radiation dose to members of the public might result from increased LLW
24 storage and disposal during reactor operations at a combined total power level of
25 11,856 MW(t); the increase would be up to a factor of 1.8 over current two unit operations if the
26 increase is proportional to the power level. During the uprated operational period, public
27 exposures from LLW disposal would be maintained within regulatory limits and are expected to
28 remain small. The staff concludes the effect of public exposure from LLW storage and disposal
29 is within the envelope of impacts considered in the GEIS as a Category 1 issue provided that
30 exposure to the public is maintained to within the regulatory limits.

31
32 • Mixed waste storage and disposal

33
34 Some increase in radiation dose to members of the public and exposure to toxic materials might
35 result from increased mixed waste generation during reactor operations at a combined total
36 power level of 11,856 MW(t); the increase would be up to a factor of 1.8 over current two unit
37 operations if the increase is proportional to the power level. During the uprated operational
38 period, public exposures from mixed waste disposal would be maintained within regulatory limits
39 and are expected to remain small. Any increase in mixed waste storage would be within the
40 current BFN storage capacity, and additional impact on licensed mixed waste disposal facilities
41 would be minimal. The staff concludes the effect of mixed waste storage and disposal is within

Environmental Impacts of Operation

1 the envelope of impacts considered in the GEIS as a Category 1 issue provided that the
2 radiation dose to the public is maintained to within the regulatory limits.

3
4 • Onsite spent fuel

5
6 Some marginal increase in onsite storage of spent fuel is expected as a result of a combined
7 total power level of 11,856 MW(t). The commission has made a generic determination that, if
8 necessary, spent fuel generated in any reactor can be stored safely and without significant
9 environmental impacts for at least 30 years beyond the license life for generation including any
10 license renewal term. During the uprated operational period, occupational exposures from
11 spent fuel management would be maintained within regulatory limits and with continuing
12 application of ALARA principles, are expected to remain small. The staff concludes that the
13 effect on occupational exposure from onsite spent fuel is within the envelope of impacts
14 considered in the GEIS as a Category 1 issue provided that the occupational exposure is
15 maintained to within the regulatory limits during the storage period.

16
17 • Nonradiological waste

18
19 Operation of BFN at uprated power levels is not expected to substantially change the quantities
20 of nonradiological waste generated at the facility. Any small marginal increases in routine
21 nonradiological waste generated at the plant would be well within quantities that could be
22 accommodated by onsite or community waste management facilities, and ongoing waste
23 minimization and recycling programs are expected to continue to reduce the quantities of these
24 wastes. The staff concludes the effect from nonradiological waste is within the envelope of
25 impacts considered in the GEIS as a Category 1 issue.

26
27 • Transportation

28
29 Some increase in radiation dose to members of the public and transportation workers might
30 result from increased transport of unirradiated fuel, spent fuel, and radiological wastes during
31 reactor operations at a combined total power level of 11,856 MW(t); the increase would be up
32 to 20 percent during operation, if the increase is in proportion to the power level. Because of
33 the regulatory requirements related to fuel shipments, the staff believes that any increase in
34 BFN impact due to the combined total power level will be consistent with the impact values
35 contained in 10 CFR 51.52(c), Summary Table S-4 - Environmental Impact of Transportation of
36 Fuel and Waste to and from One Light-Water-Cooled Nuclear Power Reactor. The staff
37 concludes that the effect of transportation of the unirradiated fuel, spent fuel, and radiological
38 wastes is within the envelope of impacts considered in the GEIS as a Category 1 issue provided
39 that the dose to the public and transportation workers is maintained to within the regulatory
40 limits during the renewal period.
41

4.8 Cumulative Impacts of Operations During the License Renewal Term

The staff considered the potential cumulative impacts during the evaluation of information applicable to each of the potential impacts of operations during the license renewal term identified within the GEIS. For purposes of this analysis, past actions were those related to the resources at the time of plant licensing and construction, present actions are those related to the resources at the time of current operation of the power plant, and future actions are considered to be those that are reasonably foreseeable through the end of the current license term, as well as the 20-year license renewal term. The geographical area over which past, present, and future actions could contribute to cumulative impacts is dependent on the type of action considered, and is described below for each impact area.

The impacts of the proposed action are combined with other past, present, and reasonably foreseeable future actions at BFN, regardless of what agency (Federal or non-Federal) or person undertakes such other actions. These combined impacts are defined as "cumulative" in 40 CFR 1508.7 and include individually minor, but collectively significant, actions taking place over time. It is possible that an impact that may be SMALL by itself could result in a MODERATE or LARGE impact when considered in combination with the impacts of other actions on the affected resource. Likewise, if a resource is regionally declining or imperiled, even a SMALL individual impact could be important if it contributes to or accelerates the overall resource decline.

4.8.1 Cumulative Impacts Resulting from Operation of the Plant Cooling System

For the purposes of this analysis, the geographic area considered for cumulative impacts resulting from operation of the BFN cooling system is primarily the Wheeler Reservoir portion of the Tennessee River. Wheeler Reservoir is located within the Lower Tennessee River Basin which extends from Chattanooga, Tennessee, to near Paducah, Kentucky. The main stem of the Tennessee River in this area is highly regulated with few free-flowing reaches. Six major reservoirs are located within the Lower Tennessee River, and three additional reservoirs are located on its major tributaries (USGS 1998). The reservoirs were created for the purpose of power generation, navigation, and flood control. They are also used extensively as sources of drinking water and for recreational activities (USGS 1998.) Interbasin transfers of water occur downstream of BFN (i.e., with the Mobile River Basin via the Tennessee-Tombigbee Waterway near the Pickwick Reservoir and with the Cumberland River Basin through the Barkley-Kentucky Canal at the Kentucky Reservoir) (Kingsbury et al. 1999).

The mean annual streamflow in the Lower Tennessee River Basin ranges from about 1017 m³/s (35,900 cfs) at Chattanooga, Tennessee, to 1858 m³/s (65,600 cfs) at Paducah, Kentucky. Elk

Environmental Impacts of Operation

1 and Duck Rivers are the two largest tributaries within the lower Tennessee River Basin and
2 contribute about 26 percent of the streamflow gained between Chattanooga and Paducah
3 (Kingsbury et al. 1999). Within the Tennessee River watershed, an average of 46.2
4 million m³/d (12.2 billion gpd) were used in 2000 for public supply, industrial water supply,
5 irrigation, and thermoelectric power generation; however, only about 5 percent (2.5 million m³/d
6 [649 MGD]) was used consumptively. By 2030, water withdrawals are projected to increase to
7 nearly 53 million m³/d (14 billion gpd) (Hutson et al. 2003). Most of the consumptive use
8 (2.0 million m³/d [530 MGD]) has occurred upstream of Wheeler Dam, and this is expected to
9 increase to 2.9 million m³/d (760 MGD) by 2030 (TVA 2003b). Within Wheeler Reservoir there
10 are eight potable water intakes that withdraw about 0.47 million m³/d (124 MGD) for municipal
11 and industrial use, while there are 11 municipal plant discharges totaling over 0.11 million m³/d
12 (30 MGD) and 18 municipal plants discharging more than 9.5 million m³/d (2513 MGD)
13 (TVA 2003b).

14
15 The main land cover in the Lower Tennessee River Basin is forest (55 percent) and row crops
16 and pastureland (41 percent). There are numerous industries along the mainstem of the
17 Tennessee River in northern Alabama. They manufacture and produce a variety of products
18 (e.g., missiles and rockets, electronics, pulp and paper, synthetic fibers, chemicals, aluminum,
19 and nickel-plated foam) (USGS 1998).

20
21 Section 2.2.5 discusses the major changes and modifications within the Tennessee River,
22 particularly the Wheeler Reservoir area, that have had the greatest effects on aquatic
23 resources. These include physical and chemical stresses, developments, overfishing (including
24 commercial clam harvests), and introduction of non-native species. Physical and chemical
25 stresses that have impacted the Tennessee River include urban, industrial, and agricultural
26 contaminants (e.g., nutrients, toxic chemicals, sediments); stream modifications (e.g., dams
27 and reservoirs); land use changes (e.g., residential, recreational, agricultural, and industrial
28 development); dredging (e.g., to maintain navigation channels); shoreline modifications;
29 wetland elimination and modification; water diversions (e.g., Tennessee-Tombigbee Waterway);
30 and commercial and recreational boating (TVA 2003b, 2004b).

31
32 Construction of the TVA reservoir system significantly altered both the water quality and
33 physical environment of the Tennessee River, with little regard for the subsequent effects on
34 aquatic resources (TVA 2004b). Overall, completion of the water control system on the
35 Tennessee River resulted in the following impacts (Barclay 2004):

- 36
- 37 • conversion of riverine habitat to reservoir pool habitat
- 38 • loss of riverine habitat and associated biota
- 39 • conversion of floodplain to reservoir pool
- 40 • loss of seasonal floodplain habitat and associated biota
- 41 • fragmentation of riverine sections
- 42 • disruption of fish migrations
- 43

- 1 • seasonal fluctuations of pool levels
- 2 • thermal stratification
- 3 • stress or mortality of organisms or sensitive life stages
- 4 • seasonal dissolved oxygen depletion in temperature stratified waters
- 5 • ammonia released by the presence of oxygen-depleted water
- 6 • disruption of sediment transport
- 7 • trapping of sediment, capture of toxic substances associated with substrates,
- 8 • toxic substance releases
- 9 • nutrient enrichment with consequent changes in habitat quality and associated species.

10
11 Within the Lower Tennessee River Basin, nutrient enrichment and pathogens have been
12 identified as water-quality issues affecting both surface water and groundwater. Nonpoint
13 sources for nutrients (nitrogen and phosphorous) include urban runoff, fertilizer application,
14 failing septic tanks, livestock waste, nitrogen fixation, sediment and rock dissolution, and
15 atmospheric deposition (Kingsbury et al.1999).

16
17 Because of the altered habitat conditions created by reservoir pools and dam tailwater, State
18 agencies introduced numerous sport and some prey species into the Tennessee River
19 watershed including several trout species, striped bass (*Morone saxatilis*), northern pike
20 (*Esox lucius*), yellow perch (*Perca flavescens*), walleye (*Stizostedion vitreum*), rainbow smelt
21 (*Osmerus mordax*), and alewife (*Alosa pseudoharengus*). Some of the game species are not
22 self-sustaining and, thus, continue to be stocked (TVA 2004b). Non-native species (e.g.,
23 common carp [*Cyprinus carpio*], grass carp [*Ctenopharyngodon idella*], Eurasian watermilfoil
24 [*Myriophyllum spicatum*], and Asian clam) have impacted native aquatic species. Further
25 spread or establishment of species such as the alewife, bighead carp (*Hypophthalmichthys*
26 *nobilis*), silver carp (*H. molitrix*), zebra and quagga mussels (*Dreissena bugensis*), rusty
27 crayfish (*Orconectes rusticus*), and the cladoceran *Daphnia lumholtzi* may also have major
28 impacts on the aquatic community dynamics in Wheeler Reservoir.

29
30 TVA's reservoir operations policy guides the day-to-day operation of the Tennessee River
31 system, and sets the balance of trade-offs for the sometimes competing uses of water in the
32 system. TVA undertook a study to determine if changes in its reservoir system operating
33 policies could produce a greater overall public value. A no-action alternative and eight
34 alternative operating policies were evaluated. The evaluations included the assumption that the
35 consumptive use of water above Wheeler Dam would increase by 0.87 million m³/d (230 MGD).
36 Reservoir operations over the 100 year hydrologic record were simulated. It was determined
37 that for all hydrologic conditions and for all alternatives the existing minimum flow past BFN
38 could be maintained (TVA 2004b). Therefore, the growth in consumptive water use would not
39 affect minimum flow past BFN regardless of the reservoir operating policy adopted.
40
41

Environmental Impacts of Operation

1 Under the preferred TVA reservoir system operating policy alternative, drawdown of Wheeler
2 Reservoir would begin on Labor Day rather than on August 1 to increase recreational
3 opportunities. Fluctuations in reservoir levels to strand mosquito eggs and larvae would
4 continue until Labor Day. Also, minimum winter elevations would be raised 15 cm (6 in.) to
5 ensure that the 3.4-m (11-ft) navigation channel is maintained throughout the reservoir
6 (TVA 2004b).
7

8 Under its regulatory programs, TVA treats wastewater effluents, collects and properly disposes
9 of potential contaminants, and undertakes pollution prevention activities that comply with
10 regulatory requirements and minimize the risk of adverse environmental impacts (TVA 2003b).
11 The BFN NPDES permit is renewed every 5 years; this helps to ensure that no changes have
12 been made to the facility that would alter aquatic impacts and that no significant adverse
13 impacts have occurred. Compliance with the NPDES process, other provisions of the FWPCA
14 (e.g., Sections 316[a], 316[b], 401, and 404), and other regulatory requirements are expected to
15 adequately control potential chemical effluent effects. In general, under these regulatory
16 programs, TVA treats wastewater effluents, collects and properly disposes of potential
17 contaminants, and undertakes pollution prevention activities that comply with regulatory
18 requirements and minimize the risk of adverse environmental impacts.
19

20 Future contributions to cumulative impacts to aquatic resources within Wheeler Reservoir would
21 generally occur from those actions that currently cause impacts (e.g., reservoir operations,
22 human habitation, urban and industrial development, agriculture, and commercial and recrea-
23 tional fisheries). There is a potential for severe impacts to aquatic resources from large oil or
24 chemical spills within Wheeler Reservoir or its tributaries, but the risk of such spills is relatively
25 small. The probability of smaller spills is higher, but the impacts from such spills would
26 probably be small, temporary, and additive, and unlikely to severely affect aquatic resources,
27 especially if spill response activities are undertaken when such events occur. The potential
28 exists for the expansion of exotic species that have already begun to occur in the Tennessee
29 River, and for additional exotic species to become established in Wheeler Reservoir.
30

31 The reservoir water supply is adequate to meet the needs of BFN for cooling purposes under all
32 conditions. The total BFN intake water flow of 139 m³/s (4907 cfs) can encompass a significant
33 fraction of the daily average river flow past the plant; however, consumptive water uses are
34 negligible and are expected to remain so throughout the license renewal term (TVA 2003b).
35 There are no significant cumulative impacts on water supply. The staff, while preparing this
36 assessment, assumed that other industrial, commercial, or public installations could be located
37 in the general vicinity of the BFN site prior to the end of BFN operations. The discharge of
38 water to Wheeler Reservoir from these facilities would be regulated by the ADEM. The
39 discharge limits are set considering the overall or cumulative impact of all of the other regulated
40 activities in the area. Compliance with the FWPCA and its NPDES permits minimizes
41 cumulative effects on aquatic resources.
42

1 There are also other power plants within the Tennessee River system that impact aquatic biota.
2 Entrainment, impingement, and, for non-hydroelectric plants, thermal discharges occur at other
3 power plants within the Tennessee River system. These include 11 coal-fired plants,
4 30 hydroelectric facilities, and three nuclear plants (including BFN) operated by the TVA
5 (ScanChattanooga.Com 2001) and non-TVA plants such as the two Calpine combined-cycle
6 plants near Decatur (TVA 2003b). Fish egg entrainment is not likely to be a serious problem at
7 most dams because the freshwater drum, mooneye and, possibly, skipjack herring are the only
8 species with buoyant or semibuoyant eggs. Larvae and juveniles of non-migratory species may
9 only be incidentally susceptible to turbine entrainment, and the resultant effects are not
10 significant to the dynamics of the reservoir's resident fish community (Cada 1990).

11
12 The staff has determined that the cumulative impacts of BFN cooling system operations
13 (including entrainment and impingement of fish and shellfish, heat shock, or any of the cooling
14 system-related Category 1 issues) are not contributing to an overall decline in water quality or
15 the status of the fishery or other aquatic resources, and no additional mitigation measures are
16 warranted.

17
18 Continued operation of BFN will require renewed discharge permits from the ADEM, which will
19 address changing requirements so that cumulative water-quality objectives are served.
20 Therefore, the staff concludes that the potential cumulative impacts of cooling system operation
21 contributed by the continued operation of BFN will be SMALL, and that no further mitigation
22 measures are warranted.

23 24 25 **4.8.2 Cumulative Impacts Resulting from Continued Operation of the** 26 **Transmission Lines**

27
28 The continued operation of the BFN electrical transmission facilities was evaluated to determine
29 if there is a potential for interactions with other past, present, and future actions that could result
30 in adverse cumulative impacts to terrestrial resources such as wildlife populations, the size and
31 distribution of habitat areas, aquatic resources such as wetlands and floodplains, and both the
32 acute and chronic effects of electromagnetic fields. For purposes of this analysis, the geo-
33 graphic area that encompasses the past, present, and foreseeable future actions that could
34 contribute to adverse cumulative effects is the area serviced by the transmission lines
35 associated with the BFN (Figure 2.4).

36
37 TVA follows right-of-way management procedures that were found to be protective of sensitive
38 ecological resources, including wildlife habitat, wetlands, and floodplains (TVA 2003b). TVA
39 maintains maps of known sensitive resources such as wetlands, and maintains the
40 transmission line rights-of-way to minimize impacts, with the result that no net loss of resources
41

Environmental Impacts of Operation

1 occurs. The maintenance procedures minimize disturbance to wildlife and, in many ways,
2 provide greater protection relative to many of the surrounding areas with other land uses.

3
4 The staff determined that the electrical current induced by the electromagnetic fields from the
5 BFN transmission lines is well below the National Electric Safety Code recommendations for
6 preventing electrical shock from induced currents. Therefore, continued operation of the BFN
7 transmission lines will not detectably change the overall potential for electrical shock in the
8 future within the analysis area. With respect to chronic effects of electromagnetic fields,
9 although the staff considers the GEIS conclusion of "not applicable" to be appropriate in regard
10 to BFN, the BFN transmission lines are not likely to detectably contribute to the regional
11 exposure to extremely low frequency electromagnetic fields (ELF-EMF). This conclusion is
12 based on the fact that BFN transmission lines primarily pass through sparsely populated, rural
13 areas, with few residences or businesses close enough to have detectable ELF-EMF.

14
15 Therefore, since the impacts from maintaining and operating the transmission system are so
16 minor that they will neither destabilize or noticeably alter the existing aquatic or terrestrial
17 environment, the staff determined that the cumulative impacts of continued operation of BFN
18 transmission lines will be SMALL, and that no additional mitigation is warranted.

20 4.8.3 Cumulative Radiological Impacts

21
22 EPA and NRC established radiological dose limits for protection of the public and workers from
23 both instantaneous and cumulative impacts of exposure to radiation and radioactive materials.
24 These dose limits are codified in 40 CFR Part 190 and 10 CFR Part 20. For the purpose of this
25 analysis, the area within an 80-km (50-mi) radius of the BFN site was included. As stated in
26 Section 2.2.7, TVA has conducted a radiological environmental monitoring program (REMP)
27 around the BFN site since 1968. The REMP measures radiation and radioactive materials from
28 all sources, including BFN. Additionally, in Sections 2.2.7 and 4.3, the staff concluded that
29 impacts of radiation exposure to the public and workers (occupational) from operation of BFN
30 during the license renewal term are small. Therefore, the monitoring program and staff's
31 conclusion considered cumulative impacts. The NRC and the State of Alabama would regulate
32 any reasonably foreseeable future actions in the vicinity of the BFN site that could contribute to
33 cumulative radiological impacts.

34
35 Therefore, the staff concludes that cumulative radiological impacts of continued operations of
36 BFN would be SMALL, and that no further mitigation measures are warranted.

38 4.8.4 Cumulative Socioeconomic Impacts

39
40 Much of the analysis of socioeconomic impacts presented in Section 4.4 of this draft SEIS
41 already incorporate cumulative impact analysis, because the metrics used for quantification
42 only make sense when placed in the total or cumulative context. For instance, the impact of the

1 total number of additional housing units that may be needed can only be evaluated with respect
2 to the total number of units in the impacted area. Therefore, the geographic area of the
3 cumulative analysis varies depending on the particular impact considered, and may depend on
4 specific boundaries, such as taxation jurisdictions, or may be distance related, as for
5 environmental justice.
6

7 The continued operation of BFN is not likely to add to any cumulative socioeconomic impacts
8 beyond those already evaluated in Section 4.4. In other words, the impacts of issues such as
9 transportation or offsite land use are likely to be nondetectable beyond the regions previously
10 evaluated and will quickly decrease with increasing distance from the site. The staff determined
11 that the impacts on housing, public utilities, public services, offsite land use, and environmental
12 justice would all be negligible. There are no reasonable foreseeable scenarios that would alter
13 these conclusions in regard to cumulative impacts.
14

15 Related to historic and archeological resources, two sites at BFN have been identified that
16 require protection. TVA has procedures in place to protect these sites, and to take into account
17 the inadvertent discovery of historic and archaeological remains at BFN. There are no plans to
18 construct new facilities in areas that have not been heavily disturbed in the past, or to construct
19 new transmission lines. Therefore, continued operation and maintenance of the BFN site and
20 transmission line rights-of-way would not impact historic or archeological properties beyond the
21 site or rights-of-way boundaries and, therefore, the contribution to cumulative adverse impacts
22 would be negligible.
23

24 Based on these considerations, the staff concludes that continued operation of BFN is not likely
25 to make a detectable contribution to the cumulative effects associated with any of the socio-
26 economic issues discussed in Section 4.4; therefore, the cumulative impacts will be SMALL,
27 and no additional mitigation measures are warranted.
28

29 **4.8.5 Cumulative Impacts on Groundwater Use and Quality**

30
31 There are no groundwater withdrawals at BFN, and TVA imports potable water from local
32 utilities, most of which withdraw water from surface sources, primarily the Tennessee River. As
33 described in Section 4.5.1, operation of BFN has not had a detectable impact on groundwater
34 levels in the vicinity of the site. BFN does not discharge any waste to the groundwater.
35 Because there are no groundwater withdrawals or discharges at BFN and none are anticipated
36 in the future, BFN is not causing a detectable change in the regional groundwater usage or
37 quality. Therefore, the contributions to cumulative impacts are SMALL, and no mitigation
38 measures are warranted.
39

1 **4.8.6 Cumulative Impacts on Threatened or Endangered Species**
2

3 The geographic area considered in the analysis of potential cumulative impacts to threatened or
4 endangered species includes those Alabama and Mississippi counties that contain the BFN site
5 and its associated transmission line rights-of-way (Colbert, Franklin, Lawrence, Limestone, and
6 Morgan Counties in Alabama, and Itawamba, Lee, Tishomingo, and Union Counties in
7 Mississippi) and the waters of the Tennessee River, particularly Wheeler Reservoir, in the
8 vicinity of the BFN site^(a). As discussed in Sections 2.2.5 and 2.2.6, there are a number of
9 threatened or endangered species that could occur within this area. The staff's findings,
10 presented in the October 25, 2004 (NRC 2004d) BA and in Section 4.6, are that continued
11 operation of BFN, including return to three-unit operation at a total combined power level of
12 11,856 MW(t) and associated transmission line rights-of-way maintenance during the license
13 renewal term, will have no effect, or is not likely to adversely affect any Federally listed species,
14 nor will it adversely impact any designated critical habitat. Therefore, the BFN contribution to
15 cumulative impacts to Federally protected species or designated critical habitat is SMALL and
16 no mitigation is warranted.

17
18 • **Aquatic Species**
19

20 Thirty-eight Federally listed aquatic species (including three candidate species) occur (or
21 historically occurred) in either Wheeler Reservoir or its tributaries or in other streams, rivers, or
22 caves within the counties of Alabama and Mississippi within which the BFN transmission lines
23 pass. As mentioned in Section 2.2.5, past actions that have adversely affected these species
24 have included siltation, impoundments, in-stream-habitat disturbance, contaminants, pearl
25 button and cultured pearl industries (for mussel species), and introduced species. As
26 discussed in Section 4.6.1, best management practices are used for transmission line
27 maintenance, which reduces the likelihood of adverse impacts to aquatic habitats and any
28 protected species that may be present within them.

29
30 The combination of nonpoint-source pollution (primarily from siltation) and alteration of flow
31 regimes (primarily from impoundments) are anthropogenic factors responsible for about
32 72 percent of fish imperilment problems in the Southeast (Etnier 2002). These factors are also
33 the major contributor to the endangerment of most of the listed mussel species, while habitat
34 loss, modification, and fragmentation caused by impoundments have impacted the aquatic snail
35 species (Neves et al. 2002). Because some mussels can live to be more than 100 years old,
36 population declines due to poor reproductive success may continue for decades. Therefore,
37 extirpation of some species may be a prolonged event, lagging behind the factors directly
38 responsible for attrition of the fauna (Neves et al. 2002). An oil or chemical spill, especially in a
39 tributary stream, could be significant for a listed species that has a limited distribution (e.g.,
40

(a) Prentiss County, Mississippi not included. Species accounted for in adjacent counties.

1 Anthony's riversnail [*Athearnia anthonyi*], slender campeloma [*Campeloma decampi*], and
2 boulder darter [*Etheostoma boschungii*].
3

4 The Asiatic clam competitively interacts with native mussels for food and space. Invasion of the
5 Tennessee River basin by the zebra mussel and the quagga mussel could also be detrimental
6 to native mussels (Neves et al. 2002). The zebra mussel may ultimately cause extinction to
7 several Federally protected mussels or cause other mussel species to become endangered or
8 threatened (Neves et al. 2002). If the black carp (*Mylopharyngodon piceus*) becomes estab-
9 lished in the Tennessee River, it could pose a serious threat to the listed mussel and snail
10 species because it feeds almost exclusively upon molluscs (Chick 2002; Jernigan 2003).
11

12 The staff determined that the contribution to cumulative impacts to aquatic threatened or
13 endangered species due to continued operation of BFN and its transmission lines would be
14 inconsequential, and that no further mitigation measures are warranted.
15

16 • **Terrestrial Species**
17

18 There are no Federally listed threatened or endangered species known to occur within at least
19 5 km (3 mi) of the BFN site. Operation of BFN is not likely to have a detectable effect on
20 terrestrial species located 5 km (3 mi) away from the site. Therefore, operations at the plant
21 site will not have a detectable contribution to the cumulative, regional impacts on threatened or
22 endangered species.
23

24 Habitat for some of the Federally listed species could potentially be found within the rights-of-
25 way of BFN transmission lines. However, TVA monitors and tracks populations of Federal
26 listed species on the BFN site and within transmission line rights-of-way. In addition, TVA
27 works with its contract personnel and appropriate Federal and State agencies to develop and
28 implement restrictions and safeguards to protect threatened or endangered species and their
29 habitats during maintenance of transmission line rights-of-way (Muncy et al. 1999). In some
30 cases, the rights-of-way and the maintenance practices may provide for habitat that is not found
31 in surrounding areas with other land uses.
32

33 Therefore, the staff determined that the contributions to cumulative impacts to threatened or
34 endangered terrestrial species due to the continued operation of the BFN and associated
35 transmission lines will be inconsequential, and that additional mitigation measures would not be
36 warranted.

4.9 Summary of Impacts of Operations During the License Renewal Term

TVA and the staff discovered no new and significant information related to any of the applicable Category 1 issues associated with BFN operation during the license renewal term. Therefore, the staff concludes that the environmental impacts associated with the Category 1 issues are bounded by the impacts described in the GEIS. For each of the issues, the GEIS concluded that the impacts would be SMALL and that additional plant-specific mitigation measures are not likely to be sufficiently beneficial to warrant implementation.

Plant-specific environmental evaluations were conducted for 14 Category 2 issues applicable to BFN operation during the license renewal term and for environmental justice and chronic effects of electromagnetic fields. For all 14 issues and environmental justice, the staff's conclusion is that the potential environmental impact of license renewal-term operations of BFN would be of SMALL significance in the context of the standards set forth in the GEIS and that further mitigation is not warranted. In addition, the staff determined that a consensus has not been reached by appropriate Federal health agencies regarding chronic adverse effects from electromagnetic fields. Therefore, no evaluation of this issue is required.

Cumulative impacts of past, present, and reasonably foreseeable future actions were considered, regardless of what agency (Federal or non-Federal) or person undertakes such other actions. For purposes of analysis, where BFN license renewal impacts are deemed to be SMALL, the staff concluded that these impacts would not result in significant cumulative impacts on potentially affected resources.

4.10 References

10 CFR Part 20. Code of Federal Regulations, Title 10, *Energy*, Part 20, "Standards for Protection Against Radiation."

10 CFR Part 51. Code of Federal Regulations, Title 10, *Energy*, Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions."

36 CFR Part 800. Code of Federal Regulations, Title 36, *Parks, Forests, and Public Property*, Part 800, "Protection of Historic Properties."

40 CFR Part 190. Code of Federal Regulations, Title 40, *Protection of Environment*, Part 190, "Environmental Protection Standards for Nuclear Power Operations."

40 CFR Part 1508. Code of Federal Regulation, Title 40, *Protection of Environment*, Part 1508, "Terminology and Index."

1 59 FR 7629. Executive Order 12898, "Federal Actions to Address Environmental Justice in
2 Minority and Low-Income Populations." *Federal Register*. Vol. 59, No. 32. February 16, 1994.

3
4 69 FR 52040. Policy Statement on the Treatment of Environmental Justice Matters in NRC
5 Regulatory and Licensing Actions. *Federal Register*. Vol. 69, No. 163. August 24, 2004.

6
7 69 FR 41575. Final Regulation to Establish Requirements for Cooling Water Intake Structures
8 at Phase II Existing Facilities. *Federal Register*. Vol. 69, No. 131. July 9, 2004.

9
10 Alabama Department of Environmental Management (ADEM). 2000. *National Pollutant*
11 *Discharge Elimination System Permit Tennessee Valley Authority Browns Ferry Nuclear Plant*.
12 Permit No. AL0022080, Alabama Department of Environmental Management, Water Division -
13 Industrial Section, Montgomery, Alabama.

14
15 Alabama Historical Commission (AHC). 1972. Letter from O. Warner Floyd to
16 Mr. George R. Deveny, Tennessee Valley Authority, March 16, 1972.

17
18 Barclay, L.A. 2004. Biological Opinion of the Tennessee Valley Authority's Proposed Reservoir
19 Operation Study. U.S. Fish and Wildlife Service, Tennessee Ecological Services Field Office,
20 Cookeville, Tennessee.

21
22 Baxter, D.S. and J.P. Buchanan. 1998. *Browns Ferry Nuclear Plant Thermal Variance*
23 *Monitoring Program Including Statistical Analyses*. Final Report. Tennessee Valley Authority,
24 Water Management Environmental Compliance. Available on the Internet under Accession
25 No. ML041530161, dated May 27, 2004 at <http://www.nrc.gov/reading-rm/adams.html>

26
27 Bohac, C.E. 2004. "References for Environmental Report table E2-14 and 2-15" email of
28 tables and explanation to C.L. Wilson, Tennessee Valley Authority, May 2004.

29
30 Bowzer, T.W. and B.L. Lippincott. 2000. *A Summary of Long-Term Fisheries Monitoring in*
31 *Pool 14 of the Upper Mississippi River near Quad Cities Station (1971-1999)*. Prepared by
32 Lawler, Matusky & Skelly Engineers LLP, Woodstock, Illinois, for Commonwealth Edison
33 Company, Chicago, Illinois.

34
35 Buchanan, J.P. 1980. *Fish Entrainment at Browns Ferry Nuclear Plant, Wheeler Reservoir,*
36 *Alabama, for the Years 1978 and 1979*. Tennessee Valley Authority, Division of Water
37 Resources, Fisheries and Aquatic Ecology Branch, Norris, Tennessee. Available on the
38 Internet under Accession No. ML041530161, dated May 27, 2004 at
39 <http://www.nrc.gov/reading-rm/adams.html>

40
41 Buchanan, J.P. 1990. Thermal Variance Monitoring for Browns Ferry Nuclear Plant, Wheeler
42 Reservoir, 1987 - 1989. Tennessee Valley Authority, Water Resources, Aquatic Biology

Environmental Impacts of Operation

1 Department, Norris, Tennessee. Available on the Internet under Accession No. ML041530161,
2 dated May 27, 2004 at <http://www.nrc.gov/reading-rm/adams.html>

3
4 Cada, G.F. 1990. "A Review of Studies Relating to the Effects of Propeller-Type Turbine
5 Passage on Fish Early Life Stages." *North American Journal of Fisheries Management*
6 10:418-426.

7
8 Centers for Disease Control and Prevention (CDC). 2004. "Legionellosis: Legionnaire's
9 Disease (LD) and Pontiac Fever." Atlanta, Georgia. Accessed on the Internet June 7, 2004 at
10 http://www.cdc.gov/ncidod/dbmd/diseaseinfo/legionellosis_g.htm

11
12 Cherry, D.S., K.L. Dickson, and J. Cairns, Jr. 1975. "Temperatures Selected and Avoided by
13 Fish at Various Acclimation Temperatures." *Journal of Fisheries Research Board of Canada*
14 32:485-491.

15
16 Chick, J.H. 2002. "Asian Carp in the Upper Mississippi River System." *Illinois Natural History*
17 *Survey Reports, Spring 2002, 371:6, Champaign, Illinois.*

18
19 Community Development Department (CDD). 2004. Interview with Community Development
20 Staff, M. Jordan and A. Stover. March 31, 2004. Decatur, Alabama.

21
22 Deacon, J. 2004. "The Microbial World: Thermophilic Microorganisms." The University of
23 Edinburgh, Institute of Cell and Molecular Biology, Edinburgh, United Kingdom. Accessed on
24 the Internet June 7, 2004 at <http://helios.bto.ed.ac.uk/bto/microbes/thermo.htm>

25
26 Endangered Species Act of 1973 (ESA). 16 USC 1531, et seq.

27
28 Etnier, D.A. 2002. "Jeopardized Southeastern Freshwater Fishes: A Search for Causes." In
29 *Aquatic Fauna in Peril: The Southeastern Perspective*, G.W. Benz and D.E. Collins (eds.).
30 *Sherpa Guides* by Lenz Design, Decatur, Georgia. Accessed on the Internet January 20, 2004,
31 at http://www.sherpaguides.com/southeast/aquatic_fauna/chapter_3

32
33 Federal Water Pollution Control Act Amendments of 1972 (FWPCA) (Also referred to as the
34 Clean Water Act). 33 USC 1251, et seq.

35
36 Goldman, L.E. 2004. Letter from L.E. Goldman, Field Supervisor, U.S. Fish and Wildlife
37 Service, Daphne Field Office, Daphne, Alabama to M. Masnik, U.S. Nuclear Regulatory
38 Agency, Division of Regulatory Improvement Programs, Washington, D.C., Subject: "List of
39 Protected Species within the Area under Evaluation for the Browns Ferry Nuclear Plant License
40 Renewal." May 19, 2004.

41
42 Hopping, P.N. 2004. Email from P.N. Hopping, Tennessee Valley Authority to C. L. Wilson,
43 Tennessee Valley Authority, Browns Ferry Nuclear Plant, Limestone County, Alabama and

1 A. Stegen, Pacific Northwest National Laboratory, Richland, Washington. Subject: "Heat
2 rejection and water flows." May 14, 2004. Available on the Internet under Accession
3 No. ML041530161, dated May 27, 2004 at <http://www.nrc.gov/reading-rm/adams.html>

4
5 Hutson, S.S., M.C. Koroa, and C.M. Murphree. 2003. *Estimated Use of Water in the*
6 *Tennessee River Watershed in 2000 and Projections of Water Use to 2030*. USGS Water-
7 Resources Investigations Report 03-4302, USGS Information Services, Denver, Colorado.
8 Accessed on the Internet on May 19, 2004 at
9 http://water.usgs.gov/pubs/immediate_release.html

10
11 Institute of Electrical and Electronic Engineers (IEEE). 1997. *National Electrical Safety Code -*
12 *1997 Version*. New York.

13
14 Institute of Electrical and Electronic Engineers (IEEE). 2002. *National Electrical Safety Code -*
15 *2002 Version*. New York.

16
17 Jernigan, J. 2003. "Asian Carp in Alabama." Alabama Department of Conservation and
18 Natural Resources, Montgomery, Alabama. Accessed on the Internet January 19, 2004 at
19 <http://www.dcnr.state.al.us/agfd/fish/fnaasian.html>

20
21 Julian, H. 2004. "Groundwater level data, tables, graphs." Email of data, tables, and graphs to
22 C. L. Wilson, Tennessee Valley Authority, dated May 2004.

23
24 Kendall, P. 2003. "Bacterial Food-Borne Illness." Fact Sheet No. 9.300. Colorado State
25 University Cooperative Extension, Colorado State University, Fort Collins, Colorado. Accessed
26 on the Internet June 7, 2004 at <http://www.ext.colostate.edu/pubs/foodnut/09300.html>

27
28 Kingsbury, J.A., A.B. Hoos, and M.D. Woodside. 1999. *Environmental Setting and Water-*
29 *Quality Issues in the Lower Tennessee River Basin*. USGS Water-Resources Investigations
30 Report 99-4080. U.S. Geological Survey, Nashville, Tennessee.

31
32 LaJeone, L.J. and R.G. Monzingo. 2000. "316(b) and Quad Cities Station, Commonwealth
33 Edison Company." *Environmental Science & Policy*, 3: S313-S322.

34
35 Lofgren, J.P. 2003. Letter from J.P. Lofgren, M.D., Medical Epidemiologist, Division of
36 Epidemiology, Alabama Department of Public Health, Montgomery, Alabama to M. Burzynski,
37 Manager, Nuclear Licensing, Tennessee Valley Authority, Chattanooga, Tennessee. Subject:
38 "Whether Discharge Waters from the Browns Ferry Nuclear Plant Increase the Risk of Human
39 Diseases from Thermophilic Microorganisms." November 4, 2003.

40
41 Lowery, D.R. and W.L. Poppe. 1992. *Thermal Variance Monitoring for Browns Ferry Nuclear*
42 *Plant, Wheeler Reservoir, 1990-1991*. Tennessee Valley Authority, Water Resources Division,

Environmental Impacts of Operation

1 Aquatic Biology Department, Knoxville, Tennessee. Available on the Internet under Accession
2 No. ML041530161, dated May 27, 2004 at <http://www.nrc.gov/reading-rm/adams.html>

3
4 Maceina, M.J., P.W. Bettoli, S.D. Finely, and V.J. DiCenzo. 1998. "Analyses of the Sauger
5 Fishery with Simulated Effects of a Minimum Size Limit in the Tennessee River of Alabama."
6 *North American Journal of Fisheries Management*, 18: 66-75.

7
8 Muncy, J.A., C. Austin, C. Brewster, A. Lewis, K. Smithson, T. Broyles, and T. Wojtalik. 1999.
9 *A Guide for Environmental Protection and Best Management Practices for Tennessee Valley*
10 *Authority Transmission Construction and Maintenance Activities*. Technical Note
11 TVA/LR/NRM 92/1 November 1992 (revised December 1999). Tennessee Valley Authority,
12 Norris and Chattanooga, Tennessee.

13
14 National Environmental Policy Act of 1969 (NEPA). 42 USC 4321, et seq.

15
16 National Historic Preservation Act of 1966 (NHPA). 16 USC 470, et seq.

17
18 National Institute of Environmental Health Sciences (NIEHS). 1999. *NIEHS Report on Health*
19 *Effects from Exposure to Power Line Frequency and Electric and Magnetic Fields*. Publication
20 No. 99-4493, Research Triangle Park, North Carolina.

21
22 Neves, R.J., A.E. Bogan, J.D. Williams, S.A. Ahlstedt, and P.W. Hartfield. 2002. "Status of
23 Aquatic Mollusks in the Southeastern United States: A Downward Spiral of Diversity." In
24 *Aquatic Fauna in Peril: The Southeastern Perspective*, G.W. Benz and D.E. Collins (eds.).
25 *Sherpa Guides* by Lenz Design, Decatur, Georgia. Accessed on the Internet January 20, 2004
26 at http://www.sherpaguides.com/southeast/aquatic_fauna/chapter_3

27
28 Rohr, U., S. Weber, R. Michel, F. Selenka, and M. Wilhelm. 1998. "Comparison of Free-Living
29 Amoeba in Hot Water Systems of Hospitals with Isolates from Moist Sanitary Areas by
30 Identifying Genera and Determining Temperature Tolerance." *Applied Environmental*
31 *Microbiology*, 64(5): 1822-1824. Accessed on the Internet June 7, 2004 at
32 <http://aem.asm.org/cgi/content/full/64/5/1822>

33
34 ScanChattanooga.Com. 2001. "Tennessee Valley Authority Power Generation Facilities".
35 Accessed on the Internet May 18, 2004 at [http://www.scanchattanooga.com/federal/tva-](http://www.scanchattanooga.com/federal/tva-facilities.html)
36 [facilities.html](http://www.scanchattanooga.com/federal/tva-facilities.html)

37
38 State Historic Preservation Office (SHPO). 2002. Letter from Elizabeth Ann Brown, Alabama
39 Historical Commission, to J. Bennett Graham, Tennessee Valley Authority. April 24, 2002.

40
41 Talmage, S.S. and D.M. Opresko. 1981. *Literature Review: Response of Fish to Thermal*
42 *Discharges*. EPRI EA-1840, Research Project 877, ORNL/EIS-193. Prepared by Oak Ridge

1 National Laboratory, Oak Ridge, Tennessee for Electric Power Research Institute, Palo Alto,
2 California.

3
4 Tennessee Valley Authority (TVA). 1972. *Final Environmental Statement Browns Ferry
5 Nuclear Plant Units 1, 2, and 3*. Tennessee River Authority, Office of Health and Environmental
6 Science, Chattanooga, Tennessee.

7
8 Tennessee Valley Authority (TVA). 1978a. *Biological Effects of Intake Browns Ferry Nuclear
9 Plant. Volume 4: Effects of the Browns Ferry Nuclear Plant Cooling Water Intake on the Fish
10 Populations of Wheeler Reservoir*. Tennessee Valley Authority, Division of Forestry, Fisheries,
11 and Wildlife Development, Fisheries and Waterfowl Resources Branch, Norris, Tennessee.
12 Available on the Internet under Accession No. ML041530161, dated May 27, 2004 at
13 <http://www.nrc.gov/reading-rm/adams.html>

14
15 Tennessee Valley Authority (TVA). 1978b. *Browns Ferry Nuclear Plant Preoperational
16 Fisheries Resources Report*. Tennessee Valley Authority, Division of Forestry, Fisheries, and
17 Wildlife Development, Norris, Tennessee. Available on the Internet under Accession
18 No. ML041530161, dated May 27, 2004 at <http://www.nrc.gov/reading-rm/adams.html>

19
20 Tennessee Valley Authority (TVA). 1983. *A Supplemental 316 (a) Demonstration for
21 Alternative Thermal Discharge Limits for Browns Ferry Nuclear Plant, Wheeler Reservoir,
22 Alabama*. Available on the Internet under Accession No. ML041530161, dated May 27, 2004 at
23 <http://www.nrc.gov/reading-rm/adams.html>

24
25 Tennessee Valley Authority (TVA). 1999. "Browns Ferry Nuclear Plant (BFN) – Units 1, 2, and
26 3 – Updated Final Safety Analysis Report (UFSAR), Amendment 20." Tennessee Valley
27 Authority, September 15, 2003.

28
29 Tennessee Valley Authority (TVA). 2002. *Final Supplemental Environmental Impact Statement
30 for Operating License Renewal of the Browns Ferry Nuclear Plant in Athens, Alabama*.
31 Tennessee Valley Authority, Knoxville, Tennessee.

32
33 Tennessee Valley Authority (TVA). 2003a. *Final EA, Browns Ferry Nuclear Power Plant
34 Units 2 and 3*. Chattanooga, Tennessee.

35
36 Tennessee Valley Authority (TVA). 2003b. *Applicant's Environmental Report, Operating
37 License Renewal Stage, Browns Ferry Nuclear Power Plant Units 1, 2, and 3*. Chattanooga,
38 Tennessee.

39
40 Tennessee Valley Authority (TVA). 2004a. "BNF Relicensing ER Information Needs:
41 Socioeconomic and EJ." Available on the Internet under Accession No. ML041530161, dated
42 May 27, 2004 at <http://www.nrc.gov/reading-rm/adams.html>

Environmental Impacts of Operation

1 Tennessee Valley Authority (TVA). 2004b. *Wheeler Reservoir Operations under the ROS*
2 *Preferred Alternative*. Tennessee Valley Authority, Knoxville, Tennessee. Accessed on the
3 Internet March 25, 2004 at http://www.tva.com/feature_rosstudy/pdf/wheeler.pdf
4

5 Todar, K. 2002. "*Pseudomonas aeruginosa*." Bacteriology at UW-Madison, Bacteriology 330
6 Home Page, University of Wisconsin-Madison, Department of Bacteriology, Madison,
7 Wisconsin. Accessed on the Internet June 7, 2004, at
8 <http://www.bact.wisc.edu/Bact330/lecturepseudomonas>
9

10 U.S. Census Bureau (USCB). 2000. "Census 2000 Summary File I (SF-1) 100 Percent Data.
11 Accessed on the Internet January 2003 at
12 [http://factfinder.census.gov/servlet/DatasetMainPageServlet?_ds_name=DEC_2000_SF3_U&](http://factfinder.census.gov/servlet/DatasetMainPageServlet?_ds_name=DEC_2000_SF3_U&_program=DEC&_lang=en)
13 [program=DEC&_lang=en](http://factfinder.census.gov/servlet/DatasetMainPageServlet?_ds_name=DEC_2000_SF3_U&_program=DEC&_lang=en)
14

15 U.S. Census Bureau (USCB).. 2001. "Glossary – Definition and Explanations – decennial
16 census terms." Accessed on the Internet January 2003 at
17 <http://landview.census.gov/dmd/www/advGLOSSARY.html>
18

19 U.S. Environmental Protection Agency (EPA). 2004. "National Pollutant Discharge Elimination
20 System – Final Regulations to Establish Requirements for Cooling Water Intake Structures at
21 Phase II Existing Facilities." *Federal Register* 69(131):41575-41624.
22

23 U.S. Geological Survey (USGS). 1998. "National Water-Quality Assessment (NAWQA)
24 Program Lower Tennessee River Basin. Basin Description." U.S. Geological Survey,
25 Tennessee District Office, Nashville, Tennessee. Accessed on the Internet January 21, 2004 at
26 <http://tn.water.usgs.gov/lten/basin-description.html>
27

28 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement*
29 *for License Renewal of Nuclear Plants*. NUREG-1437, Volumes 1 and 2, Washington, D.C.
30

31 U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement*
32 *for License Renewal of Nuclear Plants, Main Report*, "Section 6.3 – Transportation, Table 9.1,
33 Summary of findings on NEPA issues for license renewal of nuclear power plants, Final
34 Report." NUREG-1437, Volume 1, Addendum 1, Washington, D.C.
35

36 U.S. Nuclear Regulatory Commission (NRC). 2004a. "Procedural Guidance for Preparing
37 Environmental Assessments and Considering Environmental Issues." Appendix D to NRR
38 Office of Nuclear Reactor Regulation Instruction, LIC-203, Rev. 1, May 24, 2004, Washington,
39 D.C.
40

41 U.S. Nuclear Regulatory Commission (NRC). 2004b. Letter from P.T. Kuo, Program Director.
42 License Renewal and Environmental Impacts Program, Office of Nuclear Reactor Regulation,
43 NRC, Washington, D.C. to Dr. Lee Warner, State Historic Preservation Officer, Alabama

1 Historical Commission, Montgomery, Alabama. Subject "Browns Ferry Nuclear Plant License
2 Renewal." March 8, 2004.

3
4 U.S. Nuclear Regulatory Commission (NRC). 2004c. Letter from P.T. Kuo, Program Director,
5 License Renewal and Environmental Impacts Program, Office of Nuclear Reactor Regulation,
6 NRC, Washington, D.C. to L. Goldman, Field Supervisor, U.S. Fish and Wildlife Service,
7 Daphne Field Office, Daphne, Alabama. Subject: "Request for a List of Protected Species
8 within the Area under Evaluation for the Browns Ferry Nuclear Plant License Renewal." March
9 5, 2004.

10
11 U.S. Nuclear Regulatory Commission (NRC). 2004d. Letter from P.T. Kuo, Program Director,
12 License Renewal and Environmental Impacts Program, Office of Nuclear Reactor Regulation,
13 NRC, Washington, D.C. to L. Goldman, Field Supervisor, U.S. Fish and Wildlife Service,
14 Daphne Field Office, Daphne, Alabama. Subject: Biological Assessment for License Renewal
15 of the Browns Ferry Nuclear Plant, and a Request for Informal Consultation. October 25, 2004.
16

5.0 Environmental Impacts of Postulated Accidents

Environmental issues associated with postulated accidents are discussed in the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants (GEIS)*, NUREG-1437, Volumes 1 and 2 (NRC 1996; 1999).^(a) The GEIS includes a determination of whether the analysis of the environmental issue could be applied to all plants and whether additional mitigation measures would be warranted. Issues are then assigned a Category 1 or a Category 2 designation. As set forth in the GEIS, Category 1 issues are those that meet all of the following criteria:

- (1) The environmental impacts associated with the issue have been determined to apply either to all plants or, for some issues, to plants having a specific type of cooling system or other specified plant or site characteristic.
- (2) Single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to the impacts (except for collective offsite radiological impacts from the fuel cycle and from high-level waste and spent fuel disposal).
- (3) Mitigation of adverse impacts associated with the issue has been considered in the analysis, and it has been determined that additional plant-specific mitigation measures are likely not to be sufficiently beneficial to warrant implementation.

For issues that meet the three Category 1 criteria, no additional plant-specific analysis is required unless new and significant information is identified.

Category 2 issues are those that do not meet one or more of the criteria for Category 1, and therefore, additional plant-specific review of these issues is required.

This chapter describes the environmental impacts from postulated accidents that might occur during the license renewal term.

5.1 Postulated Plant Accidents

Two classes of accidents are evaluated in the GEIS. These are design-basis accidents (DBAs) and severe accidents, as discussed below.

(a) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and Addendum 1.

Postulated Accidents

5.1.1 Design-Basis Accidents

In order to receive NRC approval to operate a nuclear power facility, an applicant must submit a safety analysis report (SAR) as part of the application. The SAR presents the design criteria and design information for the proposed reactor and comprehensive data on the proposed site. The SAR also discusses various hypothetical accident situations and the safety features that are provided to prevent and mitigate accidents. The NRC staff reviews the application to determine whether the plant design meets the Commission's regulations and requirements and includes, in part, the nuclear plant design and its anticipated response to an accident.

DBAs are those accidents that both the licensee and the NRC staff evaluate to ensure that the plant can withstand normal and abnormal transients, and a broad spectrum of postulated accidents without undue hazard to the health and safety of the public. A number of these postulated accidents are not expected to occur during the life of the plant but are evaluated to establish the design basis for the preventive and mitigative safety systems of the facility. The acceptance criteria for DBAs are described in 10 CFR Part 50 and 10 CFR Part 100.

The environmental impacts of DBAs are evaluated during the initial licensing process, and the ability of the plant to withstand these accidents is demonstrated to be acceptable before issuance of the operating license (OL). The results of these evaluations are found in license documentation such as the staff's safety evaluation report (SER), the final environmental statement (FES), the licensee's updated final safety analysis report (UFSAR), and Section 5.1 of this supplemental environmental impact statement (SEIS). The licensee is required to maintain the acceptable design and performance criteria throughout the life of the plant, including any extended-life operation. The consequences for these events are evaluated for the hypothetical maximally exposed individual; as such, changes in the plant environment will not affect these evaluations. Because of the requirements that continuous acceptability of the consequences and aging management programs be in effect for license renewal, the environmental impacts as calculated for DBAs should not differ significantly from initial licensing assessments over the life of the plant, including the license renewal period. Accordingly, the design of the plant relative to DBAs during the extended period is considered to remain acceptable, and the environmental impacts of those accidents were not examined further in the GEIS.

The Commission has determined that the environmental impacts of DBAs are of SMALL significance for all plants because the plants were designed to successfully withstand these accidents. Therefore, for the purposes of license renewal, design-basis accidents are designated as a Category 1 issue in 10 CFR Part 51, Subpart A, Appendix B, Table B-1. The early resolution of the DBAs make them a part of the current licensing basis of the plant; the current licensing basis of the plant is to be maintained by the licensee under its current license

1 and, therefore, under the provisions of 10 CFR 54.30, is not subject to review under license
 2 renewal. This issue, applicable to BFN, is listed in Table 5-1.

3
 4 **Table 5-1. Category 1 Issue Applicable to Postulated Accidents During the License Renewal**
 5 **Term**

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Section
POSTULATED ACCIDENTS	
Design-basis accidents	5.3.2; 5.5.1

6
 7
 8
 9
 10
 11
 12 Based on information in the GEIS, the Commission found that

13
 14 The NRC staff has concluded that the environmental impacts of design-basis accidents
 15 are of small significance for all plants.

16
 17 Tennessee Valley Authority (TVA) stated in its Environmental Report (ER) (TVA 2003) that it is
 18 not aware of any new and significant information associated with the renewal of the Browns
 19 Ferry Nuclear Plant, Units 1, 2, and 3 (BFN) OLS. The staff has not identified any new and
 20 significant information during the staff's independent review of the BFN ER (TVA 2003), the
 21 scoping process, the staff's site visit, the staff's evaluation of other available information, and
 22 public comments. Therefore, the staff concludes that there are no impacts of design-basis
 23 accidents during the renewal term beyond those discussed in the GEIS.

24
 25 **5.1.2 Severe Accidents**

26
 27 Severe nuclear accidents are those that are more severe than DBAs because they could result
 28 in substantial damage to the reactor core, whether or not there are serious offsite
 29 consequences. The GEIS assessed the impacts of severe accidents during the license renewal
 30 period, using the results of existing analyses and site-specific information to conservatively
 31 predict the environmental impacts of severe accidents for each plant during the renewal period.

32
 33 Based on information in the GEIS, the Commission found that

34
 35 The probability weighted consequences of atmospheric releases, fallout onto open
 36 bodies of water, releases to ground water, and societal and economic impacts from
 37 severe accidents are small for all plants. However, alternatives to mitigate severe
 38 accidents must be considered for all plants that have not considered such alternatives.

Postulated Accidents

Therefore, the Commission has designated mitigation of severe accidents as a Category 2 issue in 10 CFR Part 51, Subpart A, Appendix B, Table B-1. This issue, applicable to BFN, is listed in Table 5-2.

Table 5-2. Category 2 Issue Applicable to Postulated Accidents During the License Renewal Term

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Sections	10 CFR 51.53(c)(3)(ii) Subparagraph	SEIS Section
POSTULATED ACCIDENTS			
Severe Accidents	5.3.3; 5.3.3.2; 5.3.3.3; 5.3.3.4; 5.3.3.5; 5.4; 5.5.2	L	5.2

The staff has not identified any new and significant information during the staff's independent review of the BFN ER (TVA 2003), the scoping process, the staff's site visit, the staff's evaluation of other available information, and public comments. Therefore, the staff concludes that there are no impacts of severe accidents beyond those discussed in the GEIS. However, in accordance with 10 CFR 51.53(c)(3)(ii)(L), the staff has reviewed severe accident mitigation alternatives (SAMAs) for BFN. The results of the staff's review are discussed in Section 5.2.

5.2 Severe Accident Mitigation Alternatives (SAMAs)

10 CFR 51.53(c)(3)(ii)(L) requires that license renewal (LR) applicants consider alternatives to mitigate severe accidents if the staff has not previously evaluated SAMAs for the applicant's plant in an environmental impact statement (EIS) or related supplement or in an environmental assessment. The purpose of this consideration is to ensure that plant changes (i.e., hardware, procedures, and training) with the potential for improving severe accident safety performance are identified and evaluated. SAMAs have not been previously considered for BFN; therefore, the remainder of Chapter 5 addresses those alternatives.

5.2.1 Introduction

This section presents a summary of the SAMA evaluation for BFN conducted by TVA and described in the ER (TVA 2003) and of the NRC's review of that evaluation. The details of the review are described in the NRC staff evaluation that was prepared by the staff with contract assistance from Information Systems Laboratories, Inc. The entire evaluation is presented in Appendix G.

1 The SAMA evaluation for BFN was a four-step process. In the first step, TVA quantified the
2 level of risk associated with potential reactor accidents using the plant-specific probabilistic
3 safety assessment (PSA) and other risk models.
4

5 In the second step, TVA examined the major risk contributors and identified possible ways
6 (SAMAs) of reducing that risk. Common ways of reducing risk are changes to components,
7 systems, procedures, and training. TVA initially identified 135 potential SAMAs. TVA screened
8 out SAMAs that were not applicable to BFN due to design differences, had already been
9 implemented, were similar in nature and could be combined with another SAMA, or cost more
10 than \$6M to implement. This screening reduced the list of potential SAMAs to 43.
11

12 In the third step, TVA estimated the benefits and costs associated with each of the remaining
13 SAMAs. Estimates were made of how much each proposed SAMA could reduce risk. Those
14 estimates were developed in terms of dollars in accordance with NRC guidance for performing
15 regulatory analyses (NRC 1997a). The costs of implementing the proposed SAMAs were also
16 estimated.
17

18 Finally in the fourth step, the costs and benefits of each of the remaining SAMAs were compared
19 to determine whether the SAMA was cost-beneficial, meaning the benefits of the SAMA were
20 greater than the costs (a positive cost-benefit). In the final analysis, TVA concluded that none of
21 these 43 SAMAs were cost-beneficial for BFN.
22

23 Each of these four steps is discussed in more detail in the sections that follow.
24

25 **5.2.2 Estimate of Risk** 26

27 TVA submitted an assessment of SAMAs for BFN as part of the ER (TVA 2003). This
28 assessment considers all three Browns Ferry units, each operating at 120 percent of their
29 original licensed power level. Ideally, this assessment would take advantage of a plant-specific
30 Probabilistic Safety Assessment (PSA) that reflects operation of all three units at 120 percent of
31 their original licensed power. However, such a PSA is not currently available. Because of the
32 progressive screening nature of the SAMA evaluation, TVA relied on the available PSA
33 information, along with engineering knowledge of the plant, to form a basis for the three-unit
34 SAMA assessment. This assessment was based on the most recent PSA for Unit 2 and Unit 3
35 available at that time. A PSA for Unit 1 was not available at the time of the SAMA analysis. The
36 assessment was also based on insights from a Multiple-Unit PSA performed in 1995 to bound
37 the effects of three-unit operation, a plant-specific offsite consequence analysis performed using
38 the MELCOR Accident Consequence Code System 2 (MACCS2) computer program, and
39 insights from the Browns Ferry Individual Plant Examination (TVA 1992) and the Individual Plant
40 Examination of External Events (IPEEE) (TVA 1995, 1996, 1997).
41

Postulated Accidents

Two distinct analyses are combined to form the basis for the risk estimates used in the SAMA analysis: (1) the BFN PSA Unit 2 and Unit 3 models, and (2) a supplemental analysis of offsite consequences and economic impacts (essentially a Level 3 PSA model) developed specifically for the SAMA analysis. The SAMA analysis is based on the most recent PSA models available at the time of the ER, referred to as the Extended Power Uprate (EPU) PSA for Unit 2, and the EPU PSA for Unit 3. The PSAs include a Level 1 analysis to determine the CDF from internally-initiated events and a Level 2 analysis to assess containment performance during severe accidents. The scope of the BFN PSAs does not include external events.

The baseline CDFs for the purpose of the SAMA evaluation are approximately 2.6×10^{-6} per year for Unit 2 and 3.6×10^{-6} per year for Unit 3. The CDFs are based on the risk assessment for internally-initiated events at EPU conditions, i.e., 120 percent of their original licensed power level. TVA did not include the contribution to risk from external events within the BFN risk estimates. This is discussed further in Sections G.2.2 and G.6.2.

The breakdown of CDF by initiating event is provided in Table 5-3. As shown in this table, transients and loss of offsite power initiated events are dominant contributors to the CDF.

Table 5-3. BFN Core-Damage Frequency ...

Initiating Event or Accident Class	Unit 2		Unit 3	
	CDF (Per Year)	% Contribution to CDF	CDF (Per Year)	% Contribution to CDF
Transients	1.6×10^{-6}	63	1.8×10^{-6}	52
Loss of offsite power (LOOP)	4.8×10^{-7}	19	1.1×10^{-6}	32
Support system failures	2.2×10^{-7}	8	2.3×10^{-7}	7
Internal Flooding	1.0×10^{-7}	4	1.6×10^{-7}	5
Loss of coolant accidents (LOCAs)	5.3×10^{-8}	2	5.4×10^{-8}	2
Stuck open relief valves	4.7×10^{-8}	2	5.8×10^{-8}	2
Interfacing system LOCA (ISLOCA)	4.6×10^{-8}	2	4.6×10^{-8}	1
Total CDF (from internal events)	2.6×10^{-6}	100	3.4×10^{-6}	100

1 Bypass events (i.e., interfacing systems loss of coolant accident) contribute two percent or less
 2 to the total internal events CDF. Anticipated transients without scram (ATWS) events and
 3 station blackout (SBO) events are not specifically identified in the internal events CDF
 4 breakdown. In response to an RAI, TVA stated that the ATWS CDF is estimated to be 2.3×10^{-7}
 5 per year for each unit, and the SBO CDF is 3.7×10^{-8} per year for Unit 2 and 3.9×10^{-8} per year for
 6 Unit 3 (TVA 2004a). SAMAs to address ATWS and SBO events were considered in the SAMA
 7 evaluation. TVA estimated the dose from all postulated accidents to the population within 80 km
 8 (50 mi) of the BFN site to be approximately 0.0164 person-Sv (1.64 person-rem) per year for
 9 Unit 2, and approximately 0.0195 person-Sv (1.95 person-rem) per year for Unit 3. The
 10 breakdown of the population dose by containment release mode is summarized in Table 5-4.
 11 No containment failures and early containment failures dominate the population dose. The
 12 apparent conclusion that population dose is dominated by events involving no containment
 13 failure is due to the conservative assignment of key plant damage states to release categories in
 14 which containment is assumed to fail.

15
 16
 17 **Table 5-4. Breakdown of Population Dose by Containment Release Mode**
 18

Containment Release Mode	Unit 2		Unit 3	
	Population Dose (Person-Rem ¹ Per Year)	% Contribution	Population Dose (Person-Rem ¹ Per Year)	% Contribution
Early containment failure or Containment isolation failure	0.64	39	0.71	36
Bypass	0.01	<1	0.01	<1
Late containment failure	0.11	7	0.16	8
No containment failure ²	0.88	54	1.07	55
Total Population Dose	1.64	100	1.95	100

19
 20
 21
 22
 23
 24
 25
 26
 27
 28
 29 The staff has reviewed TVA's data and evaluation methods and concludes that the quality of the
 30 risk analyses is adequate to support an assessment of the risk reduction potential for the
 31 candidate SAMAs. Accordingly, the staff based its assessment of offsite risk on the CDF and
 32 offsite doses provided by TVA.

33 34 5.2.3 Potential Plant Improvements

35
 36 Once the dominant contributors to plant risk were identified, TVA searched for ways to reduce
 37 that risk. In identifying and evaluating potential SAMAs, TVA considered SAMA analyses
 38 performed for other operating plants that have submitted license renewal applications, as well as

Postulated Accidents

1 industry and NRC documents that discuss potential plant improvements, such as NUREG-1560
2 (NRC 1997b). TVA identified 135 potential risk-reducing improvements (SAMAs) to plant
3 components, systems, procedures and training.
4

5 All but 43 of the these SAMAs were removed from further consideration because: (1) the SAMA
6 was not applicable at BFN due to design differences, (2) the SAMA had already been addressed
7 in the existing BFN design, (3) the SAMA was similar to and could be combined with another
8 SAMA, or (4) the SAMA cost more than \$6M to implement, considering the effects of multiple-
9 unit operation and uncertainties.
10

11 The staff concludes that TVA used a systematic and comprehensive process for identifying
12 potential plant improvements for BFN, and that the set of potential plant improvements identified
13 by TVA is reasonably comprehensive and therefore acceptable.
14

15 5.2.4 Evaluation of Risk Reduction and Costs of Improvements

16
17 TVA evaluated the risk-reduction potential of the remaining 43 SAMAs that were applicable to
18 BFN. A majority of the SAMA evaluations were performed in a bounding fashion in that the
19 SAMA was assumed to completely eliminate the risk associated with the proposed
20 enhancement. Such bounding calculations overestimate the benefit of the risk reduction and are
21 conservative.
22

23 TVA estimated the costs of implementing the 43 candidate SAMAs through the application of
24 engineering judgment and review of prior BFN completed capital projects for similar
25 improvements. The cost estimates provided in the ER accounted for inflation (three percent per
26 year) to arrive at year 2016 estimated costs. Cost estimates typically included changes to and
27 implementation of procedures, training, and documentation, in addition to any hardware costs
28 (TVA 2003).
29

30 The staff reviewed TVA's bases for calculating the risk reduction for the various plant
31 improvements and concluded that the rationale and assumptions for estimating risk reduction
32 are reasonable and generally conservative. Therefore, the staff based its estimates of averted
33 risk for the various SAMAs on TVA's risk reduction estimates. However, the staff concluded that
34 the benefit estimates should be increased by a factor of two to account for the potential impacts
35 of external events.
36

37 The staff reviewed the bases for the applicant's cost estimates. For certain improvements, the
38 staff also compared the cost estimates to estimates developed elsewhere for similar
39 improvements, including estimates developed as part of other licensees' analyses of SAMAs for
40 operating reactors and advanced light-water reactors.
41

1 The staff concludes that the risk reduction and the cost estimates provided by TVA are
2 sufficient and appropriate for use in the SAMA evaluation.

3 4 **5.2.5 Cost/Benefit Comparison**

5
6 The cost-benefit analysis performed by TVA was based primarily on NUREG/BR-0184 (NRC
7 1997a) and was executed consistent with this guidance. The total benefit associated with each
8 of the 43 SAMAs was evaluated by TVA. These values were determined for the various
9 averted costs based on the estimated annual reductions in CDF and person-rem dose.

10
11 For the TVA SAMA evaluation, it is assumed that with all 3 units operational, the baseline CDFs
12 and risks for Units 1 and 2 are equal and will be four times greater than the CDF from the Unit 2
13 EPU PSA. Because Unit 1 is more closely tied to Unit 2 than to Unit 3, it is expected that the
14 impact of Unit 1 operation on the Unit 3 CDF and risk would be smaller than the above impact
15 on Unit 2. Based on this reasoning, the operation of Unit 1 is assumed to result in a factor of
16 two increase in Unit 3 CDF and risk from that indicated by the Unit 3 EPU PSA. Therefore,
17 TVA applied a multiplier of four to the Unit 2 averted cost estimates (benefits), assumed these
18 same benefits for Unit 1, and applied a multiplier of two to the Unit 3 averted cost estimates.
19 Additionally, TVA accounted for analysis uncertainties by comparing the implementation costs
20 with three times the averted cost estimates. As a result, all SAMAs that were evaluated were
21 eliminated because the cost was expected to exceed the estimated benefit, as adjusted to
22 account for multiple-unit operation and uncertainties.

23
24 The staff based its evaluation on TVA's estimated benefits for a seven-percent discount rate,
25 applied the same multipliers as TVA to account for multiple-unit operation, and applied an
26 additional multiplier of two to the averted cost estimates for each SAMA to account for the
27 potential impact of external events. As a result, none of the SAMAs appeared to be potentially
28 cost-beneficial. However, four SAMAs appeared to be within a factor of three of being cost-
29 beneficial. These involve: improving/enhancing procedures for load shedding, which would
30 improve DC reliability (SAMA B11); improving procedures and hardware changes for use of
31 cross-tied component cooling or service water (SW) pumps (SAMA G04); adding redundant DC
32 control power for the SW pumps (SAMA G12c); and, developing procedure(s) to instruct
33 operators to trip unneeded residual heat removal/core spray pumps on loss of room ventilation
34 (SAMA G17). TVA performed a more detailed assessment of each of these SAMAs to more
35 realistically estimate the risk reduction and/or implementation costs for each SAMA. Based on
36 the re-assessment, none of the SAMAs are within a factor of three of being cost-beneficial.
37

Postulated Accidents

5.2.6 Conclusions

The staff reviewed the TVA SAMA analysis and concluded that the methods used and the implementation of those methods were sound. The treatment of SAMA benefits and costs, the generally large negative net benefits, and the inherently small baseline risks support the general conclusion that the SAMA evaluations performed by TVA are reasonable and sufficient for the license renewal submittal.

The staff considered the impact if the cost and benefits were increased by a factor of three to account for uncertainties and determined that four SAMAs could be potentially cost-beneficial. TVA re-examined each of these SAMAs and provided a more realistic estimate of their benefits and/or implementation costs. As a result of this reassessment, the cost-benefit analyses showed that none of the candidate SAMAs were cost-beneficial.

The staff concludes that none of the candidate SAMAs are cost beneficial. This conclusion is consistent with the low residual level of risk indicated in the BFN PSA and the fact that BFN has already implemented many plant improvements identified from the IPE and IPEEE process, with the exception of the removal of the transformers, which is scheduled to occur in the future.

5.3 References

10 CFR Part 50. Code of Federal Regulations, Title 10, *Energy*, Part 50, "Domestic Licensing of Production and Utilization Facilities."

10 CFR Part 51. Code of Federal Regulations, Title 10, *Energy*, Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions."

10 CFR Part 54. Code of Federal Regulations, Title 10, *Energy*, Part 54, "Requirements for Renewal of Operating Licenses for Nuclear Power Plants."

10 CFR Part 100. Code of Federal Regulations, Title 10, *Energy*, Part 100, "Reactor Site Criteria."

Tennessee Valley Authority (TVA). 1992. Letter from Mark O. Medford, TVA, to U. S. NRC Document Control Desk. Subject: Browns Ferry Nuclear Plant (BFN) – Response to Generic Letter (GL) 88-20 – "Individual Plant Examination for Severe Accident Vulnerabilities – 10 CFR 50.54(f)," September 1, 1992.

1 Tennessee Valley Authority (TVA). 1995. Letter from Pedro Salas, TVA, to U. S. NRC
2 Document Control Desk. Subject: Browns Ferry Nuclear Plant (BFN) – Generic Letter (GL) 88-
3 20, Supplement 4, Individual Plant Examination of External Events (IPEEE) for Severe Accident
4 Vulnerabilities – Partial Submittal of Report, July 24, 1995.

5
6 Tennessee Valley Authority (TVA). 1996. Letter from Pedro Salas, TVA, to U. S. NRC
7 Document Control Desk. Subject: Browns Ferry Nuclear Plant (BFN) – Units 2 and 3 – Generic
8 Letter (GL) 87-02, Supplement 1, Verification of Seismic Adequacy of Mechanical and Electrical
9 Equipment in Operating Reactors, Unresolved Safety Issue (USI) A-46 and GL 88-20,
10 Supplement 4, Individual Plant Examination of External Events (IPEEE) for Severe Accident
11 Vulnerabilities – Submittal of Seismic Evaluation Reports (TAC Nos. M69431, M69432, M83596
12 and M83597), June 28, 1996.

13
14 Tennessee Valley Authority (TVA). 1997. Letter from T. E. Abney, TVA, to U. S. NRC
15 Document Control Desk. Subject: Browns Ferry Nuclear Plant (BFN) – Unit 3 – Generic Letter
16 (GL) 88-20, Supplement 4, Individual Plant Examination of External Events (IPEEE) for Severe
17 Accident Vulnerabilities – Submittal of Report Internal Fires Analysis (TAC No. M83597), July 11,
18 1997.

19
20 Tennessee Valley Authority (TVA). 2003. *Applicant's Environmental Report—Operating License*
21 *Renewal Stage, Browns Ferry Nuclear Power Plant Units 1, 2, and 3.* Tennessee Valley
22 Authority, Knoxville, Tennessee. December 2003.

23
24 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement*
25 *for License Renewal of Nuclear Plants.* NUREG-1437, Volumes 1 and 2, Washington, D.C.

26
27 U.S. Nuclear Regulatory Commission (NRC). 1997a. *Regulatory Analysis Technical Evaluation*
28 *Handbook.* NUREG/BR-0184, Washington, D.C.

29
30 U.S. Nuclear Regulatory Commission (NRC). 1997b. *Individual Plant Examination Program:*
31 *Perspectives on Reactor Safety and Plant Performance.* NUREG-1560, Washington, D.C.

32
33 U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement*
34 *for License Renewal of Nuclear Plants, Main Report, "Section 6.3 – Transportation, Table 9.1,*
35 *Summary of findings on NEPA issues for license renewal of nuclear power plants, Final Report."*
36 NUREG-1437, Volume 1, Addendum 1, Washington, D.C.

37
38 U.S. Nuclear Regulatory Commission (NRC). 2004a. Letter from Michael T. Masnik, U.S. NRC
39 to J. A. Scalice, Tennessee Valley Authority. Subject: Request for Additional Information (RAI)
40 Regarding Severe Accident Mitigation Alternatives for the Browns Ferry Nuclear Plant, Units 1,
41 2, and 3 (TAC Nos. MC1768, MC1769, and MC1770), April 28, 2004.

6.0 Environmental Impacts of the Uranium Fuel Cycle and Solid Waste Management

Environmental issues associated with the uranium fuel cycle and solid waste management are discussed in the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437, Volumes 1 and 2 (NRC 1996, 1999).^(a) The GEIS includes a determination of whether the analysis of the environmental issue could be applied to all plants and whether additional mitigation measures would be warranted. Issues are then assigned a Category 1 or a Category 2 designation. As set forth in the GEIS, Category 1 issues are those that meet all of the following criteria:

- (1) The environmental impacts associated with the issue have been determined to apply either to all plants or, for some issues, to plants having a specific type of cooling system or other specified plant or site characteristics.
- (2) A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to the impacts (except for collective offsite radiological impacts from the fuel cycle and from high-level waste [HLW] and spent fuel disposal).
- (3) Mitigation of adverse impacts associated with the issue has been considered in the analysis, and it has been determined that additional plant-specific mitigation measures are likely not to be sufficiently beneficial to warrant implementation.

For issues that meet the three Category 1 criteria, no additional plant-specific analysis is required unless new and significant information is identified.

Category 2 issues are those that do not meet one or more of the criteria for Category 1, and therefore, additional plant-specific review of these issues is required.

This chapter addresses the issues that are related to the uranium fuel cycle and solid waste management during the license renewal term that are listed in Table B-1 of Title 10 of the Code of Federal Regulations (CFR) Part 51, Subpart A, Appendix B, and are applicable to Browns Ferry Nuclear Plant, Units 1, 2, and 3 (BFN). The generic potential radiological and nonradiological environmental impacts of the uranium fuel cycle and transportation of nuclear fuel and wastes are described in detail in the GEIS based, in part, on the generic impacts provided in 10 CFR 51.51(b), Table S-3, "Table of Uranium Fuel Cycle Environmental Data," and in 10 CFR 51.52(c), Table S-4, "Environmental Impact of Transportation of Fuel and Waste to and

(a) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and its Addendum 1.

Fuel Cycle

1 from One Light-Water-Cooled Nuclear Power Reactor.” The GEIS also addresses the impacts
2 from radon-222 and technetium-99. There are no Category 2 issues for the uranium fuel cycle
3 and solid waste management.
4

5 **6.1 The Uranium Fuel Cycle**

6
7 Category 1 issues in 10 CFR Part 51, Subpart A, Appendix B, Table B-1, that are applicable to
8 BFN from the uranium fuel cycle and solid waste management are listed in Table 6-1.
9

10 **Table 6-1. Category 1 Issues Applicable to the Uranium Fuel Cycle and Solid Waste**
11 **Management During the License Renewal Term**

12	13 ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	13 GEIS Section
14	URANIUM FUEL CYCLE AND WASTE MANAGEMENT	
15	Offsite radiological impacts (individual effects from other than the	6.1; 6.2.1; 6.2.2.1; 6.2.2.3;
16	disposal of spent fuel and high-level waste)	6.2.3; 6.2.4; 6.6
17	Offsite radiological impacts (collective effects)	6.1; 6.2.2.1; 6.2.3; 6.2.4; 6.6
18	Offsite radiological impacts (spent fuel and high-level waste)	6.1; 6.2.2.1; 6.2.3; 6.2.4; 6.6
19	Nonradiological impacts of the uranium fuel cycle	6.1; 6.2.2.6; 6.2.2.7; 6.2.2.8; 6.2.2.9; 6.2.3; 6.2.4; 6.6
20	Low-level waste storage and disposal	6.1; 6.2.2.2; 6.4.2; 6.4.3; 6.4.3.1; 6.4.3.2; 6.4.3.3; 6.4.4; 6.4.4.1; 6.4.4.2; 6.4.4.3; 6.4.4.4; 6.4.4.5; 6.4.4.5.1; 6.4.4.5.2; 6.4.4.5.3; 6.4.4.5.4; 6.4.4.6; 6.6
21	Mixed waste storage and disposal	6.4.5.1; 6.4.5.2; 6.4.5.3; 6.4.5.4; 6.4.5.5; 6.4.5.6; 6.4.5.6.1; 6.4.5.6.2; 6.4.5.6.3; 6.4.5.6.4; 6.6
22		
23		
24	Onsite spent fuel	6.1; 6.4.6; 6.4.6.1; 6.4.6.2; 6.4.6.3; 6.4.6.4; 6.4.6.5; 6.4.6.6; 6.4.6.7; 6.6
25	Nonradiological waste	6.1; 6.5; 6.5.1; 6.5.2; 6.5.3; 6.6
26	Transportation	6.1; 6.3.1; 6.3.2.3; 6.3.3; 6.3.4; 6.6, Addendum 1
27		

1 The Tennessee Valley Authority (TVA) stated in its Environmental Report (ER) (TVA 2003) that
2 it is not aware of any new and significant information associated with renewal of the BFN
3 operating licenses. The staff has not identified any new and significant information during its
4 independent review of the TVA ER, the staff's site visit, the scoping process, or its evaluation of
5 other available information, such as operation at a combined total power level of 11,856 MW(t).
6 Therefore, the staff concludes that there are no impacts related to these issues beyond those
7 discussed in the GEIS. For these issues, the staff concluded in the GEIS that the impacts are
8 SMALL except for collective offsite radiological impacts from the fuel cycle and from HLW and
9 spent fuel disposal, as discussed below, and that additional plant-specific mitigation measures
10 are not likely to be sufficiently beneficial to be warranted.

11
12 A brief description of the staff review and the GEIS conclusions, as codified in Table B-1,
13 10 CFR Part 51, for each of these issues follows:

- 14
15 • Offsite radiological impacts (individual effects from other than the disposal of spent fuel
16 and high level waste). Based on information in the GEIS, the Commission found that

17
18 Off-site impacts of the uranium fuel cycle have been considered by the
19 Commission in Table S-3 of this part [10 CFR 51.51(b)]. Based on information in
20 the GEIS, impacts on individuals from radioactive gaseous and liquid releases
21 including radon-222 and technetium-99 are small.

22
23 The staff has not identified any new and significant information during its independent
24 review of the TVA ER, the staff's site visit, the scoping process, or its evaluation of other
25 available information, such as operation at a combined total power level of 11,856 MW(t).
26 Therefore, the staff concludes that there are no offsite radiological impacts of the uranium
27 fuel cycle during the license renewal term beyond those discussed in the GEIS.

- 28
29 • Offsite radiological impacts (collective effects). Based on information in the GEIS, the
30 Commission found that

31
32 The 100 year environmental dose commitment to the U.S. population from the
33 fuel cycle, high level waste and spent fuel disposal excepted, is calculated to be
34 about 14,800 person rem [148 person Sv], or 12 cancer fatalities, for each
35 additional 20-year power reactor operating term. Much of this, especially the
36 contribution of radon releases from mines and tailing piles, consists of tiny doses
37 summed over large populations. This same dose calculation can theoretically be
38 extended to include many tiny doses over additional thousands of years as well
39 as doses outside the U.S. The result of such a calculation would be thousands
40 of cancer fatalities from the fuel cycle, but this result assumes that even tiny
41 doses have some statistical adverse health effect which will not ever be

Fuel Cycle

1 mitigated (for example no cancer cure in the next thousand years), and that
2 these doses projected over thousands of years are meaningful. However, these
3 assumptions are questionable. In particular, science cannot rule out the
4 possibility that there will be no cancer fatalities from these tiny doses. For
5 perspective, the doses are very small fractions of regulatory limits and even
6 smaller fractions of natural background exposure to the same populations.
7

8 Nevertheless, despite all the uncertainty, some judgement as to the regulatory
9 NEPA [National Environmental Policy Act] implications of these matters should
10 be made and it makes no sense to repeat the same judgement in every case.
11 Even taking the uncertainties into account, the Commission concludes that these
12 impacts are acceptable in that these impacts would not be sufficiently large to
13 require the NEPA conclusion, for any plant, that the option of extended operation
14 under 10 CFR Part 54 should be eliminated. Accordingly, while the Commission
15 has not assigned a single level of significance for the collective effects of the fuel
16 cycle, this issue is considered Category 1.
17

18 The staff has not identified any new and significant information during its independent
19 review of the TVA-ER, the staff's site visit, the scoping process, or its evaluation of other
20 available information, such as operation at a combined total power level of 11,856 MW(t).
21 Therefore, the staff concludes that there are no offsite radiological impacts (collective
22 effects) from the uranium fuel cycle during the license renewal term beyond those
23 discussed in the GEIS.
24

- 25 • Offsite radiological impacts (spent fuel and high level waste disposal). Based on
26 information in the GEIS, the Commission found that
27

28 For the high level waste and spent fuel disposal component of the fuel cycle,
29 there are no current regulatory limits for offsite releases of radionuclides for the
30 current candidate repository site. However, if we assume that limits are
31 developed along the lines of the 1995 National Academy of Sciences (NAS)
32 report [NAS 1995], "Technical Bases for Yucca Mountain Standards," and that in
33 accordance with the Commission's Waste Confidence Decision, 10 CFR 51.23, a
34 repository can and likely will be developed at some site which will comply with
35 such limits, peak doses to virtually all individuals will be 100 millirem [1 mSv] per
36 year or less. However, while the Commission has reasonable confidence that
37 these assumptions will prove correct, there is considerable uncertainty since the
38 limits are yet to be developed, no repository application has been completed or
39 reviewed, and uncertainty is inherent in the models used to evaluate possible
40 pathways to the human environment. The NAS report indicated that 100 millirem
41 [1 mSv] per year should be considered as a starting point for limits for individual

1 doses, but notes that some measure of consensus exists among national and
2 international bodies that the limits should be a fraction of the 100 millirem
3 [1 mSv] per year. The lifetime individual risk from 100 millirem [1 mSv] annual
4 dose limit is about 3×10^{-3} .

5
6 Estimating cumulative doses to populations over thousands of years is more
7 problematic. The likelihood and consequences of events that could seriously
8 compromise the integrity of a deep geologic repository were evaluated by the
9 Department of Energy in the "Final Environmental Impact Statement:
10 Management of Commercially Generated Radioactive Waste," October 1980
11 [DOE 1980]. The evaluation estimated the 70-year whole-body dose
12 commitment to the maximum individual and to the regional population resulting
13 from several modes of breaching a reference repository in the year of closure,
14 after 1,000 years, after 100,000 years, and after 100,000,000 years. Subse-
15 quently, the NRC and other federal agencies have expended considerable effort
16 to develop models for the design and for the licensing of a high level waste
17 repository, especially for the candidate repository at Yucca Mountain. More
18 meaningful estimates of doses to population may be possible in the future as
19 more is understood about the performance of the proposed Yucca Mountain
20 repository. Such estimates would involve very great uncertainty, especially with
21 respect to cumulative population doses over thousands of years. The standard
22 proposed by the NAS is a limit on maximum individual dose. The relationship of
23 potential new regulatory requirements, based on the NAS report, and cumulative
24 population impacts has not been determined, although the report articulates the
25 view that protection of individuals will adequately protect the population for a
26 repository at Yucca Mountain. However, EPA's generic repository standards in
27 40 CFR part 191 generally provide an indication of the order of magnitude of
28 cumulative risk to population that could result from the licensing of a Yucca
29 Mountain repository, assuming the ultimate standards will be within the range of
30 standards now under consideration. The standards in 40 CFR part 191 protect
31 the population by imposing "containment requirements" that limit the cumulative
32 amount of radioactive material released over 10,000 years. Reporting
33 performance standards that will be required by EPA are expected to result in
34 releases and associated health consequences in the range between 10 and
35 100 premature cancer deaths with an upper limit of 1,000 premature cancer
36 deaths world-wide for a 100,000 metric tonne (MT) repository.

37
38 Nevertheless, despite all the uncertainty, some judgement as to the regulatory
39 NEPA implications of these matters should be made and it makes no sense to
40 repeat the same judgement in every case. Even taking the uncertainties into
41 account, the Commission concludes that these impacts are acceptable in that

Fuel Cycle

1 these impacts would not be sufficiently large to require the NEPA conclusion, for
2 any plant, that the option of extended operation under 10 CFR part 54 should be
3 eliminated. Accordingly, while the Commission has not assigned a single level of
4 significance for the impacts of spent fuel and high level waste disposal, this issue
5 is considered Category 1.
6

7 On February 15, 2002, subsequent to the preparation of an environmental impact statement
8 (DOE 2002) and receipt of a recommendation by the Secretary, U.S. Department of Energy,
9 the President recommended the Yucca Mountain site for the development of a repository for
10 the geologic disposal of spent nuclear fuel and high-level nuclear waste. The U.S.
11 Congress approved this recommendation on July 9, 2002. On July 23, 2002, the President
12 signed into law House Joint Resolution 87 designating Yucca Mountain as the repository for
13 spent nuclear fuel and HLW. This development does not represent new and significant
14 information with respect to the offsite radiological impacts related to spent fuel and HLW
15 disposal related to license renewal.
16

17 On June 13, 2001, acting pursuant to the Energy Policy Act, the U.S. Environmental
18 Protection Agency (EPA) published its final rule, "Public Health and Environmental
19 Radiation Protection Standards for Yucca Mountain, Nevada," at 40 CFR Part 197
20 (66 FR 32074). Shortly thereafter, NRC issued its conforming licensing standards in
21 10 CFR Part 63, "Disposal of High-level Radioactive Wastes in a Proposed Geological
22 Repository at Yucca Mountain, Nevada" (66 FR 55732). On July 9, 2004, in *Nuclear Energy*
23 *Institute, Inc. v. EPA*, No. 01-1258, the U.S. Court of Appeals for the District of Columbia
24 Circuit vacated the EPA's 40 CFR Part 197 standard and, insofar as the NRC incorporated
25 the EPA compliance period (i.e., 10,000 years for Yucca Mountain) in its rule, 10 CFR
26 Part 63 was also vacated (D.C. Cir. July 9, 2004). The promulgation of the EPA and NRC
27 rules subsequent to the issuance of the GEIS and the invalidation of the 40 CFR 197
28 standard does not change the Commission's conclusions that the offsite radiological
29 impacts are not sufficiently large that the option of extended operation under 10 CFR Part
30 54 should be eliminated.
31

32 The staff has not identified any new and significant information during its independent
33 review of the TVA ER, the staff's site visit, the scoping process, or its evaluation of other
34 available information, including operation at a combined total of 11,856 MW(t). Therefore,
35 the staff concludes that there are no offsite radiological impacts related to spent fuel and
36 HLW disposal during the license renewal term beyond those discussed in the GEIS.
37
38
39
40

- 1 • Nonradiological impacts of the uranium fuel cycle. Based on information in the GEIS,
2 the Commission found that

3
4 The nonradiological impacts of the uranium fuel cycle resulting from the renewal
5 of an operating license for any plant are found to be small.
6

7 The staff has not identified any new and significant information during its independent
8 review of the TVA ER, the staff's site visit, the scoping process, or its evaluation of other
9 available information, such as operation at a combined total power level of 11,856 MW(t).
10 Therefore, the staff concludes that there are no nonradiological impacts of the uranium fuel
11 cycle during the license renewal term beyond those discussed in the GEIS.
12

- 13 • Low-level waste storage and disposal. Based on information in the GEIS, the
14 Commission found that

15
16 The comprehensive regulatory controls that are in place and the low public
17 doses being achieved at reactors ensure that the radiological impacts to the
18 environment will remain small during the term of a renewed license. The
19 maximum additional on-site land that may be required for low-level waste
20 storage during the term of a renewed license and associated impacts will be
21 small. Nonradiological impacts on air and water will be negligible. The
22 radiological and nonradiological environmental impacts of long-term disposal of
23 low-level waste from any individual plant at licensed sites are small. In addition,
24 the Commission concludes that there is reasonable assurance that sufficient low-
25 level waste disposal capacity will be made available when needed for facilities to
26 be decommissioned consistent with NRC decommissioning requirements.
27

28 The staff has not identified any new and significant information during its independent
29 review of the TVA ER, the staff's site visit, the scoping process, or its evaluation of other
30 available information, such as operation at a combined total power level of 11,856 MW(t).
31 Therefore, the staff concludes that there are no impacts of low-level waste storage and
32 disposal associated with the license renewal term beyond those discussed in the GEIS.
33

- 34 • Mixed waste storage and disposal. Based on information in the GEIS, the Commission
35 found that

36
37 The comprehensive regulatory controls and the facilities and procedures that are
38 in place ensure proper handling and storage, as well as negligible doses and
39 exposure to toxic materials for the public and the environment at all plants.
40 License renewal will not increase the small, continuing risk to human health and
41 the environment posed by mixed waste at all plants. The radiological and

Fuel Cycle

1 nonradiological environmental impacts of long-term disposal of mixed waste from
2 any individual plant at licensed sites are small. In addition, the Commission
3 concludes that there is reasonable assurance that sufficient mixed waste
4 disposal capacity will be made available when needed for facilities to be
5 decommissioned consistent with NRC decommissioning requirements.
6

7 The staff has not identified any new and significant information during its independent
8 review of the TVA ER, the staff's site visit, the scoping process, or its evaluation of other
9 available information, such as operation at a combined total power level of 11,856 MW(t).
10 Therefore, the staff concludes that there are no impacts of mixed waste storage and
11 disposal associated with the license renewal term beyond those discussed in the GEIS.
12

- 13 • Onsite spent fuel. Based on information in the GEIS, the Commission found that

14
15 The expected increase in the volume of spent fuel from an additional 20 years of
16 operation can be safely accommodated on site with small environmental effects
17 through dry or pool storage at all plants if a permanent repository or monitored
18 retrievable storage is not available.
19

20 The staff has not identified any new and significant information during its independent
21 review of the TVA ER, the staff's site visit, the scoping process, or its evaluation of other
22 available information, such as operation at a combined total power level of 11,856 MW(t).
23 Therefore, the staff concludes that there are no impacts of onsite spent fuel associated with
24 the license renewal term beyond those discussed in the GEIS.
25

- 26 • Nonradiological waste. Based on information in the GEIS, the Commission found that

27
28 No changes to generating systems are anticipated for license renewal. Facilities
29 and procedures are in place to ensure continued proper handling and disposal at
30 all plants.
31

32 The staff has not identified any new and significant information during its independent
33 review of the TVA ER, the staff's site visit, the scoping process, or its evaluation of other
34 available information, such as operation at a combined total power level of 11,856 MW(t).
35 Therefore, the staff concludes that there are no nonradiological waste impacts during the
36 license renewal term beyond those discussed in the GEIS.
37

- 1 • Transportation. Based on information contained in the GEIS, the Commission found
2 that

3
4 The impacts of transporting spent fuel enriched up to 5 percent uranium-235 with
5 average burnup for the peak rod to current levels approved by NRC up to
6 62,000 MWd/MTU and the cumulative impacts of transporting high-level waste to
7 a single repository, such as Yucca Mountain, Nevada are found to be consistent
8 with the impact values contained in 10 CFR 51.52(c), Summary
9 Table S-4—Environmental Impact of Transportation of Fuel and Waste to and
10 from One Light-Water-Cooled Nuclear Power Reactor. If fuel enrichment or
11 burnup conditions are not met, the applicant must submit an assessment of the
12 implications for the environmental impact values reported in § 51.52.
13

14 BFN meets the fuel-enrichment and burnup conditions set forth in Addendum 1 to the GEIS.
15 The staff has not identified any new and significant information during its independent
16 review of the TVA ER, the staff's site visit, the scoping process, or its evaluation of other
17 available information, such as operation at a combined total power level of 11,856 MW(t).
18 Therefore, the staff concludes that there are no impacts of transportation associated with
19 the license renewal term beyond those discussed in the GEIS.
20

21 6.2 References

22
23 10 CFR Part 51. Code of Federal Regulations, Title 10, *Energy*, Part 51, "Environmental
24 Protection Regulations for Domestic Licensing and Related Regulatory Functions."

25
26 10 CFR Part 54. Code of Federal Regulations, Title 10, *Energy*, Part 54, "Requirements for
27 Renewal of Operating Licenses for Nuclear Power Plants."

28
29 10 CFR Part 63. Code of Federal Regulations, Title 10, *Energy*, Part 63, "Disposal of High-
30 Level Radioactive Wastes in a Geologic Repository at Yucca Mountain, Nevada."

31 40 CFR Part 191. Code of Federal Regulations, Title 40, *Protection of Environment*, Part 191,
32 "Environmental Radiation Protection Standards for Management and Disposal of Spent Nuclear
33 Fuel, High-Level and Transuranic Radioactive Waste."

34
35 40 CFR Part 197. Code of Federal Regulations, Title 40, *Protection of Environment*, Part 197,
36 "Public Health and Environmental Radiation Protection Standards for Yucca Mountain,
37 Nevada."

38
39 National Academy of Sciences (NAS). 1995. *Technical Bases for Yucca Mountain Standards*.
40 Washington, D.C.

Fuel Cycle

- 1 National Environmental Policy Act (NEPA) of 1969, as amended, 42 USC 4321, et. seq.
2
3 Tennessee Valley Authority (TVA). 2003. *Applicant's Environmental Report – Operating*
4 *License Renewal Stage, Browns Ferry Units 1, 2, and 3*. Knoxville, Tennessee.
5
6 U.S. Department of Energy (DOE). 1980. *Final Environmental Impact Statement:*
7 *Management of Commercially Generated Radioactive Waste*. DOE/EIS-0046F,
8 Washington, D.C.
9
10 U.S. Department of Energy (DOE). 2002. *Final Environmental Impact Statement for a*
11 *Geologic Repository for the Disposal of Spent Nuclear Fuel and High-Level Radioactive Waste*
12 *at Yucca Mountain, Nye County, Nevada*. DOE/EIS-0250F, Office of Civilian Radioactive
13 Waste Management, Washington, D.C.
14
15 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement*
16 *for License Renewal of Nuclear Plants*. NUREG-1437, Volumes 1 and 2, Washington, D.C.
17
18 U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement*
19 *for License Renewal of Nuclear Plants, Main Report*, "Section 6.3 – Transportation, Table 9.1,
20 Summary of findings on NEPA issues for license renewal of nuclear power plants, Final
21 Report." NUREG-1437, Volume 1, Addendum 1, Washington, D.C.
22

7.0 Environmental Impacts of Decommissioning

Environmental impacts from the activities associated with the decommissioning of any reactor, before or at the end of an initial or renewed license are evaluated in the *Generic Environmental Impact Statement for Decommissioning of Nuclear Facilities Regarding the Decommissioning of Nuclear Power Reactors*, NUREG-0586, Supplement 1 (NRC 2002). The staff's evaluation of the environmental impacts of decommissioning presented in Supplement 1 resulted in a range of impacts for each environmental issue. These results may be used by licensees as a starting point for a plant-specific evaluation of the decommissioning impacts at their facilities.

The incremental environmental impacts associated with decommissioning activities resulting from continued plant operation during the renewal term are evaluated in the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437, Volumes 1 and 2 (NRC 1996, 1999).^(a) The evaluation in NUREG-1437 includes a determination of whether the analysis of the environmental issue could be applied to all plants and whether additional mitigation measures would be warranted. Issues are then assigned a Category 1 or a Category 2 designation. As set forth in the GEIS, Category 1 issues are those that meet all of the following criteria:

- (1) The environmental impacts associated with the issue have been determined to apply either to all plants or, for some issues, to plants having a specific type of cooling system or other specified plant or site characteristics.
- (2) A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to the impacts (except for collective offsite radiological impacts from the fuel cycle and from high level waste and spent fuel disposal):
- (3) Mitigation of adverse impacts associated with the issue has been considered in the analysis, and it has been determined that additional plant-specific mitigation measures are likely not to be sufficiently beneficial to warrant implementation.

For issues that meet the three Category 1 criteria, no additional plant-specific analysis is required unless new and significant information is identified.

Category 2 issues are those that do not meet one or more of the criteria for Category 1, and therefore, additional plant-specific review of these issues is required. There are no Category 2 issues related to decommissioning.

(a) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and its Addendum 1.

7.1 Decommissioning

Category 1 issues in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B that are applicable to Browns Ferry Nuclear Plant, Units 1, 2, and 3 decommissioning following the renewal term are listed in Table 7-1. Tennessee Valley Authority (TVA) stated in its Environmental Report (ER) (TVA 2003) that it is aware of no new and significant information regarding the environmental impacts of Browns Ferry Nuclear Plant, Units 1, 2, and 3 license renewal. The staff has not identified any new and significant information during its independent review of the TVA ER, the staff's site visit, the scoping process, or its evaluation of other available information, such as operation at a combined total power level of 11,856 MW(t). Therefore, the staff concludes that there are no impacts related to these issues beyond those discussed in the GEIS. For all of these issues, the staff concluded in the GEIS that the impacts are SMALL, and additional plant-specific mitigation measures are not likely to be sufficiently beneficial to be warranted.

Table 7-1. Category 1 Issues Applicable to the Decommissioning of Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 Following the License Renewal Term

	ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Section
	DECOMMISSIONING	
21	Radiation Doses	7.3.1; 7.4
22	Waste Management	7.3.2; 7.4
23	Air Quality	7.3.3; 7.4
24	Water Quality	7.3.4; 7.4
25	Ecological Resources	7.3.5; 7.4
26	Socioeconomic Impacts	7.3.7; 7.4

A brief description of the staff's review and the GEIS conclusions, as codified in Table B-1, for each of the issues follows:

- Radiation doses. Based on information in the GEIS, the Commission found that

Doses to the public will be well below applicable regulatory standards regardless of which decommissioning method is used. Occupational doses would increase no more than 1 man-rem [0.01 person-Sv] caused by buildup of long-lived radionuclides during the license renewal term.

The staff has not identified any new and significant information during its independent review of the TVA ER, the staff's site visit, the scoping process, or its evaluation of other

1 available information, such as operation at a combined total power level of 11,856 MW(t).
2 Therefore, the staff concludes that there are no radiation dose impacts associated with
3 decommissioning following the license renewal term beyond those discussed in the GEIS.
4

- 5 • Waste management. Based on information in the GEIS, the Commission found that

6
7 Decommissioning at the end of a 20-year license renewal period would generate
8 no more solid wastes than at the end of the current license term. No increase in
9 the quantities of Class C or greater than Class C wastes would be expected.
10

11 The staff has not identified any new and significant information during its independent
12 review of the TVA ER, the staff's site visit, the scoping process, or its evaluation of other
13 available information, such as operation at a combined total power level of 11,856 MW(t).
14 Therefore, the staff concludes that there are no impacts from solid waste associated with
15 decommissioning following the license renewal term beyond those discussed in the GEIS.
16

- 17 • Air quality. Based on information in the GEIS, the Commission found that

18
19 Air quality impacts of decommissioning are expected to be negligible either at
20 the end of the current operating term or at the end of the license renewal term.
21

22 The staff has not identified any new and significant information during its independent
23 review of the TVA ER, the staff's site visit, the scoping process, or its evaluation of other
24 available information, such as operation at a combined total power level of 11,856 MW(t).
25 Therefore, the staff concludes that there are no impacts on air quality associated with
26 decommissioning following the license renewal term beyond those discussed in the GEIS.
27

- 28 • Water quality. Based on information in the GEIS, the Commission found that

29
30 The potential for significant water quality impacts from erosion or spills is no
31 greater whether decommissioning occurs after a 20-year license renewal period
32 or after the original 40-year operation period, and measures are readily available
33 to avoid such impacts.
34

35 The staff has not identified any new and significant information during its independent
36 review of the TVA ER, the staff's site visit, the scoping process, or its evaluation of other
37 available information, such as operation at a combined total power level of 11,856 MW(t).
38 Therefore, the staff concludes that there are no impacts on water quality associated with
39 decommissioning following the license renewal term beyond those discussed in the GEIS.
40
41

Environmental Impacts of Decommissioning

- 1 • Ecological resources. Based on information in the GEIS, the Commission found that
2
3 Decommissioning after either the initial operating period or after a 20-year
4 license renewal period is not expected to have any direct ecological impacts.
5

6 The staff has not identified any new and significant information during its independent
7 review of the TVA ER, the staff's site visit, the scoping process, or its evaluation of other
8 available information, such as operation at a combined total power level of 11,856 MW(t).
9 Therefore, the staff concludes that there are no impacts on ecological resources associated
10 with decommissioning following the license renewal term beyond those discussed in the
11 GEIS.
12

- 13 • Socioeconomic Impacts. Based on information in the GEIS, the Commission found that
14
15 Decommissioning would have some short-term socioeconomic impacts. The
16 impacts would not be increased by delaying decommissioning until the end of a
17 20-year relicense period, but they might be decreased by population and
18 economic growth.
19

20 The staff has not identified any new and significant information during its independent
21 review of the TVA ER, the staff's site visit, the scoping process, or its evaluation of other
22 available information, such as operation at a combined total power level of 11,856 MW(t).
23 Therefore, the staff concludes that there are no socioeconomic impacts associated with
24 decommissioning following the license renewal term beyond those discussed in the GEIS.
25

26 7.2 References

27
28 10 CFR Part 51. Code of Federal Regulations, Title 10, *Energy*, Part 51, "Environmental
29 Protection Regulations for Domestic Licensing and Related Regulatory Functions."

30
31 Tennessee Valley Authority (TVA). 2003. *Applicant's Environmental Report – Operating
32 License Renewal Stage, Browns Ferry Units 1, 2, and 3*. Knoxville, Tennessee.
33

34 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement
35 for License Renewal of Nuclear Plants*. NUREG-1437, Volumes 1 and 2, Washington, D.C.
36

37 U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement
38 for License Renewal of Nuclear Plants, Main Report*, "Section 6.3 – Transportation, Table 9.1,
39 Summary of findings on NEPA issues for license renewal of nuclear power plants, Final
40 Report." NUREG-1437, Volume 1, Addendum 1, Washington, D.C.

Environmental Impacts of Decommissioning

- 1 U.S. Nuclear Regulatory Commission (NRC). 2002. *Generic Environmental Impact Statement*
- 2 *on Decommissioning of Nuclear Facilities. Supplement 1 Regarding the Decommissioning of*
- 3 *Nuclear Power Reactors. Final Report.* NUREG-0586, Supplement 1, Volumes 1 and 2.
- 4 Office of Nuclear Reactor Regulation, Washington, D.C.

8.0 Environmental Impacts of Alternatives to Operating License Renewal

This chapter examines the potential environmental impacts associated with denying the renewal of the operating licenses (OLs) (i.e., the no-action alternative) for Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 (BFN); the potential environmental impacts from electric generating sources other than BFN; the possibility of purchasing electric power from other sources to replace power generated by BFN and the associated environmental impacts; the potential environmental impacts from a combination of generating and conservation measures; and other generation alternatives that were deemed unsuitable for replacement of power generated by BFN. The environmental impacts are evaluated using the U.S. Nuclear Regulatory Commission's (NRC's) three-level standard of significance – SMALL, MODERATE, or LARGE – developed using the Council on Environmental Quality guidelines and set forth in the footnotes to Table B-1 of Title 10 of the Code of Federal Regulations (CFR) Part 51, Subpart A, Appendix B:

SMALL – Environmental effects are not detectable or are so minor that they will neither destabilize nor noticeably alter any important attribute of the resource.

MODERATE – Environmental effects are sufficient to alter noticeably, but not to destabilize important attributes of the resource.

LARGE – Environmental effects are clearly noticeable and are sufficient to destabilize important attributes of the resource.

The impact categories evaluated in this chapter are the same as those used in the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437, Volumes 1 and 2 (NRC 1996, 1999)^(a) with the additional impact categories of environmental justice and transportation.

8.1 No-Action Alternative

NRC's regulations implementing the National Environmental Policy Act of 1969 (NEPA) specify that the no-action alternative be discussed in an NRC environmental impact statement (EIS) (10 CFR Part 51, Subpart A, Appendix A(4)). For license renewal, the no-action alternative refers to a scenario in which NRC would not renew the OLs for the three BFN units. The Tennessee Valley Authority (TVA) would then decommission the three BFN units after plant operations cease.

(a) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and its Addendum 1.

Alternatives

1 TVA states in its Environmental Report (ER) (TVA 2003) that if renewal of the Unit 1 OL is
2 denied, further work on Unit 1 recovery and restart would terminate because restart would be
3 economically infeasible. Operation of Units 2 and 3 would cease upon expiration of their OLs
4 in 2014 and 2016, respectively. TVA would likely jointly and concurrently decommission all
5 three units after the expiration of the Unit 3 OL (TVA 2003).
6

7 Under the no-action alternative, replacement of BFN electricity generation capacity would be
8 met by (1) demand-side management (DSM) and energy conservation, (2) power purchased
9 from other electricity providers, (3) TVA generating alternatives other than BFN, or (4) some
10 combination of these options. The environmental impacts associated with alternative
11 generation technologies are discussed in Section 8.2.
12

13 TVA will be required to comply with NRC decommissioning requirements at 10 CFR 50.82
14 whether or not the BFN OLs are renewed. If the OLs are renewed, decommissioning activities
15 may be postponed for up to an additional 20 years.
16

17 The environmental impacts associated with decommissioning under both license renewal and
18 the no-action alternative would be bounded by the discussion of impacts in Chapter 7 of the
19 GEIS, Chapter 7 of this draft supplemental environmental impact statement (SEIS), and
20 Supplement 1 to the *Final Generic Environmental Impact Statement on Decommissioning of
21 Nuclear Facilities Regarding the Decommissioning of Nuclear Power Reactors* (NRC 2002).
22 The impacts of decommissioning after 60 years of operation are not expected to be significantly
23 different from those occurring after 40 years of operation.
24

25 The environmental impacts resulting from the no-action alternative are summarized in Table 8-1
26 and are discussed in the following paragraphs. Implementation of the no-action alternative
27 would also have certain positive impacts in that adverse environmental impacts associated with
28 the current operation of BFN would be eliminated.
29

30 **Table 8-1. Summary of Environmental Impacts of the No-Action Alternative at the Browns Ferry**
31 **Nuclear Power Plant, Units 1,2,and 3**
32

33	Impact Category	Impact	Comment
34	Land Use	SMALL	Onsite impacts expected to be temporary. No offsite impacts expected.
35	Ecology	SMALL	Impacts to ecology are expected to be temporary and can be mitigated using best management practices.
36	Water Use and Quality	SMALL	Water use would decrease. Water quality unlikely to be adversely affected.
37	Air Quality	SMALL	Greatest impact is likely to be from fugitive dust; impact can be mitigated using best management practices.

Table 8-1. (contd)

Impact Category	Impact	Comment
Waste	SMALL	Low-Level radioactive waste (LLW) would be disposed of in licensed facilities. High-level radioactive waste (HLW) can be safely stored until a permanent HLW repository is available.
Human Health	SMALL	Radiological doses to workers and members of the public are expected to be within regulatory limits and comparable to, or lower than, doses from operating plants. Occupational injuries are possible, but injury rates at nuclear power plants are below the U.S. average industrial rate.
Socioeconomics	MODERATE	Decrease in employment in Limestone County and surrounding counties and tax revenues in Limestone County.
Aesthetics	SMALL	Positive impact from eventual removal of buildings and structures. Some noise impact during decommissioning operations.
Historic and Archaeological Resources	SMALL	Minimal impact on land utilized during plant operations. Land occupied by BFN would likely be retained by TVA for other purposes.
Environmental Justice	SMALL	Some loss of employment opportunities and social programs is expected.

8.1.1 Land Use

Temporary changes in onsite land use could occur during decommissioning. Temporary changes may include addition or expansion of staging and laydown areas or construction of temporary buildings and parking areas. Offsite land-use impacts associated with uranium mining would no longer occur. In the GEIS, the staff estimated that approximately 400 ha (1000 ac) would be affected for mining the uranium and processing it during the operating life of a 1000-MW(e) nuclear power plant (NRC 1996). Following decommissioning, the land occupied by BFN would likely be retained by TVA for other purposes. It is expected that the existing transmission system, including rights-of-way, would be retained. Eventual sale or transfer of the land occupied by the plant, however, could result in changes to land use. Notwithstanding this possibility, the impacts of the no-action alternative on land use are considered SMALL.

8.1.2 Ecology

Impacts on aquatic ecology could result from removal of in-water pipes and structures. Any impacts to aquatic ecology would likely be short term and could be mitigated. The aquatic environment is expected to recover naturally. Impacts on the terrestrial ecology could occur as a result of land disturbance for additional laydown yards, stockpiles, and support facilities. Land disturbance is expected to be minimal and result in relatively short-term impacts that can be

Alternatives

1 mitigated using best management practices. The land is expected to recover naturally.
2 Overall, the ecological impacts associated with decommissioning are considered SMALL.

3 4 **8.1.3 Water Use and Quality**

5
6 Cessation of plant operations would result in a significant reduction in water use because
7 reactor cooling would no longer be required. As plant staff size decreases, the demand for
8 potable water is expected to also decrease. Onsite disposal of demolition debris could result in
9 minimal impacts to water quality. Overall, water use and quality impacts of decommissioning
10 are considered SMALL.

11 12 **8.1.4 Air Quality**

13
14 Decommissioning activities that can adversely affect air quality include dismantlement of
15 systems and equipment, demolition of buildings and structures, and the operation of internal
16 combustion engines. The most likely adverse impact would be the generation of fugitive dust.
17 Best management practices, such as seeding and wetting, can be used to minimize the
18 generation of fugitive dust. Overall, air-quality impacts associated with decommissioning
19 activities are considered SMALL.

20 21 **8.1.5 Waste**

22
23 Decommissioning activities would result in the generation of radioactive and nonradioactive
24 waste. The volume of low-level radioactive waste (LLW) is related to the type and size of the
25 plant, the decommissioning option chosen, and the waste treatment and volume reduction
26 procedures used. LLW must be disposed of in a facility licensed by NRC or a State with
27 authority delegated by NRC. Recent advances in volume reduction and waste processing have
28 significantly reduced waste volumes. A permanent repository for high-level radioactive waste
29 (HLW) is not currently available. The NRC has made a generic determination that, if
30 necessary, spent fuel generated in any reactor can be stored safely and without significant
31 environmental impacts for at least 30 years beyond the licensed life for operation (which may
32 include the term of a revised or renewed license) of that reactor at its spent fuel storage basin
33 or at either onsite or offsite independent spent fuel storage installations (10 CFR 51.23(a)).
34 Disposal of nonradioactive waste would be at onsite and offsite licensed disposal facilities.
35 Overall, waste impacts associated with decommissioning activities are considered SMALL.

36 37 **8.1.6 Human Health**

38
39 Radiological doses to occupational workers during decommissioning activities are estimated to
40 average approximately 5 percent of the dose limits in 10 CFR Part 20, and to be similar to, or
41 lower than, the doses experienced by workers in operating nuclear power plants. Collective
42 doses to members of the public and to the maximally exposed individual as a result of decom-

1 missioning activities are estimated to be well below the limits in 10 CFR Part 20, and to be
2 similar to, or lower than, the doses received from operating nuclear power plants. Occupational
3 injuries to workers engaged in decommissioning activities are possible. However, historical
4 injury and fatality rates at nuclear power plants have been lower than the average U.S.
5 industrial rates. Overall, the human health impacts associated with decommissioning activities
6 are considered SMALL.

8 **8.1.7 Socioeconomics**

9
10 If BFN ceased operation, there would be a decrease in employment and tax revenues
11 associated with the closure. Impacts on employment (primary and secondary) and population
12 would occur over a wide area. BFN employees reside in a number of counties; however,
13 approximately 75 percent of employees live in Lauderdale, Limestone, Madison, and Morgan
14 Counties (TVA 2003).

15
16 Tax-related impacts would occur in Limestone County and surrounding counties. TVA makes
17 tax-equivalent payments to states served by TVA who in turn redistribute some of the tax
18 payments to the counties that are served by TVA power. In fiscal year 2001 to 2002, Limestone
19 County received more than \$4.5 million from the State of Alabama as redistribution of these
20 payments from TVA (TVA 2003). Other counties in the primary labor market area received
21 substantial amounts as well. For example, Madison County received more than \$13 million and
22 Morgan County more than \$10 million. In 2002, revenues from TVA represented 5.88 percent
23 of the total budget of Limestone County (TVA 2003). The no-action alternative would result in
24 the loss of the taxes attributable to BFN as well as the loss of plant payrolls 20 years earlier
25 than if the OLS were renewed. There would also be an adverse impact on housing values and
26 the local nearby economy if BFN were to cease operations.

27
28 Both Chapter 7 of the GEIS and Supplement 1 to NUREG-0586 (NRC 2002) note that
29 socioeconomic impacts would be expected as a result of the decision to close a nuclear power
30 plant, and that the direction and extent of the overall impacts would depend on the state of the
31 economy, the net change in workforce at the plant, and the changes in local government tax
32 receipts. The socioeconomic impact of decommissioning activities themselves is expected to
33 be minimal. Appendix J of Supplement 1 to NUREG-0586 (NRC 2002) shows that the overall
34 socioeconomic impact of plant closure plus decommissioning could be greater than small.

35
36 The staff concluded that when the property tax revenue from a nuclear power plant comprises
37 less than 10 percent of the tax revenue of a local jurisdiction, the socioeconomic impacts
38 associated with the loss of the plant's tax revenue as a result of plant closure would likely be
39 minor. Because the tax payments received by Limestone County from TVA are less than
40 10 percent of total tax revenue, socioeconomic impacts to Limestone County resulting from loss
41 of this revenue would be minimal.

42

Alternatives

1 TVA employees working at BFN contribute time and money toward community involvement,
2 including school, churches, charities, and other civic activities. It is likely that with a reduced
3 presence in the community following decommissioning, community involvement efforts by TVA
4 and its employees in the region would be less.
5

6 Overall, the socioeconomic impacts associated with non-renewal and decommissioning of the
7 BFN OLS are considered MODERATE.
8

9 **8.1.8 Aesthetics**

10
11 Decommissioning would result in the eventual dismantlement of buildings and structures at the
12 BFN site resulting in a positive aesthetic impact. Noise would be generated during decom-
13 missioning operations that may be detectable offsite; however, the impact is unlikely to be of
14 large significance. Overall, the aesthetic impacts associated with decommissioning are
15 considered SMALL.
16

17 **8.1.9 Historic and Archaeological Resources**

18
19 The amount of undisturbed land needed to support the decommissioning process would be
20 relatively small. Activities conducted within operational areas are not expected to have a
21 detectable effect on important cultural resources because these areas have likely been
22 impacted during the operating life of BFN. Minimal disturbance of land outside TVA's
23 operational area for decommissioning activities is expected. Historic and archaeological
24 resources on undisturbed portions of the plant site are not expected to be adversely affected.
25 The site would likely be retained by TVA following decommissioning. Eventual sale or transfer
26 of the site, however, could result in adverse impacts to cultural resources if the land-use pattern
27 changes dramatically. Notwithstanding this possibility, the impacts of the no-action alternative
28 on historic and archaeological resources are considered SMALL.
29

30 **8.1.10 Environmental Justice**

31
32 Current operations at BFN have no disproportionate adverse impacts on the minority and low-
33 income populations of Limestone County and surrounding counties, and no environmental
34 pathways have been identified that would cause disproportionate impacts. Closure of the plant
35 would result in decreased employment opportunities and tax revenues in Limestone County and
36 surrounding counties as a result of reduced in-lieu-of-tax payments from TVA. Together, these
37 impacts could have negative and disproportionate impacts on minority or low-income popula-
38 tions. Overall, however, the environmental justice impacts under the no-action alternative are
39 considered SMALL.
40

8.2 Alternative Energy Sources

This section discusses the environmental impacts associated with alternative sources of electric power to replace the baseload^(a) electric power generating capacity of BFN assuming that the OLs are not renewed.

The TVA ER states that the combined generating capacity of BFN Units 1, 2, and 3 at full uprated power will be 3840 megawatts-electric (MW[e])^(b) (TVA 2003). This level of power production will make BFN among the largest, if not the largest, thermal generating station in the United States (DOE/EIA 2002). If the BFN OLs are not renewed, it is unlikely that this level of power (3840 MW[e]) would be produced from alternative generating sources at the BFN site or any other single alternative site. For purposes of the Section 8.2 analysis, it is assumed that replacement power production for the 3840 MW(e) will occur at more than one site and that the BFN site could be one site for siting new alternative power generating sources. Siting of additional energy sources at the BFN site would likely require TVA to acquire additional land beyond the current site boundary. Such acquisition would be complicated by the fact that there are nearby residential areas both upriver and downriver from the BFN site; however, the site could potentially be expanded to the northeast.

The order of presentation of alternative energy sources in Section 8.2 does not imply which alternative would be most likely to occur or to have the least environmental impacts. The following generation alternatives are considered in detail:

- pulverized coal (Section 8.2.1)
- coal gasification (Section 8.2.2)
- natural gas combined-cycle (Section 8.2.3)
- new nuclear (Section 8.2.4).

Consistent with the TVA ER, the principal cooling alternative considered for each alternative energy plant is closed-cycle wet cooling using mechanical draft cooling towers. For completeness, the alternative of once-through cooling is considered, although the use of once-through cooling for newly constructed power plants is limited by the Environmental Protection Agency

(a) A baseload plant normally operates to supply all or part of the minimum continuous load of a system and consequently produces electricity at an essentially constant rate. Nuclear power plants are commonly used for baseload generation; that is, these units generally run near full load continuously.
(b) One megawatt electric (MW[e]) represents one million watts of electric capacity.

Alternatives

1 (EPA) requirements specified in 40 CFR Part 125, Subpart I, for cooling water intake structures
2 for new facilities under Section 316(b) of the Clean Water Act.

3
4 The alternative of purchasing power from other sources to replace power generated at BFN is
5 discussed in Section 8.2.5. Other power generation alternatives and conservation alternatives
6 considered by the staff and found not to be reasonable replacements for the BFN generation
7 capacity are discussed in Section 8.2.6. Section 8.2.7 discusses the environmental impacts of
8 a combination of generation and conservation alternatives.

9
10 Each year, the Energy Information Administration (EIA), a component of the U.S. Department of
11 Energy (DOE), issues an Annual Energy Outlook. The 2004 report projects that combined-
12 cycle,^(a) combustion turbine, or distributed generation technology fueled by natural gas is likely
13 to account for approximately 62 percent of new electricity generating capacity added between
14 2002 and 2025 (DOE/EIA 2004). Combined-cycle technology can be used to meet baseload
15 requirements. Coal-fired plants are projected by EIA to account for approximately 33 percent of
16 new capacity during this period. Coal-fired plants are generally used to meet baseload
17 requirements. Renewable energy sources, primarily wind and biomass units, are projected by
18 EIA to account for the remaining 5 percent of capacity additions. EIA's projections are based
19 on the assumption that providers of new generating capacity will seek to minimize cost while
20 meeting applicable environmental requirements. Combined-cycle plants are projected by EIA
21 to have the lowest adjusted generation cost for new plants in 2010 (DOE/EIA 2004). Coal-fired
22 plants are projected to have the lowest adjusted generation cost for new plants in 2025
23 (DOE/EIA 2004).

24
25 EIA projects that oil-fired plants will account for no new generation capacity in the United States
26 through the year 2025, except for limited industrial combined heat and power applications,
27 because of higher fuel costs and lower efficiencies (DOE/EIA 2004).

28
29 EIA's reference case also projects that new nuclear power plants will not account for any new
30 generation capacity in the United States through the year 2025 because of the relative eco-
31 nomics of competing technologies (DOE/EIA 2004). In spite of this projection, a new nuclear
32 plant alternative for replacing power generated by BFN was considered in the TVA ER and is
33 discussed in Section 8.2.4.

34
35 If an alternative generating technology were selected to replace power generated by BFN,
36 Units 1, 2, and 3 would be decommissioned. Environmental impacts associated with
37 decommissioning are discussed in Section 8.1 and are not otherwise addressed in Section 8.2.
38

(a) In the combined-cycle unit, hot combustion gases in a combustion turbine rotate the turbine to generate electricity. Waste combustion heat from the combustion turbine is routed through a heat-recovery boiler to make steam to generate additional electricity.

1 **8.2.1 Pulverized Coal-Fired Generation**

2
3 In a pulverized coal-fired generation system, pieces of coal are crushed between balls or
4 cylindrical rollers. The raw coal is then fed into the pulverizer along with air heated to about
5 (343°C) 650°F from the boiler. As the coal is crushed by the rolling action, the hot air both dries
6 it and moves the usable fine coal powder to a burner in the boiler where it is combusted.

7
8 In its ER, TVA considered the construction of 1200-MW(e) pulverized coal power stations,
9 composed of two 600-MW(e) subcritical units (TVA 2003). At least three of these stations
10 would be needed to replace the generating capacity of BFN. Each unit would have its own
11 subcritical steam generator and condensing steam turbine generator. The subcritical steam
12 generators would be balanced draft pulverized coal furnaces with drum type, single reheat
13 boilers. Each unit would be an eight-heater cycle design with four low-pressure feedwater
14 heaters, three high-pressure feedwater heaters, and a de-aerator. Ignition fuel would be No. 2
15 fuel oil.

16
17 Major structures for the pulverized coal-fired facility would include the boiler building, turbine
18 and control building, and limestone preparation building. TVA assumed a single common
19 concrete chimney for each station, with dual flues for wet stack gas (TVA 2003).

20
21 The pulverized coal-fired stations could be located near the coal supply (i.e., at the "mine
22 mouth") or at a location with suitable cooling water that is closer to the loads to be served. For
23 a mine-mouth plant, the impacts of coal transportation would be relatively small. However, lime
24 or limestone, which is used in the scrubbing process for control of sulfur dioxide emissions,^(a)
25 would still need to be delivered to the plant site. Additionally, transmission line impacts would
26 likely be greater for a mine-mouth plant than for a plant sited closer to the areas ultimately
27 needing the power generated at the plant. For a plant not located at the mine mouth, coal
28 would be delivered by railroad or barge.

29
30 Although the license renewal term is only 20 years, the impact of operating coal-fired stations
31 for 40 years is considered (as a reasonable projection of the operating life of a coal-fired plant).

32
33 **8.2.1.1 Closed-Cycle Cooling System**

34
35 The overall impacts of constructing three 1200-MW(e) pulverized coal-fired power stations
36 using closed-cycle cooling are discussed in the following sections and summarized in Table 8-2.
37 The

(a) In a typical wet scrubber, lime (calcium hydroxide) or limestone (calcium carbonate) is injected as a slurry into the hot effluent combustion gases to remove entrained sulfur dioxide. The lime-based scrubbing solution reacts with sulfur dioxide to form calcium sulfite, which precipitates out and is removed in sludge form.

Alternatives

1 **Table 8-2. Summary of Environmental Impacts of Pulverized Coal-Fired Generation Using**
 2 **Closed-Cycle Cooling**
 3

4	Impact Category	Impact	Comment
5	Land Use	MODERATE to LARGE	Approximately 1200 ha (3000 ac) for power block; coal handling, storage, and transportation facilities; infrastructure facilities; and waste disposal. Mining the coal and disposal of waste could impact more than 30,000 ha (120 mi ²). Additional land impacts for limestone mining, electric power transmission lines, rail spurs, and cooling water intake and discharge pipelines.
6	Ecology	MODERATE to LARGE	Impact depends on location and ecology of the site, surface water body used for intake and discharge, and electric power transmission line route; potential habitat loss and fragmentation; reduced productivity and biological diversity; impacts to terrestrial ecology from cooling tower drift.
7	Water Use and	SMALL to	Impact would depend on the volume of water withdrawn and discharged, the constituents in the discharge water, and the characteristics of the surface water body. Discharges would be regulated by the State or EPA.
8	Quality	MODERATE	
9	Air Quality	MODERATE	Air emissions from three pulverized coal-fired plants sized to replace the uprated BFN capacity would be approximately: Sulfur oxides – 13,300 MT/yr (14,700 tons/yr) Nitrogen oxides – 15,900 MT/yr (17,500 tons/yr) PM ₁₀ – 3200 MT/yr (3500 tons/yr) Carbon monoxide – 4130 MT/yr (4550 tons/yr) Small amounts of mercury and other hazardous air pollutants and naturally occurring radioactive materials, mainly uranium and thorium. 40 million MT/yr (44 million tons/yr) of unregulated carbon dioxide.
10	Waste	MODERATE	For three 1200-MW(e) stations, potentially marketable material waste streams include 900,000 MT/yr (990,000 tons/yr) of fly ash, 224,400 MT/yr (247,500 tons/yr) of bottom ash, and 1,662,000 MT/yr (1,833,000 tons/yr) of flue gas desulfurization sludge (gypsum). Unusable waste streams would include 1695 MT/yr (1869 tons/yr) of raw water treatment sludges and 1062 MT/yr (1170 tons/yr) of general water treatment sludges.
11	Human Health	SMALL	Impacts are uncertain, but considered SMALL in the absence of more quantitative data.

Table 8-2. (contd)

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28

Impact Category	Impact	Comment
Socioeconomics	MODERATE	Construction impacts depend on location and how many plants are constructed at the location. Limestone County could experience loss of BFN tax base and employment. Transportation impacts would result from commuting workers and delivery of coal and lime/limestone by rail or barge. Overall, impacts are considered MODERATE.
Aesthetics	MODERATE to LARGE	Impact would depend on the site selected and the surrounding land features. Power block, exhaust stacks, cooling towers, and cooling tower plumes would be visible from nearby areas. If needed, new electric power transmission lines could have a significant aesthetic impact. Noise impact from plant operations and intermittent sources such as rail transportation of coal would be noticeable. Overall, visual and noise impacts are considered MODERATE to LARGE.
Historic and Archeological Resources	SMALL	New plant locations would necessitate cultural resource studies. Any potential impacts can likely be effectively managed.
Environmental Justice	SMALL to MODERATE	Impacts would vary depending on population distribution at the site. Impacts in Limestone County would be the same as those under the no-action alternative.

use of three 1200-MW(e) units is intended to be an approximation of the uprated BFN capacity; actual capacity of BFN is slightly larger - 3840 MW(e). It is unlikely that the three 1200-MW(e) stations would be located at a single site.

• Land Use

Approximately 400 ha (1000 ac) would be required for construction and operation of each 1200-MW(e) station. This area includes land for a barge unloading facility, the coal pile, a limestone pile, ash and scrubber solids disposal area, and plant buildings and structures, but it does not include land for an associated coal mine, transmission lines, access road, and railroad spur (TVA 2003).

In the GEIS, the staff estimated that approximately 8800 ha (34 mi²) would be affected for mining the coal and disposing of the waste to support a 1000-MW(e) coal plant during its operational life (NRC 1996). A replacement coal-fired plant to replace the 3840-MW(e) capacity of BFN would affect proportionately more land.

Alternatives

1 Construction of each station would permanently change the land use at the site, and would
2 most likely involve an irretrievable but moderate loss of forest land and/or farmland. Because
3 of the use of erosion control practices during and following construction, no significant impacts
4 to plant site soils are anticipated.

5
6 The impacts of three 1200-MW(e) pulverized coal-fired generating stations on land use is best
7 characterized as MODERATE to LARGE. The impact would definitely be greater than the
8 alternative of renewing the BFN OLS.

9 10 • Ecology

11
12 The coal-fired generation alternative would introduce construction impacts and new incremental
13 operational impacts. Even assuming siting at a previously disturbed area, the impacts would
14 alter the ecology. Impacts could include wildlife habitat loss, reduced productivity, habitat
15 fragmentation, and a local reduction in biological diversity. Use of cooling makeup water from a
16 nearby surface water body could have adverse aquatic resource impacts. If needed,
17 construction and maintenance of a transmission line and a rail spur would have ecological
18 impacts. There could be impacts to terrestrial ecology from cooling tower drift. Overall, the
19 ecological impacts would be MODERATE to LARGE.

20 21 • Water Use and Quality

22
23 Construction of each power station (including transmission lines and access roads) would affect
24 surface water hydrology, but sites could be chosen to avoid extensive site excavation, filling, or
25 grading. New construction would disturb the land surface, which may temporarily affect surface
26 water quality. Potential water-quality impacts would consist of suspended solids from disturbed
27 soils, biochemical oxygen demand, nutrient loading from disturbed vegetation, and oil and
28 grease from construction equipment. New construction activities that disturb 2 ha (5 ac) or
29 more would require a National Pollutant Discharge Elimination System (NPDES) permit for
30 storm water discharges from the site to ensure the implementation of best management
31 practices and to minimize impacts to surface waters during construction. To minimize the
32 impacts of storm water flow erosion during construction, onsite retention areas (storm water
33 detention pond) would be designed to detain storm water from the 25-year, 24-hour rainfall
34 event. Runoff detention ponds would be designed to detain runoff within the containment areas
35 to allow for settling and to reduce peak discharges. Best management practices would also be
36 required during construction to minimize water-quality impacts. Construction would cause no
37 significant consumption of surface water resources. Sanitary waste water would most likely be
38 routed to a publicly owned treatment works, if available. If a sanitary waste treatment system
39 was not available, one would be constructed (TVA 2003).

40
41 During operation, approximately 90.5 percent of the 908 L/s (14,400 gal/min) plant intake water
42 requirement for each 1200-MW(e) station would be for cooling tower makeup water flow, or

1 about 822.7 L/s (13,040 gal/min). This amount of water consumption is normally obtainable
2 from river intake or wells with a negligible impact on water availability downstream or in the
3 vicinity of the plant. Cooling water for the main condensers and miscellaneous components
4 would be recirculated through the cooling towers, with the blowdown (i.e., the fraction of
5 circulated water that is discharged to prevent the buildup of dissolved salts and minerals) and
6 other plant operational waste water streams subsequently being discharged through diffusers.
7 A biocide would be used to protect the cooling water system from biological growths. Cooling
8 tower blowdown amounting to 164 L/s (2600 gal/min) is expected to be several times larger
9 than any other waste water stream, but it would not contain any detectable amounts of priority
10 pollutants. Plant process waste water streams would include demineralizer regeneration
11 wastes (11.4 L/s [180 gal/min]), steam cycle blowdown (13 L/s [200 gal/min]), and service
12 water/pre-treatment waste and chemical drains (5.80 L/s [92 gal/min]). Plant waste water
13 outfalls would also require an NPDES permit, with established treatment standards and
14 discharge limits. To prevent leachate in storm water runoff from entering the surficial aquifer,
15 the coal storage area and the runoff basin would be lined with low-permeability materials.
16 Runoff streams from the coal pile, fly ash and bottom ash piles, and gypsum storage area
17 would be collected in the lined recycle basin for reuse (which would be sized to exceed capacity
18 requirements for the 25-year, 24-hour storm event), with no direct discharge to the surface
19 water (TVA 2003).

20
21 Overall, water use and quality impacts can be characterized as SMALL to MODERATE.

22
23 • **Air Quality**

24
25 The air-quality impacts of coal-fired generation vary considerably from those of nuclear
26 generation due to emissions of sulfur oxides (SO_x), nitrogen oxides (NO_x), particulates, carbon
27 monoxide, hazardous air pollutants such as mercury, and naturally occurring radioactive
28 materials. Estimated emissions for SO_x, NO_x, PM₁₀ (particulate matter with an aerodynamic
29 diameter less than or equal to 10 μm), and carbon monoxide are shown in Table 8-2. The
30 emissions are for new pulverized coal-fired plants meeting all applicable regulatory
31 requirements with a capacity sufficient to replace the power generated at the BFN.

32
33 A new coal-fired generating plant would need to meet the new source review requirements in
34 Title I of the Clean Air Act (42 USC 7491). The plant would need an operating permit issued
35 under Title V of the Clean Air Act. The plant would also need to comply with the new source
36 performance standards for new generating plants in 40 CFR Part 60 Subpart Da. The
37 standards establish limits for particulate matter and opacity (40 CFR 60.42a), sulfur dioxide
38 (SO₂) (40 CFR 60.43a), and NO_x (40 CFR 60.44a).

39
40 EPA has various regulatory requirements for visibility protection in 40 CFR Part 51, Subpart P,
41 including a specific requirement for review of any new major stationary source in an area
42 designated as attainment or unclassified under the Clean Air Act.

Alternatives

1 Section 169A of the Clean Air Act establishes a national goal of preventing future and
2 remedying existing impairment of visibility in mandatory Class I Federal areas when impairment
3 results from air pollution caused by human activities. In addition, EPA issued a new regional
4 haze rule in 1999 (64 FR 35714). The rule specifies that State agencies must establish goals
5 for reasonable progress towards achieving natural visibility conditions for each mandatory
6 Class I Federal area located within a state. The reasonable progress goals must provide for
7 an improvement in visibility for the most-impaired days over the period of the implementation
8 plan and ensure no degradation in visibility for the least-impaired days over the same period
9 (40 CFR 51.30(d)(1)). If a new coal-fired power plant were located close to a mandatory
10 Class I area, additional air pollution control requirements could be imposed.

11
12 In 1998, EPA issued a rule requiring 22 eastern states to revise their State implementation
13 plans to reduce NO_x emissions. Nitrogen oxide emissions contribute to violations of the
14 national ambient air-quality standard for ozone (40 CFR 50.9). The total amount of NO_x that
15 can be emitted by each of the 22 states in the year 2007 ozone season (May 1 through
16 September 30, 2007) is specified in 40 CFR 51.121(e). For Alabama, the amount is
17 156,597 MT (172,619 tons). Any new coal-fired plant sited in Alabama would be subject to
18 these limitations.

19
20 A new coal-fired power plant would be subject to the requirements in Title IV of the Clean Air
21 Act. Title IV was enacted to reduce emissions of SO₂ and NO_x, the two principal precursors of
22 acid rain, by restricting emissions of these pollutants from power plants. Title IV caps
23 aggregate annual power plant SO₂ emissions and imposes control on SO₂ emissions through a
24 system of marketable allowances. EPA issues one allowance for each ton of SO₂ that a unit is
25 allowed to emit. New units do not receive allowances but are required to have allowances to
26 cover their SO₂ emissions. Owners of new units must therefore acquire allowances from
27 owners of other power plants by purchase or reduce SO₂ emissions at other power plants they
28 own. Allowances can be banked for use in future years. Thus, a new coal-fired power plant
29 would not add to net regional SO₂ emissions, although it might do so locally. Regardless, SO₂
30 emissions would be greater for the coal alternative than the OL renewal alternative because a
31 nuclear power plant releases almost no SO₂ during normal operations.

32
33 Section 407 of the Clean Air Act establishes technology-based emission limitations for NO_x
34 emissions. The market-based allowance system used for SO₂ emissions is not used for NO_x
35 emissions. A new coal-fired power plant would be subject to the new source performance
36 standards for such plants at 40 CFR 60.44a(d)(1). This regulation, issued on
37 September 16, 1998 (63 FR 49453), limits the discharge of any gases that contain nitrogen
38 oxides (expressed as NO₂) in excess of 200 ng/J of gross energy output (1.6 lb/MWh), based
39 on a 30-day rolling average.

40
41 During the construction of a coal-fired plant, fugitive dust would be generated. Exhaust
42 emissions would come from vehicles and motorized equipment used during the construction
43 process. In addition, coal-handling equipment would introduce fugitive particulate emissions.

1 In December 2000, the EPA issued regulatory findings on emissions of hazardous air pollutants
2 from electric utility steam-generating units (65 FR 79825). The EPA determined that coal- and
3 oil-fired electric utility steam-generating units are significant emitters of hazardous air pollutants.
4 Coal-fired power plants were found by EPA to emit arsenic, beryllium, cadmium, chromium,
5 dioxins, hydrogen chloride, hydrogen fluoride, lead, manganese, and mercury. The EPA
6 concluded that mercury is the hazardous air pollutant of greatest concern. The EPA found that
7 (1) there is a link between coal utilization and mercury emissions; (2) electric utility steam-
8 generating units are the largest domestic source of mercury emissions; and (3) certain
9 segments of the U.S. population (e.g., the developing fetus and subsistence fish-eating
10 populations) are believed to be at potential risk of adverse health effects because of mercury
11 exposures resulting from consumption of contaminated fish. Accordingly, EPA added coal-
12 and oil-fired electric utility steam-generating units to the list of source categories under
13 Section 112(c) of the Clean Air Act for which emission standards for hazardous air pollutants
14 will be issued.

15
16 Coal contains uranium and thorium. Uranium concentrations are generally in the range of 1 to
17 10 parts per million. Thorium concentrations are generally about 2.5 times greater than
18 uranium concentrations (Gabbard 1993). One estimate is that a 1000-MW(e) coal-fired plant
19 had an annual release of approximately 4.7 MT (5.2 tons) of uranium and 11.6 MT (12.8 tons)
20 of thorium in 1982 (Gabbard 1993). The population dose equivalent from the uranium and
21 thorium releases and daughter products produced by the decay of these isotopes has been
22 calculated to be significantly higher than that from nuclear power plants (Gabbard 1993).

23
24 A coal-fired plant would also have unregulated carbon dioxide emissions that could contribute to
25 global warming. TVA estimates that pulverized coal-fired plants sufficient to replace the power
26 generated at BFN would emit approximately 40 million MT/yr (44 million tons/yr) of carbon
27 dioxide (TVA 2003).

28
29 The GEIS analysis did not quantify emissions from coal-fired power plants but implied that air-
30 quality impacts would be substantial. The GEIS also mentioned global warming from
31 unregulated carbon dioxide emissions and acid rain from SO_x and NO_x emissions as potential
32 impacts (NRC 1996). Adverse human health effects from coal combustion, such as cancer and
33 emphysema, have been associated with the products of coal combustion.

34
35 Overall, the air-quality impacts associated with three new 1200-MW(e) pulverized coal-fired
36 stations to replace the power generated at BFN would be MODERATE. The impacts would be
37 clearly noticeable, but would not destabilize air quality.
38

Alternatives

• Waste

Coal combustion generates waste in the form of ash, and equipment for controlling air pollution generates additional ash, spent selective catalytic reduction (SCR) catalyst, and scrubber sludge.

Pulverized coal-fired plants would produce solid material streams in significant quantities, including both potential by-products and unusable solid wastes. The potentially marketable material streams for three 1200-MW(e) units are shown in Table 8-2. All of these by-product and waste streams are classified as non-hazardous, as determined by the Resource Conservation and Recovery Act (RCRA) toxicity characteristic leaching procedure (TVA 2003). Provision would be made to store fly ash, bottom ash, and scrubber by-products onsite indefinitely. If permitted, it might be possible to inject ash into underground mine works in the future. TVA would explore the market potential and economic benefit of selling the ash and scrubber by-products to wallboard manufacturers. Water treatment sludges would be disposed of at a State-approved landfill, either onsite or offsite. Spent SCR catalyst would be regenerated or disposed of offsite. Waste impacts to groundwater and surface water could extend beyond the operating life of the plant if leachate and runoff from the waste storage area occurs. Disposal of the waste could noticeably affect land use and groundwater quality, but with appropriate management and monitoring, it would not destabilize any resources. After closure of the waste site and revegetation, the land could be available for other uses.

In May 2000, EPA issued a "Notice of Regulatory Determination on Wastes from the Combustion of Fossil Fuels" (65 FR 32214). EPA concluded that some form of national regulation is warranted to address coal combustion waste products because (1) the composition of these wastes could present danger to human health and the environment under certain conditions; (2) EPA has identified 11 documented cases of proven damages to human health and the environment by improper management of these wastes in landfills and surface impoundments; (3) present disposal practices are such that, in 1995, these wastes were being managed in 40 to 70 percent of landfills and surface impoundments without reasonable control in place, particularly in the area of groundwater monitoring; and (4) EPA identified gaps in State oversight of coal combustion wastes. Accordingly, EPA announced its intention to issue regulations for disposal of coal combustion waste under subtitle D of RCRA.

Debris would be generated during construction activities for the three 1200-MW(e) units. Such debris would be disposed of in landfills.

For all of the preceding reasons, the appropriate characterization of impacts from waste generated from burning pulverized coal is MODERATE; the impacts would be clearly noticeable but would not destabilize any important resource.

1 • **Human Health**

2
3 Coal-fired power generation introduces worker risks from coal and limestone mining, worker
4 and public risks from coal and lime/limestone transportation, worker and public risks from
5 disposal of coal combustion wastes, and public risks from inhalation of stack emissions.
6 Emission impacts can be widespread and health risks are difficult to quantify. The coal
7 alternative also introduces the risk of coal-pile fires and attendant inhalation risks.

8
9 The staff stated in the GEIS that there could be human health impacts (cancer and
10 emphysema) from inhalation of toxins and particulates from a coal-fired plant, but did not
11 identify the significance of these impacts (NRC 1996). In addition, the discharges of uranium
12 and thorium from coal-fired plants can potentially produce radiological doses in excess of those
13 arising from nuclear power plant operations (Gabbard 1993).

14
15 Regulatory agencies, including EPA and State agencies, set air emission standards and
16 requirements based on human health impacts. These agencies also impose site-specific
17 emission limits as needed to protect human health. As discussed previously, EPA has recently
18 concluded that certain segments of the U.S. population (e.g., the developing fetus and
19 subsistence fish-eating populations) are believed to be at potential risk of adverse health effects
20 because of mercury exposures from sources such as coal-fired power plants. However, in the
21 absence of more quantitative data, human health impacts from radiological doses and inhaling
22 toxins and particulates generated by burning coal at a newly constructed coal-fired plant are
23 characterized as SMALL.

24
25 • **Socioeconomics**

26
27 The projected construction period for a 1200-MW(e) pulverized coal-fired power plant would be
28 54 months, with the first unit becoming operational at 48 months (TVA 2003). The total
29 construction workforce would ramp up to the peak of 1100 workers over the first 18 months
30 and then remain there until beginning to decline at 30 months to 500 workers at 42 months
31 (TVA 2003). The total number of workers would exceed 500 for approximately 18 months. The
32 peak number of workers would noticeably affect the local workforce for most sites, but the jobs
33 would be temporary and many of the workers would commute from surrounding areas. The
34 influx of workers could noticeably affect local school systems and other social services.

35
36 For a mine-mouth plant, the mining process preparation would increase the local construction
37 employment to a base of 1500 workers for 4 years, peaking at 2500 workers (TVA 2003). A
38 construction workforce of this size would have a noticeable impact for most prospective sites.

39
40 The permanent operating staff for a 1200-MW(e) pulverized coal-fired power plant would be
41 approximately 120 workers. If the plant is sited at a mine mouth, the projected local
42 employment for the mining operation would be approximately 320 workers (TVA 2003).

Alternatives

1 The coal-fired plants would provide a new tax base for the local communities in which they are
2 sited through the in-lieu-of-tax payments made by TVA. In-lieu-of-tax payments in Limestone
3 County would likely decrease if the BFN OLs are not renewed. For all of these reasons, the
4 nontransportation socioeconomic impacts for new pulverized coal-fired plants would be
5 noticeable, but would be unlikely to destabilize the area.
6

7 For transportation related to commuting of plant operating personnel for a 1200-MW(e)
8 pulverized coal-fired power plant, the impacts are considered negligible. Transportation
9 impacts would be temporary, noticeable, but not destabilizing during plant construction.
10

11 The GEIS states that socioeconomic impacts at a rural site would be larger than at an urban
12 site, because more of the peak construction workforce would need to move to the area to work
13 (NRC 1996).
14

15 Coal and lime/limestone would likely be delivered by rail to each power plant, although barge
16 delivery is feasible for a site located on a navigable body of water. Socioeconomic impacts
17 associated with rail transportation would likely have some impact to the community. Barge
18 delivery of coal and lime/limestone would likely have minor socioeconomic impacts.
19

20 For power plants not located at the mine mouth, socioeconomic impacts would also occur at the
21 site of coal mining.
22

23 Overall, the staff concludes that socioeconomic impacts associated with constructing and
24 operating three 1200-MW(e) pulverized coal-fired plants would be MODERATE.
25

• Aesthetics

26
27
28 The coal-fired power block could be as much as 60 m (200 ft) tall and could be visible offsite
29 during daylight hours. The exhaust stack could be as much as 200 m (650 ft) high. The stack
30 would likely be highly visible in daylight hours for distances greater than 16 km (10 mi). The
31 plant and associated stack would also be visible at night because of outside lighting. The
32 Federal Aviation Administration generally requires that all structures exceeding an overall height
33 of 60 m (200 ft) above ground level have markings and/or lighting so as not to impair aviation
34 safety (FAA 2000). Visual impacts of a new coal-fired plant could be mitigated by landscaping
35 and color selection for buildings that is consistent with the environment. Visual impact at night
36 could be mitigated by reduced use of lighting, provided the lighting meets Federal Aviation
37 Administration requirements, and appropriate use of shielding. Overall, the addition of the coal-
38 fired unit and the associated exhaust stack would likely have some aesthetic impact. There
39 could be a significant aesthetic impact if construction of a new transmission line and/or rail spur
40 is needed.
41

1 Coal-fired generation would introduce mechanical sources of noise that would be audible
 2 offsite. Sources contributing to total noise produced by plant operation are classified as
 3 continuous or intermittent. Continuous sources include the mechanical equipment associated
 4 with normal plant operations. Intermittent sources include the equipment related to coal
 5 handling, solid-waste disposal, transportation related to coal and lime/limestone delivery, use of
 6 outside loudspeakers, and the commuting of plant employees. The noise impacts of a coal-
 7 fired plant would be slightly greater than those of current operations at BFN. Noise impacts
 8 associated with rail delivery of coal and lime/limestone would be most significant for residents
 9 living in the vicinity of the facility and along the rail route. Although noise from passing trains
 10 significantly raises noise levels near the rail line, the short duration of the noise reduces the
 11 impact. Nevertheless, given the frequency of train transport and the fact that many people are
 12 likely to be within hearing distance of the rail route, the impacts of noise on residents in the
 13 vicinity of the facility and the rail line would be noticeable. Noise associated with barge
 14 transportation of coal and lime/limestone would be minimal. Noise and light from the pulverized
 15 coal-fired power plants would be detectable offsite. Aesthetic impacts at the plant site would be
 16 mitigated if the plant were located in an industrial area adjacent to other power plants.

17
 18 Overall, the aesthetic impacts associated with new pulverized coal-fired power plants can be
 19 categorized as MODERATE to LARGE.

20
 21 • **Historic and Archaeological Resources**

22
 23 At any prospective site for a pulverized coal-fired power plant, a cultural resources inventory
 24 would likely be needed for any onsite property that has not been previously surveyed. Other
 25 lands, if any, that are acquired to support the plant would also likely need an inventory of field
 26 cultural resources, identification and recording of existing historic and archaeological resources,
 27 and possible mitigation of adverse effects from subsequent ground-disturbing actions related to
 28 physical expansion of the plant site.

29
 30 Before construction, studies would likely be needed to identify, evaluate, and address mitigation
 31 of the potential impacts of new plant construction on cultural resources. The studies would
 32 likely be needed for all areas of potential disturbance at the proposed plant site and along
 33 associated corridors where new construction would occur (e.g., roads, transmission lines, rail
 34 lines, or other rights-of-way). Historic and archaeological resource impacts can generally be
 35 effectively managed and as such are considered SMALL.

36
 37 • **Environmental Justice**

38
 39 Environmental justice impacts would depend upon the sites chosen for the pulverized coal-fired
 40 power plants and the nearby population distribution. Construction activities would offer new
 41 employment possibilities, but could have negative impacts on the availability and cost of
 42 housing, which could disproportionately affect minority and low-income populations. Impacts in

Alternatives

1 Limestone County would be the same as those under the no-action alternative. Overall,
2 environmental justice impacts are likely to be SMALL to MODERATE.

3 4 **8.2.1.2 Once-Through Cooling System**

5
6 The environmental impacts of constructing and operating a pulverized coal-fired power plant
7 using closed-cycle cooling with wet cooling towers are essentially the same as the impacts for a
8 coal-fired plant using a once-through system. However, there are some environmental
9 differences between the closed-cycle and once-through cooling systems. Table 8-3
10 summarizes the incremental differences.

11
12 **Table 8-3. Summary of Environmental Impacts of Pulverized Coal-Fired Generation with**
13 **Once-Through Cooling**
14

Impact Category	Change in Impacts from Closed-Cycle Cooling System
16 Land Use	10 to 12 ha (25 to 30 ac) less land required per 1200-MW(e) unit because cooling towers and associated infrastructure are not needed.
17 Ecology	Impact would depend on ecology at the site. No impact to terrestrial ecology from cooling tower drift. Increased water withdrawal with possible greater impact to aquatic ecology.
18 Surface Water Use and Quality	No discharge of cooling tower blowdown. Increased water withdrawal and more thermal load on receiving body of water.
19 Groundwater Use and Quality	No change
20 Air Quality	No change
21 Waste	No change
22 Human Health	No change
23 Socioeconomics	No change
24 Aesthetics	Less aesthetic impact because cooling towers would not be used.
25 Historic and Archaeological Resources	Less land impacted.
26 Environmental Justice	No change

27 28 **8.2.2 Coal Gasification**

29
30 Coal gasification is a method of producing relatively clean, burnable gas from almost any type
31 of coal or from petroleum coke. The basic process involves crushing the coal and partially
32 oxidizing the carbon in the coal. Partial oxidation converts the coal into a gaseous fuel
33 composed primarily of combustible hydrogen and carbon monoxide. The gas can be piped

1 directly into a gas turbine to generate electricity. The exhaust from the gas turbine is ducted
2 into a heat recovery steam generator to produce steam for a conventional steam turbine
3 generator. To make the overall process both environmentally safe and thermally efficient, a
4 coal gasification plant must integrate a number of different technologies. Major systems include
5 fuel preparation, an air separation unit, a gasifier, acid gas removal, sulfur recovery, a
6 combustion turbine generator, a heat recovery steam generator, and a steam turbine generator
7 (TVA 2003).

8
9 It its ER TVA evaluated the construction and operation of a 2720-MW(e) coal gasification plant
10 sited at TVA's unfinished Bellefonte nuclear plant site. Additional capacity beyond the
11 2720-MW(e) plant, probably sited at another location, would be needed to fully replace the
12 3840-MW(e) uprated capacity of BFN. The Bellefonte site comprises approximately 610 ha
13 (1500 ac) and is located adjacent to the Tennessee River (Guntersville Lake) in Jackson
14 County, Alabama. Construction access routes are completed at the Bellefonte site, and basic
15 support functions (i.e., electric power, potable water, sanitary waste disposal, office buildings,
16 parking lots, railways, and barge unloading facility) are in place (TVA 2003). Almost all of the
17 basic site preparation work such as grading has been completed.

18
19 The coal gasification plant would have eight 340-MW(e) modules, each consisting of one coal
20 gasification plant, one combustion turbine, and one heat recovery steam generator. The steam
21 recovered from each module would be collected and routed to the two existing low-pressure
22 steam turbine generators, four modules per steam turbine. An air separation plant would be
23 constructed for each gasifier to supply the pressurized 95 percent (by volume) oxygen required
24 for the oxygen-blown gasifiers (TVA 2003).

25
26 Delivery of coal and/or petroleum coke to the Bellefonte site would be needed. Approximately
27 21,800 MT (24,000 tons) of fuel would be shipped in daily, probably via barge (TVA 2003). If
28 coal is used as fuel, the origin would likely be southern Illinois. If petroleum coke is used as
29 fuel, the origin would likely be Texas or Louisiana, states with extensive refining industries.
30 Approximately 218 MT/day (240 tons/day) of limestone would likely be required for air pollution
31 control. Trucking would be used for limestone delivery. Fuel oil would be required for startup
32 activities, but would not be used as a backup fuel (TVA 2003).

33 34 **8.2.2.1 Closed-Cycle Cooling System**

35
36 The overall impacts of constructing a coal gasification plant at the Bellefonte site are discussed
37 in the following sections and summarized in Table 8-4. Additional impacts would occur at
38 another location as necessary to fully replace the 3840-MW(e) capacity of BFN. The impact
39 categorizations in Table 8-4 are based on 3840 MW(e) of coal gasification generating capacity.
40
41

Alternatives

1 **Table 8-4. Summary of Environmental Impacts of Coal Gasification Using Closed-**
 2 **Cycle Cooling**
 3

4	Impact Category	Impact	Comment
5	Land Use	MODERATE to LARGE	Impact at the Bellefonte site would be minor, but there would be offsite impacts for coal and limestone mining. At other sites, several hundred acres would be impacted for the power block; fuel handling, storage, and transportation facilities; infrastructure facilities; and for waste disposal. Additional land impacts for coal and limestone mining, electric power transmission lines, and cooling water intake and discharge pipelines.
6	Ecology	SMALL to LARGE	Impact at the Bellefonte site would be SMALL to MODERATE. Impacts at another site could be as much as LARGE and would depend on the location and the ecology of the site, the surface water body used for intake and discharge, and the electric power transmission line route; potential habitat loss and fragmentation; reduced productivity and biological diversity; impacts to terrestrial ecology from cooling tower drift.
7	Water Use and Quality	SMALL to MODERATE	Impact would depend on the volume of water withdrawn and discharged, the constituents in the discharge water, and the characteristics of the surface water body. Discharges at the Bellefonte site would be regulated by the Alabama Department of Environmental Management.
8	Air Quality	MODERATE	<p>Air emissions from coal gasification plants sized to fully replace BFN capacity would be approximately:</p> <p>Sulfur oxides – 10,700 MT/yr (11,800 tons/yr) Nitrogen oxides – 4881 MT/yr (5380 tons/yr) PM₁₀ – 1524 MT/yr (1680 tons/yr) Carbon monoxide – 5661 MT/yr (6240 tons/yr)</p> <p>Small amounts of mercury and other hazardous air pollutants and naturally occurring radioactive materials, mainly uranium and thorium, would be discharged along with approximately 28 million MT/yr (31 million tons/yr) of unregulated carbon dioxide.</p>
9	Waste	MODERATE	Waste streams from the 2720-MW(e) plant would be 457,000 MT/yr (504,000 tons/yr) of slag, 36,000 MT/yr (40,000 tons/yr) of fly ash, 180,000 MT/yr (200,000 tons/yr) of sulfur, 1161 MT/yr (1280 tons/yr) of raw water treatment sludge, 730 MT/yr (800 tons/yr) of general waste water treatment sludge, and 36 MT/yr (40 tons/yr) of sludges from the biotreatment of gasification process waste water.

Table 8-4. (contd)

Impact Category	Impact	Comment
Human Health	SMALL	Impacts are uncertain, but considered to be SMALL in the absence of more quantitative data.
Socioeconomics	MODERATE	Peak construction employment at the Bellefonte site would be approximately 2200 workers. The operating workforce would be approximately 530. Limestone County could experience loss of BFN tax base and employment. Transportation impacts would result from commuting workers and delivery of coal and lime/limestone. Transportation of coal to the Bellefonte site would likely be by barge with negligible socioeconomic impacts. Overall, impacts are considered MODERATE.
Aesthetics	MODERATE	Introduction of 12 new emission stacks 99.1 m (325 ft) high and two flaring stacks 60 m (200 ft) high. No new transmission lines or cooling towers at the Bellefonte site.
Historic and Archeological Resources	SMALL	The Bellefonte site has had previous surveys for historic and archeological resources. Any potential impacts can likely be effectively managed.
Environmental Justice	SMALL to MODERATE	Impacts would vary depending on population distribution and makeup water at the site. Impacts in Limestone County would be the same as those under the no-action alternative.

• Land Use

TVA assumes siting of the coal gasification facility at the existing unfinished Bellefonte nuclear plant site (TVA 2003). The existing cooling towers and circulating water system at the Bellefonte site would be used. There is an existing 39.9-km (24.8-mi) 500-kV transmission line to the Bellefonte site that is not energized (TVA 2003). Approximately 77 ha (190 ac) to the southwest of the existing cooling towers would be used to construct new facilities. Construction in this location would require the demolition or relocation of several existing buildings and underground utilities. After completion of demolition, the area would be cleared of existing vegetation, then leveled to an elevation above the 500-year floodplain (TVA 2003).

Construction would include the preparation of an area for disposal of unmarketable slag. There would be offsite land impacts to supply coal and limestone for the plant.

At another site, several hundred acres would be impacted for the power block; fuel handling, storage, and transportation facilities; infrastructure facilities; and waste disposal. There would be additional land impacts for coal and limestone mining, electric power transmission lines, and cooling water intake and discharge pipelines.

In the GEIS, the staff estimated that approximately 8800 ha (34 mi²) would be affected for mining the coal and disposing of the waste to support a 1000-MW(e) coal plant during its

Alternatives

1 operational life (NRC 1996). A replacement coal gasification plant to replace the 3840-MW(e)
2 capacity of BFN would affect proportionately more land.

3
4 Overall, land-use impacts can be characterized as MODERATE to LARGE.

5 6 • Ecology

7
8 At the Bellefonte site, there are no Federally or State-listed threatened or endangered plant
9 species (TVA 2003). Construction of barge facilities could result in some reduction in roosting
10 and foraging sites for raptors, bats, waterfowl, and wading birds such as great egrets, green
11 herons, and great blue herons. There are no caves at the Bellefonte site that support the
12 Federally endangered Indiana and gray bats, but they are known to forage along the
13 Gunterville Lake shoreline. However, areas close to the Bellefonte site have an extensive
14 network of similar wooded shoreline and shallow lagoon habitats. Therefore, the impacts
15 associated with new coal gasification facilities are expected to be minimal. Lowering the
16 existing diffuser at the site and constructing the barge terminal and mooring cells would require
17 in-stream dredging to remove approximately 115,000 m³ (150,000 yd³) of material, resulting in
18 impacts on resident aquatic communities. However, surveys have found no toxic sediments
19 and a low average density of mussels in the area, and it is expected that the dredge material
20 would be disposed on land (TVA 2003). Because water intake demand is small compared to
21 the total water mass flowing past the Bellefonte site, there is little potential for significant
22 entrainment or impingement impacts (TVA 2003). The existing Bellefonte water intake
23 structure would be used. The greatest impacts of entrainment and impingement would result
24 from water withdrawn from the upstream productive overbank, although losses to the lake fish
25 community should be minimal due to the large amounts of similar habitat near the plant and in
26 other areas of the lake (TVA 2003). There could be impacts to terrestrial ecology from cooling
27 tower drift.

28
29 At another site, the coal gasification alternative would introduce construction impacts and new
30 incremental operational impacts. Even assuming siting at a previously disturbed area, the
31 impacts would alter the ecology. Impacts could include wildlife habitat loss, reduced
32 productivity, habitat fragmentation, and a local reduction in biological diversity. Use of cooling
33 makeup water from a nearby surface water body could have adverse aquatic resource impacts.
34 If needed, construction and maintenance of a transmission line and a rail spur would have
35 ecological impacts.

36
37 Overall, the ecological impacts at the Bellefonte site are considered SMALL to MODERATE and
38 at another site SMALL to LARGE.

1 • **Water Use and Quality**

2
3 Raw water for construction and operation at the Bellefonte site would be obtained from the
4 Tennessee River. The quantities needed would be unlikely to have a significant effect on the
5 river. The highest sustained water needs during operation would be approximately 2315 L/s
6 (36,700 gal/min), or about 0.21 percent of the average river flow. Of the 2315 L/s, 1142 L/s
7 (18,100 gal/min) would be for cooling system makeup water. Both existing closed-cycle natural
8 draft cooling towers on the Bellefonte site would be used (TVA 2003).

9
10 Potable water is supplied to the Bellefonte site by the City of Hollywood, which receives its
11 water from the City of Scottsboro. The Bellefonte site is connected to the Hollywood municipal
12 sewage system treatment plant located adjacent to the south side of the site. The sewage
13 treatment plant serves the Bellefonte site and residential customers in the area, but currently it
14 does not have sufficient capacity to handle the increased demand of a large construction
15 workforce and would have to be enlarged (TVA 2003).

16
17 No significant construction-related impacts to surface water resources would be expected as a
18 result of the project. The majority of the power plant and associated facilities would be
19 constructed on land that has been previously disturbed due to construction activities related to
20 the uncompleted Bellefonte nuclear plant. Construction of new facilities and overall site
21 reclamation activities would affect surface hydrology, but extensive site excavation, filling, or
22 grading would not be needed. The primary surface water impact during construction would be
23 soil erosion, which could be kept low by the use of best management practices. To minimize
24 the impacts of storm water flow during construction, a storm water retention pond would be
25 designed to retain storm water from the 25-year, 24-hour rainfall event, in compliance with
26 regulatory requirements (TVA 2003).

27
28 The surface water resources within the areas of the proposed development at the Bellefonte
29 site are currently monitored under an NPDES permit issued by the Alabama Department of
30 Environmental Management.

31
32 Any impacts to groundwater during operation would most likely be associated with storage and
33 handling of feedstocks and the storage, handling, and disposal of wastes generated. Runoff
34 from the coal and petroleum coke storage areas would be collected in a drainage basin and
35 treated as needed (TVA 2003).

36
37 At another site, water use and quality impacts would depend on the volume of water withdrawn
38 and discharged, the constituents in the discharge water, and the characteristics of the surface
39 water body. Discharges would be regulated by the State or by EPA. Construction-related
40 impacts at another site may be significantly greater than at the Bellefonte site; however, they
41 would be mitigable and temporary.

Alternatives

1 Overall, water use and quality impacts at the Bellefonte site or another site can be
2 characterized as SMALL to MODERATE.

4 • Air Quality

5
6 Estimated air emissions for a coal gasification plant meeting all applicable regulatory require-
7 ments and sized to fully replace the 3840-MW(e) uprated capacity of BFN are shown in
8 Table 8-4 (TVA 2003). The estimated emissions are based on using petroleum coke as fuel.
9 Emissions of SO_x are higher for petroleum coke than if coal is used as the fuel.

10
11 A new coal gasification generating plant would need to meet the new source review require-
12 ments in Title I of the Clean Air Act. The plant would need an operating permit issued under
13 Title V of the Clean Air Act. The plant would also need to comply with the new source
14 performance standards for new generating plants in 40 CFR Part 60, Subpart Da. The
15 standards establish limits for particulate matter and opacity (40 CFR 60.42a),
16 SO₂ (40 CFR 60.43a), and NO_x (40 CFR 60.44a).

17
18 EPA has various regulatory requirements for visibility protection in 40 CFR Part 51 Subpart P,
19 including a specific requirement for review of any new major stationary source in an area
20 designated as attainment or unclassified under the Clean Air Act. All of Jackson County,
21 Alabama, the location of the Bellefonte site, is classified as attainment or unclassified for criteria
22 pollutants under the Clean Air Act.^(a)

23
24 Section 169A of the Clean Air Act establishes a national goal of preventing future and
25 remedying existing impairment of visibility in mandatory Class I Federal areas when impairment
26 is from air pollution resulting from human activities. In addition, EPA issued a new regional
27 haze rule in 1999 (64 FR 35714). The rule specifies that for each mandatory Class I Federal
28 area located within a state, State agencies must establish goals that provide for reasonable
29 progress towards achieving natural visibility conditions. The reasonable progress goals must
30 provide for an improvement in visibility for the most-impaired days over the period of the
31 implementation plan and ensure no degradation in visibility for the least-impaired days over the
32 same period (40 CFR 51.308(d)(1)). If a new coal gasification power plant were located close
33 to a mandatory Class I area, additional air pollution control requirements could be imposed.
34 The nearest Class I area to the Bellefonte site is the Cohutta Wilderness, which is
35 approximately 120 km (75 mi) distant (TVA 2003).

36
37 In 1998, the EPA issued a rule requiring 22 eastern states to revise their state implementation
38 plans to reduce NO_x emissions. Nitrogen oxide emissions contribute to violations of the
39 national ambient air quality standard for ozone (40 CFR 50.9). The total amount of NO_x that

(a) Existing criteria pollutants under the Clean Air Act are ozone, carbon monoxide, particulates, sulfur dioxide, lead, and nitrogen oxide. Ambient air standards for criteria pollutants are set out at 40 CFR Part 50.

1 can be emitted by each of the 22 states in the year 2007 ozone season (May 1 through
 2 September 30) is set out at 40 CFR 51.121(e). For Alabama, the amount is 172,619 tons. Any
 3 new fossil-fired plant sited in Alabama would be subject to these limitations.
 4

5 Overall, the air-quality impacts associated with new coal gasification plants to replace the power
 6 generated at BFN would be MODERATE. The impacts would be clearly noticeable, but would
 7 not destabilize air quality.
 8

9 • **Waste**

10
 11 The major solid waste and by-product streams would be generated by the gasifiers. Slag, fly
 12 ash, and sulfur account for more than 99 percent of the solids produced by coal gasification
 13 plants, with the remaining 1 percent consisting of spent catalysts and water treatment sludges.
 14 The generation rates in tons per year for a 2720-MW(e) plant are shown in Table 8-4
 15 (TVA 2003). The slag produced is an inert, glass-like material that has been found in coal
 16 gasification demonstrations to be nonleachable (TVA 2003). Based on testing at gasification
 17 demonstration plants, the slag and fly ash from gasification of eastern bituminous coal is
 18 expected to be below the RCRA threshold limits for hazardous designation (TVA 2003). Most
 19 of the sulfur in the coal is converted to hydrogen sulfide in the synthetic gas. The hydrogen
 20 sulfide is removed by acid gas removal and then converted to elemental sulfur by-product in the
 21 sulfur recovery system. TVA anticipates that the slag, fly ash, and sulfur produced at a coal
 22 gasification plant would be of sufficient quality to be marketed (TVA 2003).
 23

24 There would be three process solid waste streams composed of sludges from raw water or
 25 waste water treatment: raw water treatment sludge, general waste water treatment sludge, and
 26 sludge from the biotreatment of gasification process waste water. Generation amounts are
 27 shown in Table 8-4. These sludges are typically not hazardous and would be disposed of at
 28 nearby State-approved municipal disposal sites (TVA 2003).
 29

30 Construction-related debris would be generated during construction activities for the coal
 31 gasification units and disposed of at a landfill.
 32

33 For all the preceding reasons, the appropriate characterization of waste impacts from coal
 34 gasification is MODERATE; the impacts would be clearly noticeable but would not destabilize
 35 any important resource.
 36

37 • **Human Health**

38
 39 Power generation from coal introduces worker risks from coal and limestone mining, worker
 40 and public risks from coal and lime/limestone transportation, worker and public risks from
 41 disposal of coal combustion wastes, and public risks from inhalation of stack emissions.
 42 Emission impacts can be widespread and health risks difficult to quantify. The coal gasification
 43 alternative also introduces the risk of coal-pile fires and attendant inhalation risks.

Alternatives

1 The staff stated in the GEIS that there could be human health impacts (cancer and
2 emphysema) from inhalation of toxins and particulates from a coal-fired plant, but did not
3 identify the significance of these impacts (NRC 1996). In addition, the discharges of uranium
4 and thorium from coal-fired plants can potentially produce radiological doses in excess of those
5 arising from nuclear power plant operations (Gabbard 1993).
6

7 Regulatory agencies, including EPA and State agencies, set air emission standards and
8 requirements based on human health impacts. These agencies also impose site-specific
9 emission limits as needed to protect human health. As discussed previously, EPA has recently
10 concluded that certain segments of the U.S. population (e.g., the developing fetus and
11 subsistence fish-eating populations) are believed to be at potential risk of adverse health effects
12 due to mercury exposures from sources such as coal-fired power plants. However, in the
13 absence of more quantitative data, human health impacts from radiological doses and inhaling
14 toxins, and particulates generated by burning coal at a newly constructed coal gasification plant
15 are characterized as SMALL.
16

• Socioeconomics

17
18
19 Peak employment during construction at the Bellefonte site would be approximately 2200
20 workers (TVA 2003). The peak number of workers would noticeably affect the local workforce
21 near the Bellefonte site, but the jobs would be temporary and many of the workers would
22 commute from surrounding areas. The influx of workers could noticeably affect local school
23 systems and other social services. The permanent operating staff would be approximately
24 530 workers (TVA 2003).
25

26 The coal gasification plants would provide a new tax base for Jackson County and any other
27 local communities in which they were sited through the in-lieu-of tax payments made by TVA.
28 In-lieu-of-tax payments in Limestone County would likely decrease if the BFN OLS were not
29 renewed. For all these reasons, the nontransportation socioeconomic impacts for new coal
30 gasification plants would be noticeable, but would be unlikely to destabilize the area.
31

32 For transportation related to commuting of plant operating personnel, the impacts are
33 considered negligible. Transportation impacts would be noticeable, temporary, but not
34 destabilizing during plant construction.
35

36 The GEIS states that socioeconomic impacts at a rural site would be larger than at an urban
37 site, because more of the peak construction workforce would need to move to the area to work
38 (NRC 1996).
39

40 Coal and lime/limestone would likely be delivered by barge to the Bellefonte site (TVA 2003).
41 Approximately 17 barges of coal per day would be delivered (TVA 2003). Some recreational
42 impact would result from increased barge traffic. Nevertheless, barge delivery of coal and
43 lime/limestone would likely have minor socioeconomic impacts.
44

1 For coal gasification power plants not located at the mine mouth, socioeconomic impacts would
 2 also occur at the site of the coal mine.

3
 4 Overall, the staff concludes that socioeconomic impacts associated with constructing and
 5 operating new coal gasification plants would be MODERATE.

6
 7 • **Aesthetics**

8
 9 The 2720-MW(e) coal gasification plant would have 12 stacks for emissions that would be
 10 approximately 99.1 m (325 ft) high (TVA 2003). In addition, the completed plant would have
 11 two flaring stacks to burn waste gas approximately 60 m (200 ft) in height. Flaring operations
 12 would generally be visible within a 5-km (3-mi) radius, particularly at night. The stacks would
 13 not rise to the height of the existing cooling towers at the Bellefonte site, but would be visible up
 14 to 10 km (6 mi) away. Vapor fog from the cooling towers and stack emissions could be visible
 15 from distances of 16 km (10 mi) or more. There is an existing 40-km (24.8-mi) 500-kV
 16 transmission line to the Bellefonte site that is not energized (TVA 2003). Consequently, there
 17 would not be a new incremental aesthetic impact associated with transmission lines. Overall,
 18 construction and operation of a new coal gasification plant at the Bellefonte site would likely
 19 have a MODERATE aesthetic impact.

20
 21 • **Historic and Archaeological Resources**

22
 23 A 1972 archaeological survey of the Bellefonte site identified five historic sites, none of which
 24 are within proposed construction zones for a coal gasification plant (TVA 2003). The original
 25 town of Bellefonte was located just offsite and determined in 1974 to be eligible for placement
 26 on the National Register of Historic Places. Prior to the initiation of construction of the
 27 uncompleted Bellefonte nuclear plant, the Alabama State Historic Preservation Office
 28 determined that no mitigation would be required. Since that time all structures have been
 29 removed by landowners (TVA 2003).

30
 31 At an alternative site, a cultural resources inventory would likely be needed for any onsite
 32 property that has not been previously surveyed. Other lands, if any, that are acquired to
 33 support the plant would also likely need an inventory of field cultural resources, identification
 34 and recording of existing historic and archaeological resources, and possible mitigation of
 35 adverse effects from subsequent ground-disturbing actions related to physical expansion of the
 36 plant site.

37
 38 Before construction at an alternative site, studies would likely be needed to identify, evaluate,
 39 and address mitigation of the potential impacts of new plant construction on cultural resources.
 40 The studies would likely be needed for all areas of potential disturbance at the proposed plant
 41 site and along associated corridors where new construction would occur (e.g., roads,
 42 transmission line, rail lines, or other rights-of-way). Historic and archaeological resource
 43 impacts can generally be effectively managed and would likely be SMALL.

Alternatives

• **Environmental Justice**

Environmental justice impacts would depend upon the population distribution around the Bellefonte site or other alternative sites. Construction activities would offer new employment possibilities, but could have negative impacts on the availability and cost of housing, which could disproportionately affect minority and low-income populations. Impacts in Limestone County would be the same as those under the no-action alternative assuming no construction of a coal gasification plant at the BFN site. Overall, environmental justice impacts are likely to be SMALL to MODERATE.

8.2.2.2 Once-Through Cooling System

The environmental impacts of constructing and operating a coal gasification plant using closed-cycle cooling with wet cooling towers are essentially the same impacts for a coal gasification plant using a once-through cooling system. However, there are some environmental differences between the closed-cycle and once-through cooling systems. Table 8-5 summarizes the incremental differences.

Table 8-5. Summary of Environmental Impacts of a Coal Gasification Plant with Once-Through Cooling

Impact Category	Change in Impacts from Closed-Cycle Cooling System
Land Use	Less land required because cooling towers and associated infrastructure are not needed.
Ecology	Impact would depend on ecology at the site. No impact to terrestrial ecology from cooling tower drift. Increased water withdrawal with possible greater impact to aquatic ecology.
Surface Water Use and Quality	No discharge of cooling tower blowdown. Increased water withdrawal and more thermal load on receiving body of water.
Groundwater Use and Quality	No change
Air Quality	No change
Waste	No change
Human Health	No Change
Socioeconomics	No change
Aesthetics	Less aesthetic impact because cooling towers would not be used.
Historic and Archaeological Resources	Less land impacted.
Environmental Justice	No change

1 **8.2.3 Natural Gas Combined-Cycle Generation**

2
 3 The TVA ER considers the construction of 510-MW(e) natural gas combined-cycle power plants
 4 using mechanical draft cooling towers. Eight such plants would be needed to fully replace the
 5 3840-MW(e) uprated capacity of BFN. It is likely that multiple locations would be needed for
 6 this number of plants. At each location it is likely that a new transmission line would need to be
 7 constructed to connect to existing lines. In addition, construction or upgrade of a natural gas
 8 pipeline from the plant location to a supply point where a firm supply of gas would be available
 9 would be needed.

10
 11 Although the OL renewal term is only 20 years, the impact of operating the natural gas
 12 combined-cycle alternative for 40 years is considered (as a reasonable projection of the
 13 operating life of a natural gas combined-cycle plant).

14
 15 **8.2.3.1 Closed-Cycle Cooling System**

16
 17 The overall impacts associated with the construction and operation of natural gas combined-
 18 cycle plants of sufficient capacity to replace the uprated BFN are summarized in Table 8-6 and
 19 are discussed in the following sections.

20
 21 **Table 8-6. Summary of Environmental Impacts of Natural Gas Combined-Cycle Generation**
 22 **Using Closed-Cycle Cooling**

23

Impact Category	Impact	Comment
Land Use	MODERATE to LARGE	Approximately 640 ha (1600 ac) would be needed to fully replace BFN capacity. Additional site-specific impacts for natural gas pipeline, electric power transmission lines, rail spurs, and cooling water intake and discharge pipelines.
Ecology	MODERATE	Impact depends on location and ecology of the site, surface water body used for intake and discharge, and electric power transmission line and natural gas pipeline routes; potential habitat loss and fragmentation; reduced productivity and biological diversity; impacts to terrestrial ecology from cooling tower drift.
Water Use and Quality	SMALL to MODERATE	Impact would depend on the volume of water withdrawn and discharged, the constituents in the discharge water, and the characteristics of the surface water body. Discharges would be regulated by the State or EPA.

Alternatives

Table 8-6. (contd)

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

Impact Category	Impact	Comment
Air Quality	MODERATE	Air emissions to fully replace BFN capacity would be approximately: Sulfur oxides – 67 MT/yr (74 tons/yr) Nitrogen oxides – 1295 MT/yr (1428 tons/yr) PM ₁₀ – 1188 MT/yr (1310 tons/yr) Carbon monoxide – 4941 MT/yr (5446 tons/yr) Small amounts of hazardous air pollutants would be discharged along with 17.1 million MT/yr (18.9 million tons/yr) of unregulated carbon dioxide.
Waste	SMALL	The only significant waste would be spent SCR catalyst used for control of nitrogen oxide emissions.
Human Health	SMALL	Impacts are uncertain, but considered SMALL in the absence of more quantitative data.
Socioeconomics	MODERATE	Construction impacts depend on location and how many plants are constructed at the location. Limestone County could experience loss of BFN tax base and employment. Impacts during operation of the natural gas plants would likely be SMALL. Transportation impacts would result from commuting workers.
Aesthetics	MODERATE to LARGE	Impact would depend on the site selected and the surrounding land features. Power block, exhaust stacks, cooling towers, and cooling tower plumes would be visible from nearby areas. If needed, new electric power transmission lines could have a significant aesthetic impact. Noise impact from plant operations and intermittent sources would be noticeable.
Historic and Archeological Resources	SMALL	New plant locations would necessitate cultural resource studies. Any potential impacts can likely be effectively managed.
Environmental Justice	SMALL to MODERATE	Impacts would vary depending on population distribution at the site. Impacts in Limestone County would be the same as those under the no-action alternative.

• Land Use

Each 510-MW(e) natural gas combined-cycle plant would require approximately 80 ha (200 ac) (TVA 2003). Additional land would be impacted for construction of a transmission line and natural gas pipeline to serve the plant. For any new natural gas combined-cycle plant, additional land would be required for natural gas wells and collection stations. In the GEIS, the staff estimated that approximately 1500 ha (3600 ac) would be needed for a 1000-MW(e) plant (NRC 1996). Proportionately more land would be needed for a natural gas combined-cycle plant replacing the 3840-MW(e) uprated generating capacity of BFN.

1
2 Overall, land-use impacts for construction of eight 510-MW(e) natural gas combined-cycle
3 plants are considered MODERATE to LARGE.

4
5 • **Ecology**

6
7 Ecological impacts would depend on the nature of the land converted for the plant and any new
8 transmission lines or gas pipelines. Construction of a transmission line and a gas pipeline to
9 serve the plant would be expected to have temporary ecological impacts. Ecological impacts to
10 a plant site and utility easements could include impacts on threatened or endangered species,
11 wildlife habitat loss and reduced productivity, habitat fragmentation, and a local reduction in
12 biological diversity. Intake and discharge of makeup water for the cooling system could
13 adversely affect aquatic resources. There could be impacts to terrestrial ecology from cooling
14 tower drift. Overall, ecological impacts are considered MODERATE.

15
16 • **Water Use and Quality**

17
18 Construction would be expected to increase erosion and storm water runoff of suspended solids
19 above existing levels, but this would be temporary and mitigable by the use of best
20 management practices. Completion of a retention pond for the treatment of storm water runoff
21 early in the construction phase would significantly reduce potential increased solids loading to
22 local surface drainage waterways. Application of best management practices to control erosion
23 during construction should mitigate construction impacts of transmission lines and pipelines
24 (natural gas supply, potable water supply, process water supply, and waste water discharge).
25 Impacts of constructing new intake and discharge structures on nearby waterways and/or
26 reservoirs would be minimized by construction techniques to minimize disturbance of sediments
27 and by the use of mitigation measures such as coffer dams, turbidity curtains, and selection of
28 a construction time window (TVA 2003).

29
30 Waste water discharges would be regulated by the State or by EPA. Approximately 90 percent
31 of the waste water discharge flow would be cooling tower blowdown. Other sources of waste
32 water include steam cycle blowdown, water from inlet fogging, demineralizer rinse water, and
33 miscellaneous low-volume waste water. This water would be treated onsite as necessary to
34 meet regulatory requirements before being discharged to local waters (TVA 2003).

35
36 Storm water runoff during plant operation would be drained to a retention pond to allow
37 sediments to settle out prior to discharge to local waterways. Rainwater that falls in secondary
38 containment around oil-containing equipment would drain to an oil/water separator where the oil
39 would be removed for disposal and the water would subsequently drain to the process water
40 pond. Excavation and grading associated with construction of the plant or any of the ancillary
41 features, such as the transmission lines, backup power, process and potable water pipelines,
42 waste water discharge pipelines, and natural gas pipelines, are not expected to cause adverse
43 effects to groundwater. Excavations that penetrate the water table may require temporary
44 construction dewatering. Any groundwater drawdown impacts associated with construction
45 dewatering would be temporary. The long-term impact of these activities should be negligible

Alternatives

1 because of the limited depth and relatively small area of disturbance. Structural damage to
2 aquifer areas resulting from pipeline construction is not anticipated because aquifers are not
3 generally located within excavation depth (TVA 2003).
4

5 The impact on the surface water would depend on the discharge volume and the characteristics
6 of the receiving body of water. Intake from and discharge to any surface body of water would
7 be regulated by the State.
8

9 Water-quality impacts from sedimentation during construction of a natural-gas-fired plant were
10 characterized in the GEIS as small (NRC 1996). NRC staff also noted in the GEIS that
11 operational water-quality impacts would be similar to, or less than, those from other generating
12 technologies.
13

14 Overall, water use and quality impacts are considered **SMALL to MODERATE**.
15

• Air Quality

16
17
18 Natural gas is a relatively clean-burning fuel. The natural gas combined-cycle alternative would
19 release similar types of emissions, but in lesser quantities than the coal-fired alternative.
20

21 A new natural gas combined-cycle generating plant would likely require a permit issued under
22 the new source review procedures in Title I, Part C, of the Clean Air Act and an operating
23 permit issued under Title V. A new natural gas combined-cycle power plant would also be
24 subject to the new source performance standards for such units at 40 CFR Part 60, Subparts
25 Da and GG. These regulations establish emission limits for particulates, opacity, SO₂, and NO_x.
26

27 The EPA has various regulatory requirements for visibility protection in 40 CFR Part 51,
28 Subpart P, including a specific requirement for review of any new major stationary source in an
29 area designated as attainment or unclassified under the Clean Air Act.
30

31 Section 169A of the Clean Air Act establishes a national goal of preventing future impairment
32 and remedying existing impairment of visibility in mandatory Class I Federal areas when the
33 impairment results from air pollution caused by human activities. In addition, EPA issued a new
34 regional haze rule in 1999 (64 FR 35714). The rule specifies that for each mandatory Class I
35 Federal area located within a state, the State must establish goals that provide for reasonable
36 progress towards achieving natural visibility conditions. The reasonable progress goals must
37 provide for an improvement in visibility for the most-impaired days over the period of the
38 implementation plan and ensure no degradation in visibility for the least-impaired days over the
39 same period (40 CFR 51.308(d)(1)). If a new natural gas combined-cycle power plant were
40 located close to a mandatory Class I area, additional air pollution control requirements could be
41 imposed.
42

43 In 1998, EPA issued a rule requiring 22 eastern states, including Alabama, to revise their State
44 implementation plans to reduce nitrogen oxide emissions. NO_x emissions contribute to
45 violations of the national ambient air-quality standard for ozone (40 CFR 50.9). The total

1 amount of NO_x that can be emitted by each of the 22 states in the year 2007 ozone season
 2 (May 1 through September 30) is set out at 40 CFR 51.121(e). For Alabama, the amount is
 3 156,597 MT (172,619 tons). Any new natural gas combined-cycle plant sited in Alabama would
 4 be subject to these limitations.

5
 6 The estimated annual emissions for natural gas combined-cycle plants sized to replace the
 7 power generated by BFN are shown in Table 8-6 (TVA 2003).
 8

9 The combustion turbine portion of the combined-cycle plant would be subject to EPA's National
 10 Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines at
 11 40 CFR Part 63, Subpart YYYY, if the site is a major source of hazardous air pollutants. Major
 12 sources have the potential to emit 9.1 MT (10 tons) per year or more of any single hazardous
 13 air pollutant or 22.7 MT (25 tons) or more per year of any combination of hazardous air
 14 pollutants (40 CFR 63.6085(b)).
 15

16 Construction activities would result in temporary fugitive dust. Exhaust emissions would also
 17 come from vehicles and motorized equipment used during the construction process.
 18

19 Overall, the air-quality impacts of new natural gas combined-cycle plants sized to replace the
 20 BFN capacity are estimated to be MODERATE.
 21

22 • **Waste**

23
 24 In the GEIS the staff concluded that waste generation from natural-gas-fired technology would
 25 be minimal (NRC 1996). The only significant solid waste generated at a new natural gas
 26 combined-cycle plant would be spent SCR catalyst. The SCR catalyst is used to control NO_x
 27 emissions. The spent catalyst would be regenerated or disposed of offsite. Other than spent
 28 SCR catalyst, waste generation at an operating natural gas combined-cycle plant would be
 29 largely limited to typical office wastes; impacts would be so minor that they would not noticeably
 30 alter any important resource attribute. Construction-related debris would be generated during
 31 construction activities.
 32

33 Overall, the solid waste impacts associated with natural gas combined-cycle plants sized to
 34 replace the BFN capacity are expected to be SMALL.
 35

36 • **Human Health**

37
 38 Potential accidents related to plant operations include the possible rupture of natural gas
 39 pipelines both onsite and offsite, and the possible release of ammonia (TVA 2003). Ammonia
 40 is used in the SCR process for control of NO_x emissions. Both events are considered very low
 41 probability.
 42

43 In the GEIS, the staff identified cancer and emphysema as potential health risks from gas-fired
 44 plants (NRC 1996). The risk may be attributable to NO_x emissions that contribute to ozone
 45 formation, which in turn contribute to health risks. NO_x emissions from any plant would be

Alternatives

1 regulated by the State or EPA. For a plant sited in Alabama, NO_x emissions would be regulated
2 by the Alabama Department of Environmental Management. Human health effects are not
3 expected to be detectable or sufficiently minor that they would neither destabilize nor noticeably
4 alter any important attribute of the resource. Overall, the impacts on human health of newly
5 constructed natural gas combined-cycle plants are considered SMALL.

• Socioeconomics

6
7
8
9 Construction of a 510-MW(e) natural gas combined-cycle plant would take approximately
10 22 months (TVA 2003). Peak employment would be approximately 420 workers. Employment
11 would exceed 200 workers for approximately 6 months (TVA 2003). During construction, the
12 communities immediately surrounding each plant site would experience demands on housing
13 and public services that could have noticeable impacts. These impacts would be tempered by
14 construction workers commuting to the sites from more distant cities. After construction,
15 the communities would be impacted by the loss of jobs. The operating workforce at each
16 510-MW(e) plant would be approximately 40 persons (TVA 2003). The BFN workforce would
17 decline through a decommissioning period to a minimal maintenance size. The new natural gas
18 combined-cycle plants would provide a new tax base through TVA's in-lieu-of-tax payments, at
19 their respective locations.

20
21 Jobs related to pipeline construction and to transmission/distribution line upgrades would not be
22 centralized at one location for any significant period of time and, therefore, would have no
23 important impact on the local economy or on community and government services.

24
25 In the GEIS, the staff concluded that socioeconomic impacts from constructing a natural-gas-
26 fired plant would not be very noticeable and that the small operational workforce would have the
27 lowest socioeconomic impacts of any nonrenewable technology (NRC 1996). Compared to the
28 coal-fired and nuclear alternatives, the smaller size of the construction workforce, the shorter
29 construction time frame, and the smaller size of the operations workforce would mitigate
30 socioeconomic impacts.

31
32 Transportation impacts related to commuting of plant operating personnel, the impacts would
33 depend on the population density and transportation infrastructure in the vicinity of the site but
34 are likely to be negligible. Impacts related to the commuting of plant construction personnel
35 would be noticeable, temporary, but not destabilizing.

36
37 Overall, socioeconomic impacts resulting from construction and operation of natural gas
38 combined-cycle plants can be characterized as MODERATE.

• Aesthetics

39
40
41
42 The natural gas combined-cycle plants would alter the visual landscape character at each
43 location. The tallest structures would be the 46-m (150-ft)-high auxiliary boiler and two heat
44 recovery steam generator stacks, as well as the 30-m (100-ft)-high steam turbine building.
45 (TVA 2003). Some portion of these structures would likely be visible for 2 km (1 mi) or more.

1 Cooling tower plumes would also be visible. There would be more lighting visible across the
2 night landscape, and sky brightness would increase somewhat. Noise from the plant would be
3 detectable offsite.

4
5 If a new electric power transmission line is needed, the aesthetic impact could be significant.
6 The gas pipeline compressors also would be visible. Aesthetic impacts would be mitigated if
7 the plant were located in an industrial area adjacent to other power plants. Overall, the
8 aesthetic impacts associated with replacement natural gas combined-cycle plants are
9 categorized as MODERATE to LARGE, with site-specific factors determining the final
10 categorization.

11 • Historic and Archaeological Resources

12
13
14 A cultural resource inventory would likely be needed for any onsite property that has not been
15 previously surveyed. Other lands, if any, that are acquired to support the plant would also likely
16 need an inventory of field cultural resources, identification and recording of existing historic and
17 archaeological resources, and possible mitigation of adverse effects from subsequent
18 ground-disturbing actions related to physical expansion of the plant site.

19
20 Before construction, studies would likely be needed to identify, evaluate, and address mitigation
21 of the potential impacts of new plant construction on cultural resources. The studies would
22 likely be needed for all areas of potential disturbance at the proposed plant site and along
23 associated corridors where new construction would occur (e.g., roads, transmission lines,
24 pipelines, or other rights-of-way). Impacts to cultural resources can be effectively managed
25 under current laws and regulations and kept SMALL.

26 • Environmental Justice

27
28
29 Environmental justice impacts would depend upon the sites chosen for the natural gas
30 combined-cycle power plants and the nearby population distribution. Construction activities
31 would offer new employment possibilities, but could have negative impacts on the availability
32 and cost of housing, which could disproportionately affect minority and low-income populations.
33 Impacts in Limestone County would be the same as those under the no-action alternative
34 assuming no construction of natural gas combined-cycle plants at the BFN site. Overall,
35 environmental justice impacts are likely to be SMALL to MODERATE.

36 37 8.2.3.2 Once-Through Cooling System

38
39 The environmental impacts of constructing and operating a natural gas combined-cycle
40 generating plant using once-through cooling are essentially the same as the impacts for a plant
41 using closed-cycle cooling with wet cooling towers. However, there are some environmental
42 differences between the closed-cycle and once-through cooling systems. Table 8-7
43 summarizes the incremental differences.
44

Alternatives .

1 **Table 8-7. Summary of Environmental Impacts of a Natural Gas Combined-Cycle Plant with**
2 **Once-Through Cooling**
3

Impact Category	Change in Impacts from Closed-Cycle Cooling System
4 Land Use	Less land required because cooling towers and associated infrastructure are not needed.
5 Ecology	Impact would depend on ecology at the site. No impact to terrestrial ecology from cooling tower drift. Increased water withdrawal with possible greater impact to aquatic ecology.
6 Surface Water Use and Quality	No discharge of cooling tower blowdown. Increased water withdrawal and more thermal load on receiving body of water.
7 Groundwater Use and Quality	No change
8 Air Quality	No change
9 Waste	No change
10 Human Health	No change
11 Socioeconomics	No change
12 Aesthetics	Less aesthetic impact because cooling towers would not be used.
13 Historic and Archaeological Resources	Less land impacted.
14 Environmental Justice	No change

15
16 **8.2.4 Nuclear Power Generation**
17

18 The TVA ER considers the feasibility of constructing and operating two Advanced Boiling Water
19 Reactors (ABWR) at the unfinished Bellefonte nuclear plant site (TVA 2003). The ABWR
20 design is a light-water reactor that has been certified by the NRC (10 CFR Part 52,
21 Appendix A).
22

23 Although construction of the original Bellefonte nuclear units has been halted, TVA still retains
24 construction permits issued by NRC. Construction access routes are completed at the site, and
25 basic support functions (electric power, potable water, sanitary waste disposal, office buildings,
26 parking lots, railways, and barge unloading facility) are in place to support resumption of con-
27 struction. Almost all the basic site preparation work, such as grading, has been completed,
28 including where the ABWR units would be constructed (TVA 2003). DOE is cooperating with an
29 industry team led by TVA to conduct a detailed study of the potential construction of a two-unit
30 ABWR nuclear plant at the Bellefonte site (DOE 2004a).
31

32 Construction of two ABWR units at the Bellefonte site would likely make use of the existing site
33 intake water pumping station, natural draft cooling towers, discharge water diffusers, and
34 electrical transmission lines and switchyards, each with varying degrees of modification
35
36
37

1 (TVA 2003). Some existing service facilities such as fire protection, temporary construction
 2 power, auxiliary boilers, office buildings and parking lots, environmental monitoring, outside
 3 lighting, diesel fuel storage tanks, telecommunications, and potable water and sanitary waste
 4 supply lines would be used wherever possible. Almost none of the existing unfinished nuclear
 5 units and their contiguous support systems would be used (TVA 2003). To supplement the
 6 existing natural draft cooling towers, two additional mechanical draft cooling towers may be built
 7 on land immediately adjacent to and just south of the existing cooling towers, between the
 8 existing cooling towers and the proposed ABWR plant (TVA 2003). A 3.6-ha (9-ac) cooling
 9 spray pond may also be constructed south of the ABWR plant to serve as the emergency core
 10 cooling ultimate heat sink for the two units. All this land has previously been cleared for other
 11 uses (TVA 2003).

12
 13 The base or lowest expected power output is 1336 MW(e) per unit during summer, which would
 14 likely increase to 1380 MW(e) during winter months as the condenser inlet temperature (and
 15 consequently the condenser backpressure) is reduced (TVA 2003). Although some uprating of
 16 the ABWR units may be possible, an additional ABWR unit, probably constructed at another
 17 site, would likely be needed to fully replace the uprated 3840-MW(e) capacity of BFN.

18
 19 NRC has summarized environmental data associated with the uranium fuel cycle in Table S-3
 20 of 10 CFR 51.51. The impacts shown in Table S-3 are representative of the impacts that would
 21 be associated with a replacement nuclear power plant. The impacts shown in Table S-3 are for
 22 a 1000-MW(e) reactor and would need to be adjusted to reflect replacement of the uprated
 23 3840-MW(e) capacity of BFN. The environmental impacts associated with transporting fuel and
 24 waste to and from a light-water cooled nuclear power reactor are summarized in Table S-4 of
 25 10 CFR 51.52. The summary of NRC's findings on NEPA issues for license renewal of nuclear
 26 power plants in Table B-1 of 10 CFR Part 51 Subpart A, Appendix B, is also relevant, although
 27 not directly applicable, for consideration of environmental impacts associated with the operation
 28 of a replacement nuclear power plant. Additional environmental impact information for a
 29 replacement nuclear power plant using closed-cycle cooling is presented in Section 8.2.4.1 and
 30 using once-through cooling in Section 8.2.4.2.

31
 32 **8.2.4.1 Closed-Cycle Cooling System**

33
 34 The overall impacts associated with the construction and operation of two ABWR generating
 35 units at the Bellefonte site are discussed in the following sections. The impacts are
 36 summarized in Table 8-8. Additional impacts would occur, probably at another site, to fully
 37 replace the 3840-MW(e) capacity at BFN. The impact categorizations for Table 8-8 are based
 38 on 3840 MW(e) of new ABWR generating capacity.

Alternatives

1 **Table 8-8. Summary of Environmental Impacts of New ABWR Units Using Closed-**
 2 **Cycle Cooling**
 3

	Impact Category	Impact	Comment
5	Land Use	SMALL to LARGE	Most of the construction would take place on already disturbed areas of the Bellefonte site. Construction of an ABWR at another site would require approximately 200 ha (500 ac) for the plant and possibly additional land if a new transmission line and/or rail spur is needed. Additional land-use impacts would occur for uranium mining.
6	Ecology	SMALL to LARGE	Impact at the Bellefonte site would be SMALL to MODERATE. Impacts at another site could be LARGE and would depend on location and ecology of the site, surface water body used for intake and discharge, and electric power transmission line route; potential habitat loss and fragmentation; reduced productivity and biological diversity; and impacts to terrestrial ecology from cooling tower drift.
7	Water Use and Quality	SMALL to MODERATE	Impact would depend on the volume of water withdrawn and discharged, the constituents in the discharge water, and the characteristics of the surface water body. Discharges at the Bellefonte site would be regulated by the State of Alabama.
9	Air Quality	SMALL	<p>Air emissions from ABWR plants sized to fully replace BFN capacity would be approximately:</p> <p>Sulfur oxides – 12.7 MT/yr (14 tons/yr) Nitrogen oxides – 12.7 MT/yr (14 tons/yr) PM₁₀ – 0.62 MT/yr (0.68 tons/yr) Carbon monoxide – 3.4 MT/yr (3.7 tons/yr)</p> <p>Approximately 4350 MT/yr (4800 tons/yr) of unregulated carbon dioxide would be discharged.</p>
10	Waste	SMALL	Radioactive waste generated at a ABWR would be less than a conventional boiling water reactor (BWR). Debris would be generated and removed during the construction process.
11	Human Health	SMALL	Impacts are uncertain, but considered SMALL in the absence of more quantitative data. ABWR units are expected to have a lower human health impact than existing BWR units.
12	Socioeconomics	MODERATE to LARGE	Peak construction employment at the Bellefonte site would be approximately 3100 workers. The operating workforce would be approximately 900. Limestone County could experience loss of BFN tax base and employment. Impacts at an alternate rural site could be LARGE.
13	Aesthetics	MODERATE to LARGE	At the Bellefonte site, a new off-gas stack would be needed. Cooling tower plumes would be visible for 16 km (10 mi) or more. At an alternative site, a new transmission line may be needed, which could have a LARGE impact.

Table 8-8. (contd)

Impact Category	Impact	Comment
Historic and Archeological Resources	SMALL	The Bellefonte site has had previous surveys for historic and archeological resources. Any potential impacts can likely be effectively managed.
Environmental Justice	SMALL to MODERATE	Impacts would vary depending on population distribution and makeup at the site. Impacts in Limestone County would be the same as those under the no-action alternative.

• Land Use

Twin ABWR units would be constructed adjacent to and directly south of the existing cooling towers (TVA 2003). A construction lay-down space is planned for the area bordered by the existing cooling towers, the existing 500-kV transmission line, and the ABWR plant. Almost all the ABWR construction activities would take place on land that has already been disturbed for the original Bellefonte construction. There are no buried structures that cannot be removed or transferred (TVA 2003).

Including wind effect, the maximum flood level of the Bellefonte site is 191.3 m (627.7 ft) above mean sea level, which is higher than the 189-m (620-ft) average grade for the planned construction area. Keeping the finished grade above the maximum flood level would require adding about 3 m (10 ft) of fill soil to the construction area, increasing its elevation to 192 m (630 ft) (TVA 2003). The grading soil would most likely be taken from hills to the east or southwest of the construction area.

Compared to a fossil-fueled power plant, which would involve either long fuel pipelines or large fuel and combustion product storage areas, the impacts on land use and soils are minimal for completing a relatively compact nuclear plant on the previously disturbed Bellefonte site. Land-use impacts are expected to be SMALL at the Bellefonte site, and MODERATE to LARGE if an additional site is needed to fully replace the power generated by BFN. At another site, approximately 200 ha (500 ac) would be needed for the plant and possibly additional land needed for construction of a transmission line and/or rail spur. Additional land-use impacts would occur for uranium mining.

• Ecology

At the Bellefonte site there are no Federally or State-listed threatened or endangered plant species (TVA 2003). There are no caves at the site that support the Federally endangered Indiana and gray bats, but they are known to forage along the Gunterville Lake shoreline. However, the immediate area near the site has an extensive network of similar wooded shoreline and shallow lagoon habitats.

The intake channel at the site has not been maintained and would require dredging, both initially and periodically throughout the life of the plant. Surveys have found no toxic sediments

Alternatives

1 and a low average density of mussels in the area. It is expected that the dredge material would
2 be disposed of on land (TVA 2003). Because water intake demand would be small compared
3 to the total water mass flowing past the Bellefonte site, there is little potential for significant
4 entrainment/impingement impacts. The existing water intake structure at the site would be
5 used; this intake system entrains water through a 7.6-m (25-ft)-wide trench connected to the
6 original river channel and is designed such that 85 percent of the intake demand would be
7 withdrawn from the river channel and 15 percent from the more productive upstream overbank
8 habitat. The greatest impacts of entrainment and impingement would result from water
9 withdrawn from the upstream productive overbank, although losses to the lake fish community
10 should be minimal due to the large amounts of similar habitat near the plant and in other areas
11 of the lake (TVA 2003). There could be impacts to terrestrial ecology from cooling tower drift.
12

13 Overall, siting of two ABWR units at the Bellefonte site would have a **SMALL to MODERATE**
14 ecological impact.
15

16 At an alternate site, there would be construction impacts and new incremental operational
17 impacts. Even assuming siting at a previously disturbed area, the impacts would alter the
18 ecology. Impacts could include wildlife habitat loss, reduced productivity, habitat fragmentation,
19 and a local reduction in biological diversity. Use of cooling water from a nearby surface water
20 body could have adverse aquatic resource impacts. If needed, construction and maintenance
21 of the transmission line would have ecological impacts. Overall, the ecological impacts at an
22 alternate site would be **MODERATE to LARGE**.
23

• **Water Use and Quality**

24
25
26 Raw water for construction and operation would be obtained from the Tennessee River. The
27 quantities needed would be unlikely to have a significant effect on the river. Both existing
28 closed-cycle natural draft cooling towers on the Bellefonte site would likely be used. The
29 existing intake channel at the site has not been periodically maintained and may require some
30 dredging (TVA 2003).
31

32 No significant construction-related impacts to surface water resources would be expected as a
33 result of the project. The majority of the power plant and associated facilities would be
34 constructed on land that has been previously altered because of construction activities related
35 to the uncompleted Bellefonte nuclear plant. Construction of new facilities and overall site
36 reclamation activities would affect surface hydrology, but extensive site excavation, filling, or
37 grading would not be needed. The primary surface water impact during construction would be
38 soil erosion, which could be kept low by the use of best management practices. To minimize
39 the impacts of storm water flow during construction, a storm water retention pond would be
40 designed to retain storm water from the 25-year, 24-hour rainfall event, in compliance with
41 regulatory requirements (TVA 2003).
42

43 The surface water resources within the areas of the proposed development at the Bellefonte
44 site are currently monitored under an NPDES permit issued by the Alabama Department of
45 Environmental Management.

1 Potable water is supplied to the Bellefonte site by the City of Hollywood, which receives its
 2 water from the City of Scottsboro. The Bellefonte site is connected to the Hollywood municipal
 3 sewage system treatment plant located adjacent to the south side of the site. The sewage
 4 treatment plant serves the Bellefonte site and residential customers in the area, but currently it
 5 does not have sufficient capacity to handle the increased demand of a large construction force
 6 and would have to be enlarged (TVA 2003).

7
 8 Surface water impacts at the Bellefonte site are expected to be sufficiently minor that they
 9 would not noticeably alter any important attribute of the resource.

10
 11 For alternate sites, the impact on the surface water would depend on the discharge volume and
 12 the characteristics of the receiving body of water. Intake from and discharge to any surface
 13 body of water would be regulated by the State or by EPA.

14
 15 A nuclear power plant sited at an alternate site may use groundwater. Groundwater withdrawal
 16 at an alternate site would likely require a permit.

17
 18 Overall, water use and quality impacts are estimated to be SMALL to MODERATE.

19
 20 • **Air Quality**

21
 22 Annual emission rate estimates for operating ABWR units sized to fully replace the power
 23 generated by BFN are shown in Table 8-8 (TVA 2003). The only combustion sources to
 24 produce carbon dioxide are the small auxiliary heating boilers, emergency power generators
 25 (usually diesel-driven but sometimes combustion turbines), service vehicles, some portable
 26 self-powered devices such as pumps and generators, and some types of welding and heat
 27 treatment gear (TVA 2003).

28
 29 There would be fugitive emissions during the construction process. Exhaust emissions would
 30 also come from vehicles and motorized equipment used during the construction process.

31
 32 Overall, plant emissions and associated impacts are considered SMALL.

33
 34 • **Waste**

35
 36 The waste impacts associated with operation of pressurized-water reactor (PWR) and boiling
 37 water reactor (BWR) nuclear power plants are set out in Table B-1 of 10.CFR 51 Subpart A,
 38 Appendix B. Similar to conventional BWRs, during operation the ABWR produces spent resins
 39 from the condensate filters and demineralizers and dry active wastes from maintenance
 40 operations, typically gloves, plastic sheeting, mops, rags, wood, paper, metal, and plastic
 41 scraps. Based on experience with LLW generated at both conventional and advanced BWRs in
 42 Japan, TVA expects that the LLW generated at the ABWR units would be less than 15 percent
 43 of the LLW currently generated at BFN BWR units (TVA 2003). The reasons for the reduction
 44 in LLW for the ABWR include lower regeneration requirements for condensate demineralizer;
 45 non-precoat, hollow-fiber filters for the condensate filters; and less required maintenance and

Alternatives

1 inspection overall. As an alternative means of disposal for solid and liquid LLW waste, TVA
2 would explore the feasibility of shipping it to offsite contractors for processing (incineration,
3 compaction, etc.) prior to permanent disposal at a licensed facility, similar to what is currently
4 done for radioactive wastes generated at BFN (TVA 2003).

5
6 In addition to the impacts shown in Table B-1, construction-related debris would be generated
7 during construction activities, which would be disposed of in landfills. During construction,
8 some modifications to the existing cooling towers at the Bellefonte site might be necessary to
9 increase their cooling capacity (TVA 2003). Modifications could potentially include replacing the
10 present asbestos fill. In this case, proper disposal of the asbestos fill in an offsite permitted
11 landfill would be required. Much of the waste generated during construction would be typical
12 construction/ demolition waste (e.g., broken concrete, rock, asphalt, scrap lumber and metal,
13 etc.) generated by the modification/removal of existing buildings such as old warehouses and
14 the building of the new plant. There is enough space available on the Bellefonte site for a
15 landfill to receive construction/demolition waste, but it may prove more economical to use any
16 of several existing landfills within 80 km (50 mi) of Bellefonte that have adequate storage
17 capacity and life expectancy (TVA 2003).

18
19 Waste impacts associated with construction of ABWR units at another site are unlikely to
20 exceed those associated with construction at the Bellefonte site. Overall, waste impacts are
21 considered SMALL.

22 • Human Health

23
24
25 Human health impacts for operating PWR and BWR nuclear power plants are set out in
26 10 CFR 51 Subpart A, Appendix B, Table B-1.

27
28 The total worker radiation exposure for an operating two-unit ABWR is projected to be about
29 0.62 man-Sieverts/yr, based on experience from the first 5 years of commercial operation for
30 two comparable ABWR units in Japan and adjusted to projected steady-state conditions
31 (TVA 2003). For three ABWR units to fully replace BFN capacity, total worker radiation
32 exposure would be about 0.93 man-Sieverts/yr. For comparison, the median U.S. annual
33 exposure for (two-unit) BWRs is 2.88 man-Sieverts/yr (TVA 2003). The reasons for the
34 reduced occupational exposure include less piping, particularly in containment, and therefore
35 less in-service inspection; larger maneuvering space for maintenance work inside containment;
36 improved design requiring less maintenance of reactor components such as control rod drives;
37 and shortened durations of refueling and maintenance outages due to expanded use of
38 automated systems and design improvements such as split-type control rod drive housings.
39 Approximately half of the radiation exposure is accumulated during outages. Experience with
40 the prototype ABWR plants in Japan has shown that radiation exposure during outages has
41 decreased steadily with time, reflecting lessons learned through operating experience (TVA
42 2003).

43
44 Overall, human health impacts for siting of new ABWR units at the Bellefonte site or at
45 alternative sites are considered SMALL.

1 • **Socioeconomics**

2
3 Based on Japanese ABWR construction experience, TVA expects that the construction period
4 for two new ABWR units at the Bellefonte site would be 34 months (TVA 2003). This abbrevi-
5 ated schedule reflects a high degree of modularization, requiring the use of large cranes;
6 expansion of the work scope, which can proceed in parallel; and a number of improvements in
7 field productivity through innovations such as increased use of automatic welding machines.
8 Peak employment during construction of the two units is estimated to be approximately
9 3115 workers, of which 2885 workers would be craft workers and craft work supervisors
10 (TVA 2003). Approximately 230 workers would be construction and pre-operational turnover
11 engineers and technical advisors supplied by an architectural/engineering company with ABWR
12 construction experience. TVA estimates that approximately one-third of the crafts workers
13 would move into the local area, with the rest commuting from longer distances. TVA expects
14 that less than half of those moving into the local area would buy or rent houses. Of those
15 workers who do move to the area, TVA estimates that more than two-thirds would bring their
16 families. TVA expects that few, if any, of the architectural/engineering personnel would buy
17 houses in the local area (TVA 2003). TVA estimates that approximately 720 new students
18 would attend the Scottsboro and Jackson county schools temporarily during the construction
19 period (TVA 2003).

20
21 The total projected employment during operation for the two-unit ABWR plant is 906 workers
22 (TVA 2003). For comparison, there are currently 1297 workers at BFN Units 2 and 3 (TVA
23 2003). TVA projects that the total population impact on Jackson County attributable to the new
24 ABWR units would be approximately 1200 to 1400 workers. The total annual employment
25 generated in Jackson County is estimated by TVA to be approximately 1600 workers, and the
26 total annual income generated to be over \$78 million (TVA 2003). The impacts from plant
27 operation on housing, schools, and services such as fire protection would be less than those of
28 peak construction and should, therefore, be accommodated without difficulty.

29
30 The new ABWR units would likely provide an increase in the in-lieu-of-tax payments received by
31 Jackson County or any other county where new units are constructed by TVA. In-lieu-of-tax
32 payments in Limestone County would likely decrease if the BFN OLs are not renewed. Employ-
33 ment in Limestone County would decrease if the BFN OLs are not renewed.

34
35 Construction of new ABWR units at a site other than Bellefonte would relocate some socio-
36 economic impacts, but would not eliminate them. Assuming the new units were not built at the
37 BFN site, the communities around the BFN site would experience the impact of operational job
38 loss and the loss of tax base. The communities around the new site would have to absorb the
39 impacts of a large, temporary workforce and a permanent operating workforce. In the GEIS,
40 the staff noted that socioeconomic impacts at a rural site would be larger than at an urban site
41 because more of the peak construction workforce would need to move to the area to work
42 (NRC 1996). Alternate sites would need to be analyzed on a case-by-case basis.
43 Socioeconomic impacts at a rural site could be LARGE. Transportation-related impacts

Alternatives

1 associated with commuting construction workers at an alternate site are site dependent.
2 Transportation impacts related to commuting of plant operating personnel would also be site-
3 dependent.

4
5 Overall, the socioeconomic impacts associated with constructing and operating new ABWR
6 units sized to replace BFN capacity are considered MODERATE to LARGE.

8 • Aesthetics

9
10 The Bellefonte site is seen most frequently by passing motorists from various points along
11 U.S. Highway 72. The on-ground plant facilities such as roads, parking lots, and office
12 buildings are screened for the most part by low rolling terrain in the foreground. The Bellefonte
13 site is buffered from the main Tennessee River channel by a wooded ridgeline, which rises
14 approximately 60 m (200 ft) above the lake surface. Distant views of the 145-m (477-ft)-high
15 cooling towers and the reactor domes can be seen in excess of 8 km (5 mi) away. The only
16 new ABWR construction that would rise to a height comparable to the existing cooling towers
17 would be an off-gas stack, which would have no associated visible plume (TVA 2003). Vapor
18 fog from the cooling towers could be visible from distances of 16 km (10 mi) or more. There is
19 an existing 39.9-km (24.8-mi) 500-kV transmission line to the Bellefonte site that is not
20 energized (TVA 2003).

21
22 Noise from operation of a replacement nuclear power plant would potentially be audible offsite
23 in calm wind conditions or when the wind was blowing in the direction of the listener. Mitigation
24 measures, such as reduced or no use of outside loudspeakers, can be employed to reduce
25 noise level.

26
27 At an alternate site, there would be an aesthetic impact from the buildings. There would also be
28 a significant aesthetic impact if a new transmission line were needed. Noise and light from the
29 plant would be detectable offsite. The impact of noise and light would be mitigated if the plant
30 was located in an industrial area adjacent to other power plants. Overall, the aesthetic impacts
31 associated with locating new ABWR units at Bellefonte or at an alternative site can be
32 categorized as MODERATE to LARGE.

34 • Historic and Archaeological Resources

35
36 A 1972 archaeological survey of the Bellefonte site identified five historic sites, none of which
37 are within proposed construction zones (TVA 2003). The original town of Bellefonte was
38 located just offsite and determined in 1974 to be eligible for placement on the National Register
39 of Historic Places. Prior to the initiation of construction of the uncompleted Bellefonte nuclear
40 plant, the Alabama State Historic Preservation Office determined that no mitigation would be
41 required. Since that time all structures have been removed by landowners (TVA 2003).

42
43 At an alternate site, a cultural resources inventory would likely be needed for any onsite pro-
44 perty that has not been previously surveyed. Other lands, if any, that are acquired to support
45 the plant would also likely need an inventory of field cultural resources, identification and

1 recording of existing historic and archaeological resources, and possible mitigation of adverse
 2 effects from subsequent ground-disturbing actions related to physical expansion of the plant
 3 site.
 4

5 Before construction at an alternate site, studies would likely be needed to identify, evaluate, and
 6 address mitigation of the potential impacts of new plant construction on cultural resources. The
 7 studies would likely be needed for all areas of potential disturbance at the proposed plant site
 8 and along associated rights-of-way where new construction would occur (e.g., roads,
 9 transmission lines, rail lines, or other rights-of-way). Historic and archaeological resource
 10 impacts can generally be effectively managed and would likely be SMALL at either the
 11 Bellefonte or an alternate site.

12 • **Environmental Justice**

13
 14 Environmental justice impacts would depend upon the population distribution around the
 15 Bellefonte site or other alternate sites. Construction activities would offer new employment
 16 possibilities, but could have negative impacts on the availability and cost of housing, which
 17 could disproportionately affect minority and low-income populations. Impacts in Limestone
 18 County would be the same as those under the no-action alternative. Overall, environmental
 19 justice impacts are likely to be SMALL to MODERATE.
 20

21 **8.2.4.2 Once-Through Cooling System**

22
 23 The environmental impacts of constructing and operating new ABWR units using once-through
 24 cooling are essentially the same as the impacts for a plant using closed cycle-cooling with wet
 25 cooling towers. However, there are some environmental differences between the closed-cycle
 26 and once-through cooling systems. Table 8-9 summarizes the incremental differences.
 27

28 **Table 8-9. Summary of Environmental Impacts of a New Nuclear Plant with Once-**
 29 **Through Cooling**
 30

Impact Category	Change in Impacts from Closed-Cycle Cooling System
Land Use	Less land required because cooling towers and associated infrastructure are not needed.
Ecology	Impact would depend on ecology at the site. No impact to terrestrial ecology from cooling tower drift. Increased water withdrawal with possible greater impact to aquatic ecology.
Surface Water Use and Quality	No discharge of cooling tower blowdown. Increased water withdrawal and more thermal load on receiving body of water.
Groundwater Use and Quality	No change
Air Quality	No change
Waste	No change
Human Health	No change

Table 8-9. (contd)

Impact Category	Change in Impacts from Closed-Cycle Cooling System
Socioeconomics	No change
Aesthetics	Less aesthetic impact because cooling towers would not be used.
Historic and Archaeological Resources	Less land impacted.
Environmental Justice	No change

8.2.5 Purchased Electrical Power

If available, purchased power from other sources could potentially obviate the need to renew the BFN OLs. TVA currently purchases electric power from other generators (TVA 2003). However, some power purchase activities implemented by TVA have not performed as intended in delivering reliable power to TVA customers. TVA has issued several requests for proposals in recent years with the goal of obtaining additional peaking and baseload power (TVA 2003). Some of the responses have either not met stated conditions and requirements, or the entities submitting the proposals could not deliver power by the needed dates. Consequently, the projected power hoped for from the requests for proposals has not fully materialized (TVA 2003).

Current regional reserve margins^(a) in the TVA service area are estimated to be approximately 30 percent; however, projections suggest that this surplus will be exhausted before the current BFN OLs expire (TVA 2003).

If power to replace the capacity of BFN were to be purchased from sources within the United States or from a foreign country, the generating technology likely would be one of those described in this SEIS and in the GEIS (probably coal, natural gas, or nuclear). The descriptions of the environmental impacts of other technologies in Chapter 8 of the GEIS and in Chapter 8 of this SEIS are representative of the environmental impacts associated with the purchased electrical power alternative to renewal of the BFN OLs. Under the purchased power alternative, the environmental impacts of imported power would still occur, but would be located elsewhere within the region, the United States, or another country.

8.2.6 Other Alternatives

Other generation technologies are discussed in the following subsections.

(a) Reserve margin is the amount of unused available capability of an electric power system (at peak load) as a percentage of total capability.

8.2.6.1 Oil-Fired Generation

EIA projects that oil-fired plants will account for no new generation capacity in the United States through the year 2025, except for limited industrial combined heat and power applications, because of higher fuel costs and lower efficiencies (DOE/EIA 2004). Oil-fired operation is more expensive than nuclear or coal-fired operation. In addition, future increases in oil prices are expected to make oil-fired generation increasingly more expensive than coal-fired generation. The high cost of oil has resulted in a decline in its use for electricity generation. In Section 8.3.11 of the GEIS, the staff estimated that construction of a 1000-MW(e) oil-fired plant would require about 49 ha (120 ac) (NRC 1996). Operation of oil-fired plants would have environmental impacts (including impacts on the aquatic environment and air) that would be similar to those from a coal-fired plant.

8.2.6.2 Wind Power

Most of Alabama, Mississippi, and western Tennessee are in a wind power Class 1 region (average wind speeds less than 5.6 m/s) (DOE 2004b). Class 1 has the lowest potential for wind energy generation (DOE 2004b). Alabama does not have sufficient wind resources to use large-scale wind turbines (DOE 2004c).

Aside from the coastal areas and exposed mountains and ridges of the Appalachian Mountains, there is little wind energy potential in the East Central region of the United States for current wind turbine applications (Elliott et al. 1987). Moreover, wind turbines typically operate at a 25 to 35 percent capacity factor compared to 90 to 95 percent for a baseload plant (NWPPC 2000).

Therefore, the staff concludes that locating a wind-energy facility on or near BFN or offshore as a replacement for BFN generating capacity would not be economically feasible given the current state of wind-energy generation technology.

8.2.6.3 Solar Power

Solar technologies use the sun's energy to provide heat and cooling, light, hot water, and electricity for homes, businesses, and industry. Solar power technologies (both photovoltaic and thermal) cannot currently compete with conventional nuclear and fossil-fueled technologies in grid-connected applications because of higher capital costs per kilowatt of capacity. Energy storage requirements also limit the use of solar-energy systems as baseload electricity supply. The average capacity factor of photovoltaic cells is about 25 percent (NRC 1996), and the capacity factor for solar thermal systems is about 25 to 40 percent (NRC 1996).

There are substantial impacts to natural resources (wildlife habitat, land use, and aesthetic impacts) from construction of solar-generating facilities. As stated in the GEIS, land requirements are high – 142 km² (55 mi²) per 1000 MW(e) for photovoltaic (NRC 1996) and approximately 57 km² (22 mi²) per 1000 MW(e) for solar thermal systems (NRC 1996). Neither

Alternatives

1 type of solar electric system would fit at the BFN site, and both would have large environmental
2 impacts at an alternate site.

3
4 The BFN site receives approximately 4500 to 5000 Wh/m² per day that can be used for flat-
5 plate solar systems and 3500 to 4000 Wh/m² per day that can be used for solar concentrating
6 systems. This is in comparison to areas in the southwestern United States that receive up to
7 7500 Wh/m² per day (DOE 2004d). For solar concentrating collectors, Alabama only has a
8 useful resource in the southeastern portion of the state. The solar resource in Alabama can be
9 used for water heating or photovoltaic systems, but not large concentrating solar thermal utility
10 systems (DOE 2004d).

11
12 Because of the natural resource impacts (land and ecological), the area's relatively low rate of
13 solar radiation, and high cost, solar power is not deemed a feasible baseload alternative to
14 renewal of the BFN OLs. Some onsite generated solar power (e.g., from rooftop photovoltaic
15 applications) may substitute for electric power from the grid. Implementation of solar
16 generation on a scale large enough to replace BFN would likely result in LARGE environmental
17 impacts.

18 19 **8.2.6.4 Hydropower**

20
21 Alabama has an estimated 363 MW^(a) of developable hydroelectric resources (INEEL 1998).
22 Tennessee has an estimated 138 MW of developable hydroelectric resources (INEEL 1997).
23 This total amount is significantly less than needed to replace the 3840-MW(e) uprated capacity
24 of BFN. As stated in Section 8.3.4 of the GEIS, hydropower's percentage of U.S. generating
25 capacity is expected to decline because hydroelectric facilities have become difficult to site as a
26 result of public concern about flooding, destruction of natural habitat, and alteration of natural
27 river courses. In the GEIS, the staff estimated that land requirements for hydroelectric power
28 are approximately 400,000 ha (1 million ac) per 1000 MW(e) (NRC 1996). Because of the
29 relatively low amount of undeveloped hydropower resource in Alabama and Tennessee and the
30 large land-use and related environmental and ecological resource impacts associated with
31 siting hydroelectric facilities large enough to replace BFN, the staff concludes that local
32 hydropower is not a feasible alternative to renewal of the BFN OLs. Any attempts to site
33 hydroelectric facilities large enough to replace the BFN would result in LARGE environmental
34 impacts.

35 36 **8.2.6.5 Geothermal Energy**

37
38 Geothermal energy technologies have an average capacity factor of 90 percent and can be
39 used for baseload power where available. However, geothermal technology is not widely used
40 for baseload generation due to the limited geographical availability of the resource and
41 immature status of the technology (NRC 1996). As illustrated by Figure 8.4 in the GEIS,
42 geothermal plants are most likely to be sited in the western continental United States, Alaska,

(a) One megawatt (MW) represents one million watts of electricity.

1 and Hawaii where hydrothermal reservoirs are prevalent. Alabama has low-to-moderate
2 geothermal resources that can be tapped for direct heat or for geothermal heat pumps.
3 However, electrical generation is not possible with these resources (DOE 2004e). There is no
4 practical eastern location for geothermal capacity to serve as an alternative to BFN. The staff
5 concludes that geothermal energy is not a feasible alternative to renewal of the BFN OLS.
6

7 **8.2.6.6 Wood Waste**

8
9 A wood-burning facility can provide baseload power and operate with an average annual
10 capacity factor of around 70 to 80 percent and with 20 to 25 percent efficiency (NRC 1996).
11 The fuels required are variable and site-specific. A significant barrier to the use of wood waste
12 to generate electricity is the high delivered-fuel cost and high construction cost per MW of
13 generating capacity. The larger wood-waste power plants are only 40 to 50 MW(e) in size.
14 Estimates in the GEIS suggest that the overall level of construction impact per MW of installed
15 capacity should be approximately the same as that for a coal-fired plant, although facilities
16 using wood waste for fuel would be built at smaller scales (NRC 1996). Like coal-fired plants,
17 wood-waste plants require large areas for fuel storage and processing and involve the same
18 type of combustion equipment.
19

20 Because of uncertainties associated with obtaining sufficient wood and wood waste to fuel a
21 baseload generating facility, ecological impacts of large-scale timber cutting (e.g., soil erosion
22 and loss of wildlife habitat), and low efficiency, the staff determined that wood waste is not a
23 feasible alternative to renewing the BFN OLS.
24

25 **8.2.6.7 Municipal Solid Waste**

26
27 Municipal waste combustors incinerate the waste and use the resultant heat to generate steam,
28 hot water, or electricity. The combustion process can reduce the volume of waste by up to
29 90 percent and the weight of the waste by up to 75 percent (EPA 2004). Municipal waste
30 combustors use three basic types of technologies: mass burn, modular, and refuse-derived
31 fuel (DOE/EIA 2001). Mass burning technologies are most commonly used in the United
32 States. This group of technologies process raw municipal solid waste "as is," with little or no
33 sizing, shredding, or separation before combustion. The initial capital costs for municipal solid-
34 waste plants are greater than for comparable steam-turbine technology at wood-waste facilities.
35 This is caused by the need for specialized waste-separation/handling equipment for municipal
36 solid waste (NRC 1996).
37

38 Growth in the municipal waste combustion industry slowed dramatically during the 1990s after
39 rapid growth during the 1980s. The slower growth was due to three primary factors: (1) the
40 Tax Reform Act of 1986, which made capital-intensive projects such as municipal waste
41 combustion facilities more expensive relative to less capital-intensive waste disposal alternative
42 such as landfills; (2) the 1994 Supreme Court decision (*C&A Carbone, Inc. v. Town of*
43 *Clarkstown*), 511 U.S. 383(1994), which struck down local flow control ordinances that required
44 waste to be delivered to specific municipal waste combustion facilities rather than landfills that
45 may have had lower fees; and (3) increasingly stringent environmental regulations that

Alternatives

1 increased the capital cost necessary to construct, operate, and maintain municipal waste
2 combustion facilities (DOE/EIA 2001).

3
4 Municipal solid waste combustors generate an ash residue that is buried in landfills. The ash
5 residue is composed of bottom ash and fly ash. Bottom ash refers to that portion of the
6 unburned waste that falls to the bottom of the grate or furnace. Fly ash represents the small
7 particles that rise from the furnace during the combustion process. Fly ash is generally
8 removed from flue gases using fabric filters and/or scrubbers (DOE/EIA 2001).

9
10 Currently there are approximately 89 waste-to-energy plants operating in the United States.
11 These plants generate approximately 2500 MW(e), or an average of approximately 28 MW(e)
12 per plant (Integrated Waste Services Association 2004). The staff concludes that generating
13 electricity from municipal solid waste would not be a feasible alternative to replace the uprated
14 3840-MW(e) baseload capacity of BFN and, consequently, would not be a feasible alternative
15 to renewal of the BFN OLS.

16 17 **8.2.6.8 Other Biomass-Derived Fuels**

18
19 In addition to wood and municipal solid waste fuels, there are several other concepts for fueling
20 electric generators, including burning crops, converting crops to a liquid fuel such as ethanol,
21 and gasifying crops (including wood waste). In the GEIS, the staff stated that none of these
22 technologies has progressed to the point of being competitive on a large scale or of being
23 reliable enough to replace a large baseload plant such as BFN (NRC 1996). For these
24 reasons, such fuels do not offer a feasible alternative to renewal of the BFN OLS.

25 26 **8.2.6.9 Fuel Cells**

27
28 Fuel cells work without combustion and its environmental side effects. Power is produced
29 electrochemically by passing a hydrogen-rich fuel over an anode and air over a cathode.
30 Activated by a catalyst, hydrogen atoms separate into protons and electrons, which take
31 different paths to the cathode. The electrons go through an external circuit, creating a flow of
32 electricity. The only by-products are heat, water, and carbon dioxide. Hydrogen fuel can come
33 from a variety of hydrocarbon resources by subjecting them to steam under pressure. Natural
34 gas is typically used as the source of hydrogen.

35
36 Phosphoric acid fuel cells are generally considered first-generation technology. Higher
37 temperature second-generation fuel cells achieve higher fuel-to-electricity conversions and
38 thermal efficiencies. The higher temperatures contribute to improved efficiencies and give the
39 second-generation fuel cells the capability to generate steam for cogeneration and combined-
40 cycle operations.

41
42 During the past three decades, significant efforts have been made to develop more practical
43 and affordable fuel cell designs for stationary power applications, but progress has been slow
44 (DOE 2004e). Today, the most widely marketed fuel cells cost about \$4500 per kW of installed

1 capacity; by contrast, a diesel generator costs \$800 to \$1500 per kilowatt, and a natural gas
 2 turbine can be even less (DOE 2004f).

3
 4 DOE has launched an initiative – the Solid State Energy Conversion Alliance – to bring about
 5 dramatic reductions in fuel cell costs. DOE’s goal is to cut costs to as low as \$400 per kW of
 6 installed capacity by the end of this decade, which would make fuel cells competitive for virtually
 7 every type of power application (DOE 2004f).

8
 9 The staff concludes that at the present time fuel cells are not economically or technologically
 10 competitive with other alternatives for baseload electricity generation. Future gains in cost
 11 competitiveness for fuels cells compared to other fuels are speculative. Fuel cells are,
 12 consequently, currently not a feasible alternative to renewal of the BFN OLS.

13
 14 **8.2.6.10 Delayed Retirement**

15
 16 It is conceptually possible that delayed retirement of other TVA generating units could replace
 17 the power generated by BFN. TVA has no plans for retiring any of its nuclear plants. Some
 18 fossil plants are slated for retirement, principally because of difficulty in meeting air emission
 19 requirements. Delayed retirement of these fossil units would involve major construction to
 20 upgrade or replace plant components (TVA 2003). The environmental impacts of such a
 21 scenario are bounded by the pulverized coal (Section 8.2.1) and natural gas combined-cycle
 22 (Section 8.2.3) generation alternatives.

23
 24 **8.2.6.11 Utility-Sponsored Conservation**

25
 26 The utility-sponsored conservation alternative refers to a situation with the following three
 27 conditions: (1) BFN ceases to operate, (2) no new generation is brought online to meet the lost
 28 generation, and (3) the lost generation is instead replaced by more efficient use of electricity
 29 brought about by DSM programs.

30
 31 DSM programs consist of the planning, implementing, and monitoring activities of electric
 32 utilities that are designed to encourage consumers to modify their level and pattern of electricity
 33 usage. DSM programs have been part of TVA’s energy portfolio since the 1970s. They were
 34 initiated in response to the rising cost of energy and the rising cost of building new electric
 35 generating units that began in the mid 1970s. By 1988, TVA DSM programs were credited with
 36 saving more than 2.3 billion kilowatt-hours per year and cutting system demand by 1200 MW
 37 (TVA 2003). Of these savings, 960 MW came from the residential sector after weatherization
 38 measures were installed in 631,000 homes in the Tennessee Valley. DSM initiatives (such as
 39 energy-right home electrical efficiency, direct load control, industrial customer products and
 40 services, and firm buy-back agreements) continue to be implemented through TVA power
 41 distributors with an estimated 154 MW of capacity added from 1995 through 1999, and an
 42 additional 264 MW from 2000 to 2002 (TVA 2003). TVA’s energy savings attributable to DSM
 43 are part of its long-range plan for meeting projected demand, and thus are not available offsets
 44 for the generating capacity of BFN.

Alternatives

1 Current residential DSM programs offered by TVA include a new homes plan, a heat pump
2 plan, a water heater plan, and a new manufactured home plan. Current commercial DSM
3 programs offered by TVA include onsite operations support to aid the achievement of energy
4 savings, support to industrial power users to improve energy efficiency, and an initiative to
5 encourage use of groundwater heat pumps.
6

7 Although DSM programs are an important part of TVA's energy portfolio, the staff concludes
8 that additional DSM, by itself, would not be sufficient to replace the uprated 3840-MW(e)
9 capacity of BFN and that it is not a reasonable substitute for renewing the OLs.
10

11 8.2.7 Combination of Alternatives

12
13 Even though individual alternatives might not be sufficient on their own to replace the BFN
14 generating capacity because of the small size of the resource or lack of cost-effective
15 opportunities, it is conceivable that a combination of alternatives might be cost-effective.
16

17 BFN is projected to have an uprated capacity of 3840 MW(e). There are many possible
18 combinations of alternatives to replace this capacity. Table 8-10 contains a summary of the
19 environmental impacts of an assumed combination of alternatives consisting of 3060-MW(e)
20 (six 510-MW(e)) plants of natural gas combined-cycle generation using mechanical draft cooling
21 towers, 400 MW purchased from other generators, and 380 MW gained from additional DSM
22 measures. The impacts associated with the natural gas combined-cycle units are based on the
23 discussion in Section 8.2.3, adjusted for the reduced generating capacity. While the DSM
24 measures would have few environmental impacts, operation of the new natural gas combined-
25 cycle plants would result in increased emissions and other environmental impacts. The
26 environmental impacts associated with power purchased from other generators would still
27 occur, but would be located elsewhere within the region as discussed in Section 8.2.4. The
28 environmental impacts associated with purchased power are not shown in Table 8-10. The
29 staff concludes that it is very unlikely that the environmental impacts of any reasonable
30 combination of generating and conservation options could be reduced to the level of impacts
31 associated with renewal of the BFN OLs.
32

33 **Table 8-10. Summary of Environmental Impacts of an Assumed Combination of Generation**
34 **and Acquisition Alternatives**
35

36	Impact Category	Impact	Comment
37	Land Use	MODERATE to LARGE	Approximately 80 ha (200 ac) for each of six 510-MW(e) plant. Additional site-specific impacts for natural gas pipeline, electric power transmission lines, rail spurs, and cooling water intake and discharge pipelines.
38	Ecology	MODERATE	Impact depends on location and ecology of the site, surface water body used for intake and discharge, and electric power transmission line and natural gas pipeline routes; potential habitat loss and fragmentation; reduced productivity and biological diversity; impacts to terrestrial ecology from cooling tower drift.

Table 8-10. (contd)

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20

Impact Category	Impact	Comment
Water Use and Quality	SMALL to MODERATE	Impact would depend on the volume of water withdrawn and discharged, the constituents in the discharge water, and the characteristics of the surface water body. Discharges would be regulated by the State or EPA.
Air Quality	MODERATE	Air emissions would be approximately: Sulfur oxides – 53.6 MT/yr (59.1 tons/yr) Nitrogen oxides – 1032 MT/yr (1138 tons/yr) PM ₁₀ – 947 MT/yr 1044 (tons/yr) Carbon monoxide – 3940 MT/yr (4340 tons/yr) Small amounts of hazardous air pollutants would be emitted along with 13.7 million MT/yr (15.1 million tons/yr) of unregulated carbon dioxide.
Waste	SMALL	The only significant waste would be spent catalyst from the SCR process used to control NO _x emissions.
Human Health	SMALL	Impacts are uncertain, but considered SMALL in the absence of more quantitative data.
Socioeconomics	MODERATE	Construction impacts depend on location and how many plants are constructed at the location. Limestone County could experience loss of BFN tax base and employment. Impacts related to the operation of the gas plants would be minor. Transportation impacts would result from commuting workers.
Aesthetics	MODERATE to LARGE	Impact would depend on the site selected and the surrounding land features. Power block, exhaust stacks, cooling towers, and cooling tower plumes would be visible from nearby areas. If needed, new electric power transmission lines could have a LARGE aesthetic impact. Noise impact from plant operations and intermittent sources would be noticeable.
Historic and Archeological Resources	SMALL	New plant locations would necessitate cultural resource studies. Any potential impacts can likely be effectively managed.
Environmental Justice	SMALL to MODERATE	Impacts would vary depending on population distribution and makeup water at the site. Impacts in Limestone County would be the same as those under the no-action alternative.

8.3 Summary of Alternatives Considered

As discussed in Chapter 4, the environmental impacts of the proposed action, renewal of the BFN OLS, are SMALL for all impact categories, except for collective offsite radiological impacts from the fuel cycle and from HLW and spent fuel disposal. Collective offsite radiological impacts from the fuel cycle and from HLW and spent fuel disposal were not assigned a single

Alternatives

1 significance level, but were determined by the Commission to be acceptable. The following
2 alternative actions were considered: the no-action alternative (discussed in Section 8.1); new
3 generation alternatives from pulverized coal, coal gasification, natural gas combined-cycle, and
4 new nuclear (discussed in Sections 8.2.1 through 8.2.4, respectively); purchased electrical
5 power (discussed in Section 8.2.5); alternative technologies (discussed in Section 8.2.6); and
6 the combination of alternatives (discussed in Section 8.2.7).

7
8 The no-action alternative purchasing would require replacing electrical generating capacity by
9 (1) DSM and energy conservation, (2) purchasing power from other electricity providers,
10 (3) generating alternatives other than BFN, or (4) some combination of these options, and
11 would result in decommissioning BFN. For each of the new generation alternatives (pulverized
12 coal, coal gasification, natural gas combined-cycle, and new nuclear), the environmental
13 impacts would not be less than the impacts of license renewal. For example, the land-
14 disturbance impacts resulting from construction of any new facility would be greater than the
15 impacts of continued operation of BFN. The impacts of purchased electrical power would still
16 occur, but would occur elsewhere. Alternative technologies are not considered feasible at this
17 time, and it is very unlikely that the environmental impacts of any reasonable combination of
18 generation and conservation options could be reduced to the level of impacts associated with
19 renewal of the BFN OL.

20
21 The staff concludes that the alternative actions, including the no-action alternative, may have
22 environmental effects in at least some impact categories that reach MODERATE or LARGE
23 significance.
24

25 8.4 References

26
27 10 CFR Part 20. Code of Federal Regulations, Title 10, *Energy*, Part 20, "Standards for
28 Protection Against Radiation."

29
30 10 CFR Part 50. Code of Federal Regulations, Title 10, *Energy*, Part 50, "Domestic Licensing
31 of Production and Utilization Facilities."

32
33 10 CFR Part 51. Code of Federal Regulations, Title 10, *Energy*, Part 51, "Environmental
34 Protection Regulations for Domestic Licensing and Related Functions."

35
36 10 CFR Part 52. Code of Federal Regulations, Title 10, *Energy*, Part 52, "Early Site Permits;
37 Standard Design Certifications; and Combined Licenses for Nuclear Power Plants."

38
39 40 CFR Part 50. Code of Federal Regulations, Title 40, *Protection of Environment*, Part 50,
40 "National Primary and Secondary Ambient Air Quality Standards."

41
42 40 CFR Part 51. Code of Federal Regulations, Title 40, *Protection of Environment*, Part 51,
43 "Requirements for Preparation, Adoption, and Submittal of Implementation Plans."
44

1 40 CFR Part 60. Code of Federal Regulations, Title 40, *Protection of Environment*, Part 60,
2 "Standards of Performance for New Stationary Sources."

3
4 40 CFR Part 63. Code of Federal Regulations, Title 40, *Protection of the Environment*, Part 63,
5 "National Emissions Standards for Hazardous Air Pollutants for Source Categories."

6
7 63 FR 49453. September 16, 1998. "Revision of Standards of Performance for Nitrogen Oxide
8 Emissions From New Fossil-Fuel Fired Steam Generating Units; Revisions to Reporting
9 Requirements for Standards of Performance for New Fossil-Fuel Fired Steam Generating Units,
10 Final Rule." *Federal Register*. U.S. Environmental Protection Agency.

11
12 64 FR 35714. July 1, 1999. "Regional Haze Regulations, Final Rule." *Federal Register*,
13 U.S. Environmental Protection Agency.

14
15 65 FR 32214. May 22, 2000. "Notice of Regulatory Determination on Wastes From the
16 Combustion of Fossil Fuels." *Federal Register*, U.S. Environmental Protection Agency.

17
18 65 FR 79825. December 20, 2000. "Regulatory Finding on the Emissions of Hazardous Air
19 Pollutants from Electric Utility Steam Generating Units." *Federal Register*, U.S. Environmental
20 Protection Agency.

21
22 C & A Carbone, Inc. v. Town of Clarkstown, 511 U.S. 383, (U.S. Supreme Court 1994).

23
24 Clean Air Act. 42 USC 7401, et seq.

25
26 Clean Water Act (also referred to as the Federal Water Pollution Control Act). 33 USC
27 1251, et seq.

28
29 Elliott, D.L., G.G. Holladay, W.R. Barchet, H.P. Foote, and W.F. Sandusky. 1987. *Wind*
30 *Energy Atlas of the United States*. DOE/CH 10093-4. Accessed on the Internet February 16,
31 2004 at <http://rredc.nrel.gov/wind/pubs/atlas/titlepg.html>

32
33 Federal Aviation Administration (FAA). 2000. "Obstruction Marking and Lighting." Advisory
34 Circular AC 70/7460-1K. Accessed on the Internet February 13, 2004 at
35 <http://www.faa.gov/ats/ata/ai/circV.pdf>

36
37 Gabbard, A. 1993. "Coal Combustion: Nuclear Resource or Danger," *Oak Ridge National*
38 *Laboratory Review*. Oak Ridge National Laboratory, Oak Ridge, Tennessee. Summer/Fall
39 1993. Accessed on the Internet February 13, 2004 at
40 <http://www.ornl.gov/ORNLReview/rev26-34/text/colmain.html>

41
42 Idaho National Engineering and Environmental Laboratory (INEEL). 1997. *U.S. Hydropower*
43 *Resource Assessment for Tennessee*. DOE/ID-10430(TN). Accessed on the Internet
44 February 13, 2004 at <http://hydropower.id.doe.gov/resourceassessment/tn/tn.pdf>

Alternatives

- 1 Idaho National Engineering and Environmental Laboratory (INEEL). 1998. *U.S. Hydropower*
2 *Resource Assessment for Alabama*. DOE/ID-10430(AL). Accessed on the Internet
3 February 13, 2004 at <http://hydropower.id.doe.gov/resourceassessment/al/al.pdf>
4
- 5 Integrated Waste Services Association. 2004. "About Waste-to-Energy." Accessed on the
6 Internet July 7, 2004 at <http://www.wte.org/waste.html>
7
- 8 National Environmental Policy Act of 1969 (NEPA). 42 USC 4321, et seq.
9
- 10 Northwest Power Planning Council (NWPPC). 2000. "Northwest Power Supply Adequacy/
11 Reliability Study Phase I Report." Accessed on the Internet February 17, 2004 at
12 <http://www.nwcouncil.org/library/2000/2000-4a.pdf>
13
- 14 Tennessee Valley Authority (TVA). 2003. *Applicant's Environmental Report – Operating*
15 *License Renewal Stage, Browns Ferry Nuclear Power Plant Units 1, 2, and 3*. Knoxville,
16 Tennessee.
17
- 18 U.S. Department of Energy, Energy Information Administration (DOE/EIA). 2001. *Renewable*
19 *Energy 2000: Issues and Trends*. DOE/EIA-0628(2000). Washington, D.C. Accessed on the
20 Internet February 17, 2004 at <http://tonto.eia.doe.gov/FTPROOT/renewables/06282000.pdf>
21
- 22 U.S. Department of Energy, Energy Information Administration (DOE/EIA). 2002. "100 Largest
23 Electric Plants." Accessed on the Internet April 27, 2004 at
24 <http://www.eia.doe.gov/neic/rankings/plantsbycapacity.htm>
25
- 26 U.S. Department of Energy, Energy Information Administration (DOE/EIA). 2004. *Annual*
27 *Energy Outlook 2004 with Projections to 2025*. DOE/EIA-0383(2003). Washington, D.C.
28 Accessed on the Internet January 27, 2004 at <http://www.eia.doe.gov/oiaf/aeo/index.html>
29
- 30 U.S. Department of Energy (DOE). 2004a. "Department of Energy Announces Study of
31 Advanced New Nuclear Power Plant at TVA Site." Accessed on the Internet May 25, 2004 at
32 http://www.energy.gov/engine/content.do?PUBLIC_ID=15945&BT_CODE=PR_PRESSRELEASES&TT_CODE=PRESSRELEASE
33
- 34
- 35 U.S. Department of Energy (DOE). 2004b. "U.S. Annual Wind Power Resource and Wind
36 Power Classes - Contiguous U.S. States." Accessed on the Internet February 16, 2004 at
37 http://www.eere.energy.gov/windandhydro/wind_potential.html
38
- 39 U.S. Department of Energy (DOE). 2004c. "Alabama Wind Resources." Accessed on the
40 Internet February 16, 2004 at
41 http://www.eere.energy.gov/state_energy/tech_wind.cfm?state=AL
42
- 43 U.S. Department of Energy (DOE). 2004d. "Alabama Solar Resources." Accessed on the
44 Internet February 16, 2004 at
45 http://www.eere.energy.gov/state_energy/tech_solar.cfm?state=AL

- 1 U.S. Department of Energy (DOE). 2004e. "Alabama Geothermal Resources." Accessed on
 2 the Internet February 16, 2004 at
 3 http://www.eere.energy.gov/state_energy/tech_geothermal.cfm?state=AL
 4
- 5 U.S. Department of Energy (DOE). 2004f. "Future Fuel Cells." Accessed on the Internet
 6 February 16, 2004 at <http://www.fossil.energy.gov/programs/powersystems/fuelcells/>
 7
- 8 U.S. Environmental Protection Agency (EPA). 2004. "Municipal Solid Waste Disposal."
 9 Accessed on the Internet February 17, 2004 at
 10 <http://www.epa.gov/epaoswer/non-hw/muncpl/disposal.htm>
 11
- 12 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement*
 13 *for License Renewal of Nuclear Plants*. NUREG-1437, Volumes 1 and 2, Washington, D.C.
 14
- 15 U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement*
 16 *for License Renewal of Nuclear Plants: Main Report*. "Section 6.3 – Transportation, Table 9.1
 17 Summary of findings on NEPA issues for license renewal of nuclear power plants, Final
 18 Report." NUREG-1437, Volume 1, Addendum 1, Washington, D.C.
 19
- 20 U.S. Nuclear Regulatory Commission (NRC). 2002. *Generic Environmental Impact Statement*
 21 *on Decommissioning of Nuclear Facilities – Supplement 1 Regarding the Decommissioning of*
 22 *Nuclear Power Reactors*. NUREG-0586 Supplement 1, Washington, D.C. Accessed on the
 23 Internet April 27, 2004 at <http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr0586/>

9.0 Summary and Conclusions

1 By letter dated December 31, 2003, the Tennessee Valley Authority (TVA) submitted an
2 application to the U.S. Nuclear Regulatory Commission (NRC) to renew the operating licenses
3 (OLs) for Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 (BFN) for an additional 20-year
4 period (TVA 2003a). If the OLs are renewed, State regulatory agencies and TVA will ultimately
5 decide whether the plant will continue to operate based on factors such as the need for power
6 or other matters within the State's jurisdiction or the purview of the owners. If the OLs are not
7 renewed, then the plants must be shut down at or before the expiration of the current OLs,
8 which expire on December 20, 2013, for Unit 1, June 28, 2014, for Unit 2, and July 2, 2016, for
9 Unit 3.

10
11 Section 102 of the National Environmental Policy Act of 1969 (NEPA) (42 USC 4321) directs
12 that an environmental impact statement (EIS) is required for major Federal actions that
13 significantly affect the quality of the human environment. The NRC has implemented Section
14 102 of NEPA in 10 CFR Part 51. Part 51 identifies licensing and regulatory actions that require
15 an EIS. In 10 CFR 51.20(b)(2), the Commission requires preparation of an EIS or a
16 supplement to an EIS for renewal of a reactor OL; 10 CFR 51.95(c) states that the EIS
17 prepared at the OL renewal stage will be a supplement to the *Generic Environmental Impact*
18 *Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437, Volumes 1 and 2
19 (NRC 1996, 1999).^(a)

20
21 Upon acceptance of the TVA application, NRC began the environmental review process
22 described in 10 CFR Part 51 by publishing a notice of intent to prepare an EIS and conduct
23 scoping (69 FR11462) on March 10, 2004 (NRC 2004a). The staff visited the BFN site in
24 March 2004 and held public scoping meetings on April 1, 2004, in Athens, Alabama (NRC
25 2004b). The staff reviewed the TVA Environmental Report (ER) (TVA 2003b) and other TVA
26 environmentally related documents and compared them to the GEIS, consulted and discussed
27 the application with other agencies, and conducted an independent review of the issues
28 following the guidance set forth in NUREG-1555, Supplement 1, the *Standard Review Plans for*
29 *Environmental Reviews for Nuclear Power Plants, Supplement 1: Operating License Renewal*
30 (NRC 2000). The staff also considered the public comments received during the scoping
31 process for preparation of this supplemental environmental impact statement (SEIS) for BFN.
32 The public comments received during the scoping process that were considered to be within the
33 scope of the environmental review are provided in Appendix A, Part 1, of this draft SEIS.

34
35 The staff will hold two public meetings in Athens, Alabama, in January 2005, to describe the
36 results of the NRC environmental review and to answer questions to provide members of the

(a) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and its Addendum 1.

Summary and Conclusions

1 public with information to assist them in formulating their comments on this SEIS. When the
2 comment period ends, the staff will consider and address all of the comments received. These
3 comments will be addressed in Appendix A, Part 2, of the final SEIS.
4

5 This draft SEIS includes the NRC staff's analysis that considers and weighs the environmental
6 effects of the proposed action, the environmental impacts of alternatives to the proposed action,
7 and mitigation measures available for reducing or avoiding adverse effects. It also includes the
8 staff's recommendation regarding the proposed action.
9

10 The NRC has adopted the following statement of purpose and need for license renewal from
11 the GEIS:
12

13 The purpose and need for the proposed action (renewal of an operating license) is to
14 provide an option that allows for power generation capability beyond the term of a
15 current nuclear power plant operating license to meet future system generating needs,
16 as such needs may be determined by State, utility, and, where authorized, Federal
17 (other than NRC) decisionmakers.
18

19 The goal of the staff's environmental review, as defined in 10 CFR 51.95(c)(4) and the GEIS, is
20 to determine
21

22 ... whether or not the adverse environmental impacts of license renewal are so great
23 that preserving the option of license renewal for energy planning decisionmakers would
24 be unreasonable.
25

26 Both the statement of purpose and need and the evaluation criterion implicitly acknowledge that
27 there are factors, in addition to license renewal, that will ultimately determine whether an
28 existing nuclear power plant continues to operate beyond the period of the current OL.
29

30 NRC regulations [10 CFR 51.95(c)(2)] contain the following statement regarding the content of
31 SEISs prepared at the license renewal stage:
32

33 The supplemental environmental impact statement for license renewal is not required to
34 include discussion of need for power or the economic costs and economic benefits of
35 the proposed action or of alternatives to the proposed action except insofar as such
36 benefits and costs are either essential for a determination regarding the inclusion of an
37 alternative in the range of alternatives considered or relevant to mitigation. In addition,
38 the supplemental environmental impact statement prepared at the license renewal stage
39 need not discuss other issues not related to the environmental effects of the proposed

1 action and the alternatives, or any aspect of the storage of spent fuel for the facility
2 within the scope of the generic determination in § 51.23(a) and in accordance with
3 § 51.23(b).^(a)
4

5 The GEIS contains the results of a systematic evaluation of the consequences of renewing an
6 OL and operating a nuclear power plant for an additional 20 years. It evaluates
7 92 environmental issues using the NRC's three-level standard of significance – SMALL,
8 MODERATE, or LARGE – developed using the Council on Environmental Quality guidelines.
9 The following definitions of the three significance levels are set forth in the footnotes to
10 Table B-1 of 10 CFR Part 51, Subpart A, Appendix B:
11

12 SMALL – Environmental effects are not detectable or are so minor that they will neither
13 destabilize nor noticeably alter any important attribute of the resource.
14

15 MODERATE – Environmental effects are sufficient to alter noticeably, but not to
16 destabilize, important attributes of the resource.
17

18 LARGE – Environmental effects are clearly noticeable and are sufficient to destabilize
19 important attributes of the resource.
20

21 For 69 of the 92 issues considered in the GEIS, the staff analysis in the GEIS shows the
22 following:
23

- 24 (1) The environmental impacts associated with the issue have been determined to apply either
25 to all plants or, for some issues, to plants having a specific type of cooling system or other
26 specified plant or site characteristics.
27
28 (2) A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to the
29 impacts (except for collective off-site radiological impacts from the fuel cycle and from high-
30 level waste [HLW] and spent fuel disposal).
31
32 (3) Mitigation of adverse impacts associated with the issue has been considered in the analysis,
33 and it has been determined that additional plant-specific mitigation measures are likely not
34 to be sufficiently beneficial to warrant implementation.
35

(a) The title of 10 CFR 51.23 is "Temporary storage of spent fuel after cessation of reactor operations-
generic determination of no significant environmental impact."

Summary and Conclusions

1 These 69 issues were identified in the GEIS as Category 1 issues. In the absence of new and
2 significant information, the staff relied on conclusions as amplified by supporting information in
3 the GEIS for issues designated Category 1 in Table B-1 of 10 CFR Part 51, Subpart A,
4 Appendix B.
5

6 Of the 23 issues that do not meet the criteria set forth above, 21 are classified as Category 2
7 issues requiring analysis in a plant-specific supplement to the GEIS. The remaining two issues,
8 environmental justice and chronic effects of electromagnetic fields, were not categorized.
9 Environmental justice was not evaluated on a generic basis and must also be addressed in a
10 plant-specific supplement to the GEIS. Information on the chronic effects of electromagnetic
11 fields was not conclusive at the time the GEIS was prepared.
12

13 This SEIS documents the staff's consideration of all 92 environmental issues identified in the
14 GEIS. The staff considered the environmental impacts associated with alternatives to license
15 renewal and compared the environmental impacts of license renewal and the alternatives. The
16 alternatives to license renewal that were considered include the no-action alternative (not
17 renewing the OLS for BFN) and alternative methods of power generation. These alternatives
18 were evaluated assuming that the replacement power generation plant is located at either the
19 BFN site, at the unfinished Bellefonte nuclear plant site, or at other locations.
20

21 **9.1 Environmental Impacts of the Proposed Action – License** 22 **Renewal**

23
24 TVA and the NRC staff have established independent processes for identifying and evaluating
25 the significance of any new information on the environmental impacts of license renewal.
26 Neither TVA nor the NRC staff has identified information that is both new and significant related
27 to Category 1 issues that would call into question the conclusions in the GEIS. Similarly,
28 neither the scoping process, TVA, nor the NRC staff has identified any new issue applicable to
29 BFN that has a significant environmental impact. Therefore, the staff relies upon the
30 conclusions of the GEIS for all Category 1 issues that are applicable to BFN.
31

32 TVA's license renewal application presents an analysis of the Category 2 issues that are
33 applicable to BFN, plus environmental justice and chronic effects from electromagnetic fields.
34 The staff has reviewed the TVA analysis for each issue and has conducted an independent
35 review of each issue plus environmental justice and chronic effects from electromagnetic fields.
36 Three Category 2 issues are not applicable because they are related to plant design features or
37 site characteristics not found at BFN. Four Category 2 issues are not discussed in this SEIS
38 because they are specifically related to refurbishment. TVA (TVA 2003b) has stated that its
39 evaluation of structures and components, as required by 10 CFR 54.21, did not identify any
40 major plant refurbishment activities or modifications as necessary to support the continued

1 operation of BFN for the license renewal term. In addition, any replacement of components or
2 additional inspection activities are within the bounds of normal plant component replacement
3 and, therefore, are not expected to affect the environment outside the bounds of the plant
4 operations evaluated in the TVA *Final Environmental Statement Related to the Operation of*
5 *Browns Ferry Units 1, 2, and 3* (TVA 1972), which was adopted by the Atomic Energy
6 Commission.

7
8 Fourteen Category 2 issues related to operational impacts and postulated accidents during the
9 license renewal term, as well as environmental justice and chronic effects of electromagnetic
10 fields, are discussed in detail in this SEIS. Four of the Category 2 issues and environmental
11 justice apply to both refurbishment and to operation during the license renewal term and are
12 only discussed in this SEIS in relation to operation during the license renewal term. For all 14
13 Category 2 issues and environmental justice, the staff concludes that the potential
14 environmental effects are of SMALL significance in the context of the standards set forth in the
15 GEIS. In addition, the staff determined that appropriate Federal health agencies have not
16 reached a consensus on the existence of chronic adverse effects from electromagnetic fields.
17 Therefore, no further evaluation of this issue is required. For severe accident mitigation
18 alternatives (SAMAs), the staff concludes that a reasonable, comprehensive effort was made to
19 identify and evaluate SAMAs. Based on its review of the SAMAs for BFN and the plant
20 improvements already made, the staff concludes that none of the candidate SAMAs are cost-
21 beneficial.

22
23 Mitigation measures were considered for each Category 2 issue. Current measures to mitigate
24 the environmental impacts of plant operation were found to be adequate, and no additional
25 mitigation measures were deemed sufficiently beneficial to be warranted. Cumulative impacts
26 of past, present, and reasonably foreseeable future actions were considered, regardless of
27 what agency (Federal or non-Federal) or person undertakes such other actions. For purposes
28 of this analysis, where BFN license renewal impacts are deemed to be SMALL, the staff
29 concluded that these impacts would not result in significant cumulative impacts on potentially
30 affected resources.

31
32 The following sections discuss unavoidable adverse impacts, irreversible or irretrievable
33 commitments of resources, and the relationship between local short-term use of the
34 environment and long-term productivity.

35 36 **9.1.1 Unavoidable Adverse Impacts**

37
38 An environmental review conducted at the license renewal stage differs from the review
39 conducted in support of a construction permit because the plant is in existence at the license
40 renewal stage and has operated for a number of years. As a result, adverse impacts

Summary and Conclusions

1 associated with the initial construction have been avoided, have been mitigated, or have
2 already occurred. The environmental impacts to be evaluated for license renewal are those
3 associated with refurbishment and continued operation during the license renewal term.
4

5 The adverse impacts of continued operation identified are considered to be of SMALL signifi-
6 cance, and none warrants implementation of additional mitigation measures. The adverse
7 impacts of likely alternatives if BFN ceases operation at or before the expiration of the current
8 OLs will not be smaller than those associated with continued operation of these units, and they
9 may be greater for some impact categories in some locations.
10

11 **9.1.2 Irreversible or Irrecoverable Resource Commitments**

12
13 The commitment of resources related to construction and operation of BFN during the current
14 license term was made when the plant was built. The resource commitments to be considered
15 in this SEIS are associated with continued operation of the plant for an additional 20 years.
16 These resources include materials and equipment required for plant maintenance and
17 operation, the nuclear fuel used by the reactors and, ultimately, permanent offsite storage
18 space for the spent fuel assemblies.
19

20 The most significant resource commitments related to operation during the license renewal
21 term are the new fuel and the permanent storage space for the spent fuel. BFN currently
22 replaces approximately 38 percent of the fuel assemblies in each unit during every refueling
23 outage, which occurs on a 24-month cycle. With the planned extended power uprate, and a
24 contemplated change to blended low-enriched uranium fuel assemblies, the proportion of the
25 fuel assemblies replaced during each refueling cycle may increase to approximately 48 percent.
26

27 The likely power generation alternatives if BFN ceases operation on or before the expiration of
28 the current OLs will require a commitment of resources for construction of the replacement
29 plants as well as for fuel to operate the plants.
30

31 **9.1.3 Short-Term Use Versus Long-Term Productivity**

32
33 An initial balance between local short-term uses and the maintenance and enhancement of the
34 long-term productivity of the environment at the BFN site was set when the plants were
35 approved and construction began. That balance is now well established. Renewal of the OLs
36 for BFN and continued operation of the plants will not alter the existing balance because the
37 decision to use the BFN site to produce power has already been made, but may postpone the
38 availability of the site for other uses. Denial of the application to renew the OLs will lead to
39 shutdown of the plants and will alter the balance in a manner that depends on subsequent uses
40 of the site. For example, the environmental consequences of turning the BFN site into a park or
41 an industrial facility are quite different.
42

9.2 Relative Significance of the Environmental Impacts of License Renewal and Alternatives

The proposed action is renewal of the OLs for Units 1, 2, and 3 at BFN. Chapter 2 describes the site, the power plant, and interactions of the plant with the environment. As noted in Chapter 3, no-refurbishment activities and therefore no refurbishment impacts are expected at BFN. Chapters 4 through 7 discuss environmental issues associated with renewal of the OLs. Environmental issues associated with the no-action alternative and alternatives involving power generation and use reduction are discussed in Chapter 8.

The significance of the environmental impacts from the proposed action (approval of the application for renewal of the OLs), the no-action alternative (denial of the application), alternatives involving nuclear or coal-fired, coal gasification, or natural-gas-fired generation of power at the BFN site, nuclear generation at the TVA-owned Bellefonte site, and a combination of alternatives are compared in Table 9-1. Continued use of a once-through cooling system with helper towers for BFN is assumed for Table 9-1.

Table 9-1 shows that the significance of the environmental effects of the proposed action are SMALL for all impact categories (except for collective offsite radiological impacts from the fuel cycle and from high-level waste and spent fuel disposal, for which a single significance level was not assigned [Chapter 6]). The alternative actions, including the no-action alternative, may have environmental effects in at least some impact categories that reach MODERATE or LARGE significance.

9.3 Staff Conclusions and Recommendations

Based on (1) the analysis and findings in the GEIS (NRC 1996, 1999); (2) the TVA Environmental Report (TVA 2003b); (3) consultation with Federal, State, and local agencies; (4) the staff's own independent review; and (5) the staff's consideration of public comments, the recommendation of the staff is that the Commission determine that the adverse environmental impacts of license renewal for Units 1, 2, and 3 at BFN are not so great that preserving the option of license renewal for energy-planning decisionmakers would be unreasonable.

Table 9-1. Summary of Environmental Significance of License Renewal, the No-Action Alternative, and Alternative Methods of Generation Using Closed-Cycle Cooling

Impact Category	Proposed Action (License Renewal)	No-Action Alternative (Denial of Renewal)	Pulverized Coal-Fired Generation	Coal Gasification ^(a)	Natural-Gas-Combined-Cycle Generation	New Nuclear Generation ^(a)	Combination of Energy Alternatives
Land Use	SMALL	SMALL	MODERATE to LARGE	MODERATE to LARGE	MODERATE to LARGE	SMALL to LARGE	MODERATE to LARGE
Ecology	SMALL	SMALL	MODERATE to LARGE	SMALL to LARGE	MODERATE	SMALL to LARGE	MODERATE
Water Use and Quality	SMALL	SMALL	SMALL to MODERATE	SMALL to MODERATE	SMALL to MODERATE	SMALL to MODERATE	SMALL to MODERATE
Air Quality	SMALL	SMALL	MODERATE	MODERATE	MODERATE	SMALL	MODERATE
Waste	SMALL	SMALL	MODERATE	MODERATE	SMALL	SMALL	SMALL
Human Health	SMALL ^(b)	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL
Socio-economics	SMALL	MODERATE	MODERATE	MODERATE	MODERATE	MODERATE to LARGE	MODERATE
Aesthetics	SMALL	SMALL	MODERATE to LARGE	MODERATE	MODERATE to LARGE	MODERATE to LARGE	MODERATE to LARGE
Historic and Archaeological Resources	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL
Environmental Justice	SMALL	SMALL	SMALL to MODERATE	SMALL to MODERATE	SMALL to MODERATE	SMALL to MODERATE	SMALL to MODERATE

(a) This alternative assumes building at TVA's unfinished Bellefonte nuclear plant site.

(b) Except for collective offsite radiological impacts from the fuel cycle and from HLW and spent-fuel disposal, for which a significance level was not assigned. See Chapter 6 for details.

9.4 References

10 CFR Part 51. Code of Federal Regulations, Title 10, *Energy*, Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions."

10 CFR Part 54. Code of Federal Regulations, Title 10, *Energy*, Part 54, "Requirements for Renewal of Operating Licenses for Nuclear Power Plants."

National Environmental Policy Act of 1969 (NEPA). 42 USC 4321, et seq.

Tennessee Valley Authority (TVA). 1972. *Final Environmental Impact Statement Browns Ferry Nuclear Plant, Units 1, 2, and 3*. Tennessee Valley Authority, Office of Health & Environmental Science. Chattanooga, Tennessee.

Tennessee Valley Authority (TVA). 2003a. *Application for Renewed Operating Licenses, Browns Ferry Units 1, 2, and 3*. Knoxville, Tennessee.

Tennessee Valley Authority (TVA). 2003b. *Applicant's Environmental Report – Operating License Renewal Stage, Browns Ferry Units 1, 2, and 3*. Knoxville, Tennessee.

U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*. NUREG-1437, Volumes 1 and 2, Washington, D.C.

U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants: Main Report, Section 6.3 – Transportation, Table 9.1, Summary of findings on NEPA issues for license renewal of nuclear power plants, Final Report*. NUREG-1437, Volume 1, Addendum 1, Washington, D.C.

U.S. Nuclear Regulatory Commission (NRC). 2000. "Standard Review Plans for Environmental Reviews for Nuclear Power Plants, Supplement 1: Operating License Renewal." NUREG-1555, Supplement 1, Washington, D.C.

U.S. Nuclear Regulatory Commission (NRC). 2004a. "Notice of Intent To Prepare an Environmental Impact Statement and Conduct Scoping Process." *Federal Register*. Vol. 69, No. 47, pp. 11462-11464. Washington, D.C.

U.S. Nuclear Regulatory Commission (NRC). 2004b. *Environmental Impact Statement Scoping Process: Summary Report – Browns Ferry Nuclear Plant, Units 1, 2, and 3*. Athens, Alabama.

Appendix A

Comments Received on the Environmental Review

Appendix A

Comments Received on the Environmental Review

1 Part I – Comments Received During Scoping

2
3 On March 10, 2004, the U.S. Nuclear Regulatory Commission (NRC) published a Notice of
4 Intent in the Federal Register (69 FR 11462), to notify the public of the staff's intent to prepare
5 a plant-specific supplement to the *Generic Environmental Impact Statement for License*
6 *Renewal of Nuclear Plants* (GEIS), NUREG-1437, Volumes 1 and 2, to support the renewal
7 application for the Browns Ferry operating licenses and to conduct scoping. The plant-specific
8 supplement to the GEIS has been prepared in accordance with the National Environmental
9 Policy Act (NEPA), Council on Environmental Quality (CEQ) guidance, and 10 CFR Part 51. As
10 outlined by NEPA, the NRC initiated the scoping process with the issuance of the Federal
11 Register Notice. The NRC invited the applicant; Federal, State, and local government
12 agencies; Native American tribal organizations; local organizations; and individuals to
13 participate in the scoping process by providing oral comments at the scheduled public meetings
14 and/or submitting written suggestions and comments no later than May 9, 2004. The deadline
15 for filing comments was subsequently extended to June 4, 2004 (69 FR 30338).

16
17 The scoping process included two public scoping meetings, which were held at Athens State
18 University in Athens, Alabama on April 1, 2004. Approximately 40 members of the public
19 attended each meeting. Both sessions began with NRC staff members providing a brief
20 overview of the license renewal process and the NEPA process. After the NRC's prepared
21 statements, the meetings were open for public comments. Seven attendees provided oral
22 statements that were recorded and transcribed by a certified court reporter and written
23 statements that were appended to the transcript. The meeting transcripts are an attachment to
24 the April 1, 2004, Scoping Meeting Summary dated May 14, 2004. The meeting summary is
25 available electronically for public inspection in the NRC Public Document Room or from the
26 Publicly Available Records component of NRC's document system (ADAMS) under accession
27 number ML041390581. In addition to the comments received during the public meetings, four
28 comment letters and two e-mail messages were received by the NRC in response to the Notice
29 of Intent.

30
31 The NRC received a letter dated May 19, from Mr. Larry Goldman of the U.S. Fish and Wildlife
32 Service (FWS) providing comments on the environmental review. These comments were not
33 included in the scoping summary report. However, the staff did consider the comments from
34 FWS in the preparation of this supplemental environmental impact statement (SEIS).

35
36 At the conclusion of the scoping period, the NRC staff and its contractor(s) reviewed the tran-
37 scripts and all written material to identify specific comments and issues. Each set of comments

Appendix A

1 from a given commenter was given a unique identifier (Commenter ID), so that each set of
2 comments from a commenter could be traced back to the transcript or letter by which the
3 comments were submitted. Specific comments were numbered sequentially within each
4 comment set. One commenter submitted comments through multiple sources (e.g., afternoon
5 and evening scoping meetings). All of the comments received and the staff responses are
6 included in the Environmental Scoping Summary Report dated July 2004.
7

8 Table A-1 identifies the individuals who provided comments applicable to the environmental
9 review and the Commenter ID associated with each person's set(s) of comments. The
10 individuals are listed in the order in which they spoke at the public meeting, and in alphabetical
11 order for the comments received by letter or e-mail. To maintain consistency with the Scoping
12 Summary Report, the unique identifier used in that report for each set of comments is retained
13 in this appendix.
14

15 Specific comments were categorized and consolidated by topic. Comments with similar specific
16 objectives were combined to capture the common essential issues raised by the commenters.
17 The comments fall into one of the following general groups:
18

- 19 • Specific comments that address environmental issues within the purview of the NRC
20 environmental regulations related to license renewal. These comments address
21 Category 1 or Category 2 issues or issues that were not addressed in the GEIS. They
22 also address alternatives and related Federal actions.
23
- 24 • General comments (1) in support of or opposed to nuclear power or license renewal or
25 (2) on the renewal process, the NRC's regulations, and the regulatory process. These
26 comments may or may not be specifically related to the Browns Ferry license renewal
27 application.
28
- 29 • Questions that do not provide new information.
30
- 31 • Specific comments that address issues that do not fall within or are specifically excluded
32 from the purview of NRC environmental regulations related to license renewal. These
33 comments typically address issues such as the need for power, emergency prepared-
34 ness, security, current operational safety issues, and safety issues related to operation
35 during the renewal period.
36
37

1 **Table A-1. Individuals Providing Comments During Scoping Comment Period**

2

3	Commenter ID	Commenter	Affiliation (If Stated)	Comment Source and Accession Number:
4	BF-A	Stewart Horn		Afternoon Scoping Meeting ML041350407
5	BF-B	Dr. Lane Price		Afternoon Scoping Meeting
6	BF-C	Ann Harris	We the People, Inc.	Afternoon Scoping Meeting
7	BF-D	Stewart Ward		Afternoon Scoping Meeting
8	BF-E	Chuck Wilson	Tennessee Valley Authority	Afternoon Scoping Meeting
9	BF-F	Nancy Muse		Evening Scoping Meeting ML041350459
10	BF-G	Jeff North		Evening Scoping Meeting
11	BF-H	Chuck Wilson	Tennessee Valley Authority	Evening Scoping Meeting
12	BF-I	Zola		Email ML041250405
13	BF-J	Michael Bolt	Eastern Band of Cherokee Indians	Email ML0415540361
14	BF-K	Michelle Hamilton	Eastern Band of Cherokee Indians	Comment Letter ML041490083
15	BF-L	Sara Barczak and David Ritter	Southern Alliance for Clean Air and Public Citizen's Critical Mass Energy and Environmental Program	Comment Letter ML041340245
16	BF-M	Anoatubby	Chickasaw Nation	Comment Letter ML041410044
17	BF-N	Frances Lamberts	Tennessee League of Women Voters	Comment Letter ML041600095

18
19 Comments applicable to this environmental review and the staff's responses are summarized in
20 this appendix. The parenthetical alpha-numeric identifier after each comment refers to the
21 comment set (Commenter ID) and the comment number. This information, which was
22 extracted from the Browns Ferry Scoping Summary Report, is provided for the convenience of
23 those interested in the scoping comments applicable to this environmental review. The
24 comments that are general or outside the scope of the environmental review for Browns Ferry
25 are not included here. More detail regarding the disposition of general or inapplicable
26 comments can be found in the summary report. The ADAMS accession number for the
27 Scoping Summary Report is ML041970736.

Appendix A

1 This accession number is provided to facilitate access to the document through the Public
2 Electronic Reading Room (ADAMS) <http://www.nrc.gov/reading-rm.html>.

3
4 Comments in this section are grouped in the following categories:

- 5
- 6 A.1.1 Aquatic Ecology Issues
- 7 A.1.2 Threatened and Endangered Species
- 8 A.1.3 Air Quality Issues
- 9 A.1.4 Human Health Issues
- 10 A.1.5 Cultural Resources Issues
- 11 A.1.6 Alternative Energy Sources
- 12 A.1.7 Surface Water Quality, Hydrology, and Use
- 13 A.1.8 Postulated Accidents
- 14 A.1.9 Uranium Fuel Cycle

15 16 **Part I. Comments Received During Scoping**

17 18 **A.1 Comments and Responses**

19
20 The comments and suggestions received as part of scoping are discussed below. Parentheti-
21 cal numbers after each comment refer to the commenter's ID letter and the comment number.
22 Comments can be tracked to the commenter and the source document through the ID letter
23 and comment number listed in Table A-1.

24 25 **A.1.1 Comments Concerning Aquatic Ecology Issues**

26
27 **Comment:** I don't understand the terminology impingement and entrainment. I don't know
28 how to comment on that without understanding what it is. (BF-F-6)

29
30 **Comment:** Through impingement and entrainment, and through thermal alteration of returned
31 water they cause damage to aquatic life, including great fishery and related recreational losses
32 along river systems on which they are located. (BF-N-15)

33
34 **Response:** *Impingement occurs when fish or shellfish are pulled onto the intake screens that*
35 *are part of the cooling water systems associated with nuclear power plants. Entrainment*
36 *occurs when fish, shellfish, or larvae that are too small to be impinged on the screen are*
37 *entrained in the flow through the plant, traversing the plant cooling system. Impingement and*
38 *entrainment, as well as other aquatic ecology issues, will be discussed in Chapter 2 and*
39 *Chapter 4 of the SEIS.*

1 **Comment:** The EIS should include (3) analysis of aquatic wildlife and terrestrial species
2 impacts, with extensive involvement of the Federal and State agencies charged
3 with natural resource protection. (BF-N-23)
4

5 **Response:** *Impacts to aquatic and terrestrial species will be discussed in Chapter 4 of the*
6 *SEIS.*
7

8 **A.1.2 Comments Concerning Threatened and Endangered Species** 9

10 **Comment:** New data on the status of Federally and State-listed endangered or threatened
11 terrestrial animal, aquatic, and plant species should be required and studied as to the impacts
12 of an additional 20 years of operations per reactor. (BF-L-13)
13

14 **Comment:** Proper notification to, along with creation of working relationships with, state
15 agencies, Fish and Wildlife Service, and National Marine Fisheries Service should occur.
16 (BF-L-14)
17

18 **Response:** *During the analysis and preparation of the draft SEIS for license renewal, the NRC*
19 *staff consults with appropriate Federal agencies. The NRC usually contacts directly the*
20 *U.S. Fish and Wildlife Service (Department of the Interior) and the National Marine Fisheries*
21 *Service (Department of Commerce) for environmental issues related to the impact on any*
22 *threatened or endangered species that may be in the vicinity of the plant or to any critical*
23 *habitat. If other agencies have actions or jurisdiction over areas directly related to the review,*
24 *they would also be contacted directly by the NRC.*
25

26 *In addition to NRC coordinated consultation, after a draft SEIS is published, it is also reviewed*
27 *by various Federal agencies at their discretion. For example, at the Federal level, the draft*
28 *SEIS for license renewal are most commonly reviewed by the Environmental Protection Agency*
29 *and the Department of the Interior. The comments from these agencies are considered and*
30 *included in the final SEIS as appropriate.*
31

32 *Potential impacts of renewing the operating licenses for Browns Ferry Nuclear Plant, Units 1, 2,*
33 *and 3 on threatened or endangered species will be evaluated in Chapter 2 and Chapter 4 of the*
34 *SEIS.*
35

36 **A.1.3 Comments Concerning Air Quality Issues** 37

38 **Comment:** We note that Limestone County is not evaluated as having bad air quality and that
39 the annual quantity of emissions released into the atmosphere is normal for a nuclear plant. In
40 an ideal situation it would not be necessary for us to make comment on air quality, however the

Appendix A

1 air quality situation is far from ideal in the Great Smoky Mountains. Because air flows from
2 Alabama frequently move towards our mountains we would like to encourage the exploration of
3 reducing emissions at Browns Ferry. (BF-J-1)
4

5 **Response:** *Air quality impacts from plant operations were evaluated in the GEIS and found to*
6 *be minimal. Air emissions are regulated by the Environmental Protection Agency and the State*
7 *of Alabama. Air quality will be discussed in Chapter 2 of the SEIS.*
8

9 **A.1.4 Comments Concerning Human Health Issues**

10
11 **Comment:** I'm also concerned about the level of radioactive substances that are effluent. If
12 and what they are, and where can we get that information. Is that on the web site of the NRC?
13 Radioactivity that is released into the environment in any way. (BF-F-7)
14

15 **Comment:** Could you specifically address the effluent from Browns Ferry. What do you all
16 actually put into the river, itself? (BF-B-1)
17

18 **Comment:** I want to know whether the Millie is per what or per person. What it meant when
19 you gave that answer, when you said equal to a dose of ... Is that what a person can get by
20 being in the water at the point of the – at the pipes? (BF-D-1)
21

22 **Response:** *NRC is a regulatory agency charged with assuring public health and safety. NRC*
23 *does this by providing the industry with regulations as well as conducting plant inspections.*
24 *The licensee is allowed to release gaseous and liquid effluents to the environment, but the*
25 *releases must be monitored and meet the requirements of 10 CFR Part 20, Appendix B,*
26 *Table 2; therefore, contaminants may be present and detectable offsite. However, the release*
27 *limits have been designed and proven to be protective of the health and safety of the public and*
28 *environment. NRC sets limits on radiological effluents, requires monitoring of effluents and*
29 *foodstuffs to ensure those limits are met, and has set dose limits to regulate the release of*
30 *radioactive material from nuclear power facilities. The regulations are intentionally conservative*
31 *and provide adequate protection for the public including the most radiosensitive members of the*
32 *population. TVA monitors its effluent and calculates an offsite annual dose caused by*
33 *radioactive liquid and gaseous effluents. These calculations are performed to demonstrate the*
34 *licensee's compliance with its technical specifications and NRC regulations.*
35

36 *NRC publishes two annual reports for Browns Ferry regarding environmental monitoring and*
37 *environmental effluents. The "Annual Radiological Environmental Operating Report (AREOR)"*
38 *and the "Annual Radiological Effluent Release (ARER) Report" are available to the public*
39 *through NRC's Public Document Room in Rockville, Maryland, or from NRC's Electronic*
40 *Reading Room available online at <http://www.nrc.gov/reading-rm.html>. The comments did not*
41 *provide new and significant information; therefore, they will not be evaluated further.*

1 **A.1.5 Comments Concerning Cultural Resources**

2
3 **Comment:** According to the information you provided, the EBCI's THPO has determined that
4 the proposed activities will not have an effect on any known cultural resources significant to our
5 Tribe. (BF-K-1)

6
7 **Comment:** We have also determined the undertaking will not have an affect on known cultural
8 resources listed on or eligible for the National Register of Historic Places provided that archaeo-
9 logical site 1Li535 is avoided as stated in the BFN License Renewal Final Supplemental EIS.
10 (BF-K-2)

11
12 **Response:** *The comments refer to historic and archaeological resources near Browns Ferry.*
13 *These issues will be addressed in Chapter 2 and Chapter 4 of the SEIS.*

14 **A.1.6 Comments Concerning Alternative Energy Sources**

15
16
17 **Comment:** In our experience, the relicensing process has generally provided an inadequate
18 analysis of energy alternatives. (BF-L-15)

19
20 **Comment:** In addition, other electricity generating technologies, such as solar, wind, and
21 biomass should be investigated. (BF-L-17)

22
23 **Comment:** The League believes that an emphasis on conserving energy and using
24 energy-efficient technologies is by far the wisest and safest course of action for our nation and
25 state. (BF-N-3)

26
27 **Comment:** The League also believes that predominant reliance should be placed on
28 production of energy from renewable sources. (BF-N-5)

29
30 **Comment:** We have applauded and strongly support the TVA's initiation of a Green Power
31 Switch program whose wind, solar, and methane gas installations now produce electric power
32 for more than seven thousand residential and business users. At this time, however, TVA's
33 generational capacity under this program makes up less than one percent of its capacity from
34 the two, now operating Browns Ferry units. For ecological and other reasons, the strongest
35 market trends in the energy field, around the world favor energy production from renewable
36 sources and weight of public opinion is on the side of expansion of these sources, at least
37 within the Tennessee part of the Agency service area. (BF-N-6)

38
39 **Response:** *The GEIS included an extensive discussion of alternative energy sources.*
40 *Environmental impacts associated with various reasonable alternatives to renewal of the*

Appendix A

1 *operating licenses for Browns Ferry will be discussed in Chapter 8 of the SEIS. The comments*
2 *did not provide new and significant information; therefore, they will not be evaluated further.*
3

4 **Comment:** It should thoroughly assess and clearly delineate (2) the alternative
5 options and their economic, environmental and social benefits and costs. Delineation of
6 alternatives should include optimization of energy efficiency technologies, energy conservation,
7 and Green-Power-Switch program maximization. (BF-N-22)
8

9 **Comment:** It should also include comprehensive assessment and comparison of normal
10 (4) safety-related costs for nuclear plants relative to alternative, renewable-source generation
11 options. (BF-N-24)
12

13 **Comment:** The NRC must review in every respect these safety implications and costs of
14 nuclear-power sources as against the societal and environmental advantages which renewable
15 and substantially risk-free generation sources offer. (BF-N-27)
16

17 **Response:** *NRC determined that an applicant for license renewal need not provide an analysis*
18 *of the economic costs or economic benefits of the proposed or alternative actions. The*
19 *comments did not provide new and significant information; therefore, they will not be evaluated*
20 *further.*
21

22 **A.1.7 Comments Concerning Surface Water Quality, Hydrology and Use**

23

24 **Comment:** I will only focus on the high discharge temperature that will occur when all three
25 units are operating at 3952 Mega-watts Thermal. The existing five cooling towers are unable to
26 cool the water at peak summer conditions without derating an operating unit. (BF-I-1)
27

28 **Comment:** There is no concerted effort to built back cooling tower #4 or build additional
29 cooling towers to allow operation at 100% of Extended Power Uprate (EPU) without derating all
30 three units or having to take one off-line. Studies have been conducted by TVA's Norris labs to
31 validate this assertion. (BF-I-2)
32

33 **Comment:** I believe there is a planned effort to allow Unit 1 to continue in it's effort to restart
34 with paying for the adequate cooling to meet the discharge limits. This is being driven by a
35 fervent desire to hold the restart costs down and not impact schedule dates. (BF-I-3)
36

37 **Response:** *These comments refer to surface water quality issues. These issues will be*
38 *addressed in Chapters 2 and 4 of the SEIS.*
39

1 **Comment:** NRC should evaluate the impacts of extended generation from a regional
2 perspective and should investigate state-level political concerns that may affect that ability to
3 dedicate large water resources for extremely long periods of time. (BF-L-9)
4

5 **Comment:** NRC should require updated water use information for the region on current water
6 needs, as in what industries and municipalities are currently using and are projected to use in
7 the future as population centers continue to grow. (BF-L-12)
8

9 **Comment:** Since construction of the Brown's Ferry plant some four decades ago, Tennessee
10 and the region have experienced enormous growth in population, with corresponding demands
11 on water--our most important and life-necessary natural resource. (BF-N-16)
12

13 **Comment:** Since Unit 1 has not operated since 1985, and all of the reactors came on-line for a
14 time in the mid-to-late 1970s, thorough water withdrawal and water consumption analyses,
15 along with fish and vegetation studies, must be done using updated data (not referring back to
16 original operating license information). (BF-L-10)
17

18 **Comment:** Further, the impact of the water withdrawn and its effect on the flow of the
19 Tennessee River should be evaluated not during just "normal" conditions but in times of
20 drought, which have impacted the region when Browns Ferry Unit 1 was not even operating.
21 (BF-L-11)
22

23 **Comment:** We have strong concerns regarding nuclear power plant impacts on the region's
24 water resources. Reactors like those at Browns Ferry consume through evaporation about
25 20,000 gallons per minute; their flow-through rate exceeds 600,000 gallons per minute and their
26 direct and indirect cost to the water resource exceeds 50 gallons per each kilowatt hour of
27 electricity they generate. (BF-N-14)
28

29 **Comment:** Given their huge withdrawal demands, it is imperative that the NRC consider the
30 water impacts from the Browns Ferry reactors in a comprehensive way and from the
31 perspective of all human and wildlife needs and all competing uses over the longer-term future.
32 (BF-N-17)
33

34 **Comment:** We believe, therefore, that committing to electricity generation such large water
35 withdrawals as are needed for safe operation of the Browns Ferry reactors, for more than three
36 decades hence, may not be wise when generation options which have no or minimal impacts,
37 e.g. from renewable sources, are available. (BF-N-19)
38

39 **Response:** *These comments refer to water use and water use conflicts. These issues will be*
40 *addressed in Chapter 4 of the SEIS.*
41

Appendix A

1 **Comment:** Possible threats to water security in the region under various climate-change
2 scenarios must also be considered in this context. (BF-N-18)

3
4 **Response:** *While climate change is a legitimate concern, the specific impacts of climate
5 change within a particular region or watershed are still highly speculative, and are therefore
6 beyond the scope of a NEPA review for reactor license renewal. Furthermore, any changes in
7 watershed characteristics would likely be gradual, allowing water use conflicts be resolved as
8 needed. The comment did not provide new and significant information; therefore, will not be
9 evaluated further.*

10 11 **A.1.8 Comments Concerning Postulated Accidents**

12
13 **Comment:** Directly relevant to Browns Ferry Unit 1 concerns about restart and the subsequent
14 operating extension are the accident projections from the Brookhaven National Laboratory
15 Study in 1997 for a closed BWR for an area within 50 miles of the plant: population dose of 38
16 million rem, 15, 300 latent fatalities, 140 square miles of condemned land, and a cost of \$48
17 billion (NUREG/CR-6451, April 1997). (BF-L-4)

18
19 **Comment:** I believe that the people of the Tennessee Valley may be in real danger from a
20 major nuclear accident if these concerns prove to be accurate. (BF-A-4)

21
22 **Response:** *The effects of accidents are considered in both environmental and safety reviews
23 for license renewal. Postulated accidents, including design basis and severe accidents, will be
24 addressed in Section 5.0 and Appendix G of the SEIS.*

25 26 **A.1.9 Comments Concerning Uranium Fuel Cycle**

27
28 **Comment:** Further, spent fuel casks, both for onsite storage and for transportation, have not
29 undergone adequate testing to demonstrate thorough safety and containment of radiation, both
30 during normal usage and during various accident scenarios. (BF-L-22)

31
32 **Comment:** Again, the industry's inclination to take every opportunity to cut costs (in attempting
33 to make nuclear energy appear remotely viable, economically) creates a disturbing tension
34 here, with nuclear utilities gravitating towards the casks that are cheapest and the least tested.
35 (BF-L-23)

36
37 **Response:** *NRC is committed to preventing detrimental health impacts to the public. NRC has
38 regulations covering the long-term storage of spent fuel onsite as well as packaging and
39 transport of radioactive material. These regulations regarding packaging and transport of
40 radioactive material are found at 10 CFR Part 71. NRC regulations related to exposure to the*

1 *public are found at 10 CFR Part 20. In addition, the Department of Transportation and the*
2 *Environmental Protection Agency have regulations to protect the public from health effects*
3 *associated with radiation. Department of Transportation regulations related to transportation of*
4 *radioactive material are found at 49 CFR Part 173, and Environmental Protection Agency*
5 *regulations related to radiation are found at 40 CFR Parts 190 through 194.*

6
7 *The safety and environmental effects of long-term storage of spent fuel onsite has been*
8 *evaluated by NRC, and as set forth in the Waste Confidence Rule, the NRC has generically*
9 *determined that such storage can be accomplished without significant environmental impact. In*
10 *the Waste Confidence Rule, the Commission determined that spent fuel can be safely stored*
11 *onsite for at least 30 years beyond the licensed operating life, which may include the term of a*
12 *renewed license. NRC has a certification process for casks, regulated by 10 CFR Part 72.*
13 *Such wastes are under continual licensing control. The comments did not provide new and*
14 *significant information; therefore, they will not be evaluated further.*

15
16 **Part II. Comments Received on the Draft SEIS**
17

Appendix B

Contributors to the Supplement

Appendix B

Contributors to the Supplement

The overall responsibility for the preparation of this supplement was assigned to the Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission (NRC). The statement was prepared by members of the Office of Nuclear Reactor Regulation with assistance from other NRC organizations, Pacific Northwest National Laboratory, Argonne National Laboratory, and Los Alamos National Laboratory.

Name	Affiliation	Function or Expertise
NUCLEAR REGULATORY COMMISSION		
Michael T. Masnik	Nuclear Reactor Regulation	Sr. Project Manager, Ecology
Robert G. Schaaf	Nuclear Reactor Regulation	Project Manager
Tomeka Terry	Nuclear Reactor Regulation	Civil Engineer
Barry Zalzman	Nuclear Reactor Regulation	Technical Monitor
Jennifer A. Davis	Nuclear Reactor Regulation	Historic and Archaeological Resources
Robert Palla	Nuclear Reactor Regulation	Severe Accident Mitigation Alternatives
James Wilson	Nuclear Reactor Regulation	Ecology, Water Use
Andrew J. Kugler	Nuclear Reactor Regulation	Section Chief
Richard L. Emch	Nuclear Reactor Regulation	Radiation Protection
Alicia R. Williamson	Nuclear Reactor Regulation	Environmental Scientist
PACIFIC NORTHWEST NATIONAL LABORATORY^(a)		
Michael R. Sackschewsky		Task Leader
J. Amanda Stegen		Deputy Task Leader
William F. Sandusky		Air Quality, Noise, Electromagnetic Fields
Katherine A. Cort		Socioeconomics, Environmental Justice
Kathleen Rhoads		Decommissioning, Radiation Protection
Stuart B. Saslow		Water Use and Hydrology
Tara O. Eschbach		Historic and Archaeological Resources
Paul L. Hendrickson		Land Use, Alternatives
Cary A. Counts		Technical Editor
Debra A. Schulz		Document Design
Trina I. Russell		Document Design
Jean M. Cheyney		Document Design
Barbara Wilson		Publications Assistant
ARGONNE NATIONAL LABORATORY^(b)		
William Vinikour		Aquatic Ecology
LOS ALAMOS NATIONAL LABORATORY^(c)		
Sam Loftin		Terrestrial Ecology
INFORMATION SYSTEMS LABORATORY		
Bob Schmidt		Severe Accident Mitigation Alternatives
Kimberly Green		Severe Accident Mitigation Alternatives
(a) Pacific Northwest National Laboratory is operated for the U.S. Department of Energy by Battelle Memorial Institute. (b) Argonne National Laboratory is operated for the U.S. Department of Energy by the University of Chicago. (c) Los Alamos National Laboratory is operated for the U.S. Department of Energy by the University of California.		

Appendix C

Chronology of NRC Staff Environmental Review Correspondence Related to the Tennessee Valley Authority Application for License Renewal of Browns Ferry Nuclear Power Plant, Units 1, 2, and 3

Appendix C

Chronology of NRC Staff Environmental Review Correspondence Related to the Tennessee Valley Authority Application for License Renewal of Browns Ferry Nuclear Power Plant, Units 1, 2, and 3

1 This appendix contains a chronological listing of correspondence between the U.S. Nuclear
2 Regulatory Commission (NRC) and the Tennessee Valley Authority (TVA) and other
3 correspondence related to the NRC staff's environmental review, under 10 CFR Part 51, of
4 TVA's application for renewal of the operating licenses for Browns Ferry Nuclear Power Plants,
5 Units 1, 2, and 3 (BNF). All documents, with the exception of those containing proprietary
6 information, have been placed in the Commission's Public Document Room, at One White Flint
7 North, 11555 Rockville Pike (first floor), Rockville, Maryland, and are available electronically
8 from the Public Electronic Reading Room found on the Internet at the following web address:
9 <http://www.nrc.gov/reading-rm.html>. From this site, the public can gain access to the NRC's
10 Agencywide Document Access and Management System (ADAMS), which provides text and
11 image files of NRC's public documents in the Publicly Available Records (PARS) component of
12 ADAMS. The ADAMS accession number for each document is included below.

13
14 December 31, 2003 Letter from TVA to NRC, BFN, Docket No. 50-259, 50-260, and
15 50-296, Application for Renewed Operating Licenses
16 (Accession No. ML040060355).
17
18 January 7, 2004 Letter from NRC to Mr. J.A. Scalice, TVA, Receipt and Availability of
19 the License Renewal Application for BFN
20 (Accession No. ML040090370).
21
22 January 8, 2004 NRC press release announcing the availability of license renewal
23 application for BFN (Accession No. ML040080693).
24
25 February 27, 2004 Letter from NRC to Mr. R. Crabtree, National Marine Fisheries
26 Service (NOAA Fisheries), Request for List of Protected Species
27 Within the Area Under Evaluation for the BFN License Renewal
28 (Accession No. ML040610754).
29

Appendix C

1	March 4, 2004	Letter from NRC to Mr. J.A. Scalice, TVA, transmitting Determination of Acceptability and Sufficiency for Docketing, Proposed Review Schedule, and Opportunity for a Hearing Regarding the Application from Tennessee Valley Authority for Renewal of the Operating Licenses for BFN (Accession No. ML040650206).
2		
3		
4		
5		
6		
7	March 4, 2004	Letter from NRC to Mr. J.A. Scalice, TVA, Notice of Intent to Prepare an Environmental Impact Statement and Conduct Scoping Process for License Renewal for the BFN (Accession No. ML040640755).
8		
9		
10		
11	March 5, 2004	Letter from NRC to Mr. L. Goldman, U.S. Fish and Wildlife Service (FWS), Request for List of Protected Species Within the Area Under Evaluation for the BFN License Renewal (Accession No. ML040680881).
12		
13		
14		
15		
16	March 8, 2004	Letter from NRC to Dr. L. Warner, State Historic Preservation Office, BFN Operating License Renewal (Accession No. ML040700557).
17		
18		
19	March 10, 2004	NRC press release announcing for hearing on application for license renewal of BFN (Accession No. ML040700395).
20		
21		
22	March 11, 2004	Letter from D. Bernhart, NOAA Fisheries, to NRC Protected Species List Request, Proposed Renewal of Operating Licenses for BFN, Limestone County, Alabama (Accession No. ML041330242).
23		
24		
25		
26	March 17, 2004	Notice of Public Meeting to Discuss Environmental Scoping Process for the BFN License Renewal Application (Accession No. ML040770966).
27		
28		
29		
30	March 23, 2004	Letter from NRC to the Honorable C. Smith, Principal Chief, Cherokee Nation of Oklahoma, Request for Comments Concerning BFN Operating License Renewal (Accession No. ML040890750).
31		
32		
33		
34	March 23, 2004	Letter from NRC to the Honorable K. Chambers, Principal Chief, Seminole Nation of Oklahoma, Request for Comments Concerning BFN Operating License Renewal (Accession No. ML040890884).
35		
36		
37		
38	March 23, 2004	Letter from NRC to the Honorable B. Anoatubby, Governor, Chickasaw Nation, Request for Comments Concerning BFN Operating License Renewal (Accession No. ML040890969).
39		
40		
41		

1 March 23, 2004 Letter from NRC to the Honorable R.P. Beaver, Principal Chief,
2 Muscogee (Creek) Nation, Request for Comments Concerning BFN
3 Operating License Renewal (Accession No. ML040890973).
4
5 March 23, 2004 Letter from NRC to the Honorable M. Hicks, Principal Chief, Eastern
6 Band of Cherokee Indians, Request for Comments Concerning BFN
7 Operating License Renewal (Accession No. ML040890980).
8
9 March 23, 2004 Letter from NRC to the Honorable L. Poncho, Chairman, Coushatta
10 Indians, Request for Comments Concerning BFN Operating License
11 Renewal (Accession No. ML040860795).
12
13 March 23, 2004 Letter from NRC to the Honorable C. Enyart, Chief, Eastern Shawnee
14 Tribe of Oklahoma, Request for Comments Concerning BFN
15 Operating License Renewal (Accession No. ML040860780).
16
17 March 23, 2004 Letter from NRC to the Honorable C. Norris, Chief, Jena Band of
18 Choctaw Indians, Request for Comments Concerning BFN Operating
19 License Renewal (Accession No. ML040860586).
20
21 March 23, 2004 Letter from NRC to the Honorable P. Martin, Chief, Mississippi Band
22 of Choctaw Indians, Request for Comments Concerning BFN
23 Operating License Renewal (Accession No. ML040890862).
24
25 March 23, 2004 Letter from NRC to the Honorable B.K. McGertt, Town King,
26 Thlopthlocco Tribal Town, Request for Comments Concerning BFN
27 Operating License Renewal (Accession No. ML040860319).
28
29 March 23, 2004 Letter from NRC to the Honorable T. Yargee, Chief, Alabama-
30 Quassarte Tribal Town, Request for Comments Concerning BFN
31 Operating License Renewal (Accession No. ML040890959).
32
33 March 23, 2004 Letter from NRC to the Honorable L. Wesley, Towns King, Kialagee
34 Tribal Towns, Request for Comments Concerning BFN Operating
35 License Renewal (Accession No. ML040860311).
36
37 March 23, 2004 Letter from NRC to the Honorable G.E. Pyle, Chief, Choctaw Nation
38 of Oklahoma, Request for Comments Concerning BFN Operating
39 License Renewal (Accession No. ML040860339).
40
41 March 23, 2004 Letter from NRC to the Honorable D. Proctor, Chief, United
42 Keetoowah band of Cherokee Indians, Request for Comments
43 Concerning BFN Operating License Renewal
44 (Accession No. ML040890841).

Appendix C

1	March 23, 2004	Letter from NRC to the Honorable M. Cypress, Chairman, Seminole Indian Tribe, Request for Comments Concerning BFN Operating License Renewal (Accession No. ML040890689).
2		
3		
4		
5	March 23, 2004	Letter from NRC to the Honorable K. Battiste, Chairman, Alabama-Coushatta Tribe of Texas, Request for Comments Concerning BFN Operating License Renewal (Accession No. ML040890931).
6		
7		
8		
9	March 23, 2004	Letter from NRC to Mr. E. Barbry Jr., Director, Tunica-Biloxi Tribe, Request for Comments Concerning BFN Operating License Renewal (Accession No. ML040860762).
10		
11		
12		
13	March 23, 2004	Letter from NRC to Ms. J. Makaseah, Cultural/Historic Preservation Department, Absentee-Shawnee Executive Committee, Request for Comments Concerning BFN Operating License Renewal (Accession No. ML040860705).
14		
15		
16		
17		
18	March 23, 2004	Letter from NRC to Mr. R. Thrower, Tribal Historic Preservation Office, Poarch Creek Indians, Request for Comments Concerning BFN Operating License Renewal (Accession No. ML040860251).
19		
20		
21		
22	March 23, 2004	Letter from NRC to the Honorable B. Cypress, Chairman, Miccosukee Indians Tribe, Request for Comments Concerning BFN Operating License Renewal (Accession No. ML040860239).
23		
24		
25		
26	March 31, 2004	Letter from NRC to Mr. J.A. Scalice, TVA, Review Schedule for Application for Renewal of the Operating Licenses for the Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 (TAC Nos. MC1704, MC1705, and MC1706). (Accession No. ML040910016).
27		
28		
29		
30		
31	April 28, 2004	Letter from NRC to Mr. J.A. Scalice, TVA, Request for Additional Information Regarding Severe Accident Mitigation Alternatives (SAMAs) for the BFN, License Renewal Application (Accession No. ML041200517).
32		
33		
34		
35		
36	May 14, 2004	Summary of Scoping Meetings to Support Review of the BFN, License Renewal Application (Accession No. ML041390581).
37		
38		
39		
40		

1 May 19, 2004 Letter from Mr. L. Goldman, FWS, Daphne, Alabama, to NRC,
2 providing an updated list of protected species within the area under
3 evaluation for the BFN License Renewal
4 (Accession No. ML041550148).
5
6 May 20, 2004 Letter from NRC to Mr. J.A. Scalice, TVA, Notice of Extension of the
7 Comment period on the Environmental Scope of the Plant-Specific
8 Supplement to the Generic Environmental Impact Statement (GEIS)
9 Regarding License Renewal for BFN (Accession No. ML041450255).
10
11
12 May 27, 2004 Letter from Mr. M.J. Burzynski, TVA to NRC, Browns Ferry Nuclear
13 Plant (BFN) - Units 1,2, and 3 - March 30-31, 2004 Meeting Follow-
14 Up - Additional Information for License Renewal Environmental
15 Review (Accession No. ML041530161).
16
17 June 25, 2004 Letter from TVA to NRC, Browns Ferry Nuclear Plant (BFN), Units 2
18 and 3, Change Technical Specifications (TS) for TS-418, Request for
19 License Amendment, Extended Power Uprate (EPU) Operation
20 (Accession No. ML041840301).
21
22 June 28, 2004 Letter from TVA to NRC, Browns Ferry Nuclear Plant (BFN), Unit 1,
23 Proposed Change for TS-431, Request for License Amendment, EPU
24 Operation (Accession No. ML042800186).
25
26 July 7, 2004 Letter from TVA to NRC, Response to Request for Additional
27 Information Regarding SAMAs to support the Review of the Browns
28 Ferry Nuclear Power Plant, Units 1, 2, and 3, License Renewal
29 Application (Accession No. ML041910423).
30
31 July 15, 2004 Letter from NRC to Karl W. Singer, TVA, Issuance of Environmental
32 Scoping Summary Report Associated with the Staff's Review of the
33 Application by Tennessee Valley Authority for Renewal of the
34 Operating Licenses for Browns Ferry Nuclear Power Plant, Units 1, 2,
35 and 3 (TAC Nos. MC1768, MC1769, and MC1770)
36 (Accession No. ML041970726).
37
38 August 20, 2004 Letter from NRC to TVA, Request for Additional Clarification
39 Regarding Severe Accident Mitigation Alternatives for the Browns
40 Ferry Nuclear Plant, Units 1, 2, and 3 (TAC Nos. MC1768, MC1769,
41 and MC1770) (Accession No. ML042330233).
42

Appendix C

1	September 15, 2004	Letter from NRC to TVA, Summary of Telecommunication with TVA to
2		discuss follow-on Severe Accident Mitigation Analysis (SAMA)
3		Requests for Additional Information, (RAI)
4		(Accession No. ML042590186).
5		
6	September 30, 2004	Letter from TVA to NRC, Response to Request for Additional
7		Information (RAI) Regarding Severe Accident Mitigation Alternatives
8		for Browns Ferry Nuclear Plant (BFN) Units 1, 2, and 3 (Accession
9		No. ML043860076)
10		
11	October 20, 2004	E-mail from C. A. McCullough, TVA to R. Palla, NRC, Response to
12		Request for Additional Information Concerning BFN, LR, SAMA,
13		RAI-II, Number of Plant Damage States (Accession
14		No. ML043010285)
15		
16	October 25, 2004	Letter from NRC to L. Goldman, FWS, Biological Assessment for
17		License Renewal of the Browns Ferry Nuclear Power Plant, and a
18		Request for Informal Consultation (Accession No. ML042990342)

Appendix D

Organizations Contacted

Appendix D

Organizations Contacted

1 During the course of the staff's independent review of environmental impacts from operations
2 during the renewal term, the following Federal, State, regional, local, and Native American tribal
3 agencies were contacted:

4
5 Absentee-Shawnee Executive Committee, Shawnee, Oklahoma

6
7 Advisory Council on Historic Preservation, Washington D.C.

8
9 Alabama-Coushatta Tribe of Texas, Livingston, Texas

10
11 Alabama Department of Conservation, Montgomery, Alabama

12
13 Alabama Department of Environmental Quality, Decatur, Alabama

14
15 Alabama Department of Environmental Quality, Water Division, Montgomery, Alabama

16
17 Alabama Department of Transportation, Montgomery, Alabama

18
19 Alabama Economic and Community Development, Office of Water Resources,
20 Montgomery, Alabama

21
22 Alabama Historical Commission, Montgomery, Alabama

23
24 Alabama-Quassarte Tribal Town, Wetumka, Oklahoma

25
26 Century 21 Realtors, Athens, Alabama

27
28 Cherokee Nation of Oklahoma, Tahlequah, Oklahoma

29
30 Chickasaw Nation, Ada, Oklahoma

31
32 Choctaw Nation of Oklahoma, Durant, Oklahoma

33
34 City of Athens Chamber of Commerce, Athens, Alabama

35
36 City Clerk, Athens, Alabama

37
38 Community Development Department, Decatur, Alabama

Appendix D

- 1 Coushatta Indian Tribe, Elton, Louisiana
- 2
- 3 Eastern Band of Cherokee Indians, Cherokee, North Carolina
- 4
- 5 Eastern Shawnee Tribe of Oklahoma, Seneca, Missouri
- 6
- 7 Jena Band of Choctaw Indians, Jena, Louisiana
- 8
- 9 Kialegee Tribal Town, Wetumka, Oklahoma
- 10
- 11 Limestone County Administrators, Athens, Alabama
- 12
- 13 Miccosukee Indian Tribe, Miami, Florida
- 14
- 15 Mississippi Band of Choctaw Indians, Philadelphia, Mississippi
- 16
- 17 Morgan County Commissioners Office, Decatur, Alabama
- 18
- 19 Muscogee (Creek) Nation, Okmulgee, Oklahoma
- 20
- 21 National Oceanic and Atmospheric Administration, St. Petersburg, Florida
- 22
- 23 Poarch Creek Indians, Atmore, Alabama
- 24
- 25 Seminole Indian Tribe, Hollywood, Florida
- 26
- 27 Seminole Nation of Oklahoma, Wewoka, Oklahoma
- 28
- 29 Thlopthlocco Tribal Town, Okemah, Oklahoma
- 30
- 31 Tribal Historic Preservation Office, Atmore, Alabama
- 32
- 33 Tunica-Biloxi Tribe, Office of Cultural and Historic Preservation Department, Marksville,
34 Louisiana
- 35
- 36 USDA Forest Service, Bankhead National Forest, Double Springs, Alabama
- 37
- 38 USDA Forest Service, Southern Region, Pineville, Louisiana
- 39
- 40 U.S. Bureau of Indian Affairs, Washington, D.C.
- 41

- 1 U.S. Fish and Wildlife Service, Daphne, Alabama
- 2
- 3 United Keetoowah Band of Cherokee Indians, Tahlequah, Oklahoma

Appendix E

**Browns Ferry Nuclear Power Plant, Units 1, 2, and 3
Compliance Status and Consultation Correspondence**

Appendix E

Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 Compliance Status and Consultation Correspondence

1 Licenses, permits, consultations, and other approvals obtained from Federal, State, regional,
2 and local authorities for Browns Ferry Nuclear Plant, Units 1, 2, and 3 (BFN) are identified in
3 this appendix.

4
5 Correspondence received during the evaluation process of the application for renewal of the
6 operating license for BFN is identified in Table E-1. Copies of the correspondence are included
7 at the end of this appendix.

8
9 The licenses, permits, consultations, and other approvals obtained from Federal, State,
10 regional, and local authorities for BFN are listed in Table E-2.

11
12 **Table E-1. Consultation Correspondence Regarding License Renewal for Browns Ferry**
13 **Nuclear Power Plant, Units 1, 2, and 3**

14	15	16	17
	Source	Recipient	Date of Letter
16	U.S. Nuclear Regulatory	National Oceanic and Atmospheric	February 27, 2004
17	Commission (P.T. Kuo)	Administration Fisheries (Dr. R. Crabtree)	(Accession No. ML04610754)
18	U.S. Nuclear Regulatory	U.S. Fish and Wildlife Service	March 5, 2004
19	Commission (P.T. Kuo)	(Mr. L. Goldman)	(Accession No. ML040680881)
20	U.S. Nuclear Regulatory	Alabama Historical Commission	March 8, 2004
21	Commission (P.T. Kuo)	(Dr. L. Warner)	(Accession No. ML0040700557)
22	National Oceanic Atmospheric	U.S. Nuclear Regulatory	March 11, 2004
23	Administration Fisheries	Commission	(Accession No. ML0411330242)
24	(D. Bernhart)		
25	U.S. Nuclear Regulatory	Cherokee Nation of Oklahoma	March 23, 2004
26	Commission (P.T. Kuo)	(The Honorable C. Smith)	(Accession No. ML040890750)
27	U.S. Fish and Wildlife Service	U.S. Nuclear Regulatory	May 19, 2004
28	(L. Goldman)	Commission (Dr. M. Masnik)	(Accession No. ML041550148)
29	U.S. Nuclear Regulatory	U.S. Fish and Wildlife Service	October 25, 2004
30	Commission (P.T. Kuo)	(Mr. L. Goldman)	(Accession No. ML042990342)
31			

Table E-2. Federal, State, and Local Licenses, Permits, Consultations, and Other Approvals for the Browns Ferry Nuclear Power Plant, Units 1, 2, and 3

Agency	Authority	Description	Number	Issue Date	Expiration Date	Remarks
NRC	Atomic Energy Act, 10 CFR Part 50	Operating License for Unit 1	Docket Number: 05000259	12/20/1973	12/20/2013	License authorizes operation of Unit 1.
NRC	Atomic Energy Act, 10 CFR Part 50	Operating License for Unit 2	Docket Number: 05000260	08/02/1974	06/28/2014	License authorizes operation of Unit 2.
NRC	Atomic Energy Act, 10 CFR Part 50	Operating License for Unit 3	Docket Number: 05000298	08/18/1976	07/02/2016	License authorizes operation of Unit 3.
ADEM	Clean Water Act, Alabama Water Pollution Control Act	NPDES Permit	AL0022080	12/29/2000	01/31/2006	Permit authorizes effluent discharges to the Tennessee River.
ADEM	Clean Air Act, Alabama Air Pollution Control Act	Air emission permits	708-0003-2002; 708-0003-2003	10/5/1978; 08/28/1995	None	Permits cover operation of auxiliary boilers, emergency diesel generators, and gasoline dispensing facility.
ADEM	Alabama Solid Wastes Disposal Act	Construction/ Demolition landfill permit	42-02	05/17/2000	05/16/2005	Permit allows disposition of nonhazardous, nonradioactive wastes in the onsite landfill.
FWS	Section 7 of the Endangered Species Act (16 USC 1536)	Consultation	N/A			Section 7 of the Endangered Species Act requires that Federal agencies, in cooperation with the license applicant, consult with the FWS and/or the NOAA fisheries concerning the potential impacts of a proposed licensing action on threatened or endangered species. Correspondence with FWS related to Section 7 is included in Appendix E.

November 2004

E-2

Draft NUREG-1437, Supplement 21

1
2
3
4
5
6
7
8
9
10
11
12

Table E-2. (contd)

Agency	Authority	Description	Number	Issue Date	Expiration Date	Remarks
Alabama Department of Economic and Community Affairs, Office of Water Resources		Water withdrawal permit	Certificate of Use No. OWR - 1058	01/1/2001	01/1/2006	Permit specifies the maximum capacity of water withdrawn, diverted, or consumed and average daily use.
Alabama Historical Commission	Section 106 of the National Historic Preservation Act (16 USC 470f)	Consultation	Letters from E.A. Brown, Deputy State Historic Preservation Officer, to TVA, dated 01/8/2001 and 05/24/2001			The National Historic Preservation Act requires Federal agencies to take into account the effect of any undertaking on any district, site, building, structure, or object that is included in or eligible for inclusion in the National Register of Historic Places. The Alabama Historical Commission determined that activities related to license renewal will have no effect on significant cultural resources provided that archaeological site 1LI535 and the Cox cemetery are avoided. Correspondence is included in Appendix E.

ADEM	=	Alabama Department of Environmental Management
CFR	=	Code of Federal Regulations
FWS	=	Fish and Wildlife Service
NOAA	=	National Oceanic and Atmospheric Administration
NPDES	=	National Pollutant Discharge Elimination System
NRC	=	Nuclear Regulatory Commission
USC	=	United States Code

November 2004

E-3

Draft NUREG-1437, Supplement 21

Appendix E

February 27, 2004

Dr. Roy Crabtree
Regional Administrator
NOAA Fisheries
Southeast Regional Office
9721 Executive Center Drive North
St. Petersburg, FL 33702

**SUBJECT: REQUEST FOR A LIST OF PROTECTED SPECIES WITHIN THE AREA
UNDER EVALUATION FOR THE BROWNS FERRY NUCLEAR PLANT
LICENSE RENEWAL**

Dear Dr. Crabtree:

The U.S. Nuclear Regulatory Commission (NRC) is reviewing an application submitted by the Tennessee Valley Authority (TVA) for the renewal of the operating licenses for Browns Ferry Nuclear Plant Units 1, 2, and 3 (BFN). BFN is located in Limestone County, Alabama, 16 km (10 mi) southwest of Athens, Alabama. As part of the review of the license renewal application, the NRC is preparing a Supplemental Environmental Impact Statement (SEIS) under the provision of the National Environmental Policy Act (NEPA) of 1969, as amended, which includes an analysis of pertinent environmental issues, including endangered or threatened species and impacts to fish and wildlife. This letter is being submitted under the provisions of the Endangered Species Act of 1973, as amended, and the Fish and Wildlife Coordination Act of 1934, as amended.

The proposed action would include the use and continued maintenance of existing plant facilities and transmission lines and would not result in significant new construction or disturbance. Any maintenance activities would be limited to previously disturbed areas. For the specific purpose of connecting BFN to the regional transmission system, there are seven 500-kilovolt (kV) lines and two 161-kV lines. These transmission line corridors are being evaluated as part of the SEIS process. The transmission line corridors traverse Limestone, Morgan, Lawrence, Franklin, and Colbert counties in Alabama; and Union, Lee, Tishomingo, and Itawamba counties in Mississippi. The site boundary and transmission lines are identified in Enclosures 1 and 2. The site boundary and transmission line corridors can also be viewed at <http://www.nrc.gov/reactors/operating/licensing/renewal/applications/browns-ferry/env-bfn-2.pdf> the NRC's web site on pages E-70 and E-388, respectively.

The plant uses an open-cycle cooling system to dissipate waste heat to the environment. Cooling water is drawn from Wheeler Reservoir on the Tennessee River into the turbine-generator condensers and discharging it back to the reservoir via large submerged diffuser pipes that are perforated to maximize uniform mixing into the flowstream. Mechanical draft helper cooling towers are also used in the summer to reduce the heat load to the reservoir.

To support the environmental impact statement preparation process and to ensure compliance with Section 7 of the Endangered Species Act, the NRC requests a list of species and information on protected, proposed, and candidate species and critical habitat that may be in

1

Dr. R. Crabtree

-2-

the vicinity of BFN and its associated transmission lines. The NRC has requested the same information and list of species from the U.S. Fish and Wildlife Service.

On March 30-31, 2004, the NRC plans to conduct a site audit at the BFN site. In addition, we plan to hold two public NEPA scoping meetings on April 1, 2004, at the Athens State University Student Center Cafeteria Ballroom, 300 Beatty Street, Athens, Alabama 35611-1999. Your staff is invited to attend both the site audit and the public meetings. Additional information on these activities will be forwarded to Mr. David Bernhart of your staff. The NRC staff will also forward to your office a copy of the draft SEIS along with a request for comments.

If you have any questions concerning BFN, the license renewal application, or other aspects of this project, please contact Dr. Michael Masnik, Senior Environmental Project Manager, at (301) 415-1191 or by e-mail at mtm2@nrc.gov.

Sincerely,

/RA/

Pao-Tsin Kuo, Program Director
License Renewal and Environmental Impacts
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Docket Nos.: 50-259, 50-260, and 50-296

March 5, 2004

Mr. Larry Goldman
Field Supervisor
U.S. Fish and Wildlife Service
Daphne Field Office
P.O. Drawer 1190
Daphne, AL 36526

**SUBJECT: REQUESTS FOR A LIST OF PROTECTED SPECIES WITHIN THE AREA
UNDER EVALUATION FOR THE BROWNS FERRY NUCLEAR PLANT
LICENSE RENEWAL**

Dear Mr. Goldman:

The U.S. Nuclear Regulatory Commission (NRC) is reviewing an application submitted by the Tennessee Valley Authority (TVA) for the renewal of the operating licenses for Browns Ferry Nuclear Plant Units 1, 2, and 3 (BFN). BFN is located in Limestone County, Alabama, 16 km (10 mi) southwest of Athens, Alabama. As part of the review of the license renewal application, the NRC is preparing a Supplemental Environmental Impact Statement (SEIS) under the provision of the National Environmental Policy Act (NEPA) of 1969, as amended, which includes an analysis of pertinent environmental issues, including endangered or threatened species and impacts to fish and wildlife. This letter is being submitted under the provisions of the Endangered Species Act of 1973, as amended, and the Fish and Wildlife Coordination Act of 1934, as amended.

The proposed action would include the use and continued maintenance of existing plant facilities and transmission lines and would not result in significant new construction or disturbance. For the specific purpose of connecting BFN to the regional transmission system, there are seven 500-kilovolt (kV) lines and two 161-kV lines. These transmission line corridors are being evaluated as part of the SEIS process. The transmission line corridors traverse Limestone, Morgan, Lawrence, Franklin, and Colbert counties in Alabama; and Union, Lee, Tishomingo, and Itawamba counties in Mississippi. The site boundary and transmission lines are identified in Enclosures 1 and 2. The site boundary and transmission line corridors can also be viewed at <http://www.nrc.gov/reactors/operating/licensing/renewal/applications/browns-ferry/env-bfn-2.pdf> the NRC's website at on pages E-70 and E-388, respectively.

The plant uses an open-cycle cooling system to dissipate waste heat to the environment. Cooling water is drawn from Wheeler Reservoir on the Tennessee River into the turbine-generator condensers and discharging it back to the reservoir via large submerged diffuser pipes that are perforated to maximize uniform mixing into the flow-stream. Mechanical draft helper cooling towers are also used in the summer to reduce the heat load to the reservoir.

To support the environmental impact statement preparation process and to ensure compliance with Section 7 of the Endangered Species Act, the NRC requests a list of species and information on protected, proposed, and candidate species and critical habitat that may be in

1
L. Goldman

-2-

the vicinity of BFN and its associated transmission lines. The NRC has requested the same information and list of species from NOAA Fisheries. In addition, please provide any information you consider appropriate under the provisions of the Fish and Wildlife Coordination Act.

On March 30-31, 2004, we plan to conduct a site audit at the BFN site. We plan to hold two public NEPA scoping meetings on April 1, 2004, at the Athens State University Student Center Cafeteria Ballroom, 300 North Beaty Street, Athens, Alabama 35611-1999. You and your staff are invited to attend both the site audit and the public meetings. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is November 2004.

If you have any questions concerning BFN, the license renewal application, or other aspects of this project, please contact Dr. Michael Masnik, Senior Environmental Project Manager, at (301) 415-1191 or by e-mail at mtm2@nrc.gov.

Sincerely,

/RA/

Pao-Tsin Kuo, Program Director
License Renewal and Environmental Impacts
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Docket Nos.: 50-259, 50-260, and 50-296

March 8, 2004

Dr. Lee Warner
State Historic Preservation Officer
Alabama Historical Commission
468 South Perry Street
Montgomery, AL 36130-0900

SUBJECT: BROWNS FERRY NUCLEAR PLANT LICENSE RENEWAL REVIEW

Dear Dr. Warner:

The U.S. Nuclear Regulatory Commission (NRC) staff is reviewing an application to renew the operating licenses for Browns Ferry Nuclear Plant, Units 1, 2, and 3 (BFN), which is located in Limestone County, Alabama, 16 km (10 mi) southwest of Athens, Alabama. BFN is operated by the Tennessee Valley Authority (TVA). The site boundary is shown on the NRC's web site at <http://www.nrc.gov/reactors/operating/licensing/renewal/applications/browns-ferry/env-bfn-2.pdf> on page E-70. The application for renewal was submitted by TVA on January 6, 2004, pursuant to NRC requirements at Title 10 of the *Code of Federal Regulations Part 54* (10 CFR Part 54). The NRC has established that, as part of the staff review of any nuclear power plant license renewal action, a site-specific Supplemental Environmental Impact Statement (SEIS) to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (GEIS), NUREG-1437, will be prepared under the provisions of 10 CFR Part 51, which implements the National Environmental Policy Act of 1969 (NEPA). In accordance with 36 CFR 800.8, the SEIS will include analyses of potential impacts to historic and cultural resources. A draft SEIS is scheduled for publication in November of 2004, and will be provided to you for review and comment.

In the context of the National Historic Preservation Act of 1966, as amended, the NRC staff has determined that the area of potential effect (APE) for a license renewal action is the area at the power plant site and its immediate environs which may be impacted by post-license renewal land disturbing operation or projected refurbishment activities associated with the proposed action. The APE may extend beyond the immediate environs in those instances where post-license renewal land disturbing operations or projected refurbishment activities, specifically related to license renewal, may potentially have an effect on known or proposed historic sites located beyond the immediate environs of the proposed site. This determination is made irrespective of ownership or control of the lands of interest.

We understand that in a letter dated January 8, 2001, after reviewing the TVA issued Draft Environmental Impact Statement for Operating License Renewal of the Browns Ferry Nuclear Plant, you concluded that license renewal activities will have no effect on significant cultural resources, provided that site 1Li535 and the Cox Cemetery are avoided. The Alabama Historical Commission tracking number for this action is 2001-1439.

Dr. L. Warner

-2-

On April 1, 2004, the NRC will conduct two public NEPA scoping meetings at the Athens State University Student Center Cafeteria Ballroom, 300 North Beaty Street, Athens, Alabama 35611-1999. You and your staff are invited to attend. Your office will receive a copy of the draft SEIS for review and comment. If you have any questions or require additional information, please contact the Senior Environmental Project Manager for the BFN project, Dr. Michael Masnik, at 301-415-1191 or mtm2@nrc.gov.

Sincerely,

/RA/

Pao-Tsin Kuo, Program Director
License Renewal and Environmental Impacts
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Docket Nos.: 50-259, 50-260, and 50-296



UNITED STATES DEPARTMENT OF COMMERCE
National Oceanic and Atmospheric Administration
NATIONAL MARINE FISHERIES SERVICE
Southeast Regional Office
9721 Executive Center Drive North
St. Petersburg, FL 33702
(727) 570-5312, FAX 570-5517
<http://caldera.sero.nmfs.gov>

Dear Colleague:

MAR 11 2004

The National Marine Fisheries Service (NOAA Fisheries) Protected Resources Division has reviewed your letter pursuant to section 7(a)(2) of the Endangered Species Act (ESA) concerning WHA dated 2/27/04; The NRC is reviewing an application submitted by the Tennessee Valley Authority (TVA) for renewal of the operating licenses for Browns Ferry Nuclear Plants Units 1, 2, 3 (BFW).

We cannot determine impacts to threatened or endangered species, or designated critical habitat, under NOAA Fisheries' purview because the letter lacks sufficient information to evaluate the project. Enclosed are guidelines to conduct a proper biological evaluation.

✓ As requested, enclosed is a list of federally-protected species under the jurisdiction of NOAA Fisheries for the state of Alabama. Biological information on federally-protected sea turtles, shortnose and gulf sturgeon, smalltooth sawfish, and other listed species and candidate species can be found at the following website addresses: NOAA Fisheries Southeast Regional Office (<http://caldera.sero.nmfs.gov/protect/protect.htm>); NOAA Fisheries Office of Protected Resources (http://www.nmfs.noaa.gov/prot_res/prot_res.html); U.S. Fish and Wildlife Service (<http://no.florida.fws.gov/SeaTurtles/seaturtle-info.htm>), <http://www.turtles.org>; <http://www.seaturtle.org>; <http://alabama.fws.gov/ga/>; <http://endangered.fws.gov/wildlife.html#Species>; the Ocean Conservancy (<http://www.ocean.org/main.php?l>); the Caribbean Conservation Corporation (<http://www.cccturtle.org/>); Florida Fish and Wildlife Conservation Commission (<http://floridaconservation.org/psm/turtles/turtle.htm>); http://obis.env.duke.edu/data/sp_profiles.php; www.mote.org/~coljns/Sawfish/SawfishHomePage.html; www.floridasawfish.com; www.fimnh.usf.edu/fish/sharks/InNews/sawprop.htm.

It is NOAA Fisheries' opinion that the project will have no effect on listed species or critical habitat protected by the ESA under NOAA Fisheries' purview. No further consultation with NOAA Fisheries pursuant to section 7(a)(2) of the ESA is required. Consultation with NOAA Fisheries, Habitat Conservation Division, pursuant to the Magnuson-Stevens Fishery Conservation and Management Act's requirements for essential fish habitat consultation (16 U.S.C. 1855 (b)(2) and 50 CFR 600.905-930, subpart K), may be required. Please contact our Habitat Conservation Division at (727) 570-5317.

If you have any questions, please contact the ESA section 7 coordinator, Eric Hawk, at (727) 570-5312, or by e-mail at eric.hawk@noaa.gov.

Sincerely,

David Bernhart
Acting Assistant Regional Administrator
for Protected Resources

✓ Enclosure
File:1514-22.
O:\forms\no-effect letter.wpd
Y/SER/2004/
AL species List



1

**Endangered and Threatened Species and Critical Habitats
under the Jurisdiction of the National Marine Fisheries Service**

Alabama

Listed Species	Scientific Name	Status	Date Listed
Marine Mammals			
blue whale	<i>Balaenoptera musculus</i>	Endangered	12/02/70
finback whale	<i>Balaenoptera physalus</i>	Endangered	12/02/70
humpback whale	<i>Megaptera novaeangliae</i>	Endangered	12/02/70
sei whale	<i>Balaenoptera borealis</i>	Endangered	12/02/70
sperm whale	<i>Physeter macrocephalus</i>	Endangered	12/02/70
Turtles			
green sea turtle	<i>Chelonia mydas</i>	Threatened ¹¹	07/28/78
hawksbill sea turtle	<i>Eretmochelys imbricata</i>	Endangered	06/02/70
Kemp's ridley sea turtle	<i>Lepidochelys kempi</i>	Endangered	12/02/70
leatherback sea turtle	<i>Dermochelys coriacea</i>	Endangered	06/02/70
loggerhead sea turtle	<i>Caretta caretta</i>	Threatened	07/28/78
Fish			
Gulf sturgeon	<i>Acipenser oxyrinchus desotoi</i>	Threatened	09/30/91

Species Proposed for Listing

None

Designated Critical Habitat

Gulf Sturgeon: Gulf Sturgeon: A final rule designating Gulf sturgeon critical habitat was published on March 18, 2003 (68 FR 13370) and 14 geographic areas (units) among the Gulf of Mexico rivers and tributaries were identified. Maps and details regarding the final rule can be found at alabama.fws.gov/gs

Proposed Critical Habitat

None

3/10/04 11:20 AM

Appendix E

1

file:///O:/FORMS/Species Lists/AL_CAND.htm

Candidate Species ⁽²⁾	Scientific Name
Fish	
Alabama shad	<i>Alosa alabamae</i>
dusky shark	<i>Carcharhinus obscurus</i>
Goliath grouper	<i>Epinephelus itajara</i>
night shark	<i>Carcharhinus signatus</i>
saltmarsh topminnow	<i>Fundulus jenkinsi</i>
sand tiger shark	<i>Odontaspis taurus</i>
speckled hind	<i>Epinephelus drummondhayi</i>
Warsaw grouper	<i>Epinephelus nigritus</i>

1. Green turtles are listed as threatened, except for breeding populations of green turtles in Florida and on the Pacific Coast of Mexico, which are listed as endangered.

2. Candidate species are not protected under the Endangered Species Act, but concerns about their status indicate that they may warrant listing in the future. Federal agencies and the public are encouraged to consider these species during project planning so that future listings may be avoided.

1

March 23, 2004

The Honorable Chadwick Smith, Principal Chief
Cherokee Nation of Oklahoma
PO Box 948
Tahlequah, OK 74465

**SUBJECT: U.S. NUCLEAR REGULATORY COMMISSION REVIEW OF THE BROWNS
FERRY NUCLEAR PLANT LICENSE RENEWAL APPLICATION**

Dear Chief Smith:

The U.S. Nuclear Regulatory Commission (NRC) is seeking input for its environmental review of an application from Tennessee Valley Authority (TVA) to renew its operating licenses for the Browns Ferry Nuclear Plant, Units 1, 2, and 3 (BFN), located in Limestone County, Alabama, 16 km (10 mi) southwest of Athens, Alabama. BFN is in close proximity to lands that may be of interest to the Cherokee Nation Tribe. As described below, the NRC process includes an opportunity for public participation in the environmental review. We want to ensure that you are aware of our efforts and, pursuant to 10 CFR 51.28(b), the NRC invites the Cherokee Nation Tribal Community to provide input to the scoping process relating to the NRC's environmental review of the application.

The NRC will hold public scoping meetings for the BFN license renewal supplement to the NRC's "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (GEIS) (NUREG-1437). These scoping meetings will be held at the Athens State University, Student Center Cafeteria Ballroom, 300 North Beaty Street, Athens, Alabama, on Thursday, April 1, 2004. There will be two sessions to accommodate interested parties. The first session will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second session will convene at 7:00 p.m., with a repeat of the overview portions of the meeting, and will continue until 10:00 p.m., as necessary. Additionally, the NRC staff will host informal discussions one hour before the start of each session. No formal comments on the proposed scope of the supplement to the GEIS will be accepted during the informal discussions. To be considered, comments must be provided either at the transcribed public meetings or in writing. The application and the environmental review process are described below.

Under NRC regulations, the original operating license for a nuclear power plant is issued for up to 40 years. The license may be renewed for up to an additional 20 years if NRC requirements are met. The current operating licenses for BFN will expire in 2013, 2014, and 2016 respectively. TVA submitted an environmental report as part of its application for renewal of the BFN operating license on January 6, 2004. The application is electronically available for inspection from the Publicly Available Records (PARs) component of NRC's Agencywide Documents Access and Management System (ADAMS). ADAMS is accessible at <http://www.nrc.gov/reading-rm/adams.html>, which provides access through the NRC's Public Electronic Reading Room (PERR) link. If you do not have access to ADAMS or if there are problems in accessing the documents located in ADAMS, contact the NRC's Public Document Room (PDR) Reference staff at 1 (800) 397-4209, (301) 415-4737, or by e-mail to pdr@nrc.gov. In addition, the application can be viewed on the Internet at

Chief C. Smith

<http://www.nrc.gov/reactors/operating/licensing/renewal/applications.html>.

A paper copy of the document can be viewed at the NRC's PDR, located at One White Flint North, 11555 Rockville Pike (first floor), Rockville, Maryland, 20852-2738 and at the Athens-Limestone Public Library, 405 East South Street, Athens, Alabama, 35611-1999. Also, the GEIS assesses the scope and impact of environmental effects that would be associated with license renewal at any nuclear power plant site. A copy of this document can also be found on the NRC's website or at the NRC's PDR.

The NRC is gathering information for the document that will be a BFN-specific supplement to the GEIS. The supplement will contain the results of the review of the environmental impacts on the area surrounding the BFN site that are related to terrestrial ecology, aquatic ecology, hydrology, cultural resources, and socioeconomic issues (among others) and will contain a recommendation regarding the environmental acceptability of the license renewal action.

Please submit any written comments the Cherokee Nation Tribal Community may have to offer on the scope of the environmental review by April 26, 2004. Comments should be submitted either by mail to the Chief, Rules and Directives Branch, Division of Administrative Services, Mail Stop T-6D59, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555-0001, or by e-mail to BrownsFerryEIS@nrc.gov.

At the conclusion of the scoping process, the NRC staff will prepare a summary of the significant issues identified, the conclusions reached, and will mail a copy to you.

The NRC will prepare a draft supplemental environmental impact statement (SEIS) for public comment, and will hold another set of public meetings in the site vicinity to solicit comments on the draft. A copy of the draft SEIS will be sent to you for your review and comment. After consideration of public comments received on the draft, the NRC will prepare a final SEIS. If you need additional information regarding the environmental review process, please contact Dr. Michael Masnik, Senior Environmental Project Manager, at (301) 415-1191.

Sincerely,

/RA/

Pao-Tsin Kuo, Program Director
License Renewal and Environmental Impacts Program
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Docket Nos.: 50-259, 50-260, and 50-296



IN REPLY REFER TO:

04-0760

United States Department of the Interior

FISH AND WILDLIFE SERVICE
P.O. Drawer 1190
Daphne, Alabama 36526

May 19, 2004

U.S. Nuclear Regulatory Commission
Division of Regulatory Improvement Programs
Attn: Dr. Michael Masnik
Washington, D.C. 20555-0001

Dear Dr. Masnik:

This letter is in response to your letter, dated March 4, 2004, notifying our agency of the Nuclear Regulatory Commission's (NRC) plan to prepare a Supplemental Environmental Impact Statement (SEIS) for the Browns Ferry Nuclear Plant Operations License Renewal, Limestone County, Alabama. The following comments are provided in accordance with the Fish and Wildlife Coordination Act, as amended (16 U.S.C. 661-667e), the Migratory Bird Treaty Act (16 U.S.C. 703, *et seq.*) and section 7 of the Endangered Species Act, as amended (16 U.S.C. 1531-1543).

According to your letter, the proposed action would include the use and continued maintenance of the existing plant facilities and transmission lines. However, you indicated that very little new construction or ground disturbance would occur as a result of the proposed action. The entire Tennessee River system and the 5-county area traversed by the transmission lines provides habitat to a number of terrestrial and aquatic federally listed species. A county list of these species may be found on our website at the following address, <http://daphne.fws.gov/es/specieslst.htm>. The SEIS should address the type of ground disturbance and maintenance needed for the transmission lines. If the maintenance involves the use of chemicals or mowing to maintain the rights-of-way in a herbaceous environment, further consultation with the Service will be required to determine the extent, if any, these applications will have on listed species.

The U.S. Fish and Wildlife Service, Daphne, Alabama Field Office has concerns with the thermal plume that will be created if the maximum operating power level is increased for the facility. Thermal plume could impact aquatic organisms, particularly the rough pigtoe (*Pleurobema plenum*), an endangered mussel found in the vicinity of the discharge. The Service requests that surveys for threatened and endangered mussels be conducted and thermal plume models be produced pursuant to the preparation of the SEIS, and provided to this office for review.

The Service appreciates the early coordination on this project and we look forward to working with you during the preparation of the SEIS. If you have questions or comments, please direct them to

PHONE: 251-441-5181

www.fws.gov

FAX: 251-441-6222

SHIPPING ADDRESS: 1208-B Main Street, Daphne, AL 36526


1

Appendix E

1

Mr. Bruce Porter, at (251)441-5864 or via email bruce_porter@fws.gov.

Sincerely,

A handwritten signature in black ink, appearing to read "Larry E. Goldman". The signature is fluid and cursive, with the first name "Larry" being the most prominent.

Larry E. Goldman
Field Supervisor

cc: Mr. Jon M. Loney,
Environmental Policy and Planning
Tennessee Valley Authority
400 West Summit Hill Drive
Knoxville, Tennessee 37902-1499

October 25, 2004

1
2 Mr. Larry Goldman
3 Field Supervisor
4 U.S. Fish and Wildlife Service
5 P.O. Drawer 1190
6 Daphne, AL 36526

7
8 **SUBJECT: BIOLOGICAL ASSESSMENT FOR LICENSE RENEWAL OF THE BROWNS**
9 **FERRY NUCLEAR POWER PLANT, AND A REQUEST FOR INFORMAL**
10 **CONSULTATION**

11
12 Dear Mr. Goldman:

13
14 The U.S. Nuclear Regulatory Commission (NRC) staff has prepared the enclosed biological
15 assessment (Enclosure 1) to evaluate whether the proposed renewal of the Browns Ferry
16 Nuclear Plant, Units 1, 2, and 3 (BFN) operating licenses for a period of an additional 20 years
17 would have adverse effects on listed species. The proposed action (license renewal) is not a
18 major construction activity. BFN is located on the north shore of Wheeler Reservoir in
19 Limestone County, Alabama, at Tennessee River Mile (TRM) 294.

20
21 By letter dated March 5, 2004, the NRC requested a list of Federally threatened or endangered
22 species that may be in the vicinity of BFN and its associated transmission lines. In a letter
23 dated May 19, 2004, the U.S. Fish and Wildlife Service (FWS) directed the NRC to the following
24 Website, <http://daphne.fws.gov/es/specieslst.htm>, for a list of Federally listed threatened or
25 endangered species to evaluate in a biological assessment (BA). The FWS Website listed 11
26 terrestrial and 38 aquatic Federally protected species as potentially occurring in counties
27 containing the BFN site, transmission line and rights-of-way, and Wheeler Reservoir. Your letter
28 dated May 19, 2004, also expressed concerns related to the operation of BFN and the potential
29 impact on the rough pigtoe; specifically, potential impacts resulting from the plant operating at
30 maximum power levels.

31
32 For documentation purposes, the NRC has included all terrestrial and aquatic species found on
33 the aforementioned FWS Website in the enclosed BA. This BA provides an evaluation of the
34 potential impact of renewing the BFN operating licenses for an additional 20 years of operation
35 on the forty-five listed species and four candidate species identified in Tables 1, 2, and 3 of the
36 BA.

37
38 The NRC has determined that the proposed action has no effect on the red-cockaded
39 woodpecker (*Picoides borealis*), the American hart's tongue fern (*Asplenium scolopendrium*
40 var. *americanum*), and 29 of the aquatic species (Table 3). In addition, the staff has
41 determined that the proposed action may affect, but is not likely to adversely affect, the bald
42 eagle (*Haliaeetus leucocephalus*), gray bat (*Myotis grisescens*), Indiana bat (*Myotis sodalis*),
43 Price's potato bean (*Apios priceana*), leafy prairie clover (*Dalea foliosa*), Eggert's sunflower
44 (*Helianthus eggertii*), fleshy-fruited gladecress (*Leavenworthia crassa*), lyrate bladder-pod
45 (*Lesquerella lyrata*), Tennessee yellow-eyed grass (*Xyris tennesseensis*), Anthony's riversnail
46

Appendix E

1 L. Goldman

2
3 (*Athearnia anthonyi*), slender campeloma (*Campeloma decampi*), armored snail (*Pyrgulopsis*
4 *pachyta*), spectaclecase (*Cumberlandia monodonta*), Cumberlandian combshell (*Epioblasma*
5 *brevidens*), pink mucket (*Lampsilis abrupta*), slabside pearlymussel (*Lexingtonia dolabelloides*),
6 rough pigtoe (*Pleurobema plenum*), and the slackerwater darter (*Etheostoma boschungii*). The
7 site contains no critical habitat for any protected species. However, some areas within the
8 transmission line rights-of-way have recently been designated critical habitat for the
9 Cumberlandian combshell. TVA has designed and implemented maintenance procedures for
10 its transmission line rights-of-way that protect all listed species and their habitats.

11
12 We are placing this BA in our project files and are requesting your concurrence with our
13 determination. In reaching its conclusion, the NRC staff relied on information provided by the
14 licensee, on research performed by NRC staff, and information from the FWS (i.e., including
15 current listings of species provided by FWS, Daphne, Alabama Field Office).

16
17 If you have any questions regarding this BA or the staff's request, please contact
18 Dr. Michael Masnik, Senior Project Manager, at 301-415-1191 or by email at mtm2@nrc.gov.

19
20
21 Sincerely,

22
23 */RA/*

24
25 Pao-Tsin Kuo, Program Director
26 License Renewal and Environmental Impacts Program
27 Division of Regulatory Improvement Programs
28 Office of Nuclear Reactor Regulation

29
30 Docket Nos.: 50-259, 50-260, and 50-296

31
32 Enclosure: As stated

33
34 cc w/encl.: See next page

1
2
3
4
5

Biological Assessment

**Browns Ferry Nuclear Power Plant
License Renewal Review**

Limestone County, Alabama

October 2004

Docket Numbers 50-259, 50-260, and 50-296

**U.S. Nuclear Regulatory Commission
Rockville, Maryland**

1 **Biological Assessment of the Potential Effects on Endangered or**
2 **Threatened Species from the Proposed License Renewal for the**
3 **Browns Ferry Nuclear Plant**
4

5 **1.0 Introduction**
6

7 The U.S. Nuclear Regulatory Commission (NRC) licenses the operation of domestic nuclear
8 power plants in accordance with the Atomic Energy Act of 1954, as amended, and NRC
9 implementing regulations. The Tennessee Valley Authority (TVA) operates Browns Ferry
10 Nuclear Power Plant, Units 1, 2, and 3 (BFN) pursuant to NRC operating license (OL)
11 numbers DPR-33, DPR-52, DPR-68, which expire on December 20, 2013, June 28, 2014, and
12 July 2, 2016, respectively.

13
14 TVA has prepared an Environmental Report (ER) (TVA 2003) in conjunction with its application
15 for renewal of the BFN OLs, as provided for by the following NRC regulations:

- 16
17
18 • Title 10 of the Code of *Federal Regulations*, Part 54, "Requirements for Renewal of
19 Operating Licenses for Nuclear Power Plants," Section 54.23, Contents of application -
20 environmental information (10 CFR 54.23).
21
22
23 • Title 10 of the Code of Federal Regulations, Part 51, "Environmental Protection
24 Regulations for Domestic Licensing and Related Regulatory Functions," Section 51.53,
25 Postconstruction environmental reports, Subsection 51.53(c), Operating license renewal
26 stage (10 CFR 51.53(c)).
27

28 The renewed OLs would allow up to 20 additional years of plant operation beyond the current
29 licensed operating term.

30
31 No major refurbishment or replacement of important systems, structures, or components are
32 expected during the 20-year BFN license renewal term. In addition, no construction activities
33 are expected to be associated with license renewal.
34

35 In a letter dated March 5, 2004, the staff requested comments from the U.S. Fish and Wildlife
36 Service (FWS) on the OL renewal application for BFN (NRC 2004). Specifically, the staff
37 requested a list of species and information on protected, proposed, and candidate species and
38 critical habitat that may be in the vicinity of BFN and its associated transmission line rights-of-
39 way. In a letter from the FWS dated May 19, 2004 (FWS 2004e), the staff was directed to an
40 FWS website (<http://daphne.fws.gov/es/specieslst.htm>) for a list of species to include in this
41 biological assessment (BA). A total of 11 terrestrial and 38 aquatic species were listed for the
42 counties within which the BFN site and its transmission line rights-of-way are located,
43 and for Wheeler Reservoir, which serves as the source of cooling water for BFN. The FWS
44 expressed specific concern (FWS 2004) over the potential impact of all three BFN units
45 operating at maximum power levels on the rough pigtoe (*Pleurobema plenum*).
46

2.0 Proposed Action

The proposed Federal action is the renewal of the OLs for BFN. In response to the increasing demands for bulk power, TVA seeks to use existing facilities to the greatest extent possible to meet requirements for electric power. TVA is pursuing this approach because: (1) it ensures that future power needs can be met; (2) it avoids the large capital expenditures associated with construction of new generating facilities; and (3) it avoids the environmental impacts resulting from siting and constructing new power generating facilities. Consistent with this approach, TVA proposes to continue operation of BFN after expiration of the current OL for each unit. Implementing the proposed action is dependent on the staff determining that renewal of the OLs for BFN is the best course of action. Renewal of the current OLs would permit operation of the units for an additional 20 years beyond their current (original) 40-year operating license period.

In July 2004, the TVA submitted extended power uprate (EPU) applications to increase the licensed power levels of each of the three units to 3952 megawatts thermal (MW(t)) (i.e., to 120% of the originally licensed power levels), thereby bringing the combined total power level for the three units to 11,856 MW(t). In a separate environmental assessment, NRC is currently evaluating the potential environmental impacts of the proposed EPUs at BFN. If approved, the EPUs would take effect during the existing license term and would continue during the 20 year term of the renewed OLs. This BA was prepared to evaluate the potential environmental impacts of operating Units 1, 2, and 3 at 120% of their originally licensed power levels for an additional 20 years beyond the current license term for each unit.

Continued maintenance activities on the transmission line rights-of-way that are used to connect BFN to the electric power grid would be required if the proposed action is adopted. The TVA Transmission and Power Supply-Transmission Operations and Maintenance organization conducts maintenance activities on transmission lines and rights-of-way in the TVA system. These activities include, but are not restricted to, maintenance of vegetation in each right-of-way, replacement of poles or towers, installation of lightning arresters and counterpoise, and upgrading existing equipment. Regular maintenance activities are conducted on a 3-to-5-year cycle (Muncy et al. 1999).

3.0 The Plant

3.1 Plant Description

The three-unit BFN plant, including the intake and discharge canals, is enclosed by a security fence. Primary access to the plant area is by way of an access road through a security gate. The plant has the following principal physical structures in the central site area: reactor containment building, turbine building, radioactive waste building, service building, intake pumping station, transformer yard, 161-kV and 500-kV switchyards, off-gas stack, sewage treatment facilities, and administration and maintenance buildings. The hot and cold water discharge channels and mechanical draft cooling towers are located northwest of the central site area, while the training center, employee physical fitness center, materials storage and procurement complex, and structures from a former aquatic research laboratory are located to the east of the central site area (see Figure 1).

1 **3.2 Reactor Systems**
2

3 BFN has two active nuclear reactor units (Units 2 and 3) and one inactive unit (Unit 1). Each
4 unit includes a boiling water reactor (BWR) and a steam-driven turbine generator manufactured
5 by General Electric Company. Work began in 2002 to bring Unit 1 up to current standards, and
6 operation of the reactor is currently scheduled to resume in 2007.
7

8 The nuclear steam supply system at BFN is typical of General Electric BWRs. Each nuclear
9 system includes a single-cycle, forced-circulation, General Electric BWR that produces steam
10 for direct use in a steam turbine. The design employs a pressure suppression primary
11 containment that houses the reactor vessel, the reactor coolant recirculating loops, and other
12 branch connections of the reactor primary system. The pressure suppression system consists
13 of a dry well, a pressure suppression chamber that stores a large volume of water, connecting
14 vents between the dry well and the pressure suppression chamber, isolation valves,
15 containment cooling systems, and other service equipment. Cooling systems are provided to
16 remove heat from the reactor core, the dry well, and the water in the pressure suppression
17 chamber, thus providing continuous cooling of the primary containment under accident
18 conditions. Appropriate isolation valves are actuated during this period to ensure confinement
19 of radioactive material, which might otherwise be released from the reactor containment during
20 the course of an accident.
21

22 The secondary containment substructure consists of poured-in-place, reinforced concrete
23 exterior walls that extend up to the refueling floor. The refueling room floor is also constructed
24 of reinforced, poured-in-place concrete. The secondary containment structure completely
25 encloses the primary containment dry wells, fuel storage and handling facilities, and essentially
26 all of the core standby cooling systems for the three units. During normal operation and when
27 isolated, the secondary containment is maintained at a negative pressure relative to the building
28 exterior.
29

30 **3.3 Cooling and Auxillary Water Systems**
31

32 Wheeler Reservoir on the Tennessee River is the source for cooling water and most of the
33 auxiliary water systems for BFN (see Figure 2). Potable water is supplied by the City of Athens
34 Utilities Water Department in Athens, Alabama. Groundwater is not used at the site. Figure 1
35 shows the general layout of the buildings and structures at the site.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32

November 2004

E-23

Draft NUREG-1437, Supplement 21




Figure 1. Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 Site Features

Appendix E

1 The intake forebay is separated from Wheeler Reservoir by a gate structure with three bays
2 that are each 12 m (40 ft) wide by about 7.3 m (24 ft) high (TVA 1972). Each bay includes a 6-
3 m (20-ft)-high gate that can be raised or lowered depending on the operational requirements of
4 the plant. The flow velocity through the openings varies depending on the gate position. When
5 the gates are in their full-open position and the plant is operated in either the open mode (once-
6 through) or cooling tower helper mode, the average flow velocity through the openings is about
7 0.2 m/s (0.6 fps) for the operation of one unit, 0.34 m/s (1.1 fps) for the operation of two units,
8 and 0.52 m/s (1.7 fps) for the operation of all three units (TVA 2003). These flow velocities are
9 based on an intake flow per unit of about 46,300 L/s (734,000 gpm), which is 46.3 m³/s (1635
10 cfs).
11

12 The intake pumping station includes 18 bays (i.e., six bays per reactor unit), each with a
13 traveling screen. Each bay has a net opening size of about 2.6 m by 6 m (8.75 ft by 20 ft). The
14 maximum average flow velocity through each bay is about 0.49 m/s (1.6 fps) and is
15 independent of the reservoir surface elevation. The maximum average velocity through a clean
16 screen with net openings of 0.95 cm by 0.95 cm (3/8 in. by 3/8 in.) is about 0.64 m/s (2.1 fps)
17 (TVA 2003). Flow velocities through the intake pump station bays and traveling screens are
18 independent of the number of units in operation and the reservoir elevation.
19

20 The BFN units are normally cooled by pumping water from Wheeler Reservoir into the turbine
21 generator condensers and discharging it back to the reservoir via three large submerged
22 diffuser pipes that are perforated to maximize uniform mixing into the flow stream. These pipes
23 range in diameter from 5.2 m to 6.2 m (17 ft to 20.5 ft). The flow exits each discharge pipe
24 through 7800 5-cm (2-in.) ports (TVA 2003). This straight-through flow path is known as "open
25 cycle" or "open mode" operation. As originally designed, the maximum thermal discharge from
26 the once-through cooling water system is directed into the Wheeler Reservoir, with a
27 temperature increase across the intake and discharge of 13.9°C (25°F) (TVA 1972). The flow
28 exits the diffusers and mixes with the reservoir flow. At the edge of the discharge mixing zone,
29 the water temperature is required to be less than 5.6°C (10°F) above ambient (ADEM 2003).
30

31 Through various gates, some of this cooling water can also be directed through mechanical
32 draft cooling towers to reduce its temperature as necessary to comply with environmental
33 regulations. This flow path is known as the "helper mode," and the cooling towers are referred
34 to as "helper towers."
35

36 The capacity also exists to recycle cooling water from the cooling towers directly back to the
37 intake structure without being discharged to the reservoir. This flow path, known as the "closed
38 mode" of operation, has not been used since the restart of Units 2 and 3 because of difficulties
39 in achieving temperature limits in summer months and problems with equipment reliability. TVA
40 does not anticipate using this mode in the future, and no procedures for operating in this mode
41 currently exist.
42

43 In recent years, only Units 2 and 3 have been in operation, but because of a combination of
44 system upgrades and improved flow calibrations, the measured total per-unit condenser
45 circulating water (CCW) flow rate in open mode (with three CCW water pumps per unit) has
46 increased. The condenser tubes were replaced with stainless steel tubing that have a larger
47
48
49

1 internal diameter and lower flow resistance. This modification increased flow through the
2 condenser by approximately 6 percent. TVA estimates total intake for three-unit operation in
3 open mode to be 139 m³/s (4907 cfs) or 12,000 m³/d (3171 MGD) (TVA 2003).

4
5 Because of various system limitations, BFN cannot pass all the CCW through the cooling
6 towers when operating in the helper mode. The fraction of cooling water that cannot be passed
7 through the cooling towers is routed directly to the river. Almost all of the cooling water that
8 passes through the cooling towers is returned to the river, but a small amount is lost to the
9 atmosphere during operation. If cooling tower capacity is increased during the license renewal
10 term, this consumptive use could increase proportionately. The cooling towers are only
11 operated when necessary to meet thermal discharge temperature limits specified in the
12 National Pollutant Discharge Elimination System (NPDES) permit, typically a few weeks during
13 the hottest part of the summer (typically July and August).

14
15 For the last 6 years, during which Units 2 and 3 have both been in service, the greatest amount
16 of time cooling tower operation has been required has been about 8 percent of a year
17 (TVA 2003). Increased thermal power limits proposed for Units 2 and 3 will result in an
18 additional increase of approximately 2.2°C (4°F) in the circulating water temperature leaving the
19 main condenser (for each operating unit) (Hopping 2004). This increase in water discharge
20 temperature will result in increased use of the cooling tower during summer periods to maintain
21 compliance with discharge limitations. No changes to the plant intake system or to the
22 individual unit intake flow rates are expected to be required as a result of the Units 2 and 3 EPU
23 project, and operations will continue to meet regulatory limits established in the existing NPDES
24 permit.

25
26 Simulations with the near-field hydrothermal model were conducted for the period 1985 through
27 2002, excluding 2 years (1989 and 1990) for which no river ambient temperature data are
28 available (TVA 2003). TVA varied both the use of the helper towers and unit power levels to
29 maintain discharge temperatures to within NPDES permit limits. Model results showed that,
30 with Units 2 and 3 operating at 120 percent power, the cooling towers will be used on average
31 approximately 5.3 percent of the time, and derating will be required approximately 0.10 percent
32 of the time (i.e., 6.2 days over the 16-year simulation period). On average, with all three units
33 at 120 percent power, use of the cooling towers will increase to approximately 7.2 percent of
34 the time and derating will increase to approximately 0.29 percent of the time (i.e., 17 days over
35 the 16-year simulation). The simulation of three unit operation at 120 percent power assumed
36 the construction and operation of an additional sixth 20 cell cooling tower. The licensee has
37 committed placing the new tower in operation prior to the first summer following the return of
38 Unit 1 to service (TVA 2004c).

39
40 The residual heat removal service water (RHRSW) system consists of four pairs of pumps
41 located on the intake structure for pumping raw river water to the heat exchangers in the
42 RHRSW system and four additional pumps for supplying water to the emergency equipment
43 cooling water (EECU) system. The EECU system distributes cooling water supplied by the
44 RHRSW system to essential equipment during normal and accident conditions.

45 The impacts evaluated in this BA include those from operation of all three of the BFN reactor
46
47
48

Appendix E

1 units, each at 120 percent of the original licensed thermal power level. TVA has stated
2 (TVA 2002a) that "no changes are expected to be required to the plant intake system or to the
3 individual unit intake flow rates as a result of the EPU project." TVA also indicated that existing
4 thermal discharge limits would be met by increased use of the helper towers, and if necessary,
5 derating one or more units
6

7 **4.0 Environmental Setting**

8
9 The proposed license renewal will apply to all three units BFN, which is located on the north
10 shore of Wheeler Reservoir in Limestone County, Alabama, at Tennessee River Mile (TRM)
11 294. The BFN site is approximately 48 km (30 mi) west of Huntsville, Alabama; 16 km (10 mi)
12 northwest of Decatur, Alabama; and 16 km (10 mi) southwest of Athens, Alabama (Figure 2).
13 The power plant is located on a 340-ha (840-ac) tract owned by the Federal government and
14 held in custody by TVA, a corporate agency and instrumentality of the United States.
15

16 **4.1 Terrestrial Resources**

17
18 BFN is located within the Highland Rim section of the Interior Low Plateau Physiographic
19 Province. Botanically, the site is within the Mississippian Plateau section of the Western
20 Mesophytic Forest Region (EPA 2004). In this region of northern Alabama, native forest
21 communities generally consist of mixed oak forests that vary in composition in relation to
22 topography and soils. Historically, upland forests in the vicinity of the site were characterized by
23 mixtures of southern red oak (*Quercus falcata*), black oak (*Q. velutina*), post oak (*Q. stellata*),
24 and white oak (*Q. alba*), with dogwood (*Cornus* spp.) commonly present in the understory. The
25 clearing of forested lands for agriculture has converted many of these forest communities to
26 early successional habitats, allowing introduced plant species to replace representative native
27 plant communities.
28

29 The site is situated in an area where the land is used primarily for agriculture (TVA 2003). The
30 countryside includes open pasture lands, scattered farmsteads, few residents, and little industry
31 within several miles. The south and west side of the BFN site abuts Wheeler Reservoir, and
32 has a shoreline of approximately 3772 m (12,375 ft), with 58 percent of the shoreline stabilized
33 with riprap. The remaining 42 percent of the shoreline of the site is partially eroded and is
34 composed of mixed upland forest vegetation. The stabilized shoreline adjacent to the BFN
35 facilities is primarily vegetated by young (approximately 4-to-5-year-old) black willow (*Salix*
36 *nigra*), common hackberry (*Celtis occidentalis*), sumac (*Rhus* spp.), and exotic species such as
37 Chinese privet (*Ligustrum sinense*), Japanese honeysuckle (*Lonicera japonica*), and trumpet
38 creeper (*Campsis radicans*). The remainder of the shoreline just west of the facility is
39 vegetated with a young mixed upland forest scattered with a few large, old specimens
40 (approximately 80-plus years) of oaks and loblolly pine (*Pinus taeda*). Young plants associated
41 with the upland forest include black locust (*Robinia pseudoacacia*), sweetgum (*Liquidambar*
42 *styraciflua*), sassafras (*Sassafras albidum*), cottonwood (*Populus* spp.), elm (*Ulmus* spp.),
43 common hackberry, and black cherry (*Prunus serotina*). Common understory vegetation in the
44 forested area includes Chinese privet, spleenwort (*Asplenium* spp.), Virginia creeper
45 (*Parthenocissus quinquefolia*), and poison ivy (*Toxicodendron radicans*).
46 Invasive exotic plant species are a concern in the area. TVA reports approximately 19 invasive
47 species in the area with a special emphasis on Chinese privet, Japanese honeysuckle,
48 Japanese knotweed (*Polygonum cuspidatum*), and Nepal grass (*Microstegium vimineum*)
49 (TVA 2003).
50
51

1 There are approximately 10 ha (25 ac) and 5 ha (12 ac) of National Wetlands Inventory and
2 U.S. Army Corps of Engineers-classified wetlands, respectively, occurring at the BFN site
3 (TVA 2003). These areas include forested wetlands, emergent (marsh) wetlands, and scrub-
4 shrub/emergent wetlands (based on 1980s aerial photography). The wetland ecological
5 communities identified at the site are dominated by plant species that are common in the
6 region, including black willow, buttonbush (*Cephalanthus occidentalis*), sedges (*Carex lupulina*,
7 *C. vulpinoidea*, *Rhynchospora corniculata*), rushes (*Juncus* spp., *J. brachycarpus*), water
8 hemlock (*Conium maculatum*), and smartweeds (*Polygonum* spp.). These wetlands occur in
9 areas that have been previously disturbed by clearing and agriculture, and areas that are
10 mowed periodically. These types of wetlands commonly occur on previously disturbed former
11 or presently used agricultural land, and the dominant vegetation species occurring within them
12 are common in the region.

13
14 The vegetation communities described above are not unusual for the area and provide no
15 sensitive or rare forms of wildlife habitat. Wildlife habitat on the site can be broadly classified
16 as upland and riparian/wetland. Animal species commonly associated with upland communities
17 include white-tailed deer (*Odocoileus virginianus*), cottontail rabbit (*Sylvilagus floridanus*),
18 Virginia opossum (*Didelphis virginiana*), hispid cotton rat (*Sigmodon hispidus*), song sparrow
19 (*Melospiza melodia*), eastern bluebird (*Sialia sialis*), northern mockingbird (*Mimus polyglottus*),
20 turkey vulture (*Cathartes aura*), tufted titmouse (*Baeolophus bicolor*), American toad (*Bufo*
21 *americanus*), spring peeper (*Pseudacris crucifer*), black racer (*Coluber constrictor constrictor*),
22 and eastern box turtle (*Terrapene carolina*) (TVA 2003). Riparian communities can support a
23 unique assemblage of wildlife including muskrat (*Ondatra zibethicus*), beaver (*Castor*
24 *canadensis*), raccoon (*Procyon lotor*), wood duck (*Aix sponsa*), belted kingfisher (*Ceryle*
25 *alcyon*), barred owl (*Strix varia*), American woodcock (*Scolopax minor*), Carolina wren
26 (*Thryothorus ludovicianus*), prothonotary warbler (*Protonotaria citrea*), eastern phoebe
27 (*Sayornis phoebe*), bullfrog (*Rana catesbeiana*), green frog (*Rana clamitans*), eastern newt
28 (*Notophthalmus viridescens*), southern two-lined salamander (*Eurycea cirrigera*), common
29 snapping turtle (*Chelydra serpentina serpentina*), and northern water snake (*Nerodia sipedon*)
30 (TVA 2003). Some water holes along Wheeler Reservoir are used by American alligators
31 (*Alligator mississippiensis*) in the winter. Invasive terrestrial animals that are expected to occur
32 in the project vicinity include European starling (*Sturnus vulgaris*), house sparrow (*Passer*
33 *domesticus*), and rock dove (*Columba livia*).

34
35 BFN is connected to the TVA system network by seven 500-kilovolt (kV) transmission lines via
36 the 500-kV switchyard (TVA 2003). One line is to the Madison substation; two are to the Trinity
37 substation; one line each are to the West Point, Maury, and Union substations; and one line is
38 to the Limestone 500-kV substation. There are two additional 161-kV lines, one to the Athens
39 substation and one to the Trinity substation. All lines occupy portions of four rights-of-way;
40 three that terminate at the Maury, Trinity, and Athens substations, Alabama, and one that
41

Appendix E

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48




Figure 2. Brown's Ferry Nuclear Power Plant, Units 1, 2, and 3 Site and Surrounding Area
 Draft NUREG-1437, Supplement 21 E-28 November 2004

1 terminates at the Union substation in Union County, Mississippi (Figure 3). In all, there are
2 approximately 257 km (160 mi) of transmission line rights-of-way associated with BFN. The
3 rights-of-way pass through Colbert, Franklin, Lawrence, Limestone, and Morgan Counties,
4 Alabama, and Itawamba, Lee, Tishomingo, and Union Counties, Mississippi.^a The Maury,
5 Trinity, and Athens transmission line rights-of-way are found in the Eastern Highland Plain
6 ecoregion, while the 175-km (109-mi)-long Union right-of-way traverses the Eastern Highland
7 Plain and Transition Hills, crosses into Mississippi and passes through the Fall Line Hills,
8 Flatwoods/Blackland Prairie Margins, and Blackland Prairie ecoregions (EPA 2004).
9

10 Transmission line maintenance activities are reviewed for potential resource issues by technical
11 specialists in the TVA Regional Natural Heritage and Cultural Resources programs (Muncy et
12 al. 1999). A 1.6-km (1.0-mi) buffer area on either side of each transmission line right-of-way is
13 reviewed for the presence of terrestrial species, while a 16.1-km (10-mi) buffer area is used for
14 aquatic species (TVA 2003). The TVA Regional Natural Heritage program maintains a
15 database of more than 27,000 occurrence records for protected plants, animals, caves,
16 National Wetland Inventory wetlands, cultural resources, and areas of management concern for
17 the entire TVA Power Service Area. TVA also conducts fieldwork to inventory and protect
18 threatened and endangered species and environmentally sensitive areas on public lands it
19 administers. Activities conducted by project staff members include monitoring species
20 populations, educating the public, and managing and maintaining habitats (including caves) at
21 TVA-managed sites.
22

23 Transmission line rights-of-way are regularly surveyed and video taped from a helicopter.
24 Video tapes can then be used to search for sensitive habitat types before field crews are
25 dispatched. Access routes and restrictions for maintenance activities are determined based on
26 knowledge of the species or resources to be protected. Vehicles and equipment are restricted
27 from a site when habitat-sensitive resources are present (Class 2 restrictions). Within Class 2
28 restricted areas, all vegetation clearing and herbicide applications are done by hand. Class 1
29 restrictions allow hand or mechanical clearing and herbicide use for vegetation control on
30 transmission line rights-of-way. There is no broadcast application of herbicides. Herbicide
31 application is carefully controlled and personnel who apply the herbicides are trained, licensed,
32 and follow manufacturer's guidelines, U.S. Environmental Protection Agency (EPA) guidelines,
33 and State regulations. The streamside management zone is maintained to (1) slow and spread
34 surface-water flow so particulate matter will be trapped and filtered before reaching the stream
35 channel, (2) protect stream bank integrity, and (3) protect water temperature in the stream.
36

^aPrentiss County, Mississippi is not included. Species accounted for in adjacent counties.
November 2004





Figure 3. Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 and Its Associated Transmission Lines and Rights-of-Way

4.2 Aquatic Resources

The aquatic resources in the vicinity of BFN are primarily associated with the Wheeler Reservoir portion of the Tennessee River. Wheeler Reservoir is the source and receiving body for the BFN cooling system (TVA 2003). Other aquatic habitats include several tributaries to Wheeler Reservoir: Paint Rock and Flint Rivers in the upper reach; Indian, Cotaco, and Flint Creeks in the middle reach; and Limestone, Piney, Swan, Fox, Mallard, Spring, First, and Second Creeks and the Elk River in the lower section. Elk River, the largest of these tributaries, flows into Wheeler Reservoir about 16 km (10 mi) downstream of BFN. Gunterville Reservoir is upstream of Wheeler Reservoir, while Wilson Reservoir is downstream. All three reservoirs are run-of-the-river impoundments on the Tennessee River.

The seven transmission lines located in four rights-of-way associated with BFN cross a number of streams ranging in size from small intermittent streams to the Tennessee River. Rivers and larger streams crossed by or near the transmission lines include Limestone, Piney, Swan, Round Island, Big Nance, Town, Spring, Cedar, Little Bear, and Bear Creeks in Alabama; and Bear, Little Brown, Donovan, Twentymile, Mantachie, Mud, and Bridge Creeks and the Tennessee-Tombigbee Waterway in Mississippi. Transmission line right-of-way maintenance activities in the vicinity of stream and river crossings employ best management practices to minimize erosion and shoreline disturbance while encouraging vegetative cover (TVA 2003).

A total of 63 fish species plus hybrid sunfish, hybrid striped bass x white bass (*Morone saxatilis* x *M. chrysops*), and hybrid walleye x sauger (*Stizostedion vitreum* x *S. canadense*) were collected from 1995 through 2002 in the vicinity of BFN (TVA 2002b, 2003). A total of 72 fish species were identified in impingement samples collected between 1974 and 1977 (TVA 1978). Important commercial fish species that occur in Wheeler Reservoir include blue catfish (*Ictalurus furcatus*), channel catfish (*I. punctatus*), flathead catfish (*Pylodictis olivaris*), bigmouth buffalo (*Ictiobus cyprinellus*), smallmouth buffalo (*I. bubalus*), and common carp (*Cyprinus carpio*). Gizzard shad (*Dorosoma cepedianum*) and threadfin shad (*D. petenense*) are the dominant forage species in Wheeler Reservoir (TVA 2003). Threadfin shad has been the dominant species numerically in Wheeler Reservoir since 1990 (Baxter and Buchanan 1998). Game fish species include largemouth bass (*Micropterus salmoides*), smallmouth bass (*M. dolomieu*), spotted bass (*M. punctulatus*), black crappie (*Pomoxis nigromaculatus*), white crappie (*P. annularis*), bluegill (*Lepomis macrochirus*), longear sunfish (*L. megalotis*), redear sunfish (*L. microlophus*), sauger, striped bass, hybrid striped bass, yellow bass (*Morone mississippiensis*), and yellow perch (*Perca flavescens*).

Historically, 39 mussel species occurred in Wheeler Reservoir. Thirty-one of these species were considered riverine (i.e., those that evolved in free-flowing reaches), with 19 of these species now considered non-reproducing riverine species within Wheeler Reservoir (Ahlstedt and McDonough 1992). In 1982, 12 mussel species were collected during a survey for the proposed barge facility at BFN (Pryor 1982), and 11 species were collected across the river during a survey for a proposed barge terminal for the Mallard-Fox Creek Development Project (Carroll 1982). The washboard (*Megaloniais nervosa*) was the most common species collected during both surveys. It is currently the predominant species that is commercially harvested (TVA 2003). The Ohio pigtoe (*Pleurobema cordatum*) was previously the most

Appendix E

1 valuable commercial species, but its numbers have decreased because of habitat alterations
2 due to impoundment (Ahlstedt and McDonough 1992). None of the species collected were
3 Federally or State protected.
4

5 In 1991, 24 species of mussels were collected from Wheeler Reservoir, with six species
6 represented by weathered, empty shells (Ahlstedt and McDonough 1992). The 24 species
7 included all species previously collected near BFN in the two 1982 collections by Pryor and
8 Carroll. It was estimated that 460 million mussels or 2.33 mussels/m² (0.22 mussels/ft²)
9 occurred in the reservoir in 1991 (Ahlstedt and McDonough 1992). The most common species
10 (and estimated number within Wheeler Reservoir) collected in 1991 were the elephant-ear
11 (*Elliptio crassidens*, 116 million), washboard (88 million), pink heelsplitter (*Potamilus alatus*, 56
12 million), and threehorn wartyback (*Obliquaria reflexa*, 44 million) (Ahlstedt and McDonough
13 1992). In addition to the habitat alteration resulting from reservoir creation, over-harvesting and
14 periods of drought (e.g., from 1983 to 1988) may have affected reproduction and/or survival of
15 most thick-shelled mussel species in Wheeler Reservoir (Ahlstedt and McDonough 1992).
16 Water-quality impairments and loss of necessary fish hosts have also contributed to the decline
17 of mussel populations. The biodiversity of mussel communities in the mainstem Tennessee
18 River reservoirs is anticipated to continue the long-term downward trend in terms of abundance
19 and diversity (TVA 2004a).
20

21 In 1998, 17 mussel species were collected on the east channel of Wheeler Reservoir near
22 Hobbs Island, over 64 river kilometers (40 river miles) upstream of BFN, between TRMs 336.4
23 and 335.5. The two most common mussel species were the elephant-ear and the Ohio pigtoe.
24 Two Federally endangered species were also collected: one specimen of the rough pigtoe
25 (*Pleurobema plenum*) and 16 specimens of the pink mucket (*Lampsilis abrupta*) (Yokely 1998).
26 In 1999, 16 native mussel species were collected in the vicinity of BFN: 14 species at
27 (TRM) 298 upstream of BFN and 12 species at TRM 292 downstream of BFN. None of these
28 were Federally listed species (TVA 2003). Eleven commercial mussel species have been
29 reported near BFN from TRM 305 to TRM 275 (Ahlstedt and McDonough 1992).
30

31 Two areas of Wheeler Reservoir are designated as State-protected mussel sanctuaries where
32 commercial mussel fishing is not permitted. One sanctuary extends from Gunterville Dam
33 (TRM 349) downstream to the mouth of Shoal Creek (TRM 347); the second extends from the
34 upstream end of Hobbs Island (TRM 337) downstream to Whitesburg Bridge (TRM 333)
35 (TVA 2003). In the reservoir overbanks, mussels are generally spread over large areas and are
36 not concentrated in mussel beds (TVA 2003).
37

38 **5.0 Evaluation of Threatened and Endangered Species**

39 A review of the TVA Regional Natural Heritage database indicates that no Federally listed
40 species of animals or plants have been reported from areas within 4.8 km (3.0 mi) of the BFN
41 site (TVA 2003). However, there are 49 species (11 terrestrial and 38 aquatic species) that are
42 listed as threatened, endangered, or candidate species by FWS that occur, at least historically,
43 within the portion of the Tennessee River that encompasses Wheeler Reservoir or within one or
44 more of the counties of Alabama and Mississippi within which the BFN transmission lines are
45 located.
46
47
48

5.1 Terrestrial Species

There are 11 terrestrial species that are listed as threatened, endangered by the FWS and that potentially occur in the vicinity of BFN or along the transmission line rights-of-way (Table 1). All 11 Federally listed species have been reported from counties that contain BFN transmission line rights-of-way (Table 1).

Bald Eagle (*Haliaeetus leucocephalus*)

The bald eagle is reported to occur in Franklin County, Alabama, and Itawamba and Tishomingo Counties, Mississippi. Bald eagles prefer habitat along coastlines, lakes, rivers and other water bodies that provide their primary food source – fish and waterfowl (NatureServe 2004). Eagles generally nest in tall trees or on cliff faces near water and away from human disturbance. Bald eagles are known in the area around BFN, but there is no known nesting habitat within 4.8 km (3.0 mi) of the site. Nesting sites on other TVA property are managed using FWS guidelines (FWS 1987a). Transmission line rights-of-way are likely to be within foraging areas for this species, particularly those that cross Wheeler Reservoir and the Tennessee-Tombigbee Waterway. The TVA reports incidents of eagle mortality associated with transmission lines but no mortality has been observed on BFN-associated lines.

Construction and maintenance of transmission line rights-of-way are designed to minimize environmental impacts, and transmission line right-of-way maintenance activities are reviewed for potential resource issues by TVA (Muncy et al. 1999). Access routes and activity restrictions are determined based on knowledge of the eagles in the area. Mechanical clearing and herbicide use may be used for vegetation control in transmission line rights-of-way. Access routes and activity restrictions are determined based on knowledge of the eagles in the area. Herbicide application is carefully controlled and personnel who apply the herbicides are trained, licensed, and follow manufacturer's guidelines, EPA guidelines, and State regulations. The staff reviewed TVA maintenance activities and determined that continued operation of BFN over the 20-year license renewal term may affect, but is not likely to adversely affect, bald eagles.

Appendix E

Table 1. Federally Listed and Candidate Terrestrial Species for Colbert, Franklin, Lawrence, Limestone, and Morgan Counties, Alabama, and Itawamba, Lee, Tishomingo, and Union Counties, Mississippi, Occurring Near Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 and Along the Transmission Line Rights-of-Way.

Scientific Name	Common Name	Status ^(a)	County Listings		Habitat
			AL ^(b)	MS ^(c)	
Birds					
<i>Haliaeetus leucocephalus</i>	bald eagle	T	Fr	It Ti	Coastlines, lakes, rivers and other water bodies
<i>Picoides borealis</i>	red-cockaded woodpecker	E	La	--	Open pine forests, generally at least 80 to 120 years old
Mammals					
<i>Myotis grisescens</i>	gray bat	E	Co Fr La Li Mo	Ti	Restricted to cave or cave-like habitats. Gray bats roost and form maternity colonies in caves located along rivers and reservoirs
<i>Myotis sodalis</i>	Indiana bat	E	Co La Li Mo	Ti	Hibernate in caves during winter months but can be found in hollow trees and under loose tree bark during the summer
Plants					
<i>Apios priceana</i>	Price's potato bean	T	--	Le	Open mixed hardwood forests often on floodplains, in or near riparian areas
<i>Asplenium scolopendrium</i> var. <i>americanum</i>	American hart's-tongue fern	T	Mo	--	Around the openings to limestone caves and sinkholes
<i>Dalea foliosa</i>	leafy prairie-clover	E	Fr La Mo	--	Cedar glades in northern Alabama and central Tennessee
<i>Helianthus eggertii</i>	Eggert's sunflower	T	Co Fr La Li Mo	--	Barrens habitats within the Interior Plateau Ecoregion of Kentucky, Tennessee, and Alabama

Table 1. (contd)

	Scientific Name	Common Name	Status ^(a)	County Listings		Habitat
				AL ^(b)	MS ^(c)	
3	<i>Lesquerella lyrata</i>	lyrate bladder-pod	T	Co Fr La	--	Disturbed glade habitats
4	<i>Xyris tennesseensis</i>	Tennessee yellow-eyed grass	E	Fr	--	Moist to wet, limestone-derived soils in open or lightly wooded sites
7	<i>Leavenworthia crassa</i>	Fleshy-fruited gladecress	C	La Mo	--	Endemic to limestone glades in Lawrence and Morgan Counties

(a) Status: C = candidate, E = endangered, T = threatened;

(b) AL counties: Co = Colbert; Fr = Franklin; La = Lawrence; Li = Limestone; Mo = Morgan;

(c) MS counties: It = Itawamba; Le = Lee; Tj = Tishomingo; -- = not listed.

Sources: FWS 2000b, 2004a; NatureServe 2004.

Red-Cockaded Woodpecker (*Picoides borealis*)

The red-cockaded woodpecker is reported to occur in Lawrence County, Alabama, but not within at least 4.8 km (3.0 mi) of the transmission line rights-of-way. Red-cockaded woodpeckers inhabit open pine forests that are at least 80 to 120 years old (NatureServe 2004). Hardwood forests, or pine forests with a hardwood understory are usually avoided. There is no woodpecker habitat within 4.8 km (3.0 mi) of BFN, and it is unlikely that there is any suitable habitat along the BFN transmission line rights-of-way.

Because there is no habitat on the BFN site or transmission line rights-of-way, the staff determined that continued operation of BFN over the 20-year license renewal term will have no effect on the red-cockaded woodpecker.

Gray Bat (*Myotis grisescens*)

The gray bat is reported to occur in Colbert, Franklin, Lawrence, Limestone, and Morgan Counties, Alabama, and in Tishomingo County, Mississippi. Gray bats are colonial and are restricted to cave or cave-like habitats (NatureServe 2004). They roost, and the females form maternity colonies in caves located along rivers and reservoirs over which they feed. During the winter, gray bats congregate and hibernate in a limited number of caves across the southeast. Although no suitable habitat for this species occurs within 4.8 km (3.0 mi) of BFN,

Appendix E

1 gray bats likely forage along the Tennessee River, adjacent to the plant site. Some of the BFN
2 transmission line rights-of-way are likely to be within foraging areas for this species.

3
4 Construction and maintenance of transmission line rights-of-way are designed to minimize
5 environmental impacts and transmission line right-of-way maintenance activities are reviewed
6 for potential resource issues by the TVA (Muncy et al. 1999). Access routes and activity
7 restrictions are determined based on knowledge of gray bats in the area. Mechanical clearing
8 and herbicides may be used for vegetation control in transmission line rights-of-way. Herbicide
9 application is carefully controlled and personnel who apply the herbicides are trained, licensed,
10 and follow manufacturer's guidelines, EPA guidelines, and State regulations.

11
12 The staff has reviewed TVA maintenance activities and has determined that continued
13 operation of BFN over the 20-year license renewal term may affect, but is not likely to adversely
14 affect, the gray bat.

15 16 **Indiana Bat (*Myotis sodalis*)**

17
18 The Indiana bat is reported to occur in Colbert, Lawrence, Limestone, and Morgan Counties,
19 Alabama, and in Tishomingo County, Mississippi. Indiana bats are colonial and hibernate in
20 caves during winter months, but they can be found in hollow trees and under loose tree bark
21 during the summer, where they form small maternity colonies (NatureServe 2004). Indiana bats
22 forage for insects primarily in riparian and upland forests. Roosting and foraging habitat for
23 Indiana bats is very limited on the BFN site. Water sources are composed of water lagoons,
24 sedimentation ponds, and drainage canals, and forested habitats are primarily small woodlots
25 of poor quality. No suitable Indiana bat habitat is known to occur within 4.8 km (3.0 mi) of the
26 BFN site. Some of the BFN transmission line rights-of-way are likely to be within foraging areas
27 for this species.

28
29 Construction and maintenance of transmission line rights-of-way are designed to minimize
30 environmental impacts, and may improve foraging habitat for Indiana bats. Transmission line
31 right-of-way maintenance activities are reviewed for potential resource issues by the TVA
32 (Muncy et al. 1999). Access routes and activity restrictions are determined based on
33 knowledge of Indiana bats in the area. Mechanical clearing and herbicides may be used for
34 vegetation control in transmission line rights-of-way. Herbicide application is carefully controlled
35 and personnel who apply the herbicides are trained, licensed, and follow manufacturer's
36 guidelines, EPA guidelines, and State regulations.

37
38 Because there is no habitat for Indiana bats on the BFN site, and after reviewing the TVA
39 maintenance activities, which may improve habitat along transmission line rights-of-way, the
40 staff determined that continued operation of BFN over the 20-year license renewal term may
41 affect, but is not likely to adversely affect, the Indiana bat.

1 **Price's Potato Bean (*Apios priceana*)**

2
3 Price's potato bean is reported to occur in Lee County, Mississippi. This species is found in
4 open mixed hardwood forests, often on flood plains in or near riparian areas (NatureServe
5 2004). Although thought to be somewhat dependent on disturbances that maintain an early
6 successional environment, it is also reported to be sensitive to some management activities
7 such as logging, cattle grazing, and highway rights-of-way maintenance. No populations of
8 Price's potato bean are known to exist within 4.8 km (3.0 mi) of BFN, but suitable habitat could
9 be found along the BFN transmission line rights-of-way.

10
11 Construction and maintenance of transmission line rights-of-way are designed to minimize
12 environmental impacts (Muncy et al. 1999), and may improve habitat for this species.
13 Transmission line rights-of-way maintenance activities are reviewed for potential resource
14 issues by the TVA (Muncy et al. 1999). Access routes and activity restrictions are determined
15 based on knowledge of Price's potato bean in the area. Mechanical clearing and herbicide use
16 may be used for vegetation control on transmission line rights-of-way. Herbicide application is
17 carefully controlled and personnel who apply the herbicides are trained, licensed, and follow
18 manufacturer's guidelines, EPA guidelines, and State regulations.

19
20 Because there is no habitat for Price's potato bean on the BFN site, and after reviewing the
21 TVA maintenance activities, which may improve habitat along transmission line rights-of-way,
22 the staff determined that continued operation of BFN over the 20-year license renewal term
23 may affect, but is not likely to adversely affect, Price's potato bean.

24
25 **American Hart's-Tongue Fern (*Asplenium scolopendrium* var. *americanum*)**

26
27 American hart's-tongue fern is reported to occur in Morgan County, Alabama. In the southern
28 portions of its range, this fern is found only around the openings to limestone caves and
29 sinkholes (NatureServe 2004). No populations have been recorded within 4.8 km (3.0 mi) of
30 BFN, and no suitable cave habitat has been identified along the BFN transmission line rights-of-
31 way.

32
33 Because it does not occur at the BFN site or along BFN-associated transmission line
34 rights-of-way, the staff has determined that continued operation of BFN over the 20-year
35 license renewal term will have no effect on the American hart's tongue fern.

36
37 **Leafy Prairie Clover (*Dalea foliosa*)**

38
39 Leafy prairie clover is reported to occur in Franklin, Lawrence, and Morgan Counties, Alabama.
40 This species is found in association with cedar glades in northern Alabama and central
41 Tennessee. No populations of leafy prairie clover are known from within 4.8 km (3.0 mi) of
42
43 BFN, but suitable habitat could be found along the transmission line rights-of-way. The leafy
44 prairie clover has been found within 4.8 km (3.0 mi) of the Union transmission line in Colbert
45 County, Alabama (TVA 2004b).

Appendix E

1 Construction and maintenance of the transmission line rights-of-way are designed to minimize
2 environmental impacts, and transmission line rights-of-way maintenance activities are reviewed
3 for potential resource issues by TVA (Muncy et al. 1999). Access routes and activity
4 restrictions are determined based on knowledge of leafy prairie clover in the area. Mechanical
5 clearing and herbicides may be used for vegetation control on transmission line rights-of-way.
6 Herbicide application is carefully controlled and personnel who apply the herbicides are trained,
7 licensed, and follow manufacturer's guidelines, EPA guidelines, and State regulations.

8
9 There is no habitat on the BFN site but suitable habitat could exist along a portion of the Union
10 transmission line in Colbert County, Alabama. After reviewing the TVA maintenance activities,
11 the staff has determined that continued operation of BFN over the 20-year license renewal term
12 may affect, but is not likely to adversely affect, the leafy prairie clover.

13 14 **Eggert's Sunflower (*Helianthus eggertii*)**

15
16 Eggert's sunflower is reported to occur in Colbert, Franklin, Lawrence, Limestone, and Morgan
17 Counties, Alabama. This species is found in barrens habitat within the Interior Plateau
18 Ecoregion of Kentucky, Tennessee, and Alabama (NatureServe 2004). No populations have
19 been recorded within 4.8 km (3.0 mi) of BFN. Populations may occur along the BFN
20 transmission rights-of-way because the species is reported to respond favorably to
21 management activities such as burning and mowing (NatureServe 2004).

22
23 Construction and maintenance of transmission line rights-of-way are designed to minimize
24 environmental impacts (Muncy et al. 1999), and may improve habitat for this species.
25 Transmission line right-of-way maintenance activities are reviewed for potential resource issues
26 by the TVA (Muncy et al. 1999). Access routes and activity restrictions are determined based
27 on knowledge of the Eggert's sunflower in the area. Mechanical clearing and herbicides may
28 be used for vegetation control on transmission line rights-of-way. Herbicide application is
29 carefully controlled and personnel who apply the herbicides are trained, licensed, and follow
30 manufacturer's guidelines, EPA guidelines, and State regulations.

31
32 Because there is no habitat on the BFN site and after reviewing the TVA maintenance activities,
33 which may improve habitat along transmission line rights-of-way, the staff determined that
34 continued operation of BFN over the 20-year license renewal term may affect, but is not likely to
35 adversely affect, the Eggert's sunflower.

36 37 38 39 **Fleshy-Fruited Gladecress (*Leavenworthia crassa*)**

40
41 The fleshy-fruited gladecress is listed as a candidate species by FWS and is reported to occur
42 in Lawrence and Morgan Counties, Alabama. Reportedly endemic to Lawrence and Morgan
43 Counties, this species inhabits limestone glades and has been identified from only six sites
44 (NatureServe 2004). No populations have been recorded within 4.8 km (3.0 mi) of BFN, but
45 suitable habitat could be found along the BFN transmission line rights-of-way.

1 Construction and maintenance of transmission line rights-of-way are designed to minimize
2 environmental impacts (Muncy et al. 1999), and may improve habitat for this species.
3 Transmission line right-of-way maintenance activities are reviewed for potential resource issues
4 by the TVA (Muncy et al. 1999). Access routes and activity restrictions are determined based
5 on knowledge of fleshy-fruited gladececess in the area. Mechanical clearing and herbicide use
6 may be used for vegetation control on transmission line rights-of-way. Herbicide application is
7 carefully controlled and personnel who apply the herbicides are trained, licensed, and follow
8 manufacturer's guidelines, EPA guidelines, and State regulations.

9
10 Because there is no habitat on the BFN site and after reviewing the TVA maintenance activities,
11 which may improve habitat along transmission line rights-of-way, the staff determined that
12 continued operation of BFN over the 20-year license renewal term may affect, but is not likely to
13 adversely affect, the fleshy-fruited gladececess.

14 15 **Lyrate Bladder-Pod (*Lesquerella lyrata*)**

16
17 Lyrate bladder-pod is reported to occur in Colbert, Franklin, and Lawrence Counties, Alabama.
18 The species is known from only two populations in Franklin and Colbert Counties (FWS 2004b).
19 The plant is an annual in the mustard family and is found in disturbed glade habitats. No
20 populations have been recorded within 4.8 km (3.0 mi) of BFN, but suitable habitat could be
21 found along the BFN transmission line rights-of-way.

22
23 Construction and maintenance of transmission line rights-of-way are designed to minimize
24 environmental impacts (Muncy et al. 1999), and may improve habitat for this species.
25 Transmission line right-of-way maintenance activities are reviewed for potential resource issues
26 by the TVA (Muncy et al. 1999): Access routes and activity restrictions are determined based
27 on knowledge of lyrate bladder-pod in the area. Mechanical clearing and herbicide use may be
28 used for vegetation control on transmission line rights-of-way. Herbicide application is carefully
29 controlled and personnel who apply the herbicides are trained, licensed, and follow
30 manufacturer's guidelines, EPA guidelines, and State regulations.

31
32 Because there is no habitat on the BFN site and after reviewing the TVA maintenance activities,
33 which may improve habitat along transmission line rights-of-way, the staff determined that
34 continued operation of BFN over the 20-year license renewal term may affect, but is not likely to
35 adversely affect, the lyrate bladder-pod.

36 37 **Tennessee Yellow-Eyed Grass (*Xyris tennesseensis*)**

38
39 Tennessee yellow-eyed grass is reported to occur in Franklin County, Alabama. This species
40 is found in moist-to-wet, limestone-derived soils in open or lightly wooded sites
41 (NatureServe 2004). No populations are known to exist within 4.8 km (3.0 mi) of BFN, but
42 suitable habitat could be found along the BFN transmission line rights-of-way. It has been
43 found within 4.8 km (3.0 mi) of the Union transmission line in Franklin County, Alabama
44 (TVA 2004b).

45
46 Construction and maintenance of transmission line rights-of-way are designed to minimize
47 environmental impacts (Muncy et al. 1999), and may improve habitat for this species.

Appendix E

1 Transmission line right-of-way maintenance activities are reviewed for potential resource issues
2 by the TVA (Muncy et al. 1999). Access routes and activity restrictions are determined based
3 on knowledge of Tennessee yellow-eyed grass in the area. Mechanical clearing and herbicides
4 may be used for vegetation control on transmission line rights-of-way. Herbicide application is
5 carefully controlled and personnel who apply the herbicides are trained, licensed, and follow
6 manufacturer's guidelines, EPA guidelines, and State regulations.

7
8 Because there is no habitat on the BFN site and after reviewing the TVA maintenance activities,
9 which may improve habitat along transmission line rights-of-way, the staff determined that
10 continued operation of BFN over the 20-year license renewal term may affect, but is not likely to
11 adversely affect, the Tennessee yellow-eyed grass.

12 13 5.2 Aquatic Species

14
15 A total of 38 Federally listed aquatic species on the FWS website are identified as potentially
16 occurring in the project area (i.e. Wheeler Reservoir or in streams crossed by transmission line
17 rights-of-way associated with the BFN site). Nine of these species have a reasonable potential
18 of occurring in the project area and are discussed in Section 5.2.1 below. The remaining 29
19 species are only briefly discussed in Section 5.2.2 because of presumed extinction or
20 extirpation from the project area, no recent records of collection, or because the habitat of the
21 project area is clearly unsuitable for the species.

22 23 5.2.1 Species Potentially Occurring in the Project Area

24
25 Nine aquatic species are listed as threatened, endangered, or candidate species by FWS and
26 have a reasonable potential to occur in the project area (i.e., Wheeler Reservoir or within
27 streams crossed by the transmission lines associated with BFN) (Table 2).

28 29 Anthony's Riversnail (*Athearnia anthonyi*)

30
31 Anthony's riversnail is Federally listed as endangered throughout its entire range (FWS 1994),
32 except where proposed for establishment as a nonessential experimental population in the free-
33 flowing reach of the Tennessee River from the base of Wilson Dam downstream to the back-
34 waters of Pickwick Reservoir (about 19 km [12 mi]) and the lower 8 km (5 mi) of all tributaries to
35 this reach in Colbert and Lauderdale Counties, Alabama (FWS 2001). It was known to occur in
36 Alabama, Georgia, and Tennessee. It has been extirpated from most of its historic range due
37 to pollution, siltation, and habitat modification or destruction. Many populations were lost when
38 the Tennessee River and the lower reaches of its tributaries were impounded (FWS 1994).
39 Only two populations of Anthony's riversnail are known to survive. The largest of these occurs
40 in the Tennessee River, Jackson County, Alabama, and Marion County, Tennessee, a short
41 distance downstream of Nickajack Dam. This population also extends a short distance into the
42 lower section Sequatchie River, Marion County, Tennessee (FWS 1997b). This population
43 occurs well upstream from the BFN site. The other surviving population is restricted to a
44 relatively short reach of lower Limestone Creek, Limestone County, Alabama (FWS 1997b).
45 Limestone Creek is crossed at three locations by a BFN transmission line and is closely
46 paralleled by the transmission line along two stream segments (TVA 2004b). However, the

Table 2. (contd)

1 BFN transmission line does not cross or parallel the lower section of Limestone Creek where
 2 the snail is known to occur. Anthony's riversnail inhabits large rivers and the lower reaches of
 3 larger creeks, occurring on cobble/boulder substrates in the vicinity of riffles. However, it does
 4 not always occur in strongly flowing sections (NatureServe 2004). At the two sites in Limestone
 5

6 **Table 2.** Federally Listed and Candidate Aquatic Species Potentially Occurring in Wheeler
 7 Reservoir or Streams Crossed by the Browns Ferry Nuclear Power Plant, Units 1, 2,
 8 and 3 Transmission Line Rights-of-Way.
 9

Scientific Name	Common Name	Status ^(a)	County Listings ^(b)		Habitat
			AL	MS	
Snails					
<i>Atheamnia anthonyi</i>	Anthony's riversnail	E	Co Li	--	Large rivers and lower reaches of large creeks on cobble/boulder substrates near riffles.
<i>Campeloma decampi</i>	slender campeloma	E	Li	--	Large creeks in soft sediments (sand or mud) or detritus.
<i>Pyrgulopsis pachyta</i>	armored snail	E	Li	--	Shallow, still water along the edge of pools on tree roots and detritus of creeks.
Scientific Name	Common Name	Status ^(b)	County Listings ^(a)		Habitat
			AL	MS	
Mussels					
<i>Cumberlandia monodonta</i>	spectaclecase	C	Co La Li Mo	--	Large rivers with swiftly flowing water, among boulders in patches of sand, cobble, or gravel in areas where current is reduced.
<i>Epioblasma brevidens</i>	Cumberlandian combshell	E	Co Fr Li	Ti	Coarse sand to mixtures of gravel, cobble and boulder-sized rocks in medium to large rivers; tends to occur at depths less than 1m (3 ft).
<i>Lampsilis abrupta</i>	pink mucket	E	Co La Li Mo	--	Larger rivers in gravel or sand.

1	<i>Lexingtonia</i>	slabside	C	Co	Ti	Moderate to high gradient riffles
2	<i>dolabelloides</i>	pearlymussel		Fr		in medium to large rivers.
				Li		
3	<i>Pleurobema</i>	rough pigtoe	E	Co	--	Medium to large rivers in sand
4	<i>plenum</i>			La		or gravel.
				Li		
				Mo		
5	Fish					
6	<i>Etheostoma</i>	slackwater darter	T	Li	--	Gravel-bottomed pools and
7	<i>boschungii</i>					runs of creeks and small rivers.
8	(a) Co = Colbert; Fr = Franklin; It = Itawamba; La = Lawrence; Li = Limestone; Mo = Morgan;					
9	Ti = Tishomingo; -- = not listed.					
10	(b) Status: C = candidate, E = endangered, T = threatened.					
11	Sources: ADCNR 2003; Cummings and Mayer 1992; FWS 1990b, 2000b, 2004c; Johnson and					
12	Wehrle 2004; MMNS 2002; MNHP 2002; NatureServe 2004; NCWRC 2004; Page and Burr 1991;					
13	TVA 2003, 2004a.					

14
15
16
17 Creek where Anthony's riversnail is known to occur, its density reaches several hundred
18 individuals per square meter. However, both Sequatchie and Limestone Creeks have been
19 severely impacted in the past, and continue to be impacted, by siltation and other sources of
20 pollution (e.g., pesticide spraying and mining effluents). A single catastrophic pollution event
21 could potentially destroy all populations of the snail within a creek (FWS 1994, 1997b). A
22 recovery plan for Anthony's riversnail has been prepared (FWS 1997b).

23
24 The staff visited the site and reviewed the life history information about Anthony's riversnail.
25 Based on this information, and that previously described for the TVA transmission line rights-of-
26 way maintenance procedures, the staff concludes that continued operation of BFN over the
27 20-year license renewal term may affect, but is not likely to adversely affect, Anthony's
28 riversnail.

29
30 **Slender Campeloma (*Campeloma decampi*)**

31
32 The slender campeloma is Federally listed as endangered throughout its entire range
33 (FWS 2000a). It is known to occur in only several isolated populations along Limestone, Piney,
34 and Round Island Creeks in northern Alabama (NatureServe 2004). All three creeks are
35 crossed by BFN transmission lines. Piney Creek is crossed once, while Round Island and
36 Limestone Creeks are each crossed three times. Segments of Round Island and Limestone
37 Creeks are also closely paralleled by the transmission lines. The slender campeloma has been
38 found within 4.8 km (3.0 mi) of the Trinity, Maury, and Athens transmission lines in Limestone
39 County, Alabama (TVA 2004b). The slender campeloma typically burrows in soft sediment or
40 detritus. Impacts to slender campeloma include siltation and other pollutants from poor land-
41 use practices and waste discharges (FWS 2000a).

1 The staff visited the site and reviewed the life history information about the slender campeloma.
2 On the basis of this information and information previously described for the TVA transmission
3 line right-of-way maintenance procedures, the staff concludes that continued operation of BFN
4 over the 20-year license renewal term may affect, but is not likely to adversely affect, the
5 slender campeloma.
6

7 **Armored Snail (*Pyrgulopsis pachyta*)**

8
9 The armored snail (or armored marstonia) is Federally listed as endangered throughout its
10 entire range (FWS 2000a). It is known to occur in Alabama from several isolated sites in
11 Limestone and Piney Creeks near Mooresville, Alabama (NatureServe 2004). Piney Creek was
12 formerly a tributary of Limestone Creek before the construction of Wheeler Reservoir
13 (NatureServe 2004). The BFN transmission lines cross both of these streams. BFN
14 transmission lines cross Limestone Creek at three locations and closely parallels along two
15 segments of the creek. Both streams are crossed several miles upstream from Mooresville.
16 The armored snail has been collected within 4.8 km (3.0 mi) of the Maury transmission line in
17 Limestone County, Alabama (TVA 2004b). The armored snail is found in shallow, still water
18 along the edge of pools on tree roots and detritus. It probably also occurs on mud
19 (NatureServe 2004). Impacts to the armored snail include siltation and other pollutants from
20 poor land-use practices and waste discharges (FWS 2000a).
21

22 The staff visited the site and reviewed the life history information about the armored snail. On
23 the basis of this information and information previously described for the TVA transmission line
24 right-of-way maintenance procedures, the staff concludes that continued operation of BFN over
25 the 20-year license renewal term may affect, but is not likely to adversely affect, the armored
26 snail.
27

28 **Spectaclecase (*Cumberlandia monodonta*)**

29
30 The spectaclecase is a candidate for Federal listing. Its historic range includes Alabama,
31 Arkansas, Iowa, Indiana, Illinois, Kentucky, Missouri, Nebraska, Ohio, Tennessee, Virginia, and
32 Wisconsin (FWS 2004c). It has been largely reduced to a relatively few disjunct sites. The
33 mussels at some of the sites may no longer be capable of reproduction because of loss of fish
34 hosts or adverse environmental conditions (e.g., hypolimnetic releases from reservoirs)
35 (NatureServe 2004). In Alabama, the spectaclecase is known from Limestone and Morgan
36 Counties. The spectaclecase is usually found in areas with a strong current. In medium-sized
37 rivers, it prefers coarse substrates such as cobble, gravel, or cracks in bedrock. In large rivers,
38 substrates used are typically finer and include sand or mud. The spectaclecase may be
39 associated with shoals, bars, and islands (NatureServe 2004). It is often found in small clusters
40 of the same-aged individuals (NatureServe 2004). Fish hosts for the spectaclecase are
41 unknown (Schulz and Marbain 1998). Live specimens have been collected in the main stem of
42 the Tennessee River in Colbert, Lauderdale, Limestone, and Morgan Counties as recently as
43 2000. Recent collections in the mainstem of the Tennessee River have been made in the
44 tailwaters downstream of dams. Weathered shells were collected in the Elk River, Limestone
45 County, Alabama, in 1998 and 1974 (Butler 2002).
46

47 The staff visited the site and reviewed the life history information about the spectaclecase. On
48 the basis of this information and information previously described for the TVA transmission line

1 right-of-way maintenance procedures, the staff concludes that continued operation of BFN over
2 the 20-year license renewal term may affect, but is not likely to adversely affect, the
3 spectaclecase.
4

5 **Cumberlandian Combshell (*Epioblasma brevidens*)**

6
7 The Cumberlandian combshell is Federally listed as endangered throughout its entire range
8 (FWS 1997a), except where proposed for establishment as a nonessential experimental
9 population in the free-flowing reach of the Tennessee River from the base of Wilson Dam
10 downstream to the backwaters of Pickwick Reservoir (about 19 km [12 mi]) and the lower 8 km
11 (5 mi) of all tributaries to this reach in Colbert and Lauderdale Counties, Alabama (FWS 2001).
12 A draft recovery plan has been prepared for the species (FWS 2003). The Cumberlandian
13 combshell is known to occur in Alabama, Kentucky, Tennessee, and Virginia (FWS 1997a).
14 The Cumberlandian combshell is now restricted to populations in limited areas of five
15 drainages, and some of these may no longer be reproducing. The species was eliminated from
16 much of its historic range by impoundments. Existing populations are in decline due to pollution
17 (especially from mining activities), impoundments, and siltation (FWS 1997a). It was last
18 collected from Muscle Shoals (the area now incorporated within the upper reaches of Pickwick
19 Reservoir through Wilson Reservoir and into Wheeler Reservoir) in 1925 (Garner 1997). The
20 Cumberlandian combshell is typically associated with riffle and shoal areas in medium and large
21 rivers in substrates of coarse sand to cobble. It has been apparently eliminated from the main
22 stem of the Tennessee and Cumberland Rivers (FWS 2004d). In Alabama, moribund
23 specimens were found in the late 1990s in Bear Creek, a tributary of the Tennessee River
24 (NatureServe 2004). Fish hosts for the Cumberlandian combshell include darters and sculpins
25 (Schulz and Marbain 1998). Critical habitat has been designated for the species within the
26 Tennessee and Cumberland River basins, including a portion of Bear Creek that flows through
27 Colbert County, Alabama, and Tishomingo County, Mississippi (FWS 2004d). One of the BFN
28 transmission lines crosses Bear Creek in Tishomingo County, Mississippi, within the proposed
29 reach of critical habitat.
30

31 The staff visited the site and reviewed the life history information about the Cumberlandian
32 combshell. On the basis of this information, information previously provided on the aquatic
33 resources within the Wheeler Reservoir, and information previously described for the TVA
34 transmission line right-of-way maintenance procedures, the staff concludes that continued
35 operation of BFN over the 20-year license renewal term may affect, but is not likely to adversely
36 affect, the Cumberlandian combshell.
37

38 **Pink Mucket (*Lampsilis abrupta*)**

39
40 The pink mucket is Federally listed as endangered throughout its entire range (FWS 1976). It
41 is known to occur in Alabama, Arkansas, Illinois, Indiana, Kentucky, Louisiana, Missouri, Ohio,
42 Pennsylvania, Tennessee, Virginia, and West Virginia (NatureServe 2004). It is apparently
43 surviving and reproducing in river segments that have been altered by impoundments; however,
44 its range has diminished (e.g., it has been extirpated from Ohio, Pennsylvania, and Illinois)
45 (NatureServe 2004). Within Alabama, the pink mucket occurs in Colbert, Lauderdale,
46 Limestone, Madison, Marshall, and Morgan Counties (NatureServe 2004). Suitable hosts for
47 the glochidia of the pink mucket include freshwater drum, largemouth bass, smallmouth bass,
48 spotted bass, sauger, and walleye (Fuller 1974; Barnhart et al. 1997). Use of mostly

1 piscivorous hosts by this mussel is consistent with the display of a relatively large fish-like lure
2 used by the mussel to attach hosts (Barnhart et al. 1997). The pink mucket inhabits areas of
3 large rivers with swift currents at depths ranging from 0.5 to 8.0 m (1.6 to 26.2 ft) and mixed
4 sand/gravel/cobble substrate (Barclay 2004). They are generally collected in the tailwater areas
5 downstream from the Tennessee River drainage dams (Barclay 2004). Therefore, it is unlikely
6 that the pink mucket exists in Wheeler Reservoir in the areas near or downstream from BFN.
7 The pink mucket has been found within 4.8 km (3.0 mi) of the Union transmission line in
8 Lawrence County, Alabama (TVA 2004b). Sixteen specimens of the pink mucket were
9 collected near Hobbs Island (over 64 km [40 mi] upstream of BFN) in 1998 (Yokely 1998). Past
10 and ongoing threats to the pink mucket include habitat loss and modification from dams and
11 dredging, water quality degradation, and commercial over-harvesting (NatureServe 2004). The
12 zebra mussel would also pose a threat to the pink mucket in areas where they co-exist.
13

14 The staff visited the site and reviewed the life history information about the pink mucket. On the
15 basis of this information, information previously provided on the aquatic resources in Wheeler
16 Reservoir, and information previously described for the TVA transmission line right-of-way
17 maintenance procedures, the staff concludes that continued operation of BFN over the 20-year
18 license renewal term may affect, but is not likely to adversely affect, the pink mucket.
19

20 **Slabside Pearlymussel (*Lexingtonia dolabelloides*)**

21
22 The slabside pearlymussel is a candidate for Federal listing. Its historic range includes
23 Alabama, Kentucky, Tennessee, and Virginia (FWS 2004c). Most surviving individuals are
24 restricted to two or three populations; and the long-term viability of all extant occurrences is
25 questionable (NatureServe 2004). It historically occurred in the Cumberland River, although it
26 is now extirpated from the entire Cumberland River system. The slabside pearlymussel was
27 once prevalent in the Tennessee River system. Historically, it was fairly common from Muscle
28 Shoals (the area is now incorporated within the upper reaches of Pickwick Reservoir through
29 Wilson Reservoir and into Wheeler Reservoir) to the Tennessee River headwater tributaries in
30 Virginia and the Duck River drainage. It was last collected from Muscle Shoals in 1963
31 (Garner 1997). Remaining populations occur in a number of tributary streams of the
32 Tennessee River system, but not in the main stem of the Tennessee River (NatureServe 2004).
33 Bear Creek is the only one of these streams that is crossed by a BFN transmission line. Fish
34 hosts for the slabside pearlymussel include the smallmouth bass and, possibly, various minnow
35 species (Schulz and Marbain 1998). Threats to the species include channel alterations,
36 impoundments, siltation, pollution, commercial clamming, and gravel and coal mining
37 (NatureServe 2004). It is generally found in areas of moderate to swift current velocities with
38 substrates ranging from coarse sand to heterogenous assemblages of larger-sized particles
39 (NatureServe 2004).
40

41 The staff visited the site and reviewed the life history information about the slabside
42 pearlymussel. On the basis of this information, information previously provided on the aquatic
43 resources within the Wheeler Reservoir, and information previously described for the TVA
44 transmission line rights-of-way maintenance procedures, the staff concludes that continued
45 operation of BFN over the 20-year license renewal term may affect, but is not likely to adversely
46 affect, the slabside pearlymussel.

1 **Rough Pigtoe (*Pleurobema plenum*)**

2
3 The rough pigtoe is Federally listed as endangered throughout its entire range (FWS 1976). It
4 has a wide, but very fragmented, distribution in Alabama, Indiana, Kentucky, Pennsylvania,
5 Tennessee, and Virginia (NatureServe 2004). The distribution of the rough pigtoe in Alabama
6 includes Colbert, Lauderdale, Limestone, and Morgan Counties. Within the Tennessee River,
7 the rough pigtoe is currently present in tailwaters downstream of Pickwick, Wilson, and
8 Guntersville Dams (NatureServe 2004). The rough pigtoe occurs in medium to large rivers in
9 sand, gravel, and cobble substrates in shoals, although it is occasionally found on flats and
10 muddy sand (NatureServe 2004). It does not occur in the impounded sections of rivers
11 (FWIE 1996). Therefore, it is unlikely that the rough pigtoe exists in Wheeler Reservoir in the
12 areas near or downstream from BFN. One specimen was collected near Hobbs Island (over
13 64 km [40 mi] upstream of BFN) in 1998 (Yokely 1998). Possible host fish for the rough pigtoe
14 are bluegill and rosefin shiner (*Lythrurus ardens*) (Schulz and Marbain 1998). The long-term
15 viability of most populations is in jeopardy, particularly for those in large rivers where zebra
16 mussels are established (NatureServe 2004). Other threats to the rough pigtoe include
17 impoundments, channelization, dredging, industrial and residential discharges, siltation,
18 herbicide and fertilizer run-off, loss of fish hosts, and natural predators (NatureServe 2004).

19
20 The staff visited the site and reviewed the life history information about the rough pigtoe. On
21 the basis of this information and information previously described for the TVA transmission line
22 right-of-way maintenance procedures, the staff concludes that continued operation of BFN over
23 the 20-year license renewal term may affect, but is not likely to adversely affect, the rough
24 pigtoe.

25
26 **Slackwater Darter (*Etheostoma boschungii*)**

27
28 The slackwater darter is Federally listed as threatened throughout its entire range
29 (FWS 1977b). Critical habitat was also designated for the species (FWS 1977b). It is known to
30 occur in Alabama and Tennessee. The slackwater darter occupies five tributaries of the
31 Tennessee River: Buffalo River and upper Shoal Creek in Lawrence County, Tennessee; Flint
32 River, Madison County, Alabama; Swan Creek, Limestone County, Alabama, and Cypress
33 Creek, Lauderdale County, Alabama (NatureServe 2004). Swan Creek is crossed by the Maury
34 transmission line. The slackwater darter has been found within 4.8 km (3.0 mi) of the Trinity
35 and Maury transmission lines in Limestone County, Alabama (TVA 2004b). Critical habitat for
36 the slackwater darter includes many of the permanent and intermittent streams that are
37 tributaries to Cypress Creek in Lauderdale County, Alabama, and Wayne County, Tennessee
38 (FWS 1977b). None of these streams are located near BFN transmission lines. The
39 slackwater darter typically occurs in gravel-bottomed pools in sluggish areas of creeks and
40 small rivers that are not more than 12 m (39 ft) wide and 2 m (6.6 ft) deep. They often inhabit
41 slow waters beneath undercut banks or accumulations of leaf litter or detritus. Spawning
42 occurs in very shallow (5 to 10 cm [2 to 4 in.]) clear, flowing seepage water characterized by the
43 presence of *Juncus* spp. and *Eleocharis* spp. in fields and open woods. Threats to the species
44 include habitat loss and degradation. In some locations, the heavy use of groundwater causes
45 seepage areas used for spawning to dry up (NatureServe 2004).

1
2 The staff visited the site and reviewed the life history and distribution of the slackwater darter.
3 On the basis of this information and information provided by TVA, the staff concludes that
4 continued operation of BFN over the 20-year license renewal term may affect, but is not likely to
5 adversely affect, the slackwater darter.
6

7 **5.2.2 Additional Aquatic Species**

8
9 In addition to the nine species discussed above, there are 29 additional Federally listed aquatic
10 species (including one candidate species) whose distribution includes, or historically included,
11 the Wheeler Reservoir portion of the Tennessee River or other streams, rivers, or caves within
12 the counties of Alabama and Mississippi within which the BFN transmission lines occur
13 (Table 3). However, these 29 species would not currently be expected to occur within Wheeler
14 Reservoir near or downstream of BFN (i.e., the portions of the Tennessee River that could be
15 affected by BFN operations) or within the streams crossed by the transmission lines associated
16 with BFN. The rationale for this determination is based on the following: (1) the species are
17 presumed extinct; (2) the species are presumed to be extirpated from the region; (3) there are
18 no recent records of the species in the BFN project area; (4) there are no collection records for
19 the species from pertinent locations; and/or (5) project areas of concern do not have
20 appropriate habitat for the species (e.g., county records are for streams or caves that are not
21 crossed by the BFN transmission lines). The notes column of Table 3 provides the rationale for
22 each species. The staff reviewed the design, operation, and location of the intake and
23 discharge structures at BFN and the impingement and entrainment data collected during plant
24 operation. The staff also visited the site and reviewed the life history information about these
25 29 species. On the basis of this information, information previously provided on the aquatic
26 resources within the Wheeler Reservoir, and information previously described for the TVA
27 transmission line rights-of-way maintenance procedures, the staff concludes that continued
28 operation of BFN over the 20-year license renewal Term would have no effect on these
29 species. Therefore, these species are not evaluated in any detail in this BA.
30

31 **6.0 Conclusions**

32
33 The staff identified nine terrestrial and nine aquatic species listed as threatened, endangered,
34 or candidate under the Endangered Species Act that have a reasonable potential to occur in the
35 vicinity of BFN or along the transmission line rights-of-way (including Wheeler Reservoir near
36 and downstream of BFN and within streams crossed by the BFN transmission lines). Two
37 terrestrial species were evaluated and determined that they would not occur in the project area.
38 In addition, 29 aquatic species listed by FWS were identified by the staff as having no
39 reasonable potential to occur in the project areas and were not evaluated in detail.
40

41 None of the terrestrial or aquatic species are known to inhabit areas within 4.8 km (3.0 mi) of
42 BFN. The transmission line rights-of-way may cross or contain suitable habitat for some of
43 these species, including designated critical habitat for the Cumberlandian combshell. Given
44 this possibility, TVA has designed and implemented maintenance procedures for its
45 transmission line rights-of-way that protect listed species and their habitats.
46
47
48
49

1 **Table 3.** Federally Listed Aquatic Species in Northwestern Alabama and Northeastern
 2 Mississippi that are Considered Unlikely to be Present Near the Browns Ferry
 3 Nuclear Power Plant, Units 1, 2, and 3 Site or Its Transmission Line Rights-of-Way.
 4

5	6	7	County		Notes
			AL	MS	
8	Scientific Name (Common Name)	Status ^(b)	Listings ^(a)		
			Mussels		
9	<i>Cyprogenia stegaria</i> (fanshell)	E	Co	--	Relatively deep water in gravelly substrates with moderate currents in medium to large rivers. Last collected in Muscle Shoals ^(c) circa 1976 to 1978. Live specimen last reported from Wheeler Reservoir in 1979. Possibly extirpated from Alabama.
11	<i>Dromus dromas</i> (dromedary pearlymussel)	E	Co Li Mo	--	Sand and gravel substrates in riffles and shoals of medium to large rivers. Last collected in Muscle Shoals in 1931. Only current Tennessee River records are from Meigs County, Tennessee. Possibly extirpated from Alabama.
14	<i>Epioblasma capsaeformis</i> (oyster mussel)	E	Co	--	Usually in small- to medium-sized rivers in substrates of coarse sand to boulder substrates in moderate to swift currents. Last collected from Muscle Shoals circa 1925. No longer present in the mainstem of the Tennessee River. Presumed extirpated from Alabama.
17	<i>Epioblasma florentina florentina</i> (yellow-blossom pearlymussel)	E	Co	--	Riffle and shoal areas of small-sized to medium-sized streams. Last collected from Muscle Shoals circa 1925. Not collected anywhere since 1970. Possibly extinct.
21	<i>Epioblasma florentina walkeri</i> (tan riffleshell)	E	Li	--	Headwaters, riffles, and shoals in sand and gravel substrates. Only one reproducing population known (Indian Creek of the upper Clinch River, Virginia). Presumed extirpated from Alabama.

Table 3. (contd)

3 4 5	Scientific Name (Common Name)	Status ^(b)	County Listings ^(a)		Notes
			AL	MS	
6 7	<i>Epioblasma penita</i> (Southern combshell)	E	--	It	Riffles or shoals of medium-sized rivers with sandy gravel to gravel-cobble substrates in moderate to swift current. Currently limited to the East Fork Tombigbee River, Sipsey River, and Buttahatchie River, well south of the BFN project area. Presumed extirpated from Alabama.
8 9 10 11	<i>Epioblasma torulosa</i> <i>torulosa</i> (tubercled blossom pearlymussel)	E	Co Li Mo	--	Sandy gravel substrates in riffles and shoals in rapid currents of medium to large rivers. Last collected from Muscle Shoals in 1931. Presumed extirpated from Alabama, species possibly extinct.
12 13 14	<i>Epioblasma turgidula</i> (turgid blossom pearlymussel)	E	Co Fr	--	Sand and gravel substrates of shallow, fast-flowing streams. Last collected from Muscle Shoals circa 1925. Not collected anywhere since the mid-1960s, possibly extinct.
15 16	<i>Fusconaia cor</i> (shiny pigtoe)	E	Co	--	Shoals and riffles in clear streams with moderate to fast current. Last collected from Muscle Shoals circa 1925. No recent collections from the Tennessee River or its tributaries that are crossed by the BFN transmission lines. Currently exists in the North Fork of the Holston River, the Clinch and Powell Rivers in Tennessee, and in the Paint Rock River in Alabama.
17 18	<i>Fusconaia cuneolus</i> (finerayed pigtoe)	E	Fr Li	--	Firm cobble and gravel substrates of clear, high-gradient streams. Last collected from Muscle Shoals circa 1925. No recent collections from the Tennessee River or its tributaries that are crossed by the BFN transmission lines. Currently persists in Clinch and Powell Rivers, the North Fork of the Holston River, and in the Paint Rock River.
19 20 21	<i>Hemistena lata</i> (cracking pearlymussel)	E	Co Li	--	Sand, gravel and cobble substrates in swift currents or mud and sand in slower currents of medium to large rivers. Last collected from Muscle Shoals circa 1925. Presumed extirpated from Alabama. May exist in the Clinch River, Tennessee.

Table 3. (contd)

	Scientific Name (Common Name)	Status ^(b)	County Listings ^(a)		Notes
			AL	MS	
1 2	<i>Lampsilis perovalis</i> (orangenacre mucket)	T	--	It	Medium and large rivers in gravel/cobble or gravel/coarse sand substrates. Survives in a few Tombigbee, Black Warrior, and Alabama River tributaries well south of the BFN transmission lines.
3 4	<i>Lampsilis virescens</i> (Alabama lampmussel)	E	Co Fr	--	Sand and gravel substrates in shoal areas of medium to large rivers. Last collected from Muscle Shoals circa 1925. Extirpated from most of its range. Only one live specimen found in recent years from Paint Rock River drainage in Jackson County, Alabama, well upstream from the BFN project area.
5 6	<i>Lemiox rimosus</i> (birdwing pearlymussel)	E	Co Li	--	Riffle areas with sand and gravel substrates in moderate to fast currents of creeks to medium-sized rivers. Last collected from Muscle Shoals circa 1925. Presumed extirpated from Alabama. Only a few known occurrences in the Clinch, Powell, Elk, and Duck Rivers in Tennessee and Virginia.
7 8	<i>Obovaria retusa</i> (ring pink)	E	Co Li Mo	--	Gravel and sand bars of large rivers. Last collected from Muscle Shoals in 1992. Empty shells collected from Wheeler Reservoir in 1991. Possibly extirpated from Alabama.
9 10 11 12	<i>Plethobasus cicatricosus</i> (white wartyback pearlymussel)	E	Co	--	Gravel substrates of large rivers. No living specimens found in the Tennessee River since the 1960s, although fresh dead specimens collected in 1979 and 1982 downstream of Pickwick Dam near Savannah, Tennessee. Possibly extinct.
13 14 15 16	<i>Plethobasus cooperianus</i> (orangefoot pimpleback)	E	Co Li Mo	--	Sand, gravel, and cobble substrates in riffles and shoals in deep water and steady current of large rivers. Last collected from Muscle Shoals in 1978. Possibly extirpated from Alabama.
17 18	<i>Pleurobema clava</i> (clubshell)	E	Co	--	Medium to large rivers in clean gravel or mixed gravel and sand. Last collected from Muscle Shoals circa 1925. Presumed extirpated from Alabama.

Table 3. (contd)

	Scientific Name (Common Name)	Status ^(b)	County Listings ^(a)		Notes
			AL	MS	
1 2	<i>Pleurobema curtum</i> (black clubshell)	E	--	It	Sandy gravel to gravel-cobble substrates in riffles and shoals with moderate to fast currents in medium to large rivers. Current range limited to the East Fork Tombigbee River. Possibly extinct.
3 4	<i>Pleurobema decisum</i> (southern clubshell)	E	--	It	Sand and gravel substrates of medium to large rivers. Very few viable populations occur in the Sipsey River (Tombigbee River drainage), Chewacla Creek (Tallapoosa River drainage), and the Conasauga River (upper Coosa River drainage); all three waterbodies located well outside the BFN project area. It does not occur in the Tennessee River drainage.
5 6	<i>Pleurobema perovatum</i> (ovate clubshell)	E	--	It	Moderate gradient pools and riffles of medium to large rivers. Currently found in Tombigbee River tributaries and Chewacla Creek in the Tallapoosa River drainage. It does not occur in the Tennessee River drainage.
7 8	<i>Pleurobema taitianum</i> (heavy pigtoe)	E	--	It	Riffles and shoals on sandy gravel to gravel-cobble substrates in areas of moderate to fast currents of medium to large rivers. Not known from the Tennessee River drainage. Currently only found in the Alabama River in Dallas and Lowndes Counties, Alabama.

Table 3. (contd)

	Scientific Name (Common Name)	Status ^(b)	County Listings ^(a)		Notes
			AL	MS	
1 2 3	<i>Ptychobranchnus subtentum</i> (fluted kidneyshell)	C	Li	--	Small to medium rivers in areas with swift current or riffles; larger rivers in shoal areas. Last collected from Muscle Shoals circa 1925. Presumed extirpated from Alabama.
4 5 6	<i>Quadrula intermedia</i> (Cumberland monkeyface)	E	Co Li	--	Sand and gravel substrates in shallow riffle and shoal areas of headwater streams to bigger rivers at depths to 0.6 m (2 ft). Last collected from Muscle Shoals circa 1925. Possibly extirpated from Alabama.
7 8	<i>Toxolasma cylindrellus</i> (pale lilliput)	E	Co	--	Firm rubble, gravel, and sand substrates in shallow riffles and shoals of clean, fast-flowing streams. Currently known only from the Paint Rock River drainage in Jackson County, Alabama, well upstream from the BFN project area.
9 10	<i>Villosa trabalis</i> (Cumberland bean)	E	Mo	--	Sand, gravel, and cobble substrates in waters of moderate to swift currents and depths less than 1m (3 ft) in medium to large rivers. Last collected from Muscle Shoals circa 1925. Presumed extirpated from Alabama.
11	Shrimp				
12 13	<i>Palaemonias alabamiae</i> (Alabama cave shrimp)	E	Co	--	Silt-bottom pools in caves. Currently known to occur in two caves in Madison County, Alabama. No BFN transmission lines occur near these caves.
14	Fishes				
15 16	<i>Cyprinella monacha</i> (spotfin chub)	E	Co	--	Rocky riffles and runs of clean small to medium riffles. Currently only known to exist in Tennessee and North Carolina. It is possibly extirpated from Alabama.
17 18	<i>Etheostoma wapiti</i> (boulder darter)	E	Li	--	Fast, rocky riffles of small to medium rivers. Presently restricted to the Elk River in Tennessee and Alabama, and Richland and Indian Creeks in Giles County, Tennessee. No BFN transmission lines cross these waterbodies.

Table 3. (contd)

	Scientific Name (Common Name)	Status ^(b)	County Listings ^(a)		Notes
			AL	MS	
1	(a) Co = Colbert; Fr = Franklin; It = Itawamba; La = Lawrence; Li = Limestone; Mo = Morgan.				
2	Ti = Tishomingo; -- = not listed.				
3	(b) Status: C = candidate, E = endangered, T = threatened.				
4	(c) Muscle Shoals is the area now incorporated within the upper reach of Pickwick Reservoir, through				
5	Wilson Reservoir, and into Wheeler Reservoir.				
6	Sources: ADCNR 2003; Ahlstedt and McDonough 1992; Cummings and Mayer 1992; FWS 1976,				
7	1977a, b, 1987b, 1988a, b, 1989a, b, 1990a, b, c, 1993a,b, 1997a, 2000b, 2004c; Garner 1997;				
8	Johnson and Wehrle 2004; MMNS 2002; MNHP 2002; NatureServe 2004; NCWRC 2004; Page and				
9	Burr 1991; Rogers et al. 2001; TVA 2003, 2004a.				
10					
11	The staff has determined that license renewal for BFN would have no effect on the				
12	red-cockaded woodpecker, the American hart's tongue fern, and 29 of the aquatic species.				
13	License renewal may affect, but is not likely to adversely affect, the bald eagle, gray bat,				
14	Indiana bat, Price's potato bean, leafy prairie clover, Eggert's sunflower, fleshy-fruited				
15	gladecress, lyrate bladder pod, Tennessee yellow-eyed grass, Anthony's riversnail, slender				
16	campeloma, armored snail, spectaclecase, Cumberlandian combshell, pink mucket, slabside				
17	pearlymussel, rough pigtoe, and the slackwater darter.				

7.0 References

10 CFR Part 51. Code of *Federal Regulations*, Title 10, *Energy*, Part 51, "Environmental Protection Regulations for Domestic Licensing and Regulatory Requirements."

10 CFR Part 54. Code of *Federal Regulations*, Title 10, *Energy*, Part 51, "Requirements for Renewal of Operating Licenses for Nuclear Power Plants."

Ahlstedt, S. A. and T. A. McDonough. 1992. "Quantitative Evaluation of Commercial Mussel Populations in the Tennessee River Portion of Wheeler Reservoir of Wheeler Reservoir, Alabama." Tennessee River Authority, Norris and Knoxville, Tennessee. Available on the Internet under Accession No. ML041530161, May 27, 2004 at <http://www.nrc.gov/reading-rm/adams.html>.

Alabama Department of Conservation and Natural Resources (ADCNR). 2003. "County-by-County Listing of Alabama Species on the Federal List for Threatened and Endangered Species or Whose Status Is a Concern." Alabama Department of Conservation and Natural Resources, Montgomery, Alabama. Accessed on the Internet, March 25, 2004 at <http://dcnr.state.al.us/watchable-wildlife/regulations/endangered-county.cfm>.

Alabama Department of Environmental Management (ADEM). 2003. NPDES Permit Modification Rationale Fact Sheet. Revised August, 13, 2003, Montgomery, Alabama.

Atomic Energy Act of 1954. 42 USC 2011, et seq.

Barclay, L. A. 2004. *Biological Opinion of the Tennessee Valley Authority's Proposed Reservoir Operation Study*. U.S. Fish and Wildlife Service, Tennessee Ecological Services Field Office, Cookeville, Tennessee.

Barnhart, M. C., F. A. Riusech, and A. D. Roberts. 1997. "Fish Hosts of the Federally Endangered Pink Mucket, *Lampsilis abrupta*." Triannual Unionid Report No. 13. Accessed on the Internet, January 19, 2004 at <http://ellipse.inhs.uiuc.edu/FMCS/TUR/TUR13.html>.

Baxter, D. S. and J. P. Buchanan. 1998. *Browns Ferry Nuclear Plant Thermal Variance Monitoring Program Including Statistical Analyses. Final Report*. Tennessee Valley Authority, Water Management Environmental Compliance. Available on the Internet under ADAMS Accession No. ML041530161, May 27, 2004, at <http://www.nrc.gov/reading-rm/adams.html>.

Butler, R. S. (Leader). 2002. "Status Assessment Report for the Spectaclecase, *Cumberlandia monodonta*, Occurring in the Mississippi River System (U.S. Fish and Wildlife Service Regions 3, 4, 4, and 6)." U.S. Fish and Wildlife Service, Ohio River Valley Ecosystem Team, Mollusk Subgroup, Asheville, North Carolina. Accessed on the Internet, January 20, 2004 at <http://midwest.fws.gov/endangered/clams/spectaclecase-sa.pdf>.

Carroll, B. B. 1982. Letter from B. B. Carroll, Chief, Fisheries and Aquatic Ecology Branch, Division of Water Resources, to L. W. Colaw, Assistant Director, Industrial Development, Office of Economic and Community Development, Subject: "Mallard-Fox Mussel Survey - Report." September 30, 1982. Available on the Internet under ADAMS Accession No. ML041530161, May 27, 2004, at <http://www.nrc.gov/reading-rm/adams.html>.

1 Cummings, K. S. and C. A. Mayer. 1992. "Field Guide to Freshwater Mussels of the Midwest.
2 Illinois Natural History Survey, Manual 5." Illinois Natural History Survey, Urbana, Illinois.
3 Accessed on the Internet, March 15, 2004 at
4 http://www.inhs.uiuc.edu/chf/pub/mussel_man/cover.html.

5
6 Endangered Species Act of 1973. 16 USC 1531, et seq.

7
8 Fish and Wildlife Information Exchange (FWIE). 1996. "Endangered Species Information
9 System." Virginia Polytechnic Institute and State University, Blacksburg, Virginia. Accessed on
10 the Internet, May 20, 2004 at <http://fwie.fw.vt.edu/WWW/esis/index.html>.

11
12 Fuller, S. L. H. 1974. "Clams and Mussels (Mollusca: Bivalvia)." In *Pollution Ecology of*
13 *Freshwater Invertebrates*, Hart, C. W., Jr. and S. L. H. Fuller (eds.), Chapter 8, Academic
14 Press, Inc.

15
16 Garner, J. T. 1997. "Mussels of Muscle Shoals." *Triannual Unionid, Report Number 13*.
17 Accessed on the Internet, March 25, 2004 at
18 <http://ellipse.inhs.uiuc.edu/FMCS/TUR/TUR13.html>.

19
20 Hopping, P.N. 2004. "Heat Rejection and Water Flows." Email of model results to C.L. Wilson
21 and A. Stegen, Tennessee Valley Authority Environmental Hydraulics, May 2004, Knoxville,
22 Tennessee. Available on the Internet under ADAMS Accession No. ML041530161, dated May
23 27, 2004, at <http://www.nrc.gov/reading-rm/adams.html>.

24
25 Johnson, R. and B. Wehrle. 2004. "Threatened and Endangered Species of Alabama: A
26 Guide to Assist with Forestry Activities. Invertebrates." Private Forest Management Team,
27 Auburn University, Auburn, Alabama. Accessed on the Internet, January 20, 2004 at
28 <http://www.pfmt.org/wildlife/endangered/invertebrates.htm>.

29
30 Mississippi Museum of Natural Science (MMNS). 2002. "Natural Heritage Inventory: Search
31 Animal Database." Jackson, Mississippi. Accessed on the Internet, March 17, 2004 at
32 http://www.mdwfp.com/museum/html/research/query_animals.asp?cntyID=71.

33
34 Mississippi Natural Heritage Program (MNHP). 2002. "Endangered Species of Mississippi."
35 Museum of Natural Science, Mississippi Department of Wildlife, Fisheries, and Parks, Jackson,
36 Mississippi. Accessed on the Internet, March 25, 2004 at
37 <http://www.mdwfp.com/museum/html/heritage/tandelist.pdf>.

38
39 Muncy, J. A., C. Austin, C. Brewster, A. Lewis, K. Smithson, T. Broyles, and T. Wojtalik. 1999.
40 *A Guide for Environmental Protection and Best Management Practices for Tennessee Valley*
41 *Authority Transmission Construction and Maintenance Activities*. Chattanooga, Tennessee.

42
43 NatureServe. 2004. "NatureServe Explorer: An Online Encyclopedia of Life." Version 3.1,
44 NatureServe, Arlington, Virginia. Accessed on the Internet, May 26, 2004 at
45 <http://www.natureserve.org/explorer>.

46
47 North Carolina Wildlife Resources Commission (NCWRC). 2004. "North Carolina Freshwater
48 Mussels – Species Information and Status." North Carolina Wildlife Resources Commission,
49 Nongame and Endangered Wildlife Program, Raleigh, North Carolina. Accessed on the

1 Internet, March 26, 2004 at http://www.ncwildlife.org/fs_index_07_conservation.htm.

2
3 Page, L. M. and B. M. Burr. 1991. *A Field Guide to Freshwater Fishes*. Houghton Mifflin
4 Company, Boston, Massachusetts.

5
6 Pryor, R. J. 1982. Letter from R. J. Pryor, Program Manager, Aquatic Resource Protection,
7 Fisheries and Aquatic Ecology Branch, Division of Water Resources, TVA, to J. D. Henson,
8 Supervisor, Radiological and Environmental Protection Section, Controls and Test Branch,
9 Division of Nuclear Power, TVA, Subject: "Browns Ferry Nuclear Plant (BFNP) – Proposed
10 Barge Facility." April 13, 1982. Available on the Internet under ADAMS Accession No.
11 ML041530161, May 27, 2004, at <http://www.nrc.gov/reading-rm/adams.html>.

12
13 Rogers, S. O., B. T. Watson, and R. J. Neves. 2001. "Life History and Population Biology of
14 the Endangered Tan Riffleshell (*Epioblasma Florentina Walkeri*) (Bivalvia: Unionidae)." *Journal*
15 *of the North American Benthological Society* 20(4):582-594.

16
17 Schulz, C. and K. Marbain. 1998. "A List of Host Species for Rare Freshwater Mussels in
18 Virginia." Triannual Unionid Report No. 15. Accessed on the Internet, January 19, 2004 at
19 <http://ellipse.inhs.uiuc.edu/FMCS/TUR/TUR15.html>.

20
21 Tennessee Valley Authority (TVA). 1972. *Final Environmental Statement Browns Ferry*
22 *Nuclear Plant Units 1, 2, and 3*. Office of Health and Environmental Science, Chattanooga,
23 Tennessee.

24
25 Tennessee Valley Authority (TVA). 1978. "Biological Effects of Intake Browns Ferry Nuclear
26 Plant. Volume 4: Effects of the Browns Ferry Nuclear Plant Cooling Water Intake on the Fish
27 Populations of Wheeler Reservoir." Tennessee Valley Authority, Division of Forestry, Fisheries,
28 and Wildlife Development, Fisheries and Waterfowl Resources Branch, Norris, Tennessee.
29 Available on the Internet under ADAMS Accession No. ML041530161, May 27, 2004, at
30 <http://www.nrc.gov/reading-rm/adams.html>.

31
32 Tennessee Valley Authority (TVA). 2002a. *Final Supplemental Environmental Impact*
33 *Statement for Operating License Renewal of the Browns Ferry Nuclear Plant in Athens,*
34 *Alabama*. Tennessee Valley Authority. Chattanooga, Tennessee.

35
36 Tennessee Valley Authority (TVA). 2002b. "Sport Fishing Index Ratings." Accessed on the
37 Internet <http://www.tva.gov/environment/water/sportfish.htm> on January 19, 2004.

38
39 Tennessee Valley Authority (TVA). 2003. *Applicant's Environmental Report – Operating*
40 *License Renewal Stage Browns Ferry Nuclear Plant Units 1, 2, and 3*. Tennessee Valley
41 Authority, License Nos. 50-259, 50-260, and 50-296, Tennessee Valley Authority, Knoxville,
42 Tennessee.

43
44 Tennessee Valley Authority (TVA). 2004a. *Final Programmatic Environmental Impact*
45 *Statement Tennessee Valley Authority Reservoir Operations Study Volume 1 – Environmental*
46 *Impact Study*. Tennessee Valley Authority, Chattanooga, Tennessee.

47
48 Tennessee Valley Authority (TVA). 2004b. Email from Chuck Wilson, Tennessee Valley
49 Authority, to Mike Sackschewsky, Pacific Northwest National Laboratory. Available on the

1 Internet under ADAMS accession no. ML042520143, September 2, 2004, at
2 <http://www.nrc.gov/reading-rm/adams.html>.

3
4 Tennessee Valley Authority (TVA). 2004c. *Browns Ferry Nuclear Plant (BFN), Unit 1,*
5 *Proposed Technical Specifications (TS) Change TS-431, Request for License Amendment for*
6 *Extended Power Uprate Operation, Browns Ferry Unit 1 Extended Power Uprate Environmental*
7 *Report.* Tennessee Valley Authority, Decatur, Alabama.

8
9 U.S. Environmental Protection Agency (EPA). 2004. "Ecoregions of Alabama and Georgia."
10 Accessed on the Internet, May 11, 2004 at
11 http://www.epa.gov/wed/pages/ecoregions/alga_eco.htm.

12
13 U.S. Fish and Wildlife Service (FWS). 1976. "Endangered and Threatened Wildlife and Plants;
14 Endangered Status for 159 Taxa of Animals." *Federal Register* 41(115):24062-24067.

15
16 U.S. Fish and Wildlife Service (FWS). 1977a. "Determination that the Tan Riffle Shell Is an
17 Endangered Species." *Federal Register* 42(163):42351-42353.

18
19 U.S. Fish and Wildlife Service (FWS). 1977b. "Final Threatened Status and Critical Habitat for
20 Five Species of Southeastern Fishes." *Federal Register* 42(175):45526-45530.

21
22 U.S. Fish and Wildlife Service (FWS). 1987a. *Habitat Guidelines for the Bald Eagle in the*
23 *Southeast Region, Revision 3, Atlanta, Georgia.*

24
25 U.S. Fish and Wildlife Service (FWS). 1987b. "Endangered and Threatened Wildlife and
26 Plants; Endangered Status for Marshall's Mussel (*Pleurobema marshalli*), Curtus' Mussel
27 (*Pleurobema curtum*), Judge Tait's Mussel (*Pleurobema taitianum*), the Stirrup Shell (*Quadrula*
28 *stapes*), and the Penitent Mussel (*Eploblasma (=Dysnomia) penita*)." *Federal Register*
29 52(66):311162-11169.

30
31 U.S. Fish and Wildlife Service (FWS). 1988a. "Endangered and Threatened Wildlife and
32 Plants: Determination of Endangered Species Status for the Boulder Darter." *Federal Register*
33 53(170):33996-33998.

34
35 U.S. Fish and Wildlife Service (FWS). 1988b. "Endangered and Threatened Wildlife and
36 Plants; Endangered Status for the Alabama Cave Shrimp, *Palaemonias Alabamae*." *Federal*
37 *Register* 53(173):34696-34698.

38
39 U.S. Fish and Wildlife Service (FWS). 1989a. "Endangered and Threatened Wildlife and
40 Plants: Designation of the Cracking Pearly-Mussel as an Endangered Species." *Federal*
41 *Register* 54(187):39850-39853.

42
43 U.S. Fish and Wildlife Service (FWS). 1989b. "Endangered and Threatened Wildlife and
44 Plants: Designation of the Ring Pink Mussel as an Endangered Species." *Federal Register*
45 54(188):40109-40112.

46
47 U.S. Fish and Wildlife Service (FWS). 1990a. "Fanshell (*Cyprogenia stegaria [=C. irrorta]*)." U.S. Fish and Wildlife Service, Region 4 (Southeast Region), Atlanta, Georgia. Accessed on
48 the Internet, May 24, 2004 at <http://endangered.fws.gov/i/saf14.html>.

1 U.S. Fish and Wildlife Service (FWS). 1990b. "Endangered and Threatened Wildlife and
2 Plants: Designation of the Freshwater Mussel, the Fanshell, as an Endangered Species."
3 *Federal Register* 55(120):25591-25596.
4

5 U.S. Fish and Wildlife Service (FWS). 1990c. "Species Accounts. Alabama Cave Shrimp
6 *Palaemonias (sic) alabamiae*." U.S. Fish and Wildlife Service, Jackson, Mississippi. Accessed
7 on the Internet, May 20, 2004 at <http://endangered.fws.gov/vk/sak07.html>.
8

9 U.S. Fish and Wildlife Service (FWS). 1993a. "Endangered and Threatened Wildlife and
10 Plants: Determination of Endangered Status for the Northern Riffleshell Mussel (*Epioblasma*
11 *Torulosa Rangiana*) and the Clubshell Mussel (*Pleurobema Clava*)." *Federal Register*
12 58(13):5638-5642.
13

14 U.S. Fish and Wildlife Service (FWS). 1993b. "Endangered and Threatened Wildlife and
15 Plants: Endangered Status for Eight Freshwater Mussels and Threatened Status for Three
16 Freshwater Mussels in the Mobil (*sic*) River Drainage." *Federal Register* 58(50):14330-14340.
17

18 U.S. Fish and Wildlife Service (FWS). 1994. "Endangered and Threatened Wildlife and Plants:
19 Determination of Endangered Status for the Royal Snail and Anthony's Riversnail." *Federal*
20 *Register* 59:17994-17998.
21

22
23
24 U.S. Fish and Wildlife Service (FWS). 1997a. "Endangered and Threatened Wildlife and
25 Plants: Determination of Endangered Status for the Cumberland Elktoe, Oyster Mussel,
26 Cumberlandian Combshell, Purple Bean, and Rough Rabbitsfoot." *Federal Register*
27 62(7):1647-1658.
28

29 U.S. Fish and Wildlife Service (FWS). 1997b. *Recovery Plan for Anthony's Riversnail*.
30 U.S. Fish and Wildlife Service, Region 4 (Southeast Region), Atlanta, Georgia.
31

32 U.S. Fish and Wildlife Service (FWS). 2000a. "Endangered and Threatened Wildlife and
33 Plants; Endangered Status for the Armored Snail and Slender Campeloma." *Federal Register*
34 65(38):10033-10039.
35

36 U.S. Fish and Wildlife Service (FWS). 2000b. "Endangered and Threatened Species of
37 Mississippi (Federally Listed Species by County)." U.S. Fish and Wildlife Service, Mississippi
38 Ecological Services Field Office, Jackson, Mississippi. Accessed on the Internet,
39 March 25, 2004 at http://southeast.fws.gov/jackson/MsCo_TE.html.
40

41 U.S. Fish and Wildlife Service (FWS). 2001. "Endangered and Threatened Wildlife and Plants:
42 Establishment of Nonessential Experimental Population Status for 16 Freshwater Mussels and
43 1 Freshwater Snail (Anthony's Riversnail) in the Free-Flowing Reach of the Tennessee River
44 below the Wilson Dam, Colbert and Lauderdale Counties, Alabama." *Federal Register*
45 66(115):32250- 32264.
46

47 U.S. Fish and Wildlife Service (FWS). 2003. *Agency Draft Recovery Plan for Cumberland*
48 *Elktoe (Alasmidonta Atropurpurea)*, *Oyster Mussel (Epioblasma Capsaeformis)*, *Cumberlandian*
49 *Combshell (Epioblasma Brevidens)*, *Purple bean (Villosa Perpurpurea)*, and *Rough Rabbitsfoot*.

1 (*Quadrula Cylindrica Strigillata*). Prepared by R. S. Butler and R. G. Biggins, Asheville Field
2 Office, U.S. Fish and Wildlife Service, Asheville, North Carolina for U.S. Fish and Wildlife
3 Service, Southeast Region, Atlanta, Georgia.

4
5 U.S. Fish and Wildlife Service (FWS). 2004a. "Alabama's Federally Listed Species." U.S. Fish
6 and Wildlife Service, Daphne Ecological Services Field Office, Daphne, Alabama. Accessed on
7 the Internet, January 20, 2004 at <http://daphne.fws.gov/es/specieslst.htm>.

8
9 U.S. Fish and Wildlife Service (FWS). 2004b. "U.S. Fish and Wildlife, Species Information,
10 Threatened and Endangered Animals and Plants." Accessed on the Internet, May 26, 2004 at
11 <http://endangered.fws.gov/wildlife.html>.

12
13 U.S. Fish and Wildlife Service (FWS). 2004c "Endangered and Threatened Wildlife and
14 Plants: Review of Species that Are Candidates or Proposed for Listing as Endangered or
15 Threatened; Annual Notice of Findings on Resubmitted Petitions; Annual Description of
16 Progress on Listing Actions." *Federal Register* 69(86):24876-24904.

17
18
19 U.S. Fish and Wildlife Service (FWS). 2004d. "Endangered and Threatened Wildlife and
20 Plants; Designation of Critical Habitat for Five Endangered Mussels in the Tennessee and
21 Cumberland River Basins." *Federal Register* 69(168)53136-53180.

22
23 U.S. Fish and Wildlife Service (FWS). 2004e. Letter from L. E. Goldman, Field Supervisor,
24 U.S. Fish and Wildlife Service, Daphne Field Office, Daphne, Alabama, to M. Masnik, U.S.
25 Nuclear Regulatory Commission, Division of Regulatory Improvement Programs, Washington,
26 D.C., Subject: "List of Protected Species within the Area under Evaluation for the Browns Ferry
27 Nuclear Plant License Renewal." May 19, 2004.

28
29 U.S. Nuclear Regulatory Commission (NRC). 2004. Letter from P.T. Kuo, U.S. Nuclear
30 Regulatory Commission, to L. Goldman, U.S. Fish & Wildlife Service, Requesting List of
31 Protected Species Within the Area Under Evaluation for the BFN License Renewal. Available
32 on the Internet under ADAMS accession No. ML040680881, March 5, 2004, at
33 <http://www.nrc.gov/reading-rm/adams.html>.

34
35 Yokely, P., Jr. 1998. "Mussel Study near Hobbs Island on the Tennessee River for Butler
36 Basin Marina." Unpublished report prepared for MST Engineering, Decatur, Alabama.
37 Available on the Internet under ADAMS accession no. ML041530161, May 27, 2004, at
38 <http://www.nrc.gov/reading-rm/adams.html>.

Appendix F

**GEIS Environmental Issues Not Applicable
to Browns Ferry Nuclear Power Plant, Units 1, 2, and 3**

Appendix F

GEIS Environmental Issues Not Applicable to Browns Ferry Nuclear Power Plant, Units 1, 2, and 3

Table F-1 lists those environmental issues listed in the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants (GEIS)* (NRC 1996; 1999)^(a) and 10 CFR Part 51, Subpart A, Appendix B, Table B-1, that are not applicable to Browns Ferry Nuclear Plant, Units 1, 2, and 3 (BFN) because of plant or site characteristics.

Table F-1. GEIS Environmental Issues Not Applicable to Browns Ferry Nuclear Power Plant, Units 1, 2, and 3

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	Category	GEIS Sections	Comment
SURFACE WATER QUALITY, HYDROLOGY, AND USE (FOR ALL PLANTS)			
Altered salinity gradients	1	4.2.1.2.2 4.4.2.2	The BFN cooling system does not discharge to an estuary.
AQUATIC ECOLOGY (FOR PLANTS WITH COOLING TOWER BASED HEAT DISSIPATION SYSTEMS)			
Entrainment of fish and shellfish in early life stages	1	4.3.3	This issue is related to heat-dissipation systems that are not used at BFN.
Impingement of fish and shellfish	1	4.3.3	This issue is related to heat-dissipation systems that are not used at BFN.
Heat shock	1	4.3.3	This issue is related to heat-dissipation systems that are not used at BFN.

(a) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and its Addendum 1.

Table F-1. (contd)

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	Category	GEIS Sections	Comment
GROUNDWATER USE AND QUALITY			
Groundwater-use conflicts (potable and service water, and dewatering; plants that use >100 gpm)	2	4.8.1.1 4.8.2.1	BFN uses <100 gpm of groundwater.
Groundwater-use conflicts (Ranney wells)	2	4.8.1.4	BFN does not have or use Ranney wells.
Groundwater quality degradation (Ranney wells)	1	4.8.2.2	BFN does not have or use Ranney wells.
Groundwater quality degradation (saltwater intrusion)	1	4.8.2.1	BFN does not currently use groundwater and is not near a saltwater body.
Groundwater quality degradation (cooling ponds in salt marshes)	1	4.8.3	This issue is related to a heat- dissipation system that is not installed at BFN.
Groundwater quality degradation (cooling ponds at inland sites)	2	4.8.3	This issue is related to a heat- dissipation system that is not installed at BFN.
TERRESTRIAL RESOURCES			
Cooling pond impacts on terrestrial resources	1	4.4.4	This issue is related to a heat- dissipation system that is not installed at BFN.

F.1 References

10 CFR Part 51. Code of Federal Regulations, Title 10, *Energy*, Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions."

U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*. NUREG-1437, Volumes 1 and 2, Washington, D.C.

U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants: Main Report*, "Section 6.3 – Transportation, Table 9.1, Summary of findings on NEPA issues for license renewal of nuclear power plants, Final Report." NUREG-1437, Volume 1, Addendum 1, Washington, D.C.

Appendix G

NRC Staff Evaluation of Severe Accident Mitigation Alternatives (SAMAs) for Browns Ferry Nuclear Plant, Units 1, 2, and 3, in Support of the License Renewal Application Review

Appendix G

NRC Staff Evaluation of Severe Accident Mitigation Alternatives (SAMAs) for Browns Ferry Nuclear Plant, Units 1, 2 and 3, in Support of the License Renewal Application Review

G.1 Introduction

Tennessee Valley Authority (TVA) submitted an assessment of SAMAs for Browns Ferry Nuclear Plant (BFN) Units 1, 2, and 3 as part of the Environmental Report (ER) (TVA 2003). This assessment considers all three Browns Ferry units, each operating at 120 percent of their original licensed power level. Ideally, this assessment would take advantage of a plant-specific Probabilistic Safety Assessment (PSA) that reflects operation of all three units at 120 percent of their original licensed power. However, such a PSA is not currently available. Because of the progressive screening nature of the SAMA evaluation, TVA relied on the available PSA information, along with engineering knowledge of the plant, to form a basis for the three-unit SAMA assessment. This assessment was based on the most recent PSA for Unit 2 and Unit 3 available at that time, insights from a Multiple-Unit PSA performed in 1995 to bound the effects of three-unit operation, a plant-specific offsite consequence analysis performed using the MELCOR Accident Consequence Code System 2 (MACCS2) computer program, and insights from the Browns Ferry Individual Plant Examination of External Events (IPEEE) (TVA 1995a, 1996, 1997). In identifying and evaluating potential SAMAs, TVA considered SAMA candidates that addressed the major contributors to core damage frequency (CDF) and large early release frequency (LERF), as well as generic SAMAs considered in analyses performed for other operating plants which have submitted license renewal applications. TVA identified 135 potential SAMA candidates. This list was reduced to 43 unique SAMA candidates by eliminating SAMAs that were not applicable to BFN due to design differences, had already been implemented, were similar in nature and could be combined with another SAMA, or cost more than \$6M to implement. TVA assessed the costs and benefits associated with each of the remaining SAMAs and concluded in the ER that none of the candidate SAMAs evaluated would be cost-beneficial for BFN.

Based on a review of the SAMA assessment, the NRC issued a request for additional information (RAI) to TVA by letter dated April 28, 2004 (NRC 2004). Key questions concerned: the mapping of key plant damage states to release categories; reasons for the relatively large reduction in CDF since the individual plant examination (IPE); dominant risk

Appendix G

1 contributors at BFN and the SAMAs that address these contributors; the rationale for
2 increasing the Unit 2 and 3 CDFs to account for Unit 1 operation; the sequence-specific impact
3 of Unit 1 operation on the candidate SAMAs; consideration of the potential impact of external
4 events; and details on certain SAMAs. TVA submitted additional information by letter dated
5 July 7, 2004 (TVA 2004a) including: summaries of peer review comments and their impact on
6 the SAMA analysis; a description of the various changes to the PSA model since the IPE; an
7 explanation of how of key plant damage states were mapped to release categories; a cross
8 reference of the major contributors to CDF to candidate SAMAs; discussions of the impact of
9 the operation of Unit 1 and the impact of external events. TVA's responses addressed the
10 staff's concerns.

11
12 Based on its review, the staff concluded that the contribution to risk from fire events would be
13 higher than assumed in TVA's SAMA analysis. The staff adjusted TVA's risk reduction
14 estimates to account for the contribution to risk (and risk reduction) from fire events, and found
15 that none of the candidate SAMAs would be cost-beneficial.

16
17 An assessment of SAMAs for BFN is presented below.

18 19 **G.2 Estimate of Risk for BFN**

20
21 TVA's estimates of offsite risk at BFN are summarized in Section G.2.1. The summary is
22 followed by the staff's review of TVA's risk estimates in Section G.2.2.

23 24 **G.2.1 TVA's Risk Estimates**

25
26 Two distinct analyses are combined to form the basis for the risk estimates used in the SAMA
27 analysis: (1) the BFN PSA Unit 2 and Unit 3 models, and (2) a supplemental analysis of offsite
28 consequences and economic impacts (essentially a Level 3 PSA model) developed specifically
29 for the SAMA analysis. The SAMA analysis is based on the most recent PSA models available
30 at the time of the ER, referred to as the Extended Power Uprate (EPU) PSA for Unit 2, and the
31 EPU PSA for Unit 3. (A PSA for Unit 1 was not available at the time of the SAMA analysis.)
32 The PSAs include a Level 1 analysis to determine the CDF from internally-initiated events and a
33 Level 2 analysis to assess containment performance during severe accidents. The scope of the
34 BFN PSAs does not include external events.

35
36 The baseline CDFs for the purpose of the SAMA evaluation are approximately 2.6×10^{-6} per year
37 for Unit 2 and 3.6×10^{-6} per year for Unit 3. The CDFs are based on the risk assessment for
38 internally-initiated events at EPU conditions, i.e., 120 percent of their original licensed power
39

1 level. TVA did not include the contribution to risk from external events within the BFN risk
2 estimates. This is discussed further in Sections G.2.2 and G.6.2.

3
4 The breakdown of CDF by initiating event is provided in Table G-1. As shown in this table,
5 transients and loss of offsite power initiated events are dominant contributors to the CDF.
6 Bypass events (i.e., interfacing systems loss of coolant accident) contribute two percent or less
7 to the total internal events CDF. Anticipated transients without scram (ATWS) events and
8 station blackout (SBO) events are not specifically identified in the internal events CDF
9 breakdown. In response to an RAI, TVA stated that the ATWS CDF is estimated to be 2.3×10^{-7}
10 per year for each unit, and the SBO CDF is 3.7×10^{-8} per year for Unit 2 and 3.9×10^{-8} per year for
11 Unit 3 (TVA 2004a). SAMAs to address ATWS and SBO events were considered in the SAMA
12 evaluation.

13
14 **Table G-1. BFN Core Damage Frequency**

15

Initiating Event or Accident Class	Unit 2		Unit 3	
	CDF (Per Year)	% Contribution to CDF	CDF (Per Year)	% Contribution to CDF
Transients	1.6×10^{-6}	63	1.8×10^{-6}	52
Loss of offsite power (LOOP)	4.8×10^{-7}	19	1.1×10^{-6}	32
Support system failures	2.2×10^{-7}	8	2.3×10^{-7}	7
Internal Flooding	1.0×10^{-7}	4	1.6×10^{-7}	5
Loss of coolant accidents (LOCAs)	5.3×10^{-8}	2	5.4×10^{-8}	2
Stuck open relief valves	4.7×10^{-8}	2	5.8×10^{-8}	2
Interfacing system LOCA (ISLOCA)	4.6×10^{-8}	2	4.6×10^{-8}	1
Total CDF (from internal events)	2.6×10^{-6}	100	3.4×10^{-6}	100

16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31 The Level 2 analysis utilized the plant damage state (PDS) assignment rules developed for the
32 BFN IPE to assign each of the Level 1 accident sequences that leads to core damage to a PDS
33 in the PDS matrix from the BFN IPE. The assignment rules consider the status of containment
34 (intact, bypassed, not isolated/failing early, or failing late), the status of key plant systems
35 (drywell sprays, suppression pool cooling, torus vent and reactor protection system) and other
36 conditions (vessel pressure and water on drywell floor) at the time of core damage in assigning

Appendix G

each sequence to one of 37 possible PDSs. These PDSs are then condensed into a reduced set of eight key plant damage states (KPDSs). TVA states that this mapping is done conservatively on the basis of phenomenological parameters except in a few cases where PDSs with very low relative frequencies are mapped to nonconservative KPDSs. TVA states that the overall result is a conservative estimate of risk.

Each of these KPDSs was then mapped directly to a single release category whose release fractions and other parameters were determined by MAAP analyses of representative sequences. This mapping of KPDSs to release categories on a one to one basis was done conservatively to simplify the analysis. For example, the fraction of the KPDS which includes the dominant CDF sequences which would not be expected to lead to containment failure are all assumed to lead to early containment failure for the purpose of determining the fission product release fractions. This leads to sequences, which would normally be categorized as having no containment failure, that dominate the offsite risk.

The offsite consequences and economic impact analyses use the MACCS2 code to determine the offsite risk impacts on the surrounding environment and public. Inputs for this analysis include plant-specific and site-specific input values for core radionuclide inventory, source term and release characteristics, site meteorological data, projected population distribution (within a 80 km [50-mi] radius) for the year 2036, emergency response evacuation modeling, and economic data.

In the ER, TVA estimated the dose to the population within 80 km (50 mi) of the BFN site to be approximately 0.0164 person-Sv (1.64 person-rem) per year for Unit 2, and approximately 0.0195 person-Sv (1.95 person-rem) per year for Unit 3. The breakdown of the total population

Table G-2. Breakdown of Population Dose by Containment Release Mode for BFN

Containment Release Mode	Unit 2		Unit 3	
	Population Dose (Person-Rem ¹ Per Year)	% Contribution	Population Dose (Person-Rem ¹ Per Year)	% Contribution
Early containment failure or Containment isolation failure	0.636	39	0.706	36
Bypass	0.009	<1	0.009	<1
Late containment failure	0.111	7	0.156	8
No containment failure ²	0.882	54	1.072	55
Total Population Dose	1.64	100	1.95	100

¹ One person-Rem = 0.01 person-Sv

² Release mode is dominated by KPDSs that are assigned to release categories in which containment is assumed to fail.

1 dose by containment release mode is summarized in Table G-2. The apparent conclusion that
2 population dose is dominated by events involving no containment failure is due to the
3 aforementioned assumption. Except for this, early containment failure resulting from ATWS
4 events dominates the population dose risk.

5 The above CDF and population dose risk for BFN Units 2 and 3 are based on the assumption
6 that Unit 1 is in extended lay-up and not operating. The proposed operation of Unit 1 would
7 increase the CDF and risk for Units 2 and 3 due to the decreased availability of equipment
8 shared between units, including diesel generators, the residual heat removal (RHR) service
9 water system, and the emergency cooling water system. The estimation of the CDF for Unit 1,
10 and the impact of Unit 1 operation on the CDF for Units 2 and 3 are accounted for in the SAMA
11 analysis by applying a multiplier to the estimated SAMA benefits for Units 2 and 3. This is
12 discussed further in Section G.6.

13 14 **G.2.2 Review of TVA's Risk Estimates**

15
16 TVA's determination of offsite risk at BFN is based on the following major elements:

- 17
18 • the Level 1 and 2 risk models that form the bases for the 1992 IPE submittal for Unit 2
19 (TVA 1992)
- 20
21 • the major modifications to the IPE models that have been incorporated in the BFN Unit 2
22 and Unit 3 PSAs, and
- 23
24 • the MACCS2 analyses performed to translate fission product source terms and release
25 frequencies from the Level 2 PSA models into offsite consequence measures.

26
27 Each of these elements was reviewed to determine the acceptability of TVA's risk estimates for
28 the SAMA analysis, as summarized below.

29
30 The staff's review of the BFN Unit 2 IPE is described in an NRC report dated September 28,
31 1994 (NRC 1994). In that review, the staff evaluated the methodology, models, data, and
32 assumptions used to estimate the CDF and characterize containment performance and fission
33 product releases. The staff concluded that TVA's analysis met the intent of Generic Letter
34 88-20 (NRC 1988a), with the exception of TVA's response to two parts of the containment
35 improvement program recommendations. Although the staff reviewed certain aspects of the
36 IPE in more detail than others, it primarily focused on the licensee's ability to examine BFN Unit
37 2 for severe accident vulnerabilities and not specifically on the detailed findings or quantification
38 estimates. Overall, the staff believed that TVA demonstrated an overall appreciation of severe
39 accidents and had an understanding of the most likely severe accident sequences that could
40 occur at the BFN Unit 2 facility.

41
42 There have been several revisions to the BFN PSA since the IPE was submitted. A comparison
43 of internal events risk profiles between the IPE and the PSA used in the SAMA analysis

Appendix G

1 indicates a decrease of almost 95 percent in the total CDF for Unit 2 (from 4.8×10^{-5} per year to
2 2.6×10^{-6} per year). The reduction is attributed to plant and modeling improvements that have
3 been implemented at BFN since the IPE was submitted. A summary listing of those changes
4 that resulted in the greatest impact on the total CDF was provided in the ER and in response to
5 RAIs (TVA 2003, 2004a, 2004b), and are provided in Table G-3. As noted in this table, model
6 changes to address the two CPI issues identified in the staff's SER for the IPE were also
7 incorporated in the updated PRA.
8

9 At the time the SAMA analysis was performed, TVA did not have a completed PSA model for
10 Unit 1. TVA completed the PSA model for Unit 1 in August 2004, and subsequently provided a
11 summary report to the staff describing the Unit 1 PSA results (TVA 2004b). The initial
12 conditions of the Unit 1 PSA model are with Unit 1 operating at EPU power with Units 2 and 3 in
13 service at EPU operating conditions. The CDF for Unit 1 is 1.86×10^{-6} per year. This compares
14 to the CDF ascribed to Unit 1 in the SAMA analysis of approximately 1×10^{-5} per year. The
15 breakdown of the Unit 1 CDF by initiating event is similar to that shown in Table G-1 for Units 2
16 and 3.
17

18 The results of the recently completed Unit 1 PSA suggest that the use of the multipliers to
19 estimate the impacts of multiple-unit operation in the SAMA analysis is conservative. These
20 results indicate that either multiple-unit operation reduces the CDF for Units 1 and 2 (rather
21 than increase it, as assumed in the SAMA analysis), or that the CDF for Unit 1 is noticeably
22 lower than that for Unit 2. The staff has not reviewed the details of the Unit 1 PSA, and cannot
23 validate the stated values. However, even if the Unit 1 CDF is substantially greater than the
24 value estimated in the Unit 1 PSA, it would likely be bounded by the benefits assumed in the
25 SAMA analysis (which were based on applying a multiplier of four to the benefit estimates for
26 Unit 2 CDF, as discussed in Section G.6).
27

Table G-3. Level 1 PSA Summary

Level 1 PSA Version	Unit Operating Status	Summary of Changes from Prior Version	Mean CDF (per year)
Unit 2 IPE Rev. 0 1992 (TVA 1992)	Unit 2 operating, Units 1 and 3 in lay-up	original IPE submittal, addressed only single unit operation	4.8×10^{-5} (Unit 2)
Unit 2 IPE Rev. 1A 1994	Unit 2 operating, Units 1 and 3 in lay-up	<ul style="list-style-type: none"> - used plant-specific diesel generator failure rates - credited powering of the Unit 2 4 KV shutdown boards - used the electric power recovery curves from NUREG/CR-5032 (NRC 1988b) 	7.6×10^{-6} (Unit 2)
Multiple-Unit PSA 1995 (TVA 1995b)	All units operating	<ul style="list-style-type: none"> - modeled multiple-unit initiators, e.g., loss of offsite power - changed success criteria for shared systems, e.g., residual heat removal service water - addressed and closed out the two containment performance improvement program (CPI) open items from the Unit 2 IPE SER 	2.8×10^{-5} (Unit 2)
Unit 2 PSA with Unit 3 operating May 1996 (NRC 1997c)	Units 2 and 3 operating, Unit 1 in lay- up	- refined the model for floods in the turbine building	5.4×10^{-6} (Unit 2)
Unit 3 PSA with Unit 2 operating June 1996 (NRC 1997c)	Units 2 and 3 operating, Unit 1 in lay- up	responded to staff request for a Unit 3 PSA	9.2×10^{-6} (Unit 3)
PSA Rev. 0 2002	Units 2 and 3 operating, Unit 1 in lay- up	<ul style="list-style-type: none"> - used revised transient initiating event frequencies from NUREG/CR-5750 (NRC 1999) - used updated plant-specific component failure rates, and - used revised common cause failure parameters - reevaluated human error probability - resolved BWROG certification facts and observations 	1.3×10^{-6} (Unit 2) 1.9×10^{-6} (Unit 3)

Appendix G

Table G3. (Contd)

Level 1 PSA Version	Unit Operating Status	Summary of Changes from Prior Version	Mean CDF (per year)
EPU PSA 2004 (TVA 2004b)	Units 2 and 3 operating at updated (120 percent) conditions, Unit 1 in lay-up	- eliminated credit for the control rod drive (CRD) system alone as makeup to the reactor pressure vessel at high pressure	2.6x10 ⁻⁶ (Unit 2) 3.4x10 ⁻⁶ (Unit 3)
PSA Rev. 2 August 2004 (TVA 2004b)	Unit 1 at updated (120 percent) conditions, with Units 2 and 3 in service at updated conditions	- incorporated all applicable design changes planned for implementation up to Unit 1 restart	1.86x10 ⁻⁶ (Unit 1)

The CDF value for BFN is comparable to the CDF values reported in the IPEs for other boiling water reactor (BWR) plants. Figure 11.2 of NUREG-1560 shows that the IPE-based total internal events CDF for BWR 3/4 plants ranges from 1x10⁻⁶ to 8x10⁻⁵ per year (NRC 1997a). It is recognized that other plants have reduced the values for CDF subsequent to the IPE submittals due to modeling and hardware changes. The current internal events CDF results for BFN remain comparable to other plants of similar vintage and characteristics.

The staff considered the peer reviews performed for the BFN PSA, and the potential impact of the review findings on the SAMA evaluation. In 1997, the Unit 2 PSA (with Unit 3 operating) was reviewed by the Boiling Water Reactor Owners Group (BWROG) Peer Review Team. The results of the review are summarized in response to an RAI (TVA 2004a). The following areas were deemed sufficiently important to require enhancement in the model:

- use of plant-specific data for system unavailabilities
- incorporation of common cause miscalibration of low pressure interlock
- additional containment features (e.g., external ring header) and loading issues (e.g., high blowdown)
- reassessment of the truncation value used quantification process
- incorporation of containment flood and reactor pressure vessel vent into the Level 2, along with a definition of LERF consistent with the PSA Application Guide.

According to TVA, the areas noted above have all been resolved in the PSA model used for the SAMA analysis (TVA 2004a).

1 Improvements were needed in three additional PSA elements. These elements were in the
2 areas of thermal hydraulic analysis, data analysis, and containment performance analysis. The
3 Peer Review Team recommended that five specific model enhancements be implemented to
4 address these three elements. A subsequent self assessment by TVA concluded that the facts
5 and observations associated with the three elements have been resolved.
6

7 Given that the BFN PSA has been peer reviewed and the recommended enhancements to
8 resolve known issues have been incorporated, that TVA satisfactorily addressed staff questions
9 regarding the PSA (TVA 2004a and 2004b), that PSA reflects the current units designs and the
10 planned EPU condition, and that the CDF is in the range of contemporary CDFs for similar
11 BWR plants, the staff concludes that the Level 1 PSA model is of sufficient quality to represent
12 the risk from the plant given the operational configuration assumed for the PSAs, that is, Units
13 2 and 3 operating and Unit 1 in a defueled lay-up condition.
14

15 TVA submitted an IPEEE by letters dated July 24, 1995 (TVA 1995a), June 28, 1996
16 (TVA 1996) and July 11, 1997 (TVA 1997). TVA did not identify any fundamental weaknesses
17 or vulnerabilities to severe accident risk in regard to the external events related to fire, high
18 winds, floods, and other external events. However, a number of areas were identified for
19 improvement in both the seismic and fire areas. In a letter dated June 22, 2000 (NRC 2000),
20 the staff concluded that the submittal met the intent of Supplement 4 to Generic Letter 88-20,
21 and that the licensee's IPEEE process is capable of identifying the most likely severe accidents
22 and severe accident vulnerabilities.
23

24 The IPEEE uses a focused scope EPRI seismic margins analysis. This method is qualitative
25 and does not provide numerical estimates of the CDF contributions from seismic initiators. TVA
26 found that, based on the EPRI assessment methodology, all of the plant's high confidence low
27 probability of failure (HCLPF) values were at least equal to the 0.3g review level earthquake
28 used in the IPEEE except for two 4kV/480V transformers located in the Units 1 and 2 diesel
29 generator building. These transformers were to be replaced as part of TVA's long-term
30 polychlorinated biphenyls and asbestos removal program. In response to an RAI, TVA
31 indicated that these transformers are still scheduled to be removed. Specific HCLPF values for
32 other structures or components are not provided in the IPEEE; however, TVA stated that there
33 are no other structures or components with HCLPF values less than the review level
34 earthquake acceleration of 0.3g.
35

36 In a subsequent submittal by TVA for another risk-informed application (TVA 2004c), TVA used
37 a published simplified methodology to estimate the seismic CDF as 2.5×10^{-6} per year. This is
38 based on the assumption that the plant HCLPF is equal to that for the two transformers
39 mentioned above (0.26g).
40

41 The staff has considered the impact of seismic events on the SAMA analysis from two aspects.
42 First, would any seismic-specific SAMA be expected to be cost-beneficial and second, would
43 the benefit of non-seismic SAMAs be increased significantly due to their impact on seismic

Appendix G

1 sequences. For the first situation, using the simplified methodology used by TVA (TVA 2004c),
2 an increase in plant HCLPF value from 0.3g (assuming the previously limiting transformers
3 have been removed) to 0.35g reduces the seismic CDF by approximately 0.7×10^{-6} per year or
4 approximately 30 percent of the Unit 2 CDF due to internal events. From information provided
5 in the ER (Table IV-8) this would correspond to an averted cost benefit in the range of \$20,000
6 to \$80,000, depending on the discount rate used. Increases in the seismic capacity of the plant
7 would involve modifications and reanalysis of multiple components since it is expected that
8 there are numerous components whose current HCLPF values are in the 0.3g to 0.35g range.
9 The costs associated with the modifications and analyses would be well in excess of the
10 estimated benefits, even when the impacts of alternative seismic hazard curves (i.e., the LLNL
11 curves rather than the EPRI curves), multiple-unit operation, and analysis uncertainties are
12 considered. Based on this, the staff concludes that it is unlikely that any cost effective seismic
13 SAMAs would be found.
14

15 For the second situation, the additional benefit of internal event SAMAs due to their impact on
16 seismic-initiated sequences are most likely realized in relatively low-g seismic events that are of
17 sufficient magnitude to result in either non-recoverable loss of offsite power (LOOP) events or
18 other more ordinary transient events similar to those evaluated in the internal events-PSA.
19 Plant trips due to seismic events might start to occur in the peak ground acceleration range of
20 0.15g to 0.2g (BFN has an operating basis earthquake of 0.1g.). The exceedance frequency
21 for these magnitude earthquakes is approximately 5×10^{-5} per year. For a seismic LOOP event,
22 the CDF can be estimated using this frequency and the conditional core damage probability for
23 a non-recoverable station blackout. This is estimated to be on the order of 1×10^{-3} , giving a
24 CDF or 5×10^{-8} per year. This is small compared to the internal events CDFs for BFN of 3×10^{-6}
25 per year. While the seismic SBO CDF estimated above is the same order of magnitude as the
26 internal events SBO CDF, the frequencies are so low that a cost-beneficial SBO related SAMA
27 would not be expected. (This conclusion is supported by the analysis of SAMA B04, "add
28 dedicated blackout diesel generator," which indicates that this would not be cost effective even
29 if the benefit is doubled due to the benefit from seismic events. For non-SBO sequences, the
30 seismic transient initiating event frequency estimated above of 5×10^{-5} per year is several orders
31 of magnitude lower than the internal initiating event frequencies, therefore, the added benefit
32 due to seismic sequences for the non-SBO SAMA is expected to be small.
33

34 Based on the above assessment, the staff concludes that the opportunity for seismic-related
35 SAMAs has been adequately explored and that there are no cost-beneficial, seismic-related
36 SAMA candidates.
37

38 The BFN fire analysis employed the Fire Induced Vulnerability Evaluation (FIVE) methodology
39 for screening of compartments. The licensee's overall approach in the IPEEE fire analysis is
40 similar to other fire analysis techniques, employing a graduated focus on the most important fire
41 zones using qualitative and quantitative screening criteria. The fire zones or compartments
42 were subjected to at least two screening phases. In the first phase, a compartment was
43 screened out if it was found to not contain any safety-related equipment or reactor trip initiators.

1 In the second phase, a CDF criterion of 1×10^{-6} per year was applied. The licensee used the
 2 PSA model (IPE Rev. 1 August 1994) of internal events to quantify the CDF resulting from a fire
 3 initiating event. The conditional core damage probability (CCDP) was based on the equipment
 4 and systems unaffected by the fire. The CDF for each zone was obtained by multiplying the
 5 frequency of a fire in a given fire zone by the conditional core damage probability associated
 6 with that fire zone. The screening methodology applied by the licensee makes less and less
 7 conservative assumptions (e.g., equipment that may survive the fires in the area) until a fire
 8 zone is screened out. The fire CDF (based on a summation of the fire zone CDFs) was
 9 estimated in the staff's SER to be less than 1.24×10^{-5} per year for Unit 2, and 7.5×10^{-6} per year
 10 for Unit 3, which are about factors of five and two higher than the internal events CDF used in
 11 the SAMA analysis, respectively. The zones that contributed more than 1×10^{-6} per year are
 12 listed below.

<u>Fire Zone</u>	<u>CDF</u>
Unit 2:	
2-5 621' and North 639'	1.1×10^{-6}
Control room, Unit 1 & 2	5.6×10^{-6}
Unit 3:	
Control room	3.0×10^{-6}

13
 14
 15
 16
 17
 18
 19
 20
 21
 22
 23 In light of these values, the staff asked TVA to assess the impact on the initial and final
 24 screenings if the internal events risk reduction estimates were increased by a factor that would
 25 bound the risk from fire and seismic events (NRC 2004). In response to the RAI, TVA stated
 26 that such an assessment is inappropriate since it contains an implicit assumption that the
 27 systems, structures and components (SSCs) important to the risk from internal events have
 28 equivalent importance to the risk from fire and seismic events (TVA 2004a). Additionally, TVA
 29 stated that the CDF values in NUREG-1742 (used by the staff to estimate the ratio of external
 30 to internal events risk) should be considered as upper bound values only, and that the mean
 31 CDF due to fire-related initiating events in each of the fire areas is judged to be considerably
 32 lower than these values (TVA 2004a).

33
 34 The staff agrees that the BFN fire analysis contains numerous conservatisms and that a more
 35 realistic assessment could result in a substantially lower fire CDF. Based on evaluations of past
 36 ERs submitted in support of license renewal applications, the staff believes that a more realistic
 37 fire CDF is likely a factor of two to three less than the screening values used in the FIVE
 38 methodology. Given a factor of three reduction, the resulting fire CDF would be comparable to
 39 the internal events CDF used in the SAMA analysis. This would justify use of a multiplier of two
 40 to the averted cost estimates (for internal events) to represent the additional SAMA benefits in
 41 external events. The staff's review is described in Section G.6.2.

Appendix G

1 The BFN IPEEE evaluated high winds, floods and other events using the progressive screening
2 approach recommended in NUREG-1407 (NRC 1991). Based on this evaluation, the licensee
3 determined that the risk from high winds, floods and other events (transportation and nearby
4 facility accidents) were not significant vulnerabilities at the plant.

5
6 The staff reviewed the process used by TVA to extend the containment performance (Level 2)
7 portion of the PSA to an assessment of offsite consequences (essentially a Level 3 PSA). This
8 included consideration of the source terms used to characterize fission product releases for the
9 applicable containment release category and the major input assumptions used in the offsite
10 consequence analyses. The MACCS2 code was utilized to estimate offsite consequences.
11 Plant-specific input to the code includes the BFN reactor core radionuclide inventory, source
12 terms for each release category, site-specific meteorological data, projected population
13 distribution within a 80 km (50 mile) radius for the year 2036, and emergency evacuation
14 modeling. This information is provided in Attachment E to the ER (TVA 2003).

15
16 The reactor core inventory input to the MACCS2 code was developed for an average bundle
17 thermal power level of 5.28 MW(t)h, which is representative of EPU conditions. Three fission
18 product inventories were utilized—GE Uprated, Framatome Commercial, and Framatome
19 Blended LEU. The fission product inventory for each radionuclide group is provided in Table II-
20 3 of Attachment E to the ER (TVA 2003).

21
22 TVA grouped the key plant damage states into a set of eight release categories based on their
23 expected source term results. The release fractions for each of the release categories are
24 reported in Table II-4 of Attachment E to the ER (TVA 2003). The staff concludes that the
25 process used to assign release categories and source terms is consistent with typical PSA
26 practices and acceptable for use in the SAMA analysis.

27
28 TVA used site-specific meteorological data obtained from the plant meteorological tower,
29 processed from hourly measurements for the calendar year 1980. In response to an RAI, TVA
30 stated that the 1980 data is representative, and the year 1980 was slightly wetter than average.
31 TVA further stated that use of more recent data would not yield a more accurate prediction of
32 weather for the term of license renewal (TVA 2004a).

33
34 The population distribution the applicant used as input to the MACCS2 analysis is given in
35 Tables II-1 and II-2 of Attachment E to the ER (TVA 2003). The population distribution is
36 based on the U. S. Census Bureau data from 1990 and 2000. The data were linearly
37 extrapolated to 2036. Sectors with a negative growth rate were estimated to have the same
38 population as in the year 2000 (TVA 2004b). The staff considers the methods and assumptions
39 for estimating population reasonable and acceptable for purposes of the SAMA evaluation.

40
41 The emergency evacuation model was modeled as a single evacuation zone extending out 16
42 km (10 mi) from the plant. It was assumed that 95 percent of the population evacuates radially
43 at an average speed of 0.234 meters/second 120 minutes after the alarm (TVA 2004a). This

1 assumption is conservative relative to the NUREG-1150 study (NRC 1990), which assumed
2 evacuation of 99.5 percent of the population within the emergency planning zone.
3

4 Economic data were specified for the area surrounding the plant, to a distance of 50 miles. The
5 agricultural economic data were obtained from Statistical Abstracts of the United States, 1998
6 (TVA 2004b). The values obtained from the reference document were inflated to the year 2016
7 using both seven-percent and three-percent discount factors.
8

9 The staff concludes that the methodology used by TVA to estimate the offsite consequences for
10 BFN provides an acceptable basis from which to proceed with an assessment of risk reduction
11 potential for candidate SAMAs. Accordingly, the staff based its assessment of offsite risk on
12 the CDF and offsite doses reported by TVA.
13

14 **G.3 Potential Plant Improvements**

15
16 The process for identifying potential plant improvements, an evaluation of that process, and the
17 improvements evaluated in detail by TVA are discussed in this section.
18

19 **G.3.1 Process for Identifying Potential Plant Improvements**

20
21 TVA's process for identifying potential plant improvements (SAMAs) consisted of the following
22 elements:
23

- 24 • review of the major contributors to CDF and LERF for Units 2 and 3 in the current for
25 BFN PSA,
- 26
- 27 • review of other NRC and industry documentation discussing potential plant
28 improvements, e.g., NUREG-1560, and
- 29
- 30 • review of generic SAMAs from past submittals in support of original licensing and
31 license renewal activities for other operating nuclear power plants.
32

33 Based on this process, an initial set of 135 candidate SAMAs was identified, as reported in the
34 ER. Of these, 20 are specific to BFN, and 115 are generic SAMAs from past submittals. All
35 BFN-specific SAMAs were assumed to pass the Phase 1 screening and were explicitly
36 evaluated in Phase 2. For the 115 generic SAMAs, TVA performed a qualitative screening and
37 eliminated SAMAs from further consideration using the following criteria:
38

- 39 • the SAMA is not applicable at BFN or for a BWR 4/Mark I design due to design
40 differences,
- 41
- 42 • the SAMA had already been implemented at BFN
43

Appendix G

- 1 • the SAMA is similar in nature to and could be combined with another SAMA, or
- 2
- 3 • the SAMA costs more than \$6M to implement (the maximum avoided cost for completely
- 4 eliminating severe accidents, including the effects of multiple-unit operation and
- 5 uncertainties).
- 6

7 Based on this screening, 92 SAMAs were eliminated. Of the 92 SAMAs eliminated, 45 were
8 eliminated because they were not applicable to BFN, 19 were eliminated because they already
9 had been implemented at BFN, 15 were similar to and combined with other SAMAs, and 11
10 exceeded \$6M in cost, and two were eliminated for other reasons (TVA 2003). A benefit
11 analysis was performed for each of the 43 remaining SAMA candidates.

12
13 The 43 remaining SAMAs were further evaluated and subsequently eliminated in the final
14 screening, as described in Sections G.4 and G.6.1 below.

15 16 **G.3.2 Review of TVA's Process**

17
18 TVA's efforts to identify potential SAMAs focused primarily on areas associated with internal
19 initiating events. The initial list of SAMAs generally addressed the accident categories that are
20 dominant CDF and LERF contributors at BFN.

21
22 The preliminary review of BFN's SAMA identification process raised some concerns regarding
23 the completeness of the set of SAMAs identified and the inclusion of plant-specific risk
24 contributors. The staff requested clarification regarding the portion of risk represented by the
25 dominant risk contributors. Because a review of the importance ranking of basic events in the
26 PSA could identify SAMAs that may not be apparent from a review of the top cut sets, the staff
27 also questioned whether an importance analysis was used to confirm the adequacy of the
28 SAMA identification process. In response to the RAI, TVA stated that the reviews of the
29 importance rankings and a review of the highest frequency CDF and LERF sequences from the
30 Unit 2 and Unit 3 PSA models were utilized to identify groups of sequences contributing to CDF
31 and LERF. TVA provided tables that cross referenced the ten CDF and LERF significant
32 groups with important human actions and systems (TVA 2004a). TVA also provided a cross
33 reference of the significant groups to the SAMAs evaluated in the ER. TVA explained that if an
34 appropriate generic SAMA did not address the plant-specific risk contributor, a BFN-specific
35 SAMA was developed (TVA 2004a).

36
37 While TVA did identify BFN-specific candidate SAMAs for fire (B16), earthquakes (B17) and
38 high winds, floods, transportation and other extreme external events (B19), none were
39 quantitatively evaluated due to the findings of the IPEEE that no vulnerabilities existed and/or
40 that all outliers had been satisfactorily resolved as part of the IPEEE or related programs. Even
41 though no BFN-specific external events SAMAs were quantitatively evaluated, candidate
42 SAMAs selected because of their potential risk reduction on the risk from internal events will, in
43 most cases, also reduce the risk due to external event initiators. The use of a multiplier of two

1 to the benefits estimated for the internal events for these SAMAs in part addresses the lack of
2 BFN-specific SAMAs for external events.

3
4 The staff notes that the set of SAMAs submitted is not all inclusive, since additional, possibly
5 even less expensive, design alternatives can always be postulated. However, the staff
6 concludes that the benefits of any additional modifications are unlikely to exceed the benefits of
7 the modifications evaluated and that the alternative improvements would not likely cost less
8 than the least expensive alternatives evaluated, when the subsidiary costs associated with
9 maintenance, procedures, and training are considered.

10
11 The staff concludes that TVA used a systematic and comprehensive process for identifying
12 potential plant improvements for BFN, and that the set of potential plant improvements
13 identified by TVA is reasonably comprehensive and therefore acceptable. This search included
14 reviewing insights from the IPE and IPEEE and other plant-specific studies, reviewing plant
15 improvements considered in previous SAMA analyses, and using the knowledge and
16 experience of its personnel. While explicit treatment of external events in the SAMA
17 identification process was limited, it is recognized that the absence of external event
18 vulnerabilities reasonably justifies examining primarily the internal events risk results for this
19 purpose.

20 21 **G.4 Risk Reduction Potential of Plant Improvements**

22
23 TVA evaluated the risk-reduction potential of the 43 SAMAs that were applicable to BFN. Many
24 of the SAMA evaluations were performed in a bounding fashion in that the SAMA was assumed
25 to completely eliminate the risk associated with the proposed enhancement. Such bounding
26 calculations overestimate the benefit and are conservative.

27
28 For a majority of the Phase 2 SAMAs, new PSA models that incorporate individual SAMAs were
29 developed and quantified. For several of the SAMAs, information from the PSA (e.g., system
30 importance measures) was used to estimate their potential benefit. The CDF and population
31 dose reductions were estimated using the EPU PSAs for Units 2 and 3. The new models or
32 changes made to models to quantify the impact of SAMAs are detailed in Section VI of
33 Attachment E to the ER (TVA 2003) and in response to an RAI (TVA 2004a). Table G-4 lists
34 the assumptions considered to estimate the risk reduction for each of the 43 Phase 2 SAMAs,
35 the estimated risk reduction in terms of percent reduction in CDF and population dose, and the
36 estimated total benefit (present value) of the averted risk. The determination of the benefits for
37 the various SAMAs is further discussed in Section G.6.

38
39 The staff has reviewed TVA's bases for calculating the risk reduction for the various plant
40 improvements and concludes that the rationale and assumptions for estimating risk reduction
41 are reasonable and generally conservative (i.e., the estimated risk reduction is higher than what
42 would actually be realized). Accordingly, the staff based its estimates of averted risk for the

Appendix G

1 various SAMAs on TVA's risk reduction estimates reported in the ER, but applied a multiplier to
2 the associated benefits to account for benefits in external events as discussed in Section G.6.2.

3 4 **G.5 Cost Impacts of Candidate Plant Improvements**

5
6 TVA estimated the costs of implementing the 43 candidate SAMAs through the application of
7 engineering judgment and review of prior BFN completed capital projects for similar
8 improvements. The cost estimates provided in the ER accounted for inflation (three percent per
9 year) to arrive at year 2016 estimated costs (TVA 2003).

10
11 The staff reviewed the bases for the applicant's cost estimates. For certain improvements, the
12 staff also compared the cost estimates to estimates developed elsewhere for similar
13 improvements, including estimates developed as part of other licensees' analyses of SAMAs for
14 operating reactors and advanced light-water reactors. The staff reviewed the costs and found
15 them to be consistent with estimates provided in support of other plants' analyses.

16
17 The staff concludes that the cost estimates provided by TVA are sufficient and appropriate for
18 use in the SAMA evaluation.

Table G-4. SAMA Cost/Benefit Screening Analysis

Phase 2 SAMA	Assumptions	% Risk Reduction (Unit 2) / (Unit 3)		Total Baseline Benefit (\$)¹	Estimated Cost² (S)
		CDF	Population Dose		
B01 Improve reliability of automatic depressurization system (ADS)	The failure probability of top event "operator depressurizes the reactor vessel" was set to 0	58 / 45	34 / 24	1,481,000	4,500,000
B02 Improve reliability of high pressure coolant injection (HPCI) and reactor core isolation cooling (RCIC) by adding redundant train	The failure probability of top events "start and short-term operation of HPCI and RCIC" were set to 0	57 / 50	32 / 31	1,489,000	21,900,000
B03 Improve reliability of safety relief valves (SRVs) by replacing valves with more reliable design	The failure probability of top event "hardware unavailability of SRVs" was set to 0	<1 / <1	0 / 0	6,600	21,900,000
B04 Add dedicated blackout diesel generator	The failure probability of top event "diesel B or 3EB" was set to 0	12 / 24	7 / 17	406,000	8,800,000
B05 Improve procedures and training to control pressure during ATWS	The failure probability of top event "operator depressurizes vessel" was set to 0	1 / 1	0 / <1	16,000	146,000³
B06 Automate standby liquid control (SLC) initiation to mitigate failure of SLC due to operator error during ATWS conditions	The failure probability of top event "operator initiates SLC injection" was set to 0	3 / 3	31 / 26	611,000	1,870,000
B07 Improve reliability of SLC by adding redundant train	The failure probability of top event "hardware unavailability of SLC injection" was set to 0	1 / 1	6 / 6	129,000	4,500,000

Table G-4. (Contd)

Phase 2 SAMA	Assumptions	% Risk Reduction (Unit 2) / (Unit 3)		Total Baseline Benefit (\$)¹	Estimated Cost² (\$)
		CDF	Population Dose		
B08A Decrease frequency of ISLOCA through major hardware modifications to prevent overpressurization	The ISLOCA initiating event frequency was set to 0	2 / 1	<1 / <1	39,000	21,900,000
B08B Decrease frequency of ISLOCA through improved procedures and training or minor hardware modifications	ISLOCA frequency is reduced by 50 percent	1 / 1	0 / <1	20,000	146,000³
B09 Improve suppression pool cooling reliability for transients by adding redundant train or additional cross-tie capability	The failure probability of top events "heat exchangers A and B, RHR pumps A and B, and the alignment to suppression pool cooling" were set to 0	12 / 17	7 / 12	363,000	21,900,000
B10 Automate torus cooling on high torus temperature to avoid lack of torus cooling due to operator error	The failure probability of top event "operator initiates torus cooling" was set to 0	5 / 5	3 / 3	143,000	1,870,000
B11 Improve direct current (DC) reliability through increase/improved procedures to load shed	The failure probability of top events "battery boards 1, 2, and 3" were set to 0	2 / 1	1 / 1	54,000 [11,000]⁴	146,000³
B12 Improve level control through improved procedures and training	The failure probability of top event "operator controls low pressure injection" was set to 0	<1 / <1	1 / 2	36,000	146,000³
B13 Improve suppression pool cooling by adding redundant train	The failure probability of top events "heat exchangers A, B, C, and D, RHR pumps A, B, C, and D; operator initiates suppression pool cooling mode; and switch to suppression pool cooling mode" were set to 0	3 / 2	1 / 1	67,000	8,800,000

Table G-4. (Contd)

Phase 2 SAMA	Assumptions	% Risk Reduction (Unit 2) / (Unit 3)		Total Baseline Benefit (\$)¹	Estimated Cost² (\\$)
		CDF	Population Dose		
B14 Reduce frequency of excessive LOCA by increasing reactor pressure vessel inspection frequency	The "Excessive LOCA" initiating event frequency was set to 0	<1 / <1	2 / 2	40,000	465,000
B15 Add motor-driven startup feedwater pump	A new top event, "startup feedwater pump" was inserted in the event model. The unavailability of the startup feedwater pump if offsite power is available was set to 4.2×10^{-3}	50 / 35	29 / 22	1,254,000	21,900,000
B16 Mitigate fire risk by adding new fire barriers, new cable routing, and training and procedures	No quantitative assessment was performed.	not assessed	not assessed	not assessed	>21,900,000
B17 Mitigate earthquake effects by strengthening structures and equipment	No quantitative assessment was performed.	not assessed	not assessed	not assessed	>21,900,000
B18 Implement internal flood prevention and mitigation enhancements	The frequency of all internal flood initiators were set to 0	4 / 5	2 / 4	118,000	>21,900,000
B19 Mitigate effects of high winds, floods, transportation, and other external events	No quantitative assessment was performed.	not assessed	not assessed	not assessed	not estimated
G01 Increase control rod drive (CRD) pump lube oil capacity	No quantitative assessment was performed.	not assessed	not assessed	not assessed	not estimated

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24

November 2004

G-19

Draft NUREG-1437, Supplement 21

Table G-4. (Contd)

Phase 2 SAMA	Assumptions	% Risk Reduction (Unit 2) / (Unit 3)		Total Baseline Benefit (\$)¹	Estimated Cost² (\$)
		CDF	Population Dose		
G02 Replace emergency core cooling system (ECCS) pump motor with air-cooled motors	The dependency on all RHR and core spray pumps on emergency equipment cooling water (EECW) was eliminated. All split fractions associated with RHR pumps and core spray system were reduced by 20 percent	8 / 9	4 / 6	217,000	26,400,000
G03 Implement procedures to stagger CRD pump use after a loss of service water (SW)	No quantitative assessment was performed. ⁵	not assessed	not assessed	not assessed	146,000 ³
G04 Develop/enhance procedural guidance for use of cross-tied component cooling or SW pumps	Actions necessary to align the swing pumps for EECW service are assumed to occur with a probability of 1. Reactor building closed cooling water (RBCCW) is assumed to be successful if raw cooling water (RCW) is available. The frequency of the initiator loss of RBCCW is set to 0.	2 / 2	2 / 2	74,000	146,000 ³ [377,000] ⁴
G05 Enhance procedures and operator training in support system failure sequences, with emphasis on anticipating problems and coping	Each of the split fractions associated with recovery of key support systems were assumed to improve by a factor of 3	<1 / <1	0 / 0	900	146,000 ³
G06 Improve ability to cool the residual heat removal (RHR) heat exchangers	The failure fraction for top events SW2A, SW2C, SW2B, and SW2D were set to 0	<1 / 5	0 / 3	26,000	4,500,000
G07 Provide a redundant train of ventilation	The redundant train of ventilation has an availability of 1.0 and is independent of any support system such as electric power	2 / 9	2 / 2	71,000	26,400,000

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

November 2004

G-21

Draft NUREG-1437, Supplement 21

Table G-4. (Contd)

Phase 2 SAMA	Assumptions	% Risk Reduction (Unit 2) / (Unit 3)		Total Baseline Benefit (\$) ¹	Estimated Cost ² (\$)
		CDF	Population Dose		
G08 Improve diagnosis of loss of switchgear room HVAC a) install high temperature alarm b) install redundant louver and thermostat	Top events related to diesel support recovery were set to guaranteed success	<1 / <1	0 / 0	300	a) 587,000/bldg b) 8,800,000/bldg
G09 Install a containment vent large enough to remove ATWS decay heat	The relevant logic macro (AHEAT) was modified to reflect the vent as a potential success path	3 / 2	2 / 3	97,000	8,700,000
G10 Use fire protection system as a back-up source for the drywell spray system	The top event representing the containment spray function was set to success	<1 / <1	<1 / 3	14,000	2,200,000
G11 Install a passive containment spray system	The top event representing the containment spray function was set to success	<1 / <1	<1 / 3	14,000	26,400,000
G12a Provide additional DC battery capacity	Any sequence involving successful scram, no stuck open SRVs, and successful operation and control of either HPCI or RCIC was considered to be successfully mitigated	18 / 29	10 / 21	564,000 [61,000] ⁴	4,500,000
G12b Use fuel cells instead of lead acid batteries		18 / 29	10 / 21	564,000 [61,000] ⁴	26,400,000
G12c Add redundant DC control power for SW pumps		18 / 29	10 / 21	564,000 [61,000] ⁴	1,500,000
G13a Incorporate an alternate battery charging capability	Improve the unavailability of each of the three station batteries by a factor of 10	2 / 1	1 / 1	52,000	4,500,000
G13b Replace existing batteries with more reliable ones		2 / 1	1 / 1	52,000	26,400,000

Table G-4. (Contd)

Phase 2 SAMA	Assumptions	% Risk Reduction (Unit 2) / (Unit 3)		Total Baseline Benefit (\$)¹	Estimated Cost² (\$)
		CDF	Population Dose		
G14 Develop procedures to repair or replace failed 4kV breakers	The transfer of power at the unit board level was assumed to occur without fault	<1 / <1	0 / 0	0	146,000³
G15 Use fire protection system (FPS) as a back-up source for diesel cooling	The FPS has sufficient capacity to service all 8 diesel generators. The FPS is aligned for diesel cooling in a timely manner. The FPS unavailability is set to 0.	8 / 9	4 / 6	217,000	1,500,000
G16 Improve inspection of rubber expansion joints on main condenser	The initiating event flooding frequencies were reduced from the base case by 25 percent. The new flooding frequencies for small and large turbine building floods became 1.15×10^{-2} and 1.76×10^{-3} , respectively	<1 / <1	<1 / <1	21,000	440,000
G17 Develop procedure to instruct operators to trip unneeded RHR/core spray pumps on loss of room ventilation	All requirements for area cooling were removed for the top events representing RHR and core spray pumps by reducing each corresponding split fraction by 20 percent	2 / 2	2 / 2	71,000	146,000³ [476,000]⁴
G18 Increase the SRV reseal reliability	Any valves that lift will successfully reseal	<1 / 1	<1 / 2	30,000	3,100,000
G19 Reduce DC dependency between high pressure injection system and automatic depressurization system	DC dependency for HPCI was completely removed	<1 / 1	0 / <1	10,000	1,870,000

1
2
3
4
5
6
7
8
9
10
11
Draft NUREG-1437, Supplement 21

12
13
G-22

14
15
16
17

18
19

20
21
22
23

November 2002

Table G-4. (Contd)

Phase 2 SAMA	Assumptions	% Risk Reduction (Unit 2) / (Unit 3)		Total Baseline Benefit (\$) ¹	Estimated Cost ² (\$)
		CDF	Population Dose		
G20 Use CRD for alternate boron injection	Actions by the operator are necessary to initiate boron injection. Any additional operator actions associated with initiating the CRD are represented by a top event. Any additional failure modes of the CRD system over that analyzed in the base case were not significant contributors to CRD system unavailability in its postulated function of delivering boron solution to the reactor.	<1 / <1	5 / 5	105,000	8,700,000

¹ Values are based on TVA averted cost estimates (using seven-percent discount rate) reported in the ER. The values include multipliers to the estimated benefits for Units 2 and 3 to account for multiple-unit operation. The values also include a multiplier of two to account for additional risk reduction benefits in external events.

² Estimated costs are given in 2016 dollars, and are stated for site-wide implementation unless otherwise noted.

³ Costs for a procedure and training were estimated to be \$73,000/unit (year 2016). However, due to similarities between units and shared systems, this cost was doubled to obtain a site-wide implementation cost.

⁴ The information within brackets indicates revised values were provided by the licensee in response to an RAI (TVA 2004b).

⁵ This SAMA would provide little benefit since the CRD system is a backup for high pressure injection, and it does not rely on SW.

1
2 **G.6 Cost-Benefit Comparison**

3
4 TVA's cost-benefit analysis and the staff's review are described in the following sections.

5
6 **5.1.1 G.6.1 TVA Evaluation**

7
8 The methodology used by TVA was based primarily on NRC's guidance for performing cost-benefit analysis, i.e., NUREG/BR-0184, *Regulatory Analysis Technical Evaluation Handbook* (NRC 1997b). The guidance involves determining the net value for each SAMA according to the following formula:

9
10
11
12
13
$$\text{Net Value} = (\text{APE} + \text{AOC} + \text{AOE} + \text{AOSC}) - \text{COE}$$

14
15 where,

- 16
17 APE = present value of averted public exposure (\$)
18 AOC = present value of averted offsite property damage costs (\$)
19 AOE = present value of averted occupational exposure costs (\$)
20 AOSC = present value of averted onsite costs (\$)
21 COE = cost of enhancement (\$).

22
23 If the net value of a SAMA is negative, the cost of implementing the SAMA is larger than the benefit associated with the SAMA and it is not considered cost-beneficial. TVA's derivation of each of the associated costs is summarized below. For the purposes of the SAMA analysis, TVA considered the "present" to be the year 2016; therefore, all values were recalculated to the year 2016 using a three percent per year inflation rate.

24
25
26
27
28
29 TVA presented the results for both a three-percent and seven-percent real discount rate. For the purposes of the staff's evaluation, the staff relied on the values given by TVA for the seven-percent real discount rate, but also considered the impact on the results of a three-percent discount rate.

30
31
32
33
34 Averted Public Exposure (APE) Costs

35
36 The APE costs were calculated using the following formula:

37
38
$$\text{APE} = \text{Annual reduction in public exposure } (\Delta \text{person-rem/year})$$

39 x monetary equivalent of unit dose (\$3,097 per person-rem, based on \$2,000 per
40 person-rem inflated at three percent to year 2016 values)
41 x present value conversion factor (10.76 based on a 20-year period with a seven-
42 percent discount rate).

1 As stated in NUREG/BR-0184 (NRC 1997b), it is important to note that the monetary value of
 2 the public health risk after discounting does not represent the expected reduction in public health
 3 risk due to a single accident. Rather, it is the present value of a stream of potential losses
 4 extending over the remaining lifetime (in this case, the renewal period) of the facility. Thus, it
 5 reflects the expected annual loss due to a single accident, the possibility that such an accident
 6 could occur at any time over the renewal period, and the effect of discounting these potential
 7 future losses to present value. For the purposes of initial screening, TVA calculated an APE of
 8 approximately \$54,700 (Unit 2) and \$64,900 (Unit 3) for the 20-year license renewal period,
 9 which assumes elimination of all severe accidents.

10 11 Averted Offsite Property Damage Costs (AOC)

12
13 The AOCs were calculated using the following formula:

$$14 \quad \text{AOC} = \text{Annual CDF reduction} \\ 15 \quad \quad \quad \times \text{offsite economic costs associated with a severe accident (on a per-event basis)} \\ 16 \quad \quad \quad \times \text{present value conversion factor.} \\ 17$$

18
19 For the purposes of initial screening, which assumes all severe accidents are eliminated, TVA
 20 calculated an annual offsite economic risk of about \$2,000 (Unit 2) and \$2,100 (Unit 3) based on
 21 the Level 3 risk analysis. This results in a discounted value of approximately \$21,200 (Unit 2)
 22 and \$23,000 (Unit 3) for the 20-year license renewal period.

23 24 Averted Occupational Exposure (AOE) Costs

25
26 The AOE costs were calculated using the following formula:

$$27 \quad \text{AOE} = \text{Annual CDF reduction} \\ 28 \quad \quad \quad \times \text{occupational exposure per core damage event} \\ 29 \quad \quad \quad \times \text{monetary equivalent of unit dose} \\ 30 \quad \quad \quad \times \text{present value conversion factor.} \\ 31$$

32
33 TVA derived the values for averted occupational exposure from information provided in Section
 34 5.7.3 of the regulatory analysis handbook (NRC 1997b). Best estimate values provided for
 35 immediate occupational dose (3300 person-rem) and long-term occupational dose (20,000
 36 person-rem over a 10-year cleanup period) were used. The present value of these doses was
 37 calculated using the equations provided in the handbook in conjunction with a monetary
 38 equivalent of unit dose of \$3,097 per person-rem, based on \$2,000 per person-rem inflated at
 39 three percent to year 2016 values, a real discount rate of seven-percent, and a time period of 20
 40 years to represent the license renewal period. For the purposes of initial screening, which
 41 assumes all severe accidents are eliminated, TVA calculated an AOE of approximately \$1,500
 42 (Unit 2) and \$2,000 (Unit 3) for the 20-year license renewal period.

1 Averted Onsite Costs (AOSC)

2
3 Averted onsite costs (AOSC) include averted cleanup and decontamination costs and averted
4 power replacement costs. Repair and refurbishment costs are considered for recoverable
5 accidents only and not for severe accidents. TVA derived the values for AOSC based on
6 information provided in Section 5.7.6 of the regulatory analysis handbook (NRC 1997b).

7
8 TVA divided this cost element into two parts – the Onsite Cleanup and Decontamination Cost,
9 also commonly referred to as averted cleanup and decontamination costs, and the replacement
10 power cost.

11
12 Averted cleanup and decontamination costs (ACC) were calculated using the following formula:

13
14
$$\text{ACC} = \text{Annual CDF reduction}$$

15
$$\quad \times \text{ present value of cleanup costs per core damage event}$$

16
$$\quad \times \text{ present value conversion factor.}$$

17
18 The total cost of cleanup and decontamination subsequent to a severe accident is estimated in
19 the regulatory analysis handbook to be $\$1.7 \times 10^9$, based on $\$1.1 \times 10^9$ inflated at three percent to
20 year 2016 values. This value was converted to present costs over a 10-year cleanup period and
21 integrated over the term of the proposed license extension. For the purposes of initial
22 screening, which assumes all severe accidents are eliminated, TVA calculated an ACC of
23 approximately \$48,400 (Unit 2) and \$62,000 (Unit 3) for the 20-year license renewal period.

24
25 Long-term replacement power costs (RPC) were calculated using the following formula:

26
27
$$\text{RPC} = \text{Annual CDF reduction}$$

28
$$\quad \times \text{ present value of replacement power for a single event}$$

29
$$\quad \times \text{ factor to account for remaining service years for which replacement power is}$$

30
$$\quad \text{required}$$

31
$$\quad \times \text{ reactor power scaling factor}$$

32
33 TVA based its calculations on the value of 1190 MW(e), which is the current electrical output for
34 Units 2 and 3. Therefore, TVA applied a power scaling factor of 1190 MW(e)/910 MW(e) to
35 determine the replacement power costs. For the purposes of initial screening, which assumes
36 all severe accidents are eliminated, TVA calculated an RPC of approximately \$42,200 (Unit 2)
37 and \$54,000 (Unit 3) for the 20-year license renewal period.

38
39 In response to an RAI regarding the expected output under EPU conditions, TVA stated that
40 using a scaling factor of 1250 MW(e)/910 MW(e) would result in a five-percent increase in the
41 replacement power costs, and a 1.6 percent (Unit 2) and 1.7 percent (Unit 3) increase in the total
42 avoidance costs.

43
44 Using the above equations, the total "present" (i.e., year 2016) dollar value equivalent
45 associated with completely eliminating severe accidents from internal events at Browns Ferry to

1 be about \$168,000 (Unit 2) and \$206,000 (Unit 3). Considering the effect of multiple-unit
2 operation and uncertainties, TVA conservatively established a value of \$6M for the initial
3 screening of SAMAs that are not economically feasible.

4 5 TVA's Results

6
7 The total benefit associated with each of the 43 SAMAs was evaluated by TVA. These values
8 were determined based on the above equations for the various averted costs together with the
9 estimated annual reductions in CDF and person-rem dose.

10
11 The CDF and population dose risk for BFN Units 2 and 3, which are used to calculate the
12 averted costs, are based on the assumption that Unit 1 is in extended lay-up and not operating.
13 The license renewal application presumes that Unit 1 will be returned to operation. The
14 operation of Unit 1 will increase the CDF values calculated in the Unit 2 and Unit 3 PSAs due to
15 the impact of shared equipment including diesel generators, the residual heat removal (RHR)
16 service water system, and the emergency cooling water system. This impact is estimated from
17 the results of the Multiple-Unit PSA performed in 1995 (TVA 1995b). This study indicated that
18 the mean CDF for Unit 2 with all 3 units operating (2.8×10^{-5} per year) is a factor of four greater
19 than in the earlier PSA (Unit 2 IPE Rev. 1A) with only Unit 2 operating (7.6×10^{-6} per year). For
20 the TVA SAMA evaluation, it is assumed that with all 3 units operational, the baseline CDFs and
21 risks for Units 1 and 2 are equal and will be four times greater than the CDF from the Unit 2 EPU
22 PSA. Because Unit 1 is more closely tied to Unit 2 than to Unit 3, it is expected that the impact
23 of Unit 1 operation on the Unit 3 CDF and risk would be smaller than the above impact on Unit 2.
24 Based on this reasoning, the operation of Unit 1 is assumed to result in a factor of two increase
25 in Unit 3 CDF and risk from that indicated by the Unit 3 EPU PSA. Therefore, TVA applied a
26 multiplier of four to the Unit 2 averted cost estimates (benefits), assumed these same benefits
27 for Unit 1, and applied a multiplier of two to the Unit 3 averted cost estimates. As a result, all
28 SAMAs that were evaluated were eliminated because the cost was expected to exceed the
29 estimated benefit, as adjusted to account for multiple-unit operation.

30
31 As described below, the staff based its evaluation on TVA's estimated benefits for a seven-
32 percent discount rate, applied the same multipliers as TVA to account for multiple-unit operation,
33 and applied an additional multiplier of two to the averted cost estimates for each SAMA to
34 account for the potential impact of external events. As a result, none of the SAMAs appeared to
35 be potentially cost-beneficial. However, four SAMAs appeared to be within a factor of three of
36 being cost-beneficial (i.e., SAMAs B11, G04, G12, and G17). TVA performed a more detailed
37 assessment of each of these SAMAs to more realistically estimate the risk reduction and/or
38 implementation costs for each SAMA. The revised values are denoted by brackets within Table
39 G-4. Based on this re-assessment, none of the SAMAs is within a factor of three of being cost-
40 beneficial.

1 G.6.2 Review of TVA's Cost-Benefit Evaluation

2
3 The cost-benefit analysis performed by TVA was based primarily on NUREG/BR-0184 (NRC
4 1997b) and was executed consistent with this guidance. However, TVA considered the
5 "present" to be the year 2016, and therefore, inflated dollar values to the year 2016 using a three
6 percent per year inflation rate. This was done for both implementation costs and SAMA benefits,
7 and is therefore consistent.

8
9 The TVA BFN license renewal application is made assuming that Unit 1 is returned to service.
10 As described above, the impact of all units operating is accounted for in the SAMA analysis by
11 increasing the Unit 2 risk from the EPU PSA by a factor of four and the Unit 3 risk by a factor of
12 two. The factor of four is obtained from the ratio of Unit 2 CDF in the Multiple-Unit PSA with all
13 units considered operating (Multiple-Unit PSA - 2.8×10^{-5} per year) to the CDF from the revised
14 Unit 2 IPE, which considered only Unit 2 operating (Unit 2 IPE Rev. 1A - 7.6×10^{-6} per year). The
15 factor of two used to adjust the Unit 3 risk was based on the judgment that the impact of all units
16 operating would be less for Unit 3 than for Unit 2 since Units 1 and 2 share more equipment than
17 Unit 3 shares with Units 1 and 2. The CDF for Unit 1 was assumed to be equal to the adjusted
18 CDF for Unit 2.

19
20 The staff notes that the adjustment factors for multiple-unit operation are based on the total
21 CDF. However, the impact of all units operating will vary from sequence to sequence,
22 depending on the failures involved in the sequences. For sequences that involve shared
23 systems (e.g., loss of offsite power) the increase could be larger than the average factors of four
24 (Units 1 and 2) and two (Unit 3), while for other sequences that do not involve significant shared
25 systems, the increase could be smaller.

26
27 In response to an RAI (TVA 2004a), TVA assessed the impact of multiple-unit operation on an
28 initiator-specific basis. The impact of multiple-unit operation was found to be greater than the
29 multiplier of four used (for Units 1 and 2) for four initiating events. In three cases the modeling in
30 the Multiple-Unit PSA was found to be conservative so that the correct impact of multiple-unit
31 operation would be expected to be less than that used (four for unit 2 and two for unit 3). In the
32 fourth case, the frequency of the CDF for the initiator is so small that, even if the multiplier of
33 four is used, the benefit of any SAMA that eliminates this initiator would not be cost effective.
34 The impact of three-unit operation could also reduce the availability of the emergency equipment
35 cooling water (EECW) system and the residual heat removal service water (RHRSW) system
36 which are shared between Units 1 and 2. This was also addressed by TVA in response to an
37 RAI (TVA 2004b). While the impact of this on CDF may be larger than the multiplier of four
38 used, the importance of these systems is small enough that the impact on CDF is expected to be
39 so small that it would not lead to cost effective SAMAs.

40
41 There is considerable uncertainty in the validity of the above "correction factors," or multipliers.
42 However, based on a review of the modeling changes made for the Multiple-Unit PSA, other
43 results such as the change in CDF when Unit 3 operation is accounted for (Unit 2 PSA with Unit
44 3 operating versus Unit 2 IPE Rev. 1A), and the relatively large "effective" CDF after applying
45 these factors compared to the CDF for other similar BWRs, the staff finds that these factors are

1 acceptable for estimating the impact of multiple-unit operation. It is noted that during the course
2 of the review, TVA completed a PSA for Unit 1, based on the expected configuration at the time
3 of restart, including EPU conditions (TVA 2004b). The Unit 1 CDF is 1.86×10^{-6} per year, which is
4 less than the EPU PSA CDF for Unit 2 used in the SAMA analysis. As such, the use of the Unit
5 2 CDF with a multiplier of four to represent the Unit 1 CDF appears to be bounding and
6 conservative for the purposes of the SAMA analysis.

7
8 In the IPEEE SER, the staff estimated a fire CDF 1.24×10^{-5} per year for Unit 2, and 7.5×10^{-6} per
9 year for Unit 3. In response to an RAI, TVA provided the control room fire CDF based on the
10 latest fire analysis. The control room fire CDF for BFN is approximately 1×10^{-5} per year for Unit
11 2, which is about a factor of four greater than the internal events CDF of 2.6×10^{-6} per year for
12 Unit 2 used in the SAMA analysis. TVA stated that the fire CDF values should be considered as
13 upper bound values only, and that the mean CDF due to fire-related initiating events in each of
14 the fire areas is judged to be considerably lower than these values (TVA 2004a).

15
16 The staff agrees that the BFN fire analysis contains numerous conservatisms and that a more
17 realistic assessment could result in a substantially lower fire CDF. However, the staff believes
18 that the information provided by TVA is not sufficient to ignore the risk contribution from external
19 events. Based on evaluations of past ERs submitted in support of license renewal applications,
20 the staff believes that a more realistic fire CDF is likely a factor of two to three less than the
21 screening values used in the FIVE methodology. If a factor of three reduction is applied to the
22 BFN fire CDF, the external events (fire) CDF and internal events CDF are comparable. As such,
23 this would justify use of a multiplier of two to the averted cost estimates (for internal events) to
24 represent the additional SAMA benefits in external events. Therefore, the staff applied a
25 multiplier of two the averted cost estimates (for internal events) to obtain a baseline estimate of
26 the benefits for each SAMA. This implicitly assumes that each SAMA would offer the same
27 percentage reduction in external event CDF and population dose as it offers in internal event
28 CDF and population dose. The adjusted benefit values are shown in Table G-4 for the 43
29 SAMAs. No SAMAs were found to be cost-beneficial, even after applying a multiplier of two to
30 account for external events.

31
32 The staff notes that TVA evaluated a SAMA for a control room fire, which is a one of the zones
33 that contributes largely to the fire CDF. The averted cost was estimated to be about \$479,000
34 (Unit 2) and \$239,000 (Unit 3). After accounting for multiple-unit operation, the maximum
35 averted cost was estimated to be \$4,300,000 for the site (TVA 2004b). The estimated cost to
36 install redundant remote shutdown panels is \$5M per unit. Therefore, this SAMA would not be
37 cost-beneficial.

38
39 The staff also considered the impact that further increases in the contribution from analysis
40 uncertainties would have on the estimated costs and benefits. TVA estimated that the ratio of
41 the 95th percentile to the mean CDF is 3.2 and 2.8 for Units 2 and 3, respectively (TVA 2003).
42 The staff considered the impact if the cost and benefits were altered by a factor of three to

1 account for uncertainties. Four SAMAs had estimated benefits within a factor of three of the
2 estimated implementation costs and were further evaluated.

3
4 In response to an RAI, TVA re-examined each of these SAMAs. This included re-examining the
5 modeling assumptions that could lead to overestimation of the averted costs, and refining the
6 implementations costs to better represent the actual costs that would be incurred. The results of
7 this reassessment are provided in the RAI response (TVA 2004b), and summarized below. The
8 revised values are also reported in Table G-4.

- 9
- 10 • SAMA B11 involves improving/enhancing procedures for load shedding, which would
11 improve direct current (DC) reliability. The staff estimated the benefit of this SAMA to be
12 \$54,000 for the site based on TVA's risk reduction estimate reported in the ER and a
13 multiplier of two to account for external events. Implementation costs were estimated by
14 TVA to be \$73,000/unit. However, this is a procedural modification and, therefore, the
15 staff estimates that such a modification would not be three times the estimated cost for
16 three units. Due to similarities between units and shared systems, the staff doubled
17 TVA's implementation cost from \$73,000 to \$146,000 to obtain a site-wide
18 implementation cost. Thus, this SAMA was within a factor of three of being cost-
19 beneficial. TVA's initial risk reduction estimate was bounding, in that it set the
20 unavailability of the three battery boards to zero. TVA reassessed the potential
21 enhancement and determined that, more realistically, only a 20 percent improvement
22 would be achieved (TVA 2004b). Therefore, the revised benefit, or averted cost, would
23 be 20 percent of the initial value, or approximately \$10,800. Additionally, TVA stated that
24 an engineering analysis would be necessary to determine the improvement in
25 unavailability, if any. When compared to the implementation cost of \$146,000 for the
26 site, this SAMA is not cost-beneficial, nor would it be when considering uncertainties.
 - 27
28 • SAMA G04 involves both procedural improvements and hardware changes for use of
29 cross-tied component cooling or service water (SW) pumps, which would reduce the
30 frequency of a loss of component cooling water or SW. The staff estimated the benefit
31 of this SAMA to be \$74,000 for the site based on TVA's risk reduction estimate reported
32 in the ER and a multiplier of two to account for external events. Implementation costs
33 were initially estimated by TVA to be \$73,000/unit. However, this is a procedural
34 modification, and therefore, the staff estimates that such a modification would not be
35 three times the estimated cost for three units. Due to similarities between units and
36 shared systems, the staff doubled TVA's implementation cost from \$73,000 to \$146,000
37 to obtain a site-wide implementation cost. Thus, this SAMA was within a factor of three
38 of being cost-beneficial. According to TVA, this SAMA would require a hardware
39 modification as well as the procedural modification (TVA 2004b). The cost of the
40 hardware modification was not included in the initial implementation cost, and would
41 increase the implementation cost by \$77,000/unit to \$150,000/unit. Since a procedural
42 modification is estimated by the staff to cost \$146,000 for the site, the addition of the
43 hardware modification (\$77,000/unit or \$231,000 for the site) would bring the
44 implementation costs to \$377,000 for the site. TVA also noted that the potential benefits
45 are clearly over-stated since the frequency of the loss of RBCCW initiator is assumed to

1 be zero, and that the action to align the swing pumps is assumed to occur without error.
2 The staff agrees with the revised implementation costs because of the need to develop
3 new procedure(s), to perform engineering analysis to support procedure development,
4 and to install the required hardware. The staff also agrees that the benefits would be
5 much less if more realistic assumptions are used. The staff concludes that this SAMA
6 has a negative net value. Accordingly, the staff concurs that this SAMA would not be
7 cost-beneficial at BFN even when considering uncertainties.

- 8
- 9 • SAMA G12c involves the addition of redundant DC control power for the SW pumps,
10 which would increase the reliability of the SW system and decrease CDF due to a loss of
11 SW. The staff estimated the benefit of this SAMA to be \$564,000 for the site based on
12 TVA's risk reduction estimate reported in the ER and a multiplier of two to account for
13 external events. Implementation costs were estimated by TVA to be \$1.5M for the site.
14 Thus, this SAMA was within a factor of three of being cost-beneficial. TVA's initial risk
15 reduction estimate was bounding, in that it assumed that charging capability is always
16 available to extend the life of the batteries. The assessment also assumed that if high
17 pressure coolant injection (HPCI) or reactor core isolation cooling (RCIC) maintain level
18 for six hours, then the scenario is successfully terminated. TVA reassessed the potential
19 enhancement using a more realistic, but still bounding, model that assumed that the
20 reliability of every battery would be increased as a result of the addition of redundant DC
21 control power; however, the unavailability of each battery was assumed to decrease by a
22 factor of two (TVA 2004b). This resulted in a total site benefit of \$61,000 (including the
23 multiplier of two to account for external events). The staff finds the implementation cost
24 to be reasonable and comparable to costs provided by other applicants for similar
25 modifications. Additionally, the staff agrees that the original assessment over-estimated
26 the benefit, and that the revised assessment is more realistic. Therefore, the staff
27 agrees that this SAMA would not be cost-beneficial even when considering uncertainties.
28
 - 29 • SAMA G17 involves the development of procedure(s) to instruct operators to trip
30 unneeded residual heat removal/core spray pumps on loss of room ventilation. The staff
31 estimated the benefit of this SAMA to be \$71,000 based on TVA's risk reduction estimate
32 reported in the ER and a multiplier of two to account for external events. Implementation
33 costs were estimated to be \$73,000/unit. However, this is a procedural modification, and
34 therefore, the staff estimates that such a modification would not be three times the
35 estimated cost for three units. Due to similarities between units and shared systems, the
36 staff doubled TVA's implementation cost from \$73,000 to \$146,000 to obtain a site-wide
37 implementation cost. Thus, this SAMA is within a factor of three of being cost-beneficial.
38 TVA's initial analysis assumed that the unavailability of the RHR and core spray pumps
39 would be decreased by 20 percent if dependence of room ventilation could be removed.
40 This value was derived from a review of the system analyses; ventilation failures
41 contribute approximately 20 percent to the unavailability of the RHR and core spray (CS)
42 pumps. However, engineering analyses to support the assumption that environmental
43 conditions would remain within pump operability limits if the unneeded pumps were

1 tripped would be required. Additionally, local area temperature time histories would have
2 to be conducted for all three units. TVA stated that the cost of these analyses
3 (engineering and temperature histories) were not included in the original implementation
4 costs (TVA 2004b). The cost for these analyses is estimated to be \$110K/unit; therefore,
5 the total implementation cost would be \$476,000 for the site. The staff agrees with the
6 revised implementation costs because of the need to develop new procedure(s) and to
7 perform engineering analyses and other analyses. The staff concludes that this SAMA
8 has a negative net value. Accordingly, the staff agrees that this SAMA would not be
9 cost-beneficial at BFN even when considering uncertainties.

10
11 The staff reviewed the SAMAs analyzed by TVA to determine if lower cost alternatives had been
12 evaluated, including the use of portable battery chargers. TVA did evaluate the use of portable
13 battery chargers (SAMA G13) (TVA 2003). The estimated benefit associated with this SAMA is
14 around \$52,000 per site. The implementation cost provided by TVA was over \$2M per site. This
15 implementation cost is questionable; however, the staff expects that the realistic implementation
16 costs would be greater than the estimated benefits. In SAMA G10, TVA assessed the use of the
17 fire protection system as a backup source to the drywell spray system. The estimated benefit
18 associated with this SAMA is around \$14,000, which is less than the cost that would be incurred
19 for such a modification. Although the implementation costs provided by TVA appear to be over-
20 estimated, the expected costs would be significantly greater than the estimated benefits. The
21 staff considers the evaluation and estimation of these lower cost alternatives reasonable and
22 acceptable for purposes of the SAMA evaluation.

23
24 TVA estimated all costs based on three-percent and seven-percent real discount rates. When
25 determining if a SAMA was cost-beneficial, TVA utilized the values based on the three-percent
26 real discount rate. The use of a three-percent real discount rate (rather than seven percent used
27 in the baseline) results in an increase in the maximum attainable benefit of approximately 54
28 percent. The results of using the three-percent discount rate are bounded by the staff's averted
29 cost estimates, which applied a multiplier of two to the internal events benefits to obtain a
30 baseline estimate for each SAMA.

31
32 The staff concludes that the costs of all of the SAMAs assessed would be higher than the
33 associated benefits. Improvements realized as a result of the IPE and IPEEE processes and
34 resolution of seismic outliers would minimize the likelihood of identifying further cost-beneficial
35 enhancements.

36 37 **G.7 Conclusions**

38
39 TVA compiled a list of 135 SAMA candidates based on the major contributors to CDF and LERF
40 at BFN, generic SAMAs based on analyses submitted in support of licensing activities for other
41 nuclear power plants, NRC and industry documents discussing potential plant improvements,
42 and insights from current PSA. A qualitative screening removed SAMA candidates that (1) were
43 not applicable at BFN due to design differences, (2) were related to reactor coolant pumps
44 (RCP) seal leakage, (3) had already been implemented at BFN, (4) were similar in nature to and
45 could be combined with another SAMA, or (5) cost more than \$6M to implement. A total of 92

1 SAMA candidates were eliminated based on the above criteria, leaving 43 SAMA candidates for
2 further evaluation.

3
4 Using guidance in NUREG/BR-0184 (NRC 1997b), the current PSA model, and a Level 3
5 analysis developed specifically for SAMA evaluation, a more detailed assessment of the costs
6 and benefits was developed for the 43 remaining SAMA candidates. TVA concluded in the ER
7 that none of the candidate SAMAs evaluated would be cost-beneficial for BFN because their
8 implementation costs exceeded their estimated benefits.

9
10 The staff reviewed the TVA analysis and concluded that the methods used and the
11 implementation of those methods were sound. The unavailability of a seismic and fire PSA
12 model precluded a detailed quantitative evaluation of SAMAs specifically aimed at reducing risk
13 of these initiators. In view of the relative contribution to risk from fire events indicated from the
14 BFN fire analysis, the staff applied a multiplier of two to the averted cost estimates for each
15 SAMA to account for the potential impact of external events. Even then, however, none of the
16 SAMAs were cost-beneficial.

17
18 The staff considered the impact if the cost and benefits were increased by a factor of three to
19 account for uncertainties and determined that four SAMAs could be potentially cost-beneficial.
20 TVA re-examined each of these SAMAs and provided a more realistic estimate of their benefits
21 and/or implementation costs. As a result of this reassessment, the cost-benefit analyses
22 showed that none of the candidate SAMAs was cost-beneficial.

23
24 Based on its review of the TVA SAMA analysis, the staff concurs that none of the candidate
25 SAMAs is cost-beneficial. This is based on conservative treatment of costs and benefits. This
26 conclusion is consistent with the low residual level of risk indicated in the BFN PSA and the fact
27 that BFN has already implemented the plant improvements identified from the IPE and IPEEE
28 processes, with the exception of the removal of the transformers, which is scheduled to occur in
29 the future.

30 31 **G.8 References**

32
33 Tennessee Valley Authority (TVA). 1992. Letter from Mark O. Medford, TVA, to U. S. NRC
34 Document Control Desk. Subject: Browns Ferry Nuclear Plant (BFN) – Response to Generic
35 Letter (GL) 88-20 – “Individual Plant Examination for Severe Accident Vulnerabilities – 10 CFR
36 50.54(f),” September 1, 1992.

37
38 Tennessee Valley Authority (TVA). 1995a. Letter from Pedro Salas, TVA, to U. S. NRC
39 Document Control Desk. Subject: Browns Ferry Nuclear Plant (BFN) – Generic Letter (GL) 88-
40 20, Supplement 4, Individual Plant Examination of External Events (IPEEE) for Severe Accident
41 Vulnerabilities – Partial Submittal of Report, July 24, 1995.

1 Tennessee Valley Authority (TVA). 1995b. Letter from Pedro Salas, TVA, to U. S. NRC
2 Document Control Desk. Subject: Browns Ferry Nuclear Plant (BFN) – Multi-Unit Probabilistic
3 Risk Assessment (PRA), April 14, 1995.

4
5 Tennessee Valley Authority (TVA). 1996. Letter from Pedro Salas, TVA, to U. S. NRC
6 Document Control Desk. Subject: Browns Ferry Nuclear Plant (BFN) – Units 2 and 3 – Generic
7 Letter (GL) 87-02, Supplement 1, Verification of Seismic Adequacy of Mechanical and Electrical
8 Equipment in Operating Reactors, Unresolved Safety Issue (USI) A-46 and GL 88-20,
9 Supplement 4, Individual Plant Examination of External Events (IPEEE) for Severe Accident
10 Vulnerabilities.– Submittal of Seismic Evaluation Reports (TAC Nos. M69431, M69432, M83596
11 and M83597), June 28, 1996.

12
13 Tennessee Valley Authority (TVA). 1997. Letter from T. E. Abney, TVA, to U. S. NRC
14 Document Control Desk. Subject: Browns Ferry Nuclear Plant (BFN) – Unit 3 – Generic Letter
15 (GL) 88-20, Supplement 4, Individual Plant Examination of External Events (IPEEE) for Severe
16 Accident Vulnerabilities – Submittal of Report Internal Fires Analysis (TAC No. M83597), July 11,
17 1997.

18
19 Tennessee Valley Authority (TVA). 2003. *Applicant's Environmental Report—Operating License*
20 *Renewal Stage, Browns Ferry Nuclear Power Plant Units 1, 2, and 3.* Tennessee Valley
21 Authority, Knoxville, Tennessee. December 2003.

22
23 Tennessee Valley Authority (TVA). 2004a. Letter from Mark J. Burzynski (TVA) to U. S. NRC
24 Document Control Desk. Subject: Response to Request for Additional Information (RAI)
25 Regarding Severe Accident Mitigation Alternatives for Browns Ferry Nuclear Plant (BFN), Units
26 1, 2, and 3 (TAC Nos. MC1768, MC1769, and MC1770), July 7, 2004.

27
28 Tennessee Valley Authority (TVA). 2004b. Letter from Mark J. Burzynski (TVA) to U. S. NRC
29 Document Control Desk. Subject: Response to Request for Additional Information (RAI)
30 Regarding Severe Accident Mitigation Alternatives for Browns Ferry Nuclear Plant (BFN), Units
31 1, 2, and 3, September 30, 2004.

32
33 Tennessee Valley Authority (TVA). 2004c. Letter from T. E. Abney (TVA) to U. S. NRC
34 Document Control Desk. Subject: Browns Ferry Nuclear Plant (BFN) – Units 2 and 3 –
35 Technical Specifications (TS) Change 448 - One-Time Frequency Extension for Containment
36 Integrated Leakage Rate Test (ILRT) Interval, July 8, 2004.

37
38 U.S. Nuclear Regulatory Commission (NRC). 1988a. Generic Letter 88-20, "Individual Plant
39 Examination for Severe Accident Vulnerabilities," November 23, 1988.

40
41 U.S. Nuclear Regulatory Commission (NRC). 1988b. *Modeling Time to Recovery and Initiating*
42 *Event Frequency for Loss of Offsite Power Incidents at Nuclear Power Plants.* NUREG/CR-
43 5032, January 1988.

1 U.S. Nuclear Regulatory Commission (NRC). 1990. *Severe Accident Risks: An Assessment for*
2 *Five U.S. Nuclear Power Plants*. NUREG-1150, Washington, D.C.

3
4 U.S. Nuclear Regulatory Commission (NRC). 1991. *Procedural and Submittal Guidance for the*
5 *Individual Plant Examination of External Events (IPEEE) for Severe Accident Vulnerabilities*.
6 NUREG-1407, Washington, D.C.

7
8 U.S. Nuclear Regulatory Commission (NRC). 1994. Letter from Joseph F. Williams, U. S. NRC,
9 to Oliver D. Kingsley, Jr., TVA. Subject: Browns Ferry Nuclear Plant Unit 2 -- Individual Plant
10 Examination Submittal for Internal Events (TAC No. M74385), September 28, 1994.

11
12 U.S. Nuclear Regulatory Commission (NRC). 1997a. *Individual Plant Examination Program:*
13 *Perspectives on Reactor Safety and Plant Performance*. NUREG-1560, Washington, D.C.

14
15 U.S. Nuclear Regulatory Commission (NRC). 1997b. *Regulatory Analysis Technical Evaluation*
16 *Handbook*. NUREG/BR-0184, Washington, D.C.


17
18 U.S. Nuclear Regulatory Commission (NRC). 1997c. Memorandum to File from Joseph F.
19 Williams, U.S. NRC. Subject: Browns Ferry Nuclear Plant Units 2 and 3 Probabilistic Safety
20 Assessments, August 6, 1997.

21
22 U.S. Nuclear Regulatory Commission (NRC). 1999. *Rates of Initiating Events at U.S. Nuclear*
23 *Power Plants*. NUREG/CR-5750, Idaho National Engineering and Environmental Laboratory,
24 February 1999.

25
26 U.S. Nuclear Regulatory Commission (NRC). 2000. Letter from William O. Long, U.S. NRC to
27 J. A. Scalice, Tennessee Valley Authority. Subject: Browns Ferry Units 1, 2 and 3, Individual
28 Plant Examination of External Events (IPEEE) and Related Generic Safety Issues, Issuance of
29 Staff Evaluation (TAC Nos. M83595, M83596, M83697), June 22, 2000.

30
31 U.S. Nuclear Regulatory Commission (NRC). 2004. Letter from Michael T. Masnik, U.S. NRC
32 to J. A. Scalice, Tennessee Valley Authority. Subject: Request for Additional Information (RAI)
33 Regarding Severe Accident Mitigation Alternatives for the Browns Ferry Nuclear Plant, Units 1,
34 2, and 3 (TAC Nos. MC1768, MC1769, and MC1770), April 28, 2004.

<p>NRC FORM 335 (9-2004) NRCMD 3.7</p> <p style="text-align: center;">U.S. NUCLEAR REGULATORY COMMISSION</p> <p style="text-align: center;">BIBLIOGRAPHIC DATA SHEET <i>(See instructions on the reverse)</i></p>	<p>1. REPORT NUMBER (Assigned by NRC, Add Vol., Supp., Rev., and Addendum Numbers, if any.)</p> <p style="text-align: center;">NUREG-1437, Supplement 21</p>				
<p>2. TITLE AND SUBTITLE</p> <p>Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Supplement 21 Regarding Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 Draft Report for Comment</p>	<p>3. DATE REPORT PUBLISHED</p> <table border="1" style="width: 100%;"> <tr> <td style="width: 50%;">MONTH</td> <td style="width: 50%;">YEAR</td> </tr> <tr> <td style="text-align: center;">November</td> <td style="text-align: center;">2004</td> </tr> </table> <p>4. FIN OR GRANT NUMBER</p>	MONTH	YEAR	November	2004
MONTH	YEAR				
November	2004				
<p>5. AUTHOR(S)</p> <p>See Appendix B of report.</p>	<p>6. TYPE OF REPORT</p> <p style="text-align: center;">Technical</p> <p>7. PERIOD COVERED <i>(Inclusive Dates)</i></p>				
<p>8. PERFORMING ORGANIZATION - NAME AND ADDRESS <i>(If NRC, provide Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)</i></p> <p>Division of Regulatory Improvement Programs Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Washington, D.C. 20555-0001</p>					
<p>9. SPONSORING ORGANIZATION - NAME AND ADDRESS <i>(If NRC, type "Same as above"; if contractor, provide NRC Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address.)</i></p> <p>Same as above</p>					
<p>10. SUPPLEMENTARY NOTES</p> <p>Docket No. 50-259, 50-260, and 50-296</p>					
<p>11. ABSTRACT <i>(200 words or less)</i></p> <p>This draft supplemental environmental impact statement (SEIS) has been prepared in response to an application submitted to the NRC by Tennessee Valley Authority (TVA) to renew the operating licenses (OL) for Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 for an additional 20 years under 10 CFR Part 54. This draft SEIS includes the NRC staff's analysis that considers and weighs the environmental impacts of the proposed action, the environmental impacts of the alternatives to the proposed action, and mitigation measures available for reducing or avoiding adverse impacts. It also includes the staff's preliminary recommendation regarding the proposed action.</p> <p>The NRC staff's preliminary recommendation is that the Commission determine that the adverse environmental impacts of license renewal for Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 are not so great that preserving the option of license renewal for energy planning decision makers would be unreasonable. The recommendation is based on (1) the analysis and findings in the GEIS; (2) the Environmental Report submitted by TVA; (3) consultation with Federal, State, and local agencies; (4) the staff's own independent review; and (5) the staff's consideration of the public comments received during the scoping process.</p>					
<p>12. KEY WORDS/DESCRIPTORS <i>(List words or phrases that will assist researchers in locating the report.)</i></p> <p>Browns Ferry Nuclear Power Plant, Units 1, 2, and 3 Supplement to the Generic Environmental Impact Statement GEIS National Environmental Policy Act NEPA License Renewal Browns Ferry BFN</p>	<p>13. AVAILABILITY STATEMENT</p> <p style="text-align: center;">unlimited</p> <p>14. SECURITY CLASSIFICATION</p> <p><i>(This Page)</i></p> <p style="text-align: center;">unclassified</p> <p><i>(This Report)</i></p> <p style="text-align: center;">unclassified</p> <p>15. NUMBER OF PAGES</p> <p>16. PRICE</p>				



Federal Recycling Program

**UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, DC 20555-0001**

OFFICIAL BUSINESS