



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

CONSTELLATION FITZPATRICK, LLC

AND

CONSTELLATION ENERGY GENERATION, LLC

DOCKET NO. 50-333

JAMES A. FITZPATRICK NUCLEAR POWER PLANT

RENEWED FACILITY OPERATING LICENSE

Renewed License No. DPR-59

1. The Nuclear Regulatory Commission (NRC or the Commission), having previously made the findings set forth in Facility Operating License No. DPR-59, dated November 21, 2000, has found that:
 - A. The application to renew Facility Operating License No. DPR-59 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I, and all required notifications to other agencies or bodies have been duly made;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. Actions have been identified and have been or will be taken with respect to: (1) managing the effects of aging on the functionality of structures and components that have been identified to require review under 10 CFR 54.21(a)(1) during the period of extended operation, and (2) time-limited aging analyses that have been identified to require review under 10 CFR 54.21(c), such that there is reasonable assurance that the activities authorized by this renewed operating license will continue to be conducted in accordance with the current licensing basis, as defined in 10 CFR 54.3 for the facility, and that any changes made to the facility's current licensing basis in order to comply with 10 CFR 54.29(a) are in accordance with the Act and the Commission's regulations;
 - D. There is reasonable assurance (i) that the activities authorized by this renewed operating license can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - E. Constellation FitzPatrick, LLC ("Constellation FitzPatrick") and Constellation Energy Generation, LLC are financially and technically qualified to engage in the activities authorized by this renewed operating license;

- F. Constellation FitzPatrick and Constellation Energy Generation, LLC have satisfied the applicable provisions of 10 CFR Part 140, "Financial Protection Requirements and Indemnity Agreements," of the Commission's regulations;
 - G. The issuance of this renewed operating license will not be inimical to the common defense and security or to the health and safety of the public;
 - H. The receipt, possession, and use of source, byproduct, and special nuclear material as authorized by this renewed operating license will be in accordance with the Commission's regulations in 10 CFR Parts 30, 40, and 70, including 10 CFR Sections 30.33, 40.32, 70.23, and 70.31; and
 - I. The issuance of this renewed operating license is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, Facility Operating License No. DPR-59 (previously issued to the Power Authority of the State of New York and Niagara Mohawk Power Corporation pursuant to the Atomic Safety and Licensing Board's Initial Decision and Supplemental Initial Decision dated November 12, 1973, and January 10, 1974, respectively; and the Atomic Safety and Licensing Appeal Board's Decision dated January 29, 1974) as previously amended and transferred to Entergy Nuclear FitzPatrick, LLC (ENF) and Entergy Nuclear Operations, Inc. (ENO) dated November 21, 2000, is superseded by Renewed Facility Operating License No. DPR-59, hereby issued to Constellation FitzPatrick and Constellation Energy Generation, LLC (the licensee) to read as follows:
- A. This renewed operating license applies to the James A. FitzPatrick Nuclear Power Plant, a boiling water nuclear reactor and associated equipment (the facility), owned by Constellation FitzPatrick and operated by Constellation Energy Generation, LLC (collectively, the licensees). The facility is located in Scriba, Oswego County, New York, and is described in the "Final Safety Analysis Report," as supplemented and amended, and the Environmental Report, as supplemented and amended.
 - B. Subject to the conditions and requirements incorporated herein, the Commission hereby licenses:
 - (1) Pursuant to Section 104b of the Act and 10 CFR Part 50, "Licensing of Production and Utilization Facilities," (a) Constellation FitzPatrick as the owner to possess and (b) Constellation Energy Generation, LLC as the operator to possess, use, and operate the facility at the designated location in Scriba, Oswego County, New York, in accordance with the procedures and limitations set forth in this renewed operating license;
 - (2) Constellation Energy Generation, LLC, pursuant to the Act and 10 CFR Part 70, to receive, possess, and use at any time, special nuclear material as reactor fuel, in accordance with the limitations for storage and amounts required for reactor operation, as described in the Final Safety Analysis Report, as supplemented and amended;

- (3) Constellation Energy Generation, LLC, pursuant to the Act and 10 CFR Parts 30, 40, and 70, to receive, possess, and use, at any time, any byproduct, source, and special nuclear material as sealed neutron sources for reactor startup, sealed sources for reactor instrumentation and radiation monitoring equipment calibration, and as fission detectors in amounts as required;
 - (4) Constellation Energy Generation, LLC, pursuant to the Act and 10 CFR Parts 30, 40, and 70, to receive, possess, and use, at any time, any byproduct, source, and special nuclear material without restriction to chemical or physical form, for sample analysis or instrument calibration; or associated with radioactive apparatus, components or tools.
 - (5) Constellation Energy Generation, LLC, pursuant to the Act and 10 CFR Parts 30 and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of the facility.
- C. This renewed operating license shall be deemed to contain and is subject to the conditions specified in the following Commission regulations in 10 CFR Chapter I: Part 20, Section 30.34 of Part 30, Section 40.41 of Part 40, Sections 50.54 and 50.59 of Part 50, and Section 70.32 of Part 70; and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:
- (1) Maximum Power Level
Constellation Energy Generation, LLC is authorized to operate the facility at steady state reactor core power levels not in excess of 2536 megawatts (thermal).
 - (2) Technical Specifications
The Technical Specifications contained in Appendix A, as revised through Amendment No. 354, are hereby incorporated in the renewed operating license. The licensee shall operate the facility in accordance with the Technical Specifications.

(3) Fire Protection

Constellation Energy Generation, LLC shall implement and maintain in effect all provisions of the approved fire protections program as described in the Final Safety Analysis Report for the facility and as approved in the SER dated November 20, 1972; the SER Supplement No. 1 dated February 1, 1973; the SER Supplement No. 2 dated October 4, 1974; the SER dated August 1, 1979; the SER Supplement dated October 3, 1980; the SER Supplement dated February 13, 1981; the NRC Letter dated February 24, 1981; Technical Specification Amendments 34 (dated January 31, 1978), 80 (dated May 22, 1984), 134 (dated July 19, 1989), 135 (dated September 5, 1989), 142 (dated October 23, 1989), 164 (dated August 10, 1990), 176 (dated January 16, 1992), 177 (dated February 10, 1992), 186 (dated February 19, 1993), 190 (dated June 29, 1993), 191 (dated July 7, 1993), 206 (dated February 28, 1994), and 214 (dated June 27, 1994); and NRC Exemptions and associated safety evaluations dated April 26, 1983, July 1, 1983, January 11, 1985, April 30, 1986, September 15, 1986, and September 10, 1992, subject to the following provision:

Constellation Energy Generation, LLC may make changes to the approved fire protection program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.

(4) Systems Integrity
Deleted by Amendment No. 274

(5) Iodine Monitoring
Deleted by Amendment No. 274

(6) New or Revised ITS Surveillance Requirements Applicability:

The schedule for performing Surveillance Requirements (SRs) that are new or revised in Amendment No. 274 shall be as follows:

- (a) For SRs that are new in this amendment, the first performance is due at the end of the first surveillance interval that begins on the date of implementation of this amendment.
- (b) For SRs that existed prior to this amendment whose intervals of performance are being reduced, the first reduced surveillance interval begins upon completion of the first surveillance performed after implementation of this amendment.
- (c) For SRs that existed prior to this amendment whose intervals of performance are being extended, the first extended surveillance interval begins upon completion of the last surveillance performed prior to implementation of this amendment.

- (d) For SRs that existed prior to this amendment that have modified acceptance criteria, the first performance is due at the end of the first surveillance interval that began on the date the surveillance was last performed prior to the implementation of this amendment.

D. Physical Protection

Constellation Energy Generation, LLC shall fully implement and maintain in effect all provisions of the Commission-approved physical security, training and qualification, and safeguards contingency plans including amendments made pursuant to provisions of the Miscellaneous Amendments and Search Requirements revisions to 10 CFR 73.55 (51 FR 27817 and 27822), and to the authority of 10 CFR 50.90 and 10 CFR 50.54(p). The combined set of plans¹, which contain Safeguards Information protected under 10 CFR 73.21, is entitled: "James A. FitzPatrick Nuclear Power Plant Physical Security, Training & Qualification and Safeguards Contingency Plan, Revision 0," submitted by letter dated October 26, 2004, as supplemented by letter dated May 17, 2006.

Constellation Energy Generation, LLC shall fully implement and maintain in effect all provisions of the Commission-approved cyber security plan (CSP), including changes made pursuant to the authority of 10 CFR 50.90 and 10 CFR 50.54(p). The CSP was approved by License Amendment No. 300, as supplemented by changes approved by License Amendment Nos. 303, 308, 311, and 316.

Constellation Energy Generation, LLC has been granted Commission authorization to use "stand alone preemption authority" under Section 161A of the Atomic Energy Act, 42 U.S.C. 2201a with respect to the weapons described in Attachment 1, Section II contained in its application submitted by letter dated August 30, 2013, as supplemented by letters dated November 12, 2013, and July 11, 2014. Constellation Energy Generation, LLC shall fully implement and maintain in effect the provisions of the Commission-approved authorization.

E. Power Uprate License Amendment Implementation

The licensee shall complete the following actions as a condition of the approval of the power uprate license amendment.

(1) Recirculation Pump Motor Vibration

Perform monitoring of recirculation pump motor vibration during initial Cycle 13 power ascension for uprated power conditions.

(2) Startup Test Program

The licensee will follow a startup testing program, during Cycle 13 power ascension, as described in GE Licensing Topical Report NEDC-31897P-1, "Generic Guidelines for General Electric Boiling Water Reactor Power Uprate."

¹ The Training and Qualification Plan and Safeguards Contingency Plan are Appendices to the Security Plan.

The startup test program includes system testing of such process control systems as the feedwater flow and main steam pressure control systems. The licensee will collect steady-state operational data during various portions of the power ascension to the higher licensed power level so that predicted equipment performance characteristics can be verified. The licensee will do the startup testing program in accordance with its procedures. The licensee's approach is in conformance with the test guidelines of GE Licensing Topical Report NEDC-31897P-1, "Generic Guidelines for General Electric Boiling Water Reactor Power Uprate," June 1991 (proprietary), GE Licensing Topical Report NEDO-31897, "Generic Guidelines for General Electric Boiling Water Reactor Power Uprate," February 1992 (nonproprietary), and NEDC-31897P-AA, Class III (proprietary), May 1992.

(3) Human Factors

The licensee will review the results of the Cycle 13 startup test program to determine any potential effects on operator training. Training issues identified will be incorporated in Licensed Operator training during 1997. Simulator discrepancies identified will be addressed in accordance with simulator Configuration Management procedural requirements.

F. Additional Conditions

The Additional Conditions contained in Appendix C, as revised through Amendment No. 347, are hereby incorporated into this renewed operating license. Constellation Energy Generation, LLC shall operate the facility in accordance with the Additional Conditions.

G. Constellation Energy Generation, LLC shall provide to the Director of the Office of Nuclear Reactor Regulation or the Director of the Office of Nuclear Material Safety and Safeguards, as applicable, a copy of any application, at the time it is filed, to transfer (excluding grants of security interests or liens) from Constellation Energy Generation, LLC to its direct or indirect parent, or to any other affiliated company, facilities for the production, transmission, or distribution of electric energy having a depreciated book value exceeding ten percent (10%) of Constellation Energy Generation, LLC's consolidated net utility plant, as recorded on Constellation Energy Generation, LLC's books of account.

H. DELETED

I. DELETED

J. DELETED

K. DELETED

L. DELETED

M. DELETED

N. DELETED

O. DELETED

P. DELETED

Q. DELETED

R. Mitigation Strategy License Condition

Develop and maintain strategies for addressing large fires and explosions and that include the following key areas:

- (a) Fire fighting response strategy with the following elements:
 - 1. Pre-defined coordinated fire response strategy and guidance
 - 2. Assessment of mutual aid fire fighting assets
 - 3. Designated staging areas for equipment and materials
 - 4. Command and control
 - 5. Training of response personnel

- (b) Operations to mitigate fuel damage considering the following:
 - 1. Protection and use of personnel assets
 - 2. Communications
 - 3. Minimizing fire spread
 - 4. Procedures for implementing integrated fire response strategy
 - 5. Identification of readily-available pre-staged equipment
 - 6. Training on integrated fire response strategy
 - 7. Spent fuel pool mitigation measures

- (c) Actions to minimize release to include consideration of:
 - 1. Water spray scrubbing
 - 2. Dose to onsite responders

- S. The licensee shall implement and maintain all Actions required by Attachment 2 to NRC Order EA-06-137, issued June 20, 2006, except the last action that requires incorporation of the strategies into the site security plan, contingency plan, emergency plan and/or guard training and qualification plan, as appropriate.
- T. License Renewal – UFSAR supplement submitted pursuant to 10 CFR 54.21(d), as revised during the license renewal application review process, and as supplemented by Appendix A of NUREG-1905, “Safety Evaluation Report Related to the License Renewal of James A. FitzPatrick Nuclear Power Plant,” dated April 2008, describes certain programs to be implemented and activities to be completed prior to the period of extended operation (PEO).
 - a. The licensee shall implement those new programs and enhancements to existing programs no later than the PEO date.
 - b. The licensee shall complete those inspection and testing activities by the PEO date.

The licensee shall notify the NRC in writing within 10 days after having accomplished item (a) above and include the status of those activities that have been or remain to be completed in item (b) above.

- U. UFSAR Supplement Changes - The UFSAR supplement, as revised, submitted pursuant to 10 CFR 54.21(d), shall be included in the next scheduled update to the UFSAR required by the 10 CFR 50.71(e)(4) following the issuance of this renewed operating license. Until that update is complete, the licensee may make changes to the programs and activities described in the supplement without prior Commission approval, provided that the licensee evaluate such changes pursuant to the criteria set forth in 10 CFR 50.59 and otherwise complies with the requirements in that section.
- V. Capsule withdrawal schedule - All capsules in the reactor vessel that are removed and tested must meet the test procedures and reporting requirements of the most recent NRC-approved version of the Boiling Water Reactor Vessel and Internals Project (BWRVIP) Integrated Surveillance Program (ISP) appropriate for the configuration of the specimens in the capsule. Any changes to the capsule withdrawal schedule, including spare capsules, must be approved by the NRC prior to implementation. All capsules placed in storage must be maintained for future insertion. Any changes to storage requirements must be approved by the NRC, as required by 10 CFR Part 50, Appendix H.

- W. Constellation Energy Generation, LLC shall, no later than the date the closing of the transaction approved on November 16, 2021, occurs, enter into a Support Agreement of approximately \$85 million with Constellation FitzPatrick. Constellation FitzPatrick shall not take any action to cause Constellation Energy Generation, LLC, or its successors and assigns, to void, cancel, or materially modify the Constellation Energy Generation, LLC Support Agreement or cause it to fail to perform, or impair its performance under the constellation Energy Generation, LLC Support Agreement, without the prior written consent of the NRC. The Constellation Energy Generation, LLC Support Agreement may not be amended or modified without 30 days prior written notice to the Director of the Constellation Energy Generation, LLC Support Agreement shall be submitted to the NRC no later than 30 days after the completion of the proposed transaction. Constellation Energy Generation, LLC shall inform the NRC in writing no later than 14 days after any funds are provided to or for Constellation FitzPatrick under the Constellation Energy Generation, LLC Support Agreement.
- X. Constellation Energy Generation, LLC is approved to implement 10 CFR 50.69 using the processes for categorization of Risk-Informed Safety Class (RISC)-1, RISC-2, RISC-3, and RISC-4 Structures, Systems, and Components (SSCs) using: Probabilistic Risk Assessment (PRA) models to evaluate risk associated with internal events, including internal flooding, and internal fire; the shutdown safety assessment process to assess shutdown risk; the Arkansas Nuclear One, Unit 2 (ANO-2) passive categorization method to assess passive component risk for Class 2 and Class 3 and non-Class SSCs and their associated supports; the results of the non-PRA evaluations that are based on the IPEEE Screening Assessment for External Hazards updated using the external hazard screening significance process identified in ASME/ANS PRA Standard RA-Sa-2009 for other external hazards except seismic; and the alternative seismic approach as described in Exelon Generation Company, LLC's submittal letter dated July 30, 2021, and all its subsequent associated supplements as specified in License Amendment No. 352 dated August 23, 2022.

Prior NRC approval, under 10 CFR 50.90, is required for a change to the categorization process specified above (e.g., change from a seismic margins approach to a seismic probabilistic risk assessment approach).

- Y. Adoption of Risk Informed Completion Times TSTF-505, Revision 2, "Provide Risk-Informed Extension Completion Times – RITSTF Initiative 4b"

Constellation Energy Generation, LLC is approved to implement TSTF-505, Revision 2, modifying the Technical Specification requirements related to Completion Times (CT) for Required Actions to provide the option to calculate a longer, risk-informed CT (RICT). The methodology for using the new Risk-Informed Completion Time Program is described in NEI 06-09-A, "Risk-Informed Technical Specifications Initiative 4b, Risk-Managed Technical specifications (RMTS) Guidelines," Revision 0, which was approved by the NRC on May 17, 2007.

Constellation Energy Generation, LLC will complete implementation items listed in Attachment 6 of Exelon Generation Company, LLC Letter to the NRC dated July 30, 2021, prior to implementation of RICT Program. All issues identified in the attachment will be addressed and any associated changes will be made, focused-scope peer reviews will be performed on changes that are PRA upgrades as defined in PRA standard (ASME/ANS RA-Sa-2009, as endorsed by RG 1.200, Revision 2), and any findings will be resolved and reflected in the PRA of record prior to the implementation of the RICT Program.

3. This renewed operating license is effective as of the date of issuance and shall expire at midnight October 17, 2034.

FOR THE NUCLEAR REGULATORY COMMISSION

\RA\

Eric J. Leeds, Director
Office of Nuclear Reactor Regulation

Attachments/Appendices:

1. Appendix A – Technical Specifications
2. Appendix B – Deleted
3. Appendix C – Additional Conditions

Date of Issuance: September 8, 2008

APPENDIX A
TECHNICAL SPECIFICATIONS
FOR
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
DOCKET NO. 50-333

1.0 USE AND APPLICATION

1.1 Definitions

----- NOTE -----

The defined terms of this section appear in capitalized type and are applicable throughout these Technical Specifications and Bases.

<u>Term</u>	<u>Definition</u>
ACTIONS	ACTIONS shall be that part of a Specification that prescribes Required Actions to be taken under designated Conditions within specified Completion Times.
AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR)	The APLHGR shall be applicable to a specific planar height and is equal to the sum of the heat generation rate per unit length of fuel rod for all the fuel rods in the specified assembly at the specified height divided by the number of fuel rods in the fuel assembly at the height.
CHANNEL CALIBRATION	A CHANNEL CALIBRATION shall be the adjustment, as necessary, of the channel output such that it responds within the necessary range and accuracy to known values of the parameter that the channel monitors. The CHANNEL CALIBRATION shall encompass all devices in the channel required for channel OPERABILITY and the CHANNEL FUNCTIONAL TEST . Calibration of instrument channels with resistance temperature detector (RTD) or thermocouple sensors may consist of an in-place qualitative assessment of sensor behavior and normal calibration of the remaining adjustable devices in the channel. The CHANNEL CALIBRATION may be performed by means of any series of sequential, overlapping, or total channel steps, and each step must be performed within the Frequency in the Surveillance Frequency Control Program for the devices included in the step.
CHANNEL CHECK	A CHANNEL CHECK shall be the qualitative assessment, by observation, of channel behavior during operation. This determination shall include, where possible, comparison of the channel indication and status to other indications or status derived from independent instrument channels measuring the same parameter.

(continued)

1.1 Definitions (continued)

CHANNEL FUNCTIONAL TEST	A CHANNEL FUNCTIONAL TEST shall be the injection of a simulated or actual signal into the channel as close to the sensor as practicable to verify OPERABILITY of all devices in the channel required for channel OPERABILITY. The CHANNEL FUNCTIONAL TEST may be performed by means of any series of sequential, overlapping, or total channel steps, and each step must be performed within the Frequency in the Surveillance Frequency Control Program for the devices included in the step.
CORE ALTERATION	<p>CORE ALTERATION shall be the movement of any fuel, sources, or reactivity control components within the reactor vessel with the vessel head removed and fuel in the vessel. The following exceptions are not considered to be CORE ALTERATIONS:</p> <ol style="list-style-type: none">Movement of source range monitors, local power range monitors, intermediate range monitors, traversing incore probes, or special movable detectors (including undervessel replacement); andControl rod movement, provided there are no fuel assemblies in the associated core cell. <p>Suspension of CORE ALTERATIONS shall not preclude completion of movement of a component to a safe position.</p>
CORE OPERATING LIMITS REPORT (COLR)	The COLR is the plant specific document that provides cycle specific parameter limits for the current reload cycle. These cycle specific limits shall be determined for each reload cycle in accordance with Specification 5.6.5. Plant operation within these limits is addressed in individual Specifications.
DOSE EQUIVALENT I-131	DOSE EQUIVALENT I-131 shall be that concentration of I-131 (microcuries/gram) that alone would produce the same thyroid dose as the quantity and isotopic mixture of I-131, I-132, I-133, I-134, and I-135 actually present. The thyroid dose conversion factors used for this calculation shall be those listed in International Commission on Radiological Protection Publication 30 (ICRP-30), "Limits for Intake by Workers," or in NRC Regulatory Guide 1.109, Rev. 1, 1977.

(continued)

1.1 Definitions (continued)

DRAIN TIME

The DRAIN TIME is the time it would take for the water inventory in and above the Reactor Pressure Vessel (RPV) to drain to the top of the active fuel (TAF) seated in the RPV assuming:

- a) The water inventory above the TAF is divided by the limiting drain rate:
- b) The limiting drain rate is the larger of the drain rate through a single penetration flow path with the highest flow rate, or the sum of the drain rates through multiple penetration flow paths susceptible to a common mode failure for all penetration flow paths below the TAF except:
 1. Penetration flow paths connected to an intact closed system, or isolated by manual or automatic valves that are closed and administratively controlled in the closed position, blank flanges, or other devices that prevent flow of reactor coolant through the penetration flow paths;
 2. Penetration flow paths capable of being isolated by valves that will close automatically without offsite power prior to the RPV water level being equal to the TAF when actuated by RPV water level isolation instrumentation; or
 3. Penetration flow paths with isolation devices that can be closed prior to the RPV water level being equal to the TAF by a dedicated operator trained in the task, who in continuous communication with the control room, is stationed at the controls, and is capable of closing the penetration flow path isolation device without offsite power.
- c) The penetration flow paths required to be evaluated per paragraph b) are assumed to open instantaneously and are not subsequently isolated, and no water is assumed to be subsequently added to the RPV water inventory;
- d) No additional draining events occur; and
- e) Realistic cross-sectional areas and drain rates are used.

A bounding DRAIN TIME may be used in lieu of a calculated value.

(continued)

1.1 Definitions (continued)

INSERVICE TESTING PROGRAM	The INSERVICE TESTING PROGRAM is the licensee program that fulfills the requirements of 10 CFR 50.55a(f).
ISOLATION INSTRUMENTATION RESPONSE TIME	The ISOLATION INSTRUMENTATION RESPONSE TIME shall be that time interval from when the monitored parameter exceeds its isolation initiation setpoint at the channel sensor until the isolation valve receives the isolation signal (e.g., de-energization of the main steam isolation valve solenoids). The response time may be measured by means of any series of sequential, overlapping, or total steps so that the entire response time is measured. In lieu of measurement, response time may be verified for selected components provided that the components and methodology for verification have been previously reviewed and approved by the NRC.
LEAKAGE	LEAKAGE shall be: <ul style="list-style-type: none">a. <u>Identified LEAKAGE</u><ul style="list-style-type: none">1. LEAKAGE into the drywell, such as that from pump seals or valve packing, that is captured and conducted to a sump or collecting tank; or2. LEAKAGE into the drywell atmosphere from sources that are both specifically located and known to not interfere with the operation of leakage detection systems;b. <u>Unidentified LEAKAGE</u> All LEAKAGE into the drywell that is not identified LEAKAGE;c. <u>Total LEAKAGE</u> Sum of the identified and unidentified LEAKAGE; andd. <u>Pressure Boundary LEAKAGE</u> LEAKAGE through a fault in a Reactor Coolant System (RCS) component body, pipe wall, or vessel wall. LEAKAGE past seals, packing, or gaskets is not pressure boundary LEAKAGE.

(continued)

1.1 Definitions (continued)

LINEAR HEAT GENERATION RATE (LHGR)	The LHGR shall be the heat generation rate per unit length of fuel rod. It is the Integral of the heat flux over the heat transfer area associated with the unit length.
LOGIC SYSTEM FUNCTIONAL TEST	A LOGIC SYSTEM FUNCTIONAL TEST shall be a test of all logic components required for OPERABILITY of a logic circuit, from as close to the sensor as practicable up to, but not including, the actuated device, to verify OPERABILITY. The LOGIC SYSTEM FUNCTIONAL TEST may be performed by means of any series of sequential, overlapping, or total system steps so that the entire logic system is tested.
MINIMUM CRITICAL POWER RATIO (MCPR)	The MCPR shall be the smallest critical power that exists in the core for each type of fuel. The CPR is that power in the assembly that is calculated by application of the appropriate correlation(s) to cause some point in the assembly to experience boiling transition, divided by the actual assembly operating power.
MODE	A MODE shall correspond to any one inclusive combination of mode switch position, average reactor coolant temperature, and reactor vessel head closure bolt tensioning specified in Table 1.1-1 with fuel in the reactor vessel.
OPERABLE-OPERABILITY	A system, subsystem, division, component, or device shall be OPERABLE or have OPERABILITY when it is capable of performing its specified safety function(s) and when all necessary attendant instrumentation, controls, normal or emergency electrical power, cooling and seal water, lubrication, and other auxiliary equipment that are required for the system, subsystem, division, component, or device to perform its specified safety function(s) are also capable of performing their related support function(s).
PRESSURE AND TEMPERATURE LIMITS REPORT (PTLR)	The PTLR is the unit specific document that provides the reactor vessel pressure and temperature limits, including heatup and cooldown rates, for the current reactor vessel fluence period. These pressure and temperature limits shall be determined for each fluence period in accordance with Specification 5.6.7.

(continued)

1.1 Definitions (continued)

RATED THERMAL POWER	RTP shall be a total reactor core heat transfer (RTP) rate to the reactor coolant of 2536 MWt.
REACTOR PROTECTION SYSTEM (RPS) RESPONSE TIME	The RPS RESPONSE TIME shall be that time interval from when the monitored parameter exceeds its RPS trip setpoint at the channel sensor until de-energization of the scram pilot valve solenoids. The response time may be measured by means of any series of sequential, overlapping, or total steps so that the entire response time is measured. In lieu of measurement, response time may be verified for selected components provided that the components and methodology for verification have been previously reviewed and approved by the NRC.
SHUTDOWN MARGIN (SDM)	SDM shall be the amount of reactivity by which the reactor is subcritical or would be subcritical throughout the operating cycle assuming that: <ol style="list-style-type: none">The reactor is xenon free;The moderator temperature is $\geq 68^{\circ}\text{F}$, corresponding to the most reactive state; andAll control rods are fully inserted except for the single control rod of highest reactivity worth, which is assumed to be fully withdrawn. With control rods not capable of being fully inserted, the reactivity worth of these control rods must be accounted for in the determination of SDM.
STAGGERED TEST BASIS	A STAGGERED TEST BASIS shall consist of the testing of one of the systems, subsystems, channels, or other designated components during the interval specified by the Surveillance Frequency, so that all systems, subsystems, channels, or other designated components are tested during n Surveillance Frequency intervals, where n is the total number of systems, subsystems, channels, or other designated components in the associated function.
THERMAL POWER	THERMAL POWER shall be the total reactor core heat transfer rate to the reactor coolant.

(continued)

1.1 Definitions (continued)

**TURBINE BYPASS SYSTEM
RESPONSE TIME**

The TURBINE BYPASS SYSTEM RESPONSE TIME consists of two components:

- a. The time from initial movement of the main turbine stop valve or control valve until 80% of the assumed turbine bypass capacity is established; and
- b. The time from initial movement of the main turbine stop valve or control valve until initial movement of the turbine bypass valve.

The response time may be measured by means of any series of sequential, overlapping, or total steps so that the entire response time is measured.

Table 1.1-1 (page 1 of 1)
MODES

MODE	TITLE	REACTOR MODE SWITCH POSITION	AVERAGE REACTOR COOLANT TEMPERATURE (°F)
1	Power Operation	Run	NA
2	Startup	Refuel ^(a) or Startup/Hot Standby	NA
3	Hot Shutdown ^(a)	Shutdown	> 212
4	Cold Shutdown ^(a)	Shutdown	≤ 212
5	Refueling ^(b)	Shutdown or Refuel	NA

(a) All reactor vessel head closure bolts fully tensioned.

(b) One or more reactor vessel head closure bolts less than fully tensioned.

1.0 USE AND APPLICATION

1.2 Logical Connectors

PURPOSE The purpose of this section is to explain the meaning of logical connectors.

Logical connectors are used in Technical Specifications (TS) to discriminate between, and yet connect, discrete Conditions, Required Actions, Completion Times, Surveillances, and Frequencies. The only logical connectors that appear in TS are AND and OR. The physical arrangement of these connectors constitutes logical conventions with specific meanings.

BACKGROUND Several levels of logic may be used to state Required Actions. These levels are identified by the placement (or nesting) of the logical connectors and by the number assigned to each Required Action. The first level of logic is identified by the first digit of the number assigned to a Required Action and the placement of the logical connector in the first level of nesting (i.e., left justified with the number of the Required Action). The successive levels of logic are identified by additional digits of the Required Action number and by successive indentions of the logical connectors.

When logical connectors are used to state a Condition, Completion Time, Surveillance, or Frequency, only the first level of logic is used, and the logical connector is left justified with the statement of the Condition, Completion Time, Surveillance, or Frequency.

EXAMPLES The following examples illustrate the use of logical connectors.

(continued)

1.2 Logical Connectors

EXAMPLES
(continued)

EXAMPLE 1.2-1

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. LCO not met.	A.1 Verify . . . <u>AND</u> A.2 Restore . . .	

In this example the logical connector AND is used to indicate that when in Condition A, both Required Actions A.1 and A.2 must be completed.

(continued)

1.2 Logical Connectors

EXAMPLES
(continued)

EXAMPLE 1.2-2

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. LCO not met.	A.1 Trip . . . <u>OR</u> A.2.1 Verify . . . <u>AND</u> A.2.2.1 Reduce . . . <u>OR</u> A.2.2.2 Perform . . . <u>OR</u> A.3 Align . . .	

This example represents a more complicated use of logical connectors. Required Actions A.1, A.2, and A.3 are alternative choices, only one of which must be performed as indicated by the use of the logical connector OR and the left justified placement. Any one of these three Actions may be chosen. If A.2 is chosen, then both A.2.1 and A.2.2 must be performed as indicated by the logical connector AND. Required Action A.2.2 is met by performing A.2.2.1 or A.2.2.2. The indented position of the logical connector OR indicates that A.2.2.1 and A.2.2.2 are alternative choices, only one of which must be performed.

1.0 USE AND APPLICATION

1.3 Completion Times

PURPOSE The purpose of this section is to establish the Completion Time convention and to provide guidance for its use.

BACKGROUND Limiting Conditions for Operation (LCOs) specify minimum requirements for ensuring safe operation of the plant. The ACTIONS associated with an LCO state Conditions that typically describe the ways in which the requirements of the LCO can fail to be met. Specified with each stated Condition are Required Action(s) and Completion Times(s).

DESCRIPTION The Completion Time is the amount of time allowed for completing a Required Action. It is referenced to the time of discovery of a situation (e.g., inoperable equipment or variable not within limits) that requires entering an ACTIONS Condition unless otherwise specified, providing the plant is in a MODE or specified condition stated in the Applicability of the LCO. Required Actions must be completed prior to the expiration of the specified Completion Time. An ACTIONS Condition remains in effect and the Required Actions apply until the Condition no longer exists or the plant is not within the LCO Applicability.

If situations are discovered that require entry into more than one Condition at a time within a single LCO (multiple Conditions), the Required Actions for each Condition must be performed within the associated Completion Time. When in multiple Conditions, separate Completion Times are tracked for each Condition starting from the time of discovery of the situation that required entry into the Condition.

Once a Condition has been entered, subsequent divisions, subsystems, components, or variables expressed in the Condition, discovered to be inoperable or not within limits, will not result in separate entry into the Condition unless specifically stated. The Required Actions of the Condition continue to apply to each additional failure, with Completion Times based on initial entry into the Condition.

(continued)

1.3 Completion Times

DESCRIPTION
(continued)

However, when a subsequent division, subsystem, component, or variable expressed in the Condition is discovered to be inoperable or not within limits, the Completion Time(s) may be extended. To apply this Completion Time extension, two criteria must first be met. The subsequent inoperability:

- a. Must exist concurrent with the first inoperability;
and
- b. Must remain inoperable or not within limits after the first inoperability is resolved.

The total Completion Time allowed for completing a Required Action to address the subsequent inoperability shall be limited to the more restrictive of either:

- a. The stated Completion Time, as measured from the initial entry into the Condition, plus an additional 24 hours; or
- b. The stated Completion Time as measured from discovery of the subsequent inoperability.

The above Completion Time extension does not apply to those Specifications that have exceptions that allow completely separate re-entry into the Condition (for each division, subsystem, component or variable expressed in the Condition) and separate tracking of Completion Times based on this re-entry. These exceptions are stated in individual Specifications.

The above Completion Time extension does not apply to a Completion Time with a modified "time zero." This modified "time zero" may be expressed as a repetitive time (i.e., "once per 8 hours," where the Completion Time is referenced from a previous completion of the Required Action versus the time of Condition entry) or as a time modified by the phrase "from discovery . . ."

(continued)

1.3 Completion Times (continued)

EXAMPLES

The following examples illustrate the use of Completion Times with different types of Conditions and changing Conditions.

EXAMPLE 1.3-1

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	12 hours
	<u>AND</u> B.2 Be in MODE 4.	36 hours

Condition B has two Required Actions. Each Required Action has its own separate Completion Time. Each Completion Time is referenced to the time that Condition B is entered.

The Required Actions of Condition B are to be in MODE 3 within 12 hours AND in MODE 4 within 36 hours. A total of 12 hours is allowed for reaching MODE 3 and a total of 36 hours (not 48 hours) is allowed for reaching MODE 4 from the time that Condition B was entered. If MODE 3 is reached within 6 hours, the time allowed for reaching MODE 4 is the next 30 hours because the total time allowed for reaching MODE 4 is 36 hours.

If Condition B is entered while in MODE 3, the time allowed for reaching MODE 4 is the next 36 hours.

(continued)

1.3 Completion Times

EXAMPLES
(continued)

EXAMPLE 1.3-2

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One pump inoperable.	A.1 Restore pump to OPERABLE status.	7 days
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	12 hours
	<u>AND</u> B.2 Be in MODE 4.	36 hours

When a pump is declared inoperable, Condition A is entered. If the pump is not restored to OPERABLE status within 7 days, Condition B is also entered and the Completion Time clocks for Required Actions B.1 and B.2 start. If the inoperable pump is restored to OPERABLE status after Condition B is entered, Conditions A and B are exited, and therefore, the Required Actions of Condition B may be terminated.

When a second pump is declared inoperable while the first pump is still inoperable, Condition A is not re-entered for the second pump. LCO 3.0.3 is entered, since the ACTIONS do not include a Condition for more than one inoperable pump. The Completion Time clock for Condition A does not stop after LCO 3.0.3 is entered, but continues to be tracked from the time Condition A was initially entered.

While in LCO 3.0.3, if one of the inoperable pumps is restored to OPERABLE status and the Completion Time for Condition A has not expired, LCO 3.0.3 may be exited and operation continued in accordance with Condition A.

(continued)

1.3 Completion Times

EXAMPLES

EXAMPLE 1.3-2 (continued)

While in LCO 3.0.3, if one of the inoperable pumps is restored to OPERABLE status and the Completion Time for Condition A has expired, LCO 3.0.3 may be exited and operation continued in accordance with Condition B. The Completion Time for Condition B is tracked from the time the Condition A Completion Time expired.

On restoring one of the pumps to OPERABLE status, the Condition A Completion Time is not reset, but continues from the time the first pump was declared inoperable. This Completion Time may be extended if the pump restored to OPERABLE status was the first inoperable pump. A 24 hour extension to the stated 7 days is allowed, provided this does not result in the second pump being inoperable for > 7 days.

(continued)

1.3 Completion Times

EXAMPLES
(continued)

EXAMPLE 1.3-3

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One Function X subsystem inoperable.	A.1 Restore Function X subsystem to OPERABLE status.	7 days
B. One Function Y subsystem inoperable.	B.1 Restore Function Y subsystem to OPERABLE status.	72 hours
C. One Function X subsystem inoperable. <u>AND</u> One Function Y subsystem inoperable.	C.1 Restore Function X subsystem to OPERABLE status. <u>OR</u> C.2 Restore Function Y subsystem to OPERABLE status.	12 hours 12 hours

(continued)

1.3 Completion Times

EXAMPLES

EXAMPLE 1.3-3 (continued)

When one Function X subsystem and one Function Y subsystem are inoperable, Condition A and Condition B are concurrently applicable. The Completion Times for Condition A and Condition B are tracked separately for each subsystem, starting from the time each subsystem was declared inoperable and the Condition was entered. A separate Completion Time is established for Condition C and tracked from the time the second subsystem was declared inoperable (i.e., the time the situation described in Condition C was discovered).

If Required Action C.2 is completed within the specified Completion Time, Conditions B and C are exited. If the Completion Time for Required Action A.1 has not expired, operation may continue in accordance with Condition A. The remaining Completion Time in Condition A is measured from the time the affected subsystem was declared inoperable (i.e., initial entry into Condition A).

It is possible to alternate between Conditions A, B, and C in such a manner that operation could continue indefinitely without ever restoring systems to meet the LCO. However, doing so would be inconsistent with the basis of the Completion Times. Therefore, there shall be administrative controls to limit the maximum time allowed for any combination of Conditions that result in a single contiguous occurrence of failing to meet the LCO. These administrative controls shall ensure that the Completion Times for those Conditions are not inappropriately extended.

(continued)

1.3 Completion Times

EXAMPLES
(continued)

EXAMPLE 1.3-4

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more valves inoperable.	A.1 Restore valve(s) to OPERABLE status.	4 hours
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	12 hours
	<u>AND</u> B.2 Be in MODE 4.	36 hours

A single Completion Time is used for any number of valves inoperable at the same time. The Completion Time associated with Condition A is based on the initial entry into Condition A and is not tracked on a per valve basis. Declaring subsequent valves inoperable, while Condition A is still in effect, does not trigger the tracking of separate Completion Times.

Once one of the valves has been restored to OPERABLE status, the Condition A Completion Time is not reset, but continues from the time the first valve was declared inoperable. The Completion Time may be extended if the valve restored to OPERABLE status was the first inoperable valve. The Condition A Completion Time may be extended for up to 4 hours provided this does not result in any subsequent valve being inoperable for > 4 hours.

If the Completion Time of 4 hours (plus the extension) expires while one or more valves are still inoperable, Condition B is entered.

(continued)

1.3 Completion Times

EXAMPLES
(continued)

EXAMPLE 1.3-5

ACTIONS

-----NOTE-----
Separate Condition entry is allowed for each inoperable valve.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more valves inoperable.	A.1 Restore valve to OPERABLE status.	4 hours
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	12 hours
	<u>AND</u> B.2 Be in MODE 4.	36 hours

The Note above the ACTIONS Table is a method of modifying how the Completion Time is tracked. If this method of modifying how the Completion Time is tracked was applicable only to a specific Condition, the Note would appear in that Condition rather than at the top of the ACTIONS Table.

The Note allows Condition A to be entered separately for each inoperable valve, and Completion Times tracked on a per valve basis. When a valve is declared inoperable, Condition A is entered and its Completion Time starts. If subsequent valves are declared inoperable, Condition A is entered for each valve and separate Completion Times start and are tracked for each valve.

(continued)

1.3 Completion Times

EXAMPLES

EXAMPLE 1.3-5 (continued)

If the Completion Time associated with a valve in Condition A expires, Condition B is entered for that valve. If the Completion Times associated with subsequent valves in Condition A expire, Condition B is entered separately for each valve and separate Completion Times start and are tracked for each valve. If a valve that caused entry into Condition B is restored to OPERABLE status, Condition B is exited for that valve.

Since the Note in this example allows multiple Condition entry and tracking of separate Completion Times, Completion Time extensions do not apply.

EXAMPLE 1.3-6

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One channel inoperable.	A.1 Perform SR 3.x.x.x.	Once per 8 hours
	<u>OR</u> A.2 Place channel in trip.	8 hours
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	12 hours

(continued)

1.3 Completion Times

EXAMPLES

EXAMPLE 1.3-6 (continued)

Entry into Condition A offers a choice between Required Action A.1 or A.2. Required Action A.1 has a "once per" Completion Time, which qualifies for the 25% extension, per SR 3.0.2, to each performance after the initial performance. The initial 8 hour interval of Required Action A.1 begins when Condition A is entered and the initial performance of Required Action A.1 must be complete within the first 8 hour interval. If Required Action A.1 is followed and the Required Action is not met within the Completion Time (plus the extension allowed by SR 3.0.2), Condition B is entered. If Required Action A.2 is followed and the Completion Time of 8 hours is not met, Condition B is entered.

If after entry into Condition B, Required Action A.1 or A.2 is met, Condition B is exited and operation may then continue in Condition A.

(continued)

1.3 Completion Times

EXAMPLES
(continued)

EXAMPLE 1.3-7

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One subsystem inoperable.	A.1 Verify affected subsystem isolated.	1 hour <u>AND</u> Once per 8 hours thereafter
	<u>AND</u> A.2 Restore subsystem to OPERABLE status.	72 hours
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	12 hours
	<u>AND</u> B.2 Be in MODE 4.	36 hours

Required Action A.1 has two Completion Times. The 1 hour Completion Time begins at the time the Condition is entered and each "Once per 8 hours thereafter" interval begins upon performance of Required Action A.1.

If after Condition A is entered, Required Action A.1 is not met within either the initial 1 hour or any subsequent 8 hour interval from the previous performance (plus the extension allowed by SR 3.0.2), Condition B is entered. The Completion Time clock for Condition A does not stop after Condition B is entered, but continues from the time Condition A was initially entered. If Required Action A.1 is met after Condition B is entered, Condition B is exited

(continued)

1.3 Completion Times

EXAMPLES

EXAMPLE 1.3-7 (continued)

and operation may continue in accordance with Condition A, provided the Completion Time for Required Action A.2 has not expired.

EXAMPLE 1.3-8

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One subsystem inoperable.	A.1 Restore subsystem to OPERABLE status.	7 days <u>OR</u> In accordance with the Risk Informed Completion Time Program
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	6 hours
	<u>AND</u> B.2 Be in MODE 5.	36 hours

When a subsystem is declared inoperable, Condition A is entered. The 7 day Completion Time may be applied as discussed in Example 1.3-2. However, the licensee may elect to apply the Risk Informed Completion Time Program which permits calculation of a Risk Informed Completion Time (RICT) that may be used to complete the Required Action beyond the 7 day Completion Time. The RICT cannot exceed 30 days. After the 7 day Completion Time has expired, the subsystem must be restored to OPERABLE status within the RICT or Condition B must also be entered.

The Risk Informed Completion Time Program requires recalculation of the RICT to reflect changing plant conditions. For planned changes, the revised RICT must be determined prior to implementation of the change in configuration. For emergent conditions, the revised RICT must be determined within the time limits of the Required Action Completion Time (i.e., not the RICT) or 12 hours after the plant configuration change, whichever is less.

(continued)

1.3 Completion Times

EXAMPLES

EXAMPLE 1.3-8 (continued)

If the 7 day Completion Time clock of Condition A has expired and subsequent changes in plant condition result in exiting the applicability of the Risk Informed Completion Time Program without restoring the inoperable subsystem to OPERABLE status, Condition B is also entered and the Completion Time clocks for Required Actions B.1 and B.2 start.

If the RICT expires or is recalculated to be less than the elapsed time since the Condition was entered and the inoperable subsystem has not been restored to OPERABLE status, Condition B is also entered and the Completion Time clocks for Required Actions B.1 and B.2 start. If the inoperable subsystems are restored to OPERABLE status after Condition B is entered, Condition A is exited, and therefore, the Required Actions of Condition B may be terminated.

**IMMEDIATE
COMPLETION
TIME**

When "Immediately" is used as a Completion Time, the Required Action should be pursued without delay and in a controlled manner.

1.0 USE AND APPLICATION

1.4 Frequency

PURPOSE The purpose of this section is to define the proper use and application of Frequency requirements.

DESCRIPTION Each Surveillance Requirement (SR) has a specified Frequency in which the Surveillance must be met in order to meet the associated Limiting Condition for Operation (LCO). An understanding of the correct application of the specified Frequency is necessary for compliance with the SR.

The "specified Frequency" is referred to throughout this section and each of the Specifications of Section 3.0. Surveillance Requirement (SR) Applicability. The "specified Frequency" consists of the requirements of the Frequency column of each SR, as well as certain Notes in the Surveillance column that modify performance requirements.

Sometimes special situations dictate when the requirements of a Surveillance are to be met. They are "otherwise stated" conditions allowed by SR 3.0.1. They may be stated as clarifying Notes in the Surveillance, as part of the Surveillance, or both.

Situations where a Surveillance could be required (i.e., its Frequency could expire), but where it is not possible or not desired that it be performed until sometime after the associated LCO is within its Applicability, represent potential SR 3.0.4 conflicts. To avoid these conflicts, the SR (i.e., the Surveillance or the Frequency) is stated such that it is only "required" when it can be and should be performed. With an SR satisfied, SR 3.0.4 imposes no restriction.

The use of "met" or "performed" in these instances conveys specific meanings. A Surveillance is "met" only when the acceptance criteria are satisfied. Known failure of the requirements of a Surveillance, even without a Surveillance specifically being "performed," constitutes a Surveillance not "met." "Performance" refers only to the requirement to specifically determine the ability to meet the acceptance

(continued)

1.4 Frequency

DESCRIPTION (continued)

criteria. Some Surveillances contain notes that modify the Frequency of performance of the conditions during which the acceptance criteria must be satisfied. For these Surveillances, the MODE entry restrictions of SR 3.0.4 may not apply. Such a Surveillance is not required to be performed prior to entering a MODE or other specified condition in the Applicability of the associated LCO if any of the following three conditions are satisfied:

- a. The Surveillance is not required to be met in the MODE or other specified condition to be entered; or
- b. The Surveillance is required to be met in the MODE or other specified condition to be entered, but has been performed within the specified Frequency (i.e., it is current) and is known not to be failed; or
- c. The Surveillance is required to be met, but not performed, in the MODE or other specified condition to be entered, and is known not to be failed.

Examples 1.4-3, 1.4-4, 1.4-5, and 1.4-6 discuss these special situations.

EXAMPLES

The following examples illustrate the various ways that Frequencies are specified. In these examples, the Applicability of the LCO (LCO not shown) is MODES 1, 2, and 3.

(continued)

1.4 Frequency

EXAMPLES
(continued)

EXAMPLE 1.4-1

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
Perform CHANNEL CHECK.	12 hours

Example 1.4-1 contains the type of SR most often encountered in the Technical Specifications (TS). The Frequency specifies an interval (12 hours) during which the associated Surveillance must be performed at least one time. Performance of the Surveillance initiates the subsequent interval. Although the Frequency is stated as 12 hours, an extension of the time interval to 1.25 times the interval specified in the Frequency is allowed by SR 3.0.2 for operational flexibility. The measurement of this interval continues at all times, even when the SR is not required to be met per SR 3.0.1 (such as when the equipment is inoperable, a variable is outside specified limits, or the plant is outside the Applicability of the LCO). If the interval specified by SR 3.0.2 is exceeded while the plant is in a MODE or other specified condition in the Applicability of the LCO, and the performance of the Surveillance is not otherwise modified (refer to Examples 1.4-3 and 1.4-4), then SR 3.0.3 becomes applicable.

If the interval as specified by SR 3.0.2 is exceeded while the plant is not in a MODE or other specified condition in the Applicability of the LCO for which performance of the SR is required, the Surveillance must be performed within the Frequency requirements of SR 3.0.2 prior to entry into the MODE or other specified condition. Failure to do so would result in a violation of SR 3.0.4.

(continued)

1.4 Frequency

EXAMPLES
(continued)

EXAMPLE 1.4-2

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
Verify flow is within limits.	Once within 12 hours after ≥ 25% RTP <u>AND</u> 24 hours thereafter

Example 1.4-2 has two Frequencies. The first is a one time performance Frequency, and the second is of the type shown in Example 1.4-1. The logical connector "AND" indicates that both Frequency requirements must be met. Each time reactor power is increased from a power level < 25% RTP to ≥ 25% RTP, the Surveillance must be performed within 12 hours.

The use of "once" indicates a single performance will satisfy the specified Frequency (assuming no other Frequencies are connected by "AND"). This type of Frequency does not qualify for the extension allowed by SR 3.0.2. "Thereafter" indicates future performances must be established per SR 3.0.2, but only after a specified condition is first met (i.e., the "once" performance in this example). If reactor power decreases to < 25% RTP, the measurement of both intervals stops. New intervals start upon reactor power reaching 25% RTP.

(continued)

1.4 Frequency

EXAMPLES
(continued)

EXAMPLE 1.4-3

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p style="text-align: center;">----- NOTE ----- Not required to be performed until 12 hours after ≥ 25% RTP. -----</p>	
<p>Perform channel adjustment.</p>	<p>7 days</p>

The interval continues whether or not the plant operation is < 25% RTP between performances.

As the Note modifies the required performance of the Surveillance, it is construed to be part of the "specified Frequency." Should the 7 day interval be exceeded while operation is < 25% RTP, this Note allows 12 hours after power reaches ≥ 25% RTP to perform the Surveillance. The Surveillance is still considered to be within the "specified Frequency." Therefore, if the Surveillance were not performed within the 7 day interval (plus the extension allowed by SR 3.0.2), but operation was < 25% RTP, it would not constitute a failure of the SR or failure to meet the LCO. Also, no violation of SR 3.0.4 occurs when changing MODES, even with the 7 day Frequency not met, provided operation does not exceed 12 hours (plus the extension allowed by SR 3.0.2) with power ≥ 25% RTP.

Once the plant reaches 25% RTP, 12 hours would be allowed for completing the Surveillance. If the Surveillance were not performed within this 12 hour interval (plus the extension allowed by SR 3.0.2), there would then be a failure to perform a Surveillance within the specified Frequency, and the provisions of SR 3.0.3 would apply.

(continued)

1.4 Frequency

EXAMPLES
(continued)

EXAMPLE 1.4-4

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>-----NOTE----- Only required to be met in MODE 1. -----</p>	
<p>Verify leakage rates are within limits.</p>	<p>24 hours</p>

Example 1.4-4 specifies that the requirements of this Surveillance do not have to be met until the plant is in MODE 1. The interval measurement for the Frequency of this Surveillance continues at all times, as described in Example 1.4-1. However, the Note constitutes an "otherwise stated" exception to the Applicability of this Surveillance. Therefore, if the Surveillance were not performed within the 24 hour interval (plus the extension allowed by SR 3.0.2), but the plant was not in MODE 1, there would be no failure of the SR nor failure to meet the LCO. Therefore, no violation of SR 3.0.4 occurs when changing MODES, even with the 24 hour Frequency exceeded, provided the MODE change was not made into MODE 1. Prior to entering MODE 1 (assuming again that the 24 hour Frequency were not met), SR 3.0.4 would require satisfying the SR.

(continued)

1.4 Frequency

EXAMPLES
(continued)

EXAMPLE 1.4-5

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>.....-NOTE-..... Only required to be performed in MODE 1.</p> <p>Perform complete cycle of the valve.</p>	<p>7 days</p>

The interval continues, whether or not the plant operation is in MODE 1, 2, or 3 (the assumed Applicability of the associated LCO) between performances.

As the Note modifies the required performance of the Surveillance, the Note is construed to be part of the "specified Frequency." Should the 7 day interval be exceeded while operation is not in MODE 1, this Note allows entry into and operation in MODES 2 and 3 to perform the Surveillance. The Surveillance is still considered to be performed within the "specified Frequency" if completed prior to entering MODE 1. Therefore, if the Surveillance were not performed within the 7 day (plus the extension allowed by SR 3.0.2) interval, but operation was not in MODE 1, it would not constitute a failure of the SR or failure to meet the LCO. Also, no violation of SR 3.0.4 occurs when changing MODES, even with the 7 day Frequency not met, provided operation does not result in entry into MODE 1.

Once the plant reaches MODE 1, the requirement for the Surveillance to be performed within its specified Frequency applies and would require that the Surveillance had been performed. If the Surveillance were not performed prior to entering MODE 1, there would then be a failure to perform a Surveillance within the specified Frequency, and the provisions of SR 3.0.3 would apply.

(continued)

1.4 Frequency

EXAMPLES
(continued)

EXAMPLE 1.4-6

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>-----NOTE----- Not required to be met in MODE 3. -----</p> <p>Verify parameter is within limits.</p>	<p>24 hours</p>

Example 1.4-6 specifies that the requirements of this Surveillance do not have to be met while the plant is in MODE 3 (the assumed Applicability of the associated LCO is MODES 1, 2, and 3). The interval measurement for the Frequency of this Surveillance continues at all times, as described in Example 1.4-1. However, the Note constitutes an "otherwise stated" exception to the Applicability of this Surveillance. Therefore, if the Surveillance were not performed within the 24 hour interval (plus the extension allowed by SR 3.0.2), and the unit was in MODE 3, there would be no failure of the SR nor failure to meet the LCO. Therefore, no violation of SR 3.0.4 occurs when changing MODES to enter MODE 3, even with the 24 hour Frequency exceeded, provided the MODE change does not result in entry into MODE 2. Prior to entering MODE 2 (assuming again that the 24 hour Frequency were not met), SR 3.0.4 would require satisfying the SR.

2.0 SAFETY LIMITS (SLs)

2.1 SLs

2.1.1 Reactor Core SLs

2.1.1.1 With the reactor steam dome pressure < 685 psig or core flow < 10% rated core flow:

THERMAL POWER shall be $\leq 25\%$ RTP.

2.1.1.2 With the reactor steam dome pressure ≥ 685 psig and core flow $\geq 10\%$ rated core flow:

MCPR shall be ≥ 1.07 .

2.1.1.3 Reactor vessel water level shall be greater than the top of active irradiated fuel.

2.1.2 Reactor Coolant System Pressure SL

Reactor steam dome pressure shall be ≤ 1325 psig.

2.2 SL Violations

With any SL violation, the following actions shall be completed within 2 hours:

2.2.1 Restore compliance with all SLs; and

2.2.2 Insert all insertable control rods.

3.0 LIMITING CONDITION FOR OPERATION (LCO) APPLICABILITY

LCO 3.0.1	LCOs shall be met during the MODES or other specified conditions in the Applicability, except as provided in LCO 3.0.2, LCO 3.0.7, LCO 3.0.8, and LCO 3.0.9.
-----------	--

LCO 3.0.2	<p>Upon discovery of a failure to meet an LCO, the Required Actions of the associated Conditions shall be met, except as provided in LCO 3.0.5 and LCO 3.0.6.</p> <p>If the LCO is met or is no longer applicable prior to expiration of the specified Completion Time(s), completion of the Required Action(s) is not required, unless otherwise stated.</p>
-----------	---

LCO 3.0.3	<p>When an LCO is not met and the associated ACTIONS are not met, an associated ACTION is not provided, or if directed by the associated ACTIONS, the plant shall be placed in a MODE or other specified condition in which the LCO is not applicable. Action shall be initiated within 1 hour to place the plant, as applicable, in:</p> <ul style="list-style-type: none">a. MODE 2 within 7 hours;b. MODE 3 within 13 hours; andc. MODE 4 within 37 hours. <p>Exceptions to this Specification are stated in the individual Specifications.</p> <p>Where corrective measures are completed that permit operation in accordance with the LCO or ACTIONS, completion of the actions required by LCO 3.0.3 is not required.</p> <p>LCO 3.0.3 is only applicable in MODES 1, 2, and 3.</p>
-----------	---

LCO 3.0.4	<p>When an LCO is not met, entry into a MODE or other specified condition in the Applicability shall only be made:</p> <ul style="list-style-type: none">a. When the associated ACTIONS to be entered permit continued operation in the MODE or other specified condition in the Applicability for an unlimited period of time;
-----------	---

(continued)

3.0 LCO APPLICABILITY

LCO 3.0.4
(continued)

- b. After performance of a risk assessment addressing inoperable systems and components, consideration of the results, determination of the acceptability of entering the MODE or other specified condition in the Applicability, and establishment of risk management actions, if appropriate; exceptions to this Specification are stated in the Individual Specifications; or
- c. When an allowance is stated in the individual value, parameter, or other Specification.

This Specification shall not prevent changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS or that are part of a shutdown of the unit.

LCO 3.0.5

Equipment removed from service or declared inoperable to comply with ACTIONS may be returned to service under administrative control solely to perform testing required to demonstrate its OPERABILITY or the OPERABILITY of other equipment. This is an exception to LCO 3.0.2 for the system returned to service under administrative control to perform the testing required to demonstrate OPERABILITY.

LCO 3.0.6

When a supported system LCO is not met solely due to a support system LCO not being met, the Conditions and Required Actions associated with this supported system are not required to be entered. Only the support system LCO ACTIONS are required to be entered. This is an exception to LCO 3.0.2 for the supported system. In this event, an evaluation shall be performed in accordance with Specification 5.5.12, "Safety Function Determination Program (SFDP)." If a loss of safety function is determined to exist by this program, the appropriate Conditions and Required Actions of the LCO in which the loss of safety function exists are required to be entered.

When a support system's Required Action directs a supported system to be declared inoperable or directs entry into Conditions and Required Actions for a supported system, the applicable Conditions and Required Actions shall be entered in accordance with LCO 3.0.2.

(continued)

3.0 LCO APPLICABILITY (continued)

LCO 3.0.7 Special Operations LCOs in Section 3.10 allow specified Technical Specifications (TS) requirements to be changed to permit performance of special tests and operations. Unless otherwise specified, all other TS requirements remain unchanged. Compliance with Special Operations LCOs is optional. When a Special Operations LCO is desired to be met but is not met, the ACTIONS of the Special Operations LCO shall be met. When a Special Operations LCO is not desired to be met, entry into a MODE or other specified condition in the Applicability shall only be made in accordance with the other applicable Specifications.

LCO 3.0.8 When one or more required snubbers are unable to perform their associated support function(s), any affected supported LCOs are not required to be declared not met solely for this reason if risk is assessed and managed, and:

- a. the snubbers not able to perform their associated support function(s) are associated with only one train or subsystem of a multiple train or subsystem supported system or are associated with a single train or subsystem supported system and are able to perform their associated support function within 72 hours; or
- b. the snubbers not able to perform their associated support function(s) are associated with more than one train or subsystem of a multiple train or subsystem supported system and are able to perform their associated support function within 12 hours.

At the end of the specified period, the required snubbers must be able to perform their associated support function(s), or the affected supported system LCOs shall be declared not met.

(continued)

3.0 LCO APPLICABILITY (continued)

LCO 3.0.9 When one or more required barriers are unable to perform their related support function(s), any supported system LCO(s) are not required to be declared not met solely for this reason for up to 30 days provided that at least one train or subsystem of the supported system is OPERABLE and supported by barriers capable of providing their related support function(s), and risk is assessed and managed. This specification may be concurrently applied to more than one train or subsystem of a multiple train or subsystem supported system provided at least one train or subsystem of the supported system is OPERABLE and the barriers supporting each of these trains or subsystems provide their related support function(s) for different categories of initiating events.

For the purposes of this specification, the High Pressure Coolant Injection system, the Reactor Core Isolation Cooling system, and the Automatic Depressurization System are considered independent subsystems of a single system.

If the required OPERABLE train or subsystem becomes inoperable while this specification is in use, it must be restored to OPERABLE status within 24 hours or the provisions of this specification cannot be applied to the trains or subsystems supported by the barriers that cannot perform their related support function(s).

At the end of the specified period, the required barriers must be able to perform their related support function(s) or the supported system LCO(s) shall be declared not met.

3.0 SURVEILLANCE REQUIREMENT (SR) APPLICABILITY

SR 3.0.1 SRs shall be met during the MODES or other specified conditions in the Applicability for individual LCOs, unless otherwise stated in the SR. Failure to meet a Surveillance, whether such failure is experienced during the performance of the Surveillance or between performances of the Surveillance, shall be failure to meet the LCO. Failure to perform a Surveillance within the specified Frequency shall be failure to meet the LCO except as provided in SR 3.0.3. Surveillances do not have to be performed on inoperable equipment or variables outside specified limits.

SR 3.0.2 The specified Frequency for each SR is met if the Surveillance is performed within 1.25 times the interval specified in the Frequency, as measured from the previous performance or as measured from the time a specified condition of the Frequency is met.

For Frequencies specified as "once," the above interval extension does not apply.

If a Completion Time requires periodic performance on a "once per . . ." basis, the above Frequency extension applies to each performance after the initial performance.

Exceptions to this Specification are stated in the individual Specifications.

SR 3.0.3 If it is discovered that a Surveillance was not performed within its specified Frequency, then compliance with the requirement to declare the LCO not met may be delayed, from the time of discovery, up to 24 hours or up to the limit of the specified Frequency, whichever is greater. This delay period is permitted to allow performance of the Surveillance. A risk evaluation shall be performed for any Surveillance delayed greater than 24 hours and the risk impact shall be managed.

If the Surveillance is not performed within the delay period, the LCO must immediately be declared not met, and the applicable Condition(s) must be entered.

When the Surveillance is performed within the delay period and the Surveillance is not met, the LCO must immediately be declared not met, and the applicable Condition(s) must be entered.

(continued)

3.0 SR APPLICABILITY (continued)

SR 3.0.4 Entry into a MODE or other specified condition in the Applicability of an LCO shall only be made when the LCO's Surveillances have been met within their specified Frequency, except as provided by SR 3.0.3. When an LCO is not met due to Surveillances not having been met, entry into a MODE or other specified condition in the Applicability shall only be made in accordance with LCO 3.0.4.

This provision shall not prevent entry into MODES or other specified conditions in the Applicability that are required to comply with ACTIONS or that are part of a shutdown of the unit.

3.1 REACTIVITY CONTROL SYSTEMS

3.1.1 SHUTDOWN MARGIN (SDM)

LCO 3.1.1 SDM shall be $\geq 0.38\% \Delta k/k$, with the highest worth control rod analytically determined.

APPLICABILITY: MODES 1, 2, 3, 4, and 5.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. SDM not within limits in MODE 1 or 2.	A.1 Restore SDM to within limits.	6 hours
B. Required Action and associated Completion Time of Condition A not met.	B.1 Be in MODE 3.	12 hours
C. SDM not within limits in MODE 3.	C.1 Initiate action to fully insert all insertable control rods.	Immediately
D. SDM not within limits in MODE 4.	D.1 Initiate action to fully insert all insertable control rods. <u>AND</u>	Immediately (continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. (continued)	D.2 Initiate action to restore secondary containment to OPERABLE status.	1 hour
	<u>AND</u> D.3 Initiate action to restore one standby gas treatment (SGT) subsystem to OPERABLE status.	1 hour
	<u>AND</u> D.4 Initiate action to restore isolation capability in each required secondary containment penetration flow path not isolated.	1 hour
E. SDM not within limits in MODE 5.	E.1 Suspend CORE ALTERATIONS except for control rod insertion and fuel assembly removal.	Immediately
	<u>AND</u> E.2 Initiate action to fully insert all insertable control rods in core cells containing one or more fuel assemblies.	Immediately
	<u>AND</u>	(continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
E. (continued)	E.3 Initiate action to restore secondary containment to OPERABLE status.	1 hour
	<u>AND</u> E.4 Initiate action to restore one SGT subsystem to OPERABLE status.	1 hour
	<u>AND</u> E.5 Initiate action to restore isolation capability in each required secondary containment penetration flow path not isolated.	1 hour

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.1.1.1 Verify SDM is $\geq 0.38\%$ $\Delta k/k$ with the highest worth control rod analytically determined.	Prior to each in vessel fuel movement during fuel loading sequence <u>AND</u> Once within 4 hours after criticality following fuel movement within the reactor pressure vessel or control rod replacement

3.1 REACTIVITY CONTROL SYSTEMS

3.1.2 Reactivity Anomalies

LCO 3.1.2 The reactivity difference between the measured core k_{eff} and the predicted core k_{eff} shall be within $\pm 1\% \Delta k/k$.

APPLICABILITY: MODES 1 and 2

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Core reactivity difference not within limit.	A.1 Restore core reactivity difference to within limit.	72 hours
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3	12 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.1.2.1 Verify core reactivity difference between the measured core k_{eff} and the predicted core k_{eff} is within $\pm 1\% \Delta k/k$.</p>	<p>Once within 24 hours after reaching equilibrium conditions following startup after fuel movement within the reactor pressure vessel or control rod replacement</p> <p><u>AND</u></p> <p>1000 MWD/T thereafter during operations in MODE 1</p>

3.1 REACTIVITY CONTROL SYSTEMS

3.1.3 Control Rod OPERABILITY

LCO 3.1.3 Each control rod shall be OPERABLE.

APPLICABILITY: MODES 1 and 2.

ACTIONS

-----NOTE-----
Separate Condition entry is allowed for each control rod.

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. One withdrawn control rod stuck.</p>	<p>-----NOTE----- Rod worth minimizer (RWM) may be bypassed as allowed by LCO 3.3.2.1, "Control Rod Block Instrumentation," if required, to allow continued operation. -----</p>	<p>Immediately</p> <p>2 hours</p> <p>(continued)</p>
	<p>A.1 Verify stuck control rod separation criteria met.</p>	
	<p><u>AND</u></p> <p>A.2 Disarm the associated control rod drive (CRD).</p> <p><u>AND</u></p>	

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. (continued)	<p>A.3 Perform SR 3.1.3.2 for each withdrawn OPERABLE control rod.</p> <p><u>AND</u></p> <p>A.4 Perform SR 3.1.1.1.</p>	<p>24 hours from discovery of Condition A concurrent with THERMAL POWER greater than the low power setpoint (LPSP) of the RWM</p> <p>72 hours</p>
B. Two or more withdrawn control rods stuck.	B.1 Be in MODE 3.	12 hours
C. One or more control rods inoperable for reasons other than Condition A or B.	<p>C.1 ----- NOTE----- RWM may be bypassed as allowed by LCO 3.3.2.1, if required, to allow insertion of inoperable control rod and continued operation. -----</p> <p>Fully insert inoperable control rod.</p> <p><u>AND</u></p> <p>C.2 Disarm the associated CRD.</p>	<p>3 hours</p> <p>4 hours</p>

(continued).

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>D. -----NOTE----- Not applicable when THERMAL POWER > 10% RTP. -----</p> <p>Two or more inoperable control rods not in compliance with banked position withdrawal sequence (BPWS) and not separated by two or more OPERABLE control rods.</p>	<p>D.1 Restore compliance with BPWS.</p> <p><u>OR</u></p> <p>D.2 Restore control rod to OPERABLE status.</p>	<p>4 hours</p> <p>4 hours</p>
<p>E. Required Action and associated Completion Time of Condition A, C. or D not met.</p> <p><u>OR</u></p> <p>Nine or more control rods inoperable.</p>	<p>E.1 Be in MODE 3.</p>	<p>12 hours</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.1.3.1	Determine the position of each control rod.	In accordance with the Surveillance Frequency Control Program
SR 3.1.3.2	<p>----- NOTE-----</p> <p>Not required to be performed until 31 days after the control rod is withdrawn and THERMAL POWER is greater than the LPSP of the RWM.</p> <p>-----</p> <p>Insert each withdrawn control rod at least one notch.</p>	In accordance with the Surveillance Frequency Control Program
SR 3.1.3.3	Verify each control rod scram time from fully withdrawn to notch position 04 is ≤ 7 seconds.	In accordance with SR 3.1.4.1, SR 3.1.4.2, SR 3.1.4.3, and SR 3.1.4.4
SR 3.1.3.4	Verify each control rod does not go to the withdrawn overtravel position.	<p>Each time the control rod is withdrawn to "full out" position</p> <p><u>AND</u></p> <p>Prior to declaring control rod OPERABLE after work on control rod or CRD System that could affect coupling</p>

3.1 REACTIVITY CONTROL SYSTEMS

3.1.4 Control Rod Scram Times

- LCO 3.1.4
- a. No more than 10 OPERABLE control rods shall be "slow," in accordance with Table 3.1.4-1; and
 - b. No more than 2 OPERABLE control rods that are "slow" shall occupy adjacent locations.

APPLICABILITY: MODES 1 and 2.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Requirements of the LCO not met.	A.1 Be in MODE 3.	12 hours

SURVEILLANCE REQUIREMENTS

-----NOTE-----
 During single control rod scram time Surveillances, the control rod drive (CRD) pumps shall be isolated from the associated scram accumulator.

SURVEILLANCE	FREQUENCY
SR 3.1.4.1 Verify each control rod scram time is within the limits of Table 3.1.4-1 with reactor steam dome pressure \geq 800 psig.	Prior to exceeding 40% RTP after each reactor shutdown \geq 120 days

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.1.4.2	Verify, for a representative sample, each tested control rod scram time is within the limits of Table 3.1.4-1 with reactor steam dome pressure \geq 800 psig.	In accordance with the Surveillance Frequency Control Program
SR 3.1.4.3	Verify each affected control rod scram time is within the limits of Table 3.1.4-1 with any reactor steam dome pressure.	Prior to declaring control rod OPERABLE after work on control rod or CRD System that could affect scram time
SR 3.1.4.4	Verify each affected control rod scram time is within the limits of Table 3.1.4-1 with reactor steam dome pressure \geq 800 psig.	<p>Prior to exceeding 40% RTP after fuel movement within the affected core cell</p> <p><u>AND</u></p> <p>Prior to exceeding 40% RTP after work on control rod or CRD System that could affect scram time</p>

Table 3.1.4-1 (page 1 of 1)
Control Rod Scram Times

----- NOTES -----

1. OPERABLE control rods with scram times not within the limits of this Table are considered "slow."
 2. Enter applicable Conditions and Required Actions of LCO 3.1.3, "Control Rod OPERABILITY," for control rods with scram times > 7 seconds to notch position 04. These control rods are inoperable, in accordance with SR 3.1.3.3, and are not considered "slow."
-

NOTCH POSITION	SCRAM TIMES (a) (b) when REACTOR STEAM DOME PRESSURE ≥ 800 psig (seconds)
46	0.44
36	1.08
26	1.83
06	3.35

(a) . Maximum scram time from fully withdrawn position, based on de-energization of scram pilot valve solenoids at time zero.

(b) . Scram times as a function of reactor steam dome pressure, when < 800 psig, are within established limits.

3.1 REACTIVITY CONTROL SYSTEMS

3.1.5 Control Rod Scram Accumulators

LCO 3.1.5 Each control rod scram accumulator shall be OPERABLE.

APPLICABILITY: MODES 1 and 2.

ACTIONS

-----NOTE-----
Separate Condition entry is allowed for each control rod scram accumulator.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One control rod scram accumulator inoperable with reactor steam dome pressure \geq 900 psig.	A.1 -----NOTE----- Only applicable if the associated control rod scram time was within the limits of Table 3.1.4-1 during the last scram time Surveillance. ----- Declare the associated control rod scram time "slow."	8 hours
	<u>OR</u> A.2 Declare the associated control rod inoperable.	8 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>B. Two or more control rod scram accumulators inoperable with reactor steam dome pressure \geq 900 psig.</p>	<p>B.1 Restore charging water header pressure to \geq 940 psig.</p> <p><u>AND</u></p> <p>B.2.1 -----NOTE----- Only applicable if the associated control rod scram time was within the limits of Table 3.1.4-1 during the last scram time Surveillance. -----</p> <p>Declare the associated control rod scram time "slow."</p> <p><u>OR</u></p> <p>B.2.2 Declare the associated control rod inoperable.</p>	<p>20 minutes from discovery of Condition B concurrent with charging water header pressure $<$ 940 psig</p> <p>1 hour</p> <p>1 hour</p>
<p>C. One or more control rod scram accumulators inoperable with reactor steam dome pressure $<$ 900 psig.</p>	<p>C.1 Verify all control rods associated with inoperable accumulators are fully inserted.</p> <p><u>AND</u></p>	<p>Immediately upon discovery of charging water header pressure $<$ 940 psig</p> <p>(continued)</p>

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. (continued)	C.2 Declare the associated control rod inoperable.	1 hour
D. Required Action B.1 or C.1 and associated Completion Time not met.	D.1 ----- NOTE----- Not applicable if all inoperable control rod scram accumulators are associated with fully inserted control rods. ----- Place the reactor mode switch in the shutdown position.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.1.5.1 Verify each control rod scram accumulator pressure is \geq 940 psig.	In accordance with the Surveillance Frequency Control Program

3.1 REACTIVITY CONTROL SYSTEMS

3.1.6 Rod Pattern Control

LCO 3.1.6 OPERABLE control rods shall comply with the requirements of the banked position withdrawal sequence (BPWS).

APPLICABILITY: MODES 1 and 2 with THERMAL POWER \leq 10% RTP.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. One or more OPERABLE control rods not in compliance with BPWS.</p>	<p>A.1NOTE..... Rod worth minimizer (RWM) may be bypassed as allowed by LCO 3.3.2.1, "Control Rod Block Instrumentation." Move associated control rod(s) to correct position.</p>	<p>8 hours</p>
	<p><u>OR</u> A.2 Declare associated control rod(s) inoperable.</p>	<p>8 hours</p>

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. Nine or more OPERABLE control rods not in compliance with BPWS.	B.1 ----- NOTE ----- Rod worth minimizer (RWM) may be bypassed as allowed by LCO 3.3.2.1. ----- Suspend withdrawal of control rods.	Immediately
	<u>AND</u> B.2 Place the reactor mode switch in the shutdown position.	1 hour

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.1.6.1 Verify all OPERABLE control rods comply with BPWS.	In accordance with the Surveillance Frequency Control Program

3.1 REACTIVITY CONTROL SYSTEMS

3.1.7 Standby Liquid Control (SLC) System

LCO 3.1.7 Two SLC subsystems shall be OPERABLE

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One SLC subsystem inoperable.	A.1 Restore SLC subsystem to OPERABLE status.	7 days <u>OR</u> In accordance with the Risk Informed Completion Time Program
B. Two SLC subsystems inoperable.	B.1 Restore one SLC subsystem to OPERABLE status.	8 hours
C. Required Action and associated Completion Time not met.	C.1 Be in MODE 3. <u>AND</u> C.2 Be in MODE 4.	12 hours 36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.1.7.1	Verify available volume of sodium pentaborate solution is within the limits of Figure 3.1.7-1.	In accordance with the Surveillance Frequency Control Program
SR 3.1.7.2	Verify temperature of sodium pentaborate solution is within the limits of Figure 3.1.7-2.	In accordance with the Surveillance Frequency Control Program
SR 3.1.7.3	Verify temperature of pump suction piping is within the limits of Figure 3.1.7-2.	In accordance with the Surveillance Frequency Control Program
SR 3.1.7.4	Verify continuity of explosive charge.	In accordance with the Surveillance Frequency Control Program

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.1.7.5	Verify the concentration of sodium pentaborate in solution is within the limits of Figure 3.1. 7-1.	In accordance with the Surveillance Frequency Control Program <u>AND</u> Once within 24 hours after water or sodium pentaborate is added to solution <u>AND</u> Once within 24 hours after solution temperature is restored within the limits of Figure 3.1.7-2
SR 3.1.7.6	Verify each SLC subsystem manual valve in the flow path that is not locked, sealed, or otherwise secured in position is in the correct position, or can be aligned to the correct position.	In accordance with the Surveillance Frequency Control Program
SR 3.1.7.7	Verify each pump develops a flow rate ≥ 50 gpm at a discharge pressure ≥ 1275 psig.	In accordance with the INSERVICE TESTING PROGRAM
SR 3.1.2.8	Verify flow through one SLC subsystem from pump into reactor pressure vessel.	In accordance with the Surveillance Frequency Control Program

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.1.7.9	Verify all heat traced piping between storage tank and pump suction is unblocked.	In accordance with the Surveillance Frequency Control Program <u>AND</u> Once within 24 hours after piping temperature is restored within the limits of Figure 3.1.7-2
SR 3.1.7.10	Verify sodium pentaborate enrichment is ≥ 34.7 atom percent B-10.	Prior to addition to SLC tank
SR 3.1.7.11	Verify sodium pentaborate enrichment in solution in the SLC tank is ≥ 34.7 atom percent B-10.	In accordance with the Surveillance Frequency Control Program




Figure 3.1.7-1 (page 1 of 1)
Sodium Pentaborate Solution Volume
Versus Concentration Requirements




Figure 3.1.7-2 (page 1 of 1)
Sodium Pentaborate Solution Temperature
Versus Concentration Requirements

3.1 REACTIVITY CONTROL SYSTEMS

3.1.8 Scram Discharge Volume (SDV) Vent and Drain Valves

LCO 3.1.8 Each SDV vent and drain valve shall be OPERABLE.

APPLICABILITY: MODES 1 and 2.

ACTIONS

-----NOTES-----

1. Separate Condition entry is allowed for each SDV vent and drain line.
 2. An isolated line may be unisolated under administrative control to allow draining and venting of the SDV.
-

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more SDV vent or drain lines with one valve inoperable.	A.1 Isolate the associated line.	7 days
B. One or more SDV vent or drain lines with both valves inoperable.	B.1 Isolate the associated line.	8 hours
C. Required Action and associated Completion Time not met.	C.1 Be in MODE 3.	12 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.1.8.1	<p>-----NOTE----- Not required to be met on vent and drain valves closed during performance of SR 3.1.8.2. -----</p> <p>Verify each SDV vent and drain valve is open.</p>	In accordance with the Surveillance Frequency Control Program
SR 3.1.8.2	Cycle each SDV vent and drain valve to the fully closed and fully open position.	In accordance with the INSERVICE TESTING PROGRAM
SR 3.1.8.3	<p>Verify each SDV vent and drain valve:</p> <ul style="list-style-type: none"> a. Closes in ≤ 30 seconds after receipt of an actual or simulated scram signal; and b. Opens when the actual or simulated scram signal is reset. 	In accordance with the Surveillance Frequency Control Program

3.2 POWER DISTRIBUTION LIMITS

3.2.1 AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR)

LCO 3.2.1 All APLHGRs shall be less than or equal to the limits specified in the COLR.

APPLICABILITY: THERMAL POWER \geq 25% RTP.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Any APLHGR not within limits.	A.1 Restore APLHGR(s) to within limits.	2 hours
B. Required Action and associated Completion Time not met.	B.1 Reduce THERMAL POWER to < 25% RTP.	4 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.2.1.1 Verify all APLHGRs are less than or equal to the limits specified in the COLR.	Once within 12 hours after \geq 25% RTP <u>AND</u> In accordance with the Surveillance Frequency Control Program

3.2 POWER DISTRIBUTION LIMITS

3.2.2 MINIMUM CRITICAL POWER RATIO (MCPR)

LCO 3.2.2 All MCPRs shall be greater than or equal to the MCPR operating limits specified in the COLR.

APPLICABILITY: THERMAL POWER \geq 25% RTP.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Any MCPR not within limits.	A.1 Restore MCPR(s) to within limits.	2 hours
B. Required Action and associated Completion Time not met.	B.1 Reduce THERMAL POWER to < 25% RTP.	4 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.2.2.1 Verify all MCPRs are greater than or equal to the limits specified in the COLR.	Once within 12 hours after \geq 25% RTP <u>AND</u> In accordance with the Surveillance Frequency Control Program

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
SR 3.2.2.2 Determine the M CPR limits.	Once within 72 hours after each completion of SR 3.1.4.1 <u>AND</u> Once within 72 hours after each completion of SR 3.1.4.2 <u>AND</u> Once within 72 hours after each completion of SR 3.1.4.4

3.2 POWER DISTRIBUTION LIMITS

3.2.3 LINEAR HEAT GENERATION RATE (LHGR)

LCO 3.2.3 All LHGRs shall be less than or equal to the limits specified in the COLR.

APPLICABILITY: THERMAL POWER \geq 25% RTP.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Any LHGR not within limits.	A.1 Restore LHGR(s) to within limits.	2 hours
B. Required Action and associated Completion Time not met.	B.1 Reduce THERMAL POWER to < 25% RTP.	4 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.2.3.1 Verify all LHGRs are less than or equal to the limits specified in the COLR.	Once within 12 hours after \geq 25% RTP <u>AND</u> In accordance with the Surveillance Frequency Control Program

3.3 INSTRUMENTATION

3.3.1.1 Reactor Protection System (RPS) Instrumentation

LCO 3.3.1.1 The RPS Instrumentation for each Function in Table 3.3.1.1-1 shall be OPERABLE.

APPLICABILITY: According to Table 3.3.1.1-1.

ACTIONS

----- NOTE -----

1. Separate Condition entry is allowed for each channel.
 2. When Functions 2.b and 2.c channels are inoperable due to the calculated power exceeding the APRM output by more than 2% RTP while operating at $\geq 25\%$ RTP, entry into associated Conditions and Required Actions may be delayed for up to 2 hours.
-

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. One or more required channels inoperable.</p>	<p>A.1 Place channel in trip.</p>	<p>12 hours</p> <p><u>OR</u></p> <p>----- NOTE ----- Not applicable when trip capability is not maintained. -----</p> <p>In accordance with the Risk Informed Completion Time Program</p>
	<p><u>OR</u></p> <p>A.2 Place associated trip system in trip.</p>	<p>12 hours</p> <p><u>OR</u></p> <p>----- NOTE ----- Not applicable when trip capability is not maintained. -----</p> <p>In accordance with the Risk Informed Completion Time Program</p>

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>B. One or more Functions with one or more required channels inoperable in both trip systems.</p>	<p>B.1 Place channel in one trip system in trip.</p> <p><u>OR</u></p> <p>B.2 Place one trip system in trip.</p>	<p>6 hours</p> <p><u>OR</u></p> <p>-----NOTE----- Not applicable when trip capability is not maintained. -----</p> <p>In accordance with the Risk Informed Completion Time Program</p> <p>6 hours</p> <p><u>OR</u></p> <p>-----NOTE----- Not applicable when trip capability is not maintained. -----</p> <p>In accordance with the Risk Informed Completion Time Program</p>

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. One or more Functions with RPS trip capability not maintained.	C.1 Restore RPS trip capability.	1 hour
D. Required Action and associated Completion Time of Condition A, B, or C not met.	D.1 Enter the Condition referenced in Table 3.3.1.1-1 for the channel.	Immediately
E. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	E.1 Reduce THERMAL POWER to < 29% RTP.	4 hours
F. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	F.1 Be in MODE 2.	6 hours
G. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	G.1 Be in MODE 3.	12 hours
H. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	H.1 Initiate action to fully insert all insertable control rods in core cells containing one or more fuel assemblies.	Immediately

SURVEILLANCE REQUIREMENTS

----- NOTES -----

1. Refer to Table 3.3.1.1-1 to determine which SRs apply for each RPS Function.
 2. When a channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours provided the associated Function maintains RPS trip capability.
-

SURVEILLANCE		FREQUENCY
SR 3.3.1.1.1	Perform CHANNEL CHECK.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.2	<p>----- NOTE -----</p> <p>Not required to be performed until 12 hours after THERMAL POWER \geq 25% RTP.</p> <p>-----</p> <p>Verify the calculated power does not exceed the average power range monitor (APRM) channels by greater than 2% RTP while operating at \geq 25% RTP.</p>	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.3	<p>----- NOTE -----</p> <p>Not required to be performed when entering MODE 2 from MODE 1 until 12 hours after entering MODE 2.</p> <p>-----</p> <p>Perform CHANNEL FUNCTIONAL TEST.</p>	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.4	Perform a functional test of each RPS automatic scram contactor.	In accordance with the Surveillance Frequency Control Program

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.3.1.1.5	NOT USED	
SR 3.3.1.1.6	NOT USED	
SR 3.3.1.1.7	Calibrate the local power range monitors.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.8	Perform CHANNEL FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.9	<p>-----NOTES-----</p> <ol style="list-style-type: none"> 1. Neutron detectors are excluded. 2. For Functions 1.a and 2.a, not required to be performed when entering MODE 2 from MODE 1 until 12 hours after entering MODE 2. 3. For Function 2.b, the recirculation loop flow signal portion of the channel is excluded. <p>-----</p> <p>Perform CHANNEL CALIBRATION.</p>	In accordance with the Surveillance Frequency Control Program

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.3.1.1.10	Calibrate the trip units.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.11	Perform CHANNEL FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.12	<p style="text-align: center;">-----NOTE-----</p> <p>For Function 2.b, all portions of the channel except the recirculation loop flow signal portion are excluded.</p> <p style="text-align: center;">-----</p> <p>Perform CHANNEL CALIBRATION.</p>	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.13	Perform LOGIC SYSTEM FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.14	Verify Turbine Stop Valve-Closure and Turbine Control Valve Fast Closure, EHC Oil Pressure - Low Functions are not bypassed when THERMAL POWER is $\geq 29\%$ RTP.	In accordance with the Surveillance Frequency Control Program
SR 3.3.1.1.15	<p style="text-align: center;">-----NOTES-----</p> <ol style="list-style-type: none"> 1. Neutron detectors are excluded. 2. "n" equals 2 channels for the purpose of determining the STAGGERED TEST BASIS Frequency. <p style="text-align: center;">-----</p> <p>Verify the RPS RESPONSE TIME is within limits.</p>	In accordance with the Surveillance Frequency Control Program

Table 3.3.1.1-1 (page 1 of 3)
Reactor Protection System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1	SURVEILLANCE REQUIREMENTS	ALLOWED VALUE
1. Intermediate Range Monitors					
a. Neutron Flux - High	2	3	G	SR 3.3.1.1.1 SR 3.3.1.1.3 SR 3.3.1.1.4 SR 3.3.1.1.9 SR 3.3.1.1.13	≤ 120/125 divisions of full scale
	5 ^(a)	3	H	SR 3.3.1.1.1 SR 3.3.1.1.3 SR 3.3.1.1.4 SR 3.3.1.1.9 SR 3.3.1.1.13	≤ 120/125 divisions of full scale
b. Inop	2	3	G	SR 3.3.1.1.3 SR 3.3.1.1.4 SR 3.3.1.1.13	NA
	5 ^(a)	3	H	SR 3.3.1.1.3 SR 3.3.1.1.4 SR 3.3.1.1.13	NA
2. Average Power Range Monitors					
a. Neutron Flux - High, (Startup)	2	2	G	SR 3.3.1.1.1 SR 3.3.1.1.3 SR 3.3.1.1.4 SR 3.3.1.1.7 SR 3.3.1.1.9 SR 3.3.1.1.13	≤ 15% RTP
b. Neutron Flux - High (Flow Biased)	1	2	F	SR 3.3.1.1.1 SR 3.3.1.1.2 SR 3.3.1.1.4 SR 3.3.1.1.7 SR 3.3.1.1.8 SR 3.3.1.1.9 SR 3.3.1.1.12 SR 3.3.1.1.13 SR 3.3.1.1.15	As specified in the COLR and ≤ 117% RTP

(continued)

(a) With any control rod withdrawn from a core cell containing one or more fuel assemblies.

Table 3.3.1.1-1 (page 2 of 3)
Reactor Protection System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1	SURVEILLANCE REQUIREMENTS	ALLOWED VALUE
2. Average Power Range Monitors (continued)					
c. Neutron Flux - High (Fixed)	1	2	F	SR 3.3.1.1.1 SR 3.3.1.1.2 SR 3.3.1.1.4 SR 3.3.1.1.7 SR 3.3.1.1.8 SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 120% RTP
d. Inop	1,2	2	G	SR 3.3.1.1.4 SR 3.3.1.1.7 SR 3.3.1.1.8 SR 3.3.1.1.13	NA
3. Reactor Pressure - High	1,2	2	G	SR 3.3.1.1.1 SR 3.3.1.1.4 SR 3.3.1.1.8 SR 3.3.1.1.10 SR 3.3.1.1.12 SR 3.3.1.1.13	≤ 1080 psig
4. Reactor Vessel Water Level - Low (Level 3)	1,2	2	G	SR 3.3.1.1.1 SR 3.3.1.1.4 SR 3.3.1.1.8 SR 3.3.1.1.10 SR 3.3.1.1.12 SR 3.3.1.1.13	≥ 177 inches
5. Main Steam Isolation Valve - Closure	1	8	F	SR 3.3.1.1.4 SR 3.3.1.1.8 SR 3.3.1.1.12 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 15% closed
6. Drywell Pressure - High	1,2	2	G	SR 3.3.1.1.1 SR 3.3.1.1.4 SR 3.3.1.1.8 SR 3.3.1.1.10 SR 3.3.1.1.12 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 2.7 psig

(continued)

Table 3.3.1.1-1 (page 3 of 3)
Reactor Protection System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
7. Scram Discharge Volume Water Level - High					
a. Differential Pressure Transmitter/Trip Unit	1,2	2	G	SR 3.3.1.1.1 SR 3.3.1.1.4 SR 3.3.1.1.9 SR 3.3.1.1.13	≤ 34.5 gallons
	5(a)	2	H	SR 3.3.1.1.1 SR 3.3.1.1.4 SR 3.3.1.1.9 SR 3.3.1.1.13	≤ 34.5 gallons
b. Level Switch	1,2	2	G	SR 3.3.1.1.4 SR 3.3.1.1.8 SR 3.3.1.1.12 SR 3.3.1.1.13	≤ 34.5 gallons
	5(a)	2	H	SR 3.3.1.1.4 SR 3.3.1.1.8 SR 3.3.1.1.12 SR 3.3.1.1.13	≤ 34.5 gallons
8. Turbine Stop Valve - Closure	≥ 29% RTP	4	E	SR 3.3.1.1.1 SR 3.3.1.1.4 SR 3.3.1.1.8 SR 3.3.1.1.10 SR 3.3.1.1.12 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 15% closed
9. Turbine Control Valve Fast Closure, EHC Oil Pressure - Low	≥ 29% RTP	2	E	SR 3.3.1.1.1 SR 3.3.1.1.4 SR 3.3.1.1.8 SR 3.3.1.1.10 SR 3.3.1.1.12 SR 3.3.1.1.13 SR 3.3.1.1.14 SR 3.3.1.1.15	≥ 500 psig and ≤ 850 psig
10. Reactor Mode Switch – Shutdown Position	1,2	1	G	SR 3.3.1.1.11 SR 3.3.1.1.13	NA
	5(a)	1	H	SR 3.3.1.1.11 SR 3.3.1.1.13	NA
11. Manual Scram	1,2	1	G	SR 3.3.1.1.8 SR 3.3.1.1.13	NA
	5(a)	1	H	SR 3.3.1.1.8 SR 3.3.1.1.13	NA

(a) With any control rod withdrawn from a core cell containing one or more fuel assemblies.

3.3 INSTRUMENTATION

3.3.1.2 Source Range Monitor (SRM) Instrumentation

LCO 3.3.1.2 The SRM instrumentation in Table 3.3.1.2-1 shall be OPERABLE.

APPLICABILITY: According to Table 3.3.1.2-1.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more required SRMs inoperable in MODE 2 with intermediate range monitors (IRMs) on Range 2 or below.	A.1 Restore required SRMs to OPERABLE status.	4 hours
B. Three required SRMs inoperable in MODE 2 with IRMs on Range 2 or below.	B.1 Suspend control rod withdrawal.	Immediately
C. Required Action and associated Completion Time of Condition A or B not met.	C.1 Be in MODE 3.	12 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. One or more required SRMs inoperable in MODE 3 or 4.	D.1 Fully insert all insertable control rods.	1 hour
	<u>AND</u>	
	D.2 Place reactor mode switch in the shutdown position.	1 hour
E. One or more required SRMs inoperable in MODE 5.	E.1 Suspend CORE ALTERATIONS except for control rod insertion.	Immediately
	<u>AND</u>	
	E.2 Initiate action to fully insert all insertable control rods in core cells containing one or more fuel assemblies.	Immediately

SURVEILLANCE REQUIREMENTS

----- NOTE -----
Refer to Table 3.3.1.2-1 to determine which SRs apply for each applicable MODE or other specified condition.

SURVEILLANCE	FREQUENCY
SR 3.3.1.2.1 Perform CHANNEL CHECK.	In accordance with the Surveillance Frequency Control Program

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.3.1.2.2 ----- NOTE-----</p> <ol style="list-style-type: none"> 1. Only required to be met during CORE ALTERATIONS. 2. One SRM may be used to satisfy more than one of the following. <p>-----</p> <p>Verify an OPERABLE SRM detector is located in:</p> <ol style="list-style-type: none"> a. The fueled region; b. The core quadrant where CORE ALTERATIONS are being performed, when the associated SRM is included in the fueled region; and c. A core quadrant adjacent to where CORE ALTERATIONS are being performed, when the associated SRM is included in the fueled region. 	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.3.1.2.3 Perform CHANNEL CHECK.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.3.1.2.4 ----- NOTE-----</p> <p>Not required to be met with less than or equal to four fuel assemblies adjacent to the SRM and no other fuel assemblies in the associated core quadrant.</p> <p>-----</p> <p>Verify count rate is ≥ 3.0 cps with a signal to noise ratio $\geq 2:1$.</p> <p>or</p> <p>Verify count rate is ≥ 0.7 cps with a signal to noise ratio $\geq 20:1$.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.3.1.2.5 ----- NOTE ----- The determination of signal to noise ratio is not required to be met with less than or equal to four fuel assemblies adjacent to the SRM and no other fuel assemblies in the associated core quadrant. ----- Perform CHANNEL FUNCTIONAL TEST and determination of signal to noise ratio.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.3.1.2.6 ----- NOTE ----- Not required to be performed until 12 hours after IRMs on Range 2 or below. ----- Perform CHANNEL FUNCTIONAL TEST and determination of signal to noise ratio.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.3.1.2.7 ----- NOTE ----- 1. Neutron detectors are excluded. 2. Not required to be performed until 12 hours after IRMs on Range 2 or below. ----- Perform CHANNEL CALIBRATION.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>

Table 3.3.1.2-1 (page 1 of 1)
Source Range Monitor Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	SURVEILLANCE REQUIREMENTS
1. Source Range Monitor	2(a)	3	SR 3.3.1.2.1 SR 3.3.1.2.4 SR 3.3.1.2.6 SR 3.3.1.2.7
	3.4	2	SR 3.3.1.2.3 SR 3.3.1.2.4 SR 3.3.1.2.6 SR 3.3.1.2.7
	5	2(b)(c)	SR 3.3.1.2.1 SR 3.3.1.2.2 SR 3.3.1.2.4 SR 3.3.1.2.5 SR 3.3.1.2.7

(a) With IRMs on Range 2 or below.

(b) Only one SRM channel is required to be OPERABLE during spiral offload or reload when the fueled region includes only that SRM detector.

(c) Special movable detectors may be used in place of SRMs if connected to normal SRM circuits.

3.3 INSTRUMENTATION

3.3.2.1 Control Rod Block Instrumentation

LC0 3.3.2.1 The control rod block instrumentation for each Function in Table 3.3.2.1-1 shall be OPERABLE.

APPLICABILITY: According to Table 3.3.2.1-1.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One rod block monitor (RBM) channel inoperable.	A.1 Restore RBM channel to OPERABLE status.	24 hours
B. Required Action and associated Completion Time of Condition A not met. <u>OR</u> Two RBM channels inoperable.	B.1 Place one RBM channel in trip.	1 hour
C. Rod worth minimizer (RWM) inoperable during reactor startup.	C.1 Suspend control rod movement except by scram. <u>OR</u>	Immediately (continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. (continued)	<p>C.2.1.1 Verify \geq 12 rods withdrawn.</p> <p style="text-align: center;"><u>OR</u></p> <p>C.2.1.2 Verify by administrative methods that startup with RWM inoperable has not been performed in the current calendar year.</p> <p style="text-align: center;"><u>AND</u></p> <p>C.2.2 Verify movement of control rods is in compliance with banked position withdrawal sequence (BPWS) by a second licensed operator or other qualified member of the technical staff.</p>	<p>Immediately</p> <p>Immediately</p> <p>During control rod movement</p>
D. RWM inoperable during reactor shutdown.	D.1 Verify movement of control rods is in compliance with BPWS by a second licensed operator or other qualified member of the technical staff.	During control rod movement

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
E. One or more Reactor Mode Switch—Shutdown Position channels inoperable.	E.1 Suspend control rod withdrawal.	Immediately
	<u>AND</u> E.2 Initiate action to fully insert all insertable control rods in core cells containing one or more fuel assemblies.	Immediately

SURVEILLANCE REQUIREMENTS

- NOTE -----
1. Refer to Table 3.3.2.1-1 to determine which SRs apply for each Control Rod Block Function.
 2. When an RBM channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours provided the associated Function maintains control rod block capability.
-

SURVEILLANCE	FREQUENCY
SR 3.3.2.1.1 Perform CHANNEL FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program
SR 3.3.2.1.2 ----- NOTE ----- Not required to be performed until 1 hour after any control rod is withdrawn at $\leq 10\%$ RTP in MODE 2. ----- Perform CHANNEL FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.3.2.1.3 ----- NOTE ----- Not required to be performed until 1 hour after THERMAL POWER is \leq 10% RTP in MODE 1. -----</p> <p>Perform CHANNEL FUNCTIONAL TEST.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.3.2.1.4 ----- NOTE ----- Neutron detectors are excluded. -----</p> <p>Verify the RBM is not bypassed:</p> <p>a. When THERMAL POWER is \geq 30% RTP; and</p> <p>b. When a peripheral control rod is not selected.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.3.2.1.5 ----- NOTE -----</p> <p>1. Neutron detectors are excluded.</p> <p>2. For Function 1.a, the recirculation loop flow signal portion of the channel is excluded. -----</p> <p>Perform CHANNEL CALIBRATION.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.3.2.1.6 Verify the RWM is not bypassed when THERMAL POWER is \leq 10% RTP.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.3.2.1.7	<p>----- NOTE ----- Not required to be performed until 1 hour after reactor mode switch is in the shutdown position. -----</p> <p>Perform CHANNEL FUNCTIONAL TEST.</p>	In accordance with the Surveillance Frequency Control Program
SR 3.3.2.1.8	<p>----- NOTE ----- For Function 1.a, all portions of the channel except the recirculation loop flow signal portion are excluded. -----</p> <p>Perform CHANNEL CALIBRATION.</p>	In accordance with the Surveillance Frequency Control Program
SR 3.3.2.1.9	Verify control rod sequences input to the RWM are in conformance with BPWS.	Prior to declaring RWM OPERABLE following loading of sequence into RWM

Control Rod Block Instrumentation
3.3.2.1

Table 3.3.2.1-1 (page 1 of 1)
Control Rod Block Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. Rod Block Monitor				
a. Upscale	(a)	2	SR 3.3.2.1.4 SR 3.3.2.1.5 SR 3.3.2.1.8	As specified in the COLR
b. Inop	(a)	2	SR 3.3.2.1.1 SR 3.3.2.1.4	NA
c. Downscale	(a)	2	SR 3.3.2.1.4 SR 3.3.2.1.5	≥ 2.5/125 divisions of full scale
2. Rod Worth Minimizer	1 ^(b) , 2 ^(b)	1	SR 3.3.2.1.2 SR 3.3.2.1.3 SR 3.3.2.1.6 SR 3.3.2.1.9	NA
3. Reactor Mode Switch - Shutdown Position	(c)	2	SR 3.3.2.1.7	NA

(a) THERMAL POWER ≥ 30% RTP and no peripheral control rod selected.

(b) With THERMAL POWER ≤ 10% RTP.

(c) Reactor mode switch in the shutdown position.

3.3 INSTRUMENTATION

3.3.2.2 Feedwater and Main Turbine High Water Level Trip Instrumentation

LCO 3.3.2.2 Three channels of feedwater and main turbine high water level trip instrumentation shall be OPERABLE.

APPLICABILITY: THERMAL POWER ≥ 25% RTP.

ACTIONS

----- NOTE -----
Separate Condition entry is allowed for each channel.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One feedwater and main turbine high water level trip channel inoperable.	A.1 Place channel in trip.	7 days <u>OR</u> ----- NOTE ----- Not applicable when trip capability is not maintained ----- In accordance with the Risk Informed Completion Time Program
B. Two or more feedwater and main turbine high water level trip channels inoperable.	B.1 Restore feedwater and main turbine high water level trip capability.	2 hours

(continued)

Feedwater and Main Turbine High Water Level Trip Instrumentation
3.3.2.2

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. Required Action and associated Completion Time not met.	C.1 ----- NOTE----- Only applicable if inoperable channel is the result of inoperable feedwater pump turbine or main turbine stop valve. ----- Remove affected stop valve(s) from service.	4 hours
	<u>OR</u> C.2 Reduce THERMAL POWER to < 25% RTP.	4 hours

SURVEILLANCE REQUIREMENTS

----- NOTE -----

When a channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours provided feedwater and main turbine high water level trip capability is maintained.

SURVEILLANCE	FREQUENCY
SR 3.3.2.2.1 Perform CHANNEL CHECK.	In accordance with the Surveillance Frequency Control Program
SR 3.3.2.2.2 ----- NOTE ----- Only required to be performed when in MODE 4 for > 24 hours. ----- Perform CHANNEL FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program
SR 3.3.2.2.3 Perform CHANNEL CALIBRATION. The Allowable Value shall be ≤ 222.5 inches.	In accordance with the Surveillance Frequency Control Program
SR 3.3.2.2.4 Perform LOGIC SYSTEM FUNCTIONAL TEST including valve actuator.	In accordance with the Surveillance Frequency Control Program

3.3 INSTRUMENTATION

3.3.3.1 Post Accident Monitoring (PAM) Instrumentation

LCO 3.3.3.1 The PAM Instrumentation for each Function in Table 3.3.3.1-1 shall be **OPERABLE**.

APPLICABILITY: MODES 1 and 2.

ACTIONS

-----**NOTE**-----
 Separate Condition entry is allowed for each Function.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more Functions with one required channel inoperable.	A.1 Restore required channel to OPERABLE status.	30 days
B. Required Action and associated Completion Time of Condition A not met.	B.1 Initiate action in accordance with Specification 5.6.6.	Immediately
C. One or more Functions with two required channels inoperable.	C.1 Restore one required channel to OPERABLE status.	7 days

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. Required Action and associated Completion Time of Condition C not met.	D.1 Enter the Condition referenced in Table 3.3.3.1-1 for the channel.	Immediately
E. As required by Required Action D.1 and referenced in Table 3.3.3.1-1.	E.1 Be in MODE 3.	12 hours
F. As required by Required Action D.1 and referenced in Table 3.3.3.1-1.	F.1 Initiate action in accordance with Specification 5.6.6.	Immediately

SURVEILLANCE REQUIREMENTS

----- NOTE -----

When a channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours provided the other required channel in the associated Function is OPERABLE.

SURVEILLANCE	FREQUENCY
SR 3.3.3.1.1 Perform CHANNEL CHECK of each required PAM instrument channel.	In accordance with the Surveillance Frequency Control Program

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.3.3.1.2	Perform CHANNEL CALIBRATION of each required PAM instrumentation channel.	In accordance with the Surveillance Frequency Control Program

Table 3.3.3.1-1 (page 1 of 1)
Post Accident Monitoring Instrumentation

FUNCTION	REQUIRED CHANNELS	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1
1. Reactor Vessel Pressure	2	E
2. Reactor Vessel Water Level		
a. Fuel Zone	2	E
b. Wide Range	2	E
3. Suppression Pool Water Level (Wide Range)	2	E
4. Drywell Pressure		
a. Narrow Range	2	E
b. Wide Range	2	E
5. Containment High Range Radiation	2	F
6. Drywell Temperature	2	E
7. Penetration Flow Path PCIV Position	2 per penetration flow path (a)(b)	E
8. Suppression Chamber Pressure	2	E
9. Suppression Pool Water Temperature	2	E
10. Drywell Water Level	2	E

(a) Not required for isolation valves whose associated penetration flow path is isolated by at least one closed and deactivated automatic valve, closed manual valve, blind flange, or check valve with flow through the valve secured.

(b) Only one position indication channel is required for penetration flow paths with only one installed control room indication channel.

3.3 INSTRUMENTATION

3.3.3.2 Remote Shutdown System

LCO 3.3.3.2 The Remote Shutdown System Functions shall be OPERABLE.

APPLICABILITY: MODES 1 and 2.

ACTIONS

-----NOTE-----
Separate Condition entry is allowed for each Function.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more required Functions inoperable.	A.1 Restore required Function to OPERABLE status.	30 days
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	12 hours

SURVEILLANCE REQUIREMENTS

----- NOTE -----

When a channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours

SURVEILLANCE		FREQUENCY
SR 3.3.3.2.1	Perform CHANNEL CHECK for each required instrumentation channel that is normally energized.	In accordance with the Surveillance Frequency Control Program*
SR 3.3.3.2.2	Verify each required control circuit and transfer switch is capable of performing the intended function.	In accordance with the Surveillance Frequency Control Program
SR 3.6.4.1.4	Perform CHANNEL CALIBRATION for each required instrumentation channel.	In accordance with the Surveillance Frequency Control Program

* This Surveillance for ST-43I is not required to be performed until following the return of the "A" RHR pump to OPERABLE. This past due Surveillance will be completed as stated in Section 3.5 of letter JAFP-21-0053, dated June 14, 2021.

3.3 INSTRUMENTATION

3.3.4.1 Anticipated Transient Without Scram Recirculation Pump Trip (ATWS-RPT) Instrumentation

LCO 3.3.4.1 Two channels per trip system for each ATWS-RPT instrumentation Function listed below shall be OPERABLE:

- a. Reactor Vessel Water Level-Low Low (Level 2); and
- b. Reactor Pressure-High.

APPLICABILITY: MODE 1.

ACTIONS

----- NOTE -----
Separate Condition entry is allowed for each channel.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more channels inoperable.	A.1 Restore channel to OPERABLE status. <u>OR</u>	14 days <u>OR</u> ----- NOTE ----- Not applicable when trip capability is not maintained ----- In accordance with the Risk Informed Completion Time Program

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. (continued)	<p>A.2 ----- NOTE----- Not applicable if inoperable channel is the result of an inoperable breaker. ----- Place channel in trip.</p>	<p>14 days <u>OR</u> ----- NOTE----- Not applicable when trip capability is not maintained ----- In accordance with the Risk Informed Completion Time Program</p>
B. One Function with ATWS-RPT trip capability not maintained.	B.1 Restore ATWS-RPT trip capability.	72 hours
C. Both Functions with ATWS-RPT trip capability not maintained.	C.1 Restore ATWS-RPT trip capability for one Function.	1 hour
D. Required Action and associated Completion Time not met.	<p>D.1 ----- NOTE----- Only applicable if inoperable channel is the result of an inoperable RPT breaker. ----- Remove the affected recirculation pump from service.</p> <p><u>OR</u></p> <p>D.2 Be in MODE 2.</p>	<p>6 hours</p> <p>6 hours</p>

SURVEILLANCE REQUIREMENTS

-----**NOTE**-----
 When a channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours provided the associated Function maintains ATWS-RPT trip capability.

SURVEILLANCE		FREQUENCY
SR 3.3.4.1.1	Perform CHANNEL CHECK.	In accordance with the Surveillance Frequency Control Program
SR 3.3.4.1.2	Perform CHANNEL FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program
SR 3.3.4.1.3	Calibrate the trip units.	In accordance with the Surveillance Frequency Control Program
SR 3.3.4.1.4	Perform CHANNEL CALIBRATION. The Allowable Values shall be: a. Reactor Vessel Water Level—Low Low (Level 2): ≥ 105.4 inches; and b. Reactor Pressure—High: ≤ 1153 psig.	In accordance with the Surveillance Frequency Control Program
SR 3.3.4.1.5	Perform LOGIC SYSTEM FUNCTIONAL TEST including breaker actuation.	In accordance with the Surveillance Frequency Control Program

3.3 INSTRUMENTATION

3.3.5.1 Emergency Core Cooling System (ECCS) Instrumentation

LCO 3.3.5.1 The ECCS instrumentation for each Function in Table 3.3.5.1-1 shall be OPERABLE.

APPLICABILITY: According to Table 3.3.5.1-1.

ACTIONS

-----NOTE-----
Separate Condition entry is allowed for each channel.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more channels inoperable.	A.1 Enter the Condition referenced in Table 3.3.5.1-1 for the channel.	Immediately
B. As required by Required Action A.1 and referenced in Table 3.3.5.1-1.	B.1 -----NOTE----- Only applicable for Functions 1.a, 1.b, 2.a, and 2.b. ----- Declare supported feature(s) inoperable when its redundant feature ECCS initiation capability is inoperable. <u>AND</u>	1 hour from discovery of loss of initiation capability for feature(s) in both divisions. (continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>B. (continued)</p>	<p>B.2 ----- NOTE----- Only applicable for Functions 3.a and 3.b. -----</p> <p>Declare High Pressure Coolant Injection (HPCI) System inoperable.</p> <p><u>AND</u></p> <p>B.3 Place channel in trip.</p>	<p>1 hour from discovery of loss of HPCI initiation capability</p> <p>24 hours</p> <p><u>OR</u></p> <p>----- NOTE----- Not applicable when trip capability is not maintained -----</p> <p>In accordance with the Risk Informed Completion Time Program</p>
<p>C. As required by Required Action A.1 and referenced in Table 3.3.5.1-1.</p>	<p>C.1 ----- NOTE----- Only applicable for Functions 1.c, 1.d, 2.c, 2.d, and 2.f. -----</p> <p>Declare supported feature(s) inoperable when its redundant feature ECCS initiation capability is inoperable.</p> <p><u>AND</u></p>	<p>1 hour from discovery of loss of initiation capability for feature(s) in both divisions</p> <p>(continued)</p>

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. (continued)	<p>C.2 Restore channel to OPERABLE status.</p>	<p>24 hours</p> <p><u>OR</u></p> <p>-----NOTE----- Not applicable when trip capability is not maintained -----</p> <p>In accordance with the Risk Informed Completion Time Program</p>
D. As required by Required Action A.1 and referenced in Table 3.3.5.1-1.	<p>D.1 -----NOTE----- Only applicable if HPCI pump suction is not aligned to the suppression pool. -----</p> <p>Declare HPCI System inoperable.</p> <p><u>AND</u></p> <p>D.2.1 Place channel in trip.</p> <p><u>OR</u></p>	<p>1 hour from discovery of loss of HPCI initiation capability</p> <p>24 hours</p> <p><u>OR</u></p> <p>-----NOTE----- Not applicable when trip capability is not maintained -----</p> <p>In accordance with the Risk Informed Completion Time Program</p> <p>(continued)</p>

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. (continued)	D.2.2 Align the HPCI pump suction to the suppression pool.	24 hours
E. As required by Required Action A.1 and referenced in Table 3.3.5.1-1.	<p>E.1 ----- NOTE----- Only applicable for Functions 1.e, 1.f, and 2.g. -----</p> <p>Declare supported feature(s) inoperable when its redundant feature ECCS initiation capability is inoperable.</p> <p><u>AND</u></p> <p>E.2 Restore channel to OPERABLE status.</p>	<p>1 hour from discovery of loss of initiation capability for subsystems in both divisions</p> <p>7 days</p> <p><u>OR</u></p> <p>----- NOTE----- Not applicable when trip capability is not maintained -----</p> <p>In accordance with the Risk Informed Completion Time Program</p>

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>F. As required by Required Action A.1 and referenced in Table 3.3.5.1-1.</p>	<p>F.1 Declare Automatic Depressurization System (ADS) valves inoperable.</p> <p><u>AND</u></p> <p>F.2 Place channel in trip.</p>	<p>1 hour from discovery of loss of ADS initiation capability in both trip systems</p> <p>96 hours from discovery of inoperable channel concurrent with HPCI or reactor core isolation cooling (RCIC) inoperable</p> <p><u>OR</u></p> <p>-----NOTE----- Not applicable when trip capability is not maintained -----</p> <p>In accordance with the Risk Informed Completion Time Program</p> <p><u>AND</u></p> <p>8 days</p> <p><u>OR</u></p> <p>-----NOTE----- Not applicable when trip capability is not maintained -----</p> <p>In accordance with the Risk Informed Completion Time Program</p>

(continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>G. As required by Required Action A.1 and referenced in Table 3.3.5.1-1.</p>	<p>G.1 Declare ADS valves inoperable.</p> <p><u>AND</u></p> <p>G.2 Restore channel to OPERABLE status.</p>	<p>1 hour from discovery of loss of ADS initiation capability in both trip systems</p> <p>96 hours from discovery of inoperable channel concurrent with HPCI or RCIC inoperable</p> <p><u>OR</u></p> <p>-----NOTE----- Not applicable when trip capability is not maintained -----</p> <p>In accordance with the Risk Informed Completion Time Program</p> <p><u>AND</u></p> <p>8 days</p> <p><u>OR</u></p> <p>-----NOTE----- Not applicable when trip capability is not maintained -----</p> <p>In accordance with the Risk Informed Completion Time Program</p>
<p>H. Required Action and associated Completion Time of Condition B, C, D, E, F, or G not met.</p>	<p>H.1 Declare associated supported feature(s) inoperable.</p>	<p>Immediately</p>

SURVEILLANCE REQUIREMENTS

-----NOTES-----

1. Refer to Table 3.3.5.1-1 to determine which SRs apply for each ECCS Function.
 2. When a channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed as follows: (a) for up to 6 hours for Functions 3.c, 3.f, and 3.g; and (b) for up to 6 hours for Functions other than 3.c, 3.f, and 3.g provided the associated Function or the redundant Function maintains ECCS initiation capability.
-

SURVEILLANCE	FREQUENCY
SR 3.3.5.1.1 Perform CHANNEL CHECK.	In accordance with the Surveillance Frequency Control Program
SR 3.3.5.1.2 Perform CHANNEL FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program
SR 3.3.5.1.3 Perform CHANNEL CALIBRATION.	In accordance with the Surveillance Frequency Control Program
SR 3.3.5.1.4 Calibrate the trip units.	In accordance with the Surveillance Frequency Control Program
SR 3.3.5.1.5 Perform CHANNEL CALIBRATION.	In accordance with the Surveillance Frequency Control Program
SR 3.3.5.1.6 Perform LOGIC SYSTEM FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program

Table 3.3.5.1-1 (page 1 of 5)
Emergency Core Cooling System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER FUNCTION	CONDITIONS REFERENCED FROM REQUIRED ACTION A.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. Core Spray System					
a. Reactor Vessel Water Level – Low Low Low (Level 1)	1, 2, 3	4 ^(a)	B	SR 3.3.5.1.1 SR 3.3.5.1.2 SR 3.3.5.1.4 SR 3.3.5.1.5 SR 3.3.5.1.6	≥ 18 inches
b. Drywell Pressure - High	1, 2, 3	4 ^(a)	B	SR 3.3.5.1.1 SR 3.3.5.1.2 SR 3.3.5.1.4 SR 3.3.5.1.5 SR 3.3.5.1.6	≤ 2.7 psig
c. Reactor Pressure – Low (Injection Permissive)	1, 2, 3	4	C	SR 3.3.5.1.1 SR 3.3.5.1.2 SR 3.3.5.1.4 SR 3.3.5.1.5 SR 3.3.5.1.6	≥ 410 psig and ≤ 490 psig
d. Core Spray Pump Start – Time Delay Relay	1, 2, 3	1 per pump	C	SR 3.3.5.1.5 SR 3.3.5.1.6	≤ 12.34 seconds
e. Core Spray Pump Discharge Flow – Low (Bypass)	1, 2, 3	1 per pump	E	SR 3.3.5.1.5 SR 3.3.5.1.6	≥ 510 gpm and ≤ 980 gpm
f. Core Spray Pump Discharge Pressure – High (Bypass)	1, 2, 3	1 per pump	E	SR 3.3.5.1.3 SR 3.3.5.1.6	≥ 90 psig and ≤ 110 psig
2. Low Pressure Coolant Injection (LPCI) System					
a. Reactor Vessel Water Level – Low Low Low (Level 1)	1, 2, 3	4 ^(a)	B	SR 3.3.5.1.1 SR 3.3.5.1.2 SR 3.3.5.1.4 SR 3.3.5.1.5 SR 3.3.5.1.6	≥ 18 inches

(continued)

(a) Also required to initiate the associated emergency diesel generator subsystem.

Table 3.3.5.1-1 (page 2 of 5)
Emergency Core Cooling System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER FUNCTION	CONDITIONS REFERENCED FROM REQUIRED ACTION A.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
2. LPCI System (continued)					
b. Drywell Pressure - High	1, 2, 3	4 ^(a)	B	SR 3.3.5.1.1 SR 3.3.5.1.2 SR 3.3.5.1.4 SR 3.3.5.1.5 SR 3.3.5.1.6	≤ 2.7 psig
c. Reactor Pressure – Low (Injection Permissive)	1, 2, 3	4	C	SR 3.3.5.1.1 SR 3.3.5.1.2 SR 3.3.5.1.4 SR 3.3.5.1.5 SR 3.3.5.1.6	≥ 410 psig and ≤ 490 psig
d. Reactor Pressure – Low (Recirculation Discharge Valve Permissive)	1 ^(b) , 2 ^(b) , 3 ^(b)	4	C	SR 3.3.5.1.1 SR 3.3.5.1.2 SR 3.3.5.1.4 SR 3.3.5.1.5 SR 3.3.5.1.6	≥ 295 psig
e. Reactor Vessel Shroud Level (Level 0)	1, 2, 3	2	B	SR 3.3.5.1.1 SR 3.3.5.1.2 SR 3.3.5.1.4 SR 3.3.5.1.5 SR 3.3.5.1.6	≥ 1.0 inches
f. Low Pressure Coolant Injection Pump Start – Time Delay Relay	1, 2, 3	1 per pump	C	SR 3.3.5.1.5 SR 3.3.5.1.6	
Pumps A, D					≤ 1.51 seconds
Pumps B, C					≤ 6.73 seconds
(continued)					

(a) Also required to initiate the associated emergency diesel generator subsystem.

(b) With associated recirculation pump discharge valve open.

Table 3.3.5.1-1 (page 3 of 5)
Emergency Core Cooling System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER FUNCTION	CONDITIONS REFERENCED FROM REQUIRED ACTION A.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
2. LPCI System (continued)					
g. Low Pressure Coolant Injection Pump Discharge Flow – Low (Bypass)	1, 2, 3	1 per subsystem	E	SR 3.3.5.1.5 SR 3.3.5.1.6	≥ 1040 gpm and ≤ 1665 gpm
h. Containment Pressure - High	1, 2, 3	4	B	SR 3.3.5.1.3 SR 3.3.5.1.6	≥ 1 psig and ≤ 2.7 psig
3. High Pressure Coolant Injection (HPCI) System					
a. Reactor Vessel Water Level – Low Low (Level 2)	1, 2 ^(c) , 3 ^(c)	4	B	SR 3.3.5.1.1 SR 3.3.5.1.2 SR 3.3.5.1.4 SR 3.3.5.1.5 SR 3.3.5.1.6	≥ 126.5 inches
b. Drywell Pressure - High	1, 2 ^(c) , 3 ^(c)	4	B	SR 3.3.5.1.1 SR 3.3.5.1.2 SR 3.3.5.1.4 SR 3.3.5.1.5 SR 3.3.5.1.6	≤ 2.7 psig
c. Reactor Vessel Water Level – High (Level 8)	1, 2 ^(c) , 3 ^(c)	2	C	SR 3.3.5.1.1 SR 3.3.5.1.2 SR 3.3.5.1.4 SR 3.3.5.1.5 SR 3.3.5.1.6	≤ 222.5 inches
d. Condensate Storage Tank Level - Low	1, 2 ^(c) , 3 ^(c)	4	D	SR 3.3.5.1.3 SR 3.3.5.1.6	≥ 59.5 inches
e. Suppression Pool Water Level - High	1, 2 ^(c) , 3 ^(c)	2	D	SR 3.3.5.1.3 SR 3.3.5.1.6	≤ 14.75 ft
f. High Pressure Coolant Injection Pump Discharge Flow – Low (Bypass)	1, 2 ^(c) , 3 ^(c)	1	E	SR 3.3.5.1.5 SR 3.3.5.1.6	≥ 475 gpm and ≤ 800 gpm
g. High Pressure Coolant Injection Pump Discharge Pressure – High (Bypass)	1, 2 ^(c) , 3 ^(c)	1	E	SR 3.3.5.1.3 SR 3.3.5.1.6	≥ 25 psig and ≤ 80 psig
(continued)					

(c) With reactor steam dome pressure > 150 psig.

Table 3.3.5.1-1 (page 4 of 5)
Emergency Core Cooling System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER FUNCTION	CONDITIONS REFERENCED FROM REQUIRED ACTION A.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
4. Automatic Depressurization System (ADS) Trip System A					
a. Reactor Vessel Water Level – Low Low Low (Level 1)	1, 2 ^(c) , 3 ^(c)	2	F	SR 3.3.5.1.1 SR 3.3.5.1.2 SR 3.3.5.1.4 SR 3.3.5.1.5 SR 3.3.5.1.6	≥ 18 inches
b. Automatic Depressurization System Initiation Timer	1, 2 ^(c) , 3 ^(c)	1	G	SR 3.3.5.1.5 SR 3.3.5.1.6	≤ 134 seconds
c. Reactor Vessel Water Level – Low (Level 3)	1, 2 ^(c) , 3 ^(c)	1	F	SR 3.3.5.1.1 SR 3.3.5.1.2 SR 3.3.5.1.4 SR 3.3.5.1.5 SR 3.3.5.1.6	≥ 177 inches
d. Core Spray Pump Discharge Pressure - High	1, 2 ^(c) , 3 ^(c)	2	G	SR 3.3.5.1.3 SR 3.3.5.1.6	≥ 90 psig and ≤ 110 psig
e. Low Pressure Coolant Injection Pump Discharge Pressure - High	1, 2 ^(c) , 3 ^(c)	4	G	SR 3.3.5.1.3 SR 3.3.5.1.6	≥ 105 psig and ≤ 145 psig
5. ADS Trip System B					
a. Reactor Vessel Water Level – Low Low Low (Level 1)	1, 2 ^(c) , 3 ^(c)	2	F	SR 3.3.5.1.1 SR 3.3.5.1.2 SR 3.3.5.1.4 SR 3.3.5.1.5 SR 3.3.5.1.6	≥ 18 inches
b. Automatic Depressurization System Initiation Timer	1, 2 ^(c) , 3 ^(c)	1	G	SR 3.3.5.1.5 SR 3.3.5.1.6	≤ 134 seconds

(continued)

(c) With reactor steam dome pressure > 150 psig

Table 3.3.5.1-1 (page 5 of 5)
Emergency Core Cooling System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER FUNCTION	CONDITIONS REFERENCED FROM REQUIRED ACTION A.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
5. ADS Trip System B (continued)					
c. Reactor Vessel Water Level – Low (Level 3)	1, 2 ^(c) , 3 ^(c)	1	F	SR 3.3.5.1.1 SR 3.3.5.1.2 SR 3.3.5.1.4 SR 3.3.5.1.5 SR 3.3.5.1.6	≥ 177 inches
d. Core Spray Pump Discharge Pressure - High	1, 2 ^(c) , 3 ^(c)	2	G	SR 3.3.5.1.3 SR 3.3.5.1.6	≥ 90 psig and ≤ 110 psig
e. Low Pressure Coolant Injection Pump Discharge Pressure - High	1, 2 ^(c) , 3 ^(c)	4	G	SR 3.3.5.1.3 SR 3.3.5.1.6	≥ 105 psig and ≤ 145 psig

(c) With reactor steam dose pressure > 150 psig.

3.3 INSTRUMENTATION

3.3.5.2 Reactor Pressure Vessel (RPV) Water Inventory Control Instrumentation

LCO 3.3.5.2 The Reactor Pressure Vessel (RPV) Water Inventory Control Instrumentation for each Function in Table 3.3.5.2-1 shall be OPERABLE.

APPLICABILITY: According to Table 3.3.5.2-1.

ACTIONS

----- NOTE -----
Separate Condition entry is allowed for each channel.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more channels inoperable.	A.1 Initiate action to place channel in trip.	Immediately
	<u>OR</u>	
	A.2.1 Declare associated penetration flow path(s) incapable of automatic isolation.	Immediately
	<u>AND</u>	
	A.2.2 Initiate action to calculate DRAIN TIME.	Immediately

SURVEILLANCE REQUIREMENTS

----- NOTE -----

These SRs apply to each Function in Table 3.3.5.2-1.

SURVEILLANCE		FREQUENCY
SR 3.3.5.2.1	Perform CHANNEL CHECK.	In accordance with the Surveillance Frequency Control Program
SR 3.3.5.2.2	Perform CHANNEL FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program

Table 3.3.5.2-1 (page 1 of 1)
Reactor Pressure Vessel (RPV) Water Inventory Control Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER FUNCTION	ALLOWABLE VALUE
1. RHR System Isolation			
a. Reactor Vessel Water Level – Low Level 3	(a)	2 in one trip system	≥ 177 inches
2. Reactor Water Cleanup (RWCU) System Isolation			
a. Reactor Vessel Water Level – Low Level 3	(a)	2 in one trip system	≥ 177 inches

(a) When automatic isolation of the associated penetration flow path(s) is credited in calculating DRAIN TIME.

3.3 INSTRUMENTATION

3.3.5.3 Reactor Core Isolation Cooling (RCIC) System Instrumentation

LCO 3.3.5.3 The RCIC System instrumentation for each Function in Table 3.3.5.3-1 shall be OPERABLE.

APPLICABILITY: MODE 1,
MODES 2 and 3 with reactor steam dome pressure > 150 psig.

ACTIONS

----- NOTE -----
Separate Condition entry is allowed for each channel.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more channels inoperable.	A.1 Enter the Condition referenced in Table 3.3.5.3-1 for the channel.	Immediately
B. As required by Required Action A.1 and referenced in Table 3.3.5.3-1.	B.1 Declare RCIC System inoperable.	1 hour from discovery of loss of RCIC initiation capability
	<u>AND</u> B.2 Place channel in trip.	24 hours <u>OR</u> ----- NOTE ----- Not applicable when trip capability is not maintained ----- In accordance with the Risk Informed Completion Time Program

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. As required by Required Action A.1 and referenced in Table 3.3.5.3-1.	C.1 Restore channel to OPERABLE status.	24 hours
D. As required by Required Action A.1 and referenced in Table 3.3.5.3-1.	<p>D.1 ----- NOTE----- Only applicable if RCIC pump suction is not aligned to the suppression pool. ----- Declare (RCIC) System inoperable.</p> <p><u>AND</u></p> <p>D.2.1 Place channel in trip.</p> <p><u>OR</u></p> <p>D.2.2 Align RCIC pump suction to the suppression pool.</p>	<p>1 hour from discovery of loss of automatic RCIC initiation capability</p> <p>24 hours</p> <p><u>OR</u></p> <p>----- NOTE----- Not applicable when trip capability is not maintained -----</p> <p>In accordance with the Risk Informed Completion Time Program</p> <p>24 hours</p>
E. Required Action and associated Completion Time of Condition B, C, or D not met.	E.1 Declare RCIC System inoperable.	Immediately

SURVEILLANCE REQUIREMENTS

-----NOTES-----

1. Refer to Table 3.3.5.3-1 to determine which SRs apply for each RCIC Function.
 2. When a channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed as follows: (a) for up to 6 hours for Functions 2 and 4; and (b) for up to 6 hours for Functions 1 and 3 provided the associated Function maintains RCIC initiation capability.
-

SURVELLANCE		FREQUENCY
SR 3.3.5.3.1	Perform CHANNEL CHECK.	In accordance with the Surveillance Frequency Control Program
SR 3.3.5.3.2	Perform CHANNEL FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program
SR 3.3.5.3.3	Perform CHANNEL CALIBRATION.	In accordance with the Surveillance Frequency Control Program
SR 3.3.5.3.4	Calibrate the trip units.	In accordance with the Surveillance Frequency Control Program
SR 3.3.5.3.5	Perform CHANNEL CALIBRATION.	In accordance with the Surveillance Frequency Control Program
SR 3.3.5.3.6	Perform LOGIC SYSTEM FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program

Table 3.3.5.3-1 (page 1 of 1)
Reactor Core Isolation Cooling System Instrumentation

FUNCTION	REQUIRED CHANNELS PER FUNCTION	CONDITIONS REFERENCED FROM REQUIRED ACTION A.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. Reactor Vessel Water Level – Low Low (Level 2)	4	B	SR 3.3.5.3.1 SR 3.3.5.3.2 SR 3.3.5.3.4 SR 3.3.5.3.5 SR 3.3.5.3.6	≥ 126.5 inches
2. Reactor Vessel Water Level – High (Level 8)	2	C	SR 3.3.5.3.1 SR 3.3.5.3.2 SR 3.3.5.3.4 SR 3.3.5.3.5 SR 3.3.5.3.6	≤ 222.5 inches
3. Condensate Storage Tank Level - Low	4	D	SR 3.3.5.3.3 SR 3.3.5.3.6	≥ 59.5 inches
4. Manual Initiation	1	C	SR 3.3.5.3.6	NA

3.3 INSTRUMENTATION

3.3.6.1 Primary Containment Isolation Instrumentation

LCO 3.3.6.1 The primary containment isolation instrumentation for each Function in Table 3.3.6.1-1 shall be OPERABLE.

APPLICABILITY: According to Table 3.3.6.1-1.

ACTIONS

-----NOTES-----

1. Penetration flow paths may be unisolated intermittently under administrative controls.
 2. Separate Condition entry is allowed for each channel.
-

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more required channels inoperable.	A.1 Place channel in trip.	12 hours for Functions 2.a, 2.b, 2.d, 2.g, 5.e, 5.f, 6.b, 7.a, and 7.b <u>OR</u> -----NOTE----- Not applicable when trip capability is not maintained ----- In accordance with the Risk Informed Completion Time Program <u>AND</u> (continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A.	A.1 (continued)	24 hours for Functions other than Functions 2.a, 2.b, 2.d, 2.g, 5.e, 5.f, 6.b, 7.a, and 7.b <u>OR</u> -----NOTE----- Not applicable when trip capability is not maintained ----- In accordance with the Risk Informed Completion Time Program
B. One or more Functions with isolation capability not maintained.	B.1 Restore isolation capability.	1 hour
C. Required Action and associated Completion Time of Condition A or B not met.	C.1 Enter the Condition referenced in Table 3.3.6.1-1 for the channel.	Immediately
D. As required by Required Action C.1 and referenced in Table 3.3.6.1-1.	D.1 Isolate associated main steam line (MSL). <u>OR</u> D.2.1 Be in MODE 3. <u>AND</u> D.2.2 Be in MODE 4.	12 hours 12 hours 36 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
E. As required by Required Action C.1 and referenced in Table 3.3.6.1-1.	E.1 Be in MODE 2.	6 hours
F. As required by Required Action C.1 and referenced in Table 3.3.6.1-1.	F.1 Isolate the affected penetration flow path(s).	1 hour
G. As required by Required Action C.1 and referenced in Table 3.3.6.1-1.	G.1 Isolate the affected penetration flow path(s).	24 hours
H. Required Action and associated Completion Time of Condition F or G not met. <u>OR</u> As required by Required Action C.1 and referenced in Table 3.3.6.1-1.	H.1 Be in MODE 3. <u>AND</u> H.2 Be in MODE 4.	12 hours 36 hours
I. As required by Required Action C.1 and referenced in Table 3.3.6.1-1.	I.1 Declare associated standby liquid control subsystem (SLC) inoperable. <u>OR</u> I.2 Isolate the Reactor Water Cleanup System.	1 hour 1 hour
J. As required by Required Action C.1 and referenced in Table 3.3.6.1-1.	J.1 Initiate action to restore channel to OPERABLE status.	Immediately

SURVEILLANCE REQUIREMENTS

-----NOTES-----

1. Refer to Table 3.3.6.1-1 to determine which SRs apply for each Primary Containment Isolation Function.
 2. When a channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed as follows: (a) for up to 6 hours for Functions 2.d, 2.g, 7.a, and 7.b; and (b) for up to 6 hours for Functions other than 2.d, 2.g, 7.a, and 7.b provided the associated Function maintains isolation capability.
-

SURVEILLANCE	FREQUENCY
SR 3.3.6.1.1 Perform CHANNEL CHECK.	In accordance with the Surveillance Frequency Control Program
SR 3.3.6.1.2 Perform CHANNEL FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program*
SR 3.3.6.1.3 -----NOTE----- For Functions 1.f and 2.f, radiation detectors are excluded. ----- Perform CHANNEL CALIBRATION.	In accordance with the Surveillance Frequency Control Program

(continued)

* This Surveillance for ISP-150B is not required to be performed for functions 4.a, 4.b, 4.d, 4.e and 4.f of table 3.3.6.1-1 until following the return of the "A" RHR pump to OPERABLE. This past due Surveillance will be completed as stated in Section 3.5 of letter JAFP-21-0053, dated June 14, 2021.

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.3.6.1.4	Calibrate the trip units.	In accordance with the Surveillance Frequency Control Program*
SR 3.3.6.1.5	Perform CHANNEL CALIBRATION.	In accordance with the Surveillance Frequency Control Program*
SR 3.3.6.1.6	Calibrate the radiation detectors.	In accordance with the Surveillance Frequency Control Program
SR 3.3.6.1.7	Perform LOGIC SYSTEM FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program

* This Surveillance for ISP-150B is not required to be performed for functions 4.a, 4.b, 4.d, 4.e and 4.f of table 3.3.6.1-1 until following the return of the "A" RHR pump to OPERABLE. This past due Surveillance will be completed as stated in Section 3.5 of letter JAFP-21-0053, dated June 14, 2021.

Primary Containment Isolation Instrumentation
3.3.6.1

Table 3.3.6.1-1 (page 1 of 6)
Primary Containment Isolation Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRIED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION C.1	SURVEILLANCE REQUIREMENTS	ALLOWED VALUE
1. Main Steam Line Isolation					
a. Reactor Vessel Water Level - Low Low Low (Level 1)	1,2,3	2	D	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≥ 18 inches
b. Main Steam Line Pressure - Low	1	2	E	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≥ 825 psig
c. Main Steam Line Flow - High	1,2,3	2 per MSL	D	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 125.9 psid
d. Condenser Vacuum - Low	1, 2 ^(a) , 3 ^(a)	2	D	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≥ 8 inches Hg vacuum
e. Main Steam Tunnel Area Temperature - High	1,2,3	8	D	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 195 °F
f. Main Steam Line Radiation - High	1,2,3	2	F	SR 3.3.6.1.1 SR 3.3.6.1.3 SR 3.3.6.1.6 SR 3.3.6.1.7	≤ 3 times Normal Full Power Background

(continued)

(a) With any turbine stop valve not closed.

(b) Not used.

Primary Containment Isolation Instrumentation
3.3.6.1

Table 3.3.6.1-1 (page 2 of 6)
Primary Containment Isolation Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION C.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
2. Primary Containment Isolation					
a. Reactor Vessel Water Level - Low (Level 3)	1,2,3	2	H	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≥ 177 inches
b. Drywell Pressure - High	1,2,3	2	H	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 2.7 psig
c. Containment Radiation - High	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 450 R/hr
d. Drywell Pressure - High	1,2,3	2 ^(c)	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 2.7 psig
e. Reactor Vessel Water Level - Low Low Low (Level 1)	1,2,3	2	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≥ 18 inches
f. Main Steam Line Radiation - High	1,2,3	2	F	SR 3.3.6.1.1 SR 3.3.6.1.3 SR 3.3.6.1.6 SR 3.3.6.1.7	≤ 3 times Normal Full Power Background
g. Reactor Vessel Water Level - Low (Level 3)	1,2,3	2 ^(c)	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≥ 177 inches

(continued)

(b) Not used.

(c) Only one trip system provided for each associated penetration.

Primary Containment Isolation Instrumentation
3.3.6.1

Table 3.3.6.1-1 (page 3 of 6)
Primary Containment Isolation Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION C.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
3. High Pressure Coolant Injection (HPCI) System Isolation					
a. HPCI Steam Line Flow - High	1.2.3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 168.24 inches of water dP
b. HPCI Steam Supply Line Pressure - Low	1.2.3	2	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≥ 61 psig and ≤ 90 psig
c. HPCI Turbine Exhaust Diaphragm Pressure - High	1.2.3	2	F	SR 3.3.6.1.3 SR 3.3.6.1.7	≤ 9.9 psig
d. HPCI Steam Line Penetration (Drywell Entrance) Area Temperature - High	1.2.3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 160°F
e. HPCI Steam Line Torus Room Area Temperature - High	1.2.3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 160°F
f. RHR Heat Exchanger A Area Temperature - High	1.2.3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 170°F
g. RHR Heat Exchanger B Area Temperature - High	1.2.3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 170°F
h. RB Southwest Area of Elevation 272' Temperature - High	1.2.3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 144°F
i. RB Southeast Area of Elevation 272' Temperature - High	1.2.3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 144°F

(continued)

Primary Containment Isolation Instrumentation
3.3.6.1

Table 3.3.6.1-1 (page 4 of 6)
Primary Containment Isolation Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION C.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
3. HPCI System Isolation (continued)					
j. HPCI Equipment Area Temperature - High	1.2.3	2	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 144°F
4. Reactor Core Isolation Cooling (RCIC) System Isolation					
a. RCIC Steam Line Flow - High	1.2.3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 272.26 inches of water dP
b. RCIC Steam Supply Line Pressure - Low	1.2.3	2	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≥ 58 psig and ≤ 93 psig
c. RCIC Turbine Exhaust Diaphragm Pressure - High	1.2.3	2	F	SR 3.3.6.1.3 SR 3.3.6.1.7	≤ 5 psig
d. RCIC Steam Line Penetration (Drywell Entrance) Area Temperature - High	1.2.3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 160°F
e. RCIC Steam Line Torus Room Area Temperature - High	1.2.3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 160°F
f. RCIC Equipment Area Temperature - High	1.2.3	2	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 144°F

(continued)

Primary Containment Isolation Instrumentation
3.3.6.1

Table 3.3.6.1-1 (page 5 of 6)
Primary Containment Isolation Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION C.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
5. Reactor Water Cleanup (RWCU) System Isolation					
a. RWCU Suction Line Penetration Area Temperature – High	1, 2, 3	1	F	SR 3.3.6.1.3 SR 3.3.6.1.7	≤ 144°F
b. RWCU Pump Area Temperature – High	1, 2, 3	1 per room	F	SR 3.3.6.1.3 SR 3.3.6.1.7	≤ 165°F for Pump Room A and ≤ 175°F for Pump Room B
c. RWCU Heat Exchanger Room Area Temperature – High	1, 2, 3	1	F	SR 3.3.6.1.3 SR 3.3.6.1.7	≤ 155°F
d. SLC System Initiation	1, 2, 3	2(d)	I	SR 3.3.6.1.7	NA
e. Reactor Vessel Water Level – Low (Level 3)	1, 2, 3	2	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≥ 177 inches
f. Drywell Pressure – High	1, 2, 3	2	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 2.7 psig
6. Shutdown Cooling System Isolation					
a. Reactor Pressure – High	1, 2, 3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 74 psig
b. Reactor Vessel Water Level – Low (Level 3)	3	2	J	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≥ 177 inches

(continued)

(d) SLC System Initiation only inputs into one of the two trip systems and only isolates one valve in the RWCU suction and return line.

Primary Containment Isolation Instrumentation
3.3.6.1

Table 3.3.6.1-1 (page 6 of 6)
Primary Containment Isolation Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION C.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
7. Traversing Incore Probe System Isolation					
a. Reactor Vessel Water Level - Low (Level 3)	1.2.3	2	G	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≥ 177 inches
b. Drywell Pressure - High	1.2.3	2	G	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 2.7 psig

3.3 INSTRUMENTATION

3.3.6.2 Secondary Containment Isolation Instrumentation

LC0 3.3.6.2 The secondary containment isolation instrumentation for each Function in Table 3.3.6.2-1 shall be OPERABLE.

APPLICABILITY: According to Table 3.3.6.2-1.

ACTIONS

-----NOTE-----
 Separate Condition entry is allowed for each channel.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more channels inoperable.	A.1 Place channel in trip.	12 hours for Functions 1 and 2 <u>AND</u> 24 hours for Functions 3 and 4
B. One or more Functions with secondary containment isolation capability not maintained.	B.1 Restore secondary containment isolation capability.	1 hour
C. Required Action and associated Completion Time of Condition A or B not met.	C.1.1 Isolate the associated secondary containment penetration flow path(s). <u>OR</u>	1 hour (continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
C.(continued)	C.1.2 Declare associated secondary containment isolation valves inoperable.	1 hour
	<u>AND</u>	
	C.2.1 Place the associated standby gas treatment (SGT) subsystem(s) in operation.	1 hour
	<u>OR</u>	
	C.2.2 Declare associated SGT subsystem(s) inoperable.	1 hour

SURVEILLANCE REQUIREMENTS

-----NOTES-----

1. Refer to Table 3.3.6.2-1 to determine which SRs apply for each Secondary Containment Isolation Function.

 2. When a channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours provided the associated Function maintains secondary containment isolation capability.
-

SURVEILLANCE	FREQUENCY
SR 3.3.6.2.1 Perform CHANNEL CHECK.	In accordance with the Surveillance Frequency Control Program

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.3.6.2.2	Perform CHANNEL FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program
SR 3.3.6.2.3	Perform CHANNEL CALIBRATION	In accordance with the Surveillance Frequency Control Program
SR 3.3.6.2.4	Calibrate the trip units.	In accordance with the Surveillance Frequency Control Program
SR 3.3.6.2.5	Perform CHANNEL CALIBRATION.	In accordance with the Surveillance Frequency Control Program
SR 3.3.6.2.6	Perform LOGIC SYSTEM FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program

Secondary Containment Isolation Instrumentation
3.3.6.2

Table 3.3.6.2-1 (page 1 of 1)
Secondary Containment Isolation Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. Reactor Vessel Water Level – Low (Level 3)	1, 2, 3	2	SR 3.3.6.2.1 SR 3.3.6.2.2 SR 3.3.6.2.4 SR 3.3.6.2.5 SR 3.3.6.2.6	≥ 177 inches
2. Drywell Pressure - High	1, 2, 3	2	SR 3.3.6.2.1 SR 3.3.6.2.2 SR 3.3.6.2.4 SR 3.3.6.2.5 SR 3.3.6.2.6	≤ 2.7 psig
3. Reactor Building Exhaust Radiation - High	1, 2, 3, (a)	1	SR 3.3.6.2.1 SR 3.3.6.2.3 SR 3.3.6.2.6	≤ 24,800 cpm
4. Refueling Floor Exhaust Radiation - High	1, 2, 3, (a)	1	SR 3.3.6.2.1 SR 3.3.6.2.3 SR 3.3.6.2.6	≤ 24,800 cpm

(a) During movement of recently irradiated fuel assemblies in secondary containment.

3.3 INSTRUMENTATION

3.3.7.1 Control Room Emergency Ventilation Air Supply (CREVAS)
System Instrumentation

LCO 3.3.7.1 The Control Room Air Inlet Radiation — High channel shall be
OPERABLE.

APPLICABILITY: MODES 1, 2 and 3,
During movement of recently irradiated fuel assemblies in
the secondary containment,

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Channel inoperable.	A.1 Place the CREVAS System in the isolate mode of operation.	1 hour
	<p style="text-align: center;"><u>OR</u></p> A.2 Declare both CREVAS subsystems inoperable.	1 hour

SURVEILLANCE REQUIREMENTS

----- NOTE -----

When the channel is placed in an inoperable status solely for performance of required Surveillances, entry into the Condition and Required Actions may be delayed for up to 6 hours.

SURVEILLANCE	FREQUENCY
SR 3.3.7.1.1 Perform CHANNEL CHECK.	In accordance with the Surveillance Frequency Control Program
SR 3.3.7.1.2 Perform CHANNEL CALIBRATION. The Allowable Value shall be ≤ 4000 cpm.	In accordance with the Surveillance Frequency Control Program

3.3 INSTRUMENTATION

3.3.7.2 Condenser Air Removal Pump Isolation Instrumentation

LCO 3.3.7.2 Four channels of the Main Steam Line Radiation-High Function for the condenser air removal pump isolation shall be OPERABLE.

APPLICABILITY: MODES 1 and 2 with any condenser air removal pump not isolated and any main steam line not isolated.

ACTIONS

-----NOTE-----
Separate Condition entry is allowed for each channel.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more required channels inoperable.	A.1 Restore channel to OPERABLE status.	24 hours
	<p><u>OR</u></p> <p>A.2 -----NOTE----- Not applicable if inoperable channel is the result of an inoperable isolation valve. -----</p> <p>Place channel or associated trip system in trip.</p>	24 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. Condenser air removal pump isolation capability not maintained.	B.1 Restore isolation capability.	1 hour
C. Required Action and associated Completion Time of Condition A or B not met.	C.1 Isolate the condenser air removal pumps. <u>OR</u>	12 hours
	C.2 Isolate the main steam lines. <u>OR</u>	12 hours
	C.3 Be in MODE 3.	12 hours

SURVEILLANCE REQUIREMENTS

----- NOTE -----

When a channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours provided the associated Function maintains condenser air removal pump isolation capability.

SURVEILLANCE	FREQUENCY
SR 3.3.7.2.1 Perform CHANNEL CHECK.	In accordance with the Surveillance Frequency Control Program

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.3.7.2.2 -----NOTE----- Radiation detectors are excluded. -----</p> <p>Perform CHANNEL CALIBRATION. The Allowable Value shall be ≤ 3 times Normal Full Power Background.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.3.7.2.3 Calibrate the radiation detectors.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.3.7.2.4 Perform LOGIC SYSTEM FUNCTIONAL TEST including isolation valve actuation.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>

3.3 INSTRUMENTATION

3.3.7.3 Emergency Service Water (ESW) System Instrumentation

LCO 3.3.7.3 Four channels of ESW pressure instrumentation shall be OPERABLE.

APPLICABILITY: MODES 1, 2 and 3.

ACTIONS

-----NOTE-----
Separate Condition entry is allowed for each channel.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more channels inoperable.	A.1 Place channel in trip.	24 hours
B. Initiation capability not maintained in both logic systems.	B.1 Restore initiation capability.	1 hour
C. Required Action and associated Completion Time of Condition A or B not met.	C.1 Declare associated ESW subsystem(s) inoperable.	Immediately

SURVEILLANCE REQUIREMENTS

----- NOTE -----

When a channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours provided the ESW pressure instrumentation maintains initiation capability.

SURVEILLANCE	FREQUENCY
SR 3.3.7.3.1 Perform CHANNEL CALIBRATION. The Allowable Value shall be ≥ 40 psig and ≤ 50 psig.	In accordance with the Surveillance Frequency Control Program
SR 3.3.7.3.2 Perform LOGIC SYSTEM FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program

3.3 INSTRUMENTATION

3.3.8.1 Loss of Power (LOP) Instrumentation

LCO 3.3.8.1 The LOP instrumentation for each Function in Table 3.3.8.1-1 shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

----- NOTE -----
Separate Condition entry is allowed for each channel.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more channels inoperable	A.1 Place channel in trip.	1 hour
B. Required Action and associated Completion Time not met.	B.1 Declare associated EDG(s) inoperable.	Immediately

SURVEILLANCE REQUIREMENTS

----- NOTE -----
 Refer to Table 3.3.8.1-1 to determine which SRs apply for each LOP Function.

SURVEILLANCE	FREQUENCY
SR 3.3.8.1.1 Perform CHANNEL CALIBRATION.	In accordance with the Surveillance Frequency Control Program
SR 3.3.8.1.2 Perform LOGIC SYSTEM FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program

Table 3.3.8.1-1 (page 1 of 1)
Loss of Power Instrumentation

FUNCTION	REQUIRED CHANNELS PER BUS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. 4.16 kV Emergency Bus Undervoltage (Loss of Voltage)			
a. Bus Undervoltage	2	SR 3.3.8.1.1 SR 3.3.8.1.2	≥ 80.2 V and ≤ 89.8 V
b. Time Delay	1	SR 3.3.8.1.1 SR 3.3.8.1.2	≥ 2.4 seconds and ≤ 2.6 seconds
2. 4.16 kV Emergency Bus Undervoltage (Degraded Voltage)			
a. Bus Undervoltage	2	SR 3.3.8.1.1 SR 3.3.8.1.2	≥ 109.8 V and ≤ 111.4 V
b. Time Delay (LOCA)	1	SR 3.3.8.1.1 SR 3.3.8.1.2	≥ 8.4 seconds and ≤ 9.5 seconds
c. Time Delay (non-LOCA)	1	SR 3.3.8.1.1 SR 3.3.8.1.2	≥ 41.0 seconds and ≤ 46.6 seconds

3.3 INSTRUMENTATION

3.3.8.2 Reactor Protection System (RPS) Electric Power Monitoring

LCO 3.3.8.2 Two RPS electric power monitoring assemblies shall be OPERABLE for each inservice RPS motor generator set or alternate power supply.

APPLICABILITY: MODES 1 and 2,
MODES 3, 4, and 5 with any control rod withdrawn from a core cell containing one or more fuel assemblies.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or both inservice power supplies with one electric power monitoring assembly inoperable.	A.1 Remove associated inservice power supply(s) from service.	72 hours
B. One or both inservice power supplies with both electric power monitoring assemblies inoperable.	B.1 Remove associated inservice power supply(s) from service.	1 hour
C. Required Action and associated Completion Time of Condition A or B not met in MODE 1 or 2.	C.1 Be in MODE 3.	12 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. Required Action and associated Completion Time of Condition A or B not met in MODE 3, 4, or 5 with any control rod withdrawn from a core cell containing one or more fuel assemblies.	D.1 Initiate action to fully insert all insertable control rods in core cells containing one or more fuel assemblies.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.3.8.2.1 ----- NOTE----- Only required to be performed prior to entering MODE 2 from MODE 3 or 4, when in MODE 4 for ≥ 24 hours. ----- Perform CHANNEL FUNCTIONAL TEST.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.3.8.2.2	<p>Perform CHANNEL CALIBRATION of the electric power monitoring assemblies associated with the inservice RPS motor generator sets. The Allowable Values shall be:</p> <ul style="list-style-type: none"> a. Overvoltage ≤ 132 V, with time delay set to ≤ 4 seconds. b. Undervoltage ≥ 112.5 V for RPS bus A and ≥ 113.9 V for RPS bus B, with time delay set to ≤ 4 seconds. c. Underfrequency ≥ 57 Hz, with time delay set to ≤ 4 seconds. 	In accordance with the Surveillance Frequency Control Program
SR 3.3.8.2.3	<p>Perform CHANNEL CALIBRATION of the electric power monitoring assemblies associated with the inservice alternate power supplies. The Allowable Values shall be:</p> <ul style="list-style-type: none"> a. Overvoltage ≤ 132 V, with time delay set to ≤ 4 seconds. b. Undervoltage ≥ 109.9 V, with time delay set to ≤ 4 seconds. c. Underfrequency ≥ 57 Hz, with time delay set to ≤ 4 seconds. 	In accordance with the Surveillance Frequency Control Program
SR 3.3.8.2.4	Perform a system functional test.	In accordance with the Surveillance Frequency Control Program

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.1 Recirculation Loops Operating

LCO 3.4.1 Two recirculation loops with matched flows shall be in operation and the reactor operating at core flow and THERMAL POWER conditions outside the Exclusion Region of the power-to-flow map specified in the COLR.

OR

One recirculation loop shall be in operation and the reactor operating at core flow and THERMAL POWER conditions outside the Exclusion Region of the power-to-flow map specified in the COLR with the following limits applied when the associated LCO is applicable:

- a. LCO 3.2.1, "AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR)," single loop operation limits specified in the COLR;
- b. LCO 3.2.2, "MINIMUM CRITICAL POWER RATIO (MCPR)," single loop operation limits specified in the COLR;
- c. LCO 3.3.1.1, "Reactor Protection System (RPS) Instrumentation," Function 2.b (Average Power Range Monitors Neutron Flux-High (Flow Biased)), Allowable Value of Table 3.3.1.1-1 is reset for single loop operation; and
- d. LCO 3.3.2.1, "Control Rod Block Instrumentation," Function 1.a (Rod Block Monitor-Upscale), Allowable Value of Table 3.3.2.1-1 is reset for single loop operation.

APPLICABILITY: MODES 1 and 2.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. One or two recirculation loops in operation with core flow and THERMAL POWER conditions within the Exclusion Region of the power-to-flow map.</p>	<p>A.1 Initiate action to exit the Exclusion Region.</p>	<p>Immediately</p>
<p>B. Requirements of the LCO not met for reasons other than Condition A.</p>	<p>B.1 Satisfy the requirements of the LCO.</p>	<p>24 hours</p>
<p>C. Required Action and associated Completion Time of Condition A or B not met.</p> <p><u>OR</u></p> <p>No recirculation loops in operation.</p>	<p>C.1 Be in MODE 3.</p>	<p>12 hours</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.4.1.1</p> <p style="text-align: center;">----- NOTE-----</p> <p style="text-align: center;">Only required to be performed in MODE 1.</p> <p style="text-align: center;">-----</p> <p>Verify reactor operating at core flow and THERMAL POWER conditions outside the Exclusion Region of the power-to-flow map specified in the COLR.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.4.1.2</p> <p style="text-align: center;">----- NOTE-----</p> <p style="text-align: center;">Not required to be performed until 24 hours after both recirculation loops are in operation.</p> <p style="text-align: center;">-----</p> <p>Verify recirculation loop jet pump flow mismatch with both recirculation loops in operation is:</p> <ul style="list-style-type: none"> a. 10% of rated core flow when operating at < 70% of rated core flow; and b. 5% of rated core flow when operating at ≥ 70% of rated core flow. 	<p>In accordance with the Surveillance Frequency Control Program</p>

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.2 Jet Pumps

LCO 3.4.2 All jet pumps shall be OPERABLE.

APPLICABILITY: MODES 1 and 2.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more jet pumps inoperable.	A.1 Be in MODE 3.	12 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.4.2.1 ----- NOTE-----</p> <ol style="list-style-type: none"> 1. Not required to be performed until 4 hours after associated recirculation loop is in operation. 2. Not required to be performed until 24 hours after > 25% RTP. <p>-----</p> <p>Verify at least one of the following criteria (a or b) is satisfied for each operating recirculation loop:</p> <ol style="list-style-type: none"> a. Recirculation pump flow to speed ratio differs by $\leq 5\%$ from established patterns, and recirculation loop jet pump flow to recirculation pump speed ratio differs by $\leq 5\%$ from established patterns. b. Each jet pump diffuser to lower plenum differential pressure differs by $\leq 20\%$ from established patterns. 	<p>In accordance with the Surveillance Frequency Control Program</p>

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.3 Safety/Relief Valves (S/RVs)

LCO 3.4.3 The safety function of 9 S/RVs shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more required S/RVs inoperable.	A.1 Be in MODE 3.	12 hours
	<u>AND</u> A.2 Be in MODE 4.	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.4.3.1	Verify the safety function lift setpoint of the required S/RVs is 1145 ± 34.3 psig. Following testing, lift settings shall be within $\pm 1\%$.	In accordance with the INSERVICE TESTING PROGRAM
SR 3.4.3.2	Verify each required S/RV is capable of being opened.	In accordance with the INSERVICE TESTING PROGRAM

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.4 RCS Operational LEAKAGE

- LCO 3.4.4 RCS operational LEAKAGE shall be limited to:
- a. No pressure boundary LEAKAGE;
 - b. ≤ 5 gpm unidentified LEAKAGE;
 - c. ≤ 25 gpm total LEAKAGE average over the previous 24 hour period; and
 - d. ≤ 2 gpm increase in unidentified LEAKAGE within the previous 24 hour period in MODE 1.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Pressure boundary LEAKAGE exists.	A.1 Isolate affected component pipe, or vessel from the RCS by use of a closed manual valve, closed and de-activated automatic valve, blind flange, or check valve.	4 hours
B. Unidentified LEAKAGE not within limit. <u>OR</u> Total LEAKAGE not within limit.	B.1 Reduce LEAKAGE to within limits.	4 hours
C. Unidentified LEAKAGE increase not within limit.	C.1 Reduce unidentified LEAKAGE increase to within limits. <u>OR</u>	4 hours (continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. (continued)	C.2 Verify source of unidentified LEAKAGE increase is not service sensitive type 304 or type 316 austenitic stainless steel.	4 hours
D. Required Action and associated Completion Time not met.	D.1 Be in MODE 3.	12 hours
	<u>AND</u> D.2 Be in MODE 4.	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.4.4.1 Verify RCS unidentified and total LEAKAGE and unidentified LEAKAGE increase are within limits.	In accordance with the Surveillance Frequency Control Program

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.5 RCS Leakage Detection Instrumentation

LCO 3.4.5 The following RCS leakage detection instrumentation shall be OPERABLE:

- a. Drywell floor drain sump monitoring system;
- b. One channel of the drywell continuous atmospheric particulate monitoring system; and
- c. One channel of the drywell continuous atmospheric gaseous monitoring system.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Drywell floor drain sump monitoring system inoperable.	A.1 Restore drywell floor drain sump monitoring system to OPERABLE status.	30 days
B. One drywell continuous atmospheric monitoring system inoperable.	B.1 -----NOTE----- Not applicable when both drywell continuous atmospheric monitoring systems are inoperable. ----- Perform SR 3.4.5.1.	Once per 8 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. Both drywell continuous atmospheric monitoring systems inoperable.	C.1 Analyze grab samples of drywell atmosphere.	Once per 12 hours
	<u>AND</u> C.2 Restore one drywell continuous atmospheric monitoring system to OPERABLE status.	30 days
D. Required Action and associated Completion Time of Condition A, B, or C not met.	D.1 Be in MODE 3.	12 hours
	<u>AND</u> D.2 Be in MODE 4.	36 hours
E. All required leakage detection systems inoperable.	E.1 Enter LCO 3.0.3.	Immediately

SURVEILLANCE REQUIREMENTS

----- NOTE -----

When a channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours provided the other required leakage detection instrumentation is OPERABLE.

SURVEILLANCE		FREQUENCY
SR 3.4.5.1	Perform a CHANNEL CHECK of drywell continuous atmospheric monitoring systems.	In accordance with the Surveillance Frequency Control Program
SR 3.4.5.2	Perform a CHANNEL FUNCTIONAL TEST of required leakage detection instrumentation.	In accordance with the Surveillance Frequency Control Program
SR 3.4.5.3	Perform a CHANNEL CALIBRATION of required leakage detection instrumentation.	In accordance with the Surveillance Frequency Control Program

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.6 RCS Specific Activity

LCO 3.4.6 The specific activity of the reactor coolant shall be limited to DOSE EQUIVALENT I-131 specific activity $\leq 0.2 \mu\text{Ci/gm}$.

APPLICABILITY: MODE 1,
MODES 2 and 3 with any main steam line not isolated.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. Reactor coolant specific activity $> 0.2 \mu\text{Ci/gm}$ and $\leq 2.0 \mu\text{Ci/gm}$ DOSE EQUIVALENT I-131.</p>	<p>-----NOTE----- LCO 3.0.4.c is applicable. -----</p> <p>A.1 Determine DOSE EQUIVALENT I-131.</p> <p><u>AND</u></p> <p>A.2 Restore DOSE EQUIVALENT I-131 to within limits.</p>	<p>Once per 4 hours</p> <p>48 hours</p>
<p>B. Required Action and associated Completion Time of Condition A not met.</p> <p><u>OR</u></p> <p>Reactor coolant specific activity $> 2.0 \mu\text{Ci/gm}$ DOSE EQUIVALENT I-131.</p>	<p>B.1 Determine DOSE EQUIVALENT I-131.</p> <p><u>AND</u></p> <p>B.2.1 Isolate all main steam lines.</p> <p><u>OR</u></p>	<p>Once per 4 hours</p> <p>12 hours</p> <p>(continued)</p>

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. (continued)	B.2.2.1 Be in MODE 3. <u>AND</u>	12 hours
	B.2.2.2 Be in MODE 4.	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.4.6.1</p> <p>----- NOTE ----- Only required to be performed in MODE 1. -----</p> <p>Verify reactor coolant DOSE EQUIVALENT I-131 specific activity is $\leq 0.2 \mu\text{Ci/gm}$.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.7 Residual Heat Removal (RHR) Shutdown Cooling System-Hot Shutdown

LCO 3.4.7 Two RHR shutdown cooling subsystems shall be OPERABLE.

----- NOTE-----
One RHR shutdown cooling subsystem may be inoperable for up to 2 hours for the performance of Surveillances.

APPLICABILITY: MODE 3, with reactor steam dome pressure less than the RHR cut in permissive pressure.

ACTIONS

----- NOTE-----
Separate Condition entry is allowed for each RHR shutdown cooling subsystem.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or two RHR shutdown cooling subsystems inoperable.	A.1 Verify an alternate method of decay heat removal is available for each inoperable RHR shutdown cooling subsystem.	1 hour <u>AND</u> Once per 24 hours thereafter
B. Required Action and associated Completion Time of Condition A not met.	B.1 Initiate action to restore RHR shutdown cooling subsystem(s) to OPERABLE status.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.4.7.1</p> <p>----- NOTE----- Not required to be met until 2 hours after reactor steam dome pressure is less than the RHR cut in permissive pressure. -----</p> <p>Verify each required RHR shutdown cooling subsystem manual, power operated, and automatic valve in the flow path that is not locked, sealed, or otherwise secured in position, is in the correct position, or can be aligned to the correct position.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.8 Residual Heat Removal (RHR) Shutdown Cooling System – Cold Shutdown

LCO 3.4.8 Two RHR shutdown cooling subsystems shall be OPERABLE.

-----NOTE-----
One RHR shutdown cooling subsystem may be inoperable for up to 2 hours for the performance of Surveillances.

APPLICABILITY: MODE 4.

ACTIONS

-----NOTE-----
Separate Condition entry is allowed for each shutdown cooling subsystem.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or two RHR shutdown cooling subsystems inoperable.	A.1 Verify an alternate method of decay heat removal is available for each inoperable RHR shutdown cooling subsystem.	1 hour <u>AND</u> Once per 24 hours thereafter
B. Required Action and associated Completion Time of Condition A not met.	B.1 Initiate action to restore RHR shutdown cooling subsystem(s) to OPERABLE status.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.4.8.1 Verify each RHR shutdown cooling subsystem manual, power operated, and automatic valve in the flow path that is not locked, sealed, or otherwise secured in position, is in the correct position, or can be aligned to the correct position.	In accordance with the Surveillance Frequency Control Program

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.9 RCS Pressure and Temperature (P/T) Limits

LCO 3.4.9 RCS pressure, RCS temperature, RCS heatup and cooldown rates, and the recirculation pump starting temperature requirements shall be maintained within the limits specified in the PTLR.

APPLICABILITY: At all times.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. ----- NOTE ----- Required Action A.2 shall be completed if this Condition is entered. ----- Requirements of the LCO not met in MODE 1, 2, or 3.</p>	<p>A.1 Restore parameter(s) to within limits.</p> <p><u>AND</u></p>	<p>30 minutes</p>
	<p>A.2 Determine RCS is acceptable for continued operation.</p>	<p>72 hours</p>
<p>B. Required Action and associated Completion Time of Condition A not met.</p>	<p>B.1 Be in MODE 3.</p> <p><u>AND</u></p>	<p>12 hours</p>
	<p>B.2 Be in MODE 4.</p>	<p>36 hours</p>

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>C. -----NOTE----- Required Action C.2 shall be completed if this Condition is entered. ----- Requirements of the LCO not met in other than MODES 1, 2, and 3.</p>	<p>C.1 Initiate action to restore parameter(s) to within limits. <u>AND</u> C.2 Determine RCS is acceptable for operation.</p>	<p>Immediately Prior to entering MODE 2 or 3</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.4.9.1 ----- NOTE ----- Only required to be performed during RCS heatup and cooldown operations and RCS inservice leak and hydrostatic testing. -----</p> <p>Verify:</p> <ul style="list-style-type: none"> a. RCS pressure and RCS temperature are within the limits specified in the curves in the PTLR as applicable; and b. RCS temperature change averaged over a one hour period is: <ul style="list-style-type: none"> 1. $\leq 100^{\circ}\text{F}$ when the RCS pressure and RCS temperature are on or to the right of curve C in the PTLR as applicable, during inservice leak and hydrostatic testing; 2. $\leq 20^{\circ}\text{F}$ when the RCS pressure and RCS temperature are to the left of curve C in the PTLR as applicable, during inservice leak and hydrostatic testing; and 3. $\leq 100^{\circ}\text{F}$ during other heatup and cooldown operations. 	<p>In accordance with the Surveillance Frequency Control Program</p>

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.4.9.2 Verify RCS pressure and RCS temperature are within the criticality limits specified in the PTLR.</p>	<p>Once within 15 minutes prior to control rod withdrawal for the purpose of achieving criticality</p>
<p>SR 3.4.9.3 ----- NOTES -----</p> <ol style="list-style-type: none"> 1. Only required to be met in MODES 1, 2, 3, and 4 during recirculation pump startup. 2. Not required to be performed if SR 3.4.9.4 is satisfied. <p>-----</p> <p>Verify the difference between the bottom head coolant temperature and the reactor pressure vessel (RPV) coolant temperature is within the limits specified in the PTLR.</p>	<p>Once within 15 minutes prior to each startup of a recirculation pump</p>
<p>SR 3.4.9.4 ----- NOTES -----</p> <ol style="list-style-type: none"> 1. Only required to be met in MODES 1, 2, 3, and 4 during recirculation pump startup. 2. Not required to be met if SR 3.4.9.3 is satisfied. <p>-----</p> <p>Verify the active recirculation pump flow exceeds 40% of rated pump flow or the active recirculation pump has been operating below 40% rated flow for a period no longer than 30 minutes.</p>	<p>Once within 15 minutes prior to each startup of a recirculation pump</p>

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.4.9.5 ----- NOTES ----- Only required to be met in MODES 1, 2, 3, and 4 during recirculation pump startup. -----</p> <p>Verify the difference between the reactor coolant temperature in the recirculation loop to be started and the RPV coolant temperature is within the limits specified in the PTLR.</p>	<p>Once within 15 minutes prior to each startup of a recirculation pump</p>
<p>SR 3.4.9.6 ----- NOTES ----- Only required to be performed when tensioning the reactor vessel head bolting studs. -----</p> <p>Verify, when the reactor vessel head bolting studs are under tension, reactor vessel flange and head flange temperatures are within the limits specified in the PTLR.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.4.9.7 ----- NOTES ----- Not required to be performed until 30 minutes after RCS temperature $\leq 80^{\circ}\text{F}$ with any reactor vessel head bolting stud tensioned. -----</p> <p>Verify, when the reactor vessel head bolting studs are under tension, reactor vessel flange and head flange temperatures are within the limits specified in the PTLR.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.4.9.8</p> <p>----- NOTES -----</p> <p>Not required to be performed until 12 hours after RCS temperature $\leq 100^{\circ}\text{F}$ with any reactor vessel head bolting stud tensioned.</p> <p>-----</p> <p>Verify, when the reactor vessel head bolting studs are under tension, reactor vessel flange and head flange temperatures are within the limits specified in the PTLR.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>

3.5 EMERGENCY CORE COOLING SYSTEMS (ECCS), REACTOR PRESSURE VESSEL (RPV) WATER INVENTORY CONTROL, AND REACTOR CORE ISOLATION COOLING (RCIC) SYSTEM

3.5.1 ECCS-Operating

LCO 3.5.1 Each ECCS injection/spray subsystem and the Automatic Depressurization System (ADS) function of six safety/relief valves shall be OPERABLE.

-----NOTE-----
 Low pressure coolant injection (LPCI) subsystems may be considered OPERABLE during alignment and operation for decay heat removal with reactor steam dome pressure less than the Residual Heat Removal (RHR) cut in permissive pressure in MODE 3, if capable of being manually realigned and not otherwise inoperable.

APPLICABILITY: MODE 1, MODES 2 and 3, except high pressure coolant injection (HPCI) and ADS valves are not required to be OPERABLE with reactor steam dome pressure ≤ 150 psig.

ACTIONS

-----NOTE-----
 LCO 3.0.4.b is not applicable to High Pressure Coolant Injection (HPCI).

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One low pressure ECCS injection/spray subsystem inoperable. <u>OR</u> One low pressure coolant injection (LPCI) pump in both LPCI subsystems inoperable.	A.1 Restore low pressure ECCS injection/spray subsystem(s) to OPERABLE status.	7 days* <u>OR</u> In accordance with the Risk Informed Completion Time Program
B. Required Action and associated Completion Time of Condition A not met.	B.1 Be in MODE 3. <u>AND</u> B.2 Be in Mode 4.	12 hours 36 hours

(continued)

* The Completion Time to return the “A” RHR pump to OPERABLE is extended to 34 days, contingent on implementation of Compensatory Actions stated in Section 3.4 of letter JAFP-21-0053, dated June 14, 2021, as a one-time only change ending upon restoration the “A” RHR pump to OPERABLE, or on July 11, 2021 at 20:00 hours.

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>C. HPCI System inoperable.</p>	<p>C.1 Verify by administrative means RCIC System is OPERABLE.</p> <p><u>AND</u></p> <p>C.2 Restore HPCI System to OPERABLE status.</p>	<p>Immediately</p> <p>14 days</p> <p><u>OR</u></p> <p>In accordance with the Risk Informed Completion Time Program</p>
<p>D. HPCI System inoperable.</p> <p><u>AND</u></p> <p>Condition A entered.</p>	<p>D.1 Restore HPCI System to OPERABLE status.</p> <p><u>OR</u></p> <p>D.2 Restore low pressure ECCS injection/spray subsystem(s) to OPERABLE status.</p>	<p>72 hours</p> <p><u>OR</u></p> <p>In accordance with the Risk Informed Completion Time Program</p> <p>72 hours</p> <p><u>OR</u></p> <p>In accordance with the Risk Informed Completion Time Program</p>
<p>E. One required ADS valve inoperable.</p>	<p>E.1 Restore required ADS valve to OPERABLE status.</p>	<p>14 days</p> <p><u>OR</u></p> <p>In accordance with the Risk Informed Completion Time Program</p>

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>F. One required ADS valve inoperable.</p> <p><u>AND</u></p> <p>Condition A entered.</p>	<p>F.1 Restore required ADS valve to OPERABLE status.</p> <p><u>OR</u></p> <p>F.2 Restore low pressure ECCS injection/spray subsystem(s) to OPERABLE status.</p>	<p>72 hours</p> <p><u>OR</u></p> <p>In accordance with the Risk Informed Completion Time Program</p> <p>72 hours</p> <p><u>OR</u></p> <p>In accordance with the Risk Informed Completion Time Program</p>
<p>G. Required Action and associated Completion Time of Condition C, D, E, or F not met.</p> <p><u>OR</u></p> <p>Two or more required ADS valves inoperable.</p>	<p>G.1 Be in Mode 3.</p> <p><u>AND</u></p> <p>G.2 Reduce reactor steam dome pressure to ≤ 150 psig.</p>	<p>12 hours</p> <p>36 hours</p>
<p>H. Two or more low pressure ECCS injection/spray subsystems inoperable for reasons other than Condition A.</p> <p><u>OR</u></p> <p>HPCI System and one or more required ADS valves inoperable.</p>	<p>H.1 Enter LCO 3.0.3.</p>	<p>Immediately</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.5.1.1	Verify, for each ECCS injection/spray subsystem, the piping is filled with water from the pump discharge valve to the injection valve.	In accordance with the Surveillance Frequency Control Program*
SR 3.5.1.2	Verify each ECCS injection/spray subsystem manual, power operated, and automatic valve in the flow path, that is not locked, sealed, or otherwise secured in position, is in the correct position.	In accordance with the Surveillance Frequency Control Program*
SR 3.5.1.3	Verify ADS pneumatic supply header pressure is ≥ 95 psig.	In accordance with the Surveillance Frequency Control Program
SR 3.5.1.4	Verify the RHR System cross tie valves are closed and power is removed from the electrical valve operator.	In accordance with the Surveillance Frequency Control Program
SR 3.5.1.5	Cycle open and closed each LPCI motor operated valve independent power supply battery charger AC input breaker and verify each LPCI inverter output voltage is ≥ 576 V and ≤ 624 V while supplying the respective bus.	In accordance with the Surveillance Frequency Control Program

(continued)

* This Surveillance for ST-4B is not required to be performed until following the return of the "A" RHR pump to OPERABLE. This past due Surveillance will be completed as stated in Section 3.5 of letter JAFP-21-0053, dated June 14, 2021.

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY																
SR 3.5.1.6	Verify each recirculation pump discharge valve cycles through one complete cycle of full travel or is de-energized in the closed position.	24 months																
SR 3.5.1.7	<p>Verify the following ECCS pumps develop the specified flow rate against a system head corresponding to the specified reactor pressure above primary containment pressure.</p> <table border="1"> <thead> <tr> <th>SYSTEM</th> <th>FLOW RATE</th> <th>NO. OF PUMPS</th> <th>SYSTEM HEAD CORRESPONDING TO A REACTOR PRESSURE ABOVE PRIMARY CONTAINMENT PRESSURE OF</th> </tr> </thead> <tbody> <tr> <td>Core</td> <td></td> <td></td> <td></td> </tr> <tr> <td>Spray</td> <td>≥ 4265 gpm</td> <td>1</td> <td>≥ 113 psi</td> </tr> <tr> <td>LPCI</td> <td>≥ 7700 gpm</td> <td>1</td> <td>≥ 20 psi</td> </tr> </tbody> </table>	SYSTEM	FLOW RATE	NO. OF PUMPS	SYSTEM HEAD CORRESPONDING TO A REACTOR PRESSURE ABOVE PRIMARY CONTAINMENT PRESSURE OF	Core				Spray	≥ 4265 gpm	1	≥ 113 psi	LPCI	≥ 7700 gpm	1	≥ 20 psi	In accordance with the INSERVICE TESTING PROGRAM
SYSTEM	FLOW RATE	NO. OF PUMPS	SYSTEM HEAD CORRESPONDING TO A REACTOR PRESSURE ABOVE PRIMARY CONTAINMENT PRESSURE OF															
Core																		
Spray	≥ 4265 gpm	1	≥ 113 psi															
LPCI	≥ 7700 gpm	1	≥ 20 psi															
SR 3.5.1.8	<p>-----NOTE----- Not required to be performed until 12 hours after reactor steam pressure and flow are adequate to perform the test. -----</p> <p>Verify, with reactor pressure ≤ 1040 psig and ≥ 970 psig, the HPCI pump can develop a flow rate ≥ 3400 gpm against a system head corresponding to reactor pressure.</p>	In accordance with the INSERVICE TESTING PROGRAM																

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.5.1.9 -----NOTE----- Not required to be performed until 12 hours after reactor steam pressure and flow are adequate to perform the test. ----- Verify, with reactor pressure \leq 165 psig, the HPCI pump can develop a flow rate \geq 3400 gpm against a system head corresponding to reactor pressure.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.5.1.10 -----NOTE----- 1. For the HPCI System, not required to be performed until 12 hours after reactor steam pressure and flow are adequate to perform the test. 2. Vessel injection/spray may be excluded. ----- Verify each ECCS injection/spray subsystem actuates on an actual or simulated automatic initiation signal, except for valves that are locked, sealed, or otherwise secured in the actuated position.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.5.1.11 -----NOTE----- Valve actuation may be excluded. ----- Verify the ADS actuates on an actual or simulated automatic initiation signal.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.5.1.12 Verify each LPCI motor operated valve independent power supply inverter capacity is adequate to supply and maintain in OPERABLE status the required emergency loads for the design duty cycle.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.5.1.13	Verify each required ADS valve is capable of being opened.	In accordance with the INSERVICE TESTING PROGRAM

3.5 EMERGENCY CORE COOLING SYSTEM (ECCS), REACTOR PRESSURE VESSEL (RPV) WATER INVENTORY CONTROL AND REACTOR CORE ISOLATION COOLING (RCIC) SYSTEM

3.5.2 Reactor Pressure Vessel (RPV) Water Inventory Control

LCO 3.5.2 DRAIN TIME of RPV water inventory to the top of active fuel (TAF) shall be \geq 36 hours

AND

One low pressure ECCS injection/spray subsystems shall be OPERABLE.

-----NOTE-----
A Low Pressure Coolant Injection (LPCI) subsystem may be considered OPERABLE during alignment and operation for decay heat removal if capable of being manually realigned and not otherwise inoperable.

APPLICABILITY: MODES 4 and 5

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Required low pressure ECCS injection/spray subsystem inoperable.	A.1 Restore required low pressure ECCS injection/spray subsystem to OPERABLE status.	4 hours
B. Required Action and associated Completion Time of Condition A not met.	B.1 Initiate action to establish a method of water injection capable of operating without offsite electrical power.	Immediately
C. DRAIN TIME < 36 hours and \geq 8 hours.	C.1 Verify secondary containment boundary is capable of being established in less than the DRAIN TIME <u>AND</u>	4 hours

(continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. (continued)	C.2 Verify each secondary containment penetration flow path in capable of being isolated in less than the DRAIN TIME.	4 hours
	<u>AND</u> C3 Verify one standby gas treatment (SGT) subsystem is capable of being placed in operation in less than the DRAIN TIME.	4 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>D. DRAIN TIME < 8 hours</p>	<p>D.1 ----- NOTE----- Reduce ECCS injection/spray subsystem or additional method of water injection shall be capable of operating without offsite electrical power. ----- Initiate action to establish an additional method of water injection with water sources capable of maintaining RPV water level > TAF for ≥ 36 hours.</p> <p><u>AND</u></p> <p>D.2 Initiate action to establish secondary containment boundary.</p> <p><u>AND</u></p> <p>D.3 Initiate action to isolate each secondary containment penetration flow path or verify it can be automatically or manually isolated from the control room.</p> <p><u>AND</u></p> <p>D.4 Initiate action to verify one SGT subsystem is capable of being placed in operation.</p>	<p>Immediately</p> <p>Immediately</p> <p>Immediately</p> <p>Immediately</p>
<p>E. Required Action and associated Completion Time of Condition C or D not met.</p> <p><u>OR</u></p> <p>DRAINTIME < 1 hour.</p>	<p>E.1 Initiate action to restore DRAIN TIME to ≥ 36 hours.</p>	<p>Immediately</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.5.2.1	Verify DRAIN TIME \geq 36 hours.	In accordance with the Surveillance Frequency Control Program
SR 3.5.2.2	Verify, for a required LPCI subsystem, the suppression pool water level is \geq 10.33 ft.	In accordance with the Surveillance Frequency Control Program

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.5.2.3	<p>Verify, for a required Core Spray (CS) subsystem, the:</p> <ul style="list-style-type: none"> a. Suppression pool water level is ≥ 10.33 ft; or b. The water level in each condensate storage tank is ≥ 324 inches. 	In accordance with the Surveillance Frequency Control Program
SR 3.5.2.4	<p>Verify, for the required ECCS injection/spray subsystem, the piping is filled with water from the pump discharge valve to the injection valve.</p>	In accordance with the Surveillance Frequency Control Program
SR 3.5.2.5	Not Used	

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.5.2.6</p> <p>-----NOTES-----</p> <ol style="list-style-type: none"> 1. Operation may be through the test return line. 2. Credit may be taken for normal system operation to satisfy this SR. <p>-----</p> <p>Operate the required ECCS injection/spray subsystem for ≥ 10 minutes.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.5.2.7</p> <p>Verify each valve credited for automatically isolating a penetration flow path actuates to the isolation position on an actual simulated isolation signal, except for valves that are locked, sealed, or otherwise secured in the actuated position.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.5.2.8</p> <p>-----NOTE-----</p> <p>Vessel injection/spray may be excluded.</p> <p>-----</p> <p>Verify the required ECCS injection/spray subsystem can be manually operated, except for valves that are locked, sealed, or otherwise secured in the actuated position.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>

3.5 EMERGENCY CORE COOLING SYSTEMS (ECCS), REACTOR PRESSURE VESSEL (RPV) WATER INVENTORY CONTROL, AND REACTOR CORE ISOLATION COOLING (RCIC) SYSTEM

3.5.3 RCIC System

LCO 3.5.3 The RCIC System shall be OPERABLE

APPLICABILITY: MODE 1,
MODES 2 and 3 with reactor steam dome pressure > 150 psig.

ACTIONS

-----NOTE-----
LCO 3.0.4.b is not applicable to RCIC.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. RCIC System inoperable.	A.1 Verify by administrative means High Pressure Coolant Injection System is OPERABLE.	Immediately
	<u>AND</u> A.2 Restore RCIC System to OPERABLE status.	14 days <u>OR</u> In accordance with the Risk Informed Completion Time Program
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	12 hours
	<u>AND</u> B.2 Reduce reactor steam dome pressure to ≤ 150 psig.	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.5.3.1	Verify the RCIC System piping is filled with water from the pump discharge valve to the injection valve.	In accordance with the Surveillance Frequency Control Program*
SR 3.5.3.2	Verify each RCIC System manual, power operated, and automatic valve in the flow path, that is not locked, sealed, or otherwise secured in position, is in the correct position.	In accordance with the Surveillance Frequency Control Program*
SR 3.5.3.3	<p>-----NOTE----- Not required to be performed until 12 hours after reactor steam pressure and flow are adequate to perform the test. -----</p> <p>Verify, with reactor pressure \leq 1040 psig and \geq 970 psig, the RCIC pump can develop a flow rate \geq 400 gpm against a system head corresponding to reactor pressure.</p>	In accordance with the Surveillance Frequency Control Program*
SR 3.5.3.4	<p>-----NOTE----- Not required to be performed until 12 hours after reactor steam pressure and flow are adequate to perform the test. -----</p> <p>Verify, with reactor pressure \leq 165 psig, the RCIC pump can develop a flow rate \geq 400 gpm against a system head corresponding to reactor pressure.</p>	In accordance with the Surveillance Frequency Control Program*

(continued)

* This Surveillance for ST-24J is not required to be performed until following the return of the "A" RHR pump to OPERABLE. This past due Surveillance will be completed as stated in Section 3.5 letter JAFP-21-0053, dated June 14, 2021.

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.5.3.5</p> <p>-----NOTE-----</p> <ol style="list-style-type: none"> 1. Not required to be performed until 12 hours after reactor steam pressure and flow are adequate to perform the test. 2. Vessel injection may be excluded. <p>-----</p> <p>Verify the RCIC System actuates on an actual or simulated automatic initiation signal, except for valves that are locked, sealed, or otherwise secured in the actuated position.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>

3.6 CONTAINMENT SYSTEMS

3.6.1.1 Primary Containment

LC0 3.6.1.1 Primary containment shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Primary containment inoperable.	A.1 Restore primary containment to OPERABLE status.	1 hour
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	12 hours
	<u>AND</u> B.2 Be in MODE 4.	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.6.1.1.1	Perform required visual examinations and leakage rate testing except for primary containment air lock testing, in accordance with the Primary Containment Leakage Rate Testing Program.	In accordance with the Primary Containment Leakage Rate Testing Program
SR 3.6.1.1.2	Verify suppression chamber pressure increase is ≤ 0.25 in. water gauge per minute over a 10 minute period with a drywell to suppression chamber differential pressure of ≥ 1 psi.	<p>In accordance with the Surveillance Frequency Control Program</p> <p><u>AND</u></p> <p>——NOTE—— Only required after two consecutive tests fail and continues until two consecutive tests pass</p> <hr/> <p>12 months</p>

3.6 CONTAINMENT SYSTEMS

3.6.1.2 Primary Containment Air Locks

LCO 3.6.1.2 Two primary containment air locks shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

- NOTES-----
1. Entry and exit is permissible to perform repairs of the affected air lock components.
 2. Separate Condition entry is allowed for each air lock.
 3. Enter applicable Conditions and Required Actions of LCO 3.6.1.1, "Primary Containment," when air lock leakage results in exceeding overall containment leakage rate acceptance criteria.
-

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. One or more primary containment air locks with one primary containment air lock door inoperable.</p>	<p>-----NOTES-----</p> <ol style="list-style-type: none"> 1. Required Actions A.1, A.2, and A.3 are not applicable if both doors in the same air lock are inoperable and Condition C is entered. 2. Entry and exit is permissible for 7 days under administrative controls. <p>-----</p> <p>A.1 Verify the OPERABLE door is closed in the affected air lock.</p> <p><u>AND</u></p>	<p>1 hour</p> <p>(continued)</p>

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. Required Action and associated Completion Time not met.	D.1 Be in MODE 3.	12 hours
	<u>AND</u>	
	D.2 Be in MODE 4.	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.6.1.2.1</p> <p style="text-align: center;"><u>NOTES</u></p> <ol style="list-style-type: none"> 1. An inoperable air lock door does not invalidate the previous successful performance of the overall air lock leakage test. 2. Results shall be evaluated against criteria applicable to SR 3.6.1.1.1. <hr/> <p>Perform required primary containment air lock leakage rate testing in accordance with the Primary Containment Leakage Rate Testing Program.</p>	In accordance with the Primary Containment Leakage Rate Testing Program
<p>SR 3.6.1.2.2</p> <p>Verify only one door in the primary containment air lock can be opened at a time.</p>	In accordance with the Surveillance Frequency Control Program

3.6 CONTAINMENT SYSTEMS

3.6.1.3 Primary Containment Isolation Valves (PCIVs)

LCO 3.6.1.3 Each PCIV, except reactor building-to-suppression chamber vacuum breakers, shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

-----NOTES-----

1. Penetration flow paths may be unisolated intermittently under administrative controls.
 2. Separate Condition entry is allowed for each penetration flow path.
 3. Enter applicable Conditions and Required Actions for systems made inoperable by PCIVs.
 4. Enter applicable Conditions and Required Actions of LCO 3.6.1.1, "Primary Containment," when PCIV leakage results in exceeding overall containment leakage rate acceptance criteria.
-

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. ----- NOTE----- Only applicable to penetration flow paths with two or more PCIVs. ----- One or more penetration flow paths with one PCIV inoperable for reasons other than Conditions D and E.</p>	<p>A.1 Isolate the affected penetration flow path by use of at least one closed and de-activated automatic valve, closed manual valve, blind flange, or check valve with flow through the valve secured.</p> <p><u>AND</u></p>	<p>4 hours except for main steam line</p> <p><u>OR</u></p> <p>In accordance with the Risk Informed Completion Time Program</p> <p><u>AND</u></p> <p>8 hours for main steam line</p> <p><u>OR</u></p> <p>In accordance with the Risk Informed Completion Time Program</p> <p>(continued)</p>

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. (continued)</p>	<p>A.2</p> <p>-----NOTES-----</p> <ol style="list-style-type: none"> 1. Isolation devices in high radiation areas may be verified by use of administrative means. 2. Isolation devices that are locked, sealed, or otherwise secured may be verified by use of administrative means. <p>-----</p> <p>Verify the affected penetration flow path is isolated.</p>	<p>Once per 31 days following isolation for isolation devices outside primary containment</p> <p><u>AND</u></p> <p>Prior to entering MODE 2 or 3 from MODE 4, if primary containment was de-inerted while in MODE 4, if not performed within the previous 92 days, for isolation devices inside primary containment</p>

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>B. -----NOTE----- Only applicable to penetration flow paths with two or more PCIVs. ----- One or more penetration flow paths with two or more PCIVs inoperable for reasons other than Conditions D and E.</p>	<p>B.1 Isolate the affected penetration flow path by use of at least one closed and de-activated automatic valve, closed manual valve, or blind flange.</p>	<p>1 hour</p>
<p>C. -----NOTE----- Only applicable to penetration flow paths with only one PCIV. ----- One or more penetration flow paths with one PCIV inoperable for reasons other than Conditions D and E.</p>	<p>C.1 Isolate the affected penetration flow path by use of at least one closed and de-activated automatic valve, closed manual valve, or blind flange.</p> <p><u>AND</u></p>	<p>4 hours except for excess flow check valves (EFCVs) and penetrations with a closed system</p> <p><u>AND</u></p> <p>72 hours for EFCVs and penetrations with a closed system</p>

(continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. (continued)	<p>C.2 -----NOTES-----</p> <ol style="list-style-type: none"> 1. Isolation devices in high radiation areas may be verified by use of administrative means. 2. Isolation devices that are locked, sealed, or otherwise secured may be verified by use of administrative means. <p>-----</p> <p>Verify the affected penetration flow path is isolated.</p>	<p>Once per 31 days following isolation</p>
D. One or more penetration flow paths with one or more MSIVs not within leakage rate limit.	<p>D.1 Restore leakage rate to within limit.</p>	<p>8 hours</p>
E. One or more penetration flow paths with LPCI System or CS System testable check valve leakage limit not met.	<p>E.1 Restore leakage rate to within limit.</p>	<p>72 hours</p> <p><u>OR</u></p> <p>-----NOTE-----</p> <p>Not applicable if leakage exceeds limits or if loss of function</p> <p>-----</p> <p>In accordance with the Risk Informed Completion Time Program</p>

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
F. Required Action and associated Completion Time of Condition A, B, C, D, or E not met.	F.1 Be in MODE 3.	12 hours
	<u>AND</u> F.2 Be in MODE 4.	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.6.1.3.1</p> <p>-----NOTE-----</p> <p>Not required to be met when the 20 inch and 24 inch primary containment vent and purge valves are open for inerting, de-inerting, pressure control, ALARA or air quality considerations for personnel entry, or Surveillances that require the valves to be open, provided the full-flow line to Standby Gas Treatment (SGT) System is closed.</p> <p>-----</p> <p>Verify each 20 inch and 24 inch primary containment vent and purge valve is closed.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.6.1.3.2</p> <p>-----NOTE-----</p> <ol style="list-style-type: none"> 1. Valves and blind flanges in high radiation areas may be verified by use of administrative means. 2. Not required to be met for PCIVs that are open under administrative controls. <p>-----</p> <p>Verify each primary containment isolation manual valve and blind flange that is located outside primary containment and not locked, sealed or otherwise secured and is required to be closed during accident conditions is closed.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.6.1.3.3 -----NOTES-----</p> <ol style="list-style-type: none"> 1. Valves and blind flanges in high radiation areas may be verified by use of administrative means. 2. Not required to be met for PCIVs that are open under administrative controls. <p>-----</p> <p>Verify each primary containment manual isolation valve and blind flange that is located inside primary containment and not locked, sealed or otherwise secured and is required to be closed during accident conditions is closed.</p>	<p>Prior to entering MODE 2 or 3 from MODE 4 if primary containment was de-inerted while in MODE 4, if not performed within the previous 92 days</p>
<p>SR 3.6.1.3.4 Verify continuity of the traversing incore probe (TIP) shear isolation valve explosive charge.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.6.1.3.5 Verify the isolation time of each power operated, automatic PCIV, except for MSIVs, is within limits.</p>	<p>In accordance with the INSERVICE TESTING PROGRAM*</p>
<p>SR 3.6.1.3.6 Verify the isolation time of each MSIV is ≥ 3 seconds and ≤ 5 seconds.</p>	<p>In accordance with the INSERVICE TESTING PROGRAM</p>

(continued)

* This Surveillance for ST-24J is not required to be performed until following the return of the "A" RHR pump to OPERABLE. This past due Surveillance will be completed as stated in Section 3.5 of letter JAFP-21-0053, dated June 14, 2021.

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.6.1.3.7	Verify each automatic PCIV actuates to the isolation position on an actual or simulated isolation signal.	In accordance with the Surveillance Frequency Control Program
SR 3.6.1.3.8	Verify each reactor instrumentation line EFCV actuates to the isolation position on a simulated instrument line break.	In accordance with the INSERVICE TESTING PROGRAM
SR 3.6.1.3.9	Remove and test the explosive squib from each shear isolation valve of the TIP System.	In accordance with the Surveillance Frequency Control Program
SR 3.6.1.3.10	Verify combined main steam line leakage rate is ≤ 200 scfh, and ≤ 100 scfh for any one steam line, when tested at ≥ 25 psig.	In accordance with the Primary Containment Leakage Rate Testing Program
SR 3.6.1.3.11	Verify the leakage rate of each air operated testable check valve associated with the LPCI and CS Systems vessel injection penetrations is within limits.	In accordance with the Primary Containment Leakage Rate Testing Program

3.6 CONTAINMENT SYSTEMS

3.6.1.4 Drywell Pressure

LCO 3.6.1.4 Drywell pressure shall be ≤ 1.95 psig.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Drywell pressure not within limit.	A.1 Restore drywell pressure to within limit.	1 hour
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3. <u>AND</u>	12 hours
	B.2 Be in MODE 4.	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.6.1.4.1 Verify drywell pressure is within limit.	In accordance with the Surveillance Frequency Control Program

3.6 CONTAINMENT SYSTEMS

3.6.1.5 Drywell Air Temperature

LCO 3.6.1.5 Drywell average air temperature shall be $\leq 135^{\circ}\text{F}$.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Drywell average air temperature not within limit.	A.1 Restore drywell average air temperature to within limit.	8 hours
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	12 hours
	<u>AND</u> B.2 Be in MODE 4.	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.6.1.5.1 Verify drywell average air temperature is within limit.	In accordance with the Surveillance Frequency Control Program

3.6 CONTAINMENT SYSTEMS

3.6.1.6 Reactor Building-to-Suppression Chamber Vacuum Breakers

LCO 3.6.1.6 Each reactor building-to-suppression chamber vacuum breaker shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

----- NOTE -----
Separate Condition entry is allowed for each line.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more lines with one reactor building-to-suppression chamber vacuum breaker not closed.	A.1 Close the open vacuum breaker.	72 hours
B. One or more lines with two reactor building-to-suppression chamber vacuum breakers not closed.	B.1 Close one open vacuum breaker.	1 hour
C. One line with one or more reactor building-to-suppression chamber vacuum breakers inoperable for opening.	C.1 Restore the vacuum breaker(s) to OPERABLE status.	72 hours <u>OR</u> In accordance with the Risk Informed Completion Time Program

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
D Two lines with one or more reactor building-to-suppression chamber vacuum breakers inoperable for opening.	D.1 Restore all vacuum breakers in one line to OPERABLE status.	1 hour
E. Required Action and Associated Completion Time not met.	E.1 Be in MODE 3.	12 hours
	<u>AND</u> E.2 Be in MODE 4.	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.6.1.6.1 -----NOTES----- 1. Not required to be met for vacuum breakers that are open during Surveillances. 2. Not required to be met for vacuum breakers open when performing their intended function. ----- Verify each vacuum breaker is closed.	In accordance with the Surveillance Frequency Control Program
SR 3.6.1.6.2 Perform a functional test of each vacuum breaker.	In accordance with the INSERVICE TESTING PROGRAM

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.6.1.6.3	Perform a CHANNEL CALIBRATION of each air operated vacuum breaker differential pressure instrument channel and verify the setpoint is ≤ 0.5 psid.	In accordance with the Surveillance Frequency Control Program
SR 3.6.1.6.4	Verify the opening setpoint of each self actuating vacuum breaker is ≤ 0.5 psid.	In accordance with the Surveillance Frequency Control Program

3.6 CONTAINMENT SYSTEMS

3.6.1.7 Suppression Chamber-to-Drywell Vacuum Breakers

LCO 3.6.1.7 Each suppression chamber-to-drywell vacuum breaker shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One suppression chamber-to-drywell vacuum breaker inoperable for opening.	A.1 Restore the vacuum breaker to OPERABLE status.	72 hours <u>OR</u> In accordance with the Risk Informed Completion Time Program
B. One suppression chamber-to-drywell vacuum breaker not closed.	B.1 Close the open vacuum breaker.	2 hours
C. Required Action and associated Completion Time not met.	C.1 Be in MODE 3. <u>AND</u> C.2 Be in MODE 4.	12 hours 36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.6.1.7.1</p> <p style="text-align: center;">-----NOTES-----</p> <p>1. Not required to be met for vacuum breakers that are open during Surveillances.</p> <p>2. Not required to be met for vacuum breakers open when performing their intended function.</p> <p>-----</p> <p>Verify each vacuum breaker is closed.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.6.1.7.2</p> <p>Perform a functional test of each vacuum breaker.</p>	<p>In accordance with the INSERVICE TESTING PROGRAM</p>
<p>SR 3.6.1.7.3</p> <p>Verify the opening setpoint of each vacuum breaker is ≤ 0.5 psid.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>

3.6 CONTAINMENT SYSTEMS

3.6.1.8 Deleted

3.6 CONTAINMENT SYSTEMS

3.6.1.9 Residual Heat Removal (RHR) Containment Spray System

LCO 3.6.1.9 Two RHR containment spray subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One RHR containment spray subsystem inoperable.	A.1 Restore RHR containment spray subsystem to OPERABLE status.	7 days <u>OR</u> In accordance with the Risk Informed Completion Time Program
B. Two RHR containment spray subsystems inoperable.	B.1 Restore one RHR containment spray subsystem to OPERABLE status.	8 hours
C. Required Action and associated Completion Time not met.	C.1 Be in MODE 3. <u>AND</u> C.2 Be in MODE 4.	12 hours 36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.6.1.9.1	Verify each RHR containment spray subsystem manual, power operated, and automatic valve in the flow path that is not locked, sealed, or otherwise secured in position, is in the correct position or can be aligned to the correct position.	In accordance with the Surveillance Frequency Control Program
SR 3.6.1.9.2	Verify each required RHR pump develops a flow rate of ≥ 7750 gpm through the associated heat exchanger while operating in the suppression pool cooling mode.	In accordance with the INSERVICE TESTING PROGRAM
SR 3.6.1.9.3	Verify each spray nozzle is unobstructed.	In accordance with the Surveillance Frequency Control Program

3.6 CONTAINMENT SYSTEMS

3.6.2.1 Suppression Pool Average Temperature

LCO 3.6.2.1 Suppression pool average temperature shall be:

- a. $\leq 95^\circ\text{F}$ with THERMAL POWER $> 1\%$ RTP and no testing that adds heat to the suppression pool is being performed;
- b. $\leq 105^\circ\text{F}$ with THERMAL POWER $> 1\%$ RTP and testing that adds heat to the suppression pool is being performed;
 and
- c. $\leq 110^\circ\text{F}$ with THERMAL POWER $\leq 1\%$ RTP.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. Suppression pool average temperature $> 95^\circ\text{F}$ but $\leq 110^\circ\text{F}$.</p> <p><u>AND</u></p> <p>THERMAL POWER $> 1\%$ RTP.</p> <p><u>AND</u></p> <p>Not performing testing that adds heat to the suppression pool.</p>	<p>A.1 Verify suppression pool average temperature $\leq 110^\circ\text{F}$.</p> <p><u>AND</u></p> <p>A.2 Restore suppression pool average temperature to $\leq 95^\circ\text{F}$.</p>	<p>Once per hour</p> <p>24 hours</p>

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>B. Required Action and associated Completion Time of Condition A not met.</p>	<p>B.1 Reduce THERMAL POWER to $\leq 1\%$ RTP.</p>	<p>12 hours</p>
<p>C. Suppression pool average temperature $> 105^{\circ}\text{F}$.</p> <p><u>AND</u></p> <p>THERMAL POWER $> 1\%$ RTP.</p> <p><u>AND</u></p> <p>Performing testing that adds heat to the suppression pool.</p>	<p>C.1 Suspend all testing that adds heat to the suppression pool.</p>	<p>Immediately</p>
<p>D. Suppression pool average temperature $> 110^{\circ}\text{F}$ but $\leq 120^{\circ}\text{F}$.</p>	<p>D.1 Place the reactor mode switch in the shutdown position.</p> <p><u>AND</u></p> <p>D.2 Verify suppression pool average temperature $\leq 120^{\circ}\text{F}$.</p> <p><u>AND</u></p> <p>D.3 Be in MODE 4.</p>	<p>Immediately</p> <p>Once per 30 minutes</p> <p>36 hours</p>

(continued)

Suppression Pool Average Temperature
3.6.2.1

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
E. Suppression pool average temperature > 120°F.	E.1 Depressurize the reactor vessel to < 200 psig.	12 hours
	<u>AND</u>	
	E.2 Be in MODE 4.	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.6.2.1.1 Verify suppression pool average temperature is within the applicable limits.	In accordance with the Surveillance Frequency Control Program <u>AND</u> 5 minutes when performing testing that adds heat to the suppression pool

3.6 CONTAINMENT SYSTEMS

3.6.2.2 Suppression Pool Water Level

LCO 3.6.2.2 Suppression pool water level shall be ≥ 13.88 ft and ≤ 14.25 ft.

----- NOTE -----
 Not required to be met for up to 4 hours during Surveillances that
 cause suppression pool water level to be outside the limit.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Suppression pool water level not within limits.	A.1 Restore suppression pool water level to within limits.	2 hours
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	12 hours
	<u>AND</u> B.2 Be in MODE 4.	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.6.2.2.1 Verify suppression pool water level is within limits.	In accordance with the Surveillance Frequency Control Program

3.6 CONTAINMENT SYSTEMS

3.6.2.3 Residual Heat Removal (RHR) Suppression Pool Cooling

LCO 3.6.2.3 Two RHR suppression pool cooling subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One RHR suppression pool cooling subsystem inoperable.	A.1 Restore RHR suppression pool cooling subsystem to OPERABLE status.	7 days <u>OR</u> In accordance with the Risk Informed Completion Time Program
B. Two RHR suppression pool cooling subsystems inoperable.	B.1 Restore one RHR suppression pool cooling subsystem to OPERABLE status.	8 hours
C. Required Action and associated Completion Time not met.	C.1 Be in MODE 3. <u>AND</u> C.2 Be in MODE 4.	12 hours 36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.6.2.3.1	Verify each RHR suppression pool cooling subsystem manual, power operated, and automatic valve in the flow path that is not locked, sealed, or otherwise secured in position, is in the correct position or can be aligned to the correct position.	In accordance with the Surveillance Frequency Control Program
SR 3.6.2.3.2	Verify each required RHR pump develops a flow rate of ≥ 7700 gpm through the associated heat exchanger while operating in the suppression pool cooling mode.	In accordance with the INSERVICE TESTING PROGRAM

3.6 CONTAINMENT SYSTEMS

3.6.2.4 Deleted

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.6.2.4.1 Verify drywell-to-suppression chamber differential pressure is within limit.	In accordance with the Surveillance Frequency Control Program

3.6 CONTAINMENT SYSTEMS

3.6.3.1 Primary Containment Oxygen Concentration

LCO 3.6.3.1 The primary containment oxygen concentration shall be < 4.0 volume percent.

APPLICABILITY: **MODES 1 and 2.**

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Primary containment oxygen concentration not within limit.	A.1 ----- NOTE ----- LCO 3.0.4.c is Applicable. ----- Restore oxygen concentration to within limit.	72 hours
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	12 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.6.3.1.1 Verify primary containment oxygen concentration is within limits.	In accordance with the Surveillance Frequency Control Program

3.6 CONTAINMENT SYSTEMS

3.6.3.2 Deleted

3.6 CONTAINMENT SYSTEMS

3.6.4.1 Secondary Containment

LCO 3.6.4.1 The secondary containment shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
During movement of recently irradiated fuel assemblies in
the secondary containment.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Secondary containment inoperable in MODE 1, 2, or 3.	A.1 Restore secondary containment to OPERABLE status.	4 hours*
B. Required Action and associated Completion Time of Condition A not met.	B.1 Be in MODE 3.	12 hours
	<u>AND</u> B.2 Be in MODE 4.	36 hours
C. Secondary containment inoperable during movement of recently irradiated fuel assemblies in the secondary containment.	C.1 ----- NOTE----- LCO 3.0.3 is not applicable. ----- Suspend movement of recently irradiated fuel assemblies in the secondary containment.	Immediately

* The Completion Time is extended to 30 hours, in support of the "A" RHR pump repairs, contingent on implementation of Compensatory Actions stated in Section 3.4 of letter JAFP-21-0053, dated June 14, 2021, as a one-time only change ending upon restoration of the "A" RHR pump to OPERABLE, or on July 11, 2021 at 20:00 hours. Multiple entries may be necessary to implement compensatory actions, or to address unforeseen circumstances related to the "A" RHR pump motor replacement.

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.6.4.1.1	<p>-----NOTE----- Not required to be met for 4 hours if analysis demonstrates that one Standby Gas Treatment (SGT) subsystem is capable of establishing the required secondary containment vacuum. -----</p> <p>Verify secondary containment vacuum is ≥ 0.25 inch of vacuum water gauge.</p>	In accordance with the Surveillance Frequency Control Program
SR 3.6.4.1.2	Verify all secondary containment equipment hatches are closed and sealed.	In accordance with the Surveillance Frequency Control Program
SR 3.6.4.1.3	Verify one secondary containment access door in each access opening is closed, except when the access opening is being used for entry and exit.	In accordance with the Surveillance Frequency Control Program
SR 3.6.4.1.4	Verify the secondary containment can be maintained ≥ 0.25 inch of vacuum water gauge for 1 hour using one SGT subsystem at a flow rate ≤ 6000 cfm.	In accordance with the Surveillance Frequency Control Program

3.6 CONTAINMENT SYSTEMS

3.6.4.2 Secondary Containment Isolation Valves (SCIVs)

LCO 3.6.4.2 Each SCIV shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
During movement of recently irradiated fuel assemblies in
the secondary containment,

ACTIONS

-----NOTES-----

1. Penetration flow paths may be unisolated intermittently under administrative controls.
 2. Separate Condition entry is allowed for each penetration flow path.
 2. Enter applicable Conditions and Required Actions for systems made inoperable by SCIVs.
-

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. One or more penetration flow paths with one SCIV inoperable.</p>	<p>A.1 Isolate the affected penetration flow path by use of at least one closed and de-activated automatic valve, closed manual valve, or blind flange.</p> <p><u>AND</u></p>	<p>8 hours</p> <p>(continued)</p>

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. (continued)</p>	<p>A.2</p> <p>-----NOTES-----</p> <ol style="list-style-type: none"> 1. Isolation devices in high radiation areas may be verified by use of administrative means. 2. Isolation devices that are locked, sealed, or otherwise secured may be verified by use of administrative means. <p>-----</p> <p>Verify the affected penetration flow path is isolated.</p>	<p>Once per 31 days</p>
<p>B. -----NOTE----- Only applicable to penetration flow paths with two isolation valves. ----- One or more penetration flow paths with two SCIVs inoperable.</p>	<p>B.1</p> <p>Isolate the affected penetration flow path by use of at least one closed and de-activated automatic valve, closed manual valve, or blind flange.</p>	<p>4 hours</p>
<p>C. Required Action and associated Completion Time of Condition A or B not met in MODE 1, 2, or 3.</p>	<p>C.1 Be in MODE 3.</p> <p><u>AND</u></p> <p>C.2 Be in MODE 4.</p>	<p>12 hours</p> <p>36 hours</p>

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>D. Required Action and associated Completion Time of Condition A or B not met during movement of recently irradiated fuel assemblies in the secondary containment</p>	<p>D.1 -----NOTE----- LCO 3.0.3 is not applicable. ----- Suspend movement of recently irradiated fuel assemblies in the secondary containment.</p>	<p>Immediately</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.6.4.2.1</p> <hr/> <p style="text-align: center;">NOTES</p> <ol style="list-style-type: none"> 1. Valves and blind flanges in high radiation areas may be verified by use of administrative means. 2. Not required to be met for SCIVs that are open under administrative controls. <hr/> <p>Verify each secondary containment isolation manual valve and blind flange that is not locked, sealed, or otherwise secured and is required to be closed during accident conditions is closed.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.6.4.2.2</p> <p>Verify the isolation time of each power operated, automatic SCIV is within limits.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.6.4.2.3</p> <p>Verify each automatic SCIV actuates to the isolation position on an actual or simulated actuation signal.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>

3.6 CONTAINMENT SYSTEMS

3.6.4.3 Standby Gas Treatment (SGT) System

LCO 3.6.4.3 Two SGT subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
During movement of recently irradiated fuel assemblies in
the secondary containment,

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One SGT subsystem inoperable.	A.1 Restore SGT subsystem to OPERABLE status.	7 days
B. Required Action and associated Completion Time of Condition A not met in MODE 1, 2, or 3.	B.1 Be in MODE 3.	12 hours
	<u>AND</u> B.2 Be in MODE 4.	36 hours
C. Required Action and associated Completion Time of Condition A not met during movement of recently irradiated fuel assemblies in the secondary containment.	-----NOTE----- LCO 3.0.3 is not applicable. -----	Immediately
	C.1 Place OPERABLE SGT subsystem in operation. <u>OR</u>	

(continued)

ACTIONS		
CONDITION	REQUIRED ACTION	COMPLETION TIME
C. (continued)	C.2 Suspend movement of recently irradiated fuel assemblies in secondary containment.	Immediately
D. Two SGT subsystems inoperable in MODE 1, 2, or 3.	D.1 Enter LCO 3.0.3.	Immediately
E. Two SGT subsystems inoperable during movement of recently irradiated fuel assemblies in the secondary containment	E.1 -----NOTE----- LCO 3.0.3 is not applicable. ----- Suspend movement of recently irradiated fuel assemblies in secondary containment.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.6.4.3.1	Operate each SGT subsystem for ≥ 15 continuous minutes with heaters operating.	In accordance with the Surveillance Frequency Control Program
SR 3.6.4.3.2	Perform required SGT filter testing in accordance with the Ventilation Filter Testing Program (VFTP).	In accordance with the VFTP
SR 3.6.4.3.3	Verify each SGT subsystem actuates on an actual or simulated initiation signal, except for dampers that are locked, sealed, or otherwise secured in the actuated position.	In accordance with the Surveillance Frequency Control Program
SR 3.6.4.3.4	Manually cycle each SGT subsystem filter cooling cross-tie valve.	In accordance with the Surveillance Frequency Control Program

3.7 PLANT SYSTEMS

3.7.1 Residual Heat Removal Service Water (RHRSW) System

LCO 3.7.1 Two RHRSW subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One RHRSW pump inoperable.	A.1 Restore RHRSW pump to OPERABLE status.	30 days
B. One RHRSW pump in each subsystem inoperable.	B.1 Restore one RHRSW pump to OPERABLE status.	7 days <u>OR</u> In accordance with the Risk Informed Completion Time Program
C. One RHRSW subsystem inoperable for reasons other than Condition A.	----- NOTE----- Enter applicable Conditions and Required Actions of LCO 3.4.7, "Residual Heat Removal (RHR) Shutdown Cooling System - Hot Shutdown," for RHR shutdown cooling made inoperable by RHRSW System. ----- C.1 Restore RHRSW subsystem to OPERABLE status.	7 days <u>OR</u> In accordance with the Risk Informed Completion Time Program

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. Both RHRSW subsystems inoperable for reasons other than Condition B.	<hr/> NOTE <hr/> Enter applicable Conditions and Required Actions of LCO 3.4.7 for RHR shutdown cooling made inoperable by RHRSW System. <hr/>	8 hours
	D.1 Restore one RHRSW subsystem to OPERABLE status.	
E. Required Action and associated Completion Time not met.	E.1 Be in MODE 3.	12 hours
	AND E.2 Be in MODE 4.	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.7.1.1 Verify each RHRSW manual, power operated, and automatic valve in the flow path, that is not locked, sealed, or otherwise secured in position, is in the correct position or can be aligned to the correct position.	In accordance with the Surveillance Frequency Control Program

3.7 PLANT SYSTEMS

3.7.2 Emergency Service Water (ESW) System and Ultimate Heat Sink (UHS)

LCO 3.7.2 Two ESW subsystems an UHS shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. One ESW subsystem inoperable.</p>	<p>----- NOTE ----- Enter applicable Conditions and Required Actions of LCO 3.8.1, "AC Sources – Operating," for emergency diesel generator subsystem made inoperable by ESW. -----</p> <p>A.1 Restore the ESW subsystem to OPERABLE status.</p>	<p>7 days <u>OR</u> In accordance with the Risk Informed Completion Time Program</p>
<p>B. Required Action and associated Completion Time not met. <u>OR</u> Both ESW subsystems inoperable for reasons other than Condition A.</p>	<p>B.1 Be in MODE 3. <u>AND</u> B.2 Be in MODE 4.</p>	<p>12 hours 36 hours</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.7.2.1	Verify the water level in the ESW pump screenwell is ≥ 236.5 ft mean sea level.	In accordance with the Surveillance Frequency Control Program
SR 3.7.2.2	Verify the average water temperature of UHS is $\leq 85^{\circ}\text{F}$.	In accordance with the Surveillance Frequency Control Program
SR 3.7.2.3	<p>-----NOTE----- Isolation of flow to individual components does not necessarily render ESW System inoperable. -----</p> <p>Verify each ESW subsystem manual, power operated, and automatic valve in the flow paths servicing safety related systems or components, that is not locked, sealed, or otherwise secured in position, is in the correct position.</p>	In accordance with the Surveillance Frequency Control Program
SR 3.7.2.4	Verify each ESW subsystem actuates on an actual or simulated initiation signal, except for valves that are locked, sealed, or otherwise secured in the actuated position.	In accordance with the Surveillance Frequency Control Program

3.7 PLANT SYSTEMS

3.7.3 Control Room Emergency Ventilation Air Supply (CREVAS) System

LCO 3.7.3 Two CREVAS subsystems shall be OPERABLE.

----- NOTE -----
The control room envelope (CRE) boundary may be opened intermittently under administrative control.

APPLICABILITY: MODES 1, 2, and 3,
During movement of recently irradiated fuel assemblies in the secondary containment,

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One CREVAS subsystem inoperable for reasons other than Condition B.	A.1 Restore CREVAS subsystem to OPERABLE status.	7 days
B. One or more CREVAS subsystems inoperable due to inoperable CRE boundary in MODE 1, 2, or 3.	B.1 Initiate action to implement mitigating actions.	Immediately
	<u>AND</u> B.2 Verify mitigating actions ensure CRE occupant exposures to radiological, chemical, and smoke hazards will not exceed limits.	24 hours
	<u>AND</u> B.3 Restore CRE boundary to OPERABLE status.	90 days

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>C. Required Action and associated Completion Time of Condition A or B not met in MODE 1, 2, or 3.</p>	<p>C.1 Be in MODE 3. <u>AND</u> C.2 Be in MODE 4.</p>	<p>12 hours 36 hours</p>
<p>D. Required Action and associated Completion Time of Condition A not met during movement of recently irradiated fuel assemblies in the secondary containment</p>	<p>----- NOTE ----- LCO 3.0.3 is not applicable. ----- D.1 Place OPERABLE CREVAS subsystem in isolate mode. <u>OR</u> D.2 Suspend movement of recently irradiated fuel assemblies in the secondary containment.</p>	<p>Immediately Immediately</p>
<p>E. Two CREVAS subsystems inoperable in MODE 1, 2, or 3 for reasons other than Condition B.</p>	<p>E.1 Enter LCO 3.0.3.</p>	<p>Immediately</p>

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>F. Two CREVAS subsystems inoperable during movement of recently irradiated fuel assemblies in the secondary containment</p> <p><u>OR</u></p> <p>One or more CREVAS subsystems inoperable due to an inoperable CRE boundary during movement of recently irradiated fuel in the secondary containment</p>	<p>----- NOTE ----- LCO 3.0.3 is not applicable. -----</p> <p>F.1 Suspend movement of recently irradiated fuel assemblies in the secondary containment.</p>	<p>Immediately</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.7.3.1 Operate each CREVAS subsystem for \geq 15 minutes.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.7.3.2 Perform required CREVAS filter testing in accordance with the Ventilation Filter Testing Program (VFTP).</p>	<p>In accordance with the VFTP</p>

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.7.3.3	Perform required CRE unfiltered air in-leakage testing in accordance with the Control Room Envelope Habitability Program.	In accordance with the Control Room Envelope Habitability Program

3.7 PLANT SYSTEMS

3.7.4 Control Room Air Conditioning (AC) System

LCO 3.7.4 Two control room AC subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
During movement of recently irradiated fuel assemblies in the
secondary containment,

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One control room AC subsystem inoperable.	A.1 Restore control room AC subsystem to OPERABLE status.	30 days
B. Two control room AC subsystems inoperable.	B.1 Verify control room area temperature < 90 °F.	Once per 4 hours
	<u>AND</u> B.2 Restore one control room AC subsystem to OPERABLE status.	72 hours
C. Required Action and associated Completion Time of Condition A or B not met in MODE 1, 2, or 3.	C.1 Be in MODE 3.	12 hours
	<u>AND</u> C.2 Be in MODE 4.	36 hours

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.7.4.1	Verify each control room AC subsystem has the capability to remove the assumed heat load.	In accordance with the Surveillance Frequency Control Program*

* This Surveillance ST-8Q is not required to be performed until following the return of the "A" RHR pump to OPERABLE. This past due Surveillance will be completed as stated in Section 3.5 of letter JAFP-21-0053, dated June 14, 2021.

3.7 PLANT SYSTEMS

3.7.5 Main Condenser Steam Jet Air Ejector (SJAE) Offgas

LCO 3.7.5 The gross gamma activity rate of the noble gases measured at the discharge of the SJAE (prior to dilution and/or discharge) shall be $\leq 600,000 \mu\text{Ci/second}$.

APPLICABILITY: MODE 1,
MODES 2 and 3 with any main steam line not isolated and steam jet air ejector (SJAE) in operation.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Gross gamma activity rate of the noble gases not within limit.	A.1 Restore gross gamma activity rate of the noble gases to within limit.	72 hours
B. Required Action and associated Completion Time not met.	B.1 Isolate all main steam lines.	12 hours
	<u>OR</u>	
	B.2 Isolate SJAE.	12 hours
	<u>OR</u>	
	B.3.1 Be in MODE 3.	12 hours
	<u>AND</u>	
	B.3.2 Be in MODE 4.	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.7.5.1 ----- NOTE----- Not required to be performed until 31 days after any main steam line not isolated and SJAE in operation. -----</p> <p>Verify the gross gamma activity rate of the noble gases is $\leq 600,000 \mu\text{Ci/second}$.</p>	<p>In accordance with the Surveillance Frequency Control Program</p> <p><u>AND</u></p> <p>----- NOTE----- Only required when gross gamma activity rate is $\geq 5,000 \mu\text{Ci/second}$ -----</p> <p>Once within 4 hours after a $\geq 50\%$ increase in the nominal steady state fission gas release after factoring out increases due to changes in THERMAL POWER level</p>

3.7 PLANT SYSTEMS

3.7.6 Main Turbine Bypass System

LCO 3.7.6 The Main Turbine Bypass System shall be OPERABLE.

OR

The following limits are made applicable:

- a. LCO 3.2.2, "MINIMUM CRITICAL POWER RATIO (MCPR)," limits for an inoperable Main Turbine Bypass System, as specified in the COLR; and
- b. LCO 3.2.3, "LINEAR HEAT GENERATION RATE (LHGR)," limits for an inoperable Main Turbine Bypass System, as specified in the COLR.

APPLICABILITY: THERMAL POWER ≥ 25% RTP.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Requirements of the LCO not met.	A.1 Satisfy the requirements of the LCO.	2 hours <u>OR</u> In accordance with the Risk Informed Completion Time Program
B. Required Action and associated Completion Time not met.	B.1 Reduce THERMAL POWER to < 25% RTP.	4 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.7.6.1	Verify one complete cycle of each required main turbine bypass valve.	Prior to entering MODE 2 or 3 from MODE 4
SR 3.7.6.2	Perform a system functional test.	In accordance with the Surveillance Frequency Control Program
SR 3.7.6.3	Verify the TURBINE BYPASS SYSTEM RESPONSE TIME is within limits.	In accordance with the Surveillance Frequency Control Program

3.7 PLANT SYSTEMS

3.7.7 Spent Fuel Storage Pool Water Level

LCO 3.7.7 The spent fuel storage pool water level shall be \geq 21 ft 7 inches over the top of irradiated fuel assemblies seated in the spent fuel storage pool racks.

APPLICABILITY: During movement of irradiated fuel assemblies in the spent fuel storage pool.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Spent fuel storage pool water level not within limit.	A.1 ----- NOTE ----- LCO 3.0.3 is not applicable. ----- Suspend movement of irradiated fuel assemblies in the spent fuel storage pool.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.7.7.1 Verify the spent fuel storage pool water level is \geq 21 ft 7 inches over the top of irradiated fuel assemblies seated in the spent fuel storage pool racks.	In accordance with the Surveillance Frequency Control Program

3.8 ELECTRICAL POWER SYSTEMS

3.8.1 AC Sources-Operating

LCO 3.8.1 The following AC electrical power sources shall be OPERABLE:

- a. Two qualified circuits between the offsite transmission network and the plant Class 1E AC Electrical Power Distribution System; and
- b. Two emergency diesel generator (EDG) subsystems.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

-----NOTE-----

LCO 3.0.4.b is not applicable to EDG subsystems.

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. One offsite circuit inoperable.</p>	<p>A.1 Perform SR 3.8.1.1 for OPERABLE offsite circuit.</p>	<p>1 hour <u>AND</u> Once per 8 hours thereafter</p>
	<p><u>AND</u> A.2 Declare required feature(s) with no offsite power available inoperable when the redundant required feature(s) are inoperable.</p>	<p>24 hours from discovery of no offsite power to one division concurrent with inoperability of redundant required feature(s)</p>
	<p><u>AND</u></p>	<p>(continued)</p>

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. (continued)	A.3 Restore offsite circuit to OPERABLE status.	7 days <u>OR</u> In accordance with the Risk Informed Completion Time Program
B. One EDG subsystem inoperable.	<p>B.1 Perform SR 3.8.1.1 for OPERABLE offsite circuit(s).</p> <p><u>AND</u></p> <p>B.2 Declare required feature(s), supported by the inoperable EDG subsystem, inoperable when the redundant required feature(s) are inoperable.</p> <p><u>AND</u></p> <p>B.3.1 Determine OPERABLE EDG subsystem is not inoperable due to common cause failure.</p> <p><u>OR</u></p> <p>B.3.2 Perform SR 3.8.1.2 for OPERABLE EDG subsystem.</p> <p><u>AND</u></p>	<p>1 hour</p> <p><u>AND</u></p> <p>Once per 8 hours thereafter</p> <p>4 hours from discovery of Condition B concurrent with inoperability of redundant required feature(s)</p> <p>24 hours</p> <p>24 hours</p> <p>(continued)</p>

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. (continued)	B.4 Restore EDG subsystem to OPERABLE status.	14 days <u>OR</u> In accordance with the Risk Informed Completion Time Program
C. Two offsite circuits inoperable.	C.1 Declare required feature(s) inoperable when the redundant required feature(s) are inoperable. <u>AND</u> C.2 Restore one offsite circuit to OPERABLE status.	12 hours from discovery of Condition C concurrent with inoperability of redundant required feature(s) 7 days <u>OR</u> In accordance with the Risk Informed Completion Time Program
D. One offsite circuit inoperable. <u>AND</u> One EDG subsystem inoperable.	----- NOTE----- Enter applicable Conditions and Required Actions of LCO 3.8.7, "Distribution Systems – Operating," when Condition D is entered with no AC power source to any division. ----- D.1 Restore Offsite circuit to OPERABLE status. <u>OR</u>	12 hours <u>OR</u> In accordance with the Risk Informed Completion Time Program (continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. (continued)	D.2 Restore EDG subsystem to OPERABLE status.	12 hours <u>OR</u> In accordance with the Risk Informed Completion Time Program
E. Two EDG subsystems inoperable.	E.1 Restore one EDG subsystem to OPERABLE status.	2 hours
F. Required Action and associated Completion Time of Condition A, B, C, D, or E not met.	F.1 Be in MODE 3. <u>AND</u> F.2 Be in MODE 4.	12 hours 36 hours
G. Three or more AC sources inoperable.	G.1 Enter LCO 3.0.3.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.8.1.1 Verify correct breaker alignment and indicated power availability for each offsite circuit.	In accordance with the Surveillance Frequency Control Program

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.8.1.2 ----- NOTE----- All EDG subsystem starts may be preceded by an engine prelube period and followed by a warmup period prior to loading. ----- Verify each EDG subsystem starts from standby conditions, force parallels, and achieves:</p> <ol style="list-style-type: none"> a. In ≤ 10 seconds, voltage ≥ 3900 V and frequency ≥ 58.8 Hz; and b. Steady state voltage ≥ 3900 V and ≤ 4400 V and frequency ≥ 58.8 Hz and ≤ 61.2 Hz. 	<p>In accordance with the Surveillance Frequency Control Program*</p>
<p>SR 3.8.1.3 ----- NOTE-----</p> <ol style="list-style-type: none"> 1. EDG loading may include gradual loading as recommended by the manufacturer. 2. Momentary transients outside the load range do not invalidate this test. 3. This Surveillance shall be conducted on only one EDG subsystem at a time. 4. This SR shall be preceded by and immediately follow, without shutdown, a successful performance of SR 3.8.1.2. <p>----- Verify each EDG subsystem is paralleled with normal, reserve, or backfeed power and each EDG is loaded and operates for ≥ 60 minutes at a load ≥ 2340 kW and ≤ 2600 kW.</p>	<p>In accordance with the Surveillance Frequency Control Program*</p>

(continued)

* The Surveillances for ST-9BA and ST-9BB is not required to be performed until following the return of the "A" RHR Pump to OPERABLE. This past due Surveillance will be completed as stated in Section 3.5 of letter JAFP-21-0053, dated June 14, 2021.

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.8.1.4	Verify each day tank contains ≥ 327 gal of fuel oil.	In accordance with the Surveillance Frequency Control Program*
SR 3.8.1.5	Check for and remove accumulated water from each day tank	In accordance with the Surveillance Frequency Control Program*
SR 3.8.1.6	Verify that each EDG fuel oil transfer system operates to automatically transfer fuel oil from its storage tank to the associated day tank.	In accordance with the Surveillance Frequency Control Program*
SR 3.8.1.7	<p>----- NOTE-----</p> <p>Only required to be met for each offsite circuit that is not energizing its respective 4.16 kV emergency bus.</p> <p>-----</p> <p>Verify automatic and manual transfer of plant power supply from the normal station service transformer to each offsite circuit.</p>	In accordance with the Surveillance Frequency Control Program
SR 3.8.1.8	<p>----- NOTE-----</p> <p>If performance with EDG subsystem paralleled with normal, reserve, or backfeed power, it shall be performed within the power factor limit. However, if grid conditions do not permit, the power factor limit is not required to be met. Under this condition, the power factor shall be maintained as close to the limit as practicable.</p> <p>-----</p> <p>Verify each EDG subsystem rejects a load greater than or equal to its associated single largest post-accident load, and following load rejection, the frequency is ≤ 66.75 Hz.</p>	In accordance with the Surveillance Frequency Control Program

(continued)

* The Surveillances for ST-9AA, ST-9BB, ST-9BA, and ST-9BA is not required to be performed until following the return of the "A" RHR pump to OPERABLE. This past due Surveillance will be completed as stated in Section 3.5 of letter JAFP-21-0053, dated June 14, 2021.

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.8.1.9 ----- NOTE----- All EDG subsystem starts may be preceded by an engine prelube period. -----</p> <p>Verify on an actual or simulated loss of power signal:</p> <ul style="list-style-type: none"> a. De-energization of emergency buses; b. Load shedding from emergency buses; and c. EDG subsystem auto-starts from standby condition, force parallels, and: <ul style="list-style-type: none"> 1. energizes permanently connected loads in ≤ 11 seconds, 2. energizes auto-connected shutdown loads, 3. maintains steady state voltage ≥ 3900 V and ≤ 4400 V, 4. maintains steady state frequency ≥ 58.8 Hz and ≤ 61.2 Hz, and 5. supplies permanently connected and auto-connected shutdown loads for ≥ 5 minutes. 	<p>In accordance with the Surveillance Frequency Control Program</p>

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.8.1.10 ----- NOTE-----</p> <p>All EDG subsystem starts may be preceded by an engine prelube period.</p> <p>-----</p> <p>Verify on an actual or simulated Emergency Core Cooling System (ECCS) initiation signal each EDG subsystem auto-starts from standby condition, force parallels, and:</p> <ul style="list-style-type: none"> a. In ≤ 10 seconds after auto-start and during tests, achieves voltage ≥ 3900 V, frequency ≥ 58.8 Hz; b. Achieves steady state voltage ≥ 3900 V and ≤ 4400 V and frequency ≥ 58.8 Hz and ≤ 61.2 Hz; c. Operates for ≥ 5 minutes; d. Permanently connected loads remain energized from the offsite power system; and e. Emergency loads are auto-connected in the prescribed sequence from the offsite power system. 	<p>In accordance with the Surveillance Frequency Control Program</p>

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.8.1.11 ----- NOTE-----</p> <p>Momentary transients outside the load and power factor ranges do not invalidate this test.</p> <p>If grid conditions do not permit, the power factor limit is not required to be met. Under this condition, the power factor shall be maintained as close to the limit as practicable.</p> <p>-----</p> <p>Verify each EDG subsystem operating within the power factor limit operates for ≥ 8 hours:</p> <ul style="list-style-type: none"> a. For ≥ 2 hours each EDG loaded ≥ 2730 kW and ≤ 2860 kW; and b. For the remaining hours of the test each EDG loaded ≥ 2340 kW and ≤ 2600 kW. 	<p>In accordance with the Surveillance Frequency Control Program</p>

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.8.1.12 ----- NOTE----- All EDG subsystem starts may be preceded by an engine prelube period. -----</p> <p>Verify, on an actual or simulated loss of power signal in conjunction with an actual or simulated ECCS initiation signal:</p> <ul style="list-style-type: none"> a. De-energization of emergency buses; b. Load shedding from emergency buses; and c. EDG subsystem auto-starts from standby condition, force parallels, and: <ul style="list-style-type: none"> 1. energizes permanently connected loads in ≤ 11 seconds, 2. energizes auto-connected emergency loads in the prescribed sequence, 3. achieves steady state voltage ≥ 3900 V and ≤ 4400 V, 4. achieves steady state frequency ≥ 58.8 Hz and ≤ 61.2 Hz, and 5. supplies permanently connected and auto-connected emergency loads for ≥ 5 minutes. 	<p>In accordance with the Surveillance Frequency Control Program</p>
<p>SR 3.8.1.13 Verify interval between each sequenced load block is greater than or equal to the minimum design load interval.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>

3.8 ELECTRICAL POWER SYSTEMS

3.8.2 AC Sources - Shutdown

LCO 3.8.2 The following AC electrical power sources shall be OPERABLE:

- a. One qualified circuit between the offsite transmission network and one division of the plant Class 1E AC electrical power distribution subsystem(s) required by LCO 3.8.8. "Distribution Systems - Shutdown";
- b. One qualified circuit, which maybe the same circuit required by LCO 3.8.2.a. between the offsite transmission network and the other division of the plant Class 1E AC electrical power distribution subsystem(s), when a second division is required by LCO 3.8.8; and
- c. One emergency diesel generator (EDG) subsystem capable of supplying one division of the plant Class 1E AC electrical power distribution subsystem(s) required by LCO 3.8.8.

APPLICABILITY: MODES 4 and 5.
During movement of recently irradiated fuel assemblies in
the secondary containment. |

ACTIONS

-----NOTE-----

LCO 3.0.3 is not applicable.

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. One or both required offsite circuits inoperable.</p>	<p>-----NOTE----- Enter applicable Condition and Required Actions of LCO 3.8.8, when any required division is de-energized as a result of Condition A.</p> <hr/> <p>A.1 Declare affected required feature(s), with no offsite power available, inoperable.</p> <p><u>OR</u></p> <p>A.2.1 Suspend CORE ALTERATIONS.</p> <p><u>AND</u></p> <p>A.2.2 Suspend movement of recently irradiated fuel assemblies in the secondary containment.</p> <p><u>AND</u></p>	<p>Immediately</p> <p>Immediately</p> <p>Immediately</p> <p>(continued)</p>

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. (continued)	A.2.3 Initiate action to restore required offsite power circuit(s) to OPERABLE status.	Immediately
B. One required EDG subsystem inoperable.	B.1 Suspend CORE ALTERATIONS.	Immediately
	<u>AND</u>	
	B.2 Suspend movement of recently irradiated fuel assemblies in secondary containment.	Immediately
	<u>AND</u>	
	B.3 Initiate action to restore required EDG subsystem to OPERABLE status.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.8.2.1</p> <p>-----NOTES-----</p> <p>The following SRs are not required to be performed: SR 3.8.1.3, SR 3.8.1.8, and SR 3.8.1.11.</p> <p>-----</p> <p>For following SRs are applicable for AC sources required to be OPERABLE: SR 3.8.1.1, SR 3.8.1.2, SR 3.8.1.3, SR 3.8.1.4, SR 3.8.1.5, SR 3.8.1.6, SR 3.8.1.8, and SR 3.8.1.11.</p>	<p>In accordance with applicable SRs</p>

3.8 ELECTRICAL POWER SYSTEMS

3.8.3 Diesel Fuel Oil, Lube Oil, and Starting Air

LCO 3.8.3 The stored diesel fuel oil, lube oil, and starting air subsystem shall be within limits for each required emergency diesel generator (EDG).

APPLICABILITY: When associated EDG subsystem is required to be OPERABLE

ACTIONS

----- NOTE -----
Separate Condition entry is allowed for each EDG.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more EDGs with fuel oil level < a 7 day supply and > a 6 day supply in storage tank.	A.1 Restore fuel oil level to within limits.	48 hours
B. One or more EDGs with lube oil inventory < a 7 day supply and > a 6 day supply.	B.1 Restore lube oil inventory to within limits.	48 hours
C. One or more EDGs with stored fuel oil total particulates not within limit.	C.1 Restore stored fuel oil total particulates to within limit.	7 days

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. One or more EDGs with new fuel oil properties not within limits.	D.1 Restore stored fuel oil properties to within limit.	30 days
E. One or more EDGs with required starting air receiver pressure < 150 psig and ≥ 110 psig.	E.1 Restore required starting air receiver pressure to within limits.	48 hours
F. Requires Action and associated Completion Time of Condition A, B, C, D, or E not met. <u>OR</u> One or more EDGs with diesel fuel oil, lube oil, or starting air subsystem not within limits for reasons other than condition A, B, C, D, or E.	F.1 Declare associated EDG inoperable.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.8.3.1 Verify each fuel oil storage tank contains ≥ a 7 day supply of fuel.	In accordance with the Surveillance Frequency Control Program*

(continued)

* This Surveillance for ST-9AA and ST-9BB is not required to be performed until following the return of the “A” RHR pump to OPERABLE. This past due Surveillance will be completed as stated in Section 3.5 of letter JAFP-21-0053, dated June 14, 2021.

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.8.3.2	Verify lube oil inventory of each EDG is \geq a 7 day supply.	In accordance with the Surveillance Frequency Control Program*
SR 3.8.3.3	Verify fuel oil properties of new and stored fuel oil are tested in accordance with, and maintained within the limits of, the diesel Fuel Oil Testing Program.	In accordance with the Diesel Fuel Oil Testing Program
SR 3.8.3.4	Verify Each EDG required air start receiver pressure is \geq 150 psig.	In accordance with the Surveillance Frequency Control Program*
SR 3.8.3.5	Check for and remove accumulated water from each fuel oil storage tank.	In accordance with the Surveillance Frequency Control Program

* This Surveillance for ST-9AA and ST-9BB is not required to be performed until following the return of the "A" RHR pump to OPERABLE. This past due Surveillance will be completed as stated in Section 3.5 of letter JAFP-21-0053, dated June 14, 2021.

3.8 ELECTRICAL POWER SYSTEMS

3.8.4 DC Sources - Operating

LCO 3.8.4 The following DC electrical power subsystems shall be OPERABLE:

- a. Two 125 VDC subsystems; and
- b. Two 419 VDC low pressure coolant injection (LPCI) MOV independent power supply subsystems.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One battery charger on One 125 VDC power subsystem inoperable.	A.1 Restore battery terminal voltage to greater than or equal to the minimum established float voltage (127.8 VDC).	2 hours
	<u>AND</u>	
	A.2 Verify battery float current ≤ 2 amps.	Once per 12 hours
	<u>AND</u>	
	A.3 Restore battery charger to OPERABLE status.	7 days
		<u>OR</u> In accordance with the Risk Informed Completion Time Program

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>B. One 125 VDC electrical power subsystem inoperable for reasons other than Condition A.</p>	<p>B.1 Restore 125 VDC electrical power subsystem to OPERABLE status.</p>	<p>8 hours <u>OR</u> In accordance with the Risk Informed Completion Time Program</p>
<p>C. Required Action and associated Completion Time of Condition A or B not met.</p>	<p>C.1 Be in MODE 3. <u>AND</u> C.2 Be in MODE 4.</p>	<p>12 hours 36 hours</p>
<p>D. One or both 419 VDC LPCI MOV independent power supply subsystems inoperable.</p>	<p>D.1 Declare associated LPCI subsystem(s) inoperable.</p>	<p>Immediately</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.8.4.1	<p>Verify battery terminal voltage on float charge is:</p> <p>a. ≥ 127.8 VDC for 125 VDC batteries, and</p> <p>b. ≥ 396.2 VDC for 419 VDC LPCI MOV independent power supply batteries.</p>	In accordance with the Surveillance Frequency Control Program*
SR 3.8.4.2	<p>Verify each 125 VDC battery charger supplies ≥ 270 amps at ≥ 128 VDC for ≥ 4 hours.</p> <p><u>OR</u></p> <p>Verify each 125 VDC battery charger can recharge the battery to the fully charged state within 24 hours while supplying the largest combined demands of the various continuous steady state loads, after a battery discharge to the bounding design basis event discharge state.</p>	In accordance with the Surveillance Frequency Control Program
SR 3.8.4.3	<p>----- NOTE -----</p> <p>This Surveillance shall not normally be performed in MODE 1, 2, or 3 for the 125 VDC batteries. However, portions of the Surveillance may be performed to reestablish OPERABILITY provided an assessment determines the safety of the plant is maintained or enhanced. Credit may be taken for unplanned events that satisfy this SR.</p> <p>-----</p> <p>Verify battery capacity is adequate to supply, and maintain in OPERABLE status, the required emergency loads for the design duty cycle when subjected to a battery service test or a modified performance discharge test.</p>	In accordance with the Surveillance Frequency Control Program

(continued)

* This Surveillance for MST-071.10 is not required to be performed until following the return of the "A" RHR pump to OPERABLE. This past due Surveillance will be completed as stated in Section 3.5 of letter JAFP-21-0053, dated June 14, 2021.

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.8.4.4 ----- NOTE ----- This Surveillance shall not normally be performed in MODE 1, 2, or 3 for the 125 VDC batteries. However, portions of the Surveillance may be performed to reestablish OPERABILITY provided an assessment determines the safety of the plant is maintained or enhanced. Credit may be taken for unplanned events that satisfy this SR. -----</p> <p>Verify battery capacity is $\geq 80\%$ of the manufacturer's rating when subjected to a performance discharge test or a modified performance discharge test.</p>	<p>In accordance with the Surveillance Frequency Control Program</p> <p><u>AND</u></p> <p>12 months when battery shows degradation or has reached 85% of expected life with capacity < 100% of manufacturer's rating</p> <p><u>AND</u></p> <p>24 months when battery has reached 85% of the expected life with capacity $\geq 100\%$ of manufacturer's rating</p>

3.8 ELECTRICAL POWER SYSTEMS

3.8.5 DC Sources - Shutdown

LCO 3.8.5 One 125 VDC electrical power subsystem shall be OPERABLE to support one division of the plant Class IE DC Electrical Power Distribution System required by LCO 3.8.8. "Distribution Systems-Shutdown."

APPLICABILITY: MODES 4 and 5,
During movement of recently irradiated fuel assemblies in the secondary containment.

ACTIONS

.....NOTE.....
LCO 3.0.3 is not applicable.
.....

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Required DC electrical power subsystem inoperable.	A.1 Declare affected required feature(s) inoperable.	Immediately
	<u>OR</u>	
	A.2.1 Suspend CORE ALTERATIONS.	Immediately
	<u>AND</u>	
	A.2.2 Suspend movement of recently irradiated fuel assemblies in the secondary containment.	Immediately
	<u>AND</u>	
		(continued)

ACTIONS

CONDITIONS	REQUIRED ACTION	COMPLETION TIME
A. (continued)	A.2.3 Initiate action to restore required DC electrical power subsystem to OPERABLE status.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.8.5.1 ----- NOTE-----</p> <p>The following SRs are not required to be performed: SR 3.8.4.2, SR 3.8.4.3, and SR 3.8.4.4.</p> <p>-----</p> <p>For DC electrical power subsystem required to be OPERABLE the following SRs are applicable:</p> <p>SR 3.8.4.1, SR 3.8.4.2, SR 3.8.4.3, and SR 3.8.4.4.</p>	<p>In accordance with applicable SRs*</p>

* This Surveillance for MST-071.12 is not required to be performed following the return of the "A" RHR pump to OPERABLE. This past due Surveillance will be completed as stated in Section 3.5 of letter JAFP-21-0053, dated June 14, 2021.

3.8 ELECTRICAL POWER SYSTEMS

3.8.6 Battery Cell Parameters

LCO 3.8.6 Battery cell parameters for the 125 VDC and 419 VDC LPCI MOV independent power supply batteries shall be within the limits of Table 3.8.6-1.

AND

Battery cell average electrolyte temperature for the 125 VDC and 419 VDC LPCI MOV independent power supply batteries shall be within required limits.

APPLICABILITY: When associated DC electrical power subsystems are required to be OPERABLE.

ACTIONS

-----NOTE-----

Separate Condition entry is allowed for each battery.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more batteries with one or more battery cell parameters not within Category A or B limits.	A.1 Verify pilot cells electrolyte level and float voltage meet Table 3.8.6-1 Category C limits.	1 hour
	<u>AND</u>	
	A.2 Verify battery cell parameters meet Table 3.8.6-1 Category C limits.	24 hours <u>AND</u> Once per 7 days thereafter
	<u>AND</u>	(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. (continued)	A.3 Restore battery cell parameters to Category A and B limits of Table 3.8.6-1.	31 days
B. Required Action and associated Completion Time of Condition A not met. <u>OR</u> One or more batteries with average electrolyte temperature of the representative cells not within limits. <u>OR</u> One or more batteries with one or more battery cell parameters not within Category C limits.	B.1 Declare associated battery inoperable.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.8.6.1 Verify battery cell parameters meet Table 3.8.6-1 Category A limits.	In accordance with the Surveillance Frequency Control Program*

(continued)

* This Surveillance for MST-071.10 and MST-071.12 is not required to be performed until following the return of the "A" RHR pump to OPERABLE. This past due Surveillance will be completed as stated in Section 3.5 of letter JAFP-21-0053, dated June 14, 2021.

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.8.6.2	Verify battery cell parameters meet Table 3.8.6-1 Category B limits.	In accordance with the Surveillance Frequency Control Program*
SR 3.8.6.3	Verify average electrolyte temperature of representative cells is $\geq 65^{\circ}\text{F}$ for each 125 VDC battery, and $\geq 50^{\circ}\text{F}$ for each 419 VDC LPCI MOV independent power supply battery.	In accordance with the Surveillance Frequency Control Program*

* This Surveillance for MST-071.11 and MST-071.13 is not required to be performed until following the return of the "A" RHR pump to OPERABLE. This past due Surveillance will be completed as stated in Section 3.5 of letter JAFP-21-0053, dated June 14, 2021.

Table 3.8.6-1 (page 1 of 1)
Battery Cell Parameter Requirements

PARAMETER	CATEGORY A: LIMITS FOR EACH DESIGNATED PILOT CELL	CATEGORY B: LIMITS FOR EACH CONNECTED CELL	CATEGORY C: LIMITS FOR EACH CONNECTED CELL
Electrolyte Level	> Minimum level indication mark, and $\leq \frac{1}{4}$ inch above maximum level indication mark(a)	> Minimum level indication mark, and $\leq \frac{1}{4}$ inch above maximum level indication mark(a)	Above top of plates, and not overflowing
Float Voltage	≥ 2.13 V	≥ 2.13 V	> 2.07 V
Specific Gravity ^{(b)(c)}	≥ 1.195	≥ 1.195 <u>AND</u> Average of all connected cells > 1.205	Not more than 0.020 below average of all connected cells <u>AND</u> Average of all connected cells ≥ 1.195

- (a) It is acceptable for the electrolyte level to temporarily increase above the specified maximum level during and, for a limited time, following equalizing charges provided it is not overflowing.
- (b) Corrected for electrolyte temperature and level. Level correction is not required, however, when on float charge and battery charging current is < 2 amps for 125 VDC batteries and < 1 amp for 419 VDC LPCI MOV independent power supply batteries.
- (c) A battery charging current of < 2 amps for 125 VDC batteries and < 1 amp for 419 VDC LPCI MOV independent power supply batteries when on float charge is acceptable for meeting specific gravity limits following a battery recharge, for a maximum of 7 days. When charging current is used to satisfy specific gravity requirements, specific gravity of each connected cell shall be measured prior to expiration of the 7 day allowance.

3.8 ELECTRICAL POWER SYSTEMS

3.8.7 Distribution Systems - Operating

LCO 3.8.7 The Division 1 and Division 2 AC and 125 VDC electrical power distribution subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. One or more AC electrical power distribution subsystems inoperable.</p>	<p>A.1 Restore AC electrical power distribution subsystems to OPERABLE status.</p>	<p>8 hours</p> <p><u>OR</u></p> <p>-----NOTE----- Not applicable when loss of function can occur -----</p> <p>In accordance with the Risk Informed Completion Time Program</p>
<p>B. One 125 VDC electrical power distribution subsystem inoperable.</p>	<p>B.1 Restore 125 VDC electrical power distribution subsystems to OPERABLE status.</p>	<p>8 hours</p> <p><u>OR</u></p> <p>-----NOTE----- Not applicable when loss of function can occur -----</p> <p>In accordance with the Risk Informed Completion Time Program</p>

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. Required Action and associated Completion Time of Condition A or B not met.	C.1 Be in MODE 3.	12 hours
	<u>AND</u> C.2 Be in MODE 4.	36 hours
D. Two or more electrical power distribution subsystems inoperable that result in a loss of function.	D.1 Enter LCO 3.0.3.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.8.7.1 Verify correct breaker alignments and voltage to required AC and 125 VDC electrical power distribution subsystems.	In accordance with the Surveillance Frequency Control Program

3.8 ELECTRICAL POWER SYSTEMS

3.8.8 Distribution Systems - Shutdown

LCO 3.8.8 The necessary portions of the AC and 125 VDC electrical power distribution subsystems shall be OPERABLE to support equipment required to be OPERABLE.

APPLICABILITY: MODES 4 and 5.
During movement of recently irradiated fuel assemblies in the secondary containment.

ACTIONS

-----NOTE-----
LCO 3.0.3 is not applicable.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more required AC or 125 VDC electrical power distribution subsystems inoperable.	A.1 Declare associated supported required feature(s) inoperable.	Immediately
	<u>OR</u>	
	A.2.1 Suspend CORE ALTERATIONS.	Immediately
	<u>AND</u>	
	A.2.2 Suspend movement of recently irradiated fuel assemblies in the secondary containment.	Immediately
	<u>AND</u>	
		(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. (continued)	A.2.3 Initiate actions to restore required AC and 125 VDC electrical power distribution subsystems to OPERABLE status.	Immediately
	<u>AND</u> A.2.4 Declare associated required shutdown cooling subsystem(s) inoperable.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.8.8.1 Verify correct breaker alignments and voltage to required AC and 125 VDC electrical power distribution subsystems.	In accordance with the Surveillance Frequency Control Program

3.9 REFUELING OPERATIONS

3.9.1 Refueling Equipment Interlocks

LCO 3.9.1 The refueling equipment interlocks associated with the reactor mode switch in the refuel position shall be OPERABLE.

APPLICABILITY: During in-vessel fuel movement with equipment associated with the interlocks when the reactor mode switch is in the refuel position.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. One or more required refueling equipment interlocks inoperable.</p>	<p>A.1 Suspend in-vessel fuel movement with equipment associated with the inoperable interlock(s).</p>	<p>Immediately</p>
	<p><u>OR</u></p>	
	<p>A.2.1 Insert a control rod withdrawal block.</p> <p><u>AND</u></p> <p>A.2.2 Verify all control rods are fully inserted.</p>	<p>Immediately</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.9.1.1	<p>Perform CHANNEL FUNCTIONAL TEST on each of the following required refueling equipment interlock inputs:</p> <ul style="list-style-type: none"> a. All-rods-in, b. Refuel platform position, c. Refuel platform fuel grapple, fuel loaded, d. Refuel platform fuel grapple not fully up, e. Refuel platform frame mounted hoist, fuel loaded, and f. Refuel platform trolley mounted (monorail) hoist, fuel loaded. 	<p>In accordance with the Surveillance Frequency Control Program</p>

3.9 REFUELING OPERATIONS

3.9.2 Refuel Position One-Rod-Out Interlock

LCO 3.9.2 The refuel position one-rod-out interlock shall be OPERABLE.

APPLICABILITY: MODE 5 with the reactor mode switch in the refuel position and any control rod withdrawn.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Refuel position one-rod-out interlock inoperable.	A.1 Suspend control rod withdrawal.	Immediately
	<u>AND</u>	
	A.2 Initiate action to fully insert all insertable control rods in core cells containing one or more fuel assemblies.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.9.2.1 Verify reactor mode switch locked in refuel position.	In accordance with the Surveillance Frequency Control Program
SR 3.9.2.2 ----- <u>NOTE</u> ----- Not required to be performed until 1 hour after any control rod is withdrawn. ----- Perform CHANNEL FUNCTIONAL TEST.	In accordance with the Surveillance Frequency Control Program

3.9 REFUELING OPERATIONS

3.9.3 Control Rod Position

LCO 3.9.3 All control rods shall be fully inserted.

APPLICABILITY: When loading fuel assemblies into the core.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more control rods not fully inserted.	A.1 Suspend loading fuel assemblies into the core.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.9.3.1 Verify all control rods are fully inserted.	In accordance with the Surveillance Frequency Control Program

3.9 REFUELING OPERATIONS

3.9.4 Control Rod Position Indication

LCO 3.9.4 The control rod "full-in" position indication channel for each control rod shall be OPERABLE.

APPLICABILITY: MODE 5.

ACTIONS

-----NOTE-----
Separate Condition entry is allowed for each channel.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more control rod position indication channels inoperable.	A.1.1 Suspend in-vessel fuel movement.	Immediately
	<u>AND</u>	
	A.1.2 Suspend control rod withdrawal.	Immediately
	<u>AND</u>	
	A.1.3 Initiate action to fully insert all insertable control rods in core cells containing one or more fuel assemblies.	Immediately
	<u>OR</u>	
		(continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. (continued)	A.2.1 Initiate action to fully insert the control rod associated with the inoperable position indicator. <u>AND</u> A.2.2 Initiate action to disarm the control rod drive associated with the fully inserted control rod.	Immediately Immediately

SURVEILLANCE REQUIREMENT

SURVEILLANCE	FREQUENCY
SR 3.9.4.1 Verify the channel has no "full-in" indication on each control rod that is not "full-in."	Each time the control rod is withdrawn from the "full-in" position

3.9 REFUELING OPERATIONS

3.9.5 Control Rod OPERABILITY – Refueling

LCO 3.9.5 Each withdrawn control rod shall be OPERABLE.

APPLICABILITY: MODE 5.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more withdrawn control rods inoperable.	A.1 Initiate action to fully insert inoperable withdrawn control rods.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.9.5.1</p> <p>----- NOTE ----- Not required to be performed until 7 days after the control rod is withdrawn. -----</p> <p>Insert each withdrawn control rod at least one notch.</p>	In accordance with the Surveillance Frequency Control Program
<p>SR 3.9.5.2</p> <p>Verify each withdrawn control rod scram accumulator pressure is ≥ 940 psig.</p>	In accordance with the Surveillance Frequency Control Program

3.9 REFUELING OPERATIONS

3.9.6 Reactor Pressure Vessel (RPV) Water Level

LCO 3.9.6 RPV water level shall be \geq 22 ft 2 inches above the top of the RPV flange.

APPLICABILITY: During movement of irradiated fuel assemblies within the RPV,
During movement of new fuel assemblies or handling of control rods within
the RPV, when irradiated fuel assemblies are seated within the RPV.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. RPV water level not within limit.	A.1 Suspend movement of fuel assemblies and handling of control rods within the RPV.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.9.6.1 Verify RPV water level is \geq 22 ft 2 inches above the top of the RPV flange.	In accordance with the Surveillance Frequency Control Program

3.9 REFUELING OPERATIONS

3.9.7 Residual Heat Removal (RHR) - High Water Level

LCO 3.9.7 One RHR shutdown cooling subsystem shall be OPERABLE.

APPLICABILITY: MODE 5 with irradiated fuel in the reactor pressure vessel (RPV) and the water level \geq 22 ft 2 inches above the top of the RPV flange.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Required RHR shutdown cooling subsystem inoperable.	A.1 Verify an alternate method of decay heat removal is available.	1 hour <u>AND</u> Once per 24 hours thereafter
B. Required Action and associated Completion Time of Condition A not met.	B.1 Suspend loading irradiated fuel assemblies into the RPV. <u>AND</u> B.2 Initiate action to restore secondary containment to OPERABLE status. <u>AND</u>	Immediately Immediately (continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. (continued)	B.3 Initiate action to restore one standby gas treatment subsystem to OPERABLE status.	Immediately
	<p><u>AND</u></p> <p>B.4 Initiate action to restore isolation capability in each required secondary containment penetration flow path not isolated.</p>	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.9.7.1 Verify each required RHR shutdown cooling subsystem manual, power operated, and automatic valve in the flow path that is not locked, sealed, or otherwise secured in position, is in the correct position, or can be aligned to the correct position.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>

3.9 REFUELING OPERATIONS

3.9.8 Residual Heat Removal (RHR) - Low Water Level

LCO 3.9.8 Two RHR shutdown cooling subsystems shall be OPERABLE.

APPLICABILITY: MODE 5 with irradiated fuel in the reactor pressure vessel (RPV) and the water level < 22 ft 2 inches above the top of the RPV flange.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or two required RHR shutdown cooling subsystems inoperable.	A.1 Verify an alternate method of decay heat removal is available for each inoperable required RHR shutdown cooling subsystem.	1 hour <u>AND</u> Once per 24 hours thereafter
B. Required Action and associated Completion Time of Condition A not met.	B.1 Initiate action to restore secondary containment to OPERABLE status. <u>AND</u> B.2 Initiate action to restore one standby gas treatment subsystem to OPERABLE status. <u>AND</u>	Immediately Immediately (continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. (continued)	B.3 Initiate action to restore isolation capability in each required secondary containment penetration flow path not isolated.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.9.8.1 Verify each RHR shutdown cooling subsystem manual, power operated, and automatic valve in the flow path that is not locked, sealed, or otherwise secured in position, is in the correct position, or can be aligned to the correct position.	In accordance with the Surveillance Frequency Control Program

3.10 SPECIAL OPERATIONS

3.10.1 Inservice Leak and Hydrostatic Testing Operation

LCO 3.10.1 The average reactor coolant temperature specified in Table 1.1-1 for MODE 4 may be changed to "NA," and operation considered not to be in MODE 3; and the requirements of LCO 3.4.8, "Residual Heat Removal (RHR) Shutdown Cooling System—Cold Shutdown," may be suspended to allow reactor coolant temperature > 212°F:

- For performance of an inservice leak or hydrostatic test,
- As a consequence of maintaining adequate pressure for an inservice leak or hydrostatic test, or
- As a consequence of maintaining adequate pressure for control rod scram time testing initiated in conjunction with an inservice leak or hydrostatic test,

provided the following MODE 3 LCOs are met:

- a. LCO 3.3.6.2, "Secondary Containment Isolation Instrumentation," Functions 1, 3, and 4 of Table 3.3.6.2-1;
- b. LCO 3.6.4.1, "Secondary Containment";
- c. LCO 3.6.4.2, "Secondary Containment Isolation Valves (SCIVs)";
and
- d. LCO 3.6.4.3, "Standby Gas Treatment (SGT) System."

APPLICABILITY: MODE 4 with average reactor coolant temperature > 212°F.

ACTIONS

-----NOTE-----
Separate Condition entry is allowed for each requirement of the LCO.

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. One or more of the above requirements not met.</p>	<p>A.1 -----NOTE----- Required Actions to be in MODE 4 include reducing average reactor coolant temperature to $\leq 212^{\circ}\text{F}$. ----- Enter the applicable Condition of the affected LCO.</p>	<p>Immediately</p>
	<p><u>OR</u></p> <p>A.2.1 Suspend activities that could increase the average reactor coolant temperature or pressure.</p>	<p>Immediately</p>
	<p><u>AND</u></p> <p>A.2.2 Reduce average reactor coolant temperature to $\leq 212^{\circ}\text{F}$.</p>	<p>24 hours</p>

Inservice Leak and Hydrostatic Testing Operation
3.10.1

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.10.1.1 Perform the applicable SRs for the required MODE 3 LCOs.	According to the applicable SRs

3.10 SPECIAL OPERATIONS

3.10.2 Reactor Mode Switch Interlock Testing

LCO 3.10.2 The reactor mode switch position specified in Table 1.1-1 for MODES 3, 4, and 5 may be changed to include the run, startup/hot standby, and refuel position, and operation considered not to be in MODE 1 or 2, to allow testing of instrumentation associated with the reactor mode switch interlock functions, provided:

- a. All control rods remain fully inserted in core cells containing one or more fuel assemblies; and
- b. No CORE ALTERATIONS are in progress.

APPLICABILITY: MODES 3 and 4 with the reactor mode switch in the run, startup/hot standby, or refuel position.
MODE 5 with the reactor mode switch in the run or startup/hot standby position.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more of the above requirements not met.	A.1 Suspend CORE ALTERATIONS except for control rod insertion.	Immediately
	<u>AND</u>	
	A.2 Fully insert all insertable control rods in core cells containing one or more fuel assemblies.	1 hour
	<u>AND</u>	(continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. (continued)	A.3.1 Place the reactor mode switch in the shutdown position.	1 hour
	<u>OR</u>	
	A.3.2 ----- NOTE ----- Only applicable in MODE 5. ----- Place the reactor mode switch in the refuel position.	1 hour

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.10.2.1 Verify all control rods are fully inserted in core cells containing one or more fuel assemblies.	In accordance with the Surveillance Frequency Control Program
SR 3.10.2.2 Verify no CORE ALTERATIONS are in progress.	In accordance with the Surveillance Frequency Control Program

3.10 SPECIAL OPERATIONS

3.10.3 Single Control Rod Withdrawal - Hot Shutdown

LCO 3.10.3 The reactor mode switch position specified in Table 1.1-1 for MODE 3 may be changed to include the refuel position, and operation considered not to be in MODE 2, to allow withdrawal of a single control rod, provided the following requirements are met:

- a. LCO 3.9.2, "Refuel Position One-Rod-Out Interlock";
- b. LCO 3.9.4, "Control Rod Position Indication";
- c. All other control rods are fully inserted; and
- d. 1. LCO 3.3.1.1, "Reactor Protection System (RPS) Instrumentation," MODE 5 requirements for Functions 1.a, 1.b, 7.a, 7.b, 10, and 11 of Table 3.3.1.1-1, and
LCO 3.9.5, "Control Rod OPERABILITY - Refueling."

OR

2. All other control rods in a five by five array centered on the control rod being withdrawn are disarmed; at which time LCO 3.1.1, "SHUTDOWN MARGIN (SDM)," MODE 3 requirements, may be changed to allow the single control rod withdrawn to be assumed to be the highest worth control rod.

APPLICABILITY: MODE 3 with the reactor mode switch in the refuel position.

ACTIONS

-----NOTE-----
Separate Condition entry is allowed for each requirement of the LCO.

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. One or more of the above requirements not met.</p>	<p>A.1 -----NOTES----- 1. Required Actions to fully insert all insertable control rods include placing the reactor mode switch in the shutdown position. 2. Only applicable if the requirement not met is a required LCO. ----- Enter the applicable Condition of the affected LCO.</p>	<p>Immediately</p>
	<p><u>OR</u> A.2.1 Initiate action to fully insert all insertable control rods.</p>	<p>Immediately</p>
	<p><u>AND</u> A.2.2 Place the reactor mode switch in the shutdown position.</p>	<p>1 hour</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.10.3.1	Perform the applicable SRs for the required LCOs.	According to the applicable SRs
SR 3.10.3.2	<p style="text-align: center;">----- NOTE ----- Not required to be met if SR 3.10.3.1 is satisfied for LCO 3.10.3.d.1 requirements. -----</p> <p>Verify all control rods, other than the control rod being withdrawn, in a five by five array centered on the control rod being withdrawn, are disarmed.</p>	In accordance with the Surveillance Frequency Control Program
SR 3.10.3.3	Verify all control rods, other than the control rod being withdrawn, are fully inserted.	In accordance with the Surveillance Frequency Control Program

3.10 SPECIAL OPERATIONS

3.10.4 Single Control Rod Withdrawal – Cold Shutdown

LCO 3.10.4 The reactor mode switch position specified in Table 1.1-1 for MODE 4 may be changed to include the refuel position, and operation considered not to be in MODE 2, to allow withdrawal of a single control rod, and subsequent removal of the associated control rod drive (CRD) if desired, provided the following requirements are met:

- a. All other control rods are fully inserted;
- b. 1. LCO 3.9.2, "Refuel Position One-Rod-Out Interlock," and
LCO 3.9.4, "Control Rod Position Indication,"

OR

- 2. A control rod withdrawal block is inserted;
- c. 1. LCO 3.3.1.1, "Reactor Protection System (RPS) Instrumentation," MODE 5 requirements for Functions 1.a, 1.b, 7.a, 7.b, 10, and 11 of Table 3.3.1.1-1, and
LCO 3.9.5, "Control Rod OPERABILITY – Refueling,"

OR

- 2. All other control rods in a five by five array centered on the control rod being withdrawn are disarmed; at which time LCO 3.1.1, "SHUTDOWN MARGIN (SDM)," MODE 4 requirements, may be changed to allow the single control rod withdrawn to be assumed to be the highest worth control rod.

APPLICABILITY: MODE 4 with the reactor mode switch in the refuel position.

ACTIONS

-----NOTE-----
Separate Condition entry is allowed for each requirement of the LCO.

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. One or more of the above requirements not met with the affected control rod insertable.</p>	<p>A.1 -----NOTES----- 1. Required Actions to fully insert all insertable control rods include placing the reactor mode switch in the shutdown position. 2. Only applicable if the requirement not met is a required LCO. ----- Enter the applicable Condition of the affected LCO.</p>	<p>Immediately</p>
	<p><u>OR</u> A.2.1 Initiate action to fully insert all insertable control rods.</p>	<p>Immediately</p>
	<p><u>AND</u> A.2.2 Place the reactor mode switch in the shutdown position.</p>	<p>1 hour</p>

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. One or more of the above requirements not met with the affected control rod not insertable.	B.1 Suspend withdrawal of the control rod and removal of associated CRD.	Immediately
	<u>AND</u>	
	B.2.1 Initiate action to fully insert all control rods.	Immediately
	<u>OR</u>	
	B.2.2 Initiate action to satisfy the requirements of this LCO.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.10.4.1 Perform the applicable SRs for the required LCOs.	According to the applicable SRs
SR 3.10.4.2 ----- NOTE ----- Not required to be met if SR 3.10.4.1 is satisfied for LCO 3.10.4.c.1 requirements. ----- Verify all control rods, other than the control rod being withdrawn, in a five by five array centered on the control rod being withdrawn, are disarmed.	In accordance with the Surveillance Frequency Control Program

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.10.4.3	Verify all control rods, other than the control rod being withdrawn, are fully inserted.	In accordance with the Surveillance Frequency Control Program
SR 3.10.4.4	<p>----- NOTE ----- Not required to be met if SR 3.10.4.1 is satisfied for LCO 3.10.4.b.1 requirements. -----</p> <p>Verify a control rod withdrawal block is inserted.</p>	In accordance with the Surveillance Frequency Control Program

3.10 SPECIAL OPERATIONS

3.10.5 Single Control Rod Drive (CRD) Removal - Refueling

- LCO 3.10.5 The requirements of LCO 3.3.1.1, "Reactor Protection System (RPS) Instrumentation"; LCO 3.3.8.2, "Reactor Protection System (RPS) Electric Power Monitoring"; LCO 3.9.1, "Refueling Equipment Interlocks"; LCO 3.9.2, "Refuel Position One-Rod-Out Interlock"; LCO 3.9.4, "Control Rod Position Indication"; and LCO 3.9.5, "Control Rod OPERABILITY-Refueling," may be suspended in MODE 5 to allow the removal of a single CRD associated with a control rod withdrawn from a core cell containing one or more fuel assemblies, provided the following requirements are met:
- a. All other control rods are fully inserted;
 - b. All other control rods in a five by five array centered on the withdrawn control rod are disarmed;
 - c. A control rod withdrawal block is inserted and LCO 3.1.1, "SHUTDOWN MARGIN (SDM)," MODE 5 requirements, may be changed to allow the single control rod withdrawn to be assumed to be the highest worth control rod; and
 - d. No other CORE ALTERATIONS are in progress.

APPLICABILITY: MODE 5 with LCO 3.9.5 not met.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more of the above requirements not met.	A.1 Suspend removal of the CRD. <u>AND</u>	Immediately (continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. (continued)	A.2.1 Initiate action to fully insert all control rods.	Immediately
	<u>OR</u>	
	A.2.2 Initiate action to satisfy the requirements of this LCO.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.10.5.1 Verify all control rods, other than the control rod withdrawn for the removal of the associated CRD, are fully inserted.	In accordance with the Surveillance Frequency Control Program
SR 3.10.5.2 Verify all control rods, other than the control rod withdrawn for the removal of the associated CRD, in a five by five array centered on the control rod withdrawn for the removal of the associated CRD, are disarmed.	In accordance with the Surveillance Frequency Control Program
SR 3.10.5.3 Verify a control rod withdrawal block is inserted.	In accordance with the Surveillance Frequency Control Program
SR 3.10.5.4 Perform SR 3.1.1.1.	According to SR 3.1.1.1
SR 3.10.5.5 Verify no other CORE ALTERATIONS are in progress.	In accordance with the Surveillance Frequency Control Program

3.10 SPECIAL OPERATIONS

3.10.6 Multiple Control Rod Withdrawal - Refueling

LCO 3.10.6 The requirements of LCO 3.9.3, "Control Rod Position"; LCO 3.9.4, "Control Rod Position Indication"; and LCO 3.9.5, "Control Rod OPERABILITY - Refueling," may be suspended, and the "full-in" position indicators may be bypassed for any number of control rods in MODE 5, to allow withdrawal and removal of these control rods, removal of associated control rod drives (CRDs), or both, provided the following requirements are met:

- a. The four fuel assemblies are removed from the core cells associated with each control rod or CRD to be removed;
- b. All other control rods in core cells containing one or more fuel assemblies are fully inserted; and
- c. Fuel assemblies shall only be loaded in compliance with an approved spiral reload sequence.

APPLICABILITY: MODE 5 with LCO 3.9.3, LCO 3.9.4, or LCO 3.9.5 not met.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more of the above requirements not met.	A.1 Suspend withdrawal of control rods and removal of associated CRDs.	Immediately
	<u>AND</u>	
	A.2 Suspend loading fuel assemblies.	Immediately
	<u>AND</u>	(continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. (continued)	A.3.1 Initiate action to fully insert all control rods in core cells containing one or more fuel assemblies.	Immediately
	<u>OR</u>	
	A.3.2 Initiate action to satisfy the requirements of this LCO.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.10.6.1	Verify the four fuel assemblies are removed from core cells associated with each control rod or CRD removed.	In accordance with the Surveillance Frequency Control Program
SR 3.10.6.2	Verify all other control rods in core cells containing one or more fuel assemblies are fully inserted.	In accordance with the Surveillance Frequency Control Program
SR 3.10.6.3	-----NOTE----- Only required to be met during fuel loading. ----- Verify fuel assemblies being loaded are in compliance with an approved spiral reload sequence.	In accordance with the Surveillance Frequency Control Program

3.10 SPECIAL OPERATIONS

3.10.7 Control Rod Testing—Operating

LCO 3.10.7 The requirements of LCO 3.1.6, "Rod Pattern Control," may be suspended to allow performance of SDM testing, control rod scram time testing, and control rod friction testing, provided:

- a. The banked position withdrawal sequence requirements of SR 3.3.2.1.8 are changed to require the control rod sequence to conform to the specified test sequence.

OR

- b. The RWM is bypassed; the requirements of LCO 3.3.2.1, "Control Rod Block Instrumentation," Function 2 are suspended; and conformance to the approved control rod sequence for the specified test is verified by a second licensed operator or other qualified member of the technical staff.

APPLICABILITY: MODES 1 and 2 with LCO 3.1.6 not met.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Requirements of the LCO not met.	A.1 Suspend performance of the test and exception to LCO 3.1.6.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.10.7.1 -----NOTE----- Not required to be met if SR 3.10.7.2 satisfied. -----</p> <p>Verify movement of control rods is in compliance with the approved control rod sequence for the specified test by a second licensed operator or other qualified member of the technical staff.</p>	<p>During control rod movement</p>
<p>SR 3.10.7.2 -----NOTE----- Not required to be met if SR 3.10.7.1 satisfied. -----</p> <p>Verify control rod sequence input to the RWM is in conformance with the approved control rod sequence for the specified test.</p>	<p>Prior to control rod movement</p>

3.10 SPECIAL OPERATIONS

3.10.8 SHUTDOWN MARGIN (SDM) Test - Refueling

LCO 3.10.8 The reactor mode switch position specified in Table 1.1-1 for MODE 5 may be changed to include the startup/hot standby position, and operation considered not to be in MODE 2, to allow SDM testing, provided the following requirements are met:

- a. LCO 3.3.1.1, "Reactor Protection System Instrumentation," MODE 2 requirements for Functions 2.a and 2.d of Table 3.3.1.1-1;
- b. 1. LCO 3.3.2.1, "Control Rod Block Instrumentation," MODE 2 requirements for Function 2 of Table 3.3.2.1-1, with the banked position withdrawal sequence requirements of SR 3.3.2.1.8 changed to require the control rod sequence to conform to the SDM test sequence.

OR

2. Conformance to the approved control rod sequence for the SDM test is verified by a second licensed operator or other qualified member of the technical staff;
- c. Each withdrawn control rod shall be coupled to the associated CRD;
- d. All control rod withdrawals during out of sequence control rod moves shall be made in notch out mode;
- e. No other CORE ALTERATIONS are in progress; and
- f. CRD charging water header pressure \geq 940 psig.

APPLICABILITY: MODE 5 with the reactor mode switch in startup/hot standby position.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. -----NOTE----- Separate Condition entry is allowed for each control rod. ----- One or more control rods not coupled to its associated CRD.</p>	<p>-----NOTE----- Rod worth minimizer may be bypassed as allowed by LCO 3.3.2.1, "Control Rod Block Instrumentation," if required, to allow insertion of inoperable control rod and continued operation. -----</p> <p>A.1 Fully insert inoperable control rod.</p> <p><u>AND</u></p> <p>A.2 Disarm the associated CRD.</p>	<p>3 hours</p> <p>4 hours</p>
<p>B. One or more of the above requirements not met for reasons other than Condition A.</p>	<p>B.1 Place the reactor mode switch in the shutdown or refuel position.</p>	<p>Immediately</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.10.8.1 Perform the MODE 2 applicable SRs for LCO 3.3.1.1, Functions 2.a and 2.d of Table 3.3.1.1-1.</p>	<p>According to the applicable SRs</p>

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.10.8.2	<p>----- NOTE----- Not required to be met if SR 3.10.8.3 satisfied. -----</p> <p>Perform the MODE 2 applicable SRs for LCO 3.3.2.1, Function 2 of Table 3.3.2.1-1.</p>	According to the applicable SRs
SR 3.10.8.3	<p>----- NOTE----- Not required to be met if SR 3.10.8.2 satisfied. -----</p> <p>Verify movement of control rods is in compliance with the approved control rod sequence for the SDM test by a second licensed operator or other qualified member of the technical staff.</p>	During control rod movement
SR 3.10.8.4	Verify no other CORE ALTERATIONS are in progress.	In accordance with the Surveillance Frequency Control Program

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.10.8.5	Verify each withdrawn control rod does not go to the withdrawn overtravel position.	<p>Each time the control rod is withdrawn to "full-out" position</p> <p><u>AND</u></p> <p>Prior to satisfying LCO 3.10.8.c requirement after work on control rod or CRD System that could affect coupling</p>
SR 3.10.8.6	Verify CRD charging water header pressure \geq 940 psig.	In accordance with the Surveillance Frequency Control Program

4.0 DESIGN FEATURES

4.1 Site Location

4.1.1 Site and Exclusion Area Boundaries

The Site and Exclusion Area Boundaries coincide with each other and shall be as shown on Figure 4.1-1.

4.1.2 Low Population Zone (LPZ)

The LPZ shall be a 4 mile radius around the Nine Mile Point Nuclear Station Unit 1 stack.

4.2 Reactor Core

4.2.1 Fuel Assemblies

The reactor shall contain 560 fuel assemblies. Each assembly shall consist of a matrix of Zircaloy or ZIRLO fuel rods with an initial composition of natural or slightly enriched uranium dioxide (UO_2) as fuel material, and water rods. Limited substitutions of zirconium alloy or stainless steel filler rods for fuel rods, in accordance with approved applications of fuel rod configurations, may be used. Fuel assemblies shall be limited to those fuel designs that have been analyzed with NRC staff approved codes and methods and have been shown by tests or analyses to comply with all safety design bases. A limited number of lead test assemblies that have not completed representative testing may be placed in nonlimiting core regions.

4.2.2 Control Rod Assemblies

The reactor core shall contain 137 cruciform shaped control rod assemblies. The control material shall be boron carbide or hafnium metal as approved by the NRC.

(continued)

4.0 DESIGN FEATURES (continued)

4.3 Fuel Storage

4.3.1 Criticality

4.3.1.1 The spent fuel storage racks are designed and shall be maintained with:

- a. Fuel assemblies having a maximum k-infinity of 1.32 in the normal reactor core configuration at cold conditions (20°C);
- b. $k_{eff} \leq 0.95$ if fully flooded with unborated water, which includes an allowance for uncertainties as described in Section 9.3 of the UFSAR; and
- c. A nominal 6.625 inch center to center distance between fuel assemblies placed in the aluminum high density storage racks, and a nominal 6.355 inch center to center distance between fuel assemblies placed in the stainless steel high density storage racks.

4.3.1.2 The new fuel storage racks are designed and shall be maintained with:

- a. Fuel assemblies having a maximum k-infinity of 1.31 in the normal reactor core configuration at cold conditions (20°C);
- b. $k_{eff} \leq 0.90$ if dry;
- c. $k_{eff} \leq 0.95$ if fully flooded with unborated water; and
- d. A nominal 6.625 inch center to center distance between fuel assemblies placed in storage racks.

4.3.2 Drainage

The spent fuel storage pool is designed and shall be maintained to prevent inadvertent draining of the pool below elevation 344 ft 6 inches.

(continued)

4.0 DESIGN FEATURES

4.3 Fuel Storage (continued)

4.3.3 Capacity

The spent fuel storage pool is designed and shall be maintained with a storage capacity limited to no more than 3239 fuel assemblies.




Figure 4.1-1 (page 1 of 1)
Site and Exclusion Area Boundaries

5.0 ADMINISTRATIVE CONTROLS

5.1 Responsibility

- 5.1.1 The plant manager shall be responsible for overall plant operation and shall delegate in writing the succession to this responsibility during his absence.

The plant manager or his designee shall approve, prior to implementation, each proposed test, experiment, and modification to systems or equipment that affect nuclear safety.

- 5.1.2 The shift supervisor (SS) shall be responsible for the control room command function. During any absence of the SS from the control room while the plant is in MODE 1, 2, or 3, an individual with an active Senior Reactor Operator (SRO) license shall be designated to assume the control room command function. During any absence of the SS from the control room while the plant is in MODE 4 or 5, an individual with an active SRO license or Reactor Operator license shall be designated to assume the control room command function.
-

5.0 ADMINISTRATIVE CONTROLS

5.2 Organization

5.2.1 Onsite and Offsite Organizations

Onsite and offsite organizations shall be established for plant operation and corporate management, respectively. The onsite and offsite organizations shall include the positions for activities affecting safety of the nuclear power plant.

- a. Lines of authority, responsibility, and communication shall be defined and established throughout highest management levels, intermediate levels, and all operating organization positions. These relationships shall be documented and updated, as appropriate, in organization charts, functional descriptions of departmental responsibilities and relationships, and job descriptions for key personnel positions, or in equivalent forms of documentation. These requirements, including the plant-specific titles of those personnel fulfilling the responsibilities of the positions delineated in these Technical Specifications, shall be documented in the UFSAR;
- b. The plant manager shall be responsible for overall safe operation of the plant and shall have control over those onsite activities necessary for safe operation and maintenance of the plant;
- c. The chief nuclear officer shall have corporate responsibility for overall plant nuclear safety and shall take any measures needed to ensure acceptable performance of the staff in operating, maintaining, and providing technical support to the plant to ensure nuclear safety; and
- d. The individuals who train the operating staff, carry out radiation protection, or perform quality assurance functions may report to the appropriate onsite manager; however, these individuals shall have sufficient organizational freedom to ensure their independence from operating pressures.

5.2.2 Plant Staff

The plant staff organization shall include the following:

- a. At least one non-licensed operator shall be on site when the plant is in MODE 4 or 5. At least two non-licensed operators shall be on site when the plant is in MODE 1, 2, or 3.

(continued)

5.2 Organization

5.2.2 Plant Staff (continued)

- b. Shift crew composition may be less than the minimum requirement of 10 CFR 50.54(m)(2)(i) and 5.2.2.a and 5.2.2.f for a period of time not to exceed 2 hours in order to accommodate unexpected absence of on duty shift crew members provided immediate action is taken to restore the shift crew composition to within the minimum requirements.
 - c. A radiation protection technician shall be on site when fuel is in the reactor. The position may be vacant for not more than 2 hours, in order to provide for unexpected absence, provided immediate action is taken to fill the required position.
 - d. Deleted
 - e. The operations manager or assistant operations manager shall hold an SRO license.
 - f. When in MODES 1, 2, or 3 an individual shall provide advisory technical support to the unit operations shift crew in the areas of thermal hydraulics, reactor engineering, and plant analysis with regard to the safe operations of the unit. This individual shall meet the qualifications specified in the Constellation Energy Generation, LLC Quality Assurance Topical Report.
-

5.0 ADMINISTRATIVE CONTROLS

5.3 Plant Staff Qualifications

5.3.1 Each member of the unit staff shall meet or exceed the minimum qualifications referenced for comparable positions as specified in the Constellation Energy Generation, LLC Quality Assurance Topical Report.

5.0 ADMINISTRATIVE CONTROLS

5.4 Procedures

5.4.1 Written procedures shall be established, implemented, and maintained covering the following activities:

- a. The applicable procedures recommended in Regulatory Guide 1.33, Appendix A, November 1972;
 - b. The emergency operating procedures required to implement the requirements of NUREG-0737 and NUREG-0737, Supplement 1, as stated in Generic Letter 82-33;
 - c. Quality assurance program for radioactive effluent and radiological environmental monitoring;
 - d. Fire Protection Program implementation; and
 - e. All programs specified in Specification 5.5.
-

5.0 ADMINISTRATIVE CONTROLS

5.5 Programs and Manuals

The following programs and manuals shall be established, implemented and maintained.

5.5.1 Offsite Dose Calculation Manual (ODCM)

- a. The ODCM shall contain the methodology and parameters used in the calculation of offsite doses resulting from radioactive gaseous and liquid effluents, in the calculation of gaseous and liquid effluent monitoring alarm and trip setpoints, and in the conduct of the radiological environmental monitoring program; and
- b. The ODCM shall also contain the radioactive effluent controls and radiological environmental monitoring activities and descriptions of the information that should be included in the Annual Radiological Environmental Operating and Radioactive Effluent Release Reports required by Specification 5.6.2 and Specification 5.6.3.
- c. Licensee initiated changes to the ODCM:
 1. Shall be documented and records of reviews performed shall be retained. This documentation shall contain:
 - (a) sufficient information to support the change(s) together with the appropriate analyses or evaluations justifying the change(s), and
 - (b) a determination that the change(s) maintain the levels of radioactive effluent control required pursuant to 10 CFR 20.1302, 40 CFR 190, 10 CFR 50.36a, and 10 CFR 50, Appendix I, and not adversely impact the accuracy or reliability of effluent, dose, or setpoint calculations;
 2. Shall become effective after the approval of the plant manager; and
 3. Shall be submitted to the NRC in the form of a complete, legible copy of the entire ODCM as a part of or concurrent with the Radioactive Effluent Release Report for the period of the report in which any change in the ODCM was made. Each change shall be identified by

(continued)

5.5 Programs and Manuals

5.5.1 Offsite Dose Calculation Manual (ODCM) (continued)

markings in the margin of the affected pages, clearly indicating the area of the page that was changed, and shall indicate the date (i.e., month and year) the change was implemented.

5.5.2 Primary Coolant Sources Outside Containment

This program provides controls to minimize leakage from those portions of systems outside containment that could contain highly radioactive fluids during a serious transient or accident to levels as low as practicable. The systems include the Core Spray, High Pressure Coolant Injection, Residual Heat Removal, Reactor Core Isolation Cooling, Reactor Water Cleanup, process sampling, and Standby Gas Treatment. The program shall include the following:

- a. Preventive maintenance and periodic visual inspection requirements; and
- b. Integrated leak test requirements for each system at 24 month intervals or less.

The provisions of SR 3.0.2 and SR 3.0.3 are applicable to the 24 month Frequency for performing integrated leak test activities.

5.5.3 Not Used

(continued)

5.5 Programs and Manuals (continued)

5.5.4 Radioactive Effluent Controls Program

This program conforms to 10 CFR 50.36a for the control of radioactive effluents and for maintaining the doses to members of the public from radioactive effluents as low as reasonably achievable. The program shall be contained in the ODCM, shall be implemented by procedures, and shall include remedial actions to be taken whenever the program limits are exceeded. The program shall include the following elements:

- a. Limitations on the functional capability of radioactive liquid and gaseous monitoring instrumentation including surveillance tests and setpoint determination in accordance with the methodology in the ODCM;
- b. Limitations on the concentrations of radioactive material released in liquid effluents from the site to unrestricted areas, conforming to 10 times the concentration values in Appendix B, Table 2, Column 2 to 10 CFR 20.1001-20.2402;
- c. Monitoring, sampling, and analysis of radioactive liquid and gaseous effluents in accordance with 10 CFR 20.1302 and with the methodology and parameters in the ODCM;
- d. Limitations on the annual and quarterly doses or dose commitment to a member of the public from radioactive materials in liquid effluents released from the site to unrestricted areas, conforming to 10 CFR 50, Appendix I;
- e. Determination of cumulative dose contributions from radioactive effluents for the current calendar quarter and current calendar year in accordance with the methodology and parameters in the ODCM at least every 31 days. Determination of projected dose contributions from radioactive effluents in accordance with the methodology in the ODCM at least every 31 days.
- f. Limitations on the functional capability and use of the liquid and gaseous effluent treatment systems to ensure that appropriate portions of these systems are used to reduce releases of radioactivity when the projected doses in a period of 31 days would exceed 2% of the guidelines for the annual dose or dose commitment, conforming to 10 CFR 50, Appendix I;

(continued)

5.5 Programs and Manuals

5.5.4 Radioactive Effluent Controls Program (continued)

- g. Limitations on the dose rate resulting from radioactive material released in gaseous effluents from the site to areas at or beyond the site boundary shall be in accordance with the following:
 - 1. For noble gases: a dose rate \leq 500 mrem/yr to the whole body and a dose rate \leq 3000 mrem/yr to the skin, and
 - 2. For iodine-131, iodine-133, tritium, and for all radionuclides in particulate form with half-lives greater than 8 days: a dose rate \leq 1500 mrem/yr to any organ;
- h. Limitations on the annual and quarterly air doses resulting from noble gases released in gaseous effluents from the site to areas beyond the site boundary, conforming to 10 CFR 50, Appendix I;
- i. Limitations on the annual and quarterly doses to a member of the public from iodine-131, iodine-133, tritium, and all radionuclides in particulate form with half-lives $>$ 8 days in gaseous effluents released from the site to areas at or beyond the site boundary, conforming to 10 CFR 50, Appendix I;
- j. Limitations on the annual dose or dose commitment to any member of the public, beyond the site boundary, due to releases of radioactivity and to radiation from uranium fuel cycle sources, conforming to 40 CFR 190; and
- k. Limitations on venting and purging of the primary containment through the Standby Gas Treatment System to maintain releases as low as reasonably achievable.

The provisions of SR 3.0.2 and SR 3.0.3 are applicable to the Radioactive Effluent Controls Program Surveillance Frequency.

5.5.5 Component Cyclic or Transient Limit

This program provides controls to track the UFSAR Section 4.2, cyclic and transient occurrences to ensure that components are maintained within the design limits.

(continued)

5.5 Programs and Manuals (continued)

5.5.6 Primary Containment Leakage Rate Testing Program

This program implements the leakage rate testing of the containment as required by 10 CFR 50.54(o) and 10 CFR 50, Appendix J, Option B, as modified by approved exemptions. This program shall be in accordance with the guidelines contained in NEI 94-01, "Industry Guideline for Implementing Performance-based Option of 10 CFR Part 50, Appendix J", Revision 3-A, dated July 2012, and the conditions and limitations specified in NEI 94-01, Revision 2-A, dated October 2008, as modified by the following exceptions:

- Type C testing of valves not isolable from the containment free air space may be accomplished by pressurization in the reverse direction, provided that testing in this manner provides equivalent or more conservative results than testing in the accident direction. If potential atmospheric leakage paths (e.g., valve stem packing) are not subjected to test pressure, the portions of the valve not exposed to test pressure shall be subjected to leakage rate measurement during regularly scheduled Type A testing. A list of these valves, the leakage rate measurement method, and the acceptance criteria, shall be contained in the Program.
- a. The peak primary containment internal pressure for the design basis loss of coolant accident, P_a , is 45 psig.
 - b. The maximum allowable primary containment leakage rate, L_a , at P_a , shall be 1.5% of containment air weight per day.
 - c. The leakage rate acceptance criteria are:
 1. Primary containment leakage rate acceptance criteria is $\leq 1.0 L_a$. During plant startup following testing in accordance with this program, the leakage rate acceptance criteria are $\leq 0.60 L_a$ for the Type B and Type C tests, and $\leq 0.75 L_a$ for the Type A tests.
 2. Air lock testing acceptance criteria are:
 - (a) Overall air lock leakage rate is $\leq 0.05 L_a$ when tested at $\geq P_a$; and
 - (b) For each door seal, leakage rate is ≤ 120 scfd when tested at $\geq P_a$.

(continued)

5.5 Programs and Manuals

5.5.6 Primary Containment Leakage Rate Testing Program (continued)

- d. The provisions of SR 3.0.3 are applicable to the Primary Containment Leakage Rate Testing Program.
 - e. Nothing in these Technical Specifications shall be construed to modify the testing Frequencies required by 10 CFR 50, Appendix J.
-

5.5.7 Not Used

5.5.8 Ventilation Filter Testing Program (VFTP)

This program implements the following required testing of Engineered Safeguards filter ventilation systems.

The tests described in Specifications 5.5.8.a and 5.5.8.b shall be performed:

Once per 24 months;

After each complete or partial replacement of the HEPA filter train or charcoal adsorber filter or after removal of a charcoal sample;

After any structural maintenance on the HEPA filter or charcoal adsorber housing that could affect the filter system efficiency; and

Following painting, fire, or chemical release that could adversely affect the ability of the filter system to perform the intended function in any ventilation zone communicating with the system.

The tests described in Specification 5.5.8.c shall be performed:

Once per 24 months;

After 720 hours of system operation;

After any structural maintenance on the charcoal adsorber housing that could affect the filter system efficiency; and

Following painting, fire, or chemical release that could adversely affect the ability of the charcoal filter system to perform the intended function in any ventilation zone communicating with the system.

The tests described in Specifications 5.5.8.d and 5.5.8.e shall be performed once per 24 months.

(continued)

5.5 Programs and Manuals

5.5.8 Ventilation Filter Testing Program (VFTP) (continued)

The provisions of SR 3.0.2 and SR 3.0.3 are applicable to the VFTP test Frequencies.

- a. Demonstrate for each of the Engineered Safeguards systems that an inplace test of the HEPA filters shows a penetration and system bypass less than the value specified below when tested in accordance with Sections C.5.a and C.5.c of Regulatory Guide 1.52, Revision 2, and ASME N510-1980 at the system flowrate specified below.

<u>Engineered Safeguards Ventilation System</u>	<u>Penetration and System Bypass</u>	<u>Flowrate (scfm)</u>
Standby Gas Treatment System	1.5%	5,400 to 6,600
Control Room Emergency Ventilation Air Supply System	1.5%	900 to 1,100

- b. Demonstrate for each of the Engineered Safeguards systems that an inplace test of the charcoal adsorber shows a penetration and system bypass less than the value specified below when tested in accordance with Sections C.5.a and C.5.d of Regulatory Guide 1.52, Revision 2, and ASME N510-1980 at the system flowrate specified below.

<u>Engineered Safeguards Ventilation System</u>	<u>Penetration and System Bypass</u>	<u>Flowrate (scfm)</u>
Standby Gas Treatment System	1.0%	5,400 to 6,600
Control Room Emergency Ventilation Air Supply System	0.5%	900 to 1,100

(continued)

5.5 Programs and Manuals

5.5.8 Ventilation Filter Testing Program (VFTP) (continued)

- c. Demonstrate for each of the Engineered Safeguards systems that a laboratory test of a sample of the charcoal adsorber, when obtained as described in Section C.6.b of Regulatory Guide 1.52, Revision 2, shows the methyl iodide penetration less than the value specified below when tested in series, in accordance with ASTM D3803-1989 at a temperature of $\leq 30^{\circ}\text{C}$ (86°F) and the relative humidity specified below.

<u>Engineered Safeguards Ventilation System</u>	<u>Penetration</u>	<u>RH</u>
Standby Gas Treatment System	1.5%	$\geq 70\%$
Control Room Emergency Ventilation Air Supply System	1.5%	$\geq 95\%$

- d. Demonstrate for each of the Engineered Safeguards systems that the pressure drop across the combined HEPA filters and the charcoal adsorbers is less than the value specified below when tested at the system flowrate specified below:

<u>Engineered Safeguards Ventilation System</u>	<u>Delta P (inches wg)</u>	<u>Flowrate (scfm)</u>
Standby Gas Treatment System	5.7	5,400 to 6,600
Control Room Emergency Ventilation Air Supply System	5.8	900 to 1,100

- e. Demonstrate that the heaters for the Standby Gas Treatment System dissipate > 29 kW when tested in accordance with ASME N510-1975.

(continued)

5.5 Programs and Manuals (continued)

5.5.9 Explosive Gas and Storage Tank Radioactivity Monitoring Program

This program provides controls for potentially explosive gas mixtures contained in the Main Condenser Offgas Treatment System and the quantity of radioactivity contained in unprotected outdoor liquid storage tanks.

The program shall include:

- a. The limits for concentrations of hydrogen and oxygen in the Main Condenser Offgas Treatment System and a surveillance program to ensure the limits are maintained. Such limits shall be appropriate to the system's design criteria (i.e., whether or not the system is designed to withstand a hydrogen explosion); and
- b. A surveillance program to ensure that the quantity of radioactivity contained in all outdoor liquid radwaste tanks that are not surrounded by liners, dikes, or walls, capable of holding the tanks' contents and that do not have tank overflows and surrounding area drains connected to the Liquid Radwaste System is less than the amount that would result in a concentration that is 10 times the concentration values in Appendix B, Table 2, Column 2, to 10 CFR 20.1001-20.2402 (excluding tritium and dissolved or entrained noble gases) at the nearest potable water supply and the nearest surface water supply beyond the site boundary, in the event of an uncontrolled release of the tanks' contents.

The provisions of SR 3.0.2 and SR 3.0.3 are applicable to the Explosive Gas and Storage Tank Radioactivity Monitoring Program Surveillance Frequencies.

(continued)

5.5 Programs and Manuals (continued)

5.5.10 Diesel Fuel Oil Testing Program

This program implements required testing of both new fuel oil and stored fuel oil. The program shall include sampling and testing requirements, and acceptance criteria, all in accordance with applicable ASTM Standards. The purpose of the program is to establish the following:

- a. Acceptability of new fuel oil for use prior to addition to storage tanks by determining that the fuel oil has:
 1. An API gravity or an absolute specific gravity within limits,
 2. A flash point and kinematic viscosity within limits for ASTM 2D fuel oil, and
 3. A clear and bright appearance with proper color or water and sediment within limits;
- b. Within 31 days following addition of the new fuel oil to storage tanks verify that the properties of the new fuel oil, other than those addressed in Specification 5.5.10.a above, are within limits for ASTM 2D fuel oil; and
- c. Total particulate concentration of the fuel oil is ≤ 10 mg/l when tested every 31 days in accordance with the applicable ASTM Standard, except that the specified filters may be replaced with filters up to 3.0 microns.

The provisions of SR 3.0.2 and SR 3.0.3 are applicable to the Diesel Fuel Oil Testing Program test Frequencies.

(continued)

5.5 Programs and Manuals (continued)

5.5.11 Technical Specifications (TS) Bases Control Program

This program provides a means for processing changes to the Bases of these Technical Specifications.

- a. Changes to the Bases of the TS shall be made under appropriate administrative controls and reviews.
- b. Licensees may make changes to Bases without prior NRC approval provided the changes do not require either of the following:
 1. A change in the TS incorporated in the license; or
 2. A change to the UFSAR or Bases that requires NRC approval pursuant to 10 CFR 50.59.
- c. The Bases Control Program shall contain provisions to ensure that the Bases are maintained consistent with the UFSAR.
- d. Proposed changes that meet the criteria of Specification 5.5.11.b above shall be reviewed and approved by the NRC prior to implementation. Changes to the Bases implemented without prior NRC approval shall be provided to the NRC on a frequency consistent with 10 CFR 50.71(e).

(continued)

5.5 Programs and Manuals (continued)

5.5.12 Safety Function Determination Program (SFDP)

This program ensures loss of safety function is detected and appropriate actions taken. Upon entry into LCO 3.0.6, an evaluation shall be made to determine if loss of safety function exists. Additionally, other appropriate limitations and remedial or compensatory actions may be identified to be taken as a result of the support system inoperability and corresponding exception to entering supported system Condition and Required Actions. This program implements the requirements of LCO 3.0.6.

- a. The SFDP shall contain the following:
 1. Provisions for cross division checks to ensure a loss of the capability to perform the safety function assumed in the accident analysis does not go undetected;
 2. Provisions for ensuring the plant is maintained in a safe condition if a loss of function condition exists:
 3. Provisions to ensure that an inoperable supported system's Completion Time is not inappropriately extended as a result of multiple support system inoperabilities; and
 4. Other appropriate limitations and remedial or compensatory actions.
- b. A loss of safety function exists when, assuming no concurrent single failure, no concurrent loss of offsite power or no concurrent loss of emergency diesel generator subsystems, a safety function assumed in the accident analysis cannot be performed. For the purpose of this program, a loss of safety function may exist when a support system is inoperable, and:
 1. A required system redundant to system(s) supported by the inoperable support system is also inoperable; or
 2. A required system redundant to system(s) in turn supported by the inoperable supported system is also inoperable; or
 3. A required system redundant to support system(s) for the supported systems (1) and (2) above is also inoperable.

The SFDP identifies where a loss of safety function exists. If a loss of safety function is determined to exist by this program, the appropriate Conditions and Required Actions of the LCO in which the loss of safety function exists are required to be entered. When a loss of safety function is caused by the inoperability of a single Technical Specification support system, the appropriate Conditions and Required Actions to enter are those of the support system.

(continued)

5.5 Programs and Manuals (continued)

5.5.13 Configuration Risk Management Program (CRMP)

The CRMP provides a proceduralized risk-informed assessment to manage the risk associated with equipment inoperability. The program applies to technical specification structures, systems, or components for which a risk-informed allowed outage time has been granted. The program is to include the following:

- a. Provisions for the control and implementation of a Level 1 at-power internal events PRA-informed methodology. The assessment is to be capable of evaluating the applicable plant configuration.
- b. Provisions for performing an assessment prior to entering the plant configuration described by the Limiting Condition for Operation (LCO) Condition(s) for preplanned activities.
- c. Provisions for performing an assessment after entering the plant configuration described by the LCO Condition(s) for unplanned entry into the LCO Condition(s).
- d. Provisions for assessing the need for additional actions after the discovery of additional equipment-out-of-service conditions while in the plant configuration described by the LCO Condition(s).
- e. Provisions for considering other applicable risk-significant contributors such as Level 2 issues and external events, qualitatively or quantitatively.

(continued)

5.5 Programs and Manuals (continued)

5.5.14 Control Room Envelope Habitability Program

A Control Room Envelope (CRE) Habitability Program shall be established and implemented to ensure that CRE habitability is maintained such that, with an OPERABLE Control Room Emergency Ventilation Air Supply (CREVAS) System, CRE occupants can control the reactor safely under normal conditions and maintain it in a safe condition following a radiological event, hazardous chemical release, or a smoke challenge. The program shall ensure that adequate radiation protection is provided to permit access and occupancy of the CRE under design basis accident (DBA) conditions without personnel receiving radiation exposures in excess of 5 rem whole body or its equivalent to any part of the body for the duration of the accident. The program shall include the following elements:

- a. The definition of the CRE and the CRE boundary.
- b. Requirements for maintaining the CRE boundary in its design condition including configuration control and preventive maintenance.
- c. Requirements for (i) determining the unfiltered air inleakage past the CRE boundary into the CRE in accordance with the testing methods and at the Frequencies specified in Sections C.1 and C.2 of Regulatory Guide 1.197, "Demonstrating Control Room Envelope Integrity at Nuclear Power Reactors," Revision 0, May 2003, and (ii) assessing CRE habitability at the Frequencies specified in Sections C.1 and C.2 of Regulatory Guide 1.197, Revision 0.
- d. Measurement, at designated locations, of the CRE pressure relative to all external areas adjacent to the CRE boundary during the isolate mode of operation by one subsystem of the CREVAS System, operating at the flow rate required by the VFTP, at a Frequency of 18 months on a STAGGERED TEST BASIS. The results shall be trended and used as part of the 18 month assessment of the CRE boundary.
- e. The quantitative limits on unfiltered air inleakage into the CRE. These limits shall be stated in a manner to allow direct comparison to the unfiltered air inleakage measured by the testing described in paragraph c. The unfiltered air inleakage limit for radiological challenges is the inleakage flow rate assumed in the licensing basis analyses of DBA consequences. Unfiltered air inleakage limits for hazardous chemicals must ensure that exposure of CRE occupants to these hazards will be within the assumptions in the licensing basis.
- f. The provisions of SR 3.0.2 are applicable to the Frequencies for assessing CRE habitability, determining CRE unfiltered inleakage, and measuring CRE pressure and assessing the CRE boundary as required by paragraphs c and d, respectively.

(continued)

5.5 Programs and Manuals

5.5.15 Surveillance Frequency Control Program

This program provides controls for Surveillance Frequencies. The program shall ensure that Surveillance Requirements specified in the Technical Specifications are performed at intervals sufficient to assure the associated Limiting Conditions for Operation are met.

- a. The Surveillance Frequency Control Program shall contain a list of Frequencies of the Surveillance Requirements for which the Frequency is controlled by the program.
 - b. Changes to the Frequencies listed in the Surveillance Frequency Control Program shall be made in accordance with NEI 04-10, "Risk-Informed Method for Control of Surveillance Frequencies," Revision 1.
 - c. The provisions of Surveillance Requirements 3.0.2 and 3.0.3 are applicable to the Frequencies established in the Surveillance Frequency Control Program.
-

5.5.16 Risk Informed Completion Time Program

This program provides controls to calculate a Risk Informed Completion Time (RICT) and must be implemented in accordance with NEI 06-09-A, Revision 0, "Risk-Managed Technical Specifications (RMTS) Guidelines."

The program shall include the following:

- a. The RICT may not exceed 30 days;
- b. A RICT may only be utilized in MODE 1, 2;
- c. When a RICT is being used, any change to the plant configuration, as defined in NEI 06-09-A, Appendix A, must be considered for the effect on the RICT.
 1. For planned changes, the revised RICT must be determined prior to implementation of the change in configuration.
 2. For emergent conditions, the revised RICT must be determined within the time limits of the Required Action Completion Time (i.e., not the RICT) or 12 hours after the plant configuration change, whichever is less.
 3. Revising the RICT is not required if the plant configuration change would lower plant risk and would result in a longer RICT.

(continued)

5.5 Programs and Manuals (continued)

5.5.16 Risk Informed Completion Time Program (continued)

- d. For emergent conditions, if the extent of condition evaluation for inoperable structures, systems, or components (SSCs) is not complete prior to exceeding the Completion Time, the RICT shall account for the increased possibility of common cause failure (CCF) by either:
1. Numerically accounting for the increased possibility of CCF in the RICT calculation; or
 2. Risk Management Actions (RMAs) not already credited in the RICT calculation shall be implemented that support redundant or diverse SSCs that perform the function(s) of the inoperable SSCs, and, if practicable, reduce the frequency of initiating events that challenge the function(s) performed by the inoperable SSCs.
- e. The risk assessment approaches and methods shall be acceptable to the NRC. The plant PRA shall be based on the as-built, as-operated, and maintained plant; and reflect the operating experience at the plant, as specified in Regulatory Guide 1.200, Revision 2. Methods to assess the risk from extending the Completion Times must be PRA methods used to support License Amendment No. , or other methods approved by the NRC for generic use; and any change in the PRA methods to assess risk that are outside these approval boundaries require prior NRC approval.

5.0 ADMINISTRATIVE CONTROLS

5.6 Reporting Requirements

The following reports shall be submitted in accordance with 10 CFR 50.4.

5.6.1 Not Used

5.6.2 Annual Radiological Environmental Operating Report

The Annual Radiological Environmental Operating Report covering the operation of the plant during the previous calendar year shall be submitted by May 15 of each year. The report shall include summaries, interpretations, and analyses of trends of the results of the Radiological Environmental Monitoring Program for the reporting period. The material provided shall be consistent with the objectives outlined in the Offsite Dose Calculation Manual (ODCM), and in 10 CFR 50, Appendix I, Sections IV.B.2, IV.B.3, and IV.C.

The Annual Radiological Environmental Operating Report shall include the results of analyses of all radiological environmental samples and of all environmental radiation measurements taken during the period at the locations specified in the table and figures in the ODCM, as well as summarized and tabulated results of these analyses and measurements in the format of the table in the Radiological Assessment Branch Technical Position, Revision 1, November 1979. In the event that some individual results are not available for inclusion with the report, the report shall be submitted noting and explaining the reasons for the missing results. The missing data shall be submitted in a supplementary report as soon as possible.

5.6.3 Radioactive Effluent Release Report

The Radioactive Effluent Release Report covering the operation of the plant during the previous year shall be submitted prior to May 1 of each year in accordance with 10 CFR 50.36a. The report shall include a summary of the quantities of radioactive liquid and gaseous effluents and solid waste released from the plant. The material provided shall be consistent with the objectives outlined in the ODCM and Process Control Program and in conformance with 10 CFR 50.36a and 10 CFR Part 50, Appendix I, Section IV.B.1.

(continued)

5.6 Reporting Requirements (continued)

5.6.4 Not Used

5.6.5 CORE OPERATING LIMITS REPORT (COLR)

- a. Core operating limits shall be established prior to each reload cycle, or prior to any remaining portion of a reload cycle, and shall be documented in the COLR for the following:
1. The AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR) of Specification 3.2.1;
 2. The MINIMUM CRITICAL POWER RATIO (MCPR) and MCPR(99.9%) of Specification 3.2.2;
 3. The LINEAR HEAT GENERATION RATE (LHGR) of Specification 3.2.3;
 4. The Reactor Protection System (RPS) APRM Neutron Flux - High (Flow Biased) Function Allowable Value of Table 3.3.1.1-1;
 5. The Rod Block Monitor - Upscale Function Allowable Value of Table 3.3.2.1-1; and
 6. The Power/Flow Exclusion Region of Specification 3.4.1.
- b. The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC, specifically those described in the following document:
1. NEDE-24011-P-A, "General Electric Standard Application for Reactor Fuel (GESTAR II)" and the US Supplement, NEDE-24011-P-A-US

The COLR will contain the complete identification for each of the Technical Specification referenced topical reports used to prepare the COLR (i.e., report number, title, revision, date, and any supplements).

(continued)

5.6 Reporting Requirements

5.6.5 CORE OPERATING LIMITS REPORT (COLR) (continued)

- c. The core operating limits shall be determined such that all applicable limits (e.g., fuel thermal mechanical limits, core thermal hydraulic limits, Emergency Core Cooling Systems (ECCS) limits, nuclear limits such as SDM, transient analysis limits, and accident analysis limits) of the safety analysis are met.
- d. The COLR, including any midcycle revisions or supplements, shall be provided upon issuance for each reload cycle to the NRC.

5.6.6 PAM Report

When a report is required by Condition B or F of LCO 3.3.3.1, "Post Accident Monitoring (PAM) Instrumentation," a report shall be submitted within the following 14 days. The report shall outline the preplanned alternate method of monitoring, the cause of the inoperability, and the plans and schedule for restoring the instrumentation channels of the Function to OPERABLE status.

5.6.7 Reactor Coolant System (RCS PRESSURE AND TEMPERATURE LIMITS REPORT (PTLR))

- a. RCS pressure and temperature limits for heatup, cooldown, low temperature operation, criticality, and hydrostatic testing as well as heatup and cooldown rates shall be established and documented in the PTLR for the following:
 - i) Limiting Conditions for Operation Section 3.4.9 "RCS Pressure and Temperature (P/T) Limits"
 - ii) Surveillance Requirements Section 3.4.9 "RCS Pressure and Temperature (P/T) Limits"
 - b. The analytical methods used to determine the RCS pressure and temperature limits shall be those previously reviewed and approved by the NRC, specifically those described in the following documents:
 - i) SIR-05-044-A, "Pressure-Temperature Limits Report Methodology for Boiling Water Reactors"
 - ii) SIA Calculation 0800846.301, "2" Instrument Nozzle Stress Analysis"
 - c. The PTLR shall be provided to the NRC upon issuance for each reactor vessel fluence period and for any revision or supplement thereto.
-

5.0 ADMINISTRATIVE CONTROLS

5.7 High Radiation Area

Pursuant to 10 CFR Part 20, paragraph 20.1601(c), in lieu of the requirements of paragraph 20.1601(a) and 20.1601(b) of 10 CFR Part 20:

- 5.7.1 Access to each high radiation area, as defined in 10 CFR 20, in which an individual could receive a deep dose equivalent > 0.1 rem in one hour (at 30 centimeters from the radiation source or from any surface penetrated by the radiation) shall be controlled as described below to prevent unauthorized entry.
- a. Each area shall be barricaded and conspicuously posted as a high radiation area. Such barricades may be opened as necessary to permit entry or exit of personnel or equipment.
 - b. Entrance shall be controlled by requiring issuance of a Radiation Work permit (RWP) or equivalent that includes specification of radiation dose rate in the immediate work area(s) and other appropriate radiation protection equipment and measures.
 - c. Individuals qualified in radiation protection procedures or personnel continuously escorted by such individuals may, for the performance of their assigned duties in high radiation areas, be exempt from the preceding requirements for issuance of an RWP or equivalent provided they are otherwise following plant radiation protection procedures for entry into, exit from, and work in such high radiation areas.
 - d. Each individual or group of individuals permitted to enter such areas shall possess, or be accompanied by, one or more of the following:
 1. A radiation monitoring device that continuously indicates the radiation dose rate in the area.
 2. A radiation monitoring device that continuously integrates the radiation dose rate in the area and alarms when a preset setpoint is reached. Entry into high radiation areas with this monitoring device may be made after the dose rate in the area have been determined and personnel have been made knowledgeable of it.
 3. A radiation monitoring device that continuously transmits dose rate and cumulative dose information to a remote receiver monitored by radiation protection personnel responsible for controlling personnel radiation exposure within the area.
 4. An individual qualified in radiation protection procedures equipped with a radiation dose rate monitoring device. This individual shall be responsible for providing positive radiation protection control over the activities within the area and shall perform periodic radiation surveillance at the frequency specified by radiation protection supervision.

(continued)

5.7 High Radiation Area (continued)

-
- 5.7.2 In addition to the requirements of Specification 5.7.1, high radiation areas in which an individual could receive a deep dose equivalent > 1.0 rem in one hour (at 30 centimeters from the radiation source or from any surface penetrated by the radiation source or from any surface penetrated by the radiation), but less than 500 rads/hour (at 1 meter from the radiation source or from any surface penetrated by the radiation) shall be provided with a locked or continuously guarded door, or gate, or equivalent to prevent unauthorized entry.
- a. The keys to such locked doors or gates, or equivalent, shall be administratively controlled in accordance with a program approved by the radiation protection manager.
 - b. Doors and gates, or equivalent, shall remain locked except during periods of access by personnel under an approved RWP, or equivalent, to ensure individuals are informed of the dose rate in the immediate work areas prior to entry.
 - c. Individual high radiation areas in which an individual could receive a deep dose equivalent > 1.0 rem in one hour (at 30 centimeters from the radiation source or from any surface penetrated by the radiation), accessible to personnel, that are located within larger areas where no enclosure exists to enable locking, or that are not continuously guarded, and where no lockable enclosure can be reasonably constructed around the individual area require both of the following access controls:
 1. Each area shall be barricaded and conspicuously posted.
 2. A flashing light shall be activated as a warning device.
-

Appendix "B"
deleted
(letter dated July 29, 2005)

APPENDIX C
ADDITIONAL CONDITIONS
OPERATING LICENSE NO. DPR-59

Amendment Number	Additional Conditions
243	Constellation Energy Generation, LLC shall describe snubber operation and surveillance requirements in the Final Safety Analysis Report such that future changes to those requirements will be subject to the provisions of 10 CFR 50.59.
250	Constellation Energy Generation, LLC shall relocate operability and surveillance requirements for logic bus power monitors, core spray sparger differential pressure, and low pressure coolant injection cross-connect valve position instruments to a licensee-controlled document where future changes to those relocated requirements are controlled under the provisions of 10 CFR 50.59.
274	Constellation Energy Generation, LLC shall relocate the Technical Specification requirements identified in Table LA – “Removal of Details Matrix” and Table R – “Relocated Specifications” to licensee-controlled documents, as described in the application, as supplemented on June 12, 2002, and the NRC staff’s Safety Evaluation enclosed with Amendment No. 274, dated July 3, 2002. Further, relocations to the updated Final Safety Analysis Report (UFSAR) shall be reflected in the next UFSAR update required by 10 CFR 50. 71(e) following implementation of this amendment.
289	<p>Control Room Envelope Habitability</p> <p>Upon Implementation of Amendment No. 289, adopting TSTF-448, Revision 3, the determination of control room envelope (CRE) unfiltered air leakage required by SR 3.7.3.3 in accordance with TS 5.5.14.c.(i), the assessment of CRE habitability, as required by Specification 5.5.14.c.(ii), and the measurement of CRE pressure as required by Specification 5.5.14.d shall be considered met. Following implementation:</p> <p>(a) The first performance of SR 3.7.3.3 in accordance with Specification 5.5.14.c(i) shall be within the specified Frequency of 6 years, plus the 18-month allowance of SR 3.0.2, as measured from June 28, 2004, the date of the most recent successful tracer gas test, as stated in the licensee’s letter, “NRC Generic Letter 2003-01 Control Room Habitability Initial Action Summary Report” (JAFP-04-0159), dated September 27, 2004, or within 18 months if the time period since the most recent successful tracer gas test is greater than 6 years.</p>

Appendix C

- 2 -

(b) The first performance of the periodic assessment of CRE habitability Specification 5.5.14.c(ii) shall be within 3 years, plus the 9-month allowance of SR 3.0.2, as measured from June 28, 2004, the date of the most recent successful tracer gas test, as stated in the licensee's letter, "NRC Generic Letter 2003-01 Control Room Habitability Initial Action Summary Report" (JAFP-04-0159), dated September 27, 2004, or within 9 months if the time period since the most recent successful tracer gas test is greater than 3 years.

(c) The first performance of the periodic measurement of CRE pressure, Specification 5.5.14.d shall be within 18 months, plus the 138-day allowance of SR 3.0.2 as measured from the date of the most recent successful pressure measurement test or within 138 days if not performed previously.