

**Wolf Creek Nuclear Operating Corporation**

Wolf Creek Generating Station

Docket No: **50-482**

Facility Operating License No: **NPF-42**

**Annual Radioactive Effluent Release Report**

**Report No. 29**

Reporting Period: January 1, 2005 - December 31, 2005

## Table of Contents

	<u>Page</u>
<b><u>Executive Summary</u></b>	4
<b><u>Section I</u></b>	6
Report of 2005 Radioactive Effluents: Liquid	6
2005 Liquid Effluents	8
2005 Liquid Cumulative Dose Summary – Table 1	10
2005 Liquid Cumulative Dose Summary – Table 2	11
Report of 2005 Radioactive Effluents: Airborne	12
2005 Gaseous Effluents	14
2005 Gaseous Cumulative Dose Summary – Table 1	16
2005 Gaseous Cumulative Dose Summary – Table 2	17
<b><u>Section II</u></b>	18
Offsite Dose Calculation Manual Limits	18
Effluent Concentration Limits (ECLs)	18
Average Energy	19
Measurements and Approximations of Total Radioactivity (Liquid and Gaseous Effluents)	19
Batch Releases	21
Continuous Releases	21
Doses to a Member of the Public from Activities Inside the Site Boundary	21
Additional Information	22
2005 Effluent Concentration Limits	23
2005 Solid Waste Shipments	24
Irradiated Fuel Shipments	25
<b><u>Section III</u></b>	26
Meteorological Data – Hours At Each Wind Speed and Direction	26
<b><u>Section IV</u></b>	35
Unplanned or Abnormal Releases	35
Offsite Dose Calculation Manual	35
Major Changes to Liquid, Solid, or Gaseous Radioactive Waste Treatment Systems	35
Land Use Census	35
Radwaste Shipments	35
Inoperability of Effluent Monitoring Instrumentation	35
Storage Tanks	35
<b><u>Attachments</u></b>	36

## Table of Contents

- Attachment I - WCGS Procedure AP 07B-003, Revision 5, "Offsite Dose Calculation Manual"**
- Attachment II - WCGS Procedure AP 07B-004, Revision 10, "Offsite Dose Calculation Manual (Radiological Environmental Monitoring Program)"**
- Attachment III - WCGS Procedure AP 31A-100, Revision 5, "Solid Radwaste Process Control Program"**

## EXECUTIVE SUMMARY

This Annual Radioactive Effluent Release Report (Report # 29) documents the quantities of liquid and gaseous effluents and solid waste released by Wolf Creek Generating Station (WCGS) from January 1, 2005 through December 31, 2005. The format and content of this report are in accordance with Regulatory Guide 1.21, Revision 1, "Measuring, Evaluation, and Reporting Radioactivity in Solid Wastes and Releases of Radioactive Materials in Liquid and Gaseous Effluents from Light-Water-Cooled Nuclear Power Plants." Sections I, II, III, and IV of this report provide information required by NRC Regulatory Guide 1.21 and Section 7.2 of AP 07B-003, "Offsite Dose Calculation Manual" (ODCM).

**Section I** --- Section I contains, in detail, the quantities of radioactive liquid and gaseous effluents and cumulative dose summaries for 2005, tabulated for each quarter and for yearly totals. Specific ODCM effluent limits and dose limits are also listed in Section I, along with the percentage of the effluent limits actually released and the percentages of the dose limit actually received. No effluent or dose limits were exceeded during 2005.

An elevated release pathway does not exist at WCGS. All airborne releases are considered to be ground-level releases. The gaseous pathway dose determination is met by the WCGS ODCM methodology of assigning all gaseous pathways to a hypothetical individual residing at the highest annual X/Q and D/Q location, as specified in the ODCM. This results in a conservative estimate of dose to a member of the public, rather than determining each pathway dose for each release condition. A conservative error of thirty percent has been estimated in the effluent data. As stated above, no ODCM dose limits were exceeded in 2005.

**Section II** --- Section II includes supplemental information on continuous and batch releases, calculated doses, and solid waste disposal. There were 72 gaseous batch releases in 2005 versus 67 in 2004. There were 62 liquid batch releases in 2005 versus 58 in 2004. WCGS released 0.014 curies in liquid releases during 2005 versus 0.019 curies in 2004, excluding gas and tritium. Continuous release pathways remained the same as previous years and all continuous releases were monitored.

The report contains information on the following Performance Improvement Request (PIR):

PIR 2005-1836 – While performing a Volume Control Tank (VCT) purge to Gas Decay Tank #3 (GDT), a leak was identified on a moisture separator pressure switch (HAPS1035B). The leak resulted in an unplanned, monitored release.

**Section III** --- Section III documents WCGS meteorological data for wind speed, wind direction, and atmospheric stability.

**Section IV** --- Section IV documents unplanned and abnormal releases, changes to radwaste treatment systems, land use census, monitoring instruments, radwaste shipments, and storage tank quantities. There was one unplanned, monitored release in 2005.

No changes to events occurred on the land use census, monitoring instruments, radwaste shipments, and storage units.

**ATTACHMENTS**

Attachment I – AP 07B-003, revision 5, “Offsite Dose Calculation Manual”

Attachment II – AP 07B-004, revision 10, “Offsite Dose Calculation Manual (Radiological Environmental Monitoring Program)”

Attachment III – AP 31A-100, revision 5, “Solid Radwaste Process Control Program”

## SECTION I

## REPORT OF 2005 RADIOACTIVE EFFLUENTS: LIQUID

	Unit	Quarter 1	Quarter 2
A. Fission and Activation Products			
1. Total Release (not including tritium, gases, alpha)	Ci	2.08E-03	9.92E-03
2. Average Diluted Concentration During Period	µCi/ml	2.65E-11	1.09E-10
3. Percent of Applicable Limit (1)	%	4.16E-02	1.98E-01
B. Tritium			
1. Total Release	Ci	3.20E+02	1.26E+02
2. Average Diluted Concentration During Period	µCi/ml	4.07E-06	1.39E-06
3. Percent of Applicable Limit (2) (ECL)	%	4.07E-01	1.39E-01
C. Dissolved and Entrained Gases			
1. Total Release	Ci	2.35E-02	1.00E-02
2. Average Diluted Concentration During Period	µCi/ml	2.99E-10	1.10E-10
3. Percent of Applicable Limit (3)	%	1.49E-04	5.50E-05
D. Gross Alpha Radioactivity			
1. Total Release	Ci	0.00E+00	0.00E+00
E. Volume of Waste Released (prior to dilution)	Liters	1.14E+08	9.52E+07
F. Volume of Dilution Water Used	Liters	7.85E+10	9.08E+10

NOTES:

1) The applicable limit for the WCGS is 5 Curies per year. (Reference 10 CFR 50, Appendix I, "Guides On Design Objectives For Light-Water Cooled Nuclear Power Reactors," Paragraph A.2.) The value is derived by dividing the total release Curies by 5 Curies and then multiplying the result by 100.

2) This value is derived by the following formula:

$$\% \text{ of Applicable Limit} = \frac{(\text{Average Diluted Concentration}) (100)}{(\text{MPC or ECL, Appendix B, Table 2 10CFR20})}$$

3) This value is derived by the following formula:

$$\% \text{ of Applicable Limit} = \frac{(\text{Average Diluted Concentration}) (100)}{(2E - 04 \text{ from ODCM Section 2.1})}$$

## REPORT OF 2005 RADIOACTIVE EFFLUENTS: LIQUID

		Unit	Quarter 3	Quarter 4
A.	Fission and Activation Products			
1.	Total Release (not including tritium, gases, alpha)	Ci	1.64E-03	8.10E-04
2.	Average Diluted Concentration During Period	μCi/ml	1.18E-11	8.23E-12
3.	Percent of Applicable Limit (1)	%	3.27E-02	1.62E-02
B.	Tritium			
1.	Total Release	Ci	1.95E+01	3.62E+01
2.	Average Diluted Concentration During Period	μCi/ml	1.41E-07	3.68E-07
3.	Percent of Applicable Limit (2) (ECL)	%	1.41E-02	3.68E-02
C.	Dissolved and Entrained Gases			
1.	Total Release	Ci	0.00E+00	0.00E+00
2.	Average Diluted Concentration During Period	μCi/ml	0.00E+00	0.00E+00
3.	Percent of Applicable Limit (3)	%	0.00E+00	0.00E+00
D.	Gross Alpha Radioactivity			
1.	Total Release	Ci	0.00E+00	4.35E-06
E.	Volume of Waste Released (prior to dilution)	liters	1.34E+08	8.40E+07
F.	Volume of Dilution Water Used	liters	1.38E+11	9.84E+10

### NOTES:

1) The applicable limit for the WCGS is 5 Curies per year. (Reference 10 CFR 50, Appendix I, "Guides On Design Objectives For Light-Water Cooled Nuclear Power Reactors," Paragraph A.2.) The value is derived by dividing the total release Curies by 5 Curies and then multiplying the result by 100.

2) This value is derived by the following formula:

$$\% \text{ of Applicable Limit} = \frac{(\text{Average Diluted Concentration}) (100)}{(\text{MPC or ECL, Appendix B, Table 2, 10CFR20})}$$

3) This value is derived by the following formula:

$$\% \text{ of Applicable Limit} = \frac{(\text{Average Diluted Concentration}) (100)}{(2E - 04 \text{ from ODCM Section 2.1})}$$

## 2005 LIQUID EFFLUENTS

Nuclides Released	Unit	Continuous Mode		Batch Mode	
		Quarter 1	Quarter 2	Quarter 1	Quarter 2
H-3	Ci	1.66E+00	3.71E+01	3.18E+02	8.90E+01
Cr-51	Ci	N/A	N/A	N/A	9.98E-04
Mn-54	Ci	<5.68E-02	<6.69E-02	2.28E-06	<5.30E-04
Fe-55	Ci	<1.14E-01	<1.34E-01	<8.81E-04	<1.06E-03
Fe-59	Ci	<5.68E-02	<6.69E-02	<4.41E-04	<5.30E-04
Co-57	Ci	N/A	N/A	N/A	1.04E-05
Co-58	Ci	<5.68E-02	<6.69E-02	2.73E-05	2.53E-03
Co-60	Ci	<5.68E-02	<6.69E-02	4.68E-05	2.35E-04
Zn-65	Ci	<5.68E-02	<6.69E-02	<4.41E-04	<5.30E-04
Sr-89	Ci	<5.68E-03	<6.69E-03	<4.41E-05	<5.30E-05
Sr-90	Ci	<5.68E-03	<6.69E-03	<4.41E-05	<5.30E-05
Mo-99	Ci	<5.68E-02	<6.69E-02	<4.41E-04	<5.30E-04
Sb-124	Ci	N/A	N/A	<4.41E-04	4.21E-04
Sb-125	Ci	N/A	N/A	1.00E-03	5.46E-03
I-131	Ci	<1.14E-01	<1.34E-01	5.24E-04	3.92E-05
I-133	Ci	N/A	N/A	2.76E-04	1.47E-05
Cs-134	Ci	<5.68E-02	<6.69E-02	2.52E-06	5.69E-06
Cs-137	Ci	<5.68E-02	<6.69E-02	8.68E-05	1.25E-04
Ce-141	Ci	<5.68E-02	<6.69E-02	<4.41E-04	<5.30E-04
Ce-144	Ci	<5.68E-02	<6.69E-02	<4.41E-04	<5.30E-04
Na-24	Ci	N/A	N/A	N/A	1.16E-06
Rb-88	Ci	N/A	N/A	2.68E-05	N/A
Nb-95	Ci	N/A	N/A	N/A	3.77E-06
Tc-99M	Ci	N/A	N/A	3.64E-05	1.88E-05
Sb-122	Ci	N/A	N/A	N/A	1.04E-05
Sb-126	Ci	N/A	N/A	N/A	3.77E-05
I-135	Ci	N/A	N/A	5.05E-05	N/A
Gross Alpha	Ci	<1.14E-02	<1.34E-02	<8.81E-05	<1.06E-04
Ar-41	Ci	<1.14E+00	<1.34E+00	1.40E-05	<1.06E-02
Kr-85M	Ci	<1.14E+00	<1.34E+00	3.20E-05	1.11E-05
Kr-85	Ci	<1.14E+00	<1.34E+00	<8.81E-03	<1.06E-02
Kr-87	Ci	<1.14E+00	<1.34E+00	<8.81E-03	<1.06E-02
Kr-88	Ci	<1.14E+00	<1.34E+00	1.99E-05	<1.06E-02
Xe-131M	Ci	<1.14E+00	<1.34E+00	<8.81E-03	<1.06E-02
Xe-133M	Ci	<1.14E+00	<1.34E+00	2.80E-04	1.76E-04
Xe-133	Ci	<1.14E+00	<1.34E+00	2.06E-02	8.53E-03
Xe-135M	Ci	<1.14E+00	<1.34E+00	<8.81E-03	<1.06E-02
Xe-135	Ci	<1.14E+00	<1.34E+00	2.53E-03	1.28E-03

**NOTE**

"Less than" values are calculated using the Lower Limit of Detection (LLD) values listed in Table 2-1 of the ODCM multiplied by the volume of waste discharged during the respective quarter. The "less than" values are not included in the summation for the total release values.



## 2005 LIQUID EFFLUENTS

Nucl des Released	Unit	Continuous Mode		Batch Mode	
		Quarter 3	Quarter 4	Quarter 3	Quarter 4
H-3	Ci	1.53E+00	1.30E+00	1.79E+01	3.49E+01
Cr-51	Ci	N/A	N/A	N/A	N/A
Mn-54	Ci	<6.69E-02	<4.19E-02	5.63E-06	<1.46E-04
Fe-55	Ci	<1.34E-01	<8.37E-02	<3.03E-04	<2.92E-04
Fe-59	Ci	<6.69E-02	<4.19E-02	1.56E-04	<1.46E-04
Co-57	Ci	N/A	N/A	N/A	N/A
Co-58	Ci	<6.69E-02	<4.19E-02	1.79E-04	4.36E-05
Co-60	Ci	<6.69E-02	<4.19E-02	3.38E-05	2.91E-05
Zn-65	Ci	<6.69E-02	<4.19E-02	2.44E-06	<1.46E-04
Sr-89	Ci	<6.69E-03	<4.19E-03	<1.52E-05	<1.46E-05
Sr-90	Ci	<6.69E-03	<4.19E-03	<1.52E-05	<1.46E-05
Mo-99	Ci	<6.69E-02	<4.19E-02	<1.52E-04	<1.46E-04
Sb-124	Ci	N/A	N/A	1.17E-05	N/A
Sb-125	Ci	N/A	N/A	1.37E-03	4.85E-04
I-131	Ci	<1.34E-01	<8.37E-02	<3.03E-04	<2.92E-04
I-135	Ci	N/A	N/A	N/A	4.41E-07
Cs-134	Ci	<6.69E-02	<4.19E-02	2.20E-06	5.88E-06
Cs-137	Ci	<6.69E-02	<4.19E-02	2.50E-05	6.40E-05
Ce-141	Ci	<6.69E-02	<4.19E-02	<1.52E-04	<1.46E-04
Ce-144	Ci	<6.69E-02	<4.19E-02	<1.52E-04	<1.46E-04
Sr-91	Ci	N/A	N/A	3.73E-06	2.28E-06
Nb-95	Ci	N/A	N/A	N/A	1.35E-07
W-187	Ci	N/A	N/A	N/A	1.80E-04
Gross Alpha	Ci	<1.34E-02	<8.37E-03	<3.03E-05	4.35E-06
Ar-41	Ci	<1.34E+00	<8.37E-01	<3.03E-03	<2.92E-03
Kr-85M	Ci	<1.34E+00	<8.37E-01	<3.03E-03	<2.92E-03
Kr-85	Ci	<1.34E+00	<8.37E-01	<3.03E-03	<2.92E-03
Kr-87	Ci	<1.34E+00	<8.37E-01	<3.03E-03	<2.92E-03
Kr-88	Ci	<1.34E+00	<8.37E-01	<3.03E-03	<2.92E-03
Xe-131M	Ci	<1.34E+00	<8.37E-01	<3.03E-03	<2.92E-03
Xe-133M	Ci	<1.34E+00	<8.37E-01	<3.03E-03	<2.92E-03
Xe-133	Ci	<1.34E+00	<8.37E-01	<3.03E-03	<2.92E-03
Xe-135M	Ci	<1.34E+00	<8.37E-01	<3.03E-03	<2.92E-03
Xe-135	Ci	<1.34E+00	<8.37E-01	<3.03E-03	<2.92E-03

**NOTE**

"Less than" values are calculated using the Lower Limit of Detection (LLD) values listed in Table 2-1 of the ODCM multiplied by the volume of waste discharged during the respective quarter. The "less than" values are not included in the summation for the total release values.

## LIQUID CUMULATIVE DOSE SUMMARY (2005) TABLE 1

QUARTER 1 OF 2005 (mrem)	ODCM CALCULATED DOSE	ODCM LIMIT(1)	% OF LIMIT
TOTAL DOSE FOR BONE	4.56E-04	5.00E+00	9.12E-03
TOTAL DOSE FOR LIVER	6.04E-02	5.00E+00	1.21E+00
TOTAL DOSE FOR TOTAL BODY	6.02E-02	1.50E+00	4.01E+00
TOTAL DOSE FOR THYROID	6.16E-02	5.00E+00	1.23E+00
TOTAL DOSE FOR KIDNEY	6.00E-02	5.00E+00	1.20E+00
TOTAL DOSE FOR LUNG	5.99E-02	5.00E+00	1.20E+00
TOTAL DOSE FOR GI-LLI	5.98E-02	5.00E+00	1.20E+00
QUARTER 2 OF 2005 (mrem)			
TOTAL DOSE FOR BONE	1.32E-02	5.00E+00	2.65E-01
TOTAL DOSE FOR LIVER	2.17E-01	5.00E+00	4.34E+00
TOTAL DOSE FOR TOTAL BODY	2.11E-01	1.50E+00	1.41E+01
TOTAL DOSE FOR THYROID	2.02E-01	5.00E+00	4.04E+00
TOTAL DOSE FOR KIDNEY	2.05E-01	5.00E+00	4.10E+00
TOTAL DOSE FOR LUNG	2.01E-01	5.00E+00	4.02E+00
TOTAL DOSE FOR GI-LLI	2.08E-01	5.00E+00	4.17E+00
QUARTER 3 OF 2005 (mrem)			
TOTAL DOSE FOR BONE	8.80E-05	5.00E+00	1.76E-03
TOTAL DOSE FOR LIVER	2.24E-02	5.00E+00	4.47E-01
TOTAL DOSE FOR TOTAL BODY	2.23E-02	1.50E+00	1.49E+00
TOTAL DOSE FOR THYROID	2.22E-02	5.00E+00	4.45E-01
TOTAL DOSE FOR KIDNEY	2.23E-02	5.00E+00	4.46E-01
TOTAL DOSE FOR LUNG	2.23E-02	5.00E+00	4.45E-01
TOTAL DOSE FOR GI-LLI	2.23E-02	5.00E+00	4.45E-01
QUARTER 4 OF 2005 (mrem)			
TOTAL DOSE FOR BONE	2.22E-04	5.00E+00	4.45E-03
TOTAL DOSE FOR LIVER	5.77E-03	5.00E+00	1.15E-01
TOTAL DOSE FOR TOTAL BODY	5.66E-03	1.50E+00	3.78E-01
TOTAL DOSE FOR THYROID	5.45E-03	5.00E+00	1.09E-01
TOTAL DOSE FOR KIDNEY	5.56E-03	5.00E+00	1.11E-01
TOTAL DOSE FOR LUNG	5.49E-03	5.00E+00	1.10E-01
TOTAL DOSE FOR GI-LLI	5.59E-03	5.00E+00	1.12E-01
TOTALS FOR 2005 (mrem)			
TOTAL DOSE FOR BONE	1.40E-02	1.00E+01	1.40E-01
TOTAL DOSE FOR LIVER	3.05E-01	1.00E+01	3.05E+00
TOTAL DOSE FOR TOTAL BODY	2.99E-01	3.00E+00	9.97E+00
TOTAL DOSE FOR THYROID	2.91E-01	1.00E+01	2.91E+00
TOTAL DOSE FOR KIDNEY	2.93E-01	1.00E+01	2.93E+00
TOTAL DOSE FOR LUNG	2.89E-01	1.00E+01	2.89E+00
TOTAL DOSE FOR GI-LLI	2.96E-01	1.00E+01	2.96E+00

1. Based on ODCM Section 2.2, which restricts dose to the whole body to  $\leq 1.5$  mRem per quarter and 3.0 mRem per year. Dose restriction of any organ is  $\leq 5.0$  mRem per quarter and 10.0 mRem per year.

### LIQUID CUMULATIVE DOSE SUMMARY (2005) TABLE 2

A.	Fission and Activation Products (not including H-3, gases, alpha)	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total
1.	Total Release - (Ci)	2.08E-03	9.92E-03	1.63E-03	8.10E-04	1.44E-02
2.	Maximum Organ Dose (mRem)	1.79E-03	1.79E-02	1.25E-04	3.18E-04	1.90E-02
3.	Organ Dose Limit (mRem)	5.00E+00	5.00E+00	5.00E+00	5.00E+00	1.00E+01
4.	Percent of Limit	3.59E-02	3.58E-01	2.50E-03	6.36E-03	1.90E-01
B.	Tritium					
1.	Total Release - (Ci)	3.20E+02	1.26E+02	1.95E+01	3.62E+01	5.02E+02
2.	Maximum Organ Dose (mRem)	5.98E-02	1.99E-01	2.22E-02	5.45E-03	2.86E-01
3.	Organ Dose Limit (mRem)	5.00E+00	5.00E+00	5.00E+00	5.00E+00	1.00E+01
4.	Percent of Limit	1.20E+00	3.98E+00	4.45E-01	1.09E-01	2.86E+00

This table is included to show the correlation between Curies released and the associated calculated maximum organ dose. Wolf Creek ODCM methodology is used to calculate the maximum organ dose that assumes that an individual drinks the water and eats the fish from the discharge point. ODCM Section 2.2 organ dose limits are used. The less than values are not included in the summation for the total release values.

## REPORT OF 2005 RADIOACTIVE EFFLUENTS: AIRBORNE

	Unit	Quarter 1	Quarter 2
<b>A. Fission and Activation Gases</b>			
1. Total Release	Ci	3.53E-01	6.02E-01
2. Average Release Rate for Period	μCi/sec	4.54E-02	7.65E-02
3. Percent of ODCM Limit (1)	%	4.16E-03	3.76E-03
<b>B. Iodine</b>			
1. Total Release	Ci	0.00E+00	0.00E+00
2. Average Release Rate for Period	μCi/sec	0.00E+00	0.00E+00
3. Percent of Applicable Limit (2)	%	0.00E+00	0.00E+00
<b>C. Particulates</b>			
1. Particulates with Half-lives > 8 days	Ci	0.00E+00	0.00E+00
2. Average Release Rate for Period	μCi/sec	0.00E+00	0.00E+00
3. Percent of ODCM Limit (3)	%	0.00E+00	0.00E+00
4. Gross Alpha Radioactivity	Ci	0.00E+00	0.00E+00
<b>D. Tritium</b>			
1. Total Release	Ci	2.76E+00	1.43E+01
2. Average Release Rate for Period	μCi/sec	3.55E-01	1.82E+00
3. Percent of ODCM Limit (4)	%	2.66E-02	1.41E-01

**NOTES:**

- 1) The percent of ODCM limit for fission and activation gases is calculated using the following methodology:

$$\% \text{ of ODCM Limit} = \frac{(\text{Qtrly Total Beta Airdose})(100)}{10 \text{ mrad}} \text{ or } \frac{(\text{Qtrly Total Gamma Airdose})(100)}{5 \text{ mrad}}$$

The largest value calculated between Gamma and Beta air dose is listed as the % of ODCM Limit.

- 2) The percent of ODCM limit for iodine is calculated using the following methodology:

$$\% \text{ of ODCM Limit} = \frac{(\text{Total Curies of Iodine-131})(100)}{1 \text{ Curie}}$$

- 3) The percent of ODCM limit for particulates is calculated using the following methodology:

$$\% \text{ of ODCM Limit} = \frac{(\text{Highest Organ Dose Due to Particulates})(100)}{7.5 \text{ mrem}}$$

*This type of methodology is used since the Wolf Creek ties release limits to doses rather than curie release rates.*

- 4) The percent of ODCM limit for tritium is calculated using the following methodology:

$$\% \text{ of ODCM Limit} = \frac{(\text{Highest Organ Dose Due to H-3})(100)}{7.5 \text{ mrem}}$$

## REPORT OF 2005 RADIOACTIVE EFFLUENTS: AIRBORNE

	Unit	Quarter 3	Quarter 4
<b>A. Fission and Activation Gases</b>			
1. Total Release	Ci	1.78E-01	3.98E-01
2. Average Release Rate for Period	μCi/sec	2.23E-02	5.00E-02
3. Percent of ODCM Limit (1)	%	2.16E-03	3.31E-03
<b>B. Iodines</b>			
1. Total Iodine-131	Ci	0.00E+00	0.00E+00
2. Average Release Rate for Period	μCi/sec	0.00E+00	0.00E+00
3. Percent of Applicable Limit (2)	%	0.00E+00	0.00E+00
<b>C. Particulates</b>			
1. Particulates with Half-lives > 8 days	Ci	0.00E+00	0.00E+00
2. Average Release Rate for Period	μCi/sec	0.00E+00	0.00E+00
3. Percent of ODCM Limit (3)	%	0.00E+00	0.00E+00
4. Gross Alpha Radioactivity	Ci	0.00E+00	0.00E+00
<b>D. Tritium</b>			
1. Total Release	Ci	1.39E+01	1.30E+01
2. Average Release Rate for Period	μCi/sec	1.75E+00	1.64E+00
3. Percent of ODCM Limit (4)	%	1.37E-01	1.10E-01

**NOTES:**

- 1) The percent of ODCM limit for fission and activation gases is calculated using the following methodology:

$$\% \text{ of ODCM Limit} = \frac{(\text{Qtrly Total Beta Airdose})(100)}{10 \text{ mrad}} \text{ or } \frac{(\text{Qtrly Total Gamma Airdose})(100)}{5 \text{ mrad}}$$

The largest value calculated between Gamma and Beta air dose is listed as the % of ODCM Limit.

- 2) The percent of ODCM limit for iodine is calculated using the following methodology:

$$\% \text{ of ODCM Limit} = \frac{(\text{Total Curies of Iodine-131})(100)}{1 \text{ Curie}}$$

- 3) The percent of ODCM limit for particulates is calculated using the following methodology:

$$\% \text{ of ODCM Limit} = \frac{(\text{Highest Organ Dose Due to Particulates})(100)}{7.5 \text{ mrem}}$$

***This type of methodology is used since the Wolf Creek ODCM ties release limits to doses rather than curie release rates.***

- 4) The percent of ODCM limit for tritium is calculated using the following methodology:

$$\% \text{ of ODCM Limit} = \frac{(\text{Highest Organ Dose Due to H-3})(100)}{7.5 \text{ mrem}}$$

## 2005 GASEOUS EFFLUENTS

Nuclides Released	Unit	Continuous Mode		Batch Mode	
		Quarter 1	Quarter 2	Quarter 1	Quarter 2
<b>1. Fission and Activation Gases</b>					
Ar-41	Ci	N/A	N/A	3.21E-01	2.74E-01
Kr-85	Ci	N/A	N/A	2.86E-02	4.07E-02
Kr-85M	Ci	N/A	N/A	N/A	5.05E-05
Kr-87	Ci	<1.35E+01	<1.41E+01	<1.88E-02	1.12E-04
Kr-88	Ci	<1.09E+01	<1.13E+01	<1.51E-02	1.43E-04
Xe-131M	Ci	N/A	N/A	5.98E-05	1.26E-03
Xe-133	Ci	<4.34E+00	<4.51E+00	3.73E-03	2.75E-01
Xe-133M	Ci	<1.44E+01	<1.49E+01	2.36E-05	3.91E-03
Xe-135	Ci	<1.54E+00	<1.60E+00	<3.66E-03	1.13E-03
Xe-135M	Ci	N/A	N/A	N/A	1.62E-04
Xe-138	Ci	<1.63E+03	<1.69E+03	<2.25E+00	3.13E-04
Total	Ci	0.00E+00	0.00E+00	3.53E-01	6.01E-01
<b>2. Halogens (Gaseous)</b>					
I-131	Ci	<2.58E-04	<2.68E-04	<3.58E-07	<1.70E-05
I-133	Ci	<2.58E-02	<2.68E-02	<3.58E-05	<1.70E-03
Total	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>3. Particulates and Tritium</b>					
H-3	Ci	2.59E+00	9.66E+00	1.68E-01	4.65E+00
Mn-54	Ci	<2.58E-03	<2.68E-03	<3.58E-06	<1.70E-04
Fe-59	Ci	<2.58E-03	<2.68E-03	<3.58E-06	<1.70E-04
Co-58	Ci	<2.58E-03	<2.68E-03	<3.58E-06	<1.70E-04
Co-60	Ci	<2.58E-03	<2.68E-03	<3.58E-06	<1.70E-04
Zn-65	Ci	<2.58E-03	<2.68E-03	<3.58E-06	<1.70E-04
Mo-99	Ci	<2.58E-03	<2.68E-03	<3.58E-06	<1.70E-04
Cs-134	Ci	<2.58E-03	<2.68E-03	<3.58E-06	<1.70E-04
Cs-137	Ci	<2.58E-03	<2.68E-03	<3.58E-06	<1.70E-04
Ce-141	Ci	<2.58E-03	<2.68E-03	<3.58E-06	<1.70E-04
Ce-144	Ci	<2.58E-03	<2.68E-03	<3.58E-06	<1.70E-04
Sr-89	Ci	<2.58E-03	<2.68E-03	<3.58E-06	<1.70E-04
Sr-90	Ci	<2.58E-03	<2.68E-03	<3.58E-06	<1.70E-04
Gross Alpha	Ci	<2.58E-03	<2.68E-03	<3.58E-06	<1.70E-04
Total	Ci	2.59E+00	9.66E+00	1.68E-01	4.65E+00

**NOTE**

"Less than" values for Noble Gases are calculated using the Lower Limit of Detection (LLD) values obtained at Wolf Creek Generating Station multiplied by the volume of air discharged during the respective quarter. For the Halogens and Particulates the ODCM LLD values are used.

## 2005 GASEOUS EFFLUENTS

Nuclides Released	Unit	Continuous Mode		Batch Mode	
		Quarter 3	Quarter 4	Quarter 3	Quarter 4
<b>1. Fission and Activation Gases</b>					
Ar-41	Ci	N/A	N/A	1.66E-01	2.18E-01
Kr-85	Ci	N/A	N/A	5.90E-03	N/A
Kr-85M	Ci	N/A	N/A	N/A	N/A
Kr-87	Ci	<1.40E+01	<1.39E+01	<1.01E-02	<1.16E-02
Kr-88	Ci	<1.13E+01	<1.12E+01	<8.16E-03	<9.37E-03
Xe-131M	Ci	N/A	N/A	N/A	N/A
Xe-133	Ci	<4.50E+00	<4.45E+00	5.26E-03	<3.72E-03
Xe-133M	Ci	<1.49E+01	<1.47E+01	6.64E-05	<1.23E-02
Xe-135	Ci	<1.59E+00	1.80E-01	2.61E-05	<1.32E-03
Xe-138	Ci	<1.68E+03	<1.67E+03	<1.22E+00	<1.40E+00
Total	Ci	0.00E+00	1.80E-01	1.78E-01	2.18E-01
<b>2. Halogens (Gaseous)</b>					
I-131	Ci	<2.67E-04	<2.64E-04	<1.93E-07	<2.21E-07
I-133	Ci	<2.67E-02	<2.64E-02	<1.93E-05	<2.21E-05
Total	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>3. Particulates and Tritium</b>					
H-3	Ci	1.34E+01	1.27E+01	5.27E-01	3.71E-01
Mn-54	Ci	<2.67E-03	<2.64E-03	<1.93E-06	<2.21E-06
Fe-59	Ci	<2.67E-03	<2.64E-03	<1.93E-06	<2.21E-06
Co-58	Ci	<2.67E-03	<2.64E-03	<1.93E-06	<2.21E-06
Co-60	Ci	<2.67E-03	<2.64E-03	<1.93E-06	<2.21E-06
Zn-65	Ci	<2.67E-03	<2.64E-03	<1.93E-06	<2.21E-06
Mo-99	Ci	<2.67E-03	<2.64E-03	<1.93E-06	<2.21E-06
Cs-134	Ci	<2.67E-03	<2.64E-03	<1.93E-06	<2.21E-06
Cs-137	Ci	<2.67E-03	<2.64E-03	<1.93E-06	<2.21E-06
Ce-141	Ci	<2.67E-03	<2.64E-03	<1.93E-06	<2.21E-06
Ce-144	Ci	<2.67E-03	<2.64E-03	<1.93E-06	<2.21E-06
Sr-89	Ci	<2.67E-03	<2.64E-03	<1.93E-06	<2.21E-06
Sr-90	Ci	<2.67E-03	<2.64E-03	<1.93E-06	<2.21E-06
Gross Alpha	Ci	<2.67E-03	<2.64E-03	<1.93E-06	<2.21E-06
Total	Ci	1.34E+01	1.27E+01	5.27E-01	3.71E-01

**NOTE**

"Less than" values for Noble Gases are calculated using the Lower Limit of Detection (LLD) values obtained at Wolf Creek Generating Station multiplied by the volume of air discharged during the respective quarter. For the Halogens and Particulates, the ODCM LLD values are used.

GASEOUS CUMULATIVE DOSE SUMMARY (2005) TABLE 1

QUARTER 1 OF 2005 (mRem)	ODCM CALCULATED DOSE	ODCM LIMIT (1)	% OF LIMIT
TOTAL DOSE FOR BONE	0.00E+00	7.50E+00	0.00E+00
TOTAL DOSE FOR LIVER	1.95E-03	7.50E+00	2.60E-02
TOTAL DOSE FOR TOTAL BODY	1.95E-03	7.50E+00	2.60E-02
TOTAL DOSE FOR THYROID	1.95E-03	7.50E+00	2.60E-02
TOTAL DOSE FOR KIDNEY	1.95E-03	7.50E+00	2.60E-02
TOTAL DOSE FOR LUNG	1.95E-03	7.50E+00	2.60E-02
TOTAL DOSE FOR GI-LLI	1.95E-03	7.50E+00	2.60E-02
QUARTER 2 OF 2005 (mRem)			
TOTAL DOSE FOR BONE	0.00E+00	7.50E+00	0.00E+00
TOTAL DOSE FOR LIVER	1.01E-02	7.50E+00	1.35E-01
TOTAL DOSE FOR TOTAL BODY	1.01E-02	7.50E+00	1.35E-01
TOTAL DOSE FOR THYROID	1.01E-02	7.50E+00	1.35E-01
TOTAL DOSE FOR KIDNEY	1.01E-02	7.50E+00	1.35E-01
TOTAL DOSE FOR LUNG	1.01E-02	7.50E+00	1.35E-01
TOTAL DOSE FOR GI-LLI	1.01E-02	7.50E+00	1.35E-01
QUARTER 3 OF 2005 (mRem)			
TOTAL DOSE FOR BONE	0.00E+00	7.50E+00	0.00E+00
TOTAL DOSE FOR LIVER	9.86E-03	7.50E+00	1.31E-01
TOTAL DOSE FOR TOTAL BODY	9.86E-03	7.50E+00	1.31E-01
TOTAL DOSE FOR THYROID	9.86E-03	7.50E+00	1.31E-01
TOTAL DOSE FOR KIDNEY	9.86E-03	7.50E+00	1.31E-01
TOTAL DOSE FOR LUNG	9.86E-03	7.50E+00	1.31E-01
TOTAL DOSE FOR GI-LLI	9.86E-03	7.50E+00	1.31E-01
QUARTER 4 OF 2005 (mRem)			
TOTAL DOSE FOR BONE	0.00E+00	7.50E+00	0.00E+00
TOTAL DOSE FOR LIVER	9.22E-03	7.50E+00	1.23E-01
TOTAL DOSE FOR TOTAL BODY	9.22E-03	7.50E+00	1.23E-01
TOTAL DOSE FOR THYROID	9.22E-03	7.50E+00	1.23E-01
TOTAL DOSE FOR KIDNEY	9.22E-03	7.50E+00	1.23E-01
TOTAL DOSE FOR LUNG	9.22E-03	7.50E+00	1.23E-01
TOTAL DOSE FOR GI-LLI	9.22E-03	7.50E+00	1.23E-01
TOTALS FOR 2005 (mRem)			
TOTAL DOSE FOR BONE	0.00E+00	1.50E+01	0.00E+00
TOTAL DOSE FOR LIVER	3.11E-02	1.50E+01	2.08E-01
TOTAL DOSE FOR TOTAL BODY	3.11E-02	1.50E+01	2.08E-01
TOTAL DOSE FOR THYROID	3.11E-02	1.50E+01	2.08E-01
TOTAL DOSE FOR KIDNEY	3.11E-02	1.50E+01	2.08E-01
TOTAL DOSE FOR LUNG	3.11E-02	1.50E+01	2.08E-01
TOTAL DOSE FOR GI-LLI	3.11E-02	1.50E+01	2.08E-01

1. Based on Wolf Creek ODCM Section 3.2.2 which restricts dose during any calendar quarter to less than or equal to 7.5 mRem to any organ and during any calendar year to less than or equal to 15 mRem to any organ.



## GASEOUS CUMULATIVE DOSE SUMMARY (2005) TABLE 2

Nuclides Released		Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total
<b>A. Fission and Activation Gases</b>						
1.	Total Release - (Ci)	3.53E-01	6.02E-01	1.78E-01	3.98E-01	1.53E+00
2.	Total Gamma Airdose (mRad)	2.08E-04	1.88E-04	1.08E-04	1.65E-04	6.70E-04
3.	Gamma Airdose Limit (mRad)	5.00E+00	5.00E+00	5.00E+00	5.00E+00	1.00E+01
4.	Percent of Gamma Airdose Limit	4.16E-03	3.76E-03	2.16E-03	3.31E-03	6.70E-03
5.	Total Beta Airdose (mRad)	7.75E-05	9.03E-05	3.92E-05	8.07E-05	2.88E-04
6.	Beta Airdose Limit (mRad)	1.00E+01	1.00E+01	1.00E+01	1.00E+01	2.00E+01
7.	Percent of Beta Airdose Limit (mRad)	7.75E-04	9.03E-04	3.92E-04	8.07E-04	1.44E-03
<b>B. Particulates</b>						
1.	Total Particulates (Ci)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2.	Maximum Organ Dose (mRem)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3.	Organ Dose Limit (mRem)	0.00E+00	7.50E+00	7.50E+00	7.50E+00	1.50E+01
4.	Percent of Limit	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>C. Tritium</b>						
1.	Total Release (Ci)	2.76E+00	1.43E+01	1.39E+01	1.30E+01	4.41E+01
2.	Maximum Organ Dose (mRem)	2.00E-03	1.06E-02	1.03E-02	8.25E-03	3.11E-02
3.	Organ Dose Limit (mRem)	7.50E+00	7.50E+00	7.50E+00	7.50E+00	1.50E+01
4.	Percent of Limit	2.66E-02	1.41E-01	1.37E-01	1.10E-01	2.08E-01
<b>D. Iodine</b>						
1.	Total I-131, I-133 (Ci)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2.	Maximum Organ Dose (mRem)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3.	Organ Dose Limit (mRem)	7.50E+00	7.50E+00	7.50E+00	7.50E+00	1.50E+01
4.	Percent of Limit	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

This table is included to show the correlation between Curies released and the associated calculated maximum organ dose. The maximum organ dose is calculated using Wolf Creek ODCM methodology which assumes that an individual actually resides at the release point. ODCM Section 3.2.2 organ dose limits are used.

**SECTION II****SUPPLEMENTAL INFORMATION****1. Offsite Dose Calculation Manual Limits****A. For liquid waste effluents**

- A.1 The concentration of radioactive material released in liquid effluents to UNRESTRICTED AREAS shall be limited to the concentrations specified in 10 CFR 20, Appendix B, Table II, Column 2, for radionuclides other than dissolved or entrained noble gases. For dissolved or entrained noble gases, the concentration shall be limited to  $2 \times 10^{-4}$  microCuries/ml total activity.
- A.2 The dose or dose commitment to a MEMBER OF THE PUBLIC from radioactive materials in liquid effluents released, from each unit, to UNRESTRICTED AREAS shall be limited:
- During any calendar quarter to less than or equal to 1.5 mremS to the whole body and to less than or equal to 5 mremS to any organ, and
  - During any calendar year to less than or equal to 3 mremS, to the whole body and to less than or equal to 10 mremS to any organ.

**B. For gaseous waste effluents**

- B.1 The dose rate due to radioactive material released in gaseous effluents from the site to area at and beyond the SITE BOUNDARY shall be limited to the following:
- For noble gases: Less than or equal to 500 mremS/yr to the whole body and less than or equal to 3000 mremS/yr to the skin, and
  - For Iodine-131, Iodine-133, tritium, and all radionuclides in particulate form with half-lives greater than 8 days: Less than or equal to 1500 mremS/yr to any organ.
- B.2 The air dose due to noble gases released in gaseous effluents, from each unit, to areas at and beyond the SITE BOUNDARY shall be limited to the following:
- During any calendar quarter: Less than or equal to 5 mradS for gamma radiation and less than or equal to 10 mradS for beta radiation, and
  - During any calendar year: Less than or equal to 10 mradS for gamma radiation and less than or equal to 20 mradS for beta radiation.
- B.3 The dose from Iodine-131, Iodine-133, tritium, and a radionuclide in particulate form with half-lives greater than 8 days in gaseous effluents released to area at and beyond the SITE BOUNDARY shall be limited to the following:
- During any calendar quarter: Less than or equal to 7.5 mremS to any organ, and
  - During any calendar year: Less than or equal to 15 mremS to any organ.

**2. Effluent Concentration Limits (ECLs)**

Water - covered in Section I.A.

Air - covered in Section I.B.

### 3. Average Energy

Average energy of fission and activation gaseous effluents is not applicable. See ODCM Section 3.1 for the methodology used in determining the release rate limits from noble gas releases.

### 4. Measurements and Approximations of Total Radioactivity

#### A. Liquid Effluents

Liquid Release Type	Sampling Frequency	Method of Analysis	Type of Activity Analysis
1. Batch Waste Release Tank	P Each Batch	P.H.A.	Principal Gamma Emitters
	P Each Batch	P.H.A.	I-131
a. Waste Monitor Tank	P One Batch/M	P.H.A.	Dissolved and Entrained Gases (Gamma Emitters)
b. Secondary Liquid Waste Monitor Tanks	P Each Batch	L.S. S.A.C.	H-3 Gross Alpha
	P	O.S.L.	Sr-89, Sr-90
2. Continuous Releases	Daily Grab Sample	P.H.A.	Principal Gamma Emitters
		P.H.A.	I-131
a. Steam Generator Blowdown	M Grab Sample	P.H.A.	Dissolved and entrained Gases (Gamma Emitters)
b. Turbine Building Sump/Waste Water Treatment	Daily Grab Sample	L.S.	H-3
		S.A.C.	Gross Alpha
c. Lime Sludge Pond	Daily Grab Sample	O.S.L.	Sr-89, Sr-90
		O.S.L.	Fe-55

P = prior to each batch  
M = monthly  
L. S. = Liquid scintillation detector

S.A.C. = scintillation alpha counter  
O.S.L. = performed by an offsite laboratory  
P.H.A. = gamma spectrum pulse height analysis using a High Purity Germanium detector

**B. Gaseous Waste Effluents**

<b>Gaseous, Release Type</b>	<b>Sampling Frequency</b>	<b>Method of Analysis</b>	<b>Type of Activity Analysis</b>
<b>Waste Gas Decay Tank</b>	<b>P Each Tank Grab Sample</b>	<b>P.H.A.</b>	<b>Principal Gamma Emitters</b>
<b>Containment Purge or Vent</b>	<b>P Each Purge Grab Sample</b>	<b>P.H.A.</b> <hr/> <b>Gas Bubbler and L.S.</b>	<b>Principal Gamma Emitters</b> <hr/> <b>H-3 (oxide)</b>
<b>Unit Vent</b>	<b>M Grab Sample</b>	<b>P.H.A.</b> <hr/> <b>Gas Bubbler and L.S.</b>	<b>Principal Gamma Emitters</b> <hr/> <b>H-3 (oxide)</b>
<b>Radwaste Building Vent</b>	<b>M Grab Sample</b>	<b>P.H.A.</b>	<b>Principal Gamma Emitters</b>
<b>For Unit Vent and Radwaste Building Vent release types listed above</b>	<b>Continuous</b>	<b>P.H.A.</b>	<b>I-131</b> <hr/> <b>I-133</b>
	<b>Continuous</b>	<b>P.H.A. Particulate Sample</b>	<b>Principal Gamma Emitters</b>
	<b>Continuous Composite</b>	<b>S.A.C. Particulate Sample</b>	<b>Gross Alpha</b>
	<b>Continuous</b>	<b>O.S.L. Composite Particulate Sample</b>	<b>Sr-89, Sr-90</b>

**P = prior to each batch**  
**M = monthly**  
**L.S. = Liquid scintillation detector**

**S.A.C. = scintillation alpha counter**  
**O.S.L. = performed by an offsite laboratory**  
**P.H.A. = gamma spectrum pulse height analysis using a High Purity Germanium detector**

## 5. Batch Releases

A batch release is the discontinuous release of gaseous or liquid effluents which takes place over a finite period of time; usually hours or days.

There were 72 gaseous batch releases during the reporting period. The longest gaseous batch release lasted 9777 minutes, while the shortest lasted 75 minutes. The average release lasted 538 minutes with a total gaseous batch release time of 45,683 minutes.

There were 62 liquid batch releases during the reporting period. The longest liquid batch release lasted 375 minutes, while the shortest lasted 30 minutes. The average release lasted 156 minutes with a total liquid batch release time of 10,545 minutes.

## 6. Continuous Releases

A continuous release is a release of gaseous or liquid effluent, which is essentially uninterrupted for extended periods during normal operation of the facility. Four liquid release pathways were designated as continuous releases during this reporting period: Steam Generator Blowdown, Turbine Building Sump, Waste Water Treatment, and Lime Sludge Pond. Two gas release pathways were designated as continuous releases: Unit Vent and Radwaste Building Vent.

## 7. Doses to a Member of the Public from Activities Inside the Site Boundary

Four activities by members of the public were considered in this evaluation: personnel making deliveries to the plant, workers at the William Allen White Building located outside of the protected area boundary, the use of the access road south of the Radwaste Building, and public use of the cooling lake during times when fishing was allowed. The dose calculated for the maximum exposed individual for these four activities was as follows:

Plant Deliveries	3.36E-01 mRem
William Allen White Building Workers	7.42E-03 mRem
Access Road Users	3.54E-03 mRem
Lake Use	4.57E-02 mRem

The plant delivery calculations were based on deliveries 3 hours per week for 50 weeks per year. The William Allen White Building occupancy was based on normal working hours of 2000 per year. The usage factor for the access road south of the Radwaste Building was 25 hours per year. The dose to fishermen on the lake was based upon 4356 hours (12 hours a day for 363 days, based on the number of days that the lake was open to fisherman). Pathways used in the calculation were gaseous inhalation, submersion, and ground plane. All calculations were performed in accordance with the methodology and parameters in the ODCM.

**8. Additional Information**

PIR 2005-1836 – While performing a Volume Control Tank (VCT) purge to Gas Decay Tank #3 (GDT), a leak was identified on a Swagelok fitting on a moisture separator pressure switch (HAPS1035B). During the VCT purge, the Radwaste Treatment Systems Operator noticed a significant drop in pressure. The purge was secured and the system lineup verified, with no deficiencies found. The leak was found to be at a fitting on HAPS1035B, which allowed an unexpected pressure loss from GDT #3, from 21 psig to 6.8 psig over a time period of 94 minutes. Work Request 05-050478 was written. The leak resulted in an unplanned, monitored release of noble gases from the Radwaste Building Vent. No ODCM limits were exceeded. An estimated  $6.22E-03$  curies were released.

## 2005 EFFLUENT CONCENTRATION LIMITS

<u>Nuclides</u>	<u>Curies</u>	<u>Average Diluted Concentration (<math>\mu\text{Ci/ml}</math>)</u>	<u>10 CFR 20 ECL (<math>\mu\text{Ci/ml}</math>)</u>	<u>% of ECL</u>
H-3	5.01E+02	1.23E-06	1.00E-03	1.23E-01
Cr-51	9.98E-04	2.46E-12	5.00E-04	4.92E-07
Mn-54	7.91E-06	1.95E-14	3.00E-05	6.50E-08
Mn-56	N/A	N/A	7.00E-05	N/A
Co-57	1.04E-05	2.56E-14	6.00E-05	4.27E-08
Co-58	2.79E-03	6.87E-12	2.00E-05	3.44E-05
Co-60	3.44E-04	8.47E-13	3.00E-06	2.82E-05
Sb-125	8.32E-03	2.05E-11	3.00E-05	6.83E-05
Sb-124	4.33E-04	1.07E-12	7.00E-06	1.53E-05
I-131	5.63E-04	1.39E-12	1.00E-06	1.39E-04
I-133	2.91E-04	7.17E-13	7.00E-06	1.02E-05
I-135	5.09E-05	1.25E-13	3.00E-05	4.17E-07
Ce-141	N/A	N/A	3.00E-05	N/A
Cs-134	1.63E-05	4.01E-14	9.00E-07	4.46E-06
Cs-137	3.01E-04	7.41E-13	1.00E-06	7.41E-05
Nb-97	N/A	N/A	3.00E-04	N/A
Ba-139	N/A	N/A	2.00E-04	N/A
Rb-88	2.68E-05	6.60E-14	4.00E-04	1.65E-08
Sn-117M	N/A	N/A	1.00E-08	N/A
Sb-122	1.04E-05	2.56E-14	1.00E-05	2.56E-07
Sb-126	3.78E-05	9.31E-14	7.00E-06	1.33E-06
Na-24	1.16E-06	2.86E-15	5.00E-05	5.72E-09
Nb-95	3.91E-06	9.63E-15	3.00E-05	3.21E-08
Tc-99M	5.53E-05	1.36E-13	1.00E-03	1.36E-08
Fe-59	1.56E-06	3.84E-15	1.00E-05	3.84E-08
Sr-91	6.01E-06	1.48E-14	2.00E-05	7.40E-08
Zn-65	2.44E-06	6.01E-15	5.00E-06	1.20E-07
W-187	1.80E-04	4.43E-13	3.00E-05	1.48E-06
Ar-41	1.40E-05	3.45E-14	2.00E-04	1.73E-08
Kr-85	N/A	N/A	2.00E-04	N/A
Kr-85M	4.30E-05	1.06E-13	2.00E-04	5.30E-08
Kr-88	1.99E-05	4.90E-14	2.00E-04	2.45E-08
Xe-131M	N/A	N/A	2.00E-04	N/A
Xe-133M	4.55E-04	1.12E-12	2.00E-04	5.60E-07
Xe-133	2.91E-02	7.17E-11	2.00E-04	3.59E-05
Xe-135	3.81E-03	9.38E-12	2.00E-04	4.69E-06

**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT  
2005 SOLID WASTE SHIPMENTS**

**A. SOLID RADWASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL (Not irradiated fuel)**

1. Type of Waste	Unit	1- Year Period	Est. Total Error %
a. Spent resins, filter sludges evaporator bottoms, etc.	m3*	1.07E+01**	2.50E+01
	Ci	6.48E+02	
b. Dry compressible waste, contaminated equip. etc.	m3*	3.47E+02**	2.50E+01
	Ci	1.56E+00	
c. Irradiated components, control rods, etc.	m3*	0.00E+00	2.50E+01
	Ci	0.00E+00	
d. Other	m3*	0.00E+00	2.50E+01
	Ci	0.00E+00	

\*m3 = cubic meters    \*\* This is the volume sent offsite for volume reduction, prior to disposal.

**2. Estimate of Major Nuclide Composition (by type of waste).**

[Nuclides listed with % abundance greater than 10 %]

a. Spent resin, filter sludges, evaporator bottoms, etc.

<u>Nuclide Name</u>	<u>Percent Abundance</u>	<u>Curies</u>
Fe-55	24	1.57E+02
Ni-63	52	3.34E+02
Co-60	11	7.03e+01

b. Dry compressible waste, contaminated equipment, etc.

<u>Nuclide Name</u>	<u>Percent Abundance</u>	<u>Curies</u>
Fe-55	61	9.41E-01
Ni-63	23	3.57E-01



c. Irradiated components, control rods, etc. - None

d. Other - None

**3. Solid Waste Disposition**

<u>Number of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
2	Truck (Hittman Transport Services)	Barnwell Waste Management Facility, Barnwell, SC
3	Truck (Hittman Transport Services)	Duratek; Kingston, TN
2	Truck (Hittman Transport Services)	Studsvik Processing Facility, LLC; Erwin, TN
1	Truck (RACE Logistics, LLC)	RACE, LLC; Memphis, TN
2	Truck (RSB Logistics)	Studsvik Processing Facility, LLC; Erwin, TN

**4. Class of Solid Waste**

- a. Class A, Class B, Class C- Corresponding to 2a
- b. Class A - Corresponding to 2b
- c. Not applicable
- d. Not applicable

**5. Type of Container**

- a. LSA (Strong, tight), Type A, Type B - corresponding to 2a
- b. LSA (Strong, tight) - corresponding to 2b
- c. Not applicable
- d. Not applicable

**6. Solidification Agent**

- a. Not applicable
- b. Not applicable
- c. Not applicable
- d. Not applicable

**B. IRRADIATED FUEL SHIPMENTS (Disposition)**

No irradiated fuel shipments occurred during the 2005 period.

## **SECTION III**

### **HOURS AT EACH WIND SPEED AND DIRECTION**

This section documents WCGS meteorological data for wind speed, wind direction, and atmospheric stability.

The meteorological data supplied in the following tables covers the period from January 1, 2005, through December 31, 2005, and indicates the number of hours at each wind speed and direction for each stability class. All gaseous releases at the WCGS are ground level releases.

Wolf Creek Station did meet Regulatory Guide 1.23 requirement for data recovery and had a 90.58% meteorological data recovery for 2005.

### HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: JANUARY 1 THROUGH DECEMBER 31, 2005

STABILITY CLASS: A

ELEVATION: 10 METERS

WIND DIRECTION	WIND SPEED (mph)						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0.00	0.25	3.50	11.00	3.25	1.50	19.50
NNE	7.50	1.25	3.00	11.25	0.50	0.00	23.50
NE	0.50	2.50	5.75	3.50	0.00	0.00	12.25
ENE	0.25	0.50	1.75	1.00	0.00	0.00	3.50
E	0.00	3.25	3.00	4.25	0.00	0.00	10.50
ESE	0.00	1.75	8.00	6.50	0.00	0.00	16.25
SE	0.00	1.25	7.75	4.25	0.00	0.00	13.25
SSE	0.00	1.75	27.50	18.75	4.50	0.00	52.50
S	0.00	2.25	40.75	83.75	18.25	0.50	145.50
SSW	0.00	0.50	14.25	46.75	11.75	0.50	73.75
SW	0.00	0.75	6.00	1.50	0.00	0.00	8.25
WSW	0.50	1.50	5.00	1.75	0.00	0.25	9.00
W	0.00	3.75	14.00	5.50	1.25	1.00	25.50
WNW	0.50	2.00	7.50	10.50	3.25	0.50	24.25
NW	0.25	4.50	5.50	8.00	3.25	0.75	22.25
NNW	0.25	1.50	9.25	10.75	8.75	3.75	34.25
TOTAL	9.75	29.25	162.50	229.00	54.75	8.75	494.00

PERIOD OF CALM  
(HOURS): 0

### HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: JANUARY 1 THROUGH DECEMBER 31, 2005  
 STABILITY CLASS: B  
 ELEVATION: 10 METERS

WIND DIRECTION	WIND SPEED (mph)						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	1.00	2.75	10.25	10.25	3.75	0.50	28.50
NNE	0.25	2.50	6.75	8.75	0.75	0.00	19.00
NE	0.50	3.00	5.25	1.75	0.25	0.00	10.75
ENE	0.00	3.75	2.50	0.50	0.00	0.00	6.75
E	0.00	21.50	4.75	0.75	0.50	0.50	28.00
ESE	0.00	1.25	3.50	2.50	0.00	0.00	7.25
SE	0.00	2.00	10.25	1.75	0.25	0.00	14.25
SSE	0.25	5.25	12.25	5.50	2.00	0.00	25.25
S	0.00	5.50	24.75	20.50	8.75	0.25	59.75
SSW	0.25	3.00	18.25	23.75	4.00	0.50	49.75
SW	0.00	1.75	8.25	0.25	0.25	0.00	10.50
WSW	1.25	3.50	3.75	0.25	0.00	0.75	9.50
W	0.50	3.75	8.75	3.25	0.25	1.75	18.25
WNW	0.50	3.75	7.50	2.00	0.75	1.25	15.75
NW	0.50	5.00	7.25	9.25	2.25	0.50	24.75
NNW	0.50	3.00	6.50	8.75	6.25	1.25	26.25
TOTAL	4.50	71.25	140.50	99.75	30.00	7.25	354.25

PERIOD OF CALM  
 (HOURS): 0

### HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: JANUARY 1 THROUGH DECEMBER 31, 2005

STABILITY CLASS: C

ELEVATION: 10 METERS

WIND DIRECTION	WIND SPEED (mph)						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	1.25	9.50	14.25	17.50	3.00	0.25	45.75
NNE	0.75	10.50	10.75	5.50	1.00	0.00	28.50
NE	1.50	8.25	6.75	2.25	0.00	0.00	18.75
ENE	1.00	9.75	7.25	2.25	0.00	0.00	20.25
E	1.25	11.25	7.00	1.25	1.00	0.75	22.50
ESE	0.00	6.25	6.00	1.75	0.00	0.00	14.00
SE	0.75	5.75	10.75	2.75	0.00	0.00	20.00
SSE	0.50	11.75	24.25	7.75	1.50	0.00	45.75
S	0.25	14.75	23.75	15.25	9.00	0.25	63.25
SSW	2.00	5.00	23.00	19.75	3.00	0.00	52.75
SW	0.50	5.00	8.00	1.50	0.25	0.00	15.25
WSW	1.00	5.00	6.00	1.25	0.00	1.00	14.25
W	0.75	5.50	10.25	4.25	0.25	0.00	21.00
WNW	0.25	4.75	6.25	2.50	0.50	1.00	15.25
NW	1.00	7.00	5.00	9.75	5.50	2.00	30.25
NNW	0.25	3.75	11.00	10.75	3.25	2.00	31.00
TOTAL	11.75	123.75	180.25	106.00	28.25	7.25	458.50

PERIOD OF CALM  
(HOURS): 0.25

### HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: JANUARY 1 THROUGH DECEMBER 31, 2005

STABILITY CLASS: D

ELEVATION: 10 METERS

WIND DIRECTION	WIND SPEED (mph)						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	11.50	62.00	142.25	97.25	13.25	1.50	327.75
NNE	7.75	52.00	121.50	579.75	3.75	2.50	767.25
NE	27.00	119.50	75.75	18.00	0.25	0.25	240.75
ENE	16.00	69.75	30.75	3.00	0.25	0.00	119.75
E	12.00	60.75	61.00	8.25	5.50	0.25	147.75
ESE	13.25	44.00	49.50	7.75	2.50	0.00	117.00
SE	12.25	37.75	52.25	11.75	1.50	0.00	115.50
SSE	27.25	62.75	77.00	33.00	10.75	0.75	211.50
S	9.50	54.25	133.00	137.75	44.50	3.50	382.50
SSW	9.00	48.75	84.25	52.25	10.25	1.75	206.25
SW	7.00	46.00	17.50	3.00	0.50	0.75	74.75
WSW	12.25	29.50	17.50	3.75	1.50	1.75	66.25
W	7.25	24.25	28.75	10.50	2.25	0.50	73.50
WNW	16.25	29.50	41.75	21.25	9.75	1.25	119.75
NW	15.75	17.25	40.00	60.50	16.25	3.00	152.75
NNW	16.75	37.50	72.50	51.75	12.25	5.25	196.00
TOTAL	209.25	795.50	1045.25	1099.50	135.00	23.00	3319.00

PERIOD OF CALM  
(HOURS): 4

### HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: JANUARY 1 THROUGH DECEMBER 31, 2005

STABILITY CLASS: E

ELEVATION: 10 METERS

WIND DIRECTION	WIND SPEED (mph)						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	6.75	35.00	48.25	9.00	0.75	0.25	100.00
NNE	17.00	19.75	22.50	4.00	0.50	0.50	64.25
NE	21.25	33.75	17.50	0.75	0.00	0.00	73.25
ENE	17.50	32.00	11.25	1.00	0.00	0.00	61.75
E	20.75	51.25	34.25	10.00	1.25	0.00	117.50
ESE	12.50	55.25	34.75	6.75	0.00	0.00	109.25
SE	11.00	56.25	44.00	10.00	0.50	0.00	121.75
SSE	7.25	91.75	180.25	77.25	10.00	0.00	366.50
S	5.50	67.75	188.00	154.25	39.75	1.25	456.50
SSW	8.00	36.50	92.75	35.50	7.00	0.75	180.50
SW	8.25	50.75	13.75	3.50	0.00	0.00	76.25
WSW	3.25	18.50	19.75	4.00	0.00	0.25	45.75
W	3.75	15.25	38.75	4.25	0.25	0.00	62.25
WNW	1.75	13.00	33.00	3.25	1.00	0.00	52.00
NW	3.25	24.25	26.50	9.75	1.50	0.50	65.75
NNW	5.75	36.25	31.00	7.25	2.00	1.50	83.75
TOTAL	146.75	637.25	836.25	340.50	64.50	5.00	2037.00

PERIOD OF CALM

(HOURS): 188.25

### HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: JANUARY 1 THROUGH DECEMBER 31, 2005

STABILITY CLASS: F

ELEVATION: 10 METERS

WIND DIRECTION	WIND SPEED (mph)						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	4.50	30.00	9.75	0.25	0.00	0.00	44.50
NNE	7.00	22.50	6.25	0.00	0.00	0.00	35.75
NE	11.25	19.50	0.25	0.00	0.00	0.00	31.00
ENE	9.25	14.50	0.50	0.00	0.00	0.00	24.25
E	7.75	63.75	12.75	0.00	0.00	0.00	84.25
ESE	15.50	67.25	10.50	2.25	0.00	0.00	95.50
SE	11.50	68.25	16.00	175.50	0.00	0.00	271.25
SSE	4.75	75.25	34.50	3.25	0.00	0.00	117.75
S	4.50	35.25	31.75	8.75	0.00	0.00	80.25
SSW	3.25	13.00	9.25	2.00	0.00	0.00	27.50
SW	2.50	24.50	3.50	0.00	0.00	0.00	30.50
WSW	3.00	8.25	1.00	0.00	0.00	0.00	12.25
W	4.50	7.25	4.75	0.25	0.00	0.00	16.75
WNW	3.25	5.25	3.75	2.00	2.00	0.00	16.25
NW	1.00	17.25	7.00	5.50	1.50	0.00	32.25
NNW	5.50	31.50	8.75	0.25	0.00	0.00	46.00
TOTAL	94.50	503.25	160.25	200.00	3.50	0.00	966.00

PERIOD OF CALM  
(HOURS): 4



### HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: JANUARY 1 THROUGH DECEMBER 31, 2005

STABILITY CLASS: G

ELEVATION: 10 METERS

WIND DIRECTION	WIND SPEED (mph)						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	7.25	35.25	2.25	0.00	0.00	0.00	44.75
NNE	3.50	39.50	3.25	0.00	0.00	0.00	46.25
NE	6.00	36.00	1.00	0.00	0.00	0.00	43.00
ENE	10.25	31.75	0.00	0.00	0.00	0.00	42.00
E	7.75	46.75	1.50	0.00	0.00	0.00	56.00
ESE	9.75	46.00	1.00	0.00	0.00	0.00	56.75
SE	6.50	31.75	2.75	0.25	0.00	0.00	41.25
SSE	3.25	30.75	3.50	0.00	0.00	0.00	37.50
S	1.75	16.75	6.75	0.75	0.00	0.00	26.00
SSW	1.25	3.25	2.25	1.25	0.00	0.00	8.00
SW	0.75	3.25	0.00	0.00	0.00	0.00	4.00
WSW	0.75	0.50	0.00	0.00	0.00	0.00	1.25
W	2.50	0.25	0.00	0.00	0.00	0.00	2.75
WNW	2.00	0.75	0.00	0.00	0.00	0.00	2.75
NW	2.00	9.50	0.25	0.00	0.00	0.00	11.75
NNW	4.75	29.00	4.50	0.00	0.00	0.00	38.25
TOTAL	62.75	361.00	29.00	2.25	0.00	0.00	462.25

PERIOD OF CALM  
(HOURS): 2

### HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: JANUARY 1 THROUGH DECEMBER 31, 2005

STABILITY CLASS: ALL

ELEVATION: 10 METERS

WIND DIRECTION	WIND SPEED (mph)						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	32.25	174.75	230.50	145.25	24.00	4.00	610.75
NNE	43.75	148.00	174.00	609.25	6.50	3.00	984.50
NE	68.00	222.50	112.25	26.25	0.50	0.25	429.75
ENE	54.25	162.00	54.00	7.75	0.25	0.00	278.25
E	49.50	258.50	124.25	24.50	8.25	1.50	466.50
ESE	51.00	221.75	113.25	27.50	2.50	0.00	416.00
SE	42.00	203.00	143.75	206.25	2.25	0.00	597.25
SSE	43.25	279.25	359.25	145.50	28.75	0.75	856.75
S	21.50	196.50	448.75	421.00	120.25	5.75	1213.75
SSW	23.75	110.00	244.00	181.25	36.00	3.50	598.50
SW	19.00	132.00	57.00	9.75	1.00	0.75	219.50
WSW	22.00	66.75	53.00	11.00	1.50	4.00	158.25
W	19.25	60.00	105.25	28.00	4.25	3.25	220.00
WNW	24.50	59.00	99.75	41.50	17.25	4.00	246.00
NW	23.75	84.75	91.50	102.75	30.25	6.75	339.75
NNW	33.75	142.50	143.50	89.50	32.50	13.75	455.50
TOTAL	571.50	2521.25	2554.00	2077.00	316.00	51.25	8091.00

PERIOD OF CALM  
(HOURS): 198.5

## SECTION IV

### ADDITIONAL INFORMATION

#### 1. Unplanned or Abnormal Releases

One unplanned, monitored release occurred in 2005. See Section II, Additional Information.

#### 2. Offsite Dose Calculation Manual (ODCM)

The ODCM is in the form of two separate Wolf Creek Nuclear Operating Corporation (WCNOC) administrative procedures. One of these procedures, the WCNOC "Offsite Dose Calculation Manual", AP 07B-003, Revision 5, is included with this report as Attachment I. The other procedure, "Offsite Dose Calculation Manual (Radiological Environmental Monitoring Program), AP 07B-004, Revision 10, is included with this report as Attachment II.

#### 3. Major Changes to Liquid, Solid, or Gaseous Radioactive Waste Treatment Systems

There were no major changes to any of the radioactive waste treatment systems in 2005.

#### 4. Land Use Census

No new locations for dose calculation were identified during this report period.

#### 5. Radwaste Shipments

Twelve shipments of radioactive waste occurred during this report period. Section II, Subsection 3, of this report contains specific details regarding each shipment's mode of transportation and destination.

#### 6. Inoperability of Effluent Monitoring Instrumentation

No events occurred that violated ODCM Requirements Tables 2-2 and 3-2, liquid or gaseous effluent monitoring instrumentation.

#### 7. Storage Tanks

At no time during the year 2005 was there an event that led to liquid holdup tanks or gas storage tanks exceeding the limits of Technical Requirements Manual Sections 3.10.1 or 3.10.3. Technical Specification requirements for the program are now covered by Technical Requirements Manual Section 3.10, "Explosive Gas and Storage Tank Radioactivity Monitoring."

**ATTACHMENTS TO WCGS  
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT – REPORT 29**

Changes to the Wolf Creek Generating Station (WCGS) Offsite Dose Calculation Manual (ODCM) are submitted annually with the "Annual Radioactive Effluent Release Report". The WCGS ODCM is divided into two administrative procedures: WCNOG procedure AP 07B-003, "Offsite Dose Calculation Manual" and WCNOG procedure AP 07B-004, "Offsite Dose Calculation Manual (Radiological Environmental Monitoring Program)".

Attachment I is AP 07B-003, Revision 5, "Offsite Dose Calculation Manual"

Attachment II is AP 07B-004, Revision 10, "Offsite Dose Calculation Manual (Radiological Environmental Monitoring Program)"

Attachment III is AP 31A-100, Revision 5, "Solid Radwaste Process Control Program"