



Completed by
Generation in accordance with
Technical Specifications
for
United States Nuclear Regulatory Commission
License Nos.
NPF-76 & NPF-80
April 2006

Authored by:




Kim W. Reynolds
Staff Nuclear Chemist
Chemistry Division

Technical Review:



Gordon E. Williams, CHP
Health Physicist
Health Physics Division

Approved by:



Richard A. Gangluff
Manager
Chemistry Division

2005
Radioactive Effluent
Release Report

SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION

TABLE OF CONTENTS

PAGE

SUMMARY TAB

Summary and Introduction 1-1

EFFLUENT PROGRAM TAB

Supplemental Information for Effluent and Waste Disposal 2-1

- Regulatory Limits
- Effluent Concentrations Limits
- Average Energy (Million Electron Volts/Disintegration)
- Measurement and Approximations of Total Activity
- Batch Releases
- Abnormal (Unplanned) Releases
- Estimate of Total Error
- Solid Waste Shipments
- Radiological Impact on Man
- Meteorological Data
- Lower Limit of Detection
- Dose to Members of the Public

Technical Specifications and Offsite Dose Calculation Manual Controls Reporting Requirements 3-1

- Offsite Dose Calculation Manual Changes
- Annual Land Use Census
- Radioactive Waste Treatment System Design Modification Description
- Inoperable Effluent Monitoring Instrumentation Explanation
- Gas Storage Tank Curie Limit Violation Description
- Unprotected Outdoor Tank Curie Limit Violation Description
- Abnormal (Unplanned) Release Description
- Radioactive Waste Process Control Program Changes

RADIOLOGICAL DATA TAB

Gaseous Effluents..... 4-1

Liquid Effluents 5-1


Solid Waste and Irradiated Fuel Shipments 6-1

TABLE OF CONTENTS

	<u>PAGE</u>
<i>DOSE DATA TAB</i>	
Dose Accumulations.....	7-1
Results of the Protected Area Direct Radiation Measurement Program	8-1
<i>METEOROLOGICAL DATA TAB</i>	
Joint Frequency Tables	9-1
Joint Frequency Tables for First Quarter	
Joint Frequency Tables for Second Quarter	
Joint Frequency Tables for Third Quarter	
Joint Frequency Tables for Fourth Quarter	
Joint Frequency Tables for First Quarter Batch Release	
Joint Frequency Tables for Second Quarter Batch Release	
Joint Frequency Tables for Third Quarter Batch Release	
Joint Frequency Tables for Fourth Quarter Batch Release	
<i>OFFSITE DOSE CALCULATION MANUAL TAB</i>	
Offsite Dose Calculation Manual Revision 13	

Report Summary

During 2005, as in all previous years, operation of the South Texas Project created no adverse effects or health risks. The maximum radiation exposure calculated for a hypothetical person living at the boundary of the South Texas Project during 2005 due to operation of the South Texas Project was less than one millirem. For reference, this dose may be compared to the average annual radiation exposure of 360 millirem to people in the United States from all sources. Natural radiation sources in the environment contribute most of the radiation exposure to people; nuclear power operations contribute less than one millirem.




*NCRP (1987). National Council on Radiation Protection and Measurements, *Ionizing Radiation Exposure of the Population of the United States*, (Bethesda, Maryland), NCRP Report No. 93.

During 2005, the estimated total body dose to a hypothetical Member of the Public with the highest probability for exposure from radioactive effluents and direct radiation was 0.02 millirem. This total represents approximately 0.07% of the limits of 40 C.F.R. §190. Based on our 2005 Land Use Census, real individuals reside in the West by Southwest Sector, approximately 4,000 meters (2.5 miles) from the site. For dose calculation purposes, the residents at this location are characterized as the theoretically exposed with regard to food consumption, occupancy, and other uses of the areas in the plant vicinity. Our dose model assumes that this theoretically exposed individual may consume the maximum amount of food with all the food being grown or grazed at the residence. This individual receives shoreline exposure from Little Robbins Slough for 12 hours per year and consumes 21 kilograms (48 pounds) of fish taken from Little Robbins Slough. This individual receives a submersion dose from noble gases and dose from inhaled radioactive particulates, radioiodines, and tritium. This hypothetical adult is assumed to consumes 64 kilograms (150 pounds) of vegetables grown at the residence and consumes 110 kilograms (250 pounds) of meat from livestock grazed at the residence. This estimated total body dose is calculated using models and exposure pathways described in our Offsite Dose

Calculation Manual for a hypothetical individual offsite. Other dose estimates for Members of the Public onsite are listed in the report using exposure pathways not addressed by standard dose calculation methods.

Doses from releases to the environment at the South Texas Project Electric Generating Station have historically been and continue to be well below regulatory limits as shown in the following figure. Members of the public received negligible additional radiation due to the operation of the South Texas Project. This Radioactive Effluent Release Report summarizes the data describing the radioactive liquid and gaseous releases from the South Texas Project Electric Generating Station during 2005. The radioactive effluents from the South Texas Project are effectively monitored and controlled in accordance with regulatory requirements.

THEORETICAL TOTAL BODY DOSE FOR ALL PATHWAYS



Liquid and gaseous discharges from the South Texas Project are continuously monitored for radioactive content. Samples are also collected from ventilation systems and liquid discharges and analyzed for radioactivity. The sample and analysis methods are verified and augmented using an environmental laboratory. Radioactivity monitors continuously sample the ventilation exhaust systems. On the liquid discharge lines, radioactivity monitors automatically divert or isolate liquid effluents if the radioactivity is higher than expected. These monitors are also equipped with remote alarm indications in the control rooms and health physics offices.

Prior to and during power operation the South Texas Project is required to evaluate radioactive material in the environment. We are committed to sampling and analyzing environmental samples for radioactivity to support our Radiological Environmental Monitoring Program. The results of these environmental samples are reported in our Annual Environmental Operating Report. These environmental measurements affirm the accuracy of our sampling and analysis program.

The radiation monitors, and the sampling and analysis program, provide an accurate determination of the type and quantity of radioactive materials released in plant effluents. Liquid effluents are directed to the Main Cooling Reservoir that is located entirely within the site boundary. The South Texas Project continues to aggressively pursue the reduction of radioactive material in liquid effluents consistent with prudent industry practices.

Each year, the effluent monitoring results are summarized in this report and a hypothetical radiation dose to the population in the surrounding area is calculated based on gaseous radioactive effluents, meteorological conditions and liquid radioactive effluents. The hypothetical dose assumes credible paths for radioactive material to reach a member of the public, such as consumption of vegetables from a garden, fish from the river,

Introduction and Summary

inhalation, and direct exposure. The highest potential hypothetical dose to an individual at the site boundary was calculated to be less than 1 millirem which is significantly less than an average person receives from natural sources annually. The information presented in this report demonstrates that plant operation is consistently controlled to ensure that radioactive effluents remain below regulatory limits and to ensure protection of the public and the environment.

INTRODUCTION

This Radioactive Effluent Release Report is submitted for the period January 1, 2005, through December 31, 2005, in accordance with Appendix A of License Nos. NPF-76 and NPF-80, Technical Specifications and the Offsite Dose Calculation Manual.

A single submittal is made for both units combining those sections that are common. Separate tables of releases and release totals are included where separate processing systems exist.

This report includes an annual summary of hourly meteorological measurements taken during each quarter. This data appears as tables of wind direction and wind speed by atmospheric stability class. All assessments of radiation doses are performed in accordance with the Offsite Dose Calculation Manual.

Minimal quantities of radioactivity were released during 2005. Liquid effluents are discharged to the on-site Main Cooling Reservoir and subsequently released offsite. The radioactivity released in liquids beyond the site boundary was estimated using the South Texas Project Electric Generating Station Offsite Dose Calculation Manual. Solid radioactive waste is shipped offsite for disposal. The following table is a brief summary of the radioactive effluents and solid waste attributable to the station.

TYPE OF RADIOACTIVE MATERIAL	EFFLUENT TYPE	DESTINATION	VOLUME CUBIC METER	CURIES
NOBLE GAS	GAS	OFFSITE	6.0E+09	1.4E+02
PARTICULATE AND IODINES	GAS	OFFSITE	6.0E+09	4.3E-03
TRITIUM	GAS	OFFSITE	6.0E+09	2.1E+02
TRITIUM	LIQUID	OFFSITE	4.8E+06	2.5E+02
FISSION AND ACTIVATION PRODUCTS	LIQUID	OFFSITE	4.8E+06	4.3E-04
TRITIUM	LIQUID	ON-SITE	5.3E+04	1.9E+03
FISSION AND ACTIVATION PRODUCTS ⁽¹⁾	LIQUID	ON-SITE	5.3E+04	7.6E-02
SPENT RESINS AND FILTERS	SOLID	FOR BURIAL	6.8E+00	2.8E+02
DRY COMPRESSIBLE WASTE	SOLID	FOR BURIAL	2.7E+01	2.6E+00
OTHER WASTE (SECONDARY RESIN, CHARCOAL, AND FILTER CAKE)	SOLID	FOR BURIAL	2.4E+00	1.1E-04

⁽¹⁾Excludes 1.3 curies of dissolved and entrained gases.

Tritium was the largest contributor to the offsite doses from radioactive effluents both liquid and gaseous. The offsite doses are well below any regulatory limit and significantly less than the average annual radiation exposure to people in the United States from all sources (360 millirem).

Supplemental Information for Effluent and Waste Disposal

Supplemental Information for Effluent and Waste Disposal

The South Texas Project Electric Generating Station is located on 49,500,000 square meters (12,220 acres) in Matagorda County, Texas, approximately 24,000 meters (15 miles) southwest of Bay City along the west bank of the Colorado River. Until early 2005, the South Texas Project was jointly owned by Texas Genco LP, AEP Texas Central Company, the City of Austin and the City of San Antonio. In early 2005, the AEP Texas Central Company interest in the South Texas Project was transferred to Texas Genco LP and the City of San Antonio. Until late 1997, Reliant Energy HL&P was the designated licensee for the owners. On November 14, 1997, the station owners changed the licensee to STP Nuclear Operating Company, which is responsible for implementation of the Radioactive Effluent Control Program.

The South Texas Project Electric Generating Station consists of two 1,250 megawatt-electric Westinghouse pressurized water reactors. The thermal output has been up-rated by 1.4 percent increasing the electrical output. Unit 1 received a low-power testing license on August 21, 1987, obtained initial criticality on March 8, 1988, and was declared commercially operational on August 25, 1988. Unit 2 received a low-power testing license on December 16, 1988, obtained initial criticality on March 12, 1989, and was declared commercially operational on June 19, 1989. Both units together produce enough electricity to serve over one million homes.

Regulatory Limits

Fission and Activation Gases

The air dose due to noble gases released in gaseous effluents from each unit to areas at and beyond the Site Boundary shall be limited to the following:

During any calendar quarter: Less than or equal to 5 millirads for gamma radiation and less than or equal to 10 millirads for beta radiation, and

During any calendar year: Less than or equal to 10 millirads for gamma radiation and less than or equal to 20 millirads for beta radiation.

Iodines and Particulates, Half-Lives > 8 days

The dose to a Member of the Public from Iodine-131, Iodine-133, tritium, and all radionuclides in particulate form with half-lives greater than eight days in gaseous effluents released, from each unit, to areas at and beyond the Site Boundary shall be limited to the following:

During any calendar quarter: Less than or equal to 7.5 millirems to any organ; and

During any calendar year: Less than or equal to 15 millirems to any organ.

Liquid Effluents

The dose or dose commitment to a Member of the Public from radioactive materials in liquid effluents released from each unit to Unrestricted Areas shall be limited to:

During any calendar quarter: Less than or equal to 1.5 millirems to the whole body and to less than or equal to 5 millirems to any organ; and

During any calendar year: Less than or equal to 3 millirems to the whole body and to less than or equal to 10 millirems to any organ.

Effluent Concentrations Limits

Gaseous Effluents

The dose rate due to radioactive materials released in gaseous effluents from the site to areas at and beyond the Site Boundary shall be limited to the following:

For noble gases: Less than or equal to 500 millirems/year to the whole body and less than or equal to 3000 millirems/year to the skin; and

For Iodine-131, Iodine-133, tritium and all radionuclides in particulate form with half-lives greater than eight days: Less than or equal to 1500 millirems/year to any organ.

Liquid Effluents

The concentration of radioactive material released in liquid effluents to Unrestricted Areas shall be limited to 10 times the concentrations specified in 10CFR, Part 20, Appendix B, Table II, Column 2, for radionuclides other than dissolved or entrained noble gases. For dissolved or entrained noble gases, the concentration shall be limited to 2.0E-04 microcurie/milliliter total activity.

Average Energy (Million Electron Volts/Disintegration)

The Average Energy (or E-bar) shall be the average (weighted in proportion to the concentration of each radionuclide in the reactor coolant at the time of sampling) of the sum of the average beta and gamma energies per disintegration for the isotopes other than Iodines, with half-lives greater than 15 minutes, making up at least 95% of the total non-iodine activity in the coolant. The following average energy values are based on grab sample analyses from each reactor coolant systems with both samples being collected during September of 2005.

Reactor Coolant Liquid including tritium, fission products (excluding radioiodines), and corrosion and activation products

E-bar (Million Electron Volts/Disintegration)	<u>0.315</u> *	Unit 1
	<u>0.0632</u> *	Unit 2

* Includes tritium

The average energy (E-bar) values of the radionuclide mixture in gaseous releases of fission and activation gases are based on noble gases released during the reporting period.

Gaseous Effluents only Noble Gases

E-bar (Million Electron Volts/Disintegration)	<u>0.267</u>	Unit 1
	<u>0.234</u>	Unit 2

Measurement and Approximations of Total Activity

The following discussions detail the methods used to measure and approximate total activity for the following:

Gaseous Effluents: Fission and Activation Gases, Tritium, Iodines and Particulates

Liquid Effluents: Fission and Activation Products, Tritium, Dissolved and Entrained Gases

Tables A3-1 and A4-1 of the South Texas Project Electric Generating Station Offsite Dose Calculation Manual give sampling frequencies and lower limit of detection requirements for the analysis of liquid and gaseous effluent streams.

Gaseous Effluents

Analytical Methods For Gaseous Releases from the Reactor Containment Building

Monthly pre-release grab samples are collected from the plant Reactor Containment Building atmosphere. These samples are analyzed on a Gamma Spectroscopy System utilizing high purity germanium detectors for noble gas, iodine and particulate activity. Tritium specific radioactivity is measured using Liquid Scintillation Counting techniques.

The radionuclide concentrations obtained are used in conjunction with the gross noble gas release rate monitoring data collected by the radiation monitoring system to estimate the release rate of each radionuclide in the effluent streams. The noble gas release rate data collected by the unit vent radiation monitor is quantified and reported as continuous mode of release. The data from the unit vent radiation monitor in conjunction with the grab sample results of the Reactor Containment Building atmosphere are used to quantify the radioactive material released.

Analytical Methods For Continuous Gaseous Releases

Periodic noble gas and tritium grab samples are taken from the continuous release points such as the Unit Vent. Continuous sampling for particulates and iodine is also performed on effluent streams. These samples are analyzed for tritium and gamma radionuclides, as described above for gaseous releases. Strontium-89, Strontium-90, and gross alpha analyses were performed by the on-site Radiological Services Laboratory.

Noble gas quantification is performed by the plant radiation monitoring system using noble gas grab sample results and the gross noble gas release rate monitor.

Secondary liquid grab samples in conjunction with the mass of the secondary coolant lost are used for quantifying secondary steam releases. The radioactive material in the steam is based on grab sample results of the secondary liquid. The secondary liquid is analyzed for gamma emitters and tritium.

Liquid Effluents

Analytical Methods For Liquid Releases

Liquid batch releases include waste liquid treated by the liquid waste processing system and secondary chemical regeneration waste. Liquid effluents resulting from primary to secondary leakage or other plant operations are continuously monitored and are tracked as continuous releases. For batch releases, representative pre-release grab samples are taken and analyzed in accordance with Table A3-1 of the Offsite Dose Calculation Manual. For continuous releases, representative samples are collected weekly and analyzed. Radionuclide analyses are performed using a Gamma Spectroscopy System. Aliquots of each pre-release batch sample are composited in accordance with the requirements in Table A3-1 of the Offsite Dose Calculation Manual. Tritium concentrations are determined using Liquid Scintillation Counting techniques. Dissolved and entrained gas concentrations are determined by counting grab samples on the Gamma Spectroscopy System. Strontium-89, Strontium-90, gross alpha, and Iron-55 determinations are performed by the on-site Radiological Services Laboratory. The radionuclide concentrations obtained are used with the total volume for each batch release.

Batch Releases

Liquid and gaseous summaries are compiled from permits generated using a computer-based effluent management system and plant procedures. Liquid batch releases are accounted for by individual permits. Gaseous batch releases are accounted for by monthly permits and consist of reactor containment purges for the purpose of reducing radioactive material concentrations. Batch times represent the actual period of releases and the periods that the purge valves were open.

Liquid (Unit 1)

Liquid (Unit 1)	Quarter 1	Quarter 2	Quarter 3	Quarter 4
a. Number of batch releases	23	17	22	2
b. Total time period for batch releases (minutes)	1516	1098	1504	120
c. Maximum time period for a batch release (minutes)	75	71	71	69
d. Average time period for batch releases (minutes)	66	65	68	60
e. Minimum time period for a batch release (minutes)	49	33	63	51

Gaseous (Unit 1)

Gaseous (Unit 1)	Quarter 1	Quarter 2	Quarter 3	Quarter 4
a. Number of batch releases	10	3	0	0
b. Total time period for batch releases (minutes)	27420	19500	0	0
c. Maximum time period for a batch release (minutes)	7680	9720	0	0
d. Average time period for batch releases (minutes)	2742	6500	0	0
e. Minimum time period for a batch release (minutes)	120	480	0	0

Liquid (Unit 2)

Liquid (Unit 2)	Quarter 1	Quarter 2	Quarter 3	Quarter 4
a. Number of batch releases	35	15	29	23
b. Total time period for batch releases (minutes)	2109	940	1791	1310
c. Maximum time period for a batch release (minutes)	64	65	66	63
d. Average time period for batch releases (minutes)	60	63	62	57
e. Minimum time period for a batch release (minutes)	47	57	34	30

Gaseous (Unit 2)

Gaseous (Unit 2)	Quarter 1	Quarter 2	Quarter 3	Quarter 4
a. Number of batch releases	4	0	1	10
b. Total time period for batch releases (minutes)	5880	0	360	37920
c. Maximum time period for a batch release (minutes)	4320	0	360	10620
d. Average time period for batch releases (minutes)	1470	0	360	3792
e. Minimum time period for a batch release (minutes)	180	0	360	240

Abnormal (Unplanned) Releases

No abnormal releases occurred during this reporting period.

Estimate of Total Error

Estimate of Error for Liquid Effluents

The **maximum error** associated with volume and flow measurements, based upon plant calibration practice, is estimated to be $\pm 1.27\%$. The error associated with the flow measurement is small in relation to the counting uncertainty of the radionuclide concentration analysis.

The **average uncertainty** associated with counting measurements is 10% or less at the 95% confidence level.

The **error** associated with dilution volume is estimated to be $\pm 10\%$.

Estimate of Error for Gaseous Effluents

The **maximum error** associated with monitor readings, sample flow, vent flow, sample collection, monitor calibration and laboratory procedures are collectively estimated to be:

Fission and Activation Gases Low Activity (less than 10 microcurie per second)	$\pm 100\%$
Fission and Activation Gases High Activity (greater than or equal to 10 microcurie per second)	$\pm 20\%$
Iodines	$\pm 25\%$
Particulates	$\pm 25\%$
Tritium	$\pm 50\%$

The **average uncertainty** associated with counting measurements is 10% or less at the 95% confidence level for fission and activation gases, iodines, particulates and tritium.

Estimate of Error for Solid Radioactive Waste

The **error** associated with determining the volume of solid radioactive waste shipments is estimated to be $\pm 1\%$. The **error** associated with determining the filter media, spent primary resins, and spent secondary resins radioactivity is estimated to be within a factor of two of the real value and is due primarily to waste stream sampling uncertainty. The **error** associated with determining the radioactivity of other solid radioactive waste shipments is estimated to be within a factor of three of the real value.

Solid Waste Shipments

A total of eighteen shipments of radioactive filter media, spent resins, dry active and other wastes were made during the reporting period. A summary of the data is provided in the Section 6, Solid Waste and Irradiated Fuel Shipments.

Radiological Impact on Man

The data for the period January 1, 2005, through December 31, 2005, is provided in the Dose Accumulation (Section 7) and the Summary of Direct Radiation Table 8-1 (Section 8). The following dilution factors and dilution water flows were used for assessing the radiation doses due to radioactive liquid effluents released to unrestricted areas.

Receptor Location	ODCM ⁽¹⁾ Dilution Factor	Dilution Water Flow Cubic Feet/Second	Dilution Water Flow Liters/Year	Dilution Water Flow Liters/Quarter
Colorado River	1.00E+00	6.00E+02	5.36E+11	1.34E+11
Matagorda Bay	1.63E+02	9.78E+04	8.73E+13	2.18E+13
Little Robbins Slough Area	3.05E-02	1.83E+01	1.63E+10	4.08E+09

⁽¹⁾ Offsite Dose Calculation Manual factor

The dilution water flow used to estimate the individual dose due to ingestion of saltwater fish and saltwater invertebrates (shrimp) harvested from the Colorado River was 5.36E+11 liters per year for the years of 1989 through 2005. The dilution water flow used to estimate the individual dose due to ingestion of saltwater fish and saltwater invertebrates harvested from the Matagorda Bay was 8.73E+13 liters per year for the years of 1993 through 2005 as the result of a diversion channel that routes the Colorado River into Matagorda Bay. The dilution water flow used to estimate the individual dose due to ingestion of freshwater fish from the Little Robbins Slough Area was 1.63E+10 liters per year for the years 1989 through 2005. These dilution water flows were also used for estimating individual dose due to shoreline deposits. The radioactive material reported in the Liquid Effluent tables is the amount released to the Main Cooling Reservoir and does not contribute to dose until the radioactive material is released to unrestricted areas. In order to estimate the doses due to liquid effluents, the radioactive material reported must be adjusted by the values listed in the Offsite Dose Calculation Manual, Table B4-1, "Radionuclide Fractions N(i), Reaching Off-site Bodies of Water".

Meteorological Data

The 2005 meteorological data is presented in the form of joint frequency tables. Each quarter contains eight tables, one for each stability class and one for all classes combined.

A second set of joint frequency tables is provided for time periods when the reactor containment building fans were operating to remove radioactive material from the containment for personnel protection reasons. These containment purges are classified as batch releases.

Lower Limit of Detection

The Lower Limit of Detection (an a priori limit) is defined as the smallest concentration of radioactive material in a sample that will yield a net count above system background that will be detected with 95% probability, and only a 5% probability of falsely concluding that a blank observation represents a "real" signal. A zero (0) value in the attached tables indicates no activity detected.

Dose to Member of the Public

Dose to Member of the Public from Direct Radiation Outside the Site Boundary

The Offsite Dose Calculation Manual includes the direct radiation from plant structures as a component to the dose to a hypothetical, highest exposed Member of the Public located off site due to plant operations. The Offsite Dose Calculation Manual allows measurements made near the plant structures to be used in these calculations following suitable adjustments for distance and exposure time. In 2005, Thermoluminescent Dosimeters were placed along the protected area fence surrounding Units 1 and 2 of the South Texas Project as pictured in Figure 8-1 of Section 8. The results of these measurements are summarized in Table 8-1 of Section 8. The table shows that in 2005 no Thermoluminescent Dosimeter stations measured more exposure than typical of natural background determined prior to operation in the vicinity of the South Texas Project. Hence no dose due to direct radiation in 2005 was delivered to a Member of the Public located off site.

Dose to Member of the Public from Direct Radiation Inside the Site Boundary

A hypothetical Member of the Public inside the site boundary but outside the protected area fence could receive less than one millirem from direct radiation if they spent 2000 hours a year near the protected area fence south of Unit 2.

Dose to Member of the Public from Direct Radiation and Radioactive Effluents Inside the Site Boundary

A hypothetical Member of the Public outside the protected area fence but inside the site boundary could receive approximately 0.20 millirem from radioactive effluents due to inhalation and immersion. This dose plus the direct radiation dose would yield 0.20 millirem, a small fraction of 10 C.F.R. §20.1301 annual limit.

Dose to Member of the Public from Radioactive Effluents Outside the Site Boundary using ODCM Exposure Pathways

During 2005, the estimated total body dose to a hypothetical Member of the Public with the highest probability for exposure from radioactive effluents and direct radiation was 0.02 millirem. This total represents approximately 0.07% of the limits of 40 C.F.R. §190. Based on our 2005 Land Use Census, real individuals reside in the West by Southwest Sector, approximately 4,000 meters (2.5 miles) from the site. For dose calculation purposes, the residents at this location are characterized as the theoretically exposed with regard to food consumption, occupancy, and other uses of the areas in the plant vicinity. Our dose model assumes that this theoretically exposed individual may consume the maximum amount of food with all the food being grown or grazed at the residence. This individual receives shoreline exposure from Little Robbins Slough for 12 hours per year and consumes 21 kilograms (48 pounds) of fish taken from Little Robbins Slough. This individual receives a submersion dose from noble gases and dose from inhaled radioactive particulates, radioiodines, and tritium. This hypothetical adult is assumed to consume 64 kilograms (150 pounds) of vegetables grown at the residence and consumes 110 kilograms (250 pounds) of meat from livestock grazed at the residence. This estimated total body dose is calculated

using models and exposure pathways described in our Offsite Dose Calculation Manual for a hypothetical individual offsite. Other dose estimates for Members of the Public onsite are listed in the report using exposure pathways not addressed by standard dose calculation methods.

Dose to Member of the Public from Radioactive Effluents Outside the Site Boundary using Liquid to Gaseous Receptor Exposure Pathways

Consistent with normal operation of the units, approximately nineteen hundred curies of tritium were released to the Main Cooling Reservoir during 2005. Our ODCM models liquid, gaseous, and direct dose exposure pathways separately and lists methods for dose calculations using models and assumptions specified in Regulatory Guides issued by the Nuclear Regulatory Commission. The models used by our ODCM and NRC Regulatory Guides assume that radioactive material released in liquid effluent remains in liquid and any receptors are exposed via liquid pathways. Since some portion of the tritium released in liquid effluents evaporates from the main cooling reservoir, this section is included to provide an estimate of offsite dose from that gaseous source which is not modeled under our current licensing requirements. The Environmental Protection Agency has a code, Iclt3, approved to calculate airborne concentrations in regions around one or more area sources. Our main cooling reservoir with a surface area of about 28,300,000 square meters (7000 acres) is an area source and contributes tritium to the atmosphere. The atmospheric dispersion factor for the WSW sector at 4000 meters was estimated to be $4.01E-07$ seconds per cubic meter using this EPA model and 2004 meteorological data. The product of X/Q, tritium released to the MCR, and dose factor (87.9 millirem-cubic meter per second-curie) generated an estimated whole body dose of 0.07 millirem, a small fraction of the limits of 40 C.F.R. §190. A more complete description of the tritium dose to gaseous receptors from liquid effluent was evaluated by Condition Report 05-8815.

Sewage Sludge Land Farming

Sewage sludge removed from the West Sanitary Waste Treatment System was beneficially land applied onsite during 2005. This beneficial land application is not a radioactive effluent and is only reported to document this activity. The amount of radioactive material contained in the sludge was approximately 59 microcuries. This radioactive material includes nuclides of Cobalt-60 and tritium. In accordance with Texas Commission on Environmental Quality Permit No. 04523, the sludge is incorporated into the soil after application. A soil sample collected from the area in November 2005 indicated no activity above background, confirming that the concentration in the soil is below the limits established in Title 25 of the Texas Administrative Code Section 289.202 (ddd).

**Technical Specifications and Offsite Dose Calculation
Manual Controls Reporting Requirements**

**Technical Specifications and Offsite Dose Calculation Manual
Controls Reporting Requirements**

Offsite Dose Calculation Manual Changes (reference, Technical Specifications, 6.13)

The ODCM must be formally reviewed at least once every 24-months. This review typically occurs in the fall in conjunction with the annual land use census. Any recommended changes identified since the last revision are considered at that time. Several changes to Revision 12 of the ODCM have been suggested over the past 24-months and include changes to sample location descriptions associated with the Radiological Environmental Monitoring Program (REMP). In addition, Licensing and Quality identified some corrections during the review and comment process.

The changes are summarized as follows:

Replaced a reference to Technical Specification 6.14 with Technical Specification 6.8.3.n in a note to Table B5-1 of Part B that was not previously identified.

Some references in the ODCM were to the East *Branch* Little Robbins Slough rather than the East Fork. The UFSAR refers to East Fork so all occurrences of the name were changed to East Fork Little Robbins Slough.

TLD stations 38 and 40 in Table B5-3 were previously identified as necessary to meet the minimum sampling requirements of Table B5-1. That identification was removed by changing the type face from bold to normal.

A new water sampling station, #245, was added.

Some spelling errors were corrected.

These changes do not affect the methods used to calculate offsite doses or set points for effluent monitors. The changes do not affect STP's ability to meet the level of radioactive effluent control required by 10CFR20.1302, 40CFR190, 10CFR50.36a, and Appendix I to 10CFR50.

Annual Land Use Census (reference, Offsite Dose Calculation Manual Controls, 3.12.2.a)

The Land Use Census identified one resident in the east north east sector at 7200 meters (4.5 miles). Additionally the resident located in the west by northwest sector distance to the resident was more accurately measured resulting in a change of distance from the plant from 7200 to 6400 meters (4.5 to 4.0 miles). The changes of the residents locations will be included in the next revision of the ODCM and is tracked by condition report 06-5126.

Radioactive Waste Treatment System Design Modification Description (reference, Offsite Dose Calculation Manual Controls, 6.15)

No major design modifications were made to the gaseous, liquid, or solid radioactive waste treatment systems during this reporting period.

Inoperable Effluent Monitoring Instrumentation Explanation (reference, Offsite Dose Calculation Manual Controls, 6.9.1.4)

For 2005, inoperable liquid effluent monitoring instruments were corrected within the time specified in Sections 3.3.3.10 of Offsite Dose Calculation Manual Controls.

For 2005, inoperable gaseous effluent monitoring instruments were corrected within the time specified in Sections 3.3.3.11 of Offsite Dose Calculation Manual Controls.

Gas Storage Tank Curie Limit Violation Description (reference, Offsite Dose Calculation Manual Controls, 6.9.1.4)

The Reactor Coolant System Vacuum Degassing System was not used during this reporting period. Therefore, the quantity of radioactive material in the Reactor Coolant System Vacuum Degassing System Storage Tanks did not exceed the limits set forth in Section 3.11.2.6 of Technical Specifications.

Unprotected Outdoor Tank Curie Limit Violation Description (reference, Offsite Dose Calculation Manual Controls, 6.9.1.4)

There are no Unprotected Outdoor Tanks at South Texas Project Electric Generating Station. Therefore the quantity of radioactive material in any unprotected outdoor tank did not exceed the limit set forth in Section 3.11.1.4 of Technical Specifications.

Abnormal (Unplanned) Release Description (reference, Offsite Dose Calculation Manual, 6.9.1.4)

No abnormal (unplanned) releases occurred during this reporting period.

Radioactive Waste Process Control Program Changes (reference, Technical Specifications, 6.13)

There were no changes to the Radioactive Waste Process Control Program during this reporting period.

GASEOUS EFFLUENTS

**STP NUCLEAR OPERATING COMPANY
SEMIANNUAL SUMMATION OF ALL RELEASES BY QUARTER
ALL AIRBORNE EFFLUENTS**

Unit: 1

Starting : 1-Jan-2005 Ending : 30-Jun-2005

TYPE OF EFFLUENT	UNITS	QUARTER 1	QUARTER 2	EST. TOT ERROR %
A. FISSION & ACTIVATION PRODUCTS				
1. TOTAL RELEASE	CURIES	3.26E+01	1.75E+01	100
2. AVERAGE RELEASE RATE FOR PERIOD	uCi/sec	4.19E+00	2.22E+00	
3. PERCENT OF LIMIT (9.60E+04 uCi/sec)	%	4.36E-03	2.31E-03	
B. RADIOIODINES				
1. IODINE-131	CURIES	1.49E-06	1.54E-06	25
2. AVERAGE RELEASE RATE FOR PERIOD	uCi/sec	1.92E-07	1.95E-07	
3. PERCENT OF LIMIT (4.00E-02 uCi/sec)	%	4.79E-04	4.88E-04	
C. PARTICULATES				
1. PARTICULATES(HALF-LIVES>8 DAYS)	CURIES	8.05E-04	6.38E-04	25
2. AVERAGE RELEASE RATE FOR PERIOD	uCi/sec	1.04E-04	8.12E-05	
3. PERCENT OF LIMIT (3.00E-01 uCi/sec)	%	3.45E-02	2.71E-02	
4. GROSS ALPHA RADIOACTIVITY	CURIES	0.00E+00	0.00E+00	
D. TRITIUM				
1. TOTAL RELEASE	%	2.11E+01	1.18E+01	50
2. AVERAGE RELEASE RATE FOR PERIOD	uCi/sec	2.71E+00	1.51E+00	
3. PERCENT OF LIMIT (1.80E+05 uCi/sec)	%	1.50E-03	8.36E-04	

STP NUCLEAR OPERATING COMPANY

Unit 1

REPORT CATEGORY: SEMIANNUAL AIRBORNE GROUND LEVEL
CONTINUOUS AND BATCH RELEASES. TOTALS
FOR EACH NUCLIDE RELEASED.

TYPE OF ACTIVITY: FISSION GASES, IODINES, AND PARTICULATES

REPORTING PERIOD: QUARTER # 1 AND QUARTER # 2 YEAR 2005

NUCLIDES RELEASED	UNITS	CONTINUOUS MODE		BATCH MODE	
		QUARTER 1	QUARTER 2	QUARTER 1	QUARTER 2
FISSION GASES					
Argon-41	CURIES	8.40E-01	4.75E-01	1.74E+00	0.00E+00
Xenon-133	CURIES	2.02E+01	1.45E+01	9.79E+00	2.51E+00
TOTAL FOR PERIOD	CURIES	2.10E+01	1.49E+01	1.15E+01	2.51E+00
IODINES					
Iodine-131	CURIES	6.25E-08	6.86E-08	1.43E-06	1.47E-06
Iodine-133	CURIES	0.00E+00	2.59E-07	0.00E+00	0.00E+00
Iodine-135	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTAL FOR PERIOD	CURIES	6.25E-08	3.27E-07	1.43E-06	1.47E-06
PARTICULATES					
Beryllium-7	CURIES	3.30E-05	3.43E-05	2.18E-06	1.73E-06
Cobalt-57	CURIES	5.65E-08	0.00E+00	7.83E-07	3.03E-07
Cobalt-58	CURIES	2.47E-05	3.26E-05	2.54E-04	2.53E-04
Cobalt-60	CURIES	3.53E-06	6.04E-06	3.01E-05	2.57E-05
Chromium-51	CURIES	4.13E-05	1.11E-05	3.60E-04	2.28E-04
Cesium-137	CURIES	5.22E-09	1.74E-09	0.00E+00	0.00E+00
Iron-59	CURIES	4.94E-07	0.00E+00	9.46E-06	5.34E-06
Mercury-203	CURIES	2.86E-08	0.00E+00	2.39E-07	4.32E-07
Manganese-54	CURIES	1.38E-06	7.99E-07	1.37E-05	1.41E-05
Niobium-95	CURIES	1.81E-06	9.14E-07	1.62E-05	1.61E-05
Zirconium-95	CURIES	1.51E-06	7.53E-09	1.01E-05	7.57E-06
TOTAL FOR PERIOD	CURIES	1.08E-04	8.58E-05	6.97E-04	5.52E-04
OTHER					
Hydrogen-3 (Tritium)	CURIES	1.29E+01	1.03E+01	8.12E+00	1.49E+00
TOTAL FOR PERIOD	CURIES	1.29E+01	1.03E+01	8.12E+00	1.49E+00

STP NUCLEAR OPERATING COMPANY
SEMIANNUAL SUMMATION OF ALL RELEASES BY QUARTER
ALL AIRBORNE EFFLUENTS

Unit: 1

Starting : 1-Jul-2005 Ending : 31-Dec-2005

TYPE OF EFFLUENT	UNITS	QUARTER 3	QUARTER 4	EST. TOT ERROR %
A. FISSION & ACTIVATION PRODUCTS				
1. TOTAL RELEASE	CURIES	1.11E+01	1.06E+01	100
2. AVERAGE RELEASE RATE FOR PERIOD	uCi/sec	1.40E+00	1.33E+00	
3. PERCENT OF LIMIT (9.60E+04 uCi/sec)	%	1.46E-03	1.39E-03	
B. RADIOIODINES				
1. IODINE-131	CURIES	9.34E-07	0.00E+00	25
2. AVERAGE RELEASE RATE FOR PERIOD	uCi/sec	1.18E-07	0.00E+00	
3. PERCENT OF LIMIT (4.00E-02 uCi/sec)	%	2.94E-04	0.00E+00	
C. PARTICULATES				
1. PARTICULATES(HALF-LIVES>8 DAYS)	CURIES	3.59E-05	3.26E-05	25
2. AVERAGE RELEASE RATE FOR PERIOD	uCi/sec	4.51E-06	4.10E-06	
3. PERCENT OF LIMIT (3.00E-01 uCi/sec)	%	1.50E-03	1.37E-03	
4. GROSS ALPHA RADIOACTIVITY	CURIES	0.00E+00	0.00E+00	
D. TRITIUM				
1. TOTAL RELEASE	%	3.10E+01	2.33E+01	50
2. AVERAGE RELEASE RATE FOR PERIOD	uCi/sec	3.90E+00	2.93E+00	
3. PERCENT OF LIMIT (1.80E+05 uCi/sec)	%	2.17E-03	1.63E-03	

STP NUCLEAR OPERATING COMPANY

Unit 1

REPORT CATEGORY: SEMIANNUAL AIRBORNE GROUND LEVEL
CONTINUOUS AND BATCH RELEASES. TOTALS
FOR EACH NUCLIDE RELEASED.

TYPE OF ACTIVITY: FISSION GASES, IODINES, AND PARTICULATES

REPORTING PERIOD: QUARTER # 3 AND QUARTER # 4 YEAR 2005

NUCLIDES RELEASED	UNITS	CONTINUOUS MODE		BATCH MODE	
		QUARTER 3	QUARTER 4	QUARTER 3	QUARTER 4
FISSION GASES					
Argon-41	CURIES	3.35E-01	5.51E-01	0.00E+00	0.00E+00
Xenon-133	CURIES	1.08E+01	1.00E+01	0.00E+00	0.00E+00
TOTAL FOR PERIOD	CURIES	1.11E+01	1.06E+01	0.00E+00	0.00E+00
IODINES					
Iodine-131	CURIES	9.34E-07	0.00E+00	0.00E+00	0.00E+00
Iodine-133	CURIES	3.49E-06	0.00E+00	0.00E+00	0.00E+00
Iodine-135	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTAL FOR PERIOD	CURIES	4.42E-06	0.00E+00	0.00E+00	0.00E+00
PARTICULATES					
Beryllium-7	CURIES	3.03E-05	3.26E-05	0.00E+00	0.00E+00
Cobalt-58	CURIES	4.87E-06	0.00E+00	0.00E+00	0.00E+00
Cobalt-60	CURIES	5.49E-07	0.00E+00	0.00E+00	0.00E+00
Cesium-137	CURIES	4.57E-09	0.00E+00	0.00E+00	0.00E+00
Manganese-54	CURIES	1.22E-07	0.00E+00	0.00E+00	0.00E+00
TOTAL FOR PERIOD	CURIES	3.59E-05	3.26E-05	0.00E+00	0.00E+00
OTHER					
Hydrogen-3 (Tritium)	CURIES	3.10E+01	2.33E+01	0.00E+00	0.00E+00
TOTAL FOR PERIOD	CURIES	3.10E+01	2.33E+01	0.00E+00	0.00E+00

**STP NUCLEAR OPERATING COMPANY
SEMIANNUAL SUMMATION OF ALL RELEASES BY QUARTER
ALL AIRBORNE EFFLUENTS**

Unit: 2

Starting : 1-Jan-2005 Ending : 30-Jun-2005

TYPE OF EFFLUENT	UNITS	QUARTER 1	QUARTER 2	EST. TOT ERROR %
A. FISSION & ACTIVATION PRODUCTS				
1. TOTAL RELEASE	CURIES	2.60E+01	1.03E+00	100
2. AVERAGE RELEASE RATE FOR PERIOD	uCi/sec	3.34E+00	1.30E-01	
3. PERCENT OF LIMIT (9.60E+04 uCi/sec)	%	3.48E-03	1.36E-04	
B. RADIOIODINES				
1. IODINE-131	CURIES	1.55E-06	2.50E-06	25
2. AVERAGE RELEASE RATE FOR PERIOD	uCi/sec	1.99E-07	3.18E-07	
3. PERCENT OF LIMIT (4.00E-02 uCi/sec)	%	4.98E-04	7.96E-04	
C. PARTICULATES				
1. PARTICULATES(HALF-LIVES>8 DAYS)	CURIES	6.03E-05	2.95E-05	25
2. AVERAGE RELEASE RATE FOR PERIOD	uCi/sec	7.75E-06	3.75E-06	
3. PERCENT OF LIMIT (3.00E-01 uCi/sec)	%	2.58E-03	1.25E-03	
4. GROSS ALPHA RADIOACTIVITY	CURIES	0.00E+00	0.00E+00	
D. TRITIUM				
1. TOTAL RELEASE	%	7.51E+01	1.77E+01	50
2. AVERAGE RELEASE RATE FOR PERIOD	uCi/sec	9.66E+00	2.25E+00	
3. PERCENT OF LIMIT (1.80E+05 uCi/sec)	%	5.37E-03	1.25E-03	

STP NUCLEAR OPERATING COMPANY

Unit 2

REPORT CATEGORY: SEMIANNUAL AIRBORNE GROUND LEVEL
CONTINUOUS AND BATCH RELEASES. TOTALS
FOR EACH NUCLIDE RELEASED.

TYPE OF ACTIVITY: FISSION GASES, IODINES, AND PARTICULATES

REPORTING PERIOD: QUARTER # 1 AND QUARTER # 2 YEAR 2005

NUCLIDES RELEASED	UNITS	CONTINUOUS MODE		BATCH MODE	
		QUARTER 1	QUARTER 2	QUARTER 1	QUARTER 2
FISSION GASES					
Argon-41	CURIES	7.44E-01	2.41E-01	0.00E+00	0.00E+00
Krypton-85	CURIES	2.66E-01	0.00E+00	0.00E+00	0.00E+00
Xenon-131M	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Xenon-133	CURIES	2.29E+01	7.84E-01	8.30E-01	0.00E+00
Xenon-133M	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Xenon-135	CURIES	2.16E-02	0.00E+00	1.21E+00	0.00E+00
TOTAL FOR PERIOD	CURIES	2.40E+01	1.02E+00	2.04E+00	0.00E+00
IODINES					
Iodine-131	CURIES	3.90E-07	2.50E-06	1.16E-06	0.00E+00
Iodine-133	CURIES	5.07E-07	1.69E-08	0.00E+00	0.00E+00
Iodine-135	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTAL FOR PERIOD	CURIES	8.97E-07	2.52E-06	1.16E-06	0.00E+00
PARTICULATES					
Beryllium-7	CURIES	3.43E-05	2.84E-05	1.29E-05	0.00E+00
Cobalt-58	CURIES	7.77E-07	0.00E+00	4.33E-06	0.00E+00
Chromium-51	CURIES	1.35E-07	0.00E+00	4.27E-06	0.00E+00
Cesium-137	CURIES	5.73E-07	0.00E+00	0.00E+00	0.00E+00
Mercury-203	CURIES	1.14E-06	1.10E-06	1.68E-06	0.00E+00
Manganese-54	CURIES	4.14E-09	0.00E+00	0.00E+00	0.00E+00
Niobium-95	CURIES	6.51E-09	0.00E+00	2.05E-07	0.00E+00
TOTAL FOR PERIOD	CURIES	3.69E-05	2.95E-05	2.34E-05	0.00E+00
OTHER					
Hydrogen-3 (Tritium)	CURIES	4.32E+01	1.77E+01	3.19E+01	0.00E+00
TOTAL FOR PERIOD	CURIES	4.32E+01	1.77E+01	3.19E+01	0.00E+00

**STP NUCLEAR OPERATING COMPANY
SEMIANNUAL SUMMATION OF ALL RELEASES BY QUARTER
ALL AIRBORNE EFFLUENTS**

Unit: 2

Starting : 1-Jul-2005 Ending : 31-Dec-2005

TYPE OF EFFLUENT	UNITS	QUARTER 3	QUARTER 4	EST. TOT ERROR %
A. FISSION & ACTIVATION PRODUCTS				
1. TOTAL RELEASE	CURIES	6.61E-01	3.86E+01	100
2. AVERAGE RELEASE RATE FOR PERIOD	uCi/sec	8.32E-02	4.85E+00	
3. PERCENT OF LIMIT (9.60E+04 uCi/sec)	%	8.67E-05	5.05E-03	
B. RADIOIODINES				
1. IODINE-131	CURIES	2.80E-05	9.95E-04	25
2. AVERAGE RELEASE RATE FOR PERIOD	uCi/sec	3.52E-06	1.25E-04	
3. PERCENT OF LIMIT (4.00E-02 uCi/sec)	%	8.81E-03	3.13E-01	
C. PARTICULATES				
1. PARTICULATES(HALF-LIVES>8 DAYS)	CURIES	1.04E-05	1.56E-03	25
2. AVERAGE RELEASE RATE FOR PERIOD	uCi/sec	1.31E-06	1.97E-04	
3. PERCENT OF LIMIT (3.00E-01 uCi/sec)	%	4.37E-04	6.56E-02	
4. GROSS ALPHA RADIOACTIVITY	CURIES	0.00E+00	0.00E+00	
D. TRITIUM				
1. TOTAL RELEASE	%	1.13E+01	1.91E+01	50
2. AVERAGE RELEASE RATE FOR PERIOD	uCi/sec	1.42E+00	2.40E+00	
3. PERCENT OF LIMIT (1.80E+05 uCi/sec)	%	7.87E-04	1.33E-03	

STP NUCLEAR OPERATING COMPANY

Unit 2

REPORT CATEGORY: SEMIANNUAL AIRBORNE GROUND LEVEL
CONTINUOUS AND BATCH RELEASES. TOTALS
FOR EACH NUCLIDE RELEASED.

TYPE OF ACTIVITY: FISSION GASES, IODINES, AND PARTICULATES

REPORTING PERIOD: QUARTER # 3 AND QUARTER # 4 YEAR 2005

NUCLIDES RELEASED	UNITS	CONTINUOUS MODE		BATCH MODE	
		QUARTER 3	QUARTER 4	QUARTER 3	QUARTER 4
FISSION GASES					
Argon-41	CURIES	2.21E-01	2.69E-01	7.62E-02	2.79E-01
Krypton-85	CURIES	0.00E+00	0.00E+00	0.00E+00	5.64E-02
Xenon-131M	CURIES	0.00E+00	0.00E+00	0.00E+00	9.91E-02
Xenon-133	CURIES	2.21E-01	1.24E+01	1.39E-01	2.49E+01
Xenon-133M	CURIES	0.00E+00	0.00E+00	0.00E+00	2.74E-01
Xenon-135	CURIES	4.18E-03	3.48E-04	1.11E-03	3.37E-01
TOTAL FOR PERIOD	CURIES	4.45E-01	1.26E+01	2.16E-01	2.59E+01
IODINES					
Iodine-131	CURIES	2.77E-05	1.95E-04	2.78E-07	8.00E-04
Iodine-133	CURIES	3.94E-06	2.63E-06	3.43E-07	4.47E-05
Iodine-135	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTAL FOR PERIOD	CURIES	3.17E-05	1.97E-04	6.21E-07	8.45E-04
PARTICULATES					
Beryllium-7	CURIES	1.03E-05	1.37E-05	0.00E+00	0.00E+00
Cobalt-57	CURIES	0.00E+00	0.00E+00	0.00E+00	9.70E-07
Cobalt-58	CURIES	1.99E-08	1.55E-04	1.33E-08	4.80E-04
Cobalt-60	CURIES	0.00E+00	9.52E-06	0.00E+00	4.27E-05
Chromium-51	CURIES	3.90E-08	1.84E-04	2.60E-08	5.80E-04
Cesium-134	CURIES	0.00E+00	1.86E-09	0.00E+00	0.00E+00
Cesium-137	CURIES	0.00E+00	1.20E-07	0.00E+00	8.42E-07
Iron-59	CURIES	0.00E+00	2.39E-06	0.00E+00	1.05E-05
Manganese-54	CURIES	1.60E-09	9.73E-06	1.07E-09	3.08E-05
Niobium-95	CURIES	1.40E-09	6.18E-06	9.35E-10	2.32E-05
Zirconium-95	CURIES	0.00E+00	1.49E-06	0.00E+00	1.17E-05
TOTAL FOR PERIOD	CURIES	1.04E-05	3.83E-04	4.13E-08	1.18E-03
OTHER					
Hydrogen-3 (Tritium)	CURIES	1.12E+01	4.08E+00	7.30E-02	1.50E+01
TOTAL FOR PERIOD	CURIES	1.12E+01	4.08E+00	7.30E-02	1.50E+01

STP NUCLEAR OPERATING COMPANY

Unit 1 plus 2 Total

REPORT CATEGORY: ANNUAL AIRBORNE GROUND LEVEL RELEASES.
TOTALS FOR EACH NUCLIDE RELEASED. FOR
ALL OF 2005

NUCLIDES RELEASED	UNITS	UNIT 1 2005	UNIT 2 2005	TOTAL 2005
FISSION GASES				
Argon-41	CURIES	3.940E+00	1.827E+00	5.767E+00
Krypton-85	CURIES	0.000E+00	3.225E-01	3.225E-01
Xenon-131M	CURIES	0.000E+00	9.910E-02	9.910E-02
Xenon-133	CURIES	6.759E+01	6.216E+01	1.297E+02
Xenon-133M	CURIES	0.000E+00	2.737E-01	2.737E-01
Xenon-135	CURIES	0.000E+00	1.571E+00	1.571E+00
TOTAL FOR PERIOD	CURIES	7.153E+01	6.625E+01	1.378E+02
IODINES				
Iodine-131	CURIES	3.961E-06	1.027E-03	1.031E-03
Iodine-133	CURIES	3.748E-06	5.213E-05	5.588E-05
Iodine-135	CURIES	0.000E+00	0.000E+00	0.000E+00
TOTAL FOR PERIOD	CURIES	7.709E-06	1.079E-03	1.087E-03
PARTICULATES				
Beryllium-7	CURIES	1.336E-04	9.961E-05	2.332E-04
Cobalt-57	CURIES	1.143E-06	9.698E-07	2.112E-06
Cobalt-58	CURIES	5.694E-04	6.405E-04	1.210E-03
Cobalt-60	CURIES	6.599E-05	5.220E-05	1.182E-04
Chromium-51	CURIES	6.409E-04	7.685E-04	1.409E-03
Cesium-134	CURIES	0.000E+00	1.862E-09	1.862E-09
Cesium-137	CURIES	1.153E-08	1.536E-06	1.547E-06
Iron-59	CURIES	1.529E-05	1.291E-05	2.820E-05
Mercury-203	CURIES	6.998E-07	3.931E-06	4.631E-06
Manganese-54	CURIES	3.012E-05	4.056E-05	7.067E-05
Niobium-95	CURIES	3.499E-05	2.961E-05	6.460E-05
Zirconium-95	CURIES	1.919E-05	1.323E-05	3.242E-05
TOTAL FOR PERIOD	CURIES	1.511E-03	1.664E-03	3.175E-03
OTHER				
Hydrogen-3 (Tritium)	CURIES	8.696E+01	1.231E+02	2.100E+02
TOTAL FOR PERIOD	CURIES	8.696E+01	1.231E+02	2.100E+02

LIQUID EFFLUENTS

STP NUCLEAR OPERATING COMPANY
SEMIANNUAL SUMMATION OF ALL RELEASES BY QUARTER
ALL LIQUID EFFLUENTS

Unit: 1

Starting : 1-Jan-2005 Ending : 30-Jun-2005

TYPE OF EFFLUENT	UNITS	QUARTER 1	QUARTER 2	EST. TOT ERROR %
A. FISSION & ACTIVATION PRODUCTS				
1. TOTAL RELEASE (NOT INCLUDING TRITIUM, GASES, ALPHA)	CURIES	8.171E-03	6.558E-03	10
2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/mL	4.480E-09	4.218E-09	
3. PERCENT OF EC* LIMIT (FRACTIONAL)	%	8.881E-03	3.738E-03	
B. TRITIUM				
1. TOTAL RELEASE	CURIES	2.301E+02	3.957E+01	10
2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/mL	1.262E-04	2.545E-05	
3. % OF LIMIT (1.00E-02 uCi/mL)	%	1.261E+00	2.545E-01	
C. DISSOLVED AND ENTRAINED GASES				
1. TOTAL RELEASE	CURIES	9.606E-04	1.385E-04	10
2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/mL	5.267E-10	8.907E-11	
3. PERCENT OF LIMIT (2.00E-04 uCi/mL)	%	2.633E-04	4.455E-05	
D. GROSS ALPHA RADIOACTIVITY				
1. TOTAL RELEASE	CURIES	0.000E+00	0.000E+00	10
E. WASTE VOL RELEASED				
1. TOTAL PRE-DILUTION VOLUME	LITERS	7.893E+06	6.908E+06	1
2. BATCH PRE-DILUTION VOLUME	LITERS	1.216E+06	8.707E+05	1
F. VOLUME OF DILUTION WATER USED**	LITERS	1.816E+09	1.548E+09	10

*EC= Effluent Concentration

**"Volume of dilution water used" means the volume of water circulated through the main condenser during the actual time of release. Liquid effluent releases ultimately dilute into the volume of the onsite main cooling reservoir and then into offsite water bodies as described in Section 2, subsection Radiological Impact on Man of this report.

STP NUCLEAR OPERATING COMPANY

Unit 1

REPORT CATEGORY: SEMIANNUAL LIQUID CONTINUOUS AND BATCH
RELEASES. TOTALS FOR EACH NUCLIDE RELEASED.

TYPE OF ACTIVITY: ALL RADIONUCLIDES

REPORTING PERIOD: QUARTER # 1 AND QUARTER # 2 YEAR 2005

NUCLIDES RELEASED	UNITS	CONTINUOUS RELEASES		BATCH RELEASES	
		QUARTER 1	QUARTER 2	QUARTER 1	QUARTER 2
ALL NUCLIDES					
Silver-110M	CURIES	0.00E+00	0.00E+00	1.36E-05	0.00E+00
Beryllium-7	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cobalt-57	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cobalt-58	CURIES	0.00E+00	0.00E+00	2.34E-04	2.14E-03
Cobalt-60	CURIES	0.00E+00	0.00E+00	3.04E-03	9.68E-04
Chromium-51	CURIES	0.00E+00	0.00E+00	9.60E-05	5.76E-04
Cesium-134	CURIES	0.00E+00	0.00E+00	1.88E-04	7.76E-06
Cesium-137	CURIES	0.00E+00	0.00E+00	2.51E-04	2.86E-05
Iron-55	CURIES	0.00E+00	0.00E+00	1.92E-03	6.48E-04
Iron-59	CURIES	0.00E+00	0.00E+00	0.00E+00	1.96E-05
Tritium	CURIES	4.25E-02	4.24E-02	2.30E+02	3.95E+01
Iodine-131	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Iodine-133	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Krypton-85	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Krypton-85M	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Manganese-54	CURIES	0.00E+00	0.00E+00	2.63E-04	4.65E-04
Sodium-24	CURIES	0.00E+00	0.00E+00	5.50E-07	0.00E+00
Niobium-95	CURIES	0.00E+00	0.00E+00	4.01E-06	4.08E-05
Antimony-122	CURIES	0.00E+00	0.00E+00	8.59E-05	0.00E+00
Antimony-124	CURIES	0.00E+00	0.00E+00	7.73E-05	2.06E-04
Antimony-125	CURIES	0.00E+00	0.00E+00	8.86E-04	1.36E-03
Antimony-126	CURIES	0.00E+00	0.00E+00	3.97E-06	0.00E+00
Tin-117M	CURIES	0.00E+00	0.00E+00	0.00E+00	3.09E-06
Strontium-89	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Strontium-90	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Technetium-99M	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Tellurium-125M	CURIES	0.00E+00	0.00E+00	1.11E-03	0.00E+00
Tellurium-129M	CURIES	0.00E+00	0.00E+00	0.00E+00	8.69E-05
Xenon-131M	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Xenon-133	CURIES	0.00E+00	0.00E+00	8.37E-04	6.95E-05
Xenon-133M	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Xenon-135	CURIES	0.00E+00	0.00E+00	1.24E-04	6.90E-05
Zirconium-95	CURIES	0.00E+00	0.00E+00	0.00E+00	1.59E-05
TOTAL FOR PERIOD	CURIES	4.25E-02	4.24E-02	2.30E+02	3.95E+01

STP NUCLEAR OPERATING COMPANY
SEMIANNUAL SUMMATION OF ALL RELEASES BY QUARTER
ALL LIQUID EFFLUENTS

Unit: 1

Starting : 1-Jul-2005 Ending : 31-Dec-2005

TYPE OF EFFLUENT	UNITS	QUARTER 3	QUARTER 4	EST. TOT ERROR %
A. FISSION & ACTIVATION PRODUCTS				
1. TOTAL RELEASE (NOT INCLUDING TRITIUM, GASES, ALPHA)	CURIES	9.259E-03	6.029E-04	10
2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/mL	3.584E-09	3.770E-09	
3. PERCENT OF EC* LIMIT (FRACTIONAL)	%	7.928E-03	5.878E-03	
B. TRITIUM				
1. TOTAL RELEASE	CURIES	1.346E+02	3.877E+00	10
2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/mL	5.210E-05	2.424E-05	
3. % OF LIMIT (1.00E-02 uCi/mL)	%	5.208E-01	2.424E-01	
C. DISSOLVED AND ENTRAINED GASES				
1. TOTAL RELEASE	CURIES	3.067E-05	0.000E+00	10
2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/mL	1.187E-11	0.000E+00	
3. PERCENT OF LIMIT (2.00E-04 uCi/mL)	%	5.935E-06	0.000E+00	
D. GROSS ALPHA RADIOACTIVITY				
1. TOTAL RELEASE	CURIES	0.000E+00	0.000E+00	10
E. WASTE VOL RELEASED				
1. TOTAL PRE-DILUTION VOLUME	LITERS	1.037E+07	5.929E+06	1
2. BATCH PRE-DILUTION VOLUME	LITERS	1.234E+06	8.032E+04	1
F. VOLUME OF DILUTION WATER USED**	LITERS	2.573E+09	1.540E+08	10

*EC= Effluent Concentration

**"Volume of dilution water used" means the volume of water circulated through the main condenser during the actual time of release. Liquid effluent releases ultimately dilute into the volume of the onsite main cooling reservoir and then into offsite water bodies as described in Section 2, subsection Radiological Impact on Man of this report.

STP NUCLEAR OPERATING COMPANY

Unit 1

REPORT CATEGORY: SEMIANNUAL LIQUID CONTINUOUS AND BATCH
RELEASES. TOTALS FOR EACH NUCLIDE RELEASED.

TYPE OF ACTIVITY: ALL RADIONUCLIDES

REPORTING PERIOD: QUARTER # 3 AND QUARTER # 4 YEAR 2005

NUCLIDES RELEASED	UNITS	CONTINUOUS RELEASES		BATCH RELEASES	
		QUARTER 3	QUARTER 4	QUARTER 3	QUARTER 4
ALL NUCLIDES					
Silver-110M	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Beryllium-7	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cobalt-57	CURIES	0.00E+00	0.00E+00	1.07E-05	0.00E+00
Cobalt-58	CURIES	0.00E+00	0.00E+00	2.68E-03	7.19E-05
Cobalt-60	CURIES	0.00E+00	0.00E+00	2.50E-03	1.34E-04
Chromium-51	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cesium-134	CURIES	0.00E+00	0.00E+00	3.93E-04	1.22E-05
Cesium-137	CURIES	0.00E+00	0.00E+00	5.71E-04	2.29E-05
Iron-55	CURIES	0.00E+00	0.00E+00	1.36E-03	1.21E-04
Iron-59	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Tritium	CURIES	1.92E-01	1.68E-01	1.34E+02	3.71E+00
Iodine-131	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Iodine-133	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Krypton-85	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Krypton-85M	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Manganese-54	CURIES	0.00E+00	0.00E+00	1.26E-03	2.01E-04
Sodium-24	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Niobium-95	CURIES	0.00E+00	0.00E+00	1.27E-05	0.00E+00
Antimony-122	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Antimony-124	CURIES	0.00E+00	0.00E+00	1.38E-05	0.00E+00
Antimony-125	CURIES	0.00E+00	0.00E+00	4.63E-04	3.96E-05
Antimony-126	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Tin-117M	CURIES	0.00E+00	0.00E+00	1.45E-06	0.00E+00
Strontium-89	CURIES	0.00E+00	0.00E+00	4.28E-06	5.81E-07
Strontium-90	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Technetium-99M	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Tellurium-125M	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Tellurium-129M	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Xenon-131M	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Xenon-133	CURIES	0.00E+00	0.00E+00	3.07E-05	0.00E+00
Xenon-133M	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Xenon-135	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Zirconium-95	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTAL FOR PERIOD	CURIES	1.92E-01	1.68E-01	1.34E+02	3.71E+00

STP NUCLEAR OPERATING COMPANY
SEMIANNUAL SUMMATION OF ALL RELEASES BY QUARTER
ALL LIQUID EFFLUENTS

Unit: 2

Starting : 1-Jan-2005 Ending : 30-Jun-2005

TYPE OF EFFLUENT	UNITS	QUARTER 1	QUARTER 2	EST. TOT ERROR %
A. FISSION & ACTIVATION PRODUCTS				
1. TOTAL RELEASE (NOT INCLUDING TRITIUM, GASES, ALPHA)	CURIES	1.705E-02	4.744E-03	10
2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/mL	9.348E-09	3.051E-09	
3. PERCENT OF EC* LIMIT (FRACTIONAL)	%	1.018E-02	3.754E-03	
B. TRITIUM				
1. TOTAL RELEASE	CURIES	8.257E+02	3.082E+02	10
2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/mL	4.527E-04	1.982E-04	
3. % OF LIMIT (1.00E-02 uCi/mL)	%	3.045E+00	1.977E+00	
C. DISSOLVED AND ENTRAINED GASES				
1. TOTAL RELEASE	CURIES	4.337E-03	1.723E-02	10
2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/mL	2.378E-09	1.108E-08	
3. PERCENT OF LIMIT (2.00E-04 uCi/mL)	%	7.996E-04	5.525E-03	
D. GROSS ALPHA RADIOACTIVITY				
1. TOTAL RELEASE	CURIES	0.000E+00	0.000E+00	10
E. WASTE VOL RELEASED				
1. TOTAL PRE-DILUTION VOLUME	LITERS	5.413E+06	3.698E+06	1
2. BATCH PRE-DILUTION VOLUME	LITERS	1.886E+06	8.348E+05	1
F. VOLUME OF DILUTION WATER USED**	LITERS	2.706E+09	1.555E+09	10

*EC= Effluent Concentration

**"Volume of dilution water used" means the volume of water circulated through the main condenser during the actual time of release. Liquid effluent releases ultimately dilute into the volume of the onsite main cooling reservoir and then into offsite water bodies as described in Section 2, subsection Radiological Impact on Man of this report.

STP NUCLEAR OPERATING COMPANY

Unit 2

REPORT CATEGORY: SEMIANNUAL LIQUID CONTINUOUS AND BATCH
RELEASES. TOTALS FOR EACH NUCLIDE RELEASED.

TYPE OF ACTIVITY: ALL RADIONUCLIDES

REPORTING PERIOD: QUARTER # 1 AND QUARTER # 2 YEAR 2005

NUCLIDES RELEASED	UNITS	CONTINUOUS RELEASES		BATCH RELEASES	
		QUARTER 1	QUARTER 2	QUARTER 1	QUARTER 2
ALL NUCLIDES					
Silver-110M	CURIES	0.00E+00	0.00E+00	3.77E-06	0.00E+00
Beryllium-7	CURIES	0.00E+00	0.00E+00	3.21E-05	0.00E+00
Cobalt-57	CURIES	0.00E+00	0.00E+00	5.65E-05	1.46E-06
Cobalt-58	CURIES	0.00E+00	0.00E+00	5.61E-03	1.62E-04
Cobalt-60	CURIES	0.00E+00	0.00E+00	5.29E-03	1.11E-03
Chromium-51	CURIES	0.00E+00	0.00E+00	5.93E-06	7.64E-05
Cesium-134	CURIES	0.00E+00	0.00E+00	1.24E-04	2.38E-05
Cesium-137	CURIES	0.00E+00	0.00E+00	5.01E-04	9.88E-05
Iron-55	CURIES	0.00E+00	0.00E+00	4.50E-03	1.68E-03
Iron-59	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Tritium	CURIES	1.61E-02	4.34E-02	8.26E+02	3.08E+02
Iodine-131	CURIES	0.00E+00	0.00E+00	0.00E+00	1.02E-05
Iodine-133	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Krypton-85	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Krypton-85M	CURIES	0.00E+00	0.00E+00	0.00E+00	2.71E-06
Manganese-54	CURIES	0.00E+00	0.00E+00	2.27E-04	8.43E-04
Sodium-24	CURIES	0.00E+00	0.00E+00	2.28E-06	0.00E+00
Niobium-95	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Antimony-122	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Antimony-124	CURIES	0.00E+00	0.00E+00	1.60E-05	0.00E+00
Antimony-125	CURIES	0.00E+00	0.00E+00	6.86E-04	7.18E-04
Antimony-126	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Tin-117M	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Strontium-89	CURIES	0.00E+00	0.00E+00	0.00E+00	8.33E-06
Strontium-90	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Technetium-99M	CURIES	0.00E+00	0.00E+00	1.30E-06	3.60E-06
Telurium-125M	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Tellurium-129M	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Xenon-131M	CURIES	0.00E+00	0.00E+00	0.00E+00	6.75E-05
Xenon-133	CURIES	0.00E+00	0.00E+00	4.11E-03	1.69E-02
Xenon-133M	CURIES	0.00E+00	0.00E+00	2.49E-05	1.63E-04
Xenon-135	CURIES	0.00E+00	0.00E+00	1.98E-04	5.60E-05
Zirconium-95	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTAL FOR PERIOD	CURIES	1.61E-02	4.34E-02	8.26E+02	3.08E+02

STP NUCLEAR OPERATING COMPANY
SEMIANNUAL SUMMATION OF ALL RELEASES BY QUARTER
ALL LIQUID EFFLUENTS

Unit: 2

Starting : 1-Jul-2005 Ending : 31-Dec-2005

TYPE OF EFFLUENT	UNITS	QUARTER 3	QUARTER 4	EST. TOT ERROR %
A. FISSION & ACTIVATION PRODUCTS				
1. TOTAL RELEASE (NOT INCLUDING TRITIUM, GASES, ALPHA)	CURIES	1.515E-02	1.507E-02	10
2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/mL	5.864E-09	9.423E-08	
3. PERCENT OF EC* LIMIT (FRACTIONAL)	%	6.060E-03	8.982E-03	
B. TRITIUM				
1. TOTAL RELEASE	CURIES	2.628E+02	1.227E+02	10
2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/mL	1.017E-04	7.672E-04	
3. % OF LIMIT (1.00E-02 uCi/mL)	%	9.236E-01	8.239E-01	
C. DISSOLVED AND ENTRAINED GASES				
1. TOTAL RELEASE	CURIES	1.885E-01	1.050E+00	10
2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/mL	7.297E-08	6.565E-06	
3. PERCENT OF LIMIT (2.00E-04 uCi/mL)	%	3.313E-02	3.524E-01	
D. GROSS ALPHA RADIOACTIVITY				
1. TOTAL RELEASE	CURIES	0.000E+00	0.000E+00	10
E. WASTE VOL RELEASED				
1. TOTAL PRE-DILUTION VOLUME	LITERS	9.028E+06	4.068E+06	1
2. BATCH PRE-DILUTION VOLUME	LITERS	1.601E+06	1.166E+06	1
F. VOLUME OF DILUTION WATER USED**				
	LITERS	2.836E+09	1.486E+09	10

*EC= Effluent Concentration

***"Volume of dilution water used" means the volume of water circulated through the main condenser during the actual time of release. Liquid effluent releases ultimately dilute into the volume of the onsite main cooling reservoir and then into offsite water bodies as described in Section 2, subsection Radiological Impact on Man of this report.

STP NUCLEAR OPERATING COMPANY

Unit 2

REPORT CATEGORY: SEMIANNUAL LIQUID CONTINUOUS AND BATCH
RELEASES. TOTALS FOR EACH NUCLIDE RELEASED.

TYPE OF ACTIVITY: ALL RADIONUCLIDES

REPORTING PERIOD: QUARTER # 3 AND QUARTER # 4 YEAR 2005

NUCLIDES RELEASED	UNITS	CONTINUOUS RELEASES		BATCH RELEASES	
		QUARTER 3	QUARTER 4	QUARTER 3	QUARTER 4
ALL NUCLIDES					
Silver-110M	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Beryllium-7	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cobalt-57	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cobalt-58	CURIES	0.00E+00	0.00E+00	4.33E-04	2.62E-03
Cobalt-60	CURIES	0.00E+00	0.00E+00	3.61E-03	9.86E-04
Chromium-51	CURIES	0.00E+00	0.00E+00	5.44E-04	3.80E-03
Cesium-134	CURIES	0.00E+00	0.00E+00	1.80E-05	6.08E-07
Cesium-137	CURIES	0.00E+00	0.00E+00	6.34E-05	9.78E-06
Iron-55	CURIES	0.00E+00	0.00E+00	2.58E-03	1.42E-03
Iron-59	CURIES	0.00E+00	0.00E+00	0.00E+00	6.60E-05
Tritium	CURIES	6.68E-02	1.74E-02	2.63E+02	1.23E+02
Iodine-131	CURIES	0.00E+00	0.00E+00	1.24E-05	5.66E-04
Iodine-133	CURIES	0.00E+00	0.00E+00	0.00E+00	7.59E-06
Krypton-85	CURIES	0.00E+00	0.00E+00	3.42E-04	4.50E-03
Krypton-85M	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Manganese-54	CURIES	0.00E+00	0.00E+00	4.72E-04	1.33E-04
Sodium-24	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Niobium-95	CURIES	0.00E+00	0.00E+00	1.81E-05	1.78E-04
Antimony-122	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Antimony-124	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Antimony-125	CURIES	0.00E+00	0.00E+00	9.92E-04	1.18E-04
Antimony-126	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Tin-117M	CURIES	0.00E+00	0.00E+00	0.00E+00	2.32E-06
Strontium-89	CURIES	0.00E+00	0.00E+00	6.45E-06	3.02E-06
Strontium-90	CURIES	0.00E+00	0.00E+00	2.98E-06	0.00E+00
Technetium-99M	CURIES	0.00E+00	0.00E+00	0.00E+00	9.06E-06
Tellurium-125M	CURIES	0.00E+00	0.00E+00	6.40E-03	5.04E-03
Tellurium-129M	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Xenon-131M	CURIES	0.00E+00	0.00E+00	3.26E-03	2.12E-02
Xenon-133	CURIES	0.00E+00	0.00E+00	1.84E-01	1.01E+00
Xenon-133M	CURIES	0.00E+00	0.00E+00	9.94E-04	1.44E-02
Xenon-135	CURIES	0.00E+00	0.00E+00	1.51E-05	4.66E-03
Zirconium-95	CURIES	0.00E+00	0.00E+00	2.36E-06	1.11E-04
TOTAL FOR PERIOD	CURIES	6.68E-02	1.74E-02	2.63E+02	1.24E+02

STP NUCLEAR OPERATING COMPANY

Unit 1 plus 2 Total

REPORT CATEGORY: ANNUAL LIQUID RELEASES. TOTALS FOR EACH
NUCLIDE RELEASED. FOR ALL OF 2005

NUCLIDES RELEASED	UNITS	UNIT 1 2005	UNIT 2 2005	TOTAL 2005
ALL NUCLIDES				
Silver-110M	CURIES	1.36E-05	3.77E-06	1.74E-05
Beryllium-7	CURIES	0.00E+00	3.21E-05	3.21E-05
Cobalt-57	CURIES	1.07E-05	5.80E-05	6.87E-05
Cobalt-58	CURIES	5.12E-03	8.82E-03	1.39E-02
Cobalt-60	CURIES	6.64E-03	1.10E-02	1.76E-02
Chromium-51	CURIES	6.72E-04	4.43E-03	5.10E-03
Cesium-134	CURIES	6.01E-04	1.66E-04	7.67E-04
Cesium-137	CURIES	8.73E-04	6.73E-04	1.55E-03
Iron-55	CURIES	4.04E-03	1.02E-02	1.42E-02
Iron-59	CURIES	1.96E-05	6.60E-05	8.55E-05
Tritium	CURIES	4.08E+02	1.52E+03	1.93E+03
Iodine-131	CURIES	0.00E+00	5.89E-04	5.89E-04
Iodine-133	CURIES	0.00E+00	7.59E-06	7.59E-06
Krypton-85	CURIES	0.00E+00	4.84E-03	4.84E-03
Krypton-85M	CURIES	0.00E+00	2.71E-06	2.71E-06
Manganese-54	CURIES	2.19E-03	1.68E-03	3.86E-03
Sodium-24	CURIES	5.50E-07	2.28E-06	2.83E-06
Niobium-95	CURIES	5.75E-05	1.96E-04	2.54E-04
Antimony-122	CURIES	8.59E-05	0.00E+00	8.59E-05
Antimony-124	CURIES	2.97E-04	1.60E-05	3.13E-04
Antimony-125	CURIES	2.74E-03	2.51E-03	5.26E-03
Antimony-126	CURIES	3.97E-06	0.00E+00	3.97E-06
Tin-117M	CURIES	4.54E-06	2.32E-06	6.86E-06
Strontium-89	CURIES	4.86E-06	1.78E-05	2.27E-05
Strontium-90	CURIES	0.00E+00	2.98E-06	2.98E-06
Technetium-99M	CURIES	0.00E+00	1.40E-05	1.40E-05
Tellurium-125M	CURIES	1.11E-03	1.14E-02	1.25E-02
Tellurium-129M	CURIES	8.69E-05	0.00E+00	8.69E-05
Xenon-131M	CURIES	0.00E+00	2.45E-02	2.45E-02
Xenon-133	CURIES	9.37E-04	1.21E+00	1.21E+00
Xenon-133M	CURIES	0.00E+00	1.55E-02	1.55E-02
Xenon-135	CURIES	1.93E-04	4.93E-03	5.12E-03
Zirconium-95	CURIES	1.59E-05	1.13E-04	1.29E-04
TOTAL FOR PERIOD	CURIES	4.08E+02	1.52E+03	1.93E+03
TOTAL Noble Gases	CURIES	1.13E-03	1.26E+00	1.26E+00
TOTAL Excluding Tritium & Noble Gases	CURIES	2.46E-02	5.20E-02	7.65E-02

Solid Waste and Irradiated Fuel Shipments

A. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL (Not Irradiated Fuel)

1. Type of Waste	Units	12-Month Period Shipped	12-Month Period Buried	Est. Total Error, %	
a. Spent resins, filter sludges, evaporator bottoms, etc.	m ³	1.29E+01	6.77E+00	-1.0E+00	+1.0E+00
	Ci	2.78E+02	2.77E+02	-5.0E+01	+1.0E+02
b. Dry compressible waste, contaminated equip., etc.	m ³	6.19E+02	2.71E+01	-1.0E+00	+1.0E+00
	Ci	4.94E-01	2.63E+00	-6.6E+01	+2.0E+02
c. Irradiated components, control rods, etc.	m ³	0.00E+00	0.00E+00	N/A	N/A
	Ci	0.00E+00	0.00E+00		
d. Other (low level secondary resin, sludge)	m ³	1.51E+01	2.38E+00	-1.0E+00	+1.0E+00
	Ci	1.64E-04	1.14E-04	-5.0E+01	+1.0E+02

2. Estimate of major nuclide composition (by type of waste)

a. Spent resins, filters, evaporator bottoms, etc.		
Nickel-63	%	4.66 E+01
Iron-55	%	2.44 E+01
Cobalt-60	%	1.07 E+01
Cesium-137	%	7.10 E+00
Tritium	%	5.60 E+00
Cesium-134	%	3.50 E+00
Manganese-54	%	9.70 E-01
Antimony-125	%	4.00 E-01
Cobalt-58	%	3.00 E-01

b. Dry compressible waste, contaminated equip., etc.		
Cobalt-58	%	4.30 E+01
Chromium-51	%	2.77 E+01
Iron-55	%	1.10 E+01
Niobium-95	%	4.10 E+00
Cobalt-60	%	3.82 E+00
Nickel-63	%	2.96 E+00
Antimony-124	%	1.95 E+00
Zirconium-95	%	1.85 E+00
Manganese-54	%	1.27 E+00
Iron-59	%	8.30 E-01
Antimony-125	%	5.60 E-01
Silver-110m	%	4.80 E-01

c. N/A		
	N/A	N/A

d. Other (secondary DE and HVAC charcoal)		
Tritium	%	3.06 E+01
Iron-55	%	2.53 E+01
Cesium-137	%	9.38 E+00
Cobalt-60	%	9.23 E+00

d. Other (secondary DE and HVAC charcoal)		
Cerium-144	%	8.57 E+00
Nickel-63	%	7.58 E+00
Cobalt-58	%	3.47 E+00
Cesium-134	%	2.63 E+00
Manganese-54	%	1.65 E+00
Antimony-125	%	1.40 E+00

3. Solid Waste Disposition:

Number of Shipments	Mode of Transportation	Destination
4	Truck	Studs vik Processing Facility, LLC 151 TC Runnion Rd. Erwin, Tn 37650
12	Truck	GTS-Duratek 1560 Bear Creek Road Oak Ridge, TN 37830
1	Truck	Chem-Nuclear Systems Barnwell Waste Management Facility 740 Osborn Rd. Barnwell, SC 29812
1	Truck	GTS-Duratek Gallaher Road Facility 628 Gallaher Rd. Kingston, TN 37763

4. Class of Solid Waste:
A, B & C

5. Type of Containers Used for Shipment:
General Design, High-Integrity Containers, and Type A casks

6. Solidifying Agent:
N/A

B. IRRADIATED FUEL SHIPMENTS (Disposal)
No shipments made during this period.

DOSE ACCUMULATIONS

**STP NUCLEAR OPERATING COMPANY
SUMMARY OF MAXIMUM INDIVIDUAL DOSES**

Unit: 1

TOTAL ACCUMULATION FOR PERIODS:

for LIQUID, GASEOUS AND AIR

Starting: 1-Jan-2005 Ending: 31-Dec-2005

EFFLUENT	APPLICABLE ORGAN	ESTIMATED DOSE (mrem)	AGE GROUP	LOCATION DIST DIR (m) (TOWARD)	% OF APPLICABLE LIMIT	LIMIT (mrad or mrem)
LIQUID	TOTAL BODY	2.36E-03	ADULT	RECEPTOR 3 ⁽⁵⁾	7.87E-02	3.0
LIQUID	GI-TRACT	2.45E-03	ADULT	RECEPTOR 3 ⁽⁵⁾	2.45E-02	10.0
NOBLE GAS	AIR DOSE (gamma-mrad)	2.65E-03		1900m ESE	2.65E-02	10.0
NOBLE GAS	AIR DOSE (beta-mrad)	2.29E-03		1720m NW	1.15E-02	20.0
NOBLE GAS	TOTAL BODY	1.755E-03	ALL ⁽¹⁾	1900m ESE	3.50E-02	5.0
NOBLE GAS	TOTAL BODY	3.39E-04	ALL ⁽²⁾	5600m ESE	6.78E-03	5.0
NOBLE GAS	SKIN	2.90E-03	ALL ⁽¹⁾	1900m ESE	1.94E-02	15.0
NOBLE GAS	SKIN	5.64E-04	ALL ⁽²⁾	5600m ESE	3.76E-03	15.0
IODINE, PARTICULATES & TRITIUM	GI-TRACT	1.14E-02	CHILD ⁽¹⁾	1720m NW	7.63E-02	15.0
IODINE, PARTICULATES & TRITIUM	GI-TRACT	2.03E-03	CHILD ⁽²⁾	4000m WSW	1.35E-02	15.0

SUMMARY OF POPULATION DOSES FOR 2005

EFFLUENT	APPLICABLE ORGAN	ESTIMATED POPULATION DOSE (person-rem)	AVERAGE DOSE TO POPULATION (rem per person)
LIQUID	TOTAL BODY	4.2E-04	7.4E-08 ⁽³⁾
GASEOUS	TOTAL BODY	1.3E-02	1.4E-09 ⁽⁴⁾

NOTES:

⁽¹⁾Doses were calculated for HYPOTHETICAL receptors at the site boundary.

⁽²⁾Highest dose for nearest individual or receptor. This individual is assumed to reside at this location.

⁽³⁾ Calculation based on a population of 303,500 for shore line exposure and for salt water invertebrate ingestion and 3,800 for salt water sport fish ingestion.

⁽⁴⁾ Calculation based on a population of 299,000 within fifty (50) miles of South Texas Project Electric Generating Station.

⁽⁵⁾Receptor 3 is an individual ingesting fresh water sport fish and receiving shoreline exposure from the Little Robbins Slough Area.

STP NUCLEAR OPERATING COMPANY
SUMMARY OF MAXIMUM INDIVIDUAL DOSES

Unit: 2

TOTAL ACCUMULATION FOR PERIODS:
for LIQUID, GASEOUS, AND AIR
Starting: 1-Jan-2005 Ending: 31-Dec-2005

EFFLUENT	APPLICABLE ORGAN	ESTIMATED DOSE (mrem)	AGE GROUP	LOCATION DIST DIR (m) (TOWARD)	% OF APPLICABLE LIMIT	LIMIT (mrad or mrem)
LIQUID	TOTAL BODY	8.75E-03	ADULT	RECEPTOR 3 ⁽⁵⁾	2.92E-01	3.0
LIQUID	GI-TRACT	8.90E-03	ADULT	RECEPTOR 3 ⁽⁵⁾	8.90E-02	10.0
NOBLE GAS	AIR DOSE (gamma-mrad)	8.98E-04		2160m W	8.98E-03	10.0
NOBLE GAS	AIR DOSE (beta-mrad)	1.43E-03		2880m WSW	7.15E-03	20.0
NOBLE GAS	TOTAL BODY	5.71E-04	ALL ⁽¹⁾	1540m NNW	1.14E-02	5.0
NOBLE GAS	TOTAL BODY	2.77E-04	ALL ⁽²⁾	4000m WSW	5.54E-03	5.0
NOBLE GAS	SKIN	1.23E-03	ALL ⁽¹⁾	2160m W	8.18E-03	15.0
NOBLE GAS	SKIN	6.88E-04	ALL ⁽²⁾	4000m WSW	4.59E-03	15.0
IODINE, PARTICULATES & TRITIUM	THYROID	1.26E-02	CHILD ⁽¹⁾	2160m W	8.39E-02	15.0
IODINE, PARTICULATES & TRITIUM	THYROID	5.97E-03	CHILD ⁽²⁾	4000m WSW	3.98E-02	15.0

SUMMARY OF POPULATION DOSES FOR 2005			
EFFLUENT	APPLICABLE ORGAN	ESTIMATED POPULATION DOSE (person-rem)	AVERAGE DOSE TO POPULATION (rem per person)
LIQUID	TOTAL BODY	8.6E-04	1.6E-07 ⁽³⁾
GASEOUS	TOTAL BODY	1.5E-02	1.5E-09 ⁽⁴⁾

NOTES:

- ⁽¹⁾Doses were calculated for HYPOTHETICAL receptors at the site boundary.
- ⁽²⁾Highest dose for nearest individual or receptor. This individual is assumed to reside at this location.
- ⁽³⁾Calculation based on a population of 303,500 for shore line exposure and for salt water invertebrate ingestion and 3,800 for salt water sport fish ingestion.
- ⁽⁴⁾Calculation based on a population of 299,000 within fifty (50) miles of South Texas Project Electric Generating Station.
- ⁽⁵⁾Receptor 3 is an individual ingesting fresh water sport fish and receiving shoreline exposure from the Little Robbins Slough Area.

STP NUCLEAR OPERATING COMPANY
SUMMARY OF MAXIMUM INDIVIDUAL DOSES

Unit: 1 PLUS 2

TOTAL ACCUMULATION FOR PERIODS:

for LIQUID, GASEOUS, AND AIR

Starting: 1-Jan-2005 Ending: 31-Dec-2005

EFFLUENT	APPLICABLE ORGAN	UNIT 1 ESTIMATED DOSE (mrem)	UNIT 2 ESTIMATED DOSE (mrem)	TOTAL 1+2 ESTIMATED DOSE (mrem)	AGE GROUP	LOCATION DIST DIR (m) (TOWARD)
LIQUID	TOTAL BODY	2.36E-03	8.75E-03	1.11E-02	ADULT	RECEPTOR 3 ⁽⁵⁾
LIQUID	GI-TRACT	2.45E-03	8.90E-03	1.14E-02	ADULT	RECEPTOR 3 ⁽⁵⁾
NOBLE GAS	AIR DOSE (gamma-mrad)	2.65E-03	7.18E-05	2.72E-03		1900m ESE
NOBLE GAS	AIR DOSE (beta-mrad)	2.14E-03	1.07E-03	3.21E-03		1540m NNW
NOBLE GAS	TOTAL BODY	1.75E-03	4.23E-05	1.79E-03	ALL ⁽¹⁾	1900m ESE
NOBLE GAS	TOTAL BODY	1.70E-04	2.77E-04	4.48E-04	ALL ⁽²⁾	4000m WSW
NOBLE GAS	SKIN	2.90E-03	1.15E-04	3.02E-03	ALL ⁽¹⁾	1900m ESE
NOBLE GAS	SKIN	3.73E-04	6.88E-04	1.06E-03	ALL ⁽²⁾	4000m WSW
IODINE, PARTICULATES & TRITIUM	THYROID	1.14E-02	1.09E-02	2.23E-02	CHILD ⁽¹⁾	1720m NW
IODINE, PARTICULATES & TRITIUM	THYROID	2.02E-03	5.97E-03	7.99E-03	CHILD ⁽²⁾	4000m WSW
IODINE, PARTICULATES & TRITIUM	TOTAL BODY	1.56E-03	3.71E-03	5.27E-03	ADULT ⁽²⁾	4000m WSW

SUMMARY OF POPULATION DOSES FOR 2005			
EFFLUENT	APPLICABLE ORGAN	TOTAL 1+2 ESTIMATED POPULATION DOSE (person-rem)	TOTAL 1+2 AVERAGE DOSE TO POPULATION (rem per person)
LIQUID	TOTAL BODY	1.3E-03	2.4E-07 ⁽³⁾
GASEOUS	TOTAL BODY	2.9E-02	1.4E-09 ⁽⁴⁾

NOTES:

⁽¹⁾Doses were calculated for HYPOTHETICAL receptors at the site boundary.

⁽²⁾Highest dose for nearest individual or receptor. This individual is assumed to reside at this location.

⁽³⁾ Calculation based on a population of 303,500 for shore line exposure and for salt water invertebrate ingestion and 3,800 for salt water sport fish ingestion.

⁽⁴⁾ Calculation based on a population of 299,000 within fifty (50) miles of South Texas Project Electric Generating Station.

⁽⁵⁾Receptor 3 is an individual ingesting fresh water sport fish and receiving shoreline exposure from the Little Robbins Slough Area.

**RESULTS OF THE PROTECTED AREA DIRECT RADIATION
MEASUREMENTS PROGRAM**

Table 8-1

2005 STPEGS PROTECTED AREA THERMOLUMINESCENT DOSIMETER MONITORING STATIONS						
Station Number	1st Qtr Average	2nd Qtr Average	3rd Qtr Average	4th Qtr Average	Average Rate	Average (1) Net Rate
	(mR) (2)	(mR) (2)	(mR) (2)	(mR) (2)	(mR/Qtr) (2)	(mR/hour)
1	15.1	15.0	12.2	13.1	13.9	0.0
2	15.9	14.7	12.0	12.5	13.8	0.0
3	15.8	14.4	12.5	12.9	13.9	0.0
4	14.6	14.5	12.0	12.6	13.4	0.0
5	15.7	15.2	12.2	13.2	14.1	0.0
6	16.8	15.4	13.1	13.9	14.8	0.0
7	16.0	15.1	12.6	14.1	14.5	0.0
8	15.5	13.6	12.0	12.5	13.4	0.0
9	14.7	13.7	11.5	11.6	12.9	0.0
10	14.6	12.9	11.2	11.4	12.5	0.0
11	13.8	12.6	10.5	10.7	11.9	0.0
12	13.9	13.7	11.2	11.3	12.5	0.0
13	14.5	13.6	11.8	12.1	13.0	0.0
14	14.2	13.6	11.1	11.6	12.6	0.0
15	15.0	14.6	11.7	12.3	13.4	0.0
16	14.7	13.1	10.9	12.1	12.7	0.0

Notes:

Individual values normalized to a 91 day quarter.

Only the calcium sulfate elements were used in these averages.

(1) Net Rate:


Difference between the exposure rate in 2005 and the rate measured in 1986 due to natural background

(average rate - 15.4 mR background) / 91 days / 24 hours per day

The 1986 background rate of 15.4 at the site boundary has been used to reflect the pre-operational baseline exposure rate for STP. Historically the exposure rates measured near the protected area fence have been lower than the historical background at the site boundary. However, dosimeter stations 6 and 7 have at times exceeded the background exposure rate at the site boundary due to radioactive waste processing activities on the south sides to the Units. Waste processing activities during 2005 did not cause these two stations to exceed the site area background. Zero (-0-) indicates background levels.

(2) mR = milliroentgen, a unit of exposure for x and gamma rays

FIGURE 8-1
PROTECTED AREA MONITORING STATIONS



JOINT FREQUENCY TABLES

First Quarter 2005

Joint Frequency Table

From : 01/01/2005 00:00 **To** : 03/31/2005 23:00

PRIMARY TOWER

First Quarter 2005

Joint Frequency Tables

Joint Frequency Table**From** : 01/01/2005 00:00 **To** : 03/31/2005 23:00**PRIMARY TOWER****STABILITY CLASS A**

Wind Speed (MPH) → Sector	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
N	0	0	0	1	1	0	0	0	2	1.1%	13.4
NNE	0	0	3	5	3	0	0	0	11	6.1%	10.3
NE	0	0	4	1	0	0	0	0	5	2.8%	6.7
ENE	0	0	0	0	0	0	0	0	0	0.0%	0.0
E	0	0	0	0	0	0	0	0	0	0.0%	0.0
ESE	0	0	2	1	1	0	0	0	4	2.2%	8.8
SE	0	0	0	2	3	0	0	0	5	2.8%	11.9
SSE	0	0	2	3	7	0	0	0	12	6.6%	12.7
S	0	0	6	21	9	0	0	0	36	19.9%	10.6
SSW	0	0	5	27	13	0	0	0	45	24.9%	11.0
SW	0	1	3	12	12	1	0	0	29	16.0%	11.9
WSW	0	0	0	3	1	0	0	0	4	2.2%	12.8
W	0	0	0	0	0	0	0	0	0	0.0%	0.0
WNW	0	0	2	2	0	0	0	0	4	2.2%	8.1
NW	0	0	2	9	2	5	0	0	18	9.9%	13.1
NNW	0	0	0	5	0	1	0	0	6	3.3%	11.0
Total	0	1	29	92	52	7	0	0	181		
% Of Total	0.0%	0.6%	16.0%	50.8%	28.7%	3.9%	0.0%	0.0%			

Average speed for this table (MPH): 11.2
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 3
 Total number of Valid hours : 2157
 Total number of hours for period : 2160

First Quarter 2005

Joint Frequency Table

From : 01/01/2005 00:00 **To** : 03/31/2005 23:00

PRIMARY TOWER

STABILTY CLASS B

Wind Speed (MPH) -> Sector	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6 +	Total	% Of Total	Avg. Speed
N	0	0	0	3	2	0	0	0	5	6.9%	11.5
NNE	0	0	1	2	1	0	0	0	4	5.6%	10.4
NE	0	0	2	2	1	0	0	0	5	6.9%	8.8
ENE	0	0	2	0	0	0	0	0	2	2.8%	6.2
E	0	0	0	2	1	0	0	0	3	4.2%	13.2
ESE	0	0	1	0	1	0	0	0	2	2.8%	9.9
SE	0	0	0	5	2	0	0	0	7	9.7%	11.0
SSE	0	0	1	3	5	0	0	0	9	12.5%	12.5
S	0	0	0	4	0	1	0	0	5	6.9%	12.5
SSW	0	0	4	2	0	0	0	0	6	8.3%	7.9
SW	0	0	0	0	1	0	0	0	1	1.4%	15.7
WSW	0	0	1	1	0	0	0	0	2	2.8%	8.0
W	0	0	1	0	2	0	0	0	3	4.2%	10.2
WNW	0	0	2	0	0	0	0	0	2	2.8%	5.3
NW	0	1	2	3	2	0	0	0	8	11.1%	9.8
NNW	0	0	1	3	3	1	0	0	8	11.1%	11.8
Total	0	1	18	30	21	2	0	0	72		
% Of Total	0.0%	1.4%	25.0%	41.7%	29.2%	2.8%	0.0%	0.0%			

Average speed for this table (MPH): 10.6
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 3
 Total number of Valid hours : 2157
 Total number of hours for period : 2160

First Quarter 2005

Joint Frequency Table**From :** 01/01/2005 00:00 **To :** 03/31/2005 23:00**PRIMARY TOWER****STABILTY CLASS C**

Wind Speed (MPH) ->	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6 +	Total	% Of Total	Avg. Speed
Sector											
N	0	0	0	3	2	0	0	0	5	4.7%	12.2
NNE	0	0	3	4	3	0	0	0	10	9.3%	10.1
NE	0	0	1	3	3	0	0	0	7	6.5%	11.2
ENE	0	0	2	2	2	0	0	0	6	5.6%	10.3
E	0	0	1	3	7	0	0	0	11	10.3%	12.2
ESE	0	0	1	7	2	0	0	0	10	9.3%	10.1
SE	0	1	1	5	3	0	0	0	10	9.3%	9.8
SSE	0	0	2	0	7	0	0	0	9	8.4%	13.1
S	0	0	1	3	3	2	0	0	9	8.4%	13.8
SSW	0	0	1	3	1	0	0	0	5	4.7%	9.4
SW	0	0	1	2	0	0	0	0	3	2.8%	8.4
WSW	0	0	1	0	0	0	0	0	1	0.9%	6.6
W	0	0	0	0	0	0	0	0	0	0.0%	0.0
WNW	0	0	0	1	0	0	0	0	1	0.9%	11.3
NW	0	1	0	1	3	0	0	0	5	4.7%	11.6
NNW	0	1	2	7	2	3	0	0	15	14.0%	12.0
Total	0	3	17	44	38	5	0	0	107		
% Of Total	0.0%	2.8%	15.9%	41.1%	35.5%	4.7%	0.0%	0.0%			

Average speed for this table (MPH): 11.3
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 3
 Total number of Valid hours : 2157
 Total number of hours for period : 2160

First Quarter 2005

Joint Frequency Tables

Joint Frequency TableFrom : 01/01/2005 00:00 To : 03/31/2005 23:00PRIMARY TOWERSTABILTY CLASS D

Wind Speed (MPH) ->	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
Sector											
N	0	2	11	53	39	2	0	0	107	14.4%	11.4
NNE	0	1	23	59	39	1	0	0	123	16.5%	10.7
NE	0	1	22	52	11	0	0	0	86	11.5%	9.6
ENE	0	1	10	26	15	0	0	0	52	7.0%	10.6
E	0	2	8	18	18	2	0	0	48	6.4%	11.0
ESE	0	2	6	34	12	1	0	0	55	7.4%	10.5
SE	0	1	5	35	20	0	0	0	61	8.2%	10.8
SSE	0	0	8	27	19	0	0	0	54	7.2%	11.4
S	0	0	6	12	11	0	0	0	29	3.9%	11.2
SSW	0	0	10	4	0	0	0	0	14	1.9%	6.8
SW	0	0	2	9	5	0	0	0	16	2.1%	10.6
WSW	0	0	1	3	0	0	0	0	4	0.5%	7.8
W	0	0	0	3	0	0	0	0	3	0.4%	9.2
WNW	0	0	0	1	0	0	0	0	1	0.1%	9.2
NW	0	0	3	2	5	1	0	0	11	1.5%	12.1
NNW	0	0	10	38	25	8	0	0	81	10.9%	12.0
Total	0	10	125	376	219	15	0	0	745		
% Of Total	0.0%	1.3%	16.8%	50.5%	29.4%	2.0%	0.0%	0.0%			

Average speed for this table (MPH): 10.8
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 3
 Total number of Valid hours : 2157
 Total number of hours for period : 2160

First Quarter 2005

Joint Frequency Tables

Joint Frequency Table**From** : 01/01/2005 00:00 **To** : 03/31/2005 23:00**PRIMARY TOWER****STABILTY CLASS E**

Wind Speed (MPH) ->	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
Sector											
N	0	6	20	21	22	0	0	0	69	9.1%	9.9
NNE	0	1	23	43	1	0	0	0	68	9.0%	8.0
NE	0	7	20	17	1	0	0	0	45	5.9%	6.9
ENE	0	3	30	16	0	0	0	0	49	6.5%	6.7
E	0	4	26	20	1	0	0	0	51	6.7%	7.4
ESE	0	2	29	39	2	0	0	0	72	9.5%	8.1
SE	0	2	41	60	5	0	0	0	108	14.2%	8.4
SSE	0	2	36	52	19	1	0	0	110	14.5%	9.1
S	0	5	22	16	5	0	0	0	48	6.3%	7.5
SSW	0	6	32	19	1	0	0	0	58	7.7%	6.9
SW	0	1	11	16	0	0	0	0	28	3.7%	8.2
WSW	0	0	6	4	0	0	0	0	10	1.3%	7.8
W	0	0	3	1	0	0	0	0	4	0.5%	5.4
WNW	0	1	0	0	0	0	0	0	1	0.1%	2.8
NW	0	2	5	0	4	1	0	0	12	1.6%	10.1
NNW	0	3	7	8	7	0	0	0	25	3.3%	9.0
Total	0	45	311	332	68	2	0	0	758		
% Of Total	0.0%	5.9%	41.0%	43.8%	9.0%	0.3%	0.0%	0.0%			

Average speed for this table (MPH) : 8.1
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 3
 Total number of Valid hours : 2157
 Total number of hours for period : 2160

First Quarter 2005

Joint Frequency Tables

Joint Frequency Table**From** : 01/01/2005 00:00 **To** : 03/31/2005 23:00**PRIMARY TOWER****STABILTY CLASS F**

Wind Speed (MPH) -> Sector	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6 +	Total	% Of Total	Avg. Speed
N	0	2	9	1	0	0	0	0	12	6.8%	5.0
NNE	0	4	15	6	0	0	0	0	25	14.2%	6.1
NE	0	5	11	5	0	0	0	0	21	11.9%	5.3
ENE	0	8	14	1	0	0	0	0	23	13.1%	4.4
E	0	3	11	2	0	0	0	0	16	9.1%	5.2
ESE	0	5	8	1	0	0	0	0	14	8.0%	4.7
SE	0	2	11	0	0	0	0	0	13	7.4%	4.9
SSE	0	2	13	3	0	0	0	0	18	10.2%	6.3
S	0	1	6	1	0	0	0	0	8	4.5%	5.6
SSW	0	2	4	0	0	0	0	0	6	3.4%	4.5
SW	0	0	3	0	0	0	0	0	3	1.7%	6.4
WSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
W	0	1	1	0	0	0	0	0	2	1.1%	3.4
WNW	0	1	2	0	0	0	0	0	3	1.7%	4.8
NW	0	1	2	1	0	0	0	0	4	2.3%	6.1
NNW	0	6	2	0	0	0	0	0	8	4.5%	3.1
Total	0	43	112	21	0	0	0	0	176		
% Of Total	0.0%	24.4%	63.6%	11.9%	0.0%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 5.2
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 3
 Total number of Valid hours : 2157
 Total number of hours for period : 2160

First Quarter 2005

Joint Frequency Tables

Joint Frequency Table**From** : 01/01/2005 00:00 **To** : 03/31/2005 23:00**PRIMARY TOWER****STABILTY CLASS G**

Wind Speed (MPH) →	(1) CALM	(2) 1.0 - 3.5	(3) 3.6 - 7.5	(4) 7.6 - 12.5	(5) 12.6 - 18.5	(6) 18.6 - 24.5	(7) 24.6 - 32.5	(8) 32.6 +	Total	% Of Total	Avg. Speed
Sector											
N	0	2	4	0	0	0	0	0	6	5.1%	4.5
NNE	0	4	2	0	0	0	0	0	6	5.1%	3.2
NE	0	5	6	0	0	0	0	0	11	9.3%	3.5
ENE	0	8	7	0	0	0	0	0	15	12.7%	3.7
E	0	4	2	0	0	0	0	0	6	5.1%	3.5
ESE	0	9	3	1	0	0	0	0	13	11.0%	3.8
SE	0	4	3	0	0	0	0	0	7	5.9%	3.5
SSE	0	4	9	1	0	0	0	0	14	11.9%	5.2
S	0	2	1	0	0	0	0	0	3	2.5%	3.6
SSW	0	2	0	0	0	0	0	0	2	1.7%	2.6
SW	0	2	0	0	0	0	0	0	2	1.7%	1.8
WSW	0	4	0	0	0	0	0	0	4	3.4%	2.0
W	0	5	4	0	0	0	0	0	9	7.6%	3.6
WNW	0	6	1	0	0	0	0	0	7	5.9%	2.6
NW	0	3	4	0	0	0	0	0	7	5.9%	3.7
NNW	0	4	2	0	0	0	0	0	6	5.1%	3.7
Total	0	68	48	2	0	0	0	0	118		
% Of Total	0.0%	57.6%	40.7%	1.7%	0.0%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 3.7
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 3
 Total number of Valid hours : 2157
 Total number of hours for period : 2160

First Quarter 2005

Joint Frequency Table**From** : 01/01/2005 00:00 **To** : 03/31/2005 23:00**PRIMARY TOWER****ALL STABILITY CLASSES COMBINED**

Wind Speed (MPH) ->	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
Sector											
N	0	12	44	82	66	2	0	0	206	9.6%	10.4
NNE	0	10	70	119	47	1	0	0	247	11.5%	9.3
NE	0	18	66	80	16	0	0	0	180	8.3%	8.0
ENE	0	20	65	45	17	0	0	0	147	6.8%	7.5
E	0	13	48	45	27	2	0	0	135	6.3%	8.8
ESE	0	18	50	83	18	1	0	0	170	7.9%	8.4
SE	0	10	61	107	33	0	0	0	211	9.8%	8.9
SSE	0	8	71	89	57	1	0	0	226	10.5%	9.7
S	0	8	42	57	28	3	0	0	138	6.4%	9.5
SSW	0	10	56	55	15	0	0	0	136	6.3%	8.2
SW	0	4	20	39	18	1	0	0	82	3.8%	9.9
WSW	0	4	9	11	1	0	0	0	25	1.2%	7.6
W	0	6	9	4	2	0	0	0	21	1.0%	5.6
WNW	0	8	7	4	0	0	0	0	19	0.9%	5.2
NW	0	8	18	16	16	7	0	0	65	3.0%	10.4
NNW	0	14	24	61	37	13	0	0	149	6.9%	10.6
Total	0	171	660	897	398	31	0	0	2157		
% Of Total	0.0%	7.9%	30.6%	41.6%	18.5%	1.4%	0.0%	0.0%			

Average speed for this table (MPH): 9.1
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 3
 Total number of Valid hours : 2157
 Total number of hours for period : 2160

Second Quarter 2005

Joint Frequency Tables

Joint Frequency Table

From : 04/01/2005 00:00 **To** : 06/30/2005 23:00

PRIMARY TOWER

Second Quarter 2005

Joint Frequency Tables

Joint Frequency TableFrom : 04/01/2005 00:00 To : 06/30/2005 23:00PRIMARY TOWERSTABILTY CLASS A

Wind Speed (MPH) -> Sector	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
N	0	0	3	3	0	0	0	0	6	6.4%	7.1
NNE	0	1	2	0	0	0	0	0	3	3.2%	4.3
NE	0	0	6	1	0	0	0	0	7	7.4%	5.8
ENE	0	2	7	0	0	0	0	0	9	9.6%	5.4
E	0	0	2	0	0	0	0	0	2	2.1%	4.7
ESE	0	0	0	1	0	0	0	0	1	1.1%	8.6
SE	0	1	0	6	2	0	0	0	9	9.6%	10.5
SSE	0	0	5	0	5	0	0	0	10	10.6%	11.1
S	0	0	2	12	0	0	0	0	14	14.9%	10.4
SSW	0	0	4	3	2	0	0	0	9	9.6%	9.3
SW	0	0	0	0	0	0	0	0	0	0.0%	0.0
WSW	0	0	3	0	0	0	0	0	3	3.2%	4.8
W	0	0	0	0	0	0	0	0	0	0.0%	0.0
WNW	0	0	2	0	0	0	0	0	2	2.1%	5.0
NW	0	0	0	3	1	0	0	0	4	4.3%	11.6
NNW	0	0	5	6	1	3	0	0	15	16.0%	10.7
Total	0	4	41	35	11	3	0	0	94		
% Of Total	0.0%	4.3%	43.6%	37.2%	11.7%	3.2%	0.0%	0.0%			

Average speed for this table (MPH): 8.8
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 318
 Total number of Valid hours : 1866
 Total number of hours for period : 2184

Second Quarter 2005

Joint Frequency Table**From** : 04/01/2005 00:00 **To** : 06/30/2005 23:00**PRIMARY TOWER****STABILTY CLASS B**

Wind Speed (MPH) -> Sector	(1) CALM	(2) 1.0 - 3.5	(3) 3.6 - 7.5	(4) 7.6 - 12.5	(5) 12.6 - 18.5	(6) 18.6 - 24.5	(7) 24.6 - 32.5	(8) 32.6 +	Total	% Of Total	Avg. Speed
N	0	0	2	1	0	0	0	0	3	4.7%	6.5
NNE	0	0	2	3	0	0	0	0	5	7.8%	7.7
NE	0	0	0	2	0	0	0	0	2	3.1%	8.5
ENE	0	0	1	0	0	0	0	0	1	1.6%	6.8
E	0	0	1	1	0	0	0	0	2	3.1%	8.7
ESE	0	0	2	0	2	0	0	0	4	6.3%	10.7
SE	0	0	1	1	9	0	0	0	11	17.2%	14.0
SSE	0	0	0	3	0	0	0	0	3	4.7%	8.8
S	0	0	1	3	0	0	0	0	4	6.3%	7.7
SSW	0	0	6	5	0	0	0	0	11	17.2%	7.3
SW	0	0	1	0	0	0	0	0	1	1.6%	6.7
WSW	0	0	1	1	0	0	0	0	2	3.1%	7.3
W	0	0	1	0	0	0	0	0	1	1.6%	6.9
WNW	0	0	2	1	1	0	0	0	4	6.3%	9.3
NW	0	0	0	4	2	0	0	0	6	9.4%	10.5
NNW	0	0	0	2	0	2	0	0	4	6.3%	16.0
Total	0	0	21	27	14	2	0	0	64		
% Of Total	0.0%	0.0%	32.8%	42.2%	21.9%	3.1%	0.0%	0.0%			

Average speed for this table (MPH): 9.8
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 318
 Total number of Valid hours : 1866
 Total number of hours for period : 2184

Second Quarter 2005

Joint Frequency Tables

Joint Frequency TableFrom : 04/01/2005 00:00 To : 06/30/2005 23:00PRIMARY TOWERSTABILTY CLASS C

Wind Speed (MPH) ->	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
Sector											
N	0	0	2	1	3	0	0	0	6	3.0%	10.5
NNE	0	0	0	2	0	0	0	0	2	1.0%	9.3
NE	0	0	1	1	0	0	0	0	2	1.0%	6.1
ENE	0	0	2	1	0	0	0	0	3	1.5%	5.3
E	0	0	1	1	0	0	0	0	2	1.0%	8.6
ESE	0	0	0	4	13	0	0	0	17	8.4%	13.5
SE	0	0	1	33	35	0	0	0	69	34.0%	12.5
SSE	0	0	1	20	4	0	0	0	25	12.3%	11.2
S	0	0	5	34	0	0	0	0	39	19.2%	9.1
SSW	0	0	4	17	0	0	0	0	21	10.3%	9.1
SW	0	0	1	1	0	0	0	0	2	1.0%	8.8
WSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
W	0	0	0	4	0	0	0	0	4	2.0%	10.0
WNW	0	0	2	2	1	0	0	0	5	2.5%	10.3
NW	0	0	0	0	2	0	0	0	2	1.0%	15.1
NNW	0	0	0	2	1	1	0	0	4	2.0%	13.9
Total	0	0	20	123	59	1	0	0	203		
% Of Total	0.0%	0.0%	9.9%	60.6%	29.1%	0.5%	0.0%	0.0%			

Average speed for this table (MPH): 11.0
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 318
 Total number of Valid hours : 1866
 Total number of hours for period : 2184

Second Quarter 2005

Joint Frequency Tables

Joint Frequency Table**From** : 04/01/2005 00:00 **To** : 06/30/2005 23:00**PRIMARY TOWER****STABILITY CLASS D**

Wind Speed (MPH) ->	(1) CALM	(2) 1.0 - 3.5	(3) 3.6 - 7.5	(4) 7.6 - 12.5	(5) 12.6 - 18.5	(6) 18.6 - 24.5	(7) 24.6 - 32.5	(8) 32.6 +	Total	% Of Total	Avg. Speed
Sector											
N	0	6	9	3	5	0	0	0	23	2.5%	7.2
NNE	0	8	25	3	0	0	0	0	36	4.0%	4.7
NE	0	10	27	0	1	0	0	0	38	4.2%	4.6
ENE	0	4	15	5	0	0	0	0	24	2.7%	5.7
E	0	1	11	10	1	0	0	0	23	2.5%	7.6
ESE	0	3	19	33	32	0	0	0	87	9.6%	10.6
SE	0	2	44	120	90	0	0	0	256	28.3%	11.0
SSE	0	1	34	92	38	0	0	0	165	18.3%	10.3
S	0	0	19	88	11	2	0	0	120	13.3%	10.0
SSW	0	0	23	33	0	0	0	0	56	6.2%	8.2
SW	0	0	2	12	1	0	0	0	15	1.7%	9.6
WSW	0	0	3	1	0	0	0	0	4	0.4%	6.5
W	0	1	3	1	0	0	0	0	5	0.6%	6.7
WNW	0	0	7	2	2	0	0	0	11	1.2%	7.4
NW	0	1	6	8	6	0	0	0	21	2.3%	9.8
NNW	0	4	9	2	1	4	0	0	20	2.2%	8.6
Total	0	41	256	413	188	6	0	0	904		
% Of Total	0.0%	4.5%	28.3%	45.7%	20.8%	0.7%	0.0%	0.0%			

Average speed for this table (MPH): 9.5
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 318
 Total number of Valid hours : 1866
 Total number of hours for period : 2184

Second Quarter 2005

Joint Frequency TableFrom : 04/01/2005 00:00 To : 06/30/2005 23:00PRIMARY TOWERSTABILTY CLASS E

Wind Speed (MPH) -> Sector	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
N	0	0	5	8	4	0	0	0	17	5.8%	9.7
NNE	0	1	5	1	2	0	0	0	9	3.1%	6.8
NE	0	4	9	0	0	0	0	0	13	4.5%	4.3
ENE	0	1	7	0	0	0	0	0	8	2.7%	4.8
E	0	0	5	0	0	0	0	0	5	1.7%	5.9
ESE	0	0	29	14	1	0	0	0	44	15.1%	7.2
SE	0	0	29	47	8	0	0	0	84	28.8%	8.5
SSE	0	1	26	36	1	0	0	0	64	21.9%	7.7
S	0	0	5	6	0	0	0	0	11	3.8%	7.6
SSW	0	0	6	3	0	0	0	0	9	3.1%	7.3
SW	0	0	4	2	1	0	0	0	7	2.4%	7.8
WSW	0	0	1	1	0	0	0	0	2	0.7%	7.8
W	0	0	0	0	0	0	0	0	0	0.0%	0.0
WNW	0	1	1	2	0	0	0	0	4	1.4%	6.6
NW	0	0	1	3	1	0	0	0	5	1.7%	9.1
NNW	0	2	2	4	2	0	0	0	10	3.4%	8.3
Total	0	10	135	127	20	0	0	0	292		
% Of Total	0.0%	3.4%	46.2%	43.5%	6.8%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 7.7
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 318
 Total number of Valid hours : 1866
 Total number of hours for period : 2184

Second Quarter 2005

Joint Frequency TableFrom : 04/01/2005 00:00 To : 06/30/2005 23:00PRIMARY TOWERSTABILTY CLASS F

Wind Speed (MPH) ->	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
Sector											
N	0	0	7	1	0	0	0	0	8	5.6%	6.4
NNE	0	4	6	4	0	0	0	0	14	9.9%	5.4
NE	0	1	1	0	0	0	0	0	2	1.4%	3.5
ENE	0	4	2	0	0	0	0	0	6	4.2%	3.2
E	0	9	9	0	0	0	0	0	18	12.7%	3.7
ESE	0	5	12	0	0	0	0	0	17	12.0%	4.3
SE	0	3	23	2	0	0	0	0	28	19.7%	4.9
SSE	0	2	15	0	0	0	0	0	17	12.0%	5.0
S	0	0	5	0	0	0	0	0	5	3.5%	4.3
SSW	0	1	8	0	0	0	0	0	9	6.3%	5.1
SW	0	0	0	0	0	0	0	0	0	0.0%	0.0
WSW	0	1	1	0	0	0	0	0	2	1.4%	3.0
W	0	1	0	0	0	0	0	0	1	0.7%	3.4
WNW	0	1	1	0	0	0	0	0	2	1.4%	5.0
NW	0	1	4	3	0	0	0	0	8	5.6%	6.5
NNW	0	0	5	0	0	0	0	0	5	3.5%	6.2
Total	0	33	99	10	0	0	0	0	142		
% Of Total	0.0%	23.2%	69.7%	7.0%	0.0%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 4.8
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 318
 Total number of Valid hours : 1866
 Total number of hours for period : 2184

Second Quarter 2005

Joint Frequency TableFrom : 04/01/2005 00:00 To : 06/30/2005 23:00PRIMARY TOWERSTABILTY CLASS G

Wind Speed (MPH) -> Sector	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
N	0	4	2	0	0	0	0	0	6	3.6%	3.4
NNE	0	23	9	0	0	0	0	0	32	19.2%	3.5
NE	0	26	12	0	0	0	0	0	38	22.8%	3.3
ENE	0	9	12	0	0	0	0	0	21	12.6%	3.3
E	0	10	6	0	0	0	0	0	16	9.6%	3.3
ESE	0	7	9	0	0	0	0	0	16	9.6%	3.7
SE	0	4	6	0	0	0	0	0	10	6.0%	3.6
SSE	0	0	3	0	0	0	0	0	3	1.8%	4.4
S	0	0	0	0	0	0	0	0	0	0.0%	0.0
SSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
SW	0	0	0	0	0	0	0	0	0	0.0%	0.0
WSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
W	0	0	0	0	0	0	0	0	0	0.0%	0.0
WNW	0	5	4	0	0	0	0	0	9	5.4%	3.2
NW	0	2	10	0	0	0	0	0	12	7.2%	3.9
NNW	0	2	2	0	0	0	0	0	4	2.4%	3.3
Total	0	92	75	0	0	0	0	0	167		
% Of Total	0.0%	55.1%	44.9%	0.0%	0.0%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 3.4
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 318
 Total number of Valid hours : 1866
 Total number of hours for period : 2184

Second Quarter 2005

Joint Frequency TableFrom : 04/01/2005 00:00 To : 06/30/2005 23:00PRIMARY TOWERALL STABILITY CLASSES COMBINED

Wind Speed (MPH) ->	(1) CALM	(2) 1.0 - 3.5	(3) 3.6 - 7.5	(4) 7.6 - 12.5	(5) 12.6 - 18.5	(6) 18.6 - 24.5	(7) 24.6 - 32.5	(8) 32.6 +	Total	% Of Total	Avg. Speed
Sector											
N	0	10	30	17	12	0	0	0	69	3.7%	7.6
NNE	0	37	49	13	2	0	0	0	101	5.4%	4.8
NE	0	41	56	4	1	0	0	0	102	5.5%	4.2
ENE	0	20	46	6	0	0	0	0	72	3.9%	4.7
E	0	20	35	12	1	0	0	0	68	3.6%	5.4
ESE	0	15	71	52	48	0	0	0	186	10.0%	8.9
SE	0	10	104	209	144	0	0	0	467	25.0%	10.3
SSE	0	4	84	151	48	0	0	0	287	15.4%	9.4
S	0	0	37	143	11	2	0	0	193	10.3%	9.5
SSW	0	1	51	61	2	0	0	0	115	6.2%	8.1
SW	0	0	8	15	2	0	0	0	25	1.3%	8.9
WSW	0	1	9	3	0	0	0	0	13	0.7%	5.9
W	0	2	4	5	0	0	0	0	11	0.6%	7.6
WNW	0	7	19	7	4	0	0	0	37	2.0%	6.6
NW	0	4	21	21	12	0	0	0	58	3.1%	8.4
NNW	0	8	23	16	5	10	0	0	62	3.3%	9.3
Total	0	180	647	735	292	12	0	0	1866		
% Of Total	0.0%	9.6%	34.7%	39.4%	15.6%	0.6%	0.0%	0.0%			

Average speed for this table (MPH) : 8.3
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 318
 Total number of Valid hours : 1866
 Total number of hours for period : 2184

Third Quarter 2005

Joint Frequency Table

From : 07/01/2005 00:00 **To** : 09/30/2005 23:00

PRIMARY TOWER

Third Quarter 2005

Joint Frequency Tables

Joint Frequency Table**From** : 07/01/2005 00:00 **To** : 09/30/2005 23:00**PRIMARY TOWER****STABILTY CLASS A**

Wind Speed (MPH) -> Sector	(1) CALM	(2) 1.0 - 3.5	(3) 3.6 - 7.5	(4) 7.6 - 12.5	(5) 12.6 - 18.5	(6) 18.6 - 24.5	(7) 24.6 - 32.5	(8) 32.6 +	Total	% Of Total	Avg. Speed
N	0	12	9	0	0	0	0	0	21	10.6%	3.5
NNE	0	10	26	0	0	0	0	0	36	18.2%	4.4
NE	0	11	10	0	0	0	0	0	21	10.6%	3.7
ENE	0	4	5	1	0	0	0	0	10	5.1%	4.5
E	0	5	4	1	0	0	0	0	10	5.1%	4.2
ESE	0	3	12	2	0	0	0	0	17	8.6%	5.4
SE	0	2	4	0	0	0	0	0	6	3.0%	4.7
SSE	0	2	12	2	0	0	0	0	16	8.1%	5.4
S	0	0	4	3	0	0	0	0	7	3.5%	7.3
SSW	0	0	11	0	0	0	0	0	11	5.6%	5.2
SW	0	4	6	0	0	0	0	0	10	5.1%	4.4
WSW	0	4	2	0	0	0	0	0	6	3.0%	2.9
W	0	1	1	0	0	0	0	0	2	1.0%	4.2
WNW	0	1	1	0	0	0	0	0	2	1.0%	3.0
NW	0	2	1	2	0	0	0	0	5	2.5%	6.5
NNW	0	9	9	0	0	0	0	0	18	9.1%	3.6
Total	0	70	117	11	0	0	0	0	198		
% Of Total	0.0%	35.4%	59.1%	5.6%	0.0%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 4.5
 Hours in above table with variable direction : 0
 Total number of CALMs : 2
 Total number of Invalid hours : 51
 Total number of Valid hours : 2157
 Total number of hours for period : 2208

Third Quarter 2005

Joint Frequency TableFrom : 07/01/2005 00:00 To : 09/30/2005 23:00PRIMARY TOWERSTABILTY CLASS B

Wind Speed (MPH) -> Sector	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
N	0	2	17	5	0	0	0	0	24	18.2%	6.1
NNE	0	2	12	0	0	0	0	0	14	10.6%	5.6
NE	0	2	5	0	0	0	0	0	7	5.3%	4.8
ENE	0	1	2	2	0	0	0	0	5	3.8%	6.8
E	0	2	5	4	1	0	0	0	12	9.1%	6.4
ESE	0	0	4	6	0	0	0	0	10	7.6%	7.9
SE	0	0	5	9	0	0	0	0	14	10.6%	8.2
SSE	0	0	5	1	0	0	0	0	6	4.5%	5.5
S	0	0	14	4	0	0	0	0	18	13.6%	6.9
SSW	0	0	3	3	0	0	0	0	6	4.5%	7.3
SW	0	0	3	0	0	0	0	0	3	2.3%	5.9
WSW	0	0	3	0	0	0	0	0	3	2.3%	5.7
W	0	0	0	0	0	0	0	0	0	0.0%	0.0
WNW	0	1	0	0	0	0	0	0	1	0.8%	3.4
NW	0	2	0	0	0	0	0	0	2	1.5%	3.0
NNW	0	0	4	3	0	0	0	0	7	5.3%	7.1
Total	0	12	82	37	1	0	0	0	132		
% Of Total	0.0%	9.1%	62.1%	28.0%	0.8%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 6.5
 Hours in above table with variable direction : 0
 Total number of CALMs : 2
 Total number of Invalid hours : 51
 Total number of Valid hours : 2157
 Total number of hours for period : 2208

Third Quarter 2005

Joint Frequency Table**From** : 07/01/2005 00:00 **To** : 09/30/2005 23:00**PRIMARY TOWER****STABILITY CLASS C**

Wind Speed (MPH) →	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
Sector											
N	0	9	10	7	9	0	0	0	35	10.1%	8.0
NNE	0	13	12	5	0	0	0	0	30	8.7%	4.6
NE	0	6	7	6	0	0	0	0	19	5.5%	6.1
ENE	0	1	5	6	1	0	0	0	13	3.8%	7.4
E	0	1	3	10	2	0	0	0	16	4.6%	8.5
ESE	0	0	2	9	1	0	0	0	12	3.5%	9.1
SE	0	5	8	26	2	0	0	0	41	11.9%	8.2
SSE	0	0	10	40	1	0	0	0	51	14.8%	8.9
S	0	0	16	30	0	0	0	0	46	13.3%	8.2
SSW	0	0	11	28	0	0	0	0	39	11.3%	8.4
SW	0	0	5	2	1	0	0	0	8	2.3%	7.9
WSW	0	0	3	0	0	0	0	0	3	0.9%	5.7
W	0	0	1	0	0	0	0	0	1	0.3%	4.5
WNW	0	1	4	0	0	0	0	0	5	1.4%	5.3
NW	0	2	4	1	0	0	0	0	7	2.0%	4.8
NNW	0	3	13	3	0	0	0	0	19	5.5%	5.6
Total	0	41	114	173	17	0	0	0	345		
% Of Total	0.0%	11.9%	33.0%	50.1%	4.9%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 7.6
 Hours in above table with variable direction : 0
 Total number of CALMs : 2
 Total number of Invalid hours : 51
 Total number of Valid hours : 2157
 Total number of hours for period : 2208

Third Quarter 2005

Joint Frequency TableFrom : 07/01/2005 00:00 To : 09/30/2005 23:00PRIMARY TOWERSTABILTY CLASS D

Wind Speed (MPH) -> Sector	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
N	0	12	17	2	1	0	0	0	32	3.3%	4.7
NNE	0	26	34	10	1	0	0	0	71	7.4%	5.3
NE	0	22	31	6	2	0	0	0	61	6.3%	4.9
ENE	0	20	9	4	1	0	0	0	34	3.5%	4.2
E	0	27	7	18	1	0	0	0	53	5.5%	5.7
ESE	0	21	11	28	6	0	0	0	66	6.8%	7.5
SE	0	23	53	38	2	0	0	0	116	12.0%	6.3
SSE	0	6	82	64	3	0	0	0	155	16.1%	7.4
S	0	1	55	133	2	0	0	0	191	19.8%	8.7
SSW	0	0	52	40	1	0	0	0	93	9.6%	7.5
SW	0	0	10	11	1	0	0	0	22	2.3%	8.2
WSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
W	0	3	1	1	6	0	0	0	11	1.1%	10.1
WNW	0	2	3	2	2	0	0	0	9	0.9%	8.1
NW	0	3	9	0	3	1	0	0	16	1.7%	7.1
NNW	0	15	18	1	1	0	0	0	35	3.6%	4.8
Total	0	181	392	358	33	1	0	0	965		
% Of Total	0.0%	18.8%	40.6%	37.1%	3.4%	0.1%	0.0%	0.0%			

Average speed for this table (MPH): 6.9
 Hours in above table with variable direction : 0
 Total number of CALMs : 2
 Total number of Invalid hours : 51
 Total number of Valid hours : 2157
 Total number of hours for period : 2208

Third Quarter 2005

Joint Frequency Tables

Joint Frequency Table**From :** 07/01/2005 00:00 **To :** 09/30/2005 23:00**PRIMARY TOWER****STABILITY CLASS E**

Wind Speed (MPH) -> Sector	(1) CALM	(2) 1.0 - 3.5	(3) 3.6 - 7.5	(4) 7.6 - 12.5	(5) 12.6 - 18.5	(6) 18.6 - 24.5	(7) 24.6 - 32.5	(8) 32.6 +	Total	% Of Total	Avg. Speed
N	0	1	0	0	0	0	0	0	1	0.4%	2.0
NNE	0	10	18	2	0	0	0	0	30	11.2%	4.5
NE	0	7	8	2	0	0	0	0	17	6.3%	4.4
ENE	0	7	13	0	0	0	0	0	20	7.4%	4.1
E	0	3	21	2	0	0	0	0	26	9.7%	5.1
ESE	0	11	20	4	0	0	0	0	35	13.0%	5.1
SE	0	18	82	1	0	0	0	0	101	37.5%	4.6
SSE	0	4	28	0	0	0	0	0	32	11.9%	5.1
S	0	0	1	0	0	0	0	0	1	0.4%	4.7
SSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
SW	0	0	0	0	0	0	0	0	0	0.0%	0.0
WSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
W	0	0	0	0	0	0	0	0	0	0.0%	0.0
WNW	0	1	1	0	0	0	0	0	2	0.7%	3.5
NW	0	1	1	0	0	0	0	0	2	0.7%	3.8
NNW	0	0	2	0	0	0	0	0	2	0.7%	4.6
Total	0	63	195	11	0	0	0	0	269		
% Of Total	0.0%	23.4%	72.5%	4.1%	0.0%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 4.7
 Hours in above table with variable direction : 0
 Total number of CALMs : 2
 Total number of Invalid hours : 51
 Total number of Valid hours : 2157
 Total number of hours for period : 2208

Third Quarter 2005

Joint Frequency TableFrom : 07/01/2005 00:00 To : 09/30/2005 23:00PRIMARY TOWERSTABILTY CLASS F

Wind Speed (MPH) -> Sector	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
N	0	18	4	0	2	0	0	0	24	9.7%	4.0
NNE	0	26	3	1	0	0	0	0	30	12.1%	3.0
NE	0	24	2	0	0	0	0	0	26	10.5%	2.8
ENE	0	22	4	0	0	0	0	0	26	10.5%	2.9
E	0	26	5	0	0	0	0	0	31	12.5%	2.6
ESE	0	13	8	0	0	0	0	0	21	8.5%	3.1
SE	1	9	8	0	0	0	0	0	18	7.3%	3.4
SSE	0	6	3	1	0	0	0	0	10	4.0%	4.3
S	0	1	8	0	0	0	0	0	9	3.6%	5.2
SSW	0	0	8	0	0	0	0	0	8	3.2%	6.1
SW	0	0	3	0	0	0	0	0	3	1.2%	6.4
WSW	0	1	3	0	0	0	0	0	4	1.6%	4.0
W	0	2	3	0	0	0	0	0	5	2.0%	3.5
WNW	1	5	2	0	0	0	0	0	8	3.2%	2.4
NW	0	7	1	0	1	0	0	0	9	3.6%	3.7
NNW	0	13	2	0	1	0	0	0	16	6.5%	3.6
Total	2	173	67	2	4	0	0	0	248		
% Of Total	0.8%	69.8%	27.0%	0.8%	1.6%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 3.4
 Hours in above table with variable direction : 0
 Total number of CALMs : 2
 Total number of Invalid hours : 51
 Total number of Valid hours : 2157
 Total number of hours for period : 2208

Third Quarter 2005

Joint Frequency Table

From : 07/01/2005 00:00 **To** : 09/30/2005 23:00

PRIMARY TOWER

STABILTY CLASS G

Wind Speed (MPH) ->	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
Sector											
N	0	0	0	0	0	0	0	0	0	*****	0.0
NNE	0	0	0	0	0	0	0	0	0	*****	0.0
NE	0	0	0	0	0	0	0	0	0	*****	0.0
ENE	0	0	0	0	0	0	0	0	0	*****	0.0
E	0	0	0	0	0	0	0	0	0	*****	0.0
ESE	0	0	0	0	0	0	0	0	0	*****	0.0
SE	0	0	0	0	0	0	0	0	0	*****	0.0
SSE	0	0	0	0	0	0	0	0	0	*****	0.0
S	0	0	0	0	0	0	0	0	0	*****	0.0
SSW	0	0	0	0	0	0	0	0	0	*****	0.0
SW	0	0	0	0	0	0	0	0	0	*****	0.0
WSW	0	0	0	0	0	0	0	0	0	*****	0.0
W	0	0	0	0	0	0	0	0	0	*****	0.0
WNW	0	0	0	0	0	0	0	0	0	*****	0.0
NW	0	0	0	0	0	0	0	0	0	*****	0.0
NNW	0	0	0	0	0	0	0	0	0	*****	0.0
Total	0	0	0	0	0	0	0	0	0		
% Of Total	*****	*****	*****	*****	*****	*****	*****	*****	*****		

Average speed for this table (MPH): 0.0
 Hours in above table with variable direction : 0
 Total number of CALMs : 2
 Total number of Invalid hours : 51
 Total number of Valid hours : 2157
 Total number of hours for period : 2208

Third Quarter 2005

Joint Frequency TableFrom : 07/01/2005 00:00 To : 09/30/2005 23:00PRIMARY TOWERALL STABILITY CLASSES COMBINED

Wind Speed (MPH) ->	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6 +	Total	% Of Total	Avg. Speed
Sector											
N	0	54	57	14	12	0	0	0	137	6.4%	5.5
NNE	0	87	105	18	1	0	0	0	211	9.8%	4.6
NE	0	72	63	14	2	0	0	0	151	7.0%	4.5
ENE	0	55	38	13	2	0	0	0	108	5.0%	4.4
E	0	64	45	35	4	0	0	0	148	6.9%	5.2
ESE	0	48	57	49	7	0	0	0	161	7.5%	6.3
SE	1	57	160	74	4	0	0	0	296	13.7%	5.8
SSE	0	18	140	108	4	0	0	0	270	12.5%	7.1
S	0	2	98	170	2	0	0	0	272	12.6%	8.3
SSW	0	0	85	71	1	0	0	0	157	7.3%	7.5
SW	0	4	27	13	2	0	0	0	46	2.1%	7.1
WSW	0	5	11	0	0	0	0	0	16	0.7%	4.2
W	0	6	6	1	6	0	0	0	19	0.9%	7.4
WNW	1	11	11	2	2	0	0	0	27	1.3%	5.0
NW	0	17	16	3	4	1	0	0	41	1.9%	5.5
NNW	0	40	48	7	2	0	0	0	97	4.5%	4.7
Total	2	540	967	592	55	1	0	0	2157		
% Of Total	0.1%	25.0%	44.8%	27.4%	2.5%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 6.1
 Hours in above table with variable direction : 0
 Total number of CALMs : 2
 Total number of Invalid hours : 51
 Total number of Valid hours : 2157
 Total number of hours for period : 2208

Fourth Quarter 2005

Joint Frequency Table

From : 10/01/2005 00:00 To : 12/31/2005 23:00

PRIMARY TOWER

Fourth Quarter 2005

Joint Frequency Tables

Joint Frequency TableFrom : 10/01/2005 00:00 To : 12/31/2005 23:00PRIMARY TOWERSTABILTY CLASS A

Wind Speed (MPH) -> Sector	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
N	0	1	9	0	0	0	0	0	10	13.7%	4.6
NNE	0	2	6	0	0	0	0	0	8	11.0%	4.2
NE	0	1	5	0	0	0	0	0	6	8.2%	4.5
ENE	0	1	8	0	0	0	0	0	9	12.3%	4.8
E	0	2	3	0	0	0	0	0	5	6.8%	3.8
ESE	0	0	6	0	0	0	0	0	6	8.2%	5.4
SE	0	1	4	0	0	0	0	0	5	6.8%	4.6
SSE	0	0	1	0	0	0	0	0	1	1.4%	7.3
S	0	0	3	0	0	0	0	0	3	4.1%	4.8
SSW	0	1	5	1	0	0	0	0	7	9.6%	4.3
SW	0	0	3	0	0	0	0	0	3	4.1%	4.1
WSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
W	0	0	0	0	0	0	0	0	0	0.0%	0.0
WNW	0	0	0	1	0	0	0	0	1	1.4%	9.5
NW	0	1	3	0	0	0	0	0	4	5.5%	4.1
NNW	0	0	5	0	0	0	0	0	5	6.8%	5.3
Total	0	10	61	2	0	0	0	0	73		
% Of Total	0.0%	13.7%	83.6%	2.7%	0.0%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 4.7
 Hours in above table with variable direction : 0
 Total number of CALMs : 21
 Total number of Invalid hours : 1
 Total number of Valid hours : 2207
 Total number of hours for period : 2208

Fourth Quarter 2005

Joint Frequency Table**From** : 10/01/2005 00:00 **To** : 12/31/2005 23:00**PRIMARY TOWER****STABILITY CLASS B**

Wind Speed (MPH) -> Sector	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
N	0	1	4	5	3	0	0	0	13	20.0%	9.6
NNE	0	0	9	2	0	0	0	0	11	16.9%	6.1
NE	0	0	2	1	0	0	0	0	3	4.6%	5.6
ENE	0	0	4	0	0	0	0	0	4	6.2%	6.4
E	0	2	2	1	0	0	0	0	5	7.7%	4.5
ESE	0	2	1	2	0	0	0	0	5	7.7%	5.7
SE	0	0	1	0	0	0	0	0	1	1.5%	4.2
SSE	0	0	0	1	0	0	0	0	1	1.5%	8.0
S	0	0	5	0	0	0	0	0	5	7.7%	4.8
SSW	0	1	2	0	0	0	0	0	3	4.6%	4.8
SW	0	0	0	0	0	0	0	0	0	0.0%	0.0
WSW	0	0	1	0	0	0	0	0	1	1.5%	3.6
W	0	0	0	0	0	0	0	0	0	0.0%	0.0
WNW	0	0	1	0	0	0	0	0	1	1.5%	5.5
NW	0	0	4	0	0	0	0	0	4	6.2%	5.1
NNW	0	1	7	0	0	0	0	0	8	12.3%	5.2
Total	0	7	43	12	3	0	0	0	65		
% Of Total	0.0%	10.8%	66.2%	18.5%	4.6%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 6.2
 Hours in above table with variable direction : 0
 Total number of CALMs : 21
 Total number of Invalid hours : 1
 Total number of Valid hours : 2207
 Total number of hours for period : 2208

Fourth Quarter 2005

Joint Frequency TableFrom : 10/01/2005 00:00 To : 12/31/2005 23:00PRIMARY TOWERSTABILTY CLASS C

Wind Speed (MPH) -> Sector	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6 +	Total	% Of Total	Avg. Speed
N	0	3	10	15	17	0	0	0	45	19.5%	10.2
NNE	0	0	9	17	0	0	0	0	26	11.3%	7.8
NE	0	1	4	11	0	0	0	0	16	6.9%	8.4
ENE	0	1	4	9	1	0	0	0	15	6.5%	8.4
E	0	1	0	5	0	0	0	0	6	2.6%	8.6
ESE	0	1	2	10	1	0	0	0	14	6.1%	9.0
SE	0	1	1	14	2	0	0	0	18	7.8%	9.1
SSE	0	1	3	3	0	0	0	0	7	3.0%	6.9
S	0	1	9	0	0	0	0	0	10	4.3%	6.1
SSW	0	0	9	2	0	0	0	0	11	4.8%	6.5
SW	0	0	2	0	0	0	0	0	2	0.9%	5.3
WSW	0	1	0	0	0	0	0	0	1	0.4%	2.6
W	0	0	0	1	0	0	0	0	1	0.4%	9.1
WNW	0	1	1	1	1	0	0	0	4	1.7%	8.5
NW	0	1	3	1	0	0	0	0	5	2.2%	5.3
NNW	0	2	8	28	11	1	0	0	50	21.6%	10.8
Total	0	15	65	117	33	1	0	0	231		
% Of Total	0.0%	6.5%	28.1%	50.6%	14.3%	0.4%	0.0%	0.0%			

Average speed for this table (MPH): 9.0
 Hours in above table with variable direction : 0
 Total number of CALMs : 21
 Total number of Invalid hours : 1
 Total number of Valid hours : 2207
 Total number of hours for period : 2208

Fourth Quarter 2005

Joint Frequency TableFrom : 10/01/2005 00:00 To : 12/31/2005 23:00PRIMARY TOWERSTABILTY CLASS D

Wind Speed (MPH) -> Sector	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
N	1	14	36	30	17	3	0	0	101	9.6%	8.5
NNE	1	21	46	44	9	0	0	0	121	11.4%	7.1
NE	0	12	30	35	16	0	0	0	93	8.8%	8.3
ENE	1	13	22	22	2	0	0	0	60	5.7%	7.0
E	0	19	12	25	14	0	0	0	70	6.6%	7.8
ESE	0	8	9	25	21	0	0	0	63	6.0%	9.6
SE	0	7	11	32	8	0	0	0	58	5.5%	8.7
SSE	0	5	31	22	2	0	0	0	60	5.7%	7.2
S	0	5	50	76	16	0	0	0	147	13.9%	8.7
SSW	0	0	21	46	6	0	0	0	73	6.9%	8.9
SW	0	1	6	10	10	0	0	0	27	2.6%	10.5
WSW	0	0	6	2	2	0	0	0	10	0.9%	8.4
W	0	6	4	1	0	0	0	0	11	1.0%	4.3
WNW	0	6	3	3	0	0	0	0	12	1.1%	4.8
NW	1	4	8	15	3	0	0	0	31	2.9%	7.9
NNW	2	17	35	43	22	1	0	0	120	11.4%	8.7
Total	6	138	330	431	148	4	0	0	1057		
% Of Total	0.6%	13.1%	31.2%	40.8%	14.0%	0.4%	0.0%	0.0%			

Average speed for this table (MPH): 8.2
 Hours in above table with variable direction : 0
 Total number of CALMs : 21
 Total number of Invalid hours : 1
 Total number of Valid hours : 2207
 Total number of hours for period : 2208

Fourth Quarter 2005

Joint Frequency Tables

Joint Frequency TableFrom : 10/01/2005 00:00 To : 12/31/2005 23:00PRIMARY TOWERSTABILTY CLASS E

Wind Speed (MPH) ->	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
Sector											
N	0	1	13	1	0	0	0	0	15	2.8%	5.3
NNE	0	7	40	21	0	0	0	0	68	12.5%	6.2
NE	1	20	61	24	2	0	0	0	108	19.9%	5.8
ENE	1	9	48	16	0	0	0	0	74	13.6%	6.1
E	1	8	32	2	0	0	0	0	43	7.9%	4.7
ESE	0	7	31	11	0	0	0	0	49	9.0%	5.9
SE	2	6	44	7	0	0	0	0	59	10.9%	5.1
SSE	0	3	40	3	0	0	0	0	46	8.5%	5.3
S	0	0	8	6	0	0	0	0	14	2.6%	7.5
SSW	0	1	1	0	0	0	0	0	2	0.4%	3.4
SW	0	1	0	0	0	0	0	0	1	0.2%	3.1
WSW	0	1	0	0	0	0	0	0	1	0.2%	3.3
W	0	2	5	0	0	0	0	0	7	1.3%	4.6
WNW	0	4	17	0	0	0	0	0	21	3.9%	4.9
NW	0	5	8	1	0	0	0	0	14	2.6%	4.5
NNW	1	6	14	0	0	0	0	0	21	3.9%	4.0
Total	6	81	362	92	2	0	0	0	543		
% Of Total	1.1%	14.9%	66.7%	16.9%	0.4%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 5.5
 Hours in above table with variable direction : 0
 Total number of CALMs : 21
 Total number of Invalid hours : 1
 Total number of Valid hours : 2207
 Total number of hours for period : 2208

Fourth Quarter 2005

Joint Frequency Table**From** : 10/01/2005 00:00 **To** : 12/31/2005 23:00**PRIMARY TOWER****STABILTY CLASS F**

Wind Speed (MPH) -> Sector	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
N	1	11	7	11	17	1	0	0	48	20.4%	9.5
NNE	3	17	10	0	0	0	0	0	30	12.8%	2.9
NE	1	14	12	0	0	0	0	0	27	11.5%	3.2
ENE	0	7	11	0	0	0	0	0	18	7.7%	3.7
E	1	11	11	0	0	0	0	0	23	9.8%	3.6
ESE	0	9	9	0	0	0	0	0	18	7.7%	3.9
SE	1	7	4	0	0	0	0	0	12	5.1%	3.1
SSE	0	1	2	0	0	0	0	0	3	1.3%	4.3
S	0	3	1	0	0	0	0	0	4	1.7%	3.4
SSW	0	0	1	1	0	0	0	0	2	0.9%	7.0
SW	0	0	0	0	0	0	0	0	0	0.0%	0.0
WSW	0	2	0	0	0	0	0	0	2	0.9%	2.0
W	0	7	0	0	0	0	0	0	7	3.0%	2.9
WNW	0	4	2	0	0	0	0	0	6	2.6%	2.9
NW	0	3	5	0	0	0	0	0	8	3.4%	4.0
NNW	2	9	8	6	2	0	0	0	27	11.5%	5.7
Total	9	105	83	18	19	1	0	0	235		
% Of Total	3.8%	44.7%	35.3%	7.7%	8.1%	0.4%	0.0%	0.0%			

Average speed for this table (MPH): 4.9
 Hours in above table with variable direction : 0
 Total number of CALMS : 21
 Total number of Invalid hours : 1
 Total number of Valid hours : 2207
 Total number of hours for period : 2208

Fourth Quarter 2005

Joint Frequency Table

From : 10/01/2005 00:00 To : 12/31/2005 23:00

PRIMARY TOWER

STABILTY CLASS G

Wind Speed (MPH) -> Sector	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6 +	Total	% Of Total	Avg. Speed
N	0	0	0	0	0	0	0	0	0	0.0%	0.0
NNE	0	0	0	0	0	0	0	0	0	0.0%	0.0
NE	0	0	1	0	0	0	0	0	1	33.3%	4.0
ENE	0	0	0	0	0	0	0	0	0	0.0%	0.0
E	0	0	0	0	0	0	0	0	0	0.0%	0.0
ESE	0	0	1	0	0	0	0	0	1	33.3%	4.5
SE	0	0	0	0	0	0	0	0	0	0.0%	0.0
SSE	0	0	0	0	0	0	0	0	0	0.0%	0.0
S	0	0	0	0	0	0	0	0	0	0.0%	0.0
SSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
SW	0	0	0	0	0	0	0	0	0	0.0%	0.0
WSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
W	0	0	0	0	0	0	0	0	0	0.0%	0.0
WNW	0	0	0	0	0	0	0	0	0	0.0%	0.0
NW	0	0	1	0	0	0	0	0	1	33.3%	3.9
NNW	0	0	0	0	0	0	0	0	0	0.0%	0.0
Total	0	0	3	0	0	0	0	0	3		
% Of Total	0.0%	0.0%	*****	0.0%	0.0%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 4.1
 Hours in above table with variable direction : 0
 Total number of CALMs : 21
 Total number of Invalid hours : 1
 Total number of Valid hours : 2207
 Total number of hours for period : 2208

Fourth Quarter 2005

Joint Frequency Table**From** : 10/01/2005 00:00 **To** : 12/31/2005 23:00**PRIMARY TOWER****ALL STABILITY CLASSES COMBINED**

Wind Speed (MPH) ->	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6 +	Total	% Of Total	Avg. Speed
Sector											
N	2	31	79	62	54	4	0	0	232	10.5%	8.7
NNE	4	47	120	84	9	0	0	0	264	12.0%	6.3
NE	2	48	115	71	18	0	0	0	254	11.5%	6.5
ENE	2	31	97	47	3	0	0	0	180	8.2%	6.3
E	2	43	60	33	14	0	0	0	152	6.9%	6.1
ESE	0	27	59	48	22	0	0	0	156	7.1%	7.4
SE	3	22	65	53	10	0	0	0	153	6.9%	6.7
SSE	0	10	77	29	2	0	0	0	118	5.3%	6.4
S	0	9	76	82	16	0	0	0	183	8.3%	8.2
SSW	0	3	39	50	6	0	0	0	98	4.4%	8.0
SW	0	2	11	10	10	0	0	0	33	1.5%	9.3
WSW	0	4	7	2	2	0	0	0	15	0.7%	6.5
W	0	15	9	2	0	0	0	0	26	1.2%	4.2
WNW	0	15	24	5	1	0	0	0	45	2.0%	5.1
NW	1	14	32	17	3	0	0	0	67	3.0%	6.1
NNW	5	35	77	77	35	2	0	0	231	10.5%	8.2
Total	21	356	947	672	205	6	0	0	2207		
% Of Total	1.0%	16.1%	42.9%	30.4%	9.3%	0.3%	0.0%	0.0%			

Average speed for this table (MPH) : 7.1
 Hours in above table with variable direction : 0
 Total number of CALMs : 21
 Total number of Invalid hours : 1
 Total number of Valid hours : 2207
 Total number of hours for period : 2208

Batch Release

First Quarter 2005

Joint Frequency Tables

Joint Frequency Table - Batch Release Hours

From : 01/01/2005 00:00 **To** : 03/31/2005 23:00

PRIMARY TOWER

Joint Frequency Table - Batch Release Hours**From** : 01/01/2005 00:00 **To** : 03/31/2005 23:00**PRIMARY TOWER****STABILITY CLASS A**

Wind Speed (MPH) →	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
Sector											
N	0	0	0	0	0	0	0	0	0	0.0%	0.0
NNE	0	0	0	2	1	0	0	0	3	4.5%	11.3
NE	0	0	3	0	0	0	0	0	3	4.5%	5.8
ENE	0	0	0	0	0	0	0	0	0	0.0%	0.0
E	0	0	0	0	0	0	0	0	0	0.0%	0.0
ESE	0	0	1	0	0	0	0	0	1	1.5%	5.0
SE	0	0	0	1	2	0	0	0	3	4.5%	12.4
SSE	0	0	0	2	5	0	0	0	7	10.6%	14.3
S	0	0	1	7	0	0	0	0	8	12.1%	10.0
SSW	0	0	2	16	5	0	0	0	23	34.8%	10.8
SW	0	1	2	1	4	1	0	0	9	13.6%	12.4
WSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
W	0	0	0	0	0	0	0	0	0	0.0%	0.0
WNW	0	0	0	2	0	0	0	0	2	3.0%	10.5
NW	0	0	0	0	1	5	0	0	6	9.1%	19.9
NNW	0	0	0	1	0	0	0	0	1	1.5%	9.2
Total	0	1	9	32	18	6	0	0	66		
% Of Total	0.0%	1.5%	13.6%	48.5%	27.3%	9.1%	0.0%	0.0%			

Average speed for this table (MPH): 11.9
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 1
 Total number of Valid hours : 554
 Total number of hours for period : 555

Batch Release

First Quarter 2005

Joint Frequency Tables

Joint Frequency Table - Batch Release Hours**From** : 01/01/2005 00:00 **To** : 03/31/2005 23:00**PRIMARY TOWER****STABILTY CLASS B**

Wind Speed (MPH) -> Sector	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6 +	Total	% Of Total	Avg. Speed
N	0	0	0	0	0	0	0	0	0	0.0%	0.0
NNE	0	0	1	0	1	0	0	0	2	7.1%	10.0
NE	0	0	2	2	1	0	0	0	5	17.9%	8.8
ENE	0	0	0	0	0	0	0	0	0	0.0%	0.0
E	0	0	0	0	0	0	0	0	0	0.0%	0.0
ESE	0	0	1	0	0	0	0	0	1	3.6%	5.5
SE	0	0	0	4	2	0	0	0	6	21.4%	11.2
SSE	0	0	1	0	3	0	0	0	4	14.3%	14.0
S	0	0	0	2	0	0	0	0	2	7.1%	11.0
SSW	0	0	0	1	0	0	0	0	1	3.6%	10.0
SW	0	0	0	0	0	0	0	0	0	0.0%	0.0
WSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
W	0	0	1	0	0	0	0	0	1	3.6%	5.4
WNW	0	0	0	0	0	0	0	0	0	0.0%	0.0
NW	0	0	0	3	2	0	0	0	5	17.9%	12.6
NNW	0	0	0	0	1	0	0	0	1	3.6%	13.7
Total	0	0	6	12	10	0	0	0	28		
% Of Total	0.0%	0.0%	21.4%	42.9%	35.7%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 11.0
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 1
 Total number of Valid hours : 554
 Total number of hours for period : 555

Joint Frequency Table - Batch Release Hours**From :** 01/01/2005 00:00 **To :** 03/31/2005 23:00**PRIMARY TOWER****STABILTY CLASS C**

Wind Speed (MPH) ->	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
Sector											
N	0	0	0	1	0	0	0	0	1	2.3%	11.1
NNE	0	0	1	1	1	0	0	0	3	7.0%	10.3
NE	0	0	0	2	3	0	0	0	5	11.6%	13.0
ENE	0	0	2	1	0	0	0	0	3	7.0%	8.1
E	0	0	1	0	0	0	0	0	1	2.3%	6.9
ESE	0	0	1	5	0	0	0	0	6	14.0%	8.4
SE	0	0	1	4	2	0	0	0	7	16.3%	10.6
SSE	0	0	1	0	3	0	0	0	4	9.3%	13.8
S	0	0	0	1	0	0	0	0	1	2.3%	10.3
SSW	0	0	1	1	1	0	0	0	3	7.0%	9.8
SW	0	0	1	1	0	0	0	0	2	4.7%	6.4
WSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
W	0	0	0	0	0	0	0	0	0	0.0%	0.0
WNW	0	0	0	0	0	0	0	0	0	0.0%	0.0
NW	0	0	0	1	3	0	0	0	4	9.3%	13.7
NNW	0	1	0	2	0	0	0	0	3	7.0%	8.3
Total	0	1	9	20	13	0	0	0	43		
% Of Total	0.0%	2.3%	20.9%	46.5%	30.2%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 10.4
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 1
 Total number of Valid hours : 554
 Total number of hours for period : 555

Joint Frequency Table - Batch Release Hours**From** : 01/01/2005 00:00 **To** : 03/31/2005 23:00**PRIMARY TOWER****STABILITY CLASS D**

Wind Speed (MPH) -> Sector	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
N	0	0	0	3	6	0	0	0	9	6.5%	13.1
NNE	0	0	0	9	5	0	0	0	14	10.1%	12.6
NE	0	0	10	8	4	0	0	0	22	15.9%	9.0
ENE	0	1	4	0	0	0	0	0	5	3.6%	5.5
E	0	1	3	2	0	0	0	0	6	4.3%	6.3
ESE	0	0	1	7	0	0	0	0	8	5.8%	9.1
SE	0	1	4	15	11	0	0	0	31	22.5%	10.5
SSE	0	0	1	4	4	0	0	0	9	6.5%	11.9
S	0	0	1	0	2	0	0	0	3	2.2%	11.1
SSW	0	0	1	2	0	0	0	0	3	2.2%	6.8
SW	0	0	2	4	3	0	0	0	9	6.5%	10.6
WSW	0	0	0	2	0	0	0	0	2	1.4%	8.0
W	0	0	0	2	0	0	0	0	2	1.4%	8.7
WNW	0	0	0	0	0	0	0	0	0	0.0%	0.0
NW	0	0	1	1	5	1	0	0	8	5.8%	14.3
NNW	0	0	0	2	5	0	0	0	7	5.1%	14.1
Total	0	3	28	61	45	1	0	0	138		
% Of Total	0.0%	2.2%	20.3%	44.2%	32.6%	0.7%	0.0%	0.0%			

Average speed for this table (MPH): 10.6
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 1
 Total number of Valid hours : 554
 Total number of hours for period : 555

Joint Frequency Table - Batch Release Hours**From :** 01/01/2005 00:00 **To :** 03/31/2005 23:00**PRIMARY TOWER****STABILTY CLASS E**

Wind Speed (MPH) ->	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
Sector											
N	0	1	3	7	5	0	0	0	16	8.9%	10.6
NNE	0	0	2	1	0	0	0	0	3	1.7%	7.1
NE	0	3	5	0	0	0	0	0	8	4.4%	4.2
ENE	0	1	10	1	0	0	0	0	12	6.7%	5.6
E	0	0	9	4	0	0	0	0	13	7.2%	6.5
ESE	0	0	8	5	0	0	0	0	13	7.2%	7.4
SE	0	0	9	13	0	0	0	0	22	12.2%	8.2
SSE	0	1	6	17	2	1	0	0	27	15.0%	8.9
S	0	2	7	5	4	0	0	0	18	10.0%	8.1
SSW	0	1	8	9	1	0	0	0	19	10.6%	7.9
SW	0	0	6	6	0	0	0	0	12	6.7%	8.4
WSW	0	0	1	1	0	0	0	0	2	1.1%	6.4
W	0	0	1	1	0	0	0	0	2	1.1%	6.7
WNW	0	0	0	0	0	0	0	0	0	0.0%	0.0
NW	0	0	0	0	3	1	0	0	4	2.2%	18.2
NNW	0	0	2	4	3	0	0	0	9	5.0%	10.7
Total	0	9	77	74	18	2	0	0	180		
% Of Total	0.0%	5.0%	42.8%	41.1%	10.0%	1.1%	0.0%	0.0%			

Average speed for this table (MPH): 8.2
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 1
 Total number of Valid hours : 554
 Total number of hours for period : 555

Joint Frequency Table - Batch Release Hours**From :** 01/01/2005 00:00 **To :** 03/31/2005 23:00**PRIMARY TOWER****STABILITY CLASS F**

Wind Speed (MPH) → Sector	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
N	0	0	5	0	0	0	0	0	5	8.3%	4.8
NNE	0	0	7	2	0	0	0	0	9	15.0%	6.2
NE	0	0	1	1	0	0	0	0	2	3.3%	6.4
ENE	0	1	4	0	0	0	0	0	5	8.3%	4.3
E	0	0	6	2	0	0	0	0	8	13.3%	6.3
ESE	0	3	2	1	0	0	0	0	6	10.0%	4.5
SE	0	2	5	0	0	0	0	0	7	11.7%	4.5
SSE	0	0	8	3	0	0	0	0	11	18.3%	6.8
S	0	0	0	0	0	0	0	0	0	0.0%	0.0
SSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
SW	0	0	3	0	0	0	0	0	3	5.0%	6.4
WSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
W	0	0	1	0	0	0	0	0	1	1.7%	4.1
WNW	0	0	1	0	0	0	0	0	1	1.7%	7.5
NW	0	1	1	0	0	0	0	0	2	3.3%	4.7
NNW	0	0	0	0	0	0	0	0	0	0.0%	0.0
Total	0	7	44	9	0	0	0	0	60		
% Of Total	0.0%	11.7%	73.3%	15.0%	0.0%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 5.6
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 1
 Total number of Valid hours : 554
 Total number of hours for period : 555

Joint Frequency Table - Batch Release HoursFrom : 01/01/2005 00:00 To : 03/31/2005 23:00PRIMARY TOWERSTABILTY CLASS G

Wind Speed (MPH) →	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
Sector											
N	0	1	1	0	0	0	0	0	2	5.1%	4.3
NNE	0	1	0	0	0	0	0	0	1	2.6%	3.0
NE	0	1	0	0	0	0	0	0	1	2.6%	2.0
ENE	0	2	0	0	0	0	0	0	2	5.1%	3.0
E	0	0	1	0	0	0	0	0	1	2.6%	4.4
ESE	0	4	2	1	0	0	0	0	7	17.9%	4.9
SE	0	2	0	0	0	0	0	0	2	5.1%	2.7
SSE	0	1	1	0	0	0	0	0	2	5.1%	3.7
S	0	0	0	0	0	0	0	0	0	0.0%	0.0
SSW	0	2	0	0	0	0	0	0	2	5.1%	2.6
SW	0	2	0	0	0	0	0	0	2	5.1%	1.8
WSW	0	2	0	0	0	0	0	0	2	5.1%	2.3
W	0	1	1	0	0	0	0	0	2	5.1%	2.7
WNW	0	3	1	0	0	0	0	0	4	10.3%	3.0
NW	0	1	2	0	0	0	0	0	3	7.7%	3.3
NNW	0	4	2	0	0	0	0	0	6	15.4%	3.7
Total	0	27	11	1	0	0	0	0	39		
% Of Total	0.0%	69.2%	28.2%	2.6%	0.0%	0.0%	0.0%	0.0%			

Average speed for this table (MPH) : 3.4
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 1
 Total number of Valid hours : 554
 Total number of hours for period : 555

Joint Frequency Table - Batch Release Hours

From : 01/01/2005 00:00 **To** : 03/31/2005 23:00

PRIMARY TOWER

ALL STABILITY CLASSES COMBINED

Wind Speed (MPH) ->	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6 +	Total	% Of Total	Avg. Speed
Sector											
N	0	2	9	11	11	0	0	0	33	6.0%	10.0
NNE	0	1	11	15	8	0	0	0	35	6.3%	9.8
NE	0	4	21	13	8	0	0	0	46	8.3%	8.1
ENE	0	5	20	2	0	0	0	0	27	4.9%	5.4
E	0	1	20	8	0	0	0	0	29	5.2%	6.3
ESE	0	7	16	19	0	0	0	0	42	7.6%	6.9
SE	0	5	19	37	17	0	0	0	78	14.1%	9.2
SSE	0	2	18	26	17	1	0	0	64	11.6%	10.0
S	0	2	9	15	6	0	0	0	32	5.8%	9.1
SSW	0	3	12	29	7	0	0	0	51	9.2%	9.1
SW	0	3	14	12	7	1	0	0	37	6.7%	9.3
WSW	0	2	1	3	0	0	0	0	6	1.1%	5.5
W	0	1	4	3	0	0	0	0	8	1.4%	5.7
WNW	0	3	2	2	0	0	0	0	7	1.3%	5.8
NW	0	2	4	5	14	7	0	0	32	5.8%	13.9
NNW	0	5	4	9	9	0	0	0	27	4.9%	9.8
Total	0	48	184	209	104	9	0	0	554		
% Of Total	0.0%	8.7%	33.2%	37.7%	18.8%	1.6%	0.0%	0.0%			

Average speed for this table (MPH): 8.9
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 1
 Total number of Valid hours : 554
 Total number of hours for period : 555

Batch Release

Second Quarter 2005

Joint Frequency Tables

Joint Frequency Table - Batch Release Hours

From : 04/01/2005 00:00 **To** : 06/30/2005 23:00

PRIMARY TOWER

Batch Release

Second Quarter 2005

Joint Frequency Tables

Joint Frequency Table - Batch Release Hours**From** : 04/01/2005 00:00 **To** : 06/30/2005 23:00**PRIMARY TOWER****STABILTY CLASS A**

Wind Speed (MPH) -> Sector	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
N	0	0	0	0	0	0	0	0	0	0.0%	0.0
NNE	0	0	2	0	0	0	0	0	2	6.1%	4.8
NE	0	0	0	0	0	0	0	0	0	0.0%	0.0
ENE	0	0	1	0	0	0	0	0	1	3.0%	5.4
E	0	0	0	0	0	0	0	0	0	0.0%	0.0
ESE	0	0	0	0	0	0	0	0	0	0.0%	0.0
SE	0	0	0	0	1	0	0	0	1	3.0%	17.4
SSE	0	0	0	0	4	0	0	0	4	12.1%	16.7
S	0	0	0	8	0	0	0	0	8	24.2%	11.5
SSW	0	0	0	2	0	0	0	0	2	6.1%	9.7
SW	0	0	0	0	0	0	0	0	0	0.0%	0.0
WSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
W	0	0	0	0	0	0	0	0	0	0.0%	0.0
WNW	0	0	1	0	0	0	0	0	1	3.0%	4.5
NW	0	0	0	3	1	0	0	0	4	12.1%	11.6
NNW	0	0	1	5	1	3	0	0	10	30.3%	13.1
Total	0	0	5	18	7	3	0	0	33		
% Of Total	0.0%	0.0%	15.2%	54.5%	21.2%	9.1%	0.0%	0.0%			

Average speed for this table (MPH): 11.9
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 0
 Total number of Valid hours : 325
 Total number of hours for period : 325

Joint Frequency Table - Batch Release Hours**From** : 04/01/2005 00:00 **To** : 06/30/2005 23:00**PRIMARY TOWER****STABILITY CLASS B**

Wind Speed (MPH) ->	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
Sector											
N	0	0	2	1	0	0	0	0	3	18.8%	6.5
NNE	0	0	0	0	0	0	0	0	0	0.0%	0.0
NE	0	0	0	0	0	0	0	0	0	0.0%	0.0
ENE	0	0	0	0	0	0	0	0	0	0.0%	0.0
E	0	0	0	0	0	0	0	0	0	0.0%	0.0
ESE	0	0	0	0	0	0	0	0	0	0.0%	0.0
SE	0	0	0	0	2	0	0	0	2	12.5%	17.0
SSE	0	0	0	0	0	0	0	0	0	0.0%	0.0
S	0	0	0	0	0	0	0	0	0	0.0%	0.0
SSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
SW	0	0	0	0	0	0	0	0	0	0.0%	0.0
WSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
W	0	0	0	0	0	0	0	0	0	0.0%	0.0
WNW	0	0	1	1	1	0	0	0	3	18.8%	10.1
NW	0	0	0	2	2	0	0	0	4	25.0%	11.6
NNW	0	0	0	2	0	2	0	0	4	25.0%	16.0
Total	0	0	3	6	5	2	0	0	16		
% Of Total	0.0%	0.0%	18.8%	37.5%	31.3%	12.5%	0.0%	0.0%			

Average speed for this table (MPH) : 12.1
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 0
 Total number of Valid hours : 325
 Total number of hours for period : 325

Joint Frequency Table - Batch Release Hours

From : 04/01/2005 00:00 To : 06/30/2005 23:00

PRIMARY TOWER

STABILTY CLASS C

Wind Speed (MPH) -> Sector	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
N	0	0	1	0	0	0	0	0	1	6.3%	7.1
NNE	0	0	0	0	0	0	0	0	0	0.0%	0.0
NE	0	0	0	0	0	0	0	0	0	0.0%	0.0
ENE	0	0	0	0	0	0	0	0	0	0.0%	0.0
E	0	0	0	0	0	0	0	0	0	0.0%	0.0
ESE	0	0	0	0	1	0	0	0	1	6.3%	14.3
SE	0	0	0	0	2	0	0	0	2	12.5%	17.0
SSE	0	0	0	0	1	0	0	0	1	6.3%	14.9
S	0	0	0	1	0	0	0	0	1	6.3%	8.6
SSW	0	0	0	1	0	0	0	0	1	6.3%	8.2
SW	0	0	0	0	0	0	0	0	0	0.0%	0.0
WSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
W	0	0	0	0	0	0	0	0	0	0.0%	0.0
WNW	0	0	1	2	1	0	0	0	4	25.0%	11.2
NW	0	0	0	0	2	0	0	0	2	12.5%	15.1
NNW	0	0	0	1	1	1	0	0	3	18.8%	15.8
Total	0	0	2	5	8	1	0	0	16		
% Of Total	0.0%	0.0%	12.5%	31.3%	50.0%	6.3%	0.0%	0.0%			

Average speed for this table (MPH): 13.1
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 0
 Total number of Valid hours : 325
 Total number of hours for period : 325

Joint Frequency Table - Batch Release Hours**From** : 04/01/2005 00:00 **To** : 06/30/2005 23:00**PRIMARY TOWER****STABILTY CLASS D**

Wind Speed (MPH) → Sector	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
N	0	0	3	0	0	0	0	0	3	2.6%	5.4
NNE	0	0	4	0	0	0	0	0	4	3.5%	5.8
NE	0	0	4	0	0	0	0	0	4	3.5%	5.9
ENE	0	0	1	0	0	0	0	0	1	0.9%	3.9
E	0	0	0	0	0	0	0	0	0	0.0%	0.0
ESE	0	0	0	0	6	0	0	0	6	5.2%	14.6
SE	0	0	0	9	24	0	0	0	33	28.7%	14.3
SSE	0	0	0	9	13	0	0	0	22	19.1%	13.2
S	0	0	0	3	5	2	0	0	10	8.7%	15.7
SSW	0	0	2	3	0	0	0	0	5	4.3%	7.8
SW	0	0	1	2	0	0	0	0	3	2.6%	8.4
WSW	0	0	3	0	0	0	0	0	3	2.6%	5.8
W	0	0	1	0	0	0	0	0	1	0.9%	6.5
WNW	0	0	1	1	2	0	0	0	4	3.5%	10.3
NW	0	0	1	5	4	0	0	0	10	8.7%	12.2
NNW	0	0	1	1	0	4	0	0	6	5.2%	16.6
Total	0	0	22	33	54	6	0	0	115		
% Of Total	0.0%	0.0%	19.1%	28.7%	47.0%	5.2%	0.0%	0.0%			

Average speed for this table (MPH) : 12.4
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 0
 Total number of Valid hours : 325
 Total number of hours for period : 325

Joint Frequency Table - Batch Release Hours**From** : 04/01/2005 00:00 **To** : 06/30/2005 23:00**PRIMARY TOWER****STABILTY CLASS E**

Wind Speed (MPH) -> Sector	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
N	0	0	1	2	0	0	0	0	3	6.3%	9.9
NNE	0	0	0	0	0	0	0	0	0	0.0%	0.0
NE	0	0	0	0	0	0	0	0	0	0.0%	0.0
ENE	0	1	0	0	0	0	0	0	1	2.1%	3.4
E	0	0	0	0	0	0	0	0	0	0.0%	0.0
ESE	0	0	0	0	0	0	0	0	0	0.0%	0.0
SE	0	0	0	4	8	0	0	0	12	25.0%	12.3
SSE	0	0	2	11	1	0	0	0	14	29.2%	9.1
S	0	0	0	1	0	0	0	0	1	2.1%	8.4
SSW	0	0	1	1	0	0	0	0	2	4.2%	7.7
SW	0	0	1	0	0	0	0	0	1	2.1%	5.3
WSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
W	0	0	0	0	0	0	0	0	0	0.0%	0.0
WNW	0	0	0	1	0	0	0	0	1	2.1%	11.0
NW	0	0	1	3	1	0	0	0	5	10.4%	9.1
NNW	0	0	2	4	2	0	0	0	8	16.7%	9.9
Total	0	1	8	27	12	0	0	0	48		
% Of Total	0.0%	2.1%	16.7%	56.3%	25.0%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 9.8
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 0
 Total number of Valid hours : 325
 Total number of hours for period : 325

Joint Frequency Table - Batch Release Hours**From :** 04/01/2005 00:00 **To :** 06/30/2005 23:00**PRIMARY TOWER****STABILITY CLASS F**

Wind Speed (MPH) →	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6 +	Total	% Of Total	Avg. Speed
Sector											
N	0	0	4	1	0	0	0	0	5	12.2%	6.1
NNE	0	0	1	3	0	0	0	0	4	9.8%	7.7
NE	0	0	0	0	0	0	0	0	0	0.0%	0.0
ENE	0	0	0	0	0	0	0	0	0	0.0%	0.0
E	0	0	0	0	0	0	0	0	0	0.0%	0.0
ESE	0	0	0	0	0	0	0	0	0	0.0%	0.0
SE	0	0	1	0	0	0	0	0	1	2.4%	4.0
SSE	0	2	1	0	0	0	0	0	3	7.3%	3.8
S	0	0	5	0	0	0	0	0	5	12.2%	4.3
SSW	0	1	7	0	0	0	0	0	8	19.5%	5.1
SW	0	0	0	0	0	0	0	0	0	0.0%	0.0
WSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
W	0	1	0	0	0	0	0	0	1	2.4%	3.4
WNW	0	1	1	0	0	0	0	0	2	4.9%	5.0
NW	0	1	3	3	0	0	0	0	7	17.1%	6.6
NNW	0	0	5	0	0	0	0	0	5	12.2%	6.2
Total	0	6	28	7	0	0	0	0	41		
% Of Total	0.0%	14.6%	68.3%	17.1%	0.0%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 5.6
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 0
 Total number of Valid hours : 325
 Total number of hours for period : 325

Joint Frequency Table - Batch Release Hours**From** : 04/01/2005 00:00 **To** : 06/30/2005 23:00**PRIMARY TOWER****STABILTY CLASS G**

Wind Speed (MPH) -> Sector	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
N	0	2	2	0	0	0	0	0	4	7.1%	3.9
NNE	0	1	5	0	0	0	0	0	6	10.7%	5.7
NE	0	1	2	0	0	0	0	0	3	5.4%	4.6
ENE	0	0	3	0	0	0	0	0	3	5.4%	3.9
E	0	1	0	0	0	0	0	0	1	1.8%	3.4
ESE	0	1	4	0	0	0	0	0	5	8.9%	4.8
SE	0	1	5	0	0	0	0	0	6	10.7%	4.0
SSE	0	0	3	0	0	0	0	0	3	5.4%	4.4
S	0	0	0	0	0	0	0	0	0	0.0%	0.0
SSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
SW	0	0	0	0	0	0	0	0	0	0.0%	0.0
WSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
W	0	0	0	0	0	0	0	0	0	0.0%	0.0
WNW	0	5	4	0	0	0	0	0	9	16.1%	3.2
NW	0	2	10	0	0	0	0	0	12	21.4%	3.9
NNW	0	2	2	0	0	0	0	0	4	7.1%	3.3
Total	0	16	40	0	0	0	0	0	56		
% Of Total	0.0%	28.6%	71.4%	0.0%	0.0%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 4.1
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 0
 Total number of Valid hours : 325
 Total number of hours for period : 325

Joint Frequency Table - Batch Release Hours**From :** 04/01/2005 00:00 **To :** 06/30/2005 23:00**PRIMARY TOWER****ALL STABILITY CLASSES COMBINED**

Wind Speed (MPH) ->	(1) CALM	(2) 1.0 - 3.5	(3) 3.6 - 7.5	(4) 7.6 - 12.5	(5) 12.6 - 18.5	(6) 18.6 - 24.5	(7) 24.6 - 32.5	(8) 32.6 +	Total	% Of Total	Avg. Speed
Sector											
N	0	2	13	4	0	0	0	0	19	5.8%	6.2
NNE	0	1	12	3	0	0	0	0	16	4.9%	6.1
NE	0	1	6	0	0	0	0	0	7	2.2%	5.3
ENE	0	1	5	0	0	0	0	0	6	1.8%	4.1
E	0	1	0	0	0	0	0	0	1	0.3%	3.4
ESE	0	1	4	0	7	0	0	0	12	3.7%	10.5
SE	0	1	6	13	37	0	0	0	57	17.5%	12.9
SSE	0	2	6	20	19	0	0	0	47	14.5%	11.1
S	0	0	5	13	5	2	0	0	25	7.7%	11.5
SSW	0	1	10	7	0	0	0	0	18	5.5%	6.8
SW	0	0	2	2	0	0	0	0	4	1.2%	7.6
WSW	0	0	3	0	0	0	0	0	3	0.9%	5.8
W	0	1	1	0	0	0	0	0	2	0.6%	5.0
WNW	0	6	9	5	4	0	0	0	24	7.4%	7.1
NW	0	3	15	16	10	0	0	0	44	13.5%	8.7
NNW	0	2	11	13	4	10	0	0	40	12.3%	11.6
Total	0	23	108	96	86	12	0	0	325		
% Of Total	0.0%	7.1%	33.2%	29.5%	26.5%	3.7%	0.0%	0.0%			

Average speed for this table (MPH): 9.7
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 0
 Total number of Valid hours : 325
 Total number of hours for period : 325

Joint Frequency Table - Batch Release Hours

From : 07/01/2005 00:00 **To** : 09/30/2005 23:00

PRIMARY TOWER

Joint Frequency Table - Batch Release Hours**From** : 07/01/2005 00:00 **To** : 09/30/2005 23:00**PRIMARY TOWER****STABILITY CLASS A**

Wind Speed (MPH) -> Sector	(1) CALM	(2) 1.0 - 3.5	(3) 3.6 - 7.5	(4) 7.6 - 12.5	(5) 12.6 - 18.5	(6) 18.6 - 24.5	(7) 24.6 - 32.5	(8) 32.6 +	Total	% Of Total	Avg. Speed
N	0	0	0	0	0	0	0	0	0	*****	0.0
NNE	0	0	0	0	0	0	0	0	0	*****	0.0
NE	0	0	0	0	0	0	0	0	0	*****	0.0
ENE	0	0	0	0	0	0	0	0	0	*****	0.0
E	0	0	0	0	0	0	0	0	0	*****	0.0
ESE	0	0	0	0	0	0	0	0	0	*****	0.0
SE	0	0	0	0	0	0	0	0	0	*****	0.0
SSE	0	0	0	0	0	0	0	0	0	*****	0.0
S	0	0	0	0	0	0	0	0	0	*****	0.0
SSW	0	0	0	0	0	0	0	0	0	*****	0.0
SW	0	0	0	0	0	0	0	0	0	*****	0.0
WSW	0	0	0	0	0	0	0	0	0	*****	0.0
W	0	0	0	0	0	0	0	0	0	*****	0.0
WNW	0	0	0	0	0	0	0	0	0	*****	0.0
NW	0	0	0	0	0	0	0	0	0	*****	0.0
NNW	0	0	0	0	0	0	0	0	0	*****	0.0
Total	0	0	0	0	0	0	0	0	0		
% Of Total	*****	*****	*****	*****	*****	*****	*****	*****			

Average speed for this table (MPH): 0.0
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 0
 Total number of Valid hours : 6
 Total number of hours for period : 6

Joint Frequency Table - Batch Release Hours

From : 07/01/2005 00:00 **To** : 09/30/2005 23:00

PRIMARY TOWER

STABILTY CLASS B

Wind Speed (MPH) ->	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
Sector											
N	0	0	0	0	0	0	0	0	0	*****	0.0
NNE	0	0	0	0	0	0	0	0	0	*****	0.0
NE	0	0	0	0	0	0	0	0	0	*****	0.0
ENE	0	0	0	0	0	0	0	0	0	*****	0.0
E	0	0	0	0	0	0	0	0	0	*****	0.0
ESE	0	0	0	0	0	0	0	0	0	*****	0.0
SE	0	0	0	0	0	0	0	0	0	*****	0.0
SSE	0	0	0	0	0	0	0	0	0	*****	0.0
S	0	0	0	0	0	0	0	0	0	*****	0.0
SSW	0	0	0	0	0	0	0	0	0	*****	0.0
SW	0	0	0	0	0	0	0	0	0	*****	0.0
WSW	0	0	0	0	0	0	0	0	0	*****	0.0
W	0	0	0	0	0	0	0	0	0	*****	0.0
WNW	0	0	0	0	0	0	0	0	0	*****	0.0
NW	0	0	0	0	0	0	0	0	0	*****	0.0
NNW	0	0	0	0	0	0	0	0	0	*****	0.0
Total	0	0	0	0	0	0	0	0	0		
% Of Total	*****	*****	*****	*****	*****	*****	*****	*****			

Average speed for this table (MPH): 0.0
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 0
 Total number of Valid hours : 6
 Total number of hours for period : 6

Joint Frequency Table - Batch Release Hours

From : 07/01/2005 00:00 **To** : 09/30/2005 23:00

PRIMARY TOWER

STABILTY CLASS C

Wind Speed (MPH) ->	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6 +	Total	% Of Total	Avg. Speed
Sector											
N	0	0	0	0	0	0	0	0	0	*****	0.0
NNE	0	0	0	0	0	0	0	0	0	*****	0.0
NE	0	0	0	0	0	0	0	0	0	*****	0.0
ENE	0	0	0	0	0	0	0	0	0	*****	0.0
E	0	0	0	0	0	0	0	0	0	*****	0.0
ESE	0	0	0	0	0	0	0	0	0	*****	0.0
SE	0	0	0	0	0	0	0	0	0	*****	0.0
SSE	0	0	0	0	0	0	0	0	0	*****	0.0
S	0	0	0	0	0	0	0	0	0	*****	0.0
SSW	0	0	0	0	0	0	0	0	0	*****	0.0
SW	0	0	0	0	0	0	0	0	0	*****	0.0
WSW	0	0	0	0	0	0	0	0	0	*****	0.0
W	0	0	0	0	0	0	0	0	0	*****	0.0
WNW	0	0	0	0	0	0	0	0	0	*****	0.0
NW	0	0	0	0	0	0	0	0	0	*****	0.0
NNW	0	0	0	0	0	0	0	0	0	*****	0.0
Total	0	0	0	0	0	0	0	0	0		
% Of Total	*****	*****	*****	*****	*****	*****	*****	*****			

Average speed for this table (MPH): 0.0
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 0
 Total number of Valid hours : 6
 Total number of hours for period : 6

Joint Frequency Table - Batch Release Hours

From : 07/01/2005 00:00 **To** : 09/30/2005 23:00

PRIMARY TOWER

STABILTY CLASS D

Wind Speed (MPH) ->	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
Sector											
N	0	0	0	0	0	0	0	0	0	*****	0.0
NNE	0	0	0	0	0	0	0	0	0	*****	0.0
NE	0	0	0	0	0	0	0	0	0	*****	0.0
ENE	0	0	0	0	0	0	0	0	0	*****	0.0
E	0	0	0	0	0	0	0	0	0	*****	0.0
ESE	0	0	0	0	0	0	0	0	0	*****	0.0
SE	0	0	0	0	0	0	0	0	0	*****	0.0
SSE	0	0	0	0	0	0	0	0	0	*****	0.0
S	0	0	0	0	0	0	0	0	0	*****	0.0
SSW	0	0	0	0	0	0	0	0	0	*****	0.0
SW	0	0	0	0	0	0	0	0	0	*****	0.0
WSW	0	0	0	0	0	0	0	0	0	*****	0.0
W	0	0	0	0	0	0	0	0	0	*****	0.0
WNW	0	0	0	0	0	0	0	0	0	*****	0.0
NW	0	0	0	0	0	0	0	0	0	*****	0.0
NNW	0	0	0	0	0	0	0	0	0	*****	0.0
Total	0	0	0	0	0	0	0	0	0		
% Of Total	*****	*****	*****	*****	*****	*****	*****	*****			

Average speed for this table (MPH): 0.0
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 0
 Total number of Valid hours : 6
 Total number of hours for period : 6

Joint Frequency Table - Batch Release Hours

From : 07/01/2005 00:00 **To :** 09/30/2005 23:00

PRIMARY TOWER

STABILTY CLASS E

Wind Speed (MPH) ->	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
Sector											
N	0	0	0	0	0	0	0	0	0	0.0%	0.0
NNE	0	0	0	0	0	0	0	0	0	0.0%	0.0
NE	0	0	0	0	0	0	0	0	0	0.0%	0.0
ENE	0	0	0	0	0	0	0	0	0	0.0%	0.0
E	0	0	4	1	0	0	0	0	5	83.3%	6.9
ESE	0	0	0	1	0	0	0	0	1	16.7%	9.5
SE	0	0	0	0	0	0	0	0	0	0.0%	0.0
SSE	0	0	0	0	0	0	0	0	0	0.0%	0.0
S	0	0	0	0	0	0	0	0	0	0.0%	0.0
SSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
SW	0	0	0	0	0	0	0	0	0	0.0%	0.0
WSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
W	0	0	0	0	0	0	0	0	0	0.0%	0.0
WNW	0	0	0	0	0	0	0	0	0	0.0%	0.0
NW	0	0	0	0	0	0	0	0	0	0.0%	0.0
NNW	0	0	0	0	0	0	0	0	0	0.0%	0.0
Total	0	0	4	2	0	0	0	0	6		
% Of Total	0.0%	0.0%	66.7%	33.3%	0.0%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 7.3
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 0
 Total number of Valid hours : 6
 Total number of hours for period : 6

Joint Frequency Table - Batch Release Hours

From : 07/01/2005 00:00 **To** : 09/30/2005 23:00

PRIMARY TOWER

STABILTY CLASS F

Wind Speed (MPH) → Sector	(1) CALM	(2) 1.0 - 3.5	(3) 3.6 - 7.5	(4) 7.6 - 12.5	(5) 12.6 - 18.5	(6) 18.6 - 24.5	(7) 24.6 - 32.5	(8) 32.6 +	Total	% Of Total	Avg. Speed
N	0	0	0	0	0	0	0	0	0	*****	0.0
NNE	0	0	0	0	0	0	0	0	0	*****	0.0
NE	0	0	0	0	0	0	0	0	0	*****	0.0
ENE	0	0	0	0	0	0	0	0	0	*****	0.0
E	0	0	0	0	0	0	0	0	0	*****	0.0
ESE	0	0	0	0	0	0	0	0	0	*****	0.0
SE	0	0	0	0	0	0	0	0	0	*****	0.0
SSE	0	0	0	0	0	0	0	0	0	*****	0.0
S	0	0	0	0	0	0	0	0	0	*****	0.0
SSW	0	0	0	0	0	0	0	0	0	*****	0.0
SW	0	0	0	0	0	0	0	0	0	*****	0.0
WSW	0	0	0	0	0	0	0	0	0	*****	0.0
W	0	0	0	0	0	0	0	0	0	*****	0.0
WNW	0	0	0	0	0	0	0	0	0	*****	0.0
NW	0	0	0	0	0	0	0	0	0	*****	0.0
NNW	0	0	0	0	0	0	0	0	0	*****	0.0
Total	0	0	0	0	0	0	0	0	0		
% Of Total	*****	*****	*****	*****	*****	*****	*****	*****			

Average speed for this table (MPH): 0.0
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 0
 Total number of Valid hours : 6
 Total number of hours for period : 6

Joint Frequency Table - Batch Release Hours

From : 07/01/2005 00:00 **To** : 09/30/2005 23:00

PRIMARY TOWER

STABILTY CLASS G

Wind Speed (MPH) ->	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6 +	Total	% Of Total	Avg. Speed
Sector											
N	0	0	0	0	0	0	0	0	0	*****	0.0
NNE	0	0	0	0	0	0	0	0	0	*****	0.0
NE	0	0	0	0	0	0	0	0	0	*****	0.0
ENE	0	0	0	0	0	0	0	0	0	*****	0.0
E	0	0	0	0	0	0	0	0	0	*****	0.0
ESE	0	0	0	0	0	0	0	0	0	*****	0.0
SE	0	0	0	0	0	0	0	0	0	*****	0.0
SSE	0	0	0	0	0	0	0	0	0	*****	0.0
S	0	0	0	0	0	0	0	0	0	*****	0.0
SSW	0	0	0	0	0	0	0	0	0	*****	0.0
SW	0	0	0	0	0	0	0	0	0	*****	0.0
WSW	0	0	0	0	0	0	0	0	0	*****	0.0
W	0	0	0	0	0	0	0	0	0	*****	0.0
WNW	0	0	0	0	0	0	0	0	0	*****	0.0
NW	0	0	0	0	0	0	0	0	0	*****	0.0
NNW	0	0	0	0	0	0	0	0	0	*****	0.0
Total	0	0	0	0	0	0	0	0	0		
% Of Total	*****	*****	*****	*****	*****	*****	*****	*****			

Average speed for this table (MPH): 0.0
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 0
 Total number of Valid hours : 6
 Total number of hours for period : 6

Joint Frequency Table - Batch Release Hours

From : 07/01/2005 00:00 - To : 09/30/2005 23:00

PRIMARY TOWER

ALL STABILITY CLASSES COMBINED

Wind Speed (MPH) ->	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
Sector											
N	0	0	0	0	0	0	0	0	0	0.0%	0.0
NNE	0	0	0	0	0	0	0	0	0	0.0%	0.0
NE	0	0	0	0	0	0	0	0	0	0.0%	0.0
ENE	0	0	0	0	0	0	0	0	0	0.0%	0.0
E	0	0	4	1	0	0	0	0	5	83.3%	6.9
ESE	0	0	0	1	0	0	0	0	1	16.7%	9.5
SE	0	0	0	0	0	0	0	0	0	0.0%	0.0
SSE	0	0	0	0	0	0	0	0	0	0.0%	0.0
S	0	0	0	0	0	0	0	0	0	0.0%	0.0
SSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
SW	0	0	0	0	0	0	0	0	0	0.0%	0.0
WSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
W	0	0	0	0	0	0	0	0	0	0.0%	0.0
WNW	0	0	0	0	0	0	0	0	0	0.0%	0.0
NW	0	0	0	0	0	0	0	0	0	0.0%	0.0
NNW	0	0	0	0	0	0	0	0	0	0.0%	0.0
Total	0	0	4	2	0	0	0	0	6		
% Of Total	0.0%	0.0%	66.7%	33.3%	0.0%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 7.3
 Hours in above table with variable direction : 0
 Total number of CALMs : 0
 Total number of Invalid hours : 0
 Total number of Valid hours : 6
 Total number of hours for period : 6

Joint Frequency Table - Batch Release Hours

From : 10/01/2005 00:00 **To** : 12/31/2005 23:00

PRIMARY TOWER

Joint Frequency Table - Batch Release Hours**From** : 10/01/2005 00:00 **To** : 12/31/2005 23:00**PRIMARY TOWER****STABILTY CLASS A**

Wind Speed (MPH) -> Sector	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
N	0	0	4	0	0	0	0	0	4	12.1%	4.5
NNE	0	0	3	0	0	0	0	0	3	9.1%	4.6
NE	0	1	3	0	0	0	0	0	4	12.1%	3.8
ENE	0	1	6	0	0	0	0	0	7	21.2%	4.8
E	0	1	0	0	0	0	0	0	1	3.0%	1.7
ESE	0	0	3	0	0	0	0	0	3	9.1%	5.2
SE	0	0	0	0	0	0	0	0	0	0.0%	0.0
SSE	0	0	0	0	0	0	0	0	0	0.0%	0.0
S	0	0	1	0	0	0	0	0	1	3.0%	5.0
SSW	0	0	3	0	0	0	0	0	3	9.1%	4.0
SW	0	0	1	0	0	0	0	0	1	3.0%	4.7
WSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
W	0	0	0	0	0	0	0	0	0	0.0%	0.0
WNW	0	0	0	0	0	0	0	0	0	0.0%	0.0
NW	0	1	0	0	0	0	0	0	1	3.0%	2.0
NNW	0	0	5	0	0	0	0	0	5	15.2%	5.3
Total	0	4	29	0	0	0	0	0	33		
% Of Total	0.0%	12.1%	87.9%	0.0%	0.0%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 4.5
 Hours in above table with variable direction : 0
 Total number of CALMs : 18
 Total number of Invalid hours : 1
 Total number of Valid hours : 631
 Total number of hours for period : 632

Joint Frequency Table - Batch Release Hours**From :** 10/01/2005 00:00 **To :** 12/31/2005 23:00**PRIMARY TOWER****STABILTY CLASS B**

Wind Speed (MPH) →	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
Sector											
N	0	0	1	3	0	0	0	0	4	16.0%	10.2
NNE	0	0	6	2	0	0	0	0	8	32.0%	6.5
NE	0	0	1	0	0	0	0	0	1	4.0%	5.0
ENE	0	0	1	0	0	0	0	0	1	4.0%	7.3
E	0	0	0	1	0	0	0	0	1	4.0%	7.6
ESE	0	0	1	1	0	0	0	0	2	8.0%	7.5
SE	0	0	0	0	0	0	0	0	0	0.0%	0.0
SSE	0	0	0	1	0	0	0	0	1	4.0%	8.0
S	0	0	1	0	0	0	0	0	1	4.0%	5.2
SSW	0	0	2	0	0	0	0	0	2	8.0%	5.4
SW	0	0	0	0	0	0	0	0	0	0.0%	0.0
WSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
W	0	0	0	0	0	0	0	0	0	0.0%	0.0
WNW	0	0	0	0	0	0	0	0	0	0.0%	0.0
NW	0	0	0	0	0	0	0	0	0	0.0%	0.0
NNW	0	1	3	0	0	0	0	0	4	16.0%	4.6
Total	0	1	16	8	0	0	0	0	25		
% Of Total	0.0%	4.0%	64.0%	32.0%	0.0%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 6.8
 Hours in above table with variable direction : 0
 Total number of CALMs : 18
 Total number of Invalid hours : 1
 Total number of Valid hours : 631
 Total number of hours for period : 632

Joint Frequency Table - Batch Release Hours**From** : 10/01/2005 00:00 **To** : 12/31/2005 23:00**PRIMARY TOWER****STABILTY CLASS C**

Wind Speed (MPH) → Sector	(1) CALM	(2) 1.0 - 3.5	(3) 3.6 - 7.5	(4) 7.6 - 12.5	(5) 12.6 - 18.5	(6) 18.6 - 24.5	(7) 24.6 - 32.5	(8) 32.6 +	Total	% Of Total	Avg. Speed
N	0	3	5	5	0	0	0	0	13	14.3%	6.8
NNE	0	0	6	12	0	0	0	0	18	19.8%	7.9
NE	0	0	0	5	0	0	0	0	5	5.5%	9.9
ENE	0	0	2	6	0	0	0	0	8	8.8%	8.1
E	0	1	0	2	0	0	0	0	3	3.3%	6.7
ESE	0	0	0	4	0	0	0	0	4	4.4%	10.6
SE	0	0	1	10	0	0	0	0	11	12.1%	9.0
SSE	0	0	1	2	0	0	0	0	3	3.3%	8.2
S	0	1	6	0	0	0	0	0	7	7.7%	6.1
SSW	0	0	5	0	0	0	0	0	5	5.5%	6.4
SW	0	0	0	0	0	0	0	0	0	0.0%	0.0
WSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
W	0	0	0	0	0	0	0	0	0	0.0%	0.0
WNW	0	0	0	0	0	0	0	0	0	0.0%	0.0
NW	0	1	0	0	0	0	0	0	1	1.1%	3.0
NNW	0	1	0	12	0	0	0	0	13	14.3%	9.8
Total	0	7	26	58	0	0	0	0	91		
% Of Total	0.0%	7.7%	28.6%	63.7%	0.0%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 8.1
 Hours in above table with variable direction : 0
 Total number of CALMs : 18
 Total number of Invalid hours : 1
 Total number of Valid hours : 631
 Total number of hours for period : 632

Joint Frequency Table - Batch Release Hours**From** : 10/01/2005 00:00 **To** : 12/31/2005 23:00**PRIMARY TOWER****STABILTY CLASS D**

Wind Speed (MPH) →	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
Sector											
N	1	7	9	3	6	0	0	0	26	12.0%	7.1
NNE	1	11	15	3	0	0	0	0	30	13.8%	4.7
NE	0	2	10	10	1	0	0	0	23	10.6%	7.2
ENE	1	1	9	5	1	0	0	0	17	7.8%	7.3
E	0	5	2	13	12	0	0	0	32	14.7%	10.1
ESE	0	1	1	8	11	0	0	0	21	9.7%	11.8
SE	0	2	2	7	1	0	0	0	12	5.5%	8.5
SSE	0	1	4	3	1	0	0	0	9	4.1%	7.9
S	0	0	5	8	0	0	0	0	13	6.0%	8.5
SSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
SW	0	0	0	0	0	0	0	0	0	0.0%	0.0
WSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
W	0	0	0	0	0	0	0	0	0	0.0%	0.0
WNW	0	0	0	0	0	0	0	0	0	0.0%	0.0
NW	1	1	1	2	0	0	0	0	5	2.3%	5.5
NNW	2	10	5	12	0	0	0	0	29	13.4%	5.9
Total	6	41	63	74	33	0	0	0	217		
% Of Total	2.8%	18.9%	29.0%	34.1%	15.2%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 7.7
 Hours in above table with variable direction : 0
 Total number of CALMs : 18
 Total number of Invalid hours : 1
 Total number of Valid hours : 631
 Total number of hours for period : 632

Joint Frequency Table - Batch Release Hours**From** : 10/01/2005 00:00 **To** : 12/31/2005 23:00**PRIMARY TOWER****STABILTY CLASS E**

Wind Speed (MPH) -> Sector	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
N	0	1	2	0	0	0	0	0	3	1.6%	3.6
NNE	0	6	19	6	0	0	0	0	31	16.3%	5.7
NE	1	10	38	17	0	0	0	0	66	34.7%	5.9
ENE	1	2	28	2	0	0	0	0	33	17.4%	5.1
E	1	1	10	1	0	0	0	0	13	6.8%	5.0
ESE	0	2	6	1	0	0	0	0	9	4.7%	5.1
SE	2	1	16	0	0	0	0	0	19	10.0%	4.3
SSE	0	0	10	0	0	0	0	0	10	5.3%	4.9
S	0	0	0	0	0	0	0	0	0	0.0%	0.0
SSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
SW	0	0	0	0	0	0	0	0	0	0.0%	0.0
WSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
W	0	0	0	0	0	0	0	0	0	0.0%	0.0
WNW	0	0	0	0	0	0	0	0	0	0.0%	0.0
NW	0	2	0	0	0	0	0	0	2	1.1%	3.5
NNW	1	2	1	0	0	0	0	0	4	2.1%	1.9
Total	6	27	130	27	0	0	0	0	190		
% Of Total	3.2%	14.2%	68.4%	14.2%	0.0%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 5.3
 Hours in above table with variable direction : 0
 Total number of CALMs : 18
 Total number of Invalid hours : 1
 Total number of Valid hours : 631
 Total number of hours for period : 632

Joint Frequency Table - Batch Release Hours**From :** 10/01/2005 00:00 **To :** 12/31/2005 23:00**PRIMARY TOWER****STABILTY CLASS F**

Wind Speed (MPH) ->	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
Sector											
N	1	3	2	2	4	0	0	0	12	16.2%	8.4
NNE	3	3	6	0	0	0	0	0	12	16.2%	2.8
NE	0	4	6	0	0	0	0	0	10	13.5%	3.6
ENE	0	2	4	0	0	0	0	0	6	8.1%	4.0
E	0	2	6	0	0	0	0	0	8	10.8%	4.4
ESE	0	2	6	0	0	0	0	0	8	10.8%	4.8
SE	0	3	3	0	0	0	0	0	6	8.1%	3.8
SSE	0	0	0	0	0	0	0	0	0	0.0%	0.0
S	0	2	0	0	0	0	0	0	2	2.7%	2.7
SSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
SW	0	0	0	0	0	0	0	0	0	0.0%	0.0
WSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
W	0	0	0	0	0	0	0	0	0	0.0%	0.0
WNW	0	0	1	0	0	0	0	0	1	1.4%	3.8
NW	0	1	3	0	0	0	0	0	4	5.4%	4.7
NNW	2	2	1	0	0	0	0	0	5	6.8%	1.7
Total	6	24	38	2	4	0	0	0	74		
% Of Total	8.1%	32.4%	51.4%	2.7%	5.4%	0.0%	0.0%	0.0%			

Average speed for this table- (MPH): 4.4
 Hours in above table with variable direction : 0
 Total number of CALMs : 18
 Total number of Invalid hours : 1
 Total number of Valid hours : 631
 Total number of hours for period : 632

Joint Frequency Table - Batch Release Hours

From : 10/01/2005 00:00 To : 12/31/2005 23:00

PRIMARY TOWER

STABILTY CLASS G

Wind Speed (MPH) ->	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
Sector											
N	0	0	0	0	0	0	0	0	0	0.0%	0.0
NNE	0	0	0	0	0	0	0	0	0	0.0%	0.0
NE	0	0	1	0	0	0	0	0	1	*****	4.0
ENE	0	0	0	0	0	0	0	0	0	0.0%	0.0
E	0	0	0	0	0	0	0	0	0	0.0%	0.0
ESE	0	0	0	0	0	0	0	0	0	0.0%	0.0
SE	0	0	0	0	0	0	0	0	0	0.0%	0.0
SSE	0	0	0	0	0	0	0	0	0	0.0%	0.0
S	0	0	0	0	0	0	0	0	0	0.0%	0.0
SSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
SW	0	0	0	0	0	0	0	0	0	0.0%	0.0
WSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
W	0	0	0	0	0	0	0	0	0	0.0%	0.0
WNW	0	0	0	0	0	0	0	0	0	0.0%	0.0
NW	0	0	0	0	0	0	0	0	0	0.0%	0.0
NNW	0	0	0	0	0	0	0	0	0	0.0%	0.0
Total	0	0	1	0	0	0	0	0	1		
% Of Total	0.0%	0.0%	*****	0.0%	0.0%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 4.0
 Hours in above table with variable direction : 0
 Total number of CALMs : 18
 Total number of Invalid hours : 1
 Total number of Valid hours : 631
 Total number of hours for period : 632

Joint Frequency Table - Batch Release Hours**From : 10/01/2005 00:00 To : 12/31/2005 23:00****PRIMARY TOWER****ALL STABILITY CLASSES COMBINED**

Wind Speed (MPH) ->	(1) CALM	(2) 1.0 -3.5	(3) 3.6 -7.5	(4) 7.6 -12.5	(5) 12.6 -18.5	(6) 18.6 -24.5	(7) 24.6 -32.5	(8) 32.6+	Total	% Of Total	Avg. Speed
Sector											
N	2	14	23	13	10	0	0	0	62	9.8%	7.2
NNE	4	20	55	23	0	0	0	0	102	16.2%	5.5
NE	1	17	59	32	1	0	0	0	110	17.4%	6.1
ENE	2	6	50	13	1	0	0	0	72	11.4%	5.9
E	1	10	18	17	12	0	0	0	58	9.2%	7.8
ESE	0	5	17	14	11	0	0	0	47	7.4%	8.6
SE	2	6	22	17	1	0	0	0	48	7.6%	6.3
SSE	0	1	15	6	1	0	0	0	23	3.6%	6.6
S	0	3	13	8	0	0	0	0	24	3.8%	7.0
SSW	0	0	10	0	0	0	0	0	10	1.6%	5.5
SW	0	0	1	0	0	0	0	0	1	0.2%	4.7
WSW	0	0	0	0	0	0	0	0	0	0.0%	0.0
W	0	0	0	0	0	0	0	0	0	0.0%	0.0
WNW	0	0	1	0	0	0	0	0	1	0.2%	3.8
NW	1	6	4	2	0	0	0	0	13	2.1%	4.5
NNW	5	16	15	24	0	0	0	0	60	9.5%	6.0
Total	18	104	303	169	37	0	0	0	631		
% Of Total	2.9%	16.5%	48.0%	26.8%	5.9%	0.0%	0.0%	0.0%			

Average speed for this table (MPH): 6.4
 Hours in above table with variable direction : 0
 Total number of CALMs : 18
 Total number of Invalid hours : 1
 Total number of Valid hours : 631
 Total number of hours for period : 632