



# Nuclear Regulatory Commission Fire Safety Review Kickoff

19 April 2007



# Agenda

- Open Session
- Availability of Fire Hazards Analysis
- NUREG-1718 crosswalk example
- Fire Protection Program Plan
- Closed Session
- Fire Safety PSSCs → IROFS
- Process Fire Doors
- Clean Agent Systems
- Temperature Dilution for HEPA Filters
- Fire Water Supply
- Building Design and NFPA 220
- Surveillance, Testing, and Maintenance of Fire Safety Systems
- Arrival Time of SRS Fire Department
- Codes and Standards

# Availability of Fire Hazards Analysis

The approved FHA is available for on site review.

# NUREG-1718 Crosswalk

- NUREG-1718 Chapter 7 Example  
*(handout)*

# Fire Protection Program Plan

- Revision 0 of the Fire Protection Program Plan is approved and available for on site review
- The Fire Protection Program Plan identifies procedures, policies, and administrative controls required to support construction and operation
- The procedures, policies, and administrative controls will be developed or implemented later in the construction phase