

Official Transcript of Proceedings ACRST-3419

NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards

Docket Number: (n/a)

PROCESS USING ADAMS
TEMPLATE: ACRS/ACNW-005
SUNSI REVIEW COMPLETE

Location: Rockville, Maryland

Date: Thursday, December 6, 2007

Work Order No.: NRC-1898

Pages 1-168

ORIGINAL



NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

**ACRS OFFICE COPY
RETAIN FOR THE LIFE OF THE COMMITTEE**

TR04

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

December 6, 2007

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, taken on December 6, 2007, as reported herein, is a record of the discussions recorded at the meeting held on the above date.

This transcript has not been reviewed, corrected and edited and it may contain inaccuracies.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS (ACRS)

+ + + + +

548TH MEETING

+ + + + +

THURSDAY, DECEMBER 6, 2007

+ + + + +

The meeting was held in Room T-2B3, Two White Flint North, 11545 Rockville Pike, Rockville, Maryland, at 8:30 a.m., William J. Shack, Chairman, presiding.

MEMBERS PRESENT:

- WILLIAM J. SHACK Chairman
- MARIO V. BONACA Vice Chairman
- SAID ABDEL-KHALIK Member
- JOHN W. STETKAR Member
- OTTO L. MAYNARD Member
- DENNIS C. BLEY Member
- MICHAEL CORRADINI Member
- GEORGE E. APOSTOLAKIS Member
- DANA A. POWERS Member
- J. SAM ARMIJO Member
- JOHN D. SIEBER Member-At-Large

1 NRC STAFF PRESENT:

2 SAM DURAISWAMY, Designated Federal Official

3 ROBERT LEE TREGONING

4 LEE ABRAMSON

5 NILESH CHOKSHI

6 KHALID SHAUKAT

7 RICHARD DUDLEY

8 TIM COLLINS

9 GREG CRANSTON

10 TAI HUANG

11 ROBERT PRATO

12 FAROUK ELTAWILA

13 JIMI YEROKUN

14 MIKE CHEOK

15 JOCELYN MITCHELL

16 DON DUBE

17 RICH SHERRY

18 ALSO PRESENT:

19 DOUG PRUITT

20 YOUSEF FARAWILA

21 EDWIN LYMEN

22

23

24

25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

TABLE OF CONTENTS

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

PAGE

Opening Remarks 4

Draft Final NUREG-1829:

 Dr. George Apostolakis 9

 Robert L. Tregoning 9

 Nilesh Chokshi 43

AREVA Enhanced Option III Long-Term Stability

Solution:

 Said Abdel-Khalik 77

 Tai Huang 78

 Dr. Yousef Farawila 90

P R O C E E D I N G S

(8:28 a.m.)

CHAIRMAN SHACK: The meeting will come to order.

This is the first day of the 548th meeting of the Advisory Committee on Reactor Safeguards. During today's meeting, the Committee will consider the following:

Draft final NUREG-1829, estimating loss of coolant accident frequencies through the elicitation process;

And a draft NUREG on seismic considerations for the transition break size;

The AREVA enhanced Option III long-term stability solution;

The state-of-the-art reactor consequence analysis, SOARCA, which will be a part open and part closed meeting;

A draft ACRS report on the NRC Safety Research Program;

And preparation of ACRS reports.

A portion of this meeting may be closed to discuss safeguards and national security information related to the SOARCA project.

This meeting is being conducted in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 accordance with the provisions of the Federal Advisory
2 Committee Act. Mr. Sam Duraiswamy is the Designated
3 Federal Official for the initial portion of the
4 meeting.

5 We have received no written comments from
6 members of the public regarding today's session. We
7 have received a request from Dr. Edwin Lyman, Union of
8 Concerned Scientists, for time to make oral statements
9 regarding the SOARCA project.

10 A transcript of portions of the meeting is
11 being kept, and it is requested that the speakers use
12 one of the microphones, identify themselves and speak
13 with sufficient clarity and volume so that they can be
14 readily heard.

15 I will begin with some items of current
16 interest. The members are scheduled to interview a
17 candidate today during lunchtime. We'll be handing
18 out a resume. It's one candidate so we'll do it as
19 group.

20 Other information. Ms. Barbara Jo White,
21 who has been with the ACRS office for almost 40 years
22 is retiring on January 3rd, 2008. All of these years
23 she has provided outstanding administrative support to
24 the members. She has always ensured that the members
25 have a good place to stay when they attend ACRS

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 meetings in town or out of town.

2 She has been exceptional in assuring that
3 the federal register notices for the subcommittee and
4 full committee meeting have been issued consistent
5 with FACA requirements.

6 Her outstanding administrative support to
7 members, hard work, dedication, professional attitude
8 in dealing with not only the members and staff, but
9 also the public are very much appreciated.

10 Thank you, and good luck in your future
11 endeavors.

12 (Applause.)

13 CHAIRMAN SHACK: In addition to a retiree,
14 we have some new additions to the ACRS staff. Dr.
15 Harold Vander Mollen will be joining the ACRS staff as
16 a senior staff engineer on December 24th. He will be
17 the responsible engineer for the Subcommittees on
18 Reliability and PRA and Regulatory Policies and
19 Practices.

20 He came to the AEC regulatory staff from
21 the National Bureau of Standards in 1974. He spent 13
22 years in several technical branches in NRR working on
23 reactor physics, accident and transient analysis,
24 technical specifications, generic issues program, and
25 PRA issues.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 In 1987, he and his section were
2 transferred from the PRA branch in NRR to the PRA
3 branch in the Office of Nuclear Regulatory Research,
4 just in time to work on the NUREG-1150 project.

5 When it was finished, he was put in charge
6 of PRA methods development. In 1999, after 12 years
7 in the PRA branch in RES, he took over the generic
8 program issues program again.

9 Welcome aboard.

10 (Applause.)

11 CHAIRMAN SHACK: Ms. Kendra Freeland
12 joined the ACRS/ACNW&M staff on October 22nd as an
13 administrative assistant. She will be handling travel
14 authorization, vouchers and compensation for the
15 members, one of our most important concerns.

16 (Laughter.)

17 CHAIRMAN SHACK: Prior to joining the ACRS
18 ACNW&M staff, she served as secretary for the Division
19 of Contracts in the Office of Administration.

20 Kendra received a Bachelor of Arts degree
21 in corporate and broadcast communications from Elon
22 University, Elon, North Carolina, and a Master's
23 degree in communications from Hawaii Pacific
24 University, Honolulu, Hawaii.

25 She knows how to pick a graduate school.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 (Laughter.)

2 CHAIRMAN SHACK: Welcome aboard.

3 Ms. Guita Irani joined the ACRS/ACNW&M
4 staff on November 13th, 2007, as an information
5 technology specialist. She is a new member of the
6 NRC.

7 Guita started her career in information
8 technology working as a DOD contractor for the Joint
9 Spectrum Center in 2000. In 2003, she moved to the
10 Pension Benefit Guaranty Corporation to support their
11 federal contracts.

12 Guita holds a Master's degree in
13 information technology from the University of Maryland
14 and has been involved with software development and IT
15 support throughout her career.

16 Welcome aboard.

17 MR. DURAISWAMY: Janet is not here. So
18 you can do that tomorrow.

19 CHAIRMAN SHACK: Okay. We'll hold.
20 Sounds good.

21 Well, then we can move to our business
22 today, and our first item of business is the draft
23 NUREG on estimating loss of coolant accident, LOCA,
24 frequencies through the elicitation process, and Dr.
25 Apostolakis will lead us through that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER APOSTOLAKIS: Thank you, Bill.

2 We had a subcommittee meeting on the 27th
3 of November when we heard from the staff on both
4 studies. One is on the expert judgment elicitation
5 process and results, and the other one was more
6 focused studies on seismic issues.

7 There were no issues that were raised by
8 the subcommittee. The members appear to be -- well,
9 actually they were -- pleased with what they heard.
10 The staff also presented their responses to public
11 comments on the elicitation process. So we asked them
12 to come back today and give a shortened performance so
13 that the members will form an opinion.

14 And we are expected to write a letter at
15 this meeting. So with that, I should turn to you,
16 Rob?

17 MR. TREGONING: Yes.

18 MEMBER APOSTOLAKIS: Okay.

19 MR. TREGONING: Thank you, Dr. Apostolakis
20 and Mr. Chairman.

21 My name is Rob Tregoning from the Office
22 of Research, and to my right is Lee Abramson, and we
23 will be leading you through the first abridged
24 presentation on the development of NUREG-1829, on
25 passive system LOCA frequency development for risk-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 informed revision of 10 CFR 5046.

2 Why did we get into this work? Well, our
3 bosses essentially told us we needed to do this. So
4 this work was done in response to Commission direction
5 provided by SRM-02-0057, and a couple of quotes there.
6 "The staff should provide the Commission a
7 comprehensive LOCA failure analysis and frequency
8 estimation that is realistically conservative and
9 amenable to decision-making with appropriate margins
10 for uncertainty."

11 So that was our edict. That was our
12 direction. Also, in the same SRM, the Commission said
13 the staff should use expert elicitation to converge
14 whenever possible service data and PFM results. So
15 those are our marching orders. That's what we set off
16 to do.

17 And we're here today, as Dr. Apostolakis
18 had indicated, requesting a letter or an ACRS
19 recommendation to publish the study, NUREG-1829. Our
20 opinion is it sufficiently meets the Commission
21 direction, satisfies that and should be published as
22 a result.

23 A brief executive summary. We used the
24 formal elicitation process to develop estimates of
25 generic BWR and PWR passive system LOCA frequencies

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 associated with material degradation. We had a group
2 of 12 panelists. They provided us with quantitative
3 estimates supported by qualitative rationale. They
4 did this individually in individual elicitations for
5 underlying technical issues that were developed as a
6 group.

7 We had very good or generally good
8 agreement on the qualitative LOCA contributing
9 factors. However, as you've seen in the report, there
10 was large individual uncertainty and also large panel
11 variability in actually quantifying the estimates. So
12 coming up with frequency estimates associated with the
13 phenomena that they were predicting.

14 That wasn't surprising, of course. We
15 expected that, and that was the reason that we chose
16 to do elicitation to begin with, to provide a
17 framework and a mechanism for dealing with the
18 expected large uncertainty in panel variability.

19 The bottom line, we developed group
20 results. So we aggregated the individual estimates
21 for the LOCA frequency distribution parameters. So we
22 didn't determine distributions per se, but we
23 determined certain parameters of the distribution, the
24 50th, 95th and the mean. We used a number of
25 different aggregation schemes. One scheme we used was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the geometric mean. We thought those results were
2 consistent with the elicitation objective in structure
3 and they're also generally comparable with the NUREG/
4 CR-5750 estimates.

5 That study was the prior study that was
6 used to develop LOCA frequency estimates back in the
7 mid-'90s. It was not done using elicitation. It was
8 done by just simply evaluating service experience.

9 As mentioned in this last bullet, we
10 looked at other aggregation schemes and other
11 aggregation schemes can give you quite a bit different
12 results, and typically these other schemes that we
13 looked at did result in higher LOCA frequency.

14 We show the results here. These are the
15 bottom line results for BWR and PWR. Generic
16 frequencies, you see three curves on each of those.
17 The black curves are the medians, the reds are the
18 mean, and then the green are the 95th.

19 The center points are what we're
20 considering the best estimate, and then their
21 confidence bounds, the error bars represent 90 percent
22 confidence bounds. So a five percent and a 95 percent
23 upper and lower confidence bound about that best
24 estimate.

25 These particular results, we did a modest

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 adjustment for overconfidence. We adjusted error
2 factors or uncertainty ranges in some expert opinions
3 to coincide with a well-known elicitation. I don't
4 want to call it a fact, but a finding in many
5 elicitation studies that experts tend to be
6 overconfident.

7 We didn't see as strong a bias for
8 overconfidence in these results. So that's why a
9 correction ended up only being relatively modest in
10 this case.

11 These 90 percent confidence bounds, it
12 says 95, but it's really 90 percent -- they're used to
13 represent or reflect the diversity or the differences
14 among individual panelists' opinion, and then the
15 difference between the medians and the 95th really
16 reflect the individual panelists' uncertainties. So
17 there's two types of uncertainty or variability that
18 we're trying to capture.

19 MEMBER CORRADINI: Could you repeat what
20 you just said? You said that the very -- could you
21 repeat, please?

22 MR. TREGONING: The confidence bounds
23 about any individual value here, either about the
24 mean, median or 95th percentile, they represent the
25 spread or the difference among the individual

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 estimates that we got from the panel. For each
2 panelist, we asked for them for each answer that they
3 provided, we asked for a best guess, essentially a
4 median value, and then we asked high and low
5 estimates, which we interpreted as fifth and 95th
6 percentile estimates about that mid-value.

7 MEMBER CORRADINI: Thank you.

8 MR. TREGONING: I guess this is the only
9 new slide that the subcommittee hasn't seen. It was
10 put in at a request from Professor Apostolakis at the
11 subcommittee meeting. He wanted to see what the
12 distribution shape looked like. So we did a very
13 simple exercise to create these, and these are
14 essentially -- all I did was take a simple, lognormal,
15 not split or anything, just the full lognormal, and I
16 fit them to the 95th and the mean because those are
17 the two parameters that we're most interested in
18 using.

19 So I forced it to go through the mean and
20 the 95th, and then the question was, well, how well
21 does it estimate the median and the fifth. And the
22 fifth, really a lot of extrapolation to get down to
23 the fifth.

24 And both Lee and I were quite surprised at
25 how well the fits tended to be. So in the medians in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 all cases, there was less than 30 percent error, which
2 again, for LOCA frequencies, considering the
3 variability we have, is pretty darn good. And even in
4 the fifth percentile it was less than 50 percent
5 error, except in one case where we had a percent error
6 of 200.

7 And I've picked four plots here. The blue
8 plot and the red plot are actually the worst fit of
9 all the distributions that we fit to this thing. So
10 these are the worst, and the green and the black are
11 more representative of the types of fits you would
12 see.

13 And I just summarized the percent error
14 there.

15 MEMBER APOSTOLAKIS: So what does this
16 mean? Let me understand the curve. So the blue curve
17 is for BWR-5; is that what you're saying?

18 MR. TREGONING: Yes. So that's the BWR
19 LOCA frequency at LOCA Category 5. So --

20 MEMBER APOSTOLAKIS: So you are only
21 showing mean curves. All of these are mean curves?

22 MR. TREGONING: No, these are
23 distributions. So plotted on these are all of the
24 percentiles of the fit distribution.

25 MEMBER APOSTOLAKIS: Oh, I'm sorry. Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. TREGONING: And then the points are
2 our actual values.

3 MEMBER APOSTOLAKIS: The means.

4 MR. TREGONING: Those are our values. I
5 identified where the means are because the other thing
6 you can see here is that the means in all cases are a
7 relatively high percentile, not surprising, but the
8 means vary anywhere from about the 70th to even as
9 high the 85th percentile on the distribution,
10 depending on which parameter you're looking at.

11 MEMBER CORRADINI: So what you're plotting
12 here is a fit shape to the three points that we saw in
13 the previous curve on some break sizes.

14 MR. TREGONING: Right, right. If I go to
15 the previous one --

16 MEMBER CORRADINI: That's fine.

17 MR. TREGONING: -- where we didn't show
18 the fifth, that was the four points that we developed.

19 MEMBER CORRADINI: Got it.

20 MEMBER APOSTOLAKIS: Now, the scale, I
21 guess, distorts a little bit what is happening because
22 they rise too steeply, don't they? I mean the curves.

23 MEMBER BLEY: Goes over about four orders
24 of magnitude.

25 MEMBER APOSTOLAKIS: The green one is the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 only one.

2 MEMBER BLEY: And the other one goes over
3 at least two orders of magnitude.

4 CHAIRMAN SHACK: There's a good spread in
5 those curves, and the spread is sort of what you
6 think. For small breaks it's narrow, where for big
7 breaks, it's very wide.

8 MR. TREGONING: So the black one is the
9 small break. So you can see they're in order of
10 increasing break size, obviously.

11 MEMBER APOSTOLAKIS: So if I did a PRA
12 tomorrow and I needed the frequency of various LOCAs,
13 I could use this one, although this is based -- these
14 curves are based on what you call a baseline approach,
15 right?

16 MR. TREGONING: These were geometric mean
17 aggregated results. Yes, they were.

18 MEMBER CORRADINI: So I guess since I
19 didn't read in detail the report, I interpret the
20 difference between the Ps and the Bs as primarily a
21 pressure effect, not a materials effect and not a
22 chemistry effect.

23 What do the experts say relative to that
24 in terms of their -- because if I remember this
25 process, you have to elicit not just a number, but a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 reason for the number.

2 MR. TREGONING: Yes, and I didn't overlay
3 in this presentation Ps with Bs, but what you see is
4 the Ps have higher small break frequencies.

5 MEMBER CORRADINI: Right. I was looking
6 at that just from the numbers.

7 MR. TREGONING: Right. Well, it's not
8 clear from this because I show two Ps. I show two
9 small Ps and then I show two large Bs.

10 MEMBER CORRADINI: Right. It's just the
11 previous one I was looking at.

12 MR. TREGONING: Right. So the Ps are
13 higher at small break, and then they're actually lower
14 in intermediate breaks, and then at the biggest breaks
15 the Ps get higher again.

16 The Ps are higher at small break primarily
17 due to the fact steam generator tube rupture failures
18 and concern for PWSCC issues related to CRDM, other
19 small tube piping.

20 The Bs tend to get higher in the
21 intermediate break because of largely driven by
22 remaining IGSCC issues just due to the fact that BWRs,
23 a lot of the large piping still retains flaws that
24 were generated earlier under normal water chemistry
25 the documents you see.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And while the experts believe that they
2 have been mitigated to the sense that the frequencies
3 were relatively low, they still raised up or rose up
4 to be one of the highest risk contributors. So even
5 though they have been mitigated, they still were the
6 largest risk contributor.

7 And then when you get down to the highest
8 frequencies, PWRs dominate, again, and that's more of
9 a population issue. PWRs have larger pipes, more,
10 bigger non-piping components that could fail and lead
11 to a LOCA. So there wasn't anything unique that was
12 driving that other than the increased population.

13 CHAIRMAN SHACK: But these frequencies
14 still include the steam generator tubes --

15 MR. TREGONING: Yes.

16 CHAIRMAN SHACK: -- for the PWRs which
17 will --

18 MR. TREGONING: But even if I take the --

19 CHAIRMAN SHACK: It's still true.

20 MR. TREGONING: -- I don't show it here.
21 If I take the steam generator out, Ps are still
22 higher.

23 CHAIRMAN SHACK: Now, you said the
24 lognormal plots were the baseline or are they the
25 error factor corrected?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. TREGONING: These are error factor
2 corrected.

3 CHAIRMAN SHACK: Corrected. Okay. That's
4 sort of your best estimate curve.

5 MR. TREGONING: That's what we would call,
6 yes.

7 MEMBER APOSTOLAKIS: Now, if you included
8 in this the multiple distribution, what do you call
9 that?

10 MR. TREGONING: The mixture distribution?

11 MEMBER APOSTOLAKIS: Yes, mixture
12 distribution. How would these curves change? Would
13 they be broader?

14 MR. TREGONING: Yes. Yes.

15 MEMBER APOSTOLAKIS: They would be broader
16 on the high side especially or --

17 MR. TREGONING: They would be broader
18 high, broader to the high.

19 CHAIRMAN SHACK: And the means would be
20 higher.

21 MR. TREGONING: They would be broader high
22 and low.

23 MEMBER APOSTOLAKIS: And low.

24 MR. TREGONING: And low, and then the
25 means would be shift obviously.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BLEY: Medians would be about the
2 same probably?

3 MR. TREGONING: No. Again, it's a totally
4 different way to aggregate. So, no, the medians would
5 be -- I'm not sure how the medians would work out.

6 CHAIRMAN SHACK: They're higher. I mean,
7 that's the way they work out when you look at the
8 numbers.

9 MR. TREGONING: Okay.

10 CHAIRMAN SHACK: I mean, just looking I
11 can read the table.

12 MR. TREGONING: Yes, I haven't looked at
13 that.

14 MEMBER APOSTOLAKIS: You could develop
15 curves like this using that other method.

16 MR. TREGONING: Yes. Yes, you could.

17 MEMBER APOSTOLAKIS: But then ultimately
18 you might want to combine the curves.

19 MR. TREGONING: But the mixture
20 distribution, you come up with the distribution
21 itself. So you wouldn't turn around and fit it as we
22 have here.

23 MEMBER APOSTOLAKIS: I understand that,
24 but you can always change those distributions based on
25 insights you got here. I mean, ultimately what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 matters is what you learn from the whole exercise,
2 right?

3 I would make an analogy with licensing a
4 reactor. We have been told many times in this room by
5 the staff our decision is not based on a single
6 analysis. It's the result of a process.

7 So here, you know, you might say at the
8 end I want a distribution which says, you know, I've
9 been through this. I've done it ten different ways.
10 This is what I think it is.

11 Now, that takes guts.

12 (Laughter.)

13 MEMBER APOSTOLAKIS: Anyway, it's okay.
14 I did want to inquire, but this is the biggest problem
15 Bayesian methods have.

16 MR. TREGONING: Okay. I think George
17 could give this presentation at this point. I think
18 he already has. So we'll --

19 (Laughter.)

20 MR. TREGONING: -- spend the rest of the
21 time -- we'll continue to move through.

22 MEMBER APOSTOLAKIS: And you still don't
23 believe me.

24 MR. TREGONING: I believe you, you know,
25 with all of my heart.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So we did a number of sensitivity
2 analyses, and Professor Apostolakis alluded to one of
3 those, and all I'm going to touch on is one because
4 it's the one that's the most interesting. It's the
5 one that's the most controversial, and that's looking
6 at different ways to aggregate individual results.

7 So what I had shown before is essentially
8 the blue curves here, and these are the means. So if
9 I go back to this plot, those blue curves correspond
10 to the red curves on this plot. I apologize for
11 changing colors on you guys.

12 And the red curves here, they represent
13 using either arithmetic mean to aggregate the
14 individual expert estimates or analogously, at least
15 for determining the mean, actually creating a mixture
16 distribution from the result.

17 MEMBER APOSTOLAKIS: Wait a minute now.
18 Isn't it true that they can be an arithmetic mean
19 where the percentile is not the same as the mixture
20 distribution.

21 MR. TREGONING: Right, but when you're
22 looking at the mean it is.

23 MEMBER APOSTOLAKIS: Oh, you may be right
24 there.

25 MR. TREGONING: Yes, yes. For that one

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 parameter.

2 MEMBER BLEY: I'd have to think real hard
3 about that one.

4 MR. TREGONING: Well, the way we did
5 arithmetic mean aggregation, we just took the
6 arithmetic mean of all the percentile estimates of the
7 estimates.

8 So for the mean estimates that they gave
9 us, it's just the arithmetic. It's just the mean of
10 the mean. So the mixture distribution, when you work
11 through it, that mean is also the mean in the middle.

12 MEMBER APOSTOLAKIS: The mean is a funny
13 quantity.

14 CHAIRMAN SHACK: It is.

15 MEMBER ARMIJO: I don't understand why
16 there's such a big difference between the mean and the
17 mean of the mixture for LOCA Category 4 on the BWR.
18 I mean, those two curves are very different compared
19 to the PWR. What go that?

20 CHAIRMAN SHACK: Essentially we had one of
21 the panelists that if you look at the red curves,
22 they're weighted by one panelist result. So
23 essentially one panelist was very much higher than the
24 rest in their predictions for BWRs. So that's why the
25 curve shape looks like that, and that's why it's so

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 different than the geometric mean aggregate.

2 Now, that one panelist, his model was --
3 again, his biggest risk driver was IGSCC, and this was
4 a PFM approach, and the PFM model was essentially
5 giving him the result that, you know, a large break
6 LOCA has about the same frequency as a much smaller
7 LOCA in that large piping.

8 So that's why his results look so flat,
9 but they were very different. They were different
10 than everyone else's results, and that's one of the
11 reasons for the big difference between or the primary
12 reason driving the big difference between the
13 arithmetic mean and the geometric mean aggregated
14 results.

15 MEMBER ARMIJO: But that same person, when
16 you got to the Category 5 and 6s was pretty much
17 consistent with the rest of the --

18 MR. TREGONING: Yes, they go back down,
19 right.

20 CHAIRMAN SHACK: If you see a six it's not
21 a pipe break anymore, you know.

22 MR. TREGONING: This isn't a pipe break.
23 So it's apples and oranges, and five for BWR. You
24 really needed a complete rupture of the prime recirc.
25 piping to get that. So when it came down to complete,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you know, these guys are balancing for all the pipes.
2 They have to consider complete ruptures of smallest
3 pipes leading up to that LOCA category, as well as
4 partial ruptures of bigger pipes.

5 MEMBER MAYNARD: Well, they all didn't
6 provide data for every category either, did they?

7 MR. TREGONING: They were consistent in
8 that they didn't all provide us BWR and PWR
9 information. Some of the experts only felt qualified
10 to give us BWR information. But once they gave us
11 information, they gave us information from all the
12 categories from one plant type, and that was required
13 because of the way we structured the elicitation. We
14 needed that to be so that they could develop self-
15 consistent estimates.

16 Now, some of their estimates were very
17 like if their qualitative response said I don't think
18 the pump casings are a significant risk driver, right,
19 they didn't necessarily need to give us quantitative
20 estimates at that point. You know, we can take that
21 information and say, okay, I just need to make sure
22 that these don't contribute to your final risk
23 profile.

24 MEMBER ABDEL-KHALIK: What is the smallest
25 size sample in all of these categories?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. TREGONING: We had eight BWR estimates
2 and nine PWR estimates. So of the 12 we had one
3 expert that didn't provide any estimates for anything.
4 So then we had 11 that gave us estimates, and eight of
5 those gave us BWRs, and nine of them gave us Ps. So
6 we had two people that didn't give us Ps and three
7 that didn't give us Bs.

8 I wanted to talk a little bit about the
9 review. We've had quite a bit of review. We started
10 with the panel itself. We did a lot of Q&A and
11 feedback on the individual responses that they gave
12 us. They gave us pieces. To develop one set of
13 frequencies for an expert it took about 100, 200
14 questions that they had to answer. So they didn't
15 necessarily see what their final outcome was when they
16 were giving us a testimony.

17 So when they were giving us the testimony,
18 we were checking to make sure their rationale and the
19 numbers they were giving us makes sense, and that was
20 actually the most extensive part of the process
21 because quite often those things didn't match up. So
22 we had quite a lot of feedback of each of the
23 individual experts to make sure that their
24 quantitative numbers did support their qualitative
25 rationale.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 They also reviewed the calculations and
2 analysis that we did on their individual results to
3 make sure it was accurate within the framework that we
4 had provided them, and again, as I mentioned here,
5 once the draft NUREG was put together, they also
6 reviewed the general qualitative and quantitative
7 findings and conclusions.

8 Did you have a question?

9 MEMBER CORRADINI: Well, I was going to --
10 I was looking through the -- so they provided their
11 analyses or their bases for their judgments and they
12 spoke with each other and discussed it as part of it.
13 Was there interplay between the experts? I guess
14 that's what I'm asking.

15 And then did they reevaluate it and give
16 you another set of numbers?

17 MR. TREGONING: There was, and there were
18 chances for them to do the reevaluation. The way we
19 structured it is we brought them together as a group
20 to develop all of the issues and brainstorm and
21 identify the things they were going to be evaluating.

22 Then we did some background analyses which
23 I'm not going to go into, but essentially the base
24 case analyses, and we brought them together again and
25 discussed that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Then they went off and did their
2 elicitations individually. Then, once we got all of
3 the results, we brought them back together as a group
4 again and said, "Here are your individual results and
5 here are your results with respect to the group, and
6 we focused on that meeting and that was about a three-
7 day meeting. We were looking at differences because
8 you're always looking for, you know, if one expert is
9 different than the other. You're looking to see if
10 there's qualitative reasons that the other ones hadn't
11 thought about.

12 And they were given the opportunity after
13 that meeting if they so chose to revise their
14 estimates, but to be honest, nobody did. So even
15 though they were informed, no one felt strongly enough
16 about the new information that they thought they
17 needed to go back and redo their estimates.

18 Again, we've had a lot of group exchange
19 prior to that as well.

20 MEMBER CORRADINI: On the flow chart, I'm
21 sorry. I didn't mean to take -- but that was very
22 helpful. I was looking for the flow chart in the
23 document.

24 MR. TREGONING: Okay.

25 MEMBER CORRADINI: I'm sorry. Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. TREGONING: So, again, we had a lot of
2 feedback with the panel. We also had a small external
3 peer review. We had two people with decision analysts
4 and a statistician, and we asked them to look at the
5 structure of the elicitation, the analysis procedure
6 framework, how we did aggregation, and those review
7 reports are publicly available.

8 The external peer review was quite
9 helpful. It helped us refine our analysis technique.
10 We've had a large number of ACRS interactions that we
11 thank you. I think this is our 13th or maybe 14th at
12 this point.

13 And then we've had internal staff review,
14 NRR as well as people in the Office of Research, and
15 finally we went through public review and comment.

16 I'll briefly touch on here in the next few
17 slides the public comments that we got. We issued
18 draft NUREG-1829 in June of 2005. We opened the
19 public comment period, and then we closed it on
20 November 2005.

21 We had 29 comments from the public. We
22 had nice diversity of comments. We actually had one
23 of the elicitation panelists himself that felt
24 compelled to comment. That was interesting. We got
25 some comments from academia and --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: Did he ever explain
2 to you why he didn't raise his concerns during the
3 elicitation process?

4 MR. TREGONING: Oh, he did.

5 MEMBER APOSTOLAKIS: Oh, he did?

6 MEMBER CORRADINI: He just wanted to put
7 it on the record.

8 MR. TREGONING: Yes, he did.

9 (Laughter.)

10 MR. TREGONING: You know these group
11 dynamics. We discussed his comments and issues as a
12 group, and then the group --

13 CHAIRMAN SHACK: Didn't see the light.

14 MR. TREGONING: No, no one, but that's
15 okay.

16 MEMBER APOSTOLAKIS: That's good.

17 MR. TREGONING: And, in fact, I encourage
18 them to do that. I said, you know, there is an
19 opportunity and just the fact that you were an
20 elicitation panelist, that shouldn't stop you from
21 commenting as well as it shouldn't stop anybody from
22 commenting. So he did that.

23 MEMBER APOSTOLAKIS: It would be funny if
24 you commented though.

25 (Laughter.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: Right? Or Lee.

2 MR. ABRAMSON: We're a united team.

3 MR. TREGONING: I don't know if that would
4 be unprecedented, but probably close to it.

5 And then we've got a number of comments
6 from industry, owners groups, individual licensees.

7 At the same time that we went out for
8 public comment we were anxious to get this out and get
9 some comment, but the document was being reviewed
10 internally by NRR as well, and so we got a large
11 number of comments from the NRR staff, and in fact,
12 the document we provided to you has the NRR comments
13 commingled with the public comments, and we grouped
14 the comments topically just so ACRS -- we would be
15 able to avail you of that information so you could
16 consider all the comments that we got, and in total we
17 got about 101 separate comments.

18 So in general, to summarize the public
19 comments, you know, public comments were generally
20 useful. They identified some additions and
21 clarifications, that we went forward to hopefully
22 improve the exposition, as well as facilitate the use
23 of these results. None of the comments certainly in
24 the author's mind, and hopefully the responses
25 document that, presented a significant challenge to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the appropriateness of the objective approach,
2 analysis or results.

3 With the public comments as well, you can
4 see the most passionate controversy is still the
5 proper method for aggregating individual estimates to
6 produce group estimates.

7 MEMBER ARMIJO: Was there any particular
8 -- and I would know this, I guess -- from the BWR
9 owners on that discrepancy, was that a big, big issue?

10 MR. TREGONING: You mean on the
11 discrepancy between the one expert and the others?

12 MEMBER ARMIJO: Right.

13 MR. TREGONING: No, we didn't get a
14 comment on that. The comment that we got from the BWR
15 owners groups or at least one comment, and you've
16 heard these, is they were concerned that we didn't
17 appropriately credit mitigation of IGSCC. And we did
18 change some of the language in the report, but it
19 didn't change any of the estimates, and you know, we
20 documented in the report as well as in the response
21 about how we considered mitigation, not just of IGSCC,
22 but for all of these mechanisms that people were
23 considering.

24 IGSCC was probably the most unique case
25 because a lot of the service experience that you have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 for BWRs is colored by that IGSCC experience and then
2 anything --

3 MEMBER ARMIJO: Anything prior to water
4 chemistry, pre-mitigation and all of that.

5 MR. TREGONING: Anything before 1983, you
6 know, and we had a lot of discussion with the group
7 about that. In fact, a lot of the service history
8 estimates showed pre-1983 precursor events, post-1983,
9 and we actually then did sensitivity studies, both
10 from a service history perspective and then a PFM
11 perspective on the effect of different IGSCC
12 mitigations on the failure frequency.

13 So it was something that we had discussed
14 quite a bit in the elicitation.

15 So I just wanted to give you an example of
16 one public comment here, recognizing that we don't
17 have time to go into a lot of them. Of course, I'll
18 be happy to take questions on any.

19 But there was one comment that our SB LOCA
20 estimates were too high and that they weren't
21 representative of operating experience. The comment
22 said, you know, that approximately one order of
23 magnitude and then the NUREG/CR-5750 results.

24 The implication is that we should be
25 having one SB LOCA every four years and that using

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 these estimates, at least the small break LOCA
2 estimates in existing PRAs would lead to unwarranted
3 impacts that are not supported by operational
4 experience.

5 MEMBER CORRADINI: So your thought about
6 that would be?

7 MR. TREGONING: Yes, so we thought about
8 that and responded, and I think the main thing that we
9 thought was a good idea is we didn't have a comparison
10 within 1829 on how the results compared with service
11 experience. So we added this section.

12 We had a section on how it compared with
13 prior studies, and a lot of those prior studies had
14 shown how they compared with service experience, but
15 we thought a fresh look at service experience would be
16 useful.

17 And when we say "service experience,"
18 we're really limiting it to the small break LOCAs
19 because that's where we have -- you can actually argue
20 that we've had a couple of events. Certainly we've
21 had steam generator events, and we've had a few pipe
22 breaks in Class 1 systems that border on the small
23 break LOCA threshold. So we actually had some data
24 other than zero events. So we felt most comfortable
25 making those comparisons.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 This is the basis or sort of the basic
2 response or the fundamental points in the response
3 that we made to this one. It's at least the author's
4 opinion that the SB LOCA and the 5750 estimates are
5 generally consistent. The steam generator tube
6 rupture estimates are virtually identical. In fact,
7 they're actually a little bit lower, and that mainly
8 is reflective of the fact that we've had additional
9 service experience since 5750 came out, but there are
10 about --

11 MEMBER APOSTOLAKIS: What was the year of
12 5750? I don't remember.

13 MR. TREGONING: It was published, I think,
14 in '97 or '98, but a lot of the events, most of the
15 events were analyzed up to about '96.

16 MEMBER APOSTOLAKIS: That's about ten
17 years.

18 MR. TREGONING: About ten years now.

19 The BWR SB LOCA estimates are actually
20 quite similar to 5750, within about 20 percent. The
21 big discrepancies are the PWR SB LOCA estimates.
22 They're higher than the 1829 study, about a factor of
23 five, and again, the experts supported that with,
24 again, there was a lot of concern at the time about
25 the effects of PWSCC on small break LOCAs. So their

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 concern was reflected in this increase.

2 We also --

3 MEMBER APOSTOLAKIS: Excuse me, Rob. So
4 this is the estimate that would lead to one small
5 break LOCA per four years? I mean they made a
6 statement of that nature --

7 MR. TREGONING: Right.

8 MEMBER APOSTOLAKIS: -- in your slide,
9 right?

10 MR. TREGONING: Well, there were a couple
11 of things. When we published the draft NUREG, we had
12 the steam generator estimates separately. Then we
13 just had the LOCA estimates that had combined the
14 steam generator and the small break LOCA estimates.
15 Okay?

16 So when they did their estimates, they did
17 a simple subtraction, and the way we aggregated, you
18 can't really do a simple subtraction to get the
19 results. So what we did is we went back and looked at
20 each individual set of results and for each of those
21 individual results, we subtracted their steam
22 generator risk contribution from all the others, and
23 then we re-aggregated.

24 So we analyzed in a way that was
25 consistent with how we analyzed the rest of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 results, and because it's not a linear analysis, you
2 don't get the same answer as you would if you simply
3 subtract them. So in the new 1829, we actually
4 published the small break LOCA estimates without steam
5 generator contributions as well so that people can see
6 what they are.

7 So that's in addition. We added those, as
8 well as we did --

9 MEMBER APOSTOLAKIS: But what is the
10 answer to this?

11 MR. TREGONING: What do you mean?

12 MEMBER APOSTOLAKIS: Is it a true
13 statement that your estimate leads to an average of
14 one small break LOCA every four years? A simple --

15 MEMBER ARMIJO: It doesn't make sense.
16 Sanity check.

17 MEMBER APOSTOLAKIS: Are you still doing
18 that?

19 MR. TREGONING: It's not quite as high as
20 that, but you know, you're one in four, one in five,
21 but, again, you have to look at -- these are not
22 average. These frequencies are never intended to
23 represent averages over the entire operating fleet,
24 right? They were meant to be snapshots of where we
25 are now, given concerns, and they were concerns about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the effect of PWSCC and PWRs on what those frequencies
2 were.

3 We looked at all of the pipe breaks that
4 we had and Lee helped us. We did a Poisson-type of
5 analysis, and you might want to, and you might want to
6 comment on this, and showed that the estimates that we
7 had as well as the uncertainty about those estimates,
8 even though they were elevated, they were still
9 consistent with operating experience or they weren't
10 inconsistent with operating experience.

11 MEMBER APOSTOLAKIS: So is operating
12 experience telling us then that we have something we
13 can call a small break LOCA once every four or five
14 years? Is that what you're saying?

15 MR. TREGONING: No, that's not what I'm
16 saying. I'm saying the current frequencies that we
17 have are higher for PWR SB LOCAs.

18 MEMBER CORRADINI: But if I could just
19 read on page 750 of the report, specifically the
20 paragraph here that you guys have is that you point
21 out that for small breaks, the current elicitation is
22 lower than the pilot, but it is higher than -- as you
23 state, "However, the current elicitation concerns for
24 PWSCC cracking and BWR CRDM nozzles results in
25 additional increases."

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Is that -- I'm looking for a physical
2 reason why, if the expert judgment is larger than the
3 service experience, does it come down to those sorts
4 of --

5 MR. TREGONING: Yes.

6 MEMBER CORRADINI: Okay, all right.

7 MR. TREGONING: Yes, that was the
8 qualitative rationale driving it, and the expert said
9 even though, again, when we did the study, when we did
10 the results or when we did the elicitation, it was
11 2003. So you know, we had had Davis-Besse. We had
12 Oconee, We had V.C. Summer. We were still in the
13 process of attempting to develop mitigation strategies
14 or we hadn't even started it yet, to be honest with
15 you, for PWSCC. We're really starting that now.

16 And many of those same experts said while
17 it's elevated now, the expectation is that once
18 mitigation has been fully implemented, that those
19 frequencies will decrease again.

20 MEMBER CORRADINI: Okay. That's fine. I
21 just wanted to understand because this is not my area.
22 It's a material. So I'm always looking for the
23 physical reason underlying why an estimate might be
24 different than the service experience.

25 CHAIRMAN SHACK: Just Lee's Poisson

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 analysis gave him a resulting range of .7 to five
2 breaks, and you've had one basically.

3 MR. TREGONING: Yes.

4 MEMBER APOSTOLAKIS: So the third red
5 bullet, BWR small break LOCA estimates are higher by
6 approximately a factor of five, but because NUREG-5750
7 is kind of old, they think this is reasonable. That's
8 the implication there?

9 MR. TREGONING: Yes.

10 MEMBER APOSTOLAKIS: Okay.

11 MR. TREGONING: And it's not the fact that
12 NUREG/CR-5750 is old. It's the fact that, again, the
13 elicitation -- these estimates were supported by, you
14 know, expectations for higher frequencies due to PWSCC
15 cracking.

16 So that's the third bullet. You know, the
17 differences that do exist are supported by qualitative
18 rationale, and we made a number of modifications. We
19 have provided the separate steam generator tube and
20 small break LOCA estimates as I mentioned. We have a
21 much more extensive comparison between 1829 and
22 historical results, and then we also have these
23 operating --

24 MEMBER APOSTOLAKIS: So that frequency
25 then is roughly two or so, ten to the minus three, an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 average number?

2 CHAIRMAN SHACK: Five times ten to the
3 minus four for small break LOCAs.

4 MEMBER APOSTOLAKIS: Five, ten to the
5 minus four we mean by it.

6 CHAIRMAN SHACK: Which in 5750 is one.

7 MEMBER APOSTOLAKIS: Is what?

8 CHAIRMAN SHACK: A one times ten to the
9 minus four.

10 MEMBER APOSTOLAKIS: So if you have five
11 ten to the minus four and you have how many PWRs?

12 MR. TREGONING: Sixty-nine.

13 MEMBER APOSTOLAKIS: Multiply that by 69.
14 Do I get this number of four or five per year? I
15 guess I --

16 MR. TREGONING: No, no, no, no, no. You
17 get one every four years is what the commenter --

18 MEMBER APOSTOLAKIS: One every four years.
19 So 69 multiplied by four.

20 MEMBER MAYNARD: Well, another factor is
21 you want this to be a tool that's useful in the
22 future, not necessarily reflecting exactly where we
23 are today. It completes aging, and so the numbers
24 that you're giving and the tools that you're putting
25 out there need to be a good five or ten years from now

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 as well as today.

2 MR. TREGONING: Right. We did ask for
3 estimates. We asked for three time periods. We asked
4 for current snapshot. Then we asked for 15 years from
5 now and then we asked for another 20 years past that.
6 So we did provide multiple estimates, but you know,
7 there's a realization, too, that you know, your
8 epistemic knowledge state is changing as you go along,
9 too. So certainly the further you asked people to
10 prognosticate, you know, we had enough uncertainty
11 with the current day. So when you try to
12 prognosticate out further, you have more uncertainty,
13 more variability.

14 MEMBER APOSTOLAKIS: All right, fine.
15 Let's go on.

16 MR. TREGONING: That's it.

17 MEMBER APOSTOLAKIS: Any questions before
18 we move on to seismic? That's the next one, right?

19 (No response.)

20 MEMBER APOSTOLAKIS: Okay. Nilesh, are
21 you taking over?

22 MR. CHOKSHI: Yes.

23 MEMBER APOSTOLAKIS: Thank you very much,
24 by the way, as an afterthought.

25 Tell us who you are and why you're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 qualified to address this distinguished group.

2 MR. CHOKSHI: Yes, I will.

3 CHAIRMAN SHACK: He drew the short straw.

4 (Laughter.)

5 MR. CHOKSHI: Okay. Good morning. My
6 name is Nilesh Chokshi. I'm Deputy Director of the
7 Division of Environmental and Site Reviews, Office of
8 New Reactors.

9 And if you wonder why I'm here giving this
10 presentation, I was in Research when this study was
11 conducted two years back. So that's the reason I'm
12 here, and as you see from the list of names, this was
13 an interoffice team, including seismic expertise,
14 piping design, fracture mechanics, seismic risk, and
15 also the people involved in the rulemaking. So this
16 was, you know, a substantial and also very large
17 contractor support.

18 In fact, Dr. Gery Wilkowski and I and his
19 organization, EMC², made the floor piping analysis,
20 and he was here at the subcommittee presentation, and
21 I think he's available on the phone also. So that's
22 good for me. He can answer some of the questions.

23 So with that, let me --

24 MEMBER APOSTOLAKIS: Who's the gentleman
25 on your right?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. CHOKSHI: No, Gery is not here. Oh,
2 sorry. This is Mr. Khalid Shaukat. He's from
3 Research, and you'll see him again when we move
4 forward with this study, but he was the project
5 manager of this study.

6 Okay. So now what I intend to do is to
7 cover the basic objective. At the subcommittee
8 meeting we did discuss in detail the technical
9 approach and rationale behind this. I think during
10 the short time here I'm going to focus on some of the
11 key research and findings and not as much on the
12 methodology.

13 And then what I want to do is towards the
14 end I'll summarize the response from the industry on
15 specific questions where we are asking the proposed
16 rulemaking and where we are and what factors we need
17 to consider as we move forward in this rulemaking
18 process, but as pertains to this particular issue.

19 So let me start with the objective.
20 Instead of directly estimating the seismic and use
21 break frequencies as it was done for the expert
22 elicitation, we decided to concentrate on a different
23 question, and the question was: what are the
24 conditions and likelihood which would, under the
25 seismic-induced loading, which would be incompatible

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 with the proposed TBS?

2 In other words, would the seismic-induced
3 breaks, would they be larger than the TBS and would
4 have frequencies of ten to the minus five or more?

5 And I think that's a very germane
6 question, given, though, that the object was to
7 provide this information so people can comment and
8 respond to questions. In the context of the proposed
9 rule, this was a direct question and also within the
10 time period it's something you can do, you know,
11 estimating absolute frequencies given seismic events.
12 It's a much larger undertaking.

13 In order to answer this question we took
14 six activities. We looked at unflawed piping; flawed
15 piping, piping that has cracks or degradations;
16 indirect failures; review of past earthquake, past
17 PRAS; and then there was a study conducted in the
18 early '80s in connection with GDC4, which was to
19 answer the question whether the LOCA and the
20 earthquake load seems to be combined, and this was a
21 full-blown probabilistic fracture mechanics analysis.

22 The first three are the different --
23 mechanisms, how the piping and piping system can fail
24 and would have, you know, an impact on TBS.

25 The review of past earthquake experience

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and past PRAs were to get additional insight; also to
2 calibrate system level analytical study CRD, what we
3 see in the earthquake experience, and what we find
4 analytically; is this consistent or not; and then
5 this, the last, was an important study, and a lot of
6 decisions were based on this study. It also provides
7 a direct way for us to calculate the mean direct
8 failures.

9 So we used the modified history to build
10 a short current-day hazard and use that for the
11 indirect figures.

12 Now --

13 MEMBER ARMIJO: Were these analyses only
14 done for the transition break size pipes?

15 MR. CHOKSHI: No.

16 MEMBER ARMIJO: Just for that size or
17 for --

18 MR. CHOKSHI: No. How long we'll talk
19 about that, the next slide, the scope of the study.

20 And we used basically a combination of
21 deterministic and probabilistic approach. For the
22 unflawed piping and indirect failures, it's pretty
23 much probabilistic approach, and we did not estimate
24 the four distributions, but it was a probabilistic
25 approach.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 On the flawed piping, the seismic loading
2 was based on the probabilistic hazard, but the rest of
3 the calculations were deterministic.

4 To address some of the variabilities, we
5 did a large number of samples, and I'll try to tell
6 you about how many piping systems we looked at, and we
7 also conducted some additional sensitivity analysis to
8 look at the effects of key assumptions.

9 Here is, I think, to answer your question,
10 I'll move on to this viewgraph.

11 One of the biggest challenges in
12 performing this type of analysis is the availability
13 of the design information because that was our
14 starting point. We needed normal operating stresses,
15 seismic stresses. I'm talking about design stresses,
16 material properties, and a few other things so we can
17 do our calculations.

18 One of the databases which had captured
19 this information is the leak before break application
20 database, and which basically applies to PWRs. So we
21 had these data available for PWRs, and that's why one
22 of the reasons was material evaluations for BWRs.

23 Having said that, there's nothing inherent
24 in these matters or conclusions which does not apply
25 to BWRs or other situation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Now, the tool I mentioned about, that we
2 wanted to look at a large sample to cover the range of
3 materials properties, range of the seismic stresses,
4 and the site conditions. We selected 27 PWRs, 24 on
5 the large side, three on the small sides. Large size
6 from the seismic perspective is not critical. We
7 generally get higher stresses.

8 The second issue was what hazard curve to
9 use, and this was a question because, two years back,
10 this is when the Early Site Permit applications were
11 coming in, and they were using new estimates. Without
12 considering all factors, we thought that for the 27
13 sites the research we had available was that Livermore
14 has those, and we will study the sensitivity of
15 alternate hazard in a different way. So we decided to
16 use the Livermore hazard curve.

17 Now, I think to answer your question,
18 because we see what's the effect on TBS, we selected
19 piping systems larger than the TBS. We did examine
20 one or two cases with the TBS diameter, but more as a
21 calibration, but which meant that we were looking at
22 hot leg, cold leg, and crossover leg, and we selected
23 52 systems from 27 PWRs. We tried to capture the
24 highest trace locations and materials. Okay?

25 Now, one of the key, in this kind of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 evaluation, you need to do a realistic estimate of
2 seismic stresses. The design stresses is a starting
3 point, but as you go up in the earthquake, it's
4 difficult; to seismic PRA, you have to do more
5 realistic estimate of seismic stresses at the higher
6 level, and we used basically an approach commonly used
7 in the seismic PRA and seismic margin to estimate
8 those spaces.

9 So that was a common approach, I would
10 say, in all three, that we were trying to estimate
11 realistic estimates at higher level of earthquakes,
12 and for the flawed piping we selected two discrete
13 levels, ten to the minus five probability of accidents
14 and ten to the minus six probability of accidents.
15 For direct and indirect, we can basically use, then,
16 the entire probabilistic hazard code.

17 So this is what I'm talking about matters
18 and not too much more. In flawed piping and indirect,
19 I'll do a little bit more, but at the subcommittee we
20 showed some quantitative research on the unflawed
21 piping, but I think other cases are a lot more
22 interesting. So I'm going to --

23 The key finding is that unflawed piping,
24 in order to get a seismic-induced failure, you have to
25 have a lot of flaw. It just doesn't happen. In fact,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 our numerical results would be an order of mean
2 failure ten to the minus nine or less, okay, for the
3 cases we looked at.

4 I think it's important to a little bit
5 talk about now earthquake experience. We have looked
6 at a number of industrial facilities and fossil power
7 plants, most of the data come from, but all of the
8 welded piping systems which are engineered actually
9 behave very well in the earthquakes. We are looking
10 here at experience data up to .5g ground acceleration,
11 and where we see failure, there's a severe
12 degradation, either support failure, again, associated
13 with severe degradation; there is missing anchor bolts
14 or corroded plates.

15 We see relative motion. When you have an
16 inflexible pipe and there is a support, and in fact,
17 at a recent earthquake in Japan, we saw, I think, all
18 seven plants. There was a vent. Vent was connected
19 to a stack, which was in a different foundation, and
20 other support was in a different foundation. All six
21 identically failed because of this anchor motion.

22 And then things falling over the piping.
23 So I think this result is consistent. So I think this
24 case, that unflawed piping, unflawed piping is
25 basically a piping which meets the assumptions used in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 design and would fail by a particular shutting down
2 than a collapse or a tear-through.

3 Okay. Now, the flawed piping, I think
4 that's the more interesting. Again, I have been
5 conducting, you know, crude probabilistic analysis.
6 We decided to look at design conditions and the
7 conditions at the higher level. We wanted to look at
8 what are the critical flaws at ten to the minus five
9 or ten to the minus six seismic range, and either
10 they're large or small compared with the crude
11 allowable flow evaluation.

12 So we performed all the normal operating
13 conditions and earthquake, ASME inspection/evaluation
14 criteria for circumferential surface flaw, and we also
15 used the LBB procedure. What would be the through-
16 wall flaws and how they would compare with the
17 critical flaws at ten to the minus five up rate and
18 ten to the minus six up rate?

19 And this was basically to answer two
20 questions. Will ASME surface flaw criteria at normal
21 stresses find flaws that are smaller than the ten to
22 the minus six or ten to the minus five? Because this
23 implies some inherent safety.

24 And would the LBB procedure find the
25 through-wall flaws that are smaller than the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 particular flaws?

2 And also I think, as I mentioned with the
3 experience data, the question itself, how large these
4 flaws have to be, is important. So that was the
5 parameter, you know, how large these flaws have to be.
6 Because if you were really looking at the total
7 probabilistically, then you will have to look at
8 probabilities of existing flaws, probabilities of
9 detecting flaws were they to link before. So I think
10 this information was very -- that's why I said that in
11 the right context, the proposed TBS, this information
12 was germane.

13 So I'm going to now go to the resource.
14 All right. Let me first -- these are the two results
15 for the surface flaw evaluation. This is the two
16 systems from the 52 systems we examined, large, and
17 the plot on the left, I believe it's in a hot leg
18 looking at a ten to the minus five earthquake stresses
19 from a Westinghouse PWR. But let me first explain
20 what you are looking at.

21 The X axis is the flaw length. Okay? And
22 as you go from the extent of circumferential flaw
23 length. On the ordinate is the flow depth ratio, is
24 the ratio of through-wall to the pipe thickness. So
25 as the flaws get smaller, circumferentially you have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to have a larger depth for them to become critical.

2 As you move toward the right with the
3 larger flaws, then you know, these critical depth
4 ratios are becoming smaller. An interesting thing is
5 that you see that after a certain .5 or something or
6 .6, you start approaching basically asymptotic value.

7 You are also seeing the ASME code limit,
8 that basically this requires evaluation of flaw. If
9 it's smaller than that, I think you can continue
10 operation. In no case, you can go tolerate more than
11 .75 here.

12 This is a typical case. In the report
13 this is called Category A. The red line is the
14 critical ten to the minus five critical flaw length.
15 Yellow is using the ASME code strength and procedure,
16 and this is the same as the ASME procedure, but using
17 actual strength. The code allows that. In this case
18 the critical flaws associated with the earthquake,
19 large earthquake traces, is much larger and this is a
20 typical ten to the minus five.

21 Now, we also have what we call Category C,
22 a few cases, and I'll show you the overall. In this
23 case, the critical flaw is smaller than what the ASME
24 code would allow, but I think the one important thing
25 is that in all cases there are very high -- issues.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The cracks have to be pretty great.

2 Now, what I'm going to show you now, the
3 results for the ten to the minus six in a little
4 slightly different form. This is the calculation
5 performed for a large earthquake. The ten to the
6 minus five was sort of a starting point for the TBS,
7 but we also wanted to look at what happens at larger
8 earthquakes. One of the things, it answers the
9 question of an alternate hazard as well as whether
10 there is a sharp transition somewhere, you know.

11 And what you are seeing here is that upon
12 a very large flaw, for a different seismic -- for ten
13 to the minus six seismic stresses, what are the
14 critical flaw depth values? And you see that .3 is
15 the smallest value. It's somewhat material-dependent,
16 but in many cases, you wanted this stress level is
17 much larger. So you have to have a very significant,
18 large cracks in the pipes before you get to the
19 seismic in these breaks.

20 Here is the summary of the 52 cases, and
21 as I mentioned, for eight times ten to the minus five,
22 yes, 48 cases the critical crack sizes will be larger
23 than the ASME code. In one case it was larger than
24 the core evaluation using the core values, but smaller
25 using the actual strength values, and in three cases

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 was the second case I showed that's called Category C.

2 But, again, I think to me the -- well,
3 I'll come back to the final message. So this was the
4 results of the surface flaw evaluation.

5 The second thing we wanted to look at, the
6 leak-before-break behavior, and we wanted to see that
7 if you applied LBB analysis as currently with the
8 factors of safety of ten on the leak rate and on the
9 flow size factor of safety of two, and how would that
10 compare when you do the same calculations, but using
11 higher seismic stresses and also examine the
12 sensitivity to different factors of safety and also
13 maybe different assumptions on the leak detection
14 capabilities or the leak rate.

15 So I'll show you the results from the
16 sensitivity studies. This is also a factor of the
17 crack morphology, and I'm going to -- so we looked at
18 three crack morphologies, one with a very smooth
19 crack, a PWSCC type crack, and corrosion-free.

20 Okay. So here are the results. On the X
21 axis side is the ratio of normal to normal plus higher
22 side mixed traces at ten to the minus five. So as you
23 go left implies higher seismic stresses.

24 This is the leakage over critical flow
25 size, the leakage flow size using the current

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 procedures, and get the design basis stresses, SSC
2 stresses, and this is the critical flaw sizes at ten
3 to the minus five.

4 These are the results of fire systems for
5 all different plants. What it shows, that if you
6 consider the factor of safety of 1.5 instead of two,
7 in the report there are other results, but if you do
8 these calculations, you keep the liquid requirement
9 the same as factor of safety of ten on the detection
10 capability of one gpm. You will find some cases where
11 the critical flaw size would be smaller than the LBB.

12 But if you look at an alternate leak
13 detection capability, and I understand that some LBBs
14 use this, of .5 gpm, keep the same factor of safety,
15 you can see that there.

16 And you know, this was not to draw the
17 conclusions, but to provide information so people can
18 evaluate in all of the proper contexts.

19 MEMBER ARMIJO: You said .5, but the chart
20 says five.

21 MR. CHOKSHI: Well, yes. The five gpm,
22 you calculate your break size and the flaw size based
23 on the certain rate. Okay? Five gpm is used in this
24 calculation, but the current procedure requires that
25 if you have a flow liquid of five gpm, your detection

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 capability should have a factor of ten safety, safety
2 factor of ten. So detection to be .5 gpm. Okay?

3 Basically this is a sensitivity study on
4 two different detection capabilities. So this is the
5 results from the leak before break. So here is the
6 summary of the flawed piping. I think to me these two
7 viewgraphs really are critical. The critical crack
8 slips are larger than 40 percent for the ten to the
9 minus five and larger than the 30 percent thickness
10 for ten to the minus six. So you're talking about
11 substantial, large flaws. Again, I think to me it
12 seems to be consistent with what we are seeing.

13 On the LBB flaw size, again, we see in
14 many cases that the LBB flaw size will be smaller than
15 the critical, and for the better appreciation of under
16 what conditions the LBB could be, you know, at least
17 a viable consideration, we need some sensitivity
18 studies.

19 Now I am going to move to the indirect
20 failure, and this is the failure mechanism which PRAs
21 include. Seismic PRAs traditionally, and I think for
22 good reasons, have not included piping failure as an
23 initiator of LOCAs, other than small LOCAs, but some
24 of the PRAs have included this, and to give an
25 example, the 1150 study plant, there was a failure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 mode where the steam generator support failed, and
2 what happens is that those sequences occur in very
3 large earthquakes. They dominate the release
4 contributions, but they are not dominating the
5 contributing core damage because you make an
6 assumption that if I'm going to feel a support of a
7 steam generator that is going to allow movement, I'm
8 going to fail containment also at the same time, and
9 I'm going to have a LOCA which probably is not
10 possible to mitigate.

11 And so this is the assumption also. The
12 assumption is that the failure frequency of support is
13 the same as if we left concealed break.

14 Now, let me now talk a little bit about
15 the original Livermore study we just conducted in the
16 early to mid-'80s. They grouped the plants in various
17 renderings. They are Westinghouse, CE, BMW, and then
18 they also looked at one BWR plant.

19 They selected the one pilot case, and then
20 they looked at data across the fleet. They used the
21 generic hazard curve for east of the Rockies. What we
22 had to do was to primarily update the hazard
23 information.

24 Now, we have a plant specific or site
25 specific hazard information. So that was the major

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 modification to the work they did. They had a number
2 of studies. We selected two cases. One was what was
3 in the bounding case in their analysis of a
4 Westinghouse, and another was CE, and I'll show these
5 in a minute, but in Livermore study they had estimate
6 of the fragility of the support, and we modified that
7 to reflect the site specific information.

8 CHAIRMAN SHACK: Now, did you look at
9 IPEEE-2 to see if those fragilities from the Livermore
10 study were still -- you know, when people looked at
11 them presumably at their individual plant they did a
12 little better job.

13 MR. CHOKSHI: And I think what happened
14 when IPEEE, that seismic sequences were basically
15 governed by other failures. So there was little
16 inside, but when we did the seismic margin
17 development, we had looked at this, and I think only
18 two components from the seismic margin you examined
19 below .5g is the pressurizer support and the vessel
20 support for the BWRs.

21 Most of the other components are very high
22 capacity, and the results reflect that. So basically
23 we completed the failure probability of the support
24 with the site specific hazard and modification of the
25 Livermore study.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: How detailed is the
2 calculations involving support fragility for large
3 components like --

4 MR. CHOKSHI: It says --

5 MEMBER SIEBER: -- steam generators?

6 MR. CHOKSHI: It's fairly significant
7 because Unit 2, you know --

8 MEMBER SIEBER: Not just examination of
9 the beams, cradles and so forth, you know. My
10 experience is that bolting is a critical issue in
11 those large supports.

12 MR. CHOKSHI: Right. Yes, we need to look
13 at a variety of failure modes and see. You know, they
14 have combined them so that you could arrive at those.

15 MEMBER SIEBER: I guess you can draw the
16 same conclusion about pipe supports. It's the bolts
17 that fail first.

18 MR. CHOKSHI: Yes, yes. And in the Diablo
19 Canyon PRA, that was the mechanism they included, and
20 it's more than one support in order to fail a pipe.
21 You need to fail --

22 MEMBER SIEBER: You get a cascading
23 effect.

24 MR. CHOKSHI: Cascading, right. You have
25 to have at least I think, if I remember right, in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Diablo, we looked at five supports.

2 MEMBER SIEBER: Thank you.

3 MR. CHOKSHI: Now, maybe if I show you the
4 results from the Livermore regional study, and here
5 you can see that -- let me concentrate on, let's say,
6 median values. These are ten to the minus six, ten to
7 the minus seven order, and what they had on the mean
8 perspective, this was the lowest capacity plant.
9 Ninety percent was two times ten to the minus five.

10 Making corrections to the fragility and
11 using the site specific casuals, two times ten the
12 minus six. That's so we wanted to compare that, and
13 when I look at the -- and I believe for the
14 Westinghouse, the lowest capacity, three time ten to
15 the minus six. So it was still an order of less than
16 ten to the minus five.

17 Now, EPRI, as a part of the response to
18 questions, did some additional calculations using the
19 EPRI latest hazard coverage, and they examined three
20 cases, and I'm going to report on the results, but we
21 haven't reviewed. They're basically the same
22 approach, modified fragility, but they do add some
23 additional factors, and their results range from six
24 times ten to the minus six to five time ten to the
25 minus eight, and one of them was a BWR. I think five

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 times ten to the minus eight was BWR.

2 Anyway, so the bottom line, I think is
3 that you still are away from the ten to the minus five
4 type of pressure. So now let me go to the overall
5 summary of the story.

6 Unflawed piping systems have very -- you
7 know, seismic frequencies are small. Critical
8 suppressed floor and through-wall, you know, LBB, you
9 have to have large flaws to have seismic induced
10 failures.

11 And then indirect piping failure, the
12 things we looked at, it still seems like an order of
13 ten to the minus six per year. So this was the
14 overall summary.

15 Now, I'm going to switch to the approval
16 and questions associated, which are included in the
17 draft code, and responses. The proposed rule
18 contained extensive discussion. You know, it observed
19 that the expert elicitation had not included explicit
20 consideration of seismic induced failure, and here is
21 a large uncertainty, and there was still a question
22 whether a plant specific assessment would be required
23 or not, and there were three specific questions that
24 were posed. One was to comment on the evaluations of
25 the study and, you know, if any comment they had on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that; effects on the five-day degradation on seismic
2 in the LOCA frequencies and, you know, from their own
3 information; and then also the other one was to
4 potential policies and options to address this issue
5 other than what, you know, we have put forth.

6 The comments primarily were from the
7 industry, and I'll summarize quickly. Basically they
8 had no really comments on the study itself. They said
9 we agree with the study's findings and that TBS is not
10 adversely affected from the seismic consideration.

11 And I'll go to the next slide.

12 This is important. This data risk or the
13 change in the risk due to seismic is considered low,
14 and our basic argument was that components in the
15 piping in the primary loop and supports generally have
16 a much large capability or capacity. It's a lower
17 fragility compared to the rest of the plant, and so
18 the risk is general dominated by the other previous
19 scenarios, and so the seismic to be that.

20 And then I mentioned within that failure,
21 EPRI gave us additional resource which we'll have to
22 look at, and then their bottom line conclusion was
23 that plant specific assessment cannot be required.

24 This is now my last slide. I think moving
25 forward we have an ACRS recommendation. There is an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 SRM requirement, and to address this issue we need to
2 consider a number of things before we you know.

3 First, I think we need to look at the
4 response to questions, and I think my three bullets
5 actually. The next two of those, one of the response
6 only.

7 Changing the risk, I think probably that's
8 important, that we fully understand that.

9 One of the important, I think,
10 considerations will be from Commission SRM and ACRS
11 recommendations, how this will get -- addresses the
12 defense-in-depth and mitigation recommendations.
13 Because that will have an effect on any of the risks
14 under any risks.

15 We need to understand fully whether the
16 seismic -- is that under what conditions the seismic
17 risk could be affected, and I think it is my -- this
18 is mine now -- that if the seismic risk comes from the
19 structure type failures, unless plant modifications
20 are made.

21 Now, what the rule and mitigation plays
22 and nonseismic failure plays, we need to look at and
23 we need to better understand what we do here, but I
24 think unless, you know, there is a significant change
25 to the supports or something, I think I -- and then --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: I didn't get that.

2 MEMBER CORRADINI: We don't understand
3 you. I 'm trying to understand you.

4 MEMBER APOSTOLAKIS: Your conclusion you
5 don't state.

6 MR. CHOKSHI: Okay.

7 MEMBER APOSTOLAKIS: Unless -- keep going.

8 MR. CHOKSHI: Okay. What I was trying to
9 say, that unless somebody modifies the supports or
10 something, unless there are physical changes to the
11 seismic capacities are less. You know, I don't see
12 that occurring, you know.

13 Now, there may be a system and operating
14 condition changes which we have to evaluate after we
15 understand what defense-in-depth and mitigation.

16 Structural changes I think is, you know,
17 somebody's postulating. Then it will have an impact
18 on seismic risk.

19 And then finally also I think, you know,
20 this has to be reviewed to understand what the
21 Commission has asked that we develop guidance on the
22 issue of applicability of 1829, and I think to me this
23 has some of the things which we may think
24 independently in the seismic, you know, some of the
25 regulatory considerations and things like that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So at this point I think we have to wait
2 and see how these things go before we make the
3 decisions or, you know, how do we deal with these
4 issues. So that's the end of my presentation.

5 VICE CHAIRMAN BONACA: Yeah, I repeat what
6 I said during the subcommittee. You know, I would
7 like to see sensitivity of the results that you are
8 presenting to that multiplier you used to eliminate
9 the excess conservatism, as they call it, associated
10 with the design stresses.

11 I agree that we have to use a reduction,
12 and I'm not proposing that you would use the design
13 values, but that's a significant multiplier. I mean
14 you are using a .6 or something like that if I
15 remember now that was in the report, and I would like
16 to understand the sensitivity and its conclusions to
17 that multiplier.

18 MR. CHOKSHI: I think it's a good -- you
19 know,, and what drove us to the looking, also the ten
20 to the minus six, you know, a number of things, what
21 happens with automatic hazards, what happens in the
22 seismic stresses, you know.

23 It does not answer fully the question I
24 think you asked, but --

25 VICE CHAIRMAN BONACA: Well, I mean, you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 made the point that, you know, you cannot tolerate the
2 design values. They're excessive.

3 MR. CHOKSHI: Right.

4 VICE CHAIRMAN BONACA: So there is some
5 place between the design value and the reduced value,
6 and the approach you're using to scale it down seems
7 to be pretty empirical. I mean, it just --

8 MR. CHOKSHI: I think maybe the one thing
9 I didn't mention, I think I agree with you, but there
10 are a number of factors one can consider, and we
11 basically selected adjustment of the seismic spaces
12 using the concentrator on the site specific hazard
13 information.

14 We were, I would say, considerably biased
15 in that selection. We did not use all of the factors,
16 but you are right. It was qualitative, but we could
17 have examined it quantitatively.

18 VICE CHAIRMAN BONACA: Yeah, to get a
19 sense again of the sensitivity, what is the margin it
20 should have and --

21 MR. CHOKSHI: Absolutely, we can do that.
22 Thank you.

23 MEMBER APOSTOLAKIS: We were also told at
24 the subcommittee, a member of NRR, that this rule, the
25 priority of this rule has been reduced, right?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. CHOKSHI: Well, then you have person.

2 MR. DUDLEY: Yes. When the Commission
3 reviewed the staff's paper that addressed the ACRS
4 recommendations, the Commission agreed with the
5 staff's recommendation that the priority of this rule
6 should be reduced from a high priority rule to a
7 medium priority rule.

8 So we are proceeding forward with a rule,
9 but on a little slower basis and our next due date is
10 to provide a schedule to the Commission for completing
11 this rule, and the schedule is due by March 31st,
12 2008.

13 MEMBER APOSTOLAKIS: At the subcommittee
14 you told us that the reason or one of the reasons, I
15 guess is that there are insignificant safety benefits
16 of this rule, but the benefits really are negativities
17 because they won't be able to raise the power. Is
18 that a correct statement of what you said?

19 MR. DUDLEY: Well, that was the ACRS,
20 included in the ACRS' letter. The staff pretty much
21 agreed with that, and that was included in the
22 Commission paper.

23 MEMBER APOSTOLAKIS: But isn't part of
24 risk informing the regulations to remove unnecessary
25 regulatory burden?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DUDLEY: Yes, it is.

2 MEMBER APOSTOLAKIS: And wouldn't this
3 rule remove such burden?

4 I mean we are not looking for safety
5 benefits that haven't been risk informed.

6 MR. COLLINS: This is Tim Collins of the
7 staff.

8 We agree with that, and that's why I think
9 the rule was not killed as a whole.

10 MEMBER APOSTOLAKIS: Oh, okay.

11 MR. COLLINS: I mean, it was initially
12 considered high priority because of the potential for
13 safety benefits. That's got its high priority. Now,
14 when we seem to come to the realization that there
15 wasn't a whole lot necessarily there, then its
16 priority got reduced to medium because there was still
17 the potential for reducing unnecessary burden.

18 MEMBER APOSTOLAKIS: Yeah, that's helpful.

19 MEMBER ARMIJO: If I recall, some of the
20 industry people were negative because the transition
21 break size values were too high and implied that they
22 wouldn't use a rule or they didn't expect too many
23 people to want to use that rule. Is that still the
24 case?

25 MEMBER SIEBER: It doesn't make any

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 difference.

2 MR. COLLINS: Well, I think the industry
3 folks are here. Maybe they could answer that for
4 themselves. I think that's still true.

5 MR. DUDLEY: Right. We haven't heard any
6 indication from industry.

7 MEMBER ARMIJO: So the priority, it's not
8 high priority for the Commission for safety benefit,
9 and it's not much value to the industry. I think it's
10 a good study, but I think the medium of priority for
11 pursuing it is probably the right thing to do or even
12 less.

13 MEMBER MAYNARD: I think the value to the
14 industry or to a reduction in burden depends on what
15 the form of the final rule comes out to be. What are
16 the transition break sizes and what are the mitigating
17 requirements?

18 I think it's something that can be of
19 benefit and a reduction, or it can be something that
20 provides really no benefit or no reduction, depending
21 on really those two primary things, transition break
22 size and what's required for mitigation.

23 MEMBER SIEBER: Well, it allows more
24 realistic calculations in 5046 space, and to me that's
25 a significant benefit.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: So if it's of medium
2 priority, that means when are we going to see you
3 again.

4 MR. DUDLEY: I guess it will depend on the
5 schedule that we provide to the Commission on March
6 31st.

7 MEMBER APOSTOLAKIS: Okay. Your schedule.

8 MR. DUDLEY: That's correct, and some of
9 that depends on the work that you're hearing today.
10 So we really can't provide you a schedule at this
11 point in time.

12 CHAIRMAN SHACK: Nilesh, did you think of
13 asking the NDE people for what they think the
14 detectable crack size. You know, you've given me ASME
15 code limits. You know, that's wonderful. I can't
16 find a ten percent crack very reliably.

17 MR. CHOKSHI: I'm looking, but what I can
18 tell you is that there was extensive discussion about
19 that issue.

20 CHAIRMAN SHACK: I would expect there
21 would be.

22 MR. CHOKSHI: And a number of people,
23 including NRR resources. The best way to summarize is
24 that we were starting basically can we put it, say,
25 probability of detection, dealing directly.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 CHAIRMAN SHACK: And so what you're really
2 relying on is the probability that you're not going to
3 have a 30 or 40 percent deep, long crack, which, you
4 know, is pretty small.

5 MR. CHOKSHI: Implicitly I think that's
6 why I think it's a good way to present this
7 information, so people think about those factors. You
8 know, what's the probability of having this size? How
9 will it grow into the service, you know. So I think
10 to me it brings the focus.

11 We were trying not to draw conclusions
12 because it's hard to come to without any kind of
13 probability.

14 CHAIRMAN SHACK: You still have to make
15 that judgment on how likely those cracks are.

16 MR. CHOKSHI: And the report says that,
17 you know, that given this, you know, that's why we
18 looked at ten to the minus five but actual probability
19 of failures, you know, but if you consider all of
20 these factors, you know, it's obviously small.

21 MEMBER SIEBER: I think there's some
22 comfort if you take something like centrifugally cast,
23 austenitic stainless steels, it's pretty hard to find;
24 it's not as easy to find flaws in that as other --

25 CHAIRMAN SHACK: That's a mild statement.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: It's not a curiosity. On
2 the other hand, for the large pipes made of that
3 material, it usually before a break, which tells us
4 you something, too, and so I don't think that we are
5 left without assurance.

6 CHAIRMAN SHACK: Oh, no, no, no. Those
7 are big cracks under any circumstance.

8 MEMBER SIEBER: Absolutely. Well, this is
9 what you want to avoid.

10 MR. CHOKSHI: And I think then there are
11 many recent studies will even lock in a few more
12 insights into what's more likely, but when we were
13 doing it, I think, this was to present the information
14 so people can make an informed judgment.

15 MR. TREGONING: This is Rob Tregoning from
16 staff.

17 I would almost view those as a
18 demonstration requirement. They tell you the
19 performance that you have to have and then it would be
20 up to maybe the reg. guide or even licensees that want
21 to use 5046 to provide some sort of demonstration that
22 their piping will meet that performance. It's not
23 flawed, you know.

24 CHAIRMAN SHACK: But I think they're going
25 to have to make that argument not on NDE, but on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 fact that they have water chemistry and materials that
2 are not suspectable to this kind of --

3 MR. TREGONING: Well, there are a variety
4 of ways that you can make that argument.

5 CHAIRMAN SHACK: But I agree. They have
6 to make that.

7 MR. TREGONING: NDE is a piece of it, but
8 I would agree that you probably don't want to --
9 that's not your sole argument.

10 CHAIRMAN SHACK: I keep losing my argument
11 that you actually have to demonstrate leak before
12 break for these piping systems before you can take
13 credit, but I still think that's a good idea.

14 MR. CHOKSHI: But to me I think for a risk
15 informed rule, this is really a key question, and we
16 need to understand the potential changes and will they
17 have an effect on seismic risk.

18 Seismic risk is different than anything
19 else and its common cause effects and are you really
20 affecting this, you know? It may be dominated by some
21 other things, and may not have a really -- you know,
22 the redundance doesn't have the same effect from a
23 mitigation point of view of difference in depth point
24 of view on the seismic. If you put tow identical
25 systems it doesn't buy you much.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So we, I think, need to ultimately be able
2 to answer this question, you know.

3 MEMBER APOSTOLAKIS: Any other comments or
4 questions from the members?

5 (No response.)

6 MEMBER APOSTOLAKIS: Well, thank you very
7 much.

8 MR. CHOKSHI: Thank you. Thanks, Gery.
9 I hope he's there.

10 MR. WILKOWSKI: Yeah, I'm here.

11 (Laughter.)

12 MEMBER APOSTOLAKIS: And, Mr. Chairman, 25
13 minutes early.

14 CHAIRMAN SHACK: Twenty-five minutes
15 early, George.

16 MEMBER APOSTOLAKIS: I want to use that up
17 in future meetings.

18 CHAIRMAN SHACK: A credit.

19 MEMBER SIEBER: Eliminate one of them.

20 CHAIRMAN SHACK: I think we will take a
21 break now until 10:45.

22 (Whereupon, the foregoing matter went off
23 the record at 10:05 a.m. and went back on
24 the record at 10:46 a.m.)

25 CHAIRMAN SHACK: It's time to come back

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 into session.

2 Our next topic will be on the AREVA
3 Enhanced Option III long-term stability solution, a
4 topical report, and Said will be leading us through
5 that.

6 MEMBER ABDEL-KHALIK: Thank you, Mr.
7 Chairman.

8 The Thermal Hydraulics Subcommittee held
9 a meeting on November 14 to review AREVA's detect and
10 suppress stability solution and methodology. We heard
11 presentation by AREVA and the staff regarding two
12 licensing topical reports, ANP-262P, Rev. 0, entitled
13 "Enhanced Option III, Long-term Stability Solution,"
14 and BAW-10255P, Rev. 2, entitled "Cycle Specific DIVOM
15 Methodology Using the RAMONA5 Code."

16 Subsequent to the subcommittee meeting,
17 the staff issued revised draft safety evaluation
18 reports on November 27th.

19 At this time we will hear presentations by
20 AREVA and the staff. Parts of this presentation will
21 be closed because of the proprietary nature of the
22 material to be presented, and at this time I'd like to
23 call on Dr. Tai Huang of the NRC staff to begin the
24 presentation.

25 MR. CRANSTON: Let me interject just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 quickly. My name is Greg Cranston, Reactor Systems
2 Branch Chief.

3 Before we introduce Tai, I also want to
4 point out that Jose March-Leuba from Oak Ridge
5 National Laboratory also participated in preparing
6 this, is unable to attend today, and Dr. Tai Huang
7 will be making the presentation.

8 Thank you.

9 DR. HUANG: Okay. I'm Tai Huang from
10 Reactor System Branch, and I'm the original reviewer,
11 technical reviewer for the AREVA BWR Owners' Group
12 long-term stability solution, including ATWS LOOP and
13 instability, and like today the Chairman says that we
14 have two topic reports, and these regarded to
15 stability. One is Enhanced Option III and second
16 would be the cycle-specific DIVOM methodology using
17 RAMONA5-FA code. These two topical reports are really
18 interrelated, to support each other.

19 And as you see today, because the industry
20 demand on that extended operating domain, so you see
21 these three because of this demand for this extended
22 operating domain which pose new challenges to
23 stability as shown in this power flow map there. In
24 this, back in the old day, we starting with the
25 original licensing thermal power, and now into the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MELLLA EPU condition, and beyond that, they have a
2 MELLLA+ region here because this stability boundary
3 over here, and during that, the two pump trip
4 situation, either here or they end up at these
5 endpoints. In this region it would be up there, and
6 this would be much thicker beyond this stability
7 boundary region.

8 So that instability, why they post these,
9 the new kind of instability, as you see in this power
10 flow map, and then what to do then. You know, the
11 staff and industry has developed and reviewed, and
12 under this committee approved that they are generic
13 solution for the BWR Owners" Group solution and to
14 handle this region, and then after review, extended
15 good up to the region here they're called BW owners
16 group long-term stability solutions.

17 However, in this region there are two
18 measure authority. One of them has been approved.
19 The other one is today's, the under committee review.
20 So you see this is a BW owners group approved
21 solution right there, that neither Document 319608,
22 and give us all kind of solution.

23 There are three options, E1A, 1B and
24 Option 2 and 3, and these are approved and documented
25 in this document there or the U.S. BWR reactors have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 implemented one of these solutions depend on their
2 need today.

3 And now because, like in the previous
4 slides there to handle the MELLLA region, there are
5 two methodologies. It's under review, and one of
6 them, GE DSS detect-suppress solution, density has
7 been reviewed and approved for MELLLA+, and today one
8 of their topical reports on AREVA, they're called EO-
9 III, under review right now.

10 So what is what they call EO-III and what
11 is difference between EO-III and enhanced Option III,
12 and as you see previously, the owners group provision,
13 they have an Option III. So the difference would be
14 still keep the Option III features and plus some are
15 different from AREVA so that they become enhanced
16 Option III.

17 So enhanced Option III really is an
18 evolutionary step, rely on existing methodology and
19 hardware for Solution III and what the difference is
20 that EO-III introduced measures for addressing the
21 review of stability associated with extended flow in
22 all conditions and the higher probability of single
23 channel hydraulic instability excitation.

24 So the enhanced Option III have this kind
25 of features over there. So the new element to use

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 enhancement to existing Option III solutions are such
2 as they introduced, introduction of a calculated
3 exclusion region on the power flow mat designed to
4 preclude single channel instability.

5 Also, they have a calculation procedure,
6 how to do it. So this is different from the regular
7 Option III.

8 Yes.

9 MEMBER CORRADINI: Can you show us on the
10 diagram where the exclusion region is?

11 DR. HUANG: Okay. That would be in the
12 closed session.

13 MEMBER CORRADINI: Okay.

14 CHAIRMAN SHACK: Can you show us on the
15 cartoon though?

16 DR. HUANG: You want to show on cartoon?

17 CHAIRMAN SHACK: Yeah. I think that's all
18 he's asking.

19 MEMBER APOSTOLAKIS: Two slides back,
20 three slides back.

21 DR. HUANG: This one?

22 MEMBER APOSTOLAKIS: Yeah.

23 DR. HUANG: Basically I would say most
24 likely similar with this concept, but the detail be in
25 the process, you know, to show you one the slides.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIRMAN SHACK: I think we just need to
2 deal with this in the closed session.

3 MEMBER CORRADINI: Okay. Thank you.

4 DR. HUANG: Okay. So now because you have
5 EO-III and you have to have the way to apply it, EO-
6 III, so they need something they call Option III. If
7 you're aware of the Option III, they have OPRM system
8 using the OPRM input to get the set point. So they
9 need a DIVOM curve.

10 So the second topical cycle specific DIVOM
11 methodology from AREVA, and this time on curve really
12 is a relationship between the hot bundle relative
13 oxidation magnitude and the limiting fractional change
14 in critical power ratio, and this is really a document
15 in BW owners group solution, Needle 32465 document,
16 and details go in there.

17 And our review will be a trace, you know,
18 like capability of the RAMONA5-FA system core to model
19 neutron oxidation of the regional mode pipe and also
20 that range of input data defined that set points
21 within the reload cycle for which diamond curve is
22 generated, and to the end they have to summarize what
23 is the result of these calculations and come out with
24 a time on curve. So that would be, you know, the
25 start review coverage area for that time on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 methodology.

2 And our conclusion under EO-III, we said
3 EO-III is an acceptable authority to detect and
4 suppress oscillation should they occur, which means a
5 DVC-12 design criteria, design criteria 12. So the
6 EO-III solution features provide protection up to and
7 including the end of MELLLA conditions. The detail
8 will be included in cross-section.

9 Now, let's go into the conclusion for the
10 time on curve. The time on category called there,
11 this is AREVA mass authority, is consistent with
12 previous approved BWR owners" group mass authority
13 document in Needle 32465 document.

14 RAMONA5 is an integral part of AREVA time
15 on methodology, and they're using RAMONA5 and the
16 staff review, and RAMONA5 is capable computing power
17 flow and void oxidation with consistent phase lag and
18 of a frequency that presented the unstable oxidations,
19 and they can estimate the loss of critical power radio
20 induced by this oxidation, and also AREVA has commit
21 to support the staff review of RAMONA5-FA for time on
22 calculation, and on top of this because the staff only
23 make these limited reviews for this limiting
24 application for time on calculation, the detailed
25 review will be filed in the future.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 And because this, so there is staff in the
2 SER that has revised. They say RAMONA5-FA limitation
3 there. The first was in the MELLLA+ region, if you
4 want to apply this mass authority. One condition is
5 the application of RAMONA5-FA to calculate time on
6 curve under extended flow window operating domain,
7 such as MELLLA+, it restricted true stability
8 solution, having a scram protected exclusion region
9 that substantially reduced the potential severity of
10 power oxidation and why they have relieved that one
11 there. In the cross-section we have a curve which
12 shows that region always protected, you know.

13 And also, there's a penalty of ten percent
14 must be added to time on slope calculated by RAMONA5-
15 FA for extended flow window operating domains, and
16 this penalty is equivalent to penalty of ten percent
17 added to calculated relative CPR response for even
18 power oxidation magnitude, which means that they put
19 more margin there. You cannot rely on this, you know.
20 The endpoint would be the calculation of whether your
21 final MCPR compared to the stability limit. So
22 there's penalty like equivalent to about close to ten
23 percent because here is, say, from here and ten
24 percent on top of that calculated there, and you put
25 the same oxidation magnitude. You come out with CPR

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 over initial MCPR. So there's a penalty over there
2 and ten percent would be penalized for that.

3 Then, you know, like a reason for this
4 being important is because today's power operation,
5 you need a higher radio power peaking. Also, your
6 power flow ratio is higher. So that means in the
7 MELLLA+ region you're exposed to this and start really
8 quicker and then the probability is higher. So that's
9 why, you know, start will be review these and fit
10 these.

11 If they want to get this ten percent
12 penalty out, you have to review this line by line for
13 the core.

14 MEMBER ABDEL-KHALIK: I'd like to point
15 out that these two conditions were imposed by the
16 staff after the subcommittee meeting on November 14th.
17 So these were two new conditions that were included in
18 the revised safety evaluation report that was issued
19 on November 27th.

20 MEMBER SIEBER: Let me ask a question.

21 MEMBER ABDEL-KHALIK: Yes.

22 MEMBER SIEBER: Has RAMONA5-FA been
23 approved by the staff on its own merit as opposed to
24 in conjunction with this application?

25 DR. HUANG: Actually staff haven't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 approved this. However, in that application portion
2 of the staff review, we review some of this, but not
3 fully review for this RAMONA5-FA.

4 MEMBER SIEBER: Okay. So RAMONA5-FA just
5 as a computer code has not been staff approved.

6 DR. HUANG: Yes.

7 MEMBER SIEBER: And when you use RAMONA5-
8 FA for this application without that blanket approval,
9 what alternate methods did the staff want to assure us
10 and everyone else that RAMONA5 will give reasonably
11 accurate results?

12 DR. HUANG: Oh, okay. Ask staff.

13 MEMBER SIEBER: You don't have a code that
14 will do that as far as I know.

15 DR. HUANG: Yes. Staff really looked at
16 the RAMONA5A, what it can do for this limited use for
17 the time on calculation, is try to learn that where
18 the time on -- RAMONA5A, they can confirm that
19 oxidation, you know, to that extent. Also they can
20 confirm what the loads of CPR are, you know, how
21 they're protected within the range of the uncertainty
22 there. So staff looked at that and see this can
23 perform this limited application up to the MELLLA
24 region, not MELLLA+, yeah.

25 MEMBER SIEBER: Now, the restrictions that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the staff has recently proposed, ten percent and so
2 forth, I take it somewhere along the line you're going
3 to explain how those penalties somehow are related to
4 the use of RAMONA5 and why that penalty is good enough
5 to say that stability can be detected and suppressed.

6 DR. HUANG: AREVA can support this one.
7 The staff looked at proposed idea. They say five
8 percent, for example, at beginning, and we say, well,
9 this five percent penalty probably not good enough,
10 and then we say, well, twice this five percent -- if
11 we draw that line from that generic time on curve
12 slope, it's about .05 slope.

13 Now, we say ten percent penalize that one.
14 We see about .5. You know, it's ten percent. If .5
15 sit up over there, equivalent to about ten percent of
16 energy released and ten percent of CPR margin you
17 lose. That's a lot of penalty. You know, you look at
18 and you compare that initial MCPR versus later CPR to
19 come out with the set limit. It's kind of a big
20 penalty from this operation.

21 So staff say, well, ten percent should
22 cover these conditions.

23 MEMBER SIEBER: I presume that some place
24 in the presentation you will elaborate on that.

25 DR. HUANG: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: Because it looks to me
2 like there's some pulling of numbers out of the air
3 and saying we don't think this is good enough, but
4 there is no basis. But this ought to be okay.

5 DR. HUANG: Yes.

6 MEMBER SIEBER: And that may be because of
7 my lack of full understanding. On the other hand,
8 that's the way it appears.

9 DR. HUANG: Yeah, okay. I will think
10 about --

11 MEMBER ABDEL-KHALIK: This remains as a
12 major concern inasmuch as it appears to be -- you
13 know, the adequacy of this penalty has not been fully
14 justified and/or documented, and hopefully we'll hear
15 some information as to why this gives us adequate
16 assurance that this is okay until the staff completes
17 its review of RAMONA5-FA.

18 MEMBER SIEBER: Well, the staff doesn't
19 have the analytical tools to do that right now I don't
20 think.

21 MEMBER ABDEL-KHALIK: You know, we would
22 like to wait and hear what they have to say as to
23 justification for the adequacy for such a penalty.

24 MEMBER ARMIJO: But in effect, if this
25 goes through, this would be a limited approval of that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 code with some penalties that we get to determine
2 whether it's justified, which seems to be a little bit
3 backwards. It seems like you're going to approve the
4 entire code and then address its applicability to
5 different problems. We're doing it backwards.

6 MEMBER SIEBER: The problem you've solved
7 now in the total review has to wait until additional
8 analytical tools are available.

9 DR. HUANG: Yeah, we're taking into
10 consideration it's ten percent penalty equivalent to
11 MCP and they say .02, .01, some kind of number like
12 that. So we justify why this ten percent is, you
13 know.

14 MEMBER ABDEL-KHALIK: We'll probably get
15 more information in the closed session. So perhaps
16 what we ought to do is just move on with the
17 presentation.

18 Thank you, Dr. Huang.

19 At this time we'd like to move on to the
20 AREVA open part of the presentation before we get to
21 the closed session.

22 (Pause in proceedings.)

23 MEMBER ABDEL-KHALIK: Let's proceed with
24 the hard copies until visual aids are returned.

25 MEMBER ARMIJO: We're working off of this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 for this session?

2 MEMBER ABDEL-KHALIK: Yes.

3 MR. FARAWILA: And I will be giving you
4 the slide numbers.

5 MEMBER APOSTOLAKIS: Sure. We can manage
6 that.

7 (Laughter.)

8 MEMBER APOSTOLAKIS: Well, you know, it's
9 single digits.

10 DR. FARAWILA: Okay. Chairman, members of
11 the ACRS Committee, my name is Yousef Farawila. I
12 will be presenting an overview of AREVA's Enhanced
13 Option III long-term stability solution and associated
14 DIVOM methodology using RAMONA5-FA.

15 Slide 3.

16 Just a quick road map of the presentation.
17 First, I present a quick overview of the original
18 Option III detect and suppress solution and talk about
19 Part 21 report against it and the recovery from the
20 Part 21 both in the short term and in the long term.

21 And after that in closed session we will
22 present enhanced Option III solution, which depends on
23 excluding single channel hydraulic instability, and we
24 will also mention the codes and methods that support
25 that option, and then welcome your questions.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 In page 4, you will see a sketch
2 summarizing the original Option III, which is detect
3 and suppress solutions. So if you look to your left
4 where the core sketch is, you will see a closely
5 spaced LPRM strings and signals coming from them at
6 different elevations.

7 MEMBER APOSTOLAKIS: LPRM, OPRM? I don't
8 know.

9 DR. FARAWILA: Oh, OPR, local power range
10 monitors.

11 MEMBER APOSTOLAKIS: Say it again.

12 DR. FARAWILA: Local power range monitors,
13 LPRMs. They are closely spaced so that they can
14 detect regional oscillations, not only core-wide, and
15 for the sake of redundancy, you have several of these
16 composite signals, and for each one of them, you
17 collect signals from different LPRM elevations.

18 When you sum them up, you get a signal
19 that is called OPRM for oscillation power range
20 monitor. That signal can be oscillatory, noisy, and
21 before you process it first, it is filtered to remove
22 high frequency noise, and it's also normalized. And
23 the filtered and normalized signal goes to a period
24 based detection algorithm, the PBDA.

25 The function of the period based detection

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 algorithm is to examine the periodicity of the signal.
2 If the periodicity is confirmed by having several
3 successive periods within a tolerance range, then you
4 suspect that you have an oscillation and you want to
5 examine the amplitude of that oscillation against a
6 preset set point.

7 If that is the case, if passed that test
8 as well, that means you will get a trip signal. There
9 is a trip logic that requires more than one trip
10 signal order to actually scram and protect the
11 reactor.

12 Next page.

13 MEMBER CORRADINI: Let me make sure I
14 understand. And then not only is it the amplitude,
15 but the number of times it crosses, right? You look
16 for a number, not just --

17 DR. FARAWILA: Okay. I have two tests
18 here. One is the periodicity, and so you see a number
19 of confirmations. It could be 12. It could be --

20 MEMBER CORRADINI: That's where the N is.

21 DR. FARAWILA: Right.

22 MEMBER CORRADINI: Okay.

23 DR. FARAWILA: The second one is an
24 amplitude, not periodicity.

25 MEMBER CORRADINI: Don't worry. You're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 fine.

2 (Laughter.)

3 DR. FARAWILA: A big effort making this
4 part.

5 (Laughter.)

6 MEMBER CORRADINI: Easier to see than the
7 fancy new ones.

8 DR. FARAWILA: Okay. Next page.

9 All right. Because the system is designed
10 to suppress the oscillation to protect the CPR safety
11 limit, so inherently there is required a relationship
12 between that oscillation and the CPR response. That
13 relationship is called the DIVOM curve. It is based
14 on time domain code calculation of a regional mode
15 oscillation and the output is closest -- for each
16 oscillation you get the relative oscillation
17 magnitude, and you see the corresponding loss of CPR
18 margin, and you plug these against each other to
19 generate a DIVOM curve.

20 Originally, in the original Option III,
21 that DIVOM curve is generic. It's calculated once,
22 and it covers all plans and all cycles and all field
23 designs.

24 Next slide.

25 We come to mention, as the agenda

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 requires, the Part 21 report against the Option III
2 solution and how it was resolved. General Electric
3 filed for a Part 21 report in August of 2001, which
4 states that the generic DIVOM curve is not always
5 conservative, and not conservative meaning higher than
6 stated CPR response, which is equivalent to saying
7 that it has higher DIVOM slope.

8 And that condition occurs at high radial
9 peaking or high power-to-flow ratio, and the change
10 was not always in the smallest steps. It can be
11 sometimes rather high, up to probably doubling the
12 generic value.

13 The way this issue was resolved in the
14 short term was through the BWR owners group collective
15 efforts and the procedure was revised in order to
16 prescribe cycle specific DIVOM calculations. So with
17 DIVOM being cycle specific, if such higher slopes are
18 present, they would be taken into account.

19 However, this short solution was not good
20 enough for most severe conditions that could be
21 expected from MELLLA+ and also the accounting for much
22 higher DIVOM slopes would result in low setpoints,
23 which makes the system more susceptible to noise, and
24 you have a probability of spurious scrams. That's a
25 very undesirable thing.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So in the long term, a solution that takes
2 care of this DIVOM problems that's not susceptible to
3 it would be also applicable to MELLLA+. So if we
4 focus on application to MELLLA+, it automatically
5 covers the other operating regimes that are minor in
6 comparison.

7 AREVA's long-term stability solution is
8 enhanced Option III. I will just give you a quick
9 example of what a well-behaved DIVOM curve is. You
10 see it's fairly linear and very well defined slope.
11 This one we calculated with RAMONA5-FA. We wanted to
12 examine what is that elevated slope DIVOM curve.
13 We'll go in closed session very shortly.

14 So if you want to look at the other side,
15 the ill behaved ones, you probably want to borrow
16 progressing by focus from your neighbor. Then you
17 will see like on the next page, you will see how a not
18 well defined DIVOM curve could look like, and in the
19 next two or three viewgraphs we are looking at the
20 same exact reactor state. Just we changed the initial
21 perturbation to show you that the calculated DIVOM may
22 not just simply have a sometimes higher slope, but
23 it's not really that well defined.

24 Can we show the next one? Another one,
25 another one.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Okay. So you could see there that
2 DIVOM -- last time when we were here addressing the
3 subcommittee we presented something similar with a
4 reduced order model. This one we are actually showing
5 the RAMONA calculations. The rest of the presentation
6 should we go to the closed session.

7 MEMBER ABDEL-KHALIK: Okay. For the
8 reporter, we are now switching to a closed session.

9 (Whereupon, the foregoing matter went off
10 the record at 11:23 a.m. to reconvene in
11 closed session and went back on the
12 record at 1:15 p.m. in open session.)

13 CHAIRMAN SHACK: We can come back into
14 session. Our next topic is the State-of-the-Art
15 Reactor Consequence Analysis, the SOARCA project. We
16 met with the staff in a subcommittee meeting and
17 discussed, essentially, their approach to the problem,
18 and some preliminary results that they'd received.
19 And they're now going to update the Full Committee on
20 the process, and their current status.

21 MR. PRATO: My Division Director will open
22 up. Farouk.

23 MR. ELTAWILA: Good morning. I have a
24 slight cold. I got it from Bill Shack, that he
25 invited us to Oregon, and just blasted us with the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 winds over there that we could not survive.

2 As you know, the State-of-the-Art
3 Consequence Analysis, I'm going to call it SOARCA for
4 brevity from now on, is a voluntary effort, so we have
5 to rely on the involvement of the industry. So I
6 would like to start by thanking Surry and Peach Bottom
7 for their cooperation, and providing us with the
8 information that enabled us to do this analysis.

9 We met with the ACRS in the summer of
10 2006, and we met with the Subcommittee last week. And
11 we have completed the baseline calculation for both
12 Surry and Peach Bottom.

13 We started the SOARCA, because as you are
14 aware, that has been the -- the Sandia Siting Study
15 has been called into a different arena, and people are
16 using it out of context, so we decided to do this
17 analysis to try to update and replace the Sandia
18 Siting Study. And we were motivated by a lot of
19 things, among them, improvement in plant operation and
20 maintenance; all the accomplishment that has been
21 gained, or the insight that has been gained over the
22 past 20 years from severe accident research, and
23 additional regulatory requirement that was either
24 imposed by NRC, or voluntarily implemented by the
25 utility that improved plant operation and performance.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 If you look at all the study, you find
2 that there were many driven, particularly the early
3 fatality, mainly driven by scenario that lead into
4 early containment failure. And if you look at our
5 history of dealing with this issue, we have resolved
6 the main two or three issues that deal with early
7 containment failure for pressurized water reactor
8 containment heating. We're concluding that's a very
9 low probability. Alpha mode failure, we concluded
10 that is low probability, and physically impossible.
11 So if you look at it from a phenomenological point of
12 view, we have eliminated all the early containment
13 failure. By that, that by itself, you can conclude
14 that there will be no early fatalities, because there
15 are enough time to allow for the evacuation and
16 implement emergency preparedness. So we are --
17 although, the analysis, we are still doing the
18 sensitivity analysis right now, we're confident that
19 the result at the end, there will be no early
20 fatalities. And I venture to say that even for latent
21 cancer fatality, the result will be significantly
22 improved over previous analysis.

23 With that, I would like to ask Bob Prato
24 to start the discussion. Thank you.

25 MR. PRATO: Good afternoon. I'm Bob

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Prato. I'm the Program Manager for SOARCA, and I want
2 to thank you for this opportunity. As Farouk
3 mentioned, the last time we were in front of the Full
4 Committee was more than a year ago, and a lot of work
5 has been accomplished over this past year and a half.
6 And the team is looking forward to your feedback.

7 As we discussed with the Subcommittee we
8 are basically going to be covering process. But as
9 requested by the Subcommittee, we do have a
10 demonstration, a high-level demonstration of a
11 sequence that we began the SOARCA process with,
12 exercising the process itself.

13 If you turn to the agenda, we're going to
14 start with a project overview, and one of the slides
15 for the project overview is a full diagram of the
16 process, and we're going to get into great detail for
17 each one of the boxes in that flow diagram. So we're
18 going to cover accident sequence selection,
19 containment system states, mitigative measures,
20 MELCOR, MACCS2, emergency preparedness, and peer
21 review in relatively good detail, hopefully to give
22 the Full Committee an understanding of the SOARCA
23 process, itself. And then we're going to cover a
24 sample sequence, and we're going to update you on the
25 status of reporting latent cancer fatalities.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 The SOARCA objective; it's really two-
2 fold. We are developing a State-of-the-Art, more
3 realistic evaluation of progression, radiological
4 release, and off-site consequences for frequency
5 dominated core damage accident sequences. And we are
6 going to provide a more accurate assessment of
7 potential off-site consequences to replace previous
8 consequence analysis, such as NUREG-2239, which is
9 entitled, "The Technical Guide for Citing Criteria
10 Development", which was issued more than 25 years ago,
11 in November of 1982. That cite is more commonly
12 referred to as the Sandia Siting Study.

13 MEMBER APOSTOLAKIS: You did change the
14 first objective.

15 MR. PRATO: Yes, sir, as you requested.

16 MEMBER CORRADINI: Suggested.

17 MR. PRATO: Suggested.

18 MEMBER APOSTOLAKIS: Suggested.

19 MR. PRATO: And is it more accurate?

20 MEMBER APOSTOLAKIS: I think it's more
21 accurate.

22 MR. PRATO: Anybody have any questions on
23 that specifically?

24 CHAIRMAN SHACK: Just you are still moving
25 ahead now with the study on Sequoia as the next step

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in the process?

2 MR. PRATO: We are going to be contacting
3 -- we've contacted them previously. They have agreed
4 to volunteer. They went into a refueling outage, so
5 we are going to contact them again next week and set
6 up a schedule, and we plan to start somewhere in the
7 February time frame, interacting with them. Okay?

8 MR. ELTAWILA: Again, it's a voluntary
9 effort. We don't know if they are going to -- so we
10 are negotiating with different utilities, too.

11 MR. PRATO: Severe accident -- sir?

12 MEMBER APOSTOLAKIS: I guess we have
13 discussed this ad nauseam, but why aren't you doing a
14 Level 3 PRA? Is there a short answer for that?

15 MR. PRATO: There isn't a short answer to
16 it.

17 CHAIRMAN SHACK: We keep asking it again
18 and again.

19 MR. PRATO: As you well know, Charlie
20 presented the staff's view on that. Charlie has the
21 most integrated knowledge of all the pieces. Charlie,
22 unfortunately, is not here, but he did make several
23 key points.

24 MEMBER APOSTOLAKIS: What's his last name?

25 MR. PRATO: Tinkler.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 MEMBER APOSTOLAKIS: Yes, we know him.

2 MR. PRATO: Okay? The key points, and
3 I'll cover the key points first. We believe that the
4 Level 1 PRA has done an outstanding job at this point
5 of identifying what is important with regards to
6 sequences, both from a CDF perspective, and from a
7 LERF perspective. Second, and one of the underlying
8 premises of the project is that the Level 2 and Level
9 3 deserve more attention, and more rigorous
10 quantification.

11 It is also our view that the use of an
12 integrated method, such as MELCOR and MACCS, together
13 with an uncertainty analysis, was a better approach
14 for this application, versus trying to quantify
15 thousands of sequences, and it would help to shed some
16 insights on risk.

17 The other thing is, is that with MACCS and
18 MELCOR, if there is a problem with the analysis, we
19 can attack the particular model in a more direct
20 manner. And in Charlie's words, "the information is
21 no buried in a sea of numbers for which it is
22 difficult to extract this kind of information."

23 So why are we using CDS as our screening
24 criteria? Well, from the start, there is a historical
25 emphasis at the NRC on CDS, as well as an abundance of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 information on CDS. We have our updated benchmark
2 SPAR models as an internal source for CDF information.
3 And, remember, we have a high confidence in the Level
4 1 PRAs, as well, so --

5 CHAIRMAN SHACK: Internal events.

6 MR. PRATO: Excuse me?

7 CHAIRMAN SHACK: Internal events.

8 MR. PRATO: For internal events, correct.

9 CHAIRMAN SHACK: At full power.

10 MR. PRATO: Yes, sir.

11 MEMBER APOSTOLAKIS: Too many.

12 MR. PRATO: In addition, the NRC uses CDF
13 as its criteria for risk-significance in Reg Guide
14 1.174. This Reg Guide uses a CDF of 10 to the minus
15 6, and a LERF of 10 to the minus 7. We use the same
16 Reg Guide 1.174 criteria for CDF, and if you believe
17 that the conditional containment failure probability
18 is approximately 0.1, then we meet the criteria for
19 LERF, as well. And, therefore, we captured the risk
20 significance based on that criteria.

21 The only other question remaining is, are
22 we capturing all the significant contributors to LERF
23 by using CDF, as opposed to using LERF. Again, for
24 PWRs, there really shouldn't be any significant
25 dispute that early conditional containment failure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 probabilities are less than or equal to .01. As for
2 BWRs, in other studies initial results for station
3 blackout events indicated that vessel failure does not
4 occur for more than eight hours into the event. And
5 the customary definition for early is four hours, so
6 we believe that we're on the right track for BWRs, as
7 well. And although it's site-specific and sequence-
8 specific, we are paying very close attention to the
9 timing of the release, and we are making sure that it
10 is beyond the early criteria.

11 MEMBER APOSTOLAKIS: Now NUREG-1150 and
12 some other studies that are done by the industry, they
13 did go all the way to Level 3. Have you compared what
14 you have found with the findings of those studies?

15 MR. PRATO: Not yet, sir.

16 MEMBER APOSTOLAKIS: But you will do that?

17 MR. PRATO: I'm not sure if that's our
18 plan right now, but the results are relatively
19 preliminary.

20 MEMBER APOSTOLAKIS: It would add
21 confidence.

22 MR. PRATO: Mike Yerokun.

23 MR. YEROKUN: Let me try to -- a direct
24 response to the question of do you plan to compare
25 your results with NUREG-1150, I mean, yes, whatever

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 comes out from SOARCA, we definitely will see what
2 insights we can derive compared to all the previous
3 studies. Obviously, the Siting Studies, but also
4 NUREG-1150 to see what knowledge we gain from the
5 approach we've used for SOARCA, and what that really
6 means for the risk approach that was used for NUREG-
7 1150.

8 MEMBER APOSTOLAKIS: Level 3 results.

9 MR. YEROKUN: I'm sorry?

10 MEMBER STETKAR: Well, even full scope
11 Level 2.

12 MR. ELTAWILA: I'm going to jump here and
13 say I don't know what benefit we will gain out of
14 comparing the SOARCA study with NUREG-1150 study. I
15 think we believe that these previous studies are very
16 conservatively done, and did not represent the plants
17 as operated, and design, and improvement that have
18 been to the plants, so we will not be comparing apples
19 with apples. I think that -- I appreciate your
20 question, but I will prefer to do a Level 3 for a
21 plant and compare it to a SOARCA study, but to try to
22 compare the SOARCA with the NUREG-1150, it's not going
23 to be a viable comparison.

24 MEMBER APOSTOLAKIS: It would be nice to
25 know why there are differences. If you find different

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 -- if I go to the Peach Bottom evaluation in 1150,
2 they give me -- well, all five plants, actually. They
3 give me fatality curves, latent cancer curves, and so
4 on, and they give me the dominant contributors. I
5 mean, even if it's not part of your objective,
6 wouldn't you be curious to know whether your results
7 are different? And if they are different, why they
8 are different? You may come back and say because we
9 did a better job, but to say I'm not even going to
10 look at it, it's kind of -- doesn't make sense to me.

11 MR. PRATO: Well, there was one other
12 point Charlie wanted to make, or Charlie made at our
13 last meeting. And he said, "With MELCOR, we do
14 believe that additional large benefit is derived in
15 looking at mitigating measures that has not yet been
16 addressed in PRA, such as SAMGs, and other severe
17 accident mitigation guidelines."

18 MEMBER APOSTOLAKIS: Well, you can always
19 say those things when you compare. I'm not saying
20 don't say it, but at least, I mean, tell us how the
21 results are different.

22 MR. PRATO: And I think as you see -- as
23 we go through the sample analysis, you'll see how it
24 becomes obvious how considering the mitigative
25 measures, all the mitigative measures have a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 significant benefit to the outcome.

2 MR. CHEOP: This is Mike Cheop. Let me
3 try to address that. I think as part of the peer
4 review process, as we are looking at accident
5 sequences, we do ask ourselves why are we different
6 from, let's say, 1150. And if you're different, what
7 the reasons are. And we will convince ourselves what
8 the differences are. And as we go forth into the
9 Level 2 and Level 3 space, again, we do introduce a
10 lot more, as Bob said, mitigative equipment. And we
11 can't explain a lot of the differences through the
12 different strategies that we're using, and the
13 differences. We may not make a formal comparison, but
14 we do, as part of the peer review, and our internal
15 review process, try to convince ourselves as to what
16 the differences are, and what's causing the
17 differences.

18 MEMBER CORRADINI: Could I just ask for
19 clarification.

20 MS. MITCHELL: This is Jocelyn Mitchell
21 from the Office of Research. I just wanted to remind
22 you that the Level 2 part of 1150 was done using the
23 EXOR codes, like the PBSOAR, and the SRSOAR code,
24 where they took a tiny handful of source term code
25 package runs and spread them out into hundreds of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 sequences, and then subsequently collapsed into 17 for
2 Surry, and I don't know the number for Peach Bottom,
3 of release categories. I think it would be an
4 exercise in futility to try to go back and say here is
5 this integrated MELCOR analysis, and why did it change
6 from expanding, collapsing, and basing on just a few
7 runs.

8 MEMBER CORRADINI: Just to expand, I
9 guess, what George is saying, make sure I understand
10 the staff's position. So I think my way of saying it
11 in some sense coming up with the same result that
12 George is, if you took, and I'm going to pick Peach
13 Bottom and Surry because they have an interesting
14 historical, you can essentially take that and explain
15 the differences. And I think that's kind of what I
16 get from George is after, is explain the evolution of
17 your insights, both in terms of modeling, in terms of
18 additional measures that have been taken care of, and
19 you can go all the way from WASH-1400 through 1150,
20 through - and I was going to ask something about that,
21 through a current, if they had, or if they do have a
22 Level 3, and really then show what you've done, both
23 in terms of methodology, models, and improvements.
24 And that, I think, would help drive home the
25 improvements that you have with SOARCA. I guess

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that's the way I view --

2 MEMBER APOSTOLAKIS: That's part of it.

3 MEMBER CORRADINI: That's another
4 motivation to do it, as George is suggesting.

5 MEMBER SIEBER: But how does that benefit
6 the overall science of what it is they're doing here?
7 For example, methods and codes have changed,
8 reliability data has changed, assumptions have
9 changed, scope has changed. And to make the
10 comparison, you're going to list a lot of changes.
11 And it's not going to -- you aren't going to be able
12 to draw a conclusion from it, other than this one is
13 liberal, this one is conservative, not liberal,
14 realistic versus conservative, and methods have
15 changed over the years.

16 MEMBER APOSTOLAKIS: Well, there are two
17 questions that come to mind. First of all, I don't
18 even know why we're discussing this. Is this such a
19 big effort that the staff is resisting, too many
20 resources? It wouldn't look like that to me. But
21 second, and what you're saying is that the curves that
22 I see in terms of public consequences in NUREG-1150,
23 and other Level 3 PRAs, have been completely
24 invalidated, that this SOARCA thing now says don't
25 believe any of that any more?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: That's how I took it.

2 MEMBER BLEY: If that's true, I guess I'd
3 really want to understand why.

4 MEMBER APOSTOLAKIS: Me too. I really
5 want to understand why. I mean, they have very nice
6 curves there, kind of smooth. They tell you what
7 dominates. It would be nice to say yes, we are
8 consistent with those guides, but we're doing a better
9 job.

10 CHAIRMAN SHACK: I mean, we do have this
11 bifurcation where we select what we examine by looking
12 at frequency, and then we examine the risk-
13 significance of what's left. Why don't we just look
14 at risk-significance in the first place?

15 MEMBER APOSTOLAKIS: Right.

16 MEMBER STETKAR: Well, that has to do with
17 ----- having gone through a few recent, not 25 years
18 old, not 15 to 20 years old, but within the last 10
19 years, full scope Level 2 risk assessments sponsored
20 by the industry, not the NRC, that have included
21 things like SAMGs, that have concluded that the most
22 important contributors to off-site releases, and I'll
23 stop it there, because these were not Level 3 risk
24 assessments, are Level 1 core damage sequences that
25 are in the noise level for core damage frequency. The

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 most important contributors to off-site releases are
2 sequences that are a small percentage, very small
3 percentage in total of the core damage frequency.

4 In other words, it probably wouldn't even
5 make the pie chart when you look at contributors to
6 core damage. However, that has been the result of
7 detailed analyses using reasonably refined Level 2
8 codes, taking credit for existing SAMGs, existing
9 whatever you want to call them, beyond core damage
10 operating procedures. And the concern, I think --
11 part of George's concern is, is the 10 to the minus
12 6 screening criterion basically missing most of the
13 things that current studies, current industry-
14 sponsored studies show, indeed, are most important to
15 the issues that, indeed, you're examining, the Level
16 2, Level 3-type issues. In other words, are you
17 missing those sequences by your screening process?

18 MEMBER SIEBER: Well, if you divide it up
19 enough, you're going to miss a lot in the aggregate
20 that are going to mean something.

21 MEMBER APOSTOLAKIS: That is additional
22 evidence from that EPRI report that concluded that you
23 go to very low frequencies in order to --

24 CHAIRMAN SHACK: Well, even if you look in
25 1150 and you cut it off at 10 to the minus 6, not a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 whole lot happens.

2 MEMBER APOSTOLAKIS: It's an unusual
3 situation in the sense that you have -- say you went
4 to go to some end state, and you have in-between some
5 important stuff, like core damage frequency and
6 release. In traditional PRA when you say dominant
7 contributors to something at the end, you calculate
8 that something, and then you identify the dominant
9 contributors. Here we are using an intermediate
10 state, core damage, to identify what we call dominant
11 contributors, and then we see what their consequences
12 are. It's a little different thing, which is useful
13 by itself, by the way. I'm not saying it's not
14 useful. It's very useful, but the question remains,
15 why not go all the way, and bring into an additional
16 dimension. When you communicate to the public now,
17 when you say there are zero deaths, what does that do
18 to your credibility?

19 CHAIRMAN SHACK: It's no worse than a bus
20 accident.

21 MEMBER APOSTOLAKIS: You do have deaths.
22 So what you are doing is fine. It sheds a lot of
23 light into what can happen for these sequences, and so
24 on. But it's a mystery to me why there is such
25 resistance to go all the way. I mean, are we talking

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 about doubling the effort or what?

2 MR. ELTAWILA: I don't think it's an
3 effort, George. I think it is just if you keep
4 refining the sequence further and further, and go down
5 to a lower frequency event, I think that all what
6 you're generating is number, but they don't mean
7 anything. And because in most of these situations,
8 you know what you can -- how we can deal with these
9 scenarios, so it always will become to an accident
10 management and improvement in evacuation, and
11 improvement in the plant operation. So by just going
12 down in the frequency domain to a very low frequency,
13 yes, you can get an answer, yes, you can get -- that
14 answer might show you that it's risk dominant, but
15 what is the meaning of that?

16 MEMBER STETKAR: The meaning is that at
17 those lower frequencies, there may be initiating
18 events and consequential failures that also completely
19 disable all of those mitigating systems, and operator
20 actions that you're talking about. The nature of the
21 consequences changes at those very low frequencies.

22 MR. ELTAWILA: Very low frequency, 10 to
23 minus 9, but are --

24 MEMBER STETKAR: Or 10 to the minus 7.

25 MR. ELTAWILA: No, I don't think you -- we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 looked at 10 to minus 7, and we --

2 MEMBER STETKAR: In the context of the
3 limited models that you had to deal with, in the
4 context of that, those limited models, but did not
5 look at very clearly external events, seismic events,
6 things like that.

7 MR. CHEOP: Well, I think that's not quite
8 correct. I mean, in the 10 to the minus 7 range, we
9 did look at the external events, the seismic and the
10 fire events, so in that sense, those are included in
11 our 10 to the minus 7 look. And I guess in addressing
12 Dr. Sieber's earlier comment, we actually have not
13 tried to parse out the sequences to such a point where
14 we can eliminate them from the screening process. We
15 did try to keep groups together, so that we do not
16 parse them out so that they are below the screening
17 criteria, but I guess, to answer the broader question
18 as to why we don't do a risk analysis versus a
19 frequency dominant cutoff, that would be, I would
20 imagine, changing the objective of the study. I mean,
21 the objective of the study is to look at CDF dominant
22 sequences, and that's the way they're going at this
23 point.

24 MEMBER CORRADINI: I mean, if I could just
25 - if I might. But I understand you've been directed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 a certain way. And I understand when one is directed,
2 one follows the directions, but I'm asking --

3 MEMBER APOSTOLAKIS: Did the Commission
4 say this?

5 MEMBER CORRADINI: Yes.

6 MEMBER APOSTOLAKIS: The Commission
7 directed you to look at --

8 MEMBER CORRADINI: Yes. So that I
9 understand. That's why I guess in some sense why I'm
10 just suggesting for you to consider the staff to think
11 of it from the historical perspective, and use the
12 fact of the historical perspective to at least lay the
13 explanation out as to what you're seeing, and the
14 insights you're getting.

15 MR. ELTAWILA: Yes. If my answer at the
16 beginning sounds like we're not going to do that, I
17 apologize for that.

18 MEMBER CORRADINI: I sensed that you
19 wanted to.

20 MR. ELTAWILA: We are going -- but if
21 anybody asked me to try to quantify every single
22 differences, this will be impossible, but we will try
23 to -- what are the plant improvement that led into the
24 lowering of the frequency? What is the
25 phenomenological understanding that help us addressing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this issue? That's part of the SOARCA report, so
2 there is no doubt about that.

3 MEMBER SIEBER: I agree with Dr.
4 Apostolakis, that this has to be -- this comparison
5 needs to be done to a certain extent because this will
6 be an important public document, and a lot of
7 questions are going to be asked. And for sure, they
8 will point out the differences, and if you aren't
9 prepared to answer that in a public forum, then you
10 haven't done the job right.

11 CHAIRMAN SHACK: I think we'd better move
12 on. We have other things to cover, which will
13 undoubtedly lead to discussion.

14 (Off the record comments.)

15 MR. PRATO: We got past this question. I
16 think we can move forward in a reasonable --

17 MEMBER SIEBER: Do every other slide.

18 MR. PRATO: Okay. We're on slide, severe
19 accident improvement, slide 4. Severe accident
20 improvements that is, in part, the motivation behind
21 SOARCA project, included improvements such as the 25
22 years, and literally millions of dollars that have
23 been spent on national and international research that
24 provides a better understanding of severe accidents,
25 and the basis to conclude that some presumed early

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 containment failure modes have been shown to be
2 phenomenologically not feasible, or other severe
3 accidents that are feasible, but that have been
4 demonstrated to be preventable by accident mitigation.

5 Second item, regulatory improvement that
6 reduced the likelihood of severe accidents, rules such
7 as ATWS, Station Blackout Rule, and the Maintenance
8 Rule, all of these have contributed to improved
9 accident management, improved computer modeling
10 capabilities, such as MACCS and MELCOR. Keep in mind
11 that in 1982, when the 1982 study came out, there was
12 nothing like MELCOR that was used or available at the
13 time. And for MACCS, there was a much more primitive
14 model, and there has been significant improvements,
15 not only in the modeling, but in the computer
16 technology that allows us to use computer modeling.

17 Enhancements in plant design, such as the
18 TMI initial modifications, and the modifications that
19 continued beyond the post-TMI modifications during the
20 early 80s and late 90s, things that resulted in the
21 installation of additional emergency diesels, for
22 example.

23 Other plant improvements that have
24 contributed to reducing the likelihood of severe
25 accident include general improvement in plant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 performance. In the early and late 80s, capacity
2 factors were in the 60s and the 70s, today they're in
3 the 80s and the 90s. Emergency preparedness
4 guidelines are available. They've been developed, and
5 evolved, and tested very frequently. And mitigative
6 measures, as you will see, will play a big role.

7 This next slide is an overview of the
8 process. We're going to cover each one of the boxes
9 in a lot more detail, but this just shows how the
10 process flows, and how we come to -- how the SOARCA
11 process works, in general.

12 The SOARCA approach. SOARCA is the only
13 kind of accidents we're considering of full power
14 operation. We are not considering low power,
15 shutdown, or spent fuel pool-type of accidents. We
16 are using a plant-specific sequence truncation of CDF
17 of greater than or equal to 10 to the 6th, and a CDF
18 greater than or equal to 10 to the 7th for bypass
19 events.

20 MEMBER CORRADINI: Minus you mean, right?

21 MR. PRATO: Yes, minus. I'm sorry.
22 They're in there. I apologize. We did consider
23 external events. We considered all of the mitigative
24 measures that were available to the licensees. We did
25 and we're doing sensitivity analysis to assess the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 effectiveness of the different safety measures. A
2 State-of-the Art Accident Progression Modeling based
3 on 25 years of research to provide a best estimate of
4 accident progression, containment performance, time of
5 release, and fission product behavior. We are using
6 a more realistic off-site dispersion model, and we are
7 doing site-specific evaluation of public evacuation
8 based on site-specific updated emergency plans.

9 MEMBER CORRADINI: Can I repeat something
10 that you guys said in the question and answer earlier,
11 just so I put it in this context for the second
12 bullet? So even though your cutoff, as directed, was
13 that, you went down another order of magnitude and
14 surveyed what you saw at the 10 to the minus 7 cutoff.

15 MR. PRATO: We're going to get into that.

16 MEMBER CORRADINI: Okay.

17 MR. PRATO: We'll show you how the
18 sequence selection was --

19 MEMBER CORRADINI: The answer is yes.

20 MR. PRATO: But the --

21 MEMBER CORRADINI: Okay. That's fine.
22 I'll wait.

23 MR. PRATO: SOARCA insights. Okay.
24 Sequences are dominated by external events, primarily
25 large seismic events that play out similar to a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 station blackout. We also identified two additional
2 PWR bypass events that were within the scope of
3 SOARCA.

4 Previously used sequences have
5 significantly lower probability of occurrence, or are
6 not considered feasible, and that includes the alpha
7 mode, the high pressure melt injection, and ATWS. The
8 first two are considered not feasible, and the ATWS is
9 a much lower CDF than was considered in 1982.

10 Mitigative measures are proven to be
11 effective at preventing core damage or containment
12 failure.

13 MEMBER SIEBER: Did you examine the effect
14 of large seismic events on the effectiveness of the
15 emergency planning?

16 MR. PRATO: No, sir, we have not.

17 MEMBER SIEBER: Bridges knocked down,
18 roads closed, flooding, whatever.

19 MR. PRATO: We are doing sensitivity
20 analysis to address that, sir.

21 Sequence screening process. Okay. It's
22 important to mention at this time that SOARCA was
23 never intended to be a risk study. However, the staff
24 wanted its initial focus for SOARCA to include
25 sequences of greatest interest. Therefore, as the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 initial input into SOARCA, the staff used the enhanced
2 SPAR model to identify the sequences that are most
3 likely to occur. Using SPAR, we applied a screening
4 criteria for the sequences included within the scope
5 of SOARCA to identify those sequence or sequence
6 groupings that have a CDF of greater than or equal to
7 1.0 E to the minus 6 to identify those sequences which
8 are most likely to occur.

9 In addition, we wanted to pay more
10 attention to those sequences that are potentially more
11 severe, but that have a little lower likelihood of
12 occurring. For example, interface system LOCAs that
13 bypass the containment. Therefore, we lowered the
14 screening criteria for inter-system LOCAs to a CDF of
15 greater than or equal to 1.0E to the minus 7.

16 These are the steps that are used to
17 implement the screening criteria. We started with an
18 initial screening. We used enhanced SPAR model to
19 screen out low CDF sequences with an overall CDF of
20 less than or equal to 1.0E to the minus 7, and
21 sequences with a CDF of less than 1.0E to the minus 8
22 for bypass events. This step we estimated eliminated
23 less than 10 percent of the overall CDF, approximately
24 5 percent is what it typically ended up being.

25 CHAIRMAN SHACK: Typically for two cases.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PRATO: For the two plants, correct.

2 The sequence evaluation, we identified and
3 evaluated dominant cut sets for the remaining
4 sequences, and we determined systems and equipment
5 availability, unavailability, and accident sequence
6 common to those sequences. We grouped the sequences
7 together that had similar times to core damage, and
8 similar equipment availability. And then we selected
9 bounding sequences based on the most limiting
10 mitigative measures available.

11 For external events, we performed limited
12 reviews of existing external event studies, and data
13 to identify dominant externally initiated event
14 sequences for each plant of interest. And where
15 available, we specifically identified the dominant
16 accident sequences for those plants using the
17 following steps.

18 First, we identified dominant externally
19 initiated event sequences for external events, such as
20 fire, seismic, flooding, wind. And based upon
21 available probabilistic assessment documentation, like
22 NUREG-1150, the IPEEE submittals, as well as any
23 additional available supporting documentation. We did
24 not use seismic margins assessment because it lacked
25 the risk information necessary.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 We identified potential mapping between
2 dominant external events, and internally initiated
3 events identified by the SPAR analysis. Where mapping
4 between external and internal events are not possible
5 or appropriate, a unique external initiating event or
6 sensitivity study was recommended, and the resulting
7 limit --

8 CHAIRMAN SHACK: You need to click your
9 slide.

10 MR. PRATO: Oh, I'm sorry. The resulting
11 limited set of scenarios obtained for each SOARCA
12 plant was used for subsequent accident progression and
13 consequence analysis.

14 Containment system states. The objective
15 of this process is to identify the availability of
16 engineering systems that can impact post-core damage
17 containment accident progression, containment failure,
18 and radionuclide release using the following steps.
19 We determined the anticipated availability of
20 containment and containment support systems not
21 considered in the Level 1 core damage analysis. We
22 did this by determining the availability of front line
23 systems using cut set information. If all support
24 systems were considered in the Level 1 analysis,
25 availability was determined based on the cut set

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 information alone. If they were not, we constructed
2 a system dependency table showing the support systems
3 for performance of the targeted front line system.

4 We then determined the availability of the
5 front line system using engineering judgment. For
6 example, if the necessary support systems were
7 determined to be available or unavailable based on
8 engineering judgment, then the availability or
9 unavailability of the front line system was
10 determined.

11 MEMBER APOSTOLAKIS: This may be a little
12 bit misunderstood. When you say determine the
13 availability, I believe what the study did was assume
14 that the system was working or not. Right?

15 MR. PRATO: That's correct, sir.

16 MEMBER APOSTOLAKIS: Depending on what has
17 been lost.

18 MR. PRATO: That's correct, sir.

19 MEMBER APOSTOLAKIS: In PRA space, the
20 availability will be a probability.

21 MR. PRATO: That's correct.

22 MEMBER APOSTOLAKIS: And you didn't do
23 that.

24 MR. PRATO: That's correct, because we
25 weren't doing that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: Okay. So that's
2 another thing that's different from traditional PRAs.
3 The containment systems are either there or they are
4 not, and you have some logical criteria to decide
5 that.

6 MR. PRATO: That's correct.

7 MEMBER APOSTOLAKIS: But there is always
8 a possibility of a random failure, or whatever the PRA
9 does to come up with the unavailability number.

10 MR. PRATO: We did not do an HRA.

11 MEMBER APOSTOLAKIS: They didn't do that.
12 I mean, that's --

13 MEMBER SIEBER: That may be more --

14 MEMBER APOSTOLAKIS: Determine the
15 availability can be interpreted in different ways.
16 Okay. That's just a clarification.

17 CHAIRMAN SHACK: But, again, their
18 argument is their additional random failures would be
19 lowering the frequency.

20 MR. PRATO: That's correct.

21 MEMBER APOSTOLAKIS: Yes. This cutoff is
22 always running our lives here.

23 MR. PRATO: Okay. In addition --

24 MEMBER APOSTOLAKIS: Wait a minute now.
25 The cutoff is for core damage frequencies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIRMAN SHACK: But it's an overall
2 sequence. The cutoff is really on releases, and they
3 -- well, that's the directive of the SECY.

4 MEMBER APOSTOLAKIS: Wait a minute now.

5 MR. PRATO: It was release frequency.

6 CHAIRMAN SHACK: Release frequency.

7 MR. PRATO: 10 to the minus --

8 CHAIRMAN SHACK: Right. And the staff
9 took a conservative approach by going to the --

10 MR. PRATO: Core damage.

11 CHAIRMAN SHACK: -- core damage, because,
12 again, you're not going to get a release without core
13 damage.

14 MEMBER APOSTOLAKIS: That's what was done.

15 CHAIRMAN SHACK: That's what was done.

16 MR. PRATO: Okay. In addition, the
17 availability of containment systems determine the
18 availability of systems such as the low pressure
19 injection, and that can potentially impact containment
20 accident progression. For example, cooling debris in
21 the reactor cavity, or cooling reactor vessel after
22 the core damage, or prior to vessel failure. Those
23 are the systems we also considered for containment
24 system states, as well.

25 Mitigative measures analysis. The

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 mitigative measure analysis that we performed were
2 qualitative sequence-specific system and operational
3 analysis based on licensee identified mitigative
4 measures from EOPs, SAMGs, and other severe accident
5 guidelines that were determined to be applicable to
6 and available during a specific sequence, whose
7 availability, capability, and timing were utilized as
8 inputs into the MELCOR analysis.

9 CHAIRMAN SHACK: What does it mean by the
10 qualitative part, since you really used these to set
11 the boundary conditions for your MELCOR analysis, as
12 I understand.

13 MR. PRATO: In other words, we didn't
14 quantify it, and we didn't assign a risk to it. That
15 was the --

16 CHAIRMAN SHACK: You mean a probability
17 that it would be done.

18 MR. PRATO: That's correct, sir.

19 CHAIRMAN SHACK: You assumed if it was in
20 the procedure --

21 MR. PRATO: Well, we did more than that.
22 We verified that the equipment was available. We
23 verified that there was no reason to believe that it
24 was not accessible. We insured that we took
25 consideration for communications, resources. We did

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 a very extensive --

2 CHAIRMAN SHACK: Okay. You just didn't
3 assign numbers to those.

4 MR. PRATO: That's correct. That's
5 correct.

6 The process that we used to do this, for
7 those dominant sequence or sequence groups within the
8 scope of SOARCA, we determined the potential
9 availability of mitigative measures. We performed a
10 system and operational analysis based on the initial
11 condition, and the anticipated subsequent failures.
12 We determined the anticipated availability,
13 capability, and time to implementation. And we put
14 all of that information into MELCOR to determine the
15 effectiveness of those mitigative measures. We never,
16 as part of the mitigative measures, assessed its
17 effectiveness. We let MELCOR determine that as part
18 of the modeling.

19 MEMBER BLEY: Let me back you up to that
20 last question, just make sure I'm following. So you,
21 essentially, or as you said earlier, you did no HRA.
22 You, essentially, said if the equipment - this
23 scenario, if the equipment is there that could work,
24 and the procedures would make it work. We'll say it
25 works and put it into the MELCOR analysis. You've

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 essentially assumed people perform perfectly given the
2 equipment's available.

3 MR. PRATO: In general. However, we
4 assign very conservative times to the implementation.
5 We did try to consider accessibility, availability in
6 not only support systems, but support equipment that
7 was needed. Was it on hand, was it pre-staged? We
8 looked at a lot of the parameters that you would
9 consider in an HRA.

10 MEMBER BLEY: If there's time to do it,
11 and if the equipment works, it will be used and it
12 will work.

13 MR. PRATO: That's correct. We looked at
14 availability of capacity. Are the storage tanks
15 available, the bottom of the storage tanks.

16 MR. DUBE: Don Dube, NRO. I want to just
17 add that for most of these sequences, the MELCOR
18 analysis was done with and without the mitigative
19 measure. Right?

20 MR. PRATO: That's correct. We are doing
21 sensitivity analysis both with and without --

22 MR. DUBE: I know probability was
23 assigned, and it failed to --

24 MEMBER BLEY: But we have both results.

25 MR. PRATO: Yes, sir.

1 MEMBER BLEY: Before you got here, I want
2 to understand the statement you made earlier. When
3 you did the basic scenario, did you look at -- you
4 didn't do an HRA there, either. Is that right?
5 Effectively, the same thing, if the equipment is
6 there, you assume the equipment will --

7 MR. PRATO: CDF you include --

8 MR. CHEOP: To get to the CDF portion of
9 the analysis, we did HRA as part of the CDF
10 calculation.

11 MEMBER BLEY: Okay.

12 MEMBER STETKAR: What there isn't, isn't
13 a conditional dependent HRA for the Level 2, Level 3
14 mitigative functions. They're -- HRA ends at Level 1,
15 basically.

16 MR. PRATO: The structural analysis. The
17 objective of the structural analysis was to evaluate
18 the behavior of containment structure under
19 unmitigated severe accident conditions and to predict
20 the following criteria; and that is, functional
21 failure due to pressure, the structural failure due to
22 pressure, and to develop leak rates, and leak areas as
23 a function of internal pressure.

24 As a result of the structural analysis,
25 the dominant cause for containment failure at Peach

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Bottom is the -- we determined to be the head flange
2 bolts strained under gradual increasing internal
3 pressure. And for Surry, it was cracking around the
4 equipment and personnel hatch.

5 MELCOR analysis. As stated earlier,
6 MELCOR or a similar model wasn't available in 1982.
7 MELCOR, since that time, has been developed, and it
8 has evolved, and we have implemented significant
9 improvements to get it to where it is today, which we
10 believe is the state-of-the-art. More recently, and
11 specific to SOARCA, we improved the MACCS output
12 interface. We implemented fuel collapse model logic.
13 We updated MELCOR defaults, and we added approved
14 model.

15 For each of the analysis that have been
16 completed, we developed a site-specific model, and we
17 performed the accident progression for each plant
18 using MELCOR computer code to determine source term,
19 potential containment failure states, and time of
20 release as an input into the MACCS analysis.

21 Similar with MACCS-2, MACCS was around in
22 1982. It has evolved significantly. For the purposes
23 of SOARCA, we implemented a significant number of
24 improvements to bring it up-to-date, and to make it
25 state-of-the-art. I'll go over just a couple of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 these. We increased the number of evacuation cohorts
2 from three cohorts, which was previously, up to 20.
3 We have the capability of dividing up into 20
4 different cohorts. We increased angular resolution
5 from the typical 16 compass points up to 64 segments.
6 We added more plume segments, and we included KI
7 ingestion model, as well. And these are just a
8 couple.

9 MEMBER BLEY: What do you mean when you
10 say "more plume segments"? Can you describe that?

11 MEMBER SIEBER: It is finer.

12 MR. PRATO: Jocelyn, do you want to --

13 MEMBER BLEY: Are you letting them move as
14 the weather changes?

15 MR. PRATO: No.

16 MS. MITCHELL: We usually break it up. In
17 previous analyses, there were usually one puff
18 release, and then a long tail, so you had two plume
19 segments. And now we take this very long, drawn out
20 release, and break it up into typically one-hour
21 releases, and MACCS will pick up for the release of
22 the second plume. If the weather has changed, the
23 wind speed has changed, then it will pick up a new
24 weather sequence, so it's --

25 MEMBER BLEY: Opens up then.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MS. MITCHELL: Yes, right. Right. But it
2 is a one-hour, typically one-hour releases.

3 MR. PRATO: We performed the consequence
4 analysis for each plant and each sequence using the
5 MACCS-2 computer code to determine early fatalities
6 and latent cancer effects.

7 Some of the MACCS-2 assumptions that we
8 used, we assumed that no contaminated food or water
9 would be consumed. We used the latest federal
10 guideline dose conversion factors in Federal
11 Guidelines 12 and 13 for specific isotopes, to
12 specific organs, given different specific pathways.

13 We assumed KI ingestion by half of the 10-
14 mile population, and we used sub-optimal timing. That
15 sub-optimal timing results in a fraction efficacy and
16 if you do the KI ingestion at just the right time,
17 it's approximately in the mid-090s range. We used 70
18 for the efficacization.

19 We used medium values from the U.S. and
20 European study for uncertainty for non-site-specific
21 parameters. This study used expert elicitation for
22 approximately 140 different points important to off-
23 site calculations, and resulted in the distribution of
24 the response for each of those inputs. And we used
25 the mean as the input into MACCS for these things.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And it includes things, such as the dry deposition
2 velocity, the wet deposition velocity, some of the
3 parameters in the food chain model, a set for those
4 type of parameters are included in those 140 different
5 inputs.

6 MEMBER BLEY: Who were your experts for
7 that?

8 MR. PRATO: That was a separate study done
9 for not only our modeling applications, but for the
10 Europeans, and the Asians, as well. It was a
11 combination of U.S. and --

12 MEMBER APOSTOLAKIS: It was years ago,
13 wasn't it?

14 MR. PRATO: Yes, sir.

15 MEMBER BLEY: Oh.

16 MS. MITCHELL: This is Jocelyn Mitchell.
17 The study was done about 10 years ago, and had six
18 different panels that worked on different disciplines
19 that were necessary, and they had usually eight
20 experts on the panel, four from the U.S., and four
21 from the EC countries.

22 MEMBER BLEY: George just reminded me.
23 This is the one using Roger Cook's approach.

24 MEMBER APOSTOLAKIS: Yes.

25 MEMBER BLEY: Where it calibrates the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 experts.

2 MS. MITCHELL: The expert elicitation
3 itself was conducted by the U.S., and the European
4 part of it was to take the discrepant distributions
5 that come out of it, and evaluate them. We have
6 redone that, because we found some problems with how
7 it was done, and so we have re-sampled it, and have a
8 distribution that encompasses the eight expert views,
9 and we take the median, the 50th percentile from that
10 resulting distribution.

11 MR. PRATO: Okay?

12 MEMBER BLEY: Just a quick question,
13 because two or three slides earlier you talked about -
14 - you ran -- I thought I saw uncertainties on the
15 parameters, but I'm not so sure I'm hearing that any
16 more. You looked at the uncertainties, and then you
17 picked mean values or medians, and ran them through
18 the --

19 MS. MITCHELL: The difference is that the
20 MACCS code itself now has a user-friendly front end
21 that enables a relatively easy parameter uncertainty
22 consideration, so you could put in a range of values,
23 and a degree of belief, and it would sample out of
24 that range and degree of belief, and construct
25 multiple MACCS decks, run them sequentially, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 evaluate the grand averages when you get finished.
2 That model is available for what -- and we intend to
3 exercise it, but we have not, as yet. We intend to do
4 it, but for a point estimate for the stuff that we
5 have done to-date, we have taken that range of values
6 and degrees of belief, and have taken the 50th
7 percentile, and put it in as our point estimate.

8 CHAIRMAN SHACK: But you do the
9 meteorological stuff statistically, and take a mean
10 value.

11 MS. MITCHELL: The meteorological stuff is
12 sampled in a stratified random sampling method. This
13 would be for other things, like the dry deposition
14 velocity, and a whole bunch of other things.

15 MR. PRATO: For each site, we use site-
16 specific population meteorological data. We use an
17 assumed projected relocation dose, and time for the
18 area beyond the evacuation zone during the seven-day
19 emergency period of 5 rem and one day for relocation,
20 and for 2 rem, two days for relocation. Return
21 criteria at Peach Bottom we use .5 rem, which is EPA-
22 specific, and for Surry we used 4 rem and five years,
23 which is EPA-specific. In general, releases are
24 divided into one-hour plumes, as Jocelyn explained
25 previously.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Emergency preparedness. We modeled the
2 protective response afforded by current site-specific
3 emergency preparedness programs to improve realism.
4 We used site-specific evacuation time, time estimates
5 for evacuation of the EPZ. We used a new program
6 called OREMs, which is Oak Ridge Evacuation Model, to
7 model evacuation of the 10 to 20 mile area.

8 We modeled cohort data, such as
9 population, evacuation time, travel speeds, and
10 roadway networks. And the data was used in MACCS-2 to
11 develop consequence estimates. Peer review.

12 MEMBER APOSTOLAKIS: So there was no
13 uncertainties.

14 MR. PRATO: Excuse me, sir?

15 MEMBER APOSTOLAKIS: Were there any
16 uncertainties in these evaluations?

17 MR. PRATO: That's coming up, sir.

18 MEMBER APOSTOLAKIS: Coming up.

19 MR. PRATO: Yes, sir.

20 MEMBER APOSTOLAKIS: Good.

21 MR. PRATO: Okay.

22 MEMBER APOSTOLAKIS: The discussion, or
23 the answer?

24 MR. PRATO: Just a high level discussion.

25 We plan to do an uncertainty analysis, and a peer

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 review in the next calendar year. Okay?

2 Peer reviews. Internal, we've done a
3 couple of staff peer reviews, including the PRA
4 aspects that's used within SOARCA. We have recently
5 went to ACNW and given them an overview of SOARCA, as
6 well as discussed the dose threshold issue. And we've
7 been here a number of times.

8 MEMBER APOSTOLAKIS: Who are the national
9 and international experts? Can you give us a few
10 names?

11 MR. PRATO: We're working on that right
12 now as we speak.

13 MEMBER APOSTOLAKIS: Oh, you haven't done
14 this?

15 MR. PRATO: No, we're working on it. We
16 plan to do it in the next calendar year.

17 MEMBER SIEBER: We are here.

18 MR. PRATO: For Peach Bottom, Peach Bottom
19 accident sequences. The PRA model --

20 MEMBER APOSTOLAKIS: But, you see, when
21 you select the experts, I mean, an expert can come in
22 there. He's an expert say on MACCS. He will look at
23 what you've done. He'd probably say it's very good.
24 Would any of these experts dare question your
25 objectives, the same way this committee is doing? I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 don't know. I doubt it. It's okay. You don't have
2 to answer.

3 MR. PRATO: I have no answer.

4 CHAIRMAN SHACK: Many of George's
5 questions you don't have to answer.

6 MEMBER SIEBER: We are available.

7 MEMBER POWERS: But all of George's
8 questions should be appropriately considered.

9 MEMBER APOSTOLAKIS: It's one of the rare
10 occasions where the fact that I can't hear you is
11 good.

12 (Laughter.)

13 CHAIRMAN SHACK: That's the nicest thing
14 you said about him, George.

15 MEMBER CORRADINI: He's not going to
16 repeat it, either.

17 MEMBER SIEBER: But George didn't hear any
18 of it.

19 CHAIRMAN SHACK: Onward.

20 MR. PRATO: The PRA models indicate a core
21 damage frequency is dominated by seismic events, which
22 functionally work this way out as a long-term station
23 blackout. We did consider fire and flooding, as well,
24 but when we looked at the general damage, the general
25 availability of other systems to be able to mitigate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it, the seismic event had much more widespread damage,
2 and we determined that the seismic -- we evaluated the
3 seismic event, we would bound the other two.

4 MEMBER BLEY: From your statement there,
5 it's functionally a long-term station blackout. It's
6 an earthquake big enough to cause that, but not to
7 damage equipment in the plant?

8 MR. PRATO: The only thing we considered,
9 we assumed that was undamaged was containment and the
10 RCS, initially. Okay? If we had questions about
11 mitigative measures, we did an additional evaluation
12 to determine if the seismic event would result in
13 that, and damage of that equipment.

14 MEMBER STETKAR: Let me follow-up on it,
15 because I was in the Subcommittee meeting, and this
16 was one -- this follows up on something Jack brought
17 up earlier, and something you brought up earlier. We
18 don't have the details of this sequence, but it was
19 described in the Subcommittee meeting. First of all,
20 this frequency seismic event corresponds to something,
21 I think I remember something in the lg acceleration
22 rate, so this is a 7 to 8 magnitude on the Richter
23 scale earthquake.

24 The analysis of this scenario from the HRA
25 perspective takes full credit for operators manually,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 locally, mechanically controlling RCIC flow at the
2 RCIC turbine. Think of that. And it does not include
3 possible seismic effects on population evacuation,
4 emergency response. Is that correct, both of those?

5 MR. PRATO: Correct.

6 MEMBER STETKAR: Okay. Now on the HRA
7 perspective, it seems somewhat optimistic to say that
8 the operator, under these conditions --

9 MEMBER BLEY: It does not take advantage
10 of what people have -- unusual behavior we've seen in
11 people under very, very large earthquakes. And for
12 these people, that are very, very large earthquakes.

13 MR. PRATO: Can I caution us not to get
14 into the details of any of the results from this
15 meeting? It's too preliminary.

16 MEMBER BLEY: Okay. Not results, but do
17 you model people?

18 MR. PRATO: Do we model people, sir?

19 MEMBER BLEY: The thing John was pointing
20 out is, if one did an HRA of human performance after
21 this earthquake, one had better understand the
22 psychological impact of such an earthquake on people.
23 It's not something you can look up in THERP, or SPAR-
24 H, or any of the existing HRA methods. That's what
25 he's saying.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PRATO: Understand.

2 MEMBER CORRADINI: I think that point was
3 made at the Subcommittee.

4 MEMBER SIEBER: Not only the operators,
5 but also the people who live around the plant. They
6 go --

7 MEMBER BLEY: They're not living in houses
8 any more.

9 MEMBER APOSTOLAKIS: The impact of the
10 earthquake on the evacuation itself.

11 MEMBER SIEBER: Yes, bridges down, holes.

12 MEMBER APOSTOLAKIS: Not only just people,
13 but also damage to bridges.

14 MEMBER BLEY: And I think I saw something
15 about half the people taking --

16 CHAIRMAN SHACK: I think we better move
17 on.

18 MR. PRATO: Internal events were all less
19 than 10 to the minus 6, and bypass events were very,
20 very low frequency, much less than 10 to the minus 7.

21 For Surry, the events included a long-term
22 and a short-term station blackout initiated by a large
23 seismic event. And in addition to that, we had an
24 inter-system LOCA, a LOCA on a low pressure injection
25 system, and we had a steam generator tube rupture.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 SBO events are due to seismic, flood, and fire
2 initiators, and are modeled as seismic events, again
3 for the same reason, because there was much more
4 widespread damage, and a lot more equipment that was
5 unavailable.

6 MEMBER CORRADINI: So in a similar fashion
7 as you said in Peach Bottom, the seismic encompasses
8 what might have been a fire or flood event?

9 MR. PRATO: That's correct. It bounds it.
10 The IS LOCA and steam generator tube rupture are due
11 to random equipment failure, and then by a number of
12 operator errors.

13 This is a sample of sequences high level,
14 but hopefully it will give you a feel for how this
15 process was implemented. This sample sequence is a
16 loss of a vital AC bus. This sequence was selected
17 and assessed for demonstration purposes only.

18 MEMBER BLEY: Can I reflect back on your
19 last two view graphs? If I got it right, in general,
20 we're saying we're using, although you're not doing it
21 here, a cutoff of 10 to the minus 6 per year on
22 sequences, and yet our dominant sequence is about 10
23 to the minus 6 per year. Is that right?

24 MR. PRATO: That's correct.

25 MEMBER BLEY: Have I got the story right?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PRATO: Rich, that's correct, isn't
2 it?

3 MR. SHERRY: Yes.

4 MEMBER BLEY: That seems troublesome, but
5 go ahead.

6 MR. SHERRY: I guess I don't understand
7 your question. In what sense were you referring --

8 MR. PRATO: I understand his point.

9 MEMBER BLEY: If the biggest thing there
10 is is about one times 10 to the minus 6, and you don't
11 look at anything else, it makes me uncomfortable that
12 there might be other things that would add up to
13 substantially more than that.

14 MR. SHERRY: In the external events, or
15 internal events, or across the board?

16 MEMBER BLEY: Any events.

17 MR. SHERRY: I think I can say fairly
18 confidently for the internal events, that we probably
19 captured the risk dominant sequences for the PWR for
20 Surry. Okay? And I suspect -- well, I really can't
21 make that statement for Peach Bottom.

22 For external events, it's harder to make
23 that claim because we, essentially, obtained our
24 sequences by looking at older studies. We really
25 didn't use up-to-date -- we didn't have up-to-date

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 seismic PRA or other external event PRA results for
2 these plants, so we essentially looked at past
3 studies, like NUREG-1150, whatever information we
4 could get from the IPEEEs, and made judgments about
5 what the dominant sequence characteristics would be.
6 And, typically, station blackout was a typical
7 frequency dominant sequence for seismic events.

8 CHAIRMAN SHACK: There's references to
9 SPAR external events models. Just what are they?

10 MR. SHERRY: For a limited number of
11 plants, there have been a number of SPAR models which
12 have been upgraded to include, to a limited extent,
13 external events. Seismic --

14 CHAIRMAN SHACK: Does that include Surry
15 and Peach Bottom?

16 MR. SHERRY: Yes.

17 CHAIRMAN SHACK: So you do have a seismic
18 PRA of some sort.

19 MR. SHERRY: Except that these haven't
20 really been validated in any sense. Okay?

21 MR. PRATO: Okay?

22 MEMBER BLEY: Go ahead.

23 MR. PRATO: As I said, sequence was
24 selected and assessed for demonstration purposes as
25 not within the scope of SOARCA, because the CDF is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 really less than 10 to the minus 6. The MELCOR
2 analysis showed that this event can be mitigated.
3 Okay? So even though the sequence indicated that core
4 damage can be achieved, we were able to mitigate this
5 event.

6 MEMBER APOSTOLAKIS: I don't understand
7 this. You're showing us an analysis of a sequence
8 that should have been screened out?

9 MR. PRATO: Correct, sir.

10 MEMBER APOSTOLAKIS: And the purpose of
11 this is?

12 MR. PRATO: It's just for demonstration
13 purposes. When we first started up SOARCA in the
14 process, and working with MELCOR, we selected a
15 sequence, and we performed some analysis on it. And
16 we kept it because we felt that it had demonstration
17 value.

18 MEMBER APOSTOLAKIS: But this is not going
19 to convince us that --

20 MR. PRATO: It's not intended to try to
21 convince you of anything, sir. Okay?

22 MEMBER CORRADINI: Well said.

23 MEMBER STETKAR: Nor could it ever.

24 (Laughter.)

25 MEMBER APOSTOLAKIS: Very well put, sir.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. YEROKUN: If I may try to fend that
2 off. For the purpose of this discussion, we said
3 earlier we're not prepared to discuss the preliminary
4 results of this, sorry. So we've gone through the
5 process, and all these technical steps. By the way,
6 my name is Jimi Yerokun. But for the benefit of the
7 Full Committee, we thought it would be appropriate to
8 at least give you some demonstration of how this
9 process works through, some hypothetical sequence, and
10 go through the whole analysis. And this is one
11 example where it's not within the scope of the
12 analysis, but it portrays how we step through using
13 some other sequences.

14 MEMBER APOSTOLAKIS: But you have produced
15 results of this sequence?

16 MR. PRATO: Yes, sir.

17 MEMBER APOSTOLAKIS: And you're not going
18 to show them?

19 MR. PRATO: Well, we show you generally
20 what the outcome is. I'm going to go through that,
21 but we don't have the graphs, and the slides, and
22 everything that went with it. No, sir.

23 MEMBER APOSTOLAKIS: Okay.

24 MR. PRATO: Okay?

25 MEMBER APOSTOLAKIS: All right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PRATO: The initiator was a loss of
2 Division IV DC power resulting in a scram, MSIV
3 closure, and containment isolation, a RCIC auto-
4 started, and one CRD pump was active and still
5 available. The initial operator actions, the load
6 shed to maximize duration of the DC power, they
7 maximize the flow of the single CRD pump. The CRD
8 pump at this facility has a range of 110 to 180
9 gallons per minute depending on RCS pressure, but that
10 110, there is some throttling involved, so they go
11 down and they open it up, and that 110 basically turns
12 into 140 at normal RCS pressure.

13 They depressurized the RCS in about an
14 hour and a half, which with the CRD and RCIC flow they
15 had to secure the CRD from four to seven hours to
16 prevent reactor pressure vessel over-fill. The
17 capacity of make-up was sufficient to prevent core
18 damage, even though core damage was predicted by the
19 Level 1 PRA.

20 MEMBER BLEY: I take it this plant's Level
21 1 PRA did not take advantage of the CRD pumps?

22 MR. PRATO: Sir, I'm -- that's right on
23 the next slide.

24 MEMBER BLEY: Oh, sorry.

25 MR. PRATO: Sufficient injection

1 capability, there was sufficient injection capability
2 to prevent core damage. The SPAR didn't credit the
3 CRD for coolant makeup. Reactor pressure vessel
4 depressurization, and maximization of CRD flow are
5 important to operator actions to optimize recovery.
6 One other thing that we didn't consider, that wasn't
7 considered was standby liquid control, was also
8 available for high pressure injection at about 50
9 gallons per minute. And battery duration was
10 determined to be important for RCIC operation and
11 instrumentation.

12 MEMBER BLEY: Let me interrupt you again.
13 I'm sorry for so many. You thanked the utilities for
14 cooperating. Did they cooperate in the performance of
15 the analysis, or in allowing their plant and their PRA
16 to be used?

17 MR. PRATO: They were involved in the
18 performance analysis. We did make a site visit. They
19 did review our sequence truncation and verified it,
20 and we had some exchanges on that. We added one or
21 two, and they've taken one away.

22 MEMBER BLEY: This one had a lot of human
23 actions. Were they involved in the quantification of
24 the human actions?

25 MR. PRATO: They were involved in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 mitigative measures analysis. They provided a lot of
2 input and insights.

3 MEMBER BLEY: I mean, on things like
4 whatever you came up with on -- or is that as shedding
5 load and that sort of thing on the DC part of what
6 you're talking about?

7 MR. PRATO: We had a lot of procedures for
8 this facility, and we, basically, assessed -- yes.

9 MEMBER BLEY: And I know you said this
10 earlier, I just want to confirm. For the Level 1
11 PRA, you used the SPAR PRA. Is that right? I mean,
12 you used that as the basis for coming up with your
13 scenario.

14 MR. PRATO: That's correct.

15 MEMBER BLEY: Okay. Do those now really
16 have a thorough coupling of all the dependencies among
17 systems in those models? I know not too long ago they
18 did not.

19 MR. CHEOP: We have the full set of fault
20 trees, and event trees to couple all different
21 dependent failures, and human errors.

22 MEMBER BLEY: So that is pretty thorough
23 and the utilities will have --

24 MR. CHEOP: That's correct.

25 MEMBER BLEY: Okay. Thanks.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PRATO: Okay. And that brings us to
2 the conclusion on the sequence sample. The only other
3 thing left is the report on the status of the latent
4 cancer fatality reporting. The history behind this is
5 one of the key objectives of SOARCA is risk
6 communication, and for the non-NRC staff, risk
7 communication in this context does not refer to
8 communicating PRA information. It's more general.
9 It's a methodology of reporting very technical
10 information, and coming up with a unified
11 understanding of the information, coming up with a
12 single outcome of the information. And, initially, we
13 proposed to do a range of doses, and we felt that a
14 range of doses conflicted with the risk communication
15 aspect of SOARCA, which is one of our more important
16 criteria, so what we decided to do is we decided to
17 take a look at other options for reporting latent
18 cancer fatalities. And we're putting together a
19 Commission paper to inform the Commission, and right
20 now what you see here is we have three options. Very
21 recently, we had other considerations thrown at us.
22 The three options we are considering on this slide is
23 range of threshold, linear no-threshold, or an
24 estimated point value based on a Health Physics paper.
25 We are also looking at other things, like just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reporting dose. We are looking at potentially
2 truncating distance. There's a number, a variety of
3 variations, and our overall objective is to come up
4 with one single answer for each sequence at each site,
5 instead of coming up with multiple.

6 MEMBER SIEBER: These are very
7 conservative. Right?

8 MR. PRATO: Yes. This process is still
9 ongoing. We believe that it's going to come to
10 conclusion relatively in the near future, but right
11 now, we're still in the final development stage of the
12 Commission paper.

13 MEMBER SIEBER: I was thinking if these
14 are realistic, I'm in trouble.

15 MR. PRATO: Excuse me, sir?

16 MEMBER SIEBER: If these are realistic,
17 I'm in trouble after of SCAT scans.

18 MR. PRATO: Me too. Me too. That
19 completes the presentation. Any other questions?

20 MEMBER BLEY: As you left that last one,
21 what kind of a point value are you leaning toward?

22 MR. PRATO: We are not leaning towards
23 anything. The staff is working out the options, and
24 we will probably evaluate the options. And we may
25 make a recommendation, we may let the Commission

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 decide. The final form of this Commission paper has
2 not been decided yet.

3 MEMBER BLEY: Have you got a
4 recommendation from the other Committee?

5 MR. PRATO: The ACNW?

6 MEMBER BLEY: Yes.

7 MR. PRATO: The ACNW did not give us a
8 formal recommendation. They asked us to consider
9 dose, and they asked us to consider risk. We are
10 looking at them as potential options.

11 MEMBER BLEY: Thank you.

12 CHAIRMAN SHACK: Any more questions?

13 MR. PRATO: Any questions, anybody? Thank
14 you.

15 CHAIRMAN SHACK: Thank you very much. Mr.
16 Lymen, I think you wanted to make some remarks.

17 MR. LYMEN: Yes, if I may.

18 (Off the record comments.)

19 MR. LYMEN: Can you hear me? I
20 appreciate, as usual, the opportunity to make a few
21 remarks here. And, actually, when I walked in and
22 heard the opening discussion, I was wondering if it
23 was even necessary, because I think many of the
24 comments I heard from the Committee already reflect a
25 lot of our concerns.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I'd say the bottom line is that my
2 organization, the Union of Concerned Scientists, is
3 very supportive of an authoritative and independent
4 study that would approve the technical credibility and
5 accuracy of analyses of consequences of severe
6 accidents. And two issues, in particular, is one, can
7 protective actions be improved based on better
8 information, and can better siting decisions be made
9 in the event that new reactors are actually located
10 around the country, which is going to become
11 increasingly important. But our view, at this point,
12 is that SOARCA is not on track to fulfill this role,
13 and that's because the political goals from the outset
14 threaten to overwhelm the technical part.

15 What is the real point of SOARCA, it seems
16 to be knocking down a strawman, which was the 1982
17 CRAC2 study. And as you already discussed, a lot of
18 the public rationale for SOARCA seems to ignore the
19 fact that NRC staff, and contractors, and licensees
20 have been severe accident analyses for more than 20
21 years in the interim, including NUREG-1150, source
22 term is based on MELCOR, at least its initial
23 formulation, and are commonly used in regulatory
24 applications. So there is a whole body of work since
25 then, and to say we haven't done anything since 1982

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 really makes -- exaggerates the importance of this
2 project. It's really an incremental improvement over
3 what's already been done.

4 And looking at some of the statements that
5 have been made about it, the SOARCA project may show
6 that a large early release may not credibly exist, for
7 example, raises the concern that the real point is to
8 rehabilitate severe accident analysis to eliminate the
9 most risk-significant sequences on the basis that
10 they're low probability.

11 Now one concern we have is the
12 inappropriate focus on risk communication. That has
13 been part of this project, in the forefront from the
14 beginning. Results will be presented documented risk
15 communication techniques to achieve public
16 understanding, which is a little Orwellian in my view.
17 The fact is, a risk communication plan has already
18 been developed for this project years before the
19 study's results are even going to be available, and
20 that raises suspicions if the PR aspects of this
21 project are predominant. And we say really, "Just the
22 facts, ma'am." If you really want to achieve public
23 understanding, the best way to be clear about all your
24 assumptions and arguments in a step-wise fashion, so
25 that the impacts of the various changes to previous

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 studies, like CRAC2 or NUREG-1150, can be readily
2 observed and understood. And we would strongly advise
3 against bundling everything you're doing to a black
4 box and spitting out a best estimate, and forcing the
5 public to unravel, to the extent we can, exactly
6 what's been going on here. And I think the discussion
7 earlier makes clear that there is a lot going to this
8 recipe, and it would be better if we did understand
9 those changes incrementally so we can see what are the
10 significant differences.

11 Now with regard to risk communication,
12 going into a little history, there's a reason why
13 CRAC2 made the front page of the "Washington Post" in
14 1982, was not because it was necessarily so
15 frightening, it was because NRC was originally only
16 planning to release the mean values across the
17 meteorological distribution that is generated by these
18 codes, and someone leaked the files that showed the
19 maximum, or peak consequences for in worst case, where
20 the scenarios were evaluated, and it was that fact, I
21 think, that led to the reason why it got as much press
22 as it did, which should be a lesson, that if you're
23 open about what you're doing, you don't try to parse
24 the results for public perception that you're going to
25 be better off in the long run.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 This excessive secrecy marking this
2 project, which is a concern. The original SECY and
3 SRM are still being withheld from the public in their
4 entirety, despite the objection of one of the
5 Commissioners. And many of the meetings discussing
6 SOARCA have been closed, in some cases with,
7 apparently, inappropriate rationales. And one example
8 was the ACNW meeting a few weeks ago where I was
9 closed on the basis that it would be pre-decisional,
10 meaning it would have a severe impact on a regulatory
11 decision, except that SOARCA, by definition, has no
12 regulatory application, and is a project plan, so it
13 looked pretty ridiculous to say that that was pre-
14 decisional with regard to any regulatory decision, and
15 the meeting was opened after that was challenged.

16 MEMBER APOSTOLAKIS: The SRM is not
17 public?

18 MR. LYMEN: No. And I asked for it. I
19 sent a letter and was told it's sensitive.

20 Now with regard to SOARCA, there are good
21 things. And to the extent MELCOR, accident
22 progression and source term development can be updated
23 using reactor-specific data, input decks and
24 experimental insights that have been achieved through
25 Phebus and other severe accident studies, that's a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 good thing. And understanding, if there is more data
2 to better understand containment performance, and I'm
3 not sure there actually is, but to the extent there
4 is, and that can be fed in, that seems to be a big
5 uncertainty in my review of NUREG-1150, and the way
6 expert elicitation was used to gloss over things that
7 weren't known about containment performance. That
8 would be very beneficial.

9 And, again, if you can model protective
10 actions better and with more accuracy, and you can
11 come up with better results in what you do, those are
12 good. But one of the bad things is what appears to be
13 a totally inconsistent way of truncating these low CDF
14 sequences, and I think if you're screening out five,
15 or even 10 percent of a CDF, that is not an
16 insignificant chunk. In fact, if you look at what the
17 LERF would be for those plants, you can see that it
18 would be less than 10 percent, usually, so you would
19 be clearly taking a big bite out of a LERF. And it
20 seems like external events are being treated
21 inconsistently, low powering shutdown risks are being
22 treated at all, which is absurd, because it's the
23 shutdown risk that may dominate early releases if the
24 containment is open. And it just seems like the way
25 the truncation is being done, you're introducing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 round-off error that will round-off and eliminate
2 exactly the things that you should be looking at, and
3 it's absurd, circular reasoning. If you take out the
4 events that would lead to most severe consequences and
5 you find the consequences are less than you thought,
6 that's circular reasoning.

7 Also, credit for unregulated measures,
8 like SAMGs, seems to be inappropriate. I think that
9 what I heard earlier is that these have been
10 demonstrated, accidents have been demonstrated to be
11 preventable where containment failure or whatever
12 through SAMGs. I don't think SAMGs have ever
13 demonstrated anything. Those are voluntary measures,
14 and they're not regulated, not tested in any
15 verifiable way, and they should not be credited, at
16 least, to the extent they are. If, again, as I heard
17 earlier, both the results with and without SAMGs have
18 been evaluated, and present both of those to the
19 public, and explain why you believe the SAMG one is
20 more credible.

21 Finally, the "ugly" is the use of dose
22 thresholds in direct contradiction to recommendations
23 of the BIER VII Committee, among others, and I won't
24 belabor this point, but NRC is going to have to do a
25 lot of work to justify why this recommendation should

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 be ignored in the study, if it goes in that direction.
2 And I think that would severely undermine its
3 credibility.

4 Now what was so bad about CRAC2? Well, I
5 went back and looked at CRAC2, and it seems like it,
6 obviously, isn't applicable today, but the reasons are
7 different from what we've heard. For instance, CRAC2
8 uses 1970 census data. It actually assumed the entire
9 EPZ would be completely evacuated within six hours
10 after the warning was issued, when current evacuation
11 time estimates are generally much longer than that, so
12 it was actually more conservative than appropriate in
13 some cases. It assumed medical treatment for all
14 victims of acute radiation exposure would be
15 aggressive. It used a BIER III correlation for cancer
16 fatalities, which is out of date, and underestimates
17 by a factor of four, compared to ICRP-60. And it only
18 sampled a handful of weather sequences, because it at
19 that time, it took a long time to run a weather
20 sequence. Today, you can run an entire year's worth
21 of weather times 16 wind directions in a matter of
22 minutes, so there's no reason to use sampling any
23 more. You can use the entire year's worth of weather
24 data, and you get a much larger number of results for
25 your consequence distribution. I found comparing that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 sampling only 100 weather sequences compared to the
2 full year underestimates peak consequences by about 30
3 percent.

4 So we've been using MACCS-2 for a long
5 time, and find, in particular for Indian Point, the
6 CRAC2 was -- actually gives fairly good results
7 compared to what you can do with NUREG-1465. And we
8 used NUREG-1465 as a starting point for source terms,
9 because it is recommended, has been vetted, expert
10 panel reviewed it for applicability to high burn-up
11 fuel only a few years ago, and basically confirmed it
12 was appropriate. It's being used for design-basis
13 applications by a number of licensees, but it's not
14 being used for any severe accident applications, even
15 though it does actually cover severe accidents. And
16 the question is why? That's generally because if you
17 use it for design-basis applications, it gives the
18 licensees a benefit, while actually make things worse
19 if you look at the full severe accident term, so just
20 showing the source term that I used based on NUREG-
21 1465 truncated after about two hours, so there's a
22 tail that we need to consider, comparing that to,
23 let's say, what Entergy used derived from MAAP for
24 Indian Point in their license renewal application, a
25 source term which has a lot of odd things about it,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 22.9 hour duration, and release fractions which are
2 generally lower in most categories than for NUREG-
3 1465. And the consequences are dramatic in
4 comparison, and so the results within 50 miles, the
5 mean consequences for Indian Point using the 2034
6 population density are 860 early fatalities, mean
7 latent cancer is 38,500, the peak early fatalities
8 70,800, peak latent cancer is almost 700,000. So
9 since NUREG-1465 corresponds to a low pressure event
10 like large break LOCA, you can see why staff from
11 these results may not want to consider large break
12 LOCAs, if they can avoid it.

13 So my conclusions are if the main impact
14 of SOARCA is to reduce severe accident consequences by
15 eliminating consideration of large early releases,
16 that's circular reasoning. The more reasonable
17 approach would be to group sequences, not to truncate
18 at the CDF level, to truncate at the Level 2 so that
19 you have the frequencies of the various release
20 classes, and then do your screen at that point, which
21 was an approach that was rejected from the beginning.
22 The inclusion of thresholds without authoritative
23 technical justification is going to undermine the
24 credibility of the results.

25 And finally, to get an apples-to-apples

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 comparison, the way to do that is when changes are
2 made, that people understand the impact of each
3 particular change, and not simply the entire package
4 handed to you without a clear understanding of what
5 went into it. So without that, we can't understand
6 what's due to better data, improvement of the codes,
7 better technical understanding, what's due to simply
8 changing the ground rules by what accidents or
9 sequence are and aren't considered. So my
10 recommendation, I'm glad to hear there's going to be
11 an external peer review, that is one of my
12 recommendations, and I believe the best way to -- for
13 the credibility of the study to be insured is to
14 publish the results in a peer review journal. So with
15 that, I thank you.

16 CHAIRMAN SHACK: Any questions for Mr.
17 Lymen?

18 MEMBER STETKAR: Can we get a copy of the
19 slides?

20 MR. LYMEN: Absolutely.

21 MEMBER POWERS: Ed, let me ask a question.
22 The Health Physics Society seems - and I'm being
23 cautious in what I say - try to reproduce what they've
24 said, but, in effect, they've said look, you get doses
25 below about 100 millirem per year, don't try to do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 anything with it, because it's difficult to calculate
2 down there, it's hard to measure things and whatnot.
3 So for the purposes of assessing risk, cut it off at
4 100 millirem for something like that. I mean, what's
5 your take on all that?

6 MR. LYMEN: Well, my take is that if
7 you're going to make a radiation protection
8 recommendation, that it has to be based really on the
9 most authoritative sources. And the Health Physics
10 statement is not really supported by peer review
11 references, as was BIER VII. BIER VII had the
12 opportunity to consider, and they did at length, the
13 literature supporting the notion for thresholds, and
14 like you said, it wasn't. But the other thing to
15 consider is that well, if you're talking about
16 uncertainties and low dose, that actually does
17 coincide with the uncertainties in doing atmospheric
18 modeling beyond a certain radius, so to avoid having
19 to say you're using a dose threshold, a better
20 approach would simply be to say that we don't think
21 the MACCS-2, the validity of the code is really -- is
22 that useful beyond 50 miles radius, correspondence
23 between lower doses and longer distances, so that
24 would be a way to dance around what the actual --

25 MEMBER POWERS: Yes, but that's another

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 take. By the time you get out there, but I was just
2 interested in the view on the Health Physics.

3 The other thing they emphasize in BIER VII
4 in their view, is there is a wide perception that
5 somehow linear no-threshold comes from people not
6 knowing how you draw a straight line, they know it's
7 based on a biochemical model. And you really can't
8 contest it unless you have a contesting biochemical
9 model. And you struggle heroically to come up with a
10 biochemical model that for low LET radiation could
11 yield a threshold, because it involves double breaks
12 to the DNA strands, which are not easily repaired.
13 And the analogy drawn to chemical effects is
14 inappropriate, because chemical effects are all single
15 breaks to DNA strands. And so, yes, BIER VII is a
16 fairly authoritative, but now you get down to the
17 practicality of doing calculations. And like you say,
18 I mean, it seems to me the argument to make, one
19 argument certainly you could appeal to Health Physics,
20 but the other one is, there's a point where MACCS just
21 breaks down as a useful computation --

22 MR. LYMEN: Right. And that may not
23 coincide with the dose threshold you're talking about.
24 That's the only thing. But right, I mean the
25 conclusion of BIER VII was that a single DNA lesion

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 can lead to cancer, and on that basis, there is no
2 model that would justify --

3 MEMBER ARMIJO: Well, that kind of flies
4 in the face of a lot of research at the cell level
5 that directly refutes that assumption, that one single
6 lesion instantly leads, or without doubt will lead to
7 cancer. And I've been trying to read up on this work
8 by --

9 MEMBER POWERS: BIER VII didn't say that.

10 MEMBER ARMIJO: Well, that's what I heard
11 from the --

12 MEMBER POWERS: It's a probabilistic
13 argument.

14 MEMBER ARMIJO: Well, I think the -- I
15 guess I'm more impressed by experimental work. I've
16 been reading some of the work of Dr. Mitchell of AECL
17 and others, and I think there's just a preponderance
18 of information that tells us that a threshold does
19 exist. And I think it's -- to say we mustn't think
20 about it, we mustn't talk about it, because that's
21 perhaps politically incorrect, just bothers me.

22 MR. LYMEN: No, that's not what I'm
23 saying. Think about it, talk about it, but support it
24 with argument. And in the context of radiation
25 protection, it really has to be weight of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 evidence, and if you don't -- to those who believe the
2 data reads that radiation protection standards and
3 models should be changed, there simply isn't enough of
4 a coherent body of evidence to support that change.
5 And BIER VII, had the opportunity to say that, and
6 they rejected it, so at this point, it does not make
7 sense to include a threshold in these models, and it
8 is going to undermine the credibility of the result,
9 a three-year study and all the effort that's going
10 into all the various aspects of it should not be
11 undermined on that point.

12 CHAIRMAN SHACK: Further questions or
13 comments?

14 MEMBER POWERS: It's also fair to say that
15 BIER VII did a comprehensive examination of the
16 biochemical evidence. And, interestingly, they came
17 back saying that there's pretty good evidence that
18 there's no threshold in the case of neutron damage.
19 And it's only the LET, Low Energy Transfer, radiation
20 where this uncertainty exists.

21 MR. LYMEN: Right, because high LET
22 radiation, high LET particle can cause multiply
23 damaged sites.

24 CHAIRMAN SHACK: Okay. Well, thank you
25 very much.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. LYMEN: Thank you. I appreciate it.

2 CHAIRMAN SHACK: We're going to take a
3 break now. Thank the staff again for their
4 presentation. Good discussion. Take a break until
5 3:15. We're off the record.

6 (Whereupon, the proceedings went off the
7 record at 3:01:19 p.m.)

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

CERTIFICATE


This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission in the matter of:

Name of Proceeding: Advisory Committee on
Reactor Safeguards



Docket Number: n/a

Location: Rockville, MD

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and, thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.



Charles Morrison
Official Reporter
Neal R. Gross & Co., Inc.



A

AREVA

***Enhanced Option III Long Term Stability Solution
and
DIVOM Methodology using RAMONA5-FA Code***

***Presentation to the
Advisory Committee on Reactor Safeguards***


December 6, 2007

Presentation Roadmap

- > **Overview of Option III Detect & Suppress Solution**
 - ◇ **Part 21 Report and recovery**
 - **Short Term: Cycle-Specific DIVOM**
 - **Long Term: Include MELLLA+**
- > **The Enhanced Option III Solution**
 - ◇ **The single (few) channel hydraulic instability exclusion**
- > **Codes and Methods supporting EO-III**
- > **Questions, Discussions, and Conclusions**

Overview of Original Option III Solution

- > Detect & Suppress
- > Scram to Protect CPR Safety Limit



Overview of Original Option III Solution

- > System designed to suppress oscillations at a preset amplitude to protect CPR safety limit**

- > A relationship between oscillation amplitude and CPR response is required → DIVOM curve**
 - ◇ Based on relative CPR response versus relative oscillation magnitude**

 - ◇ Calculated with Time-Domain codes**

 - ◇ Originally a generic DIVOM is applied**

Original Option III Problem and Resolution


- > **Part 21 Report: Generic DIVOM curve is non-conservative**
 - ◇ Occurs at high radial peaking and high power-to-flow ratio
 - ◇ DIVOM slope may reach as high as double the generic value

- > **Resolution**
 - ◇ **Short Term:**
 - Cycle-specific DIVOM calculations instead of generic
 - Follow BWROG procedure

 - ◇ **Long Term:**
 - Improved solution not susceptible to DIVOM problems
 - Extend applicability to MELLLA+


 - ◇ **AREVA long term solution is the Enhanced Option III**

Example of Well-Behaved DIVOM Curve Calculated with RAMONA5-FA




Examples of Irregular DIVOM Curves

Initial Perturbation: 1.0% Regional and 1.0% Global




Examples of Irregular DIVOM Curves

Initial Perturbation: 1.0% Regional and -2.0% Global




Examples of Irregular DIVOM Curves

Initial Perturbation: 0.5% Regional and 0.0% Global



Examples of Irregular DIVOM Curves

Initial Perturbation: 1.0% Regional and 2.0% Global






Enhanced Option III


Applicability Domain of Original Option III

- > Armed region where instabilities are possible
- > Not qualified for MELLLA+




Applicability Domain of Enhanced Option III

- > **DIVOM problems in the high power/flow corner**
- > **Exclusion region enables extension to MELLLA+**



Applicability Domain of Enhanced Option III

- > **Conservative calculation of exclusion region using STAIF frequency domain code**



Review of the DIVOM Challenge

- > **DIVOM curve is fairly linear and well-bounded under**
 - ◇ **Conditions:**
 - Power, flow, fuel types, loading and control rod patterns...
 - Initial perturbation
 - ◇ **Modeling methods:**
 - CPR correlation, steady state simulator
 - ◇ **Transient code**
 - ◇ **Exception: Mixed mode oscillations**

- > **Irregular DIVOM curves with elevated slopes observed when single channel decay ratios exceed unity**

Elements of the Enhanced Option III Solution

- > **Define new boundary of applicability of the Option III Solution**
 - ◇ **Exclude conditions for unstable single channel interference**
 - ◇ **Imposing this restriction assures robust DIVOM curves**
 - **Fairly linear**
 - **Bounded slope**
 - **Invariant regardless of initial perturbation**
- > **Protect the single channel instability exclusion region (immediate scram upon entry)**
- > **Maintain all Detect & Suppress functions of Option III outside the channel instability exclusion zone**
- > **Define cycle-specific DIVOM curve for reactor states with all channels stable**

Transient System Code for DIVOM: RAMONA5-FA

- > Perform Well-Defined Numerical Analyses to Provide Data for DIVOM Relationship**

- > Studsvik-Scandpower RAMONA5-2.4 → RAMONA5-FA**
 - ◇ Thermal-hydraulic balance equations unchanged**
 - ◇ Modal Kinetics (similar to STAIF)**
 - ◇ Updated Closing Relations & Correlations (similar to MB2)**
 - ◇ Benchmarking & Sensitivity**
 - Integral Benchmarks**
 - Separate Effects**
 - Hydraulic loop testing**

Conclusions

Advantages of Enhanced Option III

- 1. Maintains the basis of the original Option III solution with many years of operational experience**
- 2. Clear physical basis for the proposed enhancements**
- 3. Channel exclusion region based on approved frequency domain stability code (STAIF)**
- 4. Small channel exclusion region should not interfere with normal operational flexibility**

Conclusions

Advantages of Enhanced Option III

- 5. Amplitude trip setpoint will be not be restricted by single channel interference leading to elevated DIVOM slope**
 - ◇ Reduces the probability of spurious scram due to the period-based algorithm response to LPRM noise
 - ◇ DIVOM curve will always be regular and bounded
- 6. The enhanced solution covers extended flow operating domains up to MELLLA+**
- 7. Explicitly addresses single channel instabilities**
- 8. Simple application procedure**

Thank You!



Passive System LOCA Frequencies for Risk-Informed Revision of 10 CFR 50.46

**Robert L. Tregoning
Lee Abramson
NRC\RES**

**Paul Scott
Battelle**

**Advisory Committee on Reactor Safeguards
December 6, 2007**



LOCA Frequency Reevaluation

- Commission direction (SRM-02-0057)
 - "The staff should provide the Commission a comprehensive 'LOCA failure analysis and frequency estimation' that is realistically conservative and amenable to decision-making ... with appropriate margins for uncertainty ..."
 - "The staff should use expert elicitation to converge (whenever possible) service-data and PFM results ...".
- ACRS request
 - Letter stating that NUREG-1829 sufficiently meets the Commission direction and should be published

Executive Summary


- Formal elicitation process used to estimate generic BWR and PWR passive-system LOCA frequencies associated with material degradation.
- Panelists provided quantitative estimates supported by qualitative rationale in individual elicitations for underlying technical issues.
 - Generally good agreement on qualitative LOCA contributing factors.
 - Large individual uncertainty and panel variability in quantitative estimates.
- Group results for the LOCA frequency distribution parameters (i.e., 5th, 50th, 95th, and mean) determined by aggregating panelists' estimates.
 - Geometric mean aggregated results are consistent with elicitation objective and structure; they are also generally comparable with NUREG/CR-5750 estimates.
 - Alternative aggregation schemes can result in higher LOCA frequencies.

December 6, 2007

Advisory Committee on Reactor Safeguards

Page 3 of 12

Total LOCA Frequencies



- Individual results adjusted for overconfidence and aggregated using geometric mean
- 95% confidence bounds (i.e., error bars) reflect diversity among panelists
- Differences between medians and 95th percentiles reflect individual panelist uncertainty

December 6, 2007


Advisory Committee on Reactor Safeguards

Page 4 of 12

Lognormal Fit to LOCA Frequency Parameters

- Fits to 95th percentile and mean provide a reasonable representation
- Less than 30% error in the median
- 50% error or less in 5th percentile, except for BWR-5 case


Type	Cat.	5 th (% Error)	50 th (% Error)
PWR	1	8	5
PWR	2	-42	-25
BWR	5	200	28
BWR	6	7	20



Analysis of Elicitation Responses: Sensitivity Analyses

- Determine effect of assumptions on the LOCA frequency estimates
- Sensitivity analyses conducted in five broad areas of analysis.
 - Determination of calculated means
 - Overconfidence adjustment
 - Correlation structure of panelist responses
 - **Aggregation of individual results**
 - Measurement of panel diversity

Aggregation of Individual Results: Mixture Distribution vs. Geometric Mean



- Group estimates can be significantly affected by aggregation method!

December 6, 2007

Advisory Committee on Reactor Safeguards

Page 7 of 12

Internal and External Reviews

- NUREG-1829 has been extensively reviewed
- Expert panel
 - Individual responses
 - Calculations and analysis
 - General qualitative and quantitative findings and conclusions
- External peer review (decision analyst and statistician)
 - General elicitation structure
 - Analysis procedure and framework
 - Aggregation and sensitivity analyses
 - Review reports are publicly available
- ACRS review
 - Elicitation process, structure, analysis, results, and application for 50.46
- Internal staff review
 - Analysis procedure and framework, aggregation and sensitivity analyses, and application to 10 CFR 50.46
- Public review and comment

December 6, 2007

Advisory Committee on Reactor Safeguards

Page 8 of 12

Public Comment Schedule and Results

- Draft NUREG-1829 issued June 2005
- Public comment period closed November 2005
- Identified 29 comments from public
 - Bill Galyean (elicitation panelist)
 - Penn State University – Professor Larry Hochreiter
 - Palo Verde Nuclear Power Plant staff
 - BWR Owners Group
 - Westinghouse Owners Group
 - Nuclear Energy Institute
- NRR staff provided additional comments in parallel with public comment period
- In total, 101 separate comments were identified

Public Comment Summary

- Public comments identified additions and clarifications to improve the exposition and facilitate the use of NUREG-1829
- No comments presented a significant challenge to the appropriateness of the objective, elicitation approach, analysis, or results
- Most passionate controversy remains the proper method for aggregating individual estimates to produce group estimates

Public Comment Example: Comparisons with Service Experience

- NUREG-1829 SB LOCA estimates too high
 - Approximately 1 order of magnitude higher than NUREG/CR-5750 results
 - Implies one SB LOCA every 4 years for US reactor fleet
 - Using NUREG-1829 estimates in existing PRAs would lead to unwarranted impacts that are not supported by operational experience

- Related comments: GC12, 7-1, 7-3, 7-7, 7-8, 7-9

Comparisons with Service Experience: Response

- NUREG-1829 SB LOCA and NUREG/CR-5750 estimates are generally consistent
 - SGTR estimates are virtually identical
 - BWR SB LOCA estimates are similar (within 20%)
 - PWR SB LOCA estimates are higher (by approximately a factor of 5)
- NUREG-1829 SB LOCA estimates are consistent with operating experience
- Differences that do exist are supported by the quantitative estimates and qualitative rationale provided by panelists
- Resulting NUREG modifications
 - Provided separate PWR SGTR and SB LOCA estimates (Section 7.8)
 - Provided more extensive comparisons between NUREG-1829 estimates and historical results (Section 7.9)
 - Compared estimates with operational experience (Section 7.10)

Seismic Considerations for TBS

Presented to

The Advisory Committee on Reactor Safeguards

Presented by:

Nilesh Chokshi, Dep. Dir. DSER/NRO, ncc1@nrc.gov

S. Khalid Shaikat, DE/RES, sk1@nrc.gov

Gery Wilkowski, Emc2, gwilkowski@emc-sq.com

Project Team:

C. Carpenter, J. Fair, C. Greene, G. Hammer, A. Hiser, M. Kirk, A. Wilson, NRC
G. DeGrassi, BNL, J. Johnson, JJJ and Associate, R. Olson, Battelle

December 6, 2007

Outline of the Presentation

- **Basic Objective**
- **Approach**
- **Key Assumptions**
- **Results**
- **Draft Rule and Questions**
- **Public Comments and Response to Questions**
- **Current Status and Future Activities**

Objectives and Approach

- **Objectives**
 - To examine likelihood and conditions that would result in seismically-induced breaks incompatible with the proposed TBS.
 - Provide key considerations to facilitate the public review and comments
- **Approach**
 - Use of hybrid deterministic and probabilistic approaches
 - Six supporting activities
 - Unflawed piping
 - Flawed piping
 - Indirect failures
 - Review of past earthquake experience
 - Review of past PRAs
 - Review of a LLNL study conducted in connection with revision to GDC4

Approach – Key Assumptions and Scope (Unflawed and Flawed Piping Analysis)

- Used available design information (e.g., normal operating stresses, seismic stresses, and material properties)
 - Such results only available for PWRs from LBB application database; therefore, evaluations are limited to PWRs
- Used LLNL hazard curves – then latest publicly available– for plants east of Rocky Mountains
- Include piping systems with diameter larger than the TBS diameter (e.g., hot leg, cold leg, and cross-over leg)
- Determined seismic stresses at 10^{-5} (or 10^{-6}) seismic event (elastic stresses) by scaling plant specific SSE stresses
- Apply a correction to 10^{-5} seismic stresses to account for conservatism in the design process and the extrapolation to higher levels


Key Findings – Unflawed Piping

- Our results show frequency of seismically-induced breaks much lower than $1E-5$ /year for the piping systems evaluated
- Unflawed piping case can be eliminated from further analyses as flawed piping will have to be evaluated.


Approach – Flawed Piping Two Key Questions

- Rather than conducting a full probabilistic analysis for flaw development and critical flaw sizes for the entire seismic hazard curve, the approach examined maximum allowable flaw sizes at the N+SSE seismic condition (with all the normally imposed safety factors) relative to critical flaws for 10^{-5} (or 10^{-6}) seismic events (with more realistic criteria). If the N+SSE flaw sizes are smaller than the critical flaw sizes corresponding to the 10^{-5} or 10^{-6} seismic events, then there is inherent protection for the 10^{-5} or 10^{-6} seismic flaws from the N+SSE allowable flaw sizes.
- Two flaw evaluation procedures for N+SSE loading included:
 1. ASME inspection/evaluation criteria for circumferential surface flaws
 2. NRC LBB procedures for circumferential through-wall flaws

Example of Results: Code Surface Flaw Evaluations at N+SSE (with all SFs) Relative to Critical Flaw Size at 10^{-5} Seismic Event



a) ASME flaw sizes *smaller* than critical flaw at 10^{-5} seismic




(b) ASME flaw sizes *greater* than critical flaw at 10^{-5} seismic

Results From All Analyses For Surface Flawed Piping a/t values for long flaws at 10^{-6} seismic event



Analyses for rock foundation PWR plants east of Rocky Mountains
(Stainless steel SAW or carbon steel SAW is toughness controlling material;
i.e., not considering cast SS very sensitive to thermal aging)



Results – Surface Flawed Piping Evaluation of Maximum Allowable Code Flaws


- Results from analysis of 52 large-diameter pipe systems

	N + 10 ⁻⁵ seismic loading	N + 10 ⁻⁶ seismic loading
ASME Code N+SSE allowable flaw <i>smaller</i> than critical flaw size (Desirable result)	48 cases	20 cases
Critical flaw size bracketed by two different ASME Code flaw evaluation procedures	1 case	20 cases
ASME Code N+SSE allowable flaw <i>larger</i> than critical flaw size (Undesirable result, but still large flaw sizes)	3 cases (Limiting surface flaw depth = 40% of thickness)	12 cases (Limiting surface flaw depth = 30% of thickness)

Through-Wall Flaw (LBB) Evaluation Approach

- For standard LBB analysis at N+SSE stresses with applicable safety factors (SF) on leak rate (SF = 10) and leakage flaw size (SF = 2) and code parameters for critical flaw size analysis
- For N+10⁻⁵ and 10⁻⁶ seismic loading considered alternate cases with different SFs, but with more realistic accounting for fracture toughness properties

$N + 10^{-5}$ Seismic Stresses with Safety Factor of 1.5 on Crack Length



Page 11

Key Findings – Flawed Piping

- In most cases, the ASME maximum allowable surface-flaw size at $N+SSE$ loading is smaller than the critical flaw at 10^{-5} or 10^{-6} seismic event loading. For cases that don't meet this condition, flaw sizes are still quite large.
 - Critical crack depths are larger than 40% of thickness for 10^{-5} seismic stresses
 - Critical crack depths are larger than 30% of thickness for 10^{-6} seismic stresses

- The LBB flaw sizes associated with the SSE loading are smaller than the critical mean through-wall flaws at 10^{-5} and 10^{-6} seismic events for most cases with the SFs of 1.5 and 1.0, respectively.
 - The few cases that don't pass with these SFs, could pass with a smaller normal operating leak-rate detection capabilities.

Page 12

Approach - Indirect Failure

- Failure of support of large components which may lead to failure of piping – supports are of most interest
- Use LLNL results and update them to reflect new hazard and ground motion information
- Convolve a support fragility with mean LLNL hazard to obtain mean failure probability
- Assumption – large component support failures lead to piping failure

Approach - Indirect Failure Sample LLNL Results

- Our mean result for Calvert Cliffs – 1.7E-06/year compared to LLNL 90% confidence value of 6.1E-6

Group A Plants (Combustion Engineering)	Confidence Limit ⁽¹⁾		
	10%	50%	90%
Calvert Cliffs	2.3×10^{-8}	6.1×10^{-7}	6.1×10^{-6}
Millstone 2	9.0×10^{-10}	6.6×10^{-8}	1.2×10^{-6}
Palisades	5.0×10^{-7}	6.4×10^{-6}	5.2×10^{-5}
St. Lucie 1	1.2×10^{-6}	3.8×10^{-7}	4.1×10^{-6}
St. Lucie 2	6.6×10^{-6}	1.4×10^{-6}	1.1×10^{-5}
Westinghouse Lowest Capacity Plant	2.3×10^{-7}	3.3×10^{-6}	2.3×10^{-5}

(1) A confidence limit of 90% implies that there is a 90% subjective probability (confidence) that the probability of indirect DEGB is less than the value indicated.

(1) Generic seismic hazard curves used in evaluation.

Summary of Key Findings

- Frequency of seismically-induced breaks much lower than $1E-5$ /year for the unflawed piping systems evaluated
- Critical surface flaw and through-wall flaw evaluations
 - ASME Code maximum allowable surface flaws generally smaller than critical flaws at $N+1E-5$ or $1E-6$ seismic event. In all cases, - critical crack sizes are very large.
 - The LBB flaw sizes for $N+SSE$ loading (with SFs on flaw length) generally smaller than critical through-wall flaws at seismic events of $1E-5$ and $1E-6$ /year with reduced safety factors.
- For two cases analyzed, indirectly induced piping failure (attributable to major component support failure) has a mean failure probability on the order of $1E-6$ /year.

Draft Rule and Specific Questions

- Draft rule issued with the discussion of the seismic issue including whether a plant-specific assessments were needed or not.
- To facilitate feedback, comments were solicited on the following points:
 - Results of the evaluations contained in the report
 - Effects of pipe degradation on seismically-induced LOCA frequencies and the potential affecting the selection of the TBS
 - Potential approaches and options to address this issue




Public Comments

- **Industry responses and comments:**
 - TBS is not adversely affected by seismic considerations
 - Delta risk due to seismic is considered low
 - EPRI evaluated sample cases of indirect failure using updated seismic hazard with failure frequency less than 1E-5/yr
 - Plant-specific assessments should not be required



Current Status and Future Activities

- **The staff will evaluate the need for plant-specific assessment considering the following factors:**
 - Response to the questions issued with the draft rule
 - How the rule is revised to address the Commission SRM and the ACRS recommendations, particularly those associated with the defense-in-depth and mitigation.
 - What impact any potential changes under the new rule may have on the seismic risk
 - Guidance and acceptance criteria to demonstrate applicability of NUREG-1829 results to individual plants.



U.S. NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment


AREVA Stability Methodologies: DIVOM & Enhanced Option III

Dr. Tai L. Huang (NRR/ADES/DSS/SRXB)

ACRS Committee Meeting

Dec 6, 2007


OPEN SESSION



U.S.NRC Scope of Staff Review


UNITED STATES NUCLEAR REGULATORY COMMISSION
Protecting People and the Environment


- This staff review applies to two AREVA reports in the area of stability:
 - **ANP-10262(P)**, Rev 0, Enhanced Option III Long Term Stability Solution. Framatome ANP. January 2006
 - A new long term stability solution algorithm applicable to extended flow domains (EFD's) like MELLA+
 - **BAW-10255(P)**, Rev 2, Cycle-Specific DIVOM Methodology Using the RAMONA5-FA Code. Framatome ANP. January 2006
 - AREVA's methodology for calculating the DIVOM correlation, which is a required component of detect and suppress solutions



U.S. NRC
UNITED STATES NUCLEAR REGULATORY COMMISSION
Protecting People and the Environment

Extended Operating Domains Pose New Challenges to Stability





U.S.NRC
UNITED STATES NUCLEAR REGULATORY COMMISSION
Protecting People and the Environment


Long Term Stability Solutions for Original Thermal Power

- Options were developed by BWROG and publicly available
 - Documented in NEDO-31960A “BWR Owner's Group Long-Term Stability Solutions Licensing Methodology,” Nov 95
 - Approved for operation at Original Licensed Thermal Power (OLTP) operation
- Prevention (anticipatory scram)
 - Option E1A
 - Option ID
- Detect & Suppress
 - Option II
 - Option III



LTS for Extended Operating Domains


- Two LTSs address stability challenges for operating in extended operating domains (e.g., MELLLA+)
 - DSS-CD
 - NRC reviewed and approved for MELLLA+
 - GE Proprietary
 - Enhanced Option III (EO-III)
 - Focus of current staff review
 - Areva Proprietary



U.S. NRC Enhanced Option III

UNITED STATES NUCLEAR REGULATORY COMMISSION
Protecting People and the Environment

- Enhanced Option III (EO-III) is an evolutionary step relying on the existing methodology and hardware for Solution III.
- EO-III introduces measures for addressing the reduced stability associated with extended flow window conditions and the higher probability of single channel hydraulic instability excitation
- The new elements, introduced as enhancements to the existing Option III solution are
 - Introduction of a calculated exclusion region on the power/flow map designed to preclude single channel instabilities.
 - Calculation procedures consistent with the introduction of the channel instability exclusion region



U.S.NRC
UNITED STATES NUCLEAR REGULATORY COMMISSION
Protecting People and the Environment

AREVA Cycle-Specific DIVOM Methodology


- The DIVOM curve is a relationship between the hot bundle relative oscillation magnitude and the limiting fractional change in critical power ratio
- This review addresses the capabilities of the RAMONA5-FA system code to model neutron-coupled density wave oscillations of the regional mode type, and the range of input data defining the state points within the reload cycle for which the DIVOM curve is generated.
- It also addresses the procedure for post-processing the system code output to generate the DIVOM data consistent with their intended application



U.S.NRC Review Conclusions: EO-III

UNITED STATES NUCLEAR REGULATORY COMMISSION
Protecting People and the Environment


- The staff concludes that EO-III is an acceptable methodology to detect and suppress oscillations should they occur and, thus, satisfies General Design Criteria GDC-12
 - The EO-III Solution features provide protection up to and including MELLLA+ conditions



U.S.NRC
UNITED STATES NUCLEAR REGULATORY COMMISSION
Protecting People and the Environment

Review Conclusions: DIVOM


- The AREVA DIVOM Methodology is consistent with the previously approved BWROG methodology
- RAMONA5-FA is an integral part of the AREVA DIVOM Methodology. RAMONA5-FA is capable of:
 - Computing power, flow, and void oscillations with consistent phase lags and of a frequency representative of unstable oscillations
 - Estimate the loss of critical power ratio (CPR) induced by these oscillations
- AREVA has committed to support the staff review of the RAMONA5-FA code for DIVOM calculations



U.S. NRC RAMONA5-FA Limitation

UNITED STATES NUCLEAR REGULATORY COMMISSION
Protecting People and the Environment

- EFW operation (e.g. MELLLA+) poses additional challenges to the calculations; therefore, the staff imposes the following conditions:
 - The application of RAMONA5-FA to calculate the DIVOM curve under extended flow window operating domains (such as MELLLA+) is restricted to stability solutions having a scram protected exclusion region that substantially reduces the potential severity of power oscillations.
 - A penalty of 10% must be added to DIVOM slopes calculated by RAMONA5-FA for extended flow window operating domains. This penalty is equivalent to a penalty of 10% added to the calculated relative CPR response for a given power oscillation magnitude.
- The above restrictions shall remain in effect until the staff completes a detailed review of the RAMONA5-FA code and its ability to calculate DIVOM curves in extended flow window operating domains.



U.S.NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

STATE-OF-THE-ART REACTOR CONSEQUENCE ANALYSES

Advisory Committee on Reactor Safeguards Briefing
December 6, 2007

AGENDA

- Project Overview
- Accident Sequence Selection
- Containment System States
- Mitigative Measures
- MELCOR
- MACCS2
- Emergency Preparedness
- Peer Review
- Sample Sequence
- Reporting Latent Cancer Fatalities

SOARCA Objectives


- Perform a state-of-the-art, realistic evaluation of severe accident progression, radiological releases and offsite consequences for frequency dominant core damage accident sequences
- Provide a more accurate assessment of potential offsite consequences to replace previous consequence analyses

Severe Accident Improvements

- 25 years of national and international research
- Regulatory improvements reduced the likelihood of severe accidents
- Improved modeling capability
- Improvements in plant design
- Other plant improvements

SOARCA OVERVIEW

SOARCA PROCESS



SOARCA Approach

- Full power operation
- Plant-specific sequences with a $CDF \geq 10^{-6}$ ($CDF \geq 10^{-7}$ for bypass events)
- External events included
- Consideration of all mitigative measures
- Sensitivity analyses to assess the effectiveness of different safety measures
- State-of-the-art accident progression modeling based on 25 years of research to provide a best-estimate for accident progression, containment performance, time of release and fission product behavior
- More realistic offsite dispersion modeling
- Site-specific evaluation of public evacuation based on updated Emergency Plans

SOARCA Insights

- Sequences dominated by external events, primarily large seismic events (PWR also includes bypass events)
- Previously used sequences have a significantly lower probability of occurrence or are not considered to be feasible
 - Alpha mode failure
 - High pressure melt ejection
 - ATWS
- Mitigative measures are proving to be effective at preventing core damage or containment failure

Sequence Screening Process

(Internal Events)

- Initial Screening - use enhanced SPAR models to screen out low CDF sequences with an overall CDF $\leq 1.0E-7$ and sequences with a CDF $< 1.0E-8$. This step eliminates $< 10\%$ of the overall CDF (typically about 5%)
- Sequence Evaluation – identify and evaluate the dominant cutsets for the remaining sequences ($\sim 90\%$ of initiator CDF). Determine system and equipment availability / unavailability and accident sequence timing
- Scenario Grouping - group sequences together that have similar times to core damage and equipment unavailability
- Select bounding sequences based on most limiting mitigative measures available

Sequence Screening Process

(External Events)

- Identify dominant externally initiated event sequences based upon available probabilistic risk assessment documentation from NUREG-1150, IPEEE submittals, as well as any additional and available supporting documentation
- Identify potential mapping between dominant external events and internally initiated events identified by the SPAR analysis
- Where mapping between external and internal events are not possible or appropriate, a unique externally initiated event or sensitivity study was recommended
- The resulting limited set of scenarios obtained for each SOARCA plant was used for subsequent accident progression and consequence analysis

Containment Systems States

The availability of engineered systems that can impact post-core damage containment accident progression, containment failure and radionuclide release

- Determine the anticipated availability of containment and containment support systems not considered in the Level 1 core damage analysis
- Determine the availability of non containment and non containment support systems such as low pressure injection that can impact containment accident progression

Mitigative Measures Analysis

- The mitigative measures analyses are qualitative, sequence-specific systems and operational analyses based on licensee identified mitigative measures from EOPs, SAMGs, and other severe accident guidelines that are applicable to, and determined to be available during a sequence groupings whose availability, capability and timing will be utilized as an input into the MELCOR analyses


Mitigative Measures Analysis Process

- For those dominating sequences / sequence groupings within the scope of SOARCA, determine the potentially available mitigative measures
- Perform a system and an operational analysis based on the initial conditions and anticipated subsequent failures
- Determine the anticipated availability, capability and the time to implementation
- MELCOR will determine the effectiveness of the mitigative measures based on capability and estimated time of implementation


Structural Analyses Objective

Evaluate the behavior of containment structures under unmitigated severe accident conditions to predict the following performance criteria at the selected sites:

- Functional Failure Pressure - Leakage
- Structural Failure Pressure - Rupture
- Develop Leakage Rate and/or Leakage Area as a Function of Internal Pressure



**Peach Bottom "Mark I" –
Steel Containment"**



**Surry "Reinforced Concrete
Containment"**

MELCOR Analyses

- MELCOR Code Improvements
 - MACCS2 Output Interface
 - Implement Fuel Collapse Model Logic
 - Update MELCOR Defaults
 - Pool Scrubbing Model
- Develop a plant-specific model
- Perform accident progression analyses for each plant using MELCOR computer code to determine source term, potential containment failure state, and time of release as input in the MACCS2 analyses

MACCS 2 Analyses

- MACCS2 Code Improvements
 - Increased number of evacuation cohorts
 - Alternative models for latent cancer fatality dose response
 - Increased angular resolution
 - More plume segments
 - Enable network evacuation model
 - KI ingestion
 - Evacuation speed modifiers by grid element and for precipitation
 - Enable parameter uncertainty
- Perform consequence analyses for each plant using MACCS2 computer code to determine early fatalities, and latent cancer fatalities

MACCS2 Assumptions

- No contaminated food or water consumed
- Latest federal guidelines used for dose conversion factors
- KI ingestion by half the 0 – 10 mile population, suboptimum timing
- Median values from US/CEC study of uncertainty for non-site specific parameter
- Site-specific population and meteorology
- Projected dose during emergency period, 5 rem relocate in 1 day; 2 rem, 2 days
- Return criteria: 0.5 rem in 1 yr for Peach Bottom, 4 rem in 5 yr for Surry
- In general, 1-hr plume segments are used

Emergency Preparedness

- Model the protective response afforded by current site-specific Emergency Preparedness (EP) Programs to improve realism
- Used site-specific evacuation time estimates for evacuation of EPZ
- Used OREMs to model evacuation of 10 to 20 mile area
- Modeled cohort data
 - Population
 - Evacuation timing
 - Travel speed
 - Roadway network
- Data was used in MACCS2 to develop consequence estimates

Peer Reviews

- Internal
 - Staff
 - ACNW&M
 - ACRS
- External
 - National Experts
 - International Experts

Peach Bottom Accident Sequences

- PRA models indicate core damage probability dominated by seismic event, which is functionally a long-term SBO (1×10^{-6} to 5×10^{-6} /yr)
 - Fire and flood events would be similar in terms of core damage progression
- Internal events were all $< 10^{-6}$ /yr
- Bypass events were very low frequency: $\ll 10^{-7}$ /yr

Surry Accident Sequences

- Dominant PRA events
 - Long-term SBO (1×10^{-5} to 2×10^{-5} /yr)
 - Short-term SBO (1×10^{-6} to 2×10^{-6} /yr)
 - ISLOCA (7×10^{-7} /yr)
 - SGTR (5×10^{-7} /yr)
- SBO events are due to seismic, flooding and fire initiators, and are modeled as seismic event
 - Internal fire and internal flood events are less challenging, more mitigation available
- ISLOCA and SGTR are due to random equipment failures followed by operator errors

Sample Sequence Loss of Vital AC Bus

- This sequence was selected and assessed for demonstration purposes, not within the scope of SOARCA, CDF $<10^{-6}$
- MELCOR analysis showed that this event can be mitigated

Sample Sequence

Loss of Vital AC Bus – cont.

- Initiator: Loss of Div IV dc power resulting in
 - SCRAM, MSIV closure, containment isolation
 - RCIC automatically starts, 1 CRDHS pump active
- Operator actions (base case):
 - Load shed to maximize duration of DC power
 - Maximize flow from single CRDHS pump
 - Depressurize RCS at 1.5 hours
 - Secure CRDHS from 4 – 7 hrs to prevent RPV overfill
- Sufficient to prevent core damage

Sample Sequence

Loss of Vital AC Bus – cont.

Insights

- Sufficient injection capability to prevent core damage
 - SPAR does not credit CRDHS for coolant makeup
- RPV depressurization and maximizing CRDHS flow are important operator actions to optimize recovery
- SLC also available for high pressure injection
- Battery duration is important for RCIC operation and instrumentation

Reporting Latent Cancer Fatalities

- Commission Paper
- Options
 - Range of thresholds (0 – 5 rem)
 - Linear no threshold (LNT)
 - Estimate point value from Health Physics Society
 - 5 rem in one year, 10 rem in a life time
- ACNWM Full committee Meeting
 - Presentation on MACCS2
 - Initial suggestions included reporting dose and risk versus consequences
- In staff review

NRC'S SOARCA PROGRAM: UCS CONCERNS

Dr. Edwin Lyman

Senior Staff Scientist

Union of Concerned Scientists

Remarks to NRC Advisory Committee on Reactor
Safeguards, December 6, 2007

The bottom line

- The Union of Concerned Scientists (UCS) is supportive of an authoritative and independent study that improves the technical credibility and accuracy of analyses of the consequences of severe reactor accidents
 - Improved protective actions
 - Better siting decisions for new reactors
- However, the “State-of-the-Art Reactor Consequence Assessment” (SOARCA) does not appear to be on track to fulfill such a role
 - Political goals of the project threaten to overwhelm the technical goals

What is the real point of SOARCA?

- Knocking down a “straw man:” the 1982 CRAC2 study (NUREG/CR-2239)
 - Ignores the more than 20 years of refinement of severe accident analyses performed for NUREG-1150 and subsequent work and commonly used in regulatory applications
- “The SOARCA project may show that a LER [large early release] may not credibly exist” --- Randy Sullivan, NRC, ACRS 544th meeting, July 12, 2007

Inappropriate focus on “risk communication”

- “Risk communication:” results “will be presented and documented using risk communication techniques to achieve public understanding”: NRC SOARCA Project Plan, June 2007
- The development of a “risk communication plan” years before the study’s results will be available raises the suspicion that the public relations aspects of this project are its main purpose
 - We say, “Just the facts, ma’am!” – the best way to achieve “public understanding” is to clearly present all assumptions and arguments in a step-wise fashion, so that the impact of the various changes to CRAC2 and NUREG-1150 can be readily observed; not to bundle all of them in a black box that generates an obscure “best estimate”
 - the public should be given the whole picture and the opportunity to make independent judgments of the level of risk it is willing to accept
 - The original CRAC2 risk communication fiasco occurred because NRC was preparing to release only the mean consequence values over the weather sequence distribution ; when the “peak values” were later leaked, it appeared that NRC had tried to conceal data from the public

Excessive secrecy

- Important information about the framework of SOARCA remains secret
 - SECY-05-0233 and the corresponding SRM remain withheld from the public in their entirety
 - The public has been excluded from much of the discussion of SOARCA, in some instances with an apparently inappropriate rationale

SOARCA:

The good ...

- Updated MELCOR accident progression and source term development using reactor-specific data and latest experimental insights
- Improved understanding of containment performance in severe accidents
- More accurate modeling of protective actions

...the bad ...

- Improper truncation of low-CDF sequences
 - 10% of CDF screened out --- not insignificant
 - Inconsistent treatment of external events, low-power and shutdown risks
- Credit for unregulated measures like SAMGs

... and the ugly

- Use of thresholds in dose-response modeling would directly contradict the recommendations of established scientific authorities like the National Academy of Sciences BEIR VII Committee:
 - “Mechanistic uncertainties remain, but the weight of available evidence would argue against the presence of a low dose threshold for tumor induction based on error-free repair of initial DNA damage. In summary, the committee judges that the balance of scientific evidence at low doses tends to weigh in favor of a simple proportionate relationship between radiation dose and cancer risk” (NAS, BEIR VII Phase 2, 2006, p. 246).

What was so bad about CRAC2?

- CRAC2
 - used census data from 1970
 - assumed that the entire 10-mile emergency planning zone would be completely evacuated within at most six hours after issuance of a warning
 - assumed aggressive medical treatment for all victims of acute radiation exposure
 - employed a now-obsolete correlation between radiation dose and cancer risk that underestimated the risk by a factor of 4 relative to current models;
 - sampled only 100 weather sequences out of 8760, a method which we find underestimates the peak value occurring over the course of a year by 30%.
- UCS MACCS2 calculations of the consequences of a large, early release using more recent source term (based on NUREG-1465) generally confirm CRAC2 results for Indian Point for early fatalities and find CRAC2 underestimated latent cancer fatalities by a significant factor

Source terms for early containment failure

Source term derived from NUREG-1465

Plume	Release time (hrs)	Duration(hrs)	Energy release (MW)	Kr	I	Cs	Te	Ba	Ru	Ce	La
1	1.8	0.06	28	1	0.4	0.3	0.05	0.02	0.0025	0.0005	0.0002
2	1.86	2	1.6	0	0.27	0.37	0.25	0.1	0.0025	0.005	0.005

Energy source term for Indian Point
derived from MAAP

Plume	Release time (hrs)	Duration(hrs)	Energy release (MW)	Kr	I	Cs	Te	Ba	Ru	Ce	La
1	3.66	22.9	1.08	0.7	0.24	0.23	0.23	0.046	0.09	0.0048	0.0008

MACCS2 results for large early release in 2034

Consequence within 50 miles	UCS result	IP License Renewal Environmental Report (Table E.1-14)
Mean early fatalities	860	Not reported
Mean latent cancer fatalities	38,500	Not reported
Mean population dose (person-Sv)	4.97×10^5	1.58×10^5
Peak early fatalities	70,800	Not reported
Peak latent cancer fatalities	695,000	Not reported
Peak population dose (person-Sv)	7.34×10^6	Not reported

Conclusions

- If the main impact of SOARCA is to reduce potential severe accident consequences by eliminating consideration of large early releases, then it merely will be an exercise in circular reasoning
- Inclusion of thresholds in the dose-response curve used for SOARCA without authoritative technical justification for rejection of BEIR VII conclusions will further undermine the credibility of the report
- An “apples-to-apples” comparison with previous studies will be necessary to truly evaluate the effect of improved technical understanding, better data and code improvement

Recommendations

- The best way to establish the technical credibility of SOARCA is for
 - NRC to immediately submit the methodology and interim results for external, independent peer review
 - NRC to submit the final results for publication in a reputable, peer-reviewed journal