

**Carolina Power & Light Company,
doing business as Progress Energy Carolinas, Inc.**

Shearon Harris Nuclear Power Plant

Facility Operating License No. NPF-063

Docket No. 50-400

**ANNUAL RADIOACTIVE EFFLUENT
RELEASE REPORT**

January 1, 2007 through December 31, 2007

Table of Contents

<u>Section</u>	<u>Page No.</u>
Introduction	3
Discussion	3
Appendix 1. Supplemental Information	7
Appendix 2. Effluent and Waste Disposal Report	
1. Lower Limits of Detection (LLDs)	11
2. Effluents Released	13
3. Solid Waste Disposal	22
Appendix 3. Changes to Offsite Dose Calculation Manual (ODCM)	29
Appendix 4. Changes to the Environmental Monitoring Program	
1. Environmental Monitoring Program	30
2. Land Use Census	30
Appendix 5. Additional Operational Requirements	
1. Inoperability of Liquid Effluent Monitors	31
2. Inoperability of Gaseous Effluent Monitors	31
3. Unprotected Outdoor Tanks Exceeding Limits	31
4. Gas Storage Tanks Exceeding Limits	31
5. Groundwater samples taken in Support of Groundwater Protection Initiative NEI 07-07	31
Appendix 6. Major Modifications to Radwaste System	32
Appendix 7. Meteorological Data	33
Appendix 8. Assessment of Radiation Doses	34
Attachment I ODCM, Revision 19	36

Introduction

This Annual Radioactive Effluent Release Report is prepared in accordance with Shearon Harris Nuclear Power Plant's Operational Requirements - Offsite Dose Calculation Manual (ODCM), Appendix F Section F.2, and Technical Specification 6.9.1.4, Operating License No. NPF-63.

The Shearon Harris Nuclear Power Plant (SHNPP) achieved initial criticality on January 3, 1987. This Report covers the period from January 1, 2007 to December 31, 2007. During this period, the plant operated in Cycle 14 & Cycle 15. Refueling Outage 14 was completed in October 2007.

Discussion

1. Protection Standards

The main objective in the control of radiation is to ensure that any exposure is kept not only within regulatory limits, but As Low As Reasonably Achievable (ALARA). The ALARA concept applies to reducing radiation exposure both to workers at Harris Nuclear Plant and to the general public. "Reasonably Achievable" means that radiation exposure reduction is based on sound environmental practices, economic decisions, and operating practices. By practicing ALARA, Harris Nuclear Plant and Progress Energy Carolinas, Inc. minimize health risk, environmental detriment, and ensure that exposures are maintained well below regulatory limits.

2. Sources of Radioactivity Released

During normal operations of a nuclear power station, most of the fission products are retained within the fuel and fuel cladding. However, small quantities of radioactive fission and activation products are present in the primary coolant water. The types of radioactive material released are noble gases, iodines and particulates, and tritium.

The noble gas fission products in the primary coolant are collected by a system designed for collection and storage for radioactive decay prior to release.

Small releases of radioactivity in liquids may occur from equipment associated with the primary coolant system. These liquids are collected and processed for radioactivity removal prior to release.

3. Noble Gas

Some of the fission products released in airborne effluents are radioactive isotopes of noble gases, such as krypton and xenon. Noble gases are by nature inert and do not concentrate in humans or other organisms; therefore internal exposure is negligible. Their contribution to human radiation exposure is as an external exposure. Xenon-133 and Xenon-135, with half-lives of approximately 5 days and 9 hours respectively, are the major isotopes released. Half-life is defined as the time required for a radioactive isotope to lose 50 percent of its radioactivity by decay. Noble gases are readily dispersed in the atmosphere.

4. Iodines and Particulates

Annual releases of iodines, and those particulates with half-lives greater than 8 days are small. Factors such as chemical reactivity and solubility in water, combined with high processing efficiencies, minimize their discharge. The main contribution of radioactive iodine to human exposure is to the thyroid gland, where the body concentrates iodine. The principal radioactive particulates are Cobalt-58 and Cobalt-60 which contribute to internal exposure of tissues such as the muscle, liver, and intestines. These particulates can also be a source of exposure if deposited on the ground.

5. Tritium

Tritium, a radioactive isotope of hydrogen, is the predominant radionuclide in liquid and gaseous effluents. Tritium is produced in the reactor coolant as a result of neutron interaction with deuterium (also a hydrogen isotope) and boron, both of which are present in the primary coolant. Tritium contributes very little radiation exposure to the human body, and when it is inhaled or ingested, is dispersed throughout the body until eliminated.

6. Processing and Monitoring

Effluents are strictly controlled and monitored to ensure that radioactivity released to the environment is minimal and within regulatory limits. Effluent control includes the operation of radiation monitoring systems, in-plant and environmental sampling and analyses, quality assurance programs for both in-plant and environmental sampling and analyses, and procedures that address effluent and environmental monitoring.

The plant radiation monitoring system has monitors that are designed to ensure that releases are below regulatory limits. Each instrument provides indication of the amount of radioactivity present and is equipped with alarms and indicators in the control room. The alarm setpoints are set lower than the ODCM Operational Requirements to ensure the limits are not exceeded. If a monitor alarms, a release from a tank is automatically suspended. Additionally, batch releases are sampled and analyzed in the laboratory prior to discharge. The sampling and analysis done in the laboratory provides a more sensitive and precise method of determining effluent composition than in-plant monitoring instruments.

The plant has a meteorological tower, which is linked to computers that record the meteorological data. The meteorological data and the release data can be used to assess the dose to the public. The doses reported in this report use twelve-year average (1976 through 1987) data from the onsite meteorological program.

In addition to in-plant equipment the company maintains a Radiological Environmental Monitoring Program, which consists of devices used to constantly sample the air and water in the environment. The samples collected from the surrounding environment are analyzed to determine any presence of radioactive material in the environment.

7. Exposure Pathways

Radiological exposure pathways are the methods by which people may become exposed to radioactive material. The major pathways of concern are those that could cause the highest calculated radiation dose. The projected pathways are determined from the type and amount of radioactive material that may have been released, the environmental transport mechanism, and the use of the environment. Environmental transport mechanisms include, but are not limited to, local hydrology (water) and meteorology (weather).

The release of radioactive gaseous effluents can impact the public via pathways such as external whole body exposure, deposition on plants and soils, and human inhalation. The release of radioactive material in liquid effluents can impact the public via pathways such as drinking water, fish consumption, and direct exposure from the lake at the shoreline and submersion dose while swimming.

Even though radionuclides can reach humans by many different pathways, some radionuclides result in more exposure than others. The critical pathway is the exposure that will provide, for a specific radionuclide, the greatest exposure to a population, or a specific group of the population, called the critical group. The critical group may vary depending on the radionuclides involved, the age and diet of the group, and other cultural factors. The exposure may be received to the whole body or to a specific organ, with the organ receiving the largest fraction of the exposure called the critical organ.

8. Results

The quantities of radioactive gaseous and liquid effluents and solid waste are reported using the format per Regulatory Guide 1.21 (Rev. 1) Appendix B.

The Radioactive Effluent Release Report is a detailed listing of the radioactivity released from the Harris Nuclear Plant during the period from January 1, 2007 through December 31, 2007. The assessment of annual radiation doses to members of the public from radioactive liquid and gaseous effluents from the plant are estimated using the methodology in the ODCM.

During the period of January 1, 2007 through December 31, 2007, the estimated maximum individual offsite dose due to radioactivity released in effluents was:

Liquid Effluents:	Limit
1.55 E-02 mrem, Total Body	3.0 E+00 mrem
1.99 E-02 mrem, Max Organ (GI-LLI)	1.0 E+01 mrem
Gaseous Effluents:	Limit
Noble Gases	
3.75 E-04 mrad, Beta	2.0 E+01 mrad
1.93 E-04 mrad, Gamma	1.0 E+01 mrad
Tritium, Radioiodine 131, 133, and Particulates with greater than an 8 Day Half Life:	
3.18 E-01 mrem, Critical Organ (Lung)	1.5 E+01 mrem(*)

(*) Limit applies to Tritium, Radioiodines, and Particulates with greater than an 8-Day Half Life:

These doses are in addition to what is received from natural background in the area surrounding the Harris Nuclear Plant (approximately 300 mrem per year).

Appendix 1: Supplemental Information

I. Regulatory Limits

A. Fission and Activation Gases:

ODCM Operational Requirements Maximum Instantaneous Release Rate

Total Body Dose ≤ 500 mrem/yr

Skin Dose ≤ 3000 mrem/yr

10CFR20 Limits

Annual Average Concentrations as specified in 10CFR20, Appendix B, Table 2, Column 1. This is based on 100 mrem/yr.

10CFR50, Appendix I

For Calendar Quarter

Gamma Dose ≤ 5 mrad (Used for calculating percent of applicable limit.)

Beta Dose ≤ 10 mrad (Used for calculating percent of applicable limit.)

For Calendar Year

Gamma Dose ≤ 10 mrad

Beta Dose ≤ 20 mrad

B. Iodine - 131 and 133, Tritium, and Particulates >8 day half-lives:

ODCM Operational Requirements

Maximum Instantaneous Release Rate is and inhalation dose (only) to a child to any organ ≤ 1500 mrem/yr

10CFR20 Limits

Annual Average Concentrations as specified in 10CFR20, Appendix B, Table 2, Column 1. This is based on 50 mrem/yr.

10CFR50, Appendix I (Organ Doses)

For Calendar Quarter ≤ 7.5 mrem (Used for calculating percent of applicable limit.)

For Calendar Year ≤ 15 mrem

C. Liquids:

ODCM Operational Requirements

Maximum Instantaneous Release Rate is ten times the concentrations specified in 10CFR20, Appendix B, Table 2, Column 2 for radionuclides other than dissolved or entrained noble gases.

ODCM Operational Requirements

For dissolved or entrained noble gases, the concentration shall be limited to $2.00E-04$ $\mu\text{Ci/ml}$ total activity.

10CFR20 Limits

The annual average concentrations to be less than the concentrations specified in 10CFR20, Appendix B, Table 2, Column 2. (Used for calculating percent of applicable limit.) This is based on 50 mrem/yr.

10CFR50, Appendix I

For Calendar Quarter

Total Body Dose ≤ 1.5 mrem

Any Organ Dose ≤ 5 mrem

For Calendar Year

Total Body Dose ≤ 3 mrem

Any Organ Dose ≤ 10 mrem

D. Average Energy (\bar{E}):

None applicable at HNP. HNP determines dose and dose rate based on actual releases, not on an average energy value.

Appendix 1: Supplemental Information (Continued)

II. Measurements and Approximations of Total Radioactivity

A. Continuous Gaseous Releases

1. Fission and activation gases

The total activity released is determined from the net activity of gaseous monitors times the total stack flow. The activity of each radionuclide is determined by the fraction of that radioactive gas in the isotopic analysis for that sampling period (typically weekly). If no activity is detected for the sampling period, the mix is based on historical data.

2. Iodines

The activity released as iodine-131, 133, and 135 is based on isotopic analysis of the charcoal cartridge plus the particulate filter times the total vent flow for each sample period (typically weekly).

3. Particulates

The activity released as particulates with half-lives greater than eight days is determined by isotopic analysis of particulate filters times the total vent flow for each sample period. The sample period is at a minimum weekly or more frequently if plant conditions require.

4. Tritium

The activity released as tritium is based on grab sample analysis using liquid scintillation times total stack flow. Grab sampling is typically performed weekly.

B. Batch Gaseous Releases

1. Fission and activation gases

The activity released is based on the volume released times the activity of the individual nuclides obtained from an isotopic analysis of the grab sample taken prior to the release.

2. Iodines

The iodine activity released from Waste Gas Decay Tank (WGDT) batch releases is included in the iodine determination from the continuous releases.

3. Particulates

The particulate activity released from Waste Gas Decay Tank (WGDT) batch releases is included in the particulate determination from the continuous releases.

4. Tritium

The activity released as tritium is based on the grab sample analysis using liquid scintillation of each batch times the batch volume.

C. Liquid Releases

1. Fission and Activation Products

The total activity released (excluding tritium, strontium, iron-55, alpha, and nickel-63) is comprised of the sum of the products of the individual radionuclide concentrations in each batch (identified using gamma spectroscopy) times the volume of the batch.

Appendix 1: Supplemental Information (Continued)

II. Measurements and Approximations of Total Radioactivity

C. Liquid Releases

2. Alpha and Tritium

The alpha activity released is the monthly composite alpha concentration times the volume released for the month.

The tritium activity released is the concentration of tritium in each batch release times the volume of the batch release.

The tritium activity released through the continuous pathways (turbine building drains and secondary waste) is the concentration from monthly composite samples (corrected for makeup water concentrations) times the volume released for the month. Makeup water is from the lake and has detectable tritium.

3. Strontium-89, 90, Iron-55, and Nickel-63

Analyses are performed on quarterly composite samples times the volume released during the quarter to calculate the activity released.

D. Estimated Total Errors

1. Estimated total errors for gaseous effluents are based on uncertainties in counting equipment calibration, counting statistics, vent flow rates, vent sample flow rates, chemical yield factors, and sample losses for such items as charcoal cartridges.
2. Estimated total errors for liquid effluents are based on uncertainties in counting equipment calibration, counting statistics, sampling, and volume determinations.

Appendix 1: Supplemental Information (Continued)

III. Batch Releases (2007)

A. Liquid Batch Releases

	Jan - June 2007	July - Dec 2007
Number of batch releases	1.30 E+01	2.40 E+01
Total time period for batch releases	9.17 E+03 minutes	1.68 E+04 minutes
Maximum time of a batch release	8.00 E+02 minutes	9.13 E+02 minutes
Average time for a batch release	7.06 E+02 minutes	6.98 E+02 minutes
Minimum Time for a batch release	5.53 E+02 minutes	2.18 E+02 minutes
Average stream flow during periods of release	3.49 E+03 cf/s	4.74 E+02 cf/s

B. Gaseous Batch Releases

	Jan - June 2007	July - Dec 2007
Number of batch releases	1.00 E+00	1.20 E+01
Total time period for batch releases	4.38 E+02 minutes	9.89 E+03 minutes
Maximum time of a batch release	4.38 E+02 minutes	3.01 E+03 minutes
Average time for a batch release	4.38 E+02 minutes	8.25 E+02 minutes
Minimum Time for a batch release	4.38 E+02 minutes	5.00 E+01 minutes

C. Abnormal Releases

a. Liquid

There were no abnormal liquid releases in 2007.

b. Gaseous

There were no abnormal gaseous releases in 2007.

Appendix 2: Effluent and Waste Disposal Report
Enclosure 1: Lower Limits of Detection (LLDs)

1. LLDs for Gaseous Effluents

<u>Nuclide</u>	<u>μCi/cc</u>
Gross Alpha	2.42 E-15
H-3	6.40 E-09
Ar-41	1.27 E-08
Kr-85	2.97 E-06
Kr-85m	6.76 E-09
Kr-87	4.34 E-08
Kr-88	2.65 E-08
Xe-131m	1.63 E-07
Xe-133	4.02 E-09
Xe-133m	5.92 E-08
Xe-135	9.40 E-09
Xe-135m	1.30 E-08
Xe-138	5.80 E-07
I-131	4.84 E-13
I-133	8.20 E-13
I-135	6.34 E-12
Cr-51	2.54 E-12
Mn-54	7.45 E-13
Co-58	4.81 E-13
Fe-59	1.19 E-12
Co-60	2.96 E-13
Zn-65	1.32 E-12
Sr-89	7.67 E-15
Sr-90	2.10 E-15
Nb-95	4.51 E-13
Zr-95	2.95 E-13
Mo-99	1.29 E-12
Cs-134	2.01 E-13
Cs-137	7.31 E-13
Ba-140	4.49 E-13
La-140	3.97 E-13
Ce-141	3.05 E-13
Ce-144	1.24 E-12

Appendix 2: Effluent and Waste Disposal Report (Continued)
 Enclosure 1: Lower Limits of Detection (LLDs)

2. LLDs for Liquid Effluents

<u>Nuclide</u>	<u>μCi/ml</u>
Gross Alpha	5.39 E-08
H-3	2.01 E-06
Na-24	2.67 E-08
Cr-51	1.89 E-07
Mn-54	4.41 E-08
Fe-55	1.08 E-07
Co-57	1.16 E-08
Co-58	1.59 E-08
Fe-59	1.27 E-07
Co-60	2.48 E-08
Ni-63	8.69 E-08
Zn-65	4.16 E-08
Sr-89	4.55 E-08
Sr-90	1.35 E-08
Nb-95	5.15 E-08
Zr-95	2.68 E-08
Mo-99	1.15 E-07
Tc-99m	2.75 E-08
Ru-106	3.41 E-07
Sb-124	6.24 E-08
Sb-125	9.96 E-08
Sb-126	2.69 E-08
I-131	3.57 E-08
I-133	3.01 E-08
Te-132	1.76 E-08
Xe-133	1.37 E-08
Xe-133m	2.32 E-07
Xe-135	2.99 E-08
Cs-134	1.82 E-08
Cs-137	1.53 E-08
Ba-140	1.22 E-07
La-140	3.10 E-08
Ce-141	3.95 E-08
Ce-144	1.27 E-07

Appendix 2: Effluent and Waste Disposal Report (Continued)
Enclosure 2: Effluents Released

Table 1A: GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES

	Unit	Quarter 1	Quarter 2	Est. Total Error %
A. Fission and activation gases				
1. Total release	Ci	1.77 E-01	3.06 E-04	5.27 E+01
2. Average release rate for period	μCi/sec	2.27 E-02	3.89 E-05	
3. Percent of ODCM Operational Requirement limit	%	3.58 E-04	6.21 E-07	
B. Iodines				
1. Total iodine-131	Ci	<LLD	<LLD	3.04 E+01
2. Average release rate for period	μCi/sec	<LLD	<LLD	
3. Percent of ODCM Operational Requirement limit*	%	9.99E-01	1.21 E+00	
C. Particulates				
1. Particulates with half-lives >8 days	Ci	<LLD	<LLD	3.38 E+01
2. Average release rate for period	μCi/sec	<LLD	<LLD	
3. Percent of ODCM Operational Requirement limit*	%	9.99E-01	1.21 E+00	
4. Gross alpha radioactivity	Ci	<LLD	<LLD	
D. Tritium				
1. Total release	Ci	5.55 E+01	6.74 E+01	5.22 E+01
2. Average release rate for period	μCi/sec	7.14 E+00	8.57 E+00	
3. Percent of ODCM Operational Requirement limit*	%	9.99 E-01	1.21 E+00	

* The Percent of ODCM Operational Requirement limits applies to Iodines, Particulates and Tritium combined, and is calculated using ODCM methodology and parameters. The quarterly ODCM Operational Requirement limit is 7.5 millirem. The most critical organ for both quarters was the lung.

Appendix 2: Effluent and Waste Disposal Report (Continued)
Enclosure 2: Effluents Released

Table 1A: GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES

	Unit	Quarter 3	Quarter 4	Est. Total Error %
A. Fission and activation gases				
1. Total release	Ci	8.99 E-04	1.44 E+00	5.27 E+01
2. Average release rate for period	μCi/sec	1.13 E-04	1.81 E-01	
3. Percent of ODCM Operational Requirement limit	%	2.84 E-06	3.39 E-03	
B. Iodines				
1. Total iodine-131	Ci	<LLD	<LLD	3.04 E+01
2. Average release rate for period	μCi/sec	<LLD	<LLD	
3. Percent of ODCM Operational Requirement limit*	%	1.13 E+00	8.95 E-01	
C. Particulates				
1. Particulates with half-lives >8 days	Ci	<LLD	5.08 E-7	3.38 E+01
2. Average release rate for period	μCi/sec	<LLD	6.39 E-08	
3. Percent of ODCM Operational Requirement limit*	%	1.13 E+00	8.95 E-01	
4. Gross alpha radioactivity	Ci	<LLD	<LLD	
D. Tritium				
1. Total release	Ci	6.29 E+01	4.98 E+01	5.22 E+01
2. Average release rate for period	μCi/sec	7.92 E+00	6.26 E+00	
3. Percent of ODCM Operational Requirement limit*	%	1.13 E+00	8.95 E-01	

* The Percent of ODCM Operational Requirement limit applies to Iodines, Particulates and Tritium combined, and is calculated using ODCM methodology and parameters. The quarterly ODCM Operational Requirement limit is 7.5 millirem. The most critical organ for both quarters was the lung.

Appendix 2: Effluent and Waste Disposal Report (Continued)
Enclosure 2: Effluents Released

Table 1B: GASEOUS EFFLUENTS - ELEVATED RELEASES

All releases at Shearon Harris Nuclear Power Plant are considered ground releases.

Appendix 2: Effluent and Waste Disposal Report (Continued)
Enclosure 2: Effluents Released

Table 1C: GASEOUS EFFLUENTS - GROUND LEVEL RELEASES

Nuclides Released	Unit	Continuous Mode		Batch Mode	
		Quarter 1	Quarter 2	Quarter 1	Quarter 2
1. Fission Gases					
Xenon-131m	Ci	<LLD	<LLD	<LLD	<LLD
Xenon-133	Ci	1.77 E-01	3.06 E-04	<LLD	<LLD
Xenon-133m	Ci	<LLD	<LLD	<LLD	<LLD
Xenon-135	Ci	<LLD	<LLD	<LLD	<LLD
Xenon-135m	Ci	<LLD	<LLD	<LLD	<LLD
Xenon-138	Ci	<LLD	<LLD	<LLD	<LLD
Argon-41	Ci	<LLD	<LLD	<LLD	<LLD
Krypton-85	Ci	<LLD	<LLD	<LLD	<LLD
Krypton-85m	Ci	<LLD	<LLD	<LLD	<LLD
Krypton-87	Ci	<LLD	<LLD	<LLD	<LLD
Krypton-88	Ci	<LLD	<LLD	<LLD	<LLD
Total for period	Ci	1.77 E-01	3.06 E-04	<LLD	<LLD
2. Iodines					
Iodine-131	Ci	<LLD	<LLD	Note 1	Note 1
Iodine-132	Ci	<LLD	<LLD	Note 1	Note 1
Iodine-133	Ci	<LLD	<LLD	Note 1	Note 1
Iodine-135	Ci	<LLD	<LLD	Note 1	Note 1
Total for period	Ci	<LLD	<LLD	Note 1	Note 1
3. Particulates					
Chromium-51	Ci	<LLD	<LLD	Note 1	Note 1
Manganese-54	Ci	<LLD	<LLD	Note 1	Note 1
Cobalt-58	Ci	<LLD	<LLD	Note 1	Note 1
Iron-59	Ci	<LLD	<LLD	Note 1	Note 1
Cobalt-60	Ci	<LLD	<LLD	Note 1	Note 1
Zinc-65	Ci	<LLD	<LLD	Note 1	Note 1
Strontium-89	Ci	<LLD	<LLD	Note 1	Note 1
Strontium-90	Ci	<LLD	<LLD	Note 1	Note 1
Niobium-95	Ci	<LLD	<LLD	Note 1	Note 1
Zirconium-95	Ci	<LLD	<LLD	Note 1	Note 1
Molybdenum-99	Ci	<LLD	<LLD	Note 1	Note 1
Cesium-134	Ci	<LLD	<LLD	Note 1	Note 1
Cesium-137	Ci	<LLD	<LLD	Note 1	Note 1
Barium-140	Ci	<LLD	<LLD	Note 1	Note 1
Lanthanum-140	Ci	<LLD	<LLD	Note 1	Note 1
Cerium-141	Ci	<LLD	<LLD	Note 1	Note 1
Cerium-144	Ci	<LLD	<LLD	Note 1	Note 1
Total for period	Ci	<LLD	<LLD	Note 1	Note 1

Note 1 -The particulate and iodine activities released from Waste Gas Decay Tank and Containment Purge batch releases are included in the determinations from the continuous releases.

Appendix 2: Effluent and Waste Disposal Report (Continued)
Enclosure 2: Effluents Released

Table 1C: GASEOUS EFFLUENTS - GROUND LEVEL RELEASES

Nuclides Released	Unit	Continuous Mode		Batch Mode	
		Quarter 3	Quarter 4	Quarter 3	Quarter 4
1. Fission Gases					
Xenon-131m	Ci	<LLD	<LLD	<LLD	4.18 E-02
Xenon-133	Ci	<LLD	1.01 E+00	3.15 E-04	2.33 E-01
Xenon-133m	Ci	<LLD	<LLD	<LLD	9.29 E-03
Xenon-135	Ci	<LLD	<LLD	<LLD	1.02 E-01
Xenon-135m	Ci	<LLD	<LLD	<LLD	9.29 E-04
Xenon-138	Ci	<LLD	<LLD	<LLD	6.97 E-04
Argon-41	Ci	<LLD	<LLD	<LLD	<LLD
Krypton-85	Ci	<LLD	<LLD	5.84 E-04	7.90 E-03
Krypton-85m	Ci	<LLD	<LLD	<LLD	1.25 E-02
Krypton-87	Ci	<LLD	<LLD	<LLD	4.42 E-03
Krypton-88	Ci	<LLD	<LLD	<LLD	1.57 E-02
Total for period	Ci	<LLD	1.01 E+00	8.99 E-04	4.29 E-01
2. Iodines					
Iodine-131	Ci	<LLD	<LLD	Note 1	Note 1
Iodine-133	Ci	<LLD	<LLD	Note 1	Note 1
Iodine-135	Ci	<LLD	<LLD	Note 1	Note 1
Total for period	Ci	<LLD	<LLD	Note 1	Note 1
3. Particulates					
Chromium-51	Ci	<LLD	<LLD	Note 1	Note 1
Manganese-54	Ci	<LLD	<LLD	Note 1	Note 1
Cobalt-58	Ci	<LLD	<LLD	Note 1	5.04 E-07
Iron-59	Ci	<LLD	<LLD	Note 1	Note 1
Cobalt-60	Ci	<LLD	<LLD	Note 1	3.79 E-09
Zinc-65	Ci	<LLD	<LLD	Note 1	Note 1
Strontium-89	Ci	<LLD	<LLD	Note 1	Note 1
Strontium-90	Ci	<LLD	<LLD	Note 1	Note 1
Niobium-95	Ci	<LLD	<LLD	Note 1	Note 1
Zirconium-95	Ci	<LLD	<LLD	Note 1	Note 1
Molybdenum-99	Ci	<LLD	<LLD	Note 1	Note 1
Cesium-134	Ci	<LLD	<LLD	Note 1	Note 1
Cesium-137	Ci	<LLD	<LLD	Note 1	Note 1
Barium-140	Ci	<LLD	<LLD	Note 1	Note 1
Lanthanum-140	Ci	<LLD	<LLD	Note 1	Note 1
Cerium-141	Ci	<LLD	<LLD	Note 1	Note 1
Cerium-144	Ci	<LLD	<LLD	Note 1	Note 1
Total for period	Ci	<LLD	<LLD	Note 1	5.08 E-07

Note 1 -The particulate and iodine activities released from Waste Gas Decay Tank and Containment Purge batch releases are included in the determinations from the continuous releases.

Appendix 2: Effluent and Waste Disposal Report (Continued)
Enclosure 2: Effluents Released

Table 2A: LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES

		Unit	Quarter 1	Quarter 2	Est. Total Error %
A. Fission and Activation products					
1	Total release (not including tritium, gases, alpha)	Ci	4.83 E-03	4.93 E-03	3.28 E+01
2	Average diluted concentration during period	μCi/ml	9.30 E-10	9.61 E-10	
3	Percent of applicable limit	%	7.34 E-02	1.48 E-01	
B. Tritium					
1	Total release	Ci	1.86 E+02	1.05 E+02	5.43 E+01
2	Average diluted concentration during period	μCi/ml	3.58 E-05	2.05 E-05	
3	Percent of applicable limit	%	3.58 E+00	2.05 E+00	
C. Dissolved and entrained gases					
1	Total release	Ci	<LLD	<LLD	3.28 E+01
2	Average diluted concentration during period	μCi/ml	<LLD	<LLD	
3	Percent of applicable limit	%	0.00 E+00	0.00 E+00	
D. Gross alpha radioactivity					
1	Total release	Ci	<LLD	<LLD	3.28 E+01
E. Volume of waste released					
1	Continuous Releases	liters	7.76 E+06	6.76 E+06	2.00 E+01
2	Batch Releases	liters	4.66 E+05	4.37 E+05	2.00 E+01
F. Volume of dilution water					
1	Continuous Releases	liters	5.20 E+09	5.13 E+09	2.00 E+01
2	Batch Releases	liters	5.20 E+09	5.13 E+09	2.00 E+01

Appendix 2: Effluent and Waste Disposal Report (Continued)
Enclosure 2: Effluents Released

Table 2A: LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES

		Unit	Quarter 3	Quarter 4	Est. Total Error %
A. Fission and Activation products					
1	Total release (not including tritium, gases, alpha)	Ci	3.72 E-03	2.08 E-02	3.28 E+01
2	Average diluted concentration during period	μCi/ml	6.43 E-10	3.12 E-09	
3	Percent of applicable limit	%	2.57 E-01	4.47 E-01	
B. Tritium					
1	Total release	Ci	1.25 E+02	2.49 E+02	5.43 E+01
2	Average diluted concentration during period	μCi/ml	2.15 E-05	3.73 E-05	
3	Percent of applicable limit	%	2.15 E+00	3.72 E+00	
C. Dissolved and entrained gases					
1	Total release	Ci	<LLD	<LLD	3.28 E+01
2	Average diluted concentration during period	μCi/ml	<LLD	<LLD	
3	Percent of applicable limit	%	0.00 E+00	0.00 E+00	
D. Gross alpha radioactivity					
1	Total release	Ci	<LLD	<LLD	3.28 E+01
E. Volume of waste released					
1	Continuous Releases	liters	9.05 E+06	1.88 E+07	2.00 E+01
2	Batch Releases	liters	6.11 E+05	1.02 E+06	2.00 E+01
F. Volume of dilution water					
1	Continuous Releases	liters	5.79 E+09	6.68 E+09	2.00 E+01
2	Batch Releases	liters	5.79 E+09	6.68 E+09	2.00 E+01

Appendix 2: Effluent and Waste Disposal Report (Continued)

Enclosure 2: Effluents Released

Table 2B: LIQUID EFFLUENTS

Nuclides Released	Unit	Continuous Mode		Batch Mode	
		Quarter 1	Quarter 2	Quarter 1	Quarter 2
Sodium-24	Ci	<LLD	<LLD	<LLD	<LLD
Chromium-51	Ci	<LLD	<LLD	<LLD	<LLD
Manganese-54	Ci	<LLD	<LLD	7.44 E-05	1.17 E-04
Iron-55	Ci	<LLD	<LLD	3.83 E-04	4.44 E-04
Cobalt-57	Ci	<LLD	<LLD	3.78 E-06	3.57 E-05
Cobalt-58	Ci	<LLD	<LLD	9.25 E-04	9.08 E-04
Iron-59	Ci	<LLD	<LLD	<LLD	<LLD
Cobalt-60	Ci	<LLD	<LLD	1.11 E-03	1.79 E-03
Nickel-63	Ci	<LLD	<LLD	8.55 E-04	9.89 E-04
Strontium-89	Ci	<LLD	<LLD	<LLD	<LLD
Strontium-90	Ci	<LLD	<LLD	<LLD	<LLD
Zirconium-95	Ci	<LLD	<LLD	1.46 E-05	<LLD
Zirconium-97	Ci	<LLD	<LLD	<LLD	<LLD
Niobium-95	Ci	<LLD	<LLD	3.53 E-05	<LLD
Niobium-97	Ci	<LLD	<LLD	<LLD	<LLD
Technicium-99m	Ci	<LLD	<LLD	<LLD	<LLD
Ruthenium-106	Ci	<LLD	<LLD	<LLD	<LLD
Antimony-124	Ci	<LLD	<LLD	<LLD	<LLD
Antimony-125	Ci	<LLD	<LLD	1.42 E-03	6.40 E-04
Antimony-126	Ci	<LLD	<LLD	<LLD	<LLD
Tellurium-132	Ci	<LLD	<LLD	<LLD	<LLD
Iodine-131	Ci	<LLD	<LLD	<LLD	<LLD
Iodine-132	Ci	<LLD	<LLD	<LLD	<LLD
Iodine-133	Ci	<LLD	<LLD	<LLD	<LLD
Cesium-134	Ci	<LLD	<LLD	<LLD	<LLD
Cesium-137	Ci	<LLD	<LLD	8.16 E-06	9.36 E-06
Barium-140	Ci	<LLD	<LLD	<LLD	<LLD
Lanthanum-140	Ci	<LLD	<LLD	<LLD	<LLD
Cerium-141	Ci	<LLD	<LLD	<LLD	<LLD
Cerium-144	Ci	<LLD	<LLD	<LLD	<LLD
TOTAL	Ci	<LLD	<LLD	4.83 E-03	4.93 E-03
Xenon-133	Ci	<LLD	<LLD	<LLD	<LLD
Xenon-133m	Ci	<LLD	<LLD	<LLD	<LLD
Xenon-135	Ci	<LLD	<LLD	<LLD	<LLD
TOTAL	Ci	<LLD	<LLD	<LLD	<LLD
Tritium	Ci	1.16 E-01	9.86 E-02	1.86 E+02	1.05 E+02

Appendix 2: Effluent and Waste Disposal Report (Continued)

Enclosure 2: Effluents Released

Table 2B: LIQUID EFFLUENTS

Nuclides Released	Unit	Continuous Mode		Batch Mode	
		Quarter 3	Quarter 4	Quarter 3	Quarter 4
Sodium-24	Ci	<LLD	<LLD	<LLD	<LLD
Chromium-51	Ci	<LLD	<LLD	<LLD	7.53 E-04
Manganese-54	Ci	<LLD	<LLD	1.30 E-05	6.38 E-05
Iron-55	Ci	<LLD	<LLD	3.56 E-04	1.7 E-03
Cobalt-57	Ci	<LLD	<LLD	5.68 E-06	<LLD
Cobalt-58	Ci	<LLD	<LLD	1.98 E-04	1.26 E-02
Iron-59	Ci	<LLD	<LLD	<LLD	<LLD
Cobalt-60	Ci	<LLD	<LLD	9.29 E-04	1.12 E-03
Nickel-63	Ci	<LLD	<LLD	1.16 E-03	3.19 E-03
Strontium-89	Ci	<LLD	<LLD	<LLD	<LLD
Strontium-90	Ci	<LLD	<LLD	<LLD	<LLD
Zirconium-95	Ci	<LLD	<LLD	<LLD	9.87 E-05
Zirconium-97	Ci	<LLD	<LLD	<LLD	<LLD
Niobium-95	Ci	<LLD	<LLD	<LLD	1.51 E-04
Niobium-97	Ci	<LLD	<LLD	<LLD	<LLD
Technicium-99m	Ci	<LLD	<LLD	<LLD	<LLD
Ruthenium-106	Ci	<LLD	<LLD	<LLD	<LLD
Antimony-124	Ci	<LLD	<LLD	<LLD	<LLD
Antimony-125	Ci	<LLD	<LLD	9.23 E-04	1.09 E-03
Antimony-126	Ci	<LLD	<LLD	<LLD	<LLD
Tellurium-132	Ci	<LLD	<LLD	<LLD	<LLD
Iodine-131	Ci	<LLD	<LLD	<LLD	<LLD
Iodine-132	Ci	<LLD	<LLD	<LLD	<LLD
Iodine-133	Ci	<LLD	<LLD	<LLD	<LLD
Cesium-134	Ci	<LLD	<LLD	<LLD	<LLD
Cesium-137	Ci	<LLD	<LLD	1.37 E -04	<LLD
Barium-140	Ci	<LLD	<LLD	<LLD	<LLD
Lanthanum-140	Ci	<LLD	<LLD	<LLD	<LLD
Cerium-141	Ci	<LLD	<LLD	<LLD	<LLD
Cerium-144	Ci	<LLD	<LLD	<LLD	<LLD
TOTAL	Ci	<LLD	<LLD	3.72 E-03	2.08 E-02
Xenon-133	Ci	<LLD	<LLD	<LLD	<LLD
Xenon-133m	Ci	<LLD	<LLD	<LLD	<LLD
Xenon-135	Ci	<LLD	<LLD	<LLD	<LLD
TOTAL	Ci	<LLD	<LLD	<LLD	<LLD
Tritium	Ci	1.20 E-01	3.06 E-01	1.25 E+02	2.49 E+02

Appendix 2: Effluent and Waste Disposal Report (Continued)
Enclosure 3: Solid Waste Disposal

Table 3: SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

NOTE: Table 3 includes Harris Environmental Energy Center (HEEC) solid radioactive wastes processed and commingled with HNP solid radioactive wastes.

1. Solid Waste Shipped for Burial or Disposal (WASTE CLASS A)

NOTE: Values reported in Table 3 section 1.A.a and 1.A.b. refer to radioactive solid waste materials processed and buried during 2007.

A. Type of Waste

a. Spent Resins.

Note: Waste processed and buried during 2007.

Number of Shipments	3
Activity Shipped	4.32 E-01 Curies
Estimated Total Error	96%
Quantity Shipped	1.71E+00 m ³
Solidification Agent	N/A
Container Type	NRC-Approved Package
Shipment Form	Dewatered, Compacted

b. Dry compressible Waste (DAW), Mechanical Filters, Contaminated Equipment, etc.
Note: waste processed and buried during 2007.

Number of Shipments	11
Activity Shipped	1.18E+00 Curies
Estimated Total Error	96%
Quantity Shipped	1.99E+01m ³
Solidification Agent	N/A
Container Type	NRC-Approved Package
Shipment Form	Dewatered, Compacted

c. Irradiated Components, Control rods, etc.
No waste of this type was shipped during this Report Period.

d. Other (Describe)
No waste of this type was shipped during this Report Period.

Appendix 2: Effluent and Waste Disposal Report (Continued)

Enclosure 3: Solid Waste Disposal

Table 3: SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

1. Solid Waste Shipped for Burial or Disposal (WASTE CLASS A)
 - B. Estimate of Major Nuclide Composition (by type of waste)
 - a. Spent Resins..

Note: Waste processed and buried during 2007.

Nuclide	Percent Composition	Total Activity Curies
Ce-144	1.36E-02	5.86E-03
Co-58	2.67E-04	1.16E-04
Co-60	1.90E-01	8.19E-02
Cs-137	7.46E-02	3.22E-02
Fe-55	2.01E-01	8.67E-02
H-3	6.48E-02	2.80E-02
Mn-54	2.19E-02	9.45E-03
Ni-63	4.35E-01	1.88E-01
Total	1.00E+00	4.32E-01

Appendix 2: Effluent and Waste Disposal Report (Continued)

Enclosure 3: Solid Waste Disposal

Table 3: SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

1. Solid Waste Shipped for Burial or Disposal (WASTE CLASS A)

B. Estimate of Major Nuclide Composition (by type of waste)

b. Dry Compressible Waste (DAW), Mechanical Filters, Contaminated Equipment, etc.

Note: Waste processed and buried during 2007.

Nuclide	Percent Composition	Total Activity Curies
Am-241	6.35E-06	7.48E-06
C-14	9.03E-03	1.06E-02
Ce-144	1.48E-03	1.75E-03
Cm-242	4.26E-07	5.02E-07
Cm-243	1.96E-05	2.31E-05
Co-57	3.28E-04	3.86E-04
Co-58	2.11E-02	2.49E-02
Co-60	4.58E-01	5.39E-01
Cr-51	6.37E-03	7.50E-03
Cs-134	2.34E-06	2.75E-06
Cs-137	3.10E-02	3.64E-02
Fe-55	3.32E-01	3.91E-01
H-3	1.20E-03	1.42E-03
Mn-54	1.36E-02	1.60E-02
Nb-95	2.62E-02	3.09E-02
Ni-63	7.18E-02	8.45E-02
Pu-238	5.26E-06	6.20E-06
Pu-239	1.86E-06	2.19E-06
Pu-241	1.88E-04	2.21E-04
Sb-125	6.85E-03	8.07E-03
Sn-113	8.70E-04	1.02E-03
Te-123m	1.10E-04	1.29E-04
Zn-65	1.53E-03	1.80E-03
Zr-95	1.85E-02	2.18E-02
Total	1.00E+00	1.18E+00

C. Solid Waste Disposal

Number of Shipments * 14
 Mode of Transportation Rail, Truck
 Destination Envirocare Facility, Utah

* Four shipments were made from the Studsvik processing facility in Erwin, Tennessee to Envirocare. Ten shipments were made from the Energy Solutions Processing facility in Oak Ridge, Tennessee to Envirocare.

Appendix 2: Effluent and Waste Disposal Report (Continued)
Enclosure 3: Solid Waste Disposal

Table 3: SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

2. Solid Waste Shipped for Burial or Disposal (WASTE CLASS B)

- A. Type of Waste
 - a. Spent Resins.
No waste of this type was shipped during this Report Period.
 - b. Dry Compressible Waste (DAW), Mechanical Filters, Contaminated Equipment, etc.
No waste of this type was shipped during this Report Period.
 - c. Irradiated Components, Control rods
No waste of this type was shipped during this Report Period.
 - d. Other (Describe)
No waste of this type was shipped during this Report Period.

Appendix 2: Effluent and Waste Disposal Report (Continued)
Enclosure 3: Solid Waste Disposal

Table 3: SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

3. Solid Waste Shipped for Burial or Disposal (WASTE CLASS C)

NOTE: Values reported in Table 3 section 3.A.a. & 3.A.b refer to radioactive solid waste materials processed and buried during 2007.

A. Type of Waste

a. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.

Note: Waste processed and buried during 2007.

Number of Shipments	3
Activity Shipped	1.70E+02 Curies
Estimated Total Error	96.00%
Quantity Shipped	8.45E-01 m ³
Solidification Agent	N/A
Container Type	NRC-Approved Package
Shipment Form	Dewatered, Compacted

b. Dry Compressible Waste (DAW), Mechanical Filters, Contaminated Equipment, etc.

Note: Waste processed and Buried during 2007.

Number of Shipments	1
Activity Shipped	5.03E+00 Curies
Estimated Total Error	96.00%
Quantity Shipped	2.27E-01 m ³
Solidification Agent	N/A
Container Type	NRC-Approved Package
Shipment Form	Dewatered, Compacted

c. Irradiated Components, Control Rods, etc.

No waste of this type was shipped during this Report Period.

d. Other (Describe)

No waste of this type was shipped during this Report Period.

Appendix 2: Effluent and Waste Disposal Report (Continued)
Enclosure 3: Solid Waste Disposal

Table 3: SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

2. Solid Waste Shipped for Burial or Disposal (WASTE CLASS C)

B. Estimate of Major Nuclide Composition (by type of Waste)

- a. Spent Resins, Filter Sludges, Evaporator Bottoms, etc.
Note: Waste processed and buried during 2007.

Nuclide	Percent Composition	Total Activity Curies
C-14	5.69E-04	9.69E-02
Ce-144	2.67E-04	4.54E-02
Co-57	5.89E-03	1.00E+00
Co-58	3.29E-01	5.59E+01
Co-60	4.08E-02	6.95E+00
Cs-137	1.08E-04	1.84E-02
Fe-55	1.98E-01	3.37E+01
H-3	9.62E-05	1.64E-02
I-125	5.77E-06	9.81E-04
Mn-54	6.44E-02	1.10E+01
Ni-59	5.53E-03	9.41E-01
Ni-63	3.50E-01	5.96E+01
Sb-125	5.61E-03	9.55E-01
Sr-89	4.76E-05	8.10E-03
Sr-90	6.69E-05	1.14E-02
Tc-99	2.81E-05	4.78E-03
Total	1.00E+00	1.70E+02

Appendix 2: Effluent and Waste Disposal Report (Continued)
Enclosure 3: Solid Waste Disposal

Table 3: SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

3. Solid Waste Shipped for Burial or Disposal (WASTE CLASS C)

B. Estimate of Major Nuclide Composition (by type of Waste)

b. Dry Compressible Waste(DAW), Mechanical filters, Contaminated Equipment, etc.

Note: Waste processed and buried during 2007.

Nuclide	Percent Composition	Total Activity Curies
Am-241	2.41E-05	1.21E-04
C-14	5.24E-03	2.64E-02
Ce-144	2.06E-03	1.04E-02
Cm-242	1.43E-06	7.17E-06
Cm-243	4.53E-05	2.28E-04
Co-57	6.45E-04	3.24E-03
Co-58	2.29E-02	1.15E-01
Co-60	4.27E-01	2.15E+00
Cr-51	4.47E-05	2.25E-04
Cs-137	1.66E-03	8.34E-03
Fe-55	3.99E-01	2.01E+00
H-3	9.19E-05	4.62E-04
Mn-54	1.16E-02	5.82E-02
Nb-95	1.64E-04	8.23E-04
Ni-63	1.20E-01	6.05E-01
Pu-238	2.00E-05	1.01E-04
Pu-239	7.05E-06	3.55E-05
Pu-241	7.15E-04	3.60E-03
Sb-125	7.23E-03	3.64E-02
Zr-95	9.00E-04	4.53E-03
Total	9.99E-01	5.03E+00

C. Solid Waste Disposal

Number of Shipments	4
Mode of Transportation	Truck
Destination	Barnwell Facility, South Carolina

* Four shipments were made from the Studsvik Processing Facility in Erwin, Tennessee to Barnwell.

Appendix 3: Changes to the Offsite Dose Calculation Manual (ODCM)
Technical Specifications 6.14.c

During 2007, the ODCM was revised. Revision 19 became effective on April 1, 2007. A complete copy of Revision 19 of the ODCM is included as Attachment 1 to this report.

Appendix 4: Changes to the Environmental Monitoring Program

Enclosure 1: Environmental Monitoring Program Offsite Dose Calculation Manual Operational Requirement 3.12.1.c

The HNP Environmental Monitoring Program was revised in 2007 to include the addition of six groundwater monitoring wells in response to the NEI Groundwater Initiative 07-07. One well upstream of the hydrologic gradient was deleted from the Environmental Monitoring Program.

The location and description of HNP's groundwater monitoring wells is provided in ODCM Revision 19, Table 4.1 (page 4-7) and Figure 4.1-5 (4-20) which is included as Attachment 1 to this report.

Enclosure 2: Land Use Census Offsite Dose Calculation Manual Operational Requirements 3.12.2.a and 3.12.2.b

The Land Use Census that was completed in September 2007 resulted in a couple of changes to the Environmental Monitoring Program. The changes observed in the 2007 Land Use Census from the previous year survey were as follows: a garden was found in the NW sector at 2.4 miles this year where no garden was found in 2006. A closer garden was found this year in the SE sector at 2.6 miles. No gardens were found again this year in the WNW, NE, and S sectors. As in 2006, Harris Lake County Park was also included in the survey. Although there are not yet permanent residents on site, there are plans in the future for rangers and a campground. The resident in the S sector has again been included in the data even though they are technically just outside the 5-mile radius, because of historical prevailing winds.

Appendix 5: Additional Operational Requirements

Enclosure 1: Inoperability of Liquid Effluent Monitors ODCM Operational Requirement 3.3.3.10.b

Radioactivity Liquid Effluent Monitors Providing Alarms and Automatic Termination of Release were reviewed for operability during 2007 by the Condition Reporting Process pursuant to ODCM Operational Requirement 3.3.3.10.b. None were inoperable for greater than 30 continuous days during the reporting period.

Enclosure 2: Inoperability of Gaseous Effluent Monitors ODCM Operational Requirement 3.3.3.11.b

Radioactivity Gaseous Effluent Monitors Providing Alarms and Automatic Termination of Release were reviewed for operability during 2007 by the Condition Reporting Process pursuant to ODCM Operational Requirement 3.3.3.11.b. None were inoperable for greater than 30 continuous days during the reporting period.

Enclosure 3: Unprotected Outdoor Tanks Exceeding Limits Technical Specification 3.11.1.4.

No unprotected outdoor tank exceeded the Technical Specification limit of 10 Curies, excluding tritium or dissolved noble gases during this report period.

Enclosure 4: Gas Storage Tanks Exceeding Limits PLP-114, Attachment 5, Operational Requirement 1.1

No gas storage tank exceeded the PLP-114, Attachment 5 Operational Requirement limit of 1.05 E+05 Curies during this report period.

Enclosure 5: Groundwater Samples taken in support of Groundwater Protection Initiative NEI 07-07 Industry Groundwater Protection Initiative – Final Guidance Document, Objective 2.4

Samples were taken at various locations throughout the plant in support of the Groundwater Protection Initiative. Samples included the cistern enclosure of the Air Relief Valve for the Radwaste Discharge Line, and Vaults and Yard Drains that have collapsed and contain water that could potentially affect groundwater. No samples indicated tritium activity above detection limits.

Appendix 6: Major Modifications to Radwaste System
ODCM Operational Requirement F.3

No major modifications were made to the Radwaste System during this report period.

Appendix 7: Meteorological Data
ODCM Operational Requirement F.2

As allowed by the Footnote to Operational Requirement F.2, the annual summary of meteorological data will be retained electronically on file. This data will be provided to the NRC upon request.

Appendix 8: Assessment of Radiation Doses
ODCM Operational Requirement F.2

An Assessment of radiation doses to the maximum exposed member of the public due to radioactive liquid and gaseous effluents released from the site for each calendar quarter for the calendar year of this report, along with an annual total of each effluent pathway is in pursuant to the Operational Requirement F.2. Since 10CFR50, Appendix I is more restrictive than 40CFR190 for a single unit site, the assessment for 40CFR190 is performed when any of the 10CFR50, Appendix I limits are exceeded by a factor of 2 using LADTAP, XOQDOQ, and GASPAR II (NRC computer codes). The ODCM software is more conservative and is used for annual effluent dose assessment for demonstration of compliance with 10CFR50, Appendix I and 40CFR190.

Gaseous

The dose from the gaseous pathway is based on the highest calculated twelve-year annual average relative concentration (X/Q) and deposition factor ((D/Q) for particulates) at the most restrictive location at the site boundary.

	1 ST Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter	Annual Total
Noble Gas Gamma Dose (mrad)	1.21 E-05	2.09 E-08	2.35 E-08	1.81 E-04	1.93 E-04
10CFR50 Appendix I Limit (mrad)	5.00 E+00	5.00 E+00	5.00 E+00	5.00 E+00	1.00 E+01
Noble Gas Beta Dose (mrad)	3.58 E-05	6.21 E-08	2.84 E-07	3.39 E-04	3.75 E-04
10CFR50 Appendix I Limit (mrad)	1.00 E+01	1.00 E+01	1.00 E+01	1.00 E+01	2.00 E+01
Critical Organ Dose for I-131, I-133, Particulates, & H3 With T1/2 > 8 days (mrem)	7.49 E-02	9.09 E-02	8.49 E-02	6.71 E-02	3.18 E-01
10CFR50 Appendix I Limit (mrad)	7.5 E+00	7.5 E+00	7.5 E+00	7.5 E+00	1.50 E+01

Appendix 8: Assessment of Radiation Doses (Continued)
ODCM Operational Requirement F.2

Liquid

The dose from the liquid pathway is based on fish consumption from Harris Lake (parts of the lake are within the site boundary) plus drinking water from Lillington.

	1 ST Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter	Annual Total
Total Body Dose (mrem)	2.72 E-03	2.23 E-03	3.86 E-03	6.70 E-03	1.55 E-02
10CFR50 Appendix I Limit (mrem)	1.50 E+00	1.50 E+00	1.50 E+00	1.50 E+00	3.00 E+00
Critical Organ Dose (mrem)	3.67 E-03	2.34 E-03	4.83 E-03	1.16 E-02	1.99 E-02
10CFR50 Appendix I Limit (mrem)	5.00 E+00	5.00 E+00	5.00 E+00	5.00 E+00	1.00 E+01

40CFR190 Uranium Fuel Cycle Dose Calculation Results

Maximum Total Body Dose = 3.18 E-01 mrem

Liquid and Gas Effluent Contribution to Maximum Total Body Dose

Liquid Effluent Dose = 1.99 E-02 mrem

Gas Effluent Dose = 3.18 E-01 mrem

40CFR190 Limit = 25 mrem

Maximum Organ Dose = 3.18 E-01 mrem

Liquid and Gas Effluent Contribution to Maximum Organ Dose

Liquid Effluent Dose = 1.99 E-02 mrem

Gas Effluent Dose = 3.18 E-01 mrem

40CFR190 Limit = 75 mrem

Doses Due to Direct Radiation from the Harris Nuclear Plant:

Ongoing Environmental TLD Dose measurements show that the offsite Direct Radiation Dose is negligible. Components considered include Radwaste storage onsite and the Old Steam Generator Storage Facility.

Attachment 1: Offsite Dose Calculation Manual, Revision 19