



Serial: RNP-RA/08-0034

APR 23 2008

United States Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261/LICENSE NO. DPR-23

2007 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT

Ladies and Gentlemen:

Attached is the Annual Radioactive Effluent Release Report for the period of January 1, 2007, through December 31, 2007, for H. B. Robinson Steam Electric Plant (HBRSEP), Unit No. 2. This report is submitted in accordance with 10 CFR 50.36a(a)(2) and the HBRSEP, Unit No. 2, Technical Specifications Section 5.6.3.

If you have any questions concerning this report, please contact me at 843-857-1626.

Sincerely,

A handwritten signature in black ink that reads "Curt Castell".

C. A. Castell
Supervisor - Licensing/Regulatory Programs

RAC/rac

Attachment

c: V. M. McCree, NRC, Region II
M. G. Vaaler, NRC Project Manager, NRR (w/o Attachment)
NRC Resident Inspector

TE48
NER

EFFLUENT AND WASTE DISPOSAL

ANNUAL REPORT

January 1, 2007 - December 31, 2007

PROGRESS ENERGY CAROLINAS

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2

FACILITY OPERATING LICENSE NO. DPR-23

DOCKET NO. 50-261

TABLE OF CONTENTS

	<u>Description</u>	<u>Page</u>
I.	EXECUTIVE SUMMARY.....	4
	A. Discussion.....	4
	B. Significant Variances.....	8
	C. Regulatory Compliance.....	8
II.	SUPPLEMENTAL INFORMATION.....	9
	A. Regulatory Limits.....	9
	B. Measurements and Approximations of Total Radioactivity.....	10
	C. Estimated Total Errors.....	11
III.	GASEOUS EFFLUENTS.....	12
	A. Batch Releases.....	12
	B. Abnormal Releases.....	12
	C. Data Tables.....	12
IV.	LIQUID EFFLUENTS.....	18
	A. Batch Releases.....	18
	B. Abnormal Releases.....	18
	C. Data Tables.....	18
V.	SOLID WASTE AND IRRADIATED FUEL SHIPMENTS.....	24
	A. Waste Class A.....	24
	B. Waste Class B.....	26
	C. Waste Class C.....	28
VI.	40 CFR 190 DOSE CONFORMANCE.....	30
VII.	METEOROLOGICAL DATA.....	30
	A. Continuous Release Diffusion Analysis.....	30

LIST OF TABLES

<u>Table</u>	<u>Description</u>	<u>Page</u>
Table III-A	Gaseous Effluents - Summation of All Releases	13
Table III-B	Gaseous Effluents - Ground Level and Mixed Mode Releases	15
Table III-C	Typical Lower Limits of Detection for Gaseous Effluents	17
Table IV-A	Liquid Effluents - Summation of All Releases	19
Table IV-B	Liquid Effluents - Continuous Mode and Batch Mode Releases.....	21
Table IV-C	Typical Lower Limits of Detection for Liquid Effluents.....	23
Table VII-A	Joint Occurrence Frequencies for LOWNDDEG and LOWNDSPD – Continuous Releases	31

I. EXECUTIVE SUMMARY

A. Discussion

1. Effluent Controls

The H. B. Robinson Steam Electric Plant (HBRSEP), Unit No. 2, Offsite Dose Calculation Manual specifies controls and dose limits pertaining to releases of radioactivity to the environment. None of these controls or dose limits were exceeded during 2007.

2. Protection Standards

The main objective in the control of radiation is to ensure that any exposure is kept not only within regulatory limits, but As Low As Reasonably Achievable (ALARA). The ALARA concept applies to reducing radiation exposure both to workers at HBRSEP, Unit No. 2, and to the general public. Reasonably achievable means that radiation exposure reduction is based on sound environmental practices, economic decisions, and operating practices. By practicing ALARA, HBRSEP and Progress Energy Carolinas, Inc., minimize health risk and environmental detriment, and ensure that exposures are maintained well below regulatory limits.

3. Sources of Radioactivity Released

During normal operations of a nuclear power station, most of the fission products are retained within the fuel and fuel cladding. However, small quantities of radioactive fission and activation products are present in the reactor coolant water. The types of radioactive material released are noble gases, iodines and particulates, and tritium.

The noble gas fission products in the reactor coolant water are released as a gas when the coolant is depressurized. These gases are collected by a system designed for collection and storage for radioactive decay prior to release to the environment.

Small releases of radioactivity in liquids may occur from equipment associated with the reactor coolant system. These liquids are collected and processed for radioactivity removal, prior to and during release.

4. Noble Gas

Some of the fission products released in airborne effluents are radioactive isotopes of noble gases, such as argon and xenon. Noble gases are by nature inert and do not concentrate in humans or other organisms. Noble gases contribute to human radiation exposure as external exposure.

5. Iodines and Particulates

Annual releases of iodines, and those particulates with half-lives greater than eight days were small. Factors such as chemical reactivity and solubility in water, combined with high processing efficiencies, minimize their discharge. The main contribution of radioactive iodine to human exposure is to the thyroid gland, where the body concentrates iodine. The particulates contribute to internal exposure of tissues such as the muscle, liver, and intestines. These particulates can also be a source of exposure if deposited on the ground.

6. Tritium

Tritium, a radioactive isotope of hydrogen, is the predominate radionuclide in liquid and gaseous effluents. Tritium is produced in the reactor via a number of processes. Tritium is a weak beta particle emitter and contributes very little radiation exposure to the human body, and when tritium is inhaled, ingested, or absorbed it is dispersed throughout the body until eliminated.

7. Processing and Monitoring

Effluents are strictly controlled and monitored to ensure that radioactivity released to the environment is minimal and within regulatory limits. Effluent controls include the operation of radiation monitoring systems, in-plant and environmental sampling and analyses, quality assurance programs for both in-plant and environmental sampling and analyses, and procedures that address effluent and environmental monitoring.

The plant radiation monitoring system provides monitors that are designed to ensure that releases are below regulatory limits. Each instrument provides indication of the amount of radioactivity present and is equipped with alarms and indicators in the control room. The alarm setpoints are set below the regulatory limits, i.e., typically at less than 50 percent of the regulatory limit, to ensure that the limits are not exceeded. If a monitor alarms, a release to the environment from a tank is automatically suspended. Additionally, releases are sampled and analyzed in the laboratory prior to discharge to the environment. The sampling and analysis done in the laboratory provides a more sensitive and precise method of determining pre-effluent composition than in-plant monitoring instruments.

The plant has a meteorological tower, which is linked to computers that record the meteorological data. This meteorological data and the results of the Land Use Census are used to verify the ground level dispersion factors contained in the ODCM that are used in calculating the dose to the public.

In addition to in-plant equipment, the company maintains a Radiological Environmental Monitoring Program, which consists of devices used to sample the air and water in the environment. The samples collected from the surrounding environment are analyzed to determine the presence of radioactive material in the environment.

8. Exposure Pathways

Radiological exposure pathways are the methods by which people may become exposed to radioactive material. The major pathways of concern are those which could cause the highest calculated radiation dose. The projected pathways are determined from the type and amount of radioactive material that may have been released, the environmental transport mechanism, and the use of the environment.

Environmental transport mechanisms include, but are not limited to, hydrological (i.e., water) and meteorological (i.e., weather) characteristics of the area. Information on water flow, wind speed and direction, dietary intake of residents, recreational use of the area, and location of homes and farms in the area are some of the many factors used to calculate the potential exposure to offsite personnel.

The release of radioactive gaseous effluents includes pathways such as external whole body exposure, deposition on plants and soils, and human inhalation. The release of radioactive material in liquid effluents includes pathways such as fish consumption, and direct exposure from the lake at the shoreline and while swimming.

Even though radionuclides can reach humans by many different pathways, some radionuclides result in more exposure than others. The critical pathway is the one that, for a specific radionuclide, will result in the greatest exposure to a population, or a specific group of the population, called the critical group. The critical group may vary depending on the radionuclides involved, the age and diet of the group, and other cultural factors. The exposure may be received by the whole body or to a specific organ, with the organ receiving the largest fraction of the exposure called the critical organ.

The exposures to the general public in the area surrounding HBRSEP, Unit No. 2, are calculated for gaseous and liquid releases. The exposure due to radioactive material released in gaseous effluents is calculated using factors such as the amount of radioactive material released, the concentration beyond the site boundary, locations of exposure pathways, and usage factors. The exposures calculated due to radioactive materials released in liquid effluents are calculated using factors such as the total volume of liquid, the total volume of dilution water, field irrigation, and usage factors.

9. Plant Operation

With the exception of a refueling outage from April 7, 2007 to May 13, 2007 and a brief two day outage in May 2007, HBRSEP, Unit No. 2, operated continuously during 2007.

10. Results

The Radioactive Effluent Release Report is a detailed listing of the radioactivity released from the HBRSEP, Unit No. 2, during the period from January 1, 2007 through December 31, 2007. Some of the gaseous and liquid release parameters for this reporting period are summarized below:

GASEOUS EFFLUENTS

	<u>Units</u>	<u>1st Qtr</u>	<u>2nd Qtr</u>	<u>3rd Qtr</u>	<u>4th Qtr</u>
Fission & Act. Gas	Ci	3.68E-02	8.21E-01	9.75E-02	4.16E-02
I-131	Ci	6.47E-08	2.93E-06	< LLD	< LLD
Part. >8 Day Half-Lives	Ci	< LLD	6.35E-06	< LLD	< LLD
Tritium	Ci	1.46E+00	1.58E+00	1.87E+00	1.77E+00

LIQUID EFFLUENTS

	<u>Units</u>	<u>1st Qtr</u>	<u>2nd Qtr</u>	<u>3rd Qtr</u>	<u>4th Qtr</u>
Fission & Act. Products	Ci	9.39E-04	4.36E-03	2.56E-03	5.63E-03
Tritium	Ci	2.86E+02	5.37E+01	1.31E+01	4.74E+00
Dilution Volume	Liters	2.50E+11	2.12E+11	2.89E+11	2.86E+11
Waste Volume	Liters	8.23E+05	1.11E+06	3.46E+06	6.55E+04

During the period of January 1, 2007 through December 31, 2007, the estimated maximum individual offsite dose due to radioactivity released in effluents was:

Liquid Effluents:

- Total Body Dose 0.0000977 millirem
- Critical Organ Dose 0.000113 millirem, Liver

Gaseous Effluents:

- Beta Air Dose 0.00497 millirad
- Gamma Air Dose 0.00987 millirad
- Critical Organ Dose 0.0922 millirem, Thyroid

B. Significant Variances

1. No variances in historical data of significance were identified during this period.

C. Regulatory Compliance

1. The 10 CFR 50, Appendix I, doses were calculated using the Canberra Effluent Management System (EMS¹). The EMS Software provides day-by-day dose estimates that are conservative because all releases are assigned to the limiting receptor, using the continuous ground level dispersion factors calculated from 1978 meteorology. When projected on a day-by-day basis, utilizing conservative meteorological conditions, the dose commitment from gaseous and liquid effluents is a small fraction of the 10 CFR 50, Appendix I, limits. The direct radiation assessment to the most likely exposed member of the public is reported in the Annual Radiological Environmental Operating Report. During 2007, the results of the direct radiation assessment demonstrated no measurable effect above background for plant operations.
2. There were no changes to the waste solidification Process Control Program (PCP) during this reporting period. See page 34.
3. There were no changes to the Radioactive Waste Systems (i.e., liquid, gaseous, or solid) during this reporting period. See page 34.
4. There were no reportable instrumentation inoperability events during this reporting period. See page 34.
5. There were no outside liquid holdup tanks that exceeded the 10 curie limit during this reporting period. See page 34.
6. There were no Waste Gas Decay Tanks that exceeded the 1.9E+04 curie limit during this reporting period. See page 34.
7. There were no instances of missed compensatory samples during this reporting period. See page 34.
8. There were no revisions to the ODCM during this reporting period. See page 34.

¹ EMS, Effluent Management System Software is a product of Canberra Nuclear Industries used for determining dose from radioactive effluent releases.

9. There were no dose calculations performed or special reports made as a result of any spills or leaks during this period. See page 34.

II. SUPPLEMENTAL INFORMATION

A. Regulatory Limits

1. Fission and Activation Gases:

10 CFR 20 Limits (Instantaneous Release Rate)

Total Body Dose ≤ 500 mrem/yr

Skin Dose ≤ 3000 mrem/yr

10 CFR 50, Appendix I

For Calendar Quarter

Gamma Dose ≤ 5 mrad

Beta Dose ≤ 10 mrad

For Calendar Year

Gamma Dose ≤ 10 mrad

Beta Dose ≤ 20 mrad

2. Iodine-131 and 133, Tritium, and Particulates >8 day half-lives:

10 CFR 20 Limits (Instantaneous Release Rate)

Dose from Inhalation (only) to a child to any organ ≤ 1500 mrem/yr

10 CFR 50, Appendix I (Organ Doses)

For Calendar Quarter ≤ 7.5 mrem

For Calendar Year ≤ 15 mrem

3. Liquids:

Concentrations are specified in 10 CFR 20, Appendix B, Table 2, Column 2, for radionuclides other than dissolved or entrained noble gases. For dissolved or entrained noble gases, the concentration shall be limited to $2.00E-04$ $\mu\text{Ci/ml}$ total activity.

10 CFR 50, Appendix I

For Calendar Quarter

Total Body Dose ≤ 1.5 mrem

Any Organ Dose ≤ 5 mrem

For Calendar Year

Total Body Dose ≤ 3 mrem

Any Organ Dose ≤ 10 mrem

B. Measurements and Approximations of Total Radioactivity

1. Continuous Gaseous Releases

- a) Fission and Activation Gases - The total activity released is determined from the net count rate of the gaseous monitor, its calibration factor, and the total exhaust flow. The activity of radioactive gas is determined by the fraction of that radioactive gas in the isotopic analysis for that period.
- b) Iodines - The activity released as Iodine-131, 133, and 135 is based on isotopic analysis of the charcoal cartridge and particulate filter, and the total exhaust flow.
- c) Particulates - The activity released via particulates with half-lives greater than eight days is determined by isotopic analysis of particulate filters and the total exhaust flow.
- d) Tritium - The activity released as tritium is based on weekly grab sample analysis and total exhaust flow.

2. Batch Gaseous Releases

- a) Fission and Activation Gases - The activity released is based on the volume released and the activity of the individual nuclides obtained from an isotopic analysis of the grab sample taken prior to the release.
- b) Iodines - The iodines from mixed mode batch releases are included in the iodine determination from the mixed mode continuous Reactor Auxiliary Building release.
- c) Particulates - The particulates from mixed mode batch releases are included in the particulate determination from the mixed mode continuous Reactor Auxiliary Building release.
- d) Tritium - The activity released as tritium is based on the grab sample analysis of each batch and the batch volume.

3. Liquid Releases

- a) Fission and Activation Products - The total release values (not including tritium, gases, and alpha) are comprised of the sum of the individual radionuclide activities in each release to the discharge canal for the respective quarter. These values represent the activity known to be present in the liquid radwaste effluent.
- b) Tritium - The activity released as tritium is based on the grab sample analysis of each batch and the batch volume. For continuous releases, the activity released as tritium is based on analysis of a weekly composite sample. For continuous releases without a composite sampler, the tritium activity is based on analysis of daily grab samples or a composite of grab samples.
- c) Alpha - The measured alpha concentration in a monthly composite sample is used to calculate the total release and average diluted concentration during each period.
- d) Strontium-89, 90, and Iron-55 - The total release values are measured quarterly from composite samples.

C. Estimated Total Errors

1. Estimated total errors for gaseous effluents are based on uncertainties in counting equipment calibration, counting statistics, exhaust flow rates, exhaust sample flow rates, non-steady release rates, chemical yield factors, and sample losses for such items as charcoal cartridges.
2. Estimated total errors for liquid effluents are based on uncertainties in counting equipment calibration, counting statistics, non-steady release flow rate, sampling and mixing losses, and volume determinations.
3. Estimated total errors for solid waste are based on uncertainties in equipment calibration, dose rate measurements, geometry, and volume determinations.

III. GASEOUS EFFLUENTS

A. Batch Releases

	Jan - June 2007	July - Dec 2007
Number of batch releases	64	44
Total time period for batch releases	3.67E+04 min	1.76E+04 min
Maximum time period for a batch release	2.82E+03 min	7.35E+02 min
Average time period for a batch release	5.73E+02 min	4.01E+02 min
Minimum time period for a batch release	1.40E+01 min	2.36E+02 min

B. Abnormal Releases

	Jan - June 2007	July - Dec 2007
Number of releases	0	0
Total activity released	0.00E+00 Ci	0.00E+00 Ci

C. Data Tables

The following tables provide the details of gaseous releases:

- Table III-A Summation of All Releases
- Table III-B Ground Level and Mixed Mode Releases
- Table III-C Typical Lower Limits of Detection for Gaseous Effluents

TABLE III-A
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT - 2007
GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES

Unit	Quarter 1	Quarter 2	Est. Total Error %
------	--------------	--------------	-----------------------

A. Fission and Activation Gases

1. Total release	Ci	3.68E-02	8.21E-01	3.63E+01
2. Average release rate for period	μCi/sec	4.73E-03	1.04E-01	

B. Iodines

1. Total Iodine-131	Ci	6.47E-08	2.93E-06	1.74E+01
2. Average release rate for period	μCi/sec	8.32E-09	3.72E-07	

C. Particulates

1. Particulates with half-lives >8 days	Ci	< LLD	6.35E-06	1.05E+01
2. Average release rate for period	μCi/sec	< LLD	8.07E-07	
3. Gross alpha radioactivity	Ci	< LLD	< LLD	

D. Tritium

1. Total release	Ci	1.46E+00	1.58E+00	2.31E+01
2. Average release rate for period	μCi/sec	1.87E-01	2.01E-01	

E. Percent of 10 CFR 50, Appendix I

1. Quarterly limit				
Gamma air	%	1.60E-02	1.52E-01	
Beta air	%	2.90E-03	3.97E-02	
Organ: Thyroid	%	2.67E-01	2.97E-01	
2. Annual limit*				
Gamma air	%	8.00E-03	8.40E-02	
Beta air	%	1.45E-03	2.13E-02	
Organ: Thyroid	%	1.33E-01	2.82E-01	

*Cumulative total for the year-to-date using the methodology in the ODCM.

TABLE III-A
(Continued)
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT - 2007
GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES

	Unit	Quarter 3	Quarter 4	Est. Total Error %
A. Fission and Activation Gases				
1. Total release	Ci	9.75E-02	4.16E-02	3.63E+01
2. Average release rate for period	μCi/sec	1.23E-02	5.24E-03	
B. Iodines				
1. Total Iodine-131	Ci	< LLD	< LLD	1.74E+01
2. Average release rate for period	μCi/sec	< LLD	< LLD	
C. Particulates				
1. Particulates with half-lives >8 days	Ci	< LLD	< LLD	1.05E+01
2. Average release rate for period	μCi/sec	< LLD	< LLD	
3. Gross alpha radioactivity	Ci	< LLD	< LLD	
D. Tritium				
1. Total release	Ci	1.87E+00	1.77E+00	2.31E+01
2. Average release rate for period	μCi/sec	2.35E-01	2.22E-01	
E. Percent of 10 CFR 50, Appendix I				
1. Quarterly limit				
Gamma air	%	1.39E-02	1.55E-02	
Beta air	%	4.13E-03	2.96E-03	
Organ: ¹	%	3.42E-01	3.24E-01	
2. Annual limit*				
Gamma air	%	9.10E-02	9.87E-02	
Beta air	%	2.34E-02	2.48E-02	
Organ: Thyroid	%	4.53E-01	6.15E-01	

*Cumulative total for the year-to-date using the methodology in the ODCM.

¹ No critical organ was identified as receiving the highest dose. The ODCM specified organs of liver, tbody, thyroid, kidney, lung and GI-LLI all received an equal dose.

TABLE III-B
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT - 2007
GASEOUS EFFLUENTS - GROUND LEVEL AND MIXED MODE RELEASES

Nuclides Released	Unit	Continuous Mode		Batch Mode	
		Quarter 1	Quarter 2	Quarter 1	Quarter 2
1. Fission Gases					
Ar-41	Ci	< LLD	< LLD	3.35E-02	3.00E-01
Kr-85	Ci	< LLD	< LLD	< LLD	1.67E-02
Xe-131m	Ci	< LLD	< LLD	< LLD	2.26E-03
Xe-133	Ci	< LLD	3.78E-01	3.33E-03	1.21E-01
Xe-133m	Ci	< LLD	< LLD	1.44E-05	1.47E-03
Xe-135	Ci	< LLD	< LLD	5.03E-08	1.96E-03
Total for Period	Ci	< LLD	3.78E-01	3.68E-02	4.43E-01
2. Iodines¹					
I-131	Ci	6.47E-08	2.79E-06	< LLD	1.33E-07
I-132	Ci	< LLD	< LLD	< LLD	4.47E-05
I-133	Ci	< LLD	< LLD	< LLD	< LLD
Total for Period	Ci	6.47E-08	2.79E-06	< LLD	4.48E-05
3. Particulates¹					
Mn-54	Ci	< LLD	< LLD	< LLD	1.43E-07
Co-57	Ci	< LLD	< LLD	< LLD	1.23E-08
Co-58	Ci	< LLD	< LLD	< LLD	5.01E-06
Co-60	Ci	< LLD	< LLD	< LLD	9.78E-07
Nb-95	Ci	< LLD	< LLD	< LLD	1.08E-07
Zr-95	Ci	< LLD	< LLD	< LLD	5.25E-08
Cs-137	Ci	< LLD	< LLD	< LLD	4.76E-08
Total for Period	Ci	< LLD	< LLD	< LLD	6.35E-06

¹Mixed mode continuous accountability includes mixed mode batch accountability (excludes tritium).

TABLE III-B
(Continued)
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT - 2007
GASEOUS EFFLUENTS - GROUND LEVEL AND MIXED MODE RELEASES

Nuclides Released	Unit	Continuous Mode		Batch Mode	
		Quarter 3	Quarter 4	Quarter 3	Quarter 4
1. Fission Gases					
Ar-41	Ci	< LLD	< LLD	2.65E-02	3.22E-02
Xe-133	Ci	5.60E-02	< LLD	1.50E-02	9.38E-03
Total for Period	Ci	5.60E-02	< LLD	4.15E-02	4.16E-02
2. Iodines ¹					
I-131	Ci	< LLD	< LLD	< LLD	< LLD
I-133	Ci	< LLD	< LLD	< LLD	< LLD
Total for Period	Ci	< LLD	< LLD	< LLD	< LLD
3. Particulates ¹					
Co-60	Ci	< LLD	< LLD	< LLD	< LLD
Cs-137	Ci	< LLD	< LLD	< LLD	< LLD
Total for Period	Ci	< LLD	< LLD	< LLD	< LLD

¹Mixed mode continuous accountability includes mixed mode batch accountability (excludes tritium).

TABLE III-C
TYPICAL LOWER LIMITS OF DETECTION FOR GASEOUS EFFLUENTS

Nuclide	LLD ($\mu\text{Ci/cc}$)
H-3	2.10E-09
Ar-41	3.20E-08
Mn-54	1.69E-14
Co-58	8.45E-15
Fe-59	2.34E-14
Co-60	1.36E-14
Zn-65	2.60E-14
Br-82	5.19E-14
Kr-85	3.59E-06
Kr-85m	1.49E-08
Kr-87	4.22E-08
Kr-88	4.61E-08
Sr-89	1.84E-15
Sr-90	1.04E-15
Mo-99	2.21E-13
I-131	1.72E-14
Xe-131m	6.28E-07
I-133	2.11E-13
Xe-133	4.18E-08
Xe-133m	9.78E-08
Cs-134	6.11E-15
I-135	1.99E-11
Xe-135	8.93E-09
Xe-135m	3.26E-07
Cs-137	9.38E-15
Xe-138	6.70E-07
Ba-140	4.40E-14
La-140	1.44E-14
Ce-141	4.37E-15
Ce-144	3.90E-14
Gross Alpha	3.50E-15

IV. LIQUID EFFLUENTS

A. Batch Releases

	Jan - June 2007	July - Dec 2007
Number of batch releases	69	15
Total time period for batch releases	1.39E+04 min	4.61E+04 min
Maximum time period for a batch release	3.06E+02 min	4.35E+04 min
Average time period for a batch release	2.02E+02 min	3.07E+03 min
Minimum time period for a batch release	1.70E+01 min	1.70E+01 min
Average stream flow during release periods	4.67E+05 gpm	5.73E+05 gpm

B. Abnormal Releases

	Jan - June 2007	July - Dec 2007
Number of releases	0	0
Total activity released	0.00E+00 Ci	0.00E+00 Ci

C. Data Tables

The following tables provide the details of liquid releases:

- Table IV-A Summation of All Releases
- Table IV-B Continuous Mode and Batch Mode Releases
- Table IV-C Typical Lower Limits of Detection for Liquid Effluents

TABLE IV-A
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT - 2007
LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES

	Unit	Quarter 1	Quarter 2	Est. Total Error %
A. Fission and Activation Products				
1. Total release (not including tritium, gases, alpha)	Ci	9.39E-04	4.36E-03	1.07E+01
2. Average diluted concentration during period	μCi/ml	3.76E-12	2.06E-11	
B. Tritium				
1. Total release	Ci	2.86E+02	5.37E+01	9.20E+00
2. Average diluted concentration during period	μCi/ml	1.15E-06	2.54E-07	
C. Dissolved and entrained gases				
1. Total release	Ci	3.57E-03	6.72E-03	9.60E+00
2. Average diluted concentration during period	μCi/ml	1.43E-11	3.18E-11	
3. Percent of applicable limit	%	7.15E-06	1.59E-05	
D. Gross alpha radioactivity				
1. Total release	Ci	< LLD	< LLD	1.83E+01
E. Volume of waste released prior to dilution				
	Liters	8.23E+05	1.11E+06	
F. Volume of dilution water used during period				
	Liters	2.50E+11	2.12E+11	
G. Percent of 10 CFR 50, Appendix I				
1. Quarterly Limit				
Organ: Liver	%	6.00E-04	1.01E-03	
Total body	%	1.93E-03	2.87E-03	
2. Annual Limit*				
Organ: Liver	%	3.00E-04	8.04E-04	
Total body	%	9.63E-04	2.40E-03	

*Cumulative total for the year-to-date using the methodology in the ODCM.

TABLE IV-A
(Continued)
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT - 2007
LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES

	Unit	Quarter 3	Quarter 4	Est. Total Error %
A. Fission and Activation Products				
1. Total release (not including tritium, gases, alpha)	Ci	2.56E-03	5.63E-03	1.07E+01
2. Average diluted concentration during period	μCi/ml	8.86E-12	1.97E-11	
B. Tritium				
1. Total release	Ci	1.31E+01	4.74E+00	9.20E+00
2. Average diluted concentration during period	μCi/ml	4.54E-08	1.66E-08	
C. Dissolved and entrained gases				
1. Total release	Ci	1.91E-03	< LLD	9.60E+00
2. Average diluted concentration during period	μCi/ml	6.59E-12	< LLD	
3. Percent of applicable limit	%	3.30E-06	N/A	
D. Gross alpha radioactivity				
1. Total release	Ci	< LLD	< LLD	1.83E+01
E. Volume of waste released prior to dilution				
	Liters	3.46E+06	6.55E+04	
F. Volume of dilution water used during period				
	Liters	2.89E+11	2.86E+11	
G. Percent of 10 CFR 50, Appendix I				
1. Quarterly Limit				
Organ: Liver	%	6.45E-04	5.94E-06	
Total body	%	1.71E-03	1.17E-05	
2. Annual Limit*				
Organ: Liver	%	1.13E-03	1.13E-03	
Total body	%	3.25E-03	3.26E-03	

*Cumulative total for the year-to-date using the methodology in the ODCM.

TABLE IV-B
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT - 2007
LIQUID EFFLUENTS - CONTINUOUS MODE AND BATCH MODE RELEASES

Nuclides Released	Unit	Continuous Mode		Batch Mode	
		Quarter 1	Quarter 2	Quarter 1	Quarter 2
H-3	Ci	< LLD	< LLD	2.86E+02	5.37E+01
Fe-55	Ci	< LLD	< LLD	5.46E-05	4.17E-05
Co-58	Ci	< LLD	< LLD	< LLD	2.25E-03
Co-60	Ci	< LLD	< LLD	5.01E-04	6.52E-04
Sb-124	Ci	< LLD	< LLD	< LLD	1.94E-04
Sb-125	Ci	< LLD	< LLD	3.71E-04	1.21E-03
Cs-137	Ci	< LLD	< LLD	1.28E-05	1.37E-05
Total for Period	Ci	< LLD	< LLD	9.39E-04	4.36E-03
Kr-85	Ci	< LLD	< LLD	< LLD	1.55E-03
Xe-131m	Ci	< LLD	< LLD	< LLD	3.85E-04
Xe-133	Ci	< LLD	< LLD	3.57E-03	4.75E-03
Xe-133m	Ci	< LLD	< LLD	2.96E-06	3.31E-05
Xe-135	Ci	< LLD	< LLD	< LLD	4.05E-06
Total for Period	Ci	< LLD	< LLD	3.57E-03	6.72E-03

TABLE IV-B
(Continued)
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT - 2007
LIQUID EFFLUENTS - CONTINUOUS MODE AND BATCH MODE RELEASES

Nuclides Released	Unit	Continuous Mode		Batch Mode	
		Quarter 3	Quarter 4	Quarter 3	Quarter 4
H-3	Ci	< LLD	< LLD	1.31E+01	4.74E+00
F-18	Ci	5.77E-06	< LLD	< LLD	< LLD
Fe-55	Ci	< LLD	< LLD	2.73E-12	5.28E-03
Co-58	Ci	< LLD	< LLD	9.33E-05	1.52E-05
Co-60	Ci	< LLD	< LLD	9.55E-04	1.54E-04
Te-123m	Ci	< LLD	< LLD	3.57E-07	< LLD
Sb-124	Ci	< LLD	< LLD	1.21E-04	< LLD
Sb-125	Ci	< LLD	< LLD	1.36E-03	1.79E-04
Cs-137	Ci	< LLD	< LLD	2.62E-05	8.91E-06
Total for Period	Ci	5.77E-06	< LLD	2.55E-03	5.63E-03
Kr-85	Ci	< LLD	< LLD	1.63E-03	< LLD
Xe-133	Ci	< LLD	< LLD	2.73E-04	< LLD
Total for Period	Ci	< LLD	< LLD	1.91E-03	< LLD

TABLE IV-C
TYPICAL LOWER LIMITS OF DETECTION FOR LIQUID EFFLUENTS

Nuclide	LLD ($\mu\text{Ci/ml}$)
H-3	3.92E-06
Cr-51	8.61E-07
Mn-54	1.72E-07
Fe-55	2.35E-07
Co-57	7.01E-08
Co-58	1.75E-07
Fe-59	3.87E-07
Co-60	9.92E-08
Zn-65	4.29E-07
Sr-89	2.64E-08
Sr-90	1.72E-08
Nb-95	1.48E-07
Zr-95	2.66E-07
Mo-99	1.13E-06
Tc-99m	6.72E-08
Ag-110m	1.35E-07
Sn-113	1.30E-07
Sb-122	1.50E-07
Te-123m	7.46E-08
Sb-124	1.11E-07
Sb-125	3.30E-07
Xe-127	1.46E-06
I-131	1.09E-07
Xe-131m	3.23E-06
Te-132	9.55E-08
Xe-133	2.12E-07
Xe-133m	7.80E-07
Cs-134	1.62E-07
Xe-135	9.27E-08
Cs-137	1.47E-07
Ba-140	4.14E-07
La-140	9.29E-08
Ce-141	1.27E-07
Ce-144	5.57E-07
Gross Alpha	9.88E-08

V. SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

Report Time Period: January 1, 2007, through December 31, 2007

A. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL (not irradiated fuel)

Waste Class A

1.	Type of Waste	Waste Volume (m ³)	Activity (Ci)	Estimated Error (%)	No. Ship.
----	---------------	--------------------------------	---------------	---------------------	-----------

a.	Spent resins, filter sludges, evaporator bottoms, etc.	3.85E+00	5.39E+00	2.00E+01	1
b.	Dry compressible waste, contaminated equipment, etc.	1.89E+02	1.24E+00	2.00E+01	5
c.	Irradiated components, control rods, etc.	N/A	N/A	N/A	N/A
d.	Other: Oil	1.14E+00	1.52E-04	2.00E+01	1

2. Estimate of major nuclide composition (by type of waste)

	%	Ci	
a.	Ni-63	6.64E+01	3.58E+00
	Fe-55	2.13E+01	1.15E+00
	Co-60	7.66E+00	4.13E-01
	C-14	1.27E+00	6.82E-02
	Mn-54	9.13E-01	4.92E-02
	Sb-125	8.66E-01	4.67E-02
	Ni-59	7.16E-01	3.86E-02
	Ce-144	4.36E-01	2.35E-02
	Co-57	1.44E-01	7.78E-03
	H-3	9.44E-02	5.09E-03
	Co-58	9.04E-02	4.87E-03
	Ag-110m	3.02E-02	1.63E-03
	Others *	2.79E-02	1.50E-03
b.	Co-60	4.08E+01	5.04E-01
	Fe-55	1.58E+01	1.95E-01
	Ni-63	1.43E+01	1.78E-01
	C-14	7.99E+00	9.88E-02
	H-3	5.55E+00	6.86E-02
	Nb-95	5.25E+00	6.49E-02
	Co-58	5.24E+00	6.48E-02
	Zr-95	2.22E+00	2.75E-02
	Ce-144	1.17E+00	1.45E-02
	Cs-137	9.97E-01	1.23E-02
	Sb-125	6.80E-01	8.42E-03
	I-129	N/A	<1.19E-09
	Tc-99	N/A	<5.75E-10
c.	N/A	N/A	N/A
d.	Fe-55	7.68E+01	1.17E-04
	H-3	2.15E+01	3.28E-05
	Cs-137	1.00E+00	1.53E-06
	Co-60	6.36E-01	9.69E-07
	Ce-144	1.77E-02	2.69E-08
	I-129	N/A	<6.93E-12
	Tc-99	N/A	<3.02E-12
	C-14	N/A	<1.87E-12

* Others include Nb-95, Sr-89, Sr-90, Tc-99, I-129, & Cs-137
 Total Curie Quantity and Principle Radionuclides were determined by estimate.

3. Solid Waste Deposition

Number of Shipments: 6
Mode of Transportation Exclusive Use – Highway
Destination Duratek, Barnwell

V. SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

Report Time Period: January 1, 2007, through December 31, 2007

B. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL (not irradiated fuel)

Waste Class B

1.	Type of Waste	Waste Volume (m ³)	Activity (Ci)	Estimated Error (%)	No. Ship.
----	---------------	--------------------------------	---------------	---------------------	-----------

a.	Spent resins, filter sludges, evaporator bottoms, etc.	3.85E+00	8.24E+01	2.00E+01	1
b.	Dry compressible waste, contaminated equipment, etc.	N/A	N/A	N/A	N/A
c.	Irradiated components, control rods, etc.	N/A	N/A	N/A	N/A
e.	Other: N/A	N/A	N/A	N/A	N/A

2. Estimate of major nuclide composition (by type of waste)

		%	Ci
a.	Ni-63	6.32E+01	5.21E+01
	Fe-55	2.28E+01	1.88E+01
	Co-60	7.63E+00	6.29E+00
	Co-58	3.00E+00	2.47E+00
	C-14	8.34E-01	6.88E-01
	Ni-59	6.95E-01	5.73E-01
	Cs-137	4.90E-01	4.04E-01
	Ce-144	3.44E-01	2.84E-01
	Co-57	3.29E-01	2.71E-01
	Sb-125	2.43E-01	2.00E-01
	Mn-54	2.12E-01	1.75E-01
	Sr-90	1.23E-01	1.01E-01
	Others*	1.12E-01	9.21E-02
b.	N/A	N/A	N/A
c.	N/A	N/A	N/A
d.	N/A	N/A	N/A

* Others include: H-3, Tc-99, Ag-110m, & I-129

Total Curie Quantity and Principle Radionuclides were determined by estimate

3. Solid Waste Deposition

<u>Number of Shipments:</u>	1
<u>Mode of Transportation</u>	Exclusive Use – Highway
<u>Destination</u>	Barnwell

V. SOLID WASTE AND IRRADIATED FUEL SHIPMENTS
 Report Time Period: January 1, 2007, through December 31, 2007

C. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL (not irradiated fuel)

Waste Class C

2.	Type of Waste	Waste Volume (m ³)	Activity (Ci)	Estimated Error (%)	No. Ship.
----	---------------	--------------------------------	---------------	---------------------	-----------

a.	Spent resins, filter sludges, evaporator bottoms, etc.	N/A	N/A	N/A	N/A
b.	Dry compressible waste, contaminated equipment, etc.	N/A	N/A	N/A	N/A
c.	Irradiated components, control rods, etc.	N/A	N/A	N/A	N/A
d.	Other: N/A	N/A	N/A	N/A	N/A

2. Estimate of major nuclide composition (by type of waste)

	%	Ci	
a.	N/A	N/A	N/A
b.	N/A	N/A	N/A
c.	N/A	N/A	N/A
d.	N/A	N/A	N/A

3. Solid Waste Deposition

Number of Shipments: N/A

Mode of Transportation N/A

Destination N/A

VI. 40 CFR 190 DOSE CONFORMANCE

The direct radiation assessment to the most likely exposed member of the public is reported in the Annual Radiological Environmental Operating Report. The results of the assessment demonstrate no measurable affect above background from plant operations. Since no 10 CFR 50, Appendix I, limits have been exceeded and the evaluation of the Independent Spent Fuel Storage Installations indicate only a small fraction of the total dose to the environs, this demonstrates conformance with 40 CFR 190, "Environmental Radiation Protection Standards for Nuclear Power Operation."

VII. METEOROLOGICAL DATA

A. Continuous Release Diffusion Analysis

Table VII-A presents the number and frequency of wind direction occurrences by wind speed class as recorded at the onsite meteorological system during continuous release, for the period January 1, 2007, through December 31, 2007.

The frequencies are presented as a percent of total occurrences for each stability class, as well as a summary for all classes for the lower (11 meter) sensor elevation.

Pertinent information available from the tables is as follows:

1. Stability

Percent occurrence Pasquill Stability categories based on lower level (11 meter) wind distribution:

A	B	C	D	E	F	G
6.71	6.35	7.75	35.65	23.60	10.08	9.86

2. Wind Speed 11 Meter

Average Speed (mph) 3.89
 Percent Calm 9.98
 Percent Less than 3.5 mph 53.99

3. Wind Direction 11 Meter

Prevailing S
 Percent Occurrence 12.01

TABLE VII-A JOINT OCCURRENCE FREQUENCIES FOR LOWNDDEG AND LOWNDSPD - CONTINUOUS RELEASES

Atmospheric Stability Class A																	
Max (M/S)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Total
0.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1.56	0.00	0.00	0.07	0.05	0.08	0.12	0.09	0.01	0.00	0.01	0.07	0.10	0.07	0.01	0.00	0.00	0.68
3.35	0.21	0.10	0.19	0.10	0.04	0.04	0.31	0.39	0.32	0.40	1.11	0.81	0.45	0.18	0.09	0.02	4.76
5.59	0.13	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.30	0.10	0.07	0.02	0.03	0.08	0.38	0.05	1.17
8.27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.05	0.03	0.10
11.18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
24.59	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total	0.34	0.10	0.26	0.15	0.12	0.17	0.40	0.41	0.62	0.51	1.24	0.93	0.55	0.28	0.52	0.11	6.71

Atmospheric Stability Class B																	
Max (M/S)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Total
0.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1.56	0.01	0.03	0.12	0.17	0.30	0.13	0.05	0.05	0.03	0.04	0.22	0.20	0.12	0.04	0.01	0.00	1.55
3.35	0.41	0.39	0.24	0.24	0.04	0.08	0.30	0.40	0.20	0.32	0.58	0.22	0.21	0.17	0.13	0.14	4.07
5.59	0.18	0.03	0.00	0.00	0.00	0.00	0.00	0.00	0.10	0.04	0.07	0.02	0.02	0.04	0.12	0.05	0.68
8.27	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.01	0.00	0.04
11.18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
24.59	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total	0.62	0.45	0.36	0.41	0.34	0.21	0.35	0.45	0.33	0.41	0.86	0.44	0.35	0.26	0.28	0.20	6.35

Atmospheric Stability Class C																	
Max (M/S)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Total
0.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1.56	0.05	0.12	0.30	0.35	0.40	0.38	0.39	0.12	0.10	0.12	0.19	0.19	0.10	0.03	0.03	0.05	2.93
3.35	0.61	0.49	0.29	0.15	0.08	0.04	0.13	0.41	0.29	0.35	0.39	0.20	0.08	0.15	0.22	0.28	4.16
5.59	0.12	0.03	0.00	0.00	0.00	0.00	0.00	0.00	0.09	0.08	0.05	0.00	0.00	0.08	0.05	0.10	0.61
8.27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.00	0.03
11.18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.00	0.02
24.59	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total	0.78	0.64	0.59	0.51	0.48	0.42	0.52	0.53	0.48	0.55	0.63	0.39	0.18	0.27	0.36	0.43	7.75

Atmospheric Stability Class D																	
Max (M/S)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Total
0.34	0.01	0.02	0.02	0.02	0.02	0.01	0.01	0.02	0.01	0.01	0.01	0.01	0.01	0.01	0.00	0.00	0.19
1.56	0.71	1.84	1.86	1.55	1.22	1.05	1.11	1.28	0.77	0.80	0.74	0.45	0.59	0.55	0.29	0.27	15.07
3.35	3.12	3.34	0.80	0.35	0.21	0.02	0.05	1.46	1.75	1.60	0.95	0.27	0.33	0.50	0.48	0.90	16.13
5.59	1.07	0.27	0.04	0.00	0.00	0.00	0.00	0.17	1.07	0.14	0.08	0.02	0.05	0.13	0.27	0.66	3.98
8.27	0.08	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.04	0.00	0.00	0.00	0.00	0.03	0.09	0.03	0.28
11.18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.01
24.59	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total	4.99	5.47	2.72	1.92	1.44	1.09	1.17	2.92	3.65	2.55	1.78	0.75	0.98	1.22	1.13	1.86	35.65

Atmospheric Stability Class E																		
Max (M/S)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Total	
0.34	0.07	0.10	0.12	0.07	0.02	0.02	0.01	0.13	0.29	0.30	0.17	0.14	0.09	0.08	0.06	0.07	1.76	
1.56	0.56	0.74	0.90	0.53	0.17	0.14	0.08	1.02	2.22	2.29	1.31	1.04	0.67	0.61	0.46	0.55	13.30	
3.35	0.54	0.05	0.02	0.07	0.00	0.00	0.04	0.61	1.56	1.43	0.44	0.13	0.14	0.45	0.55	1.54	7.59	
5.59	0.04	0.00	0.00	0.00	0.00	0.00	0.00	0.04	0.17	0.03	0.01	0.00	0.01	0.02	0.12	0.45	0.91	
8.27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.01	0.01	0.03	
11.18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	
24.59	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Total	1.22	0.90	1.04	0.67	0.19	0.16	0.13	1.80	4.27	4.05	1.93	1.31	0.92	1.16	1.21	2.63	23.60	

Atmospheric Stability Class F																		
Max (M/S)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Total	
0.34	0.09	0.04	0.06	0.00	0.00	0.01	0.04	0.22	0.40	0.33	0.17	0.14	0.12	0.16	0.34	0.24	2.35	
1.56	0.25	0.10	0.18	0.01	0.00	0.02	0.10	0.62	1.13	0.93	0.48	0.39	0.34	0.44	0.96	0.66	6.62	
3.35	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.04	0.02	0.00	0.00	0.01	0.05	0.12	0.81	1.12	
5.59	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
8.27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
11.18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
24.59	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Total	0.37	0.14	0.24	0.01	0.00	0.03	0.14	0.87	1.57	1.28	0.64	0.52	0.48	0.65	1.43	1.71	10.08	

Atmospheric Stability Class G																		
Max (M/S)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Total	
0.34	0.28	0.03	0.00	0.02	0.03	0.03	0.11	0.41	0.65	0.55	0.24	0.13	0.29	0.42	1.40	1.09	5.68	
1.56	0.19	0.02	0.00	0.01	0.02	0.02	0.08	0.28	0.44	0.38	0.17	0.09	0.20	0.29	0.95	0.74	3.87	
3.35	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.28	0.31	
5.59	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
8.27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
11.18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
24.59	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Total	0.48	0.05	0.00	0.03	0.05	0.05	0.19	0.68	1.09	0.93	0.41	0.22	0.49	0.71	2.37	2.11	9.86	

Total Hours	8.80	7.74	5.21	3.70	2.63	2.13	2.90	7.68	12.01	10.29	7.50	4.56	3.95	4.56	7.30	9.04	100.00
--------------------	-------------	-------------	-------------	-------------	-------------	-------------	-------------	-------------	--------------	--------------	-------------	-------------	-------------	-------------	-------------	-------------	---------------

ADDENDUM 1

CHANGES TO ODCM, PCP, AND
RADIOACTIVE WASTE SYSTEMS

TABLE OF CONTENTS

<u>Description</u>	<u>Page</u>
I. Changes to the Offsite Dose Calculation Manual (ODCM)	34
II. Changes to the Radioactive Waste Systems	34
III. Changes to the Process Control Program (PCP).....	34
IV. Changes to the Land Use Census.....	34
V. Instrument Inoperability.....	34
VI. Liquid Holdup Tank Curie Limit.....	34
VII. Waste Gas Decay Tank Curie Limit	34
VIII. Missed Compensatory Samples	34
IX. Special Ground Water Protection Requirements	34

I. CHANGES TO THE OFFSITE DOSE CALCULATION MANUAL (ODCM)

There were no changes to the ODCM during this reporting period.

II. CHANGES TO THE RADIOACTIVE WASTE SYSTEMS

There were no changes to the Radioactive Waste Systems during this reporting period.

III. CHANGES TO THE PROCESS CONTROL PROGRAM (PCP)

There were no changes to the Process Control Program during this reporting period.

IV. CHANGES TO THE LAND USE CENSUS

The Land Use Census is performed every 24 months and was last performed in 2006. The results of the 2006 Land Use Census and average meteorological data for the last 10 years identified no changes that required an ODCM change. The next Land Use Census will be performed in 2008.

V. INSTRUMENT INOPERABILITY

There were no reportable instrumentation inoperability events during this reporting period.

VI. LIQUID HOLDUP TANK CURIE LIMIT

There were no outside liquid holdup tanks that exceeded the ten curie limit during this reporting period.

VII. WASTE GAS DECAY TANK CURIE LIMIT

There were no waste gas decay tanks with a curie content that exceeded the 1.90E+04 curie limit during this reporting period.

VIII. MISSED COMPENSATORY SAMPLES

There were no instances of missed compensatory samples during this reporting period.

IX. SPECIAL GROUND WATER PROTECTION REQUIREMENTS

There were no dose calculations performed or special reports made as a result of any spills or leaks during this period.

ADDENDUM 2
CORRECTIONS TO PREVIOUS
REPORTS
TABLE OF CONTENTS

<u>Description</u>	<u>Page</u>
I. DISCUSSION	36

I. DISCUSSION

There are no corrections to previous reports.