

# **Generic Environmental Impact Statement for License Renewal of Nuclear Plants**

## **Supplement 37**

### **Regarding Three Mile Island Nuclear Station, Unit 1**

#### **Draft Report for Comment**

## AVAILABILITY OF REFERENCE MATERIALS IN NRC PUBLICATIONS

### NRC Reference Material

As of November 1999, you may electronically access NUREG-series publications and other NRC records at NRC's Public Electronic Reading Room at <http://www.nrc.gov/reading-rm.html>.

Publicly released records include, to name a few, NUREG-series publications; *Federal Register* notices; applicant, licensee, and vendor documents and correspondence; NRC correspondence and internal memoranda; bulletins and information notices; inspection and investigative reports; licensee event reports; and Commission papers and their attachments.

NRC publications in the NUREG series, NRC regulations, and *Title 10, Energy*, in the Code of *Federal Regulations* may also be purchased from one of these two sources.

1. The Superintendent of Documents  
U.S. Government Printing Office  
Mail Stop SSOP  
Washington, DC 20402-0001  
Internet: [bookstore.gpo.gov](http://bookstore.gpo.gov)  
Telephone: 202-512-1800  
Fax: 202-512-2250
2. The National Technical Information Service  
Springfield, VA 22161-0002  
[www.ntis.gov](http://www.ntis.gov)  
1-800-553-6847 or, locally, 703-605-6000

A single copy of each NRC draft report for comment is available free, to the extent of supply, upon written request as follows:

Address: U.S. Nuclear Regulatory Commission  
Office of Administration  
Mail, Distribution and Messenger Team  
Washington, DC 20555-0001  
E-mail: [DISTRIBUTION@nrc.gov](mailto:DISTRIBUTION@nrc.gov)  
Facsimile: 301-415-2289

Some publications in the NUREG series that are posted at NRC's Web site address <http://www.nrc.gov/reading-rm/doc-collections/nuregs> are updated periodically and may differ from the last printed version. Although references to material found on a Web site bear the date the material was accessed, the material available on the date cited may subsequently be removed from the site.

### Non-NRC Reference Material

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, and transactions, *Federal Register* notices, Federal and State legislation, and congressional reports. Such documents as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings may be purchased from their sponsoring organization.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at—

The NRC Technical Library  
Two White Flint North  
11545 Rockville Pike  
Rockville, MD 20852-2738

These standards are available in the library for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from—

American National Standards Institute  
11 West 42<sup>nd</sup> Street  
New York, NY 10036-8002  
[www.ansi.org](http://www.ansi.org)  
212-642-4900

Legally binding regulatory requirements are stated only in laws; NRC regulations; licenses, including technical specifications; or orders, not in NUREG-series publications. The views expressed in contractor-prepared publications in this series are not necessarily those of the NRC.

The NUREG series comprises (1) technical and administrative reports and books prepared by the staff (NUREG-XXXX) or agency contractors (NUREG/CR-XXXX), (2) proceedings of conferences (NUREG/CP-XXXX), (3) reports resulting from international agreements (NUREG/IA-XXXX), (4) brochures (NUREG/BR-XXXX), and (5) compilations of legal decisions and orders of the Commission and Atomic and Safety Licensing Boards and of Directors' decisions under Section 2.206 of NRC's regulations (NUREG-0750).

# **Generic Environmental Impact Statement for License Renewal of Nuclear Plants**

## **Supplement 37**

### **Regarding Three Mile Island Nuclear Station, Unit 1**

## **Draft Report for Comment**

Manuscript Completed: November 2008  
Date Published: December 2008

Proposed Action Issuance of a renewed operating license DPR-50 for Three Mile Island Nuclear Station, Unit 1, in Londonderry Township in Dauphin County, Pennsylvania.

Type of Statement Draft Supplemental Environmental Impact Statement

Agency Contact Sarah L. Lopas  
Mailstop O-11F1  
U.S. Nuclear Regulatory Commission  
Office of Nuclear Reactor Regulation  
Phone: 301-415-1147  
Email: sarah.lopas@nrc.gov

Comments Any interested party may submit comments on this supplemental EIS. Please specify NUREG-1437, Supplement 37, draft, in your comments. Comments must be received by March 4, 2009. Comments received after the expiration of the comment period will be considered if it is practical to do so but assurance of consideration of late comments will not be given. Comments may be emailed to [ThreeMileIslandEIS@nrc.gov](mailto:ThreeMileIslandEIS@nrc.gov) or mailed to:

Chief, Rulemaking, Directives and Editing Branch  
U.S. NRC  
Mail Stop T6-D59  
Washington, D.C. 20555-0001

## **ABSTRACT**

This draft supplemental environmental impact statement (EIS) has been prepared in response to an application submitted by AmerGen Energy Company, LLC to renew the operating license for Three Mile Island Nuclear Station, Unit 1 for an additional 20 years.

This draft supplemental EIS includes the preliminary analysis that evaluates the environmental impacts of the proposed action and alternatives to the proposed action. Alternatives considered include replacement power from new supercritical coal-fired generation and natural gas combined-cycle generation; energy conservation/energy efficiency; and a combination of alternatives that included natural gas combined-cycle generation, conservation/efficiency, and improvements to hydroelectric dams; and not renewing the license (the no-action alternative).

The preliminary recommendation is that the Commission determine that the adverse environmental impacts of license renewal for Three Mile Island Nuclear Station, Unit 1 are not so great that preserving the option of license renewal for energy-planning decisionmakers would be unreasonable.



1	<b>Table of Contents</b>	
2	Abstract.....	iii
3	Executive Summary .....	xv
4	Abbreviations and Acronyms .....	xxiii
5	1.0 Purpose and Need for Action .....	1-1
6	1.1 Proposed Federal Action .....	1-1
7	1.2 Purpose and Need for the Proposed Federal Action .....	1-1
8	1.3 Major Environmental Review Milestones.....	1-2
9	1.4 Generic Environmental Impact Statement.....	1-3
10	1.5 Supplemental Environmental Impact Statement .....	1-5
11	1.6 Cooperating Agencies .....	1-6
12	1.7 Consultations.....	1-6
13	1.8 Correspondence .....	1-7
14	1.9 Status of Compliance .....	1-8
15	1.10 References .....	1-11
16	2.0 Affected Environment.....	2-1
17	2.1 Facility Description .....	2-1
18	2.1.1 Reactor and Containment Systems.....	2-1
19	2.1.2 Radioactive Waste Management .....	2-5
20	2.1.2.1 Radioactive Liquid Waste .....	2-6
21	2.1.2.2 Radioactive Gaseous Waste .....	2-7
22	2.1.2.3 Solid Radioactive Waste.....	2-8
23	2.1.3 Nonradiological Wastes.....	2-9
24	2.1.3.1 Hazardous Waste .....	2-9
25	2.1.3.2 Residual Waste .....	2-10
26	2.1.3.3 Universal Waste .....	2-10
27	2.1.3.4 Mixed Waste.....	2-10
28	2.1.3.5 Permitted Discharges .....	2-11
29	2.1.3.6 Pollution Prevention and Waste Minimization .....	2-11
30	2.1.4 Plant Operation and Maintenance.....	2-12
31	2.1.5 Power Transmission System.....	2-12
32	2.1.6 Cooling and Auxiliary Water Systems .....	2-14
33	2.1.7 Facility Water Use and Quality .....	2-15
34	2.1.7.1 Ground Water Use.....	2-15
35	2.1.7.2 Surface Water Use .....	2-15
36	2.1.7.3 Surface Water Quality .....	2-16
37	2.2 Affected Environment .....	2-21
38	2.2.1 Land Use .....	2-21
39	2.2.2 Air and Meteorology .....	2-22

## Table of Contents

1	2.2.2.1	Regional Air Quality Impacts .....	2-25
2	2.2.3	Ground Water Resources.....	2-25
3	2.2.3.1	TMI-1 Water Supply Wells.....	2-26
4	2.2.3.2	TMI-1 Monitoring Wells.....	2-27
5	2.2.4	Surface Water Resources .....	2-28
6	2.2.5	Description of Aquatic Resources .....	2-31
7		Macroinvertebrates.....	2-31
8		Plankton.....	2-32
9		Fish.....	2-32
10	2.2.6	Terrestrial Resources .....	2-35
11	2.2.7	Threatened and Endangered Species.....	2-38
12	2.2.7.1	Aquatic Species.....	2-38
13	2.2.7.2	Terrestrial Species.....	2-39
14		Federally Protected and Formerly Protected Terrestrial Species .....	2-39
15		State Protected Terrestrial Species .....	2-40
16	2.2.8	Socioeconomic Factors .....	2-49
17	2.2.8.1	Housing .....	2-50
18	2.2.8.2	Public Services .....	2-51
19		Water Supply .....	2-51
20		Education.....	2-52
21		Transportation .....	2-53
22	2.2.8.3	Offsite Land Use.....	2-53
23		Dauphin County.....	2-53
24		Lancaster County .....	2-55
25	2.2.8.4	Visual Aesthetics and Noise .....	2-56
26	2.2.8.5	Demography .....	2-57
27		Transient Population.....	2-59
28		Migrant Farm Workers.....	2-60
29	2.2.8.6	Economy.....	2-62
30		Employment and Income.....	2-62
31		Unemployment .....	2-63
32		Taxes.....	2-63
33	2.2.9	Historic and Archaeological Resources.....	2-64
34	2.2.9.1	Cultural Background .....	2-64
35	2.2.9.2	Historic and Archaeological Resources.....	2-67
36	2.3	Related Federal and State Activities .....	2-70
37	2.4	References .....	2-70
38	3.0	Environmental Impacts of Refurbishment .....	3-1
39	3.1	Refurbishment Activities at TMI-1.....	3-2
40	3.2	Environmental Impacts of Refurbishment.....	3-4
41	3.2.1	Terrestrial Resources – Refurbishment Impacts .....	3-4
42	3.2.2	Threatened and Endangered Species.....	3-5
43	3.2.2.1	Terrestrial Species.....	3-5
44	3.2.2.2	Aquatic Species.....	3-5
45	3.2.3	Air Quality During Refurbishment (Non-Attainment and Maintenance Areas) .....	3-6



Table of Contents

1 3.2.4 Housing Impacts.....3-9

2 3.2.5 Public Services – Education (Refurbishment) .....3-10

3 3.2.6 Public Services – Public Utilities .....3-10

4 3.2.7 Public Services – Transportation.....3-10

5 3.2.8 Offsite Land Use (Refurbishment).....3-11

6 3.2.9 Historic and Archaeological Resources.....3-12

7 3.2.10 Environmental Justice .....3-13

8 3.3 Evaluation of New and Potentially Significant Information on Impacts of

9 Refurbishment .....3-13

10 3.4 Summary of Impacts of Refurbishment .....3-13

11 3.5 References .....3-13

12 4.0 Environmental Impacts of Operation .....4-1

13 4.1 Land Use .....4-1

14 4.2 Air Quality .....4-1

15 4.3 Ground Water .....4-2

16 4.3.1 Ground Water Use Conflicts (plants using >100 gpm) .....4-2

17 4.3.2 Ground Water Use Conflicts (make-up from a small river).....4-2

18 4.4 Surface Water.....4-3

19 4.4.1 Water Use Conflicts.....4-4

20 4.5 Aquatic Resources .....4-5

21 4.5.1 Generic Aquatic Ecology Issues.....4-6

22 4.6 Terrestrial Resources .....4-6

23 4.7 Threatened or Endangered Species.....4-7

24 4.7.1 Aquatic Species.....4-7

25 4.7.2 Terrestrial Species .....4-8

26 4.8 Human Health.....4-9

27 4.8.1 Generic Human Health Issues .....4-9

28 4.8.2 Microbiological Organisms – Public Health .....4-12

29 4.8.3 Electromagnetic Fields – Acute Shock.....4-15

30 4.8.4 Electromagnetic Fields – Chronic Effects.....4-17

31 4.9 Socioeconomics .....4-17

32 4.9.1 Generic Socioeconomic Issues .....4-18

33 4.9.2 Housing Impacts.....4-18

34 4.9.3 Public Services: Public Utility Impacts.....4-19

35 4.9.4 Offsite Land Use – License Renewal Period.....4-20

36 Population-Related Impacts .....4-20

37 Tax Revenue-Related Impacts .....4-21

38 4.9.5 Public Services: Transportation Impacts .....4-21

39 4.9.6 Historic and Archaeological Resources.....4-22

40 4.9.7 Environmental Justice .....4-24

41 Minority Population in 2000 .....4-25

42 Low-Income Population in 2000 .....4-26

43 Analysis of Impacts.....4-26

## Table of Contents

1	Subsistence Consumption of Fish and Wildlife .....	4-29
2	4.10 Evaluation of New and Potentially Significant Information .....	4-31
3	4.11 Cumulative Impacts .....	4-32
4	4.11.1 Cumulative Impacts on Water Resources .....	4-32
5	4.11.2 Cumulative Impacts on Aquatic Resources.....	4-34
6	4.11.3 Cumulative Impacts on Terrestrial Resources .....	4-36
7	4.11.4 Cumulative Human Health Impacts.....	4-38
8	4.11.5 Cumulative Socioeconomic Impacts .....	4-40
9	4.11.6 Summary of Cumulative Impacts .....	4-41
10	4.12 References .....	4-42
11	5.0 Environmental Impacts of Postulated Accidents .....	5-1
12	5.1 Design Basis Accidents .....	5-1
13	5.2 Severe Accidents.....	5-2
14	5.3 Severe Accident Mitigation Alternatives .....	5-3
15	5.3.1 Introduction.....	5-3
16	5.3.2 Estimate of Risk .....	5-4
17	5.3.3 Potential Plant Improvements .....	5-6
18	5.3.4 Evaluation of Risk Reduction and Costs of Improvements .....	5-7
19	5.3.5 Cost-Benefit Comparison .....	5-7
20	5.3.6 Conclusions.....	5-9
21	5.4 References .....	5-9
22	6.0 Environmental Impacts of the Uranium Fuel Cycle and Solid Waste Management .....	6-1
23	6.1 References .....	6-2
24	7.0 Environmental Impacts of Decommissioning .....	7-1
25	7.1 References .....	7-1
26	8.0 Environmental Impacts of Alternatives.....	8-1
27	8.1 Supercritical Coal-Fired Generation .....	8-3
28	8.1.1 Air Quality.....	8-5
29	Sulfur Oxides.....	8-6
30	Nitrogen Oxides.....	8-6
31	Particulates.....	8-7
32	Carbon Monoxide .....	8-7
33	Hazardous Air Pollutants .....	8-7
34	Carbon Dioxide.....	8-7
35	Summary of Air Quality.....	8-8
36	8.1.2 Ground Water Use and Quality .....	8-8
37	8.1.3 Surface Water Use and Quality.....	8-8
38	8.1.4 Terrestrial and Aquatic Ecology .....	8-9
39	Terrestrial Ecology.....	8-9
40	Aquatic Ecology.....	8-9
41	8.1.5 Human Health .....	8-9
42	Radiological Human Health Risks .....	8-10

Table of Contents

1	PAH Human Health Risks .....	8-10
2	Mercury Human Health Risks .....	8-11
3	NOx and SO <sub>2</sub> Human Health Risks .....	8-11
4	8.1.6 Socioeconomics .....	8-12
5	Land Use .....	8-12
6	Socioeconomics .....	8-13
7	Transportation .....	8-14
8	Aesthetics .....	8-14
9	Historic and Archaeological Resources .....	8-15
10	Environmental Justice .....	8-15
11	8.1.7 Waste Management .....	8-16
12	8.2 Natural Gas Combined-Cycle Generation .....	8-16
13	8.2.1 Air Quality .....	8-18
14	8.2.2 Ground Water Use and Quality .....	8-19
15	8.2.3 Surface Water Use and Quality .....	8-20
16	8.2.4 Terrestrial and Aquatic Ecology .....	8-20
17	Terrestrial Ecology .....	8-20
18	Aquatic Ecology .....	8-20
19	8.2.5 Human Health .....	8-21
20	8.2.6 Socioeconomics .....	8-21
21	Land Use .....	8-21
22	Socioeconomics .....	8-22
23	Transportation .....	8-23
24	Aesthetics .....	8-23
25	Historic and Archaeological Resources .....	8-24
26	Environmental Justice .....	8-24
27	8.2.7 Waste Management .....	8-24
28	8.3 Energy Conservation/Energy Efficiency .....	8-25
29	8.3.1 Air Quality .....	8-26
30	8.3.2 Ground Water Use and Quality .....	8-27
31	8.3.3 Surface Water Use and Quality .....	8-27
32	8.3.4 Terrestrial and Aquatic Ecology .....	8-27
33	Terrestrial Ecology .....	8-27
34	Aquatic Ecology .....	8-27
35	8.3.5 Human Health .....	8-27
36	8.3.6 Socioeconomics .....	8-28
37	Land Use .....	8-28
38	Socioeconomics .....	8-29
39	Transportation .....	8-29
40	Aesthetics .....	8-29
41	Historic and Archaeological Resources .....	8-29
42	Environmental Justice .....	8-29
43	8.3.7 Waste Management .....	8-29
44	8.4 Combination Alternative .....	8-30

Table of Contents

1	8.4.1	Air Quality.....	8-31
2	8.4.2	Ground Water Use and Quality.....	8-32
3	8.4.3	Surface Water Use and Quality.....	8-32
4	8.4.4	Terrestrial and Aquatic Ecology.....	8-32
5		Terrestrial Ecology.....	8-32
6		Aquatic Ecology.....	8-32
7	8.4.5	Human Health.....	8-33
8	8.4.6	Socioeconomics.....	8-33
9		Land Use.....	8-33
10		Socioeconomics.....	8-34
11		Transportation.....	8-34
12		Aesthetics.....	8-34
13		Historic and Archaeological Resources.....	8-35
14		Environmental Justice.....	8-35
15	8.4.7	Waste Management.....	8-35
16	8.5	Purchased Power.....	8-36
17	8.6	Alternatives Considered but Dismissed.....	8-36
18	8.6.1	Coal-Fired Integrated Gasification Combined-Cycle.....	8-36
19	8.6.2	New Nuclear.....	8-37
20	8.6.3	Wind Power.....	8-37
21	8.6.4	Solar Power.....	8-38
22	8.6.5	Wood Waste.....	8-38
23	8.6.6	Conventional Hydroelectric Power.....	8-39
24	8.6.7	Wave and Ocean Energy.....	8-39
25	8.6.8	Geothermal Power.....	8-39
26	8.6.9	Municipal Solid Waste.....	8-39
27	8.6.10	Biofuels.....	8-40
28	8.6.11	Oil-Fired Power.....	8-41
29	8.6.12	Fuel Cells.....	8-41
30	8.6.13	Delayed Retirement.....	8-41
31	8.7	No-Action Alternative.....	8-41
32	8.7.1	Air Quality.....	8-42
33	8.7.2	Ground Water Use and Quality.....	8-43
34	8.7.3	Surface Water Use and Quality.....	8-43
35	8.7.4	Aquatic and Terrestrial Ecology.....	8-43
36		Terrestrial Ecology.....	8-43
37		Aquatic Ecology.....	8-43
38	8.7.5	Human Health.....	8-43
39	8.7.6	Socioeconomics.....	8-44
40		Land Use.....	8-44
41		Socioeconomics.....	8-44
42		Transportation.....	8-44
43		Aesthetics.....	8-44
44		Historic and Archaeological Resources.....	8-44
45		Environmental Justice.....	8-45
46	8.7.7	Waste Management.....	8-45

Table of Contents

1 8.8 Alternatives Summary .....8-45

2 8.9 References .....8-47

3 9.0 Conclusion .....9-1

4 9.1 Environmental Impacts of License Renewal.....9-1

5 9.2 Comparison of Environmental Impacts of License Renewal and Alternatives.....9-2

6 9.3 Resource Commitments .....9-2

7 9.3.1 Unavoidable Adverse Environmental Impacts.....9-2

8 9.3.2 Relationship Between Local Short-Term Uses of the Environment and the

9 Maintenance and Enhancement of Long-Term Productivity .....9-3

10 9.3.3 Irreversible and Irrecoverable Commitments of Resources .....9-4

11 9.4 Recommendations.....9-4

12 10.0 List of Preparers.....10-1

13 11.0 Index .....11-1

14 A. Comments Received on the Three Mile Island Nuclear Station, Unit 1,

15 Environmental Review ..... A-1

16 B. NEPA Issues for License Renewal of Nuclear Power Plants ..... B-1

17 C. Applicable Regulations, Laws, and Agreements..... C-1

18 D. Consultation Correspondences ..... D-1

19 E. Chronology of Environmental Review Correspondence ..... E-1

20 F. U.S. Nuclear Regulatory Commission Staff Evaluation of Severe Accident

21 Mitigation Alternatives (SAMAs) for Three Mile Island Nuclear Station, Unit 1 in

22 Support of License Renewal Application Review..... F-1

23

24

**FIGURES**

25

26

27 Figure 1-1. Environmental Review Process .....1-2

28 Figure 1-2. Environmental Issues Evaluated During License Renewal .....1-5

29 Figure 2-1. Location of Three Mile Island Nuclear Station, Unit 1, 50-mi (80-km)

30 Region .....2-2

31 Figure 2-2. Location of Three Mile Island Nuclear Station, Unit 1, 6-mi (10-km) Region .....2-3

32 Figure 2-3. Three Mile Island Nuclear Station, Unit 1, General Site Layout .....2-4

33 Figure 2-4. Three Mile Island Nuclear Station, Unit 1, Transmission System.....2-13

34 Figure 2-5. Three Mile Island Nuclear Station, Unit 1, Inlet and Discharge

35 Temperatures .....2-17

Table of Contents

1 Figure 2-6. Three Mile Island Nuclear Station, Unit 1, Site Boundary Map.....2-23  
 2 Figure 2-7. Monthly Mean Flow of the Susquehanna River in 2004 and the Maximum,  
 3 Mean, and Minimum Monthly Mean Flow Date for 1891–2004 .....2-30  
 4 Figure 2-8. Three Mile Island Nuclear Station, Unit 1, Site Area Overview Map and  
 5 Transmission Lines .....2-36  
 6 Figure 4-1. Aggregate Minority Populations Within 50 Mi (80 km) of Three Mile Island  
 7 Nuclear Station, Unit 1 .....4-27  
 8 Figure 4-2. Low Income Populations Within 50 Mi (80 km) of Three Mile Island  
 9 Nuclear Station, Unit 1 .....4-28

10  
 11  
 12 **TABLES**  
 13

14 Table 1-1. Licenses and Permits .....1-9  
 15 Table 2-1. Monthly Average, Minimum, and Maximum  $\Delta T$  (°F) Based on Automatic  
 16 Temperature Sensors at the Intake Screen Pump House .....2-18  
 17 Table 2-2. National Pollutant Discharge Elimination System Effluent Limitations for  
 18 TMI-1 .....2-20  
 19 Table 2-3. Total Annual Ground Water Withdrawal (Gallons) and Average Daily  
 20 Withdrawal Rate (Gallons) for Industrial Wells, A, B, and C and  
 21 Combined for 2003–2005 .....2-27  
 22 Table 2-4. Rate of Tritiated Ground Water Migration to the Susquehanna River as  
 23 Affected by Onsite Pumping and Background Levels of Tritium (Curies  
 24 Per Year) .....2-28  
 25 Table 2-5. American Shad Passage at the Conowingo, Holtwood, Safe Harbor, and  
 26 Red Hill Dams on the Susquehanna River .....2-34  
 27 Table 2-6. Listed Aquatic and Terrestrial Species .....2-41  
 28 Table 2-7. TMI-1 Employee Residence by County .....2-50  
 29 Table 2-8. Housing in Dauphin and Lancaster Counties, Pennsylvania .....2-51  
 30 Table 2-9. Major Public Water Supply Systems.....2-52  
 31 Table 2-10. Major Commuting Routes in the Vicinity of the Three Mile Island Nuclear  
 32 Station and 2006 Average Annual Daily Traffic (AADT) Counts.....2-54  
 33 Table 2-11. Population and Percent Growth in Dauphin County and Lancaster County,  
 34 Pennsylvania, from 1970 to 2000, and projected for 2010 and 2050 .....2-57  
 35 Table 2-12. Demographic Profile of the Population in the TMI-1 Two-County  
 36 Socioeconomic Region of Influence in 2000.....2-58  
 37 Table 2-13. Demographic Profile of the Population in the TMI-1 Two-County  
 38 Socioeconomic Region of Influence in 2006 (Estimate) .....2-59  
 39 Table 2-14. Seasonal Housing in Counties Located within 50 Miles of TMI-1 .....2-59  
 40 Table 2-15. Migrant Farm Worker and Temporary Farm Labor in Counties Located  
 41 within 50 Miles of TMI-1 .....2-61  
 42 Table 2-16. Major Employers in Dauphin County in 2007 .....2-62  
 43 Table 2-17. Income Information for the TMI-1 Socioeconomic Region of Influence .....2-63  
 44 Table 2-18. TMI-1 Property Tax Paid and Percentage of Dauphin County,  
 45 Londonderry Township, and the Lower Dauphin School District from  
 46 Property Tax Revenues, 2000 to 2005 .....2-65

## Table of Contents

1	Table 3-1. Issues Related to Refurbishment at TMI-1 .....	3-1
2	Table 4-1. Land Use Issues .....	4-1
3	Table 4-2. Air Quality Issue.....	4-1
4	Table 4-3. Ground Water Use and Quality Issues. ....	4-2
5	Table 4-4. Surface Water Quality Issues .....	4-3
6	Table 4-5. Aquatic Resources Issues .....	4-6
7	Table 4-6. Terrestrial Resources Issues .....	4-7
8	Table 4-7. Threatened or Endangered Species.....	4-7
9	Table 4-8. Human Health Issues. ....	4-9
10	Table 4-9. Results of Induced Current Analysis.....	4-16
11	Table 4-10. Socioeconomic Issues .....	4-18
12	Table 4-11. Summary of Cumulative Impacts on Resources Areas. ....	4-41
13	Table 5-1. Issues Related to Postulated Accidents .....	5-1
14	Table 5-2. TMI-1 Internal Events Core Damage Frequency.....	5-5
15	Table 5-3 TMI-1 External Flooding Events Core Damage Frequency .....	5-5
16	Table 5-4. Breakdown of Population Dose by Containment Release Mode .....	5-6
17	Table 6-1. Issues Related to the Uranium Fuel Cycle and Solid Waste Management .....	6-1
18	Table 7-1. Issues Related Decommissioning.....	7-1
19	Table 8-1. Summary of Environmental Impacts of Supercritical Coal-Fired Generation	
20	Compared to Continued Operation of TMI-1. ....	8-5
21	Table 8-2. Summary of Environmental Impacts of Natural Gas Combined-Cycle	
22	Generation Compared to Continued Operation of TMI-1.....	8-18
23	Table 8-3. Summary of Environmental Impacts of Energy Conservation/Energy	
24	Efficiency Compared to Continued Operation of TMI-1. ....	8-26
25	Table 8-4. Summary of Environmental Impacts of the Combination Alternative	
26	Compared to Continued Operation of TMI-1. ....	8-31
27	Table 8-5. Summary of Environmental Impacts of the No Action Alternative Compared	
28	to Continued Operation of TMI-1. ....	8-42
29	Table 8-6. Summary of Environmental Impacts of Selected Alternatives Compared to	
30	Continued Operation of TMI-1. ....	8-46
31	Table 10-1. List of Preparers. ....	10-1
32	Table A-1. Commenters on the Scope of the Environmental Review .....	A-2
33	Table B-1. Summary of Issues and Findings .....	B-1
34	Table C-1. State Environmental Requirements .....	C-1
35	Table C-2. State Environmental Requirements .....	C-4
36	Table D-1. Consultation Correspondences.....	D-1
37	Table F-1.a TMI-1 Internal Events Core Damage Frequency.....	F-3
38	Table F-1.b TMI-1 External Flooding Events Core Damage Frequency.....	F-3
39	Table F-2. Breakdown of Population Dose by Containment Release Mode.....	F-4
40	Table F-3. TMI-1 PRA Historical Summary.....	F-6
41	Table F-4. TMI-1 Seismic Events Core Damage Frequency .....	F-9
42	Table F-5. TMI-1 Fire Areas and Their Contribution to Fire CDF.....	F-10
43	Table F-6. SAMA Cost/Benefit Screen Analysis for TMI-1 .....	F-22





## EXECUTIVE SUMMARY

### Background

By letter dated January 8, 2008, AmerGen Energy Company, LLC (AmerGen) submitted an application to the U.S. Nuclear Regulatory Commission (NRC) to issue a renewed operating license for Three Mile Island Nuclear Station, Unit 1 (TMI-1) for an additional 20-year period.

The following document and the review it encompasses are requirements of NRC regulations implementing Section 102 of the National Environmental Policy Act (NEPA), of the *United States Code* (42 U.S.C. 4321), in Title 10 of the *Code of Federal Regulations* (CFR), Part 51 (10 CFR Part 51). In 10 CFR 51.20(b)(2), the Commission indicates that issuing a renewed power reactor operating license requires preparation of an Environmental Impact Statement (EIS) or a supplement to an existing EIS. In addition, 10 CFR 51.95(c) states that the EIS prepared at the operating license renewal stage will be a supplement to the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437, Volumes 1 and 2 (NRC 1996, 1999).

Upon acceptance of AmerGen's application, we (the NRC staff) began the environmental review process described in 10 CFR Part 51 by publishing a Notice of Intent to prepare an EIS and conduct scoping. We conducted a site audit at the plant in late April 2008 and held public scoping meetings on May 1, 2008, in Middletown, Pennsylvania. In the preparation of this draft supplemental EIS for TMI-1, we reviewed AmerGen's environmental report and compared it to the GEIS, consulted with other agencies, conducted a review of the issues following the guidance set forth in NUREG-1555, Supplement 1: *Standard Review Plans for Environmental Reviews for Nuclear Power Plants, Supplement 1: Operating License Renewal* (NRC 2000), and considered the public comments received during the scoping process.

### Proposed Action

AmerGen initialized the proposed Federal action—issuing a renewed power reactor operating license—by submitting an application for license renewal of TMI-1, for which the existing license (DPR-50) expires April 19, 2014. NRC's Federal action is the decision whether to renew the license for an additional 20 years.

### Purpose and Need for Action

The purpose and need for the proposed action (issuance of a renewed license) is to provide an option that allows for power generation capability beyond the term of a current nuclear power plant operating license, and to meet future system generating needs, as determined by State, utility, and, where authorized, Federal (other than NRC) decisionmakers. This definition of purpose and need for action reflects the Commission's recognition that, unless there are findings in the safety review required by the Atomic Energy Act of 1954 or findings in the NEPA environmental analysis that would lead the NRC to reject a license renewal application, the NRC does not have a role in the energy-planning decisions of State regulators and utility officials as to whether a particular nuclear power plant should continue to operate.

## Summary

1 If the renewed license is issued, State regulatory agencies and AmerGen will ultimately decide  
2 whether the plant will continue to operate based on factors such as the need for power or other  
3 matters within the State's jurisdiction or the purview of the owners. If the operating license is not  
4 renewed, then the facility must be shut down on or before the expiration date of the current  
5 operating license, April 19, 2014.

## 6 **Environmental Impacts of License Renewal**

7 The supplemental EIS evaluates the potential environmental impacts of the proposed action.  
8 The environmental impacts from the proposed action can be SMALL, MODERATE, or LARGE.  
9 AmerGen and the NRC staff established separate processes for identifying and evaluating the  
10 significance of any new and significant information on the environmental impacts of license  
11 renewal of TMI-1. Neither AmerGen nor the NRC identified information that is both new and  
12 significant related to Category 1 issues that would call into question the conclusions in the  
13 GEIS. Similarly, neither the scoping process nor the NRC has identified any new issue  
14 applicable to TMI-1 that has a significant environmental impact. Therefore, the NRC staff relies  
15 upon the conclusions of the GEIS for all the Category 1 issues applicable to TMI-1.

### 16 **Land Use**

17 SMALL. The NRC did not identify any Category 2 impact issues for land use, nor did the staff  
18 identify any new and significant information during the environmental review. Therefore, there  
19 would be no impacts beyond those discussed in the GEIS.

### 20 **Air Quality**

21 SMALL. The NRC did not identify any Category 2 issues for the impact of transmission lines on  
22 air quality, nor did the staff identify any new or significant information during the environmental  
23 review. Therefore, for plant operation during the license renewal term, there are no impacts  
24 beyond those discussed in the GEIS.

25 However, air quality during refurbishment (in nonattainment and maintenance areas) is a  
26 Category 2 issue. Emission calculations for refurbishment activities at TMI-1 indicate that  
27 emissions are not expected to exceed emission budgets specified in the Pennsylvania State  
28 Implementation Plan, and on this basis, the NRC staff concludes that the impact of vehicle  
29 exhaust emissions resulting from refurbishment activities would be SMALL. Potential mitigation  
30 measures include implementation of a dust control plan and the use of vans and workforce shift  
31 changes to reduce the number of vehicles on the road at any one given time.

### 32 **Ground Water Use and Quality**

33 SMALL. Ground water use conflicts: potable and service water—plants using greater than 100  
34 gallons per minute; and plants using cooling towers withdrawing make-up water from a small  
35 river) are Category 2 issues related to license renewal at TMI-1. Information provided by  
36 AmerGen, including Susquehanna River Basin Commission (SRBC) pump test data, shows that  
37 TMI-1 ground water withdrawal has no effect on nearby ground water wells and ground water  
38 supplies. In addition, the withdrawal of surface water from the Susquehanna River is a small  
39 percentage of overall river flow and does not affect ground water levels in the area.

### 40 **Surface Water Use and Quality**

41 SMALL. Water use conflicts—plants with cooling ponds or cooling towers using make-up water  
42 from a small river with low flow—is a Category 2 issue related to license renewal at TMI-1.

1 Withdrawals of Susquehanna River water by TMI-1 are less than 1.6 percent of the lowest daily  
2 mean flow and less than 0.1 percent of the average annual flow of the river. TMI-1 also  
3 participates in the Cowanesque Lake water storage project, which releases water to the  
4 Susquehanna River during drought conditions.

#### 5 **Aquatic Resources**

6 SMALL. With regard to operation of TMI-1 during the license renewal term, the NRC did not  
7 identify any Category 2 issues for aquatic resources, nor did the staff identify any new and  
8 significant information during the environmental review. Therefore, there are no impacts beyond  
9 those discussed in the GEIS.

10 For refurbishment, when the transportation route of the new steam generators to the TMI-1 site  
11 is determined, AmerGen will need to consult with the appropriate State and Federal agencies  
12 regarding potential impacts of the transportation plan on aquatic resources and threatened and  
13 endangered aquatic species.

#### 14 **Terrestrial Resources**

15 SMALL. With regard to operation of TMI-1 during the license renewal term, the NRC did not  
16 identify any Category 2 issues for terrestrial resources, nor did the staff identify any new or  
17 significant information during the environmental review. Therefore, there are no impacts beyond  
18 those discussed in the GEIS.

19 However, impacts to terrestrial resources during refurbishment activities is a Category 2 issue.  
20 The majority of refurbishment activities will take place on existing facility grounds at TMI-1, and  
21 all new, permanent structures will be constructed on previously disturbed land. Although the  
22 exact transportation route of the replacement steam generators from Port Deposit, Maryland, to  
23 TMI-1, has not been determined at the time of this draft supplemental EIS's publication,  
24 AmerGen will be required to obtain all necessary Federal and State environmental and  
25 construction permits when the route is finalized. Potential mitigation measures to minimize  
26 impacts to terrestrial resources include installing silt fences to minimize sediment transport, the  
27 use of best management practices, and the restoration of cleared land upon completion of  
28 construction activities.

#### 29 **Threatened and Endangered Species**

30 SMALL. Impacts to threatened and endangered species during the period of extended operation  
31 and during refurbishment activities are Category 2 issues. The U.S. Fish and Wildlife Service  
32 indicated that no known Federally-listed threatened and endangered species occur within the  
33 project area; therefore, the proposed project would not likely impact any Federally-listed  
34 species. The Pennsylvania Department of Natural Resources indicated that although several  
35 State-listed species of concern are known to occur in the vicinity of the TMI-1 project site, no  
36 impact to these species is anticipated. Furthermore, the Pennsylvania Fish and Boat  
37 Commission indicated that no adverse impacts to State-listed rare, candidate, threatened, or  
38 endangered aquatic species are expected from the proposed project.

39 Refurbishment activities will take place on existing facility grounds at the TMI-1 site, and all new,  
40 permanent structures will be constructed on previously disturbed land; therefore, no impact to  
41 these species is anticipated. However, when the transportation route of the new steam

## Summary

1 generators to the TMI-1 site is determined, AmerGen will need to consult with the appropriate  
2 State and Federal agencies regarding potential impacts of the transportation plan on threatened  
3 and endangered species.

### 4 **Human Health**

5 SMALL. With regard to Category 1 human health issues during the license renewal term—  
6 microbiological organisms (occupational health), noise, radiation exposures to public,  
7 occupational radiation exposures, and electromagnetic fields (chronic effects)—the NRC staff  
8 did not identify any new or significant information during the environmental review. Therefore,  
9 there are no impacts beyond those discussed in the GEIS. Slightly higher radiation doses to  
10 members of the public are expected from TMI-1 during the refurbishment period. However,  
11 based on past regulatory compliance, the dose to a maximally exposed individual in the vicinity  
12 of TMI-1 for the refurbishment period is expected to continue to be a small fraction of the limits  
13 and standards specified in 10 CFR Part 20, Appendix I to 10 CFR Part 50, and 40 CFR Part  
14 190.

15 Microbiological organisms (public health) and electromagnetic fields— acute effects (electric  
16 shock) are Category 2 human health issues. When thermal discharge from TMI-1 is at its  
17 maximum temperature, and the Susquehanna River is at its maximum temperature, the  
18 resulting temperature of the mixed water in the vicinity of the TMI-1 discharge is approximately  
19 91.3 degrees Fahrenheit, which is well outside the optimal growth temperature range of  
20 thermophilic microbiological organisms, therefore the impact is SMALL. Potential mitigation  
21 measures to reduce human health impacts include monitoring for thermophilic organisms in the  
22 water and sediments near the discharge, as well as prohibiting recreational use near the  
23 discharge plume. NRC staff reviewed AmerGen’s analysis of electromagnetic fields—acute  
24 shock resulting from induced charges in metallic structures, and verified that none of TMI-1’s in-  
25 scope transmission lines have the capability to induce greater than 5 milliamperes in a vehicle  
26 parked beneath the lines. This finding conforms with National Electric Safety Code provisions  
27 for preventing electric shock from induced current. Potential mitigation measures include limiting  
28 public access to transmission line structures, installing signs at road crossings, and increasing  
29 transmission line clearances. The NRC staff considers the GEIS finding of “uncertain” for  
30 electromagnetic fields—chronic effects still appropriate and will continue to follow developments  
31 on this issue.

### 32 **Socioeconomics**

33 SMALL. The NRC identified no Category 1 public services and aesthetic impacts, or new and  
34 significant information during the environmental review. Therefore, there would be no impacts  
35 beyond those discussed in the GEIS. Category 2 socioeconomic impacts include housing  
36 impacts, public services (public utilities), offsite land use, public services (public transportation),  
37 and historic and archaeological resources. Since TMI-1 is located in a high-density population  
38 area, and growth control measures are not in effect, any changes in TMI-1 employment would  
39 have little noticeable effect on housing availability in the surrounding area. AmerGen has  
40 indicated they have no plans to add non-outage employees during the license renewal period;  
41 therefore non-outage employment levels at TMI-1 would remain relatively unchanged with no  
42 additional demand for public water and sewer services. This also applies to offsite land use and  
43 transportation issues – because non-outage employment levels at TMI-1 would remain relatively  
44 unchanged during the license renewal period, there would be no land use impacts related to

1 population or tax revenues, and no transportation impacts. Category 2 socioeconomic impacts  
2 related to refurbishment at TMI-1 would be SMALL, as the TMI-1 steam generator project is  
3 expected to require a one-time increase of outage workers for up to 70 days—a short duration  
4 of time.

5 No impacts to known historic and archaeological resources are expected from the continued  
6 operation of TMI-1 during the license renewal term. AmerGen has indicated no plans to change  
7 or modify the plant or transmission line structures. Based on the review of Pennsylvania  
8 Historical and Museum Commission files, archaeological surveys, assessments, and other  
9 information, the potential impacts on historic and archaeological resources at TMI-1 would be  
10 SMALL. Since TMI-1 is situated in an archaeologically sensitive area, development of a cultural  
11 resources management plan in addition to AmerGen's review procedures would serve to  
12 integrate cultural resource considerations with ongoing TMI-1 activities. Additionally, training of  
13 AmerGen staff in the Section 106 process would ensure that informed decisions are made when  
14 considering the effects of future projects on historic and archaeological resources. Lands that  
15 have not been surveyed should be investigated by a professional archaeologist prior to any  
16 ground disturbance. In addition, the historical farmstead site (36Da235) should be recorded and  
17 evaluated for eligibility. Because refurbishment activities will occur on previously disturbed land,  
18 the impacts associated with refurbishment are not expected to adversely affect historic or  
19 archaeological sites in the area of TMI-1 or TMI Unit 2. An analysis of minority and low-income  
20 populations residing within a 50-mile (80-kilometer) radius of TMI-1 indicated there would be no  
21 disproportionately high and adverse impacts to these populations from the continued operation  
22 of TMI-1 during the license renewal period. Based on recent monitoring results, concentrations  
23 of contaminants in native leafy vegetation, soils and sediments, surface water, and fish in areas  
24 surrounding TMI-1 have been low (at or near the threshold of detection) and seldom above  
25 background levels. Consequently, no disproportionately high and adverse human health  
26 impacts would be expected in special pathway receptor populations in the region as a result of  
27 subsistence consumption of fish and wildlife.

### 28 **Severe Accident Mitigation Alternatives**

29 Since TMI-1 had not previously considered alternatives to reduce the likelihood or potential  
30 consequences of a variety of highly uncommon but potentially serious accidents, NRC  
31 regulation 10 CFR 51.53(c)(3)(ii)(L) requires that TMI-1 evaluate Severe Accident Mitigation  
32 Alternatives (SAMAs) in the course of license renewal review. SAMAs are potential ways to  
33 reduce the risk or potential impacts of uncommon but potentially severe accidents, and may  
34 include changes to plant components, systems, procedures, and training.

35 Based on our review of potential SAMAs, we conclude that TMI-1 made a reasonable,  
36 comprehensive effort to identify and evaluate SAMAs. Based on the review of the SAMAs for  
37 TMI-1, and the plant improvements already made, we conclude that none of the potentially cost-  
38 beneficial SAMAs relate to adequately managing the effects of aging during the period of  
39 extended operation; therefore, they need not be implemented as part of the license renewal  
40 pursuant to 10 CFR Part 54.

## Summary

### 1 **Alternatives**

2 We considered the environmental impacts associated with alternatives to license renewal.  
3 These alternatives include other methods of power generation and not renewing the TMI-1  
4 operating license (the no-action alternative). Replacement power options considered were  
5 supercritical coal-fired generation, natural gas combined-cycle generation, and as part of the  
6 combination alternative, uprates to existing hydroelectric dams located in Pennsylvania.  
7 Wherever possible, we evaluated potential environmental impacts for these alternatives located  
8 both at the TMI-1 site and at some other unspecified alternate location. Energy  
9 conservation/energy efficiency, purchased power, and a combination alternative, which included  
10 natural gas combined-cycle generation, energy conservation/energy efficiency, and a series of  
11 uprates to hydroelectric dams, were also considered. We evaluated each alternative using the  
12 same impact areas that we used in evaluating impacts from license renewal. The results of this  
13 evaluation are summarized in the table on the following page.

### 14 **Comparison of Alternatives**

15 The coal-fired alternative is the least environmentally favorable alternative, due to: impacts to air  
16 quality from nitrogen oxides, sulfur oxides, particulate matter, polycyclic aromatic hydrocarbons,  
17 carbon monoxide, carbon dioxide, and mercury—and the corresponding human health impacts;  
18 construction impacts to aquatic, terrestrial, and potentially historic and archaeological resources  
19 are also factors that make the coal-fired alternative the least environmentally favorable  
20 alternative. The gas-fired alternative would have slightly lower air emissions, and impacts to  
21 aquatic, terrestrial, and historic and archaeological resources would vary depending upon  
22 location of the plant. Purchased power would likely have operational impacts that would include  
23 aspects of coal-fired, gas-fired, and existing nuclear generation.

24 The NRC notes that the energy conservation/energy efficiency alternative has SMALL impacts  
25 in all categories evaluated, and upon shut down of TMI-1, current operating impacts of TMI-1  
26 would cease. Therefore, the energy conservation/energy efficiency alternative is the  
27 environmentally preferred alternative to license renewal. All other alternatives capable of  
28 meeting the needs currently served by TMI-1 entail potentially greater impacts than the  
29 proposed action of license renewal of TMI-1. The no-action alternative does not meet the  
30 purpose and need of this draft SEIS, though if it triggers the energy conservation/energy  
31 efficiency action to replace the capacity currently supplied by TMI-1, it could result in an overall  
32 SMALL impact, as well.

### 33 **Recommendation**

34 Our preliminary recommendation is that the Commission determines that the adverse  
35 environmental impacts of license renewal for TMI-1 are not so great that preserving the option  
36 of license renewal for energy planning decisionmakers would be unreasonable. This  
37 recommendation is based on (1) the analysis and findings in the GEIS; (2) information  
38 submitted in the AmerGen's Environmental Report; (3) consultation with other Federal, State,  
39 and local agencies; (4) a review of other pertinent studies and reports; and (5) a consideration  
40 of public comments received during the scoping process.

41

<b>Alternative</b>	<b>Impact Area</b>						
	<b>Air Quality</b>	<b>Ground Water</b>	<b>Surface Water</b>	<b>Aquatic and Terrestrial Resources</b>	<b>Human Health</b>	<b>Socioeconomics</b>	<b>Waste Management</b>
<b>License Renewal</b>	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL	N/A
<b>Supercritical coal-fired alternative at a new site</b>	MODERATE	SMALL	SMALL	SMALL to LARGE	SMALL to MODERATE	SMALL to LARGE	SMALL
<b>Gas-fired alternative at the TMI-1 site</b>	MODERATE	SMALL	SMALL	SMALL	SMALL	SMALL to MODERATE	SMALL
<b>Gas-fired alternative at a new site</b>	MODERATE	SMALL	SMALL	SMALL to LARGE	SMALL	SMALL to MODERATE	SMALL
<b>Energy Conservation/ Energy Efficiency</b>	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL
<b>Combination of Alternatives</b>	SMALL to MODERATE	SMALL	SMALL	SMALL	SMALL	SMALL to MODERATE	SMALL
<b>No Action Alternative</b>	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL to MODERATE	SMALL





## ABBREVIATIONS AND ACRONYMS

1		
2	ACC	averted cleanup and decontamination costs
3	AEA	Atomic Energy Act of 1954
4	AEC	U.S. Atomic Energy Commission
5		
6	CDF	Core Damage Frequency
7	CEQ	Council on Environmental Quality
8	CFR	Code of Federal Regulations
9	CFS	cubic feet per second
10	COPC	chemicals of potential concern
11	CWA	Clean Water Act
12		
13	DBA	design-basis accident
14	DCNR	Pennsylvania Department of Conservation and Natural Resources
15	DOE	U.S. Department of Energy
16	DPR	demonstration project reactor
17	DSM	demand-side management
18		
19	EIA	Energy Information Administration (of DOE)
20	EIS	environmental impact statement
21	ELF-EMF	extremely low frequency-electromagnetic field
22	EMS	environmental management system
23	EOP	Emergency Operating Procedure
24	ER	environmental report
25	EPA	U.S. Environmental Protection Agency
26	ESA	Endangered Species Act
27	ESRP	Environmental Standard Review Plan, NUREG-1555, Supplement 1, Operating
28		License Renewal
29		
30	FAA	Federal Aviation Administration
31	FES	Final Environmental Statement
32	FR	Federal Register
33	FSAR	Final Safety Analysis Report
34	FWS	U.S. Fish and Wildlife Service
35		
36	GDC	general design criteria
37	GEIS	Generic Environmental Impact Statement for License Renewal of Nuclear Plants,
38		NUREG-1437
39	GPM	gallons per minute
40		
41	HLW	high-level waste
42		
43	Inc.	incorporated
44	IPE	Individual Plant Examination
45	IPEEE	Individual Plant Examination of External Events
46	ISFSI	independent spent fuel storage installation

## Abbreviations and Acronyms

1		
2	LLC	limited liability corporation
3	LLMW	low level mixed waste
4	LLW	low level waste
5	LNG	liquefied natural gas
6	LOCA	loss of coolant accident
7	LWR	light-water reactor
8		
9	MSA	Magnuson-Stevens Fishery Conservation and Management Act of 1996
10	Msl	mean sea level
11	MW	megawatt
12	MWe	megawatt-electric
13	MWt	megawatt-thermal
14		
15	NA	not applicable
16	NAAQS	National Ambient Air Quality Standards
17	NAS	National Academy of Sciences
18	NCI	National Cancer Institute
19	NEPA	National Environmental Policy Act of 1969
20	NESC	National Electric Safety Code
21	NHPA	National Historic Preservation Act
22	NIEHS	National Institute of Environmental Health Sciences
23	NMFS	National Marine Fisheries Service
24	NOAA	National Oceanic and Atmospheric Administration
25	NO <sub>x</sub>	nitrogen oxide(s)
26	NPDES	National Pollutant Discharge Elimination System
27	NRC	U.S. Nuclear Regulatory Commission
28	NWPPC	Northwest Power Planning Council
29		
30	ODCM	Offsite Dose Calculation Manual
31		
32	PADEP	Pennsylvania Department of Environmental Protection
33	pCi/L	picocuries per liter
34	PDS	plant damage state
35	PFBC	Pennsylvania Fish and Boat Commission
36	PGC	Pennsylvania Game Commission
37	PHMC	Pennsylvania Historical and Museum Commission
38	PM <sub>2.5</sub>	particulate matter, 2.5 microns or less in diameter
39	PM <sub>10</sub>	particulate matter, 10 microns or less in diameter
40	PRA	Probabilistic Risk Assessment
41	PSA	Probabilistic Safety Assessment
42	PSD	prevention of significant deterioration

## Abbreviations and Acronyms

1	PSW	plant service water
2	PWR	pressurized water reactor
3		
4	RAB	reactor auxiliary building
5	RAI	request for additional information
6	RCP	reactor coolant pump
7	REMP	radiological environmental monitoring program
8	rms	root mean square
9	ROW(s)	right-of-way(s)
10		
11	SAMA	Severe Accident Mitigation Alternative
12	SAR	Safety Analysis Report
13	SER	Safety Evaluation Report
14	SHPO	State Historic Preservation Office
15	SO <sub>2</sub>	sulfur dioxide
16	SRBC	Susquehanna River Basin Commission
17		
18	TSCA	Toxic Substances Control Act
19		
20	U	Uranium
21	UFSAR	Updated Final Safety Analysis Report
22	U.S.	United States
23	USACE	United States Army Corps of Engineers
24	U.S.C.	United States Code
25	USCB	U.S. Census Bureau
26	USDA	U.S. Department of Agriculture
27		
28	VOCs	Volatile Organic Compounds
29		
30	WHO	World Health Organization
31		



## 1.0 PURPOSE AND NEED FOR ACTION

Under the U.S. Nuclear Regulatory Commission's (NRC's) environmental protection regulations in Title 10, Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions," of the *Code of Federal Regulations* (10 CFR Part 51), which implement the National Environmental Policy Act (NEPA), issuance of a new nuclear power plant operating license requires the preparation of an environmental impact statement (EIS).

The Atomic Energy Act of 1954 originally specified that licenses for commercial power reactors be granted for up to 40 years with an option to renew for another 20 years. The 40-year licensing period was based on economic and antitrust considerations rather than on technical limitations of the nuclear facility.

The decision to seek a license renewal rests entirely with nuclear power facility owners and typically is based on the facility's economic viability and the investment necessary to continue to meet NRC safety and environmental requirements. The NRC makes the decision to grant or deny a license renewal application, based on whether the applicant has demonstrated that the environmental and safety requirements in the agency's regulations can be met during the period of extended operation.

### 1.1 Proposed Federal Action

AmerGen Energy Company, LLC (AmerGen) initialized the proposed Federal action by submitting an application for license renewal of Three Mile Island Nuclear Station, Unit 1 (TMI-1), for which the existing license, DPR-50, expires April 19, 2014. The NRC's Federal action is the decision whether to renew the license for an additional 20 years.

### 1.2 Purpose and Need for the Proposed Federal Action

The purpose and need for the proposed action (issuance of a renewed license) is to provide an option that allows for power generation capability beyond the term of a current nuclear power plant operating license to meet future system generating needs, as such needs may be determined by State, utility, and, where authorized, Federal (other than NRC) decisionmakers. This definition of purpose and need reflects the Commission's recognition that, unless there are findings in the safety review required by the Atomic Energy Act or findings in the NEPA environmental analysis that would lead the NRC to reject a license renewal application, the NRC does not have a role in the energy-planning decisions of State regulators and utility officials as to whether a particular nuclear power plant should continue to operate.

If the renewed license is issued, State regulatory agencies and AmerGen will ultimately decide whether the plant will continue to operate based on factors such as the need for power or other matters within the State's jurisdiction or the purview of the owners. If the operating license is not renewed, then the facility must be shut down on or before the expiration date of the current operating license, April 19, 2014.

Purpose and Need For Action


1  
2 **1.3 Major Environmental**  
3 **Review Milestones**

4 AmerGen submitted an  
5 environmental report (AmerGen  
6 2008a) as part of its license  
7 renewal application (AmerGen  
8 2008) in January 2008. After  
9 reviewing the application and the  
10 environmental report for  
11 sufficiency, the NRC staff  
12 published a Notice of Acceptability  
13 and Opportunity for Hearing on  
14 March 14, 2008, in the *Federal*  
15 *Register* (Volume 73, p. 13923, (73  
16 FR 13923)). Then, on March 28,  
17 2008, the NRC published another  
18 notice in the *Federal Register* (73  
19 FR 16729) on its intent to conduct  
20 scoping, thereby beginning the 60-  
21 day scoping period.

22 The agency held two public  
23 scoping meetings on May 1, 2008,  
24 in Middletown, Pennsylvania. The  
25 NRC report entitled,  
26 "Environmental Impact Statement  
27 Scoping Process Summary Report  
28 for Three Mile Island Nuclear  
29 Station, Unit 1," dated August 8,  
30 2008, presents the comments  
31 received during the scoping  
32 process in their entirety (NRC  
33 2008b). Appendix A to this  
34 supplemental EIS presents the  
35 comments considered to be within  
36 the scope of the environmental  
37 license renewal review and the  
38 associated NRC responses.

39 To independently verify information  
40 provided in the environmental  
41 report, the NRC staff conducted a  
42 site audit at TMI-1 from April 28  
43 through May 1, 2008. During the site audit, staff met with plant personnel, reviewed specific  
44 documentation, toured the facility, and met with interested Federal, State, and local agencies.  
45 The agency published a summary of that site audit and a list of the attendees in a report

**Figure 1-1. Environmental Review Process.** The environmental review provides opportunities for public involvement.



1 entitled, "Summary of Site Audit Related to the Review of the License Renewal Application for  
2 Three Mile Island Nuclear Station, Unit 1," dated August 5, 2008 (NRC 2008).

3 Upon completion of the scoping period and site audit, the staff compiled its findings in this  
4 document, the draft supplemental EIS (Figure 1-1). This document is made available for public  
5 comment for 75 days. During this time, NRC staff will host public meetings and collect public  
6 comments. Based on the information gathered, the staff will amend the draft supplemental EIS  
7 findings as necessary, and publish the final supplemental EIS.

8 The NRC has established a license renewal process that can be completed in a reasonable  
9 period of time with clear requirements to ensure safe plant operation for up to an additional 20  
10 years of plant life. The safety review is conducted simultaneously with the environmental  
11 review. The staff documents the findings of the safety review in a safety evaluation report. The  
12 Commission considers the findings in both the supplemental EIS and the safety evaluation  
13 report in its decision to either grant or deny the issuance of a new license.  
14

#### 15 **1.4 Generic Environmental Impact Statement**

16 The NRC performed a generic assessment of the environmental impacts associated with  
17 license renewal to improve the efficiency of the license renewal. NUREG-1437, *Generic*  
18 *Environmental Impact Statement for License Renewal of Nuclear Power Plants*, documents the  
19 results of the NRC staff's systematic approach to evaluating the environmental consequences of  
20 renewing the licenses of individual nuclear power plants and operating them for an additional 20  
21 years (NRC 1996, 1999)<sup>1</sup>. The NRC staff analyzed in detail and resolved those environmental  
22 issues that could be resolved generically in the Generic Environmental Impact Statement  
23 (GEIS).

24 The GEIS establishes 92 separate issues for the NRC staff to independently verify. Of these,  
25 the staff determined that 69 are generic to all plants (Category 1), while 21 issues do not lend  
26 themselves to generic consideration (Category 2). Two other issues remained uncategorized;  
27 environmental justice and the chronic effects of electromagnetic fields must be evaluated on a  
28 site-specific basis. Appendix B to this report lists all 92 issues.

29 For each potential environmental issue, the GEIS (1) describes the activity that affects the  
30 environment, (2) identifies the population or resource that is affected, (3) assesses the nature  
31 and magnitude of the impact on the affected population or resource, (4) characterizes the  
32 significance of the effect for both beneficial and adverse effects, (5) determines whether the  
33 results of the analysis apply to all plants, and (6) considers whether additional mitigation  
34 measures would be warranted for impacts that would have the same significance level for all  
35 plants.

36 The NRC's standard of significance for impacts was established using the Council on  
37 Environmental Quality terminology for "significant." The NRC established three levels of  
38 significance for potential impacts—SMALL, MODERATE, and LARGE, as defined below.  
39

---

<sup>1</sup> The NRC originally issued the GEIS in 1996 and issued Addendum 1 to the GEIS in 1999. Hereafter, all references to the "GEIS" include the GEIS and Addendum 1.

Purpose and Need For Action

1 **SMALL** – Environmental effects are not detectable  
2 or are so minor that they will neither destabilize nor  
3 noticeably alter any important attribute of the  
4 resource.

5  
6 **MODERATE** – Environmental effects are sufficient  
7 to alter noticeably, but not to destabilize,  
8 important attributes of the resource.

9  
10 **LARGE** – Environmental effects are clearly  
11 noticeable and are sufficient to destabilize  
12 important attributes of the resource.

**Significance** indicates the importance of likely environmental impacts and is determined by considering two variables: **context** and **intensity**.

**Context** is the geographic, biophysical, and social context in which the effects will occur.

**Intensity** refers to the severity of the impact, in whatever context it occurs.

13  
14 The GEIS includes a determination of whether the analysis of the environmental issue could be  
15 applied to all plants and whether additional mitigation measures would be warranted (Figure 1-  
16 2). Issues are assigned a Category 1 or a Category 2 designation. As set forth in the GEIS,  
17 Category 1 issues are those that meet all of the following criteria:

- 18 (1) The environmental impacts associated with the issue have been determined to apply  
19 either to all plants or, for some issues, to plants having a specific type of cooling system  
20 or other specified plant or site characteristics;
- 21 (2) A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to  
22 the impacts (except for collective offsite radiological impacts from the fuel cycle and from  
23 high-level waste and spent fuel disposal); and
- 24 (3) Mitigation of adverse impacts associated with the issue has been considered in the  
25 analysis, and it has been determined that additional plant-specific mitigation measures  
26 are likely not to be sufficiently beneficial to warrant implementation.


27 For generic issues (Category 1), no additional site-specific analysis is required in this  
28 supplemental EIS unless new and significant information is identified. Chapter 4 of this report  
29 presents the process for identifying new and significant information. Site-specific issues  
30 (Category 2) are those that do not meet one or more of the criterion for Category 1 issues, and  
31 therefore, additional site-specific review for these issues is required. The supplemental EIS  
32 documents the results of that site-specific review.

33

34



1 **Figure 1-2. Environmental Issues Evaluated During License Renewal.** 92 issues were  
 2 initially evaluated in the Generic EIS. A site-specific analysis is required for 23 of those 92  
 3 issues.



4  
 5 **1.5 Supplemental Environmental Impact Statement**

6 The supplemental EIS presents an analysis that considers the environmental effects of the  
 7 continued operation of TMI-1, alternatives to license renewal, and mitigation measures for  
 8 minimizing adverse environmental impacts. Chapter 8 analyzes and compares the potential  
 9 environmental impacts from alternatives, while Chapter 9 presents the preliminary  
 10 recommendation to the Commission as to whether or not the environmental impacts of license  
 11 renewal are so great that preserving the option of license renewal would be unreasonable. The  
 12 recommendation will be made after consideration of comments received during the public  
 13 scoping period and on the draft supplemental EIS.  
 14 In the preparation of this supplemental EIS for TMI-1, the staff undertook the following activities:

## Purpose and Need For Action

- 1 • reviewed the information provided in the AmerGen environmental report;
- 2 • consulted with other Federal, State, and local agencies;
- 3 • conducted an independent review of the issues during site audit; and
- 4 • considered the public comments received during the scoping process.

5  
6 New information can be identified from a  
7 number of sources, including the applicant,  
8 the NRC, other agencies, or public  
9 comments. If a new issue is revealed,  
10 then it is first analyzed to determine  
11 whether it is within the scope of the license  
12 renewal evaluation. If it is not addressed  
13 in the GEIS then the NRC determines its  
14 significance and documents its analysis in  
15 the supplemental EIS.  
16

**New and significant information** either:  
(1) identifies a significant environmental issue  
not covered in the GEIS, or (2) was not  
considered in the analysis in the GEIS and  
leads to an impact finding that is different from  
the finding presented in the GEIS.

## 17 **1.6 Cooperating Agencies**

18 During the scoping process, no Federal, State, or local agencies were identified as cooperating  
19 agencies in the preparation of this supplemental EIS.  
20

## 21 **1.7 Consultations**

22 The Endangered Species Act of 1973, as amended; the Magnuson-Stevens Fisheries  
23 Conservation and Management Act of 1996, as amended; and the National Historic  
24 Preservation Act of 1966 require that Federal agencies consult with applicable State and  
25 Federal agencies and groups before taking action that may affect endangered species,  
26 fisheries, or historic and archaeological resources, respectively. Below are the agencies and  
27 groups with whom the NRC consulted; Appendix D to this report includes copies of consultation  
28 documents.

29 Absentee-Shawnee Tribe of Oklahoma, Shawnee, Oklahoma  
30 Advisory Council on Historic Preservation  
31 Cayuga Nation, Versailles, New York  
32 Delaware Nation, Anadarko, Oklahoma  
33 Eastern Shawnee Tribe of Oklahoma, Seneca, Missouri  
34 Oneida Indian Nation, Verona, New York  
35 Oneida Nation of Wisconsin, Oneida, Wisconsin  
36 Onondaga Nation, Nedrow, New York  
37 Pennsylvania Historical and Museum Commission  
38 Seneca-Cayuga Tribe of Oklahoma, Miami, Oklahoma  
39 Seneca Nation of Indians, Salamanca, New York  
40 Shawnee Tribe, Miami, Oklahoma  
41 St. Regis Mohawk Tribe, Akwesasne, New York  
42 Stockbridge-Munsee Band of the Mohican Nation – Wisconsin, Bowler, Wisconsin  
43 Tonawanda Seneca Nation, Basom, New York

1 Tuscarora Nation, Lewiston, New York  
 2 U.S. Fish and Wildlife Service, Pennsylvania Field Office  
 3

4 **1.8 Correspondence**

5 During the course of the environmental review, the NRC staff contacted the following Federal,  
 6 State, regional, local, and tribal agencies. Appendix E to this report contains a chronological list  
 7 of all documents sent and received during the environmental review.

- 8 Absentee-Shawnee Tribe of Oklahoma, Shawnee, Oklahoma
- 9 Advisory Council on Historic Preservation, Washington, D.C.
- 10 Cayuga Nation, Versailles, New York
- 11 Delaware Nation, Anadarko, Oklahoma
- 12 Eastern Shawnee Tribe of Oklahoma, Seneca, Missouri
- 13 Oneida Indian Nation, Verona, New York
- 14 Oneida Nation of Wisconsin, Oneida, Wisconsin
- 15 Onondaga Nation, Nedrow, New York
- 16 Pennsylvania Department of Conservation and Natural Resources, Harrisburg,  
 17 Pennsylvania
- 18 Pennsylvania Department of Environmental Protection, Harrisburg, Pennsylvania
- 19 Pennsylvania Department of Environmental Protection, South Central Regional Office,  
 20 Harrisburg, Pennsylvania
- 21 Pennsylvania Fish and Boat Commission, Bellefonte, Pennsylvania
- 22 Pennsylvania Game Commission, Harrisburg, Pennsylvania
- 23 Pennsylvania Historical and Museum Commission, Harrisburg, Pennsylvania
- 24 Seneca-Cayuga Tribe of Oklahoma, Miami, Oklahoma
- 25 Seneca Nation of Indians, Salamanca, New York
- 26 Shawnee Tribe, Miami, Oklahoma
- 27 St. Regis Mohawk Tribe, Akwesasne, New York
- 28 Stockbridge-Munsee Band of the Mohican Nation – Wisconsin, Bowler, Wisconsin
- 29 Susquehanna River Basin Commission, Harrisburg, Pennsylvania
- 30 Tonawanda Seneca Nation, Basom, New York
- 31 Tuscarora Nation, Lewiston, New York
- 32 U.S. Fish and Wildlife Service, Pennsylvania Field Office, State College, Pennsylvania

33  
 34 A list of persons who received a copy of this draft supplemental EIS is provided below:

TMI-1 Site Vice President, AmerGen	Senior Vice President— Operations, Mid-Atlantic, AmerGen	Vice President—Licensing and Regulatory Affairs, AmerGen
Regional Administrator, Region 1, NRC	Chairman, Board of County Commissioners of Dauphin County	Chairman, Board of Supervisors of Londonderry Township
David Kern, NRC	Director—Licensing and Regulatory Affairs, AmerGen	David Allard, Pennsylvania Department of Environmental Protection

Purpose and Need For Action

Plant Manger – TMI-1, AmerGen	Regulatory Assurance Manager—TMI-1, AmerGen	Ronald Bellamy, NRC
Ronnie Gardner, AREVA NP Inc.	Judith Johnsrud, Sierra Club	Eric Epstein, TMI Alert
Correspondence Control Desk, AmerGen	Manager Licensing—TMI-1, Exelon Generation Company, LLC	Christopher Crane, AmerGen
Charles Pardee, AmerGen	Associate General Counsel, AmerGen	Chief Operating Officer, AmerGen
Senior Vice President—Operations Support, AmerGen	Frederic W. Polaski, Exelon Nuclear	Albert A. Fulvio, Exelon Nuclear
Rich Janati, Pennsylvania Department of Environmental Protection	Michael Murphy, Pennsylvania Department of Environmental Protection	Michael G. Brownell, Susquehanna River Basin Commission
Rachel Diamond, Pennsylvania Department of Environmental Protection	Nancy Ranek, Exelon Nuclear	Christopher Wilson, Exelon Nuclear
Michael P. Gallagher, Exelon Nuclear	Kathleen Yhip	William R. Geisel
Joseph Mirenzi	Anne Lovell, TetraTech NUS	James Oliver, TetraTech NUS
Larry Robbins	Mary Osborn	Michael R. Helfrich, Lower Susquehanna RiverKeeper
Linda Braasch, Harrisburg Diocesan Council of Catholic Women	Bradford S. Flynn	Douglas McLearen Pennsylvania Historical and Museum Commission
Anne Norton-Miller U.S. Environmental Protection Agency	Kimberly DePaul U.S. Environmental Protection Agency	William S. Arguto U.S. Environmental Protection Agency, Region 3

1

2 **1.9 Status of Compliance**

3 AmerGen is responsible for complying with all NRC regulations and other applicable Federal,  
 4 State, and local requirements; Appendix H to the GEIS describes some of the major Federal  
 5 statutes. Table 1-1 on the following page lists the numerous permits and licenses issued by  
 6 Federal, State, and local authorities for activities at TMI-1.

1 **Table 1-1. Licenses and Permits.** *Existing environmental authorizations for TMI-1*  
 2 *Operations.*

Permit	Number	Dates	Responsible Agency
Operating License	DPR-50	Issued: 4/19/1974 Expires: 4/19/2014	U.S. NRC
Consumptive Water Use Permit	Docket 19950302	Issued: 3/14/1980 Expires: 3/14/2010	Susquehanna River Basin Commission
Ground Water Withdrawal Permit	Docket 19961102	Issued: 1/26/1999 Expires: 11/26/2021	Susquehanna River Basin Commission
Synthetic Minor Operating Permit	22-05029	Issued: 1/1/2007 Expires: 12/31/2011	Pennsylvania Department of Environmental Protection
National Pollutant Discharge Elimination System Permit	PA 0009920	Issued: 10/30/2007 Expires: 10/31/2012	Pennsylvania Department of Environmental Protection
Maintenance Dredging Permit	CENAB-OP-RPA (AmerGen 197500083-4)	Issued: 1/3/2006 Expires: 12/31/2015	U.S. Army Corps of Engineers
Maintenance Dredging Permit	21275724	Issued: 1/13/1976 Expires: Not Listed	Pennsylvania Department of Environmental Protection
Public Water Supply Permit	22296501-T1	Issued: 1/20/2000 Expires: Not Listed	Pennsylvania Department of Environmental Protection
Public Water Supply Permit	22296501-T2	Issued: 1/20/2000 Expires: Not Listed	Pennsylvania Department of Environmental Protection

Purpose and Need For Action

<b>Permit</b>	<b>Number</b>	<b>Dates</b>	<b>Responsible Agency</b>
Acknowledgement of Notification of Regulated Waste Activity	PAR 000037861	Issued: 3/22/1999 Expires: Not Listed	U.S. Environmental Protection Agency
Storage Tank Registration/Permit Certificate	22-60170	Issued: 6/4/2007 Expires: 6/4/2008 (Annual Renewal)	Pennsylvania Department of Environmental Protection
Hazardous Materials Certificate of Registration	022307-701-002PR	Issued: 5/16/2007 Expires: 6/30/2010	U.S. Department of Transportation
Flammable and Combustible Liquid Storage Tank Approval	168,466	Issued: 6/12/1970 Expires: Not Listed	Pennsylvania Department of Labor and Industry
Flammable and Combustible Liquid Storage Tank Approval	168,465	Issued: 6/12/1970 Expires: Not Listed	Pennsylvania Department of Labor and Industry
Flammable and Combustible Liquid Storage Tank Approval	187,165	Issued: 11/17/1977 Expires: Not Listed	Pennsylvania Department of Labor and Industry
Flammable and Combustible Liquid Storage Tank Approval	203,271-B	Issued: 8/4/1989 Expires: Not Listed	Pennsylvania Department of Labor and Industry
Flammable and Combustible Liquid Storage Tank Approval	122-203,393	Issued: 9/22/1989 Expires: Not Listed	Pennsylvania Department of Labor and Industry
Sewage Disposal System Permit Modification	C179678 and C21434	Issued: 1/1/1995 Expires: Not Listed	Pennsylvania Department of Environmental Protection
Sewage Sludge Disposal Agreement	Letter Agreement	Issued: 6/20/2000 Expires: Not Listed	Pennsylvania Department of Environmental Protection
Environmental Laboratory Accreditation Certification	Reg. No. 22-00649	Issued: 4/17/2007	Pennsylvania Department of
Draft NUREG-1437, Supplement 37	1-10		December 2008

Permit	Number	Dates	Responsible Agency
		Expires: 4/30/2008	Environmental Protection
On Lot Sewage Disposal System Permit	U003282	Issued: 8/10/2007 Expires: Not Listed	Pennsylvania Department of Environmental Protection

1

2 **1.10 References**

3 10 CFR Part 51. Code of Federal Regulations, *Title 10, Energy*, Part 51, “Environmental  
4 Protection Regulations for Domestic Licensing and Related Regulatory Functions.”

5 73 FR 13923. U.S. Nuclear Regulatory Commission, Washington, D.C., “Notice of Acceptance  
6 for Docketing of the Application and Notice of Opportunity for Hearing; Regarding Renewal of  
7 Facility Operating License No. DPR-50 for an Additional 20-Year Period; AmerGen Energy  
8 Company, LLC Three Mile Island Nuclear Station, Unit 1.” *Federal Register*: Vol. 73, No. 51,  
9 pp. 13923–13925. March 14, 2008.

10 73 FR 16729. U.S. Nuclear Regulatory Commission, Washington, D.C., “Three Mile Island  
11 Nuclear Station, Unit 1; Notice of Intent to Prepare an Environmental Impact Statement and  
12 Conduct Scoping Process.” *Federal Register*: Vol. 73, No. 61, pp. 16729–16731. March 28,  
13 2008.

14 AmerGen (AmerGen Energy Company, LLC). 2008. “Three Mile Island Generating Station, Unit  
15 1, License Renewal Application.” ADAMS No. ML080220207.

16 AmerGen (AmerGen Energy Company, LLC). 2008a. “Three Mile Island Nuclear Station,  
17 Applicant’s Environmental Report, License Renewal Operating Stage.” Kennett Square,  
18 Pennsylvania. ADAMS Nos. ML080220255, ML080220257, ML080220261, and ML080220282.

19 *Atomic Energy Act of 1954*. 42 U.S.C. 2011, et seq.

20 *Endangered Species Act of 1973*. 16 U.S.C. 1531, et seq.

21 *Magnuson-Stevens Fishery Conservation and Management Act*, as amended by the  
22 *Sustainable Fisheries Act of 1996*. 16 U.S.C. 1855, et seq.

23 *National Environmental Policy Act of 1969*. 42 U.S.C. 4321, et seq.

24 *National Historic Preservation Act*. 16 U.S.C. 470, et seq.

## Purpose and Need For Action

- 1 NRC (U.S. Nuclear Regulatory Commission). 1996. *Generic Environmental Impact Statement*  
2 *for License Renewal of Nuclear Plants*. NUREG-1437, Volumes 1 and 2, Washington, D.C.  
3 ADAMS No. ML061770605.
- 4 NRC (U.S. Nuclear Regulatory Commission). 1999. *Generic Environmental Impact Statement*  
5 *for License Renewal of Nuclear Plants, Main Report*, “Section 6.3 – Transportation, Table 9.1,  
6 Summary of findings on NEPA issues for license renewal of nuclear power plants, Final Report.”  
7 NUREG-1437, Volume 1, Addendum 1, Washington, D.C.
- 8 NRC (U.S. Nuclear Regulatory Commission). 2008. “Summary of Site Audit Related to the  
9 Review of the License Renewal Application for Three Mile Island Nuclear Station, Unit 1.”  
10 ADAMS No. ML081420398.
- 11 NRC (U.S. Nuclear Regulatory Commission). 2008b. “Environmental Impact Statement Scoping  
12 Process Summary Report, Three Mile Island Nuclear Station, Unit 1.” ADAMS No.  
13 ML081920230.



## 2.0 AFFECTED ENVIRONMENT

Three Mile Island Nuclear Station, Unit 1 (TMI-1) is located in Londonderry Township of Dauphin County about 3 miles (mi) (4.8 kilometers [km]) south of Middletown, Dauphin County, and about 1.25 mi (2 km) east of the community of Goldsboro, York County. The site is approximately 10 mi (16 km) southeast of Harrisburg, Pennsylvania (AEC 1972). Figures 2-1 and 2-2 present the 50-mi (80-km) and 6-mi (10-km) vicinity maps, respectively. For purposes of the evaluation in this report, the “affected environment” is the environment that currently exists at and around TMI-1. Because existing conditions are at least partially the result of past construction and operation at the plant, the impacts of these past and ongoing actions and how they have shaped the environment are presented here. Section 2.1 of this report describes the facility and its operation, and Section 2.2 discusses the affected environment.

### 2.1 Facility Description

This assessment of the affected environment begins with a description of TMI-1, the source of potential environmental effects. TMI-1 is a pressurized-water reactor (PWR) utilizing once-through steam generators and licensed to operate at a power level of 2568 megawatt-thermal (MWt). Certain buildings and structures associated with Three Mile Island, Unit 2 (TMI Unit 2), which is owned by FirstEnergy Corporation (FirstEnergy), are intermingled with TMI-1 and its associated structures. TMI Unit 2 has been shut down since the accident in March 1979. Since December 1993, it has been in a stable, safe storage mode called post defueling monitored storage (AmerGen 2008).


The most conspicuous structures on the TMI-1 site are the four, 370-foot, hyperbolic, natural draft cooling towers. The two cooling towers to the south are inactive and were formerly utilized by the TMI Unit 2 reactor system. The two northern cooling towers are associated with the TMI-1 reactor. Other salient buildings on the TMI-1 site include the reactor building, auxiliary building, fuel-handling building, station blackout diesel generator building, intake screen and pump house, and the turbine building (AmerGen 2008). Figure 2-3 provides a general layout of the TMI-1 site.

#### 2.1.1 Reactor and Containment Systems


TMI-1 is a single-unit plant with a Babcock and Wilcox PWR. Gilbert Associates, Inc. was the architect-engineer for TMI-1 (AEC 1972). TMI-1 received its construction permit in 1968 and its operating license in 1974, and began commercial operation on September 2, 1974. The initial licensed core thermal power of TMI-1 was 2535 MWt. In July 1988, the NRC approved a measurement uncertainty recapture uprate that increased the core thermal power by 1.3 percent to 2568 MWt (NRC 1996).


Affected Environment

1



**Figure 2-1. Location of Three Mile Island Nuclear Station, Unit 1, 50-mi (80-km) Region (Source: AmerGen 2008)**





1 The reactor fuel is sintered low-enriched uranium dioxide pellets sealed in zirconium-based alloy  
2 tubing and caps (AmerGen 2008). Core reactivity is controlled by 69 movable control rod  
3 assemblies and boric acid (boric acid is a neutron absorber). The control rods are silver-  
4 indium-cadmium alloy encapsulated in stainless steel. Control rods are used for short-term  
5 reactivity control associated with changes in power level and with changes in fuel burnup  
6 between adjustments in reactor coolant dissolved boron concentrations. If a reactor trip signal is  
7 received, all 69 control rod assemblies fall into the core by gravity (AEC 1972).

8 In the PWR power generation system, reactor heat is transferred from the primary coolant to a  
9 lower pressure secondary coolant loop, allowing steam to be generated in the steam supply  
10 system. The primary coolant loops each contain one steam generator, two centrifugal coolant  
11 pumps, and the interconnected piping. Reactor coolant is pumped from the reactor through the  
12 steam generators and back to the reactor inlet by two centrifugal coolant pumps located at the  
13 outlet of each steam generator. Each steam generator is a vertical straight tube-and-shell heat  
14 exchanger that produces superheated steam at a constant pressure over the reactor operating  
15 power range. Coolant flows downward through the tubes, and steam is generated on the lower  
16 pressure shell side. Steam then flows from the steam generators to the 1800-revolutions per  
17 minute, tandem compound, six-flow turbine generator, manufactured by General Electric (AEC  
18 1972). NUREG/CR-5640, "Overview and Comparison of U.S. Commercial Nuclear Power Plant,  
19 Nuclear Power Plant System Source" (NRC 1990), provides a comprehensive overview and  
20 description of the PWR power generation system.

21 The primary containment is the reactor building and its associated isolation systems. The  
22 reactor building consists of a reinforced concrete slab and structure with cylindrical wall, a flat  
23 foundation mat, and a shallow dome roof. The 3-ft (1-meter [m]) concrete cylindrical wall is pre-  
24 stressed with a post-tensioning system in the vertical and horizontal directions. The dome roof is  
25 pre-stressed using a three way post-tensioning system. The inside surface of the reactor  
26 building is lined with a carbon steel liner 3/4-inch (1.9 centimeter [cm]) thick for the cylinder and  
27 dome and 1/4-inch (0.63 cm) thick for the base.  
28

### 29 **2.1.2 Radioactive Waste Management**

30 TMI-1 radioactive waste systems are designed to collect, treat, and dispose of the radioactive  
31 and potentially radioactive wastes that are byproducts of plant operations. Byproducts include:  
32 activation products created from the irradiation of reactor water and impurities contained in that  
33 water (which are principally metallic corrosion products); and fission products created by  
34 defective fuel cladding or uranium contamination within the reactor coolant system (AmerGen  
35 2008). Operating procedures for radioactive waste systems ensure that radioactive wastes are  
36 safely processed and discharged from the plant within the limits set forth in 10 CFR Part 20,  
37 "Standards for Protection against Radiation," 10 CFR Part 50, "Domestic Licensing of  
38 Production and Utilization Facilities," the plant's technical specifications, and the TMI-1 offsite  
39 dose calculation manual (ODCM) (AmerGen 2007a).

40 Radioactive wastes resulting from plant operations are classified as liquid, gaseous, or solid.  
41 Liquid radioactive wastes are generated from liquids received directly from portions of the  
42 reactor coolant system or were contaminated by contact with liquids from the reactor coolant  
43 system. Gaseous radioactive wastes are generated from gases or airborne particulates vented

## Affected Environment

1 from reactor and turbine equipment containing radioactive material. Solid radioactive wastes are  
2 solids from the reactor coolant system, solids that came into contact with reactor coolant system  
3 liquids or gases, or solids used in the reactor coolant system or steam and power conversion  
4 system operation or maintenance (AmerGen 2006a).

5 Reactor fuel that has exhausted a certain percentage of its fissile uranium content is referred to  
6 as spent fuel. Spent fuel assemblies are removed from the reactor core and replaced with fresh  
7 fuel assemblies during routine refueling outages, typically every 24 months. Spent fuel  
8 assemblies are then stored for a period of time in the spent fuel pool in the reactor building.

9 The TMI-1 ODCM contains the methodology and parameters used to calculate offsite doses  
10 resulting from radioactive gaseous and liquid effluents, and the gaseous and liquid effluent  
11 monitoring alarm and trip setpoints used to verify the radioactive material being discharged  
12 meets regulatory limits (AmerGen 2007a). The ODCM also contains the radioactive effluent  
13 controls and radiological environmental monitoring activities and descriptions of the information  
14 that should be included in the annual radiological environmental operating report and annual  
15 radioactive effluent release report required by Appendix I, "Numerical Guides for Design  
16 Objectives and Limiting Conditions for Operation to Meet the Criterion 'As Low as is Reasonably  
17 Achievable' for Radioactive Material in Light-Water-Cooled Nuclear Power Reactor Effluents," to  
18 10 CFR Part 50 and 10 CFR 50.36a, "Technical Specifications on Effluents from Nuclear Power  
19 Reactors," respectively.

### 20 *2.1.2.1 Radioactive Liquid Waste*

21 The TMI-1 radioactive liquid waste disposal system collects, holds, treats, processes, and  
22 monitors all liquid radioactive wastes for reuse or disposal. The system is divided into several  
23 subsystems so liquid wastes from various sources can be segregated and processed  
24 separately. Cross-connections between the subsystems provide additional flexibility for  
25 processing the wastes by alternate methods. The wastes are collected, treated, and disposed of  
26 according to their conductivity and/or radioactivity (AmerGen 2006a).

27 Radioactive liquid waste from TMI-1 is collected in sumps and drainage tanks and transferred to  
28 the appropriate subsystem collection tanks for subsequent treatment, disposal, or recycle. The  
29 liquid wastes are processed by a series of components which employ various processes  
30 specifically designed to provide maximum decontamination factors. The processing methods  
31 used include filtration, reverse osmosis, and/or demineralization. Following treatment, the  
32 processed wastes in the waste evaporator condensate tank, waste monitor tanks, or secondary  
33 liquid waste monitor tanks are analyzed for chemical and radioactive content before being  
34 discharged. In addition, the system can handle effluent streams that typically do not contain  
35 radioactive material, but that may, on occasion, become radioactive. Liquid radioactive wastes  
36 released to the west channel of the Susquehanna River are limited to the maximum extent  
37 possible to satisfy the design objectives of Appendix I to 10 CFR Part 50. Liquid discharges  
38 occur when the radioactive material has been analyzed and the projected dose to members of  
39 the public has been calculated to be within the values specified in the ODCM, 10 CFR Part 20,  
40 and Appendix I to 10 CFR Part 50 (AmerGen 2006a).

41 The NRC staff reviewed the TMI-1 radioactive effluent release reports for 2003 through 2007 for  
42 liquid effluents (AmerGen 2004b, 2005b, 2006b, 2007a, 2008b). Based on the liquid waste  
43 processing systems and effluent controls and performance from 2003 through 2007, the liquid  
44 discharges for 2007 are consistent with the radioactive liquid effluents discharged from 2003

1 through 2006. Variations on the amount of radioactive effluents released from year to year are  
2 expected based on the overall performance of the plant and the number and scope of outages  
3 and maintenance activities. The liquid radioactive wastes reported by TMI-1 are reasonable and  
4 no unusual trends were noted.

5 AmerGen intends to replace the TMI-1 steam generators before the period of extended  
6 operation. Such an action is not likely to significantly increase the amount of liquid radioactive  
7 effluents above the amount discharged during normal plant operations. This is because any  
8 liquids generated, processed, and released during the outage will be offset by the amount of  
9 liquid waste that would not be generated, processed, and released during normal plant  
10 operations. Based on the historical evaluation and because a significant increase in liquid  
11 effluents from the potential repair or replacement of the TMI-1 steam generators is not  
12 expected, similar quantities of radioactive effluents are expected to be generated during normal  
13 operations and outages from TMI-1 during the period of extended operations. The liquid  
14 releases during refurbishment will still be controlled and limited to satisfy the dose objectives of  
15 Appendix I to 10 CFR Part 50. These releases would result in doses to members of the public  
16 that are well below the ALARA dose design objectives, as discussed in Section 4.8.1 of this  
17 report.

#### 18 *2.1.2.2 Radioactive Gaseous Waste*

19 The TMI-1 radioactive gas waste disposal system processes and disposes of routine radioactive  
20 gaseous effluent to the atmosphere. The system comprises reactor coolant drain tanks,  
21 miscellaneous waste storage tanks, waste gas, decay tanks, waste gas compressors, and  
22 charcoal and high efficiency particulate filters, to accumulate, store, and process the waste  
23 fission product gases. Before gaseous radioactive waste is released to the atmosphere through  
24 the plant vents, the gas must be analyzed to determine and document the amount of  
25 radioactivity being released (AmerGen 2006a).

26 TMI-1 discharges gaseous waste in accordance with the procedures and methodology  
27 described in the ODCM. The gaseous radioactive waste system is used to reduce radioactive  
28 materials in gaseous effluents before discharge to meet the dose limits in 10 CFR Part 20 and  
29 the ALARA dose design objectives in Appendix I to 10 CFR Part 50.

30 The NRC staff reviewed the TMI-1 radioactive effluent release reports for 2003 through 2007 for  
31 liquid effluents (AmerGen 2004b, 2005b, 2006b, 2007a, 2008b). Based on the gaseous waste  
32 processing systems and effluent controls and performance from 2003 through 2007, the  
33 gaseous discharges for 2007 are consistent with the radioactive gaseous effluents discharged  
34 from 2003 through 2006. Variations on the amount of radioactive effluents released from year to  
35 year are expected based on the overall performance of the plant and the number and scope of  
36 outages and maintenance activities. The radioactive gaseous wastes reported by TMI-1 are  
37 reasonable and no unusual trends were noted.

38 AmerGen intends to replace the TMI-1 steam generators before the period of extended  
39 operation. This action is not likely to result in a significant increase in the amount of radioactive  
40 gaseous waste discharged over the amount discharged during normal plant operations,  
41 because any radioactive gaseous waste generated, processed, and released during the outage  
42 will be offset by the amount of radioactive gaseous waste that would not be generated,  
43 processed, and released during normal plant operations. Based on the historical evaluation and  
44 because no significant increase in radioactive gaseous effluents from the potential repair or



## Affected Environment

1 replacement of the TMI-1 steam generators is anticipated, similar quantities of radioactive  
2 gaseous effluents are expected to be generated during normal operations and outages from  
3 TMI-1 during the period of extended operations. The radioactive gaseous waste releases to the  
4 environment during the refurbishment will still be controlled and limited to satisfy the dose  
5 objectives of Appendix I to 10 CFR Part 50. These releases would result in doses to members of  
6 the public that are well below the ALARA dose design objectives, as discussed in Section 4.8.1.

### 7 *2.1.2.3 Solid Radioactive Waste*

8 The TMI-1 radioactive solid waste disposal system is designed to safely collect, process, store,  
9 and prepare wet and dry solid radioactive waste materials for onsite storage and offsite  
10 shipment. The system consists of a wet process stream used to collect, process, dewater, and  
11 solidify wet solid wastes, and a dry process stream used to collect and package dry solid  
12 wastes. Wet solid wastes include spent resins, filter cartridges, and filter crud. Dry solid wastes  
13 include contaminated rags, clothing, paper, outage equipment, and other radioactively  
14 contaminated equipment (AmerGen 2006a). Transportation of the radioactive solid waste is  
15 conducted in accordance with NRC and U.S Department of Transportation (DOT) regulations as  
16 specified in 10 CFR Part 61, "Licensing Requirements for Land Disposal of Radioactive Waste,"  
17 and 10 CFR Part 71, "Packaging and Transportation of Radioactive Material."

18 The NRC staff reviewed the TMI-1 solid radioactive waste reports for 2003 through 2007  
19 (AmerGen 2004b, 2005b, 2006b, 2007a, 2008b). The solid waste volumes and radioactivity  
20 amounts generated in 2007 are typical of previous annual waste shipments made by TMI-1.  
21 Variations in the amount of solid radioactive waste generated and shipped from year to year are  
22 expected based on the overall performance of the plant and the number and scope of  
23 maintenance work outages. The volume and activity of solid radioactive wastes reported by  
24 TMI-1 are reasonable and no unusual trends were noted.

25 AmerGen intends to replace the TMI-1 steam generators before the period of extended  
26 operation. Such an action is likely to result in a small increase in the amount of solid radioactive  
27 waste generated. This is based on an increase in the number of personnel working at the plant  
28 which will result in the generation of more solid waste during the outage and any other  
29 associated related work. An outage of this type will also result in an increased use of protective  
30 clothing, safety equipment, and filters, as well as a general increase in the generation of debris  
31 that will have to be disposed of as radioactive waste. The increased volume is expected to be  
32 within the range of solid waste that can be safely handled by TMI-1 during the period of  
33 extended operations. The transportation of the radioactive solid wastes related to the  
34 refurbishment activities will be conducted in accordance with NRC and DOT regulations as  
35 specified in 10 CFR Part 61 and 10 CFR Part 71.

36 Low-level mixed waste (LLMW) is waste that exhibits hazardous characteristics and contains  
37 low levels of radioactivity. LLMW has been regulated under multiple authorities. The U.S.  
38 Environmental Protection Agency (EPA) or State agencies regulate the hazardous component  
39 of LLMW through the Resource Conservation and Recovery Act (RCRA), and either the U.S.  
40 Department of Energy (DOE) or the NRC regulates the radioactive component. TMI-1 has not  
41 had any LLMW stored on site for the past 5 years and does not expect to have to store any in  
42 the foreseeable future.

43 The State of South Carolina's licensed low-level radioactive waste disposal facility, located in  
44 Barnwell, has limited the access from radioactive waste generators located in States that are



1 not part of the Atlantic Low-Level Waste Compact. Pennsylvania is not a member of the Atlantic  
2 Low-Level Waste Compact. This has impacted the ability of TMI-1 to dispose of its low-level  
3 solid radioactive waste and necessitated the need for TMI-1 to store its low-level solid  
4 radioactive waste on site. TMI-1 has decided to store its low-level solid radioactive waste in the  
5 solid waste staging facility (SWSF). The NRC staff has reviewed the TMI-1 SWFS plant  
6 procedure and has found that the SWSF performs no active function and was used for  
7 temporary staging of low-level radioactive waste before preparation for shipment and disposal.  
8 Because the SWSF is located outside and is exposed to the weather, the concrete structure and  
9 individual cells utilize gaskets, slots and weep holes, a drainage piping system, and a common  
10 sump, with its associated equipment and instrumentations, to protect the waste containers and  
11 to control the disposal of any effluent that may collect in the sump. TMI-1 has a monitoring,  
12 inspection, and testing program, which includes periodic evaluation of the operability and  
13 functional performance of active components of the SWSF system. The SWSF was designed to  
14 provide a controlled but ready access for material handling operations, to ensure that worker  
15 radiation exposures are controlled in accordance with the ALARA criteria, and to ensure that the  
16 offsite dose does not exceed any of the Federal limits specified in 10 CFR Part 20, as well as  
17 the EPA radiation standards in 40 CFR Part 190, "Environmental Radiation Protection  
18 Standards for Nuclear Power Operations."  
19

### 20 **2.1.3 Nonradiological Wastes**

21 RCRA governs the disposal of solid and hazardous waste. RCRA regulations are contained in  
22 Title 40, "Protection of the Environment," Parts 239 through 299 (40 CFR 239, et seq.), of the  
23 *Code of Federal Regulations*. Parts 239 through 259 of Title 40 contain regulations for solid  
24 (nonhazardous) waste, and Parts 260 through 279 contain regulations for hazardous waste.  
25 RCRA Subtitle C establishes a system for controlling hazardous waste from "cradle to grave,"  
26 and RCRA Subtitle D encourages States to develop comprehensive plans to manage  
27 nonhazardous solid waste and mandates minimum technological standards for municipal solid  
28 waste landfills (EPA 2007). Pennsylvania State RCRA regulations are administered by the  
29 Division of Hazardous Waste Management of the Pennsylvania Department of Environmental  
30 Protection (PADEP) and address the identification, generation, minimization, transportation, and  
31 final treatment, storage, or disposal of hazardous and nonhazardous wastes. TMI-1 generates  
32 nonradiological waste including oils, hazardous and nonhazardous solvents and degreasers,  
33 laboratory wastes, expired shelf-life chemicals and reagents, asbestos wastes, paints and paint  
34 thinners, antifreeze, non-routine (i.e., project-specific) wastes, point-source discharges  
35 regulated under the National Pollutant Discharge Elimination System (NPDES), sanitary waste  
36 (including sewage), and routine, daily refuse (AmerGen 2008).

#### 37 *2.1.3.1 Hazardous Waste*

38 Hazardous waste means solid waste, or a combination of solid wastes, which, because of its  
39 quantity, concentration, or physical, chemical, or infectious characteristics, may cause or  
40 contribute to an increase in mortality or serious illness. Such waste may also pose a significant  
41 present or potential hazard to human health or the environment if it is not properly treated,  
42 stored, transported, disposed of, or otherwise handled (40 CFR Part 261, "Identification and  
43 Listing of Hazardous Waste"). TMI-1 generates a variety of hazardous waste including spent  
44 and off-specification chemicals, laboratory chemical wastes, hazardous solvents and

## Affected Environment

1 degreasers, and occasional project-specific wastes. TMI-1 is classified as a “small quantity  
2 generator” of hazardous waste because the plant generates less than 1000 kilograms of  
3 hazardous waste in 1 month, and no more than 6000 kilograms of hazardous waste may be  
4 accumulated on site at any one time (EPA 2007a).

5 According to the EPA Envirofacts Warehouse, TMI-1 is classified as an active small quantity  
6 generator of hazardous wastes (EPA ID No. PAR000037861). The Envirofacts Warehouse  
7 database showed no violations for TMI-1 (EPA 2008a). During the site audit, the NRC viewed  
8 the TMI-1 waste storage building, which is a central facility designed for the safe and proper  
9 collection, sorting, packaging, and shipment of hazardous wastes. Also during the site audit,  
10 NRC staff reviewed AmerGen’s hazardous waste procedures and determined they complied  
11 with applicable RCRA regulations.

### 12 *2.1.3.2 Residual Waste*

13 TMI-1 generates solid waste, as defined by RCRA, as part of routine plant maintenance,  
14 cleaning activities, and plant operations. In Pennsylvania, solid waste is further classified as  
15 either municipal waste or residual waste by PA Code Article VIII and Article IX, respectively,  
16 based on its origin. TMI-1 nonhazardous solid waste is classified as residual waste. In  
17 Pennsylvania, residual waste is defined as nonhazardous industrial waste, including solid,  
18 liquid, or gaseous waste material produced by industrial, mining, or agricultural operations (PA  
19 Code Article IX). In addition to plant garbage, residual wastes generated at TMI-1 include  
20 nonhazardous waste oil and oily debris resulting from maintenance of oil-filled equipment;  
21 nonhazardous sludge from the industrial water supply treatment facility, waste water facility, or  
22 air pollution control facility; nonhazardous solvents and degreasers; asbestos; antifreeze; and  
23 occasional project-specific nonhazardous wastes. In 2007 TMI-1 generated approximately 26  
24 tons (t) (24 MT) of residual waste, not including approximately 198 t (179 MT) of garbage, of  
25 which approximately 188 t (170 MT) was incinerated at a resource recovery facility (AmerGen  
26 2008d).

### 27 *2.1.3.3 Universal Waste*

28 Universal waste is hazardous waste that is generated in a variety of settings and by a vast  
29 community and poses collection and management problems and often is not appropriately  
30 managed under existing hazardous waste regulations. EPA classifies several hazardous wastes  
31 as universal wastes including batteries, certain pesticides, mercury-containing devices, and  
32 fluorescent lamps (40 CFR Part 273, “Standards for Universal Waste Management”).  
33 Pennsylvania has incorporated by reference the EPA regulations regarding universal wastes.  
34 TMI-1 is a small quantity handler of universal waste (meaning the facility cannot accumulate  
35 more than 5000 kilograms (approximately 11,000 pounds) of universal waste at any one time),  
36 generating common operational wastes such as lighting ballasts containing polychlorinated  
37 biphenyls (PCBs), lamps, and batteries. In 2007 TMI-1 generated approximately 7,271 pounds  
38 (3,298 kilograms) of universal wastes (AmerGen 2008d).

### 39 *2.1.3.4 Mixed Waste*

40 As previously discussed in Section 2.1.2.3, LLMW contains both low-level radioactive waste and  
41 RCRA hazardous waste (40 CFR Part 266, “Storage, Treatment, Transportation, and Disposal  
42 of Mixed-Waste”). Pennsylvania has incorporated by reference Federal regulations exempting  
43 LLMW from RCRA storage and treatment regulations, provided the waste meets specific

1 conditions (PADEP 2001). TMI-1 has not generated any mixed waste in the past five years  
2 (AmerGen 2008d).

### 3 *2.1.3.5 Permitted Discharges*

4 TMI-1 generates two types of wastewater—industrial effluents and sanitary liquid wastes, both  
5 of which are discharged to the Susquehanna River according to the TMI-1 Individual  
6 Wastewater Discharge NPDES Permit No. PA0009920, enforced by PADEP (radioactive liquid  
7 waste is addressed in Section 2.1.2.1 of this report). Normal operating processes used to  
8 control the pH of the reactor coolant prevent scale and erosion in the cooling system and clean  
9 and defoul the condenser of biological organisms that generate chemical and biocide wastes.  
10 Waste liquids containing chemicals from these processes are combined with cooling tower  
11 blowdown and are discharged to the Susquehanna River according to the limitations contained  
12 in the TMI-1 NPDES permit. The industrial waste treatment system provides treatment of  
13 secondary plant sumps and drains to meet NPDES permit effluent limitations. Treatment  
14 includes settling and filtration to remove solids, an air flotation unit to remove oil and grease,  
15 and pH adjustment. TMI-1 has an onsite sewage treatment plant to treat sanitary wastewater  
16 generated by the plant. The sewage treatment plant averages approximately 11,000–12,000  
17 gallons (41,640–45,420 liters [L]) of effluent per day; approximately 7,000 gallons (26,500 L) are  
18 treated effluent and approximately 4,000 gallons (15,140 L) are filtered water used to deliver  
19 chlorine gas to the effluent for disinfection. Digested sanitary sludge from the sewage treatment  
20 plant is analyzed for radionuclides and transferred to a PADEP-approved agriculture utilization  
21 facility for disposal (AmerGen 2008d). Section 2.1.7.3 of this report provides more information  
22 on TMI-1 NPDES permit and effluent limitations.

### 23 *2.1.3.6 Pollution Prevention and Waste Minimization*

24 Currently, TMI-1 implements a waste minimization program which consists of steps such as  
25 segregating hazardous and nonhazardous wastes, choosing nonhazardous substitutes when  
26 possible, recycling or reclaiming appropriate waste materials, monitoring expired chemicals to  
27 determine minimum stocking requirements to reduce recurring excess, finding alternate uses for  
28 excess materials, or returning unused materials to the manufacturer. Currently TMI-1 does not  
29 recycle common waste materials such as paper, plastic, or aluminum.

30 In support of nonradiological waste minimization efforts, the EPA Office of Pollution Prevention  
31 and Toxics established a clearinghouse that provides information regarding waste management  
32 and technical and operational approaches to pollution prevention. The EPA clearinghouse can  
33 be used as a source for additional opportunities for waste minimization and pollution prevention  
34 at TMI-1, as appropriate (EPA 2008b).

35 EPA also encourages the use of environmental management systems (EMSs) for organizations  
36 to assess and manage the environmental impact associated with their activities, products, and  
37 services in an efficient and cost-effective manner. EPA defines an EMS as “a set of processes  
38 and practices that enable an organization to reduce its environmental impacts and increase its  
39 operating efficiency.” EMSs help organizations fully integrate a wide range of environmental  
40 initiatives, establish environmental goals, and create a continuous monitoring process to help  
41 meet those goals. The EPA Office of Solid Waste especially advocates the use of EMSs at  
42 RCRA-regulated facilities to improve environmental performance, compliance, and pollution

## Affected Environment

1 prevention (EPA 2008a). Introductory Web-based EMS training is available at the EPA Web  
2 site.<sup>2</sup>  
3

### 4 **2.1.4 Plant Operation and Maintenance**

5 Maintenance activities conducted at TMI-1 include inspection, testing, and surveillance to  
6 maintain the current licensing basis of the facility and to ensure compliance with safety and  
7 environmental requirements. Various programs and activities currently exist at TMI-1 to  
8 maintain, inspect, test, and monitor the performance of facility equipment. These maintenance  
9 activities include inspection requirements for reactor vessel materials, boiler and pressure  
10 vessel in-service inspection and testing, a maintenance structures monitoring program, and  
11 maintenance of water chemistry (AmerGen 2008c).

12 Additional programs include those implemented to meet technical specification surveillance  
13 requirements, those implemented in response to NRC generic communications, and various  
14 periodic maintenance, testing, and inspection procedures. Certain program activities are  
15 performed during the operation of the unit, while others are performed during scheduled  
16 refueling outages. Nuclear power plants must periodically discontinue the production of  
17 electricity for refueling, periodic in-service inspection, and scheduled maintenance. TMI-1  
18 refuels on a 24-month interval (AmerGen 2008c).  
19

### 20 **2.1.5 Power Transmission System**

21 TMI-1 is connected to the regional grid via four, 230-kilovolt (kV) transmission lines, which total  
22 5.6 mi (9.0 km) in length. These transmission lines are owned by AmerGen, who purchased  
23 TMI-1 from FirstEnergy in 1999; however, FirstEnergy continues to operate and maintain the  
24 transmission lines and their right-of-ways (ROWs) (AmerGen 2008). Transmission lines  
25 considered in scope for license renewal are those constructed to connect the facility to the  
26 transmission system (10 CFR 51.53(c)(3)(ii)(H)); therefore, the four lines, Line No. 1091, Line  
27 No. 1092, Line No. 1051, and the TMI-1 to TMI-1 500-kV substation line, are considered in  
28 scope and are discussed below in detail.





29 All four transmission lines originate at the TMI-1 switchyard and are shown in Figure 2-4. Line  
30 No. 1091 and Line No. 1092 extend 1.5 mi (2.4 km) northeast to the Middletown Junction  
31 Substation near Middletown, Pennsylvania. These lines share a 150-ft-wide (46-meter [m])  
32 ROW. Line No. 1051 travels south for 4.1 mi (6.6 km) from the TMI-1 switchyard to the Jackson  
33 Substation, which is located near Jackson, Pennsylvania. The fourth line, unnumbered, travels  
34 from the TMI-1 switchyard 0.7 mi (1.1 km) to the TMI 500-kV substation. Line No. 1051 and the  
35 unnumbered line share a 150-ft-wide (46 m) ROW (AmerGen 2008).

36 In total, FirstEnergy operates and maintains 5.6 mi (9.0 km) of transmission lines and maintains  
37 142 acres (ac) (57 hectares [ha]) of transmission line ROWs (AmerGen 2008). The four lines  
38 cross the Susquehanna River in three locations, as shown in Figure 2-4. The lines do not cross

---

<sup>2</sup> Web-based EMS training available URL: <http://www.epa.gov/epaoswer/ems/ems-101/ems101.htm>





**Figure 2-4. Three Mile Island Nuclear Station, Unit 1, Transmission System**  
(Source: AmerGen 2008)

## Affected Environment

1 any Federal, State, or local parks. FirstEnergy has vegetative maintenance procedures in place  
2 to prevent vegetation from interfering with the lines (FirstEnergy 2007). ROW vegetative  
3 maintenance practices use an integrated vegetation management approach that includes both  
4 mechanical and chemical control methods. Mechanical methods consist primarily of mowing,  
5 with supplementary pruning, felling, and hand trimming as needed. Chemical control methods  
6 consist of application of EPA-approved herbicides and tree-growth-regulating chemicals  
7 (FirstEnergy 2008). Procedures are in place to manage environmental incidents that might  
8 occur within the ROW, such as a chemical buildup in a wetland area. AmerGen, in conjunction  
9 with FirstEnergy staff, limits erosion around stream crossings and wetlands by using appropriate  
10 procedures and methods. ROWs that cross farmland or pastures are not maintained by  
11 FirstEnergy, as the land is cultivated by the local farmers. FirstEnergy will maintain the existing  
12 ROWs regardless of whether TMI-1 is granted a renewed operating license (AmerGen 2008).  
13

### 14 **2.1.6 Cooling and Auxiliary Water Systems**

15 The TMI-1 circulating water system withdraws cooling water from, and discharges cooling tower  
16 blowdown to, the Susquehanna River. TMI-1 uses two hyperbolic natural draft cooling towers to  
17 dissipate heat from the plant's steam cycle to the atmosphere. Other systems that dissipate  
18 heat from the plant include the secondary services cooling system, the nuclear services cooling  
19 system, and the decay-heat cooling system (AEC 1972).

20 Water that is lost through cooling tower evaporation, wind, and as blowdown returned to the  
21 Susquehanna River is termed "makeup" water. Makeup water is obtained from the secondary  
22 services river water pumping system. The river intake structure is located on the shoreline of the  
23 Susquehanna River and is designed to pump under three river conditions—minimum river level  
24 of 271 ft (83 m) ("loss of the York Haven Dam"), normal river elevation of 278 ft (85 m), and  
25 flood levels. A deicing line operates during periods of subfreezing temperatures to prevent ice  
26 from forming and possibly blocking the intake structure. Under normal operation in subfreezing  
27 weather, condenser circulating water is the source of deicing water (AEC 1972).

28 River water enters the intake structure at a velocity of approximately 0.2 feet per second (ft/s)  
29 (0.06 m per second [m/s]), passes under a skimmer wall, travels through automated trash racks  
30 with 1-inch vertical bar spacing, through 3/8-inch mesh traveling screens, through the river  
31 water pumps, and lastly through 1/8-in mesh strainers before entering the heat exchangers.  
32 Once in the heat exchangers, river water mixes with the circulating water in the circulating  
33 pumps. The circulating water pump building contains six circulating water pumps—three pumps  
34 feed each of the two, 102-inch-diameter mains (AEC 1972). The circulating water system  
35 contains a chemical injection system for controlling bacterial and algae growth and metal  
36 corrosion (AmerGen 2008). The chemical injection to the circulating water comprises sodium  
37 hypochlorite, sulfuric acid, sodium bromide, scale inhibitor, dispersants, and other associated  
38 chemicals (AmerGen 2008c).

39 Under normal operation, maximum withdrawal of makeup water from the Susquehanna River for  
40 cooling tower losses is approximately 15,250 gallons per minute (gpm) (34 cubic ft per second  
41 [cfs], or 1 cubic meter per second [m<sup>3</sup>/s]). Water is pumped to a high point on the site, and  
42 cooling tower blowdown is drained by gravity and discharged back to the Susquehanna River  
43 through a 48-inch-diameter river discharge line, which is located behind the natural shoreline  
44 downstream of the river intake structure. Cooling tower blowdown ranges from 3000 gpm (6.7

1 cfs, or 0.19 m<sup>3</sup>/s) during normal operation to 6000 gpm (13.4 cfs, or 0.38 m<sup>3</sup>/s) during maximum  
2 operation. Under normal conditions the discharge velocity is 2.7 ft/s (0.8 m/s) with a maximum  
3 value of 5.2 ft/s (1.6 m/s) (AEC 1972). The PADEP regulates plant discharges under NPDES  
4 Individual Wastewater Discharge Permit No. PA 0009920 (AmerGen 2008). Section 2.1.7.3 of  
5 this report discusses the discharges permitted from TMI-1.

6 The TMI-1 intake structure does not have a fish return system, therefore fish and other aquatic  
7 organisms that may become entrained in the TMI-1 intake structure and impinge on the trash  
8 racks, traveling screen, or mesh strainers are not returned to the river.  
9

## 10 **2.1.7 Facility Water Use and Quality**

11 The TMI-1 circulating water system and the service water system both draw water from, and  
12 discharge to, the Susquehanna River. Onsite ground water wells also supply water for cooling  
13 water makeup, domestic water consumption, and other industrial uses. The following sections  
14 detail water use at TMI-1.

### 15 *2.1.7.1 Ground Water Use*

16 A portion of the water utilized by TMI-1 for its operation is ground water. Specifically, ground  
17 water is used for station fire service, makeup water to the demineralized water system, bearing  
18 lubrication for the screen house intake pumps, service water for onsite buildings and equipment,  
19 and drinking water. Onsite ground water is drawn from three service wells (installed in 1996) as  
20 well as two drinking water wells (one of which can also be used, when needed, to supply  
21 additional water to the service system). Drinking water is treated on site using a dilute  
22 orthophosphate solution, a zinc orthophosphate solution, and a sodium hypochlorite solution, as  
23 permitted by PADEP. The site also operates a sanitary wastewater treatment facility, with a  
24 capacity of up to 80,000 gallons per day (gpd) (302,833 liters per day [Lpd]) though the typical  
25 flow ranges from 10,000 gpd to 15,000 gpd (37,854 Lpd to 56,781 Lpd), with a maximum flow of  
26 40,000 gpd (151,416 Lpd) during outages (AmerGen 2008).

### 27 *2.1.7.2 Surface Water Use*

28 Susquehanna River water is withdrawn for use in the circulating cooling water system through  
29 the intake structure located on the island's western bank. Under typical conditions the flow  
30 velocity at the intake structure is around 0.2 ft/s (0.06 m/sec), with a normal river elevation of  
31 277 feet (84.4 m). Approximately 12,250 gpm (27.3 cfs, or 0.8 m<sup>3</sup>/s) is withdrawn from the river  
32 under these conditions, and the maximum withdrawal of makeup water is approximately 15,250  
33 gpm (34 cfs, or 1.0 m<sup>3</sup>/s) (AmerGen 2008). The intake structure is designed to pump river water  
34 into the system during normal conditions and during extreme conditions such as the loss of the  
35 York Haven Dam and major flood levels (AmerGen 2008).

36 Cooling tower blowdown typically ranges from 3000 gpm to 6,000 gpm (6.68 to 13.4 cfs, or 0.2  
37 to 0.4 m<sup>3</sup>/s) at its maximum. Water not lost by evaporation or drift from the cooling towers is  
38 discharged at a rate ranging from 2.7 ft/s to 5.2 ft/s (0.82 m/s to 1.58 m/s) at its maximum, in a  
39 manner complying with the plant's NPDES Individual Wastewater Discharge Permit No. PA  
40 0009920 issued by PADEP in October 2007 (AEC 1972; AmerGen 2008).

41 The primary sources of river water consumption are evaporation and drift losses, and TMI-1 has  
42 an SRBC (Susquehanna River Basin Commission) permit allowing for the consumptive use of

## Affected Environment

1 river water of up to 18 million gpd (mgd) (68 million Lpd) (SRBC 1995). To abide by this permit,  
2 TMI-1 takes part in the Cowanesque Reservoir Water Allocation Project. This project keeps  
3 TMI-1 from having to shut down in the event of a severe drought in the Susquehanna River by  
4 allowing for water stored in the reservoir to be discharged downstream during such an  
5 emergency.

### 6 *2.1.7.3 Surface Water Quality*


7 Between the years 1974 and 1982, Metropolitan Edison and GPU Nuclear performed various  
8 studies on the water quality around Three Mile Island to evaluate the impacts of the plant on  
9 local water quality (Ichthyological Associates 1983). These studies utilized data on water  
10 chemistry, macroinvertebrates, larval and adult fishes, and thermal plume mapping. The last  
11 year with available data for both operating units is 1978 because of the accident at TMI Unit 2 in  
12 March 1979. During this period of combined operation of the two units, none of the water quality  
13 criteria violated the State requirements. The studies examined water quality parameters  
14 including turbidity, alkalinity, sulfate, total dissolved solids, total and dissolved copper, and total  
15 and dissolved zinc. The data were gathered near both the upstream and downstream discharge  
16 structures. Additional measurements of water temperature, pH, and dissolved oxygen were  
17 taken at various sampling locations (Ichthyological Associates 1983).

18 The studies concluded that mean levels for dissolved oxygen, turbidity, total copper, and total  
19 zinc peaked in April, whereas water temperature, alkalinity, sulfate, and total dissolved solids  
20 peaked in July. Dissolved zinc was highest in November. The data also showed that levels of  
21 alkalinity, sulfate, dissolved copper, and total zinc were generally higher values upstream,  
22 whereas levels of water temperature, dissolved oxygen, turbidity, total dissolved solids, and  
23 dissolved zinc were higher downstream (Ichthyological Associates 1979; 1983).


24 The Susquehanna River was tested for water temperature and showed a typical pattern of low  
25 temperatures in the winter, with highs in the late summer months. Water temperature data  
26 obtained immediately below the discharge indicated that the thermal effluent did not heat the  
27 surrounding water enough to exceed the temperatures mandated by the State. It also showed  
28 that the upstream and downstream temperatures did not differ by over 5 degrees Fahrenheit  
29 (°F) (Ichthyological Associates 1979; 1983). Water temperature data collected between March  
30 1979 and 1982 represent ambient conditions because, following the TMI Unit 2 accident, both  
31 units were shut down, with TMI-1 not resuming operation until 1985.

32 In more recent years, AmerGen has collected water temperature data using an automatic  
33 temperature sensor located at the intake screen pump house and the discharge monitoring pit,  
34 which is before the discharge water is mixed with the river water. Figure 2–5 on the following  
35 page represents the recorded daily average discharge and intake temperatures between August  
36 2005 and September 2007, with the 2006 maximum discharge recorded as 110.2°F (43.4  
37 degrees Celsius [°C]) and the 2007 maximum as 101.1°F (38.4 °C) (recorded in August and  
38 September, respectively).





**Figure 2-5. Three Mile Island Nuclear Station, Unit 1, Inlet and Discharge Temperatures**  
(Source: AmerGen 2007c)



**LEGEND**

- Daily Average Inlet
- Daily Average Discharge

- 1 Table 2-1 represents the calculated differences between discharge and intake temperature ( $\Delta T$ )  
 2 on a month-to-month basis recorded during the same time period. The maximum temperature  
 3 difference recorded is 30.16 °F in April 2006 (AmerGen 2007c).

**Table 2-1. Monthly Average, Minimum, and  
 Maximum  $\Delta T$  (°F) Based on Automatic  
 Temperature Sensors at the Intake  
 Screen Pump House**

Year	Month	Average $\Delta T$	Minimum $\Delta T$	Maximum $\Delta T$
2005	August	11.66	7.50	13.80
	September	11.04	2.76	16.46
	October	11.16	1.61	16.58
	November	5.98	0.78	14.67
	December	11.13	4.74	14.02
2006	January	9.47	6.30	10.77
	February	9.43	6.35	11.67
	March	12.23	5.32	17.04
	April	15.86	11.26	30.16
	May	16.10	7.13	20.61
	June	17.80	8.96	22.68
	July	16.59	9.72	21.17
	August	16.86	11.99	21.88
	September	18.84	10.26	21.56
	October	17.10	10.18	21.27
	November	16.04	4.83	22.41
	December	17.17	5.42	21.71
2007	January	16.88	11.35	20.22
	February	17.32	11.01	19.36
	March	17.35	9.64	24.37
	April	20.55	10.99	28.96
	May	21.01	15.97	27.08
	June	14.87	8.67	19.17
	July	15.01	11.62	18.04
	August	13.95	10.08	16.53
	September	15.56	8.74	20.95

Source: AmerGen 2007c

- 4  
 5 Historically, monitoring in the Susquehanna River has shown river flow to be a very influential  
 6 parameter in determining water quality. Over the past few decades of recorded data, mean river  
 7 flow fluctuated based on snow melt, spring runoff, rain, and periods of drought. A parameter  
 8 analysis conducted using 17 years of water temperature, pH, and dissolved oxygen data, and  
 9 13 years of total dissolved solids data found that trends appear to relate more to meteorological  
 10 cycles, river flows, and land and water uses than to operations at the TMI-1 site. In addition, the  
 11 data showed no significant impact of TMI-1 discharge on water quality (Normandeau 2007).

1 The water quality of the Lower Susquehanna River Basin has considerably improved since the  
2 1970s. Water quality issues in this area were historically dominated by acid mine drainage  
3 discharges upstream, which have been considerably reduced, as well as sewage-treatment  
4 plant improvements, a ban on phosphate detergents, and improvement of agricultural practices.  
5 The concentration of nitrate, however, has been shown to be increasing. A 2002 water quality  
6 study conducted by the SRBC collected data from 25 stations along the river, as well as at the  
7 mouths of its three major tributaries. Six of these stations were determined to be moderately  
8 impaired, and 19 were designated as slightly impaired. Out of the 950 tested water quality data  
9 points, 79 were found to exceed the tolerance levels for aquatic life. According to the SRBC  
10 report, this is an indication of fairly good water quality (SRBC 2006).

11 In accordance with the Federal Water Pollution Control Act (or the Clean Water Act (CWA)),  
12 TMI-1 effluent discharges are regulated by NPDES Individual Wastewater Discharge Permit No.  
13 PA 0009920 issued and enforced by PADEP. Section 402 of the CWA states that "NPDES  
14 prohibits [discharges] of pollutants from any point source into the nation's waters except as  
15 allowed under an NPDES permit." The purpose of this permit is to regulate wastewater  
16 discharge to preserve the water quality of the surrounding water bodies. As of the most recent  
17 permit issued, there have been no notices of violation for the TMI-1 site. Information in this  
18 section was obtained from the TMI-1 NPDES. The applicant's license renewal environmental  
19 report includes a copy of the most recent TMI-1 NPDES permit (AmerGen 2008).

20 The most recent renewal of this permit occurred in October 2007. Table 2-2 on the following  
21 page shows the quantitative effluent limitations regulated under the NPDES permit. In addition  
22 to these effluent limitations, the permit also stipulates that during any 1-hour period, discharge  
23 may not affect the temperature of the receiving water body by more than 2 °F. No violations of  
24 this limit have been recorded.

25 The permit outlines the effluent limitations and monitoring requirements of 10 different discharge  
26 outfalls. In addition to the effluent limitations shown in Table 2-2, the permit also outlines the  
27 minimum number of sampling events that are required for each outfall, where necessary.  
28 Additionally, the discharge of "floating solids, visible foam, or other substances that produce  
29 color, tastes, odors, turbidity or settle to form deposits" are to be controlled, and pH is to be  
30 monitored, with the required levels being between 6.0 and 9.0.

31 Outfall 001 (by far the largest outfall on site) receives wastewater from the circulating cooling  
32 water, secondary service water, reactor building, emergency cooling, decay heat, nuclear  
33 service water, liquid radioactive waste treatment, station blackout diesel cooling water, and  
34 several other minor sources. Its discharge limitations were calculated based on a maximum  
35 discharge rate of 81.02 mgd (306.7 million Lpd). Outfall 003 is an emergency outfall, meant to  
36 receive discharge from TMI-1 in the event that Outfall 001 is blocked. Outfall 004 is another  
37 emergency outfall which receives discharge from TMI-1 in the event that the TMI-1 mechanical  
38 draft cooling tower is blocked. Both of these emergency outfalls are based on the same rate of  
39 81.02 mgd (306.7 million Lpd) as Outfall 001. If either of these outfalls is used, the facility is  
40 required to notify PADEP within 2 days to explain the composition of the discharge and the  
41 reason for its use.

42 Outfall 101 receives wastewater from the sewage treatment plant, and its limitations are based  
43 on a discharge rate of 0.08 mgd (302,833 Lpd). In addition to the effluent limitations shown, the  
44

Table 2-2. National Pollutant Discharge Elimination System Effluent Limitations for TMI-1

Outfall No.	Total Suspended Solids (mg/L)		Oil and Grease (mg/L)		Day Chlorine (mg/L)		Phosphorus (mg/L)		Oxidants (mg/L)		Spectrus Hydrazine (mg/L)		Temperature (°F)	
	Max.	Inst.	Max.	Inst.	Max.	Inst.	Avg.	Inst.	Max.	Inst.	Max.	Inst.	Max.	Inst.
001	NLR	NLR	NLR	NLR	NLR	NLR	0.5	NLR	0.14	0.17	0.1	0.3	Not Detectable	110
003	NLR	NLR	NLR	NLR	NLR	NLR	0.5	NLR	0.14	0.17	0.1	0.3	Not Detectable	110
004	NLR	NLR	NLR	NLR	NLR	NLR	0.5	NLR	0.14	0.17	0.1	0.3	Not Detectable	NLR
005A	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR
005B	30	100	15	20	30	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR
006	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR
101	30	NLR	60	NLR	NLR	25	50	NLR	4	NLR	NLR	NLR	NLR	NLR
401	30	100	15	20	30	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR
501	30	100	15	20	30	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR
701	30	100	15	20	30	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR

Source: NPDES No. PA 0009920

NLR = No Longer Regulated

1 permit requires this outfall to be monitored for fecal coliform levels, which are restricted to an  
2 average monthly concentration of 200 per 100 milliliters from May to September, and 2000 per  
3 100 milliliters from October to April. Outfall 401 receives wastewater from the industrial waste  
4 filter system, and its limitations are based on a discharge rate of 0.3 mgd (1.1 million Lpd).  
5 Outfall 501 receives wastewater from the TMI-1 secondary neutralizer tank, and its limitations  
6 are based on a discharge rate of 0.3 mgd (1.1 million Lpd). Outfall 701 receives wastewater  
7 from the industrial waste treatment system, and its limitations are based on a discharge rate of  
8 0.3 mgd (1.1 million Lpd).

9 Outfall 005B receives wastewater from screen house desilting, dewatering of the TMI-1 natural  
10 draft cooling towers, fire brigade training, the fuel oil offloading station, industrial cooler  
11 maintenance, emergency diesel generator building floor drains, and operation of the east dike  
12 settling basin drain valve. The discharge rates upon which these limitations are based are not  
13 specified by the permit. Outfall 006 receives wastewater from intake screen wash and sluice  
14 water, the intake pump strainer backwash, and the intake chlorinator building floor drain. No  
15 discharge limitations are put on this outfall, but it does require the collection of all debris found  
16 on the intake screens which is not discharged into the Susquehanna River. The stormwater  
17 outfalls are 005A, SO1, SO2, SO3, and SO4. They do not have specific effluent limitations, but  
18 are required to be monitored for biochemical oxygen demand (BOD-5 Day), chemical oxygen  
19 demand, total suspended solids, total phosphorus, total Kjeldahl nitrogen, dissolved iron, oil and  
20 grease, and pH levels.

21 Discharge of stormwater must also be monitored for pollutants to ensure that the discharge only  
22 consists of uncontaminated stormwater. TMI-1 is required to report these data to PADEP using  
23 discharge monitoring reports. TMI-1 is also required to report, within 24 hours of their  
24 occurrence, any unexpected diversions of wastewater that exceed any listed effluent limitation,  
25 upsets that exceed or threaten to exceed any limitations, and any violations of maximum daily  
26 discharge limitations.

27 Part C of the NPDES permit specifies that waterborne releases of radioactive material must  
28 conform to the guidelines in Appendix I to 10 CFR Part 50. The facility must provide reports  
29 which describe quantities of unrestricted radioactive material released in effluent discharge to  
30 the PADEP Bureau of Radiation Protection and the NRC.

## 32 **2.2 Affected Environment**

33 This section provides general descriptions of the environment near TMI-1 as background  
34 information. This section also provides detailed descriptions where needed to support the  
35 analysis of potential environmental impacts of refurbishment and operation during the renewal  
36 term, as discussed in Chapters 3 and 4. Section 2.2.9 describes historic and archaeological  
37 resources in the TMI-1 area, and Section 2.3 describes the possible impacts associated with  
38 other Federal project activities.

### 40 **2.2.1 Land Use**

41 Three Mile Island covers approximately 370 ac (150 ha), of which about 200 ac (81 ha) are  
42 occupied by the TMI-1 and TMI Unit 2 facilities. AmerGen owns the entire island except certain

## Affected Environment

1 TMI Unit 2 facilities. AmerGen also owns all or a portion of some of the smaller islands in the  
2 vicinity of Three Mile Island and a portion of the eastern bank of the Susquehanna River. TMI-1  
3 is surrounded by fencing and contains few areas that have not been developed or previously  
4 disturbed. As can be seen in Figure 2-6, the undeveloped land on the island is found south of  
5 the TMI-1 and TMI Unit 2 facilities. The majority of this undeveloped land lies under the 10-year  
6 flood level and is subject to seasonal variations in water level. The southern part of the island  
7 contains a wetland that was formed when borrow pits created during construction of a flood dike  
8 system, which surrounds the TMI-1 and TMI Unit 2 facilities, filled with water. The southern  
9 portion of the island also contains fallow field areas that are surrounded by a woodland buffer  
10 (AmerGen 2008).




11 The TMI-1 site encompasses several properties that total approximately 440 ac (162 ha).  
12 Included are Three Mile Island; St. John's Island and Evergreen Island (also referred to as  
13 "Sand Beach Island"), which are situated north of Three Mile Island and together total  
14 approximately 31 ac (13 ha); a 6.4-ac (2.6-ha) section of Shelley Island, which is part of the  
15 western half of the TMI-1 exclusion area; and a 32-ac (13-ha) strip of land east of Three Mile  
16 Island along the eastern shore of the Susquehanna River (AmerGen 2008).

17 Three Mile Island is approximately 11,000 ft long and 1,700 ft wide with the long axis aligned  
18 north to south in the river. It lies approximately 900 ft from the east bank of the Susquehanna  
19 River and approximately 6500 ft from the west bank of the river (see Figure 2-6). The  
20 Susquehanna River makes a sharp change in directional flow from southeasterly to nearly due  
21 south just north of Three Mile Island where the river widens to approximately 1.5 mi (2.4 km).  
22 This widening resulted from the Red Hill and York Haven Dams, which transect the river on  
23 either side of the downstream end of Three Mile Island creating a barrier for the purpose of  
24 hydroelectric generation (AmerGen 2008). State Highway (SH)-441 parallels Three Mile Island  
25 to the east, and tracks of the Norfolk Southern Railroad parallel the Susquehanna River on the  
26 eastern and western banks. Shelley Island is located west of Three Mile Island in the middle of  
27 the river, and the borough of Goldsboro is located on the western bank of the river. The  
28 developed portion of the TMI-1 site is surrounded by a flood protection dike system. Access to  
29 the northern portion of Three Mile Island is by a bridge connecting the main entrance to the TMI-  
30 1 site and the mainland near the junction of SH-441 and Geyers Church Road. Another bridge  
31 connects the southern end of Three Mile Island with the east bank of the Susquehanna River  
32 near Falmouth on SH-441 in Lancaster County. The southern bridge serves as access to TMI-1  
33 for some station operation personnel, refueling outage workers, and construction equipment. It  
34 also provides an alternate egress route.  
35

### 36 **2.2.2 Air and Meteorology**

37 TMI-1 is located in Dauphin County, one of the four counties comprising the Harrisburg  
38 metropolitan area (AmerGen 2008). Pennsylvania is divided into 10 climate regions. Dauphin  
39 County belongs to Climate Region 5, along with Lycoming, Columbia, Montour, Union,  
40 Northumberland, Snyder, Mifflin, Juniata, and Perry Counties (PSC 2008). Data collected in the

Affected Environment



**Figure 2-6. Three Mile Island Nuclear Station, Unit 1, Site Boundary Map (Source: AmerGen 2008)**

## Affected Environment

1 region since 1899 show that average winter temperature is 29.9 °F (1.2 degrees Celsius [°C]),  
2 rarely dropping below 20 °F (-6.7 °C), while average summer temperature is 61.15 °F (16.39  
3 °C), with July being the hottest month (PSC 2008a).

4 Precipitation is fairly evenly distributed throughout the year. Annual precipitation amounts  
5 generally range between 30 to 48 inches, with occasional amounts reaching 54 to 58 inches.  
6 The greatest amounts of precipitation usually occur in the spring and summer months, while  
7 February is the driest month, amounting to about 2 inches less than the wettest months (PSC  
8 2008b). As documented by Pennsylvania State climatologists, average mean snowfall from  
9 1957 through 2007 was 35.4 inches (PSC 2008c).

10 The dominant wind direction throughout the State of Pennsylvania is from the west, with some  
11 seasonal variation. TMI-1 historical meteorological reports show that yearly winds from the  
12 northwest prevail, with stronger winds in winter (windspeed varies from 4 to 10 knots) and  
13 calmer winds in summer (windspeed varies from 0 to 6 knots). The median annual windspeed  
14 as reported by the National Weather Service station located in Harrisburg (approximately 10 mi  
15 [16 km] northwest of TMI-1) is 7.5 mi per hour (mph) (4.1 knots) (NCDC 2008; PSC 2008b).  
16 While the prevailing westerly winds result in most of the air masses that affect Pennsylvania  
17 (those originating from the interior of the continent), the Atlantic Ocean does have a limited  
18 influence on the climate of the State. Coastal storms can affect the day-to-day weather,  
19 primarily in the eastern section of the State.

20 Severe weather events in Pennsylvania are generally uncommon. Severe snowstorms are  
21 infrequent, but when they do occur, they can approach blizzard conditions. High winds have  
22 been known to cause huge drifts that can disrupt normal routines for several days. While the  
23 incidence of tornadoes is very low, the region has occasionally been hit with storms that caused  
24 loss of life and property damage. June is the month of highest tornado frequency, followed  
25 closely by July and August. The National Climatic Data Center (NCDC 2008a) reported 13  
26 tornadoes in Dauphin County from 1950 through February 2008—three at F0, six at F1, and  
27 four at F2 strengths.<sup>3</sup> The most destructive activity in Dauphin County occurred on April 5, 1977,  
28 and caused \$2.5 million in property damage. (NCDC 2008b)

29 The TMI-1 meteorological data monitoring system consists of Alpha and Bravo systems. Alpha  
30 system allows it to measure windspeed and direction at 100 ft (30 m) and 150 ft (46 m), ambient  
31 temperature at 33 ft (10 m), and differential temperature at 150 ft (46 m). Measurement of  
32 windspeed and direction on Bravo system is conducted at 100 ft, while ambient temperature is  
33 measured at 33 ft (10 m) and differential temperature is measured at 150 ft (46 m). The  
34 meteorological data are collected via e-mail sent by the TMI-1 chemistry department. It is  
35 sampled once per hour and stored in the meteorological database which is edited once a week;  
36 invalid data are deleted during the data review process performed by a meteorologist. The

---

<sup>3</sup> The Fujita six-point scale (F0 to F5) is used to rate the intensity of a tornado based on the damage it inflicts to structures and vegetation. The lowest intensity is F0; the highest is F5. Fujita scale categories are based on estimated (not measured) sustained windspeeds compared against observed structural damage. An enhanced Fujita scale replaced the original Fujita scale in February 2007. The enhanced Fujita scale still uses six categories of tornado intensity (EF0 to EF5), but defines those categories differently. For additional information about the Fujita scale, see the following National Oceanic and Atmospheric Administration Web site and the hypertext links therein—<http://www.spc.noaa.gov/faq/tornado/f-scale.html>.



1 quality-assured meteorological data are then compiled into monthly, quarterly, and annual  
2 reports (AmerGen 2006).

### 3 *2.2.2.1 Regional Air Quality Impacts*

4 TMI-1 is located within the Mid-Atlantic Air Quality Control Region 3, as designated by the EPA.  
5 The Mid-Atlantic Air Protection Region 3 is represented by Delaware, the District of Columbia,  
6 Maryland, Pennsylvania, Virginia, and West Virginia. The Bureau of Air Quality of PADEP is  
7 responsible for regulating all air emission sources within the State. Pennsylvania's ambient air  
8 monitoring program is a result of the implementation of the Federal Clean Air Act on a State  
9 level. The State is divided into six air regions, and Dauphin County, where TMI-1 is located,  
10 belongs to the Southcentral Air Quality Region, which includes the counties of Adams, Bedford,  
11 Berks, Blair, Cumberland, Dauphin, Franklin, Fulton, Huntington, Juniata, Lancaster, Lebanon,  
12 Mifflin, Perry, and York. Dauphin County is a nonattainment area for fine particulate matter  
13 ( $PM_{2.5}$ ) and a part of the Harrisburg-Lebanon-Carlisle  $PM_{2.5}$  nonattainment area, which includes  
14 Cumberland, Dauphin, and Lebanon Counties. There are two monitoring sites in the Harrisburg-  
15 Lebanon-Carlisle  $PM_{2.5}$  nonattainment area—one in Dauphin County (Harrisburg) and one in  
16 Cumberland County (Carlisle). PADEP also operates several types of  $PM_{2.5}$  monitors in Carlisle  
17 and Harrisburg (PADEP 2004).

18 TMI-1 is recognized as a synthetic minor facility by Pennsylvania State regulators because of  
19 the quantities of emissions and restrictions on the hours of operation of its stationary sources of  
20 criteria pollutants; therefore operation of the sources is regulated by a State Only Operating  
21 Permit for Synthetic Minor Facility (AmerGen 2006d). TMI-1 has a number of stationary  
22 emission sources, including two auxiliary boilers, six standby emergency power supply diesel  
23 generators, two emergency power generators, a blackout emergency generator, a security  
24 system uninterruptible power generator, and two substation emergency power generators. A  
25 number of sources do not require any work practice standards, test monitoring, recordkeeping,  
26 or reporting requirements, as defined by the PADEP permit for TMI-1. Some of these sources  
27 include three air compressors, the turbine building, vents, turbine oil vapor extractor, a 15,000-  
28 gallon (56,781 L) turbine lubricating oil storage tank, water and waste water treatment chemical  
29 storage tanks, water and waste water treatment system, the two natural draft cooling towers,  
30 two mechanical draft industrial cooling towers, diesel fuel and fuel oil storage tanks, and an  
31 emergency warehouse diesel-fueled fire pump. The generators are tested periodically to ensure  
32 their continued ability to perform their intended function, and there are procedures in place to  
33 ensure continuous monitoring, sampling, and filtering of the oil.  
34

### 35 **2.2.3 Ground Water Resources**

36 Three Mile Island is one of a sequence of Triassic lowland deposits in an area known as the  
37 Gettysburg Basin. The island itself formed during the later stages of glaciation as a result of  
38 fluvial deposition (materials deposited by river flow) of glacial melt-water by the slow-moving  
39 flow of the Susquehanna River and the resulting steady accumulation of sediments to form the  
40 island.

41 Two aquifers are located beneath the TMI-1 site. The shallowest aquifer consists of surficial  
42 alluvial deposits under unconfined conditions. The alluvial layer is made up of silty sand, with  
43 some gravels and clay, and ranges from 7–19 ft (2.1–5.8 m) in thickness. This layer overlies

## Affected Environment

1 layers of glacial outwash, which range from 12–21 ft (3.7–6.4 m) in thickness and are composed  
2 of dense gravel and silt.

3 The second and underlying aquifer is the Gettysburg shale, which is the primary aquifer in the  
4 area of the site. Ground water in the Gettysburg shale is under semi-confined conditions, based  
5 on information gathered during drilling operations on the island. The shale is found 19–28 ft  
6 (5.8–8.5 m) below the surface (AmerGen 2008). It is described as a tabular aquifer, meaning  
7 some beds within the Gettysburg shale are able to transmit water, while others are not. The  
8 range of permeability within the bedrock is primarily caused by varying frequencies of fractures  
9 (Conestoga-Rovers 2006). Within the bedrock, which dips to the northwest, ground water is  
10 found within joints, fractures, and bedding separations. Two major joint sets occur on the island,  
11 with one dipping nearly 90 degrees, and the other dipping 50–60 degrees in the southwestern  
12 direction. The hydraulic conductivity of the aquifer ranges from 2,126 ft–4,208 ft/yr (648.0–  
13 1282.6 m/yr).

14 The ground water conditions found in the upper aquifer (the alluvial deposits) are directed by the  
15 river itself, with the water table's maximum elevation centered in the middle of the island and  
16 gently sloping toward the island's shores. The Susquehanna acts as a boundary for this aquifer  
17 as the ground water flows into the river. The lower aquifer (the Gettysburg shale) is unlikely to  
18 receive flow from the river because of its lower flow characteristics, but could occur if pumping  
19 from the surface is heavy enough to cause infiltration.

### 20 *2.2.3.1 TMI-1 Water Supply Wells*

21 Of the 54 water supply wells found in a specified 1-mile radius of the TMI-1 site, only 7 are  
22 associated with the plant. Five of these wells are on site, while the remaining two supply potable  
23 water to the Visitors Center and the Training Center/Simulator Building. The Visitors Center well  
24 is installed at a depth of 121 ft (36.8 m) and produces up to 10 gpm (0.02 cfs, or 0.001 m<sup>3</sup>/s),  
25 while the Training Center/Simulator Building well is at 100 ft (30 m) and can yield up to 30 gpm  
26 (0.07 cfs, or 0.002 m<sup>3</sup>/s) (Conestoga-Rovers 2006). From 2003–2005, these seven ground  
27 water wells yielded a combined total that averaged to about 95–115 gpm (0.21–0.25 cfs, or  
28 0.006–0.007 m<sup>3</sup>/s), or (AmerGen 2004; 2005; 2006e).

29 Of the five onsite wells, two (the Operations Support Facility/North Office Building [OSF] well  
30 and the Building 48 [48S] well) supply the plant's public water system. The 48S well is installed  
31 at a depth of 996 ft (303 m) and produces a maximum of 30 gpm (0.07 cfs, or 0.002 m<sup>3</sup>/s). The  
32 OSF well, at 775 ft (236 m), can yield a maximum of 40 gpm (0.09 cfs, or 0.003 m<sup>3</sup>/s) and can  
33 be used, if necessary, to supplement the water production of the three industrial makeup water  
34 wells (A, B, and C). These three service water wells are installed at 400 ft (122 m), 500 ft (152  
35 m), and 400 ft (122 m), respectively. Their water is utilized for the fire service, makeup to the  
36 demineralized water system, bearing lubrication in the screen house pumps, and various other  
37 building and equipment uses. Table 2-3 shows the annual ground water withdrawal data for the  
38 three industrial wells (both individually and combined) for the years 2003–2005.

1 **Table 2-3. Total Annual Ground Water Withdrawal (Gallons) and Average Daily**  
 2 **Withdrawal Rate (Gallons) for Industrial Wells, A, B, and C and Combined for**  
 3 **2003–2005**

Year	Well A		Well B		Well C		Total	
	Total	Avg. Daily	Total	Avg. Daily	Total	Avg. Daily	Total	Avg. Daily
	Withdrawn (x1000)	Withdrawal Rate	Withdrawn (x1000)	Withdrawal Rate	Withdrawn (x1000)	Withdrawal Rate	Withdrawn	Withdrawal Rate
2003	20,648	55,805	12,895	34,851	15,664	42,335	49,207,000	132,992
2004	20,434	54,930	11,696	31,441	10,859	29,191	42,989,000	115,562
2005	19,080	51,429	6,229	16,790	6,787	18,294	32,096,000	86,512

4 Source: AmerGen 2004, AmerGen 2005, AmerGen 2006a

5

6 The SRBC originally approved the use of ground water by the TMI-1 site in 1996. Before doing  
 7 so, two 48-hour pump tests were conducted at a rate of 168,750 gpd (638,788 Lpd), and no  
 8 adverse impacts were determined (SRBC 1999). When TMI-1 applied to the SRBC in 1998 for  
 9 an increase in ground water withdrawal from its three industrial wells (A, B, and C), the original  
 10 pump test data were considered in addition to observations of plant operations. After deciding  
 11 that there were no production impacts to any of the onsite wells (including OSF and 48S) or any  
 12 wells along the eastern shore of the island, SRBC approved the increase. Currently, all three  
 13 industrial wells may pump a maximum limit of 225,000 gpd (156 gpm, or 851,718 Lpd) on a 30-  
 14 day average (SRBC 1999).

15 *2.2.3.2 TMI-1 Monitoring Wells*

16 The Three Mile Island Nuclear Station began installing ground water monitoring wells in 1980 to  
 17 monitor for the ground water infiltration of radionuclides such as tritium. As tritium decays, it  
 18 emits a low-energy beta particle that cannot travel far into either tissue or air. It is produced from  
 19 man-made sources as well as natural processes. In 2006, the background concentration of  
 20 tritium in the onsite ground water was said to be (at most) 200 picoCuries per liter (pCi/L)  
 21 (Conestoga-Rovers 2006).

22 That same year, Exelon began a study to evaluate the possible impacts of plant operation on  
 23 nearby ground water and surface water, leading to the installation of 31 new onsite ground  
 24 water monitoring wells. The initiation of this Exelon project was considered Phase 1 of the  
 25 ground water monitoring effort at TMI-1, with Phase 2 being the continuation of the ground  
 26 water monitoring program that had been in place at the station for over 20 years. Samples were  
 27 collected from up to 76 well locations and the concentration of tritium was not found to exceed  
 28 the EPA drinking water standard of 20,000 pCi/L in any location, but was detected to be higher  
 29 than the background concentration during both studies. Samples taken from offsite drinking  
 30 water wells proved to have no detectable concentrations of tritium (AmerGen 2007).

31 As a result of these studies, AmerGen introduced the Radiological Ground Water Protection  
 32 Program (RGPP) in 2007. The purpose of this program is to ensure the detection and adequate  
 33 response to any possible radiological releases to ground water. The program includes 59 onsite  
 34 monitoring wells (5 of which are the water supply wells mentioned in Section 2.2.3.1), which are  
 35 sampled for tritium, strontium-90, and gamma-emitting radionuclides (Exelon 2007). Results  
 36 from these samples are compared to the results of the 2006 studies, which now serve as the

## Affected Environment

1 baseline monitoring round, to enable the use of trends, quickly identify contamination issues,  
2 and ensure that ground water quality is maintained.

3 In 2007 the RGPP successfully identified significantly elevated tritium levels in several  
4 monitoring wells from May–July, two of which were found to have exceeded the EPA standard  
5 of 20,000 pCi/L (peaking at 29,600 pCi/L in July). The facility was able to identify the problem  
6 and the source of the tritium leak, isolate the source, and then repair it. Once the problem was  
7 corrected, tritium levels returned to acceptable standards.

8 Conestoga-Rovers & Associates also calculated the rate and amount of tritiated ground water  
9 migrating to the Susquehanna River, and the results were confirmed again following the tritium  
10 leak incident (Conestoga-Rovers 2007). Table 2-4 below shows the rate of migration as  
11 affected by the pumping of onsite water supply wells, as well as with and without background  
12 levels. Conestoga-Rovers concluded that the migration of tritium to the Susquehanna River  
13 was negligible, and that the amount of tritium entering the river in ground water was “minimal”  
14 (Conestoga-Rovers 2006).

15 **Table 2-4. Rate of Tritiated Ground Water Migration to the Susquehanna River as**  
16 **Affected by Onsite Pumping and Background Levels of Tritium**  
17 **(Curies Per Year)**

	Total Mass Flux with Background (Ci/yr)	Background Contribution (Ci/yr)	Total Mass Flux without Background (Ci/yr)
No Pumping	0.32	0.09	0.23
Tritium Captured by Pumping	0.20	0.013	0.18
With Pumping	0.12	0.074	0.05

18 Source: Conestoga-Rovers 2006

19

### 20 2.2.4 Surface Water Resources

21 TMI-1 is located at approximately river mile 58 on the Susquehanna River, about 10 mi (16 km)  
22 south of the city of Harrisburg, PA, on the northern half of the 370-ac (150-ha) Three Mile Island  
23 (AmerGen 2008). Three Mile Island is almost 12,000 ft (3,700 m) long and up to 2200 ft (700  
24 m) wide. The Susquehanna River ranges in width from 7,000 ft–8,400 ft(2,100-2600 m) at  
25 Three Mile Island, but narrows to less than 1,800 ft (500 m) wide within 3,500 ft (1,100 m)  
26 downstream of Three Mile Island (AmerGen 2008). Three Mile Island is the longest in a group  
27 of islands that divides the river into three channels (west, center, and east), as illustrated in  
28 Figure 2-6. The intake and discharge structures for TMI-1 are located along the western shore  
29 of Three Mile Island, in the center river channel (Ichthyological Associates 1983). As described  
30 in detail in Section 2.1.6, the Susquehanna River provides makeup water for and receives  
31 blowdown from the two TMI-1 cooling towers (AmerGen 2008).

1 The Susquehanna River forms from two main branches, the North Branch Susquehanna River  
2 and the West Branch Susquehanna River. The source of the North Branch is Ostego Lake in  
3 Cooperstown, NY. The North Branch flows somewhat south in a meandering fashion through  
4 Sunbury, PA, where it joins with the shorter West Branch that begins in central-western  
5 Pennsylvania. The two branches combine to form the mainstem of the Susquehanna River,  
6 which is the largest tributary of the Chesapeake Bay. The Susquehanna River flows over 440 mi  
7 (708 km) from Ostego Lake to the Chesapeake Bay. Major tributaries of the Susquehanna River  
8 include the Juniata River, the West Branch Susquehanna River, and the Chemung River (SRBC  
9 2006).


10 The Susquehanna River Basin includes portions of the Allegheny Plateau region of the  
11 Appalachian Mountains of Pennsylvania and New York, the rolling hills and farmland closer to  
12 Three Mile Island situated in the Piedmont Plateau of Pennsylvania, and the coastal plain to the  
13 Chesapeake Bay in Maryland. It drains over 27,500 square miles ( $\text{mi}^2$ ) ( $71,200 \text{ km}^2$ ) of central  
14 Pennsylvania, south-central New York, and a small portion of northeastern Maryland, and is the  
15 second-largest watershed in the eastern United States (SRBC 1999; SRBC 2006).

16 The Susquehanna River Basin is divided into six major subbasins: (1) the Upper Susquehanna  
17 Subbasin, (2) the Chemung Subbasin, (3) the Middle Susquehanna Subbasin, (4) the West  
18 Branch Susquehanna Subbasin, (5) the Juniata Subbasin, and (6) the Lower Susquehanna  
19 Subbasin, which is the location of TMI-1 (SRBC 2006). The Lower Susquehanna Subbasin is  
20 located primarily south and downstream of the other five subbasins. This subbasin drains about  
21  $5,900 \text{ mi}^2$  ( $15,300 \text{ km}^2$ ) of urban and rural areas, ridges, and open valleys and empties into the  
22 Chesapeake Bay at Havre de Grace, MD. The ridges of this subbasin are primarily forested,  
23 and the valleys are predominantly used for agriculture. Other portions of this subbasin contain  
24 developed areas, with only limited abandoned mine lands. The cities of Harrisburg, Lancaster,  
25 and York are the largest populated areas in the Lower Susquehanna Subbasin (SRBC 2006a).

26 Susquehanna River flow is monitored by the United States Geological Survey (USGS) from a  
27 station located near Harrisburg, PA. The river supplies about 19 million gpm (42,000 cfs, or  
28  $1200 \text{ m}^3/\text{s}$ ) of freshwater to the Chesapeake Bay, which is about half of the Chesapeake Bay's  
29 flow of freshwater (SRBC 2006). Figure 2-7 shows that in 2004, a year with above-average  
30 flows, the daily mean flow of the Susquehanna River through Harrisburg was 56,400 cfs (25  
31 million gpm or  $1600 \text{ m}^3/\text{s}$ ), compared to the historic annual mean flow of 34,500 cfs (15 million  
32 gpm or  $1000 \text{ m}^3/\text{s}$ ). Daily mean flow in 2004 ranged from 9600 cfs (4 million gpm or  $300 \text{ m}^3/\text{s}$ )  
33 to 500,000 cfs (224 million gpm or  $14,000 \text{ m}^3/\text{s}$ ). The lowest average annual mean flow  
34 recorded at the Harrisburg gauging station is about 16,900 cfs (8 million gpm or  $500 \text{ m}^3/\text{s}$ ), with  
35 the lowest daily mean recorded as 1700 cfs (1 million gpm or  $50 \text{ m}^3/\text{s}$ ) (Durlin and Schaffstall  
36 2005).

Affected Environment

1 **Figure 2-7.** Monthly Mean Flow of the Susquehanna River in 2004 and the Maximum, Mean,  
2 and Minimum Monthly Mean Flow Date for 1891–2004



3  
4 Source: Durlin and Schaffstall 2005

5 The Susquehanna River is well known for the flooding damage it has caused in the past, with  
6 over 40 serious floods recorded since 1736 (Alliance for the Chesapeake Bay undated). To  
7 protect the site and possible contamination of the river during a serious flood event, the  
8 developed area of TMI-1 is bordered by a flood protection dike system (AmerGen 2008).

9 Three Mile Island is located within a reservoir portion of the river adjacent to two dams, the  
10 run-of-the-river York Haven Dam and the smaller Red Hill Dam, as illustrated in Figure 2-6. The  
11 reservoir formed behind the two dams that includes part of Three Mile Island is known as York  
12 Haven Pond and Lake Frederick (AmerGen 2008). At normal levels Lake Frederick has a  
13 surface area of 2.3 mi<sup>2</sup> (596 ha) and extends 3.5 mi (5.6 km) upstream. The normal full pool  
14 elevation of Lake Frederick is 277 ft (84 m) above mean sea level, and the mean depth is 9 ft  
15 (2.7 m) (Ichthyological Associates 1983). Both dams are owned and operated by York Haven  
16 Power Company. The York Haven Dam runs diagonally downstream and southwest from the  
17 southern end of Three Mile Island and is over 9,200 ft (2,800 m) long. The dam connects Three  
18 Mile Island to the mainland on the western side of the river, and is the site of a 19–20 MWe  
19 hydroelectric plant, which controls river flow at Three Mile Island (AmerGen 2008). The dam is  
20 located at the Conewago Falls, where the river drops 19 ft (6 m) (Kapsch 2004). The 900-foot-  
21 long (290-m-long) Red Hill Dam is located at the midway point of Three Mile Island along the  
22 eastern side of the island and regulates the flow of the Susquehanna River in the eastern  
23 channel. Between the dam and Three Mile Island is a fish ladder where fish passage can be  
24 monitored (AmerGen 2008).

25 The larger water bodies that flow into the Susquehanna River near Three Mile Island include the  
26 Swatara Creek, East Conewago Creek, West Conewago Creek, and Fishing Creek. East  
27 Conewago Creek discharges into the Susquehanna River from the eastern shoreline adjacent to  
28 the southern access bridge to Three Mile Island (PADEP 2008).

29 The Susquehanna River Basin Commission (SRBC) performs bioassessments of the  
30 Susquehanna River, the six subbasins, and a number of streams within each subbasin to  
31 monitor water quality and the biological health of the river basin. As part of the Susquehanna  
32 Large River Assessment Project, the SRBC collected biological and water chemistry data at 25  
33 stations in 2005 on the mainstem Susquehanna River and at the mouths of three tributaries.  
34 Nineteen of the stations were designated slightly impaired and six other stations were  
35 designated moderately impaired. However, less than 10 percent of the samples analyzed from  
36 the 25 stations exceeded levels of tolerance for aquatic life, indicating that the Susquehanna

1 River maintains fairly good water quality. Five of the twenty-five stations were located in the  
2 Lower Susquehanna Subbasin. Thirty-one of the forty-four samples obtained at these five  
3 stations in the Lower Susquehanna Subbasin were designated slightly impaired, and 12 of the  
4 samples were designated moderately impaired. Only one of the samples was rated non-  
5 impaired (SRBC 2006).

6 In a comparison of surveys conducted in the Lower Susquehanna Subbasin in 1996 and 2005,  
7 biological conditions improved slightly, while some parameters for water quality improved and  
8 others degraded. The SRBC has attributed high levels of nutrients, sediments, and toxins in  
9 some samples to the prevalence of agricultural lands in the Lower Susquehanna Subbasin,  
10 along with areas of residential, commercial, and industrial development, and to some areas in  
11 the subbasin containing abandoned mine lands. Data collected in 2005 during the Lower  
12 Susquehanna Subbasin Survey, near the confluence of the Swatara Creek with the  
13 Susquehanna River and 2 mi upstream of Three Mile Island, rated the habitat as partially  
14 supporting, with elevated nutrient levels, elevated sodium, and nonimpaired biological  
15 conditions. Further upstream on Swatara Creek, acid mine drainage and development affected  
16 the watershed (SRBC 2006a).

## 18 2.2.5 Description of Aquatic Resources

### 19 Macroinvertebrates

20 Sampling was performed for macroinvertebrates above and below the TMI-1 discharge pipes  
21 from 1974–1982 (Ichthyological Associates 1975; 1976; 1983) and from 1986–1990  
22 (Normandeau 2007; RMC 1991), with the most taxa (165) collected in 1982. Dominant taxa  
23 were aquatic tube worms (*Limnodrilus hoffmeisteri*), the larvae of Diptera–midges (*Chironomus*  
24 *decorus*), and mollusks (*Pisidium* spp.). Virginia river snail (*Elimia virginica*) and *L. hoffmeisteri*  
25 had the greatest biomass. Distributions varied seasonally, as did relative abundance, density,  
26 and biomass, particularly after the 1980 drought in this region (Ichthyological Associates 1983).  
27 Biological data collected in 1996 by the SRBC at Conewago Falls, immediately downstream of  
28 Three Mile Island, indicated that Ephemeroptera (mayflies) and Trichoptera (caddisflies) were  
29 two of the four dominant taxa in the samples. These families are typically found in water bodies  
30 of better water quality. Coleoptera (beetle larvae) were also dominant in the sample, with  
31 Amphipoda (shrimp-like crustaceans) the most dominant of the four taxa, indicating less than  
32 ideal water quality (SRBC 1996).

33 Macroinvertebrate samples collected by the SRBC 12 mi (19 km) downstream of Three Mile  
34 Island (river mile 45) and 20 mi (32 km) upstream of Three Mile Island (river mile 77) during the  
35 1996 Lower Susquehanna River Subbasin Survey contained *Corbicula fluminea*—invasive  
36 Asiatic clams. Macroinvertebrate samples collected on the Susquehanna River at the  
37 Conewago Falls boat launch (river mile 57) contained *Corbicula* as well as the native pea clam  
38 (*Pisidium* spp.) (SRBC 1996), characterized by its extremely small size (0.5 in.) (Pennsylvania  
39 Sea Grant 2008a). Several species of snails (Gastropoda) were also identified from the boat  
40 launch samples, including *Ferrissia* spp., *Lymnaea* spp., *Physa* spp., and *Viviparus* spp. (SRBC  
41 1996). No *Corbicula* or pea clams were collected at the sampling stations located at river mile  
42 45 and river mile 77 during the 2005 Lower Susquehanna Subbasin Survey, and the only snails  
43 that were collected were *Leptoxis* spp. and *Pleurocera* spp. (SRBC 2005).

## Affected Environment

1 The nonnative mollusk Asiatic clam (*C. fluminea*) is present in the Susquehanna River and has  
2 been observed attached to the intake structures at TMI-1. Corbicula is a small bivalve originally  
3 from eastern Asia and Africa that has spread into many estuarine habitats and river beds of the  
4 United States. The adults typically do not grow over 1.5 in. in size. Corbicula tolerates polluted  
5 environments better than native mussels, which allows it to colonize areas that would most likely  
6 not be inhabited by native mussels. Corbicula is inadvertently spread by boats transported from  
7 one waterway to another, and can cause biofouling of intake structures and irrigation systems  
8 (Pennsylvania Sea Grant 2008). At TMI-1, a biocide is applied to the intake water as it reaches  
9 the screens to prevent any infestations by Corbicula (AmerGen 2008).

10 Another common, nonnative invasive mollusk, the zebra mussel (*Dreissena polymorpha*), has  
11 not been observed in the Susquehanna River near Three Mile Island. The zebra mussel,  
12 originally from Europe, has spread through many States east of the Mississippi River, and was  
13 discovered on May 17, 2007, in Cowanesque Lake near the New York State line (Pennsylvania  
14 Sea Grant 2008b). This was the first time that the zebra mussel has been observed in a  
15 Pennsylvania waterway in the Susquehanna watershed (Alliance for the Chesapeake Bay  
16 2007). In June 2007, zebra mussels were identified in the Susquehanna River mainstem in  
17 Oneonta, NY (Harman and Underwood 2008). While conducting the Upper Susquehanna  
18 Subbasin Survey in 2007, the SRBC discovered zebra mussels in the Susquehanna River  
19 around Great Bend, PA, which is the furthest point downstream in the Susquehanna River  
20 mainstem that zebra mussels have been identified (SRBC 2008; Pennsylvania Sea Grant  
21 2008b).

### 22 Plankton

23 Phytoplankton and zooplankton were studied in 1974 and 1975 at the intake and discharge  
24 structures at TMI-1. A total of 95 genera of phytoplankton were identified in 1975, with the  
25 division Chlorophyta (green algae) the most common, followed by the division Bacillariophyta  
26 (diatoms). Also identified were genera from the division Cyanophyta (blue-green algae),  
27 Pyrophyta (dinoflagellates), Euglenophyta (euglenoids), and Chrysophyta (yellow-green algae). A  
28 total of 85 taxa of zooplankton were identified in 1974 and 1975 at the TMI-1 intake and  
29 discharge structures. Cladocerans, rotifers, and copepods were the most abundant, and  
30 comprised 98.9 percent of the number of zooplankton that were identified (Ichthyological  
31 Associates 1975; 1976).

### 32 Fish

33 Several fish studies have been conducted by the facility in the vicinity of Three Mile Island from  
34 1974–1982 using various sampling methods (trapnet, seine, and electrofishing), with a total of  
35 58 different species captured. Flathead catfish (*Pylodictis olivaris*), channel catfish (*Ictalurus*  
36 *punctatus*), pumpkinseed (*Lepomis gibbosus*), smallmouth bass (*Micropterus dolomieu*), black  
37 crappie (*Pomoxis nigromaculatus*), and white crappie (*Pomoxis annularis*) dominated the  
38 catches, and the common carp (*Cyprinus carpio*) contained the greatest biomass in the catch  
39 (Ichthyological Associates 1983). A 1990 study that sampled fish in Lake Frederick found the  
40 most common fish collected, in descending order, were the mimic shiner (*Notropis volucellus*),  
41 the spotfin shiner (*Cyprinella spiloptera*), channel catfish, smallmouth bass, the tessellated  
42 darter (*Etheostoma olmstedii*), the spottail shiner (*Notropis hudsonius*), pumpkinseed, the white  
43 sucker (*Catostomus commersonii*), the bluntnose minnow (*Pimephales notatus*), and the



1 common carp (RMC 1991). Fish sampling conducted from 2002–2005 in the vicinity of the  
2 Brunner Island steam electric station, located about 4 mi downstream from Three Mile Island,  
3 has demonstrated species composition similar to the fish sampled in the vicinity of York Haven  
4 Dam. Creel surveys in the vicinity of Lake Frederick from 2007 when compared to the 1974–  
5 1982 study indicated that similar taxa of sportfish dominated the catch as well as walleye  
6 (*Sander vitreus*) and muskellunge (*Esox masquinongy*) (Normandeau 2007).

7 The American shad (*Alosa sapidissima*) is an anadromous fish that historically numbered in the  
8 millions along the entire Susquehanna River, but have substantially dropped in the last 100  
9 years. Before 1904, millions of American shad migrated up the Susquehanna River for  
10 spawning, and over 2.5 million lb (1.1 million kg) of shad were commercially harvested during  
11 the peak of this fishery in 1885 (PFBC undated). Between 1904 and 1930, four hydroelectric  
12 dams were constructed along the lower Susquehanna River between Three Mile Island and  
13 close to the mouth of the Susquehanna River in Maryland, resulting in a loss of river access for  
14 shad above each dam: York Haven Dam (1904); Holtwood Dam (1910), Conowingo Dam  
15 (1928); and Safe Harbor Dam (1930). Safe Harbor is approximately 26 mi (42 km) south of  
16 Three Mile Island, Holtwood is approximately 33 mi (53 km) south, and Conowingo is  
17 approximately 48 mi (77 km) south. Construction of the Conowingo Dam in Maryland near the  
18 mouth of the Chesapeake Bay resulted in the complete loss of accessibility to spawning habitat  
19 for American shad and other anadromous fishes on the Susquehanna River. It also led to the  
20 closure of the shad industry, since fish could no longer pass through this first dam on the  
21 Susquehanna River (The Native Fish Conservancy 2008).

22 A combination of fish passage restoration projects performed at the Red Hill Dam, Safe Harbor  
23 Dam, Holtwood Dam, and Conowingo Dam over the past several decades has returned  
24 migratory access to American shad and other migratory fishes of the Susquehanna River. The  
25 construction of fish lifts, fish ladders, low-flow fish passages, and the completion of a fish  
26 passage facility at the Red Hill dam in 2000 has potentially opened the Susquehanna River to  
27 American shad and other anadromous fishes as far upriver as Binghamton, NY. Fish passage  
28 facilities are also being constructed on the tributaries of the Susquehanna River and on smaller  
29 streams where impasses may exist. Millions of shad larvae, fry, and fingerlings are stocked  
30 annually within the Chesapeake Bay watershed, including the Susquehanna River and its  
31 tributaries, with over 455 million American shad stocked in the Chesapeake Bay watershed  
32 since 1986 (CBP 2008). Cooperative stocking efforts between New York, Pennsylvania, and  
33 Maryland are attempting to rebuild the population of American shad (Sadzinski and Jarzynski  
34 undated).

35 Since the opening of the fishway in 2000 at the Red Hill Dam, York Haven Power Company has  
36 monitored this fishway for passage of American shad, gizzard shad (*Dorosoma cepedianum*),  
37 walleye, smallmouth bass, and other species. The numbers of American shad, gizzard shad,  
38 walleye, and smallmouth bass passing the Red Hill Dam fishway have fluctuated since 2000  
39 (York Haven Power Company 2008). American shad passage at all four dams has continued to  
40 decline since 2006, as shown in Table 2-5 below (PFBC 2008a). A number of factors can be  
41 causing the decrease in American shad numbers in the Susquehanna River, such as coast-wide  
42 declines in shad populations, low hatchery outputs, low wild juvenile survival, and fish passage  
43 effectiveness (PFBC 2008d). While predation on newly stocked American shad larvae may

Affected Environment

1 reduce the number that survive to adulthood (Johnson and Dropkin 1992), mortality at  
 2 Susquehanna River stocking sites was less than 2 percent (PFBC 2008e).

3 **Table 2-5. American Shad Passage at the Conowingo, Holtwood, Safe Harbor, and**  
 4 **Red Hill Dams on the Susquehanna River**

Year	Conowingo <sup>(a)</sup>	Holtwood <sup>(b)</sup>	Safe Harbor <sup>(b)</sup>	Red Hill
2008	19,914	2,795	1,252	21
2007	25,464	10,338	7,215	192
2006	56,899	35,968	24,929	1,913
2005	68,853	34,189	24,425	1,772
2004	109,360	3,482	2,109	219
2003	125,135	25,254	16,646	2,536
2002	108,001	17,522	11,705	1,555
2001	193,574	109,976	89,816	16,200
2000	153,546	29,421	21,079	4,675
1999	69,712	34,702	34,150	--
1998	39,904	8,235	6,054	--
1997	90,971	28,063	20,828	--

5 (a) The Conowingo Dam fish lift was built in 1991, but did not pass fish until 1997.

6 (b) The Holtwood Dam and Safe Harbor Dam fish lifts came online in 1997.

7 Source: PFBC 20008a

8 Other fish besides American and gizzard shad, walleye, and smallmouth bass use the Red Hill  
 9 fish ladder. While monitoring for American shad passage during a 3-week period in 2008, data  
 10 collected by the York Haven Power Company indicated that the gizzard shad was the species  
 11 that most frequently passed up the ladder (15,930), followed by channel catfish (3,286),  
 12 quillback (*Carpoides cyprinus*) (2,045), walleye (905), carp (332), shorthead redhorse  
 13 (*Moxostoma macrolepidotum*), and smallmouth bass (150). Several other species were also  
 14 observed in lower numbers passing up the fish ladder (York Haven Power Company 2008).

15 The smallmouth bass is popular with recreational fishers on the Susquehanna River, but recent  
 16 events have caused a concern with fisheries managers regarding the health of smallmouth bass  
 17 and other fishes in the Susquehanna River. In the summers of 2005 and 2007, die-offs of mostly  
 18 young smallmouth bass occurred in the Susquehanna River, Juniata River, and the West  
 19 Branch Susquehanna River (PFBC 2008c). Mortality has been attributed to a bacterial infection  
 20 caused by *Flavobacterium columnaris*, which results in large, visible lesions on infected fish.  
 21 Greater than 50 percent of the young-of-the-year sampled in 2005 and 2007 in a study  
 22 conducted by the Pennsylvania Fish and Boat Commission (PFBC) had visible external lesions.  
 23 Scientists from the USGS suspect that stress from low rainfall and correspondingly low flows  
 24 and low dissolved oxygen levels with high temperatures played a key role in making these fish

1 susceptible to colonization by *F. columnaris* (USGS 2008). Research was conducted in 2008 by  
2 the USGS and PFBC to determine the cause of these outbreaks (USGS 2008).

3 The Susquehanna River in the vicinity of Three Mile Island is used for recreational fishing for a  
4 variety of species, such as the smallmouth bass, flathead catfish, channel catfish, and walleye  
5 (McNally 2008; PFBC 2008). To enhance recreational fishing, the PFBC annually stocks several  
6 species of fish on the Susquehanna River, typically above Lake Frederick. From 1991–2008,  
7 species stocked by the PFBC on the Susquehanna River within the Lower Susquehanna  
8 Subbasin included muskellunge and tiger muskellunge (*E. lucius* x *E. masquinongy*), walleye,  
9 striped bass (*Morone saxatilis*), Hickory shad (*Alosa mediocris*), and American shad. The  
10 stocking of striped bass on the Susquehanna River was discontinued in 2006 (PFBC 2008f).

11 The cold-water tributaries of the Susquehanna River are home to several species of trout. A  
12 number of streams in the vicinity of Three Mile Island and Harrisburg are stocked with trout for  
13 recreational fishing and to enhance the naturally reproducing populations. Several streams near  
14 Three Mile Island—such as the headwaters of a tributary of Swatara Creek, located less than 2  
15 mi upriver of Three Mile Island—also contain naturally reproducing trout populations. The  
16 Yellow Breeches, located along the west shoreline of the Susquehanna River and opposite  
17 Three Mile Island, also contains a naturally reproducing population of trout, (PFBC 2008b). No  
18 essential fish habitat has been designated for any species along the Susquehanna River  
19 upstream of Conowingo Dam (NOAA undated).

20 The EPA has outlined a nationwide program for the analysis of fish to establish fish  
21 consumption advisories. This program includes a listing of parameters for tissue analysis  
22 including PCBs, pesticides, and heavy metals. To comply with this program, Pennsylvania has  
23 conducted fish tissue contaminant monitoring throughout the Commonwealth since 1976. Public  
24 health advisories, based on fish tissue contaminant levels, are published annually in the PFBC  
25 annual summary of fishing regulations and laws. Since 2002, Pennsylvania has issued a  
26 general Statewide advisory recommending that people consume no more than one meal per  
27 week of recreationally caught sport fish. The Commonwealth issues more restrictive advisories  
28 for specific water bodies.

29 For the reach of the Susquehanna River within the vicinity of the TMI-1 facility and the nearest  
30 major water bodies—including Swatara Creek, East Conewago Creek, West Conewago Creek,  
31 and Fishing Creek—Pennsylvania issued a health advisory to limit the consumption of  
32 smallmouth bass to no more than two meals per month due to mercury contamination (PFBC  
33 2008g).  
34

### 35 **2.2.6 Terrestrial Resources**

36 The TMI-1 site and its associated transmission lines are located within the Lower Susquehanna  
37 River Subbasin and span Lancaster, York, and Dauphin Counties. Before construction, the  
38 entire TMI-1 site was within the 10-year floodplain; however, today, only the southern,  
39 undisturbed portion of the island remains in the 10-year floodplain. The TMI-1 site is  
40 approximately 370 ac (150 ha) and includes both the TMI-1 and TMI Unit 2 facilities. The  
41 buildings associated with plant generation and maintenance, parking lots, and onsite roads  
42 occupy 200 ac (81 ha) of the overall site (AmerGen 2008). The remaining 170 ac (69 ha) are  
43 covered by fields, forested land, and wetlands with several intermittent ponds. Natural areas

Affected Environment



1 within the TMI-1 site and associated transmission line ROWs include upland; riparian; river  
2 floodplain forest communities; open fields; grasslands; and ponds, streams, and wetlands,  
3 whose primary water source is the Susquehanna River. Figure 2-8 is a map of Three Mile  
4 Island, the TMI-1 site, its associated transmission lines, and the surrounding area.  
5 Preconstruction habitat at the TMI-1 site consisted of open field habitats with upland and  
6 riparian forests as well as wetlands, while the transmission line ROWs consisted mostly of  
7 forested and agricultural land. After the construction of the plant facilities at the TMI-1 and TMI  
8 Unit 2 sites, much of the island became disturbed land. Continual maintenance of the  
9 transmission lines retains previously forested ROW land in an early successional state.

10 Upland areas at the TMI-1 site primarily support Virginia pine (*Pinus virginiana*), sweet birch  
11 (*Betula lenta*), flowering dogwood (*Cornus florida*), white oak (*Quercus alba*), northern red oak  
12 (*Quercus rubra*), black oak (*Quercus velutina*), and tuliptree (*Liriodendron tulipifera*). Common  
13 nonwoody species include fan-shaped clubmoss (*Lycopodium flabelliforme*), intermediate  
14 woodfern (*Dryopteris intermedia*), ground ivy (*Glechoma hederacea*), white avens (*Geum*  
15 *canadense*), common cinquefoil (*Potentilla simplex*), common blue violet (*Viola papilionacea*),  
16 and Swan's sedge (*Carex swanii*) (WHC 2005).

17 Forested riparian areas at the TMI-1 site support a mix of maples (*Acer* spp.), alders (*Alnus*  
18 spp.), birches (*Betula* spp.), and sycamores (*Platanus occidentalis*) (AmerGen 2008). Common  
19 tree species found in the river floodplain forests in and around the TMI-1 site are silver maple  
20 (*A. saccharinum*), river birch (*B. nigra*), and northern red oak (*Quercus rubra*). Nonwoody  
21 species found in river floodplain forests include ostrich fern (*Matteuccia struthiopteris*),  
22 mayapple (*Podophyllum peltatum*), dame's rocket (*Hesperis matronalis*), false mermaid  
23 (*Floerkea proserpinacoides*), Dutchman's breeches (*Dicentra cucullaria*), jumpseed (*Polygonum*  
24 *virginianum*), common blue violet (*Viola papilionacea*), and dogtooth violet (*Erythronium*  
25 *americanum*) (WHC 2005).

26 Open fields and grassland make up the predominant habitat on the southern end of Three Mile  
27 Island. Foxtail grasses (*Alopecurus* spp.) are the dominant genus; other grasses and sedges  
28 common to the TMI-1 site include Allegheny blackberry (*Rubus allegheniensis*), northern  
29 dewberry (*Rubus flagellaris*), white heath aster (*Symphotrichum ericoides*), white panicle aster  
30 (*Symphotrichum lanceolatum*), wrinkleleaf goldenrod (*Solidago rugosa*), common sheep sorrel  
31 (*Rumex acetosella*), common cinquefoil (*Potentilla simplex*), yellowfruit sedge (*Carex*  
32 *annectens*), creeping bentgrass (*Agrostis stolonifera*), little bluestem (*Andropogon scoparius*),  
33 poverty oatgrass (*Danthonia spicata*), and common timothy (*Phleum pratense*) (WHC 2005).  
34 Sycamores, sweetgum (*Liquidambar styraciflua*), basswood (*Tilia* spp.), and locust trees are  
35 found near the edges of the grasslands (AmerGen 2008).

36 The U.S. Fish and Wildlife Service (FWS) National Wetlands Inventory database indicates that  
37 wetlands, some of which are classified as significant habits, exist on the southern end of the  
38 TMI-1 site, as well as in the vicinity of the site along the Susquehanna River shoreline (FWS  
39 2008). Figure 2-4 shows the location of the wetlands in proximity to the TMI-1 site. The onsite  
40 wetlands were formed when borrow pits were created during the construction of a dike system  
41 that surrounds the entire island (AmerGen 2008). The former borrow pits now have standing  
42 water approximately 7 months of the year (AmerGen 2008). Dragonflies, amphibians, frogs, and  
43 salamanders are all common species in the wetland ecosystems on the TMI-1 site (WHC 2005).

## Affected Environment

1 Invasive plant species common to Pennsylvania floodplain forests include tree-of-heaven  
2 (*Ailanthus altissima*), Oriental bittersweet (*Celastrus orbiculatus*), and garlic mustard (*Alliaria*  
3 *officinalis*), which encroach upon woodland areas, while purple loosestrife (*Lythrum salicaria*),  
4 wild hops (*Humulus japonicus*), and Japanese knotweed (*Polygonum cuspidatum*) are known to  
5 colonize areas along the Susquehanna River (TNC 2005). AmerGen is not required to keep  
6 records of known invasive species and does not have programs or procedures in place to  
7 control terrestrial plant or animal invasive populations on the TMI-1 site.

8 A variety of wildlife exists on and in the vicinity of the TMI-1 site. Mammals common to the TMI-  
9 1 site include white-tailed deer (*Odocoileus virginianus*); raccoon (*Procyon lotor*); gray squirrel  
10 (*Sciurus carolinensis*); red fox (*Vulpes vulpes*); striped skunk (*Mephitis mephitis*); small  
11 insectivores, such as moles, shrews, and bats; and rodents, such as mice and voles (AmerGen  
12 2008). Reptiles and amphibians common to the TMI-1 site include snakes, turtles, lizards,  
13 salamanders, and toads.

14 The TMI-1 site provides habitat to a variety of songbirds, upland game birds, waterfowl, and  
15 raptors. AmerGen maintains onsite nests for osprey (*Pandion haliaetus*), peregrine falcon (*Falco*  
16 *peregrinus*), and mallard duck (*Anas platyrhynchos*), as well as boxes for wood duck (*Aix*  
17 *sponsa*) (AmerGen 2008). Twenty existing wood duck boxes will be replaced with new boxes in  
18 the next three years (WHC 2005).

19 AmerGen has several procedures for protecting wildlife at TMI-1, including environmental  
20 review checklists and environmental evaluation forms. Environmental review checklists are  
21 completed by qualified biologists and ensure that all appropriate procedures are followed, where  
22 applicable, to minimize the effects of plant operation on wildlife. Environmental evaluations are  
23 filled out when an item on the environmental review checklist is documented as disturbed or  
24 potentially affected. The environmental evaluation forms require the qualified biologist to  
25 describe and assess the impact, document possible ways to reduce or avoid the impact, and  
26 provide any applicable mitigation options.

27

### 28 **2.2.7 Threatened and Endangered Species**

29 Table 2-6, beginning on page 2-41 lists threatened, endangered, or candidate species known to  
30 occur in Dauphin County, in which TMI-1 is located, or York and Lancaster Counties, through  
31 which transmission line ROWs associated with TMI-1 traverse.

#### 32 *2.2.7.1 Aquatic Species*

33 One Federally listed and State-listed endangered species, the dwarf wedgemussel  
34 (*Alasmodonta heterodon*), was recorded in Lancaster County, but not in the vicinity of TMI-1 or in  
35 the waterways along the transmission line corridors. The black bullhead (*Amerius melas*), a  
36 State-listed species, has been recorded in Dauphin County (PNHP 2008), but is not known to  
37 occur in the vicinity of TMI-1 or in the waterways along the transmission line corridors (AmerGen  
38 2008).

39 The FWS indicated by letter dated April 23, 2008, that no Federally listed or proposed  
40 threatened or endangered species are known to occur within the project impact area, so no  
41 biological assessment or further consultation under the Endangered Species Act is required with



1 the FWS (FWS 2008). PFBC indicated by letter dated June 7, 2008, that no adverse impacts to  
2 State-listed rare, candidate, threatened, or endangered aquatic species are expected from the  
3 proposed project (PFBC 2008h).

#### 4 2.2.7.2 Terrestrial Species

5 Two Federally listed threatened or endangered terrestrial species, the bog turtle (*Glyptemys*  
6 *muhlenbergii*) and the northeastern bulrush (*Scirpus ancistrochaetus*), are potentially found in  
7 the vicinity of the TMI-1 site (FWS 2008). The bald eagle (*Haliaeetus leucocephalus*) and the  
8 peregrine falcon were formerly listed as Federally threatened and may also be found in the  
9 vicinity of the TMI-1 site. Eleven State-listed species were identified as species for consideration  
10 of the proposed license renewal of TMI-1, including the (1) osprey, (2) prothonotary warbler  
11 (*Protonotaria citrea*), (3) yellow-crowned night heron (*Nycticorax violacea*), (4) black-crowned  
12 night heron (*Nycticorax nycticorax*), (5) aster-like boltonia (*Boltonia asteroides*), (6) Short's  
13 sedge (*Carex shortiana*), (7) flat-stemmed spike-rush (*Eleocharis compressa*), (8) ellisia (*Ellisia*  
14 *nyctelea*), (9) bronze copper (*Lycaena hyllus*), and the formerly Federally listed (10) bald eagle,  
15 and (11) peregrine falcon (DCNR 2008a; PGC 2008; AmerGen 2008; PNHP 2008). The  
16 American Holly (*Ilex opaca*), State-listed as endangered, has been documented as occurring on  
17 the TMI-1 site; however, neither the Pennsylvania Department of Conservation and Natural  
18 Resources (DCNR) nor the Pennsylvania Game Commission (PGC) have identified the species  
19 for consideration of the proposed license renewal of TMI-1 (AmerGen 2008; DCNR 2008a; PGC  
20 2008; PNHP 2008).

#### 21 Federally Protected and Formerly Protected Terrestrial Species

22 The northeastern bulrush and the bog turtle have ranges that include the TMI-1 project area, but  
23 neither species is known to occur on the TMI-1 site or along its associated transmission line  
24 ROWs (AmerGen 2008). Additionally, neither species was identified in the April 23, 2008, letter  
25 from FWS as species requiring consideration for this proposed action (FWS 2008).

26 On July 9, 2007, the FWS issued a *Federal Register* notice announcing the delisting of the bald  
27 eagle from the Federal List of Endangered and Threatened Wildlife (72 FR 37346). Eagles  
28 continue to be protected at the national level by the Bald and Golden Eagle Protection Act, as  
29 well as the Migratory Bird Treaty Act, and at the State level as a Pennsylvania-listed threatened  
30 species. The bald eagle is a large bird, even among raptor species, and can reach a weight of  
31 more than 13 lb (6 kg). The eagle has a white head and tail, with brown body feathers. Bald  
32 eagles eat fish, small mammals, birds, and occasionally carrion. Bald eagles are known to occur  
33 in Dauphin, Lancaster, and York Counties, and are seen regularly along the Susquehanna  
34 River. The eagle is occasionally seen on Three Mile Island; however, the closest known nest is  
35 20 mi (32 km) south of TMI-1, near the Holtwood Dam (AmerGen 2008).

36 The peregrine falcon was removed from Federal listing in August 1999, but continues to be  
37 listed as endangered at the State level. Adult birds have a bluish-black head and wings, are 14–  
38 19-in. (36–48 cm) tall, and have a 39–43-in (99-109 cm) wingspan (Cornell 2003). Peregrine  
39 falcons nest on high cliffs near river systems and on bridges and tall buildings (PGC 2006). The  
40 species was not observed nesting in Pennsylvania from 1959 to 1987, coinciding with the  
41 population depletion between 1950 and 1970 caused by the species' sensitivity to DDT (Cornell  
42 2003). Reintroduction efforts in Pennsylvania and neighboring states have facilitated the growth  
43 of the population since the early 1990s (PGC 2006). A breeding pair has nested on the TMI-1

## Affected Environment

1 reactor building every year since 2002 (AmerGen 2008). In an effort to protect the nesting pair  
2 and their young, AmerGen regularly communicates with FWS, DCNR, and PADEP (AmerGen  
3 2008).

### 4 State Protected Terrestrial Species

5 The Pennsylvania State-listed threatened osprey occurs on the Susquehanna River shoreline  
6 throughout the project area, and osprey nests are known to occur on the TMI-1 site (AmerGen  
7 2008). The osprey is a fairly large bird of prey with a body length of about 21–24 in. (53–61 cm)  
8 and a wingspan of 4.5–5.5 ft (1.4–1.7 m). Osprey feed exclusively on live fish (FWS 2008a).  
9 Individuals are brown with a white belly and have distinctive patches on their wings. The osprey  
10 has long, sharp talons, which are used for gripping fish. Females are larger than males, which  
11 is true for most birds of prey. The osprey's habitat includes rivers, lakes, and shallow water  
12 estuaries. Since 2004, ospreys have nested on the TMI-1 meteorological tower, located on the  
13 north end of Three Mile Island (AmerGen 2008). AmerGen built a 55-ft (17-m) nesting platform  
14 in an attempt to relocate the nesting pair to a location more secluded from human activity, but  
15 relocation efforts have been unsuccessful (AmerGen 2008).

16 The Pennsylvania State-listed endangered aster-like boltonia, also a Pennsylvania species of  
17 special concern, grows on rocky shores and exposed, rocky river beds (DCNR 2008a). The  
18 boltonia is a tall, slender plant with stalks commonly growing to heights of 4–6 ft (1.2–1.8 m).  
19 The plant has white flowers with a yellow center, which appear between July and October (Fike  
20 2008). The closest location of the boltonia to the TMI-1 site is the riverside outcrop community  
21 (Fike 1999).

22 Short's sedge, a species of special concern in Pennsylvania, occurs near wetlands along the  
23 Susquehanna River (PNHP 2008). Short's sedge is a grass-like plant, ranging in height from 8–  
24 35 in. (20–89 cm) (PNHP 2008b). The stems are light green, three-sided, and have no hairs  
25 (PNHP 2008b). Flowers, which grow on the top of each stem, are densely packed, brown  
26 cylindrical spikes and look like very small pinecones (PNHP 2008b). Short's sedge is known to  
27 occur near TMI-1 and its associated transmission line ROWs (PNHP 2008b; DCNR 2008a).

28 The flat-stemmed spike-rush, a grass-like plant in the sedge family, is listed as endangered in  
29 the Commonwealth of Pennsylvania (DCNR 2008a). DCNR also identifies the plant as a  
30 species of special concern (DCNR 2008a). The medium-to-dark green species grows 0.5–1.5 ft  
31 (15– 46 cm) in height and has a uniform diameter of 0.04 in. (1 mm) (Hilty 2006b). Generally  
32 one long, oval-shaped flower can be found per stalk. Flowers range in color from light-to-  
33 medium brown with small white spikes (Hilty 2006b).

34 The Pennsylvania-threatened ellisia is also a species of special concern for TMI-1 and the  
35 associated transmission line ROWs (DCNR 2008a). The 4–16-in. (10–41 cm) wildflower has  
36 pale green to pale purple stems and dark green, hairy leaves (Hilty 2006a). Individual flowers  
37 appear in May, span 0.25 in. (6.4 mm) in diameter, and have five small white petals surrounding  
38 a pale blue center (DCNR 2008a; Hilty 2006a). Ellisia is known to occur in the area of TMI-1 and  
39 its associated transmission line ROWs, and is generally found in damp, shady areas near  
40 stream banks with rich soils (DCNR 2008a; PNHP 2008a).

41 The bronze copper, a Pennsylvania species of special concern, is a butterfly that lives in wet  
42 meadows and marshes (DCNR 2008a). The DCNR does not currently rank the species as



1 endangered, threatened, or rare because of a lack of or conflicting information about population  
 2 trends (DCNR 2008a). The male is brown and the female is yellow-orange with black spots. In  
 3 both sexes, the underside is orange with black spots. The bronze copper likes to perch on low,  
 4 nontree plants ranging less than 3–4 ft (1–1.2 m) in size. When in its caterpillar phase, the  
 5 species eats green leaves from plants.

6 The prothonotary warbler, a Pennsylvania species of special concern, is known to nest and  
 7 forage in proximity to the TMI-1 site, according to PGC (PGC 2008); however, the species is not  
 8 identified by the FWS or DCNR as rare, threatened, or endangered for the TMI-1 site. The  
 9 warbler is a very colorful bird, with a bright yellow-golden head and underside, olive body, blue-  
 10 gray wings and tail, and white underwings. Prothonotary warblers live and breed in wooded  
 11 swamps, bottomland, flooded forests, and alongside slow-moving rivers. The warbler feeds  
 12 primarily on caterpillars, insects, fruit, and seeds (Audubon 2008). AmerGen has no known  
 13 monitoring programs for the prothonotary warbler.

14 The Pennsylvania-endangered yellow-crowned night heron lives in proximity to the TMI-1 site  
 15 (PGC 2008). Adult herons are approximately 2 ft (61 cm) tall with a long, slender appearance,  
 16 have a 3–4-ft (1.0–1.2 m) wingspan, and are blue to gray in color. The species feeds mostly on  
 17 fish. AmerGen has no known monitoring programs in place for the yellow-crowned night herons,  
 18 therefore their population numbers within the vicinity of TMI-1 are unknown.

19 The black-crowned night heron, listed in Pennsylvania as endangered, is a medium-sized heron  
 20 with a stocky body and short legs and neck (PNHP 2008). The heron has a black crown; a black  
 21 and white face, chest, and belly; and blue-gray wings. It feeds primarily on aquatic  
 22 invertebrates, fish, and frogs. The PGC identifies the species as one of special concern  
 23 because it nests near the TMI-1 site (PGC 2008). AmerGen has no known monitoring programs  
 24 in place for the black-crowned night heron; therefore, their population within the vicinity of TMI-1  
 25 is unknown.

26 **Table 2-6. Listed Aquatic and Terrestrial Species.** *The species listed are Federally-*  
 27 *listed, Pennsylvania-listed, or both that are threatened, endangered, or*  
 28 *candidate species. These species may occur on the TMI-1 site, within the*  
 29 *Susquehanna River, or within the transmission line corridors.*

Scientific Name	Common Name	Federal Status <sup>(a)</sup>	State Status <sup>(b)</sup>	Habitat
<b>Fish</b>				
<i>Ameiurus melas</i>	black bullhead		PE	Quiet backwaters
<b>Reptiles and Amphibians</b>				
<i>Glyptemys muhlenbergii</i>	bog turtle	T	PE	Wetlands, bogs, fens, meadows, and wet grassy areas
<i>Opheodrys aestivus</i>	rough green snake		PE	Hilly, forested, dry areas

## Affected Environment

Scientific Name	Common Name	Federal Status <sup>(a)</sup>	State Status <sup>(b)</sup>	Habitat
<i>Pseudemys rubriventris</i>	redbelly turtle	SC	PT	Aquatic species found in lakes, rivers, ponds, and marshes
<b>Insects</b>				
<i>Lycaena hyllus</i>	bronze copper		SC	Low wet meadows and marshes, especially in river flood plains (DCNR 2008a)
<b>Birds</b>				
<i>Bartramia longicauda</i>	upland sandpiper		PT	Bogs, fens, grasslands, and pastures
<i>Botaurus lentiginosus</i>	American bittern		PE	Freshwater wetlands and shorelines
<i>Casmerodius albus</i>	great egret		PE	Aquatic and wetland habitats
<i>Cistothorus platensis</i>	sedge wren		PE	Wet meadows, freshwater marshes, and bogs
<i>Falco peregrinus</i>	peregrine falcon	E	PE	Cliffs, usually near riverine areas
<i>Haliaeetus leucocephalus</i>	bald eagle		PT	Forests near water bodies
<i>Nyctanassa violacea</i>	yellow-crowned night-heron		PE	Freshwater and saltwater marshes, wooded swamps, and shore areas
<i>Nycticorax nycticorax</i>	black-crowned night-heron		PE	Fresh and saltwater marshes, swamps, lakes, and wooded streams
<i>Pandion haliaetus</i>	osprey		PT	Close proximity to watery areas such as lakes, bogs, rivers, bay areas, and oceans
<i>Rallus elegans</i>	king rail		PE	Freshwater and brackish marshes
<b>Mammals</b>				
<i>Cryptotis parva</i>	least shrew		PE	Grasses, brushes, and weedy fields

Scientific Name	Common Name	Federal Status <sup>(a)</sup>	State Status <sup>(b)</sup>	Habitat
<i>Neotoma magister</i>	Allegheny woodrat		PT	Rocky, forested areas
<b>Plants</b>				
<i>Agalinis auriculata</i>	eared false-foxglove		PE	Prairies, dry woods, and open fields
<i>Ammannia coccinea</i>	scarlet ammannia		PE	Moist, sandy shorelines
<i>Arethusa bulbosa</i>	swamp-pink		PE	Wetland areas
<i>Aristida purpurascens</i>	arrow-feathered three awned		PT	Moist areas, swamps, shores, and wetlands
<i>Arnica acaulis</i>	Leopard's-bane		PE	Wooded areas
<i>Asplenium bradleyi</i>	Bradley's spleenwort		PT	Exposed, barren areas; cliffs; and rocks
<i>Boltonia asteroides</i>	aster-like boltonia		PE,SC	Rocky shores and exposed rocky river beds (DCNR 2008a)
<i>Bouteloua curtipendula</i>	tall gramma		PT	Grasslands and barren areas
<i>Carex aquatilis</i>	water sedge		PT	Wetlands, ponds, marshes, and areas with standing water
<i>Carex bullata</i>	bull sedge		PE	Wetlands, ponds, marshes, and areas with standing water
<i>Carex diandra</i>	lesser panicled sedge		PT	Wetlands, ponds, marshes, and areas with standing water
<i>Carex polymorpha</i>	variable sedge		PE	Wetlands, ponds, marshes, and areas with standing water
<i>Carex prairea</i>	prairie sedge		PT	Wetlands, ponds, marshes, and areas with standing water
<i>Carex shortiana</i>	sedge		SC	Wet meadows, swamps, and wooded areas (DCNR 2008a)
<i>Carex sterilis</i>	sterile sedge		PT	Wetlands, ponds, marshes, and areas with

Affected Environment

Scientific Name	Common Name	Federal Status <sup>(a)</sup>	State Status <sup>(b)</sup>	Habitat
				standing water
<i>Carex tetanica</i>	sedge		PT	Wetlands, ponds, marshes, and areas with standing water
<i>Carex typhina</i>	cattail sedge		PE	Wetlands, ponds, marshes, and areas with standing water
<i>Chrysopsis mariana</i>	Maryland golden-aster		PT	Well-drained, open woods
<i>Cirsium horridulum</i>	horrible thistle		PE	Shores, marshes, or sandy fields
<i>Cladium mariscoides</i>	twig rush		PE	Wetlands, bogs, and freshwater shorelines
<i>Clitoria mariana</i>	butterfly-pea		PE	Dry, open areas on sandy soil
<i>Cynanchum laeve</i>	smooth swallow-wort		PE	Open areas or areas with slight ground cover
<i>Cyperus diandrus</i>	umbrella flatsedge		PE	Wetlands and wet meadows
<i>Cyperus refractus</i>	reflexed flatsedge		PE	Open dry fields, clearings, open forests, and sandy soils
<i>Cyperus retrorsus</i>	retorse flatsedge		PE	Open dry fields, clearings, open forests, and sandy soils
<i>Cypripedium reginae</i>	showy lady's-slipper		PT	Bogs, swamps, wet meadows, and damp forests
<i>Dodecatheon radicum</i>	jeweled shooting-star		PT	Moist, shaded areas and river bluffs
<i>Eleocharis compressa</i>	flat-stemmed spike-rush		PE,SC	River banks with sandy soils and usually wet areas (DCNR 2008a)
<i>Eleocharis intermedia</i>	matted spike-rush		PT	Marshes, wetlands, and muddy areas
<i>Elephantopus carolinianus</i>	elephant's foot		PE	Dry, open woods

Affected Environment

Scientific Name	Common Name	Federal Status <sup>(a)</sup>	State Status <sup>(b)</sup>	Habitat
<i>Ellisia nyctelea</i>	ellisia		PT,SC	River banks and alluvial woods (DCNR 2008a).
<i>Epilobium strictum</i>	downy willow-herb		PE	Bogs, swamps, and wetlands
<i>Erigeron bulbosa</i>	harbinger-of-spring		PT	Wet, wooded areas
<i>Euphorbia purpurea</i>	glade spurge		PE	Cool, moist woods, swamps, and alongside streambanks
<i>Festuca paradoxa</i>	cluster fescue		PE	Wet, wooded areas and wet meadows
<i>Fimbristylis annua</i>	annual fimbry		PT	Swampy, damp grasslands, and wetlands
<i>Gaylussacia dumosa</i>	dwarf huckleberry		PE	Open areas in forest habitats
<i>Gymnopogon ambiguus</i>	broad-leaved beardgrass		PE	Glades, prairies, and open fields
<i>Helianthemum bicknellii</i>	Bicknell's hoary rockrose		PE	Woodlands, prairies, and open rocky areas
<i>Hypericum densiflorum</i>	bushy St. John's-wort		PT	Stream banks, pond and lake edges, and wet meadows
<i>Ilex opaca</i>	American holly		PT	Moist, sandy woodlands
<i>Iris cristata</i>	crested dwarf iris		PE	Wooded areas and ravines
<i>Iris prismatica</i>	slender blue iris		PE	Saltwater and freshwater marshes, shores, and wet meadows
<i>Iris verna</i>	dwarf iris		PE	Grassy areas and shaded woody areas
<i>Juncus arcticus var. littoralis</i>	baltic rush		PT	Wetland areas, wet meadows, and wet grassy areas
<i>Juncus brachycephalus</i>	small-headed rush		PT	Wetland areas, wet meadows, and wet grassy areas
<i>Juncus dichotomus</i>	forked rush		PE	Wetland areas, wet meadows, and wet grassy

Affected Environment

Scientific Name	Common Name	Federal Status <sup>(a)</sup>	State Status <sup>(b)</sup>	Habitat
				areas
<i>Juncus scirpoides</i>	scirpus-like rush		PE	Wetland areas, wet meadows, and wet grassy areas
<i>Linum intercursum</i>	sandplain wild flax		PE	Dry, open grasslands
<i>Linum sulcatum</i>	grooved yellow flax		PE	Glades, prairies, and open fields
<i>Lipocarpa micrantha</i>	common hemicarpa		PE	Pond and stream edges and wetlands
<i>Lobelia kalmii</i>	brook lobelia		PE	Pond and stream edges, wetlands, and wet areas
<i>Lobelia puberula</i>	downy lobelia		PE	Wet, wooded areas, and wetlands
<i>Ludwigia decurrens</i>	upright primrose-willow		PE	Swampy, damp grasslands, and wetlands
<i>Ludwigia polycarpa</i>	false loosestrife seedbox		PE	Swamps, marshes, wet meadows, and wetlands
<i>Lycopodiella appressa</i>	southern bog clubmoss		PT	Bogs, wetlands, and sandy banks
<i>Lyonia mariana</i>	stagger-bush		PE	Moist, sandy, and wooded areas
<i>Magnolia tripetala</i>	umbrella magnolia		PT	Wooded areas and forests
<i>Magnolia virginiana</i>	sweet bay magnolia		PT	Wooded areas and forests
<i>Matelea obliqua</i>	oblique milkvine		PE	Open wooded areas, rocky slopes, and wooded edges
<i>Melica nitens</i>	three-flowered melic-grass		PT	Dry, rocky woods, and open areas along edges
<i>Myriophyllum sibiricum</i>	northern water-milfoil		PE	Lakes, ponds, and streams
<i>Panicum scoparium</i>	velvety panic-grass		PE	Prairies, glades, roadsides, and fields
<i>Passiflora lutea</i>	passion-flower		PE	Rich woods, rocky areas, and slopes

Affected Environment

Scientific Name	Common Name	Federal Status <sup>(a)</sup>	State Status <sup>(b)</sup>	Habitat
<i>Phemeranthus teretifolius</i>	round-leaved fame-flower		PT	Wooded areas
<i>Phlox ovata</i>	mountain phlox		PE	Sunny fields and open areas
<i>Phyllanthus caroliniensis</i>	Carolina leaf-flower		PE	Open fields
<i>Poa paludigena</i>	bog bluegrass		PT	Wet woods, bogs, and sedge meadows
<i>Polygala cruciata</i>	cross-leaved milkwort		PE	Wet, sandy meadows and marshes
<i>Polygala incarnata</i>	pink milkwort		PE	Open fields and semi-open forests
<i>Polygonum setaceum</i> var. <i>interjectum</i>	swamp smartweed		PE	Sandy wetlands and moist fields
<i>Potamogeton hillii</i>	Hill's pondweed		PE	Ponds, lakes, streams, and mostly submerged areas
<i>Potamogeton obtusifolius</i>	blunt-leaved pondweed		PE	Ponds, lakes, streams, and mostly submerged areas
<i>Potamogeton richardsonii</i>	red-head pondweed		PT	Ponds, lakes, streams, and mostly submerged areas
<i>Pycnanthemum torrei</i>	Torrey's mountain-mint		PE	Fields and open woods
<i>Quercus shumardii</i>	Shumard's oak		PE	Forest habitats
<i>Ranunculus fascicularis</i>	tufted buttercup		PE	Dry woods, glades, prairies, and roadsides
<i>Rhexia mariana</i>	Maryland meadow-beauty		PE	Wet meadows, freshwater marshes, bogs, and wetlands
<i>Rhododendron atlanticum</i>	dwarf azalea		PE	Wooded areas
<i>Rhynchospora capillacea</i>	capillary beaked-rush		PE	Open wetlands
<i>Ruellia strepens</i>	limestone petunia		PT	Moist, open woods and wetlands, and streambanks

Affected Environment

Scientific Name	Common Name	Federal Status <sup>(a)</sup>	State Status <sup>(b)</sup>	Habitat
<i>Scheuchzeria palustris</i>	pod-grass		PE	Marshes and bogs
<i>Schoenoplectus smithii</i>	Smith's bulrush		PE	Wetlands, shores, mudflats, and beaches
<i>Scirpus ancistrochaetus</i>	northeastern bulrush	E	PE	Small wetlands
<i>Scleria pauciflora</i>	few flowered nutrush		PT	Moist, sandy soils, wetlands, wet meadows, and bogs
<i>Scleria verticillata</i>	whorled nutrush		PE	Marshes, bogs, wetlands, and wet meadows
<i>Sericocarpus linifolius</i>	narrow-leaved white-topped aster		PE	Dry fields and open woods
<i>Sida hermaphrodita</i>	sida		PE	Open areas, floodplains, and some wet areas
<i>Sisyrinchium atlanticum</i>	eastern blue-eyed grass		PE	Fields, open woods, meadows, and edges of salt marshes
<i>Solidago simplex ssp. randii var. racemosa</i>	sticky golden-rod		PE	Riverbanks, open areas, and water edges
<i>Solidago speciosa var. erecta</i>	slender golden-rod		PE	Dry, open fields, tall, grassy areas, and roadsides
<i>Sparganium androcladum</i>	branching bur-reed		PE	Swamps and shallows
<i>Spiranthes vernalis</i>	spring ladies'-tresses		PE	Wet or dry upland prairies, and roadsides
<i>Sporobolus clandestinus</i>	rough dropseed		PE	Prairies, glades, roadsides, fields, and rocky edges
<i>Sporobolus heterolepis</i>	prairie dropseed		PE	Open fields and prairies
<i>Symphotrichum depauperatum</i>	serpentine aster		PT	Dry fields and open woods
<i>Thalictrum coriaceum</i>	thick-leaved meadow-rue		PE	Rocky, open, wooded areas, and with moist soils
<i>Triphora trianthophora</i>	nodding pogonia		PE	Dense forests



Scientific Name	Common Name	Federal Status <sup>(a)</sup>	State Status <sup>(b)</sup>	Habitat
<i>Vernonia glauca</i>	tawny ironweed		PE	Meadows and upland forests
<i>Viburnum nudum</i>	possum-haw		PE	Moist woods, wetlands, and swamps
<i>Vittaria appalachiana</i>	Appalachian gametophyte fern		PT	Rock outcrop areas in fields and forests

- 1 (a) E = Federally endangered; T = Federally threatened
- 2 (b) PE = Pennsylvania endangered; ST = Pennsylvania threatened; SC = State species of concern

3 **2.2.8 Socioeconomic Factors**

4 This section describes current socioeconomic factors that have the potential to be directly or  
 5 indirectly affected by changes in TMI-1 operations. TMI-1 and the communities that support it  
 6 can be described as a dynamic socioeconomic system. The communities provide the people,  
 7 goods, and services required by TMI-1 operations. TMI-1 operations, in turn, create the demand  
 8 and pay for the people, goods, and services in the form of wages, salaries, and benefits for jobs  
 9 and dollar expenditures for goods and services. The measure of the communities' ability to  
 10 support the demands of TMI-1 depends on their ability to respond to changing environmental,  
 11 social, economic, and demographic conditions.

12 The socioeconomic region of influence (ROI) is defined by the areas where TMI-1 employees  
 13 and their families reside, spend their income, and use their benefits, thereby affecting the  
 14 economic conditions of the region. The TMI-1 ROI consists of a two-county area (Dauphin and  
 15 Lancaster Counties) where approximately 71 percent of TMI-1 employees reside. The following  
 16 sections describe the housing, public services, offsite land use, visual aesthetics and noise,  
 17 population demography, and the economy in the ROI surrounding TMI-1.

18 AmerGen employs a permanent workforce of approximately 525 employees (AmerGen 2008).  
 19 Approximately 97 percent live in Dauphin, Lancaster, Lebanon, York, Cumberland, Perry, and  
 20 Berks Counties, PA (Table 2-7). The remaining 3 percent of the workforce are divided among 12  
 21 counties in Pennsylvania, ranging from one to five employees per county. Given the residential  
 22 locations of TMI-1 employees, the most significant impacts of plant operations are likely to occur  
 23 in Dauphin and Lancaster Counties. The focus of the socioeconomic impact analysis in this draft  
 24 supplemental environmental impact statement (EIS) is therefore on the impacts of TMI-1 on  
 25 these two counties.

26

Affected Environment

1

**Table 2-7. TMI-1 Employee Residence by County**

<b>County</b>	<b>Number of Employees</b>	<b>Percentage of Total</b>
Dauphin, PA	196	37
Lancaster, PA	176	34
Lebanon, PA	57	11
York, PA	41	8
Cumberland, PA	26	5
Perry, PA	7	1
Berks, PA	6	1
Other	16	3
Total	525	100

Source: AmerGen 2008

2 Refueling outages at TMI-1 occur at 24-month intervals. During refueling outages, site  
3 employment increases by as many as 1,400 workers for approximately 20 to 30 days (AmerGen  
4 2008). Most of these workers are assumed to be located in the same geographic areas as the  
5 permanent TMI-1 staff.

6 *2.2.8.1 Housing*

7 Table 2-8 lists the total number of occupied and vacant housing units, vacancy rates, and  
8 median value in the two-county ROI. According to the 2000 census, there were over 291,000  
9 housing units in the socioeconomic region, of which approximately 275,000 were occupied. The  
10 median value of owner-occupied units ranged from \$99,900 in Dauphin County to \$119,300 in  
11 Lancaster County. The vacancy rate was lower in Lancaster County (4.1 percent) than Dauphin  
12 County (7.6 percent).

13 By 2006, the number of housing units in Dauphin County grew to an estimated total of 115,896  
14 units, an increase of more than 4,700 units, and the number of occupied units grew by more  
15 than 1,600 units to an estimated total of 104,336 units. As a result, the number of available  
16 vacant housing units in Dauphin County increased by more than 3,090 units to 11,560, or 10  
17 percent of the available units. In addition, the estimated number of vacant housing units also  
18 increased in Lancaster County (USCB 2008).

1 **Table 2-8. Housing in Dauphin and Lancaster Counties, Pennsylvania**

	Dauphin	Lancaster	Region
<b>2000</b>			
Total	111,133	179,990	291,123
Occupied housing units	102,670	172,560	275,230
Vacant units	8,463	7,430	15,893
Vacancy rate (percent)	7.6	4.1	5.5
Median value (dollars)	99,900	119,300	109,600
<b>2006*</b>			
Total	115,896	192,351	308,247
Occupied housing units	104,336	184,581	288,917
Vacant units	11,560	7,770	19,330
Vacancy rate (percent)	10.0	4.0	6.3
Median value (dollars)	136,200	171,900	154,050

\* Estimated

2 **2.2.8.2 Public Services**

3 This section presents a discussion of public services including water supply, education, and  
4 transportation.

5 **Water Supply**

6 Because TMI-1 is located in Londonderry Township (in Dauphin County) and most of the TMI-1  
7 employees reside in Dauphin and Lancaster Counties, the discussion of public water supply  
8 systems is limited to Dauphin and Lancaster Counties.

9 ***Dauphin County***

10 Dauphin County is currently served by fourteen public water systems. Public water systems  
11 serve approximately 240,000 persons with approximately 74,000 connections (Dauphin County  
12 2008). The largest populations served are those receiving water from United Water  
13 Pennsylvania (94,000 persons served), the Harrisburg Municipal Water Authority (66,500  
14 persons), and the Pennsylvania American Water Company-Hershey (42,000 persons) (PADEP  
15 2008). The sources for these public water systems are primarily surface water (i.e. various  
16 creeks, streams and a reservoir), while the majority of the smaller systems are dependent upon  
17 ground water sources (Dauphin County 2008). County planners state that there is currently  
18 ample water to meet demand. Table 2-9 lists the largest municipal water suppliers in Dauphin  
19 County.

Affected Environment

1 *Lancaster County*

2 Lancaster County has more than 30 major public water systems providing services for larger  
 3 communities in the county. Although these systems draw from groundwater and surface water  
 4 sources, they are becoming increasingly dependent on ground water to meet growing public  
 5 demand. Over the last several decades, Lancaster County’s population has grown at a faster  
 6 rate than the Commonwealth of Pennsylvania, reflecting an increase in demand for water.  
 7 Lancaster County currently has ample supply to meet the county’s needs. However, county  
 8 planning officials are concerned about future supplies. Table 2-9 lists some of the major  
 9 community water supply systems in the two-county area.

10 **Table 2-9. Major Public Water Supply Systems**

<b>Water Supplier <sup>a</sup></b>	<b>Water Source <sup>a, b</sup></b>	<b>Average Daily Production <sup>c</sup></b>	<b>Design Capacity <sup>c</sup></b>	<b>Population Served</b>
<b>Dauphin County</b>				
Harrisburg Municipal Water Authority	SW	9	20	66,540
Pennsylvania American Water Company–Hershey	SW	6	9	42,398
United Water Pennsylvania	SW	11	16	94,000
<b>Lancaster County</b>				
City of Lancaster	SW	16	40	108,000
Columbia Water Company	SW	2	3	21,500
Elizabethtown Area Water	SW	1	2	15,000
Ephrata Area joint Authority	SW	3	4	17,937
East Hempfield Water Authority	GW	2	3	16,761

11 (a) GW = ground water; SW = surface water;  
 12 (b) EPA 2008c  
 13 (c) Million gallons per day  
 14 Source: PADEP 2008a

15 Education

16 TMI-1 is located in the Lower Dauphin School District (PDE 2004), Dauphin County, which had  
 17 an enrollment of approximately 3,950 students in 2006-2007 school year (PDE 2007a).  
 18 Including the Lower Dauphin School District, Dauphin County has 10 public school districts  
 19 (PDE 2007a) with over 38,500 enrolled students (PDE 2007b). Lancaster County has a total of  
 20 16 public school districts (PDE 2007a). Total enrollment in Lancaster County public schools in  
 21 the 2006-2007 school year was approximately 71,000 students (PDE 2007b).

## 1 Transportation

2 TMI-1 is located in the southwest corner of Dauphin County (near the northern border of  
3 Lancaster County), approximately 10 mi southeast of Harrisburg, Pennsylvania. Dauphin  
4 County is traversed by four interstate highways: 81, 83, 283, and 76. The nearest interstate,  
5 I-76, can be accessed approximately 7 mi north of TMI-1 (see Figures 2-1 and 2-2).

6 Road access to TMI-1 is via State Highway 441 (SH-441), which runs north to south on the east  
7 side of the Susquehanna River. There are two access roads to TMI-1, Liberty Lane to the north  
8 (North Access Road), and Constitution Drive to the south (South Access Road), and they both  
9 intersect with SH-441 (see Figure 2-6). The majority of the plant's operation workforce uses the  
10 northern entrance; a limited number of employees working on the southern portion of the  
11 station, as well as the outage and refurbishment workforces use the southern entrance  
12 (AmerGen 2008). Approximately 4-5 mi north of TMI-1, SH-441 intersects with I-76, which runs  
13 east to west (Figure 2-2). AmerGen and contractor employees traveling to TMI-1 from  
14 Harrisburg, Hummelstown, and Middletown from the north would use I-76, or a variety of  
15 interstate, State, and secondary roads to access SH-441. Workers traveling to TMI-1 from  
16 Elizabethtown, Mount Joy, and Lancaster from the south would also use a variety of State  
17 highways and secondary roads to access SH-441.

18 Employees traveling from the southwest would travel north to I-76, cross the Susquehanna  
19 River, and access SH-441 to reach TMI-1.

20 Table 2-10 on the following page lists commuting routes to TMI-1 and average annual daily  
21 traffic (AADT) volume values. The AADT values represent traffic volumes for a 24-hour period  
22 factored by both day of week and month of year.

### 23 *2.2.8.3 Offsite Land Use*

24 Offsite land use conditions in Dauphin and Lancaster Counties are described in this section,  
25 because the majority of TMI-1 employees live in these two counties. In addition to the real  
26 estate taxes paid by AmerGen to Dauphin County, Dauphin and other counties in the vicinity of  
27 TMI-1 receive revenue from the taxes and fees paid by AmerGen and long-term contract  
28 employees residing in the region. In addition, changes in the number of workers employed at  
29 TMI-1 and the amount of taxes paid to local jurisdictions could affect land use conditions in  
30 these counties. The TMI-1 facility is located in southwestern Dauphin County. Lancaster County  
31 is located southeast of Dauphin County along the Susquehanna River.

## 32 Dauphin County

33 Dauphin County is approximately 525 mi<sup>2</sup> (1360 km<sup>2</sup>) and has 40 municipalities including the  
34 Pennsylvania State capital in Harrisburg (USCB 2008b). The county is located in south-central  
35 Pennsylvania, along the Susquehanna River. Dauphin County planners are concerned about  
36 future population growth and making growth decisions that will not overburden taxpayers.  
37 County planners are focused on revitalizing older developed areas of the county and managing  
38 growth that will not change its rural character.

39 Dauphin County planners are working to manage development within the county through the  
40 use of Planned Growth Areas. Dauphin County adopted the Regional Growth Management Plan  
41 produced by the Tri-County Regional Planning Commission (which includes Cumberland and  
42 Perry Counties). The goal is to focus development in and around Planned Growth Areas where

1

**Table 2-10. Major Commuting Routes in the Vicinity of the Three Mile Island Nuclear Station and 2006 Average Annual Daily Traffic (AADT) Counts**

Roadway and Location	AADT <sup>(a)</sup>
State Highway 230, south of Interstate 76, near Harrisburg International Airport to Middletown	13,000–17,000
State Highway 441, just north of Interstate 76	6,400
State Highway 441, south of Interstate 76, near Middletown	7,100
State Highway 441, south of Interstate 76, near Royalton	6,700
State Highway 441, near northern entrance to Three Mile Island	3,300
State Highway 441, between Dauphin County border and intersection with State Highway 241 (Lancaster County)	4,200
State Highway 441, between intersection with State Highway 241 and intersection with State Highway 743 (Lancaster County)	5,100 – 6,300
State Highway 441, between intersection with State Highway 743 and intersection with State Highway 772 (Lancaster County)	11,000
State Highway 441, between intersection with State Highway 772 and intersection with State Highway 23 (Lancaster County)	16,000
State Highway 441, between intersection with State Highway 23 and intersection with U.S. Route 30 (Lancaster County)	17,000
State Highway 441, between intersection with U.S. Route 30 and intersection with State Highway 462 Lancaster County)	12,000

Source: PennDOT 2008.

(a) All AADTs represent traffic volume during the average 24-hour day during 2006.

2 services such as sewer, water, transit, highway access, and community facilities exist to  
 3 maximize the investment in existing infrastructure (Dauphin County 2008).

4 The recently adopted Dauphin County Comprehensive Plan describes the following land use:

- 5       • Residential: 15 percent
- 6       • Public and semi-public lands: 26 percent (two-thirds comprised of state game lands  
 7       and forest)
- 8       • Agricultural and undeveloped lands: 55 percent
- 9       • Industrial: 2 percent
- 10      • Transportation: less than 1 percent

- Commercial and service: less than 1 percent each.

In 2000, 34.5 percent of the county's residents lived in Harrisburg and 16 boroughs while others made their homes in townships and villages. As part of the 2008 Comprehensive Plan, the county considered future land use by including geographic planning sections. Northern Dauphin County is characterized by low-density residential development. Southeastern Dauphin County is characterized by medium-density residential development. Southwestern Dauphin County and Harrisburg are characterized by high-density mixed urban development (Dauphin County 2008).

Throughout the county, non-residential development occurs in a scattered fashion adjacent to roadways. The greatest concentration of non-residential development occurs between the City of Harrisburg and Derry Township, adjacent to U.S. Routes 83, 322, and 422. Limited non-residential land use has occurred on limited access intersections of Interstates 81 and 83 and the Pennsylvania Turnpike. The portions of the county located in the heart of the Susquehanna Valley contain the majority of agricultural activity. The northeastern tier of the county is mountainous and forested (Dauphin County 2008).

The Land Needs Concept forecasts land use needs by considering regional population growth trends, employment needs resulting from population growth, and real estate market projections. Previously, most planning did not take this picture into account and relied solely on population projections. The future land use map identifies land needed to accommodate population projections through 2020. All other land is designated as Rural Reserve/Agriculture for future evaluation and use (Dauphin County 2008).

### Lancaster County

Lancaster County is approximately 949 mi<sup>2</sup> (2458 km<sup>2</sup>), nearly twice the size of Dauphin County in acreage and population, and has 60 municipalities (USCB 2008b). Farming plays a major role in Lancaster County, and land use planning focuses on preservation of agricultural areas. Farmland presently occupies 69 percent of the available land area in the county. Lancaster County and Municipal Planners are concerned about preserving the farming culture and heritage of the county, especially that of the Amish. Tourists visiting these areas add \$1.6 billion annually to the county's economy.

In 1993, the county adopted a Growth Management element to its Comprehensive Plan. Future growth would be directed to Designated Growth Areas (similar to Dauphin County's Planned Growth Areas) or areas already impacted by development to emphasize reinvestment in previously developed areas. The plan defined two types of growth areas as Urban Growth Areas and Village Growth Areas to manage future land use in the county (Lancaster County 2006). The growth areas have defined boundaries around a city, borough, or village, and include developed portions of surrounding townships and enough buildable land to meet future land use needs over a 20-year period. Since 1993, 39 growth areas have been established in Lancaster County. Between 1994 and 2002, residential land use outside Designated Growth Areas occurred at a net density of 0.8 dwellings per acre, while growth inside Designated Growth Areas occurred at a net density of 5.5 dwellings per acre (Lancaster County 2006).

Currently, the largest residential, commercial and industrial development concentrations are found in the City of Lancaster and surrounding areas. Development can also be found along

## Affected Environment

1 major road corridors heading north and northwest (Interstate 76, U.S. 30, U.S. 222, and PA 283)  
2 through the county (Lancaster County 2006).

3 The Lancaster County Planning Commission is updating the Growth Management Plan element  
4 of the Lancaster County Comprehensive Plan. The update will plan for growth throughout the  
5 county through 2030, and it will be guided by the Policy Element of the Comprehensive Plan.

6 The growth management plan will:

- 7 • Examine current and projected growth patterns and infrastructure needs
- 8 • Review urban and village growth areas
- 9 • Address issues of concern within rural areas
- 10 • Provide recommendations to achieve sustainable growth that balances development  
11 with the preservation of farmland and open space.

12

### 13 *2.2.8.4 Visual Aesthetics and Noise*

14 TMI-1 is located on an island in the middle of the  
15 Susquehanna River. TMI-1 as a whole can be seen from  
16 the river, but is shielded on the land side for the most  
17 part by surrounding vegetation due to its position along  
18 the river in the Susquehanna River Valley. The cooling  
19 towers, turbine buildings, and reactor containment  
20 structures dominate the site's landscape and can be  
21 seen from the Susquehanna River.

22 With natural draft cooling towers, the most obvious  
23 aesthetic impact is the visible plume in the sky. The  
24 plumes are most persistent under certain meteorological  
25 conditions when the capacity for the atmosphere to hold  
26 additional water vapor is lowest. This occurs when  
27 relative humidity is high or air temperatures are low. Observations of cooling towers in the same  
28 region suggest that under certain meteorological conditions the visible plume could extend 1–2  
29 mi (1.6–3.2 km) (AEC 1972).

The EPA generally uses 55 decibels (dBA) as the noise threshold level to protect against excess noise during outdoor activities. However, according to the EPA, this threshold does "not constitute a standard, specification, or regulation," but was intended to provide a basis for state and local governments establishing noise standards.

30 Noise from TMI-1 can be detected offsite. Sources of noise from station operation include the  
31 cooling towers, turbines, and large pumps and cooling water system motors. Given the industrial  
32 nature of the station, noise emissions from the station are generally nothing more than an  
33 intermittent minor nuisance. Noise levels may sometimes exceed the 55 dBA level that the EPA  
34 uses as a threshold level to protect against excess noise during outdoor activities. However,  
35 according to the EPA this threshold does "not constitute a standard, specification, or regulation,"  
36 but was intended to provide a basis for State and local governments establishing noise  
37 standards.



1 2.2.8.5 Demography

2 According to the 2000 Census, approximately 787,800 people lived within 20 mi (32 km) of TMI-  
 3 1, which equates to a population density of 627 persons per square mile (AmerGen 2008). This  
 4 density translates to the least sparse Category 4 density level (greater than or equal to 120  
 5 persons per square mile within 20 mi). Approximately 2,546,500 people live within 50 mi (80 km)  
 6 of TMI-1 (AmerGen 2008). This equates to a population density of 325 persons per square mile.  
 7 Applying the GEIS proximity measures, TMI-1 is classified as proximity Category 4 (greater than  
 8 or equal to 190 persons per square mile within 50 mi). Therefore, according to the sparseness  
 9 and proximity matrix presented in the GEIS, TMI-1 rankings of sparseness Category 4 and  
 10 proximity Category 4 result in the conclusion that TMI-1 is located in a high population area.

11 Table 2-11 shows population projections and growth rates from 1970 to 2050 in Dauphin and  
 12 Lancaster Counties. The growth rate in Dauphin County showed an increase of 5.9 percent for  
 13 the period of 1990 to 2000. County populations are expected to continue to grow in both  
 14 counties in the next decades although Lancaster County's population is expected to increase at  
 15 a higher rate through 2050.

16 **Table 2-11. Population and Percent Growth in Dauphin County and Lancaster**  
 17 **County, Pennsylvania, from 1970 to 2000, and Projected for 2010 and 2050**

Year	Dauphin		Lancaster	
	Population	Percent Growth <sup>(a)</sup>	Population	Percent Growth <sup>(a)</sup>
1970	223,834	—	319,693	—
1980	232,317	3.8	362,346	13.3
1990	237,813	2.4	422,822	16.7
2000	251,798	5.9	470,658	11.3
<b>2006</b>	<b>254,176</b>	<b>0.9</b>	<b>494,486</b>	<b>5.1</b>
2010	256,478	1.9	499,261	6.1
2020	263,198	2.6	527,486	5.7
2030	270,543	2.8	554,611	5.1
2040	279,024	3.2	591,901	6.7
2050	286,710	2.7	623,536	5.3

— = No data available.

(a) Percent growth rate is calculated over the previous decade.

Sources: Population data for 1970–2000 (USCB 2008a); population data for 2006 (estimated) 2006 American Community Survey; population projections for 2010 – 2030 by Pennsylvania State Data Center, February 2008; population projections for 2040 and 2050 (calculated)

Affected Environment

1 The 2000 and 2006 (estimate) demographic profiles of the two-county region of influence  
 2 population are presented in Table 2-12 and Table 2-13. In 2000, minority individuals (both race  
 3 and ethnicity) comprised 15.5 percent of the total two-county population. The minority  
 4 population was comprised largely of Black or African American and Hispanic or Latino residents.

5 **Table 2-12. Demographic Profile of the Population in the TMI-1 Two-County**  
 6 **Socioeconomic Region of Influence in 2000**

	Dauphin	Lancaster	Region of Influence
<b>Total Population</b>	251,798	470,658	722,456
<b>Race (percent of total population, Not Hispanic or Latino)</b>			
White	75.6	89.3	84.5
Black or African American	16.6	2.5	7.4
American Indian and Alaska Native	0.1	0.1	0.1
Asian	1.9	1.4	1.6
Native Hawaiian and Other Pacific Islander	0.0	0.0	0.0
Some other race	0.1	0.1	0.1
Two or more races	1.5	0.8	1.1
<b>Ethnicity</b>			
Hispanic or Latino	10,404	26,742	37,146
Percent of total population	4.1	5.7	5.1
<b>Minority Population (including Hispanic or Latino ethnicity)</b>			
Total minority population	61,451	50,292	111,743
Percent minority	24.4	10.7	15.5

7 Source: USCB 2008a

8  
 9 According to the U.S. Census Bureau's 2006 American Community Survey, minority populations  
 10 in the two-county region were estimated to have increased by nearly 17,000 persons and  
 11 comprised 17.2 percent of the total two-county population in 2006 (see Table 2-13). The largest  
 12 increases in minority populations were estimated to occur in Hispanic or Latino and Asian  
 13 populations. The Black or African American population increased by approximately 9.4 percent  
 14 from 2000 to 2006, but remained relatively unchanged as a percentage of the total fourcounty  
 15 population.

1 **Table 2-13. Demographic Profile of the Population in the TMI-1 Two-County**  
 2 **Socioeconomic Region of Influence in 2006 (Estimate)**

	Dauphin	Lancaster	Region of Influence
<b>Total Population</b>	254,176	494,486	748,662
<b>Race (percent of total population, Not-Hispanic or Latino)</b>			
White	73.5	87.6	82.8
Black or African American	17.2	3.0	7.8
American Indian and Alaska Native	0.2	0.1	0.1
Asian	2.4	1.5	1.8
Native Hawaiian and Other Pacific Islander	0.0	0.0	0.0
Some other race	0.1	0.2	0.2
Two or more races	1.5	0.9	1.1
<b>Ethnicity</b>			
Hispanic or Latino	12,910	32,894	45,804
Percent of total population	5.1	6.7	6.1
<b>Minority Population (including Hispanic or Latino ethnicity)</b>			
Total minority population	67,434	61,435	128,869
Percent minority	26.5	12.4	17.2

3 Source: USCB 2008a

4  
 5 Transient Population

6 Within 50 mi (80 km) of TMI-1, colleges and recreational opportunities attract daily and seasonal  
 7 visitors who create demand for temporary housing and services. In 2007, there were  
 8 approximately 63,000 students attending colleges and universities within 50 mi (80 km) of TMI1  
 9 (IES 2008).

10 In 2000 in Dauphin County, 0.5 percent of all housing units were considered temporary housing  
 11 for seasonal, recreational, or occasional use. By comparison, seasonal housing accounted for  
 12 0.4 percent and 2.8 percent of total housing units in Lancaster County and Pennsylvania,  
 13 respectively (USCB 2008). Table 2-14 provides information on seasonal housing located within  
 14 50 mi of TMI-1.

15 **Table 2-14. Seasonal Housing in Counties Located within 50 Miles of TMI-1**

County <sup>(a)</sup>	Housing units	Vacant housing units: For seasonal, recreational, or occasional use	
			Percent
<b>Pennsylvania</b>	<b>5,249,750</b>	<b>148,230</b>	<b>2.8</b>
Adams	35,831	672	1.9
Berks	150,222	744	0.5
Chester	163,773	571	0.3
Columbia	27,733	1,304	4.7
Cumberland	86,951	379	0.4
Dauphin	111,133	570	0.5
Franklin	53,803	572	1.1

Affected Environment

County <sup>(a)</sup>	Housing units	Vacant housing units: For seasonal, recreational, or occasional use		Percent
Juniata	10,031	945	9.4	
Lancaster	179,990	808	0.4	
Lebanon	49,320	458	0.9	
Mifflin	20,745	1,082	5.2	
Northumberland	43,164	246	0.6	
Perry	18,941	1,270	6.7	
Schuylkill	67,806	865	1.3	
Snyder	14,890	495	3.3	
York	156,720	946	0.6	
County Subtotal	1,191,053	11,927	2.4	(avg.)
<b>Maryland</b>	<b>2,145,283</b>	<b>38,880</b>	<b>1.8</b>	
Baltimore	313,734	1,212	0.4	
Carroll	54,260	117	0.2	
Cecil	34,461	1,410	4.1	
Frederick	73,017	284	0.4	
Harford	83,146	299	0.4	
Washington	52,972	468	0.9	
County Subtotal	611,590	3,790	1.1	(avg.)
<b>County Total</b>	<b>1,802,643</b>	<b>15,717</b>	<b>2.0</b>	(avg.)

Source: USCB 2008

(a) Counties within 50 mi (80 km) of TMI-1 with at least one block group located within the 50-mile radius  
 avg. = percent average for counties within the TMI-1 50-mile radius and excludes state percentage

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17

Migrant Farm Workers

Migrant farm workers are individuals whose employment requires travel to harvest agricultural crops. These workers may or may not have a permanent residence. Some migrant workers may follow the harvesting of crops, particularly fruit, throughout the northeastern U.S. rural areas. Others may be permanent residents near TMI-1 who travel from farm to farm harvesting crops.

Migrant workers may be members of minority or low-income populations. Because they travel and can spend a significant amount of time in an area without being residents, migrant workers may be unavailable for counting by census takers. If uncounted, these workers would be “underrepresented” in USCB minority and low-income population counts.

Information on migrant farm and temporary labor was collected in the 2002 Census of Agriculture. Table 2-15 provides information on migrant farm workers and temporary farm labor (less than 150 days) within 50 mi (80 km) of TMI-1. According to the 2002 Census of Agriculture, approximately 25,000 farm workers were hired to work for less than 150 days and were employed on 5,800 farms within 50 mi (80 km) of TMI-1. The county with the largest number of temporary farm workers (5,841 workers on 1,627 farms) was Lancaster County, Pennsylvania.

1 In the 2002 Census of Agriculture, farm operators were asked for the first time whether any  
 2 hired migrant workers, defined as a farm worker whose employment required travel that  
 3 prevented the migrant worker from returning to their permanent place of residence on the same  
 4 day. A total of 648 farms in the 50-mile radius of TMI-1 reported hiring migrant workers. Chester  
 5 County reported the most farms (158) with hired migrant workers, followed by Lancaster County  
 6 (126). By comparison, the 10 farms in Dauphin County host relatively small numbers of migrant  
 7 workers. According to 2002 Census of Agriculture estimates, 425 temporary farm laborers  
 8 (those working fewer than 150 days per year) were employed on 147 farms in Dauphin County,  
 9 and as previously discussed 5,841 temporary farm workers were employed on 1,627 farms in  
 10 Lancaster County (USDA 2002 Census of Agriculture).

11 **Table 2-15. Migrant Farm Worker and Temporary Farm Labor in Counties Located**  
 12 **within 50 Miles of TMI-1**

County <sup>(a)</sup>	Number of farm workers working for less than 150 days	Number of farms hiring workers for less than 150 days	Number of farms reporting migrant farm labor	Number of farms with hired farm labor
<b>Pennsylvania</b>	<b>13,512</b>	<b>10,232</b>	<b>41,606</b>	<b>745</b>
Adams	293	211	2,437	88
Berks	549	383	2,128	28
Chester	710	494	2,470	158
Columbia	252	196	1,408	8
Cumberland	189	130	420	4
<i>Dauphin</i>	<i>194</i>	<i>147</i>	<i>425</i>	<i>10</i>
Franklin	482	342	1,819	27
Juniata	172	158	304	2
<i>Lancaster</i>	<i>1,976</i>	<i>1,627</i>	<i>5,841</i>	<i>126</i>
Lebanon	325	180	547	6
Mifflin	250	106	249	1
Northumberland	204	156	595	27
Perry	150	112	392	7
Schuylkill	173	128	556	10
Snyder	242	189	534	16
York	404	327	1,104	23
<b>County Subtotal</b>	<b>6,565</b>	<b>4,886</b>	<b>21,229</b>	<b>541</b>
<b>Maryland</b>	<b>3,321</b>	<b>2,453</b>	<b>10,551</b>	<b>212</b>
Baltimore	273	201	762	47
Carroll	244	169	414	6
Cecil	162	123	713	7
Frederick	294	223	1,269	17
Harford	148	101	406	26
Washington	188	129	443	4
<b>County Subtotal</b>	<b>1,309</b>	<b>946</b>	<b>4,007</b>	<b>107</b>
<b>County Total</b>	<b>7,874</b>	<b>5,832</b>	<b>25,236</b>	<b>648</b>

(a) Counties within 50 mi (80 km) of TMI-1 with at least one block group located within the 50-mi (80-km) radius

Source: 2002 Census of Agriculture – County Data; Table 7. Hired Farm Labor – Workers and Payroll: 2002

Affected Environment

1 2.2.8.6 *Economy*

2 This section contains a discussion of the economy, including employment and income,  
3 unemployment, and taxes.

4 Employment and Income

5 Between 2000 and 2006, the civilian labor force in Dauphin County increased 6 percent from  
6 128,611 to 136,359. During the same time period, the civilian labor force in Lancaster County  
7 grew by nearly the same percentage (5.8 percent) (USCB 2008a).

8 In 2006, educational services, health care and social assistance represented the largest sector  
9 of employment in the two-county region followed closely by manufacturing and retail trade  
10 industry. The educational services, health care, and social assistance sector employed the most  
11 people in Dauphin County, followed by the retail trade and public administration sectors. A list of  
12 some of the major employers in Dauphin County in 2007 is provided in Table 2-16. As shown in  
13 the table, the largest private employer in Dauphin County was Hershey Foods Corporation.

14 **Table 2-16. Major Employers in Dauphin County in 2007**

Name	Name
Pennsylvania State Government	Harrisburg School District
Milton S Hershey	Giant Food Stores LLC
Hershey Foods Corporation	Wal-Mart Associates Inc.
HERCO Inc./ Hershey Entertainment and Resorts	Keystone Service Systems Inc.
Pinnacle Health System	Nationwide Mutual Insurance Company
Federal Government	United Concordia Companies Inc.
Pennsylvania Higher Education Assistance Agency	Diocese of Harrisburg
Tyco Electronics Corporation	DST Health Solutions Services
Central Dauphin School District	City of Harrisburg
United Parcel Service	ArcelorMittal Steelton LLC
Pennsylvania State University	D & H Distributing Company
Capital Blue Cross	Derry Township School District
Harrisburg Area Community College	ENERFAB Inc.
Dauphin County Government	Lower Dauphin School District
Milton S Hershey School and School Trust	C & S Wholesale Grocers

Source: Center for Workforce Information and Analysis 2008

15 Income information for the TMI-1 region of influence is presented in Table 2-17. In 1999, the  
16 date of the last economic census, the two counties each had median household incomes above  
17 the Pennsylvania Commonwealth average. Per capita income, with the exception of Lancaster  
18 County, was also above the average for all of Pennsylvania. In 1999, only 7.8 percent of the  
19 population in Lancaster County was living below the official poverty level, while in Dauphin  
20 County and the Commonwealth of Pennsylvania, 9.7 and 11 percent of the respective  
21 populations were living below poverty level. The percentage of families living below the poverty  
22 level was about the same for Dauphin County and Pennsylvania as a whole. Lancaster County  
23 had a smaller percentage of families living below the poverty level (USCB 2008a).

1 **Table 2-17. Income Information for the TMI-1 Socioeconomic Region of Influence**

	Dauphin	Lancaster	Pennsylvania
Median household income 1999 (dollars)	41,507	45,507	40,106
Per capita income 1999 (dollars)	22,134	20,398	20,880
Percent of families living below the poverty level (2000)	7.5	5.3	7.8
Percent of individuals living below the poverty level (2000)	9.7	7.8	11.0

2 Source: USCB 2008  
3

4 Unemployment

5 In 2006, the annual unemployment average in Dauphin and Lancaster Counties were 4.8 and  
6 3.6 percent, respectively, which were lower than the annual unemployment average of 6.2  
7 percent for the Commonwealth of Pennsylvania (USCB 2008a).

8 Taxes

9 Currently, AmerGen pays annual property taxes on TMI-1 to Dauphin County, Londonderry  
10 Township, and the Lower Dauphin School District. Prior to 2000, real estate taxes were paid to  
11 the Commonwealth of Pennsylvania for power generation, transmission, and distribution  
12 facilities. During that time, under authority of the Pennsylvania Utility Realty Tax Act (PURTA),  
13 real estate taxes collected from all utilities (water, telephone, electric, and railroads) were  
14 redistributed to the taxing jurisdictions within the Commonwealth. In Pennsylvania, these  
15 jurisdictions included counties, cities, townships, boroughs, and school districts. The distribution  
16 of PURTA funds was determined by formula, and was not necessarily based on the individual  
17 utility's effect on a particular government entity.

18 Under 1999 Amendments to PURTA, the assessment methodology for utilities was revised from  
19 the depreciated book value to the market value of utility property. Additionally, as of January 1,  
20 2000, the owners of TMI-1 were required to begin paying real estate taxes directly to local  
21 jurisdictions, ceasing payments to the Commonwealth's PURTA fund. Accordingly, since that  
22 time, the owner of TMI-1 has periodically negotiated with local taxing jurisdictions regarding  
23 market value assessments of the station and the amount of taxes that will be paid.

24 While maintaining open appeals of the assessments from 1998 through 2002, AmerGen and the  
25 previous owners of TMI-1 entered into a Stipulation and Interim Settlement agreement with the  
26 taxing authorities, dated December 22, 2000 (2000 Stipulation). Under the 2000 Stipulation,  
27 AmerGen paid Dauphin County approximately \$146,900 annually in property taxes from 2000  
28 through 2004. These payments represented approximately 0.2 to 0.3 percent of Dauphin  
29 County's total property tax revenues for that time period (see Table 2-18 on the following page).

30 Also from 2000 through 2004 under the 2000 Stipulation, AmerGen paid property taxes annually  
31 to Londonderry Township and Lower Dauphin School District in the amounts of \$30,000 and  
32 \$394,500, respectively. These payments represented approximately 0.5 to 0.7 percent of  
33 Londonderry Township's total property tax revenues and approximately 2.1 to 2.9 percent of  
34 total property tax revenues for the Lower Dauphin School District (see Table 2-18 on the  
35 following page).

36 In 2005, AmerGen and PECO signed a settlement with the local taxing bodies (the 2005  
37 Settlement) that both acknowledged the 1999 PURTA Amendments' change in the way TMI-1's

## Affected Environment

1 value would be assessed and reported a corresponding reduction in assessed value. As a  
2 result, the 2005 Settlement slightly decreased AmerGen's property tax payments to Dauphin  
3 County, Londonderry Township, and the Lower Dauphin School District in comparison with  
4 payments made under the 2000 Stipulation. For 2005, AmerGen's property tax payments  
5 represented approximately 0.2 percent of Dauphin County's total property tax revenues, and  
6 approximately 1.7 percent of the Lower Dauphin School District's total property tax revenues  
7 (see Table 2-18).

8 From 2000 to 2005, AmerGen's annual property tax payments to both Dauphin County and  
9 Londonderry Township for TMI-1 represented less than 1 percent of each of their total property  
10 tax revenues. Annual property tax payments to the Lower Dauphin School District during the  
11 same time period represented an average of approximately 2.4 percent of the school district's  
12 total property tax revenues (see Table 2-18).

13 In July of 2008, AmerGen negotiated a new agreement with the three taxing entities (2008  
14 Agreement) that provides for an increase in the property taxes AmerGen currently pays. The  
15 2008 Agreement obligates AmerGen to pay a total of \$930,000 to the Lower Dauphin School  
16 District, Dauphin County and Londonderry Township. Annually, the school district will receive  
17 \$637,000, the county will receive \$254,634, and the township will receive \$37,665. These  
18 payments will begin in 2008 and continue through 2017.

19 Dauphin County property taxes are used to pay for county operations, the judicial system, public  
20 safety, public works, cultural and recreational programs, human services and conservation and  
21 development programs. Londonderry Township property taxes pay the operating costs for  
22 libraries, hospitals, roads, school districts, and fire departments. The continued availability of  
23 TMI-1 and the associated tax base is an important feature in the ability of the Dauphin County  
24 and Londonderry Township to continue to invest in infrastructure and to draw industry and new  
25 residents.  
26

### 27 **2.2.9 Historic and Archaeological Resources**

28 This section discusses the cultural background and the known historic and archaeological  
29 resources at the site of TMI-1 and in the surrounding area.

#### 30 *2.2.9.1 Cultural Background*

31 The region around TMI-1, located on the northern end of Three Mile Island, contains prehistoric  
32 and historic Native American and Euro-American cultural resources. Three Mile Island was  
33 formed as a result of water deposited sands and gravels resting on deposits of sedimentary  
34 sandstones, siltstones, and clays (Smith 1977). TMI-1 lies within the Gettysburg Section of the  
35 Piedmont physiographic province, which is characterized by rolling low hills and valleys (DCNR  
36 2008a). The Piedmont region contains some of the most agriculturally productive land in  
37 Pennsylvania both currently and historically, and is a favored area of settlement (Raber 1985).  
38 There are 369 properties in Dauphin, York, and Lancaster Counties that are listed on the  
39 *National Register of Historic Places* (NRHP), and 19 properties



1 **Table 2-18. TMI-1 Property Tax Paid and Percentage of Dauphin County,**  
 2 **Londonderry Township, and the Lower Dauphin School District from**  
 3 **Property Tax Revenues, 2000 to 2005**

Entity	Year	Total Property Tax Revenue (millions of dollars)	Property Tax Paid by AmerGen (thousands of dollars)	Percent of Total Revenue
Dauphin County	2000	58.0	146.9	0.3
	2001	60.1	146.9	0.2
	2002	60.5	146.9	0.2
	2003	61.5	146.9	0.2
	2004	73.9	146.9	0.2
	2005	89.3	141.6	0.2
Londonderry Township	2000	4.0	30.0	0.7
	2001	4.8	30.0	0.6
	2002	5.1	30.0	0.6
	2003	5.6	30.0	0.5
	2004	6.3	30.0	0.5
	2005	6.4	21.0	0.3
Lower Dauphin School District	2000	13.8	394.5	2.9
	2001	14.1	394.5	2.8
	2002	15.8	394.5	2.5
	2003	17.5	394.5	2.3
	2004	18.6	394.5	2.1
	2005	20.1	343.0	1.7

Source: AmerGen 2008

4 are located within 6 mi (10 km) of TMI-1 (USDOJ 2008). No NRHP listed properties are affected  
 5 by operation of TMI-1. Paleo-Indians occupied North America approximately 15,000–10,000  
 6 years ago, subsisting on hunted game and gathered plant material. In the Pennsylvania area,  
 7 Paleo-Indians migrated into an environment changed by retreating glacial ice. The climate in  
 8 Pennsylvania at the time was wetter and cooler than it is today. Large areas of grasslands  
 9 mixed with coniferous and deciduous forests were characteristic of the region (Raber 1985).  
 10 Paleo-Indian populations were highly mobile and hunted large animals such as mastodons,  
 11 bison, caribou, mammoths, horse, deer, giant beaver, moose, and elk (Raber 1985; Funk 1972).  
 12 The primary artifact associated with the Paleo-Indian period is the Clovis point, a distinctive,  
 13 fluted, lanceolate point that is widely distributed throughout Pennsylvania, especially in the  
 14 Susquehanna and Delaware River valleys (AmerGen 2008). Regional studies indicate that there  
 15 is a high probability for Clovis points to be found in the Susquehanna River Valley (Kent et al.  
 16 1971). Other tools commonly found at Pennsylvania Paleo-Indian sites include scrapers;  
 17 spurred-end scrapers; drills; cores; bifaces; microblades; and small uniface, biface, and flake  
 18 knives (AmerGen 2008).

## Affected Environment

1 During the Archaic Period, from approximately 10,000 years ago until about 3,000 years ago,  
2 subsistence strategies underwent changes to adapt to resource availability. As the glaciers  
3 retreated northward and larger animals disappeared from the region, humans adapted to exploit  
4 modern plants and smaller game animals. Like Paleo-Indians, early Archaic foragers were  
5 highly mobile (Carr 1998). As resource quality and the cultural means to access resources  
6 improved, archaeologists find evidence of larger populations by the end of the Archaic Period, a  
7 time when climate reached its modern condition. As a result of diversification of prey species, a  
8 shift in the design of hunting technology occurred. Prehistoric megafauna were replaced by  
9 deer, elk, bear, turkey and other species common to deciduous forests (Raber 1985). Projectile  
10 points also changed to smaller, barbed points (Raber 1985). Archaic people collected, hunted,  
11 and gathered most of what they needed for survival in their home territory. Large base camps  
12 found near major water sources provided a focal point for groups during the winter months.  
13 During this period, Archaic peoples developed well-defined seasonal foraging activities.

14 The "Woodland" culture existed from 3,000 years ago until European contact around 1,500 A.D.  
15 This period is defined by the introduction of horticulture to augment subsistence hunting and  
16 gathering. A reliance on agriculture led to the establishment of more permanent settlements  
17 during this period. The earliest evidence of agriculture in Pennsylvania was found at the  
18 Meadowcroft rock shelter where evidence of squash and maize (corn) appear in the  
19 archaeological record (Adovasio and Johnson 1981). Other characteristics of Woodland culture  
20 include an increase in population, the emergence of social hierarchy, expanded interregional  
21 trade, more elaborate burial rituals, the introduction of the bow and arrow, and the use of  
22 ceramics for storage and cooking (Cowin 1985).

23 The area around TMI-1 was home to a number of prehistoric populations. Evidence from  
24 archaeological sites in the region reflect the influences of Laurentian, Lamoka, Piedmont and  
25 later Hopewell cultural traditions (AmerGen 2008). Native Americans used the Susquehanna  
26 River and several overland paths and trails as their primary transportation routes. Native  
27 American societies in the region shared several important characteristics at the time of first  
28 contact with Europeans. These characteristics included an economic base that combined  
29 hunting and gathering with domesticated plants and an annual settlement pattern that varied in  
30 population size between semi-permanent river-side villages in summer, large camps in winter,  
31 and population dispersal among scattered camps in the spring and fall.

32 In the 1600s, Europeans came to the Pennsylvania area and came into contact with Late  
33 Woodland peoples known as the Delaware, Shawnee, Iroquois, and Susquehannock (AmerGen  
34 2008). The Susquehannocks were an Iroquoian-speaking tribe that lived along the  
35 Susquehanna River in Pennsylvania and Maryland (PGA Undated). Living in Algonkian-  
36 speaking tribes' territory, they engaged in many wars (AmerGen 2008). The Susquehannocks  
37 lived about 20 miles downstream from Three Mile Island in a town called Sasquesahanaugh,  
38 located on the eastern side of the Susquehanna River at Washington Boro (AEC 1972).  
39 Susquehannock populations were reduced by diseases brought by Europeans and by attacks  
40 from Marylanders and the Iroquois. By 1675, the Susquehannocks ceased to exist as a Nation  
41 (PGA Undated).

42 The rise of nation-states in Europe coincided with European land acquisition in North America.  
43 Wars in southern Germany caused many Germans to migrate to Pennsylvania. The struggle for

1 religious freedom in England brought Quakers, Puritans, and Catholics to Pennsylvania (PHMC  
2 Undated-a). Captain John Smith was the first European to explore the region. In 1608, Smith  
3 journeyed from Virginia up the Susquehanna River and made contact with the Susquehannock  
4 Indians. Around this time, Henry Hudson's voyages document the relations between the  
5 European settlers and the Indian Nations occupying Pennsylvania (Raber 1985). Between 1609  
6 and 1681, the Dutch, Swedes, and English inhabited and fought over the region that would later  
7 become eastern Pennsylvania. Ultimately, the English prevailed in Pennsylvania and the area  
8 fell under English rule (PHMC Undated-a). The effects of European contact upon Indian  
9 populations included death due to disease, increased inter-group warfare, and a dependence on  
10 European goods (Jennings 1968).

11 William Penn, a member of the Society of Friends, also known as Quakers, a persecuted  
12 religious sect in England petitioned the King of England for a haven in the New World. On  
13 March 4, 1681, the King granted the petition and named the new colony in honor of William  
14 Penn's father (PHMC Undated-a). Although William Penn was granted all of the land in  
15 Pennsylvania, he and his heirs chose not to grant or settle any part of it without first buying the  
16 claims of Native Americans who lived there. Most of Pennsylvania was purchased by 1768 and  
17 the remaining portion was purchased by the Commonwealth by 1789 (PHMC Undated-a).  
18 English, German, and Scotch-Irish immigrants eventually settled in the region.

19 As previously discussed, TMI-1 is located in Londonderry Township in Dauphin County,  
20 Pennsylvania. Dauphin County was created on March 4, 1785, from part of Lancaster County,  
21 and it was named for the French dauphin (prince), the king's eldest son (PHMC Undated-b).  
22 Harrisburg, the county seat, was named for its founder John Harris, and was incorporated as a  
23 borough in 1791 and chartered as a city in 1810 (PHMC Undated-b). John Harris, a native of  
24 Yorkshire, England, was one of the first emigrants to accompany William Penn (Harrisburg  
25 Websites Undated). In 1705, Harris secured a license to obtain land and around 1718, settled in  
26 the wilderness of what was to become Harrisburg (PHMC Undated-b). There are several islands  
27 within Londonderry Township, one of which is Three Mile Island, formerly called Elliot's Island  
28 and prior to that Conewago Island (Londonderry Township Undated).

29 Several historic canals were constructed on both sides of the Susquehanna River in the vicinity  
30 of TMI-1. The nearest canal, Pennsylvania Canal's Eastern Division (Eastern Division Canal)  
31 ran on the east side of the Susquehanna River for 43 mi (69 km) between Columbia, PA  
32 (Lancaster County) and Duncan's Island at the mouth of the Juniata River north of Harrisburg  
33 (Citizendum 2007). The Eastern Division Canal was originally owned and operated by the  
34 Commonwealth of Pennsylvania. Due to the cost of maintaining the canal and competition from  
35 railroads, the whole of Pennsylvania's Main Line canal system was sold to the Pennsylvania  
36 Railroad (PRR) in the 1850s. The PRR operated the canal until 1901, when it was replaced by  
37 the existing railroad, which is built on top of the old canal. Later, railroads became the  
38 predominant mode of freight transportation which resulted in the abandonment of the canals.

#### 39 *2.2.9.2 Historic and Archaeological Resources*

40 The islands in the Susquehanna River Valley were heavily utilized by prehistoric and historic  
41 native populations, as well as European immigrants. Three Mile Island was first purchased in  
42 1749 by Thomas Cookson who served as Thomas Penn's Deputy Surveyor for Lancaster  
43 County (Huber 1982). The island was passed down through Cookson's extended family and  
44 sold to James Duffy in 1879 (Huber 1982). Duffy's son rebuilt and transformed an existing farm

## Affected Environment

1 on the island into a tobacco producing station (Huber 1982). In 1904, ice and elevated levels of  
2 water from the winter thaw flooded the island and ruined Duffy's tobacco station. Duffy  
3 unknowingly sold the island to the York Haven Water and Power Company, which in turn sold  
4 the land to Metropolitan Edison in 1924 (Huber 1982). Between 1957 and the start of  
5 construction, 270 acres on Three Mile Island were leased for farming (AEC 1972). At the time,  
6 there was no access to the island by bridge, so equipment and produce were transported by  
7 barge. In addition to farming, there were 70 cabins on the island that were also leased (53 on  
8 the west side and 17 on the east side), along with a picnic area, a boat dock, and a well for  
9 drinking water (AEC 1972).

10 A search of the PHMC site file records identified nine prehistoric sites and one historic site on  
11 Three Mile Island. One additional historic site was identified on the island during NRC's  
12 walkover survey. Of the nine previously recorded sites, two sites (36Da51 and 36Da98) are not  
13 associated with any cultural period. Sites 36Da96, 36Da97, 36Da99, and 36Da100 contain  
14 material from Late Archaic to the Late Woodland period. Dates for these sites were based upon  
15 collected lithics, points, and pottery. Site 36Da96 was situated in a cultivated area near TMI-1  
16 and TMI Unit 2 and was assigned a cultural designation of Late Archaic to Early Woodland. It is  
17 unclear if any portions of the 36Da96 remain. Site 36Da97 was also located where TMI-1 and  
18 TMI Unit 2 are currently situated. The site form indicates that Woodland pottery was collected;  
19 however, no examples were available for study. 36Da97 was destroyed by construction of TMI-  
20 1 and TMI Unit 2. 36Da99 and 36Da100 are large multi-component campsites. On their  
21 respective site forms, 36Da99 is listed as Late Archaic and 36Da100 as a Late Woodland site.

22 Site 36Da52 is also listed as primarily an Archaic site, but some Woodland components were  
23 also recovered there. This site was recorded by the William Penn Memorial Museum in 1967  
24 (now known as the State Museum of Pennsylvania) perhaps as part of Ira Smith's salvage  
25 excavation. It is unclear whether or not 36Da52 was destroyed during the construction of TMI-1  
26 and 2.

27 In 1967, prior to construction of TMI-1 and TMI Unit 2, a cultural resource study was conducted  
28 by the Pennsylvania Historical and Museum Commission (PHMC) (AEC 1972). Five areas of  
29 the island were tested, and one multi-component site (36Da50) was selected as the most likely  
30 candidate to yield information about the island's cultural sequence. The site was excavated and  
31 yielded a rich inventory of lithic and ceramic information dating to the Early and Middle  
32 Woodland periods. The types and quantities of lithic and ceramic artifacts recovered suggests  
33 that Three Mile Island was intermittently occupied by small groups of Early and Middle  
34 Woodland peoples utilizing the area for hunting and fishing (Smith 1977). At the time, 36Da50  
35 was the largest Early to Middle Woodland site excavated in the Lower Susquehanna River  
36 Valley of Pennsylvania. Previous research in the area had primarily focused on small campsites  
37 and rock shelters. In total, eight different ceramic types were recovered from the island along  
38 with eight categories of projectile points, ten types of flake tools, and four classes of bifacials  
39 and cleavers (Smith 1977). This suggests that Three Mile Island was used for securing and  
40 processing food (Smith 1977). In total, more than 1,000 artifacts were recovered spanning from  
41 4,000 B.C. to 1,000+ A.D.

42 In 1987, a paper was presented by two archaeologists at the Mid Atlantic Archaeological  
43 Conference Annual Meeting in Lancaster Pennsylvania for archaeological work conducted at

1 Three Mile Island. The paper defined the cultural occupations of the island based on examining  
2 artifacts gathered by local collectors, reviewing previous archaeological reports, and performing  
3 limited testing on the island. Research and fieldwork (completed in 1986) indicated that the  
4 earliest occupation of Three Mile Island was during the Early Archaic period. Additionally, Early,  
5 Middle, and Late Woodland periods are also well represented. The continuous use of the island  
6 is surprising because experts believed that Late Woodland sites are comparatively infrequent on  
7 islands. To date, no Paleo-Indian artifacts have been found. While Three Mile Island was used  
8 continuously over the last 12,000 years, much of the cultural data, stratigraphy, and features  
9 relating to prehistoric occupations remain to be investigated (AmerGen 2008).

10 In 1988, the Curator of Archaeology from the State Museum of Pennsylvania performed an  
11 excavation of an historical burial site (36Da101) discovered eroding out of the river bank by a  
12 TMI-1 employee (Warfel 1988). According to PHMC survey records, 36Da101 is a large site that  
13 borders the riverbank and contains both Late Archaic and Late Woodland period artifacts in  
14 addition to the historic artifacts recovered during Warfel's excavation. As previously discussed,  
15 the island was extensively farmed in the 18<sup>th</sup> and 19<sup>th</sup> centuries (Warfel 1988). Residents of the  
16 island built houses, barns, and other structures. Records verify that children were born and  
17 adults died on the island, so the likelihood of additional burials is high (Warfel 1988).  
18 Fragmentary remains were collected and analysis of the bones and artifacts determined the  
19 burial dates to be in the 1860s–1880s time period and the bones to have originated from an  
20 adult male aged 50-plus years (Warfel 1988). The remains were collected and later reburied in a  
21 location near the original burial site. Artifacts associated with the burial were donated to the  
22 State Museum of Pennsylvania (AmerGen2008).

23 Another archaeological survey was conducted in 1998 for a proposed fish passage to be  
24 located on the east side of Three Mile Island. Previous research indicated that site 36Da51 was  
25 located in the vicinity of the project. PHMC records for 36Da51 did not indicate site type or  
26 cultural affiliation. Test units from the survey yielded some lithic flakes, fire-cracked rock, two  
27 pottery shards, and some historic artifacts. Analyses of the materials recovered indicated that  
28 further testing was not warranted. The portion of site 36Da51 that would be impacted by the  
29 proposed fish ladder did not meet any of the criteria for listing on the National Register of  
30 Historic Places.

31 As noted earlier, during the walkover survey of Three Mile Island an additional historic site was  
32 identified. Remnants of an historic farmstead were found in the woods. This farmstead is a large  
33 complex complete with foundations for approximately 10 buildings (possibly a house, barns, and  
34 other outbuildings). There is also a standing silo made from ceramic bricks. Further examination  
35 of the silo revealed manufacturing information at the base of the structure indicating that it was a  
36 NATCO Imperishable Silo, patented by the National Fire Proofing Company of Pittsburgh,  
37 Pennsylvania. The National Fire Proofing Company was purportedly established in 1889;  
38 however, financial records put the date of establishment closer to 1902 (University of Melbourne  
39 Undated). NATCO's imperishable silo is constructed of curved, hollowed blocks in which the  
40 courses are staggered (University of Melbourne Undated). This dates the silo to the first quarter  
41 of the 20<sup>th</sup> century. As a result of this discovery, AmerGen submitted a Pennsylvania  
42 Archaeological Site Survey Form along with photographs to the PHMC and the site was  
43 assigned State number 36Da235.

## Affected Environment

1 Another potential historic site on Three Mile Island is TMI Unit 2. On March 28, 1979, TMI Unit 2  
2 experienced a loss of coolant accident that resulted in a partial core meltdown, and is  
3 considered the nation's worst commercial nuclear accident (Walker 2004). Although the  
4 structure is under 40 years of age, it can be considered potentially eligible for listing on the  
5 National Register of Historic Places under Criterion A, as a site of exceptional importance. In  
6 1999, a historical marker was placed on Pennsylvania State Highway 441, commemorating the  
7 20<sup>th</sup> anniversary of the TMI Unit 2 accident (AmerGen 2008). All of the TMI Unit 2 buildings are  
8 standing and are currently in long-term monitored storage.  
9

### 10 **2.3 Related Federal and State Activities**

11 The NRC staff reviewed the possibility that activities of other Federal agencies might impact the  
12 renewal of the operating license for TMI-1. Any such activity could result in cumulative  
13 environmental impacts and the possible need for a Federal agency to become a cooperating  
14 agency in the preparation of the TMI-1 SEIS.

15 The NRC staff has determined that there are no Federal projects that would make it desirable  
16 for another Federal agency to become a cooperating agency in the preparation of the SEIS.  
17 Federal facilities and National Parks within 50 mi (80 km) of TMI-1 are listed below. There are  
18 no known American Indian lands within 50 mi (80 km) of TMI-1.

- 19 • Fort Indiantown Gap Military Reservation, Annville (closed)
- 20 • Blue Marsh Lake (U.S. Army Corps of Engineers)
- 21 • New Cumberland General Depot (U.S. Military Reservation)
- 22 • Mechanicsburg Naval Ship Parts Control Center
- 23 • Letterkenny Army Depot
- 24 • Gettysburg National Military Park
- 25 • Eisenhower National Historic Site
- 26 • Fort Ritchie Raven Rock Site
- 27 • U.S. Army Chemical Center
- 28 • Appalachian National Scenic Trail (various areas)

29  
30 NRC is required under Section 102(2)(c) of the National Environmental Policy Act of 1969  
31 (NEPA) to consult with and obtain the comments of any Federal agency that has jurisdiction by  
32 law or special expertise with respect to any environmental impact involved. NRC has consulted  
33 with the American Council on Historic Preservation and the U.S. Fish and Wildlife Service.  
34 Federal Agency consultation correspondence and comments on the SEIS are presented in  
35 Appendix D.  
36

### 37 **2.4 References**

38 10 CFR 20. *Code of Federal Regulations*, Title 10, *Energy*, Part 20, "Standards for Protection  
39 Against Radiation."

- 1 10 CFR 50. *Code of Federal Regulations*, Title 10, *Energy*, Part 50, “Domestic Licensing of  
2 Production and Utilization Facilities.”
- 3 10 CFR 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, “Requirements for Renewal  
4 of Operating Licenses for Nuclear Power Plants.”
- 5 10 CFR 61. *Code of Federal Regulations*, Title 10, *Energy*, Part 61, “Licensing Requirements for  
6 Land Disposal of Radioactive Waste.”
- 7 10 CFR 71. *Code of Federal Regulations*, Title 10, *Energy*, Part 71, “Packaging and  
8 Transportation of Radioactive Material.”
- 9 10 CFR 100. *Code of Federal Regulations*, Title 10, *Energy*, Part 100, “Reactor Site Criteria.”
- 10 25 PA Code VII § 262. *Pennsylvania Code*, Title 25, *Environmental Protection*, Article VII,  
11 *Hazardous Waste Management*, Section 262a, “Standards Applicable to Generators of  
12 Hazardous Waste.”
- 13 25 PA Code VIII. *Pennsylvania Code*, Title 25, *Environmental Protection*, Article VIII, *Municipal*  
14 *Waste*.
- 15 25 PA Code IX. *Pennsylvania Code*, Title 25, *Environmental Protection*, Article IX, *Residual*  
16 *Waste*.
- 17 40 CFR 81. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 81,  
18 “Designation of Areas for Air Quality Planning Purposes.”
- 19 40 CFR 190. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 190,  
20 “Environmental Radiation Protection Standards for Nuclear Power Operations.”
- 21 40 CFR Part 261. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 261,  
22 “Identification and Listing of Hazardous Waste.”
- 23 40 CFR 262. *Code of Federal Regulations*. Title 40, *Protection of Environment*, Part 262,  
24 “Standards Applicable to Generators of Hazardous Waste.”
- 25 40 CFR 266. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 266,  
26 “Storage, Treatment, Transportation, and Disposal of Mixed-Waste.”
- 27 40 CFR Part 273. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 273,  
28 “Standards for Universal Waste Management.”
- 29 72 FR 37346, U.S. Fish and Wildlife Service. “Endangered and threatened wildlife and plants;  
30 removing the bald eagle in the lower 48 States from the list of endangered and threatened  
31 wildlife.” *Federal Register*: Volume 72, No. 130, pp. 37346–37372. July 9, 2007.
- 32 Adovasio and Johnson (Adovasio, James and William C. Johnson). 1981. “The Appearance of  
33 Cultigens in the Upper Ohio Valley: A View from Meadowcroft Rockshelter.” *Pennsylvania*  
34 *Archaeologist*. Vol. 51 (1-2): pp. 63-80.
- 35 AEC (U.S. Atomic Energy Commission). 1972. *Final Environmental Statement related to the*  
36 *operation of Three Mile Island Nuclear Station, Units 1 and 2. Metropolitan Edison Company, et*

## Affected Environment

- 1 *al. Docket Nos. 50-289 and 50-320*. Directorate of Licensing. December. Washington, D.C.  
2 ADAMS No. ML080090250.
- 3 Alliance for the Chesapeake Bay. 2007. "Zebra Mussels Found in Pennsylvania Lake on  
4 Cowanesque River Near NY." *Chesapeake Bay Journal*. (September 2007). Available URL:  
5 <http://www.bayjournal.com/article.cfm?article=3149> (accessed June 12, 2008). ADAMS No.  
6 ML082381094.
- 7 AmerGen (AmerGen Energy Company, LLC). 2004. *Three Mile Island 2003 Annual Report,*  
8 *Record of Well Pumpage and Water Levels. Susquehanna River Basin Commission Permit No.*  
9 *19961102*. Middletown, PA. ADAMS No. ML082880148.
- 10 AmerGen (AmerGen Energy Company, LLC). 2004a. *Three Mile Island Nuclear Station Unit 1*  
11 *and Unit 2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket*  
12 *Nos. 50-289 and 50-320. Radiological Environmental Monitoring Program Report, 1 January*  
13 *through 31 December 2003*. Middletown, PA. ADAMS No. ML041250580.
- 14 AmerGen (AmerGen Energy Company, LLC). 2004b. *Three Mile Island Nuclear Station Unit 1*  
15 *and Unit 2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket*  
16 *Nos. 50-289 and 50-320. Combined 2003 Annual Radioactive Effluent Release Report.*  
17 Middletown, PA. ADAMS No. ML041180052.
- 18 AmerGen (AmerGen Energy Company, LLC). 2005. *Three Mile Island 2004 Annual Report,*  
19 *Record of Well Pumpage and Water Levels. Susquehanna River Basin Commission Permit No.*  
20 *19961102*. Middletown, PA. ADAMS No. ML082880148.
- 21 AmerGen (AmerGen Energy Company, LLC). 2005a. *Three Mile Island Nuclear Station Unit 1*  
22 *and Unit 2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket*  
23 *Nos. 50-289 and 50-320. Radiological Environmental Monitoring Program Report. 1 January*  
24 *through 31 December 2004*. Middletown, PA. ADAMS No. ML051260258.
- 25 AmerGen (AmerGen Energy Company, LLC). 2005b. *Three Mile Island Nuclear Station Unit 1*  
26 *and Unit 2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket*  
27 *Nos. 50-289 and 50-320. Combined 2004 Annual Radioactive Effluent Release Report.*  
28 Middletown, PA. ADAMS No. ML051260269.
- 29 AmerGen (AmerGen Energy Company, LLC). 2006. *Annual Report on the Meteorological*  
30 *Monitoring Program at the Three Mile Island Generating Station 2006*. Middletown, PA. ADAMS  
31 No. ML082110253.
- 32 AmerGen (AmerGen Energy Company, LLC). 2006a. *Three Mile Island Nuclear Station Unit-1*  
33 *and Unit-2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket*  
34 *Nos. 50-289 and 50-320. Updated Final Safety Analysis Report*. Middletown, PA. ADAMS No.  
35 ML080800161.
- 36 AmerGen (AmerGen Energy Company, LLC). 2006b. *Three Mile Island Nuclear Station Unit-1*  
37 *and Unit-2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket*  
38 *Nos. 50-289 and 50-320. Combined 2005 Annual Radioactive Effluent Release Report.*  
39 Middletown, PA. ADAMS No. ML061230244.



- 1 AmerGen (AmerGen Energy Company, LLC). 2006c. *Three Mile Island Nuclear Station Unit-1*  
2 *and Unit-2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket*  
3 *Nos. 50-289 and 50-320. Radiological Environmental Monitoring Program Report, 1 January*  
4 *through 31 December 2005.* Middletown, PA. ADAMS No. ML061220487.
- 5 AmerGen (AmerGen Energy Company, LLC). 2006d. *Three Mile Island Nuclear Station State*  
6 *Only Operating Permit for Synthetic Minor Facility: State Only Permit No: 22-05029,* Issued by  
7 Pennsylvania Department of Environmental Protection. December 22. Middletown, PA. ADAMS  
8 No. ML082110253.
- 9 AmerGen (AmerGen Energy Company, LLC). 2006e. *Three Mile Island 2005 Annual Report,*  
10 *Record of Well Pumpage and Water Levels. Susquehanna River Basin Commission Permit No.*  
11 *19961102.* ADAMS No. ML082880148.
- 12 AmerGen (AmerGen Energy Company, LLC). 2007. *Three Mile Island Nuclear Station Units 1*  
13 *and 2 Annual Radiological Environmental Operating Report, 1 January Through December*  
14 *2006,* Appendix F, "Annual Radiological Ground Water Protection Program Report, 1 January  
15 Through December 2006." April. Middletown, PA. ADAMS No. ML081980698.
- 16 AmerGen (AmerGen Energy Company, LLC). 2007a. *Three Mile Island Nuclear Station Unit 1*  
17 *and Unit 2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket*  
18 *Nos. 50-289 and 50-320. Combined 2006 Annual Radioactive Effluent Release Report (ODCM*  
19 *Revision 25 Enclosed).* Middletown, PA. ADAMS No. ML071290369.
- 20 AmerGen (AmerGen Energy Company, LLC). 2007b. *Three Mile Island Nuclear Station Unit 1*  
21 *and Unit 2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket*  
22 *Nos. 50-289 and 50-320. Radiological Environmental Monitoring Program Report, 1 January*  
23 *through 31 December 2006.* Middletown, PA. ADAMS No. ML071290163.
- 24 AmerGen (AmerGen Energy Company, LLC). 2007c. "Automatic Temperature Monitoring Data  
25 for TMI-1 Intake Screen Pumphouse and Discharge Monitoring Pit." Middletown, PA. ADAMS  
26 No. ML081980678.
- 27 AmerGen (AmerGen Energy Company, LLC). 2008. *Three Mile Island Nuclear Station, Unit 1,*  
28 *Applicant's Environmental Report, License Renewal Operating Stage.* ADAMS Nos.  
29 ML080220255, ML080220257, ML080220261, and ML080220282.
- 30 AmerGen (AmerGen Energy Company, LLC). 2008a. *Three Mile Island Nuclear Station Unit 1*  
31 *and Unit 2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket*  
32 *Nos. 50-289 and 50-320. Radiological Environmental Monitoring Program Report, 1 January*  
33 *through 31 December 2007.* Middletown, PA. ADAMS No. ML081300255.
- 34 AmerGen (AmerGen Energy Company, LLC). 2008b. *Three Mile Island Nuclear Station Unit 1*  
35 *and Unit 2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket*  
36 *Nos. 50-289 and 50-320. Combined 2007 Annual Radioactive Effluent Release Report.*  
37 Middletown, PA. ADAMS No. ML081300410.
- 38 AmerGen (AmerGen Energy Company, LLC). 2008c. *Three Mile Island Generating Station, Unit*  
39 *1, License Renewal Application.* Kennett Square, PA. ADAMS No. ML080220207.

## Affected Environment

- 1 AmerGen (AmerGen Energy Company, LLC). 2008d. *Three Mile Island, Unit 1, Enclosure A -*  
2 *Post Audit Environmental Information – Index Through Audit Question ENV-070, Monthly*  
3 *Report on the Meteorological Monitoring Program, February 2007 (Non-Proprietary Version).*  
4 June 10. ADAMS No. ML082110252.
- 5 Audubon Society. 2008. "Prothonotary Warbler." Available URL:  
6 <http://audubon2.org/watchlist/viewSpecies.jsp?id=165> (accessed June 4, 2008). ADAMS No.  
7 ML082880486.
- 8 Carr, K.W. 1998. "The Early Archaic Period in Pennsylvania." *Pennsylvania Archaeologist*. Vol.  
9 68. Issue 2, pp. 42-69.
- 10 Center for Workforce Information and Analysis. 2008. "Pennsylvania Department of Labor and  
11 Industry, Harrisburg, Pennsylvania." Available URL: <http://www.paworkstats.state.pa.us>  
12 (accessed September 12, 2008). ADAMS No. ML082880507.
- 13 CBP (Chesapeake Bay Program). 2008. "American Shad Management and Restoration."  
14 Available URL:  
15 <http://www.chesapeakebay.net/americanshadmanagement.aspx?menuitem=14771> (accessed  
16 July 18, 2008). ADAMS No. ML082381098.
- 17 *Clean Air Act*. 42 U.S.C. 7401, et seq. *United States Code*, Title 42, *The Public Health and*  
18 *Welfare*, Chapter 85, "Air Pollution Prevention and Control."
- 19 Conestoga-Rovers (Conestoga-Rovers & Associates). 2006. *Hydrogeologic Investigation*  
20 *Report, Fleetwide Assessment, Three Mile Island Generating Station, Middletown,*  
21 *Pennsylvania*. September. ADAMS Nos. ML081980689, ML081980691, ML081980692.
- 22 Conestoga-Rovers (Conestoga-Rovers & Associates). 2007. *Estimated Mass Flux of Tritiated*  
23 *Groundwater to the Susquehanna River, Three Mile Island Generating Station, Middletown,*  
24 *Pennsylvania*. October. ADAMS No. ML081980693.
- 25 Cornell (Cornell Lab of Ornithology). 2003. "Peregrine Falcon." Available URL:  
26 [http://www.birds.cornell.edu/AllAboutBirds/BirdGuide/Peregrine\\_Falcon\\_dtl.html](http://www.birds.cornell.edu/AllAboutBirds/BirdGuide/Peregrine_Falcon_dtl.html) (accessed June  
27 6, 2008). Accessible at ML073300303.
- 28 Cowin, Verna. 1985. "The Woodland Period." A Comprehensive State Plan for the Conservation  
29 of Archaeological Resources. Volume II. pp. 185-193. Edited by P. Raber. Pennsylvania  
30 Historical and Museum Commission. Harrisburg, PA.
- 31 CWA (*Clean Water Act; or Federal Water Pollution Control Act*). 33 U.S.C. 1251 et seq.
- 32 Dauphin County (Dauphin County Planning Commission). 2008. *Dauphin County*  
33 *Comprehensive Plan*. Available URL: <http://www.tcrpc-pa.org/dccomplan.htm> (accessed  
34 September 4, 2008). ADAMS No. ML082880507.
- 35 DCNR (Pennsylvania Department of Conservation and Natural Resources). 2008. "Gettysburg-  
36 Newark Lowland Section Piedmont Province." Available URL:

- 1 <http://www.dcnr.state.pa.us/topogeo/map13/13gnls.aspx> (accessed on September 23, 2008).  
2 ADAMS No. ML082880546.
- 3 DCNR (Pennsylvania Department of Conservation and Natural Resources). 2008a. Letter from  
4 R. Bowen, Environmental Review Specials, Pennsylvania Department of Conservation and  
5 Natural Resources, to L. Lund, Branch Chief, Division of License Renewal, Nuclear Regulatory  
6 Commission. Subject: Pennsylvania Natural Diversity Inventory Review, PNDI Number 19605,  
7 Three Mile Island Unit 1 License Renewal Species of Special Concern, Dauphin & Lancaster  
8 Counties." May 2, 2008. ADAMS No. ML081300048.
- 9 Durlin, R.R. and W.P. Schaffstall. 2005. *Water Resources Data Pennsylvania Water Year 2004,*  
10 *Water-Data Report PA-04-2.* U.S. Geological Survey. May. New Cumberland, PA. ADAMS No.  
11 ML081980705.
- 12 EPA (U.S. Environmental Protection Agency). 2000. *RCRA, Superfund & EPCRA Hotline*  
13 *Training Module. Introduction to: RCRA Statutory Overview.* EPA530-5-99-063. February.  
14 Available URL: <http://www.epa.gov/osw/inforesources/pubs/hotline/training/enforc.pdf> (accessed  
15 August 28, 2008). ADAMS No. ML082880301.
- 16 EPA (U.S. Environmental Protection Agency). 2007. *Hazardous Waste Generators Regulations.*  
17 May. Available URL: <http://www.epa.gov/osw/hazard/downloads/tool.pdf> (accessed October 14,  
18 2008). ADAMS No. ML082880301.
- 19 EPA (U.S. Environmental Protection Agency). 2007a. "Wastes – Laws and Regulations".  
20 Available URL: <http://www.epa.gov/osw/laws-regs/index.htm> (accessed August 28, 2008).  
21 ADAMS No. ML082880301.
- 22 EPA (U.S. Environmental Protection Agency). 2008. "Environmental Management Systems  
23 (EMS)." Available URL: <http://www.epa.gov/ems/index.html> (accessed August 28, 2008).  
24 ADAMS No. ML082880301.
- 25 EPA (U.S. Environmental Protection Agency). 2008a. "EPA EnviroFacts Warehouse – Facility  
26 Detail Report – AmerGen Energy Three Mile Island Nuclear Station." Available URL:  
27 [http://oaspub.epa.gov/enviro/fii\\_query\\_dtl\\_disp\\_program\\_facility?pgm\\_sys\\_id\\_in=PAR00003786](http://oaspub.epa.gov/enviro/fii_query_dtl_disp_program_facility?pgm_sys_id_in=PAR00003786)  
28 [1&pgm\\_sys\\_acrn\\_in=RCRAINFO](http://oaspub.epa.gov/enviro/fii_query_dtl_disp_program_facility?pgm_sys_id_in=PAR00003786) (accessed August 28, 2008). ADAMS No. ML082880301.
- 29 EPA (U.S. Environmental Protection Agency). 2008b. "Pollution Prevention Information  
30 Clearinghouse (PPIC)." Available URL: <http://www.epa.gov/oppt/ppic/> (accessed August 28,  
31 2008). ADAMS No. ML082880301.
- 32 EPA (U.S. Environmental protection Agency). 2008c. "Local Drinking Water Information,  
33 Pennsylvania Drinking Water, Envirofacts Data on Pennsylvania, County Search – Dauphin and  
34 Lancaster Counties – April 15, 2008." Searchable database. Available URL:  
35 [http://oaspub.epa.gov/enviro/sdw\\_form\\_v2.create\\_page?state\\_abbr=PA](http://oaspub.epa.gov/enviro/sdw_form_v2.create_page?state_abbr=PA) (accessed September  
36 2008).
- 37 ESA (*Endangered Species Act*). 16 U.S.C. 1531, et seq.

## Affected Environment

- 1 Exelon (Exelon Corporation, Inc.). 2007. *TMI Radiological Groundwater Protection Program*  
2 *(RGPP) Sample Point Data and Standard Control Limits*. CY-TM-170-400. December 16.
- 3 Fike, J. 1999. *Terrestrial and Palustrine Plant Communities of Pennsylvania*. Pennsylvania  
4 Natural Diversity Inventory. Chapter 8: Herbaceous Wetlands. Pennsylvania Natural Diversity  
5 Inventory. Available URL: <http://www.dcnr.state.pa.us/wrcf/fikebook/21chapter8.pdf> (accessed  
6 June 3, 2008). ADAMS No. ML082880541.
- 7 FirstEnergy (FirstEnergy Forest Services). 2007. *First Energy Vegetation Management*  
8 *Specifications*. ADAMS No. ML082110252.
- 9 FirstEnergy (FirstEnergy Forest Services). 2008. *Vegetation Control with Herbicides*. ADAMS  
10 No. ML082110252.
- 11 Funk, R.E. (Funk). 1972. "Early Man in the Northeast and Late Glacial Environment." *Man in the*  
12 *Northeast*. Vol. 4, pp. 7–39.
- 13 FWS (U.S. Fish and Wildlife Service). 2008. Letter from D. Densmore, Supervisor, U.S. Fish  
14 and Wildlife Service, Pennsylvania Field Office, to L. Lund, Branch Chief, Division of License  
15 Renewal, Nuclear Regulatory Commission. Subject: Three Mile Island Nuclear Station, Unit 1,  
16 License Renewal Application Review. April 23, 2008. ADAMS No. ML081280307.
- 17 FWS (U.S. Fish and Wildlife Service). 2008a. "Osprey: *Pandion haliaetus*." Available URL:  
18 <http://www.fws.gov/chesapeakebay/osprey.htm> (accessed June 5, 2008). Accessible at  
19 ML082880486.
- 20 Harman, W.N. and E. Underwood. 2008. *Survey of the Pearly Freshwater Mussels*  
21 *(Unionidae:Bivalvia) of the Susquehanna River in a reach between Exits 14 and 15 of Interstate*  
22 *88, Oneonta, NY*. State University of New York, College at Oneonta. Available URL:  
23 <http://www.oneonta.edu/academics/biofld/PUBS/ANNUAL/2007/Susquehanna%20DOT%20mus>  
24 [sel%20report%20for%20BFS%20AR.pdf](http://www.oneonta.edu/academics/biofld/PUBS/ANNUAL/2007/Susquehanna%20DOT%20mus) (accessed July 22, 2008). ADAMS No. ML082381099.
- 25 Harrisburg Websites. Undated. "Dauphin County History." Available URL:  
26 [http://www.harrisburgwebsites.com/Publications/Dauphin\\_County\\_History.htm](http://www.harrisburgwebsites.com/Publications/Dauphin_County_History.htm) (accessed on  
27 September 29, 2008). ADAMS No. ML082880526.
- 28 Hilty, J. 2006a. "Aunt Lucy." Available URL:  
29 [http://www.illinoiswildflowers.info/woodland/plants/aunt\\_lucy.htm](http://www.illinoiswildflowers.info/woodland/plants/aunt_lucy.htm) (accessed June 3, 2008).  
30 Accessible at ML082880486.
- 31 Hilty, J. 2006b. "Flat-Stemmed Spike Rush." Available URL:  
32 [http://www.illinoiswildflowers.info/grasses/plants/fs\\_spikerush.htm](http://www.illinoiswildflowers.info/grasses/plants/fs_spikerush.htm) (accessed June 3, 2008).  
33 Accessible at ML082880486.
- 34 Huber, Elaine. 1982. "Three Mile Island Had a Sometime Stormy Past." *Lancaster Sunday*  
35 *News*. (July 4, 1982). ADAMS No. ML082110252.

- 1 Ichthyological Associates, Inc. 1975. *An Ecological Study of the Susquehanna River Near the*  
2 *Three Mile Island Nuclear Station - Annual Report for 1974*. February. Etters, PA. ADAMS No.  
3 ML082381102.
- 4 Ichthyological Associates, Inc. 1976. *An Ecological Study of the Susquehanna River Near the*  
5 *Three Mile Island Nuclear Station - Annual Report for 1975*. February. Etters, PA. ADAMS No.  
6 ML082381103.
- 7 Ichthyological Associates, Inc. 1983. *An Ecological Study of the Susquehanna River Near the*  
8 *Three Mile Island Nuclear Station - Annual Report for 1982*. April. Etters, PA. ADAMS No.  
9 ML081980679.
- 10 Institute of Educational Science (IES). 2008. U.S. Department of Education. National Center for  
11 Educational Statistics. "College Opportunities Online Locator." Zip Code 17057. Available online  
12 at <http://nces.ed.gov/ipeds/cool/RefineSearch.aspx> (accessed September 9, 2008).
- 13 Johnson, J.H. and D.S. Dropkin. 1992. "Predation on Recently Released Larval American Shad  
14 in the Susquehanna River Basin." *North American Journal of Fisheries Management* 12(3):504-  
15 508. ADAMS No. ML082381104.
- 16 Kapsch, Robert J. 2004. *Canals*. W.W. Norton & Company. U.S. p. 310.
- 17 Kent et al. (Kent, Barry C., Ira F. Smith III, and Catherine McCann eds.) 1971. *Foundations of*  
18 *Pennsylvania Prehistory*. *Pennsylvania Historical and Museum Commission Anthropological*  
19 *Series, #1*. Harrisburg, PA.
- 20 Lancaster County (Lancaster County Planning Commission). 2006. "The Growth Management  
21 Element of The Comprehensive Plan for Lancaster County, Pennsylvania prepared by the  
22 Lancaster County Planning Commission and Lancaster County Growth Management Update  
23 Task Force." April. Available URL:  
24 [www.co.lancaster.pa.us/planning/lib/planning/balance\\_full\\_report.pdf](http://www.co.lancaster.pa.us/planning/lib/planning/balance_full_report.pdf) (accessed October 5,  
25 2006). ADAMS No. ML082880507.
- 26 Londonderry Township. Undated. "Londonderry Township Historical Society." Available URL:  
27 <http://www.londonderry.org/history.php> (accessed on September 30, 2008). ADAMS No.  
28 ML082880526.
- 29 Lebanon County. 2005. "Union Canal of Pennsylvania." Available URL:  
30 [http://dsf.pacounties.org/lebanon/cwp/view.asp?A=3&QUESTION\\_ID=479797](http://dsf.pacounties.org/lebanon/cwp/view.asp?A=3&QUESTION_ID=479797) (accessed on  
31 September 30, 2008). ADAMS No. ML082880526.
- 32 McNally, B. 2008. "Small Times on the Susquehanna". Available URL:  
33 <http://www.boats.com/news-reviews/articledetail.html?lid=2284> (accessed July 10, 2008).  
34 ADAMS No. ML082880347.
- 35 The Native Fish Conservancy. 2008. "Migratory Fish Restoration and Passage on the  
36 Susquehanna River." Available URL:

## Affected Environment

- 1 [http://www.nativefish.org/articles/Migratory\\_Fish\\_Restoration.php](http://www.nativefish.org/articles/Migratory_Fish_Restoration.php) (accessed June 10, 2008).  
2 ADAMS No. ML082381108.
- 3 NCDC (National Climate Data Center). 2008. Comparative Climatic Data. Available URL:  
4 <http://www.ncdc.noaa.gov/oa/climate/online/ccd/avgwind.html> (accessed June 10, 2008).  
5 ADAMS No. ML082880549.
- 6 NCDC (National Climate Data Center). 2008a. "Storm Events." Searchable database. Available  
7 URL: <http://www4.ncdc.noaa.gov/cgi-win/wwcgi.dll?wwevent~storms> (accessed June 12, 2008).
- 8 NCDC (National Climate Data Center). 2008b. "Storm Events: Dauphin County, PA most  
9 destructive tornado event." Available URL: [http://www4.ncdc.noaa.gov/cgi-](http://www4.ncdc.noaa.gov/cgi-win/wwcgi.dll?wwevent~ShowEvent~135093)  
10 [win/wwcgi.dll?wwevent~ShowEvent~135093](http://www4.ncdc.noaa.gov/cgi-win/wwcgi.dll?wwevent~ShowEvent~135093) (accessed June 12, 2008). ADAMS No.  
11 ML082880549.
- 12 NEPA (*National Environmental Policy Act of 1969*). 42 U.S.C. 4321, et seq.
- 13 NOAA (National Oceanic and Atmospheric Administration). Undated. "Guide to Essential Fish  
14 Habitat Designations in the Northeastern United States." Available URL:  
15 <http://www.nero.noaa.gov/hcd/est.htm#MARYLAND> (accessed June 19, 2008). ADAMS No.  
16 ML082380111.
- 17 Normandeau (Normandeau Associates, Inc.). 2007. *Summary of Environmental Studies Near*  
18 *the Three Mile Island Nuclear Station*. October. Drumore, PA. ADAMS No. ML081980680.
- 19 NRC (U.S. Nuclear Regulatory Commission). 1976. *NUREG-0112. Final Supplement to the*  
20 *Final Environmental Statement Related to the Operation of Three Mile Island Nuclear Station,*  
21 *Unit 2, Metropolitan Edison Company et al., Docket No. 50-320*. Office of Nuclear Reactor  
22 Regulation, Washington, D.C. December. ADAMS No. ML080090250.
- 23 NRC (U.S. Nuclear Regulatory Commission). 1988. *Issuance of Amendment No. 143 to Facility*  
24 *Operating License No. DPR-50 for the Three Mile Island Nuclear Station, Unit No. 1.*  
25 Washington, D.C. ADAMS No. ML003779786.
- 26 NRC (U.S. Nuclear Regulatory Commission). 1990. *Overview and Comparison of U.S*  
27 *Commercial Nuclear Power Plant, Nuclear Power Plant System Source*. NUREG/CR-5640.  
28 Washington, D.C.
- 29 NRC (U.S. Nuclear Regulatory Commission). 1996. *Generic Environmental Impact Statement*  
30 *for License Renewal of Nuclear Plants*. NUREG-1437, Volumes 1 and 2, Washington, D.C.  
31 ADAMS No. ML061770605.
- 32 NRC (U.S. Nuclear Regulatory Commission). 1999. *Generic Environmental Impact Statement*  
33 *for License Renewal of Nuclear Plants, Main Report*, "Section 6.3 – Transportation, Table 9.1,  
34 Summary of findings on NEPA issues for license renewal of nuclear power plants, Final Report."  
35 NUREG-1437, Volume 1, Addendum 1, Washington, D.C.
- 36 PADEP (Pennsylvania Department of Environmental Protection). 2001. "Overview of EPA's  
37 Final Rule on Storage, Treatment, Transportation and Disposal of Mixed Waste." Available URL:



- 1 [http://www.dep.state.pa.us/dep/subject/advcoun/llrw/2001/OverviewEPAFinalRuleMixedWaste.p](http://www.dep.state.pa.us/dep/subject/advcoun/llrw/2001/OverviewEPAFinalRuleMixedWaste.pdf)  
2 [df](http://www.dep.state.pa.us/dep/subject/advcoun/llrw/2001/OverviewEPAFinalRuleMixedWaste.pdf) (accessed July 15, 2008). ADAMS No. ML082880301.
- 3 PADEP (Pennsylvania Department of Environmental Protection). 2004. *Pennsylvania Air Quality*  
4 *Monitoring 2004 Annual Report*. Division of Air Quality Monitoring. Harrisburg, PA. Available  
5 URL: <http://www.dep.state.pa.us/dep/deputate/airwaste/aq/aqm/aqreport/2004aqreport.pdf>  
6 (accessed August 16, 2008). ADAMS No. ML082880549.
- 7 PADEP (Pennsylvania Department of Environmental Protection). 2008. "eMapPA." Searchable  
8 database. Available URL: <http://www.emappa.dep.state.pa.us/emappa/viewer.htm> (accessed  
9 October 14, 2008).
- 10 PADEP (Pennsylvania Department of Environmental Protection). 2008a. "Survey Information.  
11 Water Supply Data for Dauphin and Lancaster Counties." Searchable database. Available URL:  
12 [www.drinkingwater.state.pa.us/dwrs/HTM/DEP\\_frm.html](http://www.drinkingwater.state.pa.us/dwrs/HTM/DEP_frm.html) (accessed September 9, 2008).
- 13 PDE (Pennsylvania Department of Education). 2004. Map of Pennsylvania School Districts and  
14 Intermediate Unit 15. March. Available URL:  
15 [http://www.dot.state.pa.us/Internet/Bureaus/pdPlanRes.nsf/infoBPR\\_Education\\_PA\\_Intermediat](http://www.dot.state.pa.us/Internet/Bureaus/pdPlanRes.nsf/infoBPR_Education_PA_Intermediate_unit)  
16 [e\\_unit](http://www.dot.state.pa.us/Internet/Bureaus/pdPlanRes.nsf/infoBPR_Education_PA_Intermediate_unit) (accessed September 9, 2008). ADAMS No. ML082880507.
- 17 PDE (Pennsylvania Department of Education). 2007a. "Public School Enrollments by County,  
18 LEA, School, Grade and Gender Workbook 2006-2007." Excel database. July 12. Available  
19 URL: <http://www.pde.state.pa.us/k12statistics/lib/k12statistics/0607PubEnrCtySchGraGen.xls>.  
20 (accessed September 9, 2008).
- 21 PDE (Pennsylvania Department of Education). 2007b. "Public, Private and Nonpublic Schools  
22 Enrollments 2006-07." August. Available URL:  
23 <http://www.pde.state.pa.us/k12statistics/cwp/view.asp?a=3&q=129090> (accessed September 9,  
24 2008). ADAMS No. ML082880507.
- 25 PennDOT (Pennsylvania Department of Transportation). 2008. "2006 Traffic Volume Map –  
26 Dauphin County." Searchable database. Available URL:  
27 <http://www.dot.state.pa.us/Internet/Bureaus/pdPlanRes.nsf/infoBPRTrafficInfoTrafficVolumeMap>  
28 (accessed September 9, 2008). ADAMS No. ML082880507.
- 29 Pennsylvania Sea Grant. 2008. "Aquatic Invasive Species of Pennsylvania. Asiatic Clam."  
30 Available URL: <http://www.pserie.psu.edu/seagrant/ais/watershed/clam.htm> (accessed June 11,  
31 2008). ADAMS No. ML082381162.
- 32 Pennsylvania Sea Grant. 2008a. "Aquatic Invasive Species of Pennsylvania. Zebra  
33 Mussel/Quagga Mussel." Available URL:  
34 <http://www.pserie.psu.edu/seagrant/ais/watershed/mussel.htm> (accessed June 11, 2008).  
35 ADAMS No. ML082381267.
- 36 Pennsylvania Sea Grant. 2008b. "Pennsylvania Zebra and Quagga Mussel Monitoring  
37 Network." Available URL: <http://seagrant.psu.edu/zm/index.htm> (accessed July 22, 2008).  
38 ADAMS No. ML082381268.

## Affected Environment

- 1 Pennsylvania State Data Center. 2008. *The Pennsylvania Bulletin – Pennsylvania State Data*  
2 *Center; Pennsylvania Population Projections; Public Review* [38 Pa.B. 1415] [Saturday, March  
3 22, 2008] “Pennsylvania Preliminary Population Projections: 2000–2030.” February. Available  
4 URL: <http://www.pabulletin.com/secure/data/vol38/38-12/524.html> (accessed September 9,  
5 2008). ADAMS No. ML082880507.
- 6 PFBC (Pennsylvania Fish and Boat Commission). Undated. *Commercial Shad Landings*.  
7 Available URL: <http://www.fish.state.pa.us/education/whereshaddata.pdf> (accessed June 10,  
8 2008). ADAMS No. ML082381111.
- 9 PFBC (Pennsylvania Fish and Boat Commission). 2008. “Biologist Reports, Susquehanna River  
10 Smallmouth Bass, Lancaster/York County.” Available URL:  
11 [http://www.fish.state.pa.us/images/fisheries/afm/2006/6x11\\_13accomac.htm](http://www.fish.state.pa.us/images/fisheries/afm/2006/6x11_13accomac.htm) (accessed June  
12 11, 2008). ADAMS No. ML082381114.
- 13 PFBC (Pennsylvania Fish and Boat Commission). 2008a. “Susquehanna River American Shad.”  
14 Available URL: ([http://www.fish.state.pa.us/shad\\_susq.htm](http://www.fish.state.pa.us/shad_susq.htm) (accessed June 11, 2008). ADAMS  
15 No. ML082381115.
- 16 PFBC (Pennsylvania Fish and Boat Commission). 2008b. *PA Stream Sections that Support*  
17 *Natural Reproduction of Trout*. Available URL: [http://www.fish.state.pa.us/trout\\_repro.pdf](http://www.fish.state.pa.us/trout_repro.pdf)  
18 (accessed June 11, 2008). ADAMS No. ML082381116.
- 19 PFBC (Pennsylvania Fish and Boat Commission). 2008c. *Susquehanna River Drainage YOY*  
20 *Smallmouth Bass Disease Investigations 2005 and 2007*. Available URL:  
21 [http://www.fish.state.pa.us/pafish/bass\\_black/meetings/fish\\_committee2007sep/mortality07\\_05.](http://www.fish.state.pa.us/pafish/bass_black/meetings/fish_committee2007sep/mortality07_05.pdf?bcsi_scan_B666A1DE717DB577=0&bcsi_scan_filename=mortality07_05.pdf)  
22 [pdf?bcsi\\_scan\\_B666A1DE717DB577=0&bcsi\\_scan\\_filename=mortality07\\_05.pdf](http://www.fish.state.pa.us/pafish/bass_black/meetings/fish_committee2007sep/mortality07_05.pdf?bcsi_scan_B666A1DE717DB577=0&bcsi_scan_filename=mortality07_05.pdf) (accessed  
23 June 3, 2008). ADAMS No. ML082880420.
- 24 PFBC (Pennsylvania Fish and Boat Commission). 2008d. Andrew Shiels—Personal  
25 communications. July 22, 2008. ADAMS No. ML082381123.
- 26 PFBC (Pennsylvania Fish and Boat Commission). 2008e. Michael Hendricks—Personal  
27 communications. July 22, 2008. ADAMS No. ML082381123.
- 28 PFBC (Pennsylvania Fish and Boat Commission). 2008f. “Historical WW/CW Species Stocking  
29 by County.” Available URL:  
30 [http://pfbc.state.pa.us/pfbc\\_webgis/WWCWStockingDetails\\_historical.aspx](http://pfbc.state.pa.us/pfbc_webgis/WWCWStockingDetails_historical.aspx) (accessed July 21,  
31 2008). ADAMS No. ML082381124.
- 32 PFBC (Pennsylvania Fish and Boat Commission). 2008g. “2008 Pennsylvania Fishing  
33 Summary, Summary of Fishing Regulations and Laws”. Available URL:  
34 <http://www.fish.state.pa.us/fishpub/summary/z00complete.pdf> (accessed July 23, 2008).  
35 ADAMS No. ML082880450.



- 1 PFBC (Pennsylvania Fish and Boat Commission). 2008h. Letter from C. Urban, Chief, Natural  
 2 Diversity Section, Pennsylvania Fish & Boat Commission, Bellefonte, Pennsylvania, to S.  
 3 Lopas, Nuclear Regulatory Commission, Rockville, Maryland. Subject: Species Impact Review  
 4 (SIR) – Rare, Candidate, Threatened and Endangered Species, Three Mile Island Nuclear  
 5 Station, Londonderry Township/Borough, Dauphin County, PA. June 3, 2008. ADAMS No.  
 6 ML081610104.
- 7 PGA (Pennsylvania General Assembly). Undated. “Pennsylvania on the Eve of Colonization.”  
 8 Available URL: [http://www.legis.state.pa.us/WU01/VC/visitor\\_info/pa\\_history/pa\\_history.htm](http://www.legis.state.pa.us/WU01/VC/visitor_info/pa_history/pa_history.htm)  
 9 (accessed on October 1, 2008). ADAMS No. ML082880526.
- 10 PGC (Pennsylvania Game Commission). 2006. “Peregrine Falcon.” Available URL:  
 11 <http://www.pgc.state.pa.us/pgc/cwp/view.asp?a=486&q=160961> (accessed June 6, 2008).  
 12 Accessible at ML073300495.
- 13 PGC (Pennsylvania Game Commission). 2008. Letter from J. Leigey, Division of Environmental  
 14 Planning and Habitat Protection, Bureau of Wildlife Habitat Management, to L. Lund, Branch  
 15 Chief, Division of License Renewal, Nuclear Regulatory Commission. Subject: State-Protected  
 16 Bird and Mammal Species Review, Three Mile Island Nuclear Station License Renewal  
 17 Application, Londonderry Township, Dauphin County, PA. May 14, 2008. ADAMS No.  
 18 ML081500671.
- 19 PHMC (Pennsylvania Historical and Museum Commission). Undated-a. “Pennsylvania on the  
 20 Eve of Colonization.” Available URL:  
 21 <http://www.phmc.state.pa.us/bah/pahist/colony.asp?secid=31> (accessed on October 1, 2008).  
 22 ADAMS No. ML082880526.
- 23 PHMC (Pennsylvania Historical and Museum Commission). Undated-b. “Harrisburg:  
 24 Pennsylvania’s Capital City.” Available URL:  
 25 <http://www.phmc.state.pa.us/ppet/harrisburg/page1.asp?secid=31> (accessed on September 29,  
 26 2008). ADAMS No. ML082880526.
- 27 PNHP (Pennsylvania Natural Heritage Program). 2008. “State Species List, Update June 2008.”  
 28 Available URL: <http://www.naturalheritage.state.pa.us/Homepage.aspx> (accessed July 14,  
 29 2008). ADAMS No. ML082381127.
- 30 PNHP (Pennsylvania Natural Heritage Program). 2008a. “Ellisia; waterpod (*Ellizia nycetelea*).”  
 31 Available URL: <http://www.naturalheritage.state.pa.us/factsheets/14002.pdf> (accessed June 3,  
 32 2008). Accessible at ML082880486.
- 33 PNHP (Pennsylvania Natural Heritage Program). 2008b. “Short’s Sedge (*Carex shortiana*).”  
 34 Available URL: <http://www.naturalheritage.state.pa.us/factsheets/15124.pdf> (accessed June 3,  
 35 2008). Accessible at ML082880486.

## Affected Environment

- 1 PSC (The Pennsylvania State Climatologist). 2008. "Regional climate data." Available URL:  
2 <http://climate.met.psu.edu/data/state/pareg.php> (accessed June 20, 2008). ADAMS No.  
3 ML082880549.
- 4 PSC (The Pennsylvania State Climatologist). 2008a. "Pennsylvania Climate Regions. Average  
5 temperature for the Climate Region 5 (1899 - 2006)." Available URL:  
6 <http://climate.met.psu.edu/data/state/divis/divsum05.php> (accessed July 3, 2008). ADAMS No.  
7 ML082880549.
- 8 PSC (The Pennsylvania State Climatologist). 2008b. Pennsylvania Climate Regions. Total  
9 yearly and seasonal precipitation for the Climate Division 5. Available URL:  
10 <http://climate.met.psu.edu/data/state/divis/divsum05.php> (accessed June 24, 2008). ADAMS  
11 No. ML082880549.
- 12 PSC (The Pennsylvania State Climatologist). 2008c. Pennsylvania Climate Regions. Total  
13 yearly and monthly snowfall for the Climate Division 5 (1950 - 2007). Available URL:  
14 <http://climate.met.psu.edu/data/state/divis/div05snow.php> (accessed June 24, 2008). ADAMS  
15 No. ML082880549.
- 16 Raber (Raber, Paul. ed.). 1985. *A Comprehensive State Plan for the Conservation of*  
17 *Archaeological Resources*. Vol. II. Pennsylvania Historical and Museum Commission.  
18 Harrisburg, PA.
- 19 RCRA (Resource Conservation and Recovery Act). 40 CFR Part 239, et seq.
- 20 RMC (RMC Environmental Services). 1991. *An Ecological Study of the Susquehanna River*  
21 *Near The Three Mile Island Nuclear Station, Annual Report for 1990*. March. Drumore, PA.  
22 ADAMS No. ML081980683.
- 23 Sadzinski, B. and Tony Jarzynski. Undated. "Shad School." Maryland Department of Natural  
24 Resources. Available URL: <http://dnr.md.gov/fisheries/education/shadschool.html> (accessed  
25 June 10, 2008). ADAMS No. ML082381161.
- 26 Smith III, Ira F. (Smith). 1977. *Early and Middle Woodland Campsites on Three Mile Island,*  
27 *Dauphin County, Pennsylvania*. Pennsylvania Historical and Museum Commission and  
28 Metropolitan Edison Company, Three Mile Island Nuclear Generating Station Project.  
29 Harrisburg, PA. January. Non-public reference per 37 Pa. C.S.A. § 506(c) and consultation with  
30 Pennsylvania Historical and Museum Commission.
- 31 SRBC (Susquehanna River Basin Commission). 1995. *GPU Nuclear Corporation. Three Mile*  
32 *Island Nuclear Station Unit 1, Application 199550302*. March. Harrisburg, PA. ADAMS No.  
33 ML081980711.
- 34 SRBC (Susquehanna River Basin Commission). 1996. Unpublished data. ADAMS No.  
35 ML082381269.
- 36 SRBC (Susquehanna River Basin Commission). 1999. *GPU Nuclear, Inc. Application 19961102*  
37 *(Revised)*. January. Harrisburg, PA. ADAMS No. ML081980709.

- 1 SRBC (Susquehanna River Basin Commission). 2005. Unpublished data. ADAMS No.  
2 ML082381269.
- 3 SRBC (Susquehanna River Basin Commission). 2006. *Susquehanna Large River Assessment*  
4 *Project. Publication 245*. August. ADAMS No. ML082381271.
- 5 SRBC (Susquehanna River Basin Commission). 2006a. *Lower Susquehanna Subbasin Survey:*  
6 *A Water Quality and Biological Assessment, June – November 2005. Publication 247*.  
7 September. ADAMS No. ML082381273.
- 8 SRBC (Susquehanna River Basin Commission). 2008. Susan Buda—Personal  
9 communications. ADAMS No. ML082381269.
- 10 USCB (U.S. Census Bureau). 2008. “American FactFinder, American Community Survey of  
11 Dauphin and Lancaster Counties, Data Profile Highlights. Housing Characteristics for 2000 and  
12 2006.” Available URL: <http://factfinder.census.gov> (accessed August 16, 2008).
- 13 USCB (U.S. Census Bureau). 2008a. “Decennial Census 2000 Data, American FactFinder,  
14 American Community Survey of Dauphin and Lancaster Counties, Data Profile Highlights.  
15 Selected Economic Characteristics: 2006.” Searchable database. Available URL:  
16 <http://factfinder.census.gov> (accessed September 12, 2008).
- 17 USCB (U.S. Census Bureau). 2008b. “State and County QuickFacts, 2006 Data of Dauphin and  
18 Lancaster Counties.” Searchable database. Available URL: <http://quickfacts.census.gov>  
19 (accessed September 5, 2008).
- 20 USDA (U.S. Department of Agriculture). 2008. “2002 Census of Agriculture.” Available URL:  
21 <http://www.nass.usda.gov/census/census02/volume1/pa/index2.htm> (accessed September 12,  
22 2008). ADAMS No. ML082880507.
- 23 USDO I (U.S. Department of the Interior). 2008. “Index by State and County, National Register  
24 Information System.” Available URL: <http://www.nr.nps.gov/nrloc1.htm> (accessed on September  
25 23, 2008). ADAMS No. ML082880722.
- 26 USGS (U.S. Geological Survey). 2008. “Temperature, Dissolved-Oxygen, and Nutrient  
27 Monitoring in the Susquehanna River – Summer 2008. A Project Proposal.” Available URL:  
28 [http://www.fish.state.pa.us/pafish/bass\\_black/meetings/susq2008project\\_proposal.pdf](http://www.fish.state.pa.us/pafish/bass_black/meetings/susq2008project_proposal.pdf)  
29 (accessed June 10, 2008). ADAMS No. ML082381274.
- 30 Warfel, Stephen G. 1988. *A Report on the Discovery of a Human Skeleton at Three Mile Island,*  
31 *Dauphin County, Pennsylvania*. The State Museum of Pennsylvania. Harrisburg, PA. (March 21,  
32 1988). Non-public reference per 37 Pa. C.S.A. § 506(c) and consultation with Pennsylvania  
33 Historical and Museum Commission.
- 34 York Haven Power Company. 2008. Unpublished data. June. ADAMS No. ML082880482.



### 3.0 ENVIRONMENTAL IMPACTS OF REFURBISHMENT

Facility owners or operators may need to undertake or, for economic or safety reasons, may choose to perform refurbishment activities in anticipation of license renewal or during the license renewal term. The major refurbishment class of activities characterized in the generic environmental impact statement (GEIS) (NRC 1996, 1999) is intended to encompass actions that typically take place only once in the life of a nuclear plant, if at all. Examples of these activities include, but are not limited to, replacement of boiling-water reactor recirculation piping and pressurized-water reactor steam generators. As noted in the GEIS, refurbishment activities could result in environmental impacts beyond those that occur during normal plant operations. For issues that meet Category 1 criteria, no additional plant-specific analysis is required in this draft supplemental environmental impact statement (EIS) unless new and significant information is identified. Category 2 issues are those that do not meet criteria for Category 1 and, therefore, additional plant-specific review of these issues is required. Refurbishment activities may affect a variety of environmental issues as listed in Table 3-1 below.

**Table 3-1. Issues Related to Refurbishment at TMI-1**

<b>Issues</b>	<b>Category</b>
<i>Surface Water Quality, Hydrology, and Use</i>	
Impacts of refurbishment on surface water quality	1
Impacts of refurbishment on surface water use	1
<i>Aquatic Ecology</i>	
Refurbishment	1
<i>Terrestrial Resources</i>	
Refurbishment impacts	2
<i>Threatened and Endangered Species</i>	
Threatened and Endangered Species	2
<i>Ground Water Use and Quality</i>	
Impacts of refurbishment on ground water use and quality	1
<i>Air Quality</i>	
Air quality during refurbishment (nonattainment and maintenance areas)	2
<i>Land Use</i>	
Onsite land use	1

Environmental Impacts of Refurbishment

1 **Table 3-1 (continued). Issues Related to Refurbishment at TMI-1**

<i>Human Health</i>	
Radiation exposures to the public during refurbishment	1
Occupational radiation exposures during refurbishment	1
<i>Socioeconomics</i>	
Public Services: Public Safety, Social Services, and Tourism and Recreation	1
Aesthetic Impacts (refurbishment)	1
Housing Impacts	2
Public Services: Education (refurbishment)	2
Public Services: Public Utilities	2
Public Services: Transportation	2
Historic and Archaeological Resources	2
<i>Environmental Justice</i>	
Environmental Justice	Uncategorized

2  
 3 AmerGen Energy Company, LLC (AmerGen) plans to replace the two steam generators at  
 4 Three Mile Island Nuclear Station, Unit 1 (TMI-1), with new, once-through, enhanced steam  
 5 generators. As such, AmerGen and the NRC have analyzed steam generator replacement as a  
 6 refurbishment activity, pursuant to Title 10, Section 51.53(c)(3)(ii), of the *Code of Federal*  
 7 *Regulations* (10 CFR 51.53(c)(3)(ii)).  
 8

9 **3.1 Refurbishment Activities at TMI-1**

10 Steam generator replacement activities will take approximately 70 days to complete and will  
 11 occur sometime between the refueling outage scheduled for October 2009 and the expiration of  
 12 the original license period in April 2014. The original TMI-1 steam generators contain tubing  
 13 made of alloy 600MA, which can degrade over time because of corrosion and mechanical stress  
 14 from normal plant operation. AmerGen determined that both of the steam generators at TMI-1  
 15 are affected by degradation and should be replaced with new steam generators fitted with  
 16 tubing made of alloy 690TT, which is more resistant to stress-corrosion cracking. AmerGen will  
 17 also replace the hot-leg elbows, portions of the piping, and all existing steam generator  
 18 insulation. AmerGen indicated that the steam generator refurbishment will allow TMI-1 to  
 19 operate safely throughout the period of license extension and will increase the steam generator  
 20 blowdown system capacity (AmerGen 2008).

1 The replacement steam generators will be manufactured in France and transported to the TMI-1  
2 site. Transportation of these large components (each steam generator weighs approximately  
3 500 tons [454 metric tons]) will be by a combination of boat, barge, rail, and road (AmerGen  
4 2008). For transportation within the United States, AmerGen will be required to meet all  
5 Federal, State, and local requirements that may be applicable to dredge or fill activities,  
6 temporary or permanent removal of route interferences (such as narrow tunnels and low-  
7 hanging overhead wires), and movement of wide or heavy loads over rail and roadways. For  
8 example, if the overland route includes bridge crossings, weight-bearing modifications to those  
9 bridges could require temporary fill-in of these water bodies, temporary redirecting of streams,  
10 or construction of instream cofferdams. The U.S. Army Corps of Engineers (USACE) will  
11 regulate such work pursuant to Section 404 of the Clean Water Act and Section 10 of the Rivers  
12 and Harbors Act of 1899 if any of the work is performed in “navigable waters.”

13 AmerGen has contracted a vendor to conduct a detailed study of the steam generator transport  
14 process. The transportation study is scheduled to be completed in spring 2009, and, at the time  
15 of publication of this draft supplemental EIS, the study was unfinished. Until the study is  
16 complete, AmerGen cannot provide specific information regarding potential transportation  
17 routes for the replacement steam generators, work areas within the routes, or Federal, State, or  
18 local permits required for potential routes. However, AmerGen reported that the steam  
19 generators would likely be transferred to land at Port Deposit, Maryland, and that preliminary  
20 bathymetry studies provide reasonable assurance that dredging in the Susquehanna River will  
21 not be required to accommodate the transfer at that location. As details of the transportation  
22 study become available, the U.S. Nuclear Regulatory Commission (NRC) staff will include that  
23 information in the refurbishment analysis in the final supplemental EIS for TMI-1 (NRC 2008).

24 Once on site, the steam generators will be moved via a heavy-duty, self-propelled modular  
25 transporter to the steam generator storage facility that will be constructed on the power block  
26 (i.e., previously developed) portion of the site. To temporarily store the new steam generators  
27 until they are ready for installation, and to permanently store the original steam generators after  
28 removal, a 6000-square-foot (ft<sup>2</sup>) (557 square meters [m<sup>2</sup>]) steam generator storage building will  
29 be constructed on the power block within the flood protection dike. The building will be  
30 approximately 100-ft-long by 60-ft-wide (30-m-long by 18-m-wide) and 30-ft-high (9 m). Design  
31 specifications include a watertight roof membrane and reinforced concrete thick enough to  
32 provide radiological shielding to ensure that dose rates will remain within the limits set in 10  
33 CFR Part 20, “Standards for Protection against Radiation” (AmerGen 2008).

34 The steam generator storage facility will be the only permanent structure built to support the  
35 refurbishment project. Temporary facilities will be used for offices, fabrication and welding  
36 activities, and laydown areas; however, the 4500-square-ft (418 m<sup>2</sup>) fabrication/weld test shop  
37 will have a permanent concrete slab, which will remain after the building is removed. AmerGen  
38 estimates that the total area to be disturbed for refurbishment activities will be less than 10  
39 acres (ac) (4 hectares [ha]), and disturbance will all take place on the power block, which is  
40 previously disturbed property (AmerGen 2008).

41 To remove the old steam generators and install the new ones, a 26 ft by 25 ft (8 m by 7.6 m)  
42 opening will be created in the 3-foot thick (0.9 m), reinforced concrete containment building by  
43 hydrodemolition (high-pressure water) and other mechanical methods. The process of creating  
44 this opening in the containment includes detensioning and removing tendons, removing

## Environmental Impacts of Refurbishment

1 concrete, cutting rebar, and cutting and removing a section of the steel liner. The original steam  
2 generators will be drained and cut away from their supports, and penetrations and openings will  
3 be welded closed. Loose radiological contamination will be removed, and a coating will be  
4 applied to the exterior of the original generators to seal any residual contamination in place  
5 (AmerGen 2008).  
6

### 7 **3.2 Environmental Impacts of Refurbishment**

8 The following sections discuss the Category 2 issues associated with refurbishment activities at  
9 TMI-1. Any environmental impacts from refurbishment will be in addition to those associated  
10 with continued operation of TMI-1 for the period of license renewal; Chapter 4 of this report  
11 discusses those issues.  
12

#### 13 **3.2.1 Terrestrial Resources – Refurbishment Impacts**

14 Section 2.2.6 of this draft supplemental EIS describes the terrestrial resources on and in the  
15 vicinity of the TMI-1 site. Section 2.1.5 describes the transmission line right-of-ways (ROWs).  
16 For purposes of this analysis, Sections 2.1.5 and 2.2.6 describe the geographic area considered  
17 in this evaluation.

18 The majority of steam generator replacement activities for TMI-1 will take place on existing  
19 facility grounds at the TMI-1 site. The replacement project will likely require laydown areas, a  
20 permanent holding facility for the old steam generators, and several temporary buildings to  
21 support the steam generator replacement activities. All new, permanent structures will be  
22 constructed on previously disturbed land. Temporary and permanent facilities will use  
23 approximately 10 ac (4 ha) of land. Some minimal, short-term noise impacts from construction  
24 may occur. AmerGen will need to obtain all required State and Federal permits for construction  
25 of the facilities associated with refurbishment (AmerGen 2008).

26 The new steam generators will be delivered to TMI-1 from a port in Port Deposit, Maryland, and  
27 will travel over land primarily via flatbed vehicles. Although the exact route has not been  
28 decided upon, NRC staff can extrapolate potential impacts to terrestrial resources associated  
29 with transporting the steam generator. The most likely activity to occur during transport of the  
30 steam generator is increasing the height of telephone and electric power poles along the  
31 roadways to allow for clearance of the steam generators. Impacts to terrestrial resources from  
32 these activities are expected to be negligible.

33 On the basis of the information from the staff's review of AmerGen's environmental report for  
34 the TMI-1 proposed license renewal, the staff's site visit, the scoping process, and the  
35 evaluation of other reports and information, impacts to terrestrial resources during the proposed  
36 steam generator replacement will be SMALL. A few mitigation measures that could reduce  
37 impacts to the terrestrial environment during construction of the permanent storage building  
38 include silt fences to minimize sediment transport, the use of best management practices, and  
39 the restoration of cleared land remaining after completion of construction. These mitigation  
40 measures could reduce impacts by reducing erosion and minimizing the movement of sediment,



1 nutrients, and pollutants to surface and ground water resources.  
2

### 3 **3.2.2 Threatened and Endangered Species**

#### 4 *3.2.2.1 Terrestrial Species*

5 As discussed in Section 2.2.7 of this report, State and Federal agencies have recognized two  
6 Federally listed and 11 State-listed threatened, endangered, or special concern terrestrial  
7 species as occurring in the vicinity of the TMI-1 site and its associated transmission line ROWs.  
8 Additional facilities associated with refurbishment is not likely to exceed 10 ac (4 ha) in total land  
9 use; therefore no additional impacts to threatened and endangered species within the TMI-1 site  
10 and its associated transmission line ROWs are expected (AmerGen 2008). The steam  
11 generators will be transported over land from Port Deposit, Maryland, to the TMI-1 site.  
12 Although the route is still unknown, over 100 mi (161 km) of road transport could be considered  
13 for passage of the steam generators. Because the exact route is unknown, the number of  
14 threatened or endangered species that may occur in proximity to the roads is also unknown.  
15 However, as mentioned in the project description above, the most likely activity to occur is  
16 increasing the height of power and telephone poles along roadways, with the possibility of road  
17 modification to bridges or weight-restricted areas in some locations. These activities are not  
18 likely to have additional impacts on the threatened or endangered species associated with the  
19 license renewal of TMI-1 because they will be confined to previously developed land.

20 On the basis of information from the staff's review of AmerGen's environmental report for the  
21 TMI-1 proposed license renewal (AmerGen 2008), the staff's site visit, the scoping process, and  
22 the evaluation of other reports and information, impacts to threatened or endangered species  
23 during the proposed steam generator replacement will be SMALL. Mitigation measures will be  
24 similar to those used to minimize the impacts to terrestrial resources.

#### 25 *3.2.2.2 Aquatic Species*

26 As stated above, the implementation of best management practices, such as installing silt  
27 fences, would mitigate the impact of sediment-laden run-off to surface waters and aquatic  
28 species. Water used during hydrodemolition would be treated and monitored prior to discharge  
29 to the Susquehanna River. As such, refurbishment activities at the TMI-1 site will likely have a  
30 SMALL impact on aquatic species.

31 AmerGen intends to ship the two steam generators by barge to Port Deposit, Maryland, and  
32 then use ground transportation to reach Three Mile Island in Pennsylvania, which is located  
33 approximately 60 mi (96 km) from Port Deposit. Delivery of the two generators from Port  
34 Deposit to Three Mile Island will most likely require crossing numerous streams via State and  
35 county roadways. With each steam generator weighing approximately 500 tons (454 metric  
36 tons), small bridges at these stream crossings could require modifications to support the weight  
37 of the generators. These bridge modifications could include additional support structures, such  
38 as bridge abutments, or road widening and resurfacing, or possibly bridge replacement. Much  
39 of the bridge work may need to be performed within the stream itself such as the construction of  
40 a cofferdam, which requires work at the base of existing instream bridge support structures  
41 while remaining dry, and/or work in the adjacent riparian zone and associated wetlands. In  
42 some instances, the entire stream could be temporarily rerouted until the bridge modifications

## Environmental Impacts of Refurbishment

1 are completed or the old bridge is replaced. Such instream work can potentially disrupt various  
2 lifecycles of aquatic organisms. Sediment transported downstream as a result of construction  
3 can adversely impact spawning grounds for fish and invertebrates, including anadromous fish.  
4 The rerouting of a stream or replacement of stream-crossing infrastructure (e.g., culverts,  
5 abutments) may disrupt migration patterns for anadromous fish if they are unable to move  
6 upstream because of temporary construction-related impasses, including loud noises and  
7 instream equipment movement and vibrations.

8 The instream work related to bridge modifications may also impact Federally and State-listed  
9 endangered and threatened aquatic species. Aquatic species that are listed as threatened or  
10 endangered by the U.S. Fish and Wildlife Service (FWS), the Commonwealth of Pennsylvania,  
11 or the State of Maryland are known to occur in the counties in Pennsylvania and Maryland  
12 located between Port Deposit and Three Mile Island. Once AmerGen determines a final route  
13 for transportation of the stream generators, AmerGen will need to initiate discussions with FWS  
14 and Pennsylvania and Maryland natural resource agencies to determine if any State- or  
15 Federally listed aquatic species are in the vicinity of potential bridge construction and to  
16 evaluate whether the potential work will adversely affect any listed species or its designated  
17 critical habitat.  
18

### 19 **3.2.3 Air Quality During Refurbishment (Non-Attainment and Maintenance Areas)**

20 Air quality during refurbishment (nonattainment and maintenance areas) is a Category 2 issue.  
21 Table B-1 of Appendix A to Subpart B, "Environmental Effect of Renewing the Operating  
22 License of a Nuclear Power Plant," of 10 CFR Part 51, "Environmental Protection Regulations  
23 for Domestic Licensing and Related Regulatory Functions," notes the following:

24 Air quality impacts from plant refurbishment associated with license renewal are  
25 expected to be small. However, vehicle exhaust emissions could be cause for  
26 concern at locations in or near nonattainment or maintenance areas. The  
27 significance of the potential impact cannot be determined without considering the  
28 compliance statues of each site and the numbers of workers expected to be  
29 employed during the outage.

30 Specifically, 10 CFR 51.53(c)(3)(ii)(F) requires the following:

31 If the applicant's plant is located in or near a nonattainment or maintenance area,  
32 an assessment of vehicle exhaust emissions anticipated at the time of peak  
33 refurbishment work force must be provided in accordance with the Clean Air Act  
34 as amended.

35 The GEIS states the following:

36 The 1990 Clean Air Act amendments include a provision that no federal agency  
37 shall support any activity that does not conform to a state implementation plan  
38 designed to achieve the National Ambient Air Quality Standards (NAAQS) for  
39 criteria pollutants (sulfur dioxide, nitrogen dioxide, carbon monoxide, ozone, lead,

1 and particulate matter less than 10 µm in diameter). On November 30, 1993, the  
2 U.S. Environmental Protection Agency (EPA) issued a final rule (58 FR 63214)  
3 implementing the new statutory requirements, effective January 31, 1994. The  
4 final rule requires that federal agencies prepare a written conformity analysis and  
5 determination for each pollutant where the total of direct and indirect emissions  
6 caused by proposed federal action would exceed established threshold emission  
7 levels in a nonattainment<sup>4</sup> or maintenance area<sup>5</sup>.

8 AmerGen is planning to replace the two TMI-1 steam generators with enhanced once-through  
9 steam generators. AmerGen stated that an additional 900 temporary employees will be needed  
10 for the duration of the project, which is estimated to be 70 days (AmerGen 2008).

11 During steam generator replacement project activities at the TMI-1 site some minor and short-  
12 duration air quality impacts are expected to occur. The main sources of these air quality  
13 impacts will be fugitive dust from construction activities associated with the project and exhaust  
14 emissions from the motorized equipment and vehicles of workers.

15 The majority of the refurbishment activities will be performed inside existing buildings and will  
16 not cause additional atmospheric emissions. However, a permanent steam generator building  
17 and several temporary facilities will be constructed and some land will be used for laydown  
18 areas. During construction activities, some minor air quality impacts are expected to occur as a  
19 result of equipment emissions and fugitive dust from the operation of earth-moving and material-  
20 handling equipment. The small size of disturbed area and AmerGen's commitment to use best  
21 management practices, such as watering, silt fences, covering soil piles, and hydrodemolition,  
22 will minimize the amount of fugitive dust generated during operation of earth-moving and debris-  
23 hauling equipment.

24 Refurbishment activities are known to cause localized temporary increases in atmospheric  
25 concentrations of nitrogen oxides (NO<sub>x</sub>), carbon monoxide, sulfur dioxide (SO<sub>2</sub>), volatile organic  
26 compounds (VOCs), ammonia, and particulate matter (PM<sub>10</sub> and PM<sub>2.5</sub>) as a result of exhaust  
27 emissions from workers' vehicles, diesel generators, and construction equipment. Federal  
28 agencies are prohibited from issuing a license for any activity that does not conform to an  
29 applicable implementation plan (40 CFR Part 51, "Requirements for Preparation, Adoption, and  
30 Submittal of Implementation Plans," and 40 CFR Part 93, "Determining Conformity of Federal  
31 Actions to State or Federal Implementation Plans"). TMI-1 is required to show conformity to the  
32 applicable Pennsylvania State Implementation Plans by analyzing vehicle exhaust emissions  
33 that will occur during the steam generator replacement project.

34 AmerGen stated, and the NRC staff has confirmed, that Dauphin County, where TMI-1 is  
35 located, is one of three counties located within the Harrisburg-Lebanon-Carlisle PM<sub>2.5</sub>  
36 nonattainment area (Cumberland, Dauphin, and Lebanon). Using an EPA-approved screening  
37 model, AmerGen estimated the impacts of direct and indirect ozone and particulate emissions

---

<sup>4</sup> An area is designated "nonattainment" for a criteria pollutant if it does not meet the National Ambient Air Quality Standard (NAAQS) for the pollutant.

<sup>5</sup> A maintenance area has been redesignated by a State from nonattainment to attainment; the State must submit to EPA a plan for maintaining the NAAQS as a revision to its State Implementation Plan.

## Environmental Impacts of Refurbishment

1 related to refurbishment on air quality in the nonattainment areas. The results of model  
2 calculations indicate that the emissions associated with the refurbishment activities at TMI-1 will  
3 conform to the Pennsylvania State Implementation Plans for the nonattainment areas (72 FR  
4 40749).

5 The results of the model calculations indicate that that the emissions associated with the  
6 proposed action conform to the implementation plans for the nonattainment areas. Total direct  
7 and indirect emissions as a result of the postulated TMI-1 steam generator replacement project  
8 are not expected to exceed emission budgets specified in the Pennsylvania State  
9 implementation plans and rates, established by EPA, for nonattainment and maintenance areas  
10 as defined in 40 CFR Part 51. On this basis, the NRC staff concludes that the impact of vehicle  
11 exhaust emissions attributable to the steam generator replacement project will be SMALL. The  
12 NRC staff acknowledges that the applicant will use best management practices that could  
13 mitigate potential air quality impacts resulting from the TMI-1 steam generator replacement  
14 project. Additionally, the NRC staff also identified the use of multiperson vans and workforce  
15 shift changes to reduce the number of vehicles on the road at any given time.

16 PM<sub>2.5</sub> emissions from mobile sources are generated from three general processes—(1) direct  
17 emissions from the tailpipes of cars, trucks, and other onroad vehicles, (2) reentrainment from  
18 materials found on the roadway (typically known as fugitive dust), and (3) secondary formation  
19 from precursor emissions such as SO<sub>2</sub>, NO<sub>x</sub>, VOCs and ammonia. EPA requires that PM<sub>2.5</sub>  
20 conformity assessments consider NO<sub>x</sub> and SO<sub>2</sub> emissions, however, VOC and ammonia  
21 emissions need only be considered if they are significant. No such determination has been  
22 made for Dauphin County.

23 AmerGen performed a preliminary screening analysis (using an EPA-approved model) of the  
24 emissions during the construction and outage stages of the steam generator replacement  
25 project for a period of 70 days.

26 AmerGen estimated total annual emissions of NO<sub>x</sub> during the construction stage to be 21.27  
27 tons per year (ton/yr), which is 0.16 percent of the total 2001 Dauphin County emissions and  
28 21.27 percent of the EPA threshold level for this PM<sub>2.5</sub> precursor. Total NO<sub>x</sub> emissions during  
29 the outage stage were estimated to be 8.34 tons/yr, which is 0.06 percent of the total 2001  
30 Dauphin County emissions and 8.34 percent of the EPA threshold level (AmerGen 2008a).

31 Total annual emissions of SO<sub>2</sub> during the construction stage were estimated to be 0.59 tons/yr,  
32 which is 0.01 percent of the total 2001 Dauphin County emissions. During the outage stage,  
33 total SO<sub>2</sub> emissions were estimated to be 0.12 tons/yr, which is less than 1 percent of the total  
34 2001 Dauphin County emissions and 0.12 percent of the EPA threshold level (AmerGen 2008a).

35 AmerGen estimated total annual emissions of PM<sub>2.5</sub> during the construction stage to be 1.5  
36 tons/yr, which is 0.06 percent of the total 2001 Dauphin County emissions and 1.5 percent of  
37 the EPA threshold level. During the outage stage, total PM<sub>2.5</sub> emissions were estimated to be  
38 0.53 tons/yr, which is 0.02 percent of the total 2001 Dauphin County emissions and 0.53  
39 percent of the EPA threshold level (AmerGen 2008a).

40 Dauphin County is part of the Harrisburg-Lebanon-Carlisle 8-hour ozone attainment area (basic  
41 maintenance area). Ground-level ozone is formed when NO<sub>x</sub> and VOCs react in the presence  
42 of heat and sunlight. AmerGen estimated total annual emissions of VOCs during the

1 construction stage to be 2.78 tons/yr, which is 0.02 percent of the total 2001 Dauphin County  
2 emissions and 5.55 percent of the EPA threshold level. During the outage stage, total VOC  
3 emissions were estimated to be 4.04 tons/yr, which is 0.03 percent of the total 2001 Dauphin  
4 County emissions and 8.09 percent of the EPA threshold level (AmerGen 2008a).

5 The results of the model calculations indicate that the emissions associated with the proposed  
6 action conform to the implementation plans for the nonattainment areas. Total direct and  
7 indirect emissions resulting from the replacement of the two TMI-1 steam generators are not  
8 expected to exceed emission budgets specified in the Pennsylvania State implementation plans  
9 and rates, established by the EPA, for nonattainment and maintenance areas as described in 40  
10 CFR Part 51. On this basis, the NRC staff concludes that the impact of vehicle exhaust  
11 emissions during the steam generator replacement project will be SMALL. There are a number  
12 of measures that could mitigate potential air quality impacts resulting from refurbishment  
13 activities, such as implementation of a dust control plan to minimize emissions from construction  
14 activities and the use of multiperson vans and workforce shift changes to reduce the number of  
15 vehicles on the road at any one given time.  
16

### 17 **3.2.4 Housing Impacts**

18 Housing impacts during refurbishment is a Category 2 issue. Table B-1 of 10 CFR Part 51,  
19 Subpart A, Appendix B, notes that:

20 Housing impacts are expected to be of small significance at plants located in a  
21 medium or high population area and not in an area where growth control  
22 measure that limit housing development are in effect. Moderate or large housing  
23 impacts of the workforce associated with refurbishment may be associated with  
24 plants located in sparsely populated areas or in areas with growth control  
25 measures that limit housing development.

26 AmerGen estimates that steam generator replacement would require a one-time increase in the  
27 number of refueling outage workers for up to 70 days at TMI-1. Approximately 900 workers  
28 would be needed to perform TMI-1 steam generator replacement project activities in addition to  
29 the normal number of refueling outage workers (AmerGen 2008).

30 The number of additional workers would cause a short-term increase in the demand for  
31 temporary (rental) housing units in the region beyond what is normally experienced during a  
32 refueling outage at TMI-1. Since TMI-1 is located in a high population area, and Dauphin and  
33 Lancaster Counties are not subject to growth control measures that would limit housing  
34 development, any changes in TMI-1 employment would have little noticeable effect on housing  
35 availability in these counties. In addition, the number of available housing units has kept pace  
36 with or exceeded the decrease in the county populations. However, the rental housing market  
37 in the region is very large and based on this information, employment-related housing impacts  
38 would be very SMALL.  
39

## Environmental Impacts of Refurbishment

### 1 **3.2.5 Public Services – Education (Refurbishment)**

2 Public services: education (refurbishment) is a Category 2 issue. Table B-1 of 10 CFR Part 51,  
3 Subpart A, Appendix B, notes that “Most sites would experience impacts of small significance  
4 but larger impacts are possible depending on site- and project-specific factors.”

5 As discussed in Section 3.2.4, AmerGen estimates that TMI-1 steam generator replacement  
6 would require a one-time increase in the number of refueling outage workers for up to 70 days  
7 at TMI-1 (AmerGen 2008). Due to the short amount of time needed to replace the steam  
8 generators, workers would not be expected to bring families and school-age children with them  
9 and therefore there would be no impact on educational services during this extended refueling  
10 outage.  
11

### 12 **3.2.6 Public Services – Public Utilities**

13 Public services: public utilities is a Category 2 refurbishment issue. Table B-1 of 10 CFR Part  
14 51, Subpart A, Appendix B, notes that “An increased problem with water shortages at some  
15 sites may lead to impacts of moderate significance on public water supply availability.”

16 Since there is no water shortage in the TMI-1 region and the public water systems located in  
17 Dauphin and Lancaster Counties have excess capacity, any changes in TMI-1 and employee  
18 public water usage would have little noticeable affect on public water supply availability in these  
19 counties.

20 As discussed in Section 3.2.4, AmerGen estimates that steam generator replacement would  
21 require a one-time increase in the number of refueling outage workers for up to 70 days at TMI-  
22 1 (AmerGen 2008). The additional number of refueling outage workers needed to replace the  
23 steam generators would cause a short-term increase in the amount of public water and sewer  
24 services used in the immediate vicinity of TMI-1. Since the region has excess capacity water  
25 supply impacts would be very SMALL.  
26

### 27 **3.2.7 Public Services – Transportation**

28 Public services: transportation is a Category 2 refurbishment issue. Table B-1 of 10 CFR Part  
29 51, Subpart A, Appendix B, notes that:

30 Transportation impacts (level of service) of highway traffic generated during plant  
31 refurbishment and during the term of the renewed license are generally expected  
32 to be of small significance. However, the increase in traffic associated with  
33 additional workers and the local road and traffic control conditions may lead to  
34 impacts of moderate or large significance at some sites.

35 The additional number of refueling outage workers and truck material deliveries needed to  
36 support the replacement of the steam generators would cause a short-term level of service  
37 impact on access roads in the immediate vicinity of TMI-1. As previously discussed in Section  
38 2.2.8.2, major commuting routes to TMI-1, including State Highway 441, are mostly rural and

1 uncongested. Increased traffic volumes entering and leaving TMI-1 during refueling outages,  
2 which occur at intervals of approximately 24 months, has not degraded the level of service  
3 capacity on local roads. In addition, the TMI-1 site has two entrances. The entrance to the  
4 north is used by the operating work force. The entrance to the south is used by a limited  
5 number of operational employees working on the southern portion of the station and  
6 construction and outage workforces. According to AmerGen, during the refurbishment project,  
7 construction workers would use the southern entrance to the site. This could alleviate potential  
8 congestion problems at the northern site entrance.

9 Also, the delivery of the steam generators to TMI-1 would have an impact on the transportation  
10 infrastructure used to transport the steam generators to TMI-1 from the U.S. port of call (i.e.,  
11 Baltimore, Philadelphia, or Newark) to the TMI-1 site. As detailed in Section 3.1, according to  
12 AmerGen, a final option has not been selected for the delivery of the steam generators. Some  
13 options being considered may require the temporary removal and replacement of interferences,  
14 such as low-hanging overhead telephone and power lines and narrow roadway obstructions.  
15 Such activities would be temporary and localized causing short-term traffic delays and detours.  
16 Permits and approvals would be obtained from the appropriate Federal, State, and local  
17 agencies prior to the movement of the steam generators.

18 As previously discussed, a combination of barge, rail, and/or road transport from the U.S. port of  
19 call to TMI-1 is being considered by AmerGen, using one of the following options:

- 20 • Barge from Baltimore, Maryland, through the Chesapeake Bay and up the Susquehanna  
21 River to Port Deposit, Maryland, then rail or road to TMI-1;
- 22 • Rail and/or road from Baltimore, Maryland, to TMI-1;
- 23 • Rail and/or road from Philadelphia, Pennsylvania, to TMI-1; or
- 24 • Rail and/or road from Newark, New Jersey, to TMI-1.

25  
26 Based on this information and due to the short time duration (up to 70 days) for the steam  
27 generator replacement project after the arrival of the steam generators, transportation (level of  
28 service) impacts in the vicinity of TMI-1 would be SMALL and would only occur during shift  
29 changes.  
30

### 31 **3.2.8 Offsite Land Use (Refurbishment)**

32 Offsite land use (refurbishment) is a Category 2 issue. Table B-1 of 10 CFR Part 51, Subpart A,  
33 Appendix B, notes that "Impacts may be of moderate significance at plants in low population  
34 areas."

35 Since TMI-1 is located in a high population area any changes in TMI-1 employment would have  
36 little noticeable affect on land use in the region. Due to the short amount of time needed to  
37 replace the steam generators, the additional number of refueling outage workers would not  
38 cause any permanent population- and tax revenue-related land use changes in the immediate  
39 vicinity of TMI-1.  
40

1 **3.2.9 Historic and Archaeological Resources**

2 Historic and archaeological resources are a Category 2 refurbishment issue. Table B-1 of 10  
3 CFR Part 51, Subpart A, Appendix B, notes that

4           Generally, plant refurbishment and continued operation are expected to have no  
5           more than small adverse impacts on historic and archaeological resources.  
6           However, the National Historic Preservation Act requires the Federal agency to  
7           consult with the State Historic Preservation Officer to determine whether there  
8           are properties present that require protection.

9           The area potentially affected by the steam generator replacement project is in an area that was  
10           previously disturbed by the construction of TMI-1 and TMI Unit 2. Ground disturbing activities  
11           associated with the project include the excavation of previously disturbed areas in the vicinity of  
12           TMI-1 and in several areas located south and west of the TMI Unit 2 cooling towers (AmerGen  
13           2008 response to ENV-36). A 6,000 ft<sup>2</sup> (557 m<sup>2</sup>) storage facility built to house the old steam  
14           generators and other temporary structures will be constructed within the existing industrial  
15           footprint of the site (AmerGen 2008b).

16           Should AmerGen proceed with the steam generator project, all activities would be reviewed in  
17           accordance with AmerGen's site procedures which are designed to ensure that site  
18           investigations and consultations with the Pennsylvania Historical and Museum (PHMC;  
19           Pennsylvania's State Historic Preservation Office, PA SHPO) are conducted as needed, and  
20           that existing and unknown cultural resources are adequately protected. AmerGen has  
21           consulted with the PHMC. The PHMC determined that the project would have no effect on  
22           known historic and archaeological resources. However, should the project include additional  
23           ground disturbing activities beyond what is currently planned, then further consultation and  
24           mitigation would be necessary.

25           The delivery of the steam generators from the eastern shore of the Susquehanna River to TMI-1  
26           could impact remnants of the Pennsylvania Canal's Eastern Division (Eastern Division Canal)  
27           which ran on the east side of the Susquehanna River. Prehistoric and historic properties along  
28           the route could be affected by vibrations from the movement of the heavy transporter over  
29           roadways and bridges. However, most activities would be temporary and localized. Permits  
30           and approvals would be obtained from the appropriate Federal, State, and local agencies prior  
31           to the movement of the steam generators.

32           The impacts associated with this activity are not expected to adversely impact historic or  
33           archaeological sites located in the vicinity of TMI-1 and TMI Unit 2. Therefore, the potential  
34           impacts from this activity on historic or archaeological resources would be SMALL. However,  
35           should archaeological resources be encountered during construction, work would cease until  
36           AmerGen environmental personnel perform an evaluation and consider possible mitigation  
37           measures through consultation with the PHMC.  
38



### 1 **3.2.10 Environmental Justice**

2 Environmental justice is a Category 2 refurbishment issue. Table B-1 of 10 CFR Part 51,  
3 Subpart A, Appendix B, notes that “The need for and the content of an analysis of  
4 environmental justice will be addressed in plant specific reviews.”

5 Since TMI-1 is located in a high population area any changes in TMI-1 employment would have  
6 little noticeable effect on minority and/or low-income populations in the region. Due to the short  
7 amount of time (up to 70 days) needed to replace the TMI-1 steam generators and based on the  
8 analysis of impacts for the other resource areas discussed in Section 3.2, there would be no  
9 disproportionately high and adverse impacts on minority and low-income populations located in  
10 the immediate vicinity of TMI-1.  
11

### 12 **3.3 Evaluation of New and Potentially Significant Information on Impacts of** 13 **Refurbishment**

14 For all Category 1 issues related to refurbishment, the NRC staff has not identified any new and  
15 significant information during its review of the TMI-1 ER, the staff’s environmental site audit, the  
16 scoping process, or the evaluation of other available information, including the July 17, 2008  
17 telephone conference call between NRC and AmerGen, during which AmerGen’s refurbishment  
18 plans were discussed (NRC 2008). Therefore, the NRC staff adopts the findings in the GEIS for  
19 Category 1 issues associated with refurbishment, and concludes that there would be no  
20 environmental impacts during the renewal term beyond those discussed in the GEIS for these  
21 issues.  
22

### 23 **3.4 Summary of Impacts of Refurbishment**

24 For the nine Category 2 issues and environmental justice, the impacts of refurbishment at TMI-1  
25 range from no impact to SMALL. For the refurbishment issues Public Services: Education,  
26 Offsite Land Use, and Environmental Justice, the NRC staff concludes that there would be no  
27 noticeable impact. For the refurbishment issues Terrestrial Ecology, Threatened or Endangered  
28 Species, Air Quality (Nonattainment and Maintenance Areas), Housing Impacts, Public  
29 Services: Public Utilities, Public Services: Transportation, and Historic and Archeological  
30 Resources, the NRC staff concludes that the potential environmental effects are of SMALL  
31 significance.  
32

### 33 **3.5 References**

34 10 CFR 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, “Environmental Protection  
35 Regulations for Domestic Licensing and Related Regulatory Functions.”

36 40 CFR 51. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 51,  
37 “Requirements for Preparation, Adoption, and Submittal of Implementation Plans.”

## Environmental Impacts of Refurbishment

- 1 40 CFR 93. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 93,  
2 “Determining Conformity of Federal Actions to State or Federal Implementations Plans.”
- 3 72 FRN 40749. July 25, 2007. “Approval and Promulgation of Air Quality Implementation  
4 Plans; Pennsylvania; Redesignation of the Harrisburg-Lebanon-Carlisle Ozone Nonattainment  
5 Area to Attainment and Approval of the Area’s Maintenance Plan and 2002 Base Year  
6 Inventory.” *Federal Register*. Volume 72, No. 142, pp. 40749. Washington, D.C.
- 7 AmerGen (AmerGen Energy Company, LLC). 2008. *Three Mile Island Nuclear Station,*  
8 *Applicant’s Environmental Report, License Renewal Operating Stage.* Kennett Square,  
9 Pennsylvania. ADAMS Nos. ML080220255, ML080220257, ML080220261, and ML080220282.
- 10 AmerGen (AmerGen Energy Company, LLC). 2008a. *Three Mile Island, Unit 1, Enclosure A -*  
11 *Post Audit Environmental Information – Question ENV-070, Monthly Report on the*  
12 *Meteorological Monitoring Program, March 2007 through End (Non-Proprietary Version).* June  
13 10. ADAMS No. ML082110253.
- 14 AmerGen (AmerGen Energy Company, LLC). 2008b. *Three Mile Island, Unit 1, Enclosure A –*  
15 *Post Audit Environmental Information – Index through Audit Question ENV-070, Monthly Report*  
16 *on the Meteorology Program, February 2007 (Non-Proprietary Version).* ADAMS No.  
17 ML082110252.
- 18 *Clean Air Act.* 42 U.S.C. 7401, et seq. *United States Code*, Title 42, *The Public Health and*  
19 *Welfare*, Chapter 85, “Air Pollution Prevention and Control.”
- 20 *Clean Water Act.* 33 U.S.C. 26. *United State Code*, Title 33, *Navigation and Navigable Waters*,  
21 Chapter 26, “Water Pollution Prevention and Control”
- 22 NRC (U.S. Nuclear Regulatory Commission). 1996. *Generic Environmental Impact Statement*  
23 *for License Renewal of Nuclear Plants.* NUREG-1437, Volumes 1 and 2, Washington, D.C.  
24 ADAMS No. ML061770605.
- 25 NRC (U.S. Nuclear Regulatory Commission). 1999. *Generic Environmental Impact Statement*  
26 *for License Renewal of Nuclear Plants, Main Report*, “Section 6.3-Transportation, table 9.1,  
27 Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants, Final  
28 Report.” NUREG-1437, Volume 1, Addendum 1, Washington, D.C.
- 29 NRC (U.S. Nuclear Regulatory Commission). 2008. Summary of Telephone Conference Call  
30 Held on July 17, 2008, Between the U.S. Nuclear Regulatory Commission and AmerGen  
31 Energy Company, LLC, Concerning Follow-Up Questions Pertaining to the Three Mile Island  
32 Nuclear Station, Unit 1 License Renewal Environmental Review and Site Audit. Washington,  
33 D.C. ADAMS No. ML082120727.

## 4.0 ENVIRONMENTAL IMPACTS OF OPERATION

This chapter addresses potential environmental impacts related to the period of extended operation of Three Mile Island Nuclear Station, Unit 1 (TMI-1). These impacts are grouped and presented according to resource. Generic issues (Category 1) rely on the analysis provided in the generic environmental impact statement (GEIS) prepared by the U.S. Nuclear Regulatory Commission (NRC) (NRC 1996, 1999) and are discussed briefly. NRC staff analyzed site-specific issues (Category 2) for TMI-1 and assigned them a significance level of SMALL, MODERATE, or LARGE. Some remaining issues are not applicable to TMI-1 because of site characteristics or plant features. Section 1.4 of this report explains the criteria for Category 1 and Category 2 issues and defines the impact designations of SMALL, MODERATE, and LARGE.

### 4.1 Land Use

Land use issues are listed in Table 4-1. The staff did not identify any Category 2 issues for land use. The staff also did not identify any new and significant information during the review of the environmental report (ER) (AmerGen 2008) prepared by AmerGen Energy Company, LLC (AmerGen), the site audit, or the scoping process. Therefore, there are no impacts related to these issues beyond those discussed in the GEIS. For these issues, the GEIS concludes that the impacts are SMALL, and additional site-specific mitigation measures are not likely to be warranted.

**Table 4-1. Land Use Issues.** *Section 2.2.1 of this report describes the land use around TMI-1.*

Issues	GEIS Section	Category
Onsite land use	4.5.3	1
Power line right-of-way	4.5.3	1

### 4.2 Air Quality

The air quality issue applicable to TMI-1 is listed in Table 4-2. The staff did not identify any Category 2 issues related to the effects of transmission lines on air quality. Staff also did not identify any new and significant information during the review of AmerGen's ER (AmerGen 2008), the site audit, or the scoping process. Therefore, there are no impacts related to this issue beyond those discussed in the GEIS. For these issues, the GEIS concludes that the impacts are SMALL, and additional site-specific mitigation measures are not likely to be warranted.

**Table 4-2. Air Quality Issue.** *Section 2.2.2 of this report describes air quality in the vicinity of TMI-1.*

Issue	GEIS Section	Category
Air quality effects of transmission lines	4.5.2	1

1 **4.3 Ground Water**

2 The following sections discuss the Category 2 ground water issues applicable to TMI-1, which  
3 are listed in Table 4-3.

4 **Table 4-3. Ground Water Use and Quality Issues.** *Section 2.2.3 of this report*  
5 *discussed ground water use and quality at TMI-1.*

Issues	GEIS Section	Category
Ground Water use conflicts (potable and service water, plants using >100 gpm)	4.8.1.1	2
Ground Water use conflicts (plants using cooling towers withdrawing make-up water from a small river)	4.8.1.3	2

6

7 **4.3.1 Ground Water Use Conflicts (plants using >100 gpm)**

8 The NRC specifies as issue 33 in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, that, “if  
9 the applicant’s plant...pumps more than 100 gallons (total onsite) of ground water per minute  
10 (gpm), an assessment of the impact of the proposed action on ground water use must be  
11 provided.” The NRC further states that “plants that use more than 100 gpm may cause ground  
12 water use conflicts with nearby ground water users,” (10 CFR 51.53[c][3][ii][C]). This applies to  
13 TMI-1 because, as discussed in Section 2.2.3.1 of this report, TMI-1 used between 95 and 115  
14 gallons per minute (gpm) of ground water pumped from seven onsite wells from 2003 to 2005.

15 A ground water withdrawal rate of over 100 gpm has the potential to create a cone of  
16 depression large enough to affect offsite wells and ground water supplies, limiting the amount of  
17 ground water available for the area surrounding the plant. The Susquehanna River Basin  
18 Commission (SRBC) originally approved ground water withdrawal at a rate of 168,750 gallons  
19 per day (gpd) (117 gpm) at TMI-1 from wells A, B, and C after a process of simultaneous pump  
20 tests in 1995. In 1998, TMI-1 applied to SRBC for a ground water withdrawal upgrade. Based on  
21 information gathered during the original pumping tests, and after observing that there had been  
22 no impacts on the operation of the onsite Operations Support Facility/North Office Building  
23 (OSF) well, the Building 48 (48S) well, or any other onsite wells, or along the eastern shore of  
24 the Susquehanna River, SRBC approved a new ground water withdrawal rate of 225,000 gpd.

25 After reviewing the information provided by the applicant, as well as the 1996 SRBC pump test  
26 data from wells A, B, and C, which showed no effect on nearby ground water wells, the NRC  
27 staff concludes that the impacts of TMI-1 ground water withdrawal on nearby ground water  
28 users would be SMALL.

29 **4.3.2 Ground Water Use Conflicts (make-up from a small river)**

30 The NRC specifies that, “if the applicant’s plant utilizes cooling towers or cooling ponds and  
31 withdraws makeup water from a river whose annual flow rate is less than  $3.15 \times 10^{12}$  cubic ft per  
32 year (ft<sup>3</sup>/year) [(99,885 cubic ft per second (cfs))...[t]he applicant shall also provide an  
33 assessment of the impacts of the withdrawal of water from the river on alluvial aquifers during

low flow,” (10 CFR 51.53[c][3][ii][A]). For water use conflicts, the NRC further states, as issue 34 in Table B-1 of Appendix B to Subpart A of 10 CFR Part 51 that, “water use conflicts may result from surface water withdrawals from small water bodies during low flow conditions which may affect aquifer recharge, especially if other ground water or upstream surface water users come online before the time of license renewal...” This issue is applicable to TMI-1 because the plant uses cooling towers, and makeup water for its cooling systems is withdrawn from the Susquehanna River, which has an annual mean flow of approximately  $1.09 \times 10^{12}$  ft<sup>3</sup>/yr (34,450 cfs), thus meeting the NRC’s definition of a small river. Flow is monitored at the Harrisburg gauging station, about 11 miles (mi) (18 kilometers [km]) upstream of TMI-1.

Consumptive water losses at TMI-1 comprise a small fraction of the Susquehanna River flow at Lake Frederick (which is created by the damming of the Susquehanna River by the Red Hill Dam and the York Haven Dam), where TMI-1 is situated. The rate at which TMI-1 withdraws surface water is about 1.6 percent of the lowest daily mean flow of the Susquehanna River, which is less than 0.2 percent of the lowest annual mean flow and less than 0.1 percent of the average annual flow. TMI-1 is also part of the Cowanesque Lake water storage project, allowing the site 8,274 acre-feet of storage. During a period of severe drought, SRBC can direct the release of water and, of that 8,274 acre-feet, about 4,250 would alleviate any impacts to the Susquehanna River caused by the consumptive loss from plant operations, allowing for the continuation of TMI-1 operations.

Furthermore, the Commonwealth of Pennsylvania requires facilities that withdraw or use more than 10,000 gpd (378,541 liters per day [Lpd]) of surface or ground water, such as TMI-1, to register and periodically report their water usage for Commonwealth water planning purposes. Thus, the NRC staff concludes that the impacts from consumptive water use on ground water would be SMALL.

**4.4 Surface Water**

The following sections discuss the surface water quality issues applicable to TMI-1 which are listed in Table 4-4. The staff did not identify any new and significant information during the review of AmerGen’s ER (AmerGen 2008), the site audit, or the scoping process. Therefore, no impacts are related to these issues beyond those discussed in the GEIS. For these issues, the GEIS concludes that the impacts are SMALL, and additional site-specific mitigation measures are not likely to be warranted.

**Table 4-4. Surface Water Quality Issues.** *Section 2.2.4 of this report describes surface water quality conditions at TMI-1.*

Issues	GEIS Section	Category
Altered current patterns at intake and discharge structures	4.2.1.2.1	1
Altered salinity gradients	4.2.1.2.2	1
Temperature effects on sediment transport capacity	4.2.1.2.3	1
Scouring caused by discharged cooling water	4.2.1.2.3	1

## Environmental Impacts of Operation

Issues	GEIS Section	Category
Eutrophication	4.2.1.2.3	1
Discharge of chlorine or other biocides	4.2.1.2.4	1
Discharge of sanitary wastes and minor chemical spills	4.2.1.2.4	1
Discharge of other metals in wastewater	4.2.1.2.4	1
Water use conflicts (plants with cooling ponds or cooling towers using make-up water from a small river with low flow)	4.3.2.1; 4.4.2.1	2

1

### 2 4.4.1 Water Use Conflicts

3 The NRC specifies that, "if the applicant's plant uses cooling towers or cooling ponds and  
 4 withdraws makeup water from a river whose annual flow rate is less than  $3.15 \times 10^{12}$  cubic feet  
 5 per year ( $\text{ft}^3/\text{year}$ ) [ $99,885$  cubic feet per second (cfs)], an assessment of the impact of the  
 6 proposed action on the flow of the river and related impacts on instream and riparian ecological  
 7 communities must be provided" (10 CFR 51.53[c][3][ii][A]). For water use conflicts, the NRC  
 8 further states as issue 13 in Table B-1 of Appendix B to Subpart A of 10 CFR Part 51, "The  
 9 issue has been a concern at nuclear power plants with cooling ponds and at plants with cooling  
 10 towers. Impacts on instream and riparian communities near these plants could be of moderate  
 11 significance in some situations." This issue is applicable to TMI-1 because the plant uses a  
 12 cooling-tower-based heat dissipation system, and water to replace that lost to evaporation in the  
 13 cooling system is withdrawn from the Susquehanna River, which has an annual mean flow of  
 14 approximately  $1.09 \times 10^{12}$   $\text{ft}^3/\text{yr}$  (34,450 cfs), thus meeting the NRC's definition of a small river.  
 15 Flow is monitored at the Harrisburg gauging station, about 11 mi (18 km) upstream of TMI-1.

16 The GEIS considered surface water use conflicts to be a Category 2 issue for two reasons:

- 17 (1) Consumptive water use can adversely affect riparian vegetation and instream  
 18 aquatic communities. Reducing the amount of water available to either the  
 19 riparian zones or instream communities could result in impacts to threatened  
 20 and endangered species, wildlife, and recreational uses of the water body. In  
 21 addition, riparian vegetation performs several important ecological functions,  
 22 included stabilizing channels and floodplains, influencing water temperature  
 23 and quality, and providing habitat for aquatic and terrestrial wildlife.
- 24 (2) Continuing operation of these facilities depends on the availability of water  
 25 within the river from which they are withdrawing water. For facilities that are  
 26 located on small bodies of water, the volume of water available is expected to  
 27 be susceptible to droughts and to competing water uses within the basin. In  
 28 cases of extreme drought, these facilities may be required to curtail  
 29 operations if the volume of water available is not sufficient.

30 An additional potential effect of the withdrawal of water from a small river is that the withdrawal  
 31 may have an impact on ground water levels and, therefore, result in ground water use conflicts

1 (NRC 1996). The staff considers this to be a separate Category 2 issue, which is evaluated in  
2 Section 4.3 of this draft supplemental environmental impact statement (EIS).

3 The Susquehanna River meets the definition of a small river because, based on data taken 11  
4 mi (18 km) upstream of TMI-1 at Harrisburg, the annual mean flow of the river is  $1.09 \times 10^{12}$  ft<sup>3</sup>/yr  
5 (34,450 cfs). TMI-1 is permitted to withdraw up to 18 million gpd, with its average estimated rate  
6 of withdraw being 24,000 gpm. The withdraws from TMI-1 are less than 1.6 percent of the  
7 Susquehanna River flow under the conditions of a typical drought period, less than 0.2 percent  
8 of the lowest annual mean flow of the river, and less than 0.1 percent of the average annual  
9 flow. These consumptive losses are insignificant relative to the flow in the Susquehanna River  
10 and would not be expected to impact the river's aquatic and riparian ecological communities or  
11 the alluvial water-bearing material (aquifers).

12 Additionally, as detailed in Section 2.1.7.2 of this report, TMI-1 participates in the Cowanesque  
13 Lake water storage project and sponsors 8,274 acre-feet of water storage. SRBC monitors the  
14 flow of the Susquehanna River and, in the event of a drought emergency, it has the authority to  
15 signal the U.S. Army Corps of Engineers to release predetermined quantities of water from  
16 storage. In such a situation, only 4,250 of the 8,274 acre-feet sponsored by TMI-1 would be  
17 required to help offset the effects of water consumption from plant operations.

18 The staff has reviewed the available information, including that provided by the applicant,  
19 additional SRBC data, information gathered at the staff's site visit and the scoping process, and  
20 other available sources. Considering TMI-1's small consumptive water use relative to the flows  
21 in the Susquehanna River, as well as the potential for SRBC to release water into the river  
22 during periods of extreme drought, the NRC staff concludes that the impact of water use on the  
23 Susquehanna River at TMI-1 would be SMALL.

24

#### 25 **4.5 Aquatic Resources**

26 Table 4-5 on the following page lists the issues related to aquatic resources applicable to TMI-1.  
27 No Category 2 issues are related to aquatic resource. The NRC staff did not identify any new  
28 and significant information during the review of the AmerGen environmental report (AmerGen  
29 2008), the site audit, the scoping process, or the evaluation of other available information.

30 Therefore, the staff concludes that there would be no impacts related to these issues beyond  
31 those discussed in the GEIS (NRC 1996). For these issues, the GEIS concludes that the  
32 impacts are SMALL, and additional site-specific mitigation measures are not likely to warrant  
33 implementation.

34

Environmental Impacts of Operation

1 **Table 4-5. Aquatic Resources Issues.** Section 2.1.6 of this report describes the  
 2 TMI-1 cooling water system; Section 2.2.5 describes the aquatic  
 3 resources.

Issues	GEIS Section	Category
<i>For All Plants</i>		
Accumulation of contaminants in sediments or biota	4.2.1.2.4	1
Entrainment of phytoplankton and zooplankton	4.2.2.1.1	1
Cold shock	4.2.2.1.5	1
Thermal plume barrier to migrating fish	4.2.2.1.6	1
Distribution of aquatic organisms	4.2.2.1.6	1
Premature emergence of aquatic insects	4.2.2.1.7	1
Gas supersaturation (gas bubble disease)	4.2.2.1.8	1
Low dissolved oxygen in the discharge	4.2.2.1.9	1
Losses from predation, parasitism, and disease among organisms exposed to sublethal stresses	4.2.2.1.10	1
<i>For Plants with Cooling Tower-Based Heat Dissipation Systems</i>		
Entrainment of fish and shellfish in early life stages	4.3.3	1
Impingement of fish and shellfish	4.3.3	1
Heat shock	4.3.3	1

4

5 **4.5.1 Generic Aquatic Ecology Issues**

6 The NRC staff did not identify any new and significant information during the review of the  
 7 AmerGen environmental report (AmerGen 2008), the site audit, or the scoping process.  
 8 Therefore, there are no impacts related to these issues beyond those discussed in the GEIS.  
 9 For these issues, the GEIS concludes that the impacts are SMALL, and additional site-specific  
 10 mitigation measures are not likely to be sufficiently beneficial to be warranted.  
 11

12 **4.6 Terrestrial Resources**

13 The issues related to terrestrial resources applicable to TMI-1 are discussed below and listed in  
 14 Table 4-6. No Category 2 issues are related to terrestrial resources for license renewal. The  
 15 NRC staff did not identify any new and significant information during the review of the AmerGen  
 16 environmental report (AmerGen 2008), the site audit, the scoping process, or the evaluation of  
 17 other available information. Therefore, the NRC staff concludes that there would be no impacts  
 18 related to these issues beyond those discussed in the GEIS (NRC 1996). For these issues, the



1 GEIS concludes that the impacts are SMALL, and additional site-specific mitigation measures  
 2 are not likely to be sufficiently beneficial to implement.

3  
 4 **Table 4-6. Terrestrial Resources Issues.** Section 2.2.6 provides a description of the  
 5 *terrestrial resources at TMI-1 and in the surrounding area.*

Issues	GEIS Section	Category
Cooling tower impacts on crops and ornamental vegetation	4.3.4	1
Cooling tower impacts on native plants	4.3.5.1	1
Bird collisions with cooling towers	4.3.5.2	1
Power line right-of-way management (cutting herbicide application)	4.5.6.1	1
Bird collisions with power lines	4.5.6.1	1
Impacts of electromagnetic fields on flora and fauna (plants, agricultural crops, honeybees, wildlife, livestock)	4.5.6.3	1
Floodplains and wetland on power line right-of-way	4.5.7	1

6

7 **4.7 Threatened or Endangered Species**

8 **Table 4-7. Threatened or Endangered Species.** Section 2.2.7 describes the  
 9 *threatened or endangered species on or near TMI-1.*

Issue	GEIS Section	Category
Threatened or endangered species	4.1	2

10

11 **4.7.1 Aquatic Species**

12 One Federally- and State-listed endangered species, the dwarf wedgemussel (*Alasmidonta*  
 13 *heterodon*), was recorded in Lancaster County, but not in the vicinity of TMI-1 or in the  
 14 waterways along the transmission line corridors. The black bullhead (*Amerius melas*), a State-  
 15 listed species, has been recorded in Dauphin County (PNHP 2008), but is not known to occur  
 16 either in the vicinity of TMI-1 or in the waterways along the transmission line corridors  
 17 (AmerGen 2008).

18 The U.S. Fish and Wildlife Service (FWS) indicated by letter dated April 23, 2008, that no  
 19 Federally listed or proposed threatened or endangered species are known to occur within the  
 20 project impact area; hence no biological assessment or further consultation with FWS, as  
 21 required by the Endangered Species Act, is necessary (FWS 2008). The Pennsylvania Fish and  
 22 Boat Commission (PFBC) indicated by letter dated June 7, 2007, that no adverse impacts to  
 23 State-listed rare, candidate, threatened, or endangered aquatic species are expected from the  
 24 proposed project (PFBC 2008).

1 **4.7.2 Terrestrial Species**

2 Impacts to threatened and endangered terrestrial species requires consultation with appropriate  
3 agencies to determine whether such species are present and whether they would be adversely  
4 affected by continued operation of the TMI-1 site during the license renewal term. Sections 2.2.6  
5 and 2.2.7 of this draft supplemental EIS discuss the characteristics and habitat of threatened  
6 and endangered species in the vicinity of the TMI-1 site.

7 The NRC staff contacted FWS, the Pennsylvania Department of Conservation and Natural  
8 Resources (DCNR), and the Pennsylvania Game Commission (PGC) to request information that  
9 could assist in its assessment of the environmental impacts associated with license renewal. In  
10 response, on April 28, 2008, the FWS indicated that no known Federally-listed threatened or  
11 endangered species occur within the project area; therefore, the proposed project would not  
12 likely adversely affect any Federally-listed species (FWS 2008). In a May 2, 2008, letter to the  
13 NRC, DCNR stated that, although several species of concern are known to occur in the vicinity  
14 of the TMI-1 project site, no impact to these species is anticipated (DCNR 2008). In a May 14,  
15 2008, letter to the NRC, PGC indicated that, “the renewal of the TMI Operating License is not  
16 anticipated to cause any adverse impacts to special concern species of birds and mammals that  
17 may be in the vicinity of the transmission line corridors associated with the electric generating  
18 station” (PGC 2008).

19 Two Federally-listed threatened or endangered species, the bog turtle (*Glyptemys muhlenbergii*)  
20 and the northeastern bulrush (*Scirpus ancistrochaetus*), are potentially found in the vicinity of  
21 the TMI-1 site (PNHP 2008). The bald eagle (*Haliaeetus leucocephalus*) and the peregrine  
22 falcon (*Falco peregrinus*) were formerly listed as Federally-threatened. Eleven State-listed  
23 threatened or endangered species have been determined to be species of special concern for  
24 the TMI-1 site, including the osprey (*Pandion haliaetus*), the prothonotary warbler (*Protonotaria*  
25 *citrea*), the yellow-crowned night heron (*Nycticorax violacea*), the black-crowned night heron  
26 (*Nycticorax nycticorax*), the aster-like boltonia (*Boltonia asteroides*), a sedge species (*Carex*  
27 *shortiana*), the flat-stemmed spike-rush (*Eleocharis compressa*), the ellisia (*Ellisia nyctelea*), the  
28 bronze copper (*Lycaena hyllus*), and the formerly Federally-listed birds, the bald eagle and  
29 peregrine falcon (DCNR 2008; PGC 2008; AmerGen 2008; PNHP 2008). Section 2.2.7 of this  
30 report describes these species in greater detail.

31 The NRC staff encourages AmerGen and FirstEnergy Corporation (FirstEnergy), who owns the  
32 transmission lines, to report the existence of any Federally- or State-listed endangered or  
33 threatened species within or near the transmission line right-of-ways (ROWs) to DCNR and/or  
34 FWS if any such species are identified during the license renewal term. In particular, if any  
35 evidence of injury to or mortality of migratory birds or threatened or endangered species is  
36 observed within the corridor during the license renewal period, the NRC staff encourages  
37 AmerGen and FirstEnergy to promptly report this to the appropriate wildlife management  
38 agencies. Additionally, the NRC staff encourages AmerGen to continue reporting information  
39 concerning the peregrine falcon pair and their young that nest on the reactor building to the  
40 Commonwealth of Pennsylvania.

41 Operation of the TMI-1 site and its associated transmission lines is not expected to adversely  
42 affect any threatened or endangered species during the license renewal term. Therefore, the  
43 NRC staff concludes that adverse impacts to threatened or endangered species during the

1 license renewal term would be SMALL. Mitigation measures currently in place at the TMI-1 site  
 2 include nest construction and placement for several species, including the peregrine falcon and  
 3 osprey; environmental review checklists; environmental evaluation forms; and best  
 4 management practices, all of which minimize the effects of plant operation on terrestrial species.  
 5 These current mitigation measures are found to be adequate.  
 6

7 **4.8 Human Health**

8 The human health issues applicable to TMI-1 are discussed below and listed in Table 4-8 for  
 9 Category 1, Category 2, and uncategorized issues.

10 **Table 4-8. Human Health Issues.** *Table B-1 of Appendix B to Subpart A of 10 CFR*  
 11 *Part 51 contains more information on these issues.*

Issues	GEIS Section	Category
Microbiological organisms (occupational health)	4.3.6	1
Microbiological organisms (public health, for plants using small rivers)	4.3.6	2
Noise	4.3.7	1
Radiation exposures to public (license renewal term)	4.6.1, 4.6.2	1
Occupation radiation exposures (license renewal term)	4.6.3	1
Electromagnetic fields – acute effects (electric shock)	4.5.4.1	2
Electromagnetic fields – chronic effects	4.5.4.2	Uncategorized

12

13 **4.8.1 Generic Human Health Issues**

14 The staff did not identify any new and significant information during its review of the AmerGen  
 15 environmental report, the site audit, or the scoping process. Therefore, there are no impacts  
 16 related to these issues beyond those discussed in the GEIS. For these issues, the GEIS  
 17 concluded that the impacts are SMALL, and additional site-specific mitigation measures are not  
 18 likely to be sufficiently beneficial to be warranted.

19 TMI-1 conducts an annual Radiological Environmental Monitoring Program (REMP) in which  
 20 radiological impacts to the employees, the public, and the environment in and around the TMI-1  
 21 site are monitored, documented, and compared to the appropriate standards. The objectives of  
 22 the REMP include the following:

- 23 • Measure and evaluate the levels of radiation and radioactive material in the environs  
 24 around the TMI-1 site to assess the radiological impacts, if any, of plant operation on the  
 25 environment.
- 26 • Supplement the results of the radiological effluent monitoring program by verifying that  
 27 the measurable concentrations of radioactive material and levels of radiation are not  
 28 higher than expected based on the measurement of radioactive effluents and modeling  
 29 for the applicable exposure pathways.

## Environmental Impacts of Operation

- 1 • Demonstrate compliance with the requirements of applicable Federal regulatory  
2 agencies.

3  
4 Two reports summarize radiological information about the TMI-1 site—the annual radiological  
5 environmental operating report and the annual radioactive effluent release report. The TMI-1  
6 offsite dose calculation manual (ODCM) specifies limits for all radiological releases (AmerGen  
7 2007). The ODCM is used to meet Federal standards and requirements. The TMI-1 REMP  
8 samples environmental media in the environs around the site to analyze and measure the  
9 radioactivity levels that may be present. The media samples are representative of the radiation  
10 exposure pathways to the public from all plant radioactive effluents. The REMP measures the  
11 aquatic and atmospheric environment, as well as the ambient gamma radiation, for radioactivity  
12 in the vicinity of the TMI-1 site. Ambient gamma radiation pathways include radiation from  
13 buildings and plant structures and airborne material that may be released from the plant. In  
14 addition, the REMP also measures background radiation (i.e., cosmic sources, global fallout,  
15 and naturally occurring radioactive material, including radon). Thermoluminescent dosimeters  
16 (TLDs) are used to measure direct radiation. The atmospheric environmental monitoring  
17 consists of sampling the air for particulates and radioiodine. Terrestrial environmental  
18 monitoring consists of analyzing samples of milk and food products. The aquatic environmental  
19 monitoring consists of analyzing samples of surface water, drinking water, stormwater, ground  
20 water, and fish and sediment from the Susquehanna River.

21 The NRC staff reviewed the TMI-1 radioactive environmental operating reports for 2003 through  
22 2007 to look for any significant impacts to the environment or any unusual trends in the data  
23 (AmerGen 2004, 2005, 2006b, 2007a, 2008a). During 2007, no plant-related activation or fission  
24 products were detected in airborne and foodborne samples. The only radionuclide attributable to  
25 plant operation detected in 2007 was tritium, which was measured in samples of surface, storm,  
26 effluent, and drinking water (AmerGen 2008a). No unusual trends were noted and all reported  
27 data on the radionuclides detected in environmental samples were below applicable NRC  
28 reporting levels and showed no significant or measurable impact from the operations at TMI-1  
29 (AmerGen 2008a).

30 The Pennsylvania Department of Environmental Protection (PADEP), Bureau of Radiation  
31 Protection (BRP), also conducts a comprehensive environmental radiation monitoring program  
32 in Pennsylvania that routinely samples and analyzes selected environmental media in  
33 conjunction with TMI-1. The BRP environmental radiation monitoring program includes TLDs for  
34 monitoring direct radiation on samples of air, vegetation, milk, drinking water, fish, and river  
35 sediment. The results of the BRP 2003–2004 environmental radiation monitoring program  
36 showed detectable levels of radioactivity attributable to operation of TMI-1. In 2003, low levels of  
37 tritium were detected in drinking water samples near the plant site, but no reactor-produced  
38 radionuclides were detected in the fish, produce, air or milk samples. However, radioactivity  
39 from remnants of atomic weapons testing and the accident at Chernobyl was detected in water  
40 and milk samples. The report concluded, “The results of the 2003 and 2004 environmental  
41 sampling program indicate that Pennsylvanians have not been exposed to levels of radiation  
42 above normal background. This has been determined by comparing samples collected around  
43 nuclear facilities with those from locations that would not be influenced by such facilities.”  
44 (PADEP 2008).

1 In addition to the routine REMP, the applicant established an onsite ground water protection  
2 program in 2006. The program is designed to monitor the onsite environment for indication of  
3 leaks from plant systems and pipes carrying liquids with radioactive material. The results were  
4 reported as Appendix F to the TMI-1 2007 annual radiological environmental operating report.  
5 The results indicated that tritium was detected in 15 ground water samples at 3 locations at  
6 concentrations greater than the U.S. Environmental Protection Agency (EPA) drinking water  
7 standard (and the NRC reporting limit) of 20,000 picocuries per liter (pCi/L) (740,000 Becquerels  
8 per cubic meter [Bq/m<sup>3</sup>]). Tritium was detected in 47 of 68 ground water monitoring locations.  
9 The tritium concentrations ranged from 206 pCi/L (7622 Bq/m<sup>3</sup>) to 29,600 pCi/L (1,095,200  
10 Bq/m<sup>3</sup>). Tritium that was detected in ground water at the station is believed to be from a leak in  
11 the condensate de-ice line, historical releases, and/or background radiation. There were no  
12 known active releases at the end of 2007 into the ground water at the TMI-1 site. Based on the  
13 sample results, the applicant calculated that the potential dose to a member of the public from  
14 drinking this water was less than 0.008 millirems (mrem) (0.00008 milliSieverts [mSv]). This  
15 dose is a very small fraction of the dose design objective specified in Appendix I to 10 CFR Part  
16 50, "Numerical Guide for Design Objectives and Limiting Conditions for Operation to Meet the  
17 Criterion 'As Low as is Reasonably Achievable' for Radioactive Material in Light-Water-Cooled  
18 Nuclear Power Reactor Effluents."

19 Historical data on releases from TMI-1 and the resultant dose calculations demonstrate that the  
20 amount of radiation received to a hypothetical maximally exposed individual in the vicinity of  
21 TMI-1 is a small fraction of the limits specified in 10 CFR Part 20, the as low as is reasonably  
22 achievable (ALARA) dose design objectives in Appendix I to 10 CFR Part 50, and EPA's  
23 radiation standards in 40 CFR Part 190, "Environmental Radiation Protection Standards for  
24 Nuclear Power Operations." For 2007, dose estimates were calculated based on actual liquid  
25 and gaseous effluent release data and conservative models to simulate the transport  
26 mechanisms. The TMI-1 2007 annual radioactive effluent release report (AmerGen 2008b)  
27 describes the results. The following summarizes the calculated hypothetical maximum dose to  
28 an individual located at the TMI-1 site boundary from liquid and gaseous effluents released  
29 during 2007:

- 30 • The maximum whole-body dose to an offsite member of the general public from liquid  
31 effluents was 0.056 mrem (0.00056 mSv), which is well below the 3-mrem dose criteria  
32 in Appendix I to 10 CFR 50.
- 33 • The maximum whole-body dose to the likely most-exposed member of the general public  
34 from gaseous effluents was 0.025 mrem (0.0025 mSv), which is below the 5-mrem dose  
35 criteria in Appendix I to 10 CFR 50.
- 36 • The maximum whole-body dose to the likely most-exposed member of the general public  
37 from all radioactive emissions (radioactive gaseous and liquid effluents and direct  
38 radiation shine) was 0.33 mrem (0.0033 mSv), which is below the 25-mrem limit in 40  
39 CFR Part 190.

40  
41 Based on the review and assessment of the TMI-1 radioactive waste system performance in  
42 controlling radioactive effluents and the resultant doses to members of the public in  
43 conformance with the ALARA criteria, the NRC staff found that the 2007 radiological data for  
44 TMI-1 are consistent, with reasonable variation attributable to operating conditions and outages,  
45 with the 5-year historical radiological effluent releases and resultant doses. These results

## Environmental Impacts of Operation

1 demonstrate that TMI-1 is operating in compliance with Federal radiation protection standards  
2 contained in Appendix I to 10 CFR Part 50, 10 CFR Part 20, and 40 CFR Part 190. Continued  
3 compliance with regulatory requirements is expected during the license renewal term; therefore,  
4 the impacts from radioactive effluents are not expected to change.

5 Based on the applicant's assertion that refurbishment activities are planned, slightly higher  
6 doses to members of the public, and the resultant environmental impacts, are expected from  
7 TMI-1 during the refurbishment period. However, based on past regulatory compliance, the  
8 dose to a maximally exposed individual in the vicinity of TMI-1 for the refurbishment period is  
9 expected to continue to be a small fraction of the limits and standards specified in 10 CFR Part  
10 20, Appendix I to 10 CFR Part 50, and 40 CFR Part 190.  
11

### 12 4.8.2 Microbiological Organisms – Public Health

13 Table B-1 of Appendix B to Subpart A of 10 CFR Part 51 lists the effects of thermophilic  
14 microbiological organisms on human health as a Category 2 issue and requires the conduct of a  
15 plant-specific evaluation before license renewal for those plants using closed-cycle cooling that  
16 are located on a small river. The average annual flow of the Susquehanna River at the nearest  
17 measuring station to TMI-1 is approximately  $1.09 \times 10^{12}$  ft<sup>3</sup>/yr ( $3.08 \times 10^{10}$  cubic meters per year  
18 (m<sup>3</sup>/yr)) (Durlin and Schaffstall 2005). This is less than the  $3.15 \times 10^{12}$  ft<sup>3</sup>/yr ( $9 \times 10^{10}$  m<sup>3</sup>/yr), which  
19 is the threshold value in 10 CFR 51.53(c)(3)(ii)(G) for thermal discharge to a small river.  
20 Nevertheless, recreational uses of the Susquehanna River in the vicinity of TMI-1, which include  
21 boating, fishing, and swimming, create the potential for human exposure to thermophilic  
22 microbiological organisms. Consequently, the effects of its discharge on microbiological  
23 organisms must be addressed for TMI-1 license renewal.

24 The Category 2 designation is based on the magnitude of the potential public health impacts  
25 associated with thermal enhancement of enteric pathogens such as *Salmonella* spp. and  
26 *Shigella* spp., the *Pseudomonas aeruginosa* bacterium, the pathogenic strain of the free-living  
27 amoebae *Naegleria* spp., and a number of species from genus *Legionella* (NRC 1996).  
28 Thermophilic biological organisms generally occur at temperatures of 77 to 176 degrees  
29 Fahrenheit (°F) (25 to 80 degrees Celsius (°C)), with optimal growth occurring between 122 and  
30 150 °F (50 and 66 °C) and minimum tolerance of 68°F (20 °C) (Joklik and Willett 1976).  
31 However, thermal preference and tolerances vary across the bacteria family.

32 *P. aeruginosa* is an opportunistic pathogen that causes serious and sometimes fatal infections  
33 in immunocompromised individuals by producing and releasing toxins. It has an optimal growth  
34 temperature of 99 °F (37 °C) (Todar 2007). *Legionella* spp. consists of at least 46 species and  
35 70 serogroups and is responsible for Legionnaires' disease, with the onset of pneumonia in the  
36 first 2 weeks of exposure. Risk groups for *Legionella* spp. include the elderly, cigarette smokers,  
37 persons with chronic lung or immunocompromising disease, and persons receiving  
38 immunosuppressive drugs. *Legionella* spp. grows best at 90 to 105 °F (32 to 41 °C) (CDC  
39 2007). *Salmonella typhimurium* and *Salmonella enteritidis* are two of the more common species  
40 of Enterobacteriaceae which cause fever, abdominal cramps, and diarrhea. *Salmonella* spp. can  
41 occasionally establish localized infection (e.g., septic arthritis) or can progress to sepsis. All  
42 ages can be affected, but groups at greatest risk for severe or complicated disease include  
43 infants, the elderly, and persons with compromised immune systems. *Salmonella* spp. occurs at

1 temperatures between 50 and 120 °F (10 and 49 °C) (CDC 2007), with optimal growth occurring  
2 at 95 to 99 °F (35 to 37 °C) (ESR 2002). The pathogenic amoeba flagellate *Naegleria fowleri* is  
3 the causative agent of human primary amoebic meningoencephalitis. All ages can be affected,  
4 but groups at greatest risk for severe or complicated disease include infants, the elderly, and  
5 persons with compromised immune systems. *Naegleria* spp. is ubiquitous in nature and can be  
6 enhanced in thermally altered water bodies at temperatures ranging from 95 to 106 °F (35 to 41  
7 °C) or higher, but this organism is rarely found in water cooler than 95 °F (35 °C), and infection  
8 rarely occurs at these water temperatures (Tyndall et al. 1989).

9 The maximum temperature of the discharge stream on September 11, 2007, was approximately  
10 101.1 °F (38.4 °C), with a maximum ambient river temperature of 81.5 °F (27.5 °C) (AmerGen  
11 2008). As described in the GEIS (NRC 1996), nuclear power plants that discharge to “small  
12 rivers” have the greatest chance of affecting the public by increases in thermophilic  
13 microbiological organism populations. A small river is defined as one with a monthly average  
14 flow rate of less than 2,800 m<sup>3</sup>/s (100,000 ft<sup>3</sup>/s). The annual average flow rate of the  
15 Susquehanna River at the nearest measuring station to TMI-1 is approximately 1.09x10<sup>12</sup> ft<sup>3</sup>/yr  
16 (3.08x10<sup>10</sup> m<sup>3</sup>/yr), which equates to 978.1 cubic meters per second (m<sup>3</sup>/s) (34,540 cubic feet per  
17 second (ft<sup>3</sup>/s)) (Durlin and Schaffstall 2005). The average mechanical draft cooling tower basin  
18 flow rate from the current operation is about 5,000 gallons per minute (11.4 ft<sup>3</sup>/s) per unit. This  
19 flow rate is less than 1 percent of the annual average flow rate of the Susquehanna River. Thus,  
20 at a given volume of the discharge stream with a maximal temperature of 101.1 °F (38.4 °C),  
21 there will be approximately 100 equivalent diluting volumes of the Susquehanna River water  
22 with a maximal temperature of 81.5 °F (27.5 °C). When a higher temperature system comes in  
23 physical contact with a lower temperature system, there will be a net transfer of heat from the  
24 higher temperature system to the lower temperature system, until the two systems reach  
25 thermal equilibrium (Adkins 1984). As such, when the plant discharge temperature is at its  
26 maximum and the ambient Susquehanna River water is at its maximum, the temperature range  
27 of the Susquehanna River (below the discharge outfall) would maximally be 91.3 °F (33.0 °C).  
28 This temperature range is well outside the optimal growth temperature range of thermophilic  
29 microbiological organisms, which is between 122 °F and 150 °F (50 and 66 °C) (Joklik and  
30 Willett 1976). Hence, such organisms are not expected to cause any significant public health  
31 risks.

32 During the year, ambient river temperatures average 33.8 °F (1 °C) with a maximum  
33 temperature of 81.5 °F (27.5 °C) (NRC 1976). The maximum temperature of the discharge  
34 stream (at the discharge monitoring pit and before the water mixes with the Susquehanna River)  
35 on September 11, 2007, was approximately 101.1 °F (38.4 °C) (AmerGen 2008). The ambient  
36 river temperature was 81.5 °F (27.5 °C). Assume the temperature of the heated effluent area or  
37 mixing zone is 101.1 °F (38.4 °C), the lowest daily mean river flows are 34,540 ft<sup>3</sup>/s (978.1 m<sup>3</sup>/s)  
38 (Durlin and Schaffstall 2005), and the mixing zone is located 16 feet (4.88 meters) offshore and  
39 82 feet (25 meters) downstream of the discharge monitoring pit (AmerGen 2008). These  
40 thermophilic microbiological organisms would be entrained through this thermal plume for about  
41 30 seconds to less than five minutes, based on a river flow rate of 34,540 ft<sup>3</sup>/s (978.1 m<sup>3</sup>/s).  
42 Because the growth rate for thermophilic microbiological organisms is measured in hours to  
43 days (Hendricks 1972), it is not expected that the short period of plume passage would notably  
44 affect growth rates of thermophilic microbiological organisms compared to ambient river  
45 temperatures. Therefore, thermophilic microbiological organisms are not expected to cause any  
46 significant public health risks.

## Environmental Impacts of Operation

1 The current National Pollutant Discharge Elimination System (NPDES) permit requires TMI-1 to  
2 monitor fecal coliform in the plant's sewage treatment effluent. Fecal coliform bacteria are  
3 classified within the family Enterobacteriaceae. The most common species of fecal coliform is  
4 *Escherichia coli*, a prokaryotic, gram-negative, rod-shaped bacteria. The value of determining  
5 fecal coliform concentrations is to establish the extent to which the Susquehanna River has  
6 been polluted with fecal wastes. Their presence in the water indicates the potential for other  
7 pathogenic microbes, including those that cause typhoid fever, bacterial or viral gastroenteritis,  
8 or hepatitis A (NAS 2004). TMI-1 has been collecting river water samples once per quarter for  
9 fecal coliform analysis and has been implementing a disinfection program of the TMI-1 sewage  
10 treatment plant effluent in compliance with TMI-1 NPDES permit requirements. In addition, the  
11 NPDES permit requires TMI-1 to control disease-producing organisms during the swimming  
12 season (May 1 through September 30) through "effective disinfection" and to impose a fecal  
13 coliform count limit of 200 cells per 100 milliliters.

14 AmerGen consulted the PADEP Water Management Program to determine whether there was  
15 any concern about the potential occurrence of thermophilic microbiological organisms in the  
16 Susquehanna River at the TMI-1 location (AmerGen 2008). PADEP indicated that it agrees with  
17 AmerGen's conclusion that the discharge of cooling water from the operation of TMI-1 over the  
18 license renewal term would not stimulate growth of thermophilic pathogens (AmerGen 2008).

19 Available data assembled by the U.S. Centers for Disease Control and Prevention (CDC) for the  
20 years 1999 to 2004 (CDC 2001, 2002, 2002a, 2003, 2003a, 2004, 2005, 2006, 2007b) report no  
21 occurrence of waterborne disease outbreaks in the Commonwealth of Pennsylvania resulting  
22 from exposure to the thermophilic microbiological organisms *Naegleria fowleri* and  
23 *Pseudomonas aeruginosa* from the operation of TMI-1. Outbreaks of legionellosis,  
24 salmonellosis, or shigellosis that occurred in the Commonwealth of Pennsylvania were within the  
25 range of national trends (CDC 2001, 2002, 2002a, 2003, 2003a, 2004, 2005, 2006, 2007b) in  
26 terms of cases per 100,000 population or total cases per year, and the outbreaks were  
27 associated with hotel pools and spas.

28 The NRC staff independently reviewed the AmerGen environmental report and visited the TMI-1  
29 site. Based on the evaluation presented above, thermophilic microbiological organisms are not  
30 likely to present a public health hazard as a result of TMI-1 discharges to the Susquehanna  
31 River. The NRC staff concludes that impacts on public health from thermophilic microbiological  
32 organisms from continued operation of TMI-1 in the license renewal period would be SMALL.

33 The staff identified a variety of measures that could mitigate the potential impacts of  
34 thermophilic microbiological organism resulting from continued operation of TMI-1. These  
35 mitigation measures include periodically monitoring for thermophilic microbiological organisms  
36 in the water and sediments near the discharge, as well as prohibiting recreational use near the  
37 discharge plume. These mitigation measures could reduce human health impacts by minimizing  
38 public exposures to thermophilic microbiological organisms. The staff did not identify any cost-  
39 benefit studies applicable to the mitigation measures mentioned above.

40



### 1 **4.8.3 Electromagnetic Fields – Acute Shock**

2 Based on the GEIS, the NRC found that electric shock resulting from direct access to energized  
3 conductors or from induced charges in metallic structures has not been a problem at most  
4 operating plants and generally is not expected to be a problem during the period of extended  
5 operation. However, a site-specific review is required to determine the significance of the  
6 electric shock potential along the portions of the transmission lines within the scope of the  
7 supplemental EIS.

8 The GEIS states that, without a review of the conformance of each nuclear plant transmission  
9 line with National Electrical Safety Code (NESC) (NESC 2007) rules, it is not possible to  
10 determine the significance of the electric shock potential. Evaluation of individual plant  
11 transmission lines is necessary because the issue of electric shock safety was not addressed in  
12 the licensing process for some plants. For other plants, land use in the vicinity of transmission  
13 lines may have changed, or power distribution companies may have chosen to upgrade line  
14 voltage. To comply with the requirements of 10 CFR 51.53(c)(3)(ii)(H), the applicant must  
15 provide an assessment of the potential shock hazard if the transmission lines that were  
16 constructed for the specific purpose of connecting the plant to the transmission system do not  
17 meet the recommendations of the NESC for preventing electric shock from induced currents.

18 An analysis of the conformance of the TMI-1 transmission lines with the NESC standard was  
19 conducted using computer-modeled data of induced current under the transmission lines.  
20 Objects located near the transmission lines can become electrically charged because of their  
21 immersion in the electromagnetic field surrounding the lines. This electrical charge results in a  
22 current that flows through the object to the ground. This current is called “induced” because  
23 there is no direct connection between the line and the object. The induced current can also flow  
24 to the ground through the body of a person who touches the electrically charged object. An  
25 object that is insulated from the ground can actually store an electrical charge, becoming what is  
26 called “capacitively charged.” A person standing on the ground and touching a vehicle or a  
27 fence receives an electrical shock from the sudden discharge of the capacitive charge through  
28 the person’s body to the ground. After the initial discharge, a steady-state current can develop,  
29 with the magnitude of the current depending upon several factors. These factors include the  
30 strength of the electric field (dependent on the voltage of the transmission line and its height and  
31 geometry), the size of the object on the ground, and the extent to which the object is grounded  
32 (AmerGen 2008).

33 As described above, four 230-kilovolt (kV) transmission lines were specifically constructed to  
34 distribute power from TMI-1 to the electrical grid. AmerGen began its analysis of these lines by  
35 identifying the limiting case for each line, that is, the configuration along each line where the  
36 potential for induced-current shock would be greatest. Once the limiting case was identified, the  
37 electric field strength for each transmission line was calculated, and the induced current was  
38 calculated. AmerGen calculated electric field strength and induced current using a computer  
39 code called ACDCLINE, produced by the Electric Power Research Institute. The results of this  
40 program have been field-verified through actual electrostatic field measurements by several  
41 utilities. The input parameters for the ACDCLINE program include the design features of the  
42 limiting-case scenario, the NESC requirement that line sag be determined at a conductor  
43 temperature of 120 °F, and the maximum vehicle size under the lines (a tractor-trailer). The  
44 analysis determined that none of the transmission lines have the capacity to induce greater than

## Environmental Impacts of Operation

1 5 milliamperes in a vehicle parked beneath the lines (Table 4-9). Therefore, the TMI-1  
2 transmission lines conform to the NESC provisions for preventing electric shock from induced  
3 current (AmerGen 2008).

4 FirstEnergy has surveillance and maintenance procedures that provide assurance that design  
5 ground clearances will not change. These procedures include routine aerial inspections that  
6 check for evidence of clearance problems, including encroachments, broken conductors, broken  
7 or leaning structures, and signs of burning trees. In addition, ground-level inspections include  
8 examination of clearances at questionable locations, evaluation of the integrity of structures,  
9 and surveillance for dead or diseased trees that may fall on the lines. Problems noted during  
10 any inspection are identified for corrective action by the appropriate organization (AmerGen  
11 2008).

12 **Table 4-9. Results of Induced Current Analysis.**

<b>Transmission Line</b>	<b>Voltage (kilovolts)</b>	<b>Maximum Induced Current (milliamperes)</b>
Line No. 1051-TMI-1 plant to Jackson	230	1.09
Line No. 1091-TMI-1 plant to Middletown Junction	230	1.38
Line No. 1092-TMI-1 plant to Middletown Junction	230	2.09
Line from TMI-1 plant to the 500-kV substation	230 <sup>(a)</sup>	1.33

(a) Line from TMI-1 plant to the 500-kV substation was designed to operate at 500 kilovolts, but it currently operates at 230 kilovolts

Source: AmerGen 2008

13 The staff has reviewed the available information, including the applicant's evaluation and  
14 computational results, the site visit, the scoping process, and other public sources of  
15 information. Based on this information, the staff evaluated the potential impacts of electric shock  
16 resulting from operation of TMI-1 and its associated transmission lines. The staff concludes that  
17 the potential impacts of electric shock during the renewal term would be SMALL.

18 The staff identified a variety of measures that could mitigate potential acute electromagnetic  
19 field impacts resulting from continued operation of the TMI-1 transmission lines. These  
20 mitigation measures include limiting public access to transmission line structures, installing  
21 signs at road crossings, and increasing transmission line clearances.

22 These mitigation measures could reduce human health impacts by minimizing public exposures  
23 to electric shock hazards. NESC rules, as specified in Part 2, Rules 232C1c and 232D3c,  
24 contain provisions that are considered necessary for the protection of employees and the public  
25 from acute electromagnetic field hazards associated with transmission lines, which currently  
26 apply to TMI-1 and would apply during the license renewal period. AmerGen currently meets  
27 these rules. The staff did not identify any cost benefit studies applicable to the mitigation  
28 measures mentioned above.  
29

1 **4.8.4 Electromagnetic Fields – Chronic Effects**

2 The GEIS did not designate the chronic effects of 60-hertz electromagnetic fields from power  
3 lines as either Category 1 or 2; such a designation will not occur until a scientific consensus is  
4 reached on the health implications of these fields.

5 The potential for chronic effects from these fields continues to be studied and is not known at  
6 this time. The National Institute of Environmental Health Sciences (NIEHS) directs related  
7 research through the U.S. Department of Energy (DOE). An NIEHS (1999) report contains the  
8 following conclusion which is supported by the recently published Environmental Health Criteria  
9 Monograph No. 238 (2007):

10 The NIEHS concludes that ELF-EMF [extremely low frequency-electromagnetic  
11 field] exposure cannot be recognized as entirely safe because of weak scientific  
12 evidence that exposure may pose a leukemia hazard. In our opinion, this finding  
13 is insufficient to warrant aggressive regulatory concern. However, because  
14 virtually everyone in the United States uses electricity and therefore is routinely  
15 exposed to ELF-EMF, passive regulatory action is warranted such as a continued  
16 emphasis on educating both the public and the regulated community on means  
17 aimed at reducing exposures. The NIEHS does not believe that other cancers or  
18 non-cancer health outcomes provide sufficient evidence of a risk to currently  
19 warrant concern.

20 This statement is not sufficient to cause the NRC staff to change its position with respect to the  
21 chronic effects of electromagnetic fields. This position is expressed in Footnote 5 to Table B-1 of  
22 Appendix B to Subpart A of 10 CFR Part 51 as follows:

23 If in the future, the Commission finds that, contrary to current indications, a  
24 consensus has been reached by appropriate Federal health agencies that there  
25 are adverse health effects from electromagnetic fields, the Commission will  
26 require applicants to submit plant-specific reviews of these health effects as part  
27 of their license renewal applications. Until such time, applicants for license  
28 renewal are not required to submit information on this issue.

29 The NRC staff considers the GEIS finding of “Uncertain” still appropriate and will continue to  
30 follow developments on this issue.

31 **4.9 Socioeconomics**

32 The socioeconomic issues applicable to TMI-1 are discussed below and listed in Table 4-10 on  
33 the following page for Category 1, Category 2, and uncategorized issues.

Environmental Impacts of Operation

1 **Table 4-10. Socioeconomic Issues.** Section 2.2.9 of this report describes the  
 2 *socioeconomic conditions near TMI-1.*

Issues	GEIS Section	Category
Housing Impacts	4.7.1	2
Public Services: public safety, social services, and tourism and recreation	4.7.3; 4.7.3.3; 4.7.3.4; 4.7.3.6	1
Public Services: public utilities	4.7.3.5	2
Public Services: education (license renewal)	4.7.3.1	1
Offsite Land Use (license renewal term)	4.7.4	2
Public Services: transportation	4.7.3.2	2
Historic and Archaeological Resources	4.7.7	2
Aesthetic Impacts (license renewal term)	4.7.6	1
Aesthetic impacts of transmission lines (license renewal term)	4.5.8	1
Environmental Justice	Not addressed <sup>(a)</sup>	Uncategorized <sup>(a)</sup>

(a) Guidance related to environmental justice was not in place at the time the GEIS and the associated revisions to 10 CFR Part 51 were prepared. Therefore, environmental justice must be addressed in plant-specific reviews.

3

4 **4.9.1 Generic Socioeconomic Issues**

5 The NRC staff reviewed and evaluated the TMI-1 Environmental Report, scoping comments,  
 6 other available information, and visited TMI-1 in search of new and significant information that  
 7 would change the conclusions presented in the GEIS. No new and significant information was  
 8 identified during this review and evaluation. Therefore, it is expected that there would be no  
 9 impacts related to these Category 1 issues during the renewal term beyond those discussed in  
 10 the GEIS.

11

12 **4.9.2 Housing Impacts**

13 Appendix C to the GEIS presents a population characterization method based on two factors;  
 14 sparseness and proximity (see Section C.1.4). Sparseness measures population density within  
 15 20 mi (32 km) of the site, and proximity measures population density and city size within 50 mi  
 16 (80 km). Each factor has categories of density and size (see Table C.1). A matrix is used to rank  
 17 the population category as low, medium, or high (see Figure C.1).

18 According to the 2000 Census, approximately 787,800 people lived within 20 mi (32 km) of TMI-  
 19 1, which equates to a population density of 627 persons per square mile (AmerGen 2008). This  
 20 density translates to the least sparse Category 4 (greater than or equal to 120 persons per

1 square mile within 20 mi [32 km]). Approximately 2,546,500 people live within 50 mi (80 km) of  
2 TMI-1 (AmerGen 2008). This equates to a population density of 325 persons per square mile.  
3 Applying the GEIS proximity measures, TMI-1 is classified as proximity Category 4 (greater than  
4 or equal to 190 persons per square mile within 50 mi [80 km]). Therefore, according to the  
5 sparseness and proximity matrix presented in the GEIS, TMI-1 rankings of sparseness Category  
6 4 and proximity Category 4 result in the conclusion that TMI-1 is located in a high population  
7 area.

8 Table B-1 of Appendix B to Subpart A of 10 CFR Part 51 states that impacts on housing  
9 availability are expected to be of small significance in high-density population areas where  
10 growth control measures are not in effect. Since TMI-1 is located in a high population area, and  
11 Dauphin and Lancaster Counties are not subject to growth control measures that would limit  
12 housing development, any changes in TMI-1 employment would have little noticeable effect on  
13 housing availability in these counties. Since AmerGen has indicated that they have no plans to  
14 add non-outage employees during the license renewal period, non-outage employment levels at  
15 TMI-1 would remain relatively constant with no additional demand for permanent housing during  
16 the license renewal term. In addition, the number of available housing units has kept pace with  
17 or exceeded the increase in area population. Based on this information, there would be no  
18 impact on permanent housing during the license renewal term beyond what is currently being  
19 experienced.

20 However, AmerGen indicated in their environmental report that TMI-1 steam generators would  
21 be replaced prior to the license renewal term. AmerGen estimates that steam generator  
22 replacement would require a one-time increase in the number of refueling outage workers for up  
23 to 70 days at TMI-1 (AmerGen 2008). These additional workers would create an additional  
24 demand for temporary (rental) housing in the immediate vicinity of TMI-1. The impacts of TMI-1  
25 steam generator replacement are discussed in Chapter 3 of this draft supplemental EIS.  
26

#### 27 **4.9.3 Public Services: Public Utility Impacts**

28 Impacts on public utility services are considered SMALL if there is little or no change in the  
29 ability of the system to respond to demand and thus there is no need to add capital facilities.  
30 Impacts are considered MODERATE if service capabilities are overtaxed during periods of peak  
31 demand. Impacts are considered LARGE if services (e.g., water, sewer) are substantially  
32 degraded and additional capacity is needed to meet ongoing demand. The GEIS indicated that,  
33 in the absence of new and significant information to the contrary, the only impacts on public  
34 utilities that could be significant are impacts on public water supplies.

35 Analysis of the impacts on the public water and sewer systems considered both plant demand  
36 and plant-related population growth. Section 2.2.8 of this draft supplemental EIS describes the  
37 TMI-1 permitted withdrawal rate and actual use of water.

38 Since AmerGen has indicated that they have no plans to add non-outage employees during the  
39 license renewal period, non-outage employment levels at TMI-1 would remain relatively  
40 unchanged with no additional demand for public water and sewer services. Public water  
41 systems in the region would be adequate to meet the demands of residential and industrial  
42 customers in the area. Therefore, there would be no additional impact to public water and sewer  
43 services during the license renewal term beyond what is currently being experienced.

## Environmental Impacts of Operation

1 As discussed in Section 4.9.2, AmerGen indicated in their environmental report that TMI-1  
2 steam generators would be replaced prior to the license renewal term (AmerGen 2008). The  
3 additional number of refueling outage workers needed to replace the steam generators would  
4 cause a short-term increase in the amount of public water and sewer services used in the  
5 immediate vicinity of TMI-1. These impacts are discussed in Chapter 3 of this draft  
6 supplemental EIS.  
7

### 8 **4.9.4 Offsite Land Use – License Renewal Period**

9 Table B-1 of Appendix B to Subpart A of 10 CFR Part 51 notes that “significant changes in land  
10 use may be associated with population and tax revenue changes resulting from license  
11 renewal.”

12 Section 4.7.4 of the GEIS defines the magnitude of land-use changes as a result of plant  
13 operation during the period of extended operation as follows:

14 SMALL - Little new development and minimal changes to an area's land-use pattern.

15 MODERATE - Considerable new development and some changes to the land-use pattern.

16 LARGE - Large-scale new development and major changes in the land-use pattern.

17 Tax revenue can affect land use because it enables local jurisdictions to provide the public  
18 services (e.g., transportation and utilities) necessary to support development. Section 4.7.4.1 of  
19 the GEIS states that the assessment of tax-driven land-use impacts during the license renewal  
20 term should consider (1) the size of the plant's payments relative to the community's total  
21 revenues, (2) the nature of the community's existing land-use pattern, and (3) the extent to  
22 which the community already has public services in place to support and guide development. If  
23 the plant's tax payments are projected to be small relative to the community's total revenue, tax-  
24 driven land-use changes during the plant's license renewal term would be SMALL, especially  
25 when the community has pre-established patterns of development and has provided adequate  
26 public services to support and guide development.

27 Section 4.7.2.1 of the GEIS states that if tax payments by the plant owner are less than 10  
28 percent of the taxing jurisdiction's revenue, the significance level would be SMALL. If the plant's  
29 tax payments are projected to be medium to large relative to the community's total revenue,  
30 new tax-driven land-use changes would be MODERATE. If the plant's tax payments are  
31 projected to be a dominant source of the community's total revenue, new tax-driven land-use  
32 changes would be LARGE. This would be especially true when the community has no pre-  
33 established pattern of development or has not provided adequate public services to support and  
34 guide development.

### 35 Population-Related Impacts

36 Since AmerGen has indicated that they have no plans to add non-outage employees during the  
37 license renewal period, there would be no noticeable change in land use conditions in the  
38 vicinity of TMI-1. Therefore, there would be no population-related land use impacts during the  
39 license renewal term beyond those already being experienced.

1 As discussed in Section 4.9.2, AmerGen indicated in their environmental report that TMI-1  
2 steam generators would be replaced prior to the license renewal term (AmerGen 2008). Due to  
3 the short amount of time needed to replace the steam generators, the additional number of  
4 refueling outage workers would not cause any permanent population-related land use changes  
5 in the immediate vicinity of TMI-1. These impacts are discussed in Chapter 3 of this draft  
6 supplemental EIS.

#### 7 Tax Revenue-Related Impacts

8 As previously discussed in chapter 2, AmerGen pays annual real estate taxes to Dauphin  
9 County, Londonderry Township, and the Lower Dauphin School District. For the three-year  
10 period from 2003 through 2005, tax payments to Dauphin County represented 0.2 percent of the  
11 County's total annual property tax revenues, and payments to Londonderry Township  
12 represented approximately 0.3 to 0.5 percent of the Township's total annual property tax  
13 revenues. AmerGen's tax payments to the Lower Dauphin School District, for the period 2003  
14 through 2005, represented 1.7 to 2.3 percent of the District's total annual property tax revenues.

15 Since AmerGen started making payments to local jurisdictions, population levels and land use  
16 conditions in Dauphin County and Londonderry Township have not changed significantly, which  
17 might indicate that these tax revenues have had little or no affect on land use activities within  
18 the county. However, discontinuing the current level of tax revenues could have a negative  
19 economic impact on these jurisdictions and the Lower Dauphin School District.

20 AmerGen has indicated that they have no plans to add non-outage employees during the  
21 license renewal period, non-outage employment levels at TMI-1 would remain relatively  
22 unchanged. Accordingly, there would be no increase in the assessed value of TMI-1, and  
23 annual property tax payments to Dauphin County, Londonderry Township, and the Lower  
24 Dauphin School District would be expected to remain relatively unchanged throughout the  
25 license renewal period. Based on this information, there would be no land use impacts related to  
26 tax revenue during the license renewal term beyond those already being experienced.

27 As discussed in Section 4.9.2, AmerGen indicated in their environmental report that TMI-1  
28 steam generators would be replaced prior to the license renewal term (AmerGen 2008). The  
29 replacement of the existing steam generators would not likely increase the assessed value of  
30 TMI-1, and property tax payments would remain unchanged. These impacts are discussed in  
31 Chapter 3 of this draft supplemental EIS.

32

#### 33 **4.9.5 Public Services: Transportation Impacts**

34 Table B-1 of Appendix B to Subpart A of 10 CFR Part 51 states the following:

35       Transportation impacts (level of service) of highway traffic generated...during the  
36       term of the renewed license are generally expected to be of small significance.  
37       However, the increase in traffic associated with additional workers and the local  
38       road and traffic control conditions may lead to impacts of moderate or large  
39       significance at some sites.

## Environmental Impacts of Operation

1 All applicants are required by 10 CFR 51.53(c)(3)(ii)(J) to assess the impacts of highway traffic  
2 generated by the proposed project on the level of service of local highways during the term of  
3 the renewed license.

4 Since AmerGen has no plans to add non-outage employees during the license renewal period;  
5 there would be no noticeable change in traffic volume and levels of service on roadways in the  
6 vicinity of TMI-1. Therefore, there would be no transportation impacts during the license renewal  
7 term beyond those already being experienced.

8 As discussed in Section 4.9.2, AmerGen indicated in their environmental report that TMI-1  
9 steam generators would be replaced prior to the license renewal term (AmerGen 2008). The  
10 additional number of refueling outage workers and truck material deliveries needed to support  
11 the replacement of the steam generators would cause a one-time short-term transportation  
12 impact on access roads in the immediate vicinity of TMI-1. These impacts are discussed in  
13 Chapter 3 of this draft supplemental EIS.

14

### 15 **4.9.6 Historic and Archaeological Resources**

16 The National Historic Preservation Act (NHPA) requires Federal agencies to consider the effects  
17 of their undertakings on historic properties. Historic properties are defined as resources that are  
18 eligible for listing on the National Register of Historic Places (NRHP). The criteria for eligibility  
19 are listed in Title 36, "Parks, Forests, and Public Property," Part 60, Section 4, "Criteria for  
20 Evaluation," of the *Code of Federal Regulations* (36 CFR Part 60.4) and include (1) association  
21 with significant events in history; (2) association with the lives of persons significant in the past;  
22 (3) embodies distinctive characteristics of type, period, or construction, and (4) or sites or places  
23 that have yielded or is likely to yield important information (ACHP 2008). The historic  
24 preservation review process (Section 106 of the NHPA) is outlined in regulations issued by the  
25 Advisory Council on Historic Preservation in Title 36, "Parks, Forests, and Public Property,"  
26 Part 800, "Protection of Historic Properties," of the *Code of Federal Regulations*  
27 (36 CFR Part 800). The issuance of a renewed operating license for a nuclear power plant is a  
28 federal action that could possibly affect either known or undiscovered historic properties located  
29 on or near the plant site and its associated transmission lines. In accordance with the provisions  
30 of the NHPA, the NRC is required to make a reasonable effort to identify historic properties in  
31 the area of potential effect. The area of potential effect (APE) for a license renewal action is the  
32 area at the power plant site and its immediate environs that may be impacted by post-license  
33 renewal land-disturbing operations or projected refurbishment activities associated with the  
34 proposed action. If no historic properties are present or affected, the NRC is required to notify  
35 the State Historic Preservation Office before proceeding. If it is determined that historic  
36 properties are present, the NRC is required to assess and resolve possible adverse effects of  
37 the undertaking. While AmerGen owns Three Mile Island, the APE is confined to the northern  
38 portion of the island where the plant is located. The following discussion summarizes the historic  
39 and archaeological research that has been conducted on the island.

40 AmerGen contacted the Pennsylvania Historical and Museum Commission (PHMC) on May 22,  
41 2007, requesting information on historic and archaeological resources and describing the  
42 proposed action (AmerGen 2008). In a letter dated June 4, 2007, the PHMC stated that the  
43 activities described in the proposed action should have no effect on historic and archaeological



1 resources (AmerGen 2008). The PHMC requested that if the applicant becomes aware of any  
2 unidentified historic buildings, structures, or archaeological resources located on site, or if the  
3 project could have an effect on historic properties, the PHMC should be contacted immediately  
4 (AmerGen 2008). In accordance with 36 CFR 800.8(c), the NRC contacted the PHMC (NRC  
5 2008a), the Advisory Council on Historic Preservation (NRC 2008b), and the appropriate  
6 Federally-recognized Native American Tribes to initiate consultation. These letters are  
7 contained in Appendix D of this report.

8 As previously discussed in Section 2.2.9, a search of the PHMC site files identified nine  
9 prehistoric sites and one historic site on Three Mile Island. One of the sites, 36Da98 was a  
10 possible find spot reported by a local collector south of the powerblock. No time period was  
11 determined for the 36Da98 and portions of the site could still be intact and should be avoided.  
12 Sites 36Da96 and 36Da97 were located in a cultivated area which later became the  
13 construction site for TMI-1 and TMI Unit 2. Portions of the 36Da96 could also be intact due to its  
14 location on the edge of the construction zone. Site 36Da97 was destroyed by the construction of  
15 TMI-1 and TMI Unit 2. One additional site 36Da52 was recorded by the William Penn Memorial  
16 Museum in 1967. It is unclear whether 36Da52 was destroyed during the construction of TMI-1  
17 and TMI Unit 2 because it was also situated on the edge of the construction area.

18 Site 36Da50 is a large multi-component occupation that was excavated prior to the construction  
19 of TMI-1 and TMI Unit 2. During the walkover survey, it was noted that the northernmost  
20 portions of 36Da50 remain and it is an area that should be avoided. Sites 36Da99, 36Da100,  
21 and 36Da101 are large multi-component occupation sites near the riverbank. 36Da101 also  
22 contains historic artifacts. Another prehistoric occupation site is 36Da51. While test units  
23 recovered a low concentration of artifacts, portions of this site may still be intact and should be  
24 avoided. These archaeological and historic sites have the potential to contribute a large amount  
25 of prehistoric information. Archaeological surveys and reports indicate that undisturbed portions  
26 of Three Mile Island could contribute to the archaeological record of the lower Susquehanna  
27 River valley. Archaeological investigations should be conducted if ground disturbing activities  
28 would occur in undisturbed areas of the island.

29 In addition to the prehistoric sites mentioned above, Three Mile Island also contains historic  
30 sites. As noted earlier, a historic farmstead was identified (36Da235) during NRC's walkover  
31 survey of Three Mile Island. A preliminary Pennsylvania Archaeological Site Survey form was  
32 completed by AmerGen, however, documentation is incomplete. This site must be recorded and  
33 evaluated for eligibility to the National Register of Historic Places. Additionally, the remnants of  
34 Pennsylvania Canal's Eastern Division (Eastern Division Canal) are located on the eastern  
35 shore of the Susquehanna River next to AmerGen's property. Another potential resource of  
36 historic significance on Three Mile Island is TMI Unit 2. TMI Unit 2 could be considered  
37 potentially eligible for listing on the NRHP under Criterion A, as a site of exceptional importance,  
38 but its eligibility has not yet been determined.

39 AmerGen has indicated no plans to change or modify the plant or transmission line structures.  
40 However, because of the high potential for the presence of historic and archaeological  
41 resources, AmerGen should take care during continued operations and maintenance activities  
42 to not affect these resources. AmerGen's review procedures for onsite ground disturbing  
43 activities take into account the protection of historic and archaeological resources. AmerGen is  
44 currently revising its procedures to provide guidance regarding the protection of historic and  
45 archaeological resources, and to implement a stop work provision when these resources are

## Environmental Impacts of Operation

1 inadvertently discovered. It should be noted in the procedures that previously disturbed lands  
2 are areas that were disturbed by the construction of TMI-1 and TMI Unit 2. Plow zone  
3 disturbance (farming) is not considered previously disturbed land because the depth of  
4 disturbance is minimal. If ground disturbing activities are planned that may adversely affect  
5 these resources, then AmerGen should hire a PHMC approved contractor to survey the  
6 proposed site prior to construction. To date, AmerGen has employed cultural resource  
7 management firms to ensure that ground disturbing activities would not adversely affect historic  
8 and archaeological resources.

9 As discussed in Chapter 3, AmerGen plans to replace the existing steam generators for TMI-1.  
10 A dedicated storage facility to house the replaced generators will be constructed within the  
11 existing industrial footprint of the site and will be located in an area that has been previously  
12 disturbed (AmerGen 2008). The NRC staff has reviewed the potential environmental impacts of  
13 this activity in Chapter 3 of this draft supplemental EIS.

14 No impacts to known historic and archaeological resources are expected from the continued  
15 operation of TMI-1 during the license renewal term. Based on the review of PHMC files,  
16 archaeological surveys, assessments, and other information, the potential impacts on historic  
17 and archaeological resources at TMI-1 would be SMALL. Since TMI-1 is situated in an  
18 archaeologically sensitive area, development of a cultural resources management plan in  
19 addition to AmerGen's review procedures would serve to integrate cultural resource  
20 considerations with ongoing TMI-1 activities. Additionally, training of AmerGen staff in the  
21 Section 106 process would ensure that informed decisions are made when considering the  
22 effects of future projects on historic and archaeological resources. As previously discussed,  
23 lands not previously surveyed should be investigated by a professional archaeologist prior to  
24 any ground disturbance. In addition, the historical farmstead site (36Da235) should be recorded  
25 and evaluated for eligibility.  
26

### 27 **4.9.7 Environmental Justice**

28 Under Executive Order 12898 (59 FR 7629), Federal agencies are responsible for identifying  
29 and addressing potential disproportionately high and adverse human health and environmental  
30 impacts on minority and low-income populations. In 2004, the Commission issued a Policy  
31 Statement on the Treatment of Environmental Justice Matters in NRC Regulatory and Licensing  
32 Actions (69 FR 52040), which states, "The Commission is committed to the general goals set  
33 forth in Executive Order 12898, and strives to meet those goals as part of its NEPA review  
34 process."

35 The Council of Environmental Quality (CEQ) provides the following information in its 1997 report  
36 entitled, "Environmental Justice: Guidance Under the National Environmental Policy Act":

37 **Disproportionately High and Adverse Human Health Effects.** Adverse health  
38 effects are measured in risks and rates that could result in latent cancer fatalities,  
39 as well as other fatal or nonfatal adverse impacts on human health. Adverse  
40 health effects may include bodily impairment, infirmity, illness, or death.  
41 Disproportionately high and adverse human health effects occur when the risk or  
42 rate of exposure to an environmental hazard for a minority or low-income

1 population is significant (as defined by NEPA [National Environmental Policy  
2 Act]) and appreciably exceeds the risk or exposure rate for the general  
3 population or for another appropriate comparison group (CEQ 1997).

4 **Disproportionately High and Adverse Environmental Effects.** A  
5 disproportionately high environmental impact that is significant (as defined by  
6 NEPA) refers to an impact or risk of an impact on the natural or physical  
7 environment in a low-income or minority community that appreciably exceeds the  
8 environmental impact on the larger community. Such effects may include  
9 ecological, cultural, human health, economic, or social impacts. An adverse  
10 environmental impact is an impact that is determined to be both harmful and  
11 significant (as defined by NEPA). In assessing cultural and aesthetic  
12 environmental impacts, impacts that uniquely affect geographically dislocated or  
13 dispersed minority or low-income populations or American Indian tribes are  
14 considered (CEQ 1997).

15 The environmental justice analysis assesses the potential for disproportionately high and  
16 adverse human health or environmental effects on minority and low-income populations that  
17 could result from the operation of TMI-1 during the renewal term. In assessing the impacts, the  
18 following CEQ (1997) definitions of minority individuals and populations and low-income  
19 population were used:

20 **Minority individuals.** Individuals who identify themselves as members of the  
21 following population groups: Hispanic or Latino, American Indian or Alaska  
22 Native, Asian, Black or African American, Native Hawaiian or Other Pacific  
23 Islander, or two or more races meaning individuals who identified themselves on  
24 a Census form as being a member of two or more races, for example, Hispanic  
25 and Asian.

26 **Minority populations.** Minority populations are identified when (1) the minority  
27 population of an affected area exceeds 50 percent or (2) the minority population  
28 percentage of the affected area is meaningfully greater than the minority  
29 population percentage in the general population or other appropriate unit of  
30 geographic analysis.

31 **Low-income population.** Low-income populations in an affected area are  
32 identified with the annual statistical poverty thresholds from the Census Bureau's  
33 Current Population Reports, Series PB60, on Income and Poverty.

#### 34 Minority Population in 2000

35 According to 2000 census data, 11 percent of the population (approximately 2,536,000  
36 individuals) residing within a 50 mi radius of TMI-1 identified themselves as minority individuals.  
37 The largest minority group was Black or African American (131,000 persons or 5.2 percent),  
38 followed by Hispanic or Latino of any race (107,000 or about 4.2 percent) (USCB 2003 –  
39 LandView 6). About 24.4 percent of the Dauphin County population identified themselves as

## Environmental Impacts of Operation

1 minorities, with Black or African American the largest minority group (16.9 percent) followed by  
2 Hispanic or Latino (4.1 percent) (USCB 2008) (see Table 2-12).

3 The 50-mi (80 km) radius around TMI-1 includes 16 counties in Pennsylvania and six counties  
4 in Maryland. The geographic area includes any census block group with part of its area within  
5 the 50-mi (80 km) radius. Of the 1,931 census block groups located wholly or partly within the  
6 50-mi (80 km) radius of TMI-1, 155 block groups were determined to have high density minority  
7 population percentages that exceeded the Pennsylvania average by 20 percentage points or  
8 more. The largest number of high density minority block groups was Black or African American,  
9 with 78 block groups that exceed the Pennsylvania average 20 percent or more. These block  
10 groups are concentrated in urban areas with high population densities. The greatest number of  
11 high density block groups with minority populations are located in four Pennsylvania counties  
12 (Berks, Dauphin, Lancaster, and York). The closest high density minority population to TMI-1 is  
13 located in Harrisburg, Pennsylvania.

14 Based on 2000 census data, Figure 4-1 shows the location of high density minority block groups  
15 within a 50-mi radius of TMI-1.


### 16 Low-Income Population in 2000

17 According to 2000 census data, approximately 36,000 families and 188,000 individuals  
18 (approximately 5.3 and 7.4 percent, respectively) residing within a 50-mi radius of TMI-1 were  
19 identified as living below the Federal poverty threshold in 1999 (USCB 2003 – LandView 6). The  
20 1999 Federal poverty threshold was \$17,029 for a family of four.


21 According to Census data, the median household income for Pennsylvania in 2006 was  
22 \$46,259, while 12.1 percent of the State population was determined to be living below the  
23 Federal poverty threshold. Dauphin County had a higher median household incomes (\$49,093)  
24 and a lower percentage (10.1 percent) of individuals living below the poverty level when  
25 compared to the State. Lancaster County had much higher median household income in 2006  
26 (\$52,064) and a lower percentage (9.2 percent) of individuals living below the poverty level  
27 when compared to the State and Dauphin County (USCB 2008). Census block groups were  
28 considered high density low-income block groups if the percentage of households below the  
29 Federal poverty threshold exceeded the Pennsylvania average by 20 percent or more. Based  
30 on 2000 Census data, there were 66 block groups within the 50-mi (80 km) radius of TMI-1 that  
31 exceeded the Pennsylvania average for low income households by 20 percent or more. The  
32 majority of census block groups with low-income populations were located in two counties,  
33 Berks County (16 block groups) and Dauphin County (12 block groups) in Pennsylvania. The  
34 nearest high density low-income population to TMI-1 is located in Harrisburg, Pennsylvania.  
35 Figure 4-2 shows the location of high density low-income census block groups within a 50-mi  
36 (80 km) radius of TMI-1.

### 37 Analysis of Impacts

38 Consistent with the impact analysis for the public and occupational health and safety, the  
39 affected populations are defined as minority and low-income populations who reside within a 50  
40 mi (80 km) radius of TMI-1. Based on the analysis of environmental health and safety impacts  
41 presented in this draft supplemental EIS for other resource areas, there would be no



# Environmental Impacts of Operation



1 disproportionately high and adverse impacts to minority and low-income populations from the  
2 continued operation of TMI-1 during the license renewal period.

3 As discussed in Section 4.9.2, AmerGen indicated in their environmental report that TMI-1  
4 steam generators would be replaced prior to the license renewal term. AmerGen estimates that  
5 steam generator replacement would require a one-time increase in the number of refueling  
6 outage workers for up to 70 days at TMI-1 (AmerGen 2008a). These additional workers would  
7 have little noticeable affect on minority and/or low-income populations in the region. These  
8 impacts are discussed in Chapter 3 of this draft supplemental EIS.

9 NRC also analyzed the risk of radiological exposure through the consumption patterns of  
10 special pathway receptors, including subsistence consumption of fish, native vegetation, surface  
11 waters, sediments, and local produce; absorption of contaminants in sediments through the  
12 skin; and inhalation of plant materials. The special pathway receptors analysis is important to  
13 the environmental justice analysis because consumption patterns may reflect the traditional or  
14 cultural practices of minority and low-income populations in the area.

#### 15 Subsistence Consumption of Fish and Wildlife

16 Section 4-4 of Executive Order 12898 (1994) directs Federal agencies, whenever practical and  
17 appropriate, to collect and analyze information on the consumption patterns of populations who  
18 rely principally on fish and/or wildlife for subsistence and to communicate the risks of these  
19 consumption patterns to the public. In this draft supplemental EIS, NRC considered whether  
20 there were any means for minority or low-income populations to be disproportionately affected  
21 by examining impacts to American Indian, Hispanic, and other traditional lifestyle special  
22 pathway receptors. Special pathways that took into account the levels of contaminants in native  
23 vegetation, crops, soils and sediments, surface water, fish, and game animals on or near the  
24 TMI-1 site were considered.

25 Historic analyses of deer meat samples collected at TMI-1 from 1990 through 1997 found  
26 concentrations of cesium-137, tritium, and strontium-90. Cesium-137 was only detected in  
27 control samples (AmerGen 2008c). Since cesium-137 was not found in indicator samples, the  
28 presence of cesium-137 could be attributed to past fallout from nuclear weapons tests. Tritium  
29 was found in both indicator and control deer meat samples during this time period at  
30 concentrations similar to each other and similar to concentrations of tritium detected in other  
31 control food products such as milk, fruits, and vegetables (AmerGen 2008c). Since tritium  
32 occurs naturally in the environment and since the levels of concentrations were similar, the  
33 presence of tritium in both control and indicator samples therefore could not be directly  
34 attributed to TMI-1 operations. Strontium-90 was found in only one deer meat sample collected  
35 in 1992 and was consistent with the concentration found in one 1989 control sample (AmerGen  
36 2008c). Therefore, the presence of strontium-90 in the deer meat sample could also be  
37 attributed to past fallout from nuclear weapons tests.

38 AmerGen has an ongoing comprehensive Radiological Environmental Monitoring Program  
39 (REMP) at TMI-1 to assess the impact of site operations on the environment. Samples are  
40 collected from the aquatic and terrestrial pathways in the vicinity of TMI-1 and TMI Unit 2. The  
41 aquatic pathways include fish, Susquehanna River surface water, ground water, and sediment.  
42 The terrestrial pathways include airborne particulates, milk, and food product garden (leaf)

## Environmental Impacts of Operation

1 vegetation, and direct radiation. During 2007, 1,718 analyses were performed on 1,318  
2 collected samples of environmental media as part of the required REMP and showed no  
3 significant or measurable radiological impact from TMI-1 operations (AmerGen 2008b).

4 During 2007, cesium-137, strontium-90, and tritium were the only potentially plant-related  
5 radionuclides detected in environmental samples. No radionuclides other than naturally  
6 occurring and tritium were detected in the Susquehanna River water samples collected in 2007.  
7 Tritium, whose presence is likely to be due to plant operations, has been detected in the past,  
8 was detected in 8 of 24 surface water samples taken downstream of the effluent outfall in  
9 concentrations well below regulatory limits. Tritium was also detected in 3 of 36 drinking water  
10 samples at slightly above the lower limit of detection. Cesium-137 was identified in sediment  
11 samples in 2007 at very low levels (just above the lower limit of detection), and were not  
12 distinguishable from background levels (AmerGen 2008b).

13 Strontium-90 was detected in 11 of 21 milk samples collected in 2007. The amount of activity  
14 detected was consistent with those detected in the pre-operational years. Strontium-90 was also  
15 detected in 24 of 26 food product samples in both the indicator and control samples (AmerGen  
16 2008b). The source of the strontium-90 could be attributed to residual fallout from weapons  
17 testing.

18 The results of the 2007 REMP demonstrate that routine operation at TMI-1 had no significant or  
19 measurable radiological impact on the environment. No elevated radiation levels were detected  
20 in the offsite environment as a result of plant operations and the storage of radioactive waste.  
21 The results of the REMP continue to demonstrate that the operation of TMI-1 did not result in a  
22 significant measurable dose to a member of the general population or adversely impact the  
23 environment as a result of radiological effluents. The REMP continues to demonstrate that the  
24 dose to a member of the public from the operation of TMI-1 remains significantly below the  
25 federally required dose limits specified in 10 CFR Part 20 and 40 CFR Part 190.

26 The PADEP BRP maintains a comprehensive environmental radiation monitoring program in  
27 Pennsylvania, as required by the "Radiation Protection Act" (No. 1984-147). The purpose of the  
28 program is to evaluate long-term trends in environmental radiation levels; assess the  
29 environmental impact of particular sites, such as TMI-1; and provide this information to the  
30 public. The BRP currently maintains off-site environmental radiation monitoring programs  
31 around five nuclear power plants in Pennsylvania including TMI-1. Monitoring stations serve as  
32 indicators of any effects from plant operation and at control locations, which are beyond the  
33 measurable influence of the facility. These stations also provide verification of utility effluent  
34 monitoring programs during routine operations.

35 Each year, BRP collects dosimetry, air, water, milk, fish, produce, and sediment samples in the  
36 vicinity of TMI-1. Fish samples were collected in the vicinity of the TMI-1 discharge and produce  
37 samples of cabbage were collected from a truck garden located 0.4 mi east of TMI-1 in 2003  
38 and 2004. No reactor-related radioisotopes were detected in the fish and produce samples.  
39 BRP also found no traces of cesium-137 in milk samples taken monthly at two local farms.  
40 Cesium-137 was detected in sediment samples collected upstream (control) and downstream  
41 (indicator) of the TMI-1 discharge. The presence of cesium-137 could be attributed to fallout  
42 from past weapons testing and the accident at Chernobyl in April 1986. BRP also found no



1 reactor-related radioisotopes in fish and produce samples collected in 2001 and 2002 (PADEP  
2 BRP 2008).

3 Based on recent monitoring results, concentrations of radiological contaminants in native leafy  
4 vegetation, soils and sediments, surface water, and fish in areas surrounding TMI-1 have been  
5 quite low (at or near the threshold of detection) and seldom above background levels.  
6 Consequently, no disproportionately high and adverse human health impacts would be  
7 expected in special pathway receptor populations in the region as a result of subsistence  
8 consumption of fish and wildlife.

9 However, with regard to nonradiological contaminants, it should be noted that for the reach of  
10 the Susquehanna River within the vicinity of the TMI-1 facility and the nearest major water  
11 bodies, including Swatara Creek, East Conewago Creek, West Conewago Creek, and Fishing  
12 Creek, Pennsylvania issued a health advisory to limit the consumption of smallmouth bass  
13 (*Micropterus dolomieu*) to no more than two meals per month due to mercury contamination  
14 (PFBC 2008c).  
15

#### 16 **4.10 Evaluation of New and Potentially Significant Information**

17 New and significant information is (1) information that identifies a significant environmental issue  
18 not covered in the GEIS and codified in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, or  
19 (2) information that was not considered in the analyses summarized in the GEIS and that leads  
20 to an impact finding that is different from the finding presented in the GEIS and codified in 10  
21 CFR Part 51.

22 In preparing to submit its application to renew the TMI-1 operating license, AmerGen developed  
23 a process to ensure that information not addressed in or available during the GEIS evaluation  
24 regarding the environmental impacts of license renewal for TMI-1 would be properly reviewed  
25 before submitting the ER, and to ensure that such new and potentially significant information  
26 related to renewal of the operating license for TMI-1 would be identified, reviewed, and  
27 assessed during the period of NRC review. AmerGen reviewed the Category 1 issues that  
28 appear in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, to verify that the conclusions of  
29 the GEIS remained valid with respect to TMI-1. This review was performed by personnel from  
30 TMI-1 and its support organization who were familiar with NEPA issues and the scientific  
31 disciplines involved in the preparation of a license renewal ER.

32 The NRC staff also has a process for identifying new and significant information. That process is  
33 described in detail in NUREG-1555, Supplement 1, *Standard Review Plans for Environmental*  
34 *Reviews for Nuclear Power Plants, Supplement 1: Operating License Renewal* (NRC 2000).  
35 The search for new information includes (1) review of an applicant's ER and the process for  
36 discovering and evaluating the significance of new information; (2) review of records of public  
37 comments; (3) review of environmental quality standards and regulations; (4) coordination with  
38 Federal, State, and local environmental protection and resource agencies; and (5) review of the  
39 technical literature. New information discovered by the NRC staff is evaluated for significance  
40 using the criteria set forth in the GEIS. For Category 1 issues where new and significant  
41 information is identified, reconsideration of the conclusions for those issues is limited in scope to  
42 the assessment of the relevant new and significant information; the scope of the assessment  
43 does not include other facets of the issue that are not affected by the new information.

## Environmental Impacts of Operation

1 The NRC staff has not identified any new and significant information on environmental issues  
2 listed in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, related to the operation of TMI-1  
3 during the period of license extension. The NRC staff also determined that information provided  
4 during the public comment period did not identify any new issues that require site-specific  
5 assessment. The NRC staff reviewed the discussion of environmental impacts in the GEIS  
6 (NRC 1996) and conducted its own independent review (including the public scoping meetings  
7 held in May 2008) to identify new and significant information.  
8

### 9 **4.11 Cumulative Impacts**

10 The NRC staff considered potential cumulative impacts in the environmental analysis of  
11 continued operation of TMI-1. For the purposes of this analysis, past actions are those related to  
12 the resources at the time of the power plant licensing and construction, present actions are  
13 those related to the resources at the time of current operation of the power plant, and future  
14 actions are considered to be those that are reasonably foreseeable through the end of plant  
15 operation including the period of extended operation. Therefore, the analysis considers potential  
16 impacts through the end of the current license terms as well as the 20-year renewal license  
17 term. The geographic area over which past, present, and future actions would occur is  
18 dependent on the type of action considered and is described below for each impact area.

19 The impacts of the proposed action, as described in Sections 4.1–4.9, are combined with other  
20 past, present, and reasonably foreseeable future actions regardless of what agency (Federal or  
21 non-Federal) or person undertakes such other actions.  
22

#### 23 **4.11.1 Cumulative Impacts on Water Resources**

24 The SRBC regulates consumptive water use at TMI-1 and at all facilities drawing water from the  
25 Susquehanna River and the river basin. The SRBC is an independent agency that develops,  
26 effectuates, coordinates and adopts plans, policies, and programs related to water resources in  
27 the Susquehanna River basin (SRBC 2008). According to the SRBC, 89 percent of water use in  
28 the Lower Susquehanna River Basin (Lower Subbasin) is for power generation, 4.8 percent for  
29 industrial use, 4.2 percent for municipal use, 1.2 percent for agricultural use, and 0.8 percent for  
30 domestic use (SRBC 2007). TMI-1 has a permit with SRBC for consumptive use of river water  
31 up to 18 million gallons per day (mgd), on a 30-day average, for electric generation. TMI-1 also  
32 participates in the Cowanesque Reservoir water allocation project, which releases water to the  
33 Susquehanna River to augment flow during periods of drought (AmerGen 2008).

34 TMI-1 has five onsite ground water wells, and uses ground water for various industrial  
35 operations and for drinking water on site, as permitted by the SRBC. This water is primarily  
36 drawn from the Gettysburg shale aquifer located directly beneath the site (AmerGen 2008). The  
37 SRBC monitors and manages ground water use in the area including and surrounding Three  
38 Mile Island under the “Groundwater Management Plan for the Susquehanna River Basin,” which  
39 was initiated in 1993 (SRBC 2005). The SRBC estimates that the use of ground water in the  
40 Susquehanna River Basin is approximately 390 mgd. The main use in the basin is to supply  
41 drinking water wells, with the largest consumers being public water suppliers (115 mgd),

1 followed by mining sites (90 mgd), domestic consumers (80 mgd), industrial consumers (48  
2 mgd), agricultural consumers (42 mgd), and commercial consumers (12 mgd) (SRBC 2005).

3 According to the most recently issued draft ground water management plan (SRBC 2005), the  
4 quality of ground water in the Susquehanna River Basin is generally good, with the most  
5 common impacts being the geology of the area and land use. Degradation of ground water in  
6 the area is largely a result of abandoned coal mines (acid mine drainage) as well as agricultural  
7 and residential use of pesticides and contaminants. A particular problem addressed by the  
8 SRBC is the diversion of stormwater runoff into sinkholes, which essentially delivers the water  
9 directly to the aquifer. Section 4.11.2 of this report discusses ground water quality and its  
10 impacts on aquatic resources of the Susquehanna River in more depth. Other significant issues  
11 outlined by the SRBC management plan include increases in land development, overuse of  
12 ground water resources, transfer of discharge wastewater to a different watershed, unregulated  
13 use of ground water resources, drought impacts, and the need for flow compensation for  
14 consumptive water users in the basin (SRBC 2005).

15 The SRBC regulatory program, which includes the regulation of withdrawals, monitoring and  
16 enforcement duties, and the ability to designate protected areas, manages the basin's ground  
17 water resources. The regulatory program also allows for the development of ground water  
18 quality standards and conservation requirements. Additionally, the ground water management  
19 plan focuses on public outreach and education (SRBC 2005).

20 Recently there has been strong interest in the development of gas well drilling of the Marcellus  
21 shale, a gas reservoir stretching from Pennsylvania into Ohio and West Virginia which some  
22 claim contains enough gas to satisfy U.S. demand for 2 years (Buurma 2008; SRBC 2008). With  
23 the recent success of drilling the Barnett shale in Texas and new technological advances in  
24 horizontal drilling, several drilling companies have taken serious interest in the Appalachian  
25 area (SRBC 2008). The gas drilling process involves both horizontal drilling and the use of a  
26 technique known as hydraulic fracturing (or, "hydrofracking"). Hydrofracking is the high-pressure  
27 injection of a combination of sand, water, and chemicals into rock to fracture it and make it more  
28 permeable (Buurma 2008). The chemicals used in hydrofracking, however, are toxic and have  
29 the potential to contaminate drinking water and ground water systems. There is less concern  
30 over the transfer of these chemicals into ground water supplies simply because the wells are far  
31 deeper (4000 to sometimes 8000 ft deep) than the water-bearing aquifers (SRBC 2008).  
32 However, there is concern over the disposal of the toxic drilling water and where and how it will  
33 be discharged. Before any drilling can begin each company must apply to the SRBC for various  
34 water use permits. In August 2008, SRBC made the decision to require all natural gas drilling  
35 projects to apply for water withdrawal permits, regardless of the amount of water being  
36 withdrawn, as well as to raise the area's consumptive use mitigation fee (SRBC 2008).

37 To ensure that surface water and ground water resources of the Susquehanna River basin  
38 continue to meet the needs of the basin population, in addition to enforcing water use  
39 regulations, the SRBC coordinates with State and Federal agencies, conducts extensive water  
40 resources monitoring, project review, water withdrawal registration, drought coordination, flood  
41 management, low-flow management (i.e., water storage), reservoir feasibility studies, and  
42 ground water management (SRBC 2008). On the basis of this information, the independent  
43 review by the NRC staff concludes that the cumulative impact to water resources during the  
44 license renewal period would be SMALL.

45

1 **4.11.2 Cumulative Impacts on Aquatic Resources**

2 This section addresses past, present, and future actions that could result in adverse cumulative  
3 impacts on aquatic resources. For the purpose of this analysis, the geographic area considered  
4 for cumulative impacts on aquatic resources at TMI-1 is the Lower Subbasin, which is one of the  
5 six Susquehanna River major subbasins. The Lower Subbasin runs south from Sunbury in  
6 Northumberland County, PA, to Havre de Grace, MD. The lower Subbasin discharges into the  
7 Chesapeake Bay.

8 The Lower Subbasin, which drains approximately 5,809 square miles (mi<sup>2</sup>) (15,045 square  
9 kilometers [km<sup>2</sup>]) of land, is the most developed of the six Susquehanna River subbasins. The  
10 cities of Harrisburg, Lancaster, York, Lebanon, and Carlisle are contained within the Lower  
11 Subbasin. The subbasin is characterized by a mixture of land uses including residential areas,  
12 agricultural land, undeveloped land, forests, and recreational areas (SRBC 2008). The northern  
13 section of the Lower Subbasin consists primarily of forested areas interspersed with agriculture  
14 and residential areas, while the southern half of the subbasin is dominated by agriculture and  
15 urban areas, with some undeveloped areas, parks, and recreation areas (SRBC undated).

16 Almost a century of intensive anthracite coal mining within the Wyoming Valley seriously  
17 impaired the Susquehanna River's water quality and ecological resources. The river received  
18 highly acidic, iron-rich drainage from numerous mining sites that operated from the late 1800s  
19 through the early 1970s. These sites were mostly in the upper subbasins of the Susquehanna  
20 River; however, the Lower Subbasin was also impacted due to the natural flow of the river and  
21 the movement of pollutants downstream. Anthracite mining in Pennsylvania reached its peak  
22 around 1930 and ceased almost entirely in 1972, in part because of the evolving fossil fuel  
23 economy and tightening water quality regulations. However, the mines continued to leak iron-  
24 contaminated acidic runoff to streams that fed the river for many years following their  
25 abandonment. In addition to high levels of total iron and other dissolved heavy metals, mining  
26 effluents were also responsible for the high sulfate content, and low pH and dissolved oxygen  
27 levels in the river (CBF 2006).

28 Between 1972 and 1981, considerable improvement in the water quality of the Susquehanna  
29 River was noted. During this period, the volume of mining effluents being discharged to the river  
30 decreased. The reduction in mining caused a decrease in solids, iron, and sulfate  
31 concentrations throughout the Susquehanna River. These trends on improved water quality  
32 have continued, and will most likely continue as long as mining is kept at a minimum.

33 Agriculture and livestock production in the Lower Subbasin have contributed to declines in river  
34 water quality. Nutrient discharges including nitrates, nitrogen, phosphorus, and orthophosphates  
35 from runoff of pesticide and fertilized agricultural and livestock lands have been a primary  
36 source of decreased water quality (CBF 2005). Agricultural practices from the land along the  
37 Lower Subbasin have caused decreased river water quality in the Chesapeake Bay (CBF 2005).

38 Numerous wastewater treatment plants are located along the Lower Subbasin, discharges from  
39 which can contribute to decreases in river water quality. Treated water leaving wastewater  
40 plants can have increased levels of phosphates, orthophosphates, and chlorine (SRBC 2006).  
41 During high storm events, untreated overflow from treatment plants can add additional nutrient  
42 runoff to the Susquehanna River.

1 As mentioned above, the Lower Subbasin runs through more urban areas of Pennsylvania such  
2 as Harrisburg, Lancaster, and York. Urbanized areas contain more impervious surfaces than  
3 other land uses; this increases stormwater runoff to waterways and causes subsequent  
4 decreases in river water quality.

5 Anthropogenic sources of pollution will likely be an ongoing issue for the Susquehanna River.  
6 However, the SRBC, PADEP, and other environmental groups such as the Chesapeake Bay  
7 Foundation are working collaboratively in their efforts to conduct basin-wide monitoring and  
8 promote watershed protection and management. Furthermore, PADEP will continue to enforce  
9 water quality regulations through its NPDES permitting program. NPDES permits, issued by the  
10 PADEP Bureau of Water Supply and Wastewater Management, will continue to regulate  
11 municipal and industrial effluents to the Susquehanna River. The PADEP periodically reviews  
12 and renews NPDES permits; thus it is reasonable to predict that the improving trends in the  
13 Susquehanna River's water quality will likely continue throughout the license renewal period.

14 Construction of hydroelectric dams on the river in the Lower Subbasin has also created  
15 significant impacts on the aquatic ecosystem; and as power needs in Pennsylvania increase in  
16 the future, it is reasonable to predict potential upgrades and improvements to current dams on the  
17 Susquehanna River. Dams can change aquatic ecosystems by altering flow, sediment transport,  
18 critical habitats, water temperature, and chemistry (CBF 2006). As discussed in Section 2.2.5 of  
19 this supplemental EIS, the American shad (*Alosa sapidissima*) is an anadromous fish species  
20 that was once of major sport and commercial importance within the Susquehanna River.  
21 Presently, American shad are rarely found in the upper reaches of the river because dams  
22 constructed in the last one hundred years have blocked the species' natural upstream migration.  
23 Between 1904 and 1932, four hydroelectric dams were constructed on the Susquehanna River.  
24 Fish passage facilities at these early dams were primitive and often prevented shad passage.  
25 The 1928 construction of the 95-ft-high (29-m-high) Conowingo Dam, located 10 mi (16 km)  
26 above the mouth of the Susquehanna River, effectively put an end to shad migration in the  
27 Susquehanna River, and at the time, authorities deemed the Conowingo Dam too high to  
28 include fish passage modifications in the dam's design. Fish ladders or lifts currently exist at all  
29 dams throughout the Lower Subbasin, however, in the years 2006–2008, shad populations have  
30 declined throughout all the dams in the subbasin (PFBC 2008a).

31 Shad restoration attempts began in the mid-20<sup>th</sup> century with feasibility studies conducted by the  
32 Pennsylvania Fish Commission (now the PFBC). From 1970–1980, the first Conowingo fish lift  
33 was built, and hatchery cultures of fry were stocked in the Susquehanna River and its  
34 tributaries. From 1985–1994, increasing numbers of fry were stocked, and over 125,000 adult  
35 shad were stocked above the Conowingo Dam. Fry were stocked in the North Branch  
36 Susquehanna River in Pennsylvania and New York, Chemung River in New York, West Branch  
37 Susquehanna River, Juniata River, Susquehanna River near Montgomery Ferry, Conodoguinet  
38 Creek, Conestoga River, Swatara Creek, and West Conewago Creek. During this period, the  
39 annual return of shad grew from 1,500 to 60,000.

40 During the years of 1988–1997, a permanent fish passage facility was built at Conowingo Dam,  
41 and through a series of settlements with utility companies that owned Susquehanna River  
42 dams, fish elevators were constructed at the Holtwood and Safe Harbor dams. In 1997, the  
43 shad return at Conowingo exceeded 100,000 fish. In 1999 and 2000, a fish ladder was  
44 completed at the Red Hill Dam, and smaller upriver dams along the Susquehanna River and  
45 major tributaries were reopened to allow natural shad migration through Binghamton, NY. In

## Environmental Impacts of Operation

1 2001, American shad passage at the Conowingo Dam exceeded 190,000 fish. In 2008, the  
2 number of American shad passing the Conowingo Dam had decreased to less than 20,000 fish,  
3 with only 21 American shad passing the Red Hill (York Haven) Dam fish ladder at TMI-1 (PFBC  
4 2008a). An assessment of the coast-wide stock of American shad by the Atlantic States Marine  
5 Fisheries Commission noted that American shad stocks are at an all-time low and not  
6 recovering, with the primary causes for the decline attributed to “overfishing, pollution loss, and  
7 habitat loss due to dam construction” (ASMFS 2007). Design flaws in existing fish ladders at  
8 dams also limit fish passage at dams located on the Susquehanna River (Greenwire 2008). The  
9 stocking program continues to be conducted annually in efforts to rebuild the American shad  
10 population in the Susquehanna River (PFBC 2007b).

11 Other fish such as the smallmouth bass (*Micropterus dolomieu*) have also experienced a  
12 decline in their Susquehanna River populations. Damming of the river, bacterial infections, river  
13 pollution, and low dissolved oxygen levels are some of the known reasons for smallmouth bass  
14 decline (PFBC 2008b).

15 Twenty major electric power generating plants are located in the Susquehanna River Basin.  
16 Plants in the Lower Subbasin that withdraw cooling water from the Susquehanna River include  
17 Brunner Island, a three-unit, coal-fired, 1483-megawatt (MW) plant located 5 mi (8 km) south of  
18 Harrisburg (PPL 2008), and Peach Bottom Atomic Power Station, a two-unit, 2130-MW nuclear  
19 plant, located 18 mi (29 km) south of Lancaster (NRC 1996). PADEP and SRBC regulate these  
20 facilities with regard to their consumptive water use, NPDES-permitted discharges, and impact  
21 on aquatic resources in the Susquehanna River.

22 As discussed in Section 4.11.1 of this draft supplemental EIS, SRBC regulates consumptive  
23 water use at TMI-1 and at all facilities drawing water from the Susquehanna River. To ensure  
24 the water resources of the Susquehanna River Basin continue to meet the needs of the basin  
25 population, the SRBC coordinates with other State and Federal agencies and conducts  
26 extensive water resources monitoring, project review, water withdrawal registration, drought  
27 coordination, low-flow management (i.e., water storage), reservoir feasibility studies, and ground  
28 water management (SRBC 2007b).

29 The NRC staff concludes that the minimal aquatic impacts expected from the continued TMI-1  
30 operations would not contribute to an overall decline in the condition of aquatic resources.  
31 However, the cumulative impacts on aquatic resources resulting from all past, present, and  
32 reasonably foreseeable future actions, including non-TMI-1 actions, will be SMALL to  
33 MODERATE.  
34

### 35 **4.11.3 Cumulative Impacts on Terrestrial Resources**

36 This section addresses past, present, and future actions that could result in adverse cumulative  
37 impacts to terrestrial resources, including wildlife populations, upland habitats, wetlands,  
38 riparian zones, invasive species, protected species, and land use. For purposes of this analysis,  
39 the geographic area considered in the evaluation includes the TMI-1 site, the land owned by  
40 AmerGen along the eastern bank of the Susquehanna River, the wetlands on and in the vicinity  
41 of the TMI-1 site, and the in-scope transmission line ROWs identified in Section 2.1.5 of this  
42 report.

1 Before construction of the TMI-1 and TMI Unit 2 sites, terrestrial communities on Three Mile  
2 Island supported forest habitat, floodplain habitat, riparian areas, grasslands, and potential  
3 wetland habitat. Initial construction of the TMI-1 and TMI Unit 2 sites converted 200 ac (81 ha)  
4 of the island's 370 ac (150 ha) for plant facilities and industrial uses, which caused loss of  
5 terrestrial habitat (AmerGen 2008). A dike system was created during initial construction of the  
6 TMI-1 and TMI Unit 2 facilities, and a wetland habitat developed once the associated borrow  
7 pits began to fill with water (AmerGen 2008).

8 Construction of the transmission line ROWs maintained by FirstEnergy for the TMI-1 site  
9 resulted in subsequent changes to the plant species present within the ROWs. Because the  
10 length of in-scope transmission lines constructed for TMI-1 is relatively short (5.6 mi [9 km]),  
11 construction most likely did not affect wildlife in the vicinity of the lines. However, fragmentation  
12 resulting from the transmission line ROWs likely caused edge effects such as changes in light,  
13 wind, and temperature; an increased susceptibility to invasive species; and a possible reduction  
14 in habitat ranges for certain species. ROW maintenance has likely had past impacts and is likely  
15 to have present and future impacts on the terrestrial habitat, which may include the buildup of  
16 herbicide chemicals, prevention of natural succession stages, an increase in edge species, a  
17 decrease in interior species, and an increase in invasive species.

18 Neither AmerGen nor FirstEnergy manage invasive species on their land holdings; therefore, a  
19 potential exists for invasive species to be introduced on or in the vicinity of the TMI-1 site or its  
20 associated transmission line ROWs from present and future actions. Introduction of these  
21 species may contribute to the establishment of an invasive species population, which could  
22 compete with native populations for resources and degrade areas of terrestrial habitat.

23 As mentioned above, Brunner Island Power Plant is approximately 5 mi (8 km) south of TMI-1,  
24 and has three coal-fired units, totaling a 1,483-MW capacity (PPL 2008). Fossil plants release  
25 carbon dioxide, mercury, nitrogen oxides, and sulfur oxides, among other air emissions.  
26 Nitrogen oxides and sulfur oxides can combine with water to form acid rain, which can lead to  
27 erosion and changes in soil pH levels. Mercury can deposit on soils and surface water, and may  
28 then be taken up by plant or animal species, posing the risk of bioaccumulation. For these  
29 reasons, the Brunner Island Plant is likely to have current and future impacts to the terrestrial  
30 environment on the TMI-1 site and its surrounding area.

31 Two dams, the York Haven Hydroelectric Station, also known as Olympia Dam, and the Red Hill  
32 Dam, are both located less than 10 mi (16 km) from the TMI-1 project site. The Olympia Dam  
33 produces 19–20 megawatt electric (MWe) (AmerGen 2008). The Red Hill Dam does not  
34 produce electricity. Hydroelectric plants restrict the flow velocity of water downstream, which  
35 can lead to changes in downstream ecosystems. Because TMI-1 is located upstream of  
36 Olympia Dam, the plant is not likely to have cumulative impacts to the terrestrial environment on  
37 the TMI-1 site and its surrounding area.

38 Two wastewater treatment plants are located within 7 mi (11 km) of the TMI-1 site—the Borough  
39 of Middletown Wastewater Treatment Plant in Middletown, approximately 2 mi (3.2 km) north of  
40 the TMI-1 site, and the Fairview Sewerage Treatment Plant in New Cumberland, approximately  
41 7 mi (11 km) north of the TMI-1 site. Both plants are on the Susquehanna River. Chemical  
42 discharges from these wastewater treatment plants that enter the Susquehanna River may have  
43 current and future impacts on the surrounding vegetation, wetlands, and wildlife.

## Environmental Impacts of Operation

1 Bioaccumulation of chemical discharges from these treatment plants also poses a threat to  
2 terrestrial and riparian habitats as well as to wildlife species.

3 Prior and continued residential, commercial, and industrial development of Dauphin, Lancaster,  
4 and York Counties may impact terrestrial habitat in the vicinity of TMI-1 and the associated  
5 transmission line ROWs. Increases in both commercial and residential development have  
6 occurred in these counties over the past 40 years. As this area continues to grow, additional  
7 runoff from roads and impervious surfaces, development adjacent to wetlands and riparian  
8 zones, and an increase in waste releases could have future impacts on the terrestrial habitat.  
9 Section 2.2.8.3 discusses offsite land use in the vicinity of TMI-1.

10 The NRC staff believes that the cumulative impacts during the term of license renewal on  
11 terrestrial habitat and associated species, when added to past, present, and reasonably  
12 foreseeable future actions, would be SMALL.

13

### 14 **4.11.4 Cumulative Human Health Impacts**

15 The NRC and EPA developed radiological dose limits for protection of the public and workers to  
16 address the cumulative impact of acute and long-term exposure to radiation and radioactive  
17 material. These dose limits are codified in 10 CFR Part 20 and 40 CFR Part 190. This analysis  
18 includes the area within a 50-mi (80-km) radius of the TMI-1 site. The REMP conducted by  
19 AmerGen in the vicinity of the TMI-1 site measures the cumulative impact of radiation and  
20 radioactive materials from all sources, including the shut-down and defueled TMI Unit 2; Peach  
21 Bottom Atomic Power Station, Units 2 and 3; and Peach Bottom Unit 1, which has been shut  
22 down since October 1974.

23 In addition to the Unit 1 operating reactor, Three Mile Island also contains the remains of the  
24 TMI Unit 2 facility that had an accident with a partial fuel meltdown in 1979. TMI Unit 2 is  
25 permanently shut down and defueled. The damaged fuel and core debris was shipped offsite to  
26 a DOE facility. The facility has been in a monitored storage mode since December 1993 and will  
27 remain in that condition until the operating license for TMI-1 expires, at which time both plants  
28 will be decommissioned.

29 Even though TMI Unit 2 is defueled and in a monitored storage mode, there are still some  
30 controlled radioactive effluent discharges resulting from maintenance and cleanup activities.  
31 These radioactive discharges are a very small fraction of the radioactivity released from TMI-1.  
32 The calculated radiation doses to members of the public from all radioactive material released  
33 from the TMI-1 site are well within NRC's radiation safety limits. In addition to the radioactive  
34 effluent information, the staff reviewed the TMI-1 annual radiological environmental monitoring  
35 report. This report summarizes the results of environmental monitoring conducted in the  
36 environs around the TMI-1 site to determine the environmental impact from the radioactive  
37 releases from the entire TMI-1 site. No unusual trends or significant radiation levels were  
38 detected in the environment from the two units located on Three Mile Island.

39 Peach Bottom Atomic Power Station has two active nuclear reactor units (Units 2 and 3). Each  
40 unit includes a light-water boiling reactor and a steam-driven turbine generator. The facility's  
41 core power output from the two units is 3,458 megawatt-thermal (MWt). In addition to the  
42 operating units, the site also contains the shut-down Peach Bottom Atomic Power Station Unit



1 1. Unit 1 was a prototype, high-temperature, gas-cooled reactor that had a net electrical output  
2 of 40 MWe (115 MWt) and operated from 1966–1974. Since then it has been maintained in a  
3 storage mode. As part of normal operations, Peach Bottom Atomic Power Station, Units 2 and  
4 3, release radioactive effluents, contributing to the cumulative dose impacts to members of the  
5 public and the environment.

6 As discussed in Section 4.8.1 of this report, the staff reviewed the radiological environmental  
7 radiation monitoring results for the five-year period from 2003–2007 as part of the cumulative  
8 impacts assessment. Cumulative radiological impacts from all uranium fuel cycle facilities,  
9 including those discussed above, within a 50-mi (80-km) radius of the TMI-1 site, are limited by  
10 the dose limits codified in 10 CFR Part 20 and 40 CFR Part 190. In Section 4.8 of this report,  
11 the NRC staff concluded that the impacts of radiation exposure from the operation of TMI-1  
12 during the renewal term to the public would be SMALL. The NRC and the Commonwealth of  
13 Pennsylvania will regulate any future actions in the vicinity of the TMI-1 site that could contribute  
14 to cumulative radiological impacts.

15 The continued operation of TMI-1 has a low risk of causing outbreaks from thermophilic  
16 microbiological organisms associated with thermal discharges. Available data assembled by the  
17 CDC for the years 1999 to 2004 (CDC 2001, 2002, 2002a, 2003, 2003a, 2004, 2005, 2006,  
18 2007b) report no occurrence of waterborne disease outbreaks in the Commonwealth of  
19 Pennsylvania resulting from thermophilic microorganisms *Naegleria fowleri* and *Pseudomonas*  
20 *aeruginosa* from the operation of TMI-1. Outbreaks of legionellosis, salmonellosis, or shigellosis  
21 that occurred in the Commonwealth of Pennsylvania were within the range of national trends in  
22 terms of cases per 100,000 population or total cases per year, and the outbreaks were  
23 associated with hotel pools and spas (CDC 2001, 2002, 2002a, 2003, 2003a, 2004, 2005, 2006,  
24 2007b).

25 As part of its evaluation of cumulative impacts, the NRC staff also considered the effects of  
26 thermal discharges from other facilities on the Susquehanna River located within one mile  
27 upstream of TMI-1 that are also producing thermal effluents. Such facilities could promote the  
28 growth of thermophilic microbiological organisms. The NRC staff did not find any such facilities.

29 On the basis of these considerations, the NRC staff determined that the cumulative impacts to  
30 public health from thermophilic microbiological organisms resulting from operation of the TMI-1  
31 thermal discharge to the aquatic environment or in the vicinity of the site would be SMALL.

32 The staff determined that the electric field-induced currents from the TMI-1 transmission lines  
33 are well below the NESC recommendations for preventing electric shock from induced currents.  
34 Therefore, the TMI-1 transmission lines do not detectably affect the overall potential for electric  
35 shock from induced currents within the analysis area. With respect to the chronic effects of  
36 electromagnetic fields, although the GEIS finding of “not applicable” is appropriate to TMI-1, the  
37 transmission lines associated with TMI-1 are not likely to detectably contribute to the regional  
38 exposure to extremely low frequency electromagnetic fields. Therefore, the staff has determined  
39 that the cumulative impacts of the continued operation of the TMI-1 transmission lines would be  
40 SMALL.

41

1 **4.11.5 Cumulative Socioeconomic Impacts**

2 As discussed in Section 4.9 of this draft supplemental EIS, continued operation of TMI-1 during  
3 the license renewal term would have no impact on socioeconomic conditions in the region  
4 beyond those already being experienced. Since AmerGen has indicated that no additional  
5 workers would be hired during the license renewal term, overall expenditures and employment  
6 levels at TMI-1 would be expected to remain relatively constant with no additional demand for  
7 permanent housing, public utilities, and public services. In addition, since employment levels  
8 and the value of TMI-1 would not change, there would be no population and tax revenue-related  
9 land use impacts. There would also be no disproportionately high and adverse health and  
10 environmental impacts on minority and low-income populations in the region. Based on this and  
11 other information presented in this draft supplemental EIS, there would be no cumulative  
12 socioeconomic impacts from the continued operation of TMI-1 during the license renewal term  
13 beyond those already being experienced.

14 However, AmerGen indicated in their environmental report that TMI-1 steam generators would  
15 be replaced prior to the license renewal term. AmerGen estimates that steam generator  
16 replacement would require a one-time increase in the number of refueling outage workers for up  
17 to 70 days at TMI-1 (AmerGen 2008). These additional workers would create a one-time short-  
18 term increase in the demand for temporary (rental) housing, increase use of public water and  
19 sewer services, and transportation impacts on access roads in the immediate vicinity of TMI-1.  
20 Given the short amount of time needed to replace the steam generators, the additional number  
21 of refueling outage workers and truck material deliveries needed to support this one-time  
22 replacement of the TMI-1 steam generators could have a temporary cumulative effect on  
23 socioeconomic conditions in the vicinity of TMI-1. However, there would be no long-term  
24 cumulative socioeconomic impacts from TMI-1 steam generator replacement in the region.

25 As discussed in Section 4.9.6, continued operation of TMI-1 during the license renewal term  
26 would have a SMALL impact on historic and archaeological resources. AmerGen has no plans  
27 to construct additional facilities at TMI-1 related to license renewal. Any land disturbing activities  
28 would be carried out under AmerGen's corporate procedures that ensure the protection of  
29 cultural resources (AmerGen 2008). AmerGen does not anticipate any changes or additions to  
30 transmission line structures. Additionally, AmerGen plans to revise its procedures to provide  
31 clear guidance regarding consideration of potential impacts on historic and archaeological  
32 resources. This revision includes a "stop work" provision when cultural resources are  
33 inadvertently discovered (AmerGen 2008). Since AmerGen has committed to issue revised  
34 procedures, no additional adverse impacts to historic and archaeological resources are  
35 expected during the license renewal term. However, as noted in Section 4.9.6, there is the  
36 potential for prehistoric and historic archaeological resources to be present at TMI-1. Should  
37 project plans change, then further mitigation and consultation would be initiated by AmerGen  
38 with the PHMC. Based on this and other information presented in the SEIS, the staff finds that  
39 there would be no cumulative historic and archaeological impacts from the continued operation  
40 of TMI-1 during the license renewal term beyond those that have already occurred.

41 AmerGen has indicated that it plans to replace TMI-1 steam generators prior to the license  
42 renewal term. Construction, decontamination, and laydown activities would be less than 10 ac  
43 (4 ha) and would be limited to previously disturbed areas (AmerGen 2008). AmerGen has

1 consulted with the PHMC regarding this activity. The PHMC stated that the project would have  
 2 no effect on historic and archaeological resources, however, should additional grounddisturbing  
 3 activities occur, then further consultation with the PHMC would be required (AmerGen 2008).

4  
 5 **4.11.6 Summary of Cumulative Impacts**

6 We considered the potential impacts resulting from operation of TMI-1 during the period of  
 7 extended operation and other past, present, and future actions in the vicinity of TMI-1. The  
 8 preliminary determination is that the potential cumulative impacts resulting from TMI-1 operation  
 9 during the period of extended operation would be SMALL to MODERATE.

10 **Table 4-11. Summary of Cumulative Impacts on Resources Areas.**

Resource Area	Impact	Discussion
Water Resources	SMALL	Impacts to water resources in the subbasin include increases in land development, overuse of ground water resources, unregulated use of ground water resources, drought impacts, and the need for flow compensation for consumptive water users. The SRBC regulates, monitors, and enforces withdrawals of ground water and surface water in the subbasin, and manages the subbasin's water resources. Continued operation of TMI-1 would have small cumulative impacts to water resources if compliance with SRBC regulations and participation in their water storage project is maintained.
Aquatic Resources	SMALL to MODERATE	Impacts to aquatic resources from continued operation of TMI-1 would have small cumulative impacts. Past impacts to Susquehanna River water quality have impacted aquatic resources; and continued impacts from agriculture, livestock production, and development will continue to impact aquatic resources. Regulation of point-source discharges by PADEP and of subbasin water use by the SRBC will continue to mitigate impacts. Continued operation and potential future uprates to dams on the Susquehanna River will also impact aquatic resources.
Terrestrial Resources	SMALL	ROW maintenance, emissions from the Bruner Island coal-fired power plant, invasive species, chemical discharges from nearby wastewater treatment plants, and development of Dauphin, Lancaster, and York Counties have all impacted terrestrial habitat and species in the vicinity of TMI-1, and would likely continue in the future.

## Environmental Impacts of Operation

1

---

Human Health	SMALL	The cumulative human health impacts of continued operation of TMI-1 from radiation exposure to the public, microbiological organisms from thermal discharge to the Susquehanna River, and electric-field-induced currents from the TMI-1 transmission lines would all be small.
Socioeconomics	N/A	There would be no cumulative impacts to socioeconomics during the license renewal period, and no long-term cumulative impacts from refurbishment. There would be no cumulative impacts to historic and archaeological resources during the license renewal period, including refurbishment, beyond those that have already occurred.

---

2

3

### 4 **4.12 References**

5 10 CFR 20. *Code of Federal Regulations*, Title 10, *Energy*, Part 20, "Standards for Protection  
6 Against Radiation."

7 10 CFR Part 50. *Code of Federal Regulations*, Title 10, *Energy*, Part 50, "Domestic Licensing of  
8 Production and Utilization Facilities."

9 10 CFR 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, "Environmental Protection  
10 Regulations for Domestic Licensing and Related Regulatory Functions."

11 10 CFR Part 61. *Code of Federal Regulations*, Title 10, *Energy*, Part 61, "Licensing  
12 Requirements for Land Disposal of Radioactive Waste."

13 10 CFR Part 71. *Code of Federal Regulations*, Title 10, *Energy*, Part 71, "Packaging and  
14 Transportation of Radioactive Material."

15 36 CFR Part 60. *Code of Federal Regulations*, Title 36, *Parks, Forests, and Public Property*,  
16 Part 60, Section 4, "Criteria for Evaluation."

17 36 CFR 800. *Code of Federal Regulations*, Title 36, *Parks, Forests, and Public Property*, Part  
18 800, "Protection of Historic Properties."

19 40 CFR 190. *Code of Federal Regulations*, Title 40, *Protection of the Environment*, Part 190,  
20 "Environmental Radiation Protection Standards for Nuclear Power Operations."

- 1 59 FRN 7629. Executive Order 12898. "Federal Actions to Address Environmental Justice in  
2 Minority Populations and Low-Income Populations." *Federal Register*. Vol. 59, No. 32, p. 7629.  
3 Washington, D.C. February 16, 1994.
- 4 69 FRN 52040. "Treatment of Environmental Justice Matters in NRC Regulatory and Licensing  
5 Actions." *Federal Register*. Vol. 69, No. 163, pp. 52040-52048. Washington, D.C. August 24,  
6 2004.
- 7 ACHP (Advisory Council on Historic Preservation). 2008. "National Register Evaluation Criteria."  
8 Available URL: <http://www.achp.gov/nrcriteria.html> (accessed on October 10, 2008). ADAMS  
9 No. ML082880723.
- 10 Adkins, C.J. 1984. *Equilibrium Thermodynamics*, 3<sup>rd</sup> ed. Cambridge University Press.
- 11 AEC (U.S. Atomic Energy Commission). 1972. *Final Environmental Statement related to the*  
12 *operation of Three Mile Island Nuclear Station, Units 1 and 2. Metropolitan Edison Company, et*  
13 *al. Docket Nos. 50-289 and 50-320.* Directorate of Licensing. December. Washington, D.C.  
14 ADAMS No. ML080090250.
- 15 AmerGen (AmerGen Energy Company, LLC). 2004. *Three Mile Island Nuclear Station Unit-1*  
16 *and Unit-2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket*  
17 *Nos. 50-289 and 50-320. Radiological Environmental Monitoring Program Report, 1 January*  
18 *through 31 December 2003.* Middletown, PA. ADAMS No. ML041250580.
- 19 AmerGen (AmerGen Energy Company, LLC). 2004a. *Three Mile Island Nuclear Station Unit-1*  
20 *and Unit-2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket*  
21 *Nos. 50-289 and 50-320. Combined 2003 Annual Radioactive Effluent Release Report.*  
22 Middletown, PA. ADAMS No. ML041180052.
- 23 AmerGen (AmerGen Energy Company, LLC). 2005. *Three Mile Island Nuclear Station Unit-1*  
24 *and Unit-2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket*  
25 *Nos. 50-289 and 50-320. Radiological Environmental Monitoring Program Report. 1 January*  
26 *through 31 December 2004.* Middletown, PA. ADAMS No. ML051260258.
- 27 AmerGen (AmerGen Energy Company, LLC). 2005a. *Three Mile Island Nuclear Station Unit-1*  
28 *and Unit-2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket*  
29 *Nos. 50-289 and 50-320. Combined 2004 Annual Radioactive Effluent Release Report.*  
30 Middletown, PA. ADAMS No. ML051260269.
- 31 AmerGen (AmerGen Energy Company, LLC). 2006. *Three Mile Island Nuclear Station Unit-1*  
32 *and Unit-2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket*  
33 *Nos. 50-289 and 50-320. Updated Final Safety Analysis Report.* Middletown, PA. ADAMS No.  
34 ML080800161.
- 35 AmerGen (AmerGen Energy Company, LLC). 2006a. *Three Mile Island Nuclear Station Unit-1*  
36 *and Unit-2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket*

## Environmental Impacts of Operation

- 1 Nos. 50-289 and 50-320. *Combined 2005 Annual Radioactive Effluent Release Report*.  
2 Middletown, PA. ADAMS No. ML061230244.
- 3 AmerGen (AmerGen Energy Company, LLC). 2006b. *Three Mile Island Nuclear Station Unit-1*  
4 *and Unit-2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket*  
5 *Nos. 50-289 and 50-320. Radiological Environmental Monitoring Program Report, 1 January*  
6 *through 31 December 2005*. Middletown, PA. ADAMS No. ML061220487.
- 7 AmerGen (AmerGen Energy Company, LLC). 2007. *Three Mile Island Nuclear Station Unit-1*  
8 *and Unit-2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket*  
9 *Nos. 50-289 and 50-320. Combined 2006 Annual Radioactive Effluent Release Report (ODCM*  
10 *Revision 25 Enclosed)*. Middletown, PA. ADAMS No. ML071290369.
- 11 AmerGen (AmerGen Energy Company, LLC). 2007a. *Three Mile Island Nuclear Station Unit-1*  
12 *and Unit-2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket*  
13 *Nos. 50-289 and 50-320. Radiological Environmental Monitoring Program Report, 1 January*  
14 *through 31 December 2006*. Middletown, PA. ADAMS No. ML071290163.
- 15 AmerGen (AmerGen Energy Company, LLC). 2008. *Three Mile Island Nuclear Station, Unit 1,*  
16 *Applicant's Environmental Report, License Renewal Operating Stage*. Kennett Square, PA.  
17 ADAMS Nos. ML080220255, ML080220257, ML080220261, and ML080220282.
- 18 AmerGen (AmerGen Energy Company, LLC). 2008a. *Three Mile Island Nuclear Station Unit-1*  
19 *and Unit-2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket*  
20 *Nos. 50-289 and 50-320. Radiological Environmental Monitoring Program Report, 1 January*  
21 *through 31 December 2007*. Middletown, PA. ADAMS No. ML081300255.
- 22 AmerGen (AmerGen Energy Company, LLC). 2008b. *Three Mile Island Nuclear Station Unit-1*  
23 *and Unit-2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket*  
24 *Nos. 50-289 and 50-320. Combined 2007 Annual Radioactive Effluent Release Report*.  
25 Middletown, PA. ADAMS No. ML081300410.
- 26 AmerGen (AmerGen Energy Company, LLC). 2008c. "Excerpts about meat sampling from the  
27 Annual Radiological Environmental Monitoring Program (REMP) Reports for the period from  
28 1990 through 2001." *Three Mile Island, Unit 1, Enclosure A -Post Audit Environmental*  
29 *Information – Index Through Audit Question ENV-070, Monthly Report on the Meteorological*  
30 *Monitoring Program, February 2007 (Non-Proprietary Version)*. June 10. ADAMS No.  
31 ML082110252.
- 32 ASMFC (Atlantic States Marine Fisheries Commission). 2007. *Review of the Atlantic States*  
33 *Marine Fisheries Commission Fishery Management Plan for Shad and River Herring (Alosa*  
34 *spp.)*. October 3, 2007. Available URL:  
35 <http://www.asmfc.org/speciesDocuments/shad/fmps/2007ShadFMPReviewfor2006.pdf>  
36 (accessed November 7, 2008). ADAMS No. ML083170642.
- 37 CBF (Chesapeake Bay Foundation). 2005. *The Mighty Susquehanna River: Pollution Degrades*  
38 *Our Streams, the River, and the Chesapeake Bay*. Available URL:

- 1 [http://www.cbf.org/site/DocServer/susquehanna\\_factsheet.pdf?docID=3443](http://www.cbf.org/site/DocServer/susquehanna_factsheet.pdf?docID=3443) (accessed July 18,  
2 2008). ADAMS No. ML082381277.
- 3 CBF (Chesapeake Bay Foundation). 2006. *Waters at Risk; Pollution in the Susquehanna*  
4 *Watershed – Sources and Solutions*. Available URL:  
5 <http://www.cbf.org/site/DocServer/WatersAtRisk.pdf?docID=5724> (accessed August 21, 2008).  
6 ADAMS No. ML082880724.
- 7 CDC (Centers for Disease Control and Prevention). 2001. *Summary of Notifiable Diseases,*  
8 *United States 1999. Morbidity and Mortality Weekly Report, Vol. 48, No. 53.* April 6. Atlanta, GA.
- 9 CDC (Centers for Disease Control and Prevention). 2002. *Summary of Notifiable Diseases*  
10 *United States, 2000. Morbidity and Mortality Weekly Report, Vol. 49, No. 53.* June 14. Atlanta,  
11 GA.
- 12 CDC (Centers for Disease Control and Prevention). 2002a. *Surveillance for Waterborne-*  
13 *Disease Outbreaks - United States, 1999-2000. Morbidity and Mortality Weekly Report, Vol. 51*  
14 *(SS08).* November 22. Atlanta, GA.
- 15 CDC (Centers for Disease Control and Prevention). 2003. *Summary of Notifiable Diseases -*  
16 *United States, 2001. Morbidity and Mortality Weekly Report, Vol. 52, No. 40.* May 2. Atlanta,  
17 GA. May 2, 2003.
- 18 CDC (Centers for Disease Control and Prevention). 2003a. *Primary Amebic*  
19 *Meningoencephalitis - Georgia, 2002. Morbidity and Mortality Weekly Report, Vol. 50, No. 53.*  
20 October 10. Atlanta, GA.
- 21 CDC (Centers for Disease Control and Prevention). 2004. *Surveillance for Waterborne-Disease*  
22 *Outbreaks Associated with Recreational Water-United States, 2001-2002. Morbidity and*  
23 *Mortality Weekly Report, Vol. 53 (SS08).* October 22. Atlanta, GA.
- 24 CDC (Centers for Disease Control and Prevention). 2005. *Summary of Notifiable Diseases -*  
25 *United States, 2003. Morbidity and Mortality Weekly Report, Vol. 52, No. 54.* April 22. Atlanta,  
26 GA.
- 27 CDC (Centers for Disease Control and Prevention). 2006. *Summary of Notifiable Diseases -*  
28 *United States, 2004. Morbidity and Mortality Weekly Report, Vol. 53, No. 53.* June 16. Atlanta,  
29 GA.
- 30 CDC (Centers for Disease Control and Prevention). 2007. "Legionellosis: Legionnaires Disease  
31 and Pontiac Fever." Available URL:  
32 [http://www.cdc.gov/ncidod/dbmd/diseaseinfo/legionellosis\\_g.htm](http://www.cdc.gov/ncidod/dbmd/diseaseinfo/legionellosis_g.htm) (accessed on March 27,  
33 2008). ADAMS No. ML080230326.
- 34 CDC (Centers for Disease Control and Prevention). 2007a. "Salmonellosis." Available URL:  
35 [http://www.cdc.gov/ncidod/dbmd/diseaseinfo/salmonellosis\\_g.htm](http://www.cdc.gov/ncidod/dbmd/diseaseinfo/salmonellosis_g.htm) (accessed on March 27,  
36 2008). ADAMS No. ML080230323.

## Environmental Impacts of Operation

- 1 CDC (Centers for Disease Control and Prevention). 2007b. *Summary of Notifiable Diseases -*  
2 *United States, 2005. Morbidity and Mortality Weekly Report, Vol. 54, No. 53.* March 30. Atlanta,  
3 GA.
- 4 CEQ (Council on Environmental Quality). 1997. *Environmental Justice: Guidance Under the*  
5 *National Environmental Policy Act.* Executive Office of the President. December 10.  
6 Washington, DC. Available URL:  
7 [http://www.epa.gov/compliance/resources/policies/ej/ej\\_guidance\\_nepa\\_ceq1297.pdf](http://www.epa.gov/compliance/resources/policies/ej/ej_guidance_nepa_ceq1297.pdf) (accessed  
8 August 18, 2008). ADAMS No. ML082520150.
- 9 DCNR (Pennsylvania Department of Conservation and Natural Resources). 2008. Letter from R.  
10 Bowen, Environmental Review Specials, Pennsylvania Department of Conservation and Natural  
11 Resources, to L. Lund, Branch Chief, Division of License Renewal, Nuclear Regulatory  
12 Commission. Subject: Pennsylvania Natural Diversity Inventory Review, PNDI Number 19605,  
13 Three Mile Island Unit 1 License Renewal Species of Special Concern, Dauphin & Lancaster  
14 Counties. May 2, 2008. ADAMS No. ML081300048.
- 15 Durlin, R.R. and W.P. Schaffstall. 2005. *Water Resources Data Pennsylvania Water Year 2004,*  
16 *Water-Data Report PA-04-2.* U.S. Geological Survey. May. New Cumberland, PA. ADAMS No.  
17 ML081980705.
- 18 ESR (Institute of Environmental Science & Research Limited). 2002. *Risk Profile: Salmonella*  
19 *(Non Typhoid) in Poultry (Whole and Pieces).* Christchurch, New Zealand. October. Available  
20 URL: [http://www.nzfsa.govt.nz/science/risk-profiles/salmonella-in-poultry-](http://www.nzfsa.govt.nz/science/risk-profiles/salmonella-in-poultry-meat.pdf?bcsi_scan_513F405096A035F7=0&bcsi_scan_filename=salmonella-in-poul)  
21 [meat.pdf?bcsi\\_scan\\_513F405096A035F7=0&bcsi\\_scan\\_filename=salmonella-in-poul](http://www.nzfsa.govt.nz/science/risk-profiles/salmonella-in-poultry-meat.pdf?bcsi_scan_513F405096A035F7=0&bcsi_scan_filename=salmonella-in-poul)  
22 (accessed on March 27, 2008). ADAMS No. ML080880142.
- 23 FWS (United States Fish and Wildlife Service). 2008. Letter from D. Densmore, Supervisor,  
24 U.S. Fish and Wildlife Service, Pennsylvania Field Office, to L. Lund, Branch Chief, Division of  
25 License Renewal, Nuclear Regulatory Commission. Subject: Three Mile Island Nuclear Station,  
26 Unit 1, License Renewal Application Review. April 23, 2008. ADAMS No. ML081280307.
- 27 Greenwire. 2008. *Renewable Energy: Hydropower Makes a Quiet Comeback.* October 28.  
28 Available URL: <http://www.eenews.net/Greenwire/2008/10/28/archive/4?terms=holtwood>  
29 (accessed November 7, 2008). ADAMS No. ML083170642.
- 30 Hendricks, C.W. 1972. "Enteric Bacterial Growth Rates in River Water." *Applied Microbiology*  
31 24(2):168-174.
- 32 Joklik, W. K, and H. P. Willet. 1976. *Zinsser Microbiology*, 16<sup>th</sup> ed. Appleton-Century-Crofts,  
33 New York.
- 34 NAS (National Research Council of the National Academies of Science). 2004. *Indicators for*  
35 *Waterborne Pathogens.* The National Academies Press, Washington, D.C.



- 1 NESC (National Electrical Safety Code). 2007. Institute of Electrical and Electric Engineers. NY.  
 2 ADAMS No. ML080880143.
- 3 NHPA (*National Historic Preservation Act*). 1996. 16 U.S.C. 470, et seq.
- 4 NIEHS (National Institute of Environmental Health Sciences). 1999. *NIEHS Report on Health*  
 5 *Effects from Exposure to Power Line Frequency and Electric and Magnetic Fields*. Publication  
 6 No. 99-4493, Research Triangle Park, NC.
- 7 NRC (U.S. Nuclear Regulatory Commission). 1976. *NUREG-0112. Final Supplement to the*  
 8 *Final Environmental Statement Related to the Operation of Three Mile Island Nuclear Station,*  
 9 *Unit 2, Metropolitan Edison Company et al., Docket No. 50-320*. Office of Nuclear Reactor  
 10 Regulation, Washington, D.C. December. ADAMS No. ML080090250.
- 11 NRC (U.S. Nuclear Regulatory Commission). 1981. *Final Environmental Statement Related to*  
 12 *the Operation of Susquehanna Steam Electric Station. Pennsylvania Power & Light Company*  
 13 *and Allegheny Electric Cooperative, Inc.* Docket Nos. 50-387 and 50-388. Office of Nuclear  
 14 Reactor Regulation, Washington, D.C. June. ADAMS No. ML080150291.
- 15 NRC (U.S. Nuclear Regulatory Commission). 1996. *Generic Environmental Impact Statement*  
 16 *for License Renewal of Nuclear Plants*. NUREG-1437, Volumes 1 and 2, Washington, D.C.  
 17 ADAMS No. ML061770605.
- 18 NRC (U.S. Nuclear Regulatory Commission). 1999. *Generic Environmental Impact Statement*  
 19 *for License Renewal of Nuclear Plants, Main Report*, “Section 6.3 – Transportation, Table 9.1,  
 20 Summary of findings on NEPA issues for license renewal of nuclear power plants, Final Report.”  
 21 NUREG-1437, Volume 1, Addendum 1, Washington, D.C.
- 22 NRC (U.S. Nuclear Regulatory Commission). 2000. *Standard Review Plan for Environmental*  
 23 *Reviews for Nuclear Power Plants, Supplement 1: Operating License Renewal*. NUREG-1555,  
 24 Supplement 1, Washington, D.C.
- 25 NRC (U.S. Nuclear Regulatory Commission). 2008. Letter from L. Lund, U.S. Nuclear  
 26 Regulatory Commission, Washington, D.C., to J. Cutler, Pennsylvania Historical and Museum  
 27 Commission, Harrisburg, Pennsylvania. Subject: “Three Mile Island Nuclear Station, Unit 1,  
 28 License Renewal Application Review (File No. ER 07-1737-043-A).” ADAMS No.  
 29 ML080930380.
- 30 NRC (U.S. Nuclear Regulatory Commission). 2008a. Letter from L. Lund, U.S. Nuclear  
 31 Regulatory Commission, Washington, D.C., to C. Vaughn, Advisory Council on Historic  
 32 Preservation, Washington, D.C. Subject: “Three Mile Island Nuclear Station, Unit 1, License  
 33 Renewal Application Review.” ADAMS No. ML080930296.
- 34 PADEP (Pennsylvania Department of Environmental Protection). 2008. *Environmental*  
 35 *Radiation in Pennsylvania. 2003 and 2004 Annual Reports*. Available URL:  
 36 [http://www.dep.state.pa.us/brp/BRP\\_Info/Annual\\_Reports.htm](http://www.dep.state.pa.us/brp/BRP_Info/Annual_Reports.htm) (accessed August 18, 2008).  
 37 ADAMS No. ML082880726.
- 38 PGC (Pennsylvania Game Commission). 2008. Letter from J. Leigey, Division of Environmental  
 39 Planning and Habitat Protection, Bureau of Wildlife Habitat Management, to L. Lund, Branch

## Environmental Impacts of Operation

- 1 Chief, Division of License Renewal, Nuclear Regulatory Commission. Subject: State-Protected  
2 Bird and Mammal Species Review, Three Mile Island Nuclear Station License Renewal  
3 Application, Londonderry Township, Dauphin County, PA. May 14, 2008. ADAMS No.  
4 ML081500671.
- 5 PFBC (Pennsylvania Fish & Boat Commission). 2007. *Migratory Fish Restoration and Passage*  
6 *on the Susquehanna River*. Available URL:  
7 [http://www.fish.state.pa.us/pafish/shad/migratory\\_fish.pdf](http://www.fish.state.pa.us/pafish/shad/migratory_fish.pdf) (accessed July 31, 2008). ADAMS  
8 No. ML080230330.
- 9 PFBC (Pennsylvania Fish & Boat Commission). 2008. Letter from C. Urban, Chief, Natural  
10 Diversity Section, Pennsylvania Fish & Boat Commission, Bellefonte, Pennsylvania, to S.  
11 Lopas, Nuclear Regulatory Commission, Rockville, Maryland. Subject: Species Impact Review  
12 (SIR) – Rare, Candidate, Threatened and Endangered Species, Three Mile Island Nuclear  
13 Station, Londonderry Township/Borough, Dauphin County, Pennsylvania. June 3, 2008.  
14 ADAMS No. ML081610104.
- 15 PFBC (Pennsylvania Fish & Boat Commission). 2008a. “Susquehanna River American Shad.”  
16 Available URL: ([http://www.fish.state.pa.us/shad\\_susq.htm](http://www.fish.state.pa.us/shad_susq.htm) (accessed June 11, 2008). ADAMS  
17 No. ML082381115.
- 18 PFBC (Pennsylvania Fish & Boat Commission). 2008b. *Susquehanna River Drainage YOY*  
19 *Smallmouth Bass Disease Investigations 2005 and 2007*. URL:  
20 [http://www.fish.state.pa.us/pafish/bass\\_black/meetings/fish\\_committee2007sep/mortality07\\_05.](http://www.fish.state.pa.us/pafish/bass_black/meetings/fish_committee2007sep/mortality07_05.pdf?bcsi_scan_B666A1DE717DB577=0&bcsi_scan_filename=mortality07_05.pdf)  
21 [pdf?bcsi\\_scan\\_B666A1DE717DB577=0&bcsi\\_scan\\_filename=mortality07\\_05.pdf](http://www.fish.state.pa.us/pafish/bass_black/meetings/fish_committee2007sep/mortality07_05.pdf?bcsi_scan_B666A1DE717DB577=0&bcsi_scan_filename=mortality07_05.pdf) (accessed  
22 June 3, 2008). ADAMS No. ML082880420.
- 23 PFBC (Pennsylvania Fish & Boat Commission). 2008c. “2008 Pennsylvania Fishing Summary,  
24 Summary of Fishing Regulations and Laws”. Available URL:  
25 <http://www.fish.state.pa.us/fishpub/summary/z00complete.pdf> (accessed July 23, 2008).  
26 ADAMS No. ML082880450.
- 27 PNHP (Pennsylvania Natural Heritage Program). 2008. “State Species List, Update June 2008.”  
28 Available URL: <http://www.naturalheritage.state.pa.us/Homepage.aspx> (accessed July 14,  
29 2008). ADAMS No. ML082381127.
- 30 PPL Corporation (PPL). 2008. “Bruner Island Fact Sheet.” Available URL:  
31 <http://www.pplweb.com/ppl+generation/coal+plants/ppl+brunner+island+-+fact+sheet.htm>  
32 (accessed June 5, 2008). Accessible at ML08082381272.
- 33 SRBC (Susquehanna River Basin Commission). 2005. *Groundwater Management Plan for the*  
34 *Susquehanna River Basin*. June 8. Available URL:  
35 [http://www.srbc.net/programs/docs/GW\\_Mngt\\_Plan\\_June2005/Groundwater\\_Mgt\\_Plan\\_2005.ht](http://www.srbc.net/programs/docs/GW_Mngt_Plan_June2005/Groundwater_Mgt_Plan_2005.htm)  
36 [m](http://www.srbc.net/programs/docs/GW_Mngt_Plan_June2005/Groundwater_Mgt_Plan_2005.htm) (accessed July 28, 2008). ADAMS No. ML082880727.

- 1 SRBC (Susquehanna River Basin Commission). 2006. *Lower Susquehanna Subbasin Survey: A Water Quality and Biological Assessment, June – November 2005, Publication 247.*  
2  
3 September. Available URL:  
4 [http://www.srbc.net/pubinfo/techdocs/Publication\\_247/LowerSusqRept.pdf](http://www.srbc.net/pubinfo/techdocs/Publication_247/LowerSusqRept.pdf) (accessed August  
5 21, 2008). ADAMS No. ML082381270.
- 6 SRBC (Susquehanna River Basin Commission). 2008. *Draft Comprehensive Plan for the Water  
7 Resources of the Susquehanna River Basin.* Harrisburg, PA. May. Available URL:  
8 [http://www.srbc.net/planning/comp\\_plan\\_with\\_appendicies.pdf](http://www.srbc.net/planning/comp_plan_with_appendicies.pdf) (accessed August 20, 2008).  
9 ADAMS No. ML082880729.
- 10 SRBC (Susquehanna River Basin Commission). Undated. “Lower Susquehanna Subbasin  
11 Information.” Available URL: <http://www.srbc.net/subbasin/lowersus.htm> (accessed August 20,  
12 2008). ADAMS No. ML082381278.
- 13 Todar, K. 2007. *Todar’s Online Textbook of Bacteriology.* Available URL:  
14 <http://www.textbookofbacteriology.net> (accessed on July 27, 2007).
- 15 Tyndall, R. L., et al. 1989. “Effect of thermal additions on the density and distribution of  
16 thermophilic amoebae and pathogenic *Naegleria fowleri* in a newly created cooling lake.”  
17 *Applied Environmental Microbiology* 55:722–732.
- 18 USCB (U.S. Census Bureau). 2003. *Landview 6 – Census 2000 Profile of General Demographic  
19 Characteristics DP-1 (100%) and Census Profile of Selected Economic Characteristics DP-3,  
20 Summary of Census Block Groups in a 50-mile Radius around TMI-1 (40.154569 Lat., -  
21 76.725256 Long.)* December. Washington, D.C.
- 22 USCB (U.S. Census Bureau). 2008. “American FactFinder, Census 2000 Information,” and  
23 “State and County QuickFacts on Dauphin and Lancaster Counties.” Searchable databases.  
24 Available URLs: <http://factfinder.census.gov> and <http://quickfacts.census.gov> (accessed July  
25 2008).
- 26 WHO (World Health Organization). 2007. *Extremely Low Frequency Fields Environmental  
27 Health Criteria Monograph No.238.* Geneva, Switzerland. Available URL:  
28 [http://www.who.int/peh-emf/publications/elf\\_ehc/en/index.html](http://www.who.int/peh-emf/publications/elf_ehc/en/index.html) (accessed October 14, 2008).  
29 ADAMS No. ML082880728.



## 5.0 ENVIRONMENTAL IMPACTS OF POSTULATED ACCIDENTS

This chapter describes the environmental impacts from postulated accidents that might occur during the period of extended operation. The term “accident” refers to any unintentional event outside the normal plant operational envelope that results in a release or the potential for release of radioactive materials into the environment. Two classes of postulated accidents are evaluated in the GEIS and are listed in Table 5-1 below. These are design-basis accidents (DBAs) and severe accidents.

**Table 5-1. Issues Related to Postulated Accidents.** *Two issues related to postulated accidents are evaluated under NEPA in the license renewal review, design-basis accidents and severe accidents.*

Issues	GEIS Section	Category
Design-basis accidents	5.3.2; 5.5.1	1
Severe accidents	5.3.3; 5.3.3.2; 5.3.3.3; 5.3.3.4; 5.3.3.5; 5.4; 5.5.2	2

### 5.1 Design Basis Accidents

In order to receive NRC approval to operate a nuclear power facility, an applicant for an initial operating license must submit a safety analysis report (SAR) as part of its application. The SAR presents the design criteria and design information for the proposed reactor and comprehensive data on the proposed site. The SAR also discusses various hypothetical accident situations and the safety features that are provided to prevent and mitigate accidents. The NRC staff reviews the application to determine whether the plant design meets the Commission’s regulations and requirements and includes, in part, the nuclear plant design and its anticipated response to an accident.

DBAs are those accidents that both the licensee and the NRC staff evaluate to ensure that the plant can withstand normal and abnormal transients, and a broad spectrum of postulated accidents, without undue hazard to the health and safety of the public. A number of these postulated accidents are not expected to occur during the life of the plant, but are evaluated to establish the design basis for the preventive and mitigative safety systems of the facility. The acceptance criteria for DBAs are described in 10 CFR 50 and 10 CFR 100.

The environmental impacts of DBAs are evaluated during the initial licensing process, and the ability of the plant to withstand these accidents is demonstrated to be acceptable before issuance of the operating license. The results of these evaluations are found in license documentation such as the applicant’s final safety analysis report (FSAR), the safety evaluation report (SER), the final environmental statement (FES), and Section 5.1 of this draft supplemental environmental impact statement (EIS). A licensee is required to maintain the acceptable design and performance criteria throughout the life of the plant, including any extended-life operation. The consequences for these events are evaluated for the hypothetical maximum exposed individual; as such, changes in the plant environment will not affect these evaluations. Because of the requirements that continuous acceptability of the consequences

## Postulated Accidents

1 and aging management programs be in effect for the period of extended operation, the  
2 environmental impacts as calculated for DBAs should not differ significantly from initial licensing  
3 assessments over the life of the plant, including the period of extended operation. Accordingly,  
4 the design of the plant relative to DBAs during the period of extended operation is considered to  
5 remain acceptable and the environmental impacts of those accidents were not examined further  
6 in the GEIS.

7 The Commission has determined that the environmental impacts of DBAs are of SMALL  
8 significance for all plants because the plants were designed to successfully withstand these  
9 accidents. Therefore, for the purposes of license renewal, design-basis accidents are  
10 designated as a Category 1 issue. The early resolution of the DBAs makes them a part of the  
11 current licensing basis of the plant; the current licensing basis of the plant is to be maintained by  
12 the licensee under its current license and, therefore, under the provisions of 10 CFR 54.30, is  
13 not subject to review under license renewal.

14 No new and significant information related to design-basis accidents was identified during the  
15 review of AmerGen's environmental report (ER) (AmerGen 2008a), site audit, scoping process,  
16 or evaluation of other available information. Therefore, there are no impacts related to these  
17 issues beyond those discussed in the GEIS.  
18

## 19 **5.2 Severe Accidents**

20 Severe nuclear accidents are those that are more severe than DBAs because they could result  
21 in substantial damage to the reactor core, whether or not there are serious offsite  
22 consequences. In the GEIS, the staff assessed the impacts of severe accidents during the  
23 license renewal period, using the results of existing analyses and site-specific information to  
24 conservatively predict the environmental impacts of severe accidents for each plant during the  
25 renewal period.

26 Severe accidents initiated by external phenomena such as tornadoes, floods, earthquakes,  
27 fires, and sabotage have not traditionally been discussed in quantitative terms in FESs and  
28 were not specifically considered for the Three Mile Island Nuclear Station, Unit 1 (TMI-1) site in  
29 the GEIS (NRC 1996). However, the GEIS did evaluate existing impact assessments  
30 performed by NRC and by the industry at 44 nuclear plants in the United States and concluded  
31 that the risk from beyond design basis earthquakes at existing nuclear power plants is SMALL.  
32 The GEIS for license renewal performed a discretionary analysis of terrorist acts in connection  
33 with license renewal, and concluded that the core damage and radiological release from such  
34 acts would be no worse than the damage and release expected from internally initiated events.  
35 In the GEIS, the Commission concludes that the risk from sabotage and beyond design-basis  
36 earthquakes at existing nuclear power plants is small and additionally, that the risks from other  
37 external events are adequately addressed by a generic consideration of internally initiated  
38 severe accidents (NRC 1996).

39 Based on information in the GEIS, the Commission found that

40       The probability weighted consequences of atmospheric releases, fallout onto  
41       open bodies of water, releases to ground water, and societal and economic  
42       impacts from severe accidents are small for all plants. However, alternatives to

1 mitigate severe accidents must be considered for all plants that have not  
2 considered such alternatives.

3 We identified no new and significant information related to postulated accidents during the  
4 review of AmerGen's environmental report (AmerGen 2008a), the site audit, the scoping  
5 process, or evaluation of other available information. Therefore, there are no impacts related to  
6 these issues beyond those discussed in the GEIS. However, in accordance with 10 CFR  
7 51.53(c)(3)(ii)(L), we have reviewed severe accident mitigation alternatives (SAMAs) for TMI-1.  
8 The results of the review are discussed in Section 5.3.  
9

### 10 **5.3 Severe Accident Mitigation Alternatives**

11 Section 51.53(c)(3)(ii)(L) requires that license renewal applicants consider alternatives to  
12 mitigate severe accidents if the staff has not previously evaluated SAMAs for the applicant's  
13 plant in an EIS or related supplement or in an environmental assessment. The purpose of this  
14 consideration is to ensure that plant changes (i.e., hardware, procedures, and training) with the  
15 potential for improving severe accident safety performance are identified and evaluated.  
16 SAMAs have not been previously considered for TMI-1; therefore, the remainder of Chapter 5  
17 addresses those alternatives.  
18

#### 19 **5.3.1 Introduction**

20 This section presents a summary of the SAMA evaluation for TMI-1 conducted by AmerGen  
21 Energy Company, LLC (AmerGen) and the NRC staff's review of that evaluation. The NRC staff  
22 performed its review with contract assistance from Pacific Northwest National Laboratory. The  
23 NRC staff's review is available in full in Appendix F; the SAMA evaluation is available in full in  
24 AmerGen's ER.

25 The SAMA evaluation for TMI-1 was conducted with a four step approach. In the first step  
26 AmerGen quantified the level of risk associated with potential reactor accidents using the plant  
27 specific probabilistic risk assessment (PRA) and other risk models.

28 In the second step AmerGen examined the major risk contributors and identified possible ways  
29 (SAMAs) of reducing that risk. Common ways of reducing risk are changes to components,  
30 systems, procedures, and training. AmerGen identified 33 potential SAMAs for TMI-1.  
31 AmerGen performed an initial screening to determine if any SAMAs could be eliminated  
32 because they are not applicable to TMI-1 due to design differences, or have estimated  
33 implementation costs that would exceed the dollar value associated with completely eliminating  
34 all severe accident risk at TMI. No SAMAs were eliminated based on this screening, leaving all  
35 33 for further evaluation.

36 In the third step AmerGen estimated the benefits and the costs associated with each of the  
37 SAMAs. Estimates were made of how much each SAMA could reduce risk. Those estimates  
38 were developed in terms of dollars in accordance with NRC guidance for performing regulatory  
39 analyses (NRC 1997). The cost of implementing the proposed SAMAs was also estimated.

40 Finally, in the fourth step, the costs and benefits of each of the remaining SAMAs were  
41 compared to determine whether the SAMA was cost beneficial, meaning the benefits of the

## Postulated Accidents

1 SAMA were greater than the cost (a positive cost benefit). AmerGen concluded in its ER that  
2 several of the SAMAs evaluated are potentially cost-beneficial (AmerGen 2008a). However, in  
3 response to NRC staff inquiries regarding estimated benefits for certain SAMAs and lower cost  
4 alternatives, several additional potentially cost-beneficial SAMAs were identified (AmerGen  
5 2008b).

6 The potentially cost-beneficial SAMAs do not relate to adequately managing the effects of aging  
7 during the period of extended operation; therefore, they need not be implemented as part of  
8 license renewal pursuant to 10 CFR Part 54. AmerGen's SAMA analyses and the NRC's review  
9 are discussed in more detail below.

### 10 **5.3.2 Estimate of Risk**

11 AmerGen submitted an assessment of SAMAs for TMI-1 as part of the ER (AmerGen 2008a).  
12 This assessment was based on the most recent TMI-1 PRA available at that time, a plant  
13 specific offsite consequence analysis performed using the MELCOR Accident Consequence  
14 Code System 2 (MACCS2) computer program, and insights from the TMI-1 Individual Plant  
15 Examination (IPE) (GPU 1993) and Individual Plant Examination of External Events (IPEEE)  
16 (GPU 1994).

17 The scope of the Level 1 PRA model includes both internal and external initiating events. The  
18 external events evaluated are external floods, seismic events, and internal fires. However, the  
19 external events models are not integrated with the internal events model, thereby necessitating  
20 a separate assessment of the risk (and risk reduction) for internal and external events.  
21 AmerGen placed particular emphasis on external flooding events since they dominate the  
22 calculated risk at TMI-1.

23 The baseline CDF for the purpose of the SAMA evaluation is approximately  $2.37 \times 10^{-5}$  per year  
24 for internal events (including internal flooding events), and  $8.11 \times 10^{-5}$  per year for external  
25 flooding events. AmerGen accounted for the potential risk reduction benefits associated with  
26 internal event- and external flooding-related SAMAs by separately quantifying the benefits using  
27 the internal event or external flooding model, respectively. For internal event-related SAMAs,  
28 AmerGen accounted for the potential risk reduction benefits associated with non-flooding  
29 external events (i.e., seismic and fire events) by doubling the estimated benefits for internal  
30 events. For seismic- and fire-related SAMAs, AmerGen separately estimated the risk reduction  
31 benefits using the seismic and fire risk models. The breakdown of CDF by initiating event for  
32 TMI-1 is provided in Tables 5-1 and 5-2 for internal events and external flooding events,  
33 respectively.



1

**Table 5-2. TMI-1 Internal Events Core Damage Frequency**

<b>Initiating Event</b>	<b>CDF (Per Year)</b>	<b>% Contribution to CDF</b>
Loss of Offsite Power	$7.73 \times 10^{-6}$	32.6
Transients	$5.80 \times 10^{-6}$	24.5
Small and Very Small LOCA	$4.66 \times 10^{-6}$	19.7
Loss of Nuclear Service River Water	$3.67 \times 10^{-6}$	15.5
Steam Generator Tube Rupture	$9.93 \times 10^{-7}$	4.2
Internal Floods	$4.50 \times 10^{-7}$	1.9
Large and Medium LOCA	$2.06 \times 10^{-7}$	< 1
ISLOCA	$1.80 \times 10^{-7}$	<1
<b>Total CDF (internal events)</b>	<b><math>2.37 \times 10^{-5}</math></b>	<b>100</b>

2

**Table 5-3 TMI-1 External Flooding Events Core Damage Frequency**

<b>External Flooding Event</b>	<b>CDF (Per Year)</b>	<b>% Contribution to CDF</b>
>310 feet	$6.37 \times 10^{-5}$	78.5
305 to 310 feet	$1.71 \times 10^{-5}$	21.1
<305 feet	$2.50 \times 10^{-7}$	< 1
<b>Total</b>	<b><math>8.11 \times 10^{-5}</math></b>	<b>100</b>

3

4 As shown in these tables, internal event CDF is dominated by loss of offsite power events,  
 5 transients, small loss of coolant accidents (LOCA), and loss of nuclear service water events.  
 6 External flooding CDF is dominated by events with flood levels exceeding 305 feet mean sea  
 7 level (msl).

8 AmerGen estimated the dose to the population within 50 miles (80 kilometers) of the TMI-1 site  
 9 to be approximately 0.323 person-sievert (Sv) (32.3 person-rem) per year (AmerGen 2008a) for  
 10 internal events and 1.76 person-Sv (176 person-rem) per year for external flooding events  
 11 (AmerGen 2008b). The breakdown of the total population dose by containment release mode is  
 12 summarized in Table 5-3. Steam generator tube rupture (SGTR) accidents, and basemat melt-  
 13 through are the dominant contributors to population dose risk from internal events. For external

Postulated Accidents

- 1 flooding events, late containment failures and early containment failure (less than 12 hours
- 2 following accident initiation) are the dominant contributors to population dose risk.

**Table 5-4. Breakdown of Population Dose by Containment Release Mode**

Containment Release Mode	Internal Events		External Flooding Events	
	Population Dose (Person-Rem Per Year)	% Contribution	Population Dose (Person-Rem Per Year)	% Contribution
Steam generator tube rupture	11.7	36	0.1	<0.1
Interfacing system LOCA	1.0	3	negligible	0
Containment isolation failure	1.1	3	29	16
Early containment failure	5.6	17	61	35
Late containment failure (large)	0.3	1	15	9
Late containment failure (small)	1.7	5	66	37
Basemat melt-through	6.9	22	4	2
No containment failure	4.0	13	1	1
<b>Total</b>	<b>32.3</b>	<b>100</b>	<b>176</b>	<b>100</b>

3 <sup>1</sup>One person-Rem = 0.01 person-Sv

4 The NRC staff has reviewed AmerGen's data and evaluation methods and concludes that the  
 5 quality of the risk analyses is adequate to support an assessment of the risk reduction potential  
 6 for candidate SAMAs. Accordingly, the staff based its assessment of offsite risk on the CDFs  
 7 and offsite doses reported by AmerGen.

8  
 9 **5.3.3 Potential Plant Improvements**

10 Once the dominant contributors to plant risk were identified, AmerGen searched for ways to  
 11 reduce that risk. In identifying and evaluating potential SAMAs, AmerGen considered insights  
 12 from the plant-specific PRA, and SAMA analyses performed for other operating plants that have  
 13 submitted license renewal applications. This search included reviewing insights from the plant-  
 14 specific risk studies, and reviewing plant improvements considered in previous SAMA analyses.  
 15 AmerGen identified 33 potential risk-reducing improvements (SAMAs) to plant components,  
 16 systems, procedures and training. A detailed cost-benefit analysis was performed for each of  
 17 the SAMAs.

18 The staff concludes that AmerGen used a systematic and comprehensive process for identifying  
 19 potential plant improvements for TMI-1, and that the set of potential plant improvements  
 20 identified by AmerGen is reasonably comprehensive and, therefore, acceptable.

### 1 **5.3.4 Evaluation of Risk Reduction and Costs of Improvements**

2 AmerGen evaluated the risk reduction potential of the candidate SAMAs. The SAMA  
3 evaluations were performed using realistic assumptions with some conservatism.

4 AmerGen estimated the costs of implementing the candidate SAMAs through the application of  
5 engineering judgment and the use of other licensee's estimates for similar improvements. The  
6 cost estimates conservatively did not include the cost of replacement power during extended  
7 outages required to implement the modifications, nor did they account for inflation.

8 The staff reviewed AmerGen's bases for calculating the risk reduction for the various plant  
9 improvements and concludes that the rationale and assumptions for estimating risk reduction  
10 are reasonable and generally conservative (i.e., the estimated risk reduction is higher than what  
11 would actually be realized). Accordingly, the staff based its estimates of averted risk for the  
12 various SAMAs on AmerGen's risk reduction estimates.

13 The staff reviewed the bases for the applicant's cost estimates. For certain improvements, the  
14 staff also compared the cost estimates to estimates developed elsewhere for similar  
15 improvements, including estimates developed as part of other licensees' analyses of SAMAs for  
16 operating reactors and advanced light-water reactors. The staff found the cost estimates to be  
17 reasonable, and generally consistent with estimates provided in support of other plants'  
18 analyses.

19 The staff concludes that the risk reduction and the cost estimates provided by AmerGen are  
20 sufficient and appropriate for use in the SAMA evaluation.  
21

### 22 **5.3.5 Cost-Benefit Comparison**

23 The cost benefit analysis performed by AmerGen was based primarily on NUREG/BR 0184  
24 (NRC 1997) and was executed consistent with this guidance. NUREG/BR-0058 has recently  
25 been revised to reflect the agency's revised policy on discount rates. Revision 4 of NUREG/BR-  
26 0058 states that two sets of estimates should be developed - one at 3 percent and one at 7  
27 percent (NRC 2004). AmerGen performed the SAMA analysis using only a 3 percent discount  
28 rate (AmerGen 2008a) and based its decisions on potentially cost-beneficial SAMAs on these  
29 values. Use of only a 3 percent discount rate in the cost-benefit analysis is considered  
30 acceptable for the purposes of the SAMA evaluation since it would tend to result in identification  
31 of a greater number of potentially cost-beneficial SAMAs.

32 AmerGen identified nine potentially cost-beneficial SAMAs in the baseline analysis contained in  
33 the ER. The potentially cost-beneficial SAMAs are:

34 SAMA 8 – Automate reactor coolant pump trip on high motor bearing cooling temperature.

35 SAMA 11 – Enhance extreme external flooding mitigation equipment to address station  
36 blackout and loss of reactor coolant pump seal cooling scenarios.

37 SAMA 12 – Use the decay heat removal system as an alternate suction source for high  
38 pressure injection.

## Postulated Accidents

- 1 SAMA 16 – Automate high pressure injection on low pressurizer level.
- 2 SAMA 19 – Install battery backed hydrogen igniters or a passive hydrogen ignition system.
- 3 SAMA 21 – Install concrete shields to block direct pathways from the reactor pressure
- 4 vessel to the containment wall and/or direct containment flooding early in external flooding
- 5 scenarios.
- 6 SAMA 27 – Improve the 480V AC load center welds.
- 7 SAMA 32 – Pre-stage severe external flooding equipment.
- 8 SAMA 33 – Increase the flood protection height.
- 9 AmerGen performed additional analyses to evaluate the impact of parameter choices and
- 10 uncertainties on the results of the SAMA assessment (AmerGen 2008a). If the benefits are
- 11 increased by a factor of 2.75 to account for uncertainties, six additional SAMA candidates were
- 12 determined to be potentially cost-beneficial:
- 13 SAMA 2 – Install damage-resistant high temperature reactor coolant pump seals with a
- 14 portable 480V AC generator for extended emergency feedwater (EFW) operation.
- 15 SAMA 7 – Use fire service water as an alternate cooling source for the intermediate closed
- 16 cooling water heat exchangers.
- 17 SAMA 15 – Automate swap to recirculation mode.
- 18 SAMA 23 – Develop alarm response procedures to direct operation of RR-V-5 on low
- 19 reactor building emergency cooling flow.
- 20 SAMA 24 – Install damage-resistant high temperature reactor coolant pump seals with a
- 21 diesel engine as an alternate drive for an EFW pump and a portable 480V AC generator for
- 22 extended EFW operation.
- 23 SAMA 26 – Reroute cables so that they do not pass over ignition sources in fire zone CB-
- 24 FA-2e or wrap them in fire proof material.
- 25 As a result of an additional sensitivity analysis and response to an NRC staff request, AmerGen
- 26 identified two additional potentially cost-beneficial SAMAs (AmerGen 2008b):
- 27 SAMA 10 – Automate borated water storage tank refill.
- 28 SAMA 13 – Change instrument air system logic to automatically start IA-P-1A/B
- 29

1 The staff concludes that, with the exception of the potentially cost-beneficial SAMAs discussed  
2 above, the costs of the SAMAs evaluated would be higher than the associated benefits.  
3

#### 4 **5.3.6 Conclusions**

5 The staff reviewed AmerGen's analysis and concluded that the methods used and the  
6 implementation of those methods were sound. The treatment of SAMA benefits and costs  
7 support the general conclusion that the SAMA evaluations performed by AmerGen are  
8 reasonable and sufficient for the license renewal submittal.

9 Based on its review of the SAMA analysis, the staff concurs with AmerGen's identification of  
10 areas in which risk can be further reduced in a cost-beneficial manner through the  
11 implementation of all or a subset of potentially cost-beneficial SAMAs. Given the potential for  
12 cost-beneficial risk reduction, the staff considers that further evaluation of these SAMAs by  
13 AmerGen is warranted. However, none of the potentially cost-beneficial SAMAs relate to  
14 adequately managing the effects of aging during the period of extended operation. Therefore,  
15 they need not be implemented as part of the license renewal pursuant to 10 CFR Part 54.

#### 16 17 **5.4 References**

18 AmerGen (AmerGen Energy Company, LLC). 2008a. "Three Mile Island Nuclear Station,  
19 Applicant's Environmental Report, License Renewal Operating Stage." Kennett Square,  
20 Pennsylvania. ADAMS Accession Nos. ML080220255, ML080220257, ML080220261, and  
21 ML080220282.

22 AmerGen (AmerGen Energy Company, LLC). 2008b. Letter from Michael P. Gallagher,  
23 AmerGen Energy Company, LLC, to U.S. Nuclear Regulatory Commission Document Control  
24 Desk. Subject: "Response to NRC Request for Additional Information Related to Three Mile  
25 Island Nuclear Station 1 License Renewal Application (TAC No. MD7702)," dated July 17, 2008.

26 GPU (GPU Nuclear Corporation). 1993. Letter from T. G. Broughton, GPU, to U.S. NRC.  
27 Subject: Three Mile Island Nuclear Generation Station, Unit 1 (TMI-1), Operating License No.  
28 DPR-50, Docket No. 50-289, Response to Generic Letter 88-20, "Individual Plan Examinations  
29 for Severe Accident Vulnerabilities (IPE)". May 20, 1993.

30 GPU (GPU Nuclear Corporation). 1994. Letter from R. W. Keaten, GPU, to U.S. NRC.  
31 Subject: Three Mile Island Nuclear Generation Station, Unit 1 (TMI-1), Operating License No.  
32 DPR-50, Docket No. 50-289, Response to Generic Letter 88-20, Supplement 4, "Individual Plan  
33 Examination of External Events (IPEEE) for Severe Accident Vulnerabilities". December 29,  
34 1994.

35 NRC (U.S. Nuclear Regulatory Commission). 1997. *Regulatory Analysis Technical Evaluation*  
36 *Handbook*. NUREG/BR 0184, Washington, D.C.

37 NRC (U.S. Nuclear Regulatory Commission). 2004. *Regulatory Analysis Guidelines of the U.S.*  
38 *Nuclear Regulatory Commission*. NUREG/BR-0058, Rev. 4, Washington, D.C.



## 6.0 ENVIRONMENTAL IMPACTS OF THE URANIUM FUEL CYCLE AND SOLID WASTE MANAGEMENT

This chapter addresses issues related to the uranium fuel cycle and solid waste management during the period of extended operation. The uranium cycle includes uranium mining and milling, the production of uranium hexafluoride, isotopic enrichment, fuel fabrication, reprocessing of irradiated fuel, transportation of radioactive materials, and management of low-level wastes and high-level wastes related to uranium fuel cycle activities. The generic environmental impact statement (GEIS) (NRC 1996, 1999) details the potential generic impacts of the radiological and nonradiological environmental impacts of the uranium fuel cycle and transportation of nuclear fuel and wastes, as listed in Table 6-1 below. The GEIS is based, in part, on the generic impacts provided in Table S-3, "Table of Uranium Fuel Cycle Environmental Data," in Title 10, Section 51.51(b), of the Code of Federal Regulations (10 CFR 51.51(b)), and in Table S-4, "Environmental Impact of Transportation of Fuel and Waste to and from One Light-Water-Cooled Nuclear Power Reactor," in 10 CFR 51.52(c). The GEIS also addresses the impacts from radon-222 and technetium-99.

The staff of the U.S. Nuclear Regulatory Commission (NRC) did not identify any new and significant information related to the uranium fuel cycle during the review of the AmerGen Energy Company, LLC environmental report (AmerGen 2008), the site audit, and the scoping process. Therefore, there are no impacts related to these issues beyond those discussed in the GEIS. For these Category 1 issues, the GEIS concludes that the impacts are SMALL, except for the collective offsite radiological impacts from the fuel cycle and from high-level waste and spent fuel disposal.

**Table 6-1. Issues Related to the Uranium Fuel Cycle and Solid Waste Management.** *Nine generic issues are related to the fuel cycle and solid waste management. There are no site-specific issues.*

Issues	GEIS Section	Category
Offsite radiological impacts (individual effects from other than the disposal of spent fuel and high-level waste)	6.1, 6.2.1, 6.2.2.1, 6.2.2.3, 6.2.3, 6.2.4, 6.6	1
Offsite radiological impacts (collective effects)	6.1, 6.2.2.1, 6.2.3, 6.2.4, 6.6	1
Offsite radiological impacts (spent fuel and high-level waste disposal)	6.1, 6.2.2.1, 6.2.3, 6.2.4, 6.6	1
Nonradiological impacts of the uranium fuel cycle	6.1, 6.2.2.6, 6.2.2.7, 6.2.2.8, 6.2.2.9, 6.2.3, 6.2.4, 6.6	1
Low-level waste storage and disposal	6.1, 6.2.2.2, 6.4.2, 6.4.3, 6.4.3.1, 6.4.3.2, 6.4.3.3, 6.4.4,	1

## Environmental Impacts of the Uranium Fuel Cycle and Solid Waste Management

Issues	GEIS Section	Category
	6.4.4.1, 6.4.4.2, 6.4.4.3, 6.4.4.4, 6.4.4.5, 6.4.4.5.1, 6.4.4.5.2, 6.4.4.5.3, 6.4.4.5.4, 6.4.4.6, 6.6	
Mixed waste storage and disposal	6.4.5.1, 6.4.5.2, 6.4.5.3, 6.4.5.4, 6.4.5.5, 6.4.5.6, 6.4.5.6.1, 6.4.5.6.2, 6.4.5.6.3, 6.4.5.6.4, 6.6	1
Onsite spent fuel	6.1, 6.4.6, 6.4.6.1, 6.4.6.2, 6.4.6.3, 6.4.6.4, 6.4.6.5, 6.4.6.6, 6.4.6.7, 6.6	1
Nonradiological waste	6.1, 6.5, 6.5.1, 6.5.2, 6.5.3, 6.6	1
Transportation	6.1, 6.3.1, 6.3.2.3, 6.3.3, 6.3.4, 6.6, Addendum 1	1

1  
2  
3

### 6.1 References

- 4 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, “Environmental  
5 Protection Regulations for Domestic Licensing and Related Regulatory Functions.”
- 6 10 CFR Part 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, “Requirements for  
7 Renewal of Operating Licenses for Nuclear Power Plants.”
- 8 AmerGen (AmerGen Energy Company, LLC). 2008. “Three Mile Island Nuclear Station,  
9 Applicant’s Environmental Report, License Renewal Operating Stage.” Kennett Square,  
10 Pennsylvania. ADAMS Nos. ML080220255, ML080220257, ML080220261, and ML080220282.
- 11 NRC (U.S. Nuclear Regulatory Commission). 1996. *Generic Environmental Impact Statement  
12 for License Renewal of Nuclear Plants*, NUREG-1437, Volumes 1 and 2. Washington, D.C.  
13 ADAMS No. ML061770605.



## Environmental Impacts of the Uranium Fuel Cycle and Solid Waste Management

- 1 NRC (U.S. Nuclear Regulatory Commission). 1999. *Generic Environmental Impact Statement*
- 2 *for License Renewal of Nuclear Plants, Main Report*, Section 6.3, "Transportation," Table 9.1,
- 3 "Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants, Final
- 4 Report." NUREG-1437, Volume 1, Addendum 1. Washington, D.C.



## 7.0 ENVIRONMENTAL IMPACTS OF DECOMMISSIONING

Decommissioning is defined as the safe removal of a nuclear facility from service and the reduction of residual radioactivity to a level that permits release of the property for unrestricted use and termination of the license. The U.S. Nuclear Regulatory Commission (NRC) issued a generic environmental impact statement (GEIS) for decommissioning (NRC 2002) that evaluated the environmental impacts from the activities associated with the decommissioning of any reactor before or at the end of an initial or renewed license.

The NRC staff has not identified any new and significant information during the review of the AmerGen Energy Company, LLC environmental report (AmerGen 2008), the site audit, or the scoping process. Therefore, there are no impacts related to these issues beyond those discussed in the GEIS (NRC 1996, 1999). For the issues listed in table 7-1 below, the GEIS concluded that the impacts are SMALL.

**Table 7-1. Issues Related Decommissioning.** *Decommissioning would occur regardless of whether Three Mile Island Nuclear Station, Unit 1, is shut down at the end of its current operating license or at the end of the period of extended operation. There are no site-specific issues related to decommissioning.*

Issues	GEIS Section	Category
Radiation doses	7.3.1; 7.4	1
Waste management	7.3.2; 7.4	1
Air quality	7.3.3; 7.4	1
Water quality	7.3.4; 7.4	1
Ecological resources	7.3.5; 7.4	1
Socioeconomic impacts	7.3.7; 7.4	1

### 7.1 References

AmerGen (AmerGen Energy Company, LLC). 2008. *Three Mile Island Nuclear Station, Applicant's Environmental Report, License Renewal Operating Stage*. Kennett Square, Pennsylvania. ADAMS Accession Nos. ML080220255, ML080220257, ML080220261, and ML080220282.

NRC (U.S. Nuclear Regulatory Commission). 1996. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*, NUREG-1437, Vols. 1 and 2. Washington, D.C. ADAMS No. ML061770605.

NRC (U.S. Nuclear Regulatory Commission). 1999. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Main Report*, "Section 6.3, Transportation, Table 9.1,

## Environmental Impacts of Decommissioning

- 1 Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants, Final
- 2 Report.” NUREG-1437, Volume 1, Addendum 1. Washington, D.C.
- 3 NRC (U.S. Nuclear Regulatory Commission). 2002. *Generic Environmental Impact Statement*
- 4 *on Decommissioning of Nuclear Facilities: Supplement 1, Regarding the Decommissioning of*
- 5 *Nuclear Power Reactors*. NUREG-0586, Supplement 1, Volumes 1 and 2. Washington, D.C.

## 8.0 ENVIRONMENTAL IMPACTS OF ALTERNATIVES

The National Environmental Policy Act (NEPA) mandates that each environmental impact statement (EIS) consider alternatives to any proposed major Federal action. NRC regulations implementing NEPA for license renewal require that a supplemental EIS “consider and weigh the environmental effects of the proposed action [license renewal]; the environmental impacts of alternatives to the proposed action; and alternatives available for reducing or avoiding adverse environmental impacts,” (10 CFR 51.71[d]). In this case, the proposed Federal action is issuing a renewed license for Three Mile Island Nuclear Station, Unit 1 (TMI-1), which will allow the plant to operate for 20 years beyond its current license expiration date. In this chapter, we examine the potential environmental impacts of alternatives to issuing a renewed operating license for TMI-1.

While NUREG-1437 “Generic Environmental Impact Statement for License Renewal of Nuclear Plants”, (GEIS; NRC 1996, 1999), reached generic conclusions regarding many environmental issues associated with license renewal, it did not determine which alternatives are reasonable or reach conclusions about site-specific environmental impact levels. As such, NRC staff must evaluate environmental impacts of alternatives on a site-specific basis.

Alternatives to the proposed action of issuing a renewed TMI-1 operating license must meet the purpose and need for issuing a renewed license; they must

“provide an option that allows for power generation capability beyond the term of a current nuclear power plant operating license to meet future system generating needs, as such needs may be determined by State, utility, and, where authorized, Federal (other than NRC) decisionmakers.”

The NRC staff ultimately makes no decision as to which alternative (or the proposed action) to implement, since that decision falls to utility, State, or other Federal officials to decide. Comparing the environmental effects of these alternatives will assist the NRC in deciding whether the environmental impacts of license renewal are so great that preserving the option of license renewal for energy-planning decisionmakers would be unreasonable (10 CFR 51.95[c][4]). If the NRC acts to issue a renewed license, all of the alternatives, including the proposed action, will be available to energy-planning decisionmakers. If the NRC decides not to renew the license (or takes no action at all), then energy-planning decisionmakers may no longer elect to continue operating TMI-1 and will have to resort to another alternative—which may or may not be one of the alternatives the NRC considers in this section—to meet their energy needs.

In evaluating alternatives to license renewal, we first select energy technologies or options currently in commercial operation, as well as some technologies not currently in commercial operation but likely to be commercially available by the time the current TMI-1 operating license expires.

Second, we screen the alternatives to remove those that cannot meet future system needs. Then, we screen the remaining options to remove those whose costs or benefits don’t justify inclusion in the range of reasonable alternatives. Any alternatives remaining constitute alternatives to the proposed action that the NRC evaluates in-depth throughout this section. At

## Alternatives

1 the end of the section, we will briefly address each alternative that we removed during  
2 screening.

4 The NRC staff initially considered 17 discrete potential  
6 alternatives to the proposed action, and narrowed the list  
8 to the four discrete alternatives and one combination  
10 alternative, which are considered in Sections 8.1 through  
12 8.5.

14 Once we identify the in-depth alternatives, the staff refer to  
16 generic environmental impact evaluations in the GEIS.  
18 The GEIS provides overviews of some energy  
20 technologies available at the time of its publishing in 1996,  
22 though it does not reach any conclusions regarding which  
24 alternatives are most appropriate, nor does it precisely  
26 categorize impacts for each site. Since 1996, many energy  
28 technologies have evolved significantly in capability and  
30 cost, while regulatory structures have changed to either  
32 promote or impede development of particular alternatives.

34 Where applicable, our analyses draw on the GEIS and  
36 include updated information from sources like the Energy  
38 Information Administration (EIA), other organizations  
40 within the Department of Energy (DOE), the U.S.  
42 Environmental Protection Agency (EPA), industry sources  
44 and publications, and information submitted by the  
46 applicant (AmerGen Energy Company, LLC [AmerGen]) in  
48 the Environmental Report (ER).

50 For each in-depth analysis, we analyze environmental  
52 impacts across seven impact categories: (1) air quality, (2)  
54 ground water use and quality, (3) surface water use and  
56 quality, (4) ecology, (5) human health, (6) socioeconomics,  
58 and (7) waste management. As in earlier chapters of this  
60 draft supplemental EIS, we use the NRC's three-level  
62 standard of significance—SMALL, MODERATE, or  
64 LARGE—to indicate the intensity of environmental effects  
65 for each alternative that we evaluate in-depth. By placing the detailed alternative analyses in  
66 this order, the NRC staff do not mean to imply which alternative would have the least impact, or  
67 which alternative an energy-planning decisionmaker would be most likely to implement.

68 Sections 8.1–8.5 contain our analyses of environmental impacts of alternatives to license  
69 renewal. Alternatives include a supercritical coal-fired plant (Section 8.1), a combined-cycle  
70 natural gas-fired power plant (Section 8.2), a conservation alternative (Section 8.3), and a  
71 combination of alternatives (Section 8.4), which includes some natural gas-fired capacity,  
72 uprates at hydropower dams in Pennsylvania, and about half of the conservation capacity  
73 utilized in Section 8.3. The NRC also considers a purchased-power alternative in Section 8.5. A  
74 discussion of alternatives considered but dismissed is included in Section 8.6. Finally, in

### **In-Depth Alternatives**

- **Coal-fired Supercritical**
- **Natural-gas-fired Combined-cycle**
- **Conservation / Energy Efficiency**
- **Combination Alternative**
- **Purchased Power**

### **Other Alternatives Considered**

- **Coal-fired IGCC**
- **Wind Power**
- **Solar Power (photovoltaic and concentrating)**
- **Wood Waste**
- **Conventional Hydroelectric Power**
- **Wave and Ocean Energy**
- **Geothermal Power**
- **Municipal Solid Waste**
- **Biofuels**
- **Oil-fired Power**
- **Fuel Cells**
- **Delayed Retirement**

<b>Energy Outlook:</b> Each year the Energy	2
Information Administration (EIA), part of the	4
U.S. Department of Energy (DOE), issues	6
its updated <i>Annual Energy Outlook (AEO)</i> .	8
<i>AEO 2008</i> indicates that coal and natural	10
gas are likely to fuel most new electrical	12
capacity through 2030, with significant	14
contributions from new renewable sources	16
and some growth in nuclear capacity (EIA	18
2008a), though all projections are subject to	20
future developments in fuel price or	22
electricity demand:	24
<i>“Natural-gas-fired plants generally have</i>	26
<i>lower capacity costs but higher fuel costs</i>	28
<i>than coal-fired plants. As a result, coal-</i>	30
<i>fired plants . . . account for 40 percent of</i>	32
<i>total capacity additions from 2006 to</i>	34
<i>2030, compared with a 36-percent share</i>	36
<i>for natural gas. Renewable and nuclear</i>	38
<i>plants tend to have high investment</i>	40
<i>costs and relatively low operating costs.</i>	42
<i>EPACT2005 and State RPS programs</i>	44
<i>are expected to stimulate generation</i>	46
<i>from renewable and nuclear plants,</i>	48
<i>which represent 18 percent and 6</i>	50
<i>percent of total additions, respectively.</i>	52
<i>The quantity and mix of capacity</i>	54
<i>additions can also be affected by</i>	56
<i>different fuel price paths or growth rates</i>	58
<i>for electricity demand.”</i>	60
	62

Section 8.7, the NRC considers the environmental effects that could occur if NRC takes no action and does not issue a renewed license for TMI-1.

### 8.1 Supercritical Coal-Fired Generation

In this section, we evaluate the environmental impacts of supercritical coal-fired generation at an offsite location. Given that the available space at the TMI-1 site is smaller than the amount of space we predict a new coal-fired alternative would require, we will not consider a coal-fired alternative at the TMI-1 site. A summary of the environmental impacts from the coal-fired alternative compared to continued operation of TMI-1 is contained in Table 8-1 on page 8-5.

Coal-fired generation accounts for a greater share of U.S. electrical power generation than any other fuel (EIA 2007). Furthermore, the EIA projects that coal-fired power plants will account for the greatest share of capacity additions through 2030—more than natural gas, nuclear, or renewable generation options. While coal-fired power plants are widely used and likely to remain widely used, we acknowledge that future coal capacity additions may be affected by perceived or actual efforts to limit greenhouse gas emissions. For now, we consider a coal-fired alternative to be a feasible, commercially-available option for providing electrical

63 generating capacity beyond TMI-1’s current license expiration.

64 Supercritical technologies are increasingly common in new coal-fired plants. Supercritical plants  
 65 operate at higher temperatures and pressures than most existing coal-fired plants (beyond  
 66 water’s “critical point,” where boiling no longer occurs and no clear phase change occurs  
 67 between steam and liquid water). Operating at higher temperatures and pressures allows this  
 68 coal-fired alternative to operate at a higher thermal efficiency than many existing coal-fired  
 69 power plants. While supercritical facilities are more expensive to construct, they consume less  
 70 fuel for a given output, reducing environmental impacts. Based on technology forecasts from  
 71 EIA, we expect that a new, supercritical coal-fired plant beginning operation in 2014 would  
 72 operate at a heat rate of 9,069 British thermal units per kilowatt-hour (Btu/kWh), or  
 73 approximately 38 percent thermal efficiency (EIA 2008b).

## Alternatives

1 In a supercritical coal-fired power plant, burning coal heats pressurized water. As the  
2 supercritical steam/water mixture moves through plant pipes to a turbine generator, the  
3 pressure drops and the mixture flashes to steam. The heated steam expands across the turbine  
4 stages, which then spin and turn the generator to produce electricity. After passing through the  
5 turbine, any remaining steam is condensed back to water in the plant's condenser.

6 In most modern U.S. facilities, condenser cooling water circulates through cooling towers or a  
7 cooling pond system (either of which are closed-cycle cooling systems). Older plants often  
8 withdraw cooling water directly from existing rivers or lakes and discharge heated water directly  
9 to the same body of water (called open-cycle cooling). For this analysis, the NRC assumed that  
10 a new supercritical coal-fired power plant would rely on closed-cycle cooling with cooling towers.

11 The plant likely would withdraw makeup water from nearby surface water sources and  
12 discharge blowdown (water containing concentrated dissolved solids and biocides) back to that  
13 same surface water. Cooling towers could be either natural draft (similar to the existing towers  
14 at TMI-1: tall towers powered only by the difference in density between heated, humid air, and  
15 surrounding cooler and usually drier air) or mechanical draft (shorter towers powered by  
16 mechanical fans).

17 In order to replace the 802 megawatt-electric (MWe) that TMI-1 currently supplies, the coal-fired  
18 alternative would need to produce roughly 850 megawatts (MW), using about 6 percent of  
19 power output for onsite power usage (AmerGen 2008). Onsite electricity usage powers  
20 scrubbers, cooling towers, coal-handling equipment, and other onsite electrical needs. A  
21 supercritical coal-fired power plant equivalent in capacity to TMI-1 would require slightly less  
22 cooling water than TMI-1 because the plant operates at a higher thermal efficiency.

23 Aside from cooling towers, other onsite structures would include the turbine building, boiler  
24 building, plant exhaust stack, coal pile, electrical switchyard, and a rail spur or coal dock. The  
25 GEIS (NRC 1996) estimated that a coal-fired alternative would require roughly 1.7 acres (ac) (1  
26 hectare [ha]) per MWe capacity, or roughly 1,450 ac (587 ha). AmerGen indicated in their ER  
27 that the plant would require 129 ac (52 ha), a number more consistent with minimum utility  
28 needs as demonstrated by nearby power plants (including PPL Corporation's Brunner Island  
29 facility). We will adopt AmerGen's estimate for this analysis. Additional offsite land could be  
30 required for waste disposal, though much of the plant's ash and scrubber sludge could be  
31 reused in concrete and gypsum wallboard, respectively (ACAA 2007).

32 This 850 MWe power plant would consume 2.51 million tons (t) (2.28 million metric tons [MT]) of  
33 coal annually assuming an average heat content of 11,459 Btu/lb (EIA 2006). The EIA reported  
34 that most coal consumed in Pennsylvania originates in Pennsylvania. Coal would be mined  
35 either in underground mines or in surface mines, then mechanically processed and washed,  
36 before being transported—likely by rail—to the power plant site. Limestone for scrubbers would  
37 also arrive by rail. This coal-fired alternative would produce 404,000 t (366,000 MT) of ash and  
38 263,000 t (238,000 MT) of scrubber sludge. Much of the coal ash and scrubber sludge could be  
39 reused, as noted above.

40 Environmental impacts from the coal-fired alternative will be greatest during construction. Site  
41 crews will clear the plant site of vegetation, prepare the site surface, and begin excavation  
42 before other crews begin actual construction on the plant and any associated infrastructure,  
43 including a pipeline spur to serve the plant and electricity transmission infrastructure connecting



1 the plant to existing transmission lines. Given available space onsite, the coal-fired alternative  
 2 must be located elsewhere. Impacts resulting from a coal-fired unit offsite will vary depending on  
 3 the nature of the site selected (e.g., a site that has never been developed will likely experience  
 4 greater impacts than a site that was previously industrial; a site near other power plants or  
 5 industrial facilities will likely experience smaller impacts than a site surrounded by farmland or  
 6 relatively natural surroundings).

7 **Table 8-1. Summary of Environmental Impacts of Supercritical Coal-Fired**  
 8 **Generation Compared to Continued Operation of TMI-1.**

	Supercritical Coal-Fired Generation		Continued TMI-1 Operation
	At TMI-1 site	At alternate site	
<b>Air Quality</b>	N/A	MODERATE	SMALL
<b>Ground Water</b>	N/A	SMALL	SMALL
<b>Surface Water</b>	N/A	SMALL	SMALL
<b>Aquatic and Terrestrial Resources</b>	N/A	SMALL to LARGE	SMALL
<b>Human Health</b>	N/A	SMALL to MODERATE	SMALL
<b>Socioeconomics</b>	N/A	SMALL to LARGE	SMALL
<b>Waste Management</b>	N/A	SMALL	N/A

9

10 **8.1.1 Air Quality**

11 Air quality impacts from coal-fired generation can be substantial because emissions contain  
 12 significant quantities of sulfur oxides (SO<sub>x</sub>), nitrogen oxides (NO<sub>x</sub>), particulates, carbon  
 13 monoxide (CO), and hazardous air pollutants such as mercury. However, many of these  
 14 pollutants can be effectively controlled by various technologies.

15 TMI-1 is located within the Mid-Atlantic Air Quality Control Region, as designated by the EPA.  
 16 The state is divided into six air regions and Dauphin County, where TMI-1 is located, belongs to  
 17 the Southcentral Air Quality Region. Dauphin County is a nonattainment area for fine particulate  
 18 matter (PM<sub>2.5</sub>) and is part of the Harrisburg-Lebanon-Carlisle PM<sub>2.5</sub> nonattainment area (which  
 19 includes Cumberland, Dauphin and Lebanon Counties). A new coal-fired generating plant  
 20 developed at the TMI-1 site would need to comply with the new source performance standards  
 21 for coal-fired plants set forth in 40 CFR 60 Subpart D(a), "Standards of Performance for Electric  
 22 Utility Steam Generating Units for Which Construction is Commenced After September 18,  
 23 1978." The standards establish limits for particulate matter and opacity (40 CFR 60.42D(a)),  
 24 sulfur dioxide (SO<sub>2</sub>) (40 CFR 60.43D(a)), and NO<sub>x</sub> (40 CFR 60.44D(a)). A coal-fired power plant  
 25 constructed elsewhere in Pennsylvania would also need to comply with applicable provisions of  
 26 the Clean Air Act (CAA) (42 U.S.C. 7401), based on the attainment status of the selected  
 27 alternate site.

28 Section 169A of the CAA establishes a national goal of preventing future and remedying  
 29 existing impairment of visibility in mandatory Class I Federal areas when impairment results  
 30 from man-made air pollution. In 1999, EPA issued a new regional haze rule (64 FR 35714). The  
 31 rule specifies that for each mandatory Class I Federal area located within a state, the State  
 32 must establish goals that provide for reasonable progress towards achieving natural visibility

## Alternatives

1 conditions. The reasonable progress goals must provide an improvement in visibility for the  
2 most-impaired days over the period of the implementation plan and ensure no degradation in  
3 visibility for the least-impaired days over the same period (40 CFR 51.308(d)(1)). If a coal-fired  
4 plant were located close to a mandatory Class I area, additional air pollution control  
5 requirements would be imposed. There are no Mandatory Class I Federal areas in  
6 Pennsylvania, the closest is Brigantine Wilderness Area in New Jersey, roughly 125 miles east-  
7 southeast of TMI-1. At an alternate site, consideration may need to be given to the installation  
8 of additional air emission control systems if that site were in proximity to any Class I areas.

9 Pennsylvania regulates air emissions from power plants pursuant to terms of the Pennsylvania  
10 Air Pollution Control Act (APCA) (35 P.S. §§ 4001–4015). Regulations issued by the  
11 Pennsylvania Department of Environmental Protection (PADEP) adopt the EPA's CAA rules  
12 with modifications, to limit power plant emissions of SO<sub>x</sub>, NO<sub>x</sub>, particulate matter, and  
13 hazardous air pollutants (PADEP 2008). Depending where a new coal-fired facility is located  
14 within Pennsylvania, the facility will need to comply with the applicable Federal and State air  
15 regulations.

16 A supercritical coal-fired alternative would produce the following quantities of air pollutants:

### 17 Sulfur Oxides

18 A coal-fired alternative at the TMI-1 site would likely use wet, limestone-based scrubbers to  
19 remove SO<sub>x</sub>. EPA indicates that this technology can remove more than 95 percent of SO<sub>x</sub> from  
20 flue gases (EPA 2002). NRC projects total SO<sub>x</sub> emissions would be 4,991 t (4,528.20MT) per  
21 year. SO<sub>x</sub> emissions from a new coal-fired power plant would be subject to the requirements in  
22 28 Title IV of the CAA. Title IV was enacted to reduce emissions of SO<sub>2</sub> and NO<sub>x</sub>, the two  
23 principal precursors of acid rain, by restricting emissions of these pollutants from power plants.  
24 Title IV caps aggregate annual power plant SO<sub>2</sub> emissions and imposes controls on SO<sub>2</sub>  
25 emissions through a system of marketable allowances. EPA issues one allowance for each ton  
26 of SO<sub>2</sub> that a unit is allowed to emit. New units do not receive allowances, but are required to  
27 have allowances to cover their SO<sub>2</sub> emissions. Owners of new units must therefore purchase  
28 allowances from owners of other power plants or reduce SO<sub>2</sub> emissions at other power plants  
29 they own. Allowances can be banked for use in future years. Thus, provided a new coal-fired  
30 power plant is able to purchase sufficient allowances to operate, it would not add to net regional  
31 SO<sub>2</sub> emissions, although it might do so locally.

### 32 Nitrogen Oxides

33 A coal-fired alternative at the TMI-1 site would most likely employ various available NO<sub>x</sub>-control  
34 technologies including low-NO<sub>x</sub> burners, over-fire air, and selective catalytic reduction. The EPA  
35 notes that when these emissions controls are used in concert, they can reduce NO<sub>x</sub> emissions  
36 by up to 95 percent (EPA 1998a). Assuming the use of such technologies, NO<sub>x</sub> emissions after  
37 scrubbing are estimated to be 628 t (570 MT) annually.

38 Section 407 of the CAA establishes technology-based emission limitations for NO<sub>x</sub> emissions. A  
39 new coal-fired power plant would be subject to the new source performance standards for such  
40 plants as indicated in 40 CFR 60.44a(d)(1). This regulation, issued on Sept 16, 1998 (63 FR  
41 49442), limits gas discharges to 200 nanograms (ng) of NO<sub>x</sub> per joule (J) of gross energy output  
42 (equivalent to 1.6 lb/MWh), based on a 30-day rolling average. The NRC estimates that the total

1 annual NO<sub>x</sub> emissions for a new coal-fired power plant with the modern emission controls  
2 identified in the previous paragraph would be approximately 12.4 percent of the new source  
3 performance standard mission rate. The EPA further controls the total amount of NO<sub>x</sub> that can  
4 be emitted on a State-level basis. Annual budget for NO<sub>x</sub> covered by allowances for 2009–2014  
5 is 99,049 t (89,856 MT) (EPA 2005). A new coal-fired power plant would need to offset  
6 emissions through credit purchases or from a set-aside pool.

#### 7 Particulates

8 A new coal-fired power plant would use fabric filters or electrostatic precipitators to remove  
9 particulates from flue gases. AmerGen indicates that fabric filters would remove 99.9 percent of  
10 particulate matter (AmerGen 2008). The EPA notes that filters or precipitators are each capable  
11 of removing in excess of 99 percent of particulate matter, and that SO<sub>2</sub> scrubbers further reduce  
12 particulate matter emissions (EPA 2002). As such, NRC staff believes AmerGen's removal  
13 factor is appropriate. Based on this, the new supercritical coal-fired plant would emit 161.27 t  
14 (146.3 MT) of total suspended particulates and approximately 37.09 t (33.65 MT) of PM<sub>10</sub>  
15 annually. In addition, coal burning would also result in PM<sub>2.5</sub> emissions, and coal-handling  
16 equipment would introduce fugitive dust emissions when fuel is being transferred to on-site  
17 storage and then reclaimed from storage for use in the plant. During the construction of a coal-  
18 fired plant, on-site activities would also generate fugitive dust. Vehicles and motorized  
19 equipment would create exhaust emissions during the construction process. These impacts  
20 would be intermittent and short-lived, however, and to minimize dust generation construction  
21 crews would use applicable dust-control measures.

#### 22 Carbon Monoxide

23 Based on EPA emission factors (EPA 1998), NRC staff estimates that the total CO emissions  
24 would be approximately 628 t (570 MT) per year.

#### 25 Hazardous Air Pollutants

26 Following the D.C. Circuit Court's February 8, 2008, ruling that vacated its Clean Air Mercury  
27 Rule (CAMR), EPA is working to evaluate how it will regulate mercury emissions (EPA 2007).  
28 Before CAMR, EPA determined that coal- and oil-fired electric utility steam-generating units are  
29 significant emitters of hazardous air pollutants (HAPs) (EPA 2000a). EPA determined that coal  
30 plants emit arsenic, beryllium, cadmium, chromium, dioxins, hydrogen chloride, hydrogen  
31 fluoride, lead, manganese, and mercury (EPA 2000a). EPA concluded that mercury is the HAP  
32 of greatest concern and that (1) a link exists between coal combustion and mercury emissions,  
33 (2) electric utility steam-generating units are the largest domestic source of mercury emissions,  
34 and (3) certain segments of the U.S. population (e.g., the developing fetus and subsistence fish-  
35 eating populations) are believed to be at potential risk of adverse health effects resulting from  
36 mercury exposures caused by the consumption of contaminated fish (EPA 2000a). In light of  
37 the recent court decision, EPA will revisit mercury regulation, although it is possible that the  
38 agency will continue to regulate mercury as a HAP, thus requiring the use of best available  
39 control technology to prevent its release to the environment.

#### 40 Carbon Dioxide

41 A coal-fired plant would also have unregulated carbon dioxide (CO<sub>2</sub>) emissions during  
42 operations as well as during mining, processing, and transportation. Burning bituminous coal in  
43 the United States emits roughly 205.3 lb of CO<sub>2</sub> per million Btu (Hong and Slatick 1994). The

## Alternatives

1 supercritical coal-fired plant would emit approximately 5.914 million t (5.365 million MT) of CO<sub>2</sub>  
2 per year.

### 3 Summary of Air Quality

4 While the GEIS analysis mentions global warming from unregulated CO<sub>2</sub> emissions and acid  
5 rain from SO<sub>x</sub> and NO<sub>x</sub> emissions as potential impacts, it does not quantify emissions from  
6 coal-fired power plants. However, the GEIS analysis does imply that air impacts would be  
7 substantial (NRC 1996). The above analysis shows that emissions of air pollutants, including  
8 SO<sub>x</sub>, NO<sub>x</sub>, CO, and particulates, exceed those produced by the existing nuclear power plant, as  
9 well as those of the other alternatives considered in this section. Operational emissions of CO<sub>2</sub>  
10 are also much greater under the coal-fired alternative.<sup>6</sup> Adverse human health effects such as  
11 cancer and emphysema have also been associated with air emissions from coal combustion,  
12 and are discussed further in Section 8.1.5.

13 The NRC analysis for a coal-fired alternative at an alternative site indicates that impacts from  
14 the coal-fired alternative would have clearly noticeable effects, but given existing regulatory  
15 regimes, permit requirements, and emissions controls, the coal-fired alternative would not  
16 destabilize air quality. Thus, the appropriate characterization of air impacts from coal-fired  
17 generation would be MODERATE. Existing air quality at the alternate location would result in  
18 varying needs for pollution control equipment to meet applicable local requirements, or varying  
19 degrees of participation in emissions trading schemes.  
20

### 21 **8.1.2 Ground Water Use and Quality**

22 An off-site location for a coal-fired plant was assumed because Three Mile Island is too small to  
23 accommodate the area needed for this alternative. If the alternative site is adjacent to the  
24 Susquehanna River and operates 10 percent more efficiently than the current nuclear plant,  
25 most of the approximately 13,000 gallon per minute (gpm) for maximum cooling water  
26 withdrawal would be taken from the river, with an average consumptive loss of about 16 million  
27 gallons per day (mgd). The need for ground water at the plant would be minor, with supply wells  
28 used for potable drinking water and various service water functions. No effect on ground water  
29 quality would be apparent.

30 Construction of a coal-fired plant at a new site could have a localized effect on ground water  
31 due to temporary dewatering and run-off control measures. Because of its temporary nature,  
32 the impact of construction would be SMALL.  
33

### 34 **8.1.3 Surface Water Use and Quality**

35 Again, an offsite location for a coal-fired plant was assumed because Three Mile Island is too  
36 small to accommodate the area needed for this alternative. If the alternative site is adjacent to  
37 the Susquehanna River, most of the approximately 13,000 gpm needed for maximum  
38 withdrawal would be taken from the river with an average consumptive loss of about 16 mgd.

---

<sup>6</sup> Table S-3 in 10 CFR 51.51 indicates that electrical energy consumed during the uranium fuel cycle to supply a 1,000 MW(e) reactor is equivalent to the electricity produced by a 45 MW(e) coal-fired power plant.

1 This consumptive loss is less than 0.1 percent of the average annual flow of the Susquehanna  
2 River, and as such the NRC concludes the impact of surface water use at an alternative site  
3 would be SMALL. A new coal-fired plant would be required to obtain a National Pollutant  
4 Discharge and Elimination System (NPDES) permit from the PADEP for regulation of industrial  
5 waste water, storm water, and other discharges. If the plant is operated within the limits of the  
6 permit, the impact of discharges on surface water quality would be SMALL.  
7

#### 8 **8.1.4 Terrestrial and Aquatic Ecology**

##### 9 Terrestrial Ecology

10 As indicated in previous sections, constructing the coal-fired alternative will require 129 ac (52  
11 ha) of land. Coal-mining operation will also affect terrestrial ecology in offsite coal mining areas,  
12 although some of the land is likely already disturbed by mining operations. On-site and offsite  
13 land disturbances form the basis for impacts to terrestrial ecology.

14 Impacts to terrestrial ecology will be minor because the selected site has been previously  
15 disturbed. This could change if additional transmission line right-of-ways (ROWs), railways, or  
16 roads would need to be constructed through less disturbed areas. Additionally, these  
17 construction activities may have a cumulative effect of fragmenting or destroying habitats.  
18 Impacts to terrestrial ecology from on-site construction will remain minimal with occasional  
19 habitat fragmentation occurring on the southern areas of the island. Any on-site or offsite water  
20 disposal by landfilling will also affect terrestrial ecology at least through the time period when the  
21 disposal area is reclaimed. Deposition of acid rain or other emissions can also affect terrestrial  
22 ecology. Given the emission controls discussed in Section 8.1.1, air deposition impacts may be  
23 noticeable, but are not likely to be devastating. Impacts to terrestrial resources from a coal-fired  
24 alternative would be SMALL, and occur mostly during construction.

##### 25 Aquatic Ecology

26 A new coal-burning power plant constructed at an alternate site would need a source of water  
27 for the plant's cooling system (likely closed-cycled with cooling towers) as well as a discharge  
28 point for plant cooling tower blowdown. Aquatic impacts at an alternate site depend on location  
29 and ecology of the site, and the surface water body used for intake and discharge. These  
30 impacts are likely SMALL at a previously industrial site, owing to generally closer access to  
31 pipelines and transmission lines than at undeveloped sites. Impacts could range from SMALL to  
32 LARGE at previously undisturbed sites. Decreases in withdrawal from and discharge to the  
33 Susquehanna River may partially offset some aquatic impacts at an alternate site. Impacts will  
34 depend upon location and ecology of the site, and the surface water body used for intake and  
35 discharge.  
36

#### 37 **8.1.5 Human Health**

38 Human health risks of coal-fired power plants are described in general, in the GEIS Table 8-2  
39 and Section 8.3.9. Cancer and emphysema are identified as potential health risks to  
40 occupational workers and members of the public (NRC 1996). The human health risks of coal-  
41 fired power plants, both to occupational workers and to members of the public, are greater than  
42 those of the current TMI-1 due to exposures to chemicals such as mercury; SO<sub>x</sub>; NO<sub>x</sub>;

## Alternatives

1 radioactive elements such as uranium and thorium; and polycyclic aromatic hydrocarbon (PAH)  
2 compounds, including benzo(a)pyrene. However, the current Federal and State regulatory  
3 frameworks pertaining to air emission standards allow for the adequate protection of  
4 occupational workers and members of the public. Therefore, the NRC staff has adopted (where  
5 applicable) the Federal and State air quality regulatory limits as significance thresholds for  
6 determining the human health risks associated with the operation of a new coal-fired power  
7 plant.

### 8 Radiological Human Health Risks

9 Coal contains uranium, thorium, and other naturally occurring radioactive elements. The U.S.  
10 Geological Survey (USGS) indicates that Western and Illinois Basin coals contain uranium and  
11 thorium at roughly equal concentrations, mostly between 1 and 4 parts per million (ppm), but  
12 also indicates that some coals may contain concentrations as high as 20 ppm of both elements  
13 (USGS 1997). A typical 1,000 MWe coal-fired plant could release roughly 5.2 t (4.7 MT) of  
14 uranium and 12.8 t (11.6 MT) of thorium to the atmosphere (Gabbard 1993). The USGS and  
15 Gabbard indicate that almost all of the uranium, thorium, and most decay products remain in  
16 solid coal wastes, especially in the fine glass spheres that constitute much of coal's fly ash.  
17 Modern emission controls, such as those included for this coal-fired alternative, allow for  
18 recovery of greater than 99 percent of these solid wastes (EPA 1998), thus retaining most of  
19 coal's radioactive elements in solid form rather than releasing them to the atmosphere. Even  
20 after concentration in coal waste, the level of radioactive elements remains relatively low –  
21 typically 10 to 100 ppm – and consistent with levels found in naturally occurring granitic rocks,  
22 shale, and phosphate rocks (USGS 1997). Natural radioactive material in rocks and soil account  
23 for about 29 millirem (mrem) or 8 percent of the radiation dose a person typically receives in a  
24 year from all sources (natural and manmade). Currently, there is no scientific evidence that  
25 radiation dose exposures of 29 mrem above the natural background dose would cause adverse  
26 human health impacts. The Biological Effect of Ionizing Radiation (BEIR) committee has  
27 calculated the lifetime attributable risk (LAR) of incidence and mortality for all solid cancers and  
28 for leukemia to be four to five persons per 100,000 persons exposed to 100 milliseiverts (mSv)  
29 (10 rem), which is over 20 times that of the natural background radiation dose of 360 mrem  
30 (NAS 2005). Therefore, the radiological human health risks from a 1,000 MWe coal-fired plant to  
31 occupational workers and members of the public would be SMALL.

### 32 PAH Human Health Risks

33 The EPA has classified seven PAHs—benzo(a)pyrene, benz(a)anthracene, chrysene,  
34 benzo(b)fluoranthene, benzo(k)fluoranthene, dibenz(a,h)anthracene, and indeno(1,2,3-  
35 cd)pyrene—as probable human carcinogens (EPA 199a, EPA 199b, EPA 1999c). PAHs have  
36 been detected in ambient air from sources including coal tar production plants, coking plants,  
37 and coal-gasification sites. Epidemiologic studies have reported an increase in lung cancer risks  
38 in humans exposed to emission from coal tar production plants, coking plants, and coal-  
39 gasification sites. Each of these emissions mixtures contains a number of PAH compounds  
40 (ATSDR 1995, HHS 1993). The Occupational Safety and Health Administration (OSHA) has set  
41 a limit of 0.2 mg of PAHs per cubic meter (m<sup>3</sup>) of air. Given that the plant must comply with  
42 OSHA regulatory limits, the health risks to occupational workers and members of the public from  
43 benzo[a]pyrene emission is expected be MODERATE.

## 1 Mercury Human Health Risks

2 As noted in Section 8.1.1, the EPA determined that coal-fired electric utility steam generating  
3 power plants were significant emitters of hazardous air pollutants and concluded that mercury is  
4 the hazardous air pollutant of greatest concern due to its persistence in the environment,  
5 potential to bioaccumulate, and toxicity to humans and the environment (65 FR 32214).  
6 Noncancer risks of oral exposure to methyl-mercury have been observed to produce significant  
7 developmental effects in humans. Infants born to women who ingested high concentrations of  
8 methyl mercury exhibited central nervous system effects, such as mental retardation, ataxia,  
9 deafness, constriction of the visual field, blindness, and cerebral palsy. At lower methyl-mercury  
10 concentrations, developmental delays and abnormal reflexes were noted (ATSDR 1999, EPA  
11 1997). No studies are available on the carcinogenic effects or cancer risks of methyl-mercury in  
12 humans, and only one available animal study reported renal tumors in mice; nevertheless, the  
13 EPA has classified methyl-mercury as a possible human carcinogen (EPA 1999d). The methyl-  
14 mercury dose resulting from emissions from a typical coal-fired power plant are uncertain. As  
15 noted in Section 8.1.1, EPA's CAMR regulation was vacated this year, and the near-term  
16 regulatory structure for mercury emission is uncertain. It is possible that EPA will return to  
17 regulating mercury as a HAP. The NRC staff expects that the EPA will implement new mercury  
18 regulations prior to the operational date of a coal-fired alternative. Because any new coal-fired  
19 plant will have to comply with EPA regulatory limits, the health risks to occupational workers and  
20 members of the public from mercury emissions is expected be MODERATE.

## 21 NOx and SO<sub>2</sub> Human Health Risks

22 NOx causes a wide variety of health risks and environmental impacts because of various  
23 compounds and derivatives in the family, including nitrogen dioxide, nitric acid, nitrous oxide,  
24 nitrates, and nitric oxide. NOx reacts with ammonia, moisture, and other compounds to form  
25 nitric acid and related particles. Human health risks include impacts to the respiratory system,  
26 damage to lung tissue, and premature death. Small particles penetrate deeply into sensitive  
27 parts of the lungs, and can cause or worsen respiratory diseases such as emphysema and  
28 bronchitis, and can aggravate existing heart disease (EPA 2008a). Environmental impacts  
29 include increased acidic deposition, and contributions to acid rain.

30 The combustion of fossil fuels (particularly coal) accounts for 50 percent of annual global SO<sub>2</sub>  
31 emissions. Human health risks of SO<sub>2</sub> include aggravation of asthma and chronic bronchitis,  
32 emphysema, impairment of pulmonary functions, respiratory irritation, and increased mortality.  
33 Environmental concentrations of 50-100 micrograms per cubic meter (µg/m<sup>3</sup>) affect some plants  
34 species. SO<sub>2</sub> also contributes to the formation of acid rain in a similar manner as NOx (EPA  
35 2008c).

36 As indicated in the Air Quality section, NOx and SO<sub>2</sub> emissions from coal-fired power plants are  
37 subject to the requirements in Title IV of the CAA. Because CAA regulations are based on  
38 human health or environmental criteria for setting permissible levels, it sets limits both to protect  
39 public health (including the health of "sensitive" populations such as asthmatics, children and  
40 the elderly) and to protect public welfare (including protection against decreased visibility, and  
41 damage to animals, crops, vegetation, and buildings). Given that the plant must comply with  
42 CAA regulatory limits, the environmental impact and health risks to occupational workers and  
43 members of the public from NOx and SO<sub>2</sub> is expected be MODERATE.

## 44 Summary

## Alternatives

1 Regulatory agencies, including the EPA and State agencies, set air emission standards and  
2 requirements based on human health risks. These agencies also impose site-specific emission  
3 limits as needed to protect human health. Human health risks to occupational workers and to  
4 members of the public from a coal-fired power plant are expected be SMALL to MODERATE.  
5 Trading or offset mechanisms in nonattainment areas will act to prevent further degradation.  
6

### 7 **8.1.6 Socioeconomics**

#### 8 Land Use

9 The GEIS generically evaluates the impacts of nuclear power plant operations on land use both  
10 on and off each power plant site. The analysis of land use impacts focuses on the amount of  
11 land area that would be affected by the construction and operation of a new supercritical coal-  
12 fired power plant. Land-use impacts would vary depending on where the plant would be located  
13 and whether construction would take place on undeveloped land or within a previously disturbed  
14 (brownfield) area.

15 AmerGen indicated that approximately 129 ac (52 ha) would be necessary to support a coal-  
16 fired alternative capable of replacing TMI-1. The GEIS, however, estimates a need for up to  
17 1,700 ac (688 ha) for a 1,000-MWe generating station (NRC 1996). This amount of land use  
18 would include other plant structures and associated infrastructure. By scaling the GEIS  
19 estimate, a 853-MWe plant could require up to approximately 1,450 ac (587 ha) of land for the  
20 plant site, transmission line ROWs, and a rail spur.

21 Based on land use for other power plants, the NRC staff believes the AmerGen estimate to be  
22 reasonable, although additional land may be used for buffer around plant structures or to  
23 support transmission lines and a rail spur. Even assuming additional land use for these  
24 purposes, total land required by the coal-fired alternative is unlikely to exceed 1,450 ac (587 ha)  
25 for all uses, excluding coal mining.

26 Many locations suitable for siting the coal-fired alternative (especially flat terrain areas along  
27 rivers similar to power plants currently located in this part of the United States) may have been  
28 disturbed by previous development. Brownfield sites, or sites that were previously used for  
29 industrial purposes, may be the most likely location for a new supercritical coal-fired power  
30 plant. Sites along rivers generally have easier access to transportation for coal fuel and major  
31 plant components, both by barge and train. Sites that have previously been used for industrial  
32 activities may also have existing rail spurs and dock or pier infrastructure and may be closer to  
33 transmission lines.

34 Coal mining introduces offsite land use impacts in addition to direct land use impacts from the  
35 construction and operation of new coal-fired power plants. Land disturbance would likely occur  
36 in Pennsylvania, Ohio, or West Virginia because a significant amount of coal used in  
37 Pennsylvania power plants originates in these three States, although significant amounts of coal  
38 also come from Kentucky and western States like Wyoming (EIA 2006).<sup>7</sup>

---

<sup>7</sup> Western coal tends to have lower sulfur and somewhat lower heating content than eastern coal. Many power stations use western, subbituminous coal to reduce sulfur oxide emissions without having to install



1 According to analyses conducted for the GEIS, approximately 22,000 ac (8,903 ha) of land  
 2 could be affected by coal mining and waste disposal in support of a 1,000-MWe coal plant  
 3 during its operational life (NRC 1996). By scaling the GEIS estimate, an 853-MWe plant could  
 4 require up to 18,800 ac (7,600 ha) of land to support a coal-fired power plant capable of  
 5 replacing TMI-1; however, most of this land is located in existing coal-mining areas and has  
 6 already been disturbed. The elimination of uranium fuel for TMI-1 could partially offset off site  
 7 land use. In the GEIS, the NRC staff estimated that approximately 1,000 ac (405 ha) would not  
 8 be needed for mining and processing uranium during the operating life of a 1,000-MWe nuclear  
 9 power plant. For TMI-1, roughly 850 ac (344 ha) of uranium mining area would no longer be  
 10 needed. However, an additional 159 ac (64 ha) of land would be needed for waste disposal  
 11 during the 40 year plant life.<sup>8</sup> This is a smaller amount of land area than was estimated by  
 12 AmerGen in the ER (AmerGen 2008), because of higher ash and gypsum recycling rates.

13 Land use impacts could range from MODERATE to LARGE, depending on where the power  
 14 plant is located. The amount of land required under the coal-fired alternative could be reduced  
 15 by constructing new transmission lines in existing ROWs.

16 Socioeconomics

17 Socioeconomic impacts are defined in terms of changes to the demographic and economic  
 18 characteristics and social conditions of a region. For example, the number of jobs created by the  
 19 construction and operation of a new coal-fired power could affect regional employment, income,  
 20 and expenditures. Job creation is characterized by two types: (1) construction-related jobs,  
 21 which are transient, short in duration, and less likely to have a long-term socioeconomic impact;  
 22 and (2) operation-related jobs in support of power plant operations, which have the greater  
 23 potential for permanent, long-term socioeconomic impacts. Workforce requirements of power  
 24 plant construction and operation for the coal-fired alternative were determined in order to  
 25 measure their possible effect on current socioeconomic conditions.

26 AmerGen projected a maximum construction workforce of 1,328 (AmerGen 2008). The GEIS  
 27 projects a workforce of 1,200 to 2,500 for a 1,000-MWe plant (when extrapolated, a workforce of  
 28 1,000 to 2,100 for an 853-MWe plant). The NRC staff believes that the AmerGen estimate is  
 29 reasonable and is within the range provided by the GEIS. Furthermore, the upper-end estimate  
 30 of the GEIS is probably too large.

31 During the 5-year construction period, the communities surrounding the plant site would  
 32 experience increased demand for rental housing and public services, although these effects  
 33 would be moderated if the construction site is located near an urban area with many skilled  
 34 workers. The relative economic effect of these workers on local economy and tax base would  
 35 vary over time.

36 After construction, local communities may be temporarily affected by the loss of construction  
 37 jobs and associated loss in demand for business services, and the rental housing market could  
 38 experience increased vacancies and decreased prices. As noted in the GEIS, the  
 39 socioeconomic impacts at a rural construction site could be larger than at an urban site,

---

scrubber equipment. A power plant equipped with scrubbers is more likely to use local, higher sulfur coals rather than incurring the cost of shipping low-sulfur coal from western states.

<sup>8</sup> Only half of the land area needed for waste disposal is directly attributable to the alternative of renewing the TMI-1 operating license for 20 years.

## Alternatives

1 because the workforce would have to move to be closer to the construction site. The impact of  
2 construction on socioeconomic conditions could range from SMALL to LARGE depending on  
3 whether the new power plant would be located at an urban or rural site. The socioeconomic  
4 impacts of power plant construction could be reduced if the power plant is located near an urban  
5 area with many skilled workers.

6 AmerGen estimated a power plant operations workforce of 92 (AmerGen 2008), while  
7 extrapolated GEIS estimates would call for up to 213 workers. The AmerGen estimate appears  
8 reasonable and is consistent with trends toward lowering labor costs by reducing the size of  
9 power plant operations workforces. Operations impacts will likely be SMALL to MODERATE,  
10 depending on whether the power plant is located near an urban or rural area.

### 11 Transportation

12 During five years of construction, up to 2,100 workers would be commuting to the construction  
13 site. This would increase the volume of traffic on roads leading to and coming from the  
14 construction site. Effects would vary depending on the number of site access roads. In addition  
15 to workers vehicles, trucks would deliver construction material and remove debris from the  
16 worksite. The number of additional vehicles on local roads could increase the overall effect.  
17 Trains or barges, or both, could be used to deliver large power plant components to the plant  
18 site.

19 Transportation impacts would be greatly reduced after construction of the power plant. The  
20 number of operations personnel commuting to and from the plant site would range from 92 to  
21 213 workers. More significant, though, would be the frequent deliveries of coal and limestone to  
22 the plant site, most likely by rail, which would result in traffic delays at railroad crossings.  
23 Approximately 252 unit trains (trains with up to 100 cars carrying 100 t of coal per car for 10,000  
24 t [9,070 MT] per train) per year would be necessary. Onsite coal storage would make it possible  
25 to receive several trains per day. Limestone would also be delivered by rail, which could cause  
26 additional traffic delays at railroad crossings (though considerably less rail traffic than that  
27 generated by coal deliveries). If coal and limestone were delivered by barge, rail transportation-  
28 related impacts to be would be reduced.

29 Overall, the coal-fired alternative would likely have SMALL to MODERATE transportation  
30 impacts in the vicinity of the power plant site, although the extent of impacts would depend on  
31 existing infrastructure capacity and demand, as well as whether coal and limestone would be  
32 delivered by rail or barge.

### 33 Aesthetics

34 Aesthetic resources are the natural and man-made features that give a particular landscape its  
35 character and aesthetic quality. The aesthetics impact analysis focuses on the degree of  
36 contrast between the power plant and the surrounding landscape and the visibility of the power  
37 plant.

38 The coal-fired alternative's power plant could be up to 200 ft (61 m) tall and may be visible off  
39 site in daylight hours. The exhaust stack could be up to 600 ft (183 m) high (at least 500 ft [152  
40 m] for good engineering practice). Additional visual impacts would occur if a natural-draft cooling  
41 tower is constructed. Similar to the cooling towers at TMI-1, the natural-draft cooling tower may  
42 be several hundred feet high and sometimes topped with condensate plumes. Mechanical draft

1 towers would also generate condensate plumes but will be lower than the plumes from the  
 2 natural-draft tower. Other buildings on site may also affect aesthetics, as could construction of  
 3 new transmission lines. Noise and light from plant operations, as well as lighting on plant  
 4 structures, may be detectable off site.

5 If the coal-fired alternative is located along a river valley terrain, impacts may be moderated by  
 6 higher elevation ridges along the valley rim, which could make it difficult to see and hear the  
 7 plant outside of the river valley. Aesthetic impacts could be further mitigated if the plant were  
 8 located in an industrial area adjacent to other industrial facilities and power plants. Overall, the  
 9 aesthetic impacts associated with the coal-fired alternative would likely be SMALL to  
 10 MODERATE, depending on the location of the site, topography, and proximity to other industrial  
 11 facilities, as opposed to areas where visual resources are particularly valued.

12 Historic and Archaeological Resources

13 It is difficult to determine the effects on historic and archaeological resources when a specific  
 14 location has not been selected. The potential for historic and archaeological resources can vary  
 15 greatly depending on the location of the proposed site. To consider a project's effects on historic  
 16 and archaeological resources, any proposed areas will need to be surveyed to identify and  
 17 record historic and archeological resources, identify cultural resources, and develop possible  
 18 mitigation measures to address any adverse effects from ground-disturbing activities. Studies  
 19 will be needed for all areas of potential disturbance at the proposed plant site and along  
 20 associated corridors where new construction will occur (e.g., roads, transmission corridors, rail  
 21 lines, or other ROWs). In most cases, project proponents should avoid areas with the greatest  
 22 sensitivity. Depending on the resource richness of the site ultimately chosen for the coal-fired  
 23 alternative, impacts will range from SMALL to MODERATE.

24 Environmental Justice

25 The environmental justice impact analysis evaluates the potential for disproportionately high and  
 26 adverse human health and environmental effects on minority and low-income populations that  
 27 could result from the construction and operation of a new supercritical coal-fired power plant.  
 28 Adverse health effects are measured in terms of the risk and rate of fatal or nonfatal adverse  
 29 impacts on human health. Disproportionately high and adverse human health effects occur  
 30 when the risk or rate of exposure to an environmental hazard for a minority or low-income  
 31 population is significant and exceeds the risk or exposure rate for the general population or for  
 32 another appropriate comparison group. The minority and low-income populations are subsets of  
 33 the general public residing around the site, and all are exposed to the same hazards generated  
 34 from various operations at the site.

35 Minority and low-income populations could be affected by the construction and operation of a  
 36 new supercritical coal-fired power plant. Some of these effects have been identified in resource  
 37 areas discussed in this section. The extent of disproportionate effect is difficult to determine  
 38 since it would depend on the location of the coal-fired power plant. For example, increased  
 39 demand for rental housing during construction could disproportionately affect low-income  
 40 populations. However, demand for rental housing could be mitigated if the alternate plant site is  
 41 constructed near a metropolitan area. Also, increased coal consumption may affect employment  
 42 opportunities and environmental conditions in low-income regions in Pennsylvania, Ohio, or  
 43 West Virginia.

## Alternatives

1 Impacts on minority and low-income populations from the construction and operation of a coal-  
2 fired alternative could range from SMALL to MODERATE and would depend on the location of  
3 the power plant site in proximity to minority and low-income populations.  
4

### 5 **8.1.7 Waste Management**

6 Coal combustion generates several waste streams including ash (a dry solid) and sludge (a  
7 semi-solid by-product of emission control system operation). The NRC staff estimates that an  
8 850-MWe power plant would generate 222,000 t (201,000 MT) of ash and approximately 55,200  
9 t (50,000 MT) of scrubber waste per year, which would need to be disposed of onsite or in an  
10 offsite landfill (ACAA 2007). Based on industry-wide average recycling rates, of this waste,  
11 182,000 t (165,000 MT) of the ash and 208,000 t (188,000 MT) of scrubber sludge could be  
12 recycled (ACAA 2007).

13 On-site disposal is likely to encompass approximately 159 ac (64 ha) over 40 years of  
14 operation. In addition to coal combustion wastes, a supercritical coal-fired alternative would also  
15 produce small amounts of domestic and hazardous wastes.

16 Waste impacts to ground water and surface water would extend beyond the operating life of the  
17 plant if leaching and runoff from the waste storage area makes its way into ground water or  
18 surface water. Disposal of the waste would noticeably affect land use and ground water quality if  
19 not properly managed, but with appropriate management and monitoring, impacts to ground  
20 water resources would be prevented. After closure of the landfill and revegetation, the disposal  
21 area would be available for other uses. Impacts of the waste generated by a coal-fired  
22 alternative are considered by the NRC to be SMALL to MODERATE.  
23

### 24 **8.2 Natural Gas Combined-Cycle Generation**

25 In this section, we evaluate the environmental impacts of natural gas-fired combined-cycle  
26 generation at the TMI-1 site and at an alternate site. On page 8-18, Table 8-2 contains a  
27 summary of environmental impacts of natural gas combined-cycle generation in comparison to  
28 continued operation of TMI-1.

29 Natural gas fueled 20 percent of electric generation in the United States in 2006 (the most  
30 recent year for which data are available), accounting for the second greatest share of electrical  
31 power after coal (EIA 2007). Like coal-fired power plants, natural-gas-fired plants may be  
32 affected by perceived or actual action to limit greenhouse gas emissions, though they produce  
33 markedly fewer greenhouse gases per unit of electrical output than coal-fired plants. Natural  
34 gas-fired power plants are feasible, commercially available options for providing electrical  
35 generating capacity beyond TMI-1's current license expiration.

36 Combined-cycle power plants differ significantly from coal-fired and existing nuclear power  
37 plants. They derive the majority of their electrical output from a gas-turbine cycle, and then  
38 generate additional power—without burning any additional fuel—through a second, steam-  
39 turbine cycle. The first, gas turbine stage (similar to a large jet engine) burns natural gas which  
40 turns a driveshaft that powers an electric generator. The exhaust gas from the gas turbine is still  
41 hot enough, however, to boil water to steam. Ducts carry the hot exhaust to a heat recovery

1 steam generator, which produces steam to drive a steam turbine and produce additional  
2 electrical power. The combined-cycle approach is significantly more efficient than any one cycle  
3 on its own; efficiencies can exceed 60 percent. Since the natural-gas-fired alternative derives  
4 much of its power from a gas turbine cycle, and because it wastes less heat than either the  
5 coal-fired alternative or the existing TMI-1, it requires significantly less cooling water and smaller  
6 cooling towers.

7 In order to replace the 802 MWe that TMI-1 currently supplies, the NRC selected a gas-fired  
8 alternative that uses two General Electric S107H combined-cycle generating units. While any  
9 number of commercially-available combined-cycle units could be installed in a variety of  
10 combinations to replace the power currently produced by TMI-1, the S107H is a highly-efficient  
11 model that will help to minimize environmental impacts. Other manufacturers, like Siemens,  
12 offer similar high efficiency models. This gas-fired alternative produces a net 400 MWe per unit.  
13 Two units produce a total of 800 MWe, or nearly the same output as TMI-1.

14 The combined-cycle alternative operates at a heat rate of 5,690 Btu/kWh, or nearly 60 percent  
15 thermal efficiency (GE 2007). Allowing for onsite power usage, including cooling towers and site  
16 lighting, the gross output of these units would be roughly 830 MWe. As noted above, this gas-  
17 fired alternative would require much less cooling water than TMI-1, because it operates at a  
18 higher thermal efficiency and requires much less water for steam cycle condenser cooling.  
19 Cooling towers for this alternative would likely be mechanical draft-type towers approximately 65  
20 ft (20 m) in height.

21 In addition to cooling towers, other visible structures onsite include the turbines and heat  
22 recovery steam generators (which may be enclosed in a single building), two exhaust stacks, an  
23 electrical switchyard, and, possibly, equipment associated with a natural gas pipeline, like a  
24 compressor station. The GEIS (NRC 1996) estimated that a 1,000 MWe gas-fired alternative  
25 would require 110 ac (40 ha), meaning this 830-MWe plant would require 92 ac (37 ha).  
26 AmerGen indicated that the plant would require 32 ac (13 ha), a number more consistent with  
27 minimum utility needs as demonstrated by nearby power plants (including Dominion Resources'  
28 Fairless Energy Works). We will adopt AmerGen's estimate for the purposes of the following  
29 analysis.

30 This 830 MWe power plant would consume 34.2 billion cubic feet (ft<sup>3</sup>) (970 million m<sup>3</sup>) of natural  
31 gas annually assuming an average heat content of 1,033 Btu/ft<sup>3</sup> (EIA 2006). Natural gas would  
32 be extracted from the ground through wells, then treated to remove impurities (like hydrogen  
33 sulfide), and blended to meet pipeline gas standards, before being piped through the interstate  
34 pipeline system to the power plant site. This gas-fired alternative would produce relatively little  
35 waste, primarily in the form of spent catalysts used for emissions controls.

36 Environmental impacts from the gas-fired alternative will be greatest during construction. Site  
37 crews will clear vegetation from the site, prepare the site surface, and begin excavation before  
38 other crews begin actual construction on the plant and any associated infrastructure, including a  
39 pipeline spur to serve the plant and electricity transmission infrastructure connecting the plant to  
40 existing transmission lines.

41 Constructing the gas-fired alternative on AmerGen property located immediately south of  
42 remaining TMI Unit 2 plant structures would allow the gas-fired alternative to make use of TMI-  
43 1's existing transmission system, as well as take advantage of an already cleared and graded  
44 section of Three Mile Island. During the environmental site audit, TMI-1 staff indicated that some

## Alternatives

1 of this land is occasionally used for parking during outages and could be used during TMI-1 and  
2 TMI Unit 2 decommissioning. Additional offsite land, land farther south on Three Mile Island, or  
3 remaining land around the new gas-fired plant may be available for occasional use to offset this  
4 land requirement.

5 A gas-fired unit constructed offsite may cause additional construction-related impacts depending  
6 on the nature of the site selected (e.g., a site that has never been developed will likely  
7 experience greater impacts than a site that was previously industrial; a site near other power  
8 plants or industrial facilities will likely experience smaller impacts than a site surrounded by  
9 farmland or relatively natural surroundings).

10 **Table 8-2. Summary of Environmental Impacts of Natural Gas Combined-Cycle**  
11 **Generation Compared to Continued Operation of TMI-1.**

	Natural Gas Combined-Cycle		Continued TMI-1 Operation
	At TMI-1 site	At alternate site	
<b>Air Quality</b>	MODERATE	MODERATE	SMALL
<b>Ground Water</b>	SMALL	SMALL	SMALL
<b>Surface Water</b>	SMALL	SMALL	SMALL
<b>Aquatic and Terrestrial Resources</b>	SMALL	SMALL TO LARGE	SMALL
<b>Human Health</b>	SMALL	SMALL	SMALL
<b>Socioeconomics</b>	SMALL TO MODERATE	SMALL TO MODERATE	SMALL
<b>Waste Management</b>	SMALL	SMALL	N/A

12

### 13 **8.2.1 Air Quality**

14 Dauphin County does not meet the National Ambient Air Quality Standards established by EPA  
15 under the CAA and is a nonattainment area for PM<sub>2.5</sub>. A new gas-fired generating plant  
16 developed at the TMI-1 site would need to comply with the new source performance standards  
17 set forth in 40 CFR 60 Subpart D(a). The standards establish limits for particulate matter and  
18 opacity (40 CFR 60.42(a)), SO<sub>2</sub> (40 CFR 60.43(a)), and NO<sub>x</sub> (40 CFR 60.44(a)).

19 A gas-fired power plant constructed elsewhere in Pennsylvania would need to comply with  
20 applicable provisions of the CAA, based on the attainment status of the selected alternate site. If  
21 a natural gas-fired plant were located close to a mandatory Class I area, additional air pollution  
22 control requirements could be imposed. Pennsylvania does not have any designated Class I  
23 wilderness areas, the closest being Brigantine, NJ. For an alternate site, consideration may  
24 need to be given to installation of additional air emission control systems if the plant could  
25 potentially affect visibility in any of the Class I areas.

26 Pennsylvania regulates air emissions from power plants pursuant to terms of the APCA, as  
27 discussed in Section 8.1.1. Regulations enforced by the PADEP adopt the EPA's CAA rules,  
28 with modifications, to limit power plant emissions of SO<sub>x</sub>, NO<sub>x</sub>, particulate matter, and  
29 hazardous air pollutants, among other matters (PADEP 2008). Depending where a new gas-

1 fired facility is located within the State, that facility will need to comply with the applicable  
 2 Federal and State air regulations.

3 NOx is typically the pollutant of greatest concern for natural-gas-fired power plants. This gas-  
 4 fired alternative relies on dry, low-NOx burners, as well as selective catalytic reduction (SCR) to  
 5 reduce NOx emissions.

6 Pennsylvania and most other eastern states had been subject to requirements of 40 CFR  
 7 51.121(e), "Findings and requirements for submission of State implementation plan revisions  
 8 relating to emissions of oxides of nitrogen," and the total amount of NOx emissions allowed for  
 9 the Pennsylvania State implementation plan was 257,928 t (233,988 MT) for the 2007 ozone  
 10 season, and would have been subject to ozone-controlling elements of the Clean Air Interstate  
 11 Rule (CAIR) had CAIR not been vacated by the D.C. Circuit Court in July of this year. On  
 12 September 24, 2008, EPA filed for a rehearing of the D.C. Circuit Court decisions. Until EPA,  
 13 Congress, or the courts act, future NOx regulatory approaches remain uncertain.

14 The NRC staff projects the following emissions for a gas-fired alternative based on data  
 15 published by the EIA, on EPA emissions factors, and on performance characteristics for this  
 16 alternative and its emissions controls:

- 17 • Sulfur dioxide – 60 t/yr
- 18 • Nitrogen oxides – 192 t/yr
- 19 • Carbon monoxide- 40 t/yr
- 20 • PM<sub>10</sub> – 33.5 t/yr

21  
 22 A natural gas-fired plant would also have unregulated CO<sub>2</sub> emissions and, in the case of this  
 23 alternative to TMI-1, would emit approximately 1.99 million tons of CO<sub>2</sub> per year.

24 In December 2000, the EPA issued regulatory findings on emissions of hazardous air pollutants  
 25 from electric utility steam-generating units (65 FR 32214). Natural gas-fired power plants were  
 26 found by the EPA to emit arsenic, formaldehyde, and nickel. Unlike coal- and oil-fired plants, the  
 27 EPA did not determine that emissions of hazardous air pollutants from natural gas-fired power  
 28 plants should be regulated under Section 112 of the CAA.

29 Construction activities would also result in some air effects, including those from temporary  
 30 fugitive dust, though construction crews would employ dust-control practices to limit this impact.  
 31 Exhaust emissions would also come from vehicles and motorized equipment used during the  
 32 construction process, though these emissions are likely to be intermittent in nature and will  
 33 occur over a limited period of time. As such, construction stage impacts would be SMALL.

34 The overall air-quality impacts of a new natural gas-fired combined cycle plant sited at TMI-1 or  
 35 at an alternate site would be MODERATE.  
 36

### 37 **8.2.2 Ground Water Use and Quality**

38 The use of ground water for a natural gas combined cycle plant would likely be limited to supply  
 39 wells for drinking water and possibly filtered service water for system cleaning purposes. The  
 40 impact of ground water use would be SMALL. No effects on ground water quality would be

## Alternatives

1 apparent except during the construction phase when possible dewatering and run-off controls  
2 are used.

3

### 4 **8.2.3 Surface Water Use and Quality**

5 Consumptive use of surface water from the Susquehanna River would be much less for a gas-  
6 fired plant than the 18 mgd currently used on average by TMI-1. In addition, the discharge of  
7 waste water using this technology would be minimal. If this alternative is built on the current  
8 property, all intakes and discharges would be on the river and the impact on surface water  
9 resources would be SMALL.

10

### 11 **8.2.4 Terrestrial and Aquatic Ecology**

#### 12 Terrestrial Ecology

13 As indicated in previous sections, constructing the natural gas alternative will require 32 ac (13  
14 ha) of land. These land disturbances form the basis for impacts to terrestrial ecology. (Gas  
15 extraction and collection will also affect terrestrial ecology in offsite gas fields, although, as  
16 noted in Section 8.2.6, much of this land is likely already disturbed by gas extraction, and the  
17 incremental effects of this alternative on gas field terrestrial ecology are difficult to gauge.)

18 Impacts to terrestrial ecology will be minor because the selected site has been previously  
19 disturbed and is located on the southern end of the island. There is potential for disturbance of  
20 some areas with trees or manmade wetlands, and possible habitat fragmentation would occur.  
21 Construction of transmission line ROWs, a lengthy pipeline, or additional roads on undisturbed  
22 or less-disturbed areas could adversely impact terrestrial ecology by fragmenting or destroying  
23 habitats. However, a pipelined fuel source and a small workforce would help to minimize the  
24 need for additional transportation infrastructure.

25 In addition, construction on site may eliminate onsite habitats and alter the site for a long period  
26 of time. Some areas on site, such as any buffer areas, may remain undeveloped and could still  
27 harbor habitat for terrestrial species, though site lighting, noise, and activities may degrade the  
28 value of any remaining ecosystems. Deposition of air pollutants from this alternative may affect  
29 terrestrial ecology, but it is unlikely to be noticeable. Impacts to terrestrial resources from a  
30 natural gas combined-cycle alternative at both the TMI-1 site and an alternate site would like be  
31 SMALL.

#### 32 Aquatic Ecology

33 Aquatic ecology actually benefits from the onsite, gas-fired alternative, as the combined-cycle  
34 plant rejects significantly less heat to the environment than the existing TMI-1, thus requiring  
35 less water. A gas-fired alternative would require less than half as much water as the existing  
36 plant due to its much higher thermal efficiency. As the onsite gas-fired alternative would  
37 continue to use the existing cooling system, impacts to aquatic ecology would also be minimal.  
38 Aquatic impacts at an alternate site depend on location and ecology of the site, and the surface  
39 water body used for intake and discharge. These impacts are likely smaller at urban or  
40 previously industrial sites, owing to generally closer access to pipelines and transmission lines  
41 than at undeveloped sites. Overall, the ecological impacts are considered SMALL at the TMI-1



1 site and could range from SMALL to LARGE at a different location, depending on the sensitivity  
2 of local aquatic communities.  
3

#### 4 **8.2.5 Human Health**

5 Like the coal-fired alternative discussed above, a gas-fired plant would emit criteria air  
6 pollutants, but generally in smaller quantities (except NO<sub>x</sub>, which requires additional controls to  
7 reduce emissions). Human health risks of a gas-fired alternative are generally low, although in  
8 Table 8-2 of the GEIS (NRC 1996), the NRC staff identified cancer and emphysema as potential  
9 health risks from a gas-fired alternative. However, the current Federal and State regulatory  
10 frameworks, pertaining to air emission standards, allow for the adequate protection of  
11 occupational workers and members of the public. Therefore, the NRC staff has adopted (where  
12 applicable) the Federal and State air quality regulatory limits as significant thresholds for  
13 determining the human health risks associated with the operation of a new gas-fired power  
14 plant.

15 NO<sub>x</sub> emissions contribute to ozone formation, which in turn contribute to human health risks.  
16 Emission controls on this gas-fired alternative maintain NO<sub>x</sub> emissions well below air quality  
17 standards established for the purposes of protecting human health, and emissions trading or  
18 offset requirements mean that overall NO<sub>x</sub> in the region would not increase. Health risks to  
19 workers may also result from handling spent catalysts that may contain heavy metals. Overall,  
20 human health risks to occupational workers and to members of the public from gas-fired power  
21 plant emissions sited at TMI-1 or at an alternate site would be similar to the risks described for  
22 coal-fired alternative and therefore, would likely be SMALL.  
23

#### 24 **8.2.6 Socioeconomics**

##### 25 Land Use

26 A discussed in Section 8.1, the GEIS generically evaluates the impacts of nuclear power plant  
27 operations on land use both on and off each power plant site. The analysis of land use impacts  
28 focuses on the amount of land area that would be affected by the construction and operation of  
29 a natural gas-fired combined-cycle generation power plant at the TMI-1 site and at an alternate  
30 site. Land-use impacts would vary depending on where the plant would be located and whether  
31 construction would take place on undeveloped land or within a previously disturbed (brownfield)  
32 area.

33 AmerGen indicated that approximately 32 ac (13 ha) would be necessary to support a natural  
34 gas-fired alternative capable of replacing TMI-1. The GEIS, however, estimates 110 ac (45 ha)  
35 for a 1000-MWe generating station (NRC 1996). This amount of land use would include other  
36 plant structures and associated infrastructure. By scaling the GEIS estimate, an 853-MWe plant  
37 could require up to 92 ac (37 ha) of land. This amount of land will encompass the plant site at  
38 both TMI-1 and an alternate site, and transmission line ROWs at an alternate site. The NRC  
39 staff believes that the AmerGen estimate is reasonable. However, if additional land would be  
40 necessary for a buffer around plant structures or to support transmission lines at an alternate  
41 site and gas pipelines at both TMI-1 and at an alternate site, the NRC staff believes the GEIS  
42 estimate for land use provides a more useful approximation. Nevertheless, land use impacts

## Alternatives

1 from construction would be SMALL, and could be further reduced if the power plant is collocated  
2 with another generating station or on a previously industrial site like TMI-1. Impacts could be  
3 further mitigated at an alternate site by constructing new transmission lines in existing ROWs.

4 In addition to onsite land requirements, land will be required off site for natural gas wells and  
5 collection stations. The GEIS estimates that 3,600 ac (1,457 ha) would be required for wells,  
6 collection stations, and pipelines to bring the gas to a 1,000-MWe generating facility. If this land  
7 requirement were scaled directly with generating capacity, an alternative to TMI-1 could require  
8 up to 3,000 ac (1,200 ha) (though actual requirements will vary significantly). Most of this land  
9 requirement would occur on land where gas extraction already occurs. In addition, some natural  
10 gas that could be used by the new power plant may come from outside of the United States and  
11 would be delivered as liquefied gas. Effects from gas extraction are generally smaller than those  
12 for coal mining, as most land around a gas extraction site remains undisturbed, except for roads  
13 and collection pipe network. Site reclamation after natural gas extraction would be less involved  
14 than land previously used for coal mining.

15 The elimination of uranium fuel for TMI-1 could partially offset off site land requirements. In the  
16 GEIS, the NRC staff estimated that approximately 1,000 ac (405 ha) would not be needed for  
17 mining and processing uranium during the operating life of a 1,000-MWe nuclear power plant.  
18 For TMI-1, roughly 850 ac (344 ha) of uranium mining area would no longer be needed. Overall  
19 land use impacts from a gas-fired power plant would be SMALL to MODERATE, depending on  
20 local land use and the availability of land near the proposed site.

### 21 Socioeconomics

22 As discussed in Section 8.1, socioeconomic impacts are defined as changes to the  
23 demographic and economic characteristics and social conditions of a region. For example, the  
24 number of jobs created by the construction and operation of a new natural gas-fired power could  
25 affect regional employment, income, and expenditures. Job creation is characterized by two  
26 types: (1) construction-related jobs, which are transient, short in duration, and less likely to have  
27 long-term socioeconomic impacts; and (2) operation-related jobs in support of power plant  
28 operations, which have the greater potential for permanent, long-term socioeconomic impacts.  
29 Workforce requirements of power plant construction and operations for the gas-fired alternative  
30 were determined in order to measure their possible effect on current socioeconomic conditions.

31 The socioeconomic impacts from constructing and operating a gas-fired plant would have little  
32 noticeable effect. Compared to the coal-fired alternative, the small size of the construction and  
33 operations workforce would have little or no socioeconomic impact.

34 AmerGen indicated that a 483-member workforce would be required to construct the gas-fired  
35 alternative (AmerGen 2008). After construction, local communities may be temporarily affected  
36 by the loss of construction jobs and associated loss in demand for business services, and the  
37 rental housing market could experience increased vacancies and decreased prices. The impact  
38 of construction on socioeconomic conditions could range from SMALL to MODERATE  
39 depending on whether the new power plant would be located at TMI-1 or an alternate site. The  
40 socioeconomic impacts of power plant construction could be reduced if the power plant is  
41 located near an urban area with a large pool of skilled workers.

1 Following construction, a gas-fired alternative could provide up to 27 jobs, based on AmerGen  
2 estimates, or up to 125 jobs based on an extrapolated estimate from the GEIS. Depending on  
3 location, the small number of workers would not have a noticeable effect on socioeconomic  
4 conditions in the region. Therefore, socioeconomic impacts associated with operation of a gas-  
5 fired power plant would be SMALL.

#### 6 Transportation

7 Transportation impacts associated with construction and operation of a two unit power plant  
8 under the gas-fired alternative would consist of commuting workers and truck deliveries of  
9 construction materials to the TMI-1 worksite. Transportation effects would vary depending on  
10 the characteristics of site access roads. In addition to commuting workers, trucks would deliver  
11 construction materials to the worksite. These vehicles would increase the overall number of  
12 vehicles on local roads. Pipeline construction and modification to existing natural gas pipeline  
13 systems may also have a short-term impact.

14 Conversely, transportation impacts would almost disappear during plant operations. The  
15 estimated number of operating personnel would be approximately 27 workers, although the  
16 GEIS indicates that as many as 125 operations workers could be required. Since fuel is  
17 transported by pipeline, most transportation infrastructure will experience little increased use  
18 from plant operations.

19 Since fuel would be transported by pipeline, the transportation infrastructure would experience  
20 little to no increased use from plant operations. Overall, the gas-fired alternative would have a  
21 SMALL impact on transportation conditions in the region around TMI-1. Transportation impacts  
22 may vary at an alternate site and would depend on roadway capacity and average daily volume.

#### 23 Aesthetics

24 As discussed in Section 8.1, aesthetic resources are the natural and man-made features that  
25 give a particular landscape its character and aesthetic quality. The aesthetics impact analysis  
26 focuses on the degree of contrast between the power plant and the surrounding landscape and  
27 the visibility of the power plant.

28 The two gas-fired units could be approximately 100 ft (30 meters [m]) tall, with two exhaust  
29 stacks at least 175 ft (53 m) tall or taller depending on the topography at an alternate site. Some  
30 structures may require aircraft warning lights. If the plant is located near the existing TMI-1,  
31 impacts may be moderated as higher elevations and vegetation along the river valley could  
32 make it difficult to see or hear the plant outside of the river valley. Power plant infrastructure  
33 would generally be smaller and less noticeable than TMI-1 containment and cooling tower. The  
34 mechanical draft cooling towers would be markedly shorter than the natural-draft towers located  
35 at TMI-1, but they would also generate condensate plumes and operational noise. Noise during  
36 power plant operations would be limited to industrial processes and communications.

37 In addition to seeing new power plant structures, the alternate plant site may require the  
38 construction of transmission lines and natural gas pipelines. The transmission lines would have  
39 a lasting visual effect on the landscape.

40 Noise from plant operations would be primarily limited to industrial processes and  
41 communications. Unlike the coal-fired alternative, pipelines would deliver natural gas fuel, thus

## Alternatives

1 eliminating the noises from fuel and waste handling and associated transportation equipment.  
2 Noise from the pipelines could be audible off site near compressors.

3 In general, aesthetic changes would be limited to the immediate vicinity of TMI-1 or an alternate  
4 site. Impacts would likely to be SMALL to MODERATE, depending on the amount of new  
5 transmission line required.

### 6 Historic and Archaeological Resources

7 The potential for historic and archaeological resources can vary greatly depending on the  
8 location of the proposed site. To consider a project's effects on historic and archaeological  
9 resources, any proposed areas will need to be surveyed to identify and record historic and  
10 archeological resources, identify cultural resources, and develop possible mitigation measures  
11 to address any adverse effects from ground disturbing activities. Studies will be needed for all  
12 areas of potential disturbance at the proposed plant site and along associated corridors where  
13 new construction will occur (e.g., roads, transmission corridors, rail lines, or other ROWs). In  
14 most cases, project proponents should avoid areas with the greatest sensitivity.

15 Depending on the resource richness of the site ultimately chosen for the gas-fired alternative,  
16 impacts will range from SMALL to MODERATE.

### 17 Environmental Justice

18 The environmental justice impact analysis evaluates the potential for disproportionately high and  
19 adverse human health and environmental effects on minority and low-income populations that  
20 could result from the construction and operation of a new natural gas-fired combined-cycle  
21 generation power plant. Adverse health effects are measured in terms of the risk and rate of  
22 fatal or nonfatal adverse impacts on human health. Disproportionately high and adverse human  
23 health effects occur when the risk or rate of exposure to an environmental hazard for a minority  
24 or low-income population is significant and exceeds the risk or exposure rate for the general  
25 population or for another appropriate comparison group. The minority and low-income  
26 populations are subsets of the general public residing around the site, and all are exposed to  
27 the same hazards generated from various power plant operations.

28 Minority and low-income populations could be affected by the construction and operation of a  
29 new natural gas-fired power plant. Some of these effects have been identified in resource areas  
30 discussed in this section. For example, increased demand for rental housing during construction  
31 could disproportionately affect low-income populations. However, demand for rental housing  
32 could be mitigated if the alternate plant site is constructed near a metropolitan area. Impacts on  
33 minority and low-income populations from the construction and operation of a natural-gas-fired  
34 alternative could range from SMALL to MODERATE, due to the small number of workers  
35 needed to construct and operate the natural gas-fired power plant.  
36

### 37 **8.2.7 Waste Management**

38 Minor quantities of waste are generated during burning of natural gas compared to other  
39 alternatives, however use of SCR to control NO<sub>x</sub> will generate spent SCR catalysts and small  
40 amounts of solid waste products.

1 It is concluded in the GEIS by the NRC staff that gas-fired technology waste generation would  
2 be minimal (NRC 1996) and the waste impacts would be SMALL for a natural gas-fired  
3 combined-cycle plant sited at TMI-1 or at alternate site.  
4

### 5 **8.3 Energy Conservation/Energy Efficiency**

6 In this section, the NRC staff evaluates the environmental impacts of a demand-side energy  
7 conservation or energy efficiency alternative. On the following page Table 8-3 summarizes the  
8 environmental impacts of energy conservation/energy efficiency compared to continued  
9 operation of TMI-1.

10 Though often used interchangeably, energy conservation and energy efficiency are different  
11 concepts. Energy efficiency typically means deriving a similar level of services by using less  
12 energy, while energy conservation simply indicates a reduction in energy consumption. Both fall  
13 into a larger category known as demand-side management (DSM). DSM measures – unlike the  
14 energy supply alternatives discussed in previous sections – address energy end uses. DSM can  
15 include measures that shift energy consumption to different times of day to reduce peak loads,  
16 measures that interrupt certain large customers during periods of high demand or measures that  
17 interrupt certain appliances during high demand periods, and measures like replacing older, less  
18 efficient appliances, lighting, or control systems. DSM also includes measures that utilities use  
19 to boost sales, such as encouraging customers to switch from gas to electricity for water  
20 heating.

21 Unlike other alternatives to license renewal, the GEIS notes that conservation is not a discrete  
22 power generating source; it represents an option that states and utilities may use to reduce their  
23 need for power generation capability (NRC 1996). In addition, conservation represents a  
24 possible consequence of the no-action alternative. The GEIS “assumes that conservation  
25 technologies produce enough energy savings to permit the closing of a nuclear plant.”

26 Prior to the implementation of Pennsylvania’s Alternative Energy Portfolio Standard (AEPS),  
27 several Pennsylvania foundations sponsored a study by engineering firm Black and Veatch to  
28 document the potential effects renewable energy, conservation/efficiency, and unconventional  
29 power sources like waste coal (Pletka 2004). The study divided energy efficiency and  
30 conservation, and defined conservation as demand-side measures, and efficiency as supply-  
31 side measure like repowering or other power plant, transmission, or distribution improvements.  
32 Because Black and Veatch’s defined energy efficiency as only supply-side options, and  
33 because Black and Veatch defined conservation as including all demand-side measures to  
34 reduce electricity consumption, we will only use Black and Veatch’s conservation estimates in  
35 the following section.

36 Black and Veatch’s analysis indicated 18,206 gigawatt-hours (GWh) of conservation could be  
37 achieved within 10-15 years of the study’s 2004 publication date (Pletka 2004), or roughly three  
38 times the amount of electricity produced by TMI-1 in a given year. The total magnitude of these  
39 savings could be as large as 6872 MW, or more than eight times TMI-1’s power output. Overall,  
40 Black and Veatch indicated that Pennsylvania had “good” conservation resources.

41 Since the study, PJM has instituted new measures to capture energy efficiency potential, and  
42 energy efficiency measures now count for inclusion in the AEPS. The NRC had difficulty  
43 determining how much of the potential identified in the 2004 report remains available in

## Alternatives

1 Pennsylvania, though it appears unlikely that all or even most of this potential would already  
2 have been exploited. Beyond near-term potential, Black and Veatch's analysis identified an  
3 additional 70,000 GWh or 28,824 MW of conservation potential, some of which may be  
4 available at higher costs or on longer time horizons. Also, because TMI-1 sells power into the  
5 PJM interconnection, conservation in other nearby states may also help to offset power  
6 produced by TMI-1, even though sufficient capacity appears to exist in Pennsylvania alone.  
7 Therefore, the NRC staff chose to evaluate conservation as an alternative to license renewal.

8 A conservation alternative will produce different impacts than the other alternatives addressed.  
9 Unlike the discrete generation options, there is no major construction and few ongoing  
10 operational impacts. The most significant effects occur during installation or implementation or  
11 conservation measures, when old appliances may be disposed of, buildings may be retrofitted,  
12 or control devices may be installed. In some cases, increases in efficiency may come from  
13 better management of existing control systems. Many of these items may be recycled, though  
14 volumes of landfilled trash may still increase.

15 The GEIS generally indicates that impacts from a conservation alternative are small and that  
16 some postulated effects (like increases in mercury, polychlorinated biphenyls (PCBs), or  
17 chlorofluorocarbon (CFC) releases as fluorescent bulbs, old transformers or old refrigerators are  
18 replaced) may prove not to be significant as effective disposal methods can prevent health  
19 effects, and as more environmentally-benign alternatives have emerged (NRC 1996).

20 **Table 8-3. Summary of Environmental Impacts of Energy Conservation/Energy**  
21 **Efficiency Compared to Continued Operation of TMI-1.**

	<b>Energy Conservation/Energy Efficiency</b>	<b>Continued TMI-1 Operation</b>
<b>Air Quality</b>	SMALL	SMALL
<b>Ground Water</b>	SMALL	SMALL
<b>Surface Water</b>	SMALL	SMALL
<b>Aquatic and Terrestrial Resources</b>	SMALL	SMALL
<b>Human Health</b>	SMALL	SMALL
<b>Socioeconomics</b>	SMALL	SMALL
<b>Waste Management</b>	SMALL	N/A

22

### 23 8.3.1 Air Quality

24 Implementation of the energy conservation alternative reduces direct fuel use and reduces  
25 environmental emissions resulting from plant fuel cycles, workers' commuting, and plant  
26 operation and maintenance. Improvements in efficiency may also reduce consumption of fuels  
27 used for space or water heating at the same time they reduce electrical consumption.

28 As noted above, no major construction would be required and few ongoing operational impacts  
29 would be experienced during implementation of the conservation alternative. The conservation  
30 alternative would likely cause only minor and short-duration air quality impacts—use of best  
31 management practices would minimize air quality impacts during installation of new appliances

1 or systems. Implementation of energy conservation measures would improve efficiency of  
 2 boilers and heating units and would help to reduce already low air emissions.  
 3 The overall impacts on air quality of the energy conservation and/or energy efficiency alternative  
 4 would be SMALL.  
 5

6 **8.3.2 Ground Water Use and Quality**

7 The conservation alternative would not require any groundwater. It is possible that wastes  
 8 produced during installation of improved equipment could have an effect on groundwater if  
 9 leachate from landfills infiltrate groundwater, but this effect is not likely to be noticeably altered  
 10 by a small increase in overall waste production, if any, associated with the conservation  
 11 alternative. Overall impacts to groundwater are SMALL.  
 12

13 **8.3.3 Surface Water Use and Quality**

14 The impacts on surface water use and quality because of energy conservation efforts would be  
 15 SMALL, but positive. The consumptive use of water from the Susquehanna River would  
 16 certainly decrease as would the discharge of waste water streams.  
 17

18 **8.3.4 Terrestrial and Aquatic Ecology**

19 Terrestrial Ecology

20 Terrestrial ecology impacts would be SMALL. No additional land disturbances on or offsite  
 21 would be required.

22 Aquatic Ecology

23 Impacts to aquatic resources would be SMALL, but positive, as withdrawals from and  
 24 discharges to the Susquehanna River would cease, since the no-power generation alternative  
 25 would take the place of TMI-1. If more energy is conserved than is produced by TMI-1, then  
 26 positive impacts to aquatic resources could extend beyond the Susquehanna River to other  
 27 water bodies. This net conservation of energy could result in less demand for power production  
 28 at other plants and could lead to lower rates of water withdrawal and discharge at these power  
 29 plants. The implementation of conservation measures, such as the increased use of mercury-  
 30 containing compact fluorescent light bulbs and their impact to the environment after landfill  
 31 disposal, would result in SMALL impacts to the aquatic environment. While increased mercury  
 32 levels in landfills could leach into adjacent waterways, State and local landfill regulations could  
 33 reduce or eliminate such pollution.  
 34

35 **8.3.5 Human Health**

36 Energy demand reduction measures are specific procedures or technologies that are  
 37 undertaken to reduce energy demands. Human health risks of the energy conservation  
 38 alternative are minimal, although in Table 8-2 of the GEIS (NRC 1996) the NRC staff identified  
 39 radon as the major potential health risk from energy conservation alternative. Currently, there

## Alternatives

1 are no Federal or State regulatory frameworks pertaining to radon exposure standard, therefore,  
2 the NRC staff has chosen the EPA recommendation level of 4 picocuries per Liter (pCi/L) as a  
3 significant threshold for determining the human health risks associated with the energy  
4 conservation alternative.

5 Radon-222 is a naturally occurring radioactive noble gas that is formed from the decay of  
6 radium-226. Radiation exposure from radon-222 is indirect. Radon has a short half-life (4 days)  
7 and decays into other solid particulate radioactive nuclides that give off high energy alpha  
8 particles. These radioactive particles are inhaled and remain lodged in the lungs, causing  
9 continued exposure. People in affected localities can receive up to 10 mSv per year background  
10 radiation of radon-222. Radon-222 is thus the second leading cause of lung cancer after  
11 smoking, and accounts for 15,000 to 22,000 cancer deaths per year in the U.S. alone (Darby  
12 1989). The general population is exposed to small amounts of polonium as a radon-daughter in  
13 indoor air; the isotopes polonium-214 and polonium-218 are thought to cause the majority of the  
14 estimated lung cancer deaths from radon (Darby 1989). A Bonneville Power Administration  
15 radon-222 exposure study found that radon-222 was a serious concern in new home  
16 construction if mitigation measures were not implemented. Cancer cases from radon-222  
17 exposures were estimated to be 335 per 100,000 for baseline homes but as high as 767 cases  
18 per 100,000 for new homes with advanced infiltration control but no exhaust or mechanical  
19 ventilation (Pace 1991).

20 EPA recommends homes be fixed if the radon level is 4 pCi/L or more. Because there is no  
21 known safe level of exposure to radon, EPA also recommends that Americans consider fixing  
22 their homes for radon levels between 2 pCi/L and 4 pCi/L. The average radon concentration in  
23 the indoor air of America's homes is about 1.3 pCi/L. The average concentration of radon in  
24 outdoor air is 0.4 pCi/L, about 1/10th of EPA's 4 pCi/L action level (EPA 2008b). Given that a  
25 member of the public has taken appropriate mitigative actions—such as installing a more  
26 efficient ventilation system for radon removal, sealing cracks in basements, etc.—to achieve an  
27 indoor radon concentration below 2 pCi/L, the human health risks to members of the public from  
28 the energy conservation alternative would be within the range of the national average and would  
29 likely be SMALL.  
30

### 31 **8.3.6 Socioeconomics**

#### 32 Land Use

33 Since AmerGen would continue to use the existing transmission lines land use impacts of an  
34 energy efficiency alternative would be SMALL. Quickly replacing and disposing of old inefficient  
35 appliances could generate waste material and potentially increase the size of landfills. However,  
36 given the 10 to 15-year timeline for program development and implementation, the cost of  
37 replacements, and the average life of an appliance; the replacement process would probably be  
38 more gradual. Older appliances would simply be replaced by more efficient appliances as they  
39 fail (especially in the case of frequently replaced items, like lightbulbs). In addition, many items  
40 (like home appliances or industrial equipment) have substantial recycling value and would likely  
41 not be disposed of in landfills.



1 Socioeconomics

2 Socioeconomic effects of an energy efficiency program would be SMALL. As noted in the GEIS,  
 3 the program would likely employ additional workers. Lower-income families could benefit from  
 4 weatherization and insulation programs. This effect would be greater than the effect for the  
 5 general population because low-income households experience home energy burdens more  
 6 than four times larger than the average household (OMB 2007).

7 Transportation

8 Transportation impacts would be SMALL, because fewer employees would commute to TMI-1.  
 9 Any transportation effects from the energy efficiency alternative would be widely distributed  
 10 across the State, and would not be noticeable.

11 Aesthetics

12 Impacts from energy efficiency programs would be SMALL because TMI-1 would be  
 13 decommissioned with no alternative power plant to replace it. The transmission lines would  
 14 remain after plant decommissioning. Traffic to the plant would decrease, however, as would  
 15 noise and emissions. Some noise impacts could occur in instances of energy efficiency  
 16 upgrades to major building systems, though this impact would be intermittent and short-lived.

17 Historic and Archaeological Resources

18 Impacts from the energy conservation/energy efficiency alternative would be SMALL, since TMI-  
 19 1 would be decommissioned with no alternative power plant to replace it. A separate  
 20 environmental review would be conducted for decommissioning. That assessment will address  
 21 the protection of historic and archaeological resources.

22 Environmental Justice

23 Weatherization programs could target low-income residents as a cost-effective energy efficiency  
 24 option since low-income populations tend to spend a larger proportion of their incomes paying  
 25 utility bills (according to the Office of Management and Budget, low income populations  
 26 experience energy burdens more than four times as large as those of average households  
 27 [OMB 2007]). Impacts to minority and low-income populations from energy efficiency programs  
 28 would be SMALL, depending on program design and enrollment.  
 29

30 **8.3.7 Waste Management**

31 The most significant effects occur during installation or implementation or conservation  
 32 measures, when old appliances may be disposed of, buildings may be retrofitted, or control  
 33 devices may be installed. Implementation of the recycling programs would help to decrease  
 34 volumes of the generated waste, though volumes of the trash sent to the landfills may still  
 35 increase.

36 According to the GEIS, impacts from a conservation alternative are minimal, and some  
 37 postulated effects (like increases in mercury, PCBs, or CFC releases as fluorescent bulbs, old  
 38 transformers or old refrigerators are replaced) may prove to be insignificant as more  
 39 environmentally-benign alternatives have emerged, and if proper disposal methods are  
 40 employed (NRC 1996).

## Alternatives

1 Overall, the waste impacts would be SMALL for the energy conservation and/or energy  
2 efficiency alternative.

3

### 4 **8.4 Combination Alternative**

5 In this section, we evaluate the environmental impacts of a combination of alternatives. This  
6 combination will include a portion of the energy efficiency/conservation potential identified in  
7 Section 8.3, a portion of the combined-cycle gas-fired capacity identified in Section 8.2, and a  
8 series of uprates to existing hydroelectric dams. This alternative requires little new construction  
9 (only for the single gas-fired unit installed at the TMI-1 site and minor renovation at uprated  
10 dams). We acknowledge that we could also include some amount of wind power in this  
11 alternative as a companion to the hydropower uprates, though the NRC elected not to do so  
12 since constructing wind power facilities would likely increase the environmental impact of the  
13 combination alternative without a commensurate decrease in operating impacts from other  
14 portions of the combination alternative. Table 8-4 on the following page contains a summary of  
15 the environmental impacts of the combination alternative compared to continued operation of  
16 TMI-1.

17 In this alternative, slightly more than half of TMI-1's output (approximately 420 MW) would be  
18 replaced by conservation. Power uprates at existing hydroelectric dams will account for roughly  
19 100 MWe of capacity (as identified in INEEL 1997) and 280 MWe will come from one GE  
20 S107FB combined cycle power plant. The only major construction we anticipate will happen at  
21 the current TMI-1 site where the combined-cycle gas-fired power plant would be constructed.  
22 No major construction should be necessary for the conservation portion, and relatively minor  
23 construction would occur at existing dams for purposes of power uprates.

24 The appearance of the single-unit gas-fired facility would be similar to that of the two-unit gas-  
25 fired alternative considered in Section 8.2, except smaller. We estimate that the single-unit gas-  
26 fired facility would require approximately 35 percent of the space necessary for the two-unit gas-  
27 fired facility considered in Section 8.2, and that all construction effects—as well as operational  
28 aesthetic, fuel-cycle, air quality, socioeconomic, land use, environmental justice, and water  
29 consumption effects—will scale accordingly.<sup>9</sup> Since the gas-fired portion of this alternative uses  
30 roughly a third of the available land south of TMI Unit 2 on Three Mile Island, AmerGen may still  
31 be able to use most of the available space for outage personnel and eventual decommissioning  
32 activities of TMI-1.

---

<sup>9</sup> The S107FB unit considered here is slightly less efficient than the S207H units considered in Section 8.2 (heat rate of 5950 btu/kWh for the S107FB versus 5690 btu/kWh for the S207H; GE 2007). We've calculated air quality impacts in the following sections accordingly.

1 **Table 8-4. Summary of Environmental Impacts of the Combination Alternative**  
 2 **Compared to Continued Operation of TMI-1.**

	Combination Alternative		Continued TMI-1 Operation
	At TMI-1 Site	At Alternate Site	
<b>Air Quality</b>	SMALL to MODERATE	MODERATE	SMALL
<b>Ground Water</b>	SMALL	SMALL	SMALL
<b>Surface Water</b>	SMALL	SMALL	SMALL
<b>Aquatic and Terrestrial Resources</b>	SMALL	SMALL	SMALL
<b>Human Health</b>	SMALL	SMALL	SMALL
<b>Socioeconomics</b>	SMALL to MODERATE	SMALL TO MODERATE	SMALL
<b>Waste Management</b>	SMALL	SMALL	N/A

3

4 **8.4.1 Air Quality**

5 As noted in Section 8.2.1, Dauphin County does not meet the National Ambient Air Quality  
 6 Standards established by EPA under the CAA and is in a nonattainment area for PM<sub>2.5</sub>. A new  
 7 gas-fired generating plant developed at the TMI-1 site would need to comply with the new  
 8 source performance standards set forth in 40 CFR 60 Subparts D(a). The standards establish  
 9 limits for particulate matter and opacity, SO<sub>2</sub>, and NO<sub>x</sub>.

10 Pennsylvania and most other eastern states had been subject to requirements of 40 CFR  
 11 51.121(e), "Findings and requirements for submission of State implementation plan revisions  
 12 relating to emissions of oxides of nitrogen," and the total amount of NO<sub>x</sub> emissions allowed for  
 13 the Pennsylvania state implementation plan was 257,928 t (233,988 MT) for the 2007 ozone  
 14 season, and would have been subject to ozone-controlling elements of the Clean Air Interstate  
 15 Rule (CAIR) had CAIR not been vacated by the D.C. Circuit Court in July of this year. On  
 16 September 24, 2008, EPA filed for a rehearing of the D.C. Circuit Court decision. Until EPA,  
 17 Congress, or the courts act, future NO<sub>x</sub> regulatory approaches remain uncertain.

18 As noted in 8.2.1, NO<sub>x</sub> is typically the pollutant of greatest concern for natural-gas-fired power  
 19 plants. Like the plant in 8.2.1, this gas-fired portion of this alternative relies on dry, low-NO<sub>x</sub>  
 20 burners, as well as selective catalytic reduction (SCR) to reduce NO<sub>x</sub> emissions.

21 For the combination alternative only one gas-fired unit would be built. Emissions of SO<sub>x</sub>, NO<sub>x</sub>,  
 22 mercury, and particulate matter would be approximately 37 percent of those detailed in Section  
 23 8.2.1. A natural gas-fired plant would also have unregulated CO<sub>2</sub> emissions; a single-unit gas-  
 24 fired facility would emit approximately 728,000 t (660,000 MT) of CO<sub>2</sub> per year.

25 As noted in 8.2.1, EPA has determined that natural gas-fired power plants emit arsenic,  
 26 formaldehyde, and nickel. Unlike coal and oil-fired plants, EPA did not determine that emissions  
 27 of hazardous air pollutants from natural gas-fired power plants should be regulated under  
 28 Section 112 of the CAA.

29 Construction activities for the gas-fired unit as well as retrofits at existing dams would also result  
 30 in some air effects, including those from temporary fugitive dust, though construction crews

## Alternatives

1 would employ dust-control practices to limit this impact. Exhaust emissions would also come  
2 from vehicles and motorized equipment used during the construction process, though these  
3 emissions are likely to be intermittent in nature and would occur over a limited period of time.  
4 Construction stage impacts would, therefore, be SMALL.

5 The overall air-quality impacts of the combination alternative—based largely on the impacts  
6 from a new, single-unit, natural gas-fired combined cycle plant sited at TMI-1—would be  
7 SMALL to MODERATE.

8

### 9 **8.4.2 Ground Water Use and Quality**

10 If the onsite gas-fired plant continued to use groundwater for drinking water and service water,  
11 the total usage would likely be much less than TMI-1 uses, because many fewer workers are  
12 onsite, and because the gas-fired unit would have fewer auxiliary systems requiring service  
13 water. The current permitted withdrawal rate is 225,000 gpd, and pumping tests indicate this  
14 rate would not cause an effect on nearby supply wells. A reduction in this withdrawal rate  
15 means that impacts of the combination alternative would remain SMALL.

16

### 17 **8.4.3 Surface Water Use and Quality**

18 Using a combined alternative with conservation as a major component will reduce the amount of  
19 surface water consumed for cooling purposes. The maximum consumptive use would be  
20 reduced to a fraction of the 18 mgd used by the current nuclear plant. This represents less than  
21 0.1 percent of the average annual flow rate in the river. The impact of this withdrawal would be  
22 SMALL.

23

### 24 **8.4.4 Terrestrial and Aquatic Ecology**

#### 25 Terrestrial Ecology

26 Impacts to terrestrial ecology would be SMALL. ROW maintenance would continue, although no  
27 additional transmission lines would be necessary. The only construction activities that would  
28 occur for the combination alternative are the construction of a combined-cycle gas-fired power  
29 plant and any retrofit-related construction (largely internal) at existing dams. These activities  
30 would be confined to previously disturbed areas at the TMI-1 site, and would be relatively limited  
31 at dam sites. Some habitat fragmentation impacts on the southern part of the island may occur.

#### 32 Aquatic Ecology

33 Aquatic ecology would actually benefit from the combination efficiency/conservation,  
34 hydroelectric power plant uprates, and gas-fired power plant alternative, as the combined-cycle  
35 plant would reject significantly less heat to the environment than the existing TMI-1, thus  
36 requiring less water. Impacts to aquatic resources would be SMALL, but positive, as  
37 withdrawals from and discharges to the Susquehanna River would be significantly less. Energy  
38 conservation and efficiency would likewise result in less withdrawals and discharges  
39 corresponding to a decreased demand for power generation as discussed in Section 8.3.  
40 Uprates to hydroelectric power plants to compensate for loss of power generation at TMI-1

1 could lead to slight increases in entrainment and impingement impacts at these hydroelectric  
2 plants, but these impacts would be regulated and likely SMALL.  
3

#### 4 **8.4.5 Human Health**

5 The human health risks of a combination of alternatives include those that have already been  
6 discussed in their respective sections (i.e. energy conservation and combined cycle gas-fired  
7 alternatives). The human health risks are uncertain, but considered to be SMALL given the  
8 combination of alternatives must comply with health-based Federal and State emission  
9 standards.  
10

#### 11 **8.4.6 Socioeconomics**

##### 12 Land Use

13 As discussed in Section 8.1, the GEIS generically evaluates the impacts of nuclear power plant  
14 operations on land use both on and off each power plant site. The analysis of land use impacts  
15 focuses on the amount of land area that would be affected by the construction and operation of  
16 a single natural gas-fired unit power plant at the TMI-1 site and minor renovation of dams.

17 Approximately 11 ac (5 ha) would be necessary to support a single natural gas-fired unit  
18 combination alternative based on AmerGen estimates for a discrete gas-powered alternative.  
19 By scaling the GEIS estimate, a 280 MWe plant could require up to approximately 32 ac (13 ha)  
20 of land and would encompass available space at the TMI-1 site. The NRC staff believes that  
21 the AmerGen estimate is reasonable. However, if additional land were necessary for a buffer  
22 around plant structures and the construction of gas pipelines at TMI-1, the NRC staff believes  
23 the GEIS estimate provides a more useful approximation. Nevertheless, land use impacts from  
24 construction would be SMALL.

25 In addition to onsite land requirements, land will be required offsite for natural gas wells and  
26 collection stations. The GEIS estimates that 3,600 ac (1,457 ha) would be required for wells,  
27 collection stations, and pipelines to bring the gas to a 1000-MWe generating facility. If this land  
28 requirement were scaled directly with generating capacity, the combination alternative could  
29 require up to 1,025 ac (425 ha), though actual requirements will vary significantly. As previously  
30 discussed in Section 8.2, most of this land requirement would occur on land where gas  
31 extraction already occurs. In addition, some natural gas that could be used by the new power  
32 plant may come from outside of the U.S. and would be delivered as liquefied gas. Effects from  
33 gas extraction are generally smaller than those for coal mining, as most land around a gas  
34 extraction site remains undisturbed, except for roads and collection pipe network. Site  
35 reclamation after natural gas extraction would be less involved than reclamation of land  
36 previously used for coal mining.

37 As previously discussed, the elimination of uranium fuel for TMI-1 could partially offset offsite  
38 land requirements. In the GEIS, the NRC staff estimated that approximately 1,000 ac (405 ha)  
39 would no longer be needed for mining and processing uranium during the operating life of a  
40 1000-MWe nuclear power plant. For TMI-1, roughly 850 ac (344 ha) of uranium mining area  
41 would no longer be needed. Overall land use impacts from a single natural-gas-fired power  
42 plant unit under the combination alternative would be SMALL.

## Alternatives

### 1 Socioeconomics

2 As discussed in Section 8.1, socioeconomic impacts are defined in terms of changes to the  
3 demographic and economic characteristics and social conditions of a region. For example, the  
4 number of jobs created by the construction and operation of a new single natural gas-fired  
5 power plant unit could affect regional employment, income, and expenditures. Job creation is  
6 characterized by two types: (1) construction-related jobs, which are transient, short in duration,  
7 and less likely to have long-term socioeconomic impacts; and (2) operation-related jobs in  
8 support of power plant operations, which have the greater potential for permanent, long-term  
9 socioeconomic impacts. Workforce requirements for power plant construction and operations for  
10 the combination alternative were determined in order to measure their possible effect on current  
11 socioeconomic conditions.

12 The socioeconomic impacts from constructing and operating a single unit natural-gas-fired plant  
13 and minor renovation of dams would have little noticeable effect. Compared to the coal-fired  
14 alternative, the small size of the construction and operations workforce would have little or no  
15 socioeconomic impact.

16 AmerGen indicated that a peak construction workforce of 169 workers would be required to  
17 construct this alternative (AmerGen 2008). After construction, local communities may be  
18 temporarily affected by the loss of the construction jobs and associated loss in demand for  
19 business services, and the rental housing market could experience increased vacancies and  
20 decreased prices. The impact of construction on socioeconomic conditions would be SMALL.

21 Following construction, a single unit gas-fired combination alternative could provide up to nine  
22 jobs, based on AmerGen estimates, or up to 44 jobs based on an extrapolated estimate from  
23 the GEIS. Socioeconomic impacts associated with the operation of a single unit natural-gas-  
24 fired power plant would be SMALL.

### 25 Transportation

26 Transportation impacts associated with construction and operation of a single unit gas-fired  
27 power plant under the combination alternative would consist of commuting workers and truck  
28 deliveries of construction materials to the TMI-1 worksite. These vehicles would increase the  
29 overall number of vehicles on local roads. Pipeline construction and modification to existing  
30 natural gas pipeline systems may also have an additional, short-term impact.

31 Conversely, transportation impacts would almost disappear during plant operations. The  
32 estimated number of operating personnel would be approximately nine workers, although, the  
33 GEIS indicates that as many as 44 operations workers could be required. Since fuel would be  
34 transported by pipeline, the transportation infrastructure would experience little to no increased  
35 use from plant operations. Overall, the combination alternative would have a SMALL impact on  
36 transportation conditions in the region around TMI-1.

### 37 Aesthetics

38 As discussed in Section 8.1, aesthetic resources are the natural and man-made features that  
39 give a particular landscape its character and aesthetic quality. The aesthetics impact analysis  
40 focuses on the degree of contrast between the power plant and the surrounding landscape and  
41 the visibility of the power plant.

1 A single natural gas-fired unit located at TMI-1 could be approximately 100 ft (30 m) tall, with an  
 2 exhaust stack of at least 175 ft (53 m) tall. The impact would be moderated as higher elevations  
 3 and vegetation along the river valley could make it difficult to see or hear the power plant  
 4 outside of the river valley. The alternative power plant infrastructure would generally be smaller  
 5 and less noticeable than the current TMI-1 containment and cooling tower. The mechanical draft  
 6 cooling towers would be markedly shorter than the natural-draft towers located at TMI-1, but  
 7 they would also generate condensate plumes and operational noise. Noise during power plant  
 8 operations would be limited to industrial processes and communications.

9 In addition to the power plant structures, construction of natural gas pipelines would have a  
 10 short-term impact. Noise from the pipelines could be audible offsite near compressors.

11 In general, aesthetic changes would be limited to the immediate vicinity of TMI-1; therefore  
 12 aesthetic impacts would be SMALL.

13 Historic and Archaeological Resources

14 As discussed in Section 8.2.6, depending on the resource richness of the site ultimately chosen  
 15 for the gas-fired single unit as part of the combination alternative, impacts will range from  
 16 SMALL to MODERATE.

17 Environmental Justice

18 The environmental justice impact analysis evaluates the potential for disproportionately high and  
 19 adverse human health and environmental effects on minority and low-income populations that  
 20 could result from the construction and operation of a single unit natural gas-fired power plant  
 21 and uprates to existing hydroelectric dams. Adverse health effects are measured in terms of the  
 22 risk and rate of fatal or nonfatal adverse impacts on human health. Disproportionately high and  
 23 adverse human health effects occur when the risk or rate of exposure to an environmental  
 24 hazard for a minority or low-income population is significant and exceeds the risk or exposure  
 25 rate for the general population or for another appropriate comparison group. The minority and  
 26 low-income populations are subsets of the general public residing around the site, all of whom  
 27 are exposed to the same hazards generated from power plant operations.

28 Minority and low-income populations could be affected by the construction and operation of a  
 29 new single unit natural gas-fired combined-cycle generation power plant at TMI-1. Some of  
 30 these effects have been identified in resource areas discussed in this section. Effects on  
 31 minority and low-income populations in the vicinity of TMI-1 would vary from construction to  
 32 operations. Increased localized rental housing demand during construction in some locations  
 33 could disproportionately affect low-income populations. The impacts on minority and low-income  
 34 populations from the combination alternative would likely be SMALL.  
 35

36 **8.4.7 Waste Management**

37 As discussed in Sections 8.2.7 and 8.3.7, NRC staff concluded in the GEIS that gas-fired  
 38 technology waste generation would be minimal (NRC 1996) and the waste impacts would be  
 39 SMALL for a natural gas-fired combined-cycle plant sited at TMI-1 or at an alternate site; and  
 40 impacts from a conservation alternative would be SMALL. Overall, the waste impacts from the  
 41 combination alternative would be SMALL.

## Alternatives

### 1 **8.5 Purchased Power**

2 AmerGen participates in the PJM Interconnection. This restructured energy supply system  
3 allows for the sale of energy across parts of 13 States and the District of Columbia (PJM 2008).  
4 Across the PJM, coal is the predominant fuel used for generation, accounting for 55.3 percent in  
5 2007, followed by nuclear (33.9 percent), natural gas (7.7 percent), hydroelectric (1.7 percent),  
6 oil (0.5 percent), solid waste (0.7 percent), and wind (0.2 percent) (PJM 2008). Many of PJM's  
7 gas-fired units are actually able to burn fuel oil, as well, although gas utilization is much higher  
8 due to lower costs and emissions. Given the size and flexibility of PJM, the NRC staff considers  
9 it likely that purchased power could reasonably replace TMI-1.

10 Impacts would likely be similar to those of the above options located at alternate sites. If power  
11 purchases cause currently existing capacity to operate at higher capacity factors, however,  
12 rather than triggering new construction, then construction stage impacts would be eliminated. It  
13 is likely, then, that purchased power would come from older, less efficient plants than those  
14 considered in this chapter, from plants with once-through cooling, or from plants without modern  
15 emissions controls. Accordingly, impacts are difficult to quantify, although they are likely similar  
16 to those of other alternatives considered in Sections 8.2 through 8.4 in this draft supplemental  
17 EIS, as well as in the GEIS.

18 Given the location of TMI-1, it is unlikely that purchased power from outside the U.S. could  
19 replace TMI-1 capacity, regardless of whether either country has sufficient existing export  
20 capacity.

21 Since purchased power may come from a variety of generating resources, including coal,  
22 natural gas, nuclear, hydroelectric, and perhaps oil-fired installations (where impacts in previous  
23 NRC documents, including the supplemental EIS and the GEIS, were determined to be similar  
24 to or larger than those of natural-gas fired generation), NRC staff evaluation indicates that  
25 impacts from the purchased power alternative would be greater than the impacts of license  
26 renewal, and within the range of other alternatives considered in this chapter.

27

### 28 **8.6 Alternatives Considered but Dismissed**

29 In this section, the NRC staff presents the alternatives it initially considered for analysis as  
30 alternatives to license renewal of TMI-1, but later dismissed due to technical, resource  
31 availability, or commercial limitations that currently exist and that the NRC staff believes are  
32 likely to continue to exist when the existing TMI-1 license expires. Under each of the following  
33 technology headings, the NRC staff indicates why it dismissed each alternative from further  
34 consideration.

35

#### 36 **8.6.1 Coal-Fired Integrated Gasification Combined-Cycle**

37 While utilities across the U.S. have considered or are considering plans for integrated  
38 gasification combined-cycle (IGCC) coal-fired power plants, few IGCC facilities have yet been  
39 constructed. All facilities constructed in the U.S. to date have been smaller than TMI-1.



1 The technology, however, is commercially available and essentially relies on a gasifier stage  
2 and a combined-cycle turbine stage. Existing combined-cycle gas turbines (like the ones  
3 considered in Section 8.2) could be used as part of an IGCC alternative.

4 EIA indicates that IGCC and other advanced coal plants may become increasingly common in  
5 coming years (EIA 2008a, 2008b), though uncertainties about construction time periods and  
6 commercial viability in the near future leads NRC staff to believe that IGCC is an unlikely  
7 alternative to TMI-1 license renewal. For plants whose licenses expire at later dates, IGCC  
8 (with or without carbon capture and storage) may prove to be a viable alternative, though NRC  
9 did not evaluate IGCC as an alternative to TMI-1 license renewal.

10

### 11 **8.6.2 New Nuclear**

12 In its ER, AmerGen indicated that it is unlikely that a nuclear alternative could be sited,  
13 constructed and operational by the time the TMI-1 operating license expires in 2014 (AmerGen  
14 2008). Sources in the nuclear industry have recently indicated that reactor projects currently  
15 under development are likely eight or nine years from completion (Nucleonics Week 2008), or  
16 possibly online in the 2016-2017 timeframe. While several new reactor proposals currently  
17 under development or undergoing NRC review are within the footprint of PJM, they are unlikely  
18 to be available prior to the expiration of the TMI-1 operating license. Further, potential plant  
19 owners or operators wishing to submit a new proposal specifically to offset the capacity of TMI-1  
20 would require additional time to develop an application. Given the relatively short time  
21 remaining on the current TMI-1 operating license, NRC staff has not evaluated new nuclear  
22 generation as an alternative to license renewal.

23

### 24 **8.6.3 Wind Power**

25 Windpower, by itself, is not suitable for large baseload capacity. As discussed in Section 8.3.1  
26 of the GEIS, wind has a high degree of intermittency and low average annual capacity factors  
27 (up to 30 to 40 percent). Windpower, in conjunction with energy storage mechanisms or another  
28 readily dispatchable power source, like hydropower, could serve as a means of providing  
29 baseload power. Current energy storage technologies are too expensive for windpower to serve  
30 as a large baseload generator.

31 The Commonwealth of Pennsylvania is mostly a windpower Class 1 region, although some  
32 areas, particularly along ridgelines, may provide wind classes ranging from 4 to 6 (DOE 2003).  
33 Wind turbines are economical in windpower Classes 4 through 7, which have average  
34 windspeeds of 12.5 to 21.1 miles per hour (20 to 34 kilometers per hour) (DOE 2007).

35 Through the end of 2007, operators had installed 294 MWe in Pennsylvania (DOE 2008). While  
36 installed windpower capacity is relatively low, windpower installation in Pennsylvania has  
37 accelerated in recent years. As noted by the NRC staff in the draft SEIS for the Susquehanna  
38 Steam Electric Station, PJM has a maximum potential of 6,658 MWe of wind capacity with an  
39 achievable potential of 665 MWe to 1,995 MWe. Given that this capacity will function at a 30–  
40 40-percent capacity factor, it is unlikely that there will be sufficient windpower potential to  
41 replace TMI-1.

## Alternatives

1 Therefore, the NRC staff does not consider windpower to be a stand-alone alternative to TMI-1  
2 license renewal.  
3

### 4 **8.6.4 Solar Power**

5 Solar technologies use the sun's energy to produce electricity. Currently, the TMI-1 site receives  
6 approximately 4 to 4.5 kWh per square meter per day (approximately 0.4 kWh of solar radiation  
7 per square foot per day), as does much of Pennsylvania (NREL 2008), for solar collectors  
8 oriented at an angle equal to the installation's latitude. Since flat-plate photovoltaics tend to be  
9 roughly 25 percent efficient, a solar-powered alternative will require at least 3,590 to 4,040 ac  
10 (1,450 to 1,640 ha) of collectors to provide an amount of electricity equivalent to that generated  
11 by TMI-1. Space between parcels and associated infrastructure increase this land requirement.  
12 This amount of land, while large, is consistent with the land required for coal and natural gas  
13 fuel cycles. In the GEIS, the NRC staff noted that, by its nature, solar power is intermittent (i.e.,  
14 it does not work at night and cannot serve baseload when the sun is not shining), and the  
15 efficiency of collectors varies greatly with weather conditions. A solar-powered alternative will  
16 require energy storage or a backup power supply to provide electric power at night. Given the  
17 challenges in meeting baseload requirements, the NRC staff did not evaluate solar power as an  
18 alternative to license renewal of TMI-1.  
19

### 20 **8.6.5 Wood Waste**

21 In 1999, DOE researchers estimated that Pennsylvania has biomass fuel resources consisting  
22 of urban, mill, agricultural, and forest residues, as well as speculative potential for energy crops.  
23 Excluding potential energy crops, DOE researchers projected that Pennsylvania had 5,090,000  
24 tons (4,617,570 MT) of plant-based biomass available at \$50 per ton delivered (Walsh et al.  
25 2000; costs are in 1995 dollars). The Bioenergy Feedstock Development Program at Oak Ridge  
26 National Laboratory estimated that each air-dry pound of wood residue produces approximately  
27 6,400 Btu of heat (ORNL 2007). Assuming a 33 percent conversion efficiency, using all biomass  
28 available in Pennsylvania at \$50 per ton—the maximum price the researchers considered—  
29 would generate roughly 6.3 terawatt hours of electricity. This is roughly the same as the amount  
30 of electrical energy produced by TMI-1 operating at 85 percent capacity for one year.

31 Walsh et al. (2000), go on to note that these estimates of biomass capacity contain substantial  
32 uncertainty, and that potential availability does not mean biomass will actually be available at  
33 the prices indicated or that resources will be useably free of contamination. Some of these plant  
34 wastes already have reuse value, and would likely be more costly to deliver because of  
35 competition. Others, such as forest residues, may prove unsafe and unsustainable to harvest on  
36 a regular basis. As a result, the available resource potential is likely less than the estimated  
37 totals in Walsh et al., and the total resource is not likely to be sufficient to substitute for the  
38 capacity provided by TMI-1. As a result, the NRC staff has not considered a wood-fired  
39 alternative to TMI-1 license renewal.  
40

### 1 **8.6.6 Conventional Hydroelectric Power**

2 According to researchers at Idaho National Energy and Environmental Laboratory,  
3 Pennsylvania has an estimated 2,217 MW of technically available, undeveloped hydroelectric  
4 resources at 104 sites throughout the State (INEEL 1997). This amount occurs primarily in small  
5 installations generating 10 MWe or less, though one site in Pennsylvania is capable of providing  
6 at least 100 MWe. These sites are scattered widely across the state, with a significant number  
7 in the Susquehanna River Basin region. The NRC staff notes that the total available hydropower  
8 potential is greater than the capacity considered for the other alternatives to license renewal of  
9 TMI-1, although INEEL indicates that many sites may not be available for development for a  
10 variety of reasons. Given the large numbers of individual installations needed to replace the  
11 TMI-1 capacity and the uncertainty surrounding available resource potential, the NRC staff did  
12 not evaluate hydropower as an alternative to license renewal. The NRC does, however,  
13 consider that the portion of this potential capacity that is available through uprates at existing  
14 hydroelectric facilities could play a role in a combination alternative in Section 8.4.  
15

### 16 **8.6.7 Wave and Ocean Energy**

17 Wave and ocean energy has generated considerable interest in recent years. Ocean waves,  
18 currents, and tides are often predictable and reliable. Ocean currents flow consistently, while  
19 tides can be predicted months and years in advance with well-known behavior in most coastal  
20 areas. Most of these technologies are in relatively early stages of development, and while some  
21 results have been promising, they are not likely to be able to replace the capacity of TMI-1 by  
22 the time its license expires. The NRC staff has previously evaluated the potential for wave or  
23 ocean energy to provide an alternative to license renewal for the Oyster Creek Nuclear  
24 Generating Station (OCNGS) in New Jersey, also part of PJM and located on the coast. In  
25 2007, the NRC staff concluded that wave and ocean energy could not provide a feasible  
26 alternative to license renewal at OCNGS, a smaller plant than TMI-1 (NRC 2007). While testing  
27 of new technologies to produce electricity from the ocean continues, the NRC has not yet seen  
28 technological advances significant enough to consider wave and ocean energy as an alternative  
29 to TMI-1 license renewal.  
30

### 31 **8.6.8 Geothermal Power**

32 Geothermal energy has an average capacity factor of 90 percent and can be used for baseload  
33 power where available. However, geothermal electric generation is limited by the geographical  
34 availability of geothermal resources (NRC 1996). As illustrated by Figure 8.4 in the GEIS, no  
35 feasible eastern location for geothermal capacity exists to serve as an alternative to TMI-1. The  
36 NRC staff concluded that geothermal energy is not a reasonable alternative to license renewal  
37 at TMI-1.  
38

### 39 **8.6.9 Municipal Solid Waste**

40 Municipal solid waste combustors incinerate waste to produce steam, hot water, or electricity.  
41 Combustors use three types of technologies—mass burn, modular, and refuse-derived fuel.

## Alternatives

1 Mass burning is currently the method used most frequently in the United States and involves no  
2 (or little) sorting, shredding, or separation. Consequently, toxic or hazardous components  
3 present in the waste stream are combusted, and toxic constituents are exhausted to the air or  
4 become part of the resulting solid wastes. Currently, approximately 89 waste-to-energy plants  
5 operate in the United States. These plants generate approximately 2,700 MWe, or an average  
6 of approximately 30 MWe per plant (Integrated Waste Services Association 2007). More than  
7 25 average-sized plants will be necessary to provide the same level of output as the other  
8 alternatives to TMI-1 license renewal.

9 Estimates in the GEIS suggest that the overall level of construction impact from a waste-fired  
10 plant will be approximately the same as that for a coal-fired power plant. Additionally, waste-  
11 fired plants have the same or greater operational impacts than coal-fired technologies (including  
12 impacts on the aquatic environment, air, and waste disposal). The initial capital costs for  
13 municipal solid-waste plants are greater than for comparable steam-turbine technology at coal-  
14 fired facilities or at wood-waste facilities because of the need for specialized waste separation  
15 and handling equipment (NRC 1996).

16 The decision to burn municipal waste to generate energy is usually driven by the need for an  
17 alternative to landfills rather than energy considerations. The use of landfills as a waste disposal  
18 option is likely to increase in the near term as energy prices increase; however, it is possible  
19 that municipal waste combustion facilities may become attractive again.

20 Regulatory structures that once supported municipal solid waste incineration no longer exist.  
21 For example, the Tax Reform Act of 1986 made capital-intensive projects such as municipal  
22 waste combustion facilities more expensive relative to less capital-intensive waste disposal  
23 alternatives such as landfills. Also, the 1994 Supreme Court decision *C&A Carbone, Inc. v.*  
24 *Town of Clarkstown, New York*, struck down local flow control ordinances that required waste to  
25 be delivered to specific municipal waste combustion facilities rather than landfills that may have  
26 had lower fees. In addition, environmental regulations have increased the capital cost necessary  
27 to construct and maintain municipal waste combustion facilities.

28 Given the small average installed size of municipal solid waste plants and the unfavorable  
29 regulatory environment, the NRC staff does not consider municipal solid waste combustion to  
30 be a feasible alternative to TMI-1 license renewal.

31

### 32 **8.6.10 Biofuels**

33 In addition to wood and municipal solid-waste fuels, there are other concepts for biomass-fired  
34 electric generators, including direct burning of energy crops, conversion to liquid biofuels, and  
35 biomass gasification. In the GEIS, the NRC staff indicated that none of these technologies had  
36 progressed to the point of being competitive on a large scale or of being reliable enough to  
37 replace a baseload plant such as TMI-1. After reevaluating current technologies, the NRC staff  
38 believes other biomass-fired alternatives are still unable to reliably replace the TMI-1 capacity.  
39 For this reason, the NRC staff does not consider other biomass-derived fuels to be feasible  
40 alternatives to TMI-1 license renewal.

41

### 1 **8.6.11 Oil-Fired Power**

2 EIA projects that oil-fired plants will account for very little of the new generation capacity  
3 constructed in the United States during the 2007 to 2030 time period. Further, EIA does not  
4 project that oil-fired power will account for any significant additions to capacity (EIA 2008a).

5 The variable costs of oil-fired generation tend to be greater than those of the nuclear or coal-  
6 fired options, and oil-fired generation tends to have greater environmental impacts than natural-  
7 gas-fired generation. In addition, future increases in oil prices are expected to make oil-fired  
8 generation increasingly more expensive. The high cost of oil has prompted a steady decline in  
9 its use for electricity generation. Thus the NRC staff did not consider oil-fired generation as an  
10 alternative to TMI-1 license renewal.

11

### 12 **8.6.12 Fuel Cells**

13 Fuel cells oxidize fuels without combustion and its environmental side effects. Power is  
14 produced electrochemically by passing a hydrogen-rich fuel over an anode and air (or oxygen)  
15 over a cathode and separating the two by an electrolyte. The only byproducts (depending on  
16 fuel characteristics) are heat, water, and CO<sub>2</sub>. Hydrogen fuel can come from a variety of  
17 hydrocarbon resources by subjecting them to steam under pressure. Natural gas is typically  
18 used as the source of hydrogen.

19 At the present time, fuel cells are not economically or technologically competitive with other  
20 alternatives for baseload electricity generation. EIA projects that fuel cells may cost \$5,374 per  
21 installed kW (total overnight costs) (EIA 2008b), or 3.5 times the construction cost of new coal-  
22 fired capacity and 7.5 times the cost of new, advanced gas-fired, combined-cycle capacity. In  
23 addition, fuel cell units are likely to be small in size (the EIA reference plant is 10 MWe). While it  
24 may be possible to use a distributed array of fuel cells to provide an alternative to TMI-1, it  
25 would be extremely costly to do so. Accordingly, the NRC staff does not consider fuel cells to be  
26 an alternative to TMI-1 license renewal.

27

### 28 **8.6.13 Delayed Retirement**

29 Neither AmerGen nor its parent company, Exelon, has any plans to retire generating capacity  
30 within PJM (AmerGen 2008). As a result, delayed retirement is not a feasible alternative to  
31 license renewal. Other generation capacity may be retired within PJM prior to the expiration of  
32 the TMI-1 license, but this capacity is likely to be older, less efficient, and without modern  
33 emissions controls.

34

## 35 **8.7 No-Action Alternative**

36 This section will examine the environmental effects that will occur if NRC takes no action. No  
37 action in this case means that the NRC does not issue a renewed operating license for TMI-1,  
38 and the license expires at the end of the current license term, in April 2014. If the NRC takes no  
39 action, the plant will shutdown at or before the end of the current license. After shutdown, plant  
40 operators will initiate decommissioning according to 10 CFR 50.82, "Termination of License."

## Alternatives

1 Table 8-5 below contains a summary of the environmental impacts of the no-action alternative  
2 compared to continued operation of TMI-1.

3 We note that no action is the only alternative that we consider in-depth that does not satisfy the  
4 purpose and need for this draft supplemental EIS, as it does not provide power generation  
5 capacity. Furthermore, it would not meet the needs currently met by TMI-1, or the alternatives  
6 evaluated in sections 8.1 through 8.4. Assuming that a need currently exists for the power  
7 generated by TMI-1, the no-action alternative would require the appropriate energy planning  
8 decisionmakers to rely on an alternative to replace the capacity of TMI-1 or reduce the need for  
9 power.

10 In this section, we address only those impacts that arise directly as a result of plant shutdown.  
11 The NRC already addressed— in several other documents— environmental impacts from  
12 decommissioning and related activities. These documents include the *Final Generic*  
13 *Environmental Impact Statement on Decommissioning of Nuclear Facilities*, NUREG 0586,  
14 Supplement 1 (NRC 2002); the license renewal GEIS (Chapter 7; NRC 1996); and Chapter 7 of  
15 this draft supplemental EIS. These analyses either directly address or bound the environmental  
16 impacts of decommissioning whenever AmerGen ceases operating TMI-1.

17 We note that, even with a renewed operating license, TMI-1 will eventually shut down, and the  
18 environmental effects we address in this section will occur at that time. Since these effects have  
19 not otherwise been addressed in this draft supplemental EIS, we will address the impacts in this  
20 section. We expect that— as with decommissioning effects— shutdown effects will be similar  
21 whether they occur at the end of the current license or at the end of a renewed license.

22 **Table 8-5. Summary of Environmental Impacts of the No Action Alternative**  
23 **Compared to Continued Operation of TMI-1.**

	No Action		Continued TMI-1 Operation
	At TMI-1 site	At alternate site	
<b>Air Quality</b>	SMALL	N/A	SMALL
<b>Ground Water</b>	SMALL	N/A	SMALL
<b>Surface Water</b>	SMALL	N/A	SMALL
<b>Aquatic and Terrestrial Resources</b>	SMALL	N/A	SMALL
<b>Human Health</b>	SMALL	N/A	SMALL
<b>Socioeconomics</b>	SMALL to MODERATE	N/A	SMALL
<b>Waste Management</b>	SMALL	N/A	N/A

24

### 25 **8.7.1 Air Quality**

26 When the plant stops operating, there will be a reduction in emissions from activities related to  
27 plant operation, such as use of diesel generators and employees' vehicles. In Chapter 4, the  
28 NRC staff determined that these emissions would have a SMALL impact on air quality during  
29 the renewal term. Therefore, if the emissions decrease, the impact to air quality would also  
30 decrease and would be SMALL.

31

## 1 **8.7.2 Ground Water Use and Quality**

2 The use of groundwater would diminish as plant personnel are removed from the site and  
3 operations cease. Some consumption of groundwater may continue as a small staff remains  
4 onsite to maintain facilities prior to decommissioning. Overall impacts would be smaller than  
5 during operations, but would remain SMALL.  
6

## 7 **8.7.3 Surface Water Use and Quality**

8 The rate of consumptive use of surface water would decrease as the plant is shut down and the  
9 reactor cooling system continues to remove the heat of decay. Wastewater discharges would  
10 also be reduced considerably. Shutdown would reduce the already SMALL impact on surface  
11 water resources and quality.  
12

## 13 **8.7.4 Aquatic and Terrestrial Ecology**

### 14 Terrestrial Ecology

15 Terrestrial ecology impacts would be SMALL. No additional land disturbances on or offsite  
16 would occur.

### 17 Aquatic Ecology

18 If the plant were to cease operating, impacts to aquatic ecology would decrease, as the plant  
19 would withdraw and discharge less water than it does during operations. Shutdown would  
20 reduce the already SMALL impacts to aquatic ecology.  
21

## 22 **8.7.5 Human Health**

23 Human health risks would be smaller following plant shutdown. The plant, which is currently  
24 operating within regulatory limits, would emit less gaseous and liquid radioactive material to the  
25 environment. In addition, following shutdown, the variety of potential accidents at the plant  
26 (radiological or industrial) would be reduced to a limited set associated with shutdown events  
27 and fuel handling and storage. In Chapter 4 of this draft supplemental EIS, the NRC staff  
28 concluded that the impacts of continued plant operation on human health would be SMALL. In  
29 Chapter 5, the NRC staff concluded that the impacts of accidents during operation were SMALL.  
30 Therefore, as radioactive emissions to the environment decrease, and as the likelihood and  
31 variety of accidents decrease following shutdown, the NRC staff concludes that the risks to  
32 human health following plant shutdown would be SMALL.

33 In addition, the no-action alternative would require TMI-1 to initiate decommissioning activities.  
34 Environmental impacts from the activities associated with the decommissioning of any reactor  
35 before or at the end of an initial or renewed license are evaluated in the *Generic Environmental*  
36 *Impact Statement for Decommissioning of Nuclear Facilities: Supplement 1, Regarding the*  
37 *Decommissioning of Nuclear Power Reactors*, NUREG-0586, Supplement 1 (NRC 2002). The  
38 NRC's evaluation of the environmental impacts of decommissioning presented in NUREG-0586,  
39 Supplement 1, identifies a range of impacts for each environmental issue including human  
40 health risks. Based on information in the GEIS (NRC 1996) along with the information in

## Alternatives

1 Chapter 7 of this draft supplemental EIS, the Commission found that doses to the public will be  
2 well below applicable regulatory standards regardless of which decommissioning method is  
3 used. Occupational doses would increase no more than 1 person-rem caused by buildup of  
4 long-lived radionuclides during the license renewal term. Therefore, the human health risks to  
5 an occupational worker and to a member of the public, from the decommissioning of TMI-1, due  
6 to the no-action alternative, would be SMALL.  
7

### 8 **8.7.6 Socioeconomics**

#### 9 Land Use

10 Plant shutdown will not affect onsite land use. Plant structures and other facilities will likely  
11 remain in place until decommissioning. Most transmission lines at TMI-1 will remain in service  
12 after the plant stops operating. Maintenance of most existing transmission lines will continue as  
13 before. The NRC staff expects the impacts on land use from plant shutdown to be SMALL.

#### 14 Socioeconomics

15 Plant shutdown will have a minimal impact on socioeconomic conditions in the region around  
16 TMI-1, primarily because of the plant's proximity to the Harrisburg-Carlisle metropolitan  
17 statistical area and its relatively small contribution to local services. Plant shutdown will  
18 eliminate up to 525–695 jobs and will reduce tax revenue in the region, though the TMI-1  
19 contributions to local taxing jurisdictions are a small percentage of total revenue for each of the  
20 jurisdictions discussed in Chapter 4 of this draft SEIS. The loss of these contributions, which  
21 may not entirely cease until after decommissioning, will have a SMALL impact, although job  
22 losses could increase the impact level slightly. Overall, the staff expects the impacts of plant  
23 shutdown to be SMALL to MODERATE. See Appendix J to NUREG 0586, Supplement 1 (NRC  
24 2002), for additional discussion of the potential socioeconomic impacts of plant  
25 decommissioning.

#### 26 Transportation

27 Traffic volumes on the roads in the vicinity of TMI-1 will decline after plant shutdown. Most of the  
28 reduction in traffic volume will be associated with the loss of jobs. The shipment of material to  
29 and from the plant will be reduced before decommissioning. Transportation impacts will be  
30 SMALL as a result of plant shutdown. Transportation impacts will increase if a new reactor or  
31 alternative energy facility is constructed on the TMI-1 site or in the immediate vicinity. Such  
32 impacts will be SMALL to MODERATE, but of short duration.

#### 33 Aesthetics

34 Plant structures and other facilities will likely remain in place until decommissioning, although  
35 plumes from the plant's cooling towers are likely to disappear entirely. Noise caused by plant  
36 operation will cease. The NRC staff concludes that the aesthetic impacts of plant closure will be  
37 SMALL.

#### 38 Historic and Archaeological Resources

39 Impacts from the no-action alternative would be SMALL, since TMI-1 would be decommissioned  
40 with no alternative power plant to replace it. A separate environmental review would be



1 conducted for decommissioning. That assessment will address the protection of historic and  
2 archaeological resources.

### 3 Environmental Justice

4 Plant shutdown is unlikely to disproportionately affect minority and low-income populations.  
5 Impacts to all other resource areas would be SMALL to MODERATE. The communities in the  
6 immediate vicinity of TMI-1 do not have large populations of minority or low-income residents.  
7 Minority and low-income populations are generally concentrated in the urban areas of  
8 Harrisburg, Lancaster, and York. Thus, impacts from plant shutdown are likely to be SMALL.  
9 See Appendix J of NUREG 0586, Supplement 1 (NRC 2002), for additional discussion of these  
10 impacts.  
11

### 12 **8.7.7 Waste Management**

13 After implementation of the no-action alternative, generation of high-level waste would stop and  
14 generation of low-level and mixed waste would decrease. Impacts from implementation of the  
15 no-action alternative are expected to be SMALL.  
16

## 17 **8.8 Alternatives Summary**

18 In this chapter, we considered the following alternatives to TMI-1 license renewal: supercritical  
19 coal-fired generation, natural gas combined-cycle generation, energy conservation and energy  
20 efficiency, and a combination alternative. We also considered no action by the NRC and the  
21 effects it would have. The impacts for all alternatives are summarized in Table 8-6 on the  
22 following page.

23 The environmental impacts of the proposed action (issuing a renewed TMI-1 operating license)  
24 would be SMALL for all impact categories, except for the Category 1 issues of collective offsite  
25 radiological impacts from the fuel cycle, high level waste (HLW), and spent fuel disposal. The  
26 NRC staff did not assign a single significant level to these impacts, but the Commission  
27 determined them to be Category 1 issues nonetheless.

28 The coal-fired alternative is the least environmentally favorable alternative due to impacts to air  
29 quality from nitrogen oxides, sulfur oxides, particulate matter, PAHs, carbon monoxide, carbon  
30 dioxide, and mercury (and the corresponding human health impacts); and construction impacts  
31 to aquatic, terrestrial, and potential historic and archaeological resources. The gas-fired  
32 alternative would have slightly lower air emissions, and impacts to aquatic, terrestrial, and  
33 historic and archaeological resources would vary depending upon location of the plant.  
34 Purchased power would likely have operational impacts that would include aspects of coal-fired,  
35 gas-fired, and existing nuclear generation.

36 The NRC notes that the energy conservation/energy efficiency alternative has SMALL impacts  
37 in all categories evaluated, and upon shut down of TMI-1, current operating impacts of TMI-1  
38 would cease. Therefore, the energy conservation/energy efficiency alternative is the  
39 environmentally preferred alternative to license renewal. All other alternatives capable of  
40 meeting the needs currently served by TMI-1 entail potentially greater impacts than the  
41 proposed action of license renewal of TMI-1. The no-action alternative does not meet the

Alternatives

1 purpose and need of this draft SEIS, however if it triggers the energy conservation/energy  
 2 efficiency action to replace the capacity currently supplied by TMI-1, it could result in an overall  
 3 SMALL impact, as well.

4

5 **Table 8-6. Summary of Environmental Impacts of Selected Alternatives**  
 6 **Compared to Continued Operation of TMI-1.**

Alternative	Impact Area						
	Air Quality	Ground Water	Surface Water	Aquatic and Terrestrial Resources	Human Health	Socioeconomic s	Waste Management
<b>License Renewal</b>	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL	N/A
<b>Supercritical coal-fired alternative at a new site</b>	MODERATE	SMALL	SMALL	SMALL to LARGE	SMALL to MODERATE	SMALL to LARGE	SMALL
<b>Gas-fired alternative at the TMI-1 site</b>	MODERATE	SMALL	SMALL	SMALL	SMALL	SMALL to MODERATE	SMALL
<b>Gas-fired alternative at a new site</b>	MODERATE	SMALL	SMALL	SMALL to LARGE	SMALL	SMALL to MODERATE	SMALL
<b>Energy Conservation/ Energy Efficiency</b>	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL
<b>Combination of Alternatives</b>	SMALL to MODERATE	SMALL	SMALL	SMALL	SMALL	SMALL to MODERATE	SMALL
<b>No Action Alternative</b>	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL to MODERATE	SMALL

7

8

## 1 8.9 References

- 2 10 CFR 50. *Code of Federal Regulations*, Title 10, *Energy*, Part 50, “Domestic Licensing of  
3 Production and Utilization Facilities.”
- 4 10 CFR 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, “Environmental Protection  
5 Regulations for Domestic Licensing and Related Regulatory Functions.”
- 6 36 CFR 800. *Code of Federal Regulations*, Title 36, *Parks, Forests, and Public Property*, Part  
7 800, “Protection of Historic Properties.”
- 8 36 CFR Part 60. *Code of Federal Regulations*, Title 36, *Parks, Forests, and Public Property*,  
9 Part 60, Section 4, “Criteria for Evaluation.”
- 10 40 CFR 51. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 51,  
11 “Requirements for Preparation, Adoption, and Submittal of Implementation Plans.”
- 12 40 CFR 60. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 60,  
13 “Standards of Performance for New Stationary Sources.”
- 14 63 FR 49442. Environmental Protection Agency, Washington, D.C, “Revision of Standards of  
15 Performance for Nitrogen Oxide Emissions From New Fossil-Fuel Fired Steam Generating  
16 Units; Revisions to Reporting Requirements for Standards of Performance for New Fossil-Fuel  
17 Fired Steam Generating Units.” *Federal Register*. Vol. 63, NO. 179, pp. 49422–49455.  
18 September 16, 1998.
- 19 64 FR 35714. Environmental Protection Agency, Washington, D.C, “40 CFR Part 51, Regional  
20 Haze Regulations, Final Rule.” *Federal Register*. Vol. 64, No. 126, pp. 35714–35774. July 1,  
21 1999.
- 22 65 FR 32214. Environmental Protection Agency, Washington, D.C., “40 CFR Part 261, Notice of  
23 Regulatory Determination on Wastes from the Combustion of Fossil Fuels.” *Federal Register*.  
24 Vol. 65, No. 99, pp. 32214–32237. May 22, 2000.
- 25 ACAA (American Coal Ash Association). 2007. “ACAA Releases 2006 CCP Production and Use  
26 Survey.” August. Aurora, CO. Available URL: [http://www.acaa-  
27 usa.org/associations/8003/files/2006\\_CCP\\_Survey\\_\(Final-8-24-07\).pdf](http://www.acaa-usa.org/associations/8003/files/2006_CCP_Survey_(Final-8-24-07).pdf) (accessed October 14,  
28 2008). ADAMS No. ML082880731.
- 29 Air Pollution Control Act. 35 P.S. §§ 4001–4015. *Pennsylvania Statutes*, Title 35, *Health and  
30 Safety*, Chapter 23, “Air Pollution.”
- 31 AmerGen (AmerGen Energy Company, LLC). 2008. “Three Mile Island Nuclear Station,  
32 Applicant’s Environmental Report, License Renewal Operating Stage.” Kennett Square, PA.  
33 ADAMS Nos. ML080220255, ML080220257, ML080220261, and ML080220282.
- 34 ATSDR (Agency for Toxic Substances and Disease Registry). 1995. *Toxicological Profile for  
35 Polycyclic Aromatic Hydrocarbons (PAHs)*. Public Health Service, U.S. Department of Health  
36 and Human Services, Atlanta, GA.

## Alternatives

- 1 ATSDR (Agency for Toxic Substances and Disease Registry). 1999. *Toxicological Profile for*  
2 *Mercury*. Public Health Service, U.S. Department of Health and Human Services. Atlanta, GA.
- 3 California Environmental Protection Agency (CalEPA). 1997. *Air Toxics Hot Spots Program Risk*  
4 *Assessment Guidelines: Technical Support Document for Determining Cancer Potency Factors.*  
5 *Draft for Public Comment*. Office of Environmental Health Hazard Assessment. Berkeley, CA.
- 6 *Clean Air Act*. 42 U.S.C. 7401, et seq. *United States Code*, Title 42, *The Public Health and*  
7 *Welfare*, Chapter 85, "Air Pollution Prevention and Control."
- 8 Darby, S. C. December 1989. "Health Risks of Radon and Other Internally Deposited Alpha-  
9 Emitters-BEIR IV". *Biometrics* 45 (4): 1341–1342. National Research Council.
- 10 DOE (U.S. Department of Energy). 2008. "Installed U.S. Wind Capacity and Wind Project  
11 Locations." Interactive Maps. February 26, 2008. Available URL:  
12 [http://www.eere.energy.gov/windandhydro/windpoweringamerica/wind\\_installed\\_capacity.asp](http://www.eere.energy.gov/windandhydro/windpoweringamerica/wind_installed_capacity.asp)  
13 (accessed April 18, 2008).
- 14 EIA (Energy Information Administration). 2006. "Cost and Quality of Fuel for Electric Plants,  
15 2004 and 2005." DOE/EIA 0191(2006). Washington, D.C. Available URL:  
16 <http://www.eia.doe.gov/cneaf/electricity/cq/cqa2005.pdf> (accessed March 16, 2007). ADAMS  
17 No. ML082880730.
- 18 EIA (U.S. Department of Energy, Energy Information Administration). 2007. "Summary Statistics  
19 for the United States." Table ES1 from Electric Power Annual with data for 2006. Accessed at:  
20 <http://www.eia.doe.gov/cneaf/electricity/epa/epates.html> (accessed June 11, 2008). ADAMS No.  
21 ML082880730.
- 22 EIA (U.S. Department of Energy, Energy Information Administration). 2008a. *Annual Energy*  
23 *Outlook 2008 With Projections to 2030*. DOE/EIA 0383(2008). Washington, D.C. Available URL:  
24 [http://tonto.eia.doe.gov/FTPROOT/forecasting/0383\(2008\).pdf](http://tonto.eia.doe.gov/FTPROOT/forecasting/0383(2008).pdf) (accessed July 18, 2008).  
25 ADAMS No. ML082880730.
- 26 EIA (Energy Information Administration). 2008b. *Assumptions to the Annual Energy Outlook*  
27 *2008 With Projections to 2030*. DOE/EIA 0554(2008). Washington, D.C. Available URL:  
28 [http://tonto.eia.doe.gov/FTPROOT/forecasting/0554\(2007\).pdf](http://tonto.eia.doe.gov/FTPROOT/forecasting/0554(2007).pdf) (accessed July 22, 2008).  
29 ADAMS No. ML082880730.
- 30 EPA (U.S. Environmental Protection Agency). 1997. *Mercury Study Report to Congress.*  
31 *Volume V: Health Effects of Mercury and Mercury Compounds*. Office of Air Quality Planning  
32 and Standards, Office of Research and Development. Washington, D.C.
- 33 EPA (U.S. Environmental Protection Agency). 1998. *Compilation of Air Pollutant Emission*  
34 *Factors, Volume 1: Stationary Point and Area Sources: AP 42, Fifth Edition*. "Section 1.1:  
35 Bituminous and Subbituminous Coal Combustion: Final Section Supplement E." Washington,  
36 D.C.
- 37 EPA (U.S. Environmental Protection Agency). 1999a. *Integrated Risk Information System (IRIS)*  
38 *on Polycyclic Organic Matter*. National Center for Environmental Assessment, Office of  
39 Research and Development. Washington, D.C.

- 1 EPA (U.S. Environmental Protection Agency). 1999b. *Integrated Risk Information System (IRIS)*  
2 *on Benzo(a)pyrene*. National Center for Environmental Assessment, Office of Research and  
3 Development. Washington, D.C.
- 4 EPA (U.S. Environmental Protection Agency). 1999c. *Integrated Risk Information System (IRIS)*  
5 *on Benz[a]anthracene*. National Center for Environmental Assessment, Office of Research and  
6 Development. Washington, D.C.
- 7 EPA (U.S. Environmental Protection Agency). 1999d. *Integrated Risk Information System (IRIS)*  
8 *on Methyl mercury*. National Center for Environmental Assessment, Office of Research and  
9 Development. Washington, D.C.
- 10 EPA (U.S. Environmental Protection Agency). 2000. "Regulatory Finding on the Emissions of  
11 Hazardous Air Pollutants from Electric Utility Steam Generating Units." Federal Register, Vol.  
12 65, No. 245, pp. 79825–79831. Washington, DC. December 20, 2000.
- 13 EPA (U.S. Environmental Protection Agency). 2005. "Regional and State SO<sub>2</sub> and NO<sub>x</sub>  
14 Emissions Budgets." March. Washington, D.C. Available URL:  
15 <http://www.epa.gov/cair/pdfs/finaltech06.pdf> (accessed October 12, 2008). ADAMS No.  
16 ML082880732.
- 17 EPA (U.S. Environmental Protection Agency). 2007. "Clean Air Mercury Rule." Available URL:  
18 <http://www.epa.gov/air/mercuryrule/> (accessed July 9, 2007). ADAMS No. ML082880732.
- 19 EPA (U.S. Environmental Protection Agency). 2008a. "Nitrogen Oxide." Available URL:  
20 <http://www.epa.gov/air/urbanair/nox/hlth.html> (accessed July 19, 2008). ADAMS No.  
21 ML082880732.
- 22 EPA (U.S. Environmental Protection Agency ). 2008b. "Radon Exposure." Available URL:  
23 <http://www.epa.gov/radon/healthrisks.html> (accessed July 19, 2008). ADAMS No.  
24 ML082880732.
- 25 EPA (U.S. Environmental Protection Agency). 2008c. "Sulfur Dioxides." Available URL:  
26 <http://www.epa.gov/air/urbanair/so2/> (accessed July 19, 2008). ADAMS No. ML082880732.
- 27 Gabbard, A. 1993. "Coal Combustion: Nuclear Resource or Danger." Oak Ridge National  
28 Laboratory Review. Oak Ridge National Laboratory, Oak Ridge, TN. Summer/ Fall 1993.  
29 Available URL: <http://www.ornl.gov/ORNLReview/rev26-34/text/colmain.html> (accessed May 23,  
30 2007). ADAMS No. ML082880731.
- 31 GE (General Electric). 2007. "Gas Turbine and Combined Cycle Products." May 2007. Available  
32 URL: [http://www.gepower.com/prod\\_serv/products/gas\\_turbines\\_cc/en/downloads/  
33 gasturbine\\_cc\\_products.pdf](http://www.gepower.com/prod_serv/products/gas_turbines_cc/en/downloads/gasturbine_cc_products.pdf) (accessed April 14, 2008). ADAMS No. ML082880731.
- 34 HHS (U.S. Department of Health and Human Services). 1993. *Hazardous Substances Data*  
35 *Bank*. National Toxicology Information Program, National Library of Medicine. Bethesda, MD.
- 36 INEEL (Idaho National Engineering and Environmental Laboratory). 1997. "U.S. Hydropower  
37 Resource Assessment for Pennsylvania." DOE/ID-10430(PA). Idaho Falls, ID. (December  
38 1997). Available URL: <http://hydropower.inl.gov/resourceassessment/pdfs/states/pa.pdf>  
39 (accessed March 20, 2007). ADAMS No. ML082880730.

## Alternatives

- 1 Integrated Waste Services Association. 2007. "Waste-to-Energy and the Production Tax Credit."  
2 Washington, DC. Available URL: <http://www.wte.org/docs/FactSheetPTC.pdf> (accessed May  
3 24, 2007). ADAMS No. ML083050223.
- 4 NAS (National Academy of Sciences). 2005. *Health Risks from Exposure to Low Levels of*  
5 *Ionizing Radiation: Biological Effects of Ionizing Radiation (BEIR) VII, Phase 2, Seventh Ed.*  
6 Washington, D.C.
- 7 NRC (U.S. Nuclear Regulatory Commission). 1996. *Generic Environmental Impact Statement*  
8 *for License Renewal of Nuclear Plants*. NUREG-1437, Volumes 1 and 2, Washington, D.C.  
9 ADAMS No. ML061770605.
- 10 NRC (U.S. Nuclear Regulatory Commission). 1999. *Generic Environmental Impact Statement*  
11 *for License Renewal of Nuclear Plants, Main Report*, "Section 6.3 – Transportation, Table 9.1,  
12 Summary of findings on NEPA issues for license renewal of nuclear power plants, Final Report."  
13 NUREG-1437, Volume 1, Addendum 1, Washington, D.C.
- 14 NRC (U.S. Nuclear Regulatory Commission). 2002. *Generic Environmental Impact Statement*  
15 *on Decommissioning of Nuclear Facilities: Supplement 1, Regarding the Decommissioning of*  
16 *Nuclear Power Reactors*. NUREG-0586, Supplement 1, Volumes 1 and 2. Washington, D.C.
- 17 NRC (U.S. Nuclear Regulatory Commission). 2007. *Generic Environmental Impact Statement*  
18 *for License Renewal of Nuclear Plants, Supplement 28, Regarding Oyster Creek Nuclear*  
19 *Generating Station, Final Report – Main Report*. Washington, D.C.
- 20 NREL (National Renewable Energy Laboratory). 2008. "United States Atlas of Renewable  
21 Resources." Interactive Map. Available URL:  
22 [http://mapserve2.nrel.gov/website/Resource\\_Atlas/viewer.htm](http://mapserve2.nrel.gov/website/Resource_Atlas/viewer.htm) (accessed April 18, 2008).
- 23 *Nucleonics Week*. 2008. "US new reactors more likely online in 2016 and beyond, NEI official  
24 says." Vol. 49, No. 15. April 10, 2008.
- 25 OMB (U.S. Office of Management and Budget). 2007. ExpectMore.gov. "Detailed Information on  
26 the Low Income Home Energy Assistance Program Assessment." Available URL:  
27 <http://www.whitehouse.gov/omb/expectmore/detail/10001059.2003.html> (accessed July 10,  
28 2007). ADAMS No. ML082880730.
- 29 ORNL (Oak Ridge National Laboratory). 2007. "Bioenergy Conversion Factors." Available URL:  
30 [http://bioenergy.ornl.gov/papers/misc/energy\\_conv.html](http://bioenergy.ornl.gov/papers/misc/energy_conv.html) (accessed November 6, 2007).  
31 ADAMS No. ML083050223.
- 32 Pace University Center for Environmental Legal Studies, *Environmental Cost of Energy*,  
33 Oceana Publications, NY, 1991.
- 34 PADEP (Pennsylvania Department of Environmental Protection). 2008. "Pennsylvania's Clear  
35 Air Plans." Available URL:  
36 [http://www.dep.state.pa.us/dep/deputate/airwaste/aq/plans/Clean\\_air\\_plans.htm](http://www.dep.state.pa.us/dep/deputate/airwaste/aq/plans/Clean_air_plans.htm) (accessed  
37 October 12, 2008). ADAMS No. ML082880732.
- 38 PJM (PJM Interconnection, Inc.). 2008. *2007 State of the Market Report, Volume 1:*  
39 *Introduction*. March. Available URL: [Draft NUREG-1437, Supplement 37](http://www2.pjm.com/markets/market-</a></p></div><div data-bbox=)

- 1 [monitor/downloads/mmu-reports/2007-som-volume1.pdf](#) (accessed October 24, 2008). ADAMS  
 2 No. ML083050232.
- 3 USGS (U.S. Geological Survey). 1997. "Radioactive Elements in Coal and Fly Ash: Abundance,  
 4 Forms, and Environmental Significance; USGS Fact Sheet FS-163-97." Available URL:  
 5 <http://greenwood.cr.usgs.gov/energy/factshts/163-97/FS-163-97.pdf> (accessed May 22, 2007).  
 6 ADAMS No. ML082880731.
- 7 Walsh et al. (Walsh, M.E., R.L. Perlack, A. Turhollow, D. de la Torre Ugarte, D.A. Becker, R.L.  
 8 Graham, S.A. Slinsky, and D.E. Ray). 2000. "Biomass Feedstock Availability in the United  
 9 States: 1999 State Level Analysis." Available URL:  
 10 <http://bioenergy.ornl.gov/resourcedata/index.html> (accessed May 22, 2007). ADAMS No.  
 11 ML083050223.





## 9.0 CONCLUSION

This draft supplemental environmental impact statement (EIS) contains the preliminary environmental review of AmerGen Energy Company, LLC's (AmerGen's) application for a renewed operating license for Three Mile Island Nuclear Station, Unit 1 (TMI-1) as required by Part 51 of Title 10, of the *Code of Federal Regulations* (10 CFR Part 51), the NRC's regulations that implement the National Environmental Policy Act (NEPA). Chapter 9 presents the conclusions and recommendations from the site-specific environmental review of TMI-1 and summarizes site-specific environmental issues of license renewal that were identified during the review. The environmental impacts of license renewal are summarized in Section 9.1; a comparison of the environmental impacts of license renewal and energy alternatives is presented in Section 9.2; unavoidable impacts of license renewal and energy alternatives and resource commitments are discussed in Section 9.3; and conclusions and NRC staff recommendations are presented in Section 9.4.

### 9.1 Environmental Impacts of License Renewal

Our review of site-specific environmental issues in this draft supplemental EIS leads us to conclude that issuing a renewed license would have SMALL impacts for the 21 Category 2 issues applicable to license renewal and refurbishment at TMI-1, as well as environmental justice and chronic effects of electromagnetic fields.

Mitigation measures were considered for each Category 2 issue, as applicable. For ground water and surface water use issues, current measures to mitigate the environmental impacts of plant operation were found to be adequate. Potential mitigation measures for reducing impacts from thermophilic microbiological organisms resulting from TMI-1's thermal discharge include periodically monitoring for thermophilic microbiological organisms in the water and sediments near the discharge, and prohibiting recreational use near the discharge plume. The staff identified a variety of measures that could mitigate potential acute electromagnetic field impacts resulting from continued operation of the TMI-1 transmission lines, including limiting public access to transmission line structures, installing road signs at road crossings, and increasing transmission line clearances.

Mitigation measures that could reduce impacts to the terrestrial environment, as well as to the threatened and endangered species during refurbishment activities, include installing silt fences to minimize sediment transport, the use of best management practices, and restoring cleared land that remains after completion of construction. Mitigation measures to reduce potential air quality impacts resulting from refurbishment activities include implementation of a dust control plan to minimize emissions from construction activities, and the use of multiperson vans and workforce shift changes to reduce the number of vehicles on the road at any one given time.

No impacts to known historic and archaeological resources are expected from the continued operation of TMI-1 during the license renewal term. AmerGen could mitigate this impact by developing a cultural resources management plan in addition to AmerGen's review procedures. This management plan would serve to integrate cultural resource considerations with ongoing TMI-1 activities. Additionally, training of AmerGen staff in the Section 106 process would ensure

## Conclusion

1 that informed decisions are made when considering the effects of future projects on historic and  
2 archaeological resources. As previously discussed, lands not previously surveyed should be  
3 investigated by a professional archaeologist prior to any ground disturbance. In addition, the  
4 historical farmstead site (36Da235) should be recorded and evaluated for eligibility.

5 The NRC also considered cumulative impacts of past, present, and reasonably foreseeable  
6 future actions, regardless of what agency (Federal or non-Federal) or person undertakes them.  
7 The staff concluded that cumulative impacts of TMI-1 license renewal and refurbishment would  
8 be SMALL for potentially affected resources.  
9

## 10 **9.2 Comparison of Environmental Impacts of License Renewal and Alternatives**

11 In the conclusion to Chapter 8, we determined that impacts from license renewal are generally  
12 less than the impacts of alternatives to license renewal, with the exception of energy  
13 conservation and energy efficiency. In comparing likely environmental impacts from supercritical  
14 coal-fired generation, natural gas combined-cycle generation, energy conservation and energy  
15 efficiency, and a combination alternative that included natural gas, conservation/efficiency,  
16 uprates to existing hydroelectric dams, and environmental impacts from license renewal, we  
17 found that the energy conservation and energy efficiency alternative would result in the lowest  
18 environmental impact. Based on our analysis, we found that the impacts of license renewal are  
19 reasonable in light of the impacts from alternatives to the license renewal of TMI-1.  
20

## 21 **9.3 Resource Commitments**

### 22 **9.3.1 Unavoidable Adverse Environmental Impacts**

23 Unavoidable adverse environmental impacts are impacts that would occur after implementation  
24 of all feasible mitigation measures. Implementing any of the energy alternatives considered in  
25 this supplemental EIS, including the proposed action, would result in some unavoidable adverse  
26 environmental impacts.

27 Minor unavoidable adverse impacts on air quality would occur due to emission and release of  
28 various chemical and radiological constituents from power plant operations. Nonradiological  
29 emissions resulting from power plant operations are expected to comply with U.S.  
30 Environmental Protection Agency (EPA) emissions standards, though the alternative of  
31 operating a fossil-fueled power plant in some areas may worsen existing attainment issues.  
32 Chemical and radiological emissions would not exceed the National Emission Standards for  
33 Hazardous Air Pollutants.

34 During nuclear power plant operations, workers and members of the public would face  
35 unavoidable exposure to radiation and hazardous and toxic chemicals. Workers would be  
36 exposed to radiation and chemicals associated with routine plant operations and the handling of  
37 nuclear fuel and waste material. Workers would have higher levels of exposure than members  
38 of the public, but doses would be administratively controlled and would not exceed any  
39 standards or administrative control limits. In comparison, the alternatives entailing the

1 construction and operation of a non-nuclear power generating facility would also result in  
2 unavoidable exposure to hazardous and toxic chemicals to workers and the general public.

3 The generation of spent nuclear fuel and waste material, including low-level radioactive waste,  
4 hazardous waste, and nonhazardous waste would also be unavoidable. In comparison,  
5 hazardous and nonhazardous wastes would also be generated at non-nuclear power generating  
6 facilities. Wastes generated during plant operations would be collected, stored, and shipped for  
7 suitable treatment, recycling, or disposal in accordance with applicable Federal and State  
8 regulations. Due to the costs of handling these materials, power plant operators would be  
9 expected to conduct all activities and optimize all operations in a way that generates the  
10 smallest amount of waste practical.  
11

### 12 **9.3.2 Relationship Between Local Short-Term Uses of the Environment and the** 13 **Maintenance and Enhancement of Long-Term Productivity**

14 The operation of power generating facilities would result in short-term uses of the environment  
15 as described in Chapters 4, 5, 6, 7, and 8. "Short term" is the period of time during which  
16 continued power generating activities would take place.

17 Power plant operations would necessitate short-term use of the environment and commitments  
18 of resources, and would also commit certain resources (e.g., land and energy) indefinitely or  
19 permanently. Certain short-term resource commitments would be substantially greater under  
20 most energy alternatives, including license renewal, than under the No Action Alternative due to  
21 the continued generation of electrical power as well as continued use of generating sites and  
22 associated infrastructure. During operations, all energy alternatives would entail similar  
23 relationships between local short-term uses of the environment and the maintenance and  
24 enhancement of long term productivity.

25 Air emissions from power plant operations would introduce small amounts of radiological and  
26 nonradiological constituents to the region around the plant site. Over time, these emissions  
27 would result in increased concentrations and exposure, but are not expected to impact air  
28 quality or radiation exposure to the extent that public health and long-term productivity of the  
29 environment would be impaired.

30 Continued employment, expenditures, and tax revenues generated during power plant  
31 operations would directly benefit local, regional, and State economies over the short term. Local  
32 governments investing project-generated tax revenues into infrastructure and other required  
33 services could enhance economic productivity over the long term.

34 The management and disposal of spent nuclear fuel, low-level radioactive waste, hazardous  
35 waste, and nonhazardous waste would require an increase in energy and would consume  
36 space at treatment, storage, or disposal facilities. Regardless of the location, the use of land to  
37 meet waste disposal needs would reduce the long-term productivity of the land.

38 Power plant facilities would be committed to electricity production over the short term. After  
39 decommissioning these facilities and restoring the area, the land could be available for other  
40 future productive uses.  
41

## Conclusion

### 1 **9.3.3 Irreversible and Irretrievable Commitments of Resources**

2 This section describes the irreversible and irretrievable commitments of resources that have  
3 been identified in this supplemental EIS. Irreversible resources refer to when primary or  
4 secondary impacts limit the future options for a resource. An irretrievable commitment refers to  
5 the use or consumption of resources that are neither renewable nor recoverable for future use.  
6 Irreversible and irretrievable commitment of resources for electrical power generation would  
7 include the commitment of land, water, energy, raw materials, and other natural and man-made  
8 resources required for power plant operations. In general, the commitment of capital, energy,  
9 labor, and material resources would also be irreversible.

10 The implementation of any of the energy alternatives considered in this supplemental EIS would  
11 entail the irreversible and irretrievable commitment of energy, water, chemicals, and, in some  
12 cases, fossil fuels. These resources would be committed during the license renewal term and  
13 over the entire life cycle of the power plant and would essentially be unrecoverable.

14 Energy expended would be in the form of fuel for equipment, vehicles, and power plant  
15 operations and electricity for equipment and facility operations. Electricity and fuels would be  
16 purchased from offsite commercial sources. Water would be obtained from existing water supply  
17 systems. These resources are readily available, and the amounts required are not expected to  
18 deplete available supplies or exceed available system capacities.

19 The irreversible and irretrievable commitment of material resources includes materials that  
20 cannot be recovered or recycled, materials that are rendered radioactive and cannot be  
21 decontaminated, and materials consumed or reduced to unrecoverable forms of waste.  
22 However, none of the resources used by these power generating facilities are in short supply,  
23 and, for the most part, are readily available.

24 Various materials and chemicals, including acids and caustics, would be required to support  
25 operations activities. These materials would be derived from commercial vendors, and their  
26 consumption is not expected to affect local, regional, or national supplies.

27 The treatment, storage, and disposal of spent nuclear fuel, low-level radioactive waste,  
28 hazardous waste, and nonhazardous waste would require the irretrievable commitment of  
29 energy and fuel and would result in the irreversible commitment of space in disposal facilities.  
30

### 31 **9.4 Recommendations**

32 Based on (1) the analysis and findings in the GEIS, (2) information provided in the  
33 Environmental Report submitted by AmerGen, (3) consultation with Federal, State, and local  
34 agencies, (4) a review of pertinent documents and reports, and (5) consideration of public  
35 comments received during scoping, the preliminary recommendation of the NRC staff is that the  
36 Commission determine that the adverse environmental impacts of license renewal for TMI-1 are  
37 not so great that preserving the option of license renewal for energy planning decision makers  
38 would be unreasonable.

## 10.0 LIST OF PREPARERS

This supplemental EIS was prepared by members of the Office of Nuclear Reactor Regulation, with assistance from other NRC organizations and contract support from Pacific Northwest National Laboratory.

**Table 10-1. List of Preparers.** *Pacific Northwest National Laboratory provided contract support for the severe accident mitigation alternatives (SAMA) analysis, presented in Chapter 5 and Appendix F.*

Name	Affiliation	Function or Expertise
<b>Nuclear Regulatory Commission</b>		
Briana Balsam	Nuclear Reactor Regulation	Ecology, Project Support
Dennis Beissel	Nuclear Reactor Regulation	Hydrology
Richard Bulavinetz	Nuclear Reactor Regulation	Aquatic Ecology
Andrew Carerra	Nuclear Reactor Regulation	Radiation Protection; Human Health
Jennifer Davis	Nuclear Reactor Regulation	Historic and Archaeological Resources
Nathan Goodman	Nuclear Reactor Regulation	Terrestrial Ecology
Stephen Klementowicz	Nuclear Reactor Regulation	Radiation Protection
Ekaterina Lenning	Nuclear Reactor Regulation	Air Quality
Dennis Logan	Nuclear Reactor Regulation	Ecology
Sarah Lopas	Nuclear Reactor Regulation	Project Manager, Nonradiological Waste
Robert Palla	Nuclear Reactor Regulation	Severe Accident Mitigation Alternatives
Jeffrey Rikhoff	Nuclear Reactor Regulation	Socioeconomics; Land Use; Environmental Justice
Andrew Stuyvenburg	Nuclear Reactor Regulation	Alternatives
Allison Travers	Nuclear Reactor Regulation	Hydrology
<b>SAMA Contractor<sup>(a)</sup></b>		
Steve Short	Pacific Northwest National Laboratory	Severe Accidents Mitigation Alternatives
Bruce Schmitt	Pacific Northwest National Laboratory	Severe Accidents Mitigation Alternatives
Tye Blackburn	Pacific Northwest National Laboratory	Severe Accidents Mitigation Alternatives

(a) Pacific Northwest National Laboratory is operated by Batelle for the U.S. Department of Energy



## 11.0 INDEX

- 2 accidents.....xix, 5-1, 5-2, 5-3, 5-5, 8-44, A-  
3 17, B-14, F-5
- 4 aesthetic...xviii, 2-60, 4-27, 8-14, 8-15, 8-24,  
5 8-25, 8-31, 8-36, 8-46
- 6 alternatives.....iii, xix, xx, 1-5, 5-3, 5-4, 8-1,  
7 8-2, 8-8, 8-25, 8-26, 8-27, 8-31, 8-34, 8-  
8 43, 8-46, 8-47, 9-1, 9-2, 9-3, 9-4, 10-1, A-  
9 1, A-15, A-16, A-17, B-14, E-7, E-8
- 10 archaeological resources .. ...xviii, 1-6, 2-23,  
11 2-68, 3-12, 3-13, 4-44, 8-15, 8-25, B-13,  
12 D-1
- 13 Barnwell .....2-9, A-15
- 14 biota .....4-7, A-4, A-13, B-3
- 15 burnup.....2-5, B-19
- 16 chronic effects. ....xviii, 1-3, 4-10, 4-18, 4-19,  
17 4-43, 9-1, B-12
- 18 Clean Air Act 2-27, 2-78, 3-6, 3-7, 3-14, 8-  
19 5, 8-49
- 20 closed-cycle cooling ... ..4-13, 8-4, A-4, B-6,  
21 B-7
- 22 consumptive use.. 2-17, 4-35, 4-37, 8-28, 8-  
23 33, A-8
- 24 cultural resources.....3-12, 4-44, 8-15, 8-25,  
25 C-1
- 26 decommissioning ... 7-1, 8-18, 8-30, 8-31, 8-  
27 43, 8-45, 8-46, 9-4, B-18, B-20
- 28 demography ..... 2-53
- 29 design-basis accidents..... xxiii, 5-1, 5-2
- 30 discharges.....xviii, 2-7, 2-15, 2-16, 2-17, 2-  
31 19, 2-20, 2-21, 2-23, 2-30, 2-33, 2-34, 3-  
32 5, 4-4, 4-7, 4-13, 4-14, 4-15, 4-16, 4-17,  
33 4-33, 4-36, 4-43, 8-4, 8-9, 8-21, 8-28, 8-  
34 44, 9-1, A-4, A-6, A-7, A-8, A-11, A-12, B-  
35 1, B-3, B-4, B-11, C-2, C-5
- 36 dose .. xviii, 2-5, 2-6, 2-7, 2-8, 2-9, 3-3, 4-11,  
37 4-12, 4-13, 4-33, 4-41, 4-42, 5-5, 8-10, 8-  
38 11, A-12, A-13, A-14, B-11, B-14, B-16, F-  
39 32, F-33
- 40 dredging ..... 3-3, C-6
- 41 education ....2-55, 2-84, 2-87, 3-10, 4-20, 4-  
42 36, 4-45, B-12, B-13
- 43 electromagnetic fields ....xviii, 1-3, 4-8, 4-18,  
44 4-19, 4-43, 9-1, B-9, B-12
- 45 entrainment..... 8-34, A-4, B-3, B-4
- 46 environmental justice... ..1-3, 3-13, 3-14, 4-  
47 20, 4-27, 4-32, 8-15, 8-25, 8-31, 8-36, 9-  
48 1, B-20
- 49 EPA .....xxiii, 2-8, 2-9, 2-10, 2-11, 2-12, 2-  
50 15, 2-27, 2-29, 2-30, 2-37, 2-56, 2-60, 2-  
51 79, 2-80, 2-83, 3-7, 3-8, 3-9, 4-12, 4-41,  
52 8-2, 8-5, 8-6, 8-7, 8-10, 8-11, 8-12, 8-18,  
53 8-19, 8-29, 8-32, 8-49, 8-50, A-6, A-11, B-  
54 17, C-1, C-5
- 55 fish ladder ..... 2-32, 2-35, 2-36, 4-39
- 56 fish passage ..... 2-32, 2-35, 2-36, 4-38, 4-39
- 57 GEIS..xv, xvi, xvii, xviii, xxi, xxiii, 1-3, 1-4, 1-  
58 6, 1-8, 2-61, 3-1, 3-7, 3-13, 4-1, 4-2, 4-3,  
59 4-4, 4-6, 4-7, 4-8, 4-10, 4-11, 4-16, 4-18,  
60 4-19, 4-20, 4-21, 4-22, 4-34, 4-35, 4-43,  
61 5-1, 5-2, 5-3, 6-1, 7-1, 8-1, 8-2, 8-4, 8-9,  
62 8-12, 8-13, 8-14, 8-17, 8-22, 8-23, 8-24,  
63 8-26, 8-27, 8-29, 8-30, 8-31, 8-34, 8-35,  
64 8-37, 8-43, 8-45, 9-5, A-1, A-4, A-9, A-14,  
65 A-15, A-17, B-14
- 66 ground water.....xvi, 2-16, 2-28, 2-29, 2-30,  
67 2-55, 2-56, 3-1, 3-5, 4-2, 4-3, 4-5, 4-11, 4-  
68 12, 4-33, 4-35, 4-36, 4-37, 4-40, 4-45, 8-  
69 2, 8-8, 8-16, 8-20, 9-1, A-6, A-7, A-8, A-9,  
70 A-10, A-11, A-12, A-13, B-5, B-6, B-7, C-1
- 71 hazardous waste ....2-9, 2-10, 2-11, 8-16, 9-  
72 3, 9-4, C-5
- 73 high level waste ..... B-14, B-15, B-16, B-17
- 74 impingement ..... 8-34, A-4, B-3, B-5
- 75 invasive species ..... 2-41, 4-40
- 76 low level waste ..... xxiv, A-15
- 77 mitigation .. xvi, xvii, xviii, 1-3, 1-4, 1-5, 2-41,  
78 3-4, 3-12, 3-13, 4-1, 4-3, 4-6, 4-7, 4-8, 4-  
79 10, 4-11, 4-16, 4-18, 4-37, 4-44, 5-3, 5-7,  
80 8-15, 8-25, 8-29, 9-1, 9-2, 10-1, A-7, A-  
81 16, A-17, E-7, E-8, F-34
- 82 mixed waste.....xxiv, 2-8, 8-46, B-18
- 83 NEPA...xv, xxiv, 1-1, 1-12, 2-74, 2-82, 2-83,  
84 3-15, 4-26, 4-27, 4-34, 4-51, 5-1, 6-3, 7-2,  
85 8-1, 8-51, 9-1, A-5, A-1, B-1, B-15, B-17,  
86 D-1

## Index

- 1 no-action alternative. ....iii, xx, 8-26, 8-43, 8-  
2 44, 8-46  
3 nonattainment...xvi, 2-27, 3-1, 3-6, 3-7, 3-8,  
4 3-9, 8-5, 8-18, 8-32, B-9  
5 nonnative ..... 2-34  
6 nonradiological waste ..... 2-9, 2-11  
7 NPDES.....xxiv, 2-9, 2-11, 2-16, 2-20, 2-23,  
8 4-15, 4-38, 4-39, 8-9, A-4, A-5, A-8, B-2,  
9 C-1  
10 nuclides..... 8-29  
11 Pennsylvania Department of Conservation  
12 and Natural Resources...xxiii, 2-42, 2-43,  
13 2-44, 2-45, 2-46, 2-47, 2-48, 2-79, 4-9, 4-  
14 10, 4-50  
15 Pennsylvania Department of Environmental  
16 Protection ... xxiv, 2-9, 2-11, 2-16, 2-17, 2-  
17 20, 2-23, 2-27, 2-32, 2-43, 2-55, 2-56, 2-  
18 83, 4-12, 4-15, 4-33, 4-34, 4-38, 4-39, 4-  
19 51, 8-6, 8-9, 8-19, 8-51, A-5  
20 Pennsylvania Fish and Boat Commission  
21 xxiv, 2-35, 2-36, 2-37, 2-42, 2-84, 2-85, 4-  
22 9, 4-34, 4-39, 4-52  
23 Pennsylvania Game Commission . ...xxiv, 2-  
24 42, 2-43, 2-44, 2-85, 2-86, 4-9, 4-52  
25 Pennsylvania Historic and Museum  
26 Commission.... xxv, 2-86, 3-12, 3-13, 4-44  
27 postulated accidents ..... 5-1, 5-3  
28 pressurized water reactor ..... xxv  
29 radon-222..... 6-1, 8-29, B-14  
30 reactor. ....xv, xxiii, xxiv, xxv, 2-1, 2-5, 2-6, 2-  
31 7, 2-11, 2-13, 2-20, 2-43, 2-60, 3-1, 4-10,  
32 4-12, 4-33, 4-42, 5-1, 5-2, 5-3, 5-7, 5-8, 7-  
33 1, 8-44, 8-45, B-6, B-14, F-34, F-35  
34 refurbishment.....xvi, xvii, xviii, xix, 2-7, 2-8,  
35 2-23, 2-57, 3-1, 3-2, 3-3, 3-4, 3-5, 3-6, 3-  
36 7, 3-8, 3-9, 3-10, 3-11, 3-12, 3-13, 3-14,  
37 4-13, 9-1, 9-2, A-9, A-10, B-1, B-3, B-5,  
38 B-9, B-10, B-11, B-12, B-13, C-5  
39 replacement power ..... iii, 5-7, F-34  
40 scoping....xv, xvi, xxi, 1-2, 1-3, 1-5, 1-6, 3-4,  
41 3-5, 3-13, 4-1, 4-3, 4-5, 4-6, 4-7, 4-11, 4-  
42 18, 4-20, 4-35, 5-2, 5-3, 6-1, 7-1, 9-5, A-1,  
43 A-2, E-2, E-3, E-4, E-6, E-7, E-8  
44 severe accidents (SAMA)....xxv, 5-3, 5-4, 5-  
45 6, 5-7, 5-8, 5-9, 10-1, A-17, F-5, F-15, F-  
46 34, F-35  
47 solid waste... 2-8, 2-9, 2-10, 6-1, 8-10, 8-25,  
48 B-20, C-1  
49 spent fuel ...xxiv, 1-4, 2-6, 6-1, 6-2, 8-46, B-  
50 14, B-15, B-17, B-18, B-19  
51 steady-state current.....4-17  
52 stormwater .....2-23, 4-11, 4-36, A-8  
53 surface water ....xvi, xix, 2-29, 2-55, 2-56, 3-  
54 1, 3-5, 4-3, 4-4, 4-11, 4-32, 4-33, 4-34, 4-  
55 41, 8-2, 8-4, 8-9, 8-16, 8-21, 8-28, 8-33,  
56 8-44, 9-1, A-8, A-9, A-12, B-1, B-6, C-1  
57 Susquehanna River Basin Commission  
58 ....xxv, 2-17, 2-20, 2-29, 2-31, 2-32, 2-33,  
59 2-34, 2-87, 4-2, 4-3, 4-5, 4-35, 4-36, 4-37,  
60 4-38, 4-39, 4-45, 4-53, A-5, A-6, A-7  
61 taxes .....2-57, 2-66, 4-23, A-16  
62 threatened and endangered species ...xvii,  
63 1-6, 2-41, 2-42, 2-43, 2-44, 2-45, 2-53, 2-  
64 75, 3-5, 3-6, 4-4, 4-8, 4-9, 4-10, 9-1, A-9,  
65 A-11, B-3, B-9, C-1, C-6, D-1  
66 Three Mile Island Unit 2... ..xix, 2-1, 2-17, 2-  
67 24, 2-38, 2-40, 2-76, 2-77, 2-78, 2-82, 3-  
68 12, 3-13, 4-32, 4-40, 4-42, 4-51, 8-18, 8-  
69 31, A-2  
70 transmission corridors ..... 8-15, 8-25  
71 transmission lines... .. xviii, 2-13, 2-38, 2-40,  
72 4-1, 4-10, 4-16, 4-17, 4-18, 4-20, 4-40, 4-  
73 43, 8-5, 8-9, 8-12, 8-13, 8-15, 8-18, 8-21,  
74 8-22, 8-24, 8-29, 8-30, 8-45, 9-1, B-9, B-  
75 14  
76 tritium... ..2-29, 2-30, 4-11, 4-12, 4-32, 4-33,  
77 A-10, A-11, A-12, A-13  
78 U.S. Fish and Wildlife Service . xxiii, 2-40, 2-  
79 42, 2-43, 2-44, 2-80, 3-6, 4-9, 4-10, 4-50,  
80 C-6  
81 universal waste .....2-10  
82 uranium.....2-5, 2-6, 4-42, 6-1, 8-8, 8-10, 8-  
83 13, 8-23, 8-34, B-14, B-17, B-19  
84 wastewater..... 2-11, 2-16, 2-20, 2-21, 2-23,  
85 4-4, 4-36, 4-38, 4-41, A-8, B-2  
86 Yucca..... B-15, B-16, B-19



1  
2  
3  
4  
5

**Appendix A**  
**Comments Received on the**  
**Three Mile Island Nuclear Station, Unit 1,**  
**Environmental Review**



1  
2 **A. Comments Received on the Three Mile Island Nuclear Station,**  
3 **Unit 1, Environmental Review**

4 **A.1 Comments Received During Scoping**

5 The scoping process began on March 28, 2008 with the publication of the NRC's Notice of  
6 Intent to conduct scoping in the *Federal Register* (73 FR 16729). The scoping process included  
7 two public meetings held at The Elks Theatre and Londonderry Elementary School in  
8 Middletown, Pennsylvania on May 1, 2008. Approximately 90 people attended the meetings.  
9 After the NRC's prepared statements pertaining to the license renewal process, the meetings  
10 were open for public comments. Attendees provided oral statements that were recorded and  
11 transcribed by a certified court reporter. Transcripts of the entire meeting, as well as written  
12 statements submitted at the public meetings, were placed into the NRC as an attachment to  
13 the Scoping Summary Report dated August 8, 2008 (NRC 2008). In addition to the comments  
14 received during the public meetings, comments were received through the mail and email.

15 Each commenter was given a unique identifier so every comment could be traced back to its  
16 author. Table A-1 identifies the individuals who provided comments applicable to the  
17 environmental review and the Commenter ID associated with each person's set of comments.  
18 The individuals are listed in the order in which they spoke at the public meeting, and in  
19 alphabetical order for the comments received by letter or e-mail. To maintain consistency with  
20 the Scoping Summary Report, the unique identifier used in that report for each set of comments  
21 is retained in this appendix.

22 Specific comments were categorized and consolidated by topic. Comments with similar specific  
23 objectives were combined to capture the common essential issues raised by participants.  
24 Comments fall into one of the following general groups:

25 Specific comments that address environmental issues within the purview of the NRC  
26 environmental regulations related to license renewal. These comments address Category 1  
27 (generic) or Category 2 (site-specific) issues or issues not addressed in the *Generic*  
28 *Environmental Impact Statement for License Renewal of Nuclear Power Plants* (GEIS).  
29 They also address alternatives to license renewal and related Federal actions.

30 General comments (1) in support of or opposed to nuclear power or license renewal or (2)  
31 on the renewal process, the NRC's regulations, and the regulatory process. These  
32 comments may or may not be specifically related to the TMI-1 license renewal application.

33 Comments that do not identify new information for the NRC to analyze as part of its  
34 environmental review.

35 Comments that address issues that do not fall within or are specifically excluded from the  
36 purview of NRC environmental regulations related to license renewal. These comments

Appendix A

1 typically address issues such as the Three Mile Island Unit 2 and the 1979 accident,  
 2 emergency response and preparedness, security and terrorism, energy costs, energy  
 3 needs, current operational safety issues, and safety issues related to operation during the  
 4 renewal period.

5 **Table A-1. Commenters on the Scope of the Environmental Review.** *Each*  
 6 *comment is identified along with their affiliation and how their comment*  
 7 *was submitted.*

<b>Commenter ID</b>	<b>Commenter</b>	<b>Affiliation</b>	<b>Comment Source</b>	<b>ADAMS Accession Number</b>
TMI-A	Scott Portzline	TMI Alert	Afternoon Scoping Meeting; Written Comments	ML081300739 ML081330183
TMI-E	Andrew Dehoff	Susquehanna River Basin Commission	Afternoon Scoping Meeting	ML081300739
TMI-F	Eric Epstein	TMI Alert	Afternoon Scoping Meeting; Written Comments	ML081300739 ML081330183
TMI-H	Mary Osborn Ouassiai	Concerned Mothers, TMI Alert	Afternoon Scoping Meeting; Written Comments; Letter	ML081300739 ML081330183 ML081690678
TMI-J	Michael Helfrich	Lower Susquehanna RIVERKEEPER	Afternoon Scoping Meeting	ML081300739
TMI-N	Rachel S. Diamond; David J. Allard	Pennsylvania Department of Environmental Protection	Letter	ML081500598
TMI-O	Michael G. Brownell	Susquehanna River Basin Commission	Letter	ML081580174

8  
 9 Comments received during scoping applicable to this environmental review are presented in this  
 10 section along with the NRC response. The comments that are general or outside the scope of  
 11 the environmental review for TMI-1 are not included here, but can be found in the Scoping  
 12 Summary Report (NRC 2008).

13 Scoping comments are grouped in the following categories:

- 14 • Aquatic Ecology
- 15 • Water Quality and Use
- 16 • Terrestrial Resources
- 17 • Air Quality
- 18 • Nonradiological Solid Waste and Hazardous Materials
- 19 • Socioeconomics

- 1 • Human Health
- 2 • Uranium Fuel Cycle and Waste Management
- 3 • Postulated Accidents
- 4 • Alternatives

5

### 6       **A.1.1     Aquatic Ecology**

7       **Comment:** I had – we've had some concerns lately with the area that Three Mile Island is in as  
8 far as fish health. We've had some fish kills there recently, and we believe, not caused  
9 necessarily by TMI, but in the vicinity there is a decline in some fish and a decline in small  
10 mouth bass that we were observing.

11 Let's see. We also have concerns with thermal pollution in this area, and although the amount it  
12 seems that is going into the river is much less than some of the other contributors, we would be  
13 interested to know if there were thermal shock zones in the area similar to Brunner Island which  
14 has problems there where the hot water is meeting the cold water at different times of the year.

15 So although I've talked to one of the NRC biologists earlier, and they said that approximately  
16 one dead fish found per day in the intakes, I'm interested in what's going on in the effluent, and  
17 also the temperatures of that effluent, and the temperature differences between the river  
18 temperatures and the effluent. (TMI-J-1)

19       **Comment:** And also with the thermal impact as brought up, where we are pre-boiling the fish  
20 that you catch, the 102 degree temperatures, we are going to see even increased temperatures  
21 with the droughts that are occurring across the nation, and the thermal impact of nuclear power  
22 plants is going to be pronounced in decades. (TMI-A-1)

23       **Comment:** "Whether the kills are legal or not, a former southern Lancaster County worker at  
24 the Peach Bottom nuclear plant said he was "sickened" by the large numbers of sport fish he  
25 saw sucked out of the Susquehanna. "When the water comes in, fish would swim in through  
26 tunnels and swim into wire baskets," said the man who lives in southern Lancaster County and  
27 asked that his name not be used. "There were hundreds and hundreds of fish killed each day.  
28 Stripers and bass and walleye and gizzard shad and all kinds of fish. It took a forklift to carry  
29 them out. "Every species in the river comes in there when they turn those big intakes on."  
30 (Intelligencer Journal, January 15, 2005) TMI has a similar system for disposing of the fish and  
31 other organisms that make it through the intake maze. "If they get that far, they're not going  
32 back," said Pete Ressler, a spokesman for TMI owner Exelon Nuclear. "They are dumped into a  
33 container and disposed of." Will this system function in the same manner for an additional 20  
34 years? (TMI-F-7)

35       **Comment:** The Environmental Report states that in the early study (IA, 1979) the delta T did  
36 not exceed 5 degrees F while in the later study (2006 and 2007), delta T is often greater than 10  
37 degrees F, and at one point was over 30 degrees. The cause for the increase in temperature  
38 change should be identified, and the potential adverse impacts assessed. Dramatic changes in  
39 temperature can be as detrimental, and sometimes more so, for long-term community  
40 sustainability than high temperatures. Any thermal assessments should also include the volume  
41 of discharged water, as that parameter is important to the delta T. (TMI-O-1)

## Appendix A

1 **Comment:** AmerGen concludes that heat shock issue does not apply to TMI-1 because the  
2 unit does not use once-through cooling. However, it is conceivable that heat shock could be an  
3 issue during extremely low flows or during unusual operations (such as unexpected flow  
4 interruption or loss of York Haven pond). Such potential should be investigated. Again, without  
5 accurate determination of discharge water quantity and temperature, AmerGen's conclusion is  
6 unfounded. (TMI-O-2)

7 **Comment:** *Irreversible and Irrecoverable Resource Commitments.* There is no mention of the  
8 long-term implications to the resource of the facility's thermal discharge. (TMI-O-3)

9 **Comment:** *Short-Term Use Versus Long-Term Productivity of the Environment.* As with the  
10 previous issue, there is no recognition of the potential impact due to the facility's thermal  
11 discharge. (TMI-O-4)

12 **Comment:** The Environmental Report states the number of shad passed (total, high, and low),  
13 but does not compare those numbers to what was passed downstream at Safe Harbor.  
14 Although Safe Harbor is a significant distance downstream, the percentages should at least be  
15 mentioned as a comparison - and to put the overall restoration into context. As with previous  
16 two comments, the quantities of water withdrawn and discharged and their potential effects on  
17 shad movement should be assessed. (TMI-O-5)

18 **Response:** *The comments, in general, express concern regarding the impacts on aquatic*  
19 *organisms resulting from operation of the TMI-1 closed-cycle cooling system. To operate TMI-*  
20 *1, NRC regulations require AmerGen to comply with the Clean Water Act and its associated*  
21 *requirements imposed by the U.S. Environmental Protection Agency (USEPA), as part of their*  
22 *National Pollutant Discharge Elimination System (NPDES) permit. The NRC staff based its*  
23 *analysis of environmental impacts of the TMI-1 license renewal on the GEIS, which was issued*  
24 *in 1996, as amended in 1999. The effects of closed-cycle cooling system operation on aquatic*  
25 *biota are all Category 1 issues. In considering the effects of closed-cycle cooling systems on*  
26 *aquatic ecology in the GEIS, the staff evaluated the same issues that were evaluated for open-*  
27 *cycle systems, including impingement of fish and shellfish, entrainment of fish and shellfish*  
28 *early life stages, and thermal discharge effects. Based on reviews of literature and operation*  
29 *monitoring reports, consultations with utilities and regulatory agencies, and comments on the*  
30 *draft GEIS, these potential effects have not been shown to cause reductions in the aquatic*  
31 *populations near any existing nuclear power plants.*

32 *No change in operation of the TMI-1 cooling system is expected during the license renewal*  
33 *term, so no change in effects of cooling towers on aquatic biota in the Susquehanna River is*  
34 *anticipated. However, as part of its review the NRC staff looked for any new and additional*  
35 *information that might call into question the conclusions reached in the GEIS for Category 1*  
36 *issues – no new and significant information was identified, therefore, there are no impacts*  
37 *beyond those discussed in the GEIS.*

38 **Comment:** It appears that all of the presented information and conclusions are based on data  
39 at least 18 years old. Reference is made to monitoring conducted from 1974-1982 and through  
40 1990, but nothing more recent, and there is no mention of the quantity of water withdrawn and  
41 whether that has changed over time. The environmental assessment for relicensing should

1 require the collection of new monitoring data and evaluation of that data and any changes it  
2 shows. (TMI-O-6)

3 **Response:** *The NRC staff recognizes that the amount and quality of data available for NEPA*  
4 *evaluations sometimes falls short of ideal, but believes that there is sufficient information*  
5 *available to perform an assessment of the impacts of license renewal at TMI-1. Furthermore,*  
6 *NRC cannot require the collection of additional aquatic ecology data to support preparation of*  
7 *the draft supplemental environmental impact statement (EIS). NRC staff used the best*  
8 *available information, drawing from a variety of sources including data collected by AmerGen,*  
9 *the Pennsylvania Fish and Boat Commission, the Susquehanna River Basin Commission, other*  
10 *governmental agencies, independent researchers, and others. If new and significant*  
11 *information becomes available in the future that demonstrates a significant impact to the aquatic*  
12 *environment as a result of continued station operation, the staff would expect the Pennsylvania*  
13 *Department of Environmental Protection (PADEP) to require modifications to station operation*  
14 *as necessary to protect aquatic resources through the NPDES permitting process.*  
15

#### 16 **A.1.2 Water Quality and Use**

17 **Comment:** I am Andrew Dehoff. I'm the director of planning and operations at the  
18 Susquehanna River Basin commission in Harrisburg. First off I'd like to thank NRC and  
19 AmerGen staff for including us in the informational briefings and the facility tours that took place  
20 earlier this week. It was very helpful.

21 SRBC is still at the stage of gathering information, and as such don't have comments, specific  
22 comments, ready to share today, but we will be submitting written comments by the deadline.

23 Preliminarily I can offer that SRBC's main concerns would be related to the water withdrawn  
24 from the river for plant operations, and the water used onsite, and also any changes to  
25 operations or equipment that would affect the water use on site. Some examples of other  
26 issues, we might be commenting on, would relate to the facility and its situation on the river.  
27 And by that I mean flood preparedness and drought preparedness, and the fact that there is a  
28 great deal more water use both upstream and downstream of TMI than there was when the  
29 plant began operating. Finally just a thank you to NRC for hosting this open house today, and  
30 giving us the opportunity to speak. (TMI-E)

31 **Comment:** How does the NRC plan to deal with the following water related issues and  
32 structural challenges caused by: Micro fouling versus macro foiling, micro biologically influenced  
33 corrosion, biofilm's disease causing bacteria such as Legionella and listeria, the difficulty in  
34 eliminating established biofilms, oxidizing versus nonoxidizing biocides, chlorine versus bleach,  
35 alkaline versus non-alkaline environments, possible decomposition into carcinogens, and the  
36 eastward migration of Asiatic clams, zebra mussels and the anticipated arrival quagga mussels?  
37 (TMI-F-8)

38 **Comment:** *Drinking Water.* In Section 2.91 of the Environmental Report (ER), Dauphin County  
39 is listed as having 14 public water systems. According to the Safe Drinking Water Act (SDWA)  
40 definition of a public water system, that number is incorrect. The SDWA definition of a public  
41 water supply is: *a system which provides water to the public for human consumption which has*

## Appendix A

1 *at least 15 service connections or regularly serves an average of at least 25 individuals daily at*  
2 *least 60 days out of the year.* The definition goes on to define a community water system as: *a*  
3 *public water system which serves at least 15 service connections used by year-round residents*  
4 *or regularly serves at least 25 year-round residences.* Dauphin County residents are currently  
5 served by 28 community public water supplies. The population listed for two of the largest  
6 community water supplies also appears to be incorrect; the population for United Water  
7 Pennsylvania and Pennsylvania American Water Company – Hershey should be verified with  
8 the water companies.

9 Table 2.9-1 of the ER lists the community public water supplies in Dauphin County that serve  
10 more than 10,000 persons. The data provided for United Water Pennsylvania should be verified  
11 because it is not correct. Also, Middletown Borough Water Authority should be included in this  
12 table. Middletown's population (including two consecutive water systems that receive all their  
13 water from Middletown) is 10,247 persons.

14 In Section 2.3, 4.15.1 and 4.15.2, the ER states that the plant does not use water from a public  
15 water system. The SDWA defines a nontransient noncommunity public water system as: *a*  
16 *public water system which is not a community water system that regularly serves at least 25 of*  
17 *the same persons over six months per year.* Based on this definition, the Three Mile Island  
18 facility is a public water system and provides potable water to the plant population. (TMI-N-1)

19 **Comment:** It was observed during the site tour that soil has eroded from around and behind  
20 the headwall at Outfall 001. Backfilling around and behind the headwall may be necessary to  
21 prevent damage to the discharge line. (TMI-N-2)

22 **Comment:** Although generally satisfied with the ground water explanation, the 'glacial'  
23 materials could not in fact have been deposited by glaciers as their limit of extent is some 20  
24 miles north of TMI. Water in the Gettysburg shale is commonly considered to be semi-confined  
25 and not artesian. (TMI-O-7)

26 **Comment:** SRBC has approved Wells 1, 2, and 3 (aka A, B, C) for industrial water supply and  
27 is perplexed to learn that the OSF Well is also used to augment the supply of service water. If  
28 this is the case, the well would require review and approval by SRBC. (TMI-O-8)

29 **Comment:** *EPA-Regulated Facilities in Dauphin, Lancaster and York Counties.* Review of the  
30 impacts of extending TMI's license should include analysis of potential effects of TMI's water  
31 use and thermal discharge on the operations and/or waste assimilation capability of  
32 downstream withdrawals and discharges; likewise, the operation, withdrawals and discharges of  
33 upstream facilities should be analyzed for potential impacts to TMI's operations and thermal  
34 discharge assimilation. (TMI-O-9)

35 **Comment:** The potential for nearby power facilities to impact TMI's operations, and vice versa,  
36 should be evaluated. Of particular concern is operations during periods of severe low flow and  
37 extreme temperatures, including heat and river ice conditions. (TMI-O-10)

38 **Comment:** What is the auxiliary water? What are the provisions for backup supply? What is  
39 the source of auxiliary? Has it been sufficiently reviewed, and does it have the appropriate  
40 permits? (TMI-O-11)



- 1 **Comment:** AmerGen concludes that any impacts caused by TMI-1 make-up water withdrawal  
2 would be "SMALL" and would not warrant additional mitigation. What is the conclusion based  
3 on? How small is "SMALL"? The assumptions and conditions used in the analysis should be  
4 provided; they may not be valid if the same assumptions and conditions were used as in the  
5 original siting study 40 years ago. In particular, the amount of other consumptive water use on  
6 the river both upstream and downstream of TMI has changed dramatically, and will continue to  
7 grow. Natural hydrologic conditions may also have changed. Without a demonstration of  
8 accurate accounting for water withdrawal and discharge, it is impossible to assess potential  
9 impacts to downstream water users. (TMI-O-12)
- 10 **Comment:** The assessment should include the potential impact of all ground water wells on  
11 site. The conclusions presented in the Environmental Report are based on the well withdrawals  
12 already approved by SRBC; however, there is at least one additional unapproved well in  
13 production. The 1996 pump tests cited by AmerGen do not include any unapproved wells, and  
14 are thus insufficient to evaluate potential ground water use conflicts.
- 15 The use of additional unapproved wells has likely increased the quantity of ground water  
16 withdrawal on site. It appears that all ground water evaluations in the Environmental Report are  
17 based on the withdrawal quantity from approved wells only; all assessments involving ground  
18 water impacts or conflicts should be performed again using an accurate value for total ground  
19 water withdrawal.
- 20 Applicant should assess the potential ground water conflicts among wells in their own system, to  
21 ensure their long-term viability. (TMI-O-13)
- 22 **Comment:** What is the basis for the conclusion by AmerGen that the impacts of the river  
23 withdrawal to local ground water are small? The details of that analysis should be made  
24 available for review.
- 25 As the Environmental Report states, SRBC directs the release of storage on behalf of TMI  
26 during times of drought. However, the quantity released is equivalent only to the consumptive  
27 loss at the plant, and not the total withdrawal, which is considerably greater. Further,  
28 replacement releases are made only during very severe droughts, and not during moderate  
29 droughts and other short-term periods of unusually low flows. Thus, despite releases by SRBC,  
30 there remains the potential for ground water impacts due to the difference between total  
31 withdrawal and consumptive loss, and during periods of moderate and short-term severe  
32 droughts. These potential impacts should be assessed.
- 33 There is no documentation presented demonstrating that TMI-1's surface water withdrawal is  
34 capturing only river water, and not also drawing ground water from the adjacent aquifer. (TMI-  
35 O-14)
- 36 **Comment:** In addition to the impacts listed, other unavoidable impacts include thermal  
37 discharge and localized impacts of the river withdrawal. There may be others. (TMI-O-15)
- 38 **Comment:** Not listed among the resource commitments is the water demand. The water lost  
39 through plant operations is removed from the Susquehanna River Basin forever, and it is a  
40 cumulative loss that will continue through the end of license period. The long-term commitment  
41 and ultimate loss of that water renders it unavailable for use by any other power plant, water

## Appendix A

1 supply intake, recreational interest, aquatic habitat, or inflow to Chesapeake Bay. It is also  
2 important to note that renewal of the license commits that water in such a way that it is also  
3 unavailable to uses upstream of TMI, in order to ensure its continued availability for use at the  
4 plant. It is unexpected to find that AmerGen would overlook a resource as critical and integral to  
5 plant operations, as well as to the natural, social and economic development of the entire  
6 region, in its Environmental Report. (TMI-O-16)

7 **Response:** *The comments, in general, pertain to the plant's consumptive use of surface water*  
8 *from the Susquehanna River, ground water resources in the vicinity of TMI-1, the plant's use of*  
9 *ground water, and the plants impact on surface and ground water quality. Surface and ground*  
10 *water use and water quality issues, including cumulative impacts, are Category 2 issues and are*  
11 *addressed in Sections 2.1.7, 2.2.3, 2.2.4, 4.3, and 4.4 of this draft supplemental EIS.*

12 **Comment:** *Water Quality.* During steam generator replacement, high pressure water will be  
13 used to cut openings in the Unit 1 containment building. The containment building walls are  
14 made of concrete and are approximately 3 feet thick. According to AmerGen personnel, a  
15 temporary package plant will be used to treat wastewater from cutting activities (i.e., to settle  
16 suspended concrete particles and adjust pH) before discharge to the Susquehanna River. A  
17 temporary discharge permit is required for this plant. As an alternative, wastewater from this  
18 operation can be collect and sent off-site for treatment. Under no circumstances should this  
19 wastewater stream be sent to the existing wastewater treatment plant. Also, AmerGen should  
20 notify the DEP once the package plant is installed so DEP personnel can inspect it and sample  
21 the discharge. (TMI-N-3)

22 **Comment:** *Water Resources.* If transportation of the new generators along Pennsylvania  
23 highways or bridges requires any transportation system upgrades or other work, that work may  
24 encroach upon wetlands or waterways. Federal and State wetlands and stream encroachment  
25 permits or authorizations may be required for such encroachments. A 401 certification may also  
26 be necessary. Contrary to the statement made in the EIS, TMI's National Pollutant Discharge  
27 Elimination System (NPDES) permit (i.e., discharge permit) does not carry with it a new 401  
28 certification. (TMI-N-4)

29 **Comment:** An erosion and sedimentation plan, and possibly a construction stormwater NPDES  
30 permit, will be required for earth disturbance associated with the new building construction.  
31 (TMI-N-5)

32 **Response:** *The comments pertain to AmerGen's planned replacement of the TMI-1 once-*  
33 *through steam generators. Environmental impacts of refurbishment activities are evaluated in*  
34 *Chapter 3 of this draft supplemental EIS. Impacts of refurbishment on ground water and*  
35 *surface water use and quality were examined in the GEIS and are Category 1 impacts. During*  
36 *its review the NRC did not identify any new and additional information that would call into*  
37 *question the conclusions reached in the GEIS for Category 1 issues. Chapter 3 also addresses*  
38 *the impact of refurbishment activities on threatened and endangered species, including aquatic*  
39 *species that may be impacted by erosion into and sedimentation of the Susquehanna River.*  
40

### 1       **A.1.3     Terrestrial Resources**

2       **Comment:** AmerGen should consider enhancement of the created open-water wetlands  
3 established on-site from the original plant excavations. Such enhancements would be used to  
4 offset any impacts to aquatic resources that may occur as the result of its intake or other project  
5 activities. (TMI-N-6)

6       **Comment:** What is the value and quality of the wetlands that have been formed from the  
7 borrow pits? Consideration should be given to undertaking some enhancement features -  
8 perhaps in conjunction with a local environmental group. (TMI-O-17)

9       **Response:** *The potential impacts of the continued operation of TMI-1 on terrestrial ecology is a*  
10 *is addressed in Sections 2.2.6 and 4.6. Impacts of continued operation on terrestrial ecology*  
11 *were examined in the GEIS and are Category 1 impacts. During its review, the NRC did not*  
12 *identify any new and additional information that would call into question the conclusions reached*  
13 *in the GEIS for Category 1 issues. Impacts of continued operation to protected terrestrial*  
14 *species is a Category 2 issue and is addressed in Sections 2.2.7 and 4.7 of this draft*  
15 *supplemental EIS.*  
16

### 17       **A.1.4     Air Quality**

18       **Comment:** *Asbestos.* As the date of construction falls within the general timeframe when the  
19 use of asbestos-containing materials (ACM) was phased out, there is some possibility that ACM  
20 maybe be present on-site. In the event that the project includes disturbance of any ACM, it may  
21 be subject to the federal asbestos regulations found at 40 CFR Part 61, Subpart M, beginning at  
22 40 CFR 61.140. (TMI-N-7)

23       **Comment:** *Fugitive Emissions.* Construction and earthmoving activities must comply with 25  
24 Pa. Code Sections 123.1 and 123.2. These sections generally require that: 1) reasonable  
25 measures must be taken to minimize airborne dust nuisances from construction activities, 2)  
26 any dirt drag-out onto paved streets must be promptly removed, and 3) any airborne dust  
27 generated from construction activities may not visibly cross off-property. (TMI-N-8)

28       **Response:** *The comments pertain to impacts to air quality during AmerGen's planned*  
29 *replacement of the TMI-1 once-through steam generators. Impacts to air quality during*  
30 *refurbishment activities is a Category 2 issue and is evaluated in Section 3.2.3 of this draft*  
31 *supplemental EIS.*  
32

### 33       **A.1.5     Nonradiological Solid Waste and Hazardous Materials**

34       **Comment:** AmerGen should consider deconstruction and salvage to reduce waste disposal to  
35 the extent possible. All construction and demolition waste that cannot be salvaged or recycled  
36 should be properly transported and disposed of at a DEP-permitted facility. Open burning of  
37 waste is not acceptable. (TMI-N-9)

## Appendix A

1 **Comment:** Documentation should be provided demonstrating that the flood protection dike – or  
2 the location and storage of hazardous material – ensures there is protection from contamination  
3 during the flood of record. (TMI-O-18)

4 **Response:** *Nonradioactive waste management and pollution prevention is discussed in*  
5 *Section 2.1.3 of this draft supplemental EIS. The staff reviewed the plant's protocols for storing*  
6 *and managing hazardous materials on site, however, the Pennsylvania Department of*  
7 *Environmental Protection has ultimate authority in implementing regulations regarding the*  
8 *treatment, storage, and disposal of hazardous materials.*  
9

### 10 **A.1.6 Socioeconomics**

11 **Comment:** How many people work at TMI-1? How many people worked at TMI-1 when  
12 AmerGen purchased the plant from GPU? How many people does the NRC project will be  
13 working at TMI-1 in 20 years? Can you factor economics, staffing levels, or the tax base into a  
14 relicensing decision? (TMI-F-10)

15 **Response:** *The comments are related to the socioeconomic impacts associated with the*  
16 *continued operation or closure of TMI-1. Socioeconomic impacts such as housing,*  
17 *transportation, employment, and land use are Category 2 issues and are addressed in Sections*  
18 *2.2.8 and 4.9 of this draft EIS.*  
19

### 20 **A.1.7 Human Health**

21 **Comment:** TMI is located on Susquehanna River so any leaking contaminants from waste  
22 storage facilities will flow towards and eventually into the Bay. There are no monitoring wells  
23 lining the shoreline. Tritium and other leaks – examples and NRC policy on self-monitoring -  
24 also exist at Three Mile Island. How has the NRC changed modified its relicensing process to  
25 evaluate tritium monitoring? (TMI-F-11)

26 **Comment:** It was reported last year that tritium was being found in the ground water. We  
27 would like to know the extent of that, where the plumes of this are; also whether we can expect  
28 this to be increasing. Don't know that much about it, so I'd like to learn a lot more. But  
29 obviously when we are dealing with radiation and things with potentially very long half-lives,  
30 bioaccumulate – or accumulation in the environment is definitely a concern. So even though we  
31 were all – supposedly our concerns were quelled last year that these levels were not very high,  
32 if this is an ongoing issue, we would definitely want to know more about that, and have some  
33 kind of comparison to a more virgin area, perhaps somewhere far from nuclear reactors, that we  
34 might be able to get a better comparison of that. (TMI-J-2)

35 **Comment:** In sections 2.2.3 and 5.1, the report mentions an Environmental Protection Agency  
36 (EPA) drinking water standard for tritium of 20,000 pCi/L, which is used as a reference value to  
37 add perspective to results obtained in the their ground water monitoring program. Based on the  
38 method EPA uses to calculate the maximum contaminant level (MCL) for beta particle and  
39 photo radioactivity (of which tritium is a constituent), the report should have referenced the fact  
40 that gross beta analysis is routinely conducted and tritium is the only constituent which is

1 detected in the samples. The clarification would better explain what contaminants are analyzed  
2 for, which have been detected, and how they relate to EPA's drinking water standards. (TMI-N-  
3 10)

4 **Comment:** AmerGen references data presented in Section 2.3 on ground water resources at  
5 TMI, concluding that tritium in the on-site ground water is not a threat to nearby ground water  
6 sources because the Susquehanna River acts as a boundary between the island and the  
7 aquifers on the east and west shore. If that is the case, what amount of tritium is being  
8 delivered to and carried away by the Susquehanna River? What is the potential impact to the  
9 aquatic community of such delivery? Have the appropriate regulatory agencies been properly  
10 notified? (TMI-O-19)

11 **Comment:** I would be very interested in getting some biological studies of the macro-  
12 invertebrates in the area, including radiation testing. I would also like someone to look at the  
13 mussels. The mussels are very much ignored in the Susquehanna River, but throughout the  
14 United States, 70 percent of our mussel species are endangered or threatened. And the  
15 mussels are the longest living thing I believe in the river. Some mussels – we are not entirely  
16 sure how long some of them live, but some of them have been known to live 120 years. The  
17 ones that we know of in the Susquehanna live up to 40 years, and we think that testing the  
18 mussels would be a good gauge of telling radiological bioaccumulation. (TMI-J-3)

19 **Comment:** The greater number of adverse health effects from nukes occur predominantly  
20 downwind and go further than five miles, depend on atmospheric conditions and in the older  
21 plants (which now include all U.S. nukes) – case the classic mutations in flora and fauna  
22 exposed. Which includes much of the food we eat. Mutated tomatoes, yellow squash, zucchini,  
23 peaches, plums, corn, turnips and even a Heinz pickle have been grown, not only from TMI  
24 country a few other areas as well. Do you care? (TMI-H-1)

25 **Comment:** Are the existing monitoring wells adequate (appropriate locations and density) to  
26 capture any problems? Has the risk of radwaste on the island contaminating local aquifers or  
27 water supply wells been assessed? Is there any need to consider monitoring quality and  
28 quantity at some neighboring residences or businesses? (TMI-O-20)

29 **Comment:** Radioactive Liquid Waste Disposal System: There is no mention of restrictions to  
30 liquid radwaste discharge during periods of low flow. There should be an analysis of  
31 appropriate flow thresholds below which it is inadvisable to discharge radwaste. There is no  
32 discussion in the application of precautions against spills or other accidental introduction of  
33 radwaste to surface or ground water. (TMI-O-21)

34 **Response:** *NRC regulations require licensees to control and limit radioactive releases,*  
35 *including tritium, to the environment (the air and water) to very small amounts. As part of the*  
36 *NRC requirements for operating a nuclear power facility, licensees must keep releases of*  
37 *radioactive material into the environment during normal operations as low as is reasonably*  
38 *achievable (ALARA), as required by 10 CFR Part 50.36a, and comply with radiation dose limits*  
39 *for the public in 10 CFR Part 20. For liquid discharges, the ALARA standard is to keep the*  
40 *annual dose to a member of the public to no more than 3 mrem. In comparison, the annual*  
41 *dose to an average member of the public from background radiation is approximately 300*  
42 *mrem.*

## Appendix A

1 TMI-1 conducts a radiological environmental monitoring program (REMP) in which radiological  
2 impacts to the environment and the public around the TMI-1 site are monitored, documented,  
3 and compared to NRC standards. AmerGen summarizes the results of their REMP in an  
4 Annual Radiological Environmental Operating Report. The reports are publicly available on the  
5 NRC's public website. The purpose of TMI-1's REMP is to:

- 6 • Evaluate the relationship between quantities of radioactive material released from the  
7 plant and resultant radiation doses to individuals from principle pathways of exposure;
- 8 • Provide data on measurable levels of radiation and radioactive materials in the site  
9 environs;
- 10 • To verify in-plant controls for the containment of radioactive materials;
- 11 • To determine buildup of long-lived radionuclides in the environment and changes in  
12 background radiation levels;
- 13 • To provide reassurance to the public that the program is capable of adequately  
14 assessing impacts and identifying noteworthy changes in the radiological status of the  
15 environment; and
- 16 • To fulfill the requirements of the TMI-1 Technical Specifications.

17  
18 The REMP samples environmental media in the environs around the site to analyze and  
19 measure the radioactivity levels that may be present. The media samples are representative of  
20 the radiation exposure pathways to the public from all plant radioactive effluents. The REMP  
21 measures direct radiation, the airborne, and the waterborne pathways for radioactivity in the  
22 vicinity of the TMI-1 site. Direct radiation pathways include radiation from buildings and plant  
23 structures and airborne material that may be released from the plant. In addition, the REMP  
24 also measures background radiation (i.e. cosmic sources, and naturally occurring radioactive  
25 material, including radon and global fallout). Thermoluminescent dosimeters (TLDs) are used to  
26 measure direct radiation. The airborne pathway includes measurements of air, precipitation,  
27 drinking water, and broad leaf vegetation samples. The waterborne pathway consists of  
28 measurements of surface water, drinking water, effluent water, storm water, ground water, and  
29 fish and sediment from the Susquehanna River.

30 For TMI-1, the waterborne pathway consists of Susquehanna River water, fish and  
31 invertebrates, aquatic vegetation, bottom sediment, and shoreline soil. The NRC requires that  
32 only commercially or recreationally important species in the vicinity of the discharge point be  
33 sampled and analyzed. Other species, like mussels, while present in the area, do not represent  
34 a significant dose pathway to humans and are not required to be discussed in the radiological  
35 environmental report.

36 The REMP provides measurements of radiation and of radioactive materials in those exposure  
37 pathways and for those radionuclides which lead to the highest potential radiation exposure to  
38 members of the public. It does not require that every type of environmental media or biota in  
39 the area be sampled and analyzed.

40 The results of the REMP are intended to supplement the results of the radiological effluent  
41 monitoring program by verifying that the measurable concentrations of radioactive material and  
42 levels of radiation are not higher than expected on the basis of the effluent measurements and  
43 modeling of the environmental exposure pathways. The two programs work together as a

1 *check against each other. The 2007 Annual Radiological Environmental Monitoring Report for*  
2 *TMI-1 can be viewed in the ADAMS Public Electronic Reading Room, at accession number*  
3 *ML081300255.*

4 *In addition to the routine REMP, starting in 2006, AmerGen implemented a ground water*  
5 *monitoring program at TMI-1. This monitoring program was added by AmerGen to assure that*  
6 *potential liquid release pathways were being thoroughly evaluated. The program is used to*  
7 *characterize any onsite contamination, to quantify and determine its potential onsite and offsite*  
8 *radiological impact to the workers, public and surrounding environment, and to aid in*  
9 *identification and repair of any leaking systems, structures, or components.*

10 *As noted in one of the comments, in September 2005, TMI-1 had a localized tritium leakage*  
11 *inside a utility access manway in the owner-controlled area. The highest concentration of tritium*  
12 *detected in one water sample from inside the manway was 45,000 picoCuries per liter. The*  
13 *U.S. Environmental Protection Agency's drinking water standard is 20,000 picoCuries per liter;*  
14 *however this water is not used for drinking. The leak was found and fixed. Sampling conducted*  
15 *at nearby ground water wells did not have elevated levels of tritium. State and federal officials*  
16 *were informed of the issue and kept updated throughout the event. A detailed discussion of the*  
17 *inspection performed by the NRC for this event can be found in the ADAMS Public Electronic*  
18 *Reading Room, at accession number ML062070664.*

19 *The radiological effluent monitoring and environmental monitoring programs are part of the*  
20 *NRC's routine inspection program of every nuclear power plant to ensure compliance with*  
21 *regulatory requirements. For license renewal, the NRC staff reviewed these areas and*  
22 *discussions are presented in Sections 2.1.2 and 4.8 of this draft supplemental EIS.*

23 **Comment:** AmerGen has implemented a long-term ground water monitoring effort at TMI-1  
24 referred to as the Radiological Ground Water Protection Program (RGPP). Prior to AmerGen's  
25 submittal of the license application to the Nuclear Regulatory Commission (NRC), DEP had  
26 requested that the licensee provide a description of the TMI-1 RGPP. Although the inclusion of  
27 this program in the license renewal application is not required by the Nuclear Regulatory  
28 Commission (NRC), AmerGen responded favorably to DEP's request. The program description,  
29 as included in the Environmental Section of the license renewal application (Appendix E),  
30 indicates that a primary purpose of the RGPP is to provide timely detection and response to  
31 any radiological releases to ground water. Based on the information provided in this document  
32 and DEP's independent review of the TMI-1 RGPP, it has concluded that AmerGen has taken  
33 appropriate measures to protect public health and safety and the environment, both during  
34 current and extended periods of TMI-1 operations. DEP will continue to monitor AmerGen's  
35 activities in this area. This effort includes frequent interactions with the TMI-1 Environmental  
36 Monitoring Program staff and sampling of selected on-site monitoring wells, as deemed  
37 necessary. (TMI-N-11)

38 **Response:** *Sections 4.8 and 4.9.7 of this draft supplemental EIS contain the NRC staff's*  
39 *evaluation of the applicant's environmental monitoring program.*

40 **Comment:** DEP participated in the NRC's environmental audit of TMI-1 license renewal  
41 application during the week of April 28, 2008. At the time of the audit, DEP requested additional  
42 information regarding the Solid Waste Staging Facility (SWSF) at TMI-1. This facility is a

## Appendix A

1 passive system for temporary staging of radioactive waste prior to shipment to a disposal facility.  
2 The information requested by DEP includes a description of the system design, a description of  
3 the facility leak collection and monitoring systems, and a document identifying on-site  
4 monitoring wells within the SWSF area. DEP has reviewed the information provided by  
5 AmerGen and has no concerns. However, DEP staff will continue to perform on-site  
6 surveillances at the TMI site to verify the condition of the SWSF and to periodically review the  
7 sample results from the adjacent monitoring wells. (TMI-N-13)

8 **Response:** *This comment is general in nature, regarding the TMI-1 Solid Waste Staging*  
9 *Facility and on-site monitoring wells. The comment provided no new and significant information,*  
10 *and was not evaluated further.*

11 **Comment:** Have the owners of TMI-1 reassessed the National Academy of Science's  
12 statements on the harmful effects of low dose radiation exposure? After learning this from Dr.  
13 Helen Caldicott and Dr. Carl Johnson 29 years ago – the truth about the lower levels of radiation  
14 exposure has finally been realized by National Academy of Science! (TMI-H-2)

15 **Response:** *The GEIS evaluated human health issues and determined them to be a Category 1*  
16 *issue. The amount of radioactive material released from nuclear power facilities is well*  
17 *measured, well monitored, and known to be very small. The doses of radiation that are*  
18 *received by members of the public as a result of exposure to nuclear power facilities are so low*  
19 *that resulting cancers have not been observed and would not be expected. A number of studies*  
20 *of cancer incidence in the vicinity of nuclear power facilities have been conducted and there are*  
21 *no studies to date that are accepted by the scientific community that show a correlation between*  
22 *radiation dose from nuclear power facilities and cancer incidence in the general public. The*  
23 *comments were noted but provided no new and significant information and were not evaluated*  
24 *further.*  
25

### 26 A.1.8 Uranium Fuel Cycle and Waste Management

27 **Comment:** Paducah, Kentucky, talking about the – one speaker just a few minutes ago  
28 mentioned that there is no greenhouse gases released. That is not accounting for the mining  
29 and the whole fuel cycle which you would probably have to take into effect when they do an  
30 analysis, but the NRC is not going to look at that when it comes to operating this specific plant.

31 Paducah, Kentucky, emitted – one enrichment facility was emitting 88 percent of all United  
32 States CFC ozone-eating gas, 88 percent of all those produced gases came from that plant.  
33 That's – that was pretty bad. Fortunately they fixed some of those leaks in the refrigeration  
34 system. (TMI-A-4)

35 **Response:** *The carbon footprint of nuclear energy (including its fuel cycle) and alternative*  
36 *energy sources is an air quality issue. Air quality issues were evaluated in the GEIS and*  
37 *determined to be Category 1 issues. Although these comments do not provide any new and*  
38 *significant information on air quality pertaining to the relicensing of TMI-1, the carbon footprint of*  
39 *nuclear power versus other alternate energy sources is addressed in Chapter 8 (alternatives) of*  
40 *this draft EIS.*



1 **Comment:** Barnwell S.C. announced that it will close to generators on June 20, 2008. The  
2 NRC staff concluded that there was no new and significant information and therefore there  
3 would be no impacts of low level waste storage and disposal associated with the renewal term.  
4 The GEIS stated that, "...The maximum additional on-site land that may be required for low-  
5 level waste storage during the term of a renewed license and associated impacts will be small."  
6 TMI is located on Susquehanna River so any leaking contaminants from waste storage facilities  
7 will flow towards and eventually into the Bay. There are no monitoring wells lining the shoreline.  
8 We deserve to know what the LLRW storage plans are before the application is decided; so that  
9 the re-licensing decision does not prejudice any LLRW storage decision. Where will the LLRW  
10 going to be stored? For how long? And will the location be above the flood plain? (TMI-F-15)

11 **Response:** *The comment is related to the environmental impacts associated with Low Level*  
12 *Radioactive Waste Management (LLRW), which was evaluated in the GEIS and determined to*  
13 *be a Category 1 issue. The GEIS evaluated impacts associated with LLRW management for all*  
14 *plants, including TMI-1, and determined that the impact was small. During the plant-specific*  
15 *environmental review of TMI-1, the NRC staff reviewed the future actions planned to be taken at*  
16 *the TMI-1 site for the storage of LLRW (see Section 2.1.2.3) and did not identify any new and*  
17 *significant information that would call into the question the conclusions contained in the GEIS*  
18 *regarding LLRW.*

19

#### 20 **A.1.9 Postulated Accidents**

21 **Comment:** A few points to address some other things that came up after I spoke. The  
22 atmospheric sciences, I saw that is part of the environmental concerns, seems to me  
23 recognition by the nuclear industry that the atmosphere is changing; that there is more energy;  
24 that global warming may be occurring. They are certainly advertising to that extent to have  
25 people view nuclear power more favorably.

26 And if that were true then we do need to study the fact that the weather has more energy, and  
27 tornadoes are more severe, floods are more severe. There is a trend growing. It's not hard to  
28 see that in the next 10 to 20 years there could be some serious problems with tornadoes at  
29 nuclear plants like what happened at Davis-Besse a few years ago where the control room  
30 operator said, when they went into a station blackout situation, that their hearts went into their  
31 throat until finally things started to settle down a little bit. But at first they had power problems  
32 where they couldn't even read their control panels.

33 So I'd like to see that issue also cross-ties in with the security issues, where the loss of off-site  
34 power and station blackout can be caused by terrorism. The same thing can happen with a  
35 tornado, and that we need redundancy systems for – to prevent station blackout. There has  
36 been some discussion of that with the security discussions, but with environmental impact  
37 assessment including atmospheric sciences, I think that falls there too. So we've got to look at  
38 the floods. Don't forget, we had a bad flood in 1972, excuse me, the Agnes Flood, which  
39 flooded Three Mile Island. (TMI-A-6)

40 **Comment:** "AmerGen prepared this sever accident mitigation alternatives analysis... with  
41 support from it's parent company, Exelon." In case of another accident at TMI, and since  
42 AmerGen received the support from its parent company, Exelon, will Exelon also be held liable

## Appendix A

1 for costs and damages to the offsite humans, fauna and flora? Based on the continuing  
2 adverse effects caused by TMI-1's brother plant, TMI-2, State, Federal, and local governments  
3 must demand accountability next time – as many failed their constituents while, while few  
4 helped. (TMI-H-5)

5 **Comment:** “Benefits, costs, and net value of implementing potential S.A.M.A.’s” – Your cost-  
6 risk benefits have never been humane – benefitting only corporate profits (as usual – the NRC’s  
7 actions assist those they are to regulate instead of health and safety of those paying taxes to  
8 play their employees.) Remember Davis-Besse?

9 Cost-Risk benefits actually should only be for promoting and protecting the life and health of  
10 humans, flora and the planet. Corporate greed is the predominant cause of our earth in distress  
11 from global warming and also nuclear-atomic zapping! Bomb fallout and Chernobyl dust is still  
12 circling the planet and TMI mutations 29 years later are still growing – with another bumper crop  
13 this year! (TMI-H-6)

14 **Comment:** Ground Water use must be considered a significant issue due to the fact that  
15 nuclear plan uptake of water is only possible with what nature provides, and as the earthquakes  
16 in China (5/2008) caused flow of rivers to cease and become a lake instead – you must be  
17 prepared for the unexpected. Especially since TMI-1 and TMI-2 are on an earthquake fault line.  
18 Remember April 22, 1984, where the meter was set so high it didn't register the quake – but the  
19 control room operators did feel the 4.0 quake, centered in Lancaster County, under TMI and  
20 under my home as well. (TMI-H-16)

21 **Comment:** A reassessment of likely flood scenarios should be performed. The original  
22 assumptions related to the hydrology, flow patterns, and flood return intervals of the  
23 Susquehanna River are likely outdated, and certainly do not account for potential changes over  
24 the course of the extended license period due to climate change or other phenomena. (TMI-O-  
25 26)

26 **Response:** *The comments are related to the impacts of design basis accidents and severe*  
27 *accidents. The impacts of design basis accidents were evaluated in the GEIS and determined*  
28 *to be small for all plants; therefore, it is a Category 1 issue. The impact of severe accidents is a*  
29 *Category 2 issue and must have a site-specific evaluation. Additionally, alternatives to mitigate*  
30 *severe accidents must be considered for all plants that have not considered such alternatives.*  
31 *The applicant provided a severe accident mitigation alternatives (SAMA) analysis as part of the*  
32 *license renewal application for TMI-1. The NRC staff's review of the SAMA analysis is*  
33 *discussed in Section 5.3 and Appendix F of this draft supplemental EIS for TMI-1.*  
34

### 35 **A.1.10 Alternatives**

36 **Comment:** Number one is conservation. Also energy created on site, on homes – not by  
37 greedy corporate energy producers. The hydrogen fuel cell home created by college students  
38 had a cost to build – but once built the cost of energy to operate the home was a big, fat zero =  
39 \$0. Antiquated machinery is currently still in use because the money goes to support and  
40 finance nukes. Ancient Greece used solar and so did Florida – until electricity came along.

1 The time to change was 29 years ago – you obviously did not learn the lessons – even after  
2 Chernobyl. Shut-down nuclear TMI-1, put windmills on your cooling towers, solar on your  
3 parking lots – hydro from your little dam – non-tritiated water for geothermal under your ground  
4 – waste and non-food biomass. And conservation! No more subsidies to you for your ultra-  
5 hazardous (atomic bomb making) method of energy production. But going solar is what I  
6 recommend for your future. So that our will have a future. (TMI-H-4)

7 **Comment:** The assessment of alternatives in Chapter 7 is limited entirely to alternatives for  
8 power production in lieu of continued operation of TMI. An evaluation should also be conducted  
9 of alternatives to specific current operating practices at TMI that would allow continued  
10 generation at the plant, but with lesser impacts to the air, soil, and water resources of the  
11 region. Technology has advanced a great deal in the 40 years that have passed since the  
12 design of TMI-1, and its adoption and use on-site should be investigated as a condition of  
13 license renewal. (TMI-O-23)

14 **Response:** *The comments are related to the environmental impacts of alternatives to license*  
15 *renewal for TMI-1. Environmental impacts associated with various reasonable alternatives,*  
16 *including a combination of energy sources, conservation, coal and natural gas, to renewal of the*  
17 *operating licenses for TMI-1 is evaluated in Chapter 8 of this draft supplemental EIS.*  
18

## 19 A.2 References

20 73 FR 16729. U.S. Nuclear Regulatory Commission, Washington, D.C, “Three Mile Island  
21 Nuclear Station, Unit 1; Notice of Intent to Prepare an Environmental Impact Statement and  
22 Conduct Scoping Process.” *Federal Register*: Vol. 73, No. 61, pp. 16729–16731. March 28,  
23 2008.

24 NRC (U.S. Nuclear Regulatory Commission). 2008. “Environmental Impact Statement Scoping  
25 Process Summary Report, Three Mile Island Nuclear Station, Unit 1.” ADAMS Accession No.  
26 ML081920230.



## **Appendix B**

### **NEPA Issues for License Renewal of Nuclear Power Plants**



## B. NEPA Issues for License Renewal of Nuclear Power Plants

**Table B-1. Summary of Issues and Findings.** *This table is taken from Table B-1 in Appendix B, Subpart A, to 10 CFR Part 51. Data supporting this table are contained in NUREG-1437, Generic Environmental Impact Statement for License Renewal of Nuclear Plants. Throughout this report, “Generic” issues are also referred to as Category 1 issues, and “Site-specific” issues are also referred to as Category 2 issues.*

Issue	Type of Issue	Finding
Surface Water Quality, Hydrology, and Use		
Impacts of refurbishment on surface water quality	Generic	SMALL. Impacts are expected to be negligible during refurbishment because best management practices are expected to be employed to control soil erosion and spills.
Impacts of refurbishment on surface water use	Generic	SMALL. Water use during refurbishment will not increase appreciably or will be reduced during plant outage.
Altered current patterns at intake and discharge structures	Generic	SMALL. Altered current patterns have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Altered salinity gradients	Generic	SMALL. Salinity gradients have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Altered thermal stratification of lakes	Generic	SMALL. Generally, lake stratification has not been found to be a problem at operating nuclear power plants and is not expected to be a problem during the license renewal term.
Temperature effects on sediment transport capacity	Generic	SMALL. These effects have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Scouring caused by discharged cooling water	Generic	SMALL. Scouring has not been found to be a problem at most operating nuclear power plants and has caused only localized effects at a few plants. It is not expected to be a problem during the license renewal term.

Appendix B

Issue	Type of Issue	Finding
Eutrophication	Generic	SMALL. Eutrophication has not been found to be a problem at operating nuclear power plants and is not expected to be a problem during the license renewal term.
Discharge of chlorine or other biocides	Generic	SMALL. Effects are not a concern among regulatory and resource agencies, and are not expected to be a problem during the license renewal term.
Discharge of sanitary wastes and minor chemical spills	Generic	SMALL. Effects are readily controlled through NPDES permit and periodic modifications, if needed, and are not expected to be a problem during the license renewal term.
Discharge of other metals in wastewater	Generic	SMALL. These discharges have not been found to be a problem at operating nuclear power plants with cooling-tower-based heat dissipation systems and have been satisfactorily mitigated at other plants. They are not expected to be a problem during the license renewal term.
Water use conflicts (plants with once-through cooling systems)	Generic	SMALL. These conflicts have not been found to be a problem at operating nuclear power plants with once-through heat dissipation systems.
Water use conflicts (plants with cooling ponds or cooling towers using make-up water from a small river with low flow)	Site-specific	SMALL OR MODERATE. The issue has been a concern at nuclear power plants with cooling ponds and at plants with cooling towers. Impacts on instream and riparian communities near these plants could be of moderate significance in some situations. See § 51.53(c)(3)(ii)(A).
Aquatic Ecology		
Refurbishment	Generic	SMALL. During plant shutdown and refurbishment there will be negligible effects on aquatic biota because of a reduction of entrainment and impingement of organisms or a reduced release of chemicals.



Issue	Type of Issue	Finding
Accumulation of contaminants in sediments or biota	Generic	SMALL. Accumulation of contaminants has been a concern at a few nuclear power plants but has been satisfactorily mitigated by replacing copper alloy condenser tubes with those of another metal. It is not expected to be a problem during the license renewal term.
Entrainment of phytoplankton and zooplankton	Generic	SMALL. Entrainment of phytoplankton and zooplankton has not been found to be a problem at operating nuclear power plants and is not expected to be a problem during the license renewal term.
Cold shock	Generic	SMALL. Cold shock has been satisfactorily mitigated at operating nuclear plants with once-through cooling systems, has not endangered fish populations or been found to be a problem at operating nuclear power plants with cooling towers or cooling ponds, and is not expected to be a problem during the license renewal term.
Thermal plume barrier to migrating fish	Generic	SMALL. Thermal plumes have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Distribution of aquatic organisms	Generic	SMALL. Thermal discharge may have localized effects but is not expected to affect the larger geographical distribution of aquatic organisms.
Premature emergence of aquatic insects	Generic	SMALL. Premature emergence has been found to be a localized effect at some operating nuclear power plants but has not been a problem and is not expected to be a problem during the license renewal term.
Gas supersaturation (gas bubble disease)	Generic	SMALL. Gas supersaturation was a concern at a small number of operating nuclear power plants with once-through cooling systems but has been satisfactorily mitigated. It has not been found to be a problem at operating nuclear power plants with cooling towers or cooling ponds and is not expected to be a problem during the license renewal term.

Appendix B

Issue	Type of Issue	Finding
Low dissolved oxygen in the discharge	Generic	SMALL. Low dissolved oxygen has been a concern at one nuclear power plant with a once-through cooling system but has been effectively mitigated. It has not been found to be a problem at operating nuclear power plants with cooling towers or cooling ponds and is not expected to be a problem during the license renewal term.
Losses from predation, parasitism, and disease among organisms exposed to sublethal stresses	Generic	SMALL. These types of losses have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Stimulation of nuisance organisms (e.g., shipworms)	Generic	SMALL. Stimulation of nuisance organisms has been satisfactorily mitigated at the single nuclear power plant with a once-through cooling system where previously it was a problem. It has not been found to be a problem at operating nuclear power plants with cooling towers or cooling ponds and is not expected to be a problem during the license renewal term.
Aquatic Ecology (for plants with once-through and cooling pond heat dissipation systems)		
Entrainment of fish and shellfish in early life stages	Site-specific	SMALL, MODERATE, OR LARGE. The impacts of entrainment are small at many plants but may be moderate or even large at a few plants with once-through and cooling-pond cooling systems. Further, ongoing efforts in the vicinity of these plants to restore fish populations may increase the numbers of fish susceptible to intake effects during the license renewal period, such that entrainment studies conducted in support of the original license may no longer be valid. See § 51.53(c)(3)(ii)(B).
Impingement of fish and shellfish	Site-specific	SMALL, MODERATE, OR LARGE. The impacts of impingement are small at many plants but may be moderate or even large at a few plants with once-through and cooling-pond cooling systems. See § 51.53(c)(3)(ii)(B).

<b>Issue</b>	<b>Type of Issue</b>	<b>Finding</b>
Heat shock	Site-specific	SMALL, MODERATE, OR LARGE. Because of continuing concerns about heat shock and the possible need to modify thermal discharges in response to changing environmental conditions, the impacts may be of moderate or large significance at some plants. See § 51.53(c)(3)(ii)(B).
Aquatic Ecology (for plants with cooling-tower-based heat dissipation systems)		
Entrainment of fish and shellfish in early life stages	Generic	SMALL. Entrainment of fish has not been found to be a problem at operating nuclear power plants with this type of cooling system and is not expected to be a problem during the license renewal term.
Impingement of fish and shellfish	Generic	SMALL. The impingement has not been found to be a problem at operating nuclear power plants with this type of cooling system and is not expected to be a problem during the license renewal term.
Heat shock	Generic	SMALL. Heat shock has not been found to be a problem at operating nuclear power plants with this type of cooling system and is not expected to be a problem during the license renewal term.
Ground Water Use and Quality		
Impacts of refurbishment on ground water use and quality	Generic	SMALL. Extensive dewatering during the original construction on some sites will not be repeated during refurbishment on any sites. Any plant wastes produced during refurbishment will be handled in the same manner as in current operating practices and are not expected to be a problem during the license renewal term.
Ground water use conflicts (potable and service water; plants that use <100 gpm)	Generic	SMALL. Plants using less than 100 gpm are not expected to cause any ground water use conflicts.
Ground water use conflicts (potable and service water, and dewatering plants that use >100 gpm)	Site-specific	SMALL, MODERATE, OR LARGE. Plants that use more than 100 gpm may cause ground water use conflicts with nearby ground water users. See § 51.53(c)(3)(ii)(C).

Appendix B

Issue	Type of Issue	Finding
Ground water use conflicts (plants using cooling towers withdrawing make-up water from a small river)	Site-specific	SMALL, MODERATE, OR LARGE. Water use conflicts may result from surface water withdrawals from small water bodies during low flow conditions which may affect aquifer recharge, especially if other ground water or upstream surface water users come on line before the time of license renewal. See § 51.53(c)(3)(ii)(A).
Ground water use conflicts (Ranney wells)	Site-specific	SMALL, MODERATE, OR LARGE. Ranney wells can result in potential ground water depression beyond the site boundary. Impacts of large ground water withdrawal for cooling tower makeup at nuclear power plants using Ranney wells must be evaluated at the time of application for license renewal. See § 51.53(c)(3)(ii)(C).
Ground water quality degradation (Ranney wells)	Generic	SMALL. Ground water quality at river sites may be degraded by induced infiltration of poor-quality river water into an aquifer that supplies large quantities of reactor cooling water. However, the lower quality infiltrating water would not preclude the current uses of ground water and is not expected to be a problem during the license renewal term.
Ground water quality degradation (saltwater intrusion)	Generic	SMALL. Nuclear power plants do not contribute significantly to saltwater intrusion.
Ground water quality degradation (cooling ponds in salt marshes)	Generic	SMALL. Sites with closed-cycle cooling ponds may degrade ground water quality. Because water in salt marshes is brackish, this is not a concern for plants located in salt marshes.
Ground water quality degradation (cooling ponds at inland sites)	Site-specific	SMALL, MODERATE, OR LARGE. Sites with closed-cycle cooling ponds may degrade ground water quality. For plants located inland, the quality of the ground water in the vicinity of the ponds must be shown to be adequate to allow continuation of current uses. See § 51.53(c)(3)(ii)(D).

Terrestrial Ecology		
Refurbishment impacts	Site-specific	SMALL, MODERATE, OR LARGE. Refurbishment impacts are insignificant if no loss of important plant and animal habitat occurs. However, it cannot be known whether important plant and animal communities may be affected until the specific proposal is presented with the license renewal application. See § 51.53(c)(3)(ii)(E).
Cooling tower impacts on crops and ornamental vegetation	Generic	SMALL. Impacts from salt drift, icing, fogging, or increased humidity associated with cooling tower operation have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Cooling tower impacts on native plants	Generic	SMALL. Impacts from salt drift, icing, fogging, or increased humidity associated with cooling tower operation have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Bird collisions with cooling towers	Generic	SMALL. These collisions have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Cooling pond impacts on terrestrial resources	Generic	SMALL. Impacts of cooling ponds on terrestrial ecological resources are considered to be of small significance at all sites.
Power line right of way management (cutting and herbicide application)	Generic	SMALL. The impacts of right-of-way maintenance on wildlife are expected to be of small significance at all sites.
Bird collisions with power lines	Generic	SMALL. Impacts are expected to be of small significance at all sites.
Impacts of electromagnetic fields on flora and fauna	Generic	SMALL. No significant impacts of electromagnetic fields on terrestrial flora and fauna have been identified. Such effects are not expected to be a problem during the license renewal term.

Appendix B

Floodplains and wetland on power line right of way	Generic	SMALL. Periodic vegetation control is necessary in forested wetlands underneath power lines and can be achieved with minimal damage to the wetland. No significant impact is expected at any nuclear power plant during the license renewal term.
Threatened and Endangered Species		
Threatened or endangered species	Site-specific	SMALL, MODERATE, OR LARGE. Generally, plant refurbishment and continued operation are not expected to adversely affect threatened or endangered species. However, consultation with appropriate agencies would be needed at the time of license renewal to determine whether threatened or endangered species are present and whether they would be adversely affected. See § 51.53(c)(3)(ii)(E).
Air Quality		
Air quality during refurbishment (non-attainment and maintenance areas)	Site-specific	SMALL, MODERATE, OR LARGE. Air quality impacts from plant refurbishment associated with license renewal are expected to be small. However, vehicle exhaust emissions could be cause for concern at locations in or near nonattainment or maintenance areas. The significance of the potential impact cannot be determined without considering the compliance status of each site and the numbers of workers expected to be employed during the outage. See § 51.53(c)(3)(ii)(F).
Air quality effects of transmission lines	Generic	SMALL. Production of ozone and oxides of nitrogen is insignificant and does not contribute measurably to ambient levels of these gases.
Land Use		
Onsite land use	Generic	SMALL. Projected onsite land use changes required during refurbishment and the renewal period would be a small fraction of any nuclear power plant site and would involve land that is controlled by the applicant.
Power line right of way	Generic	SMALL. Ongoing use of power line right of ways would continue with no change in restrictions. The effects of these restrictions are of small significance.

1

Human Health		
Radiation exposures to the public during refurbishment	Generic	SMALL. During refurbishment, the gaseous effluents would result in doses that are similar to those from current operation. Applicable regulatory dose limits to the public are not expected to be exceeded.
Occupational radiation exposures during refurbishment	Generic	SMALL. Occupational doses from refurbishment are expected to be within the range of annual average collective doses experienced for pressurized-water reactors and boiling-water reactors. Occupational mortality risk from all causes including radiation is in the mid-range for industrial settings.
Microbiological organisms (occupational health)	Generic	SMALL. Occupational health impacts are expected to be controlled by continued application of accepted industrial hygiene practices to minimize worker exposures.
Microbiological organisms (public health)(plants using lakes or canals, or cooling towers or cooling ponds that discharge to a small river)	Site-specific	SMALL, MODERATE, OR LARGE. These organisms are not expected to be a problem at most operating plants except possibly at plants using cooling ponds, lakes, or canals that discharge to small rivers. Without site-specific data, it is not possible to predict the effects generically. See § 51.53(c)(3)(ii)(G).
Noise	Generic	SMALL. Noise has not been found to be a problem at operating plants and is not expected to be a problem at any plant during the license renewal term.
Electromagnetic fields – acute effects (electric shock)	Site-specific	SMALL, MODERATE, OR LARGE. Electrical shock resulting from direct access to energized conductors or from induced charges in metallic structures have not been found to be a problem at most operating plants and generally are not expected to be a problem during the license renewal term. However, site-specific review is required to determine the significance of the electric shock potential at the site. See § 51.53(c)(3)(ii)(H).

Appendix B

Electromagnetic fields – chronic effects	Uncategorized	UNCERTAIN. Biological and physical studies of 60-Hz electromagnetic fields have not found consistent evidence linking harmful effects with field exposures. However, research is continuing in this area and a consensus scientific view has not been reached.
Radiation exposures to public (license renewal term)	Generic	SMALL. Radiation doses to the public will continue at current levels associated with normal operations.
Occupational radiation exposures (license renewal term)	Generic	SMALL. Projected maximum occupational doses during the license renewal term are within the range of doses experienced during normal operations and normal maintenance outages, and would be well below regulatory limits.

Socioeconomic Impacts

Housing impacts	Site-specific	SMALL, MODERATE, OR LARGE. Housing impacts are expected to be of small significance at plants located in a medium or high population area and not in an area where growth control measures that limit housing development are in effect. Moderate or large housing impacts of the workforce associated with refurbishment may be associated with plants located in sparsely populated areas or in areas with growth control measures that limit housing development. See § 51.53(c)(3)(ii)(I).
Public services: public safety, social services, and tourism, and recreation	Generic	SMALL. Impacts to public safety, social services, and tourism and recreation are expected to be of small significance at all sites.
Public services: public utilities	Site-specific	SMALL OR MODERATE. An increased problem with water shortages at some sites may lead to impacts of moderate significance on public water supply availability. See § 51.53(c)(3)(ii)(I).
Public services: education (refurbishment)	Site-specific	SMALL, MODERATE, OR LARGE. Most sites would experience impacts of small significance but larger impacts are possible depending on site- and project-specific factors. See § 51.53(c)(3)(ii)(I).



Public services: education (license renewal term)	Generic	SMALL. Only impacts of small significance are expected
Offsite land use (refurbishment)	Site-specific	SMALL OR MODERATE. Impacts may be of moderate significance at plants in low population areas. See § 51.53(c)(3)(ii)(I).
Offsite land use (license renewal term)	Site-specific	SMALL, MODERATE, OR LARGE. Significant changes in land use may be associated with population and tax revenue changes resulting from license renewal. See § 51.53(c)(3)(ii)(I).
Public services: transportation	Site-specific	SMALL, MODERATE, OR LARGE. Transportation impacts (level of service) of highway traffic generated during plant refurbishment and during the term of the renewed license are generally expected to be of small significance. However, the increase in traffic associated with the additional workers and the local road and traffic control conditions may lead to impacts of moderate or large significance at some sites. See § 51.53(c)(3)(ii)(J).
Historic and archaeological resources	Site-specific	SMALL, MODERATE, OR LARGE. Generally, plant refurbishment and continued operation are expected to have no more than small adverse impacts on historic and archaeological resources. However, the National Historic Preservation Act requires the Federal agency to consult with the State Historic Preservation Officer to determine whether there are properties present that require protection. See § 51.53(c)(3)(ii)(K).
Aesthetic impacts (refurbishment)	Generic	SMALL. No significant impacts are expected during refurbishment.
Aesthetic impacts (license renewal term)	Generic	SMALL. No significant impacts are expected during the license renewal term.
Aesthetic impacts of transmission lines (license renewal term)	Generic	SMALL. No significant impacts are expected during the license renewal term.
Postulated Accidents		
Design basis accidents	Generic	SMALL. The NRC staff has concluded that the environmental impacts of design basis accidents are of small significance for all plants.

Appendix B

Severe accidents	Site-specific	SMALL. The probability weighted consequences of atmospheric releases, fallout onto open bodies of water, releases to ground water, and societal and economic impacts from severe accidents are small for all plants. However, alternatives to mitigate severe accidents must be considered for all plants that have not considered such alternatives. See § 51.53(c)(3)(ii)(L).
Uranium Fuel Cycle and Waste Management		
Offsite radiological impacts (individual effects from other than the disposal of spent fuel and high level waste)	Generic	SMALL. Off-site impacts of the uranium fuel cycle have been considered by the Commission in Table S-3 of this part. Based on information in the GEIS, impacts on individuals from radioactive gaseous and liquid releases including radon-222 and technetium-99 are small.
Offsite radiological impacts (collective effects)	Generic	The 100 year environmental dose commitment to the U.S. population from the fuel cycle, high level waste and spent fuel disposal excepted, is calculated to be about 14,800 person rem, or 12 cancer fatalities, for each additional 20-year power reactor operating term. Much of this, especially the contribution of radon releases from mines and tailing piles, consists of tiny doses summed over large populations. This same dose calculation can theoretically be extended to include many tiny doses over additional thousands of years as well as doses outside the U. S. The result of such a calculation would be thousands of cancer fatalities from the fuel cycle, but this result assumes that even tiny doses have some statistical adverse health effect which will not ever be mitigated (for example no cancer cure in the next thousand years), and that these doses projected over thousands of years are meaningful. However, these assumptions are questionable. In particular, science cannot rule out the possibility that there will be no cancer fatalities from these tiny doses. For perspective, the doses are very small fractions of regulatory limits, and even smaller fractions of natural background exposure to the same populations.  Nevertheless, despite all the uncertainty, some

judgment as to the regulatory NEPA implications of these matters should be made and it makes no sense to repeat the same judgment in every case. Even taking the uncertainties into account, the Commission concludes that these impacts are acceptable in that these impacts would not be sufficiently large to require the NEPA conclusion, for any plant, that the option of extended operation under 10 CFR Part 54 should be eliminated. Accordingly, while the commission has not assigned a single level of significance for the collective effects of the fuel cycle, this issue is considered Category 1 [Generic].

Offsite radiological impacts (spent fuel and high level waste disposal)	Generic	<p>For the high level waste and spent fuel disposal component of the fuel cycle, there are no current regulatory limits for offsite releases of radionuclides for the current candidate repository site. However, if we assume that limits are developed along the lines of the 1995 National Academy of Sciences (NAS) report, "Technical Bases for Yucca Mountain Standards," and that in accordance with the Commission's Waste Confidence Decision, 10 CFR 51.23, a repository can and likely will be developed at some site which will comply with such limits, peak doses to virtually all individuals will be 100 millirem per year or less. However, while the Commission has reasonable confidence that these assumptions will prove correct, there is considerable uncertainty since the limits are yet to be developed, no repository application has been completed or reviewed, and uncertainty is inherent in the models used to evaluate possible pathways to the human environment. The NAS report indicated that 100 millirem per year should be considered as a starting point for limits for individual doses, but notes that some measure of consensus exists among national and international bodies that the limits should be a fraction of the 100 millirem per year. The lifetime individual risk from 100 millirem annual dose limit is about <math>3 \times 10^{-3}</math>.</p> <p>Estimating cumulative doses to populations over thousands of years is more problematic. The likelihood and consequences of events that could seriously compromise the integrity of a deep geologic repository were evaluated by the</p>
---	---------	--

Department of Energy in the "Final Environmental Impact Statement: Management of Commercially Generated Radioactive Waste," October 1980. The evaluation estimated the 70-year whole-body dose commitment to the maximum individual and to the regional population resulting from several modes of breaching a reference repository in the year of closure, after 1,000 years, after 100,000 years and after 100,000,000 years. Subsequently, the NRC and other federal agencies have expended considerable effort to develop models for the design and for the licensing of a high level waste repository, especially for the candidate repository at Yucca Mountain. More meaningful estimates of doses to population may be possible in the future as more is understood about the performance of the proposed Yucca Mountain repository. Such estimates would involve very great uncertainty, especially with respect to cumulative population doses over thousands of years. The standard proposed by the NAS is a limit on maximum individual dose. The relationship of potential new regulatory requirements, based on the NAS report, and cumulative population impacts has not been determined, although the report articulates the view that protection of individuals will adequately protect the population for a repository at Yucca Mountain. However, EPA's generic repository standards in 40 CFR Part 191 generally provide an indication of the order of magnitude of cumulative risk to population that could result from the licensing of a Yucca Mountain repository, assuming the ultimate standards will be within the range of standards now under consideration. The standards in 40 CFR Part 191 protect the population by imposing amount of radioactive material released over 10,000 years. The cumulative release limits are based on EPA's population impact goal of 1,000 premature cancer deaths worldwide for a 100,000 metric ton (MTHM) repository.

Nevertheless, despite all the uncertainty, some judgment as to the regulatory NEPA implications of these matters should be made and it makes no sense to repeat the same judgment in every case. Even taking the uncertainties into account, the

---

---

		Commission concludes that these impacts are acceptable in that these impacts would not be sufficiently large to require the NEPA conclusion, for any plant, that the option of extended operation under 10 CFR Part 54 should be eliminated. Accordingly, while the Commission has not assigned a single level of significance for the impacts of spent fuel and high level waste disposal, this issue is considered in Category 1 [Generic].
Nonradiological impacts of the uranium fuel cycle	Generic	SMALL. The nonradiological impacts of the uranium fuel cycle resulting from the renewal of an operating license for any plant are found to be small.
Low-level waste storage and disposal	Generic	SMALL. The comprehensive regulatory controls that are in place and the low public doses being achieved at reactors ensure that the radiological impacts to the environment will remain small during the term of a renewed license. The maximum additional on-site land that may be required for low-level waste storage during the term of a renewed license and associated impacts will be small. Nonradiological impacts on air and water will be negligible. The radiological and nonradiological environmental impacts of long-term disposal of low-level waste from any individual plant at licensed sites are small. In addition, the Commission concludes that there is reasonable assurance that sufficient low-level waste disposal capacity will be made available when needed for facilities to be decommissioned consistent with NRC decommissioning requirements.

---

Appendix B

Mixed waste storage and disposal	Generic	SMALL. The comprehensive regulatory controls and the facilities and procedures that are in place ensure proper handling and storage, as well as negligible doses and exposure to toxic materials for the public and the environment at all plants. License renewal will not increase the small, continuing risk to human health and the environment posed by mixed waste at all plants. The radiological and nonradiological environmental impacts of long-term disposal of mixed waste from any individual plant at licensed sites are small. In addition, the Commission concludes that there is reasonable assurance that sufficient mixed waste disposal capacity will be made available when needed for facilities to be decommissioned consistent with NRC decommissioning requirements.
On-site spent fuel	Generic	SMALL. The expected increase in the volume of spent fuel from an additional 20 years of operation can be safely accommodated on site with small environmental effects through dry or pool storage at all plants if a permanent repository or monitored retrievable storage is not available.
Nonradiological waste	Generic	SMALL. No changes to generating systems are anticipated for license renewal. Facilities and procedures are in place to ensure continued proper handling and disposal at all plants.
Transportation	Generic	SMALL. The impacts of transporting spent fuel enriched up to 5 percent uranium-235 with average burnup for the peak rod to current levels approved by NRC up to 62,000 MWd/MTU and the cumulative impacts of transporting high-level waste to a single repository, such as Yucca Mountain, Nevada are found to be consistent with the impact values contained in 10 CFR 51.52(c), Summary Table S-4 – Environmental Impact of Transportation of Fuel and Waste to and from One Light-Water-Cooled Nuclear Power Reactor. If fuel enrichment or burnup conditions are not met, the applicant must submit an assessment of the implications for the environmental impact values reported in § 51.52.

1

Decommissioning		
Radiation doses	Generic	SMALL. Doses to the public will be well below applicable regulatory standards regardless of which decommissioning method is used. Occupational doses would increase no more than 1 man-rem caused by buildup of long-lived radionuclides during the license renewal term.
Waste management	Generic	SMALL. Decommissioning at the end of a 20-year license renewal period would generate no more solid wastes than at the end of the current license term. No increase in the quantities of Class C or greater than Class C wastes would be expected.
Air quality	Generic	SMALL. Air quality impacts of decommissioning are expected to be negligible either at the end of the current operating term or at the end of the license renewal term.
Water quality	Generic	SMALL. The potential for significant water quality impacts from erosion or spills is no greater whether decommissioning occurs after a 20-year license renewal period or after the original 40-year operation period, and measures are readily available to avoid such impacts.
Ecological resources	Generic	SMALL. Decommissioning after either the initial operating period or after a 20-year license renewal period is not expected to have any direct ecological impacts.
Socioeconomic impacts	Generic	SMALL. Decommissioning would have some short-term socioeconomic impacts. The impacts would not be increased by delaying decommissioning until the end of a 20-year relicense period, but they might be decreased by population and economic growth.
Environmental Justice		
Environmental Justice	Uncategorized	NONE. The need for and the content of an analysis of environmental justice will be addressed in plant-specific reviews.

2





## **Appendix C**

### **Applicable Regulations, Laws, and Agreements**



## C. Applicable Regulations, Laws, and Agreements

The Atomic Energy Act authorizes States to establish programs to assume NRC regulatory authority for certain activities. For example, through the Agreement State Program, beginning on March 31, 2008, Pennsylvania assumed regulatory responsibility over certain byproduct, source, and small quantities of special nuclear material. The Pennsylvania Department of Environmental Protection (PADEP) is responsible for implementing State nuclear regulations, which are contained in Title 25 of the Pennsylvania (Pa) Code, *Environment*, Article V, *Radiological Health*, Chapters 215 through 240.

In addition to implementing some Federal programs, State legislatures develop their own laws. State statutes supplement as well as implement Federal laws for protection of air, water quality, and ground water. State legislation may address solid waste management programs, locally rare or endangered species, and historic and cultural resources.

The Clean Water Act (CWA) allows for primary enforcement and administration through State agencies, provided the State program is at least as stringent as the Federal program. The State program must conform to the CWA and to the delegation of authority for the Federal National Pollutant Discharge and Elimination System (NPDES) program from the EPA to the State. The primary mechanism to control water pollution is the requirement for direct dischargers to obtain an NPDES permit, or in the case of states where the authority has been delegated from the EPA, an SPDES permit, pursuant to the CWA. In Pennsylvania, the PADEP issues and enforces NPDES permits.

One important difference between Federal regulations and certain State regulations is the definition of waters regulated by the State. Certain state regulations may include underground waters, while the CWA only regulates surface waters.

### C.1 State Environmental Requirements

Certain environmental requirements, including some discussed earlier, may have been delegated to State authorities for implementation, enforcement, or oversight. Table C-1 provides a list of representative State environmental requirements that may affect license renewal applications for nuclear power plants.

**Table C-1. State Environmental Requirements.** TMI-1 is subject to numerous State requirements regarding their environmental program. Those requirements are briefly described below. See Section 1.9 for TMI-1's compliance status with these requirements.

Law/Regulation	Requirements
<b>Air Quality Protection</b>	
Air Pollution Control Act, PA Public Law (P.L.) 2119 and 25 Pa Code Chapter 127	All emission sources at TMI-1 must obtain a Synthetic Minor Operating Permit prior to operation; the PADEP issues and enforces permits.

Appendix C

**Table C-1. State Environmental Requirements.** TMI-1 is subject to numerous State requirements regarding their environmental program. Those requirements are briefly described below. See Section 1.9 for TMI-1’s compliance status with these requirements.

Law/Regulation	Requirements
<b>Water Resources Protection</b>	
<p><i>Clean Water Act (CWA)</i> (33 U.S.C. Section 1251 et seq.); Pennsylvania’s Clear Streams Law, as amended (35 Pennsylvania Statute [P.S.] Section 691.1 et seq.)</p>	<p>The National Pollutant Discharge Elimination System (NPDES) permit is required for plant industrial, sanitary, and stormwater discharges to the Susquehanna River. The NPDES permit requires the compliance of each point source with authorized discharge levels, monitoring requirements, and other appropriate requirements. The PADEP is the responsible State agency for NPDES permitting.</p>
<p>CWA (33 U.S.C. Section 401)</p>	<p>The <i>Clean Water Act</i> Section 401 Water Quality Certification requires a Section 401 water quality certification and payment of applicable fees before the issuance of a Federal permit or license to conduct any activity that may result in any discharge to waters of the State. In Pennsylvania, State issuance of an NPDES permit constitutes 401 Certification.</p>
<p>Susquehanna River Basin Compact, P.L. 91-575, Article 3, Section 3.10; and Susquehanna River Basin Commission (SRBC) Regulation 803.61</p>	<p>Requires a permit to cover consumptive water use over 20,000 gallons per day (gpd) (over a 30-day average) of surface and ground water; the SRBC is the regulatory agency that issues and enforces consumptive water use permits.</p>
<p>Susquehanna River Basin Compact, P.L. 91-575, Article 3, Section 3.10; and SRBC Regulation 803.43</p>	<p>The Compact requires a permit to cover ground water withdrawals over 100,000 gpd or more (over a 30-day average) of surface water, ground water, or a combination of the two; the SRBC is the regulatory agency that issues and enforces ground water withdrawal permits.</p>
<p>P.L. 834, 204, 851, 1987, etc.</p>	<p>The U.S. Army Corps of Engineers issues maintenance dredging permits for maintenance dredging of the TMI-1 intake bay.</p>
<p>P.L. 555, as amended</p>	<p>Maintenance dredging of the TMI-1 intake bay in the Susquehanna River also requires a maintenance dredging permit issued by the PADEP.</p>
<p>Pennsylvania Safe Drinking Water Act (P.L. 206, No. 43)</p>	<p>The PADEP issues and enforces public water supply permits for operation TMI-1 plant site drinking water systems.</p>

1

**Table C-1. State Environmental Requirements.** TMI-1 is subject to numerous State requirements regarding their environmental program. Those requirements are briefly described below. See Section 1.9 for TMI-1's compliance status with these requirements.

Law/Regulation	Requirements
<b>Waste Management and Pollution Prevention</b>	
Pennsylvania Storage Tank and Spill Prevention Act (35 P.S. 6021.1016021.2104); 25 PA Code Chapter (Ch.) 245	The PADEP issues storage tank registration and permit certificates, which establish annual registration requirements for underground storage tanks containing petroleum or other regulated substances.
Pennsylvania Fire Marshall; Pennsylvania Storage Tank and Spill Prevention Act (35 P.S. 6021.1016021.2104); 25 PA Code Ch. 245	The Act requires a flammable and combustible liquid storage tank approval to construct or operate an underground storage tank containing flammable or combustible liquids.
71 P.S. Sections 510520; Sections 5 and 402 of The Clean Streams Law (35 P.S. 691.5 and 691.402); Section 9 of the Pennsylvania Sewage Facilities Act (35 P.S. Section 750.9).	The PADEP issues sewage sludge disposal agreements, which are required for the disposal of sewage sludge. The PADEP also issues on-lot sewage disposal system permits, and permit modifications for approvals of additional flows to on-lot sewage treatment systems.

2

### 3 C.2 Operating Permits and Other Requirements

4 Several operating permit applications may be prepared and submitted, and regulator approval  
 5 and permits would be received prior to license renewal approval by the NRC. Table C-2 lists  
 6 representative Federal, State, and local permits.

Appendix C

1

**Table C-2. Federal, State, and Local Permits and Other Requirements.** TMI-1 is subject to other requirements regarding various aspects of their environmental program. Those requirements are briefly described below.

License, Permit, or Other Required Approval	Responsible Agency	Authority	Relevance and Status
<b>Air Quality Protection</b>			
Approval (operating permit) for construction or modification of an air pollutant source.	PADEP	<i>Clean Air Act</i> , Title V, Sections 501-507 (42 U.S.C. 7661-7661f); Pa Code Ch.127	AmerGen may need to modify its existing Synthetic Minor Operating Permit, or apply for a new permit for temporary emissions associated with refurbishment.
<b>Water Resources Protection</b>			
NPDES permit for construction site storm water and other project-specific discharges.	PADEP	CWA (33 U.S.C. 1251 et seq.); 40 CFR Part 122; 25 Pa Code Ch. 92	AmerGen may need to modify the existing TMI-1 NPDES permit, or otherwise obtain authorization for temporary discharges associated with refurbishment.
Requires review and approval of any project that will result in consumptive use of water from the Susquehanna River.	SRBC	Susquehanna River Basin Compact; P.L. 91-575, Article 3, Section 3.10; 18 CFR Part 806; 25 Pa Code Ch. 806	Modifications to the existing TMI-1 consumptive water use permit may be necessary to supply water for refurbishment activities.
Requires any person withdrawing or diverting in excess of an average of 10,000 gpd for any consecutive 30-day period, from ground or surface water sources to register the amount of the withdrawal.	SRBC	Susquehanna River Basin Compact; P.L. 91-575, Article 3, Section 3.10; 18 CFR Part 807; 25 Pa Code Ch. 807	Refurbishment activities at TMI-1 may require additional ground water or surface water withdrawal; the existing TMI-1 water withdrawal permit may require modification.

**Table C-2. Federal, State, and Local Permits and Other Requirements.** TMI-1 is subject to other requirements regarding various aspects of their environmental program. Those requirements are briefly described below.

License, Permit, or Other Required Approval	Responsible Agency	Authority	Relevance and Status
Requires a permit be obtained before construction, modification, removal, destruction, or abandonment of an obstruction in a floodplain.	PADEP	Flood Plain Management Act (32 P.S. 679.101-679.601); 25 Pa Code Ch. 106	AmerGen is reviewing flood plain elevations associated with refurbishment activities; if avoidance is not possible, AmerGen will apply for appropriate permits.
A Spill Prevention Control and Countermeasures (SPCC) Plan is required for any facility that could discharge diesel fuel in harmful quantities into navigable waters or onto adjoining shorelines.	PADEP	CWA (33 U.S.C. 1251 et seq.); 40 CFR Part 112; 25 Pa Code Ch. 245	A SPCC Plan is required at nuclear power plants storing large volumes of diesel fuel or other petroleum products. AmerGen may need to modify its existing SPCC Plan, or develop a new plan to cover activities associated with refurbishment.
New Underground Storage Tanks System Registration is required within 30 days of bringing a new underground storage tank system into service.	PADEP	RCRA, as amended, Subtitle I (42 U.S.C. 6991a-6991i); 40 CFR §280.22; Storage Tank and Spill Prevention (35 P.S. 6021.101-6021.2104); 25 Pa Code, Ch. 245	Required if new underground storage tank systems would be installed during refurbishment at a nuclear power plant.
<b>Waste Management and Pollution Prevention</b>			
Registration and Hazardous Waste Generator Identification Number are required before a facility that generates over 100 kg (220 lb) per calendar month of hazardous waste ships the hazardous waste off-site	PADEP	RCRA, as amended (42 U.S.C. 6901 et seq.), Subtitle C; 25 Pa Code Articles VII (Hazardous Waste Management) and IX (Residual Waste	Generators of hazardous waste must notify EPA that the wastes exist and require management in compliance with RCRA. AmerGen will characterize wastes generated by refurbishment to determine proper disposal procedures and permit requirements.

Appendix C

**Table C-2. Federal, State, and Local Permits and Other Requirements.** TMI-1 is subject to other requirements regarding various aspects of their environmental program. Those requirements are briefly described below.

License, Permit, or Other Required Approval	Responsible Agency	Authority	Relevance and Status
		Management)	
<b>Emergency Planning and Response</b>			
Submission of a list of Material Safety Data Sheets is required for hazardous chemicals (as defined in 29 CFR Part 1910) that are stored onsite in excess of their threshold quantities.	State and local emergency planning agencies	Emergency Planning and Community Right-to-Know Act of 1986 (EPCRA), Section 311 (42 U.S.C. 11021); 40 CFR §370.20	Nuclear power plant operators are required to submit a List of Material Safety Data Sheets to State and local emergency planning agencies.
Transportation of Radioactive Wastes and Conversion Products Packaging, Labeling, and Routing Requirements for Radioactive Materials is required for packages containing radioactive materials that will be shipped by truck or rail.	U.S. Department of Transportation	HMTA (49 U.S.C. 1501 et seq.); Atomic Energy Act (AEA), as amended (42 U.S.C. 2011 et seq.); 49 CFR Parts 172, 173, 174, 177, and 397	When shipments of radioactive materials are made, nuclear power plant operators would comply with U.S. Department of Transportation packaging, labeling, and routing requirements.
<b>Biotic Resource Protection</b>			
Threatened and Endangered Species Consultation is required between the responsible Federal agencies and affected States to ensure that the project is not likely to: (1) jeopardize the continued existence of any species listed at the Federal or State level as endangered or threatened; or (2) result in destruction of critical habitat of such species.	U.S. Fish and Wildlife Service (FWS) and State agencies	<i>Endangered Species Act</i> of 1973, as amended (16 U.S.C. 1531 et seq.)	NRC would consult with FWS and State agencies regarding the impact of license renewal on threatened or endangered species or their critical habitats.
<i>Clean Water Act</i> Section 404 (Dredge and Fill) Permit is required to place dredged or fill material into waters of the U.S., including areas designated as	U.S. Army Corps of Engineers	CWA (33 U.S.C. 1251 et seq.); 33 CFR Parts 323 and	Any dredging or placement of fill material into wetlands within the jurisdiction of the U.S. Army Corps of Engineers at a nuclear power



**Table C-2. Federal, State, and Local Permits and Other Requirements.** TMI-1 is subject to other requirements regarding various aspects of their environmental program. Those requirements are briefly described below.

License, Permit, or Other Required Approval	Responsible Agency	Authority	Relevance and Status
wetlands, unless such placement is exempt or authorized by a nationwide permit or a regional permit; a notice must be filed if a nationwide or regional permit applies.		330	plant would require a Section 404 permit. AmerGen is reviewing options for transportation of the new steam generators from Port Deposit, Maryland, to the TMI-1 site. If the selected route requires dredge or fill activities, AmerGen would have to apply for a section 404 permit.
<b>Cultural Resources Protection</b>			
Archaeological and Historical Resources Consultation is required before a Federal agency approves a project in an area where archaeological or historic resources might be located.	Pennsylvania Historic and Museum Commission	<i>National Historic Preservation Act of 1966, as amended (16 U.S.C. 470 et seq.); Archaeological and Historical Preservation Act of 1974 (16 U.S.C. 469-469c-2); Antiquities Act of 1906 (16 U.S.C. 431 et seq.); Archaeological Resources Protection Act of 1979, as amended (16 U.S.C. 470aa-mm)</i>	NRC would consult with the State and Tribal Historic Preservation Officers and representative Indian tribes regarding the impacts of license renewal and the results of archaeological and architectural surveys of nuclear power plant sites.



**Appendix D**  
**Consultation Correspondence**



## D. Consultation Correspondences

The Endangered Species Act of 1973, as amended, the Magnuson-Stevens Fisheries Management Act of 1996, as amended; and the National Historic Preservation Act of 1966 require that Federal agencies consult with applicable State and Federal agencies and groups prior to taking action that may affect threatened and endangered species, essential fish habitat, or historic and archaeological resources, respectively. This appendix contains consultation documentation.

**Table D-1. Consultation Correspondences.** *This is a list of the consultation documents sent between the NRC and other agencies we are required to consult with based on NEPA requirements.*

Author	Recipient	Date of Letter
U.S. Nuclear Regulatory Commission (L. Lund)	U.S. Fish and Wildlife Service (D. Densmore)	April 4, 2008
U.S. Nuclear Regulatory Commission (L. Lund)	Oneida Indian Nation (R. Halbritter)	April 9, 2008 <sup>(a)</sup>
U.S. Nuclear Regulatory Commission (L. Lund)	Advisory Council on Historic Preservation (C. Vaughn)	April 15, 2008
U.S. Nuclear Regulatory Commission (L. Lund)	Pennsylvania Department of Conservation and Natural Resources (C. Firestone)	April 15, 2008
U.S. Nuclear Regulatory Commission (L. Lund)	Pennsylvania Fish and Boat Commission (C. Urban)	April 15, 2008
U.S. Nuclear Regulatory Commission (L. Lund)	Pennsylvania Game Commission (L. Leigey)	April 15, 2008
U.S. Nuclear Regulatory Commission (L. Lund)	Pennsylvania Historical and Museum Commission (J. Cutler)	April 15, 2008
Stockbridge-Munsee Tribal Historic Preservation Office (S. White)	U.S. Nuclear Regulatory Commission (L. Lund)	April 21, 2008

## Appendix D

<b>Author</b>	<b>Recipient</b>	<b>Date of Letter</b>
U.S. Fish and Wildlife Service (D. Densmore)	U.S. Nuclear Regulatory Commission (L. Lund)	April 23, 2008
Pennsylvania Department of Conservation and Natural Resources (R. Bowen)	U.S. Nuclear Regulatory Commission (L. Lund)	May 2, 2008
Pennsylvania Game Commission (J. Leigey)	U.S. Nuclear Regulatory Commission (L. Lund)	May 14, 2008
Pennsylvania Fish and Boat Commission (C. Urban)	U.S. Nuclear Regulatory Commission (S. Lopas)	June 3, 2008

(a) Similar letters went to fourteen other Native American Tribes listed in Section 1.8.

### **D.1 Consultation Correspondence**

The following pages contain copies of the letters listed in Table D-1. Figures contained in the first letter (pages D-6 and D-7) were included with each letter.

April 4, 2008

Mr. David Densmore  
U.S. Fish & Wildlife Service  
Pennsylvania Field Office  
315 South Allen Street, Suite 322  
State College, PA 16801-4850

SUBJECT: REQUEST FOR LIST OF PROTECTED SPECIES WITHIN THE AREA UNDER  
EVALUATION FOR THE THREE MILE ISLAND NUCLEAR STATION, UNIT 1,  
LICENSE RENEWAL APPLICATION REVIEW

Dear Mr. Densmore:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application submitted by AmerGen Energy Company, LLC (AmerGen), for the renewal of the operating license for Three Mile Island Nuclear Station, Unit 1 (TMI-1). TMI-1 is located on Three Mile Island, which is situated in the Susquehanna River, in Londonderry Township of Dauphin County, Pennsylvania, about 2.5 miles north of the southern tip of Dauphin County. As part of the review of the license renewal application (LRA), the NRC is preparing a Supplemental Environmental Impact Statement (SEIS) under the provisions of Title 10 of the *Code of Federal Regulations* Part 51 (10 CFR Part 51), the NRC's regulation that implements the National Environmental Policy Act (NEPA) of 1969. The SEIS includes an analysis of pertinent environmental issues, including endangered or threatened species and impacts to fish and wildlife. This letter is being submitted under the provisions of the Endangered Species Act of 1973, as amended, and the Fish and Wildlife Coordination Act of 1934, as amended.

AmerGen is requesting renewal of its operating license for TMI-1 for a period of 20 years beyond the expiration of the current license term of April 2014. The proposed action would include the use and continued maintenance of existing plant facilities and transmission lines. For the purpose of license renewal, AmerGen plans to replace the TMI-1 steam generators, and estimates that the total area disturbed by construction, decontamination, and laydown activities would be less than 10 acres, all of which would be previously disturbed property within the bounds of the TMI-1 flood protection dike.

The TMI-1 site encompasses several properties that total approximately 440 acres, including: the physical plant location on 200 acres of the 370-acre Three Mile Island; St. John's Island and Evergreen Island (also referred to as "Sand Beach Island"), together totaling 31 acres; a 6.4-acre section of Shelley Island, which is part of the western half of the TMI-1 Exclusion Area; and a 32-acre strip of land east of Three Mile Island along the eastern shore of the Susquehanna River; please see the attached site boundary map. The TMI-1 site is surrounded by fencing and contains few areas of undeveloped or undisturbed land; undeveloped land on Three Mile Island lies south of TMI-1 facilities. The majority of this land lies under the ten-year flood level, and contains wetlands and fallow field areas surrounded by a woodland buffer. Riparian buffer areas are intact around the perimeter of the island, although forested riparian areas only occur on the southern part of the island.

TMI-1 utilizes two hyperbolic natural draft cooling towers for dissipating heat from the plant steam cycle. The circulating water and service water systems withdraw water from the Susquehanna River, and are supplemented by three groundwater wells. TMI-1 has a permit with the Susquehanna River Basin Commission for consumptive use of river water up to 18 million gallons per day, on a monthly average, for electric generation. River water enters the intake structure located on the western bank of the island, passes under a skimmer wall, through automated trash racks with 1-inch vertical bar spacing, through 3/8-inch-mesh traveling screens, through the river water pumps, and finally through 1/8-inch-mesh strainers before entering the heat exchangers. Approximately 3000 gallons per minute of cooling tower blowdown are discharged to the Susquehanna River through a 48-inch-diameter river discharge line.

Four 230-kilovolt (kV) transmission lines totaling 5.6 miles of corridor and approximately 142 acres connect TMI-1 to the regional transmission system; please see the attached TMI-1 transmission system map. Two of these lines connect the plant with the substation at Middletown Junction, east of the Susquehanna River; each of these lines extends 1.5 miles. A third line extends for 4.1 miles to the west side of the Susquehanna River, where it connects to a 230-kV line terminating into the substation near Jackson – this line crosses the river twice. The fourth line extends 0.7 miles east across the Susquehanna River to the TMI-1 500-kV substation.

To support the SEIS preparation process and to ensure compliance with Section 7 of the Endangered Species Act, the NRC requests information on Federally listed, proposed, and candidate species and critical habitat that may be in the vicinity of TMI-1 and its associated transmission line corridors. In addition, please provide any information you consider appropriate under the provisions of the Fish and Wildlife Coordination Act.

The NRC staff plans to hold two public NEPA scoping meetings on May 1, 2008. The first session will be held in the afternoon and an identical session will be held later that evening. The afternoon session will be held at the Elks Movie Theatre, 4 West Emaus Street, Middletown, PA 17057. The evening session will be held at Londonderry Elementary School, 260 Schoolhouse Road, Middletown, PA 17057. The first meeting will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second meeting will convene at 7:00 p.m. and will continue until 10:00 p.m., as necessary. In addition, during the week of April 28, 2008, the NRC plans to conduct a site audit. You and your staff are invited to attend both the public meetings and the site audit. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is December 2008.



D. Densmore

- 3 -

If you have any questions concerning the NRC staff's review of this license renewal application, please contact Ms. Sarah Lopas, License Renewal Project Manager, at 301-415-1147 or [sll2@nrc.gov](mailto:sll2@nrc.gov).

Sincerely,

*/RA/*

Louise Lund, Branch Chief  
Projects Branch 1  
Division of License Renewal  
Office of Nuclear Reactor Regulation


Docket No. 50-289


Enclosures:

1. Site Boundary Map
2. TMI-1 Transmission System Map

cc w/encls.: See next page

Appendix D





## Appendix D

April 09, 2008

The Honorable Raymond Halbritter  
Nation Representative  
Oneida Indian Nation  
5218 Patrick Road  
Verona, NY 13478

SUBJECT: REQUEST FOR SCOPING COMMENTS CONCERNING THE THREE MILE  
ISLAND NUCLEAR STATION, UNIT 1, LICENSE RENEWAL APPLICATION  
REVIEW

Dear Representative Halbritter:

The U.S. Nuclear Regulatory Commission (NRC or the staff) has recently received an application from AmerGen Energy Company, LLC (AmerGen), for the renewal of the operating license for the Three Mile Island Nuclear Station, Unit 1 (TMI-1), located on Three Mile Island, which is situated in the Susquehanna River, in Londonderry Township of Dauphin County, Pennsylvania. The NRC is in the initial stages of developing a Supplemental Environmental Impact Statement to the Generic Environmental Impact Statement (GEIS), which will document the impacts associated with the renewal of TMI-1. We would like your assistance in our review by providing input to the NRC's environmental review scoping process. The NRC's process includes an opportunity for public and inter-governmental participation in the environmental review. We want to ensure that you are aware of our efforts pursuant to Title 10 of the *Code of Federal Regulations* Part 51, Section 51.28(b). In addition, as outlined in 36 CFR 800.8(c), the NRC plans to coordinate compliance with Section 106 of the National Historic Preservation Act of 1966 through the requirements of the National Environmental Policy Act of 1969.

The NRC has also sent copies of this letter to the tribal contacts for the following Federally-recognized tribes: Absentee-Shawnee Tribe of Oklahoma; Cayuga Nation; Delaware Nation; Delaware Trust Board; Eastern Shawnee Tribe of Oklahoma; Oneida Indian Nation; Oneida Nation of Wisconsin; Onondaga Nation; Seneca Nation of Indians; Seneca-Cayuga Tribe of Oklahoma; St. Regis Mohawk Tribe; Shawnee Tribe; Stockbridge-Munsee Band of the Mohican Nation of Wisconsin; Tonawanda Seneca Nation; and Tuscarora Nation.

Under NRC regulations, the original operating license for a nuclear power plant is issued for up to 40 years. The license may be renewed for up to an additional 20 years if NRC requirements are met. The current operating license for TMI-1 will expire in April 2014. The proposed action would include the use and continued maintenance of existing plant facilities and transmission lines. For the purpose of license renewal, AmerGen plans to replace the TMI-1 steam generators, and estimates that the total area disturbed by construction, decontamination, and laydown activities would be less than 10 acres, all of which would be previously disturbed property within the bounds of the TMI-1 flood protection dike. Provided for your information is the TMI-1 site boundary map (Enclosure 1) and transmission system map (Enclosure 2).

The GEIS considered the environmental impacts of renewing nuclear power plant operating licenses for a 20-year period on all currently operating sites. In the GEIS the NRC staff identified 92 environmental issues and developed generic conclusions related to environmental



-2-

impacts for 69 of these issues that apply to all plants or to plants with specific design or site characteristics. For the remaining 23 issues, plant-specific analyses will be documented in a supplement to the GEIS. A supplemental environmental impact statement will be prepared for TMI-1 to document the staff's review of environmental impacts related to terrestrial ecology, aquatic ecology, hydrology, cultural resources, and socioeconomic issues (among others), and will contain a recommendation regarding the environmental acceptability of the license renewal action.

Please submit any comments that you may have to offer on the scope of the environmental review by May 30, 2008. Written comments should be submitted by mail to the Chief, Rules and Directives Branch, Division of Administrative Services, Mail Stop T-6D59, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001. Electronic comments may be submitted to the NRC by e-mail at [ThreeMileIslandEIS@nrc.gov](mailto:ThreeMileIslandEIS@nrc.gov). At the conclusion of the scoping process, the NRC staff will prepare a summary of the significant issues identified and the conclusions reached, and mail a copy to you.

To accommodate interested members of the public, the NRC will hold two public scoping meetings for the TMI-1 license renewal supplement to the GEIS on May 1, 2008. The first session will be held in the afternoon and an identical session will be held later that evening. The afternoon session will be held at the Elks Movie Theatre, 4 West Emaus Street, Middletown, PA 17057. The evening session will be held at Londonderry Elementary School, 260 Schoolhouse Road, Middletown, PA 17057. The first meeting will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second meeting will convene at 7:00 p.m. and will continue until 10:00 p.m., as necessary. Additionally, the NRC staff will host informal discussions one hour before the start of each session.

The TMI-1 license renewal application and the GEIS are available on the internet at [www.nrc.gov/reactors/operating/licensing/renewal/applications/three-mile-island.html](http://www.nrc.gov/reactors/operating/licensing/renewal/applications/three-mile-island.html). In addition, the following locations have agreed to make the license renewal application and the GEIS available for public inspection: Londonderry Township Municipal Building, 783 South Geyers Church Road, Middletown, PA 17057; Middletown Public Library, 20 North Catherine Street, Middletown, PA 17057; and Penn State Harrisburg Library, 351 Olmsted Drive, Middletown, PA 17057.

The staff expects to publish the draft supplemental environmental impact statement in December 2008. A copy of the document will be sent to you for your review and comment. The NRC will hold another set of public meetings in the site vicinity to solicit comments on the draft supplemental environmental impact statement. After consideration of public comments received, the NRC will prepare a final supplemental environmental impact statement, which is scheduled to be issued in July 2009.

Appendix D

-3-

If you need additional information regarding the license renewal review process, please contact Ms. Sarah Lopas, License Renewal Project Manager, at 301-415-1147 or at [sl2@nrc.gov](mailto:sl2@nrc.gov).

Sincerely,

\RA\

Louise Lund, Branch Chief  
Projects Branch 1  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-289

Enclosures:  
As Stated

April 15, 2008

Ms. Charlene Dwin Vaughn  
Assistant Director  
Advisory Council on Historic Preservation  
Office of Federal Agency Programs  
1100 Pennsylvania Ave, NW, Suite 803  
Washington, DC 20004

SUBJECT: THREE MILE ISLAND NUCLEAR STATION, UNIT 1, LICENSE RENEWAL  
APPLICATION REVIEW

Dear Ms. Vaughn:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application to renew the operating license for Three Mile Island Nuclear Station, Unit 1 (TMI-1), located on Three Mile Island, which is situated in the Susquehanna River, in Londonderry Township of Dauphin County, Pennsylvania, about 2.5 miles north of the southern tip of Dauphin County. TMI-1 is operated by AmerGen Energy Company, LLC (AmerGen). The application for renewal was submitted by AmerGen in a letter dated January 8, 2008, pursuant to Title 10 of the *Code of Federal Regulations* Part 54 (10 CFR Part 54).

The NRC has established that, as part of the staff's review of any nuclear power plant license renewal action, a site-specific Supplemental Environmental Impact Statement (SEIS) to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants," NUREG-1437, will be prepared under the provisions of 10 CFR Part 51, the NRC's regulation that implements the National Environmental Policy Act of 1969 (NEPA). In accordance with 36 CFR 800.8(c), the SEIS will include analyses of potential impacts to historic and cultural resources.

On May 1, 2008, the NRC will conduct two public NEPA scoping meetings. The first session will be held in the afternoon and an identical session will be held later that evening. The afternoon session will be held at the Elks Movie Theatre, 4 West Emaus Street, Middletown, PA 17057. The evening session will be held at Londonderry Elementary School, 260 Schoolhouse Road, Middletown, PA 17057. The first meeting will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second meeting will convene at 7:00 p.m. and will continue until 10:30 p.m., as necessary. You and your staff are invited to attend the public meetings. In addition, during the week of April 28, 2008, the NRC staff plans to conduct a site audit at TMI-1. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is December 2008.

## Appendix D

C. Vaughn

-2-

If you have any questions or require additional information, please contact the License Renewal Project Manager, Ms. Sarah Lopas, at 301-415-1147 or by e-mail at [sl2@nrc.gov](mailto:sl2@nrc.gov).

Sincerely,

*/RA/*

Louise Lund, Branch Chief  
Projects Branch 1  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-289

cc: See next page



April 15, 2008

Ms. Chris Firestone  
Native Plant Program Manager  
Bureau of Forestry (Plant Program)  
Forestry Advisory Services  
Pennsylvania Department of Conservation  
and Natural Resources  
P.O. Box 8552  
Harrisburg, PA 17105-1673

SUBJECT: REQUEST FOR LIST OF STATE-PROTECTED SPECIES AND IMPORTANT HABITATS WITHIN THE AREA UNDER EVALUATION FOR THE THREE MILE ISLAND NUCLEAR STATION, UNIT 1, LICENSE RENEWAL APPLICATION REVIEW

Dear Ms. Firestone:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application submitted by AmerGen Energy Company, LLC (AmerGen), for the renewal of the operating license for Three Mile Island Nuclear Station, Unit 1 (TMI-1). TMI-1 is located on Three Mile Island, which is situated in the Susquehanna River, in Londonderry Township of Dauphin County, Pennsylvania, about 2.5 miles north of the southern tip of Dauphin County. As part of the review of the license renewal application (LRA), the NRC is preparing a Supplemental Environmental Impact Statement (SEIS) under the provisions of Title 10 of the *Code of Federal Regulations* Part 51 (10 CFR Part 51), the NRC's regulation that implements the National Environmental Policy Act (NEPA) of 1969. The SEIS includes an analysis of pertinent environmental issues, including endangered or threatened species and impacts to fish and wildlife.

AmerGen is requesting renewal of its operating license for TMI-1 for a period of 20 years beyond the expiration of the current license term of April 2014. The proposed action would include the use and continued maintenance of existing plant facilities and transmission lines. For the purpose of license renewal, AmerGen plans to replace the TMI-1 steam generators, and estimates that the total area disturbed by construction, decontamination, and laydown activities would be less than 10 acres, all of which would be previously disturbed property within the bounds of the TMI-1 flood protection dike.

The TMI-1 site encompasses several properties that total approximately 440 acres, including: the physical plant location on 200 acres of the 370-acre Three Mile Island; St. John's Island and Evergreen Island (also referred to as "Sand Beach Island"), together totaling 31 acres; a 6.4-acre section of Shelley Island, which is part of the western half of the TMI-1 Exclusion Area; and a 32-acre strip of land east of Three Mile Island along the eastern shore of the Susquehanna River; please see the enclosed site boundary map. The TMI-1 site is surrounded by fencing and contains few areas of undeveloped or undisturbed land; undeveloped land on Three Mile Island lies south of TMI-1 facilities. The majority of this land lies under the ten-year flood level, and contains wetlands and fallow field areas surrounded by a woodland buffer. Riparian buffer areas are intact around the perimeter of the island, although forested riparian areas only occur on the southern part of the island.

## Appendix D

C. Firestone

- 2 -

Four 230-kilovolt (kV) transmission lines totaling 5.6 miles of corridor and approximately 142 acres connect TMI-1 to the regional transmission system; please see the enclosed TMI-1 transmission system map. Two of these lines connect the plant with the substation at Middletown Junction, east of the Susquehanna River; each of these lines extends 1.5 miles. A third line extends for 4.1 miles to the west side of the Susquehanna River, where it connects to a 230-kV line terminating into the substation near Jackson – this line crosses the river twice. The fourth line extends 0.7 miles east across the Susquehanna River to the TMI-1 500-kV substation.

To support the SEIS preparation process and to ensure compliance with Section 7 of the Endangered Species Act, the NRC requests information on state-listed, proposed, and candidate species and critical habitat that may be in the vicinity of TMI-1 and its associated transmission line corridors.

The NRC staff plans to hold two public NEPA scoping meetings on May 1, 2008. The first session will be held in the afternoon and an identical session will be held later that evening. The afternoon session will be held at the Elks Movie Theatre, 4 West Emaus Street, Middletown, PA 17057. The evening session will be held at Londonderry Elementary School, 260 Schoolhouse Road, Middletown, PA 17057. The first meeting will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second meeting will convene at 7:00 p.m. and will continue until 10:00 p.m., as necessary. In addition, during the week of April 28, 2008, the NRC plans to conduct a site audit. You and your staff are invited to attend both the public meetings and the site audit. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is December 2008.

If you have any questions concerning the NRC staff's review of this license renewal application, please contact Ms. Sarah Lopas, License Renewal Project Manager, at 301-415-1147 or by e-mail at [sll2@nrc.gov](mailto:sll2@nrc.gov).

Sincerely,

/RA/

Louise Lund, Branch Chief  
Projects Branch 1  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-289

Enclosures:  
As stated

cc w/encls: See next page

April 15, 2008

Mr. Christopher Urban  
Chief of Natural Diversity Section  
Pennsylvania Fish and Boat Commission  
450 Robinson Lane  
Bellefonte, PA 16823-9620

SUBJECT: REQUEST FOR LIST OF STATE-PROTECTED SPECIES WITHIN THE AREA  
UNDER EVALUATION FOR THE THREE MILE ISLAND NUCLEAR STATION,  
UNIT 1, LICENSE RENEWAL APPLICATION REVIEW

Dear Mr. Urban:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application submitted by AmerGen Energy Company, LLC (AmerGen), for the renewal of the operating license for Three Mile Island Nuclear Station, Unit 1 (TMI-1). TMI-1 is located on Three Mile Island, which is situated in the Susquehanna River, in Londonderry Township of Dauphin County, Pennsylvania, about 2.5 miles north of the southern tip of Dauphin County. As part of the review of the license renewal application (LRA), the NRC is preparing a Supplemental Environmental Impact Statement (SEIS) under the provisions of Title 10 of the *Code of Federal Regulations* Part 51 (10 CFR Part 51), the NRC's regulation that implements the National Environmental Policy Act (NEPA) of 1969. The SEIS includes an analysis of pertinent environmental issues, including endangered or threatened species and impacts to fish and wildlife.

AmerGen is requesting renewal of its operating license for TMI-1 for a period of 20 years beyond the expiration of the current license term of April 2014. The proposed action would include the use and continued maintenance of existing plant facilities and transmission lines. For the purpose of license renewal, AmerGen plans to replace the TMI-1 steam generators, and estimates that the total area disturbed by construction, decontamination, and laydown activities would be less than 10 acres, all of which would be previously disturbed property within the bounds of the TMI-1 flood protection dike.

The TMI-1 site encompasses several properties that total approximately 440 acres, including: the physical plant location on 200 acres of the 370-acre Three Mile Island; St. John's Island and Evergreen Island (also referred to as "Sand Beach Island"), together totaling 31 acres; a 6.4-acre section of Shelley Island, which is part of the western half of the TMI-1 Exclusion Area; and a 32-acre strip of land east of Three Mile Island along the eastern shore of the Susquehanna River; please see the enclosed site boundary map. The TMI-1 site is surrounded by fencing and contains few areas of undeveloped or undisturbed land; undeveloped land on Three Mile Island lies south of TMI-1 facilities. The majority of this land lies under the ten-year flood level, and contains wetlands and fallow field areas surrounded by a woodland buffer. Riparian buffer areas are intact around the perimeter of the island, although forested riparian areas only occur on the southern part of the island.

TMI-1 utilizes two hyperbolic natural draft cooling towers for dissipating heat from the plant steam cycle. The circulating water and service water systems withdraw water from the Susquehanna River, and are supplemented by three groundwater wells. TMI-1 has a permit with the Susquehanna River Basin Commission for consumptive use of river water up to 18 million gallons per day, on a monthly average, for electric generation. River water enters the intake structure located on the western bank of the island, passes under a skimmer wall, through automated trash racks with 1-inch vertical bar spacing, through 3/8-inch-mesh traveling screens, through the river water pumps, and finally through 1/8-inch-mesh strainers before entering the heat exchangers. Approximately 3000 gallons per minute of cooling tower blowdown are discharged to the Susquehanna River through a 48-inch-diameter river discharge line.

Four 230-kilovolt (kV) transmission lines totaling 5.6 miles of corridor and approximately 142 acres connect TMI-1 to the regional transmission system; please see the enclosed TMI-1 transmission system map. Two of these lines connect the plant with the substation at Middletown Junction, east of the Susquehanna River; each of these lines extends 1.5 miles. A third line extends for 4.1 miles to the west side of the Susquehanna River, where it connects to a 230-kV line terminating into the substation near Jackson – this line crosses the river twice. The fourth line extends 0.7 miles east across the Susquehanna River to the TMI-1 500-kV substation.

To support the SEIS preparation process and to ensure compliance with Section 7 of the Endangered Species Act, the NRC requests information on state-listed, proposed, and candidate species and critical habitat that may be in the vicinity of TMI-1 and its associated transmission line corridors. Please see the enclosed Species Impact Review (SIR) request form.

The NRC staff plans to hold two public NEPA scoping meetings on May 1, 2008. The first session will be held in the afternoon and an identical session will be held later that evening. The afternoon session will be held at the Elks Movie Theatre, 4 West Emaus Street, Middletown, PA 17057. The evening session will be held at Londonderry Elementary School, 260 Schoolhouse Road, Middletown, PA 17057. The first meeting will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second meeting will convene at 7:00 p.m. and will continue until 10:00 p.m., as necessary. In addition, during the week of April 28, 2008, the NRC plans to conduct a site audit. You and your staff are invited to attend both the public meetings and the site audit. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is December 2008.

**FISH AND BOAT COMMISSION**

NATURAL DIVERSITY SECTION

PFBC-DES-NDS-1 (5/2/03) **SPECIES IMPACT REVIEW (SIR) REQUEST FORM**  
COMMONWEALTH

A. This form provides the site information necessary to perform a computer database search for species of special concern listed under the Endangered Species Act of 1973, the Wild Resource Conservation Act, the Pennsylvania Fish and Boat Code or the Wildlife Code.

B. Use only **one form** for each proposed project or location. Complete the information below and **mail** form to:  
OF PENNSYLVANIA

Natural Diversity Section Division  
of Environmental Services PA Fish  
and Boat Commission 450  
Robinson Lane Bellefonte, PA  
16823 Fax: (814) 359-5175

C. This form, a cover letter including a project narrative, and accompanying maps should be sent to the above address for environmental reviews that only concern reptiles, amphibians, fishes and aquatic invertebrates. Reviews for other natural resources must be submitted to other appropriate agencies.

D. The absence of recorded information from our databases and files does not necessarily imply actual conditions on site. Future field investigations could alter this determination. The information contained in our files is routinely updated. A review is valid for one year.

E. Please send us only one (1) copy of your request – either by fax or by mail – not both. Mail is preferred to improve legibility of maps. Facsimile submission will not improve our response turn-around time.

F. Allow 30 days for completion of the review from the date of PFBC receipt. Large projects and workload may extend this review timeframe.

G. In any future correspondence with us following your receipt of the SIR response, please refer to the assigned SIR number at the top left of our cover letter.

H. FORMS THAT ARE NOT COMPLETED IN FULL WILL NOT BE REVIEWED.

PLEASE PRINT OR TYPE: If available, provide the potential conflict PNDI Search Number: *N/A*

PFBC response should be sent to Company/Agency: **U.S. Nuclear Regulatory Commission**

Form Preparer: **Sarah Lopas, License Renewal Project Manager**

Address: **U.S. Nuclear Regulatory Commission, 11555 Rockville Pike, Mail Stop O-11F1, Rockville, MD 20852**

Phone (8:00 AM to 4:00 PM): **301.415.1147**

Project Description: **Three Mile Island Nuclear Station, Unit 1, License Renewal (please see cover letter)**

Indicate if the project is: Transportation or Non-transportation **X** (check one)

Will the proposed project encroach directly or indirectly (e.g., runoff) upon wetlands or waterways? Circle one for each:

Wetlands: Yes No **UNKNOWN** Waterways: **YES** No Unknown

County: **Dauphin** Township/Municipality: **Londonderry**

Name of the United States Geological Survey (U.S.G.S.) 7.5 Minute Quadrangle Map where project is located: **Middletown**

Project size (in acres): **Approximately 276** Attach an 8.5" by 11" photocopy (**DO NOT REDUCE**) of the section of the U.S.G.S. Quadrangle Map which identifies the project location. On this map, indicate the location of the project center (if linear, depict both ends) and outline the approximate boundaries of the project area. Specify latitude/longitude of the project center.

**Latitude: 40° /9.2' N.**

**Longitude: 72° /43.5' W**

**FOR PFBC USE ONLY**

SIR#	Quad Name	Data Source	Search Result-Potential Species Conflict	Action

## Appendix D

April 15, 2008

Mr. James Leigey  
Wildlife Impact Review Coordinator  
Pennsylvania Game Commission  
2001 Elmerton Avenue  
Harrisburg, PA 17110-9797

SUBJECT: REQUEST FOR LIST OF STATE-PROTECTED SPECIES WITHIN THE AREA  
UNDER EVALUATION FOR THE THREE MILE ISLAND NUCLEAR STATION,  
UNIT 1, LICENSE RENEWAL APPLICATION REVIEW

Dear Mr. Leigey:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application submitted by AmerGen Energy Company, LLC (AmerGen), for the renewal of the operating license for Three Mile Island Nuclear Station, Unit 1 (TMI-1). TMI-1 is located on Three Mile Island, which is situated in the Susquehanna River, in Londonderry Township of Dauphin County, Pennsylvania, about 2.5 miles north of the southern tip of Dauphin County. As part of the review of the license renewal application (LRA), the NRC is preparing a Supplemental Environmental Impact Statement (SEIS) under the provisions of Title 10 of the *Code of Federal Regulations* Part 51 (10 CFR Part 51), the NRC's regulation that implements the National Environmental Policy Act (NEPA) of 1969. The SEIS includes an analysis of pertinent environmental issues, including endangered or threatened species and impacts to fish and wildlife.

AmerGen is requesting renewal of its operating license for TMI-1 for a period of 20 years beyond the expiration of the current license term of April 2014. The proposed action would include the use and continued maintenance of existing plant facilities and transmission lines. For the purpose of license renewal, AmerGen plans to replace the TMI-1 steam generators, and estimates that the total area disturbed by construction, decontamination, and laydown activities would be less than 10 acres, all of which would be previously disturbed property within the bounds of the TMI-1 flood protection dike.

The TMI-1 site encompasses several properties that total approximately 440 acres, including: the physical plant location on 200 acres of the 370-acre Three Mile Island; St. John's Island and Evergreen Island (also referred to as "Sand Beach Island"), together totaling 31 acres; a 6.4-acre section of Shelley Island, which is part of the western half of the TMI-1 Exclusion Area; and a 32-acre strip of land east of Three Mile Island along the eastern shore of the Susquehanna River; please see the enclosed site boundary map. The TMI-1 site is surrounded by fencing and contains few areas of undeveloped or undisturbed land; undeveloped land on Three Mile Island lies south of TMI-1 facilities. The majority of this land lies under the ten-year flood level, and contains wetlands and fallow field areas surrounded by a woodland buffer. Riparian buffer areas are intact around the perimeter of the island, although forested riparian areas only occur on the southern part of the island.

J. Leigey

- 2 -

Four 230-kilovolt (kV) transmission lines totaling 5.6 miles of corridor and approximately 142 acres connect TMI-1 to the regional transmission system; please see the enclosed TMI-1 transmission system map. Two of these lines connect the plant with the substation at Middletown Junction, east of the Susquehanna River; each of these lines extends 1.5 miles. A third line extends for 4.1 miles to the west side of the Susquehanna River, where it connects to a 230-kV line terminating into the substation near Jackson – this line crosses the river twice. The fourth line extends 0.7 miles east across the Susquehanna River to the TMI-1 500-kV substation.

To support the SEIS preparation process and to ensure compliance with Section 7 of the Endangered Species Act, the NRC requests information on state-listed, proposed, and candidate species and critical habitat that may be in the vicinity of TMI-1 and its associated transmission line corridors.

The NRC staff plans to hold two public NEPA scoping meetings on May 1, 2008. The first session will be held in the afternoon and an identical session will be held later that evening. The afternoon session will be held at the Elks Movie Theatre, 4 West Emaus Street, Middletown, PA 17057. The evening session will be held at Londonderry Elementary School, 260 Schoolhouse Road, Middletown, PA 17057. The first meeting will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second meeting will convene at 7:00 p.m. and will continue until 10:00 p.m., as necessary. In addition, during the week of April 28, 2008, the NRC plans to conduct a site audit. You and your staff are invited to attend both the public meetings and the site audit. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is December 2008.

If you have any questions concerning the NRC staff's review of this license renewal application, please contact Ms. Sarah Lopas, License Renewal Project Manager, at 301-415-1147 or by e-mail at [sll2@nrc.gov](mailto:sll2@nrc.gov).

Sincerely,

/RA/

Louise Lund, Branch Chief  
Projects Branch 1  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-289

Enclosures:  
As stated

cc w/encls: See next page



## Appendix D

April 15, 2008

Jean Cutler, Deputy State Historic Preservation Officer  
Pennsylvania Historical and Museum Commission  
Bureau for Historic Preservation  
Commonwealth Keystone Building, Second Floor  
400 North Street  
Harrisburg, PA 17120-0093

SUBJECT: THREE MILE ISLAND NUCLEAR STATION, UNIT 1, LICENSE RENEWAL  
APPLICATION REVIEW (FILE NO. ER 07-1737-043-A)

Dear Ms. Cutler:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application to renew the operating license for Three Mile Island Nuclear Station, Unit 1 (TMI-1), located on Three Mile Island, which is situated in the Susquehanna River, in Londonderry Township of Dauphin County, Pennsylvania, about 2.5 miles north of the southern tip of Dauphin County. TMI-1 is operated by AmerGen Energy Company, LLC (AmerGen). The application for renewal was submitted by AmerGen in a letter dated January 8, 2008, pursuant to Title 10 of the *Code of Federal Regulations* Part 54 (10 CFR Part 54).

The NRC has established that, as part of the staff's review of any nuclear power plant license renewal action, a site-specific Supplemental Environmental Impact Statement (SEIS) to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants," NUREG-1437, will be prepared under the provisions of 10 CFR Part 51, the NRC's regulation that implements the National Environmental Policy Act of 1969 (NEPA). In accordance with 36 CFR 800.8(c), the SEIS will include analyses of potential impacts to historic and cultural resources.

In the context of the National Historic Preservation Act of 1966, as amended, the NRC staff has determined that the area of potential effect (APE) for a license renewal action is the area at the power plant site and its immediate environs that may be impacted by post-license renewal land-disturbing operations or projected refurbishment activities associated with the proposed action. The APE may extend beyond the immediate environs in those instances where post-license renewal land-disturbing operations or projected refurbishment activities specifically related to license renewal may potentially have an effect on known or proposed historic sites. This determination is made irrespective of ownership or control of the lands of interest.

On May 1, 2008, the NRC will conduct two public NEPA scoping meetings. The first session will be held in the afternoon and an identical session will be held later that evening. The afternoon session will be held at the Elks Movie Theatre, 4 West Emaus Street, Middletown, PA 17057. The evening session will be held at Londonderry Elementary School, 260 Schoolhouse Road, Middletown, PA 17057. The first meeting will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second meeting will convene at 7:00 p.m. and will continue until 10:00 p.m., as necessary. You and your staff are invited to attend. Your office will receive a



J. Cutler

- 2 -

copy of the draft SEIS along with a request for comments. The staff expects to publish the draft SEIS in December 2008. If you have any questions or require additional information, please contact Ms. Sarah Lopas, License Renewal Project Manager, by phone at 301-415-1147 or by e-mail at [sll2@nrc.gov](mailto:sll2@nrc.gov).

Sincerely,

/RA/

Louise Lund, Branch Chief  
Projects Branch 1  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-289

cc w/encls: See next page

*Stockbridge-Munsee Tribal Historic Preservation Office*

*Sherry White - Tribal Historic Preservation Officer*

*W13447 Camp 14 Road*

*P.O. Box 70*

*Bowler, WI 54416*

2008 APR 29 AM 8:49

RECEIVED

April 21, 2008

Chief  
Rules & Directives Branch  
Division of Administrative Services  
Mail Stop T-6D59  
U.S. Regulatory Commission  
Washington, DC 20555-0001

RE: Three Mile Island Nuclear Station, Unit 1  
License Renewal Application Review

Dear Sir:

Thank you for contacting the Stockbridge-Munsee Tribe regarding the above referenced project. The Tribe is committed to protecting archaeological sites that are important to tribal heritage, culture and religion. Furthermore, the Tribe is particularly concerned with archaeological sites that may contain human burial remains and associated funerary objects.

As described in your correspondence, the proposed ground disturbing activity of this project is not in a region of archaeological interest to the Stockbridge-Munsee Tribe.

We appreciate your cooperation in notifying the Historic Preservation Office. Should you have any questions, feel free to contact me.

Sincerely,

*Sherry White*  
Sherry White,  
Tribal Historic Preservation Officer

(715) 793-3970

Email: [sherry.white@mohican-nsn.gov](mailto:sherry.white@mohican-nsn.gov)



## United States Department of the Interior

FISH AND WILDLIFE SERVICE  
Pennsylvania Field Office  
315 South Allen Street, Suite 322  
State College, Pennsylvania 16801-4850



April 23, 2008

Louise Lund, Branch Chief  
Projects Branch 1  
Division of License Renewal  
Office of Nuclear Reactor Regulation  
Nuclear Regulatory Commission  
Washington, D.C. 20555-0001

Re: Three Mile Island Nuclear Station, Unit 1, License Renewal Application Review  
USFWS Project #2007-1764

Dear Ms. Lund:

This responds to your April 4, 2008, letter requesting information on threatened or endangered species or other natural resources of concern in the referenced project area. The following comments are provided pursuant to the Endangered Species Act of 1973 (87 Stat. 884, as amended; 16 U.S.C. 1531 *et seq.*) to ensure the protection of endangered and threatened species, and the Bald and Golden Eagle Protection Act (Eagle Act; 16 U.S.C. 668-668d).

### Federally Listed Threatened or Endangered Species

Except for occasional transient species, no federally listed or proposed threatened or endangered species under our jurisdiction are known to occur within the project impact area. Therefore, based on currently available information, no biological assessment or further consultation under the Endangered Species Act is required with the Fish and Wildlife Service. Should project plans change, or if additional information on listed or proposed species becomes available, this determination may be reconsidered.

### Bald Eagle

In a letter to Michael Gallagher of AmerGen (copy enclosed), dated June 7, 2007, we advised that a bald eagle nest is located on the west side of the Susquehanna River to the northwest of the Three Mile Island facility. At the time, the bald eagle was federally listed as threatened. However, the Fish and Wildlife Service has since published a final rulemaking to remove the bald eagle from the federal *List of Endangered and Threatened Wildlife* on July 9, 2007 (*Federal Register*, Vol. 72, No. 130). This rule became effective on August 8, 2007. Although the bald

## Appendix D

eagle no longer receives protection under the Endangered Species Act, it continues to be protected under the Eagle Act and the Migratory Bird Treaty Act. Both acts protect bald eagles by prohibiting killing, selling or otherwise harming eagles, their nests or eggs. The Eagle Act also protects eagles from disturbance. Disturb means to agitate or bother a bald or golden eagle to a degree that causes, or is likely to cause, based on the best scientific information available, 1) injury to an eagle, 2) a decrease in its productivity, by substantially interfering with normal breeding, feeding, or sheltering behavior, or 3) nest abandonment, by substantially interfering with normal breeding, feeding, or sheltering behavior.

The Service has developed *National Bald Eagle Management Guidelines* to advise landowners, land managers and others who share public and private lands with bald eagles when and under what circumstances the protective provisions of the Eagle Act may apply to their activities. The *Guidelines* include general recommendations for land management practices that will benefit bald eagles; however, the document is intended primarily as a tool to provide those who seek information and recommendations regarding how to avoid disturbing bald eagles. Adherence to the *Guidelines* will benefit individuals, agencies, organizations and companies by helping them avoid violations of the law. The *Guidelines* can be found at <http://www.fws.gov/migratorybirds/baldeagle.htm>; any questions about the *Guidelines* or how they would apply to a particular project, can be directed to this office.

Transmission lines and their support structures within or close to the shores of the river would be ideal perching locations for foraging eagles. If the lines are not already equipped with features to prevent raptor electrocution and collisions, we recommend that any future upgrades be designed following the *Suggested Practices for Avian Protection on Power Lines: The State of the Art in 2006* (available from the Avian Power Line Interaction Committee at <http://www.aplic.org>).

Based on our review of the proposed project, it is our determination that this project will not disturb bald eagles. Because no take or disturbance is anticipated, none is authorized. If project plans change, please contact the Service to determine whether or not the project modifications will result in effects to bald eagles that may necessitate an Eagle Act permit or Endangered Species Act authorization.

Thank you for the opportunity to comment. Please direct any questions regarding this matter to Cindy Tibbott of my staff at 814-234-4090.

Sincerely,



David Densmore  
Supervisor

Enclosures

Cc:  
Michael Gallagher, AmerGen, 200 Exelon Way, KSA/2-E, Kennett Square, PA 19348

CTibbott:clt 4/15/08  
P:\Drafts\Drafts 2008\2007-1764 Three Mile Island.doc



Pennsylvania Department of Conservation and Natural Resources

Bureau of Forestry

May 2, 2008

Louise Lund, Branch Chief, Reactor Projects 1  
MS O-11F1  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

C.C. Sarah Lopas  
MS O-11F1  
U.S. Nuclear Regulatory Commission  
11555 Rockville Pike  
Rockville, MD 20852

<i>Pennsylvania Natural Diversity Inventory Review, PNDI Number</i>	<b>19605 (old #19248)</b>
Three Mile Island Unit 1 License Renewal Species of Special Concern	
Dauphin & Lancaster Counties	

Dear Ms. Lund,

This responds to your request about a Pennsylvania Natural Diversity Inventory (PNDI) ER Tool "Potential Impact" or a species of special concern impact review. We screened this project for potential impacts to species and resources of special concern under the Department of Conservation and Natural Resources' responsibility, which includes plants, natural communities, terrestrial invertebrates and geologic features only.

PNDI records indicate that species and communities of special concern under DCNR's jurisdiction are known to occur in the vicinity of the above-mentioned project. Please see the attached list for species found in the vicinity of this project. No impact is anticipated since earth disturbance is expected to be "within the bounds of the Three Mile Island Flood Protection dike," as stated in April 15, 2008 letter to DCNR. If plans change to include disturbance outside of the Flood Protection dike area (particularly if more disturbance is required for Transmission Line No. 1051), please coordinate with our office as a survey may be requested.

This response represents the most up-to-date summary of the PNDI data files and is good for one (1) year from the date of this letter. An absence of recorded information does not necessarily imply actual conditions on-site. A field survey of any site may reveal previously unreported populations. Should project plans change or additional information on listed or proposed species become available, this determination may be reconsidered.

This finding applies to impacts to plants, natural communities, terrestrial invertebrates and geologic features only. To complete your review of state and federally-listed species of special concern, please be sure the U.S. Fish and Wildlife Service, the PA Game Commission and the Fish and Boat Commission has been contacted regarding this project either directly or by performing a search with the online PNDI ER Tool found at [www.naturalheritage.state.pa.us](http://www.naturalheritage.state.pa.us).

*Rebecca H. Bowen*  
 Rebecca H. Bowen, Environmental Review Specialist  
 DCNR/BOF/PNDI, PO Box 8552, Harrisburg, PA 17105 ~ Ph: 717-772-0258 ~ F: 717-772-0271 ~ [c-rbowen@state.pa.us](mailto:c-rbowen@state.pa.us)

Stewardship Partnership Service

Bureau of Forestry

May 2, 2008

<i>Pennsylvania Natural Diversity Inventory Review, PNDI Number 19605 (old #19248)</i>
Three Mile Island Unit 1 License Renewal Species of Special Concern
Dauphin & Lancaster Counties

***Plant Species of Special Concern***

Scientific Name	Common Name	Current Status	Proposed Status	Habitat	Flowering time
<i>Boltonia asteroides</i>	Aster-like Boltonia	PE	PE	rocky shores and exposed rocky river beds	flowers July-Oct
<i>Carex shortiana</i>	Sedge	N	PR	calcareous wet meadows and swamps and rich woods	
<i>Eleocharis compressa</i>	Flat-stemmed Spike-rush	PE	PE	wet, sandy ground and river banks	
<i>Ellisia nyctelea</i>	Ellisia	PT	PT	damp, shady banks and rich alluvial woods	flowers in May

***Additional Information:*****Butterfly Species of Special Concern**

Scientific Name	Common Name	Global Rank	State Rank	Habitat	Larval Host
<i>Lycaena hyllus</i>	Bronze Copper	Globally Secure	Currently unrankable due to lack of information or due to substantially conflicting information about status or trends.	Low wet meadows / marshes, especially in river flood plains. Very large, floppy-flying copper.	Water dock ( <i>Rumex orbiculatus</i> ) and curled dock ( <i>Rumex crispus</i> )

**Geologic Features of Special Concern**

Erosional Remnant made up of a series of large potholes in diabase in the bed of the Susquehanna from the Triassic Age is known to exist where the transmission lines cross the river towards York Haven.

**Communities of Special Concern**

There is also a Riverside Outcrop Community in the vicinity. This community is characterized by semi-permanently or seasonally flooded vegetation of the riverbed, banks and islands.

More information on this community may be found online in *Terrestrial & Palustrine Plant Communities of Pennsylvania* by Jean Fike, Pennsylvania Natural Diversity Inventory:  
<http://www.dcnr.state.pa.us/wrcf/fikebook/21Chapter8.pdf> (page 55).

*No impact anticipated; this list is for your own information.*



COMMONWEALTH OF PENNSYLVANIA  
**PENNSYLVANIA GAME COMMISSION**  
2001 ELMERTON AVENUE, HARRISBURG, PA 17110-9797

May 14, 2008

Ms. Louise Lund  
U.S. Nuclear Regulatory Commission  
Projects Branch 1  
Division of License Renewal  
Office of Nuclear Reactor Regulation  
Washington, D.C. 20555-0001

In re: State-Protected Bird and Mammal Species Review  
Three Mile Island Nuclear Station  
License Renewal, Application  
Londonderry Township, Dauphin County, PA

Dear Ms. Lund:

This is in response to your request of April 15, 2008 regarding information on state-listed, proposed, and candidate species of birds or mammals recognized by the Pennsylvania Game Commission (PGC), which may be in the vicinity of the Three Mile Island Nuclear Station (TMI).

Our office review has determined that Prothonotary Warblers (*Protonotaria citrea*), Bald Eagles (*Haliaeetus leucocephalus*), Yellow-crowned Night Herons (*Nycticorax violacea*), and Black-crowned Night Herons (*Nycticorax nycticorax*) have been documented nesting and foraging in proximity to the Three Mile Island Nuclear Station. Peregrine Falcons (*Falco peregrinus*) have been documented nesting on the Unit 1 Reactor Building, and Ospreys (*Pandion haliaetus*) have been documented nesting atop the weather station at the TMI.

The renewal of the TMI Operating License is not anticipated to cause any adverse impacts to special concern species of birds and mammals that may be in the vicinity of the transmission line corridors associated with the electric generating station. No adverse impacts to ospreys and peregrine falcons are anticipated due to the license renewal since there has been ongoing coordination by the AmerGen Energy Company, LLC with the PGC regarding Best Management Practices for the endangered and threatened species nesting at TMI. This determination may be reconsidered if project plans change or extend beyond the present study area, or if additional information becomes available on state-listed species.

If you have any questions, please contact me at (717) 787-4250. Please be advised that this determination is only valid for one year from the date of this letter.

ADMINISTRATIVE BUREAUS:

PERSONNEL: 717-787-7836 ADMINISTRATION: 717-787-5670 AUTOMOTIVE AND PROCUREMENT: 717-787-6594  
LICENSE DIVISION: 717-787-2084 WILDLIFE MANAGEMENT: 717-787-5529 INFORMATION & EDUCATION: 717-787-6286  
WILDLIFE PROTECTION: 717-787-5740 WILDLIFE HABITAT MANAGEMENT: 717-787-6818 REAL ESTATE: 717-787-6568  
AUTOMATED TECHNOLOGY SYSTEMS: 717-787-4076

WWW.PGC.STATE.PA.US




Ms. Louise Lund

2

May 14, 2008

Very truly yours,



James R. Leigey  
Wildlife Impact Review Coordinator  
Division of Environmental  
Planning and Habitat Protection  
Bureau of Wildlife Habitat Management

Cc: File



established 1866

## Pennsylvania Fish & Boat Commission

Division of Environmental Services  
Natural Diversity Section  
450 Robinson Lane  
Bellefonte, PA 16823-9620  
(814) 359-5237 Fax: (814) 359-5175

June 3, 2008

IN REPLY REFER TO  
SIR # 28464

SARAH LOPAS  
UNITED STATES NUCLEAR REGULATORY COMMISSION  
11555 ROCKVILLE PIKE  
MAIL STOP 0-11F1  
ROCKVILLE, MD 20852

**RE: Species Impact Review (SIR) - Rare, Candidate, Threatened and Endangered Species  
THREE MILE ISLAND NUCLEAR STATION  
LONDONDERRY Township/Borough, DAUPHIN County, Pennsylvania**

This responds to your inquiry about a Pennsylvania Natural Diversity Inventory (PNDI) Internet Database search "potential conflict" or a threatened and endangered species impact review. These projects are screened for potential conflicts with rare, candidate, threatened or endangered species under Pennsylvania Fish & Boat Commission jurisdiction (fish, reptiles, amphibians, aquatic invertebrates only) using the Pennsylvania Natural Diversity Inventory (PNDI) database and our own files. These species of special concern are listed under the Endangered Species Act of 1973, the Wild Resource Conservation Act, and the Pennsylvania Fish & Boat Code (Chapter 75), or the Wildlife Code. The absence of recorded information from our files does not necessarily imply actual conditions on site. Future field investigations could alter this determination. The information contained in our files is routinely updated. A Species Impact Review is valid for one year only.

X **NO ADVERSE IMPACTS EXPECTED FROM THE PROPOSED PROJECT**


Except for occasional transient species, rare, candidate, threatened or endangered species under our jurisdiction are not known to exist in the vicinity of the project area. Therefore, no biological assessment or further consultation regarding rare species is needed with the Commission. Should project plans change, or if additional information on listed or proposed species becomes available, this determination may be reconsidered.

X An element occurrence of a rare, candidate, threatened, or endangered species under our jurisdiction is known from the vicinity of the proposed project. However, given the nature of the proposed project, the immediate location, or the current status of the nearby element occurrence(s), no adverse impacts are expected to the species of special concern.

If you have any questions regarding this review, please contact the biologist indicated below:

<u>    </u> Jeff Schmid	814-359-5236	<u>    </u> Tina Walther	814-359-5186
<u>X</u> Nevin Welte	814-359-5234	<u>    </u> Bob Morgan	814-359-5129

I am enclosing a copy of our "SIR Request Form", which is to be used for all future species impact review requests. Please make copies of the attached form and use with all future project reviews. Thank you in advance for your cooperation and attention to this important matter of species conservation and habitat protection.

SIGNATURE:  DATE: June 3, 2008  
Christopher A. Urban  
Chief, Natural Diversity Section

**Our Mission:**

[www.fish.state.pa.us](http://www.fish.state.pa.us)

*To protect, conserve and enhance the Commonwealth's aquatic resources and provide fishing and boating opportunities.*

## **Appendix E**

### **Chronology of Environmental Review**



## E. Chronology of Environmental Review Correspondence

This appendix contains a chronological listing of correspondence between the U.S. Nuclear Regulatory Commission (NRC) and external parties as part of its environmental review for Three Mile Island Nuclear Station, Unit 1. All documents, with the exception of those containing proprietary information are available electronically from the NRC's Public Electronic Reading Room found on the Internet at the following Web address: <http://www.nrc.gov/reading-rm.html>. From this site, the public can gain access to the NRC's Agencywide Document Access and Management System (ADAMS), which provides text and image files of NRC's public documents in ADAMS. The ADAMS accession number for each document is included below.

### E.1 Environmental Review Correspondence

January 8, 2008	Letter from AmerGen forwarding the application for renewal of operating license for Three Mile Island, Unit 1, requesting an extension of operating license for an additional 20 years (ADAMS Accession No. ML080220219).
January 25, 2008	Letter to AmerGen, "Receipt and Availability of the License Renewal Application for the Three Mile Island Nuclear Station, Unit 1" (ADAMS Accession No. ML073310128).
January 28, 2008	NRC press release announcing the availability of the license renewal application for Three Mile Island, Unit 1, for public inspection (ADAMS Accession No. ML080280293).
January 31, 2008	<i>Federal Register</i> notice, "AmerGen Energy Company, LLC; Notice of Receipt and Availability of Application for Renewal of Three Mile Island Nuclear Station, Unit 1, Facility Operating License No. DPR-50 for an Additional 20-Year Period" (73 FR 5877).
February 14, 2008	Notice of public meeting to discuss the license renewal process for the Three Mile Island Nuclear Station, Unit 1, license renewal application Review (ADAMS Accession No. ML080380505).
February 26, 2008	NRC press release announcing the public meeting to discuss the review of the license renewal application for Three Mile Island Nuclear Power Plant (ADAMS Accession No. ML080570365).
March 10, 2008	Letter to AmerGen transmitting "Determination of Acceptability and Sufficiency for Docketing, Proposed Review Schedule, and Opportunity for a Hearing Regarding an Application from AmerGen Energy Company, LLC, for Renewal of the Operating License for Three Mile Island Nuclear Station, Unit 1" (ADAMS Accession No. ML080370352).

## Appendix E

- March 10, 2008 NRC press release announcing opportunity to request hearing on license renewal application for Three Mile Island Nuclear Plant (ADAMS Accession No. ML080700892).
- March 14, 2008 *Federal Register* notice, "Notice of Acceptance for Docketing of the Application and Notice of Opportunity for Hearing; Regarding Renewal of Facility Operating License No. DPR-50 for an Additional 20-Year Period; AmerGen Energy Company, LLC Three Mile Island Nuclear Station, Unit 1" (73 FR 13923).
- March 21, 2008 Letter to AmerGen, "Three Mile Island Nuclear Station, Unit 1 License Renewal Application Online Reference Portal" (ADAMS Accession No. ML080710465).
- March 24, 2008 Letter to AmerGen forwarding *Federal Register* notice, "Three Mile Island Nuclear Station, Unit 1; Notice of Intent to Prepare and Environmental Impact Statement and Conduct Scoping," in support of the review of the license renewal application (ADAMS Accession No. ML080780085).
- March 26, 2008 Notice of public meeting to discuss the environmental scoping process for the Three Mile Island Nuclear Station, Unit 1, license renewal application review (ADAMS Accession No. ML080800502).
- March 28, 2008 *Federal Register* notice, "Three Mile Island Nuclear Station, Unit 1; Notice of Intent to Prepare an Environmental Impact Statement and Conduct Scoping Process" (73 FR 16729).
- March 31, 2008 Letter from AmerGen, "Editorial Corrections to the Three Mile Nuclear Station Unit 1 License Renewal Application Environmental Report" (ADAMS Accession No. ML080930302).
- March 31, 2008 Letter from AmerGen, "Three Mile Island Nuclear Station Unit 1 License Renewal Application Online Reference Portal" (ADAMS Accession No. ML080930301).
- April 1, 2008 Letter to AmerGen, "Environmental Site Audit Regarding Three Mile Island Nuclear Station, Unit 1, License Renewal Application" (ADAMS Accession No. ML080840029).
- April 3, 2008 Letter from AmerGen, "Three Mile Island Nuclear Station Unit 1 License Renewal Application Selected Environmental Report References" (ADAMS Accession No. ML081420193).
- April 4, 2008 Letter to David Densmore, U.S. Fish and Wildlife Service, request for list of protected species for the Three Mile Island Nuclear Station,

Unit 1, license renewal review (ADAMS Accession No. ML080840027).

- April 9, 2008 Letter to The Honorable Raymond Halbritter, Nation Representative, Oneida Indian Nation, inviting participation in scoping process related to NRC's environmental review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML080980572).
- April 9, 2008 Letter to The Honorable Paul Spicer, Chief, Seneca-Cayuga Tribe of Oklahoma, inviting participation in scoping process related to NRC's environmental review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML080980572).
- April 9, 2008 Letter to The Honorable Barry Snyder, Sr., President, Seneca Nation of Indians, inviting participation in scoping process related to NRC's environmental review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML080980572).
- April 9, 2008 Letter to The Honorable Robert Chicks, Tribal Chairman, Stockbridge-Munsee Band of the Mohican Nation, Wisconsin, inviting participation in scoping process related to NRC's environmental review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML080980572).
- April 9, 2008 Letter to The Honorable Tony Gonyea, Faithkeeper, Onondaga Nation, inviting participation in scoping process related to NRC's environmental review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML080980572).
- April 9, 2008 Letter to The Honorable Gerald Dansforth, Chairwoman, Oneida Nation of Wisconsin, inviting participation in scoping process related to NRC's environmental review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML080980572).
- April 9, 2008 Letter to The Honorable Glenna Wallace, Chief, Eastern Shawnee Tribe of Oklahoma, inviting participation in scoping process related to NRC's environmental review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML080980572).
- April 9, 2008 Letter to The Honorable Kerry Holton, Tribal President, Delaware Nation, inviting participation in scoping process related to NRC's environmental review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML080980572).

## Appendix E

- April 9, 2008 Letter to The Honorable Clint Halftown, Heron Clan Representative, Cayuga Nation, inviting participation in scoping process related to NRC's environmental review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML080980572).
- April 9, 2008 Letter to The Honorable Scott Miller, Governor, Absentee-Shawnee Tribe of Oklahoma, inviting participation in scoping process related to NRC's environmental review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML080980572).
- April 9, 2008 Letter to The Honorable James Ransom, Chief, St. Regis Mohawk Tribe, inviting participation in scoping process related to NRC's environmental review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML080980572).
- April 9, 2008 Letter to The Honorable Roger Hill, Chief, Tonawanda Seneca Nation, inviting participation in scoping process related to NRC's environmental review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML080980572).
- April 9, 2008 Letter to The Honorable Leo Henry, Chief, Tuscarora Nation, inviting participation in scoping process related to NRC's environmental review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML080980572).
- April 9, 2008 Letter to The Honorable Ron Sparkmann, Chairman, Shawnee Tribe, inviting participation in scoping process related to NRC's environmental review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML080980572).
- April 15, 2008 Letter to Charlene Dwin Vaughn, Assistant Director, Advisory Council on Historic Preservation, regarding Three Mile Island Nuclear Station, Unit 1 license renewal review (ADAMS Accession No. ML080930296).
- April 15, 2008 Letter to Rich Janati, Chief, Division of Nuclear Safety, Bureau of Radiation Protection, Pennsylvania Department of Environmental Protection, regarding Three Mile Island Nuclear Station, Unit 1, license renewal (ADAMS Accession No. ML080860022).



April 15, 2008 Letter to Rachel Diamond, Regional Director, Pennsylvania Department of Environmental Protection Southcentral Regional Office, regarding Three Mile Island Nuclear Station, Unit 1, license renewal review (ADAMS Accession No. ML080930617).

April 15, 2008 Letter to Michael G. Brownell, Chief, Water Resources Management, Susquehanna River Basin Commission, regarding Three Mile Island Nuclear Station, Unit 1, license renewal review (ADAMS Accession No. ML080930632).

April 15, 2008 Letter to Chris Firestone, Native Plant Program Manager, Pennsylvania Department of Conservation and Natural Resources, request for list of protected species and important habitats for the Three Mile Island Nuclear Station, Unit 1, license renewal review (ADAMS Accession No. ML080930247).

April 15, 2008 Letter to Christopher Urban, Chief of Natural Diversity Section, Pennsylvania Fish & Boat Commission, request for list of State-protected species for the Three Mile Island Nuclear Station, Unit 1, license renewal review (ADAMS Accession No. ML080930486).

April 15, 2008 Letter to James Leigey, Wildlife Impact Review Coordinator, Pennsylvania Game Commission, request for list of State-protected species for the Three Mile Island Nuclear Station, Unit 1, license renewal review (ADAMS Accession No. ML080930178).

April 15, 2008 Letter to Jean Cutler, Deputy State Historic Preservation Officer, Pennsylvania Historic and Museum Commission, regarding Three Mile Island Nuclear Station, Unit 1, license renewal review (ADAMS Accession No. ML080930380).

April 15, 2008 NRC press release announcing the Three Mile Island, Unit 1, license renewal environment scoping meeting (ADAMS Accession No. ML081060426).

April 21, 2008 Letter from Sherry White, Tribal Historic Preservation Officer, Stockbridge-Munsee Tribal Historic Preservation Office, regarding Three Mile Island Nuclear Station, Unit 1, license renewal review (ADAMS Accession No. ML081280309).

April 23, 2008 Letter from David Densmore, Supervisor, U.S. Fish and Wildlife Service, Pennsylvania Field Office, regarding Three Mile Island Nuclear Station, Unit 1, license renewal application review (ADAMS Accession No. ML081280307).

## Appendix E

- April 23, 2008 Letter from Rebecca H. Bowen, Environmental Review Specialist, Pennsylvania Department of Conservation and Natural Resources, regarding Three Mile Island, Unit 1, license renewal species of special concern (ADAMS No. Accession ML081300048).
- May 2, 2008 Summary of public meetings related to the license renewal process for the Three Mile Island Nuclear Station, Unit 1, license renewal application (ADAMS Accession No. ML081000290).
- May 14, 2008 Letter from James R. Leigey, Wildlife Impact Review Coordinator, Pennsylvania Game Commission, regarding State-protected bird and mammal species review for Three Mile Island Nuclear Station license renewal application, Londonderry Township, Dauphin County, Pennsylvania (ADAMS Accession No. ML081500671).
- May 21, 2008 Letter to AmerGen, "Request for Additional Information Regarding Severe Accident Mitigation Alternatives for Three Mile Island Nuclear Station, Unit 1, License Renewal" (ADAMS Accession No. ML081330714).
- May 22, 2008 Summary of public environmental scoping meetings related to the review of the Three Mile Island Nuclear Station, Unit 1, license renewal application (ADAMS Accession No. ML081360648).
- June 3, 2008 Letter from Christopher A. Urban, Chief, Natural Diversity Section, Pennsylvania Fish & Boat Commission, regarding species impact review for Three Mile Island Nuclear Station, Londonderry Township/Borough, Dauphin County, Pennsylvania (ADAMS Accession No. ML081610104).
- June 3, 2008 Commission order denying Mr. Marvin Lewis's Petition to Intervene (ADAMS Accession No. ML081550359).
- June 10, 2008 Letter from AmerGen, "Three Mile Island Nuclear Station Unit 1 License Renewal Application Post-Audit Environmental Information" (ADAMS Accession No. ML082110260).
- June 12, 2008 Summary of conference call with AmerGen to discuss the severe accident mitigation alternatives and requests for additional information for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML081560666).
- July 17, 2008 Letter from AmerGen, "Response to NRC Request for Additional Information related to the Three Mile Island Nuclear Station Unit 1 License Renewal Application" (ADAMS Accession No. ML082040144).

- August 4, 2008 Summary of site audit related to the review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML081420398).
- August 5, 2008 Summary of telephone conference call held on July 17, 2008, between the NRC and AmerGen, concerning followup questions pertaining to the Three Mile Island Nuclear Station, Unit 1, license renewal environmental review and site audit (ADAMS Accession No. ML082120727).
- August 5, 2008 Letter from AmerGen, "Three Mile Island Nuclear Station Unit 1 License Renewal Application Post-Audit Environmental Information" (ADAMS Accession No. ML082200589).
- August 8, 2008 Letter to AmerGen regarding environmental scoping summary report associated with the staff's review of the application by AmerGen for renewal of the operating license for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML081920230).
- September 8, 2008 Summary of conference call with AmerGen Energy Company, LLC, to discuss responses to severe accident mitigation alternatives request for additional information for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML082340226).



**Appendix F**  
**U.S. Nuclear Regulatory Commission Staff Evaluation of**  
**Severe Accident Mitigation Alternatives (SAMAs) for**  
**Three Mile Island Nuclear Station, Unit 1**  
**In Support of License Renewal Application Review**



1       **F. U.S. Nuclear Regulatory Commission Staff Evaluation of Severe**  
2       **Accident Mitigation Alternatives (SAMAs) for Three Mile Island**  
3       **Nuclear Station, Unit 1 in Support of License Renewal Application**  
4       **Review**

5       **F.1 Introduction**

6       AmerGen Energy Company, LLC (AmerGen) submitted an assessment of severe accident  
7       mitigation alternatives (SAMAs) for the Three Mile Island Nuclear Station, Unit 1 (TMI-1) as part  
8       of the environmental report (ER) (AmerGen 2008a). This assessment was based on the most  
9       recent TMI-1 probabilistic risk assessment (PRA) available at that time, a plant-specific offsite  
10      consequence analysis performed using the MELCOR Accident Consequence Code System 2  
11      (MACCS2) computer code (NRC 1998a), and insights from the TMI-1 individual plant  
12      examination (IPE) (GPU 1993) and individual plant examination of external events (IPEEE)  
13      (GPU 1994). In identifying and evaluating potential SAMAs, AmerGen considered SAMA  
14      candidates that addressed the major contributors to core damage frequency (CDF) and  
15      population dose at TMI-1, as well as SAMA candidates for other operating plants which have  
16      submitted license renewal applications. AmerGen identified 33 potential SAMA candidates.  
17      AmerGen assessed the costs and benefits associated with each of the potential SAMAs, and  
18      concluded in the ER that several of the candidate SAMAs evaluated are potentially cost-  
19      beneficial.

20      Based on a review of the SAMA assessment, the U.S. Nuclear Regulatory Commission (NRC)  
21      issued a request for additional information (RAI) to AmerGen by letter dated May 21, 2008  
22      (NRC 2008a). Key questions concerned: major plant and modeling changes incorporated within  
23      each evolution of the PRA model; justification for the multiplier used for external events;  
24      assumptions used to quantify the benefits for certain SAMAs; identification of an optimal subset  
25      of potentially cost-beneficial SAMAs; and further information on several specific candidate  
26      SAMAs and low cost alternatives. AmerGen submitted additional information by letters dated  
27      July 17, 2008 (AmerGen 2008b) and September 8, 2008 (NRC 2008b). In the responses,  
28      AmerGen provided: additional information regarding the PRA model development; additional  
29      justification for the treatment of external events; additional explanation and justification for the  
30      assumptions used to quantify SAMA benefits; a qualitative assessment identifying the  
31      potentially cost-beneficial SAMAs having the greatest risk reduction relative to the cost of  
32      implementation; and additional information regarding several specific SAMAs. AmerGen's  
33      responses addressed the NRC staff's concerns, and resulted in the identification of two  
34      additional potentially cost-beneficial SAMAs.

35      An assessment of SAMAs for TMI-1 is presented below.

36  
37      **F.2 Estimate of Risk for TMI-1**

38      AmerGen's estimates of offsite risk at TMI-1 are summarized in Section F.2.1. The summary is  
39      followed by the NRC staff's review of AmerGen's risk estimates in Section F.2.2.

1           **F.2.1     AmerGen’s Risk Estimates**

2     Two distinct analyses are combined to form the basis for the risk estimates used in the SAMA  
3     analysis: (1) the TMI-1 Level 1 and 2 PRA models, which are updated versions of the IPE (GPU  
4     1993) and IPEEE (GPU 1994), and (2) a supplemental analysis of offsite consequences and  
5     economic impacts (essentially a Level 3 PRA) developed specifically for the SAMA analysis.  
6     The SAMA analysis is based on the most recent TMI-1 Level 1 and 2 PRA model available at  
7     the time of the ER, referred to as the 2004 Revision 2 Level 1 model (Exelon 2007a), and the  
8     Level 2 model of 2007 (Exelon 2007b). The scope of the Level 1 model includes both internal  
9     and external initiating events. The external events evaluated are external floods, seismic events,  
10    and internal fires. However, the external events models are not integrated with the internal  
11    events model, thereby necessitating a separate assessment of the risk (and risk reduction) for  
12    internal and external events. AmerGen placed particular emphasis on external flooding events  
13    since they dominate the calculated risk at TMI-1.

14    The baseline CDF for the purpose of the SAMA evaluation is approximately  $2.37 \times 10^{-5}$  per year  
15    for internal events (including internal flooding events), and  $8.11 \times 10^{-5}$  per year for external  
16    flooding events. AmerGen accounted for the potential risk reduction benefits associated with  
17    internal event-and external flooding-related SAMAs by separately quantifying the benefits using  
18    the internal event or external flooding model, respectively. For internal event-related SAMAs,  
19    AmerGen accounted for the potential risk reduction benefits associated with non-flooding  
20    external events (i.e., seismic and fire events) by doubling the estimated benefits for internal  
21    events. For seismic- and fire-related SAMAs, AmerGen separately estimated the risk reduction  
22    benefits using the seismic and fire risk models. This is discussed further in Sections F.2.2 and  
23    F.6.2.

24    The breakdown of CDF by initiating event is provided in Tables F-1a and F-1b for internal  
25    events and external flooding events, respectively. As shown in these tables, internal event CDF  
26    is dominated by loss of offsite power events, transients, small loss of coolant accidents (LOCA),  
27    and loss of nuclear service water events. External flooding CDF is dominated by events with  
28    flood levels exceeding 305 feet mean sea level (msl).

29    The Level 2 PRA model that forms the basis for the SAMA evaluation represents an updated  
30    version of the original IPE Level 2 model. The Level 1 core damage sequences are binned into  
31    Plant Damage State bins which provide the interface between the Level 1 and Level 2 models.  
32    The Level 2 model utilizes a single containment event tree (CET) containing both  
33    phenomenological and systemic events. CET nodes are evaluated using supporting fault trees  
34    and logic rules.



1

<b>Table F-1.a TMI-1 Internal Events Core Damage Frequency</b>		
<b>Initiating Event</b>	<b>CDF (Per Year)</b>	<b>% Contribution to CDF</b>
Loss of Offsite Power	$7.73 \times 10^{-6}$	32.6
Transients	$5.80 \times 10^{-6}$	24.5
Small and Very Small LOCA	$4.66 \times 10^{-6}$	19.7
Loss of Nuclear River Water	$3.67 \times 10^{-6}$	15.5
Steam Generator Tube Rupture	$9.93 \times 10^{-7}$	4.2
Internal Floods	$4.50 \times 10^{-7}$	1.9
Large and Medium LOCA	$2.06 \times 10^{-7}$	< 1
ISLOCA	$1.80 \times 10^{-7}$	<1
<b>Total CDF (internal events)</b>	<b><math>2.37 \times 10^{-5}</math></b>	<b>100</b>

2

<b>Table F-1.b TMI-1 External Flooding Events Core Damage Frequency</b>		
<b>External Flooding Event</b>	<b>CDF (Per Year)</b>	<b>% Contribution to CDF</b>
>310 feet	$6.37 \times 10^{-5}$	78.5
305 to 310 feet	$1.71 \times 10^{-5}$	21.1
<305 feet	$2.50 \times 10^{-7}$	< 1
<b>Total</b>	<b><math>8.11 \times 10^{-5}</math></b>	<b>100</b>

3

4 The result of the internal events Level 2 model is a set of 39 release categories with their  
5 respective frequency and release characteristics. The release categories and their frequencies  
6 are presented in Table E.2-16 of the ER. The categories were defined based on the timing,  
7 duration, and magnitude of the release and whether the containment remains intact or is  
8 bypassed. The frequency of each release category was obtained by summing the frequency of  
9 the individual CET end states assigned to each release category. The 39 release categories  
10 were further collapsed into nine major source term groups having similar containment response.  
11 The nine major source term groups and their release characteristics are presented in Tables  
12 E.2-17 and E.2-18 of the ER. The release characteristics for these nine source term groups  
13 were developed from Modular Accident Analysis Program (MAAP) analyses performed  
14 specifically to support the SAMA analysis (AmerGen 2008b).

Appendix F

1 For external flooding events, a simplified version of the internal events CET was developed and  
 2 used to map external flood sequences to representative release categories from the internal  
 3 events analysis. The result of the analysis is a set of eight release categories with their  
 4 respective frequencies. These release categories were subsequently collapsed into seven non-  
 5 zero source term groups. The mapping of external flood sequences to source term group is  
 6 presented in Tables E.2-21 and E.2-23 of the ER.

7 The offsite consequences and economic impact analyses use the MACCS2 code to determine  
 8 the offsite risk impacts on the surrounding environment and public. Inputs for these analyses  
 9 include plant-specific and site-specific input values for core radionuclide inventory, source term  
 10 and release characteristics, site meteorological data, projected population distribution (within an  
 11 50-mile (mi) (80-kilometer [km]) radius for the year 2034, emergency response evacuation  
 12 modeling, and economic data. The magnitude of the onsite impacts (in terms of clean-up and  
 13 decontamination costs and occupational dose) is based on information provided in NUREG/BR-  
 14 0184 (NRC 1997a).

15 AmerGen estimated the dose to the population within 50 mi (80 km) of the TMI-1 site to be  
 16 approximately 0.323 person-sievert (Sv) (32.3 person-rem) per year (AmerGen 2008a) for  
 17 internal events and 1.76 person-Sv (176 person-rem) per year for external flooding events  
 18 (AmerGen 2008b). The breakdown of the total population dose by containment release mode is  
 19 summarized in Table F-2. Steam generator tube rupture (SGTR) accidents, and basemat melt-  
 20 through are the dominant contributors to population dose risk from internal events. For external  
 21 flooding events, late containment failures and early containment failure (less than 12 hours  
 22 following accident initiation) are the dominant contributors to population dose risk.

**Table F-2.** Breakdown of Population Dose by Containment Release Mode

Containment Release Mode	Internal Events		External Flooding Events	
	Population Dose (Person-Rem Per Year)	% Contribution	Population Dose (Person-Rem Per Year)	% Contribution
Steam generator tube rupture	11.7	36	0.1	<0.1
Interfacing system LOCA	1.0	3	negligible	0
Containment isolation failure	1.1	3	29	16
Early containment failure	5.6	17	61	35
Late containment failure (large)	0.3	1	15	9
Late containment failure (small)	1.7	5	66	37
Basemat melt-through	6.9	22	4	2
No containment failure	4.0	13	1	1
<b>Total</b>	<b>32.3</b>	<b>100</b>	<b>176</b>	<b>100</b>

(a) One person-rem = 0.01 person-Sv

23  
24

## 1           **F.2.2     Review of AmerGen's Risk Estimates**

2 AmerGen's determination of offsite risk at TMI-1 is based on the following major elements of  
3 analysis:

- 4       • The Level 1 and 2 risk models that form the bases for the IPE submittal (GPU 1993) and  
5       the IPEEE submittal (GPU 1994),
- 6       • The major modifications to the IPE model that have been incorporated in the 2004  
7       Revision 2 Level 1 model (Exelon 2007a), and the Level 2 model of 2007 (Exelon  
8       2007b)
- 9       • Assignment of severe accident source terms to external flooding sequences, and
- 10      • The MACCS2 analyses performed to translate fission product source terms and release  
11      frequencies from the Level 2 PRA model into offsite consequence measures.

12  
13 Each of these analyses was reviewed to determine the acceptability of AmerGen's risk  
14 estimates for the SAMA analysis, as summarized below.

15 The NRC staff's review of the TMI-1 IPE is described in an NRC report dated December 19,  
16 1996 (NRC 1996). Based on a review of the IPE submittal and responses to RAIs, the NRC staff  
17 concluded that the IPE submittal met the intent of GL 88-20 (NRC 1988); that is, the licensee's  
18 IPE process is capable of identifying the most likely severe accidents and severe accident  
19 vulnerabilities. Although no vulnerabilities were identified in the IPE, several improvements to  
20 the plant or procedures were identified. These improvements have been either implemented at  
21 the site or addressed in the SAMA evaluation process (AmerGen 2008a). These improvements  
22 are discussed in Section F.3.2.

23 There have been six revisions to the Level 1 model since the 1992 IPE submittal. AmerGen  
24 indicated that the 2004 Revision 2 Level 1 model reflects the TMI-1 configuration and design as  
25 of the model's completion date of June 2007, but that no plant changes have occurred since  
26 completion of the model that would impact the PRA. A comparison of internal events CDF  
27 between the 1992 IPE and the current PRA model indicates a decrease of approximately 43  
28 percent (from  $4.19 \times 10^{-5}$  per year to  $2.37 \times 10^{-5}$  per year). A comparison of the contributors to  
29 the total CDF indicates that some have increased (e.g., loss of offsite power) while others have  
30 decreased (e.g., large and medium LOCA). A description of those changes that resulted in the  
31 greatest impact on the internal events CDF was provided in Section E.2.2 of the ER (AmerGen  
32 2008a), and is summarized in Table F-3.

33 The CDF value from the 1992 IPE submittal ( $4.19 \times 10^{-5}$  per year) is near the average of the  
34 CDF values reported in the IPEs for B&W plants. Figure 11.6 of NUREG-1560 shows that the  
35 IPE-based total internal events CDF for these plants ranges from approximately  $1 \times 10^{-5}$  to  
36  $7 \times 10^{-5}$  per year, with an average CDF for the group of  $3 \times 10^{-5}$  per year (NRC 1997b). It is  
37 recognized that other plants have updated the values for CDF subsequent to the IPE submittals  
38 to reflect modeling and hardware changes. The current internal event CDF result for TMI-1 ( $2.37$   
39  $\times 10^{-5}$  per year, including internal flooding) is comparable to that for other plants of similar  
40 vintage and characteristics.

<b>Table F-3. TMI-1 PRA Historical Summary</b>		
<b>PRA Version</b>	<b>Summary of Changes from Prior Model</b>	<b>CDF (per year)</b>
1992	IPE Submittal (excluding internal flooding)	$4.19 \times 10^{-5}$
2000 Update	August 2000 update (including internal flooding CDF of $3.0 \times 10^{-6}$ ) - Changed model from reliability block diagrams to fault tree structure - Updated plant unavailability and failure rates	$4.10 \times 10^{-5}$
L2RV2	November 2001 update (including internal flooding CDF of $2.56 \times 10^{-6}$ ) - Linked Level 2 model directly with Level 1 sequences	$3.95 \times 10^{-5}$
ABSA	July 2003 update (including internal flooding CDF of $3.5 \times 10^{-7}$ ) - Resolved Level A and B Facts and Observations (F&Os) from peer certification - Updated initiating event, component failure, unavailability, and common cause databases - Revised human reliability analysis (HRA) using the EPRI HRA Calculator - Updated success criteria and operator action timing based on thermal-hydraulic (MAAP) analyses - Refined internal flooding screening analysis	$3.38 \times 10^{-5}$
2004 Rev. 0	December 2004 update (including internal flooding CDF of $2.6 \times 10^{-7}$ ) - Converted model from RISKMAN linked event tree model to CAFTA single event fault tree model - Updated Main Feedwater and Main Steam system models related to steam generator isolation for SGTR and secondary line breaks - Updated 4KV/480V AC power system model to include individual fault trees for 480V buses and motor control centers - Updated common cause failure data to NUREG/CR-5497 (NRC 1998b) - Added logic to evaluate system availability following offsite power recovery - Incorporated joint human error probability (JHEP) basic events	$3.07 \times 10^{-5}$
2004 Rev. 1	June 2005 update (including internal flooding CDF of $3.7 \times 10^{-7}$ ) - Corrected errors discovered subsequent to the conversion to CAFTA	$3.36 \times 10^{-5}$
2004 Rev. 2	June 2007 update (including internal flooding CDF of $4.5 \times 10^{-7}$ ) - Added new basic events for common cause failure of several components - Added new maintenance unavailability events to include maintenance on various components - Added human error probabilities (HEPs) for controlling emergency feedwater, cooldown of the RCS, and steam generator isolation - Revised loss of offsite power (LOOP) initiating event frequency - Modified Very Small LOCAs event tree	$2.37 \times 10^{-5}$

1 The NRC staff considered the peer reviews performed for the TMI-1 PRA, and the potential  
2 impact of the review findings on the SAMA evaluation. In the ER (AmerGen 2008a), AmerGen  
3 described the formal industry peer review of the 2000 Update Model conducted in August 2000.  
4 The final report on the peer review stated that "it was the general assessment of the peer review  
5 team that the TMI-1 PRA can be effectively used to support applications involving risk significant  
6 determinations supported by deterministic analysis, once the technical issues and  
7 recommendations for enhancements that are noted in the element summaries and Fact and  
8 Observation Sheets are addressed to an appropriate level of quality." AmerGen stated in the ER  
9 that all "A" and "B" facts and observations (F&O) with the exception of one "B" level observation  
10 are closed, and that the unresolved "B" observation related to the need for independent  
11 technical and system engineer reviews of system notebooks and would have no significant  
12 impact on the SAMA evaluation. In response to an NRC staff RAI, AmerGen stated that no other  
13 peer reviews of the TMI-1 PRA have been conducted since the August 2000 peer review  
14 (AmerGen 2008b).

15 Given that the TMI-1 internal events PRA model has been peer reviewed and the peer review  
16 findings were either addressed or judged to have no adverse impact on the SAMA evaluation,  
17 and that AmerGen has satisfactorily addressed NRC staff questions regarding the PRA, the  
18 NRC staff concludes that the internal events Level 1 PRA model is of sufficient quality to  
19 support the SAMA evaluation.

20 As indicated above, the current TMI-1 PRA does not include an integral evaluation of external  
21 events. In the absence of such an analysis, AmerGen used the TMI-1 IPEEE, in conjunction  
22 with minor adjustments in seismic and fire risk results, to identify the highest risk accident  
23 sequences and the potential means of reducing the risk posed by those sequences, as  
24 discussed below.

25 The TMI-1 IPEEE was submitted in December 1994 (GPU 1994), in response to Supplement 4  
26 of Generic Letter 88-20. This submittal included a seismic PRA, a fire-induced vulnerability  
27 evaluation, and risk analyses for external flooding, high winds, and other external events. While  
28 no fundamental weaknesses or vulnerabilities to severe accident risk in regard to external  
29 events were identified, several opportunities for risk reduction were identified and implemented  
30 when demonstrated to be cost effective as discussed below. In a letter dated July 9, 1999, the  
31 NRC staff concluded that the submittal met the intent of Supplement 4 to Generic Letter 88-20,  
32 and that the licensee's IPEEE process is capable of identifying the most likely severe accidents  
33 and severe accident vulnerabilities (NRC 1999).

34 The IPEEE analysis of external flooding events followed the screening and evaluation  
35 approaches described in Supplement 4 of GL 88-20 (NRC 1991). The TMI-1 IPEEE showed  
36 that external floods are the most important contributors to external event CDF. The IPEEE  
37 external flooding analyses employed a simplified external flooding PRA and containment  
38 performance analysis. The evaluation used flood flow frequency data provided by the Corps of  
39 Engineers (COE), an assessment of the effectiveness of TMI-1 design measures to protect  
40 safety-related structures and components from the probable maximum flood (PMF), flood  
41 scenario evaluation, and manual risk quantification. The CDF for each flood scenario was  
42 obtained by multiplying the frequency of a flood reaching a given flood elevation by the  
43 conditional core damage probability associated with that flooding scenario. The potential impact  
44 on containment performance and isolation was evaluated following the core damage evaluation.

## Appendix F

1 The external flooding CDF from the IPEEE was estimated to be  $8.11 \times 10^{-5}$  year (GPU 1994).  
2 The dominant external flooding initiating events and their contributions to the external flooding  
3 CDF are provided in Table E.2-21 of the ER (AmerGen 2008a), and summarized in Table F-1.b.

4 While no external flooding vulnerabilities were identified in the IPEEE, one plant improvement  
5 was identified. This improvement involved installing a flood-resistant means of providing 480V  
6 AC power and pumps to provide reactor coolant pump (RCP) seal cooling and makeup to the  
7 steam generators in station blackout conditions. AmerGen indicated that this external flooding  
8 improvement was subsequently implemented (AmerGen 2008a). Based on the information  
9 provided in the ER and in responses to RAIs (AmerGen 2008b), the NRC staff finds the  
10 treatment of external flooding events to be reasonable for the purposes of the SAMA analysis.

11 The TMI-1 IPEEE seismic analysis employed a seismic PRA with a simplified seismic  
12 containment performance analysis consistent with NUREG-1407. The seismic approach  
13 employed plant walkdowns by seismic review teams to identify components and structures that  
14 may impact risk, development of seismic fragility values for seismic components and structures,  
15 and CDF quantification using a modified version of the IPE risk model and integration of the  
16 plant logic model with the seismic hazard curve. The seismic CDF was quantified using two  
17 different sets of seismic hazard curves -- those developed by the Electric Power Research  
18 Institute (EPRI) (EPRI 1989) and those provided by Lawrence Livermore National Laboratory  
19 (LLNL) (NRC 1994). The applicant determined the seismic CDF to be  $3.21 \times 10^{-5}$  per year using  
20 the EPRI hazard curve and  $8.43 \times 10^{-5}$  per year using the LLNL hazard curve. Table F-4  
21 summarizes the seismic CDF by initiating event category for both the EPRI and LLNL seismic  
22 hazard curves. The IPEEE did not identify any seismic vulnerabilities nor did it identify any  
23 seismic outliers beyond those already identified and resolved within the scope of the Unresolved  
24 Safety Issue (USI) A-46 program. However, in the process of performing the IPEEE analysis,  
25 several plant improvements were identified. These improvements involved modifications to:  
26 reinforce 1P, 1R, 1S, and 1T load center gusset welds, add main control room ceiling supports,  
27 add seismic restraint for penetration pressurization tank PP-T-1A, modify the supports for the  
28 diesel-driven fire pump fuel oil tanks and battery racks, modify the anchorage for the decay heat  
29 closed cooling water heat exchangers, and modify the anchorage for the emergency diesel  
30 generator (EDG) air receivers. The structural improvements to the main control room ceiling, the  
31 penetration pressurization tank, and the EDG air receiver anchorage were subsequently  
32 implemented. The structural improvements to the remaining three components are addressed  
33 by candidate SAMAs (SAMAs 27, 28, and 30). This is discussed further in Section F.3.2. The  
34 NRC review and closure of USI A-46 for TMI-1 is documented in a letter dated August 12, 1998  
35 (NRC 1998c).

1

<b>Table F-4. TMI-1 Seismic Events Core Damage Frequency</b>			
Initiating Event	Earthquake Range	CDF (per year)	
		EPRI	LLNL
SEIS1	0.052g to 0.2g	$5.78 \times 10^{-6}$	$1.26 \times 10^{-5}$
SEIS2	0.2g to 0.3g	$1.04 \times 10^{-5}$	$2.61 \times 10^{-5}$
SEIS3	0.3g to 0.5g	$1.22 \times 10^{-5}$	$3.25 \times 10^{-5}$
SEIS4	0.5g to 1.01g	$3.71 \times 10^{-6}$	$1.31 \times 10^{-5}$
Total Seismic CDF		$3.21 \times 10^{-5}$	$8.43 \times 10^{-5}$

2

3 To provide additional insight as to the appropriate seismic CDF to use for the SAMA evaluation,  
 4 the NRC staff developed an independent estimate of seismic CDF for TMI-1 using the  
 5 approximation method described in a paper by Robert P. Kennedy, entitled "Overview of  
 6 Methods for Seismic PRA and Margin Analysis Including Recent Innovations" and using  
 7 updated 2008 seismic hazard curve data from the U.S. Geologic Survey (USGS). This  
 8 approach uses a median capacity ( $C_{50}$ ) of 0.29g, based on the TMI-1 IPEEE high confidence of  
 9 low probability of failure (HCLPF) value for critical equipment. The NRC staff's independent  
 10 calculation estimates the seismic CDF for TMI-1 to be less than  $3.3 \times 10^{-5}$  per year. This is less  
 11 than half of the IPEEE-reported screening value based on the LLNL seismic hazard curve  
 12 ( $8.43 \times 10^{-5}$  per year) and is essentially the same as the IPEEE-reported value based on the  
 13 EPRI seismic hazard curve ( $3.21 \times 10^{-5}$  per year). Based on the NRC staff's independent  
 14 estimate of the seismic CDF, and the fact that structural improvements implemented since the  
 15 IPEEE have not been accounted for in the estimate of seismic CDF, the NRC staff concludes  
 16 that the seismic CDF is likely less than  $3.2 \times 10^{-5}$  per year.

17 The IPEEE fire analyses employed a progressive screening analysis, with quantification based  
 18 on the IPE PRA model. EPRI's fire-induced vulnerability evaluation (FIVE) methodology was  
 19 used with deviations. The evaluation was performed in nine steps: (1) identify critical areas of  
 20 vulnerability, (2) identify components important to safety, (3) locate components important to  
 21 safety, (4) review fire areas for growth and propagation, (5) evaluate component fragilities and  
 22 failure modes, (6) review fire detection and suppression systems, (7) identify impacts on top  
 23 events, (8) calculate screening CDF, and (9) perform detailed analysis of remaining fire areas  
 24 using FIVE fire and damage modeling techniques. The total fire CDF from the IPEEE was  
 25 estimated to be  $2.4 \times 10^{-5}$  year (GPU 1994). The dominant fire scenarios and their contributions  
 26 to the fire CDF are listed in Table F-5. The IPEEE did not identify any fire vulnerabilities or  
 27 improvements related to fire risk.

28 In the ER, AmerGen states that the use of the fire analysis results as a reflection of CDF may be  
 29 inappropriate and that while the fire PRA is generally self-consistent within its calculational  
 30 framework, the fire analysis does not compare well with the internal events PRA because of a  
 31 number of conservative assumptions that have been included in the fire analysis process. The  
 32 ER provides a list of fire analysis topics (involving technical inputs, data and modeling) that  
 33 prevent the effective comparison of the CDF between the internal events PRA and the fire  
 34 analysis. In response to an RAI requesting the applicability of the general topics to the TMI-1

Appendix F

1 fire analysis (NRC 2008a), AmerGen provided several TMI-1-specific examples of  
 2 conservatisms in the fire analysis, including: potential reduction in fire ignition frequencies,  
 3 conservative fire protection system assumptions (e.g., automatic fire suppression systems are  
 4 not credited), conservative target fire damage assumptions (e.g., a fire in a given area was  
 5 assumed to destroy all equipment in the area), and conservative failure probabilities for human  
 6 recovery actions (e.g., manual fire suppression or detection is not credited) (AmerGen 2008b).  
 7 Based on the arguments regarding the conservatisms in the fire analysis presented in the ER  
 8 and RAI responses, AmerGen assumed a total fire CDF of  $2.16 \times 10^{-5}$  per year in the SAMA  
 9 analysis, which is the sum of the fire CDF for the five fire areas having a fire CDF greater than  
 10  $1 \times 10^{-6}$  per year. While this assumption appears to be non-conservative, AmerGen noted in  
 11 Section E.6.26 of the ER that the fire CDF for fire area CB-FB-2e reported in the IPEEE ( $5.81 \times$   
 12  $10^{-6}$  per year) contained an error that overestimated the fire CDF and that the correct value is  
 13  $3.09 \times 10^{-6}$  per year. As shown in Table F-5, using the corrected fire CDF for fire area CB-FB-  
 14 2e results in a revised total fire CDF of  $2.13 \times 10^{-5}$  per year, and offsets AmerGen not including  
 15 the CDF from fire areas having a fire CDF less than  $1 \times 10^{-6}$  per year.

16 Based on the information provided by the applicant, the NRC staff finds the treatment of fire  
 17 events to be reasonable for the purposes of the SAMA analysis.

**Table F-5. TMI-1 Fire Areas and Their Contribution to Fire CDF**

Fire Area	Fire Area Description	CDF (per year)	
		IPEEE	Corrected IPEEE
CB-FA-2d	East Inverter Room	$4.94 \times 10^{-6}$	$4.94 \times 10^{-6}$
CB-FA-2e	West Inverter Room	$5.81 \times 10^{-6}$	$3.09 \times 10^{-6(c)}$
CB-FA-3a	1D Switchgear Room	$3.94 \times 10^{-6}$	$3.94 \times 10^{-6}$
CB-FA-3b	1E Switchgear Room	$4.96 \times 10^{-6}$	$4.96 \times 10^{-6}$
CB-FA-4b	Control Room -- Console CR	$1.96 \times 10^{-6}$	$1.96 \times 10^{-6}$
CB-FA-4b	Control Room -- Panel CC	$8.40 \times 10^{-7(a)}$	$8.40 \times 10^{-7(a)}$
CB-FA-2	East Battery Room	$7.35 \times 10^{-7(a)}$	$7.35 \times 10^{-7(a)}$
	Other Scenarios	$8.15 \times 10^{-7(b)}$	$8.15 \times 10^{-7(b)}$
Total Fire CDF		$2.4 \times 10^{-5}$	$2.13 \times 10^{-5}$

- 18 (a) Values provided in response to RAIs (AmerGen 2008b).  
 19 (b) Value derived as the difference between the total fire CDF reported in the IPEEE and the fire CDFs  
 20 reported for the seven fire areas.  
 21 (c) Corrected value from Section E.6.26 of the ER (AmerGen 2008a).  
 22

23 The IPEEE analysis of high winds and other non-flooding external events followed the screening  
 24 and evaluation approaches described in Supplement 4 of GL 88-20 (NRC 1991) and did not  
 25 identify any significant sequences or vulnerabilities (GPU 1994). (AmerGen modeled external  
 26 flooding events separately, as discussed above.) Based on this result, AmerGen concluded that  
 27 these other external hazards, which were estimated to have a combined CDF of  $1.33 \times 10^{-6}$  per  
 28 year, would not impact the conclusions of the SAMA analysis. Accordingly, they did not  
 29 consider specific SAMAs for these events. This is discussed further in Section F.3.2. AmerGen



1 noted that the risks from deliberate aircraft impacts were explicitly excluded since this was being  
2 considered in other forums along with other sources of sabotage.

3 Using the CDF values reported in the ER, the non-flooding external events CDF would be  
4 approximately 4.5 times the internal events CDF (based on a seismic CDF of  $8.43 \times 10^{-5}$  per  
5 year, a fire CDF of  $2.16 \times 10^{-5}$  per year, a combined CDF from high winds and other non-  
6 flooding external events of  $1.33 \times 10^{-6}$  per year, and an internal events CDF of  $2.37 \times 10^{-5}$  per  
7 year). Accordingly, the total CDF from internal and non-flooding external events would be  
8 approximately 5.5 times the internal events CDF. However, in assessing the benefits for  
9 internal event-related SAMAs, AmerGen accounted for the potential risk reduction benefits  
10 associated with non-flooding external events (i.e., seismic and fire events) by doubling the  
11 estimated benefits for internal events. (This doubling was not applied to the seismic- and fire-  
12 related SAMAs, since those SAMAs are specific to external events.)

13 The NRC staff requested additional justification for increasing the internal events benefits by  
14 only a factor of two in view of the significant contribution to CDF from non-flooding external  
15 events (NRC 2008a). In the RAI response, AmerGen clarified that the seismic CDF reported in  
16 the ER ( $8.43 \times 10^{-5}$  per year) is a screening value based on LLNL seismic hazard curves and  
17 was used only in evaluating the benefit of seismic-related SAMAs (discussed later). AmerGen  
18 indicated that, in order to not skew the external events CDF when comparing it to the internal  
19 events CDF, the seismic CDF based on the EPRI seismic hazard curves ( $3.21 \times 10^{-5}$  per year)  
20 should be used in the multiplier development (AmerGen 2008b). In response to the same RAI,  
21 AmerGen provided several TMI-1-specific examples of conservatism in the seismic analysis,  
22 including: use of generic, bounding component seismic fragility curves, conservative seismic  
23 response assumptions (e.g., recovery of seismically-induced failure of the offsite power system  
24 is not credited), conservative seismic damage assumptions (e.g., failure of the main control  
25 room ceiling is always assumed to damage train B of Class 1E AC power), and conservative  
26 component failure probabilities (e.g., if a component fails in a seismic event then all similar  
27 components are assumed to fail) (AmerGen 2008b). AmerGen also noted that plant  
28 modifications to address seismic risk have been implemented since the IPEEE (as described  
29 above) and are not reflected in the IPEEE results. AmerGen further noted that the IPEEE fire  
30 CDF was based on conditional core damage probability values from the IPE internal events  
31 model, and that a re-quantification of the fire CDF based on the current internal events PRA  
32 would result in about a 43 percent reduction in fire CDF (from  $2.16 \times 10^{-5}$  per year to  $1.22 \times 10^{-5}$   
33 per year). Using the adjusted seismic and fire CDF values, the total CDF for non-flooding  
34 external events ( $4.56 \times 10^{-5}$  per year based on a seismic CDF of  $3.21 \times 10^{-5}$  per year, a fire CDF  
35 of  $1.22 \times 10^{-5}$  per year, and high winds/other non-flooding external event CDF of  $1.33 \times 10^{-6}$  per  
36 year) is approximately twice the internal events CDF. The NRC staff concludes that AmerGen's  
37 use of a multiplier of two in evaluating internal event-related SAMAs is reasonable for the  
38 purposes of the SAMA evaluation. This is discussed further in Section F.6.2.

39 The NRC staff reviewed the general process used by AmerGen to translate the results of the  
40 Level 1 PRA into containment releases, as well as the results of the Level 2 analysis, as  
41 described in the ER and in response to NRC staff requests for additional information (AmerGen  
42 2009a and 2008b).

43 The Level 2 PRA model that forms the basis for the SAMA evaluation is referred to as the  
44 CAFTA Level 2 model of 2007 (Exelon 2007b). The model represents an updated version of

## Appendix F

1 the original IPE Level 2 model previously reviewed by the NRC staff. The Level 2 model utilizes  
2 a single containment event tree (CET), containing both phenomenological and systemic events,  
3 that is directly linked with the CAFTA 2004 Revision 2 Level 1 model. CET nodes are evaluated  
4 using supporting fault trees and logic rules. The model is fully described in TMI-PRA-001  
5 (Exelon 2007b).

6 AmerGen characterized the internal events releases for the spectrum of possible radionuclide  
7 release scenarios using a set of 39 release categories. The release categories and their  
8 frequencies are presented in Table E.2-16 of the ER. The categories were defined based on  
9 the timing, duration, and magnitude of the release and whether the containment remains intact  
10 or is bypassed. The frequency of each release category was obtained by summing the  
11 frequency of the individual CET end states assigned to each release category. The 39 release  
12 categories were further collapsed into nine major source term groups having similar  
13 containment response. The nine major source term groups and their release characteristics are  
14 presented in Tables E.2-17 and E.2-18 of the ER. The release characteristics for these nine  
15 source term groups were developed from Modular Accident Analysis Program (MAAP) analyses  
16 performed specifically to support the SAMA analysis (AmerGen 2008b).

17 The core damage sequences developed for the external flooding model include the three major  
18 groups shown in Table F-1b. Of these groups, the floods above 310 feet and those below 305  
19 feet are each represented by a single core damage sequence. The floods between 305 and  
20 310 feet are represented by six sequences that were quantified using a CET developed  
21 specifically for the IPEEE external flooding evaluation. The descriptions and frequencies of  
22 these flood sequences are summarized in Table E.2-21 of the ER. AmerGen characterized the  
23 external flooding events releases for the spectrum of possible radionuclide release scenarios  
24 using a set of eight release categories from the internal events analysis, which were  
25 subsequently collapsed into seven non-zero source term groups. The source term frequencies  
26 associated with each of the flooding sequences is provided in Table E.2-23 of the ER. In  
27 response to an RAI, AmerGen provided additional information on the logic used to derive the  
28 source term frequencies for each of the flooding sequences (AmerGen 2008b). In response to  
29 another RAI, AmerGen provided a corrected frequency of  $1.68 \times 10^{-8}$  per year for source term  
30 RC-1 (SGTR) in Table E.2-23 of the ER (AmerGen 2008b).

31 The NRC staff's review of the Level 2 IPE concluded that it addressed the most important  
32 severe accident phenomena normally associated with large, dry containments, and identified no  
33 significant problems or errors (NRC 1996). The Level 2 PRA model was included in the TMI-1  
34 peer review mentioned previously. It should be noted, however, that the current Level 2 model  
35 is a revision to version that was peer reviewed. The changes to the Level 2 model are  
36 described in Section E.2.2.3 of the ER (AmerGen 2008). Based on the NRC staff's review of  
37 the Level 2 methodology for both internal events and external flooding events and the  
38 responses to the RAIs concerning the Level 2 model, the NRC staff concludes that the Level 2  
39 PRA provides an acceptable basis for evaluating the benefits associated with various SAMAs.

40 As indicated in the ER, the reactor core radionuclide inventory used in the consequence  
41 analysis was based on a 2002 plant-specific ORIGEN 2.1 calculation and corresponds to a 24-  
42 month refueling cycle and the licensed thermal power of 2568 MWt. All releases were modeled  
43 as occurring at 51.6 meters (top of the reactor building). The thermal content of each of the  
44 releases is assumed to be  $1.0E+07$  watts based on values provided in Sample Problem A in the

1 MACCS2 user's manual (NRC 1998a) and NUREG/CR-4551 (NRC 1990a). AmerGen  
2 assessed the impact of alternatively assuming either a ground level release or an ambient (non-  
3 buoyant) plume. The results of these sensitivity cases showed that reducing the release height  
4 to ground level results in about a 5 percent decrease in population dose-risk, and reducing the  
5 thermal plume heat content to ambient conditions results in less than a 2 percent increase in  
6 population dose-risk.

7 The NRC staff reviewed the process used by AmerGen to extend the containment performance  
8 (Level 2) portion of the PRA to an assessment of offsite consequences (essentially a Level 3  
9 PRA). This included consideration of the source terms used to characterize fission product  
10 releases for the applicable containment release categories and the major input assumptions  
11 used in the offsite consequence analyses. The MACCS2 code was utilized to estimate offsite  
12 consequences. Plant-specific input to the code includes the source terms for each release  
13 category and the reactor core radionuclide inventory (both discussed above), site-specific  
14 meteorological data, projected population distribution within a 50-mi (80-km) radius for the year  
15 2034, emergency evacuation modeling, and economic data. This information is provided in  
16 Attachment E of the ER.

17 AmerGen used site-specific meteorological data for the 1998 calendar year as input to the  
18 MACCS2 code. The data were collected from the onsite meteorological tower. Data from 1998  
19 through 2000 were also considered, but the 1998 data were chosen because they were the  
20 most complete and because results of a MACCS2 sensitivity analysis indicated that the 1998  
21 data produced slightly more conservative results than the data sets for the other years. All of  
22 the missing data gaps were less than 2 hours and interpolation was used to fill the gaps. The  
23 NRC staff notes that previous SAMA analyses results have shown little sensitivity to year-to-  
24 year differences in meteorological data and concludes that the use of the 1998 meteorological  
25 data in the SAMA analysis is reasonable.

26 The population distribution the licensee used as input to the MACCS2 analysis was estimated  
27 for the year 2034, based on the U.S. Census Bureau population data for 2000, as provided by  
28 the SECPOP2000 program (NRC 2003), and the expected annual population growth rate. The  
29 baseline population was determined for each of sixteen directions and each of ten concentric  
30 rings (total of 160 sectors) out to a radius of 50 mi (80 km) surrounding the site. The transient  
31 population within 10 mi (16 km) of the site was included. U.S Census block-group level  
32 population data is allocated to each sector based on the area fraction of the census block-  
33 groups in that sector. The 1990 and 2000 census data were used to determine a ten year  
34 population growth factor for each of the 50-mi (80-km) radius rings. The population growth  
35 factor for each ring was applied uniformly to all sectors in the ring to calculate the year 2034  
36 population distribution. Population sensitivity cases were performed in which the baseline 2034  
37 population was increased by 30 percent, and then decreased to the year 2000 population data  
38 rather than the projected year 2034 population. The resulting population dose and offsite  
39 economic cost risk increased and decreased by approximately 30 percent, respectively. In  
40 response to an RAI regarding the sensitivity case using the year 2000 population, AmerGen  
41 clarified that the population change from year 2034 (to year 2000) was approximately 29  
42 percent and that the change in offsite economic cost risk was consistent with the change in  
43 population (AmerGen 2008b). The NRC staff considers the methods and assumptions for  
44 estimating population reasonable and acceptable for purposes of the SAMA evaluation.

## Appendix F

1 The emergency evacuation model was modeled as a single evacuation zone extending out 10  
2 mi (16 km) from the plant. Based on information in the ER, it was assumed that 95 percent of  
3 the population would evacuate. This assumption is conservative relative to the NUREG-1150  
4 study (NRC 1990b), which assumed evacuation of 99.5 percent of the population within the  
5 emergency planning zone (EPZ). The evacuation time used in the SAMA analysis was based  
6 on a projection for the year 2034. The evacuees were assumed to begin evacuating 90 minutes  
7 after a General Emergency has been declared and to evacuate at an average radial speed of  
8 1.18 miles per hour (mph) (0.53 meters per second [m/s]). This speed is the time weighted  
9 value accounting for season, day of the week, time of day, weather conditions, and special  
10 events. A sensitivity analysis was performed in which the evacuation speed was decreased by  
11 a factor of two (to 0.26 m/s). The result was a 15 percent increase in the total population dose.  
12 The NRC staff concludes that the evacuation assumptions and analysis are reasonable and  
13 acceptable for the purposes of the SAMA evaluation.

14 Much of the site-specific economic data was provided from SECPOP2000 (NRC 2003) by  
15 specifying the data for each of the counties surrounding the plant to a distance of 50 miles.  
16 SECPOP2000 utilizes economic data from the 1997 Census of Agriculture (USDA 1998).  
17 Generic economic data that applies to the region as a whole was taken from the MACCS2  
18 sample problem input and revised when better information was available. Revised values  
19 included daily living expenses for people who have been evacuated and relocated, and the  
20 value of farm and non-farm wealth. The economic data were inflation-adjusted to the year 2006  
21 using the consumer price index.

22 AmerGen addressed the impact on the SAMA analysis of three recently reported problems with  
23 SECPOP2000. These problems involved: (1) an inconsistency in the format in which several  
24 economic parameters were output from the SECPOP2000 code and input to the MACCS2 code,  
25 (2) an error that resulted in use of agricultural/economic data for the wrong counties in the  
26 SECPOP2000 calculations, and (3) an error that resulted in the economic data for some  
27 counties being handled incorrectly. Correction of the first of these errors is reflected in the  
28 baseline risk estimates provided in the ER. Correction of the second two errors was evaluated  
29 in a sensitivity analysis contained in the ER. Correction of the second two errors resulted in a  
30 decrease in population dose of approximately one percent and an increase in offsite economic  
31 cost risk of approximately 15 percent. The revised population dose results are reported in  
32 Section E.7.6.4 of the ER, and have been used as the basis for the NRC staff evaluation.

33 The NRC staff concludes that the methodology used by AmerGen to estimate the offsite  
34 consequences for TMI-1 provides an acceptable basis from which to proceed with an  
35 assessment of risk reduction potential for candidate SAMAs. Accordingly, the NRC staff based  
36 its assessment of offsite risk on the CDF and revised offsite doses reported by AmerGen.  
37

### 38 **F.3 Potential Plant Improvements**

39 The process for identifying potential plant improvements, an evaluation of that process, and the  
40 improvements evaluated in detail by AmerGen are discussed in this section.  
41

### 1           **F.3.1     Process for Identifying Potential Plant Improvements**

2 AmerGen's process for identifying potential plant improvements (SAMAs) consisted of the  
3 following elements:

- 4       • Review of the most significant basic events from the current, plant-specific PRA,
- 5       • Review of potential plant improvements identified in the TMI-1 IPE and IPEEE,
- 6       • Review of Phase II SAMAs from license renewal applications for six other U.S. nuclear  
7       sites,
- 8       • Review of dominant contributors to external flooding, seismic and fire events in the  
9       current external event risk models, and
- 10      • Review of other industry documentation discussing potential plant improvements.

11  
12 Based on this process, an initial set of 33 candidate SAMAs, referred to as Phase I SAMAs, was  
13 identified. In Phase I of the evaluation, AmerGen performed a qualitative screening of the initial  
14 list of SAMAs using the following criteria:

- 15      • The SAMA is not applicable at TMI-1 due to design differences, or
- 16      • The SAMA has estimated costs that would exceed the dollar value associated with  
17      completely eliminating all severe accident risk at TMI-1.

18  
19 Based on this screening, no SAMAs were eliminated leaving all 33 for further evaluation. These  
20 SAMAs, referred to as Phase II SAMAs, are listed in Table F.5-3 of the ER (AmerGen 2008a).  
21 In Phase II, a detailed evaluation was performed for each of the 33 SAMA candidates, as  
22 discussed in Sections F.4 and F.6 below.

23  
24 AmerGen accounted for the potential risk reduction benefits associated with internal event- and  
25 external flooding-related SAMAs by separately quantifying the benefits using the internal event  
26 or external flooding model, respectively. For internal event-related SAMAs, AmerGen  
27 accounted for the potential risk reduction benefits associated with non-flooding external events  
28 (i.e., seismic and fire events) by doubling the estimated benefits for internal events. For  
29 seismic- and fire-related SAMAs, AmerGen separately estimated the risk reduction benefits  
30 using the seismic and fire risk models.  
31

### 32           **F.3.2     Review of AmerGen's Process**

33 AmerGen's efforts to identify potential SAMAs focused primarily on areas associated with  
34 internal initiating events, but also included explicit consideration of potential SAMAs for external  
35 flooding, seismic, and fire events. The initial list of SAMAs generally addressed the accident  
36 sequences considered to be important to CDF from functional, initiating event, and risk  
37 reduction worth (RRW) perspectives at TMI-1, and included selected SAMAs from prior SAMA  
38 analyses for other plants.

39 AmerGen provided a tabular listing of the PRA basic events sorted according to their RRW  
40 (AmerGen 2008a). SAMAs impacting these basic events would have the greatest potential for  
41 reducing risk. AmerGen used a RRW cutoff of 1.01, which corresponds to about a one percent

## Appendix F

1 change in CDF given 100-percent reliability of the SAMA. This equates to a benefit of  
2 approximately \$52,000 (after the benefits have been multiplied to account for non-flood external  
3 events). External flooding contributions were not included in the benefit calculations  
4 establishing the RRW review threshold because the benefit of external flooding SAMAs are  
5 evaluated separately from the internal events model. AmerGen also provided and reviewed the  
6 large early release frequency (LERF)-based RRW events down to a RRW of 1.01. AmerGen  
7 correlated the basic events with highest risk importance in the Level 1 and 2 PRA with the  
8 SAMAs evaluated in Phase I or Phase II, and showed that, with a few exceptions, all of the  
9 significant basic events are addressed by one or more SAMAs (AmerGen 2008a). Of the basic  
10 events of high risk importance that are not addressed by SAMAs, each is closely tied to other  
11 basic events that had been addressed by one or more SAMAs.

12 The staff noted that basic event GADF-PALL6-CP2FS was identified in the Level 2 importance  
13 list review as being addressed by the same SAMAs as identified in the Level 1 importance list  
14 review for this same basic event but that this basic event was not listed in the Level 1  
15 importance list (NRC 2008a). In response to the RAI, AmerGen clarified that this event  
16 contributes almost exclusively to station blackout (SBO) scenarios and is effectively addressed  
17 by SAMAs 2 and 11.

18 AmerGen considered the potential plant improvements identified in the IPE and IPEEE in the  
19 identification of plant-specific candidate SAMAs for internal and external events, as summarized  
20 below.

21 The TMI-1 IPE identified five major procedural improvements. These enhancements are: (1)  
22 revise procedures to direct operators to throttle low pressure injection (LPI) prior to swapping  
23 the pump suction source from the borated water storage tank (BWST) to the containment sump,  
24 (2) revise accident management guidelines for SGTR events to direct the operators to isolate  
25 the failed steam generator and cooldown the primary system using the intact steam generator,  
26 (3) revise accident management guidelines for SGTR events in which isolation of the ruptured  
27 steam generator is not possible to direct the operators to refill the BWST to keep pace with  
28 reactor coolant system (RCS) inventory loss, (4) revise accident management guidelines to  
29 direct the operators to verify closure of the MU-14 valves after the transition to recirculation  
30 mode from high pressure injection (HPI) mode, and (5) include six specific operator actions in  
31 the licensed operator requalification training program. AmerGen noted that the first four  
32 improvements have been implemented and the fifth improvement has been partially  
33 implemented; therefore these improvements were not considered further in the SAMA analysis.  
34 The six operator actions associated with the fifth improvement included: (1) switchover to  
35 reactor sump recirculation following a LOCA, (2) properly throttling HPI flow after ES actuation,  
36 (3) tripping RCPs before seal damage after loss of nuclear services closed cooling water  
37 (NSCCW), (4) taking actions to prevent boron concentration when in recirculation following a  
38 LOCA, (5) refilling the BWST given SGTR, and (6) holding open or reopening RCP seal  
39 injection valve MU-V-20 on loss of instrument air. The first four operator actions have been  
40 implemented, and therefore were not considered further in the SAMA analysis. While AmerGen  
41 has identified no specific training for the last two operator actions, failure to perform these  
42 actions is included in the TMI-1 PRA model. The importance list review conducted by AmerGen  
43 for the SAMA analysis identified failure of operator action (5) as an important contributor to  
44 CDF. SAMA 10 was identified to address this event. The RRW for failure of operator action (6)

1 is less than the cutoff threshold of 1.01 for identifying potentially cost-beneficial SAMAs.  
2 Nevertheless, this and similar loss of instrument air events is addressed by SAMA 13.

3 The TMI-1 external flooding IPEEE identified one opportunity for improvement related to  
4 external flooding events. This enhancement was to install a flood-resistant means of providing  
5 480V AC power and pumps to provide RCP seal cooling and makeup to the steam generators.  
6 AmerGen stated that this enhancement has been implemented and was credited in the IPEEE  
7 external floods CDF. Nevertheless, AmerGen further considered potential SAMAs for external  
8 floods and identified two opportunities for additional reduction of the external flooding risk,  
9 specifically, SAMA 32, pre-stage severe external flooding equipment, and SAMA 33, increase  
10 the flood protection height. The NRC staff questioned whether there was adequate time to  
11 install the TMI-1 flood gates in fast-developing floods, such as the flood surge produced by a  
12 hurricane, and requested justification for not identifying and evaluating potential SAMAs to  
13 reduce this response time (e.g., pre-staging of cranes needed to install the gates) (NRC 2008a).  
14 In response to the RAI, AmerGen clarified that TMI-1 staff have about 7.5 hours to install the six  
15 flood panels at the Intake Screen Pumphouse, which are the last flood gates to be installed if  
16 needed, but that TMI-1 staff only require at most about 3 hours to install these panels (AmerGen  
17 2008b). AmerGen further clarified that TMI-1 staff have about 36 hours to install the many other  
18 flood gates, which is significantly more time than is needed to complete their installation  
19 (AmerGen 2008c). Based on these arguments, AmerGen determined that there were no  
20 additional potentially cost-beneficial SAMAs to mitigate external flooding events.

21 The TMI-1 seismic IPEEE identified six opportunities for improvements related to seismic  
22 events. The enhancements included: (1) add gusset weld reinforcements to load centers 1P,  
23 1R, 1S, and 1T to improve seismic ruggedness, (2) install additional supports for the main  
24 control room (MCR) ceiling to prevent failure in seismic events, (3) install a restraint on  
25 penetration pressurization tank PP-T-1A to prevent seismic interaction with reactor building  
26 purge inlet isolation valve AH-V-1D, (4) modify the diesel fire pump battery and fuel oil tank  
27 supports to increase their seismic ruggedness, (5) modify the anchorage for the decay heat  
28 service heat exchangers (DC-C-2A/B) to improve their seismic ruggedness, and (6) modify the  
29 anchorage for the EDG air receivers to improve their seismic ruggedness. AmerGen stated that  
30 enhancements (2), (3), and (6) were subsequently implemented, and therefore were not  
31 considered further in the SAMA analysis. As noted in Section E.5.1.6.2.2 of the ER (AmerGen  
32 2008a), SAMA 27, improve the 480V AC load center welds, SAMA 30, improve diesel fire pump  
33 fuel oil tank and battery rack supports, and SAMA 28, improve the decay heat service cooler  
34 (DC-C-2A/B) anchorages, were identified and retained for the Phase II evaluation to specifically  
35 address un-implemented enhancements (1), (4), and (5), respectively. AmerGen further  
36 reviewed the top contributors to seismic risk to identify additional areas for potential plant  
37 improvement and identified three opportunities for additional reduction of the seismic risk,  
38 specifically, SAMA 2, install damage resistant high temperature RCP seals with a portable 480V  
39 AC generator for extended emergency feedwater (EFW) operation (originally identified based on  
40 internal events risk), SAMA 29, replace EDG ground resistors, and SAMA 31, modify specific  
41 containment penetration motor operated valves (MOVs) to fail closed.

42 The TMI-1 fire IPEEE did not identify any opportunities for improvements related to fire events  
43 (AmerGen 2008a). Nevertheless, AmerGen further reviewed the top contributors to fire risk to  
44 identify areas for potential plant improvement and identified two opportunities for additional

## Appendix F

1 reduction of the fire risk, specifically, SAMA 2 (described above) and SAMA 26, reroute cables  
2 so that they do not pass over ignition sources in fire zone CB-FA-2e or wrap these cables in  
3 fire proof material. In response to an RAI on the potential for SAMAs that could reduce the fire  
4 risk in other fire areas screened on low CDF, AmerGen evaluated the fire risk for two additional  
5 fire scenarios, CB-FA-2f (East Battery Room) and the CC panel from fire area CB-FA-4b, and  
6 identified no additional potentially cost-beneficial SAMAs to mitigate these fire scenarios  
7 (AmerGen 2008b).

8 The TMI-1 IPEEE did not identify opportunities for improvements related to high winds,  
9 accidental aircraft impact, and hazardous chemical release events (AmerGen 2008a). In  
10 Section E.5.1.6.5 of the ER, AmerGen states that the maximum benefit of completely  
11 eliminating the risk of these events is less than the \$50,000 minimum cost for implementing a  
12 SAMA. The NRC staff questioned the methodology used by AmerGen to calculate the  
13 maximum benefit of these events and asked AmerGen to provide a revised assessment of  
14 potential SAMAs based on the methodology presented by the NRC staff (NRC 2008a). In  
15 response to the RAI (AmerGen 2008b), AmerGen stated that the only types of SAMA  
16 candidates that would be potentially cost-beneficial utilizing the higher benefit values calculated  
17 utilizing the NRC methodology would be procedure changes, of which none could be identified  
18 to mitigate these types of events (AmerGen 2008b). AmerGen therefore identified no additional  
19 potentially cost-beneficial SAMAs to mitigate high winds, accidental aircraft impact, and  
20 hazardous chemical release events.

21 As discussed above, AmerGen's SAMA evaluation included SAMAs addressing unimplemented  
22 enhancements identified in the IPE and IPEEE, and SAMAs addressing additional  
23 enhancements based on a review of the dominant contributors to internal, external flooding,  
24 seismic, and fire events. Based on this information, the NRC staff concludes that the set of  
25 SAMAs evaluated in the ER addresses the major contributors to internal and external event  
26 CDF, that the opportunity for SAMAs related to both internal and external events has been  
27 adequately explored, and that it is unlikely that there are additional potentially cost-beneficial  
28 SAMA candidates.

29 The NRC staff noted that none of the initial 33 SAMA candidates were screened from further  
30 consideration in the Phase I evaluation, and questioned whether AmerGen had conducted a  
31 pre-screening process to develop this initial list (NRC 2008a). In response to the RAI, AmerGen  
32 stated that no formal pre-screening process had been used in the development of the Phase I  
33 SAMA list and that the list of 33 SAMA candidates represents the complete results of the SAMA  
34 identification process described in the ER (AmerGen 2008b).

35 For a number of the SAMAs evaluated in the ER, the information provided did not sufficiently  
36 describe the proposed modification. Therefore, the NRC staff asked the applicant to provide  
37 more detailed descriptions of the modifications for several of the Phase II SAMA candidates  
38 (NRC 2008a). In response to the RAI, AmerGen provided the requested information (AmerGen  
39 2008b).

40 The NRC staff notes that the set of SAMAs submitted is not all inclusive, since additional,  
41 possibly even less expensive, design alternatives can always be postulated. However, the NRC  
42 staff concludes that the benefits of any additional modifications are unlikely to exceed the  
43 benefits of the modifications evaluated and that the alternative improvements would not likely



1 cost less than the least expensive alternatives evaluated, when the subsidiary costs associated  
2 with maintenance, procedures, and training are considered.

3 The NRC staff concludes that AmerGen used a systematic and comprehensive process for  
4 identifying potential plant improvements for TMI-1, and that the set of potential plant  
5 improvements identified by AmerGen is reasonably comprehensive and therefore acceptable.  
6 This search included reviewing insights from the plant-specific risk studies, and reviewing plant  
7 improvements considered in previous SAMA analyses. While explicit treatment of external  
8 events in the SAMA identification process was limited, it is recognized that the prior  
9 implementation of plant modifications for external flooding, seismic, and fire events and the  
10 absence of external event vulnerabilities reasonably justifies examining primarily the internal  
11 events risk results for this purpose.  
12

#### 13 **F.4 Risk Reduction Potential of Plant Improvements**

14 AmerGen evaluated the risk-reduction potential of the 33 SAMAs that were applicable to TMI-1.  
15 The SAMA evaluations were performed using realistic assumptions with some conservatism.  
16 On balance, such calculations overestimate the benefit and are conservative.

17 For most of the SAMAs, AmerGen used model re-quantification to determine the potential  
18 benefits. The CDF and population dose reductions for internal events were estimated using the  
19 TMI-1 Level 1 and 2 PRA model (Version 2004 Revision 2) and for external flooding events  
20 were estimated using the IPEEE external flooding PRA model with plant damage states  
21 correlated to release categories from the internal events analysis. The changes made to the  
22 models to quantify the impact of SAMAs are detailed in Section E.6 of Appendix E to the ER  
23 (AmerGen 2008a). Table F-6 lists the assumptions considered to estimate the risk reduction for  
24 each of the evaluated SAMAs, the estimated risk reduction in terms of percent reduction in CDF  
25 and population dose, and the estimated total benefit (present value) of the averted risk. The  
26 estimated benefits reported in Table F-6 reflect the combined benefit in both internal and  
27 external events and reflect corrections to previously identified SECPOP2000 errors, as  
28 described in Section E.7.6 of Appendix E to the ER (AmerGen 2008a). The determination of the  
29 benefits for the various SAMAs is further discussed in Section F.6.

30 The NRC staff questioned the assumptions used in evaluating the benefits or risk reduction  
31 estimates of certain SAMAs provided in the ER (NRC 2008a). For SAMA 1, enhance the SBO  
32 EDG with auto start and load capability, the NRC staff requested the bases for the assumption  
33 for SAMA 1 that making modifications to automate start of the SBO EDG only reduces the  
34 probability of failure to start the SBO EDG by a factor of 10. In response, AmerGen clarified that  
35 most of the benefit for this SAMA is from preventing all seal LOCA cases resulting from the  
36 inability to provide power for RCP seal cooling within 13 minutes. In order to show that the  
37 results of this SAMA evaluation are not sensitive to the human error probability used in the  
38 modeling process, AmerGen set the probability to zero and showed that the change in CDF was  
39 negligible (AmerGen 2008b). The NRC staff considers the assumptions, as clarified, to be  
40 reasonable and acceptable for purposes of the SAMA evaluation.

41 The NRC staff asked for clarification as to why SAMA 10, automate BWST refill, was assumed  
42 to prevent, rather than just delay core damage (NRC 2008a). In response to the RAI, AmerGen

## Appendix F

1 clarified that SAMA 10 would include the installation of a new, higher flow pump to ensure the  
2 BWST can be refilled at a rate greater than inventory is being lost through the steam generator  
3 tube rupture (AmerGen 2008b). The NRC staff considers the assumption, as clarified, to be  
4 reasonable and acceptable for purposes of the SAMA evaluation.

5 In a separate RAI on SAMA 10, the NRC staff asked AmerGen to provide an assessment of the  
6 impact on the net value of this SAMA if the benefit of mitigating ISLOCA events were  
7 considered in addition to the already estimated benefit of mitigating SGTR events (NRC 2008a).  
8 In response to the RAI, AmerGen re-evaluated this SAMA by assuming the SAMA also  
9 eliminates all ISLOCA events. This bounding assumption resulted in a CDF reduction of  
10 approximately 4.2 percent, compared to 3.4 percent reported in the ER, and a population dose-  
11 risk reduction of approximately 17 percent, compared to 14 percent reported in the ER  
12 (AmerGen 2008b). The NRC staff considers the assumption, as revised, to be reasonable and  
13 acceptable for purposes of the SAMA evaluation.

14 The NRC staff questioned the modeling assumption that seismic SAMA 27, improve the 480V  
15 AC load center welds (HCLPF of 0.12g), and seismic SAMA 28, improve the decay heat service  
16 cooler anchorages (HCLPF of 0.09g), would result in seismic failure probabilities similar to that  
17 for the BWST (HCLPF of 0.3g), given the design and functional dissimilarities between the  
18 respective components (NRC 2008a). In response to the RAI (AmerGen 2008b), AmerGen  
19 noted that SAMA 27 was shown to be cost-beneficial by a wide margin and that only extreme  
20 fragility data changes could impact this result, which is not likely. For SAMA 28, AmerGen  
21 compared the component failure probability data for decay heat service coolers, which is  
22 considered a good surrogate for heat exchangers, with the BWST failure probability data used  
23 in the IPEEE. Based on this comparison, AmerGen determined that they generally have similar  
24 failure probabilities for the initiating events evaluated in the IPEEE, and that use of the BWST  
25 values result in slightly larger averted cost-risk. The NRC staff considers the assumptions, as  
26 clarified, to be reasonable and acceptable for purposes of the SAMA evaluation.

27 For SAMAs that were specifically developed to address internal event issues, AmerGen  
28 increased the benefit that was derived from the internal events model by a factor 2 to account  
29 for the additional benefits that these SAMAs might have in external events other than external  
30 floods (primarily seismic and fire events). The benefits in external floods were separately  
31 quantified using the external flood risk model, where applicable (as noted in Table F-6), and  
32 combined with these benefits.

33 For SAMAs that specifically address seismic events (i.e., SAMAs 27 through 31), the reduction  
34 in seismic CDF and population dose was not directly calculated (in Table F-6 these are noted as  
35 NOT ESTIMATED). For these SAMAs, a bounding estimate of the impact of the SAMA was  
36 made based on general assumptions regarding: the approximate contribution to total risk from  
37 external events relative to that from internal events; the fraction of the external event risk  
38 attributable to seismic events; and the fraction of the seismic risk affected by the SAMA (based  
39 on information from the IPEEE). For example, AmerGen assumed that the contribution to risk  
40 from external events (excluding external flooding events) is approximately equal to that from  
41 internal events, and that seismic events contribute about 80 percent of this external events risk.  
42 The seismic re-analysis was then used to identify the fraction of the seismic risk that could be  
43 eliminated by the potential enhancements.

1 The NRC staff notes that AmerGen's assumption that the seismic CDF is equivalent to 80  
2 percent of the internal events CDF effectively results in a seismic CDF of  $1.9 \times 10^{-5}$  per year. In  
3 response an RAI, AmerGen noted that the seismic CDF reported in the IPEEE (based on use of  
4 the EPRI hazard curves) is  $3.21 \times 10^{-5}$  per year. AmerGen also identified a number of  
5 conservative assumptions in the IPEEE seismic analysis, and identified several seismic-related  
6 plant modifications that have been implemented but not reflected in the IPEEE risk results  
7 (AmerGen 2008b). As discussed in Section F.2.2, based on an independent estimate of the  
8 seismic CDF, and the fact that structural improvements implemented since the IPEEE have not  
9 been accounted for in the estimate of seismic CDF, the NRC staff expects that the seismic CDF  
10 would be less than  $3.2 \times 10^{-5}$  per year. The NRC staff assessed the impact that use of the  
11 higher seismic CDF ( $3.2 \times 10^{-5}$  per year) would have on the cost effectiveness of the evaluated  
12 seismic SAMAs and found that the conclusions regarding these SAMAs would not be impacted.

13 For the SAMA that specifically addresses fire events (i.e., SAMA 26), the reduction in fire CDF  
14 and population dose also was not directly calculated. For this SAMA, a bounding estimate of  
15 the impact of the SAMA was made using a methodology similar to that described for seismic  
16 SAMAs. For example, it is assumed that the contribution to risk from external events (excluding  
17 external flooding events) is approximately equal to that from internal events, and that internal  
18 fires contribute 85 percent of this external events risk. The fire re-analysis was then used to  
19 identify the fraction of the fire risk that could be eliminated by potential enhancements in the  
20 applicable fire area. AmerGen's assumption that the fire CDF is equivalent to 85 percent of the  
21 internal events CDF effectively results in a fire CDF of  $2.0 \times 10^{-5}$  per year. As discussed in  
22 Section F.2.2, using the corrected fire CDF for fire area CB-FB-2e results in a revised total fire  
23 CDF of  $2.13 \times 10^{-5}$  per year. Thus, the fire CDF used in assessing the benefits for the fire-  
24 related SAMA is consistent with the revised total fire CDF.

25 While noting that AmerGen's assumptions that seismic CDF is 80 percent and fire CDF is 85  
26 percent of the total non-flooding external events CDF appear internally inconsistent, the NRC  
27 staff concludes that the resulting seismic and fire CDFs are in general agreement with the  
28 seismic and fire CDFs and accompanying qualitative justification presented in Section F.2.2,  
29 and that AmerGen's risk reduction estimates for the seismic-and fire-related SAMAs are  
30 acceptable for purposes of the SAMA evaluation.

31 The NRC staff has reviewed AmerGen's bases for calculating the risk reduction for the various  
32 plant improvements and concludes that the rationale and assumptions for estimating risk  
33 reduction are reasonable and generally conservative (i.e., the estimated risk reduction is higher  
34 than what would actually be realized). Accordingly, the NRC staff based its estimates of averted  
35 risk for the various SAMAs on AmerGen's risk reduction estimates.

**Table F-6. SAMA Cost/Benefit Screen Analysis for TMI-1<sup>(a)</sup>**

SAMA	Assumptions <sup>(d)</sup>	% Risk Reduction <sup>(b)</sup>		Total Benefit <sup>(c)</sup> (\$)		Cost (\$)
		CDF	Population Dose	Baseline	Baseline With Uncertainty	
1 – Enhance the SBO EDG with auto start and load capability	<p>IE: Modify event tree to prevent all seal LOCA cases resulting from inability to provide RCP seal cooling within 13 minutes. Reduce the probability of failure to start the SBO EDG during loss of AC power events by a factor of 10, and set corresponding Joint Human Error Probabilities (JHEPs) to 0.</p> <p>EF: Reduce the risk for LOOP scenarios for floods below 305' msl by the same percent reduction as for internal events.</p>	21	16	1.0M	2.9M	3.1M
2 – Install damage resistant high temperature RCP seals with a portable 480V AC generator for extended EFW operation	<p>IE: Reduce the probabilities of RCP seal LOCAs and loss of AC power to instrument air during SBO by a factor of 10. Reduce the probability of failure to operate EFW valve EF-V-30 due to loss of instrument air by a factor of 10, and set corresponding JHEPs to 0.</p> <p>EF: Eliminate all SBO events for floods between 305' and 310' msl when flood gates are correctly installed; eliminate all risk from floods below 305' msl.</p>	53	53	4.6M	13M	7.3M
3 – Use NSCCW as an alternate cooling source for the decay heat removal (DHR) heat exchangers (DH-C-1A/B)	<p>IE: Modify fault tree to include cross-tie of the NSCCW system to the DHR heat exchangers.</p> <p>EF: Eliminate power-recovered SBO events for floods between 305' and 310' msl when flood gates are correctly installed; eliminate all risk from floods below 305' msl.</p>	15	8	620K	1.7M	2.5M

1

Appendix F

SAMA	Assumptions <sup>(d)</sup>	% Risk Reduction <sup>(b)</sup>		Total Benefit <sup>(c)</sup> (\$)			Cost (\$)
		CDF	Population Dose	Baseline	Baseline With Uncertainty		
4 – Provide alternate power to HPI pump minimum flow recirculation valves MU-V-36 and MU-V-37	The RRW for the basic event is below the cost-beneficial cutoff.			NOT ESTIMATED			
5 – Enhance valves MU-V-76A/B and MU-V-77A/B to allow for rapid alignment changes in accident conditions	IE: Reduce the probability of failure to align the "C" HPI pump to provide seal injection by a factor of 100. EF: Reduce the risk for floods below 305' msl by 6.3 percent.	6 0	3 0	240K	660K	3.2M	
6 – Add cross-ties within the trains of cooling systems – DHR, DHCCW, DHRW	IE: Modify fault tree to include cross-ties between Trains A and B of the DHR system, between Trains A and B of the DHCCW system, and between Trains A and B of the LPI system, and between Trains A and B of the DHR system. EF: Eliminate power-recovered SBO events for floods between 305' and 310' msl when flood gates are correctly installed; eliminate all risk from floods below 305' msl.	13 -0	5 -0	410K	1.1M	2.8M	
7 – Use fire service water as an alternate cooling source for the intermediate closed cooling water (ICCW) heat exchangers	IE: Modify fault tree to include cross-tie of the fire service water system to the ICCW heat exchangers. EF: Eliminate all risk from floods below 305' msl.	13 -0	6 -0	470K	1.3M	1.0M	
8 – Automate reactor coolant pump trip on high motor bearing cooling temperature	IE: Reduce the probability of failure to trip the RCPs upon loss of NSCCW by a factor of 10, and set corresponding JHEPs to 0. EF: Does not mitigate external flooding	13 0	23 0	1.3M	3.6M	150K	

Appendix F

SAMA	Assumptions <sup>(d)</sup>	% Risk Reduction <sup>(b)</sup>		Total Benefit <sup>(c)</sup> (\$)		Cost (\$)
		CDF	Population Dose	Baseline	Baseline With Uncertainty	
9 – Proceduralize local atmospheric dump valve (ADV) operation	<p>scenarios.</p> <p>The current model is conservative in that it does not credit existing procedures to perform local ADV operations. Crediting the existing procedures by assigning a human error probability of 0.1 for failure to locally operate ADVs on loss of air reduces RRW below the cost-beneficial cutoff.</p>					
<b>10 – Automate BWST refill</b>						
Baseline Case <sup>(e)</sup>	<p>IE: Reduce the probability of failure to refill the BWST from 2.65E-02 to 1.0E-04, and set corresponding JHEPs to 0. Eliminate all ISLOCA events.</p> <p>EF: Does not mitigate external flooding scenarios.</p>	4	17	1.3M <sup>(f)</sup>	3.5M <sup>(f)</sup>	3.8M
Sensitivity Case	<p>IE: Reduce the probability of failure to refill the BWST from 1.0 to 1.0E-04, and set corresponding JHEPs to 0. Eliminate all ISLOCA events.</p> <p>EF: Does not mitigate external flooding scenarios.</p>	17 <sup>(f)</sup>	50 <sup>(f)</sup>	6.3M <sup>(f)</sup>	17M <sup>(f)</sup>	3.8M
11 – Enhance extreme external flooding mitigation equipment to address SBO and loss of seal cooling scenarios	<p>IE: Reduce the probability of failure to operate the EDGs and TD EFW pumps to 0.</p> <p>EF: For all floods, reduce the probability of failure to implement the external flooding measures to 1.0E-04 and reduce</p>	34	25	17M	47M	4.3M

Appendix F

SAMA	Assumptions <sup>(d)</sup>	% Risk Reduction <sup>(b)</sup>		Total Benefit <sup>(c)</sup> (\$)		Cost (\$)
		CDF	Population Dose	Baseline	Baseline With Uncertainty	
	the probability of failure to provide flood-resistant AC power to 2.0E-02.					
12 – Use the DHR system as an alternate suction source for HPI	IE: Modify fault tree to include alignment of existing DHR valves DH-V-7A/B having a probability of failure of 0.1. EF: Does not mitigate external flooding scenarios.	4	3	210K	580K	50K
13 – Change IA system logic to automatically start IA-P-1A/B after a low voltage trip in conjunction with an engineered safeguards actuation signal (ESAS)						
Baseline Case	IE: Reduce the probability of failure to start the air compressors using emergency power to 1.0E-05, and set corresponding JHEPs to 0. EF: Does not mitigate external flooding scenarios.	3	4	330K	920K	950K
Sensitivity Case <sup>(g)</sup>	IE: Reduce the probability of failure to start the air compressors using emergency power to 1.0E-05, and set corresponding JHEPs to 0. Set the probability of failure to refill the BWST from 2.65E-2 to 1 (in both baseline and sensitivity case). EF: Does not mitigate external flooding scenarios.	8	19	2.4M <sup>(f)</sup>	6.6M <sup>(f)</sup>	950K
		0	0			

Appendix F

SAMA	Assumptions <sup>(d)</sup>	% Risk Reduction <sup>(b)</sup>		Total Benefit <sup>(c)</sup> (\$)		Cost (\$)
		CDF	Population Dose	Baseline	Baseline With Uncertainty	
14 – Replace HPI pump cooling alignment valves with MOVs	IE: Modify fault trees for all three makeup pumps to include alignment of alternative cooling sources NSCCW and DHCCW from the MCR. EF: Eliminate all risk from floods below 305' msl.	17	8	630K	1.73M	3.15M
15 – Automatic swap to recirculation mode	IE: Reduce the probabilities of failure to swap over from injection to recirculation mode within one minute and within ten minutes to 1.0E-05, and set corresponding JHEP to 0. EF: Eliminate all manual recirculation failures for floods between 305' and 310' msl when flood gates are correctly installed and for floods below 305' msl.	5	3	210K	576K	450K
16 – Automate HPI injection on low pressurizer level	IE: Reduce the probability of failure to initiate HPI to 1.0E-04, and set corresponding JHEPs to 0. EF: Reduce the risk for floods below 305' msl by the same percent reduction as the internal events CDF.	6	26	1.8M	4.8M	1.1M
17 – Auto isolate steam generators on high steam line flow	IE: Reduce the probability of failure to isolate the steam generators by a factor of 10, and set corresponding JHEP to 0. EF: Does not mitigate external flooding scenarios.	1	1	55K	150K	950K
18 – Provide the capability to align	IE: Reduce the probability of failure to align	2	~0			



Appendix F

SAMA	Assumptions <sup>(d)</sup>	% Risk Reduction <sup>(b)</sup>		Total Benefit <sup>(c)</sup> (\$)		Cost (\$)
		CDF	Population Dose	Baseline	Baseline With Uncertainty	
the standby battery charger and the 1A/1B DC cross-tie from the MCR	the standby battery charger by a factor of 10. EF: Eliminate all manual battery charger alignment failures for floods between 305' and 310' msl when flood gates are correctly installed. Reduce the risk for floods below 305' msl by the same percent reduction as the internal events CDF.	0	~0	32K	89K	100K
19 – Install battery backed hydrogen igniters or a passive hydrogen ignition system	IE: Modify fault tree for early containment failures to represent addition of a hydrogen ignition system with an unavailability of 0.01 in all sequences, including LOOP and SBO scenarios. EF: For all floods with successful containment isolation, reduce early containment failure by the same percentage as for internal events, and reassign to late containment failure.	0	11	3.4M	9.4M	760K
20 – Extend the high pressure boundary through DHR valve DH-V-3 for ISLOCA isolation	IE: Completely eliminate all ISLOCA events. EF: Does not mitigate external flooding scenarios.	1 0	3 0	190K	520K	3.0M
21 – Install concrete shields to block direct pathways from the reactor pressure vessel (RPV) to the containment wall, and/or initiate containment flooding early in external flooding scenarios	IE: Reassign early containment failures due to liner melt-thru to either basemat failure (75 percent of events) or intact containment (25 percent of events). EF: Reassign early containment failures due to liner melt-thru to either basemat failure or intact containment depending on availability of containment spray in	0 0	3 7	1.3M	3.6M	1.2M

Appendix F

SAMA	Assumptions <sup>(d)</sup>	% Risk Reduction <sup>(b)</sup>		Total Benefit <sup>(c)</sup> (\$)		Cost (\$)
		CDF	Population Dose	Baseline	Baseline With Uncertainty	
	<b>specific flood sequence.</b>					
22 – Install an independent EFW system	IE: Modify fault trees to include the independent EFW system. EF: Eliminate all risk from floods below 305' msl.	6 ~0	17 ~0	1.4M	3.8M	5.0M
23 – Develop alarm response procedures to direct operation of RR-V-5 on low reactor building emergency cooling (RBEC) flow	IE: Reduce the probability of failure to open MOV RR-V-5 by a factor of 10. EF: Reduce the population dose risk and annual offsite economic cost risk for LOOP scenarios for floods below 305' msl by the same percent reduction as for internal events.	0 0	1 0	32K	89K	50K
24 – Install damage resistant high temperature RCP seals, a diesel engine as an alternate drive for an EFW pump, and a portable 480V AC generator for extended EFW operations	IE: Same as SAMA 2. In addition, completely eliminate failure of the TD EFW pump to operate. EF: Eliminate all SBO events for floods between 305' and 310' msl when flood gates are correctly installed; eliminate all risk from floods below 305' msl.	53 5	55 6	4.7M	13M	8.4M
25 – Install an additional EDG	IE: Eliminate all failures of the SBO EDG. EF: Eliminate all risk for floods between 305' and 310' msl when flood gates are correctly installed and from all floods below 305' msl. FE: Eliminate all cable damage due to fire in fire zone CB-FA-2E.	9 5 13	9 6 13	1.6M 400K	4.3M 1.1M	6.0M 900K

Appendix F

SAMA	Assumptions <sup>(d)</sup>	% Risk Reduction <sup>(b)</sup>		Total Benefit <sup>(c)</sup> (\$)		Cost (\$)
		CDF	Population Dose	Baseline	Baseline With Uncertainty	
(West Inverter Room) or wrap them in fire proof material	EF: Does not mitigate external flooding scenarios.	0	0			
27 – Improve the 480V AC load center welds	SE: Reduce failure probabilities for 480V AC load centers 1P, 1R, 1S, and 1T to those corresponding to a HCLPF of 0.30g. EF: Does not mitigate external flooding scenarios.	NOT ESTIMATED	NOT ESTIMATED	1.4M	3.9M	580K
28 – Improve the decay heat service cooler (DC-C-2A/B) anchorages	SE: Reduce failure probabilities for decay heat service coolers to those corresponding to a HCLPF of 0.30g. EF: Does not mitigate external flooding scenarios.	NOT ESTIMATED	NOT ESTIMATED	51K	140K	580K
29 – Replace EDG ground resistors	SE: Eliminate all failures of the EDG ground resistors. EF: Does not mitigate external flooding scenarios.	NOT ESTIMATED	NOT ESTIMATED	28K	76K	800K
30 – Improve diesel fire pump fuel oil tank and battery rack supports	SE: Eliminate all failures of the FSW system supports. EF: Does not mitigate external flooding scenarios.	NOT ESTIMATED	NOT ESTIMATED	28K	76K	150K
31 – Modify specific containment penetration MOVs to fail closed	The estimated cost is greater than the entire seismic MACR.	NOT ESTIMATED		NOT ESTIMATED		4.1M
32 – Pre-stage severe external flooding equipment	IE: Does not mitigate internal events scenarios.	0	0	14M	39M	1.7M

Appendix F

SAMA	Assumptions <sup>(d)</sup>	% Risk Reduction <sup>(b)</sup>		Total Benefit <sup>(c)</sup> (\$)		Cost (\$)
		CDF	Population Dose	Baseline	Baseline With Uncertainty	
	EF: For floods > 310' msl, reduce the probability of failure to implement the external flooding measures to 1.0E-02 and reduce the probability of failure to provide flood-resistant AC power to 2.0E-02. For floods between 305' and 310' msl, reduce the probability of failure to implement the severe flooding measures to 0.14.	84	84			
<b>33 – Increase the flood protection height</b>	IE: Does not mitigate internal events scenarios. EF: For floods > 310' msl, use same failure probability for installing flood doors as used for the 305' to 310' msl floods.	0	0	9.8M	27M	2.7M

- 1 (a) SAMAs in bold are potentially cost-beneficial.
- 2 (b) First risk reduction value reflects results of changes made to the internal events PRA model and second risk reduction value reflects results of
- 3 changes made to the external flooding PRA model (AmerGen 2008a).
- 4 (c) Estimated benefits reflect revised values provided after correction of SECPOP2000 errors, as reported in Section E.7.6.5 of the ER (AmerGen
- 5 2008a). Reported benefit values account for risk reduction in internal events, external floods, and other external events, including fire and
- 6 seismic events.
- 7 (d) IE: internal events; EF: external flooding events; FE: fire events; SE: seismic events.
- 8 (e) Analysis and results for risk reduction estimates provided in response to NRC staff RAI 6.i (AmerGen 2008b).
- 9 (f) Values estimated by NRC staff using data available in the ER (AmerGen 2008a) and provided in response to RAIs (AmerGen 2008b).
- 10 (g) Analysis and results for risk reduction estimates provided in response to NRC staff RAI 6.f (AmerGen 2008b).

1 **F.5 Cost Impacts of Candidate Plant Improvements**

2 AmerGen estimated the costs of implementing the 33 candidate SAMAs through the application  
3 of engineering judgment and use of other licensees' estimates for similar improvements. The  
4 cost estimates conservatively did not include the cost of replacement power during extended  
5 outages required to implement the modifications, nor did they generally include contingency  
6 costs associated with unforeseen implementation obstacles (AmerGen 2008a, AmerGen  
7 2008b). The cost estimates provided in the ER did not account for inflation, which is considered  
8 another conservatism.

9 The NRC staff reviewed the bases for the applicant's cost estimates (presented in Section E.6  
10 of Attachment E to the ER). For certain improvements, the NRC staff also compared the cost  
11 estimates to estimates developed elsewhere for similar improvements, including estimates  
12 developed as part of other licensees' analyses of SAMAs for operating reactors and advanced  
13 light-water reactors. In response to an RAI requesting a more detailed description of the  
14 changes associated with SAMAs 1, 2, 3, 5, 6, 10, 11, 14, 15, 20, 21, 26, 27, 29, 29, 31, 32, and  
15 33, AmerGen provided additional information detailing the analysis and plant modifications  
16 included in the cost estimate of each improvement (AmerGen 2008b). The staff reviewed the  
17 costs and found them to be reasonable, and generally consistent with estimates provided in  
18 support of other plants' analyses.

19 The NRC staff requested additional clarification on the estimated cost of \$950,000 for  
20 implementation of SAMAs 13 and 17 and \$1,100,000 for implementation of SAMA 16, which  
21 seem high for what appear to be just logic changes (NRC 2008a). In response to the RAI,  
22 AmerGen further described these modifications as involving the design, procurement, and  
23 installation of hardware, simulator modifications, and changes to procedures and training  
24 (AmerGen 2008b). Based on this additional information, the NRC staff considers these  
25 estimated costs to be reasonable and acceptable for purposes of the SAMA evaluation.

26 The NRC staff concludes that the cost estimates provided by AmerGen are sufficient and  
27 appropriate for use in the SAMA evaluation.  
28

29 **F.6 Cost-Benefit Comparison**

30 AmerGen's cost-benefit analysis and the NRC staff's review are described in the following  
31 sections.

32 **F.6.1 AmerGen's Evaluation**

33 The methodology used by AmerGen was based primarily on NRC's guidance for performing  
34 cost-benefit analysis, i.e., NUREG/BR-0184, *Regulatory Analysis Technical Evaluation*  
35 *Handbook* (NRC 1997a). The guidance involves determining the net value for each SAMA  
36 according to the following formula:  
37

38 
$$\text{Net Value} = (\text{APE} + \text{AOC} + \text{AOE} + \text{AOSC}) - \text{COE}$$
 where,

## Appendix F

1           APE = present value of averted public exposure (\$)

2           AOC = present value of averted offsite property damage costs (\$)

3           AOE = present value of averted occupational exposure costs (\$)

4           AOSC = present value of averted onsite costs (\$)

5           COE = cost of enhancement (\$).

6 If the net value of a SAMA is negative, the cost of implementing the SAMA is larger than the  
7 benefit associated with the SAMA and it is not considered cost-beneficial. AmerGen's  
8 derivation of each of the associated costs is summarized below.

9 NUREG/BR-0058 has recently been revised to reflect the agency's policy on discount rates.  
10 Revision 4 of NUREG/BR-0058 states that two sets of estimates should be developed, one at 3  
11 percent and one at 7 percent (NRC 2004a). AmerGen performed the SAMA analysis using only  
12 a 3 percent discount rate (AmerGen 2008a) and based its decisions on potentially cost-  
13 beneficial SAMAs on these values.

### 14 Averted Public Exposure (APE) Costs

15 The APE costs were calculated using the following formula:

16           APE = Annual reduction in public exposure ( $\Delta$  person-rem per year)  
17           x monetary equivalent of unit dose (\$2000 per person-rem)  
18           x present value conversion factor (15.04 based on a 20-year period with a  
19           3-percent discount rate).

20 As stated in NUREG/BR-0184 (NRC 1997a), it is important to note that the monetary value of  
21 the public health risk after discounting does not represent the expected reduction in public  
22 health risk due to a single accident. Rather, it is the present value of a stream of potential  
23 losses extending over the remaining lifetime (in this case, the renewal period) of the facility.  
24 Thus, it reflects the expected annual loss due to a single accident, the possibility that such an  
25 accident could occur at any time over the renewal period, and the effect of discounting these  
26 potential future losses to present value. For the purposes of initial screening, which assumes  
27 elimination of all severe accidents due to internal and external flooding events, AmerGen  
28 calculated an APE of approximately \$972,000 for internal events and \$5,290,000 for external  
29 flooding events for the 20-year license renewal period (AmerGen 2008b).

### 30 Averted Offsite Property Damage Costs (AOC)

31 The AOCs were calculated using the following formula:

32           AOC = Annual CDF reduction  
33           x offsite economic costs associated with a severe accident (on a per-event basis)  
34           x present value conversion factor.

35 For the purposes of initial screening, which assumes all severe accidents due to internal and  
36 external flooding events are eliminated, AmerGen calculated an annual offsite economic risk of

1 about \$129,000 for internal events and \$620,000 for external flooding events based on the  
2 Level 3 risk analysis. This results in a discounted value of approximately \$1,940,000 for internal  
3 events and \$9,320,000 for external flooding events for the 20-year license renewal period  
4 (AmerGen 2008b).

#### 5 Averted Occupational Exposure (AOE) Costs

6 The AOE costs were calculated using the following formula:

$$\begin{aligned} &7 \quad \text{AOE} = \text{Annual CDF reduction} \\ &8 \quad \quad \times \text{occupational exposure per core damage event} \\ &9 \quad \quad \times \text{monetary equivalent of unit dose} \\ &10 \quad \quad \times \text{present value conversion factor.} \end{aligned}$$

11 AmerGen derived the values for averted occupational exposure from information provided in  
12 Section 5.7.3 of the regulatory analysis handbook (NRC 1997a). Best estimate values provided  
13 for immediate occupational dose (3300 person-rem) and long-term occupational dose (20,000  
14 person-rem over a 10-year cleanup period) were used. The present value of these doses was  
15 calculated using the equations provided in the handbook in conjunction with a monetary  
16 equivalent of unit dose of \$2000 per person-rem, a real discount rate of 3 percent, and a time  
17 period of 20 years to represent the license renewal period. For the purposes of initial screening,  
18 which assumes all severe accidents due to internal and external flooding events are eliminated,  
19 AmerGen calculated an AOE of approximately \$15,000 for internal events and \$50,000 for  
20 external flooding events for the 20-year license renewal period (AmerGen 2008b).

#### 21 Averted Onsite Costs

22 Averted onsite costs (AOSC) include averted cleanup and decontamination costs and averted  
23 power replacement costs. Repair and refurbishment costs are considered for recoverable  
24 accidents only and not for severe accidents. AmerGen derived the values for AOSC based on  
25 information provided in Section 5.7.6 of NUREG/BR-0184, the regulatory analysis handbook  
26 (NRC 1997a).

27 AmerGen divided this cost element into two parts – the onsite cleanup and decontamination  
28 cost, also commonly referred to as averted cleanup and decontamination costs, and the  
29 replacement power cost.

30 Averted cleanup and decontamination costs (ACC) were calculated using the following formula:

$$\begin{aligned} &31 \quad \text{ACC} = \text{Annual CDF reduction} \\ &32 \quad \quad \times \text{present value of cleanup costs per core damage event} \\ &33 \quad \quad \times \text{present value conversion factor.} \end{aligned}$$

34 The total cost of cleanup and decontamination subsequent to a severe accident is estimated in  
35 the regulatory analysis handbook to be  $\$1.5 \times 10^9$  (undiscounted). This value was converted to  
36 present costs over a 10-year cleanup period and integrated over the term of the proposed  
37 license extension. For the purposes of initial screening, which assumes all severe accidents  
38 due to internal and external flooding events are eliminated, AmerGen calculated an ACC of  
39 approximately \$462,000 for internal events and \$1,580,000 for external flooding events for the  
40 20-year license renewal period (AmerGen 2008b).

## Appendix F

1 Long-term replacement power costs (RPC) were calculated using the following formula:

2       RPC = Annual CDF reduction  
3       x present value of replacement power for a single event  
4       x factor to account for remaining service years for which replacement power is  
5       required  
6       x reactor power scaling factor

7 AmerGen based its calculations on the value of 875 megawatt electric (MWe). Therefore,  
8 AmerGen applied a power scaling factor of 875/910 (the ratio of the actual power level to the  
9 “generic” plant power level in NUREG/BR-0184) to determine the replacement power costs. For  
10 the purposes of initial screening, which assumes all severe accidents due to internal and  
11 external flooding events are eliminated, AmerGen calculated an RPC of approximately  
12 \$126,000 for internal events and \$431,000 for external flooding events for the 20-year license  
13 renewal period (AmerGen 2008b). For the purposes of initial screening, which assumes all  
14 severe accidents due to internal and external flooding events are eliminated, AmerGen  
15 calculated the AOSC to be approximately \$588,000 for internal events and \$2,010,000 for  
16 external flooding events for the 20-year license renewal period.

17 Using the above equations, AmerGen estimated the total present dollar value equivalent  
18 associated with completely eliminating severe accidents from internal and external flooding  
19 events at TMI-1 to be about \$3.5M and \$16.7M, respectively, for a total of \$20.2M. Use of a  
20 multiplier of 2 to the internal events benefits (to account for external events other than external  
21 flooding events) increases the value to \$23.7M and represents the dollar value associated with  
22 completely eliminating all internal and external event severe accident risk at TMI-1, also referred  
23 to as the Modified Maximum Averted Cost Risk (MMACR).

### 24 AmerGen's Results

25 If the implementation costs for a candidate SAMA exceeded the calculated benefit, the SAMA  
26 was considered not to be cost-beneficial. In the baseline analysis contained in the ER (using a  
27 3 percent discount rate), AmerGen identified nine potentially cost-beneficial SAMAs. The  
28 potentially cost-beneficial SAMAs are:

- 29       • SAMA 8 – Automate reactor coolant pump trip on high motor bearing cooling  
30       temperature.
- 31       • SAMA 11 – Enhance extreme external flooding mitigation equipment to address SBO  
32       and loss of RCP seal cooling scenarios.
- 33       • SAMA 12 – Use the decay heat removal (DHR) system as an alternate suction source  
34       for HPI.
- 35       • SAMA 16 – Automate HPI injection on low pressurizer level.
- 36       • SAMA 19 – Install battery backed hydrogen igniters or a passive hydrogen ignition  
37       system.
- 38       • SAMA 21 – Install concrete shields to block direct pathways from the reactor pressure  
39       vessel (RPV) to the containment wall and/or direct containment flooding early in external  
40       flooding scenarios.
- 41       • SAMA 27 – Improve the 480V AC load center welds.
- 42       • SAMA 32 – Pre-stage severe external flooding equipment.



- 1 • SAMA 33 – Increase the flood protection height.

2  
3 AmerGen performed additional analyses to evaluate the impact of parameter choices and  
4 uncertainties on the results of the SAMA assessment (AmerGen 2008a). If the benefits are  
5 increased by a factor of 2.75 to account for uncertainties, six additional SAMA candidates were  
6 determined to be potentially cost-beneficial:

- 7 • SAMA 2 – Install damage-resistant high temperature RCP seals with a portable 480V  
8 AC generator for extended EFW operation.
- 9 • SAMA 7 – Use fire service water as an alternate cooling source for the intermediate  
10 closed cooling water (ICCW) heat exchangers.
- 11 • SAMA 15 – Automate swap to recirculation mode.
- 12 • SAMA 23 – Develop alarm response procedures to direct operation of RR-V-5 on low  
13 reactor building emergency cooling (RBEC) flow.
- 14 • SAMA 24 – Install damage resistant high temperature RCP seals with a diesel engine as  
15 an alternate drive for an EFW pump and a portable 480V AC generator for extended  
16 EFW operation.
- 17 • SAMA 26 – Reroute cables so that they do not pass over ignition sources in fire zone  
18 CB-FA-2e or wrap them in fire proof material.

19  
20 These results, and the population dose and SAMA benefit estimates reported in the present  
21 document (e.g., in Tables F-2 and F-5), reflect corrections to previously identified SECPOP2000  
22 errors (AmerGen 2008a, AmerGen 2008b).

23 AmerGen also performed a sensitivity analysis of SAMA 10, automate BWST refill, assuming  
24 the current manual BWST refill capability only delayed core damage, not prevented core  
25 damage as assumed in the baseline analysis (AmerGen 2008a). Based on this sensitivity  
26 analysis, SAMA 10 was determined to be potentially cost-beneficial.

27 In response to an RAI, AmerGen provided a sensitivity analysis of SAMAs 13 and 22 also  
28 assuming manual BWST refill capability only delayed, not prevented, core damage (AmerGen  
29 2008b). The sensitivity analysis resulted in identification of SAMA 13 being potentially cost-  
30 beneficial.

31 The potentially cost-beneficial SAMAs, and AmerGen's plans for further evaluation of these  
32 SAMAs are discussed in more detail in Section F.6.2.

### 33 34 **F.6.2 Review of AmerGen's Cost-Benefit Evaluation**

35 The cost-benefit analysis performed by AmerGen was based primarily on NUREG/BR-0184  
36 (NRC 1997a) and was executed consistent with this guidance.

37 NUREG/BR-0058 has recently been revised to reflect the agency's policy on discount rates.  
38 Revision 4 of NUREG/BR-0058 states that two sets of estimates should be developed, one at 3  
39 percent and one at 7 percent (NRC 2004a). AmerGen performed the SAMA analysis using only  
40 a 3 percent discount rate (AmerGen 2008a) and based its decisions on potentially cost-  
41 beneficial SAMAs on these values. SAMA benefits produced using a 3 percent discount rate

## Appendix F

1 are greater than those produced using a 7 percent discount rate, and would tend to result in  
2 identification of a greater number of potentially cost-beneficial SAMAs. Since use of a 3 percent  
3 discount rate is conservative, the NRC staff concludes that use of only a 3 percent discount rate  
4 in the cost-benefit analysis is acceptable for the purposes of the SAMA evaluation.

5 SAMAs identified primarily on the basis of the internal events analysis could provide benefits in  
6 certain external events, in addition to their benefits in internal events. To account for the  
7 additional benefits in external events, AmerGen: (1) multiplied the internal event benefits by a  
8 factor of two for each SAMA, except those SAMAs that specifically address fire and seismic risk  
9 (SAMAs 26 through 31), and (2) separately estimated the benefits of reducing the risk of  
10 external floods for each SAMA using the external flooding risk model and an approach similar to  
11 that for internal events. Doubling the internal event estimate for SAMAs 26 through 31, or  
12 including a benefit for reducing external flooding risk would not be appropriate because these  
13 SAMAs are specific to fire and seismic risks and would not have a corresponding benefit on the  
14 risk from internal or external flooding events.

15 The NRC staff notes that using AmerGen's adjusted seismic and fire CDF values, the total CDF  
16 for non-flooding external events ( $4.56 \times 10^{-5}$  per year) is approximately twice the internal events  
17 CDF. This would suggest that the internal events benefits be tripled rather than doubled to  
18 account for additional SAMA benefits in external events. However, there are several  
19 considerations that support the use of a lower external events multiplier, as summarized below.

- 20 • The external event CDF may be lower due to remaining conservatisms in the analysis.  
21 The seismic, fire, and high winds analyses were performed in support of the IPEEE, well  
22 before the current TMI-1 internal events PRA, and vary in their degree of completeness  
23 and conservatism. The general trend in PRA development since the IPEEE has been to  
24 remove conservative modeling practices as better techniques for assessing risk are  
25 developed. Recognizing the level of conservatism in the earlier analyses and the fact  
26 that seismic improvements implemented since the IPEEE are not accounted for in the  
27 seismic CDF, the NRC staff agrees with AmerGen's claim that the CDF for non-flooding  
28 external events would likely be lower than reported above.  
29
- 30 • The significance of the external events multiplier is diminished by separate quantification  
31 of SAMA benefits in external floods and by consideration of additional SAMAs targeted  
32 specifically to seismic and fire events. AmerGen separately assessed the benefits that  
33 internal events-related SAMAs would provide in external flooding events (which are the  
34 largest risk contributors at TMI-1), and separately quantified the benefits of seismic- and  
35 fire-related SAMAs. The external events multiplier reflects only the additional benefits  
36 that internal events-related SAMAs provide in seismic and fire events. Use of an  
37 external events multiplier implicitly assumes that each SAMA would offer the same  
38 percentage reduction in external event CDF and population dose as it offers in internal  
39 events. However, internal events-related SAMAs would likely have smaller benefits in  
40 seismic and fire events than in internal events, and smaller benefits than external event-  
41 related SAMAs would have in external events. Thus, the use of a somewhat lower  
42 external events multiplier is reasonable.  
43

- 1       • The benefits of additional SAMAs would be reduced by implementation of the currently  
2 identified cost-beneficial SAMAs. AmerGen evaluated the impact on the SAMA results if  
3 the estimated total benefits (internal and external events) were increased by a factor of  
4 2.75, and included any additional potentially cost-beneficial SAMAs identified in this  
5 analysis within the set of SAMAs that they intend to examine further for implementation.  
6 AmerGen's SAMA analysis resulted in identification of 17 potentially cost-beneficial  
7 SAMAs in seven unique categories. Although use of a higher external events multiplier  
8 (in the baseline and uncertainty analyses) might result in identification of additional  
9 potentially cost-beneficial SAMAs, the currently identified SAMAs would have a greater  
10 net value, and implementation of the most cost-effective SAMAs from the set of 17  
11 would likely reduce the benefits of any additional SAMAs to the degree that they are no  
12 longer cost beneficial.

13  
14 In consideration of the above factors, the NRC staff concludes that AmerGen's use of a  
15 multiplier of two in evaluating internal event-related SAMAs is reasonable for the purposes of  
16 the SAMA evaluation.

17 The NRC staff notes that of the nine SAMAs determined to be cost-beneficial in the baseline  
18 analysis, two of these, SAMAs 19 and 21, improve containment performance but do not impact  
19 CDF, and that similar SAMAs have not been found to be cost-beneficial in previous SAMA  
20 evaluations for PWR plants. As with previously evaluated PWR plants, these SAMAs also  
21 would not be cost-beneficial if just considering the benefit associated with internal events risk  
22 reduction (and multiplier accounting for non-flooding external events); the significant additional  
23 benefit associated with reduction of external flooding risk makes these SAMAs cost-beneficial at  
24 TMI-1. The relatively high estimated benefits for these SAMAs are the result of early  
25 containment failure due to SBO events caused by external flooding. The NRC staff found the  
26 evaluation of these SAMAs to be reasonable.

27 AmerGen considered the impact that possible increases in benefits from analysis uncertainties  
28 would have on the results of the SAMA assessment. In the ER, Entergy presents the results of  
29 an uncertainty analysis of the internal events CDF which indicates that the 95<sup>th</sup> percentile value  
30 is a factor of 2.75 times the point estimate CDF. AmerGen considered whether any additional  
31 Phase I SAMAs might be retained for further analysis if the benefits (and MMACR) were  
32 increased by a factor of 2.75. However, since no SAMAs were screened from further analysis  
33 during the Phase I screening, the use of the 95<sup>th</sup> percentile CDF has no impact on the Phase I  
34 analysis.

35 AmerGen also considered the impact on the Phase II screening if the estimated benefits were  
36 increased by a factor of 2.75 (in addition to the multiplier of 2 for external events other than  
37 external floods). Six additional SAMAs became cost-beneficial in AmerGen's analysis (SAMAs  
38 2, 7, 15, 23, 24, and 26, as described above). Although not cost-beneficial in the baseline  
39 analysis, AmerGen included these six SAMAs within the set of potentially cost-beneficial  
40 SAMAs that they intend to examine further for implementation.

41 AmerGen did not develop a cost-risk analysis for three Phase II SAMAs:

- 42  
43       • SAMA 4 – Provide alternate power to HPI pump minimum flow recirculation valves MU-  
44 V-36 and MU-V-37,

## Appendix F

- 1 • SAMA 9 – Proceduralize local ADV operation, and
- 2 • SAMA 31 – Modify specific containment penetration MOVs to fail closed.

3  
4 In the ER, AmerGen noted that the only events that could cause the valves in SAMA 4 to be  
5 “stranded closed” are those in which power was available to close the valves when directed by  
6 an engineered safeguards actuation signal (ESAS) and then power was lost before the valves  
7 could be re-opened prior to failure of the HPI pumps, which corresponds to an available time of  
8 45 minutes out of 24 hours. To address this issue, AmerGen modified the fault tree to include a  
9 new basic event representing the fraction of time available to re-open the valves. For SAMA 9,  
10 AmerGen noted that TMI-1 already has procedures to perform local ADV operations that are not  
11 credited in the PRA model. To address this issue, AmerGen assigned a human error probability  
12 of 0.1 for the basic event representing local ADV operation. For both SAMAs 4 and 9,  
13 AmerGen’s analysis showed that both the CDF and LERF based RRW for the basic events is  
14 below the review cutoff of 1.01 for identifying and assessing SAMAs. For SAMA 31, AmerGen  
15 noted the estimated cost to replace existing isolation valves with “fail closed” AOVs was greater  
16 than the maximum averted cost risk for seismic events. The benefits of these SAMAs were  
17 therefore not evaluated. The NRC staff found this rationale to be reasonable.

18 AmerGen also provided the results of additional sensitivity analyses in the ER, including  
19 variations in MACCS2 input assumptions, assumptions regarding BWST refill capability and  
20 extreme flooding mitigation capability, and the impact of implementing SAMA 32 (pre-stage  
21 severe external flooding equipment) on the other potentially cost-beneficial SAMAs. The  
22 analyses of the variation in MACCS2 input assumptions and extreme flooding mitigation  
23 capability assumptions did not identify any additional potentially cost-beneficial SAMAs beyond  
24 those already identified through the uncertainty analysis.

25 The baseline SAMA analysis contained in the ER assumes that manual BWST refill is capable  
26 of preventing core damage for SGTR events at TMI-1. AmerGen indicated in the ER that the  
27 validity of this assumption has recently been called into question, and therefore included in the  
28 ER an additional evaluation of SAMA 10 assuming the current capability only delayed, not  
29 prevented, core damage (AmerGen 2008a). Based on these results, SAMA 10 was determined  
30 to be potentially cost-beneficial, but was not included among the set of potentially cost-beneficial  
31 SAMAs identified in the ER. In response to an NRC staff request for clarification regarding  
32 AmerGen’s plans for enhancement of the BWST refill capability, the licensee indicated that the  
33 SAMA process, in conjunction with other plant analyses, has identified the limited BWST refill  
34 capability as a potential area for improvement at TMI-1, and that this issue has been captured in  
35 the TMI-1 Corrective Action Program. AmerGen further stated that while the SAMA analysis  
36 does not explicitly evaluate the costs and benefits associated with only enhancing the existing  
37 manual capability, this potential option will be considered further in conjunction with the  
38 automation of the BWST refill function, i.e., SAMA 10 (AmerGen 2008b).

39 The NRC staff asked the licensee to identify and re-assess any other SAMAs that may be  
40 impacted by the BWST manual refill capability assumption (NRC 2008a). In their response to  
41 the RAI, AmerGen stated that only those SAMAs that significantly impacted SGTR frequency  
42 would be impacted by this assumption, specifically SAMAs 2, 11, 13, 16, 22, and 24. Of these,  
43 SAMAs 2, 11, 16, and 24 were already identified as being potentially cost-beneficial and were  
44 not evaluated further. AmerGen re-assessed the benefits of SAMAs 13 and 22 assuming the

1 current BWST refill capability only delayed, not prevented, core damage. Based on this re-  
2 assessment SAMA 13, change IA system logic to automatically start IA-P-1A/B after a low  
3 voltage trip in conjunction with an ESAS, would be potentially cost-beneficial (AmerGen 2008b).

4 The NRC staff notes that given the impact of BWST refill capability on the estimated benefits for  
5 many of these potentially cost-beneficial SAMAs, it would be prudent for AmerGen to either  
6 resolve the BWST issue prior to performing the more detailed evaluation of these SAMAs, or to  
7 conservatively assume that the current manual BWST refill capability is not effective when  
8 evaluating the potentially cost-beneficial SAMAs for implementation.

9 In summary, the NRC staff notes that the 15 potentially cost-beneficial SAMAs (SAMAs 2, 7, 8,  
10 11, 12, 15, 16, 19, 21, 23, 24, 26, 27, 32, and 33) identified in either AmerGen's baseline  
11 analysis, or uncertainty analysis, are included within the set of SAMAs that AmerGen will  
12 consider further for implementation (AmerGen 2008a). In response to an RAI by the NRC staff  
13 (NRC 2008a), AmerGen stated that SAMAs 10 and 13 would also be included within the set of  
14 SAMAs to be considered for implementation (NRC 2008b).

15 In the ER, AmerGen evaluated the impact of implementing SAMA 32, pre-stage severe external  
16 flooding equipment, on the benefit estimate for the other potentially cost-beneficial SAMAs.  
17 Since SAMA 32 addresses external flooding risk only, implementing this SAMA has no effect on  
18 the internal events model and associated benefit results for the other cost-beneficial SAMAs,  
19 nor does it have any affect on non-external flooding external events and those SAMAs identified  
20 to specifically address seismic and fire risk. This sensitivity analysis was performed for the  
21 baseline case assumptions with uncertainty (the most conservative case) and resulted in one  
22 previously identified potentially cost-beneficial SAMA, SAMA 21, no longer being cost-beneficial.

23 In light of the many potentially cost-beneficial SAMAs identified in the ER, the NRC staff asked  
24 AmerGen to identify those SAMAs having higher priority for being considered for  
25 implementation based on risk reduction potential and implementation cost, and which SAMAs  
26 would no longer be cost-beneficial if these higher priority SAMAs were implemented (NRC  
27 2008a). In response to the RAI (AmerGen 2008b), AmerGen performed a qualitative  
28 assessment to prioritize the cost-beneficial SAMAs into a "minimal SAMA set" addressing the  
29 most significant risk contributors. Those SAMAs determined to have the most cost-effective risk  
30 reduction potential for each of the major risk areas defined the "minimal SAMA set." Other cost-  
31 beneficial SAMAs were assigned to the "minimal SAMA set" category best representing the risk  
32 contributors each is mitigating. AmerGen determined that SAMAs 32 and 2 would have the  
33 highest priority based on their potential for significant reduction in risk (and relatively low  
34 implementation cost in the case of SAMA 32). AmerGen further identified SAMAs 12, 15, 16,  
35 26, and 27 as a second tier priority based on their mitigation of plant risk contributors not  
36 addressed by SAMAs 32 and 2. The remaining cost-beneficial SAMAs were grouped into one  
37 of these seven high priority groups. The impact of these remaining potentially cost-beneficial  
38 SAMAs is expected to be reduced significantly if the higher priority SAMAs are implemented.  
39 The NRC considers this approach for prioritizing SAMAs to be reasonable.

40 The NRC staff concludes that, with the exception of the potentially cost-beneficial SAMAs  
41 discussed above, the costs of the other SAMAs evaluated would be higher than the associated  
42 benefits.  
43

1 **F.7 Conclusions**

2 AmerGen compiled a list of 33 SAMAs based on a review of the most significant basic events  
3 from the plant-specific PRA, insights from the plant-specific IPE and IPEEE, Phase II SAMAs  
4 from license renewal applications for other plants, and review of other NRC and industry  
5 documentation. An initial screening was performed to remove SAMA candidates that (1) were  
6 not applicable at TMI-1 due to design differences or (2) had estimated costs that would exceed  
7 the dollar value associated with completely eliminating all severe accident risk at TMI-1. Based  
8 on this screening, no SAMAs were eliminated leaving all 33 candidate SAMAs for evaluation.

9 For the remaining SAMA candidates, a more detailed evaluation was performed as shown in  
10 Table F-6. The cost-benefit analyses showed that nine of the SAMA candidates were  
11 potentially cost-beneficial in the baseline analysis (SAMAs 8, 11, 12, 16, 19, 21, 27, 32, and 33).  
12 AmerGen performed additional analyses to evaluate the impact of parameter choices and  
13 uncertainties on the results of the SAMA assessment. As a result, six additional SAMAs  
14 (SAMAs 2, 7, 15, 23, 24, and 26) were identified as potentially cost-beneficial. AmerGen further  
15 identified SAMA 10 as being potentially cost-beneficial based on the results of a sensitivity  
16 analysis. In addition, as a result of the NRC staff review, AmerGen concluded that SAMA 13  
17 was also potentially cost-beneficial. AmerGen has indicated that all of these SAMAs (SAMAs 2,  
18 7, 8, 10, 11, 12, 13, 15, 16, 19, 21, 23, 24, 26, 27, 32, and 33) will be considered further for  
19 implementation.

20 The NRC staff reviewed the AmerGen analysis and concludes that the methods used and the  
21 implementation of those methods were sound. The treatment of SAMA benefits and costs  
22 support the general conclusion that the SAMA evaluations performed by AmerGen are  
23 reasonable and sufficient for the license renewal submittal. Although the treatment of SAMAs  
24 for external events was somewhat limited, the likelihood of there being cost-beneficial  
25 enhancements in this area was minimized by improvements that have been realized as a result  
26 of the IPEEE process, separate analysis of external flooding events, and inclusion of a multiplier  
27 to account for external events.

28 The NRC staff concurs with AmerGen's identification of areas in which risk can be further  
29 reduced in a cost-beneficial manner through the implementation of the identified, potentially  
30 cost-beneficial SAMAs. Given the potential for cost-beneficial risk reduction, the NRC staff  
31 agrees that further evaluation of these SAMAs by AmerGen is warranted. However, these  
32 SAMAs do not relate to adequately managing the effects of aging during the period of extended  
33 operation. Therefore, they need not be implemented as part of license renewal pursuant to Title  
34 10 of the *Code of Federal Regulations*, Part 54.  
35

36 **F.8 References**

37 AmerGen (AmerGen Energy Company, LLC). 2008a. "Three Mile Island Nuclear Station,  
38 Applicant's Environmental Report, License Renewal Operating Stage." Kennett Square,  
39 Pennsylvania. ADAMS Accession Nos. ML080220255, ML080220257, ML080220261, and  
40 ML080220282.

- 1 AmerGen (AmerGen Energy Company, LLC). 2008b. Letter from Michael P. Gallagher,  
2 AmerGen Energy Company, LLC, to U.S. Nuclear Regulatory Commission Document Control  
3 Desk. Subject: "Response to NRC Request for Additional Information Related to Three Mile  
4 Island Nuclear Station 1 License Renewal Application (TAC No. MD7702)," dated July 17, 2008.  
5 ADAMS No. ML082040144.
- 6 ETI (Earth Tech, Inc.). 2003. "Evacuation Time Estimates for the Three Mile Island Station  
7 Emergency Planning Zone". July 2003.
- 8 EPRI (Electric Power Research Institute). 1989. "Probabilistic Seismic Hazard Evaluation at  
9 Nuclear Plant Sites in the Central and Eastern United States: Resolution of the Charleston  
10 Issue," EPRI NP-6395-DI, Palo Alto, CA, April 1989.
- 11 Exelon (Exelon Corporation). 2007a. *TMI PRA Notebook, TMI-PRA-014 Quantification  
12 Notebook, TMI PRA Model 2004 Revision 2*, May 2007.
- 13 Exelon (Exelon Corporation). 2007b. *TMI PRA Notebook, TMI-PRA-015.2 Level 2 Containment  
14 Event Tree Analysis Notebook, TMI PRA Model 2004 Revision 2*, May 2007.
- 15 GPU (GPU Nuclear Corporation). 1993. Letter from T. G. Broughton, GPU, to U.S. NRC.  
16 Subject: Three Mile Island Nuclear Generation Station, Unit 1 (TMI-1), Operating License No.  
17 DPR-50, Docket No. 50-289, Response to Generic Letter 88-20, "Individual Plan Examinations  
18 for Severe Accident Vulnerabilities (IPE)". May 20, 1993.
- 19 GPU (GPU Nuclear Corporation). 1994. Letter from R. W. Keaten, GPU, to U.S. NRC.  
20 Subject: Three Mile Island Nuclear Generation Station, Unit 1 (TMI-1), Operating License No.  
21 DPR-50, Docket No. 50-289, Response to Generic Letter 88-20, Supplement 4, "Individual Plan  
22 Examination of External Events (IPEEE) for Severe Accident Vulnerabilities". December 29,  
23 1994.
- 24 Kennedy, Robert P. 1999. "Overview of Methods for Seismic PRA and Margin Analysis  
25 Including Recent Innovations". Proceedings of the OECD-NEA Workshop on Seismic Risk,  
26 Tokyo, Japan, August 1999.
- 27 NRC (U.S. Nuclear Regulatory Commission). 1988. Generic Letter 88-20, "Individual Plant  
28 Examination for Severe Accident Vulnerabilities," November 23, 1988.
- 29 NRC (U.S. Nuclear Regulatory Commission). 1990a. *Evaluation of Severe Accident Risks:  
30 Quantification of Major Input Parameters*. NUREG/CR-4551, Vol. 2, Rev. 1, Part 7, Washington,  
31 D.C.
- 32 NRC (U.S. Nuclear Regulatory Commission). 1990b. *Severe Accident Risks: An Assessment  
33 for Five U.S. Nuclear Power Plants*. NUREG-1150, Washington, D.C.
- 34 NRC (U.S. Nuclear Regulatory Commission). 1991. "Procedural and Submittal Guidance for the  
35 Individual Plant Examination of External Events (IPEEE) for Severe Accident Vulnerabilities,"  
36 NUREG-1407, Washington, D.C, June 1991.
- 37 NRC (U.S. Nuclear Regulatory Commission). 1994. "Revised Livermore Seismic Hazard  
38 Estimates for 69 Nuclear Power Plant Sites East of the Rocky Mountains," NUREG-1488,  
39 Washington, D.C., April 1994.

## Appendix F

- 1 NRC (U.S. Nuclear Regulatory Commission). 1996. "Review of Three Mile Island, Unit 1,  
2 Individual Plant Examination Submittal, (TAC No. M74480)," Washington, D.C., December 19,  
3 1996.
- 4 NRC (U.S. Nuclear Regulatory Commission). 1997a. *Regulatory Analysis Technical Evaluation*  
5 *Handbook*. NUREG/BR-0184, Washington, D.C.
- 6 NRC (U.S. Nuclear Regulatory Commission). 1997b. *Individual Plant Examination Program:*  
7 *Perspectives on Reactor Safety and Plant Performance*. NUREG-1560, Washington, D.C.
- 8 NRC (U.S. Nuclear Regulatory Commission). 1998a. *Code Manual for MACCS2: User's*  
9 *Guide*. NUREG/CR-6613, Vol. 1, Washington, D.C.
- 10 NRC (U.S. Nuclear Regulatory Commission). 1998b. *Common-Cause Failure Parameter*  
11 *Estimations*. NUREG/CR-5497, Washington, D.C.
- 12 NRC (U.S. Nuclear Regulatory Commission). 1998c. "Safety Evaluation Report for USI A-46  
13 Program Implementation at Three Mile Island Unit 1 (TAC No. M69486)," Washington, D.C.,  
14 August 12, 1998.
- 15 NRC (U.S. Nuclear Regulatory Commission). 1999. "Review of Three Mile Island Nuclear  
16 Station, Unit 1 (TMI-1) Individual Plant Examination of External Events (IPEEE) Submittal (TAC  
17 Nos. M83685)," Washington, D.C., July 9, 1999.
- 18 NRC (U.S. Nuclear Regulatory Commission). 2003. *SECPOP2000: Sector Population, Land*  
19 *Fraction, and Economic Estimation Program*. NUREG/CR-6525, Rev. 1, Washington, D.C.
- 20 NRC (U.S. Nuclear Regulatory Commission). 2004. *Regulatory Analysis Guidelines of the U.S.*  
21 *Nuclear Regulatory Commission*. NUREG/BR-0058, Rev. 4, Washington, D.C.
- 22 NRC (U.S. Nuclear Regulatory Commission). 2008a. Letter from Sarah Lopas, U.S. NRC, to  
23 Michael P. Gallagher, AmerGen Energy Company, LLC. Subject: "Request for Additional  
24 Information Regarding Severe Accident Mitigation Alternatives for Three Mile Island Nuclear  
25 Station Unit 1, License Renewal (TAC No. MD7702)," May 21, 2008. ADAMS No.  
26 ML081330714.
- 27 NRC (U.S. Nuclear Regulatory Commission). 2008b. Letter from Sarah Lopas, U.S. NRC, to  
28 AmerGen Energy Company, LLC. Subject: "Summary of Conference Call with AmerGen  
29 Energy Company, LLC, to Discuss Responses to Severe Accident Mitigation Alternatives  
30 Request for Additional Information for Three Mile Island Nuclear Station Unit 1 (TAC No.  
31 MD7702)," September 8, 2008. ADAMS No. ML082340226.
- 32 USDA (U.S. Department of Agriculture). 1998. "1997 Census of Agriculture," National  
33 Agriculture Statistics Service, 1998. Available URL:  
34 <http://www.nass.usda.gov/census/census97/volume1/vol1pubs.htm>.



**BIBLIOGRAPHIC DATA SHEET**

(See instructions on the reverse)

NUREG-1437, Supplement 37

2. TITLE AND SUBTITLE

Generic Environmental Impact Statement for License Renewal of Nuclear Plants (GEIS)  
Supplement 37  
Regarding Three Mile Island Nuclear Station, Unit 1  
Draft Report for Comment

3. DATE REPORT PUBLISHED

MONTH

YEAR

December

2008

4. FIN OR GRANT NUMBER

5. AUTHOR(S)

See Chapter 10 of Report

6. TYPE OF REPORT

Technical

7. PERIOD COVERED (Inclusive Dates)

8. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC, provide Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)

Division of License Renewal  
Office of Nuclear Reactor Regulation,  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555-0001

9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC, type "Same as above"; if contractor, provide NRC Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address.)

Same as 8 Above.

10. SUPPLEMENTARY NOTES

Docekt No. 50-000289

11. ABSTRACT (200 words or less)

This supplemental environmental impact statement (EIS) has been prepared in response to an application submitted by AmerGen Energy Company, LLC (AmerGen) to the Nuclear Regulatory Commission (NRC) to renew the operating license for Three Mile Island Nuclear Station, Unit 1 (TMI-1), for an additional 20 years under 10 CFR Part 54. The supplemental EIS includes the NRC's analysis that considers and weighs the environmental impacts of the proposed action, the environmental impacts of alternatives to the proposed action, and mitigation measures available for reducing or avoiding adverse impacts. It also includes the NRC's recommendation regarding the proposed action.

The NRC's preliminary recommendation is that the Commission determine that the adverse environmental impacts of license renewal for TMI-1 are not so great that preserving the option of license renewal for energy-planning decisionmakers would be unreasonable. The recommendation is based on (1) the analysis and findings in the GEIS; (2) the Environmental Report and supplemental information submitted by AmerGen; (3) consultation with Federal, State, and local agencies; (4) the NRC's own independent review; and (5) the NRC's consideration of public comments received during the scoping process.

12. KEY WORDS/DESCRIPTORS (List words or phrases that will assist researchers in locating the report.)

Three Mile Island Nuclear Station, Unit 1  
TMI-1  
Three Mile Island  
Supplement to the Generic Environmental Impact Statement  
DSEIS  
National Environmental Protection Act  
NEPA  
License Renewal  
GEIS  
NUREG 1437, Supplement 37

13. AVAILABILITY STATEMENT

unlimited

14. SECURITY CLASSIFICATION

(This Page)

unclassified

(This Report)

unclassified

15. NUMBER OF PAGES

16. PRICE



Federal Recycling Program