PEACH BOTTOM ATOMIC POWER STATION Unit Numbers 2 and 3 Docket Numbers 50-277 and 50-278 Unit Number 1 Docket Number 50-171 PBAPS Independent Spent Fuel Storage Installation Docket Number 72-29

RADIOACTIVE EFFLUENT RELEASE REPORT

NO. 51

JANUARY 1, 2008 THROUGH DECEMBER 31, 2008

Submitted to The United States Nuclear Regulatory Commission Pursuant to Facility Operating Licenses DPR-44 and DPR-56

(Page Intentionally Left Blank)

(

TABLE OF CONTENTS

SECTION		P
Introduction	1	
Attachment 1 Supplemental Information	3	
Regulatory Limits	5	
Maximum Permissible Concentrations	6	
Average Energy	6	
Measurements and Approximations of Total Radioactivity	6	
Batch Releases	8	
Average Stream Flow	9	
Abnormal Releases	9	
Changes to ODCM	12	
Minimum Detectable Concentrations	12	
Violations	13	
Attachment 2 Effluent Summary	15	
Gaseous Effluents - Summation of All Releases	17	
Gaseous Effluents for Elevated Release Point - Main Stack	18	
Gaseous Effluents for Ground Level Release Points - Unit 2 and Unit 3 Roof Vents & Aux Boiler Stack	19	
Liquid Effluents - Summation of All Releases	20	
Liquid Effluents Release Points – Liquid Radwaste, RHR Leaks	21	

PAGE

Attachment 3	Solid Waste and Irradiated Fuel Shipments	23				
Solid Waste Shipped						
Irradiated Fuel Shipments						
Changes	s to Process Control Program (PCP)	27				
Attachment 4	Radiological Impact on Man	29				
Radiolog	gical Impact on Man	31				
Summar	y of Gaseous and Liquid Annual Doses	31				
Liquid ai	nd Gaseous Effluent Radiation Monitors	31				
Attachment 5	Meteorological Data	33				
Appendix A	ERRATA Data Section	93				
Appendix B	Revised copy of the ODCM	101				

Technical Concurrences: (for accuracy of information)

Chemistry / Radwaste Manager

12/09

Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

INTRODUCTION

In accordance with the Reporting Requirements of Technical Specification 5.6.3 applicable during the reporting period, this report summarizes the Effluent Release Data for Peach Bottom Atomic Power Station Units 2 and 3 for the period January 1, 2008 through December 31, 2008. The notations E and E- are used to denote positive and negative exponents to the base 10, respectively.

The release of radioactive materials during the reporting period was within the Offsite Dose Calculation Manual Specification limits.

There were five unplanned releases of liquid radioactive material. Three releases were from RHR heat exchangers, one was from a groundwater tritium plume and one was from the U2 Yard Drain Sump.

There were no gaseous or liquid radioactive releases from the Independent Spent Fuel Storage Installation, <u>NRC Docket No. 72-29 (ISFSI)</u>.

There were changes made to RW-AA-100 "Process Control Program for Radioactive Waste" in 2008. All changes made were administrative and the changes did not reduce the overall conformance of solidified waste product to the existing criteria for solid wastes.

There were changes made to the ODCM during the 2008 reporting period. A copy of the revised report is attached with this document and included as Appendix B. Each change is identified by markings in the margin of affected pages, indicating the area of the page that was change and the date (month/year) the change was implemented.

Exelon common procedures, which provide consistent expectations and standards for Radioactive Effluents Controls Program, were used to generate this report. They are:

- CY-AA-170-000, Radioactive Effluent and Environmental Monitoring Program
- CY-AA-170-100, Radiological Environmental Monitoring Program
- CY-AA-170-200, Radioactive Effluent Controls Program
- CY-AA-170-300, Offsite Dose Calculation Manual Administration
- CY-AA-170-2000, Annual Radioactive Effluent Release Report
- CY-AA-170-2100, Estimated Errors of Effluent Measurement
- CY-AA-170-3100, Offsite Dose Calculation Manual Revisions

Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

(Page Intentionally Left Blank)

Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

Attachment 1

Supplemental Information

Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

(Page Intentionally Left Blank)

- 1. Regulatory Limits
 - A. Noble Gases:

1.	≤ 500 ≤ 3000	mRem/Yr mRem/Yr	- total body - skin	-	ODCMS 3.8.C.1.a
2.	[•] ≤ 10 ≤ 20	mRad mRad	- air gamma - air beta	-	quarterly air dose limits ODCMS 3.8.C.2.a and b
3.	≤ 20 ≤ 40	mRad mRad	- air gamma - air beta	-	yearly air dose limits ODCMS 3.8.C.2.c and d

B. Iodines, Tritium, Particulates with Half Life >8 days:

	1.	≤ 1500	mRem/Yr	- any organ	-	ODCMS 3.8.C.1.b
	2.	≤ 15	mRem	- any organ	-	quarterly dose limits ODCMS 3.8.C.3.a
	3.	≤ 30	mRem	- any organ	-	yearly dose limits ODCMS 3.8.C.3.b
C.	Liquio	d Effluen	ts			
	1.	Concen Append	tration ≤ 10 ti ix B, Table 2,	mes 10 CFR 20, Col. 2	-	ODCMS 3.8.B.1.a
	2.	≤ 3.0	mRem	- total body	-	quarterly dose limits
		≤ 10	mRem	- any organ		ODCMS 3.8.B.2.a
	З.	≤ 6.0	mRem	- total body	-	yearly dose limits
		≤ 20	mRem	- any organ		ODCMS 3.8.B.2.b
D.	40 C	FR 190 a	and 10 CFR 7	2.104		
		≤ 25	mRem	- total body	-	ODCMS 3.8.D.1.a

		total body	ODOINO 0.0.D.1.u
≤ 75	mRem	- thyroid	ODCMS 3.8.D.1.b
<u><</u> 25	mRem	- any other organ	ODCMS 3.8.D.1.c
<u><</u> 3.0	mRem	- from liquid and	ODCMS 3.8.D.1.d
		gaseous effluent	
<u><</u> 55	mRem	 thyroid from gases 	ODCMS 3.8.D.1.e

2. Maximum Permissible Concentrations:

Gaseous dose rates rather than effluent concentrations are used to calculate permissible release rates for gaseous releases. The maximum permissible dose rates for gaseous releases are defined in ODCMS 3.8.C.1a. and 3.8.C.1.b.

The Effluent Concentrations Limits (ECL) specified in 10 CFR 20, Appendix B, Table 2, Column 2 times 10, for identified nuclides, are used to calculate permissible release rates and concentrations for liquid release per Peach Bottom Offsite Dose Calculation Manual Specification 3.8.B.1.

The total activity concentration for all dissolved or entrained gases is limited to $< 2E-04 \mu Ci/ml$.

3. Average Energy:

The Peach Bottom ODCM limits the dose equivalent rates due to the release of noble gases to less than or equal to 500 mRem/year to the total body and less than or equal to 3000 mRem/year to the skin. Therefore, the average beta and gamma energies of the radionuclide mixture in releases of fission and activation gases as described in Regulatory Guide 1.21, "Measuring, Evaluation, and Reporting Radioactivity in Solid Wastes and Releases of Radioactive Materials in Liquid and Gaseous Effluents from Light-Water-Cooled Nuclear Power Plants," are not applicable to Peach Bottom.

- 4. Measurements and Approximations of Total Radioactivity:
 - A. Fission and Activation Gases:

The method used for Gamma Isotopic Analysis is the Canberra Genie System with a gas Marinelli beaker. Grab samples are taken and analyzed at least monthly to determine the isotopic mixture of noble gas activity released for the month. Airborne effluent gaseous activity was continuously monitored and recorded in accordance with ODCMS Table 4.8.C.1. The data from the noble gas radiation monitor was analyzed to report noble gas effluent activities. When no activity was found in the grab isotopic analysis, the isotopic mixture was assumed to be that specified in ODCM IV.B. The activity released is listed as Unidentified in the Attachment 2 Tables. If activity was found in the grab isotopic analysis, the isotopic mixture for the Noble Gas Monitor was determined from that isotopic mixture.

B. lodines:

Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

The method used is the Canberra Genie System with a charcoal cartridge. Iodine activity was continuously sampled and analyzed in accordance with ODCMS Table 4.8.C.1.

C. Particulates:

The method used is the Canberra Genie System with a particulate filter (47 mm). Particulate activity was continuously sampled and analyzed in accordance with ODCM Table 4.8.C.1.

Composite particulate air samples were submitted to an offsite vendor laboratory for analysis of Sr-89, Sr-90 and gross alpha.

D. Liquid Effluents:

Gamma isotopic activity concentrations are determined on each batch of liquid effluent prior to release using the Canberra Genie System in accordance with ODCMS Table 4.8.B.1. The total activity of a released batch is determined by multiplying each nuclide's concentration by the total volume discharged.

Composite liquid radwaste samples counted for tritium and submitted to an offsite vendor laboratory for analysis of Fe-55, P-32, Sr-89, Sr-90 and gross alpha.

E. Estimated Total Error Present

CY-AA-170-2100, Estimated Errors of Effluent Measurements, provides the methodology to obtain an overall estimate of the error associated with radioactive effluents.

Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

5. Batch Releases:

A. Liquid:

	QTR 1	QTR 2	QTR 3	QTR 4
Number of batch releases:	6	5	2	3
Total Time for batch releases (minutes)	468	431	132	354
Maximum time period for batch release (minutes):	125	110	82	260
Average time period for batch release (minutes):	78	86	66	118
Minimum time period for batch release (minutes):	38	62	50	40
Dilution volume (liters):	1.38E+12	2.21E+12	2.79E+12	2.36E+12

B. Gaseous:

	QTR 1	QTR 2	QTR 3	QTR 4
Number of batch releases:	0	0	0	0
Total Time for batch releases (minutes)	0	0	0	0
Maximum time period for batch release (minutes):	0	0	0	0
Average time period for batch release (minutes):	.0	0	0	0
Minimum time period for batch release (minutes):	0	0	0	0

6. Average Stream Flow:

The river flow is not used for dose calculations. The actual discharge of circulating water is used for liquid dose calculations. The circulating water varies from 675,000 gpm in the winter to 1,350,000 gpm in the summer.

7. Abnormal Releases: Five abnormal release sources

A. Liquid:

1. Event description – 2C Residual Heat Removal (RHR) to High Pressure Service Water (HPSW) leak

On 08/01/2005, routine sampling of the HPSW effluent to the discharge canal detected low-level radioactive contamination. Subsequent investigation determined that a trace amount of condensate stay-full or primary coolant water was leaking through the Unit 2C RHR heat exchanger into the 2A loop of the HPSW system. The 2C RHR continued to be a source of contamination to the end of 2008. The leak rate range was 0.0438 GPM from January decreasing to 0.0002 GPM throughout the end of the year.

Analysis of Releases

It was estimated that the contaminated water released to the discharge canal for all of 2008 was responsible for 2.94E-03 mRem total body dose (Adult), and 8.19E-03 mRem Critical Organ (Adult GI-LLI) dose. This dose contribution was well below the limits specified in the ODCM.

Samples were analyzed for all the parameters of radioactive effluent releases. Composite liquid radwaste samples counted for tritium and submitted to an offsite vendor laboratory for analysis of Fe-55, P-32, Sr-89, Sr-90 and gross alpha. The maximum concentration from several analyses was used to ensure conservative measures of activity released. The dose contributions and isotope quantities from the releases were added to this Radioactive Effluent Release Report for the applicable reporting periods.

 Event description – 2D Residual Heat Removal (RHR) to High Pressure Service Water (HPSW) leak

On 10/07/2005, routine sampling of the HPSW effluent to the discharge canal detected low-level radioactive contamination. Subsequent investigation determined that a trace amount of condensate stay-full or primary coolant

Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

water was leaking through the Unit 2D RHR heat exchanger into the 2B loop of the HPSW system. The 2D RHR continued to be a source of contamination to the beginning of 2008. The leak rate calculated was 0.0802 gpm to end of January. The 2D RHR heat exchanger was repaired on February 1, 2008.

Analysis of Releases

It was estimated that the contaminated water released to the discharge canal for all of 2008 was responsible 3.76E-04 mRem total body dose (Adult), and 8.91E-04 mRem Critical Organ (Adult GI-LLI) dose. This dose contribution was well below the limits specified in the ODCM.

Samples were analyzed for all the parameters of radioactive effluent releases. Composite liquid radwaste samples counted for tritium and submitted to an offsite vendor laboratory for analysis of Fe-55, P-32, Sr-89, Sr-90 and gross alpha. The dose contributions and isotope quantities from the releases were added to this Radioactive Effluent Release Report for the applicable reporting periods.

 Event description – 3A Residual Heat Removal (RHR) to High Pressure Service Water (HPSW) leak

On 04/08/2008, routine sampling of the HPSW effluent to the discharge canal detected low-level radioactive contamination. Subsequent investigation determined that a trace amount of condensate stay-full or primary coolant water was leaking through the Unit 3A RHR heat exchanger into the 3A loop of the HPSW system. The 3A RHR continued to be a source of contamination to the end of 2008. The leak rate range was 0.0642 GPM from January decreasing to 0.0035 GPM throughout the end of the year.

Analysis of Releases

It was estimated that the contaminated water released to the discharge canal for all of 2008 was responsible 9.88E-04 mRem total body dose (Adult), and 7.34E-04 mRem Critical Organ (Adult GI-LLI) dose. This dose contribution was well below the limits specified in the ODCM.

Samples were analyzed for all the parameters of radioactive effluent releases. Composite liquid radwaste samples counted for tritium and submitted to an offsite vendor laboratory for analysis of Fe-55, P-32, Sr-89, Sr-90 and gross alpha. The dose contributions and isotope quantities from the releases were added to this Radioactive Effluent Release Report for the applicable reporting periods.

Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

4. Event description – U2 Yard Drain Sump

On January 2, 2008, routine sampling of the Unit 2 Yard Drain Sump showed no gamma activity and was released to the discharge canal. The gamma analysis showed no activity but the tritium was measured to be 1.26E-06 uCi/ml. This tritium was assumed to be the concentration of the January 8, 2008 release.

Analysis of Release

It was estimated that the contaminated water released to the discharge canal at a rate of 23 gpm. With the maximum concentration 1.26E-6 uCi/mL, the water released was responsible for 5.92E-07 total body dose, and 5.92E-07 mRem Critical Organ (Child Liver) dose. This dose contribution was well below the limits specified in the ODCM.

Representative samples were analyzed for gamma activity and tritium. The dose contributions and isotope quantities from the releases were added to this Radioactive Effluent Release Report for the applicable reporting periods.

5. Event description – Ground Water Plume

During 2008, during the sampling and analysis of the Radiological Ground Water Protection Program (RGPP), tritium was measured at several locations around the site. The ground water that has detectable tritium has been determined to discharge into the intake or discharge canal. The highest concentration of tritium was 6.95E-6 uCi/ml. This concentration was assumed to be the concentration of all the ground water that discharged to the discharge canal.

Analysis of Releases

It was estimated that the ground water flowed to the discharge canal at a rate of 175 gpm. With the maximum concentration of 6.95E-06 uCi/ml, the ground water released to the discharge canal was responsible for 1.56E-05 mRem total body dose (Child), and 1.56E-05 mRem Critical Organ dose (Child). This dose contribution was well below the limits specified in the ODCM.

Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

B. Gaseous:

No abnormal releases.

8. Changes to the ODCM:

A revised copy of the ODCM is attached as Appendix B of this document for the 2008 reporting period. Each change is identified by markings in the margin of affected pages, indicating the area of the page that was changed and the date (month/year) the change was implemented.

9. Minimum Detectable Concentrations:

A. Liquid:

If a radionuclide was not detected, < LLD was reported for that isotope. Samples were analyzed with techniques that achieved the required Lower Limits of Detection (LLD) as specified in Offsite Dose Calculation Manual Specification Table 4.8.B.1, Radioactive Liquid Waste Sampling and Analysis. In all cases, the LLD requirements were satisfied.

B. Gaseous:

If a radionuclide was not detected, < LLD was reported for that isotope. Samples were analyzed with techniques which achieved the required Lower Limits of Detection (LLD) as specified in Offsite Dose Calculation Manual Specification Table 4.8.C.1, Radioactive Gaseous Waste Sampling and Analysis from Main Stack and Vent Stack. In all cases, the LLD requirements were satisfied.

10. Violations:

A. On September 26, 2008 the Main Stack Flow dropped to less than 10,000 CFM due to the unexpected loss of the E324 MCC feeder breaker at the Main Stack (E324-O-A) and the need to perform the E12 Bus Local Loop Test. This did not comply with ODCM 3.8.C.4.D. Total duration of the non compliance was 2 hrs 53 minutes.

Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

(Page Intentionally Left Blank)

Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

į

Attachment 2

Effluent Summary

Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

(Page Intentionally Left Blank)

Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

Attachment 2

Gaseous Effluents - Summation Of All Releases

Period: 2008

Unit: Peach Bottom Units 2 & 3

A. Fission & Activation Gases	Unit	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Est. Total Error %
1. Total Release	Ci	1.61E+02	2.11E+02	1.61E+02	7.39E+01	3.51E+01
2. Average release rate for the period	µCi/sec	2.04E+01	2.68E+01	2.04E+01	9.38E+00	
3. Percent of ODCM limit - Gamma	0/	1.26E-01	1.73E-01	6.93E-02	8.13E-02	
- Beta	/°	4.49E-02	6.18E-02	2.58E-02	2.86E-02	
4. Quarterly Gamma Dose	mrad	1.26E-02	1.73E-02	6.93E-03	8.13E-03	
5. Quarterly Beta Dose	mrad	8.98E-03	1.24E-02	5.16E-03	5.72E-03	

B. lodine						
1. Total iodine - 131	Ci	1.19E-03	1.72E-03	2.83E-03	8.03E-04	1.76E+01
2. Average release rate for period	µCi/sec	1.51E-04	2.18E-04	3.59E-04	1.02E-04	
3. Percent of ODCM limit	%	*	*	*	*	

C. Particulates						
1. Particulates with half-lives > 8 days	Ci	6.81E-03	1.05E-02	1.17E-02	4.13E-03	1.94E+01
2. Average release rate for the period	µCi/sec	8.64E-04	1.33E-03	1.48E-03	5.24E-04	
3. Percent of ODCM limit	%	*	*	*	*	
3. Gross alpha radioactivity	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td></td></lld<></td></lld<>	<lld< td=""><td></td></lld<>	
D. Tritium						
1. Total release	Ci	1.35E+01	<lld< td=""><td>2.28E+01</td><td>6.95E+00</td><td>1.11E+01</td></lld<>	2.28E+01	6.95E+00	1.11E+01
2. Average release rate for the period	µCi/sec	1.71E+00	<lld< td=""><td>2.89E+00</td><td>8.82E-01</td><td></td></lld<>	2.89E+00	8.82E-01	
3. Percent of ODCM limit	%	* .	*	*	*	

E. lodine 131 & 133, Tritium & Particulate					
1. Percent of ODCM limit	%	1.36E-02	5.74E+00	2.86E+00	5.04E-01
2. Quarterly Dose	mrem	2.04E-03	8.61E-01	4.29E-01	7.56E-02

* Limit is no longer applicable to iodine and particulate. Section E provides limit.

Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

Attachment 2

Gaseous Effluents for Elevated Release Point - Main Stack

Period: 2008

X

Unit: Peach Bottom Units 2 & 3

NUCLIDES RELEA	(CONTINUC	US MODE		BATCH MODE				
1. Fission gases	Unit	Quarter	Quarter	Quarter	Quarter	Quarter	Quarter	Quarter	Quarter
		1	2	3	4	1	2	3	4
Ar-41	Ci	<lld< td=""><td>7.50E-01</td><td>6.03E-01</td><td>1.59E-01</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	7.50E-01	6.03E-01	1.59E-01	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Kr-85m	Ci	2.45E+01	2.98E+01	2.91E+01	9.35E+00	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Kr-87	Ci	1.01E+00	1.49E+00	1.05E+00	1.29E-01	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Kr-88	Ċi	1.71E+01	2.23E+01	2.32E+01	1.31E+00	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Xe-133	Ci	5.45E+01	6.38E+01	7.13E+01	1.92E+01	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Xe-135m	Ci	4.51E-01	6.39E-01	<lld< td=""><td>9.64E-01</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	9.64E-01	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Xe-135	Ci	8.03E+00	2.30E+00	1.81E+00	3.10E+00	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Xe-138	Ci	7.81E+00	2.46E+01	8.90E+00	8.38E+00	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Unidentified	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Total for Period	Ci	1.13E+02	1.46E+02	1.36E+02	4.26E+01	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld_< td=""></lld_<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld_< td=""></lld_<></td></lld<></td></lld<>	<lld< td=""><td><lld_< td=""></lld_<></td></lld<>	<lld_< td=""></lld_<>
2. lodines			All the second				\$X _2		
I-131	Ci	3.90E-04	3.91E-04	4.95E-04	1.88E-04	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
I-1 <u>33</u>	Ci	8.93E-04	1.07E-03	1.47E-03	3.08E-04	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
I-135	Ci	2.16E-04	1.90E-04	5.23E-04	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Total for Period	Ci	1.50E-03	1.65E-03	2.49E-03	4.96E-04	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
3. Particulates			HE CALE			S. MARCE C.	t Strategie	R CARLES	
Cr-51	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td>8.13E-06</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td>8.13E-06</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td>8.13E-06</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	8.13E-06	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Mn-54	Ci	<lld< td=""><td><lld< td=""><td>9.14E-07</td><td>8.36E-07</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td>9.14E-07</td><td>8.36E-07</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	9.14E-07	8.36E-07	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Co-58	Ci	3.03E-07	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Co-60	Ci	3.38E-06	9.59E-06	1.43E-05	9.46E-06	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Zn-65	Ci	<lld< td=""><td><lld< td=""><td>3.22E-06</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td>3.22E-06</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	3.22E-06	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Sr-89	Ci	6.66E-04	5.88E-04	2.56E-04	6.87E-05	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Sr-90	Ci	2.62E-06	2.66E-06	6.00E-07	8.19E-07	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Cs-137	Ci	1.01E-05	5.64E-06	1.44E-06	1.24E-06	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Ba-140	Ci	1.02E-03	6.76E-04	2.33E-04	3.14E-04	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Ce-141	Ci	5.57E-07	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Am-241	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td>5.63E-07</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td>5.63E-07</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td>5.63E-07</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	5.63E-07	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
									———
Total for Period	Ci	1.70E-03	1.28E-03	5.09E-04	4.04E-04	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>

Attachment 2

Gaseous Effluents Ground Level Release Point - Unit 2 & 3 Roof Vents & Aux Boiler Stack

Period: 2008

Unit: Peach Bottom Units 2 & 3

Nuclides Released			Continuo	us Mode		Batch Mode			
1. Fission gases Unit		Quarter	Quarter	Quarter	Quarter	Quarter	Quarter	Quarter	Quarter
		1	2	3	4	1	2	3	4
Kr-85	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Kr-85m	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Kr-87	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Kr-88	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Xe-133	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Xe-135	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td>_<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td>_<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td>_<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td>_<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td>_<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	_ <lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Xe-135m	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Xe-138	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Ar-41	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Xe-133m	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Unidentified	Ci	4.77E+01	6.54E+01	2.51E+01	3.13E+01	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Total for Period	Ċi	4.77E+01	6.54E+01	2.51E+01	3.13E+01	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
2. lodines			18 6 2 73 8			31. C.		A CAR A	Gel St. H
l-131	Ci	8.04E-04	1.33E-03	2.34E-03	6.15E-04	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
l-133	Ci	2.65E-03	6.05E-03	6.25E-03	2.58E-03	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
I-135	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Total for Period	Ci	3.45E-03	7.38E-03	8.59E-03	3.20E-03	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
3. Particulates			R. H.	L. M. L. C.		Christ Mart 1			A CARRY &
Co-60	Ci	<lld< td=""><td>1.06E-05</td><td><lld< td=""><td>1.41E-05</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	1.06E-05	<lld< td=""><td>1.41E-05</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	1.41E-05	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Sr-89	Ci	1.11E-04	9.58E-05	1.13E-04	1.91E-05	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Ba-140	Ci	5.19E-05	6.06E-05	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
La-140	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Cr-51	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Mn-54	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
<u>Co-58</u>	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Co-60	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Mo-99	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Ag-110m	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Ce-141	_ Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Ce-144	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Zn-65	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Sr-90	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
0	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
	Ci								
	Ci								
	_ Ci								
Total for Period	Ci	1.63E-04	1.67E-04	1.13E-04	3.33E-05	<lld< td=""><td><pre>LLD</pre></td><td>i <lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<pre>LLD</pre>	i <lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>

Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

Liquid Effluents - Summation Of All Releases

Period: 2008

Unit: Peach Bottom Units 2 & 3

A. FISSION & ACTIVATION PRODUCTS		Quarter	Quarter	Quarter	Quarter	Est. Total
		1	2	3	4	Error %
1. Total Release (not including tritium, gases						
& alpha)	Ci	1.33E-01	1.11E-02	3.00E-02	8.04E-02	2.11E+01
2. Average diluted concentration during batch						
discharges for the period		9.64E-11	5.03E-12	1.08E-11	3.41E-11	
4. Percent of ODCM limit - Whole Body	0/	8.43E-02	8.53E-03	1.57E-02	3.45E-02	
- Organ	/°	5.96E-02	3.16E-03	9.08E-03	2.54E-02	

B. TRITIUM						
1. Total Release	Ci	7.46E-01	3.24E-01	7.21E-01	1.01E+00	6.40E+00
2. Average diluted concentration during batch						
discharges for the period	µCi/mL	5.42E-10	1.46E-10	2.59E-10	4.29E-10	
4. Percent of 10 CFR 20 limit	%	5.42E-05	1.46E-05	2.59E-05	4.29E-05	

C. DISSOLVED & ENTRAINED GASES						
1. Total Release	Ci	3.46E-04	1.77E-04	2.06E-04	4.42E-04	2.11E+01
2. Average diluted concentration during batch						
discharges for the period	µCi/mL	2.51E-13	8.00E-14	7.40E-14	1.87E-13	
4. Percent of ODCM limit	%	1.26E-07	4.00E-08	3.70E-08	9.35E-08	

D. GROSS ALPHA ACTIVITY						
1. Total release	Ci	4.32E-05	3.12E-06	4.14E-06	6.89E-06	2.30E+01
E. VOLUME OF WASTE RELEASED (prior						
to dilution)	Liters	6.96E+07	9.35E+07	1.28E+08	9.94E+07	5.00E+00

F. VOLUME OF DILUTION WATER USED						
DURING BATCH DISCHARGES	Liters	1.38E+12	2.21E+12	2.79E+12	2.36E+12	2.22E+01

Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

Attachment 2

Liquid Effluents Release Point - Liquid Radwaste & RHR Leaks

Period: 2008

Unit: Peach Bottom Units 2 & 3

NUCLIDES RELEASED			CONTINUO	US MODE			BATCH	MODE	
1. Fission gases	Unit	Quarter	Quarter	Quarter	Quarter	Quarter	Quarter	Quarter	Quarter
		1	2	3	4	1	2	3	4
Y-92	Ci	<lld< td=""><td>9.24E-05</td><td>2.83E-04</td><td>2.83E-04</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	9.24E-05	2.83E-04	2.83E-04	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Co-58	Ci	4.98E-03	3.79E-05	5.71E-05	7.89E-04	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Co-60	Ci	5.86E-02	8.33E-03	2.50E-02	6.13E-02	4.02E-07	<lld< td=""><td><lld< td=""><td>1.74E-07</td></lld<></td></lld<>	<lld< td=""><td>1.74E-07</td></lld<>	1.74E-07
Cr-51	Ci	2.12E-02	<lld< td=""><td><lld< td=""><td>7.91E-03</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td>7.91E-03</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	7.91E-03	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Fe-55	Ci	6.46E-03	1.50E-04	2.28E-04	3.90E-04	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Fe-59	Ci	5.15E-03	1.23E-05	1.25E-05	6.22E-04	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
l-131	Ci	<lld< td=""><td>2.52E-06</td><td>7.73E-06</td><td>7.73E-06</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	2.52E-06	7.73E-06	7.73E-06	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Mn-54	Ci	2.80E-02	2.11E-03	3.46E-03	6.76E-03	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Nb-95	Ci	4.51E-04	<lld< td=""><td><lld< td=""><td>6.99E-05</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td>6.99E-05</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	6.99E-05	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Nb-97	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td>1.61E-05</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td>1.61E-05</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td>1.61E-05</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	1.61E-05	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Sr-89	Ci	3.92E-06	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Sr-90	Ci	3.15E-06	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td>5.47E-07</td><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td>5.47E-07</td><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td>5.47E-07</td><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td>5.47E-07</td><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	5.47E-07	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Y-91m	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td>1.16E-05</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td>1.16E-05</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td>1.16E-05</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	1.16E-05	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Zn-65	Ci	6.96E-03	1.39E-04	5.43E-04	1.44E-03	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Zr-95	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td>8.22E-05</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td>8.22E-05</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td>8.22E-05</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	8.22E-05	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Ba-139	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td>2.10E-05</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td>2.10E-05</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td>2.10E-05</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	2.10E-05	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Cs-134	Ci	<lld< td=""><td>2.04E-05</td><td>3.08E-05</td><td>6.76E-05</td><td>3.72E-07</td><td>1.19E-06</td><td>2.27E-07</td><td>4.13E-07</td></lld<>	2.04E-05	3.08E-05	6.76E-05	3.72E-07	1.19E-06	2.27E-07	4.13E-07
<u>Cs</u> -137	Ci	4.57E-04	1.18E-04	1.68E-04	2.91E-04	1.82E-06	2.95E-06	1.01E-06	3.43E-06
Cs-138	Ci	4.47E-04	1.19E-04	1.81E-04	2.31E-04	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Hf-181	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td>5.73E-05</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td>5.73E-05</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td>5.73E-05</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	5.73E-05	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
La-142	Ci	<lld< td=""><td><lld< td=""><td>2.72E-05</td><td>4.11E-05</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td>2.72E-05</td><td>4.11E-05</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	2.72E-05	4.11E-05	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Sb-124	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td>7.40E-05</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td>7.40E-05</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td>7.40E-05</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	7.40E-05	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Ag-110m	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td>1.23E-05</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td>1.23E-05</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td>1.23E-05</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	1.23E-05	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Tritium	Ci	7.46E-01	3.23E-01	7.21E-01	8.11E-01	<lld< td=""><td>2.91E-04</td><td>7.16E-05</td><td>2.03E-01</td></lld<>	2.91E-04	7.16E-05	2.03E-01
Total for Period	Ci	8.79E-01	3.35E-01	7.51E-01	8.91E-01	2.59E-06	2.96E-04	7.28E-05	2.03E-01
Kr-87	Ci	1.87E-04	9.18E-05	1.07E-04	1.37E-04	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Xe-133	Ci	<lld< td=""><td>2.98E-05</td><td>3.47E-05</td><td>5.13E-05</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td>1.40E-05</td></lld<></td></lld<></td></lld<></td></lld<>	2.98E-05	3.47E-05	5.13E-05	<lld< td=""><td><lld< td=""><td><lld< td=""><td>1.40E-05</td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td>1.40E-05</td></lld<></td></lld<>	<lld< td=""><td>1.40E-05</td></lld<>	1.40E-05
Xe-135	Ci	<lld< td=""><td>8.40E-06</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	8.40E-06	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Xe-131m	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td>1.57E-04</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td>1.57E-04</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td>1.57E-04</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	1.57E-04	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Xe-135m	Ci	1.60E-04	4.69E-05	6.44E-05	8.23E-05	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Total for Period	Ci	3.46E-04	1.77E-04	2.06E-04	4.27E-04	<lld< td=""><td><lld< td=""><td><lld< td=""><td>1.40E-05</td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td>1.40E-05</td></lld<></td></lld<>	<lld< td=""><td>1.40E-05</td></lld<>	1.40E-05

Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

(Page Intentionally Left Blank)

Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

Attachment 3

Solid Waste and Irradiated Fuel Shipments

.

(Page Intentionally Left Blank)

Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

A. SOLID WASTE SHIPPED OF SITE FOR BURIAL OR DISPOSAL (Not irradiated fuel) 01-01-2008-12-31-2008

1.	Type of Waste	units	2008	Est. error %
a:	spent resin, filters, sludges, evaporator bottoms, etc	M3	9.20E+01	
		Ci	1.19E+03	25
b:	dry compressible waste, contaminated equipment, etc.	М3	1.28E+03	
		Ci	4.66E+00	25
c:	Irradiated components, control rods, etc.	М3	9.61E-01	
		Ci	1.78E+04	25
d:	Other (describe) oil	M3	3.14E+01	
		Ci	1.63E-02	25

2. Estimate of major nuclide composition (by type of waste)

	abundance	
nuclide	(no cutoff)	activity (Ci)
H-3	0.012%	1.43E-01
Cr-51	0.000%	3.29E-03
Mn-54	9.024%	1.07E+02
Fe-55	34.781%	4.14E+02
Fe-59	0.000%	3.84E-03
Co-58	0.002%	2.75E-02
Co-60	48.893%	5.82E+02
Ni-63	0.728%	8.67E+00
Zn-65	3.056%	3.64E+01
Nb-95	0.000%	9.02E-04
Cs-134	0.272%	3.23E+00
Cs-137	1.737%	2.07E+01
Ce-141	0.000%	3.01E-04
Ce-144	0.267%	3.18E+00
Pu-238	0.000%	3.80E-03
Pu-241	0.028%	3.36E-01
Cm-242	0.000%	8.25E-04
Cm-243	0.000%	3.75E-05
C-14	0.087%	1.03E+00
Sr-89	0.001%	8.35E-03
Sr-90	0.146%	1.74E+00
Nb-97	0.000%	2.46E-75
Tc-99	0.083%	9.92E-01
Ru-106	0.001%	1.50E-02
Ag-110m	0.879%	1.05E+01
Sb-122	0.000%	1.38E-45
Sb-124	0.000%	6.43E-04
Te-129m	0.000%	2.35E-03
I-131	0.000%	9.26E-10
Ba-140	0.000%	5.73E-07
La-140	0.000%	2.95E-38
Pr-144	0.000%	3.25E-87
Hf-175	0.000%	2.99E-06
Hf-181	0.000%	5.88E-07
Pt-191	0.000%	5.92E-24
Pu-239	0.000%	6.86E-04
Am-241	0.000%	3.27E-03
Cm-244	0.000%	3.61E-03
Totals	100.00%	1.19E+03

(

a: spent resin, filters, sludges, evaporator bottoms, etc

b: dry compressible waste, contaminated equipment, etc.

	abundance (no	
nuclide	cutoff)	activity (Ci)
H-3	0.020%	9.37E-04
Cr-51	0.103%	4.80E-03
Mn-54	5.068%	2.37E-01
Fe-55	29.181%	1.36E+00
Fe-59	0.048%	2.23E-03
Co-58	0.125%	5.86E-03
Co-60	58.604%	2.73E+00
Ni-63	1.582%	7.38E-02
Zn-65	1.654%	7.72E-02
Nb-95	0.025%	1.17E-03
Cs-134	0.277%	1.29E-02
Cs-137	2.656%	1.24E-01
Ce-141	0.002%	8.36E-05
Ce-144	0.216%	1.01E-02
Pu-238	0.000%	8.59E-06
Pu-241	0.330%	1.54E-02
Cm-242	0.000%	6.10E-06
Cm-243	0.000%	1.31E-06
C-14	0.076%	3.57E-03
Sr-89	0.001%	5.61E-05
Sr-90	0.013%	5.97E-04
Tc-99	0.006%	2.79E-04
Ag-110m	0.010%	4.75E-04
Pu-239	0.001%	6.75E-05
Am-241	0.000%	2.40E-06
Cm-244	0.000%	8.13E-06
Totals	100.00%	4.66E+00

 c: Irradiated components, control rods, etc 					
	abundance (no				
nuclide	cutoff)	activity (Ci)			
H-3	0.003%	5.17E-01			
Mn-54	1.393%	2.47E+02			
Fe-55	52.742%	9.36E+03			
Fe-59	0.000%	1.67E-09			
Co-58	0.026%	4.60E+00			
Co-60	40.399%	7.17E+03			
Ni-63	5.376%	9.55E+02			
Zn-65	0.001%	1.35E-01			
Cs-137	0.000%	1.78E-03			
Ce-144	0.000%	1.56E-02			
Pu-238	0.000%	1.56E-02			
Pu-241	0.000%	2.76E-03			
Cm-242	0.000%	3.41E-05			
C-14	0.009%	1.59E+00			
Tc-99	0.000%	8.96E-03			
Pu-239	0.000%	4.94E-04			
Am-241	0.000%	1.26E-05			
Cm-244	0.000%	8.35E-05			
I-129	0.000%	9.63E-05			
Ni-59	0.026%	4.59E+00			
Nb-94	0.000%	1.95E-02			
Ta-182	0.025%	4.38E+00			
U-235	0.000%	5.47E-08			
Totals	100.000%	1.78E+04			

Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

.

	abundance	
nuclide	(no cutoff)	activity (Ci)
H-3	95.049%	1.55E-02
Mn-54	0.001%	1.19E-07
Fe-55	1.364%	2.22E-04
Co-60	2.496%	4.07E-04
Ni-63	0.141%	2.31E-05
Zn-65	0.002%	3.24E-07
Cs-137	0.301%	4.90E-05
Ce-144	0.539%	8.79E-05
C-14	0.088%	1.44E-05
Sr-90	0.018%	2.97E-06
Tc-99	0.000%	7.34E-08
Totals	100.00%	1.63E-02

d: Other (describe) oil

3. Solid Waste Disposition

Number of shipments	Mode of Transportation	Destination
6	highway	Barnwell Waste Mgmt. Facility
14	highway	Energy Solutions (Clive, UT)
28	highway	Energy Solutions (Oak Ridge, TN)
1	highway	Studsvik Processing Facility, LLC

B. IRRADIATED FUEL SHIPMENTS (Disposition)

No shipment of irradiated fuel were made during the reporting period of 2008.

C. Changes to Process Control Program (PCP)

There were changes made to RW-AA-100 "Process Control Program for Radioactive Waste" in 2008. All changes made were administrative and the changes did not reduce the overall conformance of solidified waste product to the existing criteria for solid wastes.

.

r

-

Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

(Page Intentionally Left Blank)

Facility: Peach Bottom Units 2 & 3Licensee: Exelon Generation Company, LLCPSEG Nuclear, LLC

Attachment 4

Radiological Impact on Man

í

Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

(Page Intentionally Left Blank)

1. Radiological Impact on Man

The Annual Radiation Dose Assessment Report for January 1, 2008 to December 31, 2008 contained dose calculations based on current year meteorology and river flows. The total body and skin doses, 40 CFR 190 doses and doses to MEMBERS OF THE PUBLIC due to activities inside the site boundary are found in the Annual Radiation Dose Assessment Report for January 1, 2008 to December 31, 2008.

2. A summary of gaseous and liquid radiation annual doses to MEMBERS OF THE PUBLIC as calculated by the ODCM follows:

Effluent	Applicable	Estimated	Age	Location		% of	Limit	Unit
	Organ	Dose	Group	Distance	Direction	Applicable		
				(meters)	(toward)	Limit		
	<u> </u>							
Noble Gas	Gamma - Air Dose	4.503E-02	All	1097	SSE	2.252E-01	20	mRad
Noble Gas	Beta – Air Dose	3.22E-02	All	1097	SSE	8.051E-02	40	mRad
Gaseous	Total Body	3.47E-01	Infant	396	E	3.47E+00	10	mrem
Gaseous	Skin	4.68E-01	All	396	Ē	1.56E+00	30	mrem
lodine, Particulate & Tritium	Thyroid	1.366E+00	Infant	1097	SSE	4.55E+00	30	mrem
Direct Radiation	Total Body	<lld< td=""><td>All</td><td>1150</td><td>SSE</td><td><lld< td=""><td>22</td><td>mrem</td></lld<></td></lld<>	All	1150	SSE	<lld< td=""><td>22</td><td>mrem</td></lld<>	22	mrem
Liquid	Total Body	4.291E-03	Adult	Site Boundary		7.152E-02	6	mrem
Liquid	GI-LLI	9.724E-03	Adult	Site Boundary		4.862E-02	20	mrem

Doses calculated were well below all ODCM limits.

3. Liquid and gaseous effluent radiation monitors and instrumentation

No effluent radiation monitors and instrumentation were unavailable for periods beyond the requirements of the ODCM.

Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

(Page Intentionally Left Blank)
Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

Attachment 5

Meteorological Data

(Page Intentionally Left Blank)

Facility: Peach Bottom Units 2 & 3

Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

Attachment 5

Meteorological Data

The meteorological data can be found in the Annual Radiation Dose Assessment Report for January 1, 2008 through December 31, 2008. Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

(Page Intentionally Left Blank)

Peach Bottom Nuclear Station

Period of Record: January - March 2008 Stability Class - Extremely Unstable - 150Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Wind Speed (in mph)

Wind		~ <u>-</u>		F -	-,		
Direction	1-3	4 - 7	8-12	13-18	19-24	> 24	Total

N	0	8	0	0	0	0	8
NNE	0	. 0	0	0	0	0	0
NE	3	1	0	0	0	Ó	• 4
ENE	12	2	0	0	0	0.	14
Ε	10	14	0	0	0	0	24
ESE	2	9	0	0	0	0	11
SE	0	1	1	0	0	0	2
SSE	o	0	3	0	0	0	3
S	· 0	1	6	0	0	0	7
SSW	0	0	ľ	0	0 .	0	1
SW	0	0	0	0	0	0	0
WSW	0	1	0	0	0	0	1
W	0	1	0	0.	0	0	1
WNW	0	1	l	. 0	0	ö	2
NW)O	3	1	0.	0	0	4
NNW	0	4	l	0	0	• 0	5
Variable	0	0	. 0	0	0	0	0
Total	27	46	14	• 0	0	0	87

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

.

Hours Hours Hours

Peach Bottom Nuclear Station

Period of Record: January - March 2008 Stability Class - Moderately Unstable - 150Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Wind Speed (in mph)

Wind			F	,	-,		
Direction	1-3	4 - 7	8-12	13-18	19-24	> 24	Total
N	0	12	0	0	0	0	12
NNE	1	0	1	0	0	0	2
NE	1	0	0	0	0	0	1
ENE	2	0	0	0	0	0	2
E	3	1	0	0	0	0	4
ESE	2	0	0	0	0	0	2
SE	0	0	0	0	0	0	0
SSE	0	0	2	0	0	0	2
S	0	2	3	0	0.	0	5
SSW	0	0	0	· 0	0	o	0
SW	0	0	3	0	0	0	3
WSW	0	2	2	0	0	0	4
W	0	4	6	Q	0	0	10
WNW	0	1	9	2	0	0	12
NW	0	. 1	5	2	.0	. O .	8
NNW	0	7	3	0	0	0	10
Variable	0	. 0	0	Ő	0	0	0
Total	9	30	34	. 4	0	0	7.7
of calm in of missing of missing	this stab wind meas stability	ility c urement: measure	lass: s in this ements in	0 s stabil: n all sta	ity class ability (3: 0 classes:	17

Peach Bottom Nuclear Station

Period of Record: January - March 2008 Stability Class - Slightly Unstable - 150Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Wind Speed (in mph)

Wind											
Direction	1-3	4 - 7	8-12	13-18	19-24	> 24	Total				

N	U	1	0	0	0 ·	0	1				
NNE	0.	0	0	0	0	Q	0				
NE	з	0	0	0	0	0	3				
ENE	2	0	0	0	0	0	2				
Е	2	1	0	0	0	. 0	3.				
ESE	o	2	0	0	0	0	2				
SE	0	1	0	·0	0	0	1				
SSE	1	0	0	0	0	o	l				
S	0	1	0	0	0	0	· 1				
SSW	0	0	0	0	0	0	0				
SW	0	2	0	0	.0	0	2				
WSW	0	1	2	0	0	Ö	3				
W	0	5	4	2	0	o	11				
WNW	0	2	12	1	0	0	15				
NW	0	.8	7	· 1	0	0	16				
NNW	0	8	4	o	0	o	12				
Variable	0	0	0	. 0	0	0	.0				
Total	8	32	29	4	0	ó	73				
							·				

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

Period of Record: January - March 2008 Stability Class - Neutral - 150Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Wind Speed (in mph)

Wind								
Direction	1-3	4 - 7	8-12	13-18	19-24	> 24	Total	
N	14	12	1	0	0	0	27	
NNE	11	1	0	ó	. 0	0	12	
NE	13	1	0	0	0.	0	14	
ENE	22	0	0	0	0	0	22	
Е	21	0	0	0	0	0	21	
ESE	7	5	0	0	0	0	12	
SE	5	20	8	0	0	0	33	
SSE	1	15	11	0	0	0	27	
S	l	9	5	0	0	-0	15	
SSW	0	4	5	0	0	0	9	
SW	1	10	1	l	0	0	13	
WSW	1	9	9	4	0	0	23	
W	1	19	27	11	1	0	59	
WNW	2	22	52	14	0	0	90	
NW	9	42	84	20	0	0	155	
NNW	7	41	32	5	0	0	85	
Variable	0	0	0	0	0	0	0	
Total	116	210	235	55	1	0	617	

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes: 17

Period of Record: January - March 2008 Stability Class - Slightly Stable - 150Ft-33Ft Delta-T (P) Winds Measured at 33 Peet

Wind Speed (in mph)

Wind	warene ministra (mer uther)									
Direction	1-3	4 - 7	8-12	13-18	19-24	> 24	Total			
N	20	14	0	0	0	o	3,4			
NNE	32	4	ò ·	0	0	0	36			
NE	42	o	0	Q .	0	0	42			
ENE	40	0	0	0	0	0	40			
Е	46	3	0	0	0	0	49			
ESE	3,8	8	0	0	0	0	46			
SE	32	42	10	1	0	0	85			
SSE	15	32	16	0	0	0	63			
S	20	35	20	2	0	0	77			
SSW	14	10	5	. 1	0	0	30			
SW	9	6	4	1	0	0	20			
WSW	15	24	3	2	0	0	44			
W	19	77	19	1	0	0	116			
WNW	25	101	37	0	0	0	163			
NW	26	68	2.9	2	0	0	125			
NNW	25	30	10	0	0	0	65			
Variable	0	0	0	0	0	0	0			
Total	418	454	153	10	0	0	1035			

Hours of calm in this stability class: 11 Hours of missing wind measurements in this stability class: 3 Hours of missing stability measurements in all stability classes: 17

: ·

.

1

Peach Bottom Nuclear Station

Period of Record: January - March 2008 Stability Class - Moderately Stable - 150Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

1 1 1 1		Wind Speed (in mph)								
Direction	• 1-3	4 - 7	8-12	13-18	19-24	> 24	Total			
N	9	0	0	0	. 0	0,	9			
NNE	1	0:	0	0	0	0	1			
NE	4	0	0	0	o	0	4			
ENE	13	о	0	ο	0	0	13			
E	15	0	0	0	0	0	15			
ESE	19	· 1	0	0	° 0	0	20			
SE	9	1	0	0	. 0	Ŏ	10			
SSE	2	0	0	0	ò	o	2			
S	8	1	Ó	0	· 0	0	9			
SSW	6	0	0	0	0	0	6			
SW	12	5	0	0	0	0	17			
WSW	27	12	0	o	0	0	39			
W	17	4	0	o	0	0	21			
WNW	15	2	0	0	o	0	17			
NW	16	0	0	0	0	Ο,	16			
NNW	7	0	o	0	0	o	7			
Variable	0	0	0	0	0	0	0			
Total	180	26	0	0	0	0	206			
f calm in	this stat	oility c	lass:	6						

Hours of calm in this stability class: 6 Hours of missing wind measurements in this stability class: 1 Hours of missing stability measurements in all stability classes: 17

Facility: Peach Bottom Units 2 & 3

17

Peach Bottom Nuclear Station

Period of Record: January - March 2008 Stability Class - Extremely Stable - 150Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

101 v	Wind Speed (in mph)									
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total			
N	1	0	0	0	0	0	1			
NNE	0	ο.	, 0	0	0	0	0			
NE	0	Ο.	0	0	0	0	0			
ENE	0	0	0	0	0	0	· 0			
E	5	o	0	O	0	0	5			
ESE	8	ò	0	. 0	. 0	• 0	8			
SE	2	0.	0	0.	0	0	2			
SSE	2	0	0	0	0	0	2			
S	0	0	0	· O	, 0	0	. 0			
SSW	1	0	0	'0 .	0	o	1			
SW	1	1	0		0 ·	0	2			
WSW	9 ·	2	0	0	0	0	11			
W	.8	0	0	° o	0	0	` 8			
WNW	5	ò	0	0	0	o `	5			
NW	3	0	D	0	0	0	3			
NNW	2	0	0	0.	0	У O	2			
Variable	0	0		0	, Ö	0	0			
Total	47	3	. 0	0	0 [°]	0	50			

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 1 Hours of missing stability measurements in all stability classes:

Period of Record: January - March 2008 Stability Class - Extremely Unstable - 316Ft-33Ft Delta-T (F) Winds Measured at 320 Feet

Wind	Wind Speed (in mph)									
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total			
N	0.	.0	0	0	0	0	. 0			
NNE	0	ö	0	o	0	0	0			
NE	0	0	0	0	·o ·	0-	0			
ENE	0	0	0	0	O.	. 0	0			
Е	0	2	3	0	. 0	o	5			
ESE	o	1.	11	2	O.	0	14			
SE	0	0	2	6	0	0	8			
SSE	0	Q	0	0	0	0	0			
S	0	0	0	0	Ö	0	0			
SSW	.0	0	0	0	0	0 '	0			
SW	o	0	0	0	. 0	0	0			
WSW	0	0	0	0	0	0	0			
Ŵ	0	0	0	0	0	o (0			
WNW	0	0	. :0	0	i o	οj	. 0			
NW	0	Q	0	0	0	o :	· O			
NNW	0	0	0	0	0	0 (0			
Variable	0	0	0	0	0	0	0.			
Total	o	3	16	8	0	0	27			

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes: 17

Period of Record: January - March 2008 Stability Class - Moderately Unstable - 316Ft-33Ft Delta-T (F) Winds Measured at 320 Feet

Wind Speed (in mph)

t-1		and the second sec									
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total				
N	0	1	D	o	0	0	1				
NNE	0	0	0	0	o	0	0				
NE	. 0	0	0	0	0	0	0				
ENE	0	0	0	0	0	0	0				
E	0	0	1	0	0 ·	0	1				
ESE	0	1	2	0	0	0	3				
SE	0	0	1	0	0	0	1				
SSE	0	0	0	0	0	0	0				
S	0	0	0	6	1	0	7				
SSW	0	0	1	1	0	0	2				
SW	0	0	0	• 0	0	0	0				
WSW	0	0	0	0	0	0	0				
W	0	0	1	0	0	0	1				
WNW	0	0	0	0	1	0	1				
NW	0	0	0	0	0	0	0				
NNW	0	0	0	0	0	0	0				
Variable	0	0	0	· 0	0	0	0				
Total	0	2	6	7	2	0	17				

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

Peach Bottom Nuclear Station

Period of Record: January - March 2008 Stability Class - Slightly Unstable - 316Ft-33Ft Delta-T (F) Winds Measured at 320 Feet

Wind Speed (in mph)

tut i met											
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total				
N	0	l	2	0	0	0	3				
NNE	0	Ó	0	0	0 ·	0	0				
NE	0	2	ο	0	0	0	2				
ENE	0	0	0	0	0	0	0				
E	l	1	3	0	0	0	. 5	,			
ESE	0	2	1	1	0	0	4				
SE	o	l	2	2	o	0	5				
SSE	0	0	0	1	0	0	1				
S	•0	0	1	1	1	Q	3				
SSW	0	0	1	0	1	. 0	2				
SW	o	0	0	0	0	0	0				
WSW	0	0,	1	0	0	0	1				
W	0	0	0	٥	2	0	2				
WNW	0	0	1	0	5	3	9				
NW	0	0	1	1	2	. 2	6				
NNW	0	0	5	3	0_	0	8				
Variable	0	0	0	0	0	0	0				
Total	1	7	18	9	11	5	51.				

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

Period of Record: January - March 2008 Stability Class - Neutral - 316Ft-33Ft Delta-T (F) Winds Measured at 320 Feet

Wind Speed (in mph)

taind										
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total			
N	2	20	24	9	1	0	56			
NNE	4	10	15	2	0	0	31			
NE	4	12	3	0	0	0.	19			
ENE	5	7	4	0	· 0 ·	0	16			
Е	4	7	9	1	0	0	21			
ESE	ο ΄	13	27	8	0	0	48			
SE	2	8	31	29	1	0	71			
SSE	0	4	12	12	0	0	28			
S	0	3	13	15	7	2	40			
SSW	0	1	7	11	2	0	21			
SW	0	2	12	3	3	3	23			
WSW	0	1	9	9	2	5	26			
W	l	3	16	22	33	23	98			
WNW	0	.4.,	16	50	62	18	150			
NW	0	6	23	59	52	23	163			
NNW	· 0	28	56	51	46	15	196			
Variable	0	0	0	0	0.	0	0			
Total	22	129	277	281	209	89	1007			

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes: 17

٤.

Period of Record: January - March 2008 Stability Class - Slightly Stable - 316Ft-33Ft Delta-T (F) Winds Measured at 320 Feet

	Wind Speed (in mph)										
Direction	1-3	4 - 7	8-12	13-18	19-24	> 24	Total				
N	3	20	18	5	0	0	46				
NNE	2	12	11	2	0	0	27				
NB	4	11	4	2	ò	0	. 21 .				
ENE	3	16	6	o	0	0	25				
Е	9	10	22	9	1	о	51				
ESE	1	16	32	6	4	0	59				
SE	1	14	21	4	l	1	42				
SSE	7	14	23	14	5	l	64				
S	5	16	17	41	19	6	104				
SSW	4	8	31	9	16	2	70				
SW	3	11	12	6	0	0	32				
WSW	1	7	11	12	3	3	37				
W	4	1	14	35	9	0	63				
WNW	2	3	24	52	10	0	91				
NW	1	7	34	45	7	2	96				
NNW	1	11	28	18	2	0	60				
Variable	0	0	0	0	0	0.	्				
Total	51	177	308	260	77	15	888				

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 1 Hours of missing stability measurements in all stability classes: 17

48

Period of Record: January - March 2008 Stability Class - Moderately Stable - 316Ft-33Ft Delta-T (F) Winds Measured at 320 Feet

Wind Speed (in mph)

Wind Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total
*****	· · · ·	······································				· · · · · · · · · · · · · · · · · · ·	
N	2	0	0	0	0	Q.	2
NNE	0	6	5	. 0	• 0	0.	11
NE	2	4	2	D		0	8
ENE	2	8	5	0	. 0	0	-15
E .	o	1	0	0	o	0	1
ESE	1	4	3	• 0	0	0	8
SE	1	8	2	0	0	0	11
SSE	2	4	. 11	5	. 0	0	22
S	2	. • 8	12	2	0	0	. 24
SSW	. 1	3	7	1	0	0	12
SW	l	2	· 8	0	0	0	11
WSW	2	3.	0	3.	0,1	0	8
. พ	1	1	3	3	0	· 0 ·	8
WNW	. 0	4 ·	2	1	0	0	7
NW	0	4	3	0	0	0	7
NNW	1	2	3	0	0	0	-6
Variable	0	0	0	0΄.	0	0	. 0.
Total	18	62	66	15	0	. 0	161

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes: 17

Peach Bottom Nuclear Station

Period of Record: January - March 2008 Stability Class - Extremely Stable - 316Ft-33Ft DeltarT (F) Winds Measured at 320 Feet

Wind	Wind Speed (in mph)								
Direction	1-3.	4 - *7	8-12	13-18	19-24	> 24	Total		
N	0	1	0	0	0	0	1		
NNE	0	3	0	0	0	0	3		
NE	0	1	0	o	0	0	1		
ENE	0	. 0	1	0	. 0	. 0	l		
E	0	· 0	0	0	0	0	0		
ESE	0	0	0	0	0	0	` 0		
SE	0	Ō	0	0	0	0	0		
SSE	0	1	0	0	0	0	1		
S	0	. 0	0	0	0	o `	0		
SSW	0.	. 0	0	· 0	0	0	· · · 0		
SW	0	0	2	0	0	0	2		
WSW	0	0	1 -	0	0	0	. 1		
W	0	0	3	0	. 0	0	1.3		
WNW	0	0	0	0	0	0	0		
NW	0	0	0	0	0	0	· 0		
NNW	1	ı	.0	o	. 0	0	2		
Variable	0	0	0	0	0	Q.	0		
Total	1	7.	. 7	0	0	Ŭ,	15		

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

Period of Record: April - June 2008 Stability Class - Extremely Unstable - 150Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Wind Speed (in mph)

Wind Direction	1-3	4 - 7	8-12	13-18	19-24	> 24	Total				
N	4	19	l	0	0	0	24				
NNE	13	2	0	0	0	0	15				
NE	10	4	0	0	0	0	14				
ENE	26	2	0	0	0	0	28				
Е	22	7	0	0	0	0	29				
ESE	1.0	12	0	0	0	0	22				
SE	2	11	2	0	0	0	. 15				
SSE	1	3	l	0	o	0	5				
S	0	12	5	0	0	о	17				
SSW	0	1	0	0	0	0	1				
SW	0	1	0	0	0	0	1				
WSW	0	0	0	0	0	0	0				
W	0	2	0	0	0	0	2				
WNW	0	1	l	0	0	0	2				
NW	0	` 8	3	. 0	0	0	11				
NNW	0	26	4	0	о	0	30				
Variable	0	0	0	0	0	0	0				
Total	88	111	17	0	0	0	216				

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 18 • Hours of missing stability measurements in all stability classes: 20

Period of Record: April - June 2008 Stability Class - Moderately Unstable - 150Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Wind Speed (in mph)

Wind							
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total
N	3	10	2	0	0	0	15
NNE	3	2	0	0	0	0	5
NE	8	2	0	0	0	0	10
ENE	6	0	0	0	0	0	6
E	6	1	0	0	0	0	7
ESE	2	3	1	0	0	0	6
SE	0	6	1	0	0	0	7
SSE	0	6	l	0	0	o	7
S	0	7	3	o	0	0	10
SSW	1	1	0	1	0	0	3
SW	0	2	0	0	0	0	2
WSW	0	2	1	0	0	0	3
W	0	4	1	0	0	0	5
WNW	1	6	2	0	0	0	9
NW	1	9	6	4	0	0	20
NNW	1	21	2	0	0	0	24
Variable	0	0	0	0	0	0	0
Total	32	92	20	5	0	0	139

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 2 Hours of missing stability measurements in all stability classes: 20

Period of Record: April - June 2008 Stability Class - Slightly Unstable - 150Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Wind Speed (in mph)

Wind							
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total
*******	**	*****					
N	3	2	1	0	0	.0	6
NNE	3	2	0	0	ο	0	5
NE	3	0	0	0	0	0	3
ENE	0	0	0	0	0.	0	. 0
E	2	0	0	0	0	0	2
ESE	1	0	0	0	0	• 0	1
SE	0	2	0	0	0	0	2
SSE	0	3	1	o ′	0	0	4
S	0	3	0	0	о	0	3
SSW	o	0	· 1	0	o	0	1
SW	0	3	0	Ó	0	0	3
WSW	1	6	• 0	0	о	¹ . O	.7
W	0	4	1	0	0	0	5
WNW	1	3	2	0	0	0	6
NW	0	8	3	0	0	0	11
NNW	3	. 5	0	0	0.	0	8
Variable	0	0	. 0	O	0	0	0
Total	17	41	9	0	0	0	67

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes: 20

•

J

Peach Bottom Nuclear Station

Period of Record: April - June 2008 Stability Class - Neutral - 150Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Wind Speed (in mph)

Wind Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total
N	20	13	7.	0	0	0	40
NNE	18	1	0	0	0	0	19
NE	15	٥	0	. 0	0	0	15
ENE	10	2	0	0	0	0	12
Е	14	0	0	0	0	0	14
ESE	11	5	0	0	0	0	16
SE	0	18	4	0	0	0	22
SSE	8	28	5	. 0	Ó	õ	41
S	3	15	8	O	0.	0	26
SSW	2	10	4	0	0	0	16
SW	4	11	11	0	o	o	26
WSW	3	19	6	0	٥	0	28
W	8	29	6	o	٥	0	43
WNW	6	19	10	2	0	٥	37
NW	3	40	17	1	0	0	61
NNW	15	18	5	0	0	0	38
Variable	0	0	0	0	0	0	0
Total	140	228	83	3	0	0	454

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 15 Hours of missing stability measurements in all stability classes: 20

Peach Bottom Nuclear Station

Period of Record: April - June 2008 Stability Class - Slightly Stable - 150Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

TuT ni an nit	Wind Speed (in mph)								
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total		
N	24	20	21	0	Ō	0	65		
NNE	20	1	6	0	0	0	27		
NE	28	Q	0	0	0	o	28		
ENE	23	0	0	Ö	0	0	23		
Е	31	3	0	0	0	0	34		
ESE	27	5	σ	0	٥	0	32		
SE	35	21	0	0	0	0	56		
SSE	39	29	4	0	0	0	72		
S	36	19	8	0	0	0	63		
SSW	21	20	3	0	۵	o	44		
SW	19	28	6	Ö	` o	0	53		
WSW	18	33	0	0	0	0	51		
W	22	36	2	0	0	0	60		
WNW	19	44	2	0	0	0	65		
NW	16	52	12	0	0	0	80		
NNW	15	32	5	0	0	0	52		
Variable	0	0	́ о	Ö	0	0	0.		
Total	393	343	69	0	0	0	805		

Hours of calm in this stability class: 5 Hours of missing wind measurements in this stability class: 29 Hours of missing stability measurements in all stability classes:

Period of Record: April - June 2008 Stability Class - Moderately Stable - 150Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

	Wind Speed (in mph)									
Wind Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total			
N	2	0	0	0	0	o	2			
NNE	2	0	0	0	0	0	2			
NE	2	O	0	0	0	0	2			
ENE	5	0	0	o	O	0	5			
Е	5	0	0	0	0	0	5			
ESE	6	0	0	0	0	0	6			
SE	6	0	0	Ō	0	0	6			
SSE	4	1	0	0	0	0	. 5			
S	4	З	0	0	0	0	7			
SSW	12	0	0	о	0	0	12			
SW	25	16	0	0	0	0	41			
WSW	30	29	0	٥	0	0	59			
Ŵ	39	24	0	0	Ö	0	63			
WNW	17	5	0	0	0	0	22			
NW	9	3	0	0	0	0	12			
NNW	7	3	0	0.	0	0	10			
Variable	0	0	0	0	0	0	. 0			
Total	175	84	0	0	0	0	259			

Hours of calm in this stability class: 6 Hours of missing wind measurements in this stability class: 5 Hours of missing stability measurements in all stability classes: 20

.

Period of Record: April - June 2008 Stability Class - Extremely Stable - 150Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Wind Speed (in mph) Wind Direction 1-3 4-7 8-12 13-18 19-24 > 24 Total -------------- -- -N 0. NNE NE Ö Ø ENE Е Ö Ö Ö ESE SE SSE S SSW SW WSW Ŵ 1. WNW NW NNW Ó Ó Variable 0. Ö Total

Hours of calm in this stability class: 1 Hours of missing wind measurements in this stability class: 10 Hours of missing stability measurements in all stability classes: 20

.....

Peach Bottom Nuclear Station

Period of Record: April - June 2008 Stability Class - Extremely Unstable - 316Ft-33Ft Delta-T (F) Winds Measured at 320 Feet

Wind Speed (in mph)

Wind										
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total			
N	0	0	~0	0	0	0	0			
NNE	0	0	1	1	0	0	2			
NE	0	0	o	o	0	0	0			
ENE	0	3	1	3	0	0	7			
E	0	7	.4	4	1	.0	16			
ESE	0	6	7	б	0	0	19			
SE	0	0	4	3	1	0	8			
SSE	0	0	0	0	0	0	0			
S	0	0	0	0	0	0	0			
SSW	0	o	0	0	0	0	0			
SW	0	0	0	0	0	0	0			
WSW	0	0	0	0	0	0	0			
W	0	0	0	0	0	.0	0			
WNW	0	0 .	0	o	0	0	0			
NW	٥	0	0	0	0	0	0			
NNW	0	0	2	0	0	0	· 2			
Variable	0	0	0	0	0	0	0			
Total	0	16	19	17	.2	0	54			

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes: 20

Period of Record: April - June 2008 Stability Class - Moderately Unstable - 316Ft-33Ft Delta-T (F) Winds Measured at 320 Feet

Wind Speed (in mph)

Wind			-	•			
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total
N	0	1	6	0	Ō	0	7
NNE	0	1	0	0	o	0	l
NE	0	2	0	0	0	0	2
ENE	0	4	0	· 1	0	0	5
E	0	4	5	1	0	1	11
ESE	0	5	4	1	. 0	1	11
SE	0	1	2	2	1	0	6
SSE	0	0	2	0	0	0	2
S	0	0	2	4	1	0	7
SSW	0	0	3	0	0	0	3
SW	ο	0	0	0	0	0	. 0
WSW	0	0	. 0	0	0	Ö	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	2	0	. 0	2
NNW	0	0	2	3	2	0	7
Variable	0	0	0	0	0	0	. 0
Total	٥	18	26	14	4	2	64
							-

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes: 20

ļ

Peach Bottom Nuclear Station

Period of Record: April - June 2008 Stability Class - Slightly Unstable - 316Ft-33Ft Delta-T (F) Winds Measured at 320 Feet

Wind	Wind Speed (in mph)									
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total			
N	0	2	14	0	0	0	16			
NNE	0	2	1	2	1	0	6			
NE	1	3	0	· o	0	0	4			
ENE	1	6	2	l	0	0	10			
Ε	0 [°]	. 7	2	0	0	0	9			
ESE	0	4	4	1	0	. 1	10			
SE	0	5	б	0	1	0	12			
SSE	0	0	1	2	0	0	3			
S	0	0	5	6	2	0	13			
SSW	0	0	3	0	0	0	3			
SW	0	0	3	0	٥	0	3			
WSW	0	0	1	2	0	0	3			
W	Ó	0	1	0	0	0	1			
WNW	0	0	1	5	ò	0	6			
NW	0	0	4	· 1	3.	1	9			
NNW	0	2	19	8	2	1	32			
Variable	0	0	0	· 0	0	0	0			
Total	2	31	67	28	9	3	140			

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes: 20

Peach Bottom Nuclear Station

Period of Record: April - June 2008 Stability Class - Neutral - 316Ft-33Ft Delta-T (F) Winds Measured at 320 Feet

		Wi	nd Speed	1 (in mpl	h)	b.	
Wind Direction	1-3	4 - 7	8-12	13-18	19-24	> 24	Total
N	0	14	15	19	7	0	55
NNE	2	17	11	10	8	2	50
NE	3	8	11	1	1	0	24
ENE	3	19	14	9	1	0	46
E	5	18	30	. 7	6	0	66
ESE	1	12	15	14	ä	7	52
SE	0	8	26	11	2	1	48
SSE	0	5	29	8	0	0	42
S	0	12	13	21	6	0	52
SSW	1	4	13	9	4	0	31
SW	1	. 5	9	13	6	٥	34
WSW	0	8	7	28	. 9	1	53
W	1	9	20	18	3	3	54
WNW	0	9	23	27	7	2	68
NW	0	8	22	30	13	2	75
NNW	0	16	46	27	9	2	100
Variable	0	0	0	0	0,	0	· O
Total	17	172	304	252	85	20	850

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

V

20

Peach Bottom Nuclear Station

Period of Record: April - June 2008 Stability Class - Slightly Stable - 316Ft-33Ft Delta-T (F) Winds Measured at 320 Feet

Wind Speed (in mph)

Wind										
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total			
N	0	0	9	10	4	0	23			
NNE	2	2	12	1	1	ο.	18			
NE	0	2	9	0	0	13	24			
ENE	1	. 5	10	10	1	0	27			
Е	0.	10	14	2	2	0	28			
ESE	0	14	17	13	1	0	45			
SB	2	3	15	3	0	0	23			
SSE	1	13	14	4	1	0	33			
S	5	12	37	18	13	0	85			
SSW	2	15	30	17	3	0	67			
SW	3	20	28	14	3	0	68			
WSW	2	· 8	20	23	4	0	57			
W	1	7	22	23	3	0	56			
WNW	3	6	15	29	4	0	57			
NW	4	8	23	40	10	0	85			
NNW	5	5	14	22	5	0	51			
Variable	0	0	0	0	0	0	0			
Total	31	130	289	229	55	13	747			

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 1 Hours of missing stability measurements in all stability classes:

Peach Bottom Nuclear Station

Period of Record: April - June 2008 Stability Class - Moderately Stable - 316Ft-33Ft Delta-T (F) Winds Measured at 320 Feet

Wind Speed (in mph)

ì

Wind	······································								
Direction	1-3	4 - 7	8-12	13-18	19-24	> 24	Total		
N	. 0	1	1	1	1	0	4		
NNE	0	2	2	0	o	0	4		
NE	2	l	1	0	0	0	4		
ENE	1	1	1	0	0	0	3		
E	1	1	1	0	0	0	3		
ESE	0.	2	0	0	0	0	2		
SE	2	4	1	0	0	0	7		
SSE	0	5	3	0	0	. o	8		
S	1	4	0	0	0	0	S		
SSW	2	4	1	. 4	0	. <u> </u>	11		
SW	2	9	12	3	0	0	26		
WSW	3	8	16	10	1	0	38		
Ŵ	1	6	14	20	0	0	41		
WNW	Ó	12	3	13	2	0	30		
NW	1	3	10	8	0	0	22		
NNW	0	2	5.	3	, Ó	0	10		
Variable	0	0	0	0	. O	O	0		
Total	16	65	71	62	4	o	218		

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

ţ

Peach Bottom Nuclear Station

Period of Record: April - June 2008 Stability Class - Extremely Stable - 316Ft-33Ft Delta-T (F) Winds Measured at 320 Feet

الد مد أدالية	Wind Speed (in mph)										
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total				
N	i	3	1	0	0	0	5				
NNE	1	3	2	o	0	0	6				
NE	o	2	1	о	0	0-	3				
ENE	0	1	o	0	0	0	1				
E	0	1	0	0	0	0	1				
ESE	0	0	0	0	0	0	0				
SE	1	1	l	0	0	0	3				
SSE	1	0	o	0	. 0	0	1				
S	0	0	4	0	0	0	4				
SSW	0	3	2	l	0	0	6				
SW	0	0	1	0	0	0	ľ				
WSW	٥	1	3	2	0	0	6				
W	0	1	10	б	0	0	17				
WNW	1	5	4	0	0	0	10				
NW	1	6	8	1	Ó	0	16				
NNW	0	4	5	l	0	0	10				
Variable	0	0	0	0	0	0	0				
Total	6	31	42	11	0	0	90				

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

)

Peach Bottom Nuclear Station

Period of Record: July - September 2008 Stability Class - Extremely Unstable - 150Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Wind Speed (in mph)

***	mater open (and topest										
Direction	1-3	4 - 7	8-12	13-18	19-24	> 24	Total				
N	5	6	0	0	0	0	11				
NNE	4	0	0	0	0	0	4				
NE	4	1	0	0	0	0	5				
ENE	9	0	0	0.	0	0	9				
Е	9	1	o	0	0	0	10				
ESE	7	2	. 0	0	0	0	9				
SE	7.	16	0	o	O	• 0	23				
SSE	2	22	3	0	0	0	27				
S	0	4	1	0	0	0	5				
SSW	0	2	0	0	, O	0	2				
SW	. 0	3	3	· 0	0	0	6				
WSW	0	3	0	0	0	0	3				
W	0	0	0	0	0	0	0				
WNW	0	l	0	0	0	0	1				
NW	1	0	0	0	0	0	1				
NNW	5	8	0	0	0	o	13				
Variable	ò	0	0	0	0	0	0				
Total	53	69	7	0	0	0	- 129				

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes: 11

Period of Record: July - September 2008 Stability Class - Moderately Unstable - 150Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Wind Speed (in mph)

5.7 d an .3	with opeca (in mpn)										
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total				
N	4	16	0	0	0	0	20				
NNE	5	3	0	0.	0	0	8				
NE	3	0	0	0	o [.]	0	3				
ENE	9	0	0	0	. 0	0	9				
E	6	0	.0	0.	0	0	.6				
ESE	4	0	0.	0	0	0	4				
SE	0	. 3	0	ο ΄	0	0	3				
SSE	2	16	1	0	0	0	19				
s	0	8	0	0	0	0	8				
SSW	1	5	0	0	0	0	6				
SW	1	4	1	o	0	0	6				
WSW	2 ·	4	0	0	0	0	6				
W	0	1	0	0.	0	0	1				
WNW	i	i	0	0	0	0	2 .				
NW	2	11	0	0	0	0	13				
NNW	í	23	1	0	0.	0	25				
Variable	0	0	0	0	Q	0	0				
Total	41	95	3	0	0	0	139				

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes: 11

Peach Bottom Nuclear Station

Period of Record: July - September 2008 Stability Class - Slightly Unstable - 150Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

١

132 m 2	Wind Speed (in mph)								
Direction	1-3	4 - 7	8-12	13-18	19-24	> 24	Total		
N	l	6	0	0	0	0	7		
NNE	4	0	0	0	0.	0	4		
NE	4	0	0	0	0	0	4		
ENE	0	0	0	0	0	0	0		
Е	2	O_	o	0	0	0	2		
ESE	3	0	0	0	0	0	3		
SE	1	2	· • • ·	0	0	0	3		
SSE	0	4	1	0	0	· 0	5		
S	1	3	0	0	O	0	4		
SSW	0	4	0	0	0	0	4		
SW	2	[`] 5	1	0	0	0	8		
WSW	1	4	0	0	0	0	5		
W	1	ı	0	0	0	ίΟ.	2		
WNW	0	1	0	0	0	0	l		
NW	3	8	0	0	0	0	11		
NNW	1	9	2	• 0	0	0	12		
Variable	0	0	0	0	0	0	0		
Total	24	47	4	0	. 0	0	75		

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

	Period	of R	ecord:	July	-	Sept	ember	2008		
Stability	Class -	Neut	ral			-	150Ft	:-33Ft	Delta-T	(F)
		Winds	Measur	red a	t	33 F	eet			

i

1:1 i m al	Wind Speed (in mph)									
Direction	1-3	4 - 7	8-12	13-18	19-24	> 24	Total			
N	33	41	. 1	0.	0	o	75			
NNE	12	. 2	0	0	0	0	. 14			
NE	15	0	0	0	0	. 0	15			
ENE	9	0	0	0	0	0	9			
E	10	0	0	0	0	0	10			
ESE	5	1	0	0	0	0	6			
SE	7	9	0	0	.0	0	16			
SSE	18	28	з	0	0	0	49			
S	16	9	0	0	0	0	25			
SSW	9	5	0	0	0	0	14			
SW	8	19	1	0	0	0	28			
WSW	11	12	0	0	0	0	23			
W	6	14	0	0	0	0	20			
WNW	14	15	2	0	0	0	31			
NW	18	34	0	0	0	0	52			
NNW	22	36	2	0	0	0	60			
Variable	0	0	0	0	0	0	0			
Total	213	225	9	0	0	0	447.			

Hours of calm in this stability class: 2 Hours of missing wind measurements in this stability class: 2 Hours of missing stability measurements in all stability classes:
Peach Bottom Nuclear Station

Period of Record: July - September 2008 Stability Class - Slightly Stable - 150Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Wind Speed (in mph)

1.1.											
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total				
N .	38	55	. 6	1.	ò	0	100				
NNE	11	3	0	0	0	0	14				
NE	7	· 0	0	0	0	0	7				
ENE	10	0	0	0	٥	0	10				
Е	5	0	0	. 0	· 0	0	5				
ESE	18	0	0.	0	0	0	1.8				
SE	48	30	0	0,	0	. 0	78				
SSE	57	49	1	0	0	Ö	107				
S	46	19	1	0	0	0	66				
SSW	33	10	0	0	0	0	43				
SW	42	25	٦.	0	o	0	68				
WSW	33	15	D	o	0	0	48				
W	32	33	0	0	, · . 0	0	65				
WNW	35	31	0	0	0	0	66				
NW	34	41	3	0	· 0	0	78				
NNW	29	21	3	1	0	0	54				
Variable	0	0	o	0	0	0	0				
Total	478	332	15	2	. 0	0	827				
				· .			•				

Hours of calm in this stability class: 8 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

Peach Bottom Nuclear Station

Period of Record: July - September 2008 Stability Class - Moderately Stable - 150Ft-33Ft Delta-T (F). Winds Measured at 33 Feet

Wind Speed (in mph)

Direction							
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total
N	0	o	0	0	o	0	0
NNE	2	0	0	Ő	O,	0	2
NE	Ó	0	0	0	0	0	0
ENE	1	0	o	o	0	ò	ì
E	0	· 0	0	0	0	0 +	0
ESE	0	0	0	0	0	0	. 0
SE	4	o	0	0	0	0	4
SSE	12	5	0	0	0	0	17
S	17	1	0	0	0	0	18
SSW	17	6	0	0	0	0	23
SW	46	1	0	0	0	о	47
WSW	47	17	0	0	0	0	64
W	36	21	0	0	0.	· 0	57
WNW	26	6	0	o	0	0	32
NW	19	З	0	0	0	0	22
NNW	3	3	0	0	0	0	6
Variable	0	0	0	0	0	0	0
Total	230	63	0	0	Ŏ	o	293

Hours of calm in this stability class: 5 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes: 11

Period of Record: July - September 2008 Stability Class - Extremely Stable - 150Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Wind Speed (in mph)

.

Tild on all	narra abrea (an ubre)								
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total		
n .	0	0	0	0	0	0	0		
NNE	0	0	0	0	0	0	٥		
NB	0	0	0	0	0	0.	0		
ENE	0	0	0	0	0	0	0		
E	0	0	0	0	0	0	0		
ESE	· O	0	0	0	·· 0	0	0		
SE	0	0	0	0	0	0.	0		
SSE	0	0	0	0	0	0	0		
S	0	0	0	0	0	0	0		
SSW	8	1	0	0	0	0	9		
SW	99	3.1	0	0	0	0	130		
WSW	85	8	· 0	0	O	. 0	93		
W	18	13	0	0	0	0	31		
WNW	4	2	0	0	0	0	6		
NW	1	0	0	0	0	o	1		
NNW	0	0	0	0	0	0	0		
Variable	0	0	0	0	0	0	0		
Total	215	55	0	0	0	0	270		

Peach Bottom Nuclear Station

Period of Record: July - September 2008 Stability Class - Extremely Unstable - 316Ft-33Ft Delta-T (F) Winds Measured at 320 Feet

Wind Speed (in mph)

· · · .	remain we want (max life ba)									
Direction	1-3	4 - 7	8-12	13-18	19-24	> 24 ·	Total			
N	0	0	0	0	0	0	0			
NNE	о	0	0	0	0	0	0			
NE	o	l	4	0	0	o :	5			
ENE	0	3	<u>,</u> 5	0	0	ο.	8			
Е	0	5	4	0	0	0	9			
ESE	0	3	10	2	0	0 ⁻	15			
SE	0	· 1	3	0	0	0	4			
SSE	· o	0	1	0	0	0	1			
S	0	0	0	0	0	0	0			
SSW	0	0	0	0	0	0	0			
SW	o	0	0	0	0	0	0			
WSW	0	0	0	0	0	0	0			
W	0	0	0	0	0	0	0			
WNW	0	0	σ	0	0.	0	0			
NW	0	0	0	0	0	0	0			
NNW	0	0	0	Ō	· · O	0	0			
Variable	0	0	0	0	0	0	0			
Total	0	13	27	2	0	0	42			

Period of Record: July - September 2008 Stability Class - Moderately Unstable - 316Ft-33Ft Delta-T (F) Winds Measured at 320 Feet

Wind Speed (in mph) Wind Direction 1-3 4 - 7 8-12 19-24 13-18 > 24 Total ---------_ _ _ _ _ ____ _ _ _ _ _ -----Ν NNE Ũ NE ENE В ESE SE SSE З S SSW Ö SW WSW W WNW NW · · 0 NNW Variable Total

Peach Bottom Nuclear Station.

Period of Record: July - September 2008 Stability Class - Slightly Unstable - 316Ft-33Ft Delta-T (F) Winds Measured at 320 Feet

T.T. 5		Wi	ind Speed	(in mp)	1)	· 8	
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total
N	0	0	2	0	0	0	2
NNE	0	1	2	2	0	o	5
NE	0	6	3	1	· 0	0	10
ENE	1	2	0	1	о	0	4
Е	1	5	1	0	0	0	7
ESE	· 0	3	1	1	0	• •	5
SE	0	2	1	3	0	o	6
SSE	0	2	4	3	0	• •	9
S	0	1	14	1	2	0,	18
SSW	0	2	2	1	0	0	· 5
SW	0	.0	4.	2	0	0.	6
WSW	0	0	7	0	0	Ö	7
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	l	. 1	2	0	0	4
NNW	0	0	8	ı	· 0	0	9
Variable	0	0	0	0.	0	0	0
Total	2	25	50	18	2	0	97
	tada antanta			•			

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

Peach Bottom Nuclear Station

Period of Record: July - September 2008 Stability Class - Neutral - 316Ft-33Ft Delta-T (F) Winds Measured at 320 Feet

••3	Wind Speed (in mph)										
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total				
N	9	24	16	6	0	0	55				
NNE	9	15	22	23	1	٥	70				
NE	6	12	7	10	5	0	40				
ENE	4	10	5	0	0	0	19				
E	12	18	10	2	0	0	42				
ESE	7	4	12	16	1	0	40				
SE	5	8	11	10	. 0	0	34				
SSE	5	5	15	5	0	0	30				
S ·	4	10	17	25	1	0	57				
SSW	ı	10	7	3	٥	0	21				
SW	1	27	19	, 8	· 0	. 0	55				
WSW	2	17	17	4	1	0	41				
W	2	6	20	2	٥	0	30				
WNW	2	14	20	9	2	0	47				
NW	з	19	27	24	. 0	o	73				
NNW	6	36	57	24	1	1	125				
Variable	0	0	0	0	. 0	. 0	• 0				
Total	78	235	282	171	12	1	779				
			a	alla 1 alla		**					

:

)

Peach Bottom Nuclear Station

Period of Record: July - September 2008 Stability Class - Slightly Stable - 316Ft-33Ft Delta-T (F) Winds Measured at 320 Feet

Wind	Wind Speed (in mph)										
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total				
N	0	13	15	10	0	4	42				
NNE	3	14	20	7	10	0	54				
NE	5	9	15	4	· 0	0	33				
ENE	4	17	. 13	3	0	1	. 38				
Е	4	19	20	2	0	0	45				
ESE	5	12	17	5	0	0	39.				
SE	5	12	14	3	0	0	34				
SSE	5	14	25	14	1	0	59				
S	5	26	34	32	3	0	100				
SSW	3	15	42	13	1	Ö	74				
SW	4	16	27	13	0	o	60				
WSW	l	9	20	12	0	0	42				
W	1	6	13	11	0	ò	31				
WNW	4	5	11	28	4	0	52				
NW	2	8	15	38	7	0	70 .				
NNW	2	10	14	14	3	.0	43				
Variable	0	0	0	0	0	0	0				
Total	53	205	315	209	29	- 5	816				

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes: 11

Period of Record: July - September 2008 Stability Class - Moderately Stable - 316Ft-33Ft Delta-T (F) Winds Measured at 320 Feet

Wind Speed (in mph)

Wind	strenikersen en Britenine sterenen issTerset.									
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total			
N	1	11	8	2	0	0	22			
NNE	3	1	3	Ó	0	0	7			
NE	2	4	0	. 0	0	0	6			
ENE	1	2	0	0	0	0	3			
E	1	1	0	0	. 0	0	2			
ESE	· 2.	l	. 0	.0	0	0	3			
SE	0	l	1	0	0	o	2			
SSE	2	4	3	0	0	0	9			
S	2	4	1	5	• • •	0	12			
SSW	1	13	3	5	1	0	23			
SW	3	10	8	3	ò	o	24			
WSW	3	10	16	7	O	о	36			
W	0	8	11	7	0	o	26			
WNW	2	5	8	14	5	0	34			
NW	1	6	10	16	2	0	35			
NNW	4	7.	16	6	.0	0	33			
Variable	0	0	0	0	0	Ô	0			
Total	28	88	88	65	8	0	277			

Peach Bottom Nuclear Station

Period of Record: July - September 2008 Stability Class - Extremely Stable - 316Ft-33Ft Delta-T (F) Winds Measured at 320 Feet

Wind Speed (in mph)

Wind												
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total					
N	1:	9	8	0	0	0	18					
NNE	0	3	3	0	ò	0	6					
NE	0	2	1	0	0	0	3					
ENE	0	0	ı	0	0	0	1					
E	1	0	0	0	0	0	1					
ESE	0	` o	0	0	0	. 0	0					
SE	0	0	0	0	0	0	0					
SSE	0	0	0	0	0	0	0					
S	ı	0	0	0	0	0	1					
SSW	3	0	0	0	0	0	3					
SW	1	1	1	0	0	0	3					
WSW	0	3	5	2	1	0	11					
W	6	4	3	1	Ó	. Q	14					
WNW	2	7	2	5	l	0	17					
NW	5	5	13	2	0	0	25					
NNW	2	14	19	6	0	0	41					
Variable	0	0	0	0	0	0	0					
Total	22	48	56	16	2	0	144					

Hours of calm in this stability class: 1 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

Peach Bottom Nuclear Station

Period of Record: October - December2008 Stability Class - Extremely Unstable - 150Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Wind Speed (in mph) Wind Direction 4-7 8-12 13-18 19-24 > 24 1-3 Total ____ ----_ _ _ _ _ _ _ _ _ _ _____ N 0. NNE NE ENE Е ESE .0 SE SSE s <u></u>0 SSW Û SW Ö WSW W WNW Ũ NW Ö NNW Variable Total

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

Period of Record: October - December2008 Stability Class - Moderately Unstable - 150Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Wind Speed (in mph)

रार्ड में प्रकार	er man an fin an er en er er fin er er er fin er									
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total			
N	5	9	3	0	0	0	17			
NNE	4	з	0 -	0	o	0	. 7			
NE	6	0	0	о	0	0	6			
ENE	6	0	0	0	0	0	6			
E	7	0	0	0	0	0	7			
ESE	1	0	0	0	0	0	1			
SE	0	4	0	0	0	.0	4			
SSE	0	4	3	0	0	0	7			
S	0	2	1	0	0	0	3			
SSW	1	3	0	о	0	0	4			
SW	0	4	0	0	0	0	4			
WSW	0	3	4	0	0	0	7			
W	0	2	4	1	0	0	7			
WNW	0	5	12	1	0	Ö	18			
NW	3	8	10	0	0	o	21			
NNW	0	7	5	0	0	0	12			
Variable	0	0	0	0	0	٥	0			
Total	33	54	42	2	0	0	131			

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes: 10

Period of Record: October - December2008 Stability Class - Slightly Unstable - 150Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Wind Speed (in mph)

111	•						
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total
N	6	9	2	, o	0	0	17
NNE	1	0.	0	0	0	0.	1
NE	4	0	0	0	0	0	4.
ENE	2	0	0	0	0	0	2
E	0	0	0	0	0	Ö	Ö
ESE	3	0	0	· .0	0	0	. 3
SE	1	1	1	٥.	0	0	3
SSE	1	2	0	0	. 0	0	3
S	1	1	1	0	0	0.	3
SSW	0	3	1	0	0	0	4
SW	1	• 0	ò	Q	o	Q	1
WSW	٥	2	i	0	0	0	3
W	0	7	7	1	0	0	15
WNW	0	3	11	ı	0	0	15
NW	i	2	11	l	2	0	17
NNW	3	3	4	0	0	0	10
Variable	0	0	0	٥	0,	: 0	0
Total	24	33	39	3	2	0	101

Period of Record: October - December2008 Stability Class - Neutral - 156 Winds Measured at 33 Feet - 150Ft-33Ft Delta-T (F) Wind Speed (in mph) Wind 4 - 7 13-18 19-24 Total 8-12 > 24 Direction 1-3 **. .** ---------_____ -----.... N NNE NE ENE Ε ESE SE SSE S SSW . 7 SW WSW W WNW NW NNW Variable Total

Peach Bottom Nuclear Station

Hours of calm in this stability class: 5 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes: 10

Period of Record: October - December2008 Stability Class - Slightly Stable - 150Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Wind Speed (in mph)

	states and a state states									
Wind Direction	1-3	4 - 7	8-12	13-18	19-24	> 24	Total			
N	10	27	8	0	0	0	45			
NNE	17	3	1	0	0	0	21			
NE	14	.0	0	Ý O	0	0	14			
ENE	20	0	0	0	0	0	20			
Ε	24	0	0	0	0	0	24			
ESE	15	3	0	0	0	0	18			
SE	37	16	8	0	٥	0	61			
SSE	22	25	1	0	0	0	48			
S	22	26	16	1 ·	0	0	65			
SSW	9	12	2	0	0	0	23			
SW	21	44	2	0	0	0	67			
WSW	16	68	0	0	0	0	84			
W	25	- 69	. 12	• 0.	0	· 0	106			
WNW	22	58	15	0	0	0	95			
NW	14	32	-4	0	0	0.	50			
NNW	18	26	1	0	0	0	45			
Variable	0	0	0	0	0	0	0			
Total	306	409	70	1	0	0	786			

Period of Record: October - December2008 Stability Class - Moderately Stable - 150Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Wind Direction	1-3	4 - 7	8-12	13-18	19-24	> 24	Total
N	2	0	 0	0	0	0	2
NNE	2	0	0	0	0	0	2
NED			ů o	. · .	õ	, O	-
INE .	-		0	0	0	0	~
ENE	7	0	0	U	0	0	1
Е	7	0	0	0	0	0 ·	7
ESE	5	0	0	0	0	0	5
SE	8	0	o	.0	0	0	8
SSE	3	0	0	0	0	0	3
S	4	o	o	o	o	o	4
SSW	10	1	Ó	٥	0	o	11
SW	19	6	0	0	0	0	25
WSW	30	16	0	o	.0	0	46
W	19	16	0	0	0	0	35
WNW	12	4	0	0	0	0	16
NW	15	2	0	о	0	0	17
NNW	4	0	0	0	o	0	4
Variable	0	0	0	0	Ο.	• 0	0
Total	149	45	0	0	0	0	194

Wind Speed (in mph)

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 1 Hours of missing stability measurements in all stability classes: 10

Period of Record: October - December2008 Stability Class - Extremely Stable - 150Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Wind Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total
******				****			
N	- 0	0	0	0.	0	Ó	• 0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0.	0	0	0	0	0	0
E	3	0	0	0	0	0	3
ESE	0	0	0	0	0	່	0
SE	0	0	0	0	O	0	0
SSE	1	0	0	0	0	0	1
S	4	0	0	0	0	0	4
SSW	3	0	0	o	0	0	3
SW	31	17	0	0	0	0	48
WSW	31	.5	o	0	0	0	36
W	.19	• 0	· 0	0	0	0	19
WNW	8	0	0	0	0	0	8
NW	1	0	0	0	0	0	1
NNW	0	0	0	0	٥	0	0
Variable	0	Ö	0	0	0	0	0
Total	101	22	0	0	0	0	123

Wind Speed (in mph)

Facility: Peach Bottom Units 2 & 3

Peach Bottom Nuclear Station

Period of Record: October - December2008 Stability Class - Extremely Unstable - 316Ft-33Ft Delta-T (F) Winds Measured at 320 Feet

દાર કે આ ત્યી		Wind Speed (in mph)							
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total		
N	0	0	0	0	0	0	. 0		
NNE	0	0	0	0	0	0	0		
NE	0	1	0	0	0	o	1		
ENE	0	3	0	0	0	0	3		
E	0	0	l	0	0	0	1		
ESE	o	1	4	0	0	0	5		
SE	0	0	0	0	0	0	0		
SSE	0	0	0	0	0	0	0		
S	Ø	0	0	0	0	0	0		
SSW	0	0	0	0	0	0	0		
SW	0	0	0	0	0	0	0		
WSW	0	0	0	0	0	0	0		
W	0	0	0	0	. O ,	0	0		
WNW	0	0	0	0	0	0	0		
NW	0	0	0	0	0	0	0		
NNW	0	0	0	0	0	0	0		
Variable	0	•0	0	0	0	0	0		
Total	0	5	5	0	0	0	10		

Period of Record: October - December2008 Stability Class - Moderately Unstable - 316Ft-33Ft Delta-T (F) Winds Measured at 320 Feet

litina	Wind Speed (in mph)							
Direction	1-3	.4 - 7	8-12	13-18	19-24	> 24	Total	
N	0	0	0	. 0	0	0	0	
NNE	0	0	0	0	0	0	0	
NE	0	0	1	0.	0	0	1	
ENE	0	0	0	0	0	o	0	
Е	0	2	0	0	0	0	2	
ESE	0	1	о	o	0	0	1	
SE	0	0	1	0	0	0	1	
SSE	0	0	Ō	0	0	0	0	
S	0	· 0	0	0	0 .	0	0	
SSW	0	0	0	0	0	0	0	
SW	0	0	0	0	0	0	0	
WSW	0	0	0	0	0	0	0	
W	0	0	0	0	0	0	0	
WNW	0	0	· 0	0	0	· 0	0	
NW	0	0	-0	. 0	0	o	0	
NNW	. o	Q	1	0	•0	0	1	
Variable	0	0	0	0	0	o	Ó	
Total .	0	3	3	0	0	0	6	

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

Period of Record: October - December2008 Stability Class - Slightly Unstable - 316Ft-33Ft Delta-T (F) Winds Measured at 320 Feet

Wind Speed (in mph)							
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total
XT		· .					
IN .	•	1	-L.		Ŭ	U .	2
NNE	0	• 0	3	3	0	0	6
NE	0	0	0	0	0	0	0
ENE	2	3	• 0	0	0	0	5
E	1	0	0	0	0	0	1
ESE	0	1	0	0	0	0	1
SE	0	0	2	0	0	0	2
SSE	0	0	1	2	1	0;	4
S	0	0	0	3	0	0	3
SSW	0	1	0	0	0	0	1
SW	0	0	з	1.	0	0	4
WSW	0	0	2	0 .	· 0	1	. 3
W	· 0	0	0	3	0	3	6
WNW	0	0	1	1	4	1	7
NW	0	0	2	4	0	0	6
NNW	0	0	2	1	Ĩ	0	4
Variable	0	0	0	0	0	0	0
Total	з	6	17	18	6	5.	55

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes: 10

Period of Record: October - December2008 Stability Class - Neutral - 316Ft-33Ft Delta-T (F) Winds Measured at 320 Feet

tit da mati		Wi	nd Speed	1 (in mpl	<u>n)</u>		
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total
N	5	20	30	50	19	0	124
NNE	2	11	24	16	1	0	54
NE	4	10	8	2	o	0	24
ENE	3	15	10	0	0	0	. 28
Е	9	13	10	3	1	0	36
ESE	5	8	8	5	1	0	27
SE	1	7	19	3	5	1	36
SSE	2	9	24	20	2	2	59
S	0	11	28	22	15	1	77
SSW	0	6	11	5	8	2	32
SW	1	.8	13	5	5	1	33
WSW	1	5	. 14	9	. 7	0	36
W	0	1	17	33	51	20	122
WNW	2	4	37	47	40	26	156
NW	2	13	33	52	38	17	155
NNW	l	20	18	27	9	0	75
Variable	0	0	0	0	0	0	0
Total	38	161	304	299	202	70	1074

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes: 10

)

Peach Bottom Nuclear Station

Period of Record: October - December2008 Stability Class - Slightly Stable - 316Ft-33Ft Delta-T (F) Winds Measured at 320 Feet

Wind Speed (in mph)

Wind								
Direction	1-3	4 - 7	8-12	13-18	19-24	> 24	Total	
	~~~~	*****	*****				·	
N	3	7	23	8	2	0	43	
NNE	6	11	16	8	3	0	44	
NE	2	7	6	0	0	0.	15	
ENE	• 4	6	5	0	0.	0	15	
Е	4	8	9	3	0	0	24	
ESE	6	8	8	5	1	٥	28	
SE	2	15	14	2	5	0	38	
SSE	1	12	32	9	1	· 1	56	
S	1	12	39	25	11	3	91	
SSW	3	14	12	9	5	, o	43	
SW	2	7	15	20	6	1	51	
WSW	2	9	18	31	3	0	63	
· W	1	4	20	77	16	1 (	119	
WNW	1	5	24	24	8	1	63	
NW	3	14	24	28	4	0	73	
NNW	2	7	17	14	2	o	42	
Variable	0	0	0	0	0	0 · ·	0	
Total	43	146	282	263	67	7	808	

Hours of calm in this stability class: 1 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes: 10

.

ַם

~

١

#### Peach Bottom Nuclear Station

### Period of Record: October - December2008 Stability Class - Moderately Stable - 316Ft-33Ft Delta-T (F) Winds Measured at 320 Feet

Wind Speed (in mph)										
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total			
N	0	7	3	0	0	0	10			
NNE	0	1	5	0	• 0	0	6			
NE	l	4	1	0	0	0	6			
ENE	o	4	0	0	0	0	4			
Е	0	4	1.	0.	0	· 0	5			
ESE	0	3	3	1	• 0	0	7			
SE	0	4 、	l	1	0	0	6			
SSE	0	4	9	0	0	0	13			
S	0	2	3	0	0	0	5			
SSW	0	4	6	2	0	0	12			
SW	ı	6	5	6	4	0	22			
WSW	o	6	12	7	0	0	25			
W	· ī	l	1	3	2	o	8			
WNW	0	3	4	9	, 1	0	17			
NW	1	1	<b>.</b> 8	1	0	0	11			
NNW	0	1	8	3	0	0	12			
Variable	0	0	o	0	ο .	0	0			
Total	4	55	70	33	7	0	169			

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes: 10

,

١.

#### Peach Bottom Nuclear Station

Períod of Record: October - December2008 Stability Class - Extremely Stable - 316Ft-33Ft Delta-T (F) Winds Measured at 320 Feet

Wind Speed (in mph)								
Direction	1-3	4-7	8-12	13-18	19-24	> .24	Total	
N	2	7	0	0	0	0	9	
NNE	0	1	5	0	o	0	6	
NE	1	0	0	0	0	0	1	
ENE	1	o	0	0	0	0	l	
Е	1	1	` o	o	0	o	2	
ESE	0	0	0	о	0	0	0	
SE	1	2	0	0	٥	0	3	
SSE	0	٥	0	0	0	. 0	0	
S	0	0	0	0	0	0	0	
SSW	1	0	0	0	0	0	1	
SW	0	4	з	1	0	0	8	
WSW	0	2	9	1	0	0	12	
W	2	З	4	2	0	0	11	
winw	1	1	6	1	0	0	9	
NW	0	1	4	0	0	0	5	
NNW	0	2	5	0	0	· 0 · †	7	
Variable	0	0	0	0	0	0	0	
Total	10	24	36	5	0	0	75	

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes: 10

.

92

1

.

Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

## Appendix A- ERRATA Data Section

(Page Intentionally Left Blank)

Facility: Peach Bottom Units 2 & 3

### **ERRATA DATA Section**

The following list contains errors that were previously submitted in the 2007 Radiation Dose Assessment Report No.23 and the 2007 Radioactive Effluent Report No.50, also attached are the revised pages

Radioactive Effluent Report								
Page # in original report	Section	Error						
12	9.A Liquid	Last sentence omitted, all LLD's were satisfied for 2007						
17	Attachment 2	Quarter Gamma Beta Dose, Iodine 131&133, Tritium & particulate Dose Included						
18	Attachment 2	Iodine's reported in Particulates section as well as the Iodine's section, however, the total remains correct, iodine's were already subtracted out in the original submission						

Dose Assessment Report							
Page # in original report	Section	Error					
1	1.Executive Summary	Maximum Dose for Liquids was changed from 1.89E-02 to 2.59 E-02 (0.43%); Total quantity of Radioactive Material was changed from 1.72E-01 to 7.75E-01 (7.75%)					
6	B. Gaseous Pathway model	The year in paragraph 3 was changed to 2007					

Facility: Peach Bottom Units 2 & 3

8. Changes to the ODCM:

There were no changes to the ODCM for the 2007 reporting period.

- 9. Minimum Detectable Concentrations:
  - A. Liquid:

If a radionuclide was not detected, < LLD was reported for that isotope. Samples were analyzed with techniques that achieved the required Lower Limits of Detection (LLD) as specified in Offsite Dose Calculation Manual Specification Table 4.8.B.1, Radioactive Liquid Waste Sampling and Analysis.

### B. Gaseous:

If a radionuclide was not detected, < LLD was reported for that isotope. Samples were analyzed with techniques which achieved the required Lower Limits of Detection (LLD) as specified in Offsite Dose Calculation Manual Specification Table 4.8.C.1, Radioactive Gaseous Waste Sampling and Analysis from Main Stack and Vent Stack. In all cases, the LLD requirements were satisfied.

### Attachment 2

`

### Gaseous Effluents - Summation Of All Releases

Period: 2007

Unit: Peach Bottom Units 2 & 3

A. Fission & Activation Gases	Unit	Quarter	Quarter	Quarter 3	Quarter 4	Est. Total Error %
1. Tatal Dalacea	Ci	9 105 01	1 525,02	1 905,02	1 165 02	2.515.01
1. Total Release		0.10E+01	1.526+02	1.092+02	1.10E+02	3.51E+01
2. Average release rate for the period	µCi/sec	1.03E+01	1.93E+01	2.40E+01	1.47E+01	
3. Percent of ODCM limit - Gamma	0/	3.27E-02	1.41E-01	7.49E-02	7.36E-02	
- Beta	%	1.30E-02	5.02E-02	2.92E-02	2.67E-02	
4. Quarterly Gamma Dose	mrad	3.27E-03	1.41E-02	7.49E-03	7.36E-03	
5. Quarterly Beta Dose	mrad	2.59E-03	1.00E-02	5.84E-03	5.33E-03	

B. lodine						
1. Total iodine - 131	Ci	1.666E-03	1.950E-03	3.469E-03	1.253E-03	1.76E+01
2. Average release rate for period	µCi/sec	2.113E-04	2.474E-04	4.400E-04	1.590E-04	
3. Percent of ODCM limit	%	*	*	*	*	

C. Particulates						
1. Particulates with half-lives > 8 days	Ci	9.690E-03	1.129E-02	1.508E-02	4.84E-03	1.94E+01
2. Average release rate for the period	µCi/sec	1.229E-03	1.431E-03	1.913E-03	6.14E-04	
3. Percent of ODCM limit	%	*	*	*	*	
3. Gross alpha radioactivity	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td></td></lld<></td></lld<>	<lld< td=""><td></td></lld<>	
D. Tritium						
1. Total release	Ci	8.461E+00	5.844E+00	2.329E+01	1.552E+01	1.11E+01
2. Average release rate for the period	µCi/sec	1.073E+00	7.412E-01	2.955E+00	1.97E+00	
3. Percent of ODCM limit	%	*	*	*	*	

E. Iodine 131 & 133, Tritium & Particulate					
1. Percent of ODCM limit	%	5.403E-03	1.679E+00	7.319E+00	2.834E+00
2. Quarterly Dose	mrem	8.105E-04	2.519E-01	1.098E+00	4.250E-01

* Limit is no longer applicable to iodine and particulate. Section E provides limit.

### Attachment 2

### Gaseous Effluents for Elevated Release Point - Main Stack

Period: 2007

### Unit: Peach Bottom Units 2 & 3

NUCLIDES RELEASED		CONTINUOUS MODE				BATCH MODE			
1. Fission gases	Unit	Quarter	Quarter	Quarter	Quarter	Quarter	Quarter	Quarter	Quarter
		1	2	3	4	1	2	3	4
Kr-85	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Kr-85m	Ci	1.23E+01	1.70E+01	2.45E+01	1.93E+01	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Kr-87	Ci	1.12E+00	4.78E-01	1.16E+00	1.48E-01	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Kr-88	Ci	6.79E+00	1.08E+01	1.49E+01	1.27E+01	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Xe-133	Ci	1.98E+01	3.16E+01	7.01E+01	3.81E+01	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Xe-135	Ci	2.46E+00	3.92E+00	3.62E+00	2.20E+00	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Xe-135m	Cì	2.26E+00	2.35E+00	3.42E+00	1.51E+00	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Xe-138	Ci	2.43E+01	3.13E+01	4.42E+01	1.47E+01	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Ar-41	Ci	2.45E-01	7.61E-01	<lld< td=""><td>2.81E-01</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	2.81E-01	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Xe-133m	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Unidentified	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Total for Period	Ci	6.93E+01	9.83E+01	1.62E+02	8.88E+01	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
2. lodines			8 Z - 3 A Q					8. A.	
1-131	Ci	3.25E-04	4.89E-04	6.52E-04	3.16E-04	<lld< td=""><td><lld< td=""><td>·<lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td>·<lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	· <lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
1-133	Ci	7.51E-04	1.20E-03	1.35E-03	4.13E-04	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
I-135	Ci	2.35E-04	6.87E-04	8.88E-04	7.51E-05	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Total for Period	Ci	1.31E-03	2.38E-03	2.89E-03	8.04E-04	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
3. Particulates	_			s an sea an sea			CO CO CAR	16. N. C. N.	
Mn-54	Ci	<lld< td=""><td><lld< td=""><td>9.80E-06</td><td>7.50E-06</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td>9.80E-06</td><td>7.50E-06</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	9.80E-06	7.50E-06	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Co-58	Ci	<lld< td=""><td><lld< td=""><td>1.25E-06</td><td>1.36E-06</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td>1.25E-06</td><td>1.36E-06</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	1.25E-06	1.36E-06	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Co-60	Ci	<lld< td=""><td>5.02E-06</td><td>2.90E-05</td><td>2.13E-05</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	5.02E-06	2.90E-05	2.13E-05	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Zn-65	Ci	<lld< td=""><td><lld< td=""><td>3.21E-06</td><td>5.61E-06</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td>3.21E-06</td><td>5.61E-06</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	3.21E-06	5.61E-06	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Sr-89	Ci	6.20E-04	7.58E-04	5.47E-04	1.73E-04	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Sr-90	Ci	2.13E-06	2.45E-06	1.96E-06	5.50E-07	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Sb-125	Ci	<lld< td=""><td>1.54E-06</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	1.54E-06	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Cs-137	Ci	8.93E-06	6.33E-06	4.01E-06	6.29E-06	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Ba-140	Ci	8.99E-04	6.85E-04	4.11E-04	6.97E-04	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Ce-141	Ci	<lld< td=""><td><lld< td=""><td>4.29E-07</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td>4.29E-07</td><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	4.29E-07	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
La-140	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Cs-134	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Total for Period	Ci	1.53E-03	1.46E-03	1.01E-03	9.12E-04	<lld< td=""><td><lld< td=""><td><lld< td=""><td>  <lld td=""  <=""></lld></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td>  <lld td=""  <=""></lld></td></lld<></td></lld<>	<lld< td=""><td>  <lld td=""  <=""></lld></td></lld<>	<lld td=""  <=""></lld>

#### Peach Bottom Atomic Power Station 2007 Radiation Dose Assessment Report

#### EXECUTIVE SUMMARY

In accordance with the reporting requirements of Peach Bottom Offsite Dose Calculation Manual Specifications (ODCMS) Sections 3.8.E.2 and 3.10.3, this report summarizes the radiation doses due to the radioactive effluent releases from Peach Bottom Atomic Power Station Units 2 and 3 for the period January 1, 2007 through December 31, 2007.

The 2007 calculated doses were compared to the appropriate ODCMS and Appendix I Design Objective limits (Table I-1). The maximum offsite total body dose, due to liquid releases was **2.59 E-02 mrem.** The maximum offsite total body dose, due to gaseous releases was **2.06E-01 mrem**.

# TABLE I-1 COMPARISON OF THE 2007 CALCULATED DOSES RESULTING FROM PBAPS EFFLUENT RELEASES TO ODCMS LIMITS

CATEGORY	OOSE PATHWAY	MAXIMUM DOSE FROM PBAPS	% of A	ODCMS AND APPENDIX I DESIGN OBJECTIVE ANNUAL LIMITS A
· · · · · · · · · · · · · · · · · · ·	Liquid Effluents			
a.	Dose to total body from all pathways	2.59E-02	0.43%	6 mrem
. <b>b</b> .	Dose to any organ from all pathways	2.44E-02	0.12%	20 mrem
c.	Total quantity of radioactive material, except tritium and dissolved gases	7.75E-01	7.75%	10 Ci
II.	Gaseous Effluents *			
a	Gamma air dose	2.91E-01	1.46%	20 mrad
b.	Beta air dose	5.61E-02	0.14%	40 mrad
c.	Dose to total body of an individual	2.06E-01	2.06%	10 mrem
d.	Dose to skin of an individual	2.73E-01	0.91%	30 mrem
e.	Dose to any organ (thyroid) from all pathways	5.48E+00	18.27%	30 mrem
f.	Total quantity of	8.34E-03	0.42%	2 Ci

10CFR50 Appendix I specifies dose from noble gases only for Category II (a, b, c and d).
 PBAPS doses presented for Category II (c and d) items include noble gas and particulate components.

Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

Ł

Peach Bottom Atomic Power Station 2007 Radiation Dose Assessment Report

The annual average X/Q, depleted X/Q and D/Q values were computed for gaseous radioactive effluents from the Unit 2 and Unit 3 off-gas stack and roof vents, using the dispersion methodologies of USNRC Regulatory Guide 1.111 (Ref. 7).

Using GASPAR, two bounding dose calculations were performed for the receptor locations with the highest X/Q from the Unit 2 and Unit 3 roof vents (I54A, 1,300 feet E) and from the Unit 2 and Unit 3 off-gas stack (2068A, 14,520 feet N) (Figures VI-1 and VI-2, respectively). Gaseous release pathways considered included external radiation from the air and ground, inhalation and ingestion of vegetation, meat, and cow's milk. The inhalation and ingestion pathways were evaluated for the adult, teenager, child, and infant age groups. To assure that this analysis was conservative, it was assumed that all pathways existed at these two locations.

In addition to the bounding dose analysis calculation, an analysis for determining the doses from gaseous radioactive effluents to members of the public due to their activities inside the site boundary during 2007 was completed to comply with ODCMS Section 3.10.3. For purposes of this report, the security checkpoint (I14A) located 1,300 feet N of the PBAPS Unit 2 and Unit 3 roof vents was chosen (Figure VI-1). This on-site location was used for measuring inhalation, plume and ground shine doses to the National Guardsmen and State Police. Continuous occupancy was assumed.

Approximately 127 Ci of unidentified gaseous radioactive effluent activity released from PBAPS in 2007 were assigned to Kr-88 for calculating the Gamma Air, Beta Air and Plume doses. Kr-88 has the highest dose factor for gamma air dose, which is normally limiting, therefore the analysis remains conservative.

## Facility: Peach Bottom Units 2 & 3

Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

Appendix B- Revised Copy of the ODCM

ì

Licensee: Exelon Generation Company, LLC PSEG Nuclear, LLC

(Page Intentionally Left Blank)