ENCLOSURE 1

RADIOACTIVE EFFLUENT RELEASE REPORT FOR JANUARY 1 – DECEMBER 31, 2008

NUCLEAR MANAGEMENT COMPANY MONTICELLO NUCLEAR GENERATING PLANT License No. DPR-22

RADIOACTIVE EFFLUENT RELEASE REPORT Period : Jan - Dec 2008

Supplemental Information

1. Regulatory Limits - Quarterly levels requiring reporting to Nuclear Regulatory Commission

A. Noble Gases :

5 mrad/quarter gamma radiation 10 mrad/quarter beta radiation

B. Long Lived Iodines, Particulates, and Tritium :

7.5 mrem/quarter dose to any organ

C. Liquid Effluents :

1.5 mrem/quarter dose to the total body
5.0 mrem/quarter dose to any organ

- 2. Maximum Permissible Concentrations
 - A. Noble Gases :

10 CFR Part 20, Appendix B, Table II, Column 1

B. Long Lived Iodines, Particulates, and Tritium :

10 CFR Part 20, Appendix B, Table II, Column 1

C. Liquid Effluents :

10 CFR Part 20, Appendix B, Table II, Column 2 2.0 E-4 uci/ml for dissolved and entrained gases

3. Average Energy

(Not Applicable)

Supplemental Information (continued)

- 4. Measurements and Approximations of Total Radioactivity
 - A. Noble Gases :

Continuous gross activity monitors in Reactor Building Vent and Plant Stack exhaust streams. Weekly isotopic analysis of exhaust streams.

B. Iodines in Gaseous Effluent :

Continuous monitoring with charcoal cartridges in Reactor Building Vent and Plant Stack exhaust streams with weekly analysis.

C. Particulates in Gaseous Effluent :

Continuous monitoring with particulate filters in Reactor Building Vent and Plant Stack exhaust streams with weekly analysis.

D. Tritium in Gaseous Effluent :

Weekly grab samples from Reactor Building Vent and Plant Stack exhaust streams.

E. Liquid Effluents :

Tank sample analyzed prior to each planned release and continuous monitoring of gross activity during planned release.

5. Batch Releases

A. Liquid :

B. Gaseous :

1. Number of Batch Releases	2	
2. Total Time Period for Batch Releases	1357.0	min
3. Maximum Time Period for a Batch Release	996.0	min
4. Average Time Period for a Batch Release	678.5	min
5. Minimum Time Period for a Batch Release	361.0	min

Supplemental Information (continued)

6. Abnormal Releases

A. Liquid :

	1. Number of Releases 2. Total Activity Released	0 0.0	Ci
в.	Gaseous :		
	1. Number of Releases 2. Total Activity Released	0 0.0	Ci

Table 1A Gaseous Effluents - Summation of all Releases

	.st Qtr	2nd Qtr	Est. Total Error, %
--	---------	---------	------------------------

A. Fission & Activation gases

1. Total Release	Ci	1.43E+02	2.54E+02	2.00E+01
2. Average Release Rate	uci/sec	1.84E+01	3.23E+01	
3. Percent Tech Spec Qtrly				
Reporting Level				
Gamma Radiation	80	6.43E-02	1.15E-01	
Beta Radiation	00	2.34E-02	3.89E-02	

B. Iodines

1. Total I-131 Release	Ci	8.45E-04	2.19E-03	1.00E+01
2. Average I-131 Release Rate	uci/sec	1.09E-04	2.79E-04	

C. Particulates

1. Total Particulates	Ci	2.87E-04	1.52E-03	3.00E+01
2. Average Release Rate	uci/sec	3.70E-05	1.93E-04	
3. Gross Alpha Radioactivity	Ci	1.14E-06	4.79E-07	

D. Tritium

1. Total Release	Ci	6.05E+00	6.29E+00	1.00E+01
2. Average Release Rate	uci/sec	7.78E-01	7.99E-01	

E. Percent Qtrly Tech Spec Reporting Levels

1. Iodines, Particulates,			
and Tritium	00	1.34E-01	3.69E-01

Table 1A Gaseous Effluents - Summation of all Releases

Units	3rd Qtr	4th Qtr	Est. Total
			Error, 🗞

A. Fission & Activation gases

1. Total Release	Ci	2.65E+02	3.97E+02	2.00E+01
2. Average Release Rate	uci/sec	3.34E+01	5.00E+01	
3. Percent Tech Spec Qtrly				
Reporting Level				
Gamma Radiation	00 00	1.34E-01	3.07E-01	
Beta Radiation	00	3.83E-02	8.06E-02	

B. Iodines

1. Total I-131 Release	Ci	4.19E-03	5.08E-03	1.00E+01
2. Average I-131 Release Rate	uci/sec	5.27E-04	6.39E-04	

C. Particulates

1. Total Particulates	Ci	5.88E-04	8.71E-04	3.00E+01
2. Average Release Rate	uci/sec	7.40E-05	1.10E-04	•
3. Gross Alpha Radioactivity	Ci	5.51E-07	5.78E-07	

D. Tritium

1. Total Release	Ci	9.07E+00	9.87E+00	1.00E+01
2. Average Release Rate	uci/sec	1.14E+00	1.24E+00	,

E. Percent Qtrly Tech Spec Reporting Levels

1. Iodines, Particulates,		1	
and Tritium	olo	5.35E-01	1.00E+00

 $\hat{}$

RADIOACTIVE EFFLUENT RELEASE REPORT Period : Jan - Dec 2008

Table 1B Gaseous Effluents - Elevated Releases

		Continuo	ous Mode	Batch Mode		
Nuclides Released	Unit	lst Qtr	2nd Qtr	lst Qtr	2nd Qtr	

1. Fission Gases

KR-85M	Ci	4.08E-01	4.22E-01	0.00E+00	0.00E+00
KR-87	Ci	2.09E+00	2.47E+00	0.00E+00	0.00E+00
KR-88	Ci	1.59E+00	1.74E+00	0.00E+00	0.00E+00
KR-89	Ci	6.22E+00	1.73E+01	0.00E+00	0.00E+00
XE-133	Ci	3.64E+01	7.55E+01	0.00E+00	0.00E+00
XE-133M	Ci	5.77E-01	2.16E+00	0.00E+00	0.00E+00
XE-135	Ci	4.94E+00	1.23E+01	0.00E+00	0.00E+00
XE-135M	Ci	9.03E+00	1.97E+01	0.00E+00	0.00E+00
XE-137	Ci	5.16E+01	7.81E+01	0.00E+00	0.00E+00
XE-138	Ci	2.66E+01	3.68E+01	0.00E+00	0.00E+00
Total for Period	Ci	1.39E+02	2.46E+02	0.00E+00	0.00E+00

2. Iodines

I-131	Ci	4.63E-04	1.13E-03	0.00E+00	0.00E+00
I-133	Ci	4.40E-03	1.22E-02	0.00E+00	0.00E+00
I-135	Ci	8.13E-03	2.26E-02	0.00E+00	0.00E+00
Total for Period	Ci	1.30E-02	3.60E-02	0.00E+00	0.00E+00

CO-60	Ci	6.32E-07	5.61E-07	0.00E+00	0.00E+00
BA-140	Ci	5.02E-05	1.01E-04	0.00E+00	0.00E+00
SR-89	Ci	1.72E-05	2.63E-06	0.00E+00	0.00E+00
SR-90	Ci	1.24E-07	9.68E-09	0.00E+00	0.00E+00
Total for Period	Ci	6.81E-05	1.04E-04	0.00E+00	0.00E+00

Table 1B Gaseous Effluents - Elevated Releases

,	:	Continuc	ous Mode	Batch Mode		
Nuclides Released	Unit	3rd Qtr	4th Qtr	3rd Qtr	4th Qtr	

1. Fission Gases

KR-85M	Ci	4.73E-01	8.02E-01	1.09E-01	0.00E+00
KR-87	Ci	2.65E+00	4.07E+00	0.00E+00	0.00E+00
KR-88	Ci	1.70E+00	2.69E+00	3.76E-02	0.00E+00
KR-89	Ci	2.91E+01	5.62E+01	0.00E+00	0.00E+00
XE-133	Ci	6.77E+01	7.93E+01	2.07E+01	1.33E-02
XE-133M	Ci	1.87E+00	2.31E+00	4.01E-01	0.00E+00
XE-135	Ci	1.08E+01	1.26E+01	3.66E+00	0.00E+00
XE-135M	Ci	1.17E+01	2.00E+01	0.00E+00	0.00E+00
XE-137	Ci	7.16E+01	1.38E+02	0.00E+00	0.00E+00
XE-138	Ci	3.42E+01	5.78E+01	0.00E+00	0.00E+00
Total for Period	Ci	2.32E+02	3.74E+02	2.49E+01	1.33E-02

2. Iodines

I-131	Ci	2.49E-03	1.75E-03	5.64E-07	7.11E-09
I-133	Ci .	1.54E-02	1.81E-02	1.60E-06	0.00E+00
I-135	Ci	2.67E-02	3.39E-02	9.75E-07	0.00E+00
Total for Period	Ci	4.46E-02	5.37E-02	3.14E-06	7.11E-09

CR-51	Ci	3.23E-06	0.00E+00	0.00E+00	0.00E+00
MN-54	Ci	1.35E-07	0.00E+00	0.00E+00	0.00E+00
CO-58	Ci	8.13E-08	0.00E+00	0.00E+00	0.00E+00
CO-60	Ci	1.13E-06	0.00E+00	0.00E+00	0.00E+00
ZN-65	Ci	1.62E-07	0.00E+00	0.00E+00	0.00E+00
NB-95	Ci	4.91E-08	0.00E+00	0.00E+00	0.00E+00
CS-137	Ci	3.10E-06	9.85E-08	0.00E+00	0.00E+00
BA-140	Ci	1.67E-04	1.81E-04	0.00E+00	0.00E+00
CE-141	Ci	2.42E-07	7.69E-08	0.00E+00	0.00E+00
CE-144	Ci	9.77E-07	1.81E-07	0.00E+00	0.00E+00
SR-89	Ci	1.75E-04	6.83E-05	0.00E+00	0.00E+00
SR-90	Ci	3.41E-07	4.58E-07	0.00E+00	0.00E+00
Total for Period	Ci	3.51E-04	2.50E-04	0.00E+00	0.00E+00

Table 1C Gaseous Effluents - Building Vent Releases

		Continuc	ous Mode	Batch Mode		
Nuclides Released	Unit	1st Qtr	2nd Qtr	lst Qtr	2nd Qtr	

1. Fission Gases

XE-135	Ci	3.47E+00	5.81E+00	0.00E+00	0.00E+00
XE-135M	Ci	0.00E+00	1.73E+00	0.00E+00	0.00E+00
			,		
Total for Period	Ci	3.47E+00	7.54E+00	0.00E+00	0.00E+00

2. Iodines

I-131	Ci	3.81E-04	1.06E-03	0.00E+00	0.00E+00
I-133	Ci	2.55E-03	9.38E-03	0.00E+00	0.00E+00
I-135	Ci	0.00E+00	1.51E-02	0.00E+00	0.00E+00
Total for Period	Ci	2.93E-03	2.55E-02	0.00E+00	0.00E+00

CO-60	Ci	7.91E-05	1.22E-04	0.00E+00	0.00E+00
CS-137	Ci	9.07E-05	3.91E-05	0.00E+00	0.00E+00
BA-140	Ci	2.37E-05	9.76E-05	0.00E+00	0.00E+00
SR-89	Ci	2.58E-05	1.15E-03	0.00E+00	0.00E+00
SR-90	Ci	0.00E+00	8.40E-06	0.00E+00	0.00E+00
Total for Period	Ci	2.19E-04	1.41E-03	0.00E+00	0.00E+00

Table 1C Gaseous Effluents - Building Vent Releases

	-	Continuous Mode		Batch Mode	
Nuclides Released	Unit	3rd Qtr	4th Qtr	3rd Qtr	4th Qtr

1. Fission Gases

XE-133	Ci	1.49E+00	2.00E+00	0.00E+00	0.00E+00
XE-135	Ci	4.22E+00	9.04E+00	0.00E+00	0.00E+00
XE-135M	Ci	2.94E+00	1.23E+01	0.00E+00	0.00E+00
XE-138	Ci	0.00E+00	2.62E-01	0.00E+00	0.00E+00
Total for Period	Ci	8.65E+00	2.36E+01	0.00E+00	0.00E+00

2. Iodines

I-131	Ci	1.70E-03	3.33E-03	0.00E+00	0.00E+00
I-133	Ci	1.19E-02	3.81E-02	0.00E+00	0.00E+00
I-135	Ci	1.92E-02	9.04E-02	0.00E+00	0.00E+00
Total for Period	Ci	3.28E-02	1.32E-01	0.00E+00	0.00E+00

	<u></u>			0.007.00	0.000
CR-51	Ci	0.00E+00	2.69E-06	0.00E+00	0.00E+00
CO-60	Ci	4.10E-05	4.21E-05	0.00E+00	0.00E+00
CS-137	Ci	2.54E-05	3.02E-05	0.00E+00	0.00E+00
BA-140	Ci	1.27E-04	4.40E-04	0.00E+00	0.00E+00
CE-141	Ci	1.20E-06	6.10E-06	0.00E+00	0.00E+00
SR-89	Ci	4.20E-05	9.97E-05	0.00E+00	0.00E+00
Total for Period	Ci	2.37E-04	6.21E-04	0.00E+00	0.00E+00

Table 2A Liquid Effluents - Summation of all Releases

Units	lst Qtr	2nd Qtr	Est. Total
			Error, %

A. Fission & Activation products

1. Total Release (not including				
tritium, gases, alpha)	Ci	0.00E+00	0.00E+00	0.00E+00
2. Avg Diluted Concentration	uci/ml	0.00E+00	0.00E+00	,

B. Tritium

1. Total Release	Ci	0.00E+00	0.00E+00	0.00E+00
2. Avg Diluted Concentration	uci/ml	0.00E+00	0.00E+00	

C. Dissolved and Entrained Gases

1.	Total Release	Ci	0.00E+00	0.00E+00	0.00E+00
2.	Avg Diluted Concentration	uci/ml	0.00E+00	0.00E+00	

D. Percent Qtrly Tech Spec Reporting Level

1. Whole Body Dose	0/0	0.00E+00	0.00E+00
2. Organ Dose	0\0	0.00E+00	0.00E+00

E. Gross Alpha Radioactivity

1. Total Release Ci 0.00E+00 0.00E+00 0.00	E+00
--	------

F. Volume of Waste Released Liters 0.00E+00 0.00E+00 0.00E+00

F. Volume of Dilution Water Used Liters 0.00E+00 0.00E+00 0.00E+00

Table 2B Liquid Effluents

		Continuo	ous Mode	Batch	Mode
Nuclides Released	Unit	lst Qtr	2nd Qtr	1st Qtr	2nd Qtr

None Released This Period

Table 2A Liquid Effluents - Summation of all Releases

,	Units	3rd Qtr	4th Qtr	Est. Total
· · · · · · · · · · · · · · · · · · ·			· · · · · · · · · · · · · · · · · · ·	Error, %

A. Fission & Activation products

1	1. Total Release (not including				
	tritium, gases, alpha)	Ci	0.00E+00	0.00E+00	0.00E+00
1	2. Avg Diluted Concentration	uci/ml	0.00E+00	0.00E+00	

B. Tritium

1. Total Release	Ci	0.00E+00	0.00E+00	0.00E+00
2. Avg Diluted Concentration	uci/ml	0.00E+00	0.00E+00	

C. Dissolved and Entrained Gases

1. Total Release	Ci	0.00E+00	0.00E+00	0.00E+00
2. Avg Diluted Concentration	uci/ml	0.00E+00	0.00E+00	•

D. Percent Qtrly Tech Spec Reporting Level

1. Whole Body Dose	0/0	0.00E+00	0.00E+00
2. Organ Dose	olo	0.00E+00	0.00E+00

E. Gross Alpha Radioactivity

1. Total Release Ci 0.00E+00 0.00E+00 0.00E+00

F. Volume of Waste Released Liters 0.00E+00 0.00E+00 0.00E+00

F. Volume of Dilution Water Used Liters 0.00E+00 0.00E+00 0.00E+00

Table 2B Liquid Effluents

		Continue	ous Mode	Batch	Mode
Nuclides Released	Unit	3rd Qtr	4th Qtr	3rd Qtr	4th Qtr

None Released This Period

Table 3 Solid Waste and Irradiated Fuel Shipments A. Solid Waste Shipped Offsite for Burial or Disposal (not irradiated fuel)

1. Type of Waste	Units	12-month	Est. Total
		Period	Error, 🗞
A. Spent resins, filter sludges,	Cu. Meter	1.17E+01	
evaporator bottoms, etc.	Ci (est)	2.03E+01	3.70E+01
B. Dry compressible waste,	Cu. Meter	2.63E+02	
contaminated equipment, etc.	Ci (est)	9.00E+00	3.50E+01
C. Irradiated components,	Cu. Meter	7.05E+00	
control rods, etc.	Ci (est)	2.86E+04	3.50E+01
D. Other (describe)	Cu. Meter	1.57E+01	
	Ci (est)	1.25E+01	3.50E+01

2. Estimate of ma	or nuclide	compositior	n (by type d	of waste)
	Туре А	Туре В	Туре С	Type D
Nuclide	percent	percent	percent	percent
H-3	5.56E-01	5.63E-01	3.04E-03	
C-14	7.42E-01	7.02E-01	9.49E-03	
Cr-51		4.87E-04		
Mn-54	3.83E+00	3.86E+00	1.83E+00	3.18E+00
Fe-55	2.50E+01	2.51E+01	4.56E+01	3.41E+01
Co-58	2.66E-01	2.80E-01	9.39E-02	
Fe-59		8.28E-05		
Ni-59		1.32E-04	2.55E-02	
Co-60	2.94E+01	2.99E+01	4.60E+01	3.76E+01
Ni-63	1.53E+00	1.49E+00	5.38E+00	1.03E+00
Zn-65	3.11E+00	3.23E+00	2.50E-03	4.59E+00
Sr-89		1.49E-03		
Sr-90	5.20E-02	5.61E-02	6.24E-06	
Tc-99		5.28E-06	2.50E-05	
Ag110m	2.61E-01	2.62E-01		
Sb-124	1.00E-02	9.56E-03		× .
Sb-125	3.50E-02	3.25E-02		
Cs-134		1.39E-04		
Cs-137	3.50E+01	3.42E+01	1.12E-04	1.82E+01
Ba-140	1.00E-03	6.63E-03		
Ce-141	2.20E-02	2.46E-02		
Ce-144	1.53E-01	1.52E-01		
Np-237		5.47E-06		
Pu-238	1.00E-03	1.09E-03		
Pu-239	1.00E-03	1.03E-03		
Am-241	5.00E-03	5.28E-03		
Pu-241	2.20E-02	2.64E-02	4.24E-05	
Cm-242	1.00E-03	9.78E-04		
Cm-243	2.30E-02	1.99E-03		
				1

Table 3 Solid Waste and Irradiated Fuel Shipments

3. Solid waste disposal

Number of	Mode of	Destination	
Shipments	Transportation		
3	Truck	Chem-Nuc Inc., Barnwell, SC.	
4	Truck	Envirocare, Clive, UT.	
6	Truck	RACE Inc., Memphis, TN.	
		-	•

B. Irradiated Fuel Shipments

1. Disposition

Number of	Mode of	Destination
Shipments	Transportation	

None This Period

C. Shipping Container and Solidification Method

No.	Volume	Activity	Type of	Container	Solidification
	МЗ	Ci	Waste	Code	Code
08-06	3.79E+01	1.49E-01	В	L	N
08-07	5.89E+01	2.40E-01	В	L	N
08-15	5.83E+00	8.48E+00	A	${ m L}$	D
08-11	4.26E+01	4.75E-03	В	${ m L}$	· N
08-13	5.83E+00	8.51E+00	В	\mathbf{L}	D
08-18	3.78E+00	8.92E+01	С	В	N
08-21	1.64E+00	1.27E+04	C ·	В	N
08-31	1.64E+00	1.58E+04	C	В	N
08-38	5.89E+01	4.92E-02	В	${ m L}$	N
08-59	4.70E+00	1.25E+01	D	A	N
08-62	1.10E+01	1.09E-02	D	L	N
08-66	5.89E+01	4.81E-02	В	Ĺ	N
08-69	5.83E+00	1.18E+01	A	L	D

Waste type Codes :

Container Codes :

L - LSA

B - Dry waste, equipment

C - Irradiated components

A - Spent resins, sludges

- А Туре А
- В Туре В
- Solidification Codes :
 - C Cement
 - U Urea Formaldehyde
 - D Dewatering
- Q Large Quantity N Not Applicalble

D - Other (describe)

Table 5.3

Sample Type	Analysis	Location	Collection Date or Period	Reason for not conducting REMP as required	Plans for Preventing Recurrence
AP/AI	Beta, I-131	M-02	5/28/2008	Sampler pump failure, open fuse.	Sampler pump was replaced.
AP/AI	Beta, I-131	M-05	7/9/2008	Sampler pump failure, sampler head leakage.	Sampler pump was replaced.
MI	Gamma, I-131	M-28	4/9/2008- 12/31/2008	Hoglund Farm no longer in the dairy business.	Pasture grass collections were initiated at locations M-41, M-42, M-43 in Sept. 2008
TLD	Ambient Gamma	M-01B	1st. Qtr. 2008	Missing in the field	None required.
TLD	Ambient Gamma	M-01S	2nd. Qtr. 2008	Missing in the field	None required.
TLD	Ambient Gamma	M-01S	4th. Qtr. 2008	Missing in the field	None required.
во	Gamma	M-08, M-09	Oct., 2008	Collection missed due to unsafe river conditions.	None required.
sw	Surface Water Gamma	M-08	Jan, Feb, Mar, 2008	Missed due to unsafe ice.	None required.
		M-08	Dec, 2008	Three of five weekly samples missed due to unsafe ice.	None required.

14

ENCLOSURE 2

OFF-SITE RADIATION DOSE ASSESSMENT FOR JANUARY 1 – DECEMBER 31, 2008

MONTICELLO NUCLEAR GENERATING PLANT

Offsite Radiation Dose Assessment for January 1, - December 31, 2008

An assessment of radiation dose due to releases from the Monticello Nuclear Generating Plant during 2008 was performed in accordance with the Offsite Dose Calculation Manual (ODCM). Computed doses were well below the 40 CFR 190 Standards and 10 CFR Part 50, Appendix I Guidelines.

Offsite dose calculation formulas and meteorological data from the Offsite Dose Calculation Manual were used in making this assessment. Source terms were obtained from the Radioactive Effluent Release Report for 2008.

Offsite Dose from Gaseous Releases (ODCM –08.01 section 2.1.3)

Computed dose due to gaseous releases are reported in Table 1. Critical receptor location and pathways for organ dose are reported in Table 2. Whole body and organ dose due to gaseous releases are a small percentage of Appendix I Guidelines.

Offsite Dose From Liquid Releases

(ODCM –08.01 section 2.1.3)

Dose from liquid releases are listed in Table 1.

Dose to Individuals Due to Their Activities Inside the Site Boundary (ODCM –08.01 section 2.1.3)

Computed dose to the whole body, skin and organ (thyroid), are reported in Table 1. There are several groups of concern, Security Officers training at the rifle range at the old EPA station, cleaning contractors at the new Receiving Warehouse and XCEL Energy Company transmission and distribution crews working in the substation. Use of a very conservative assumption of 40 hours/week spent inside the site boundary by these groups would conservatively represent the most exposed individual. The annual whole body, skin and organ dose was computed using plant stack and reactor building vent X/Q and D/Q values for the Substation (a bounding location due to predominant wind direction and nearness to the release points) as input to the GASPAR code. This computed dose was reduced by the factor of 40/168 to account for limited occupancy.

Dose to the Likely Most Exposed Member of the General Public from Reactor Releases and Other Nearby Uranium Fuel Cycle Sources (ODCM -08.01 section 2.1.4)

There are no other uranium fuel facilities in the vicinity of the Monticello site. The only artificial source of exposure to the general public in addition to the plant effluent releases is from direct radiation of the reactor and the steam turbines.

An Independent Spent Fuel Storage Facility (ISFSI) was constructed west of the plant in 2007. Preoperational monitoring for gamma and neutron dose has been completed. The initial loading campaign was completed in 2008 with 10 HCM's loaded with spent fuel.

Environmental TLDs were used to provide data on direct and skyshine radiation dose and the GASPAR code was used to provide data on dose from airborne pathways.

TLD results from the area of the site boundary and the 5 mile ring show no significant differences between these TLD's and the control TLD's.

Therefore, the likely most exposed member of the general public will not receive an annual radiation dose from reactor effluent releases and all other fuel cycle activities in excess of 40 CFR 190 standards of 25 millirem to the whole body, 75 millirem to the thyroid, and 25 millirem to any other organ.

Changes in Land Use and Non Obtainable Milk or Vegetable Samples

(ODCM –08.01 sections 2.1.8 and 2.1.9)

There were no changes in land use resulting in significant increases in calculated doses. Milk samples were unavailable at sample location M-28 (Hoglund Farm) after 4/09/08 due to the farm going out of business. Land use census results show that there were no other indicator sample locations to replace this farm. As a result of the last dairy farm going out of business, control milk samples at location M-10 were discontinued at the end of 2008. Vegetation sampling was initiated at locations M-41, M-42 and M-43 in September 2008 as a replacement for milk sampling.

Table 1

Offsite Radiation Dose Assessment - Monticello

	· · · · · · · · · · · · · · · · · · ·	
		10CFR50 Appendix I
GASEOUS RELEASES	DOSE	Guidelines
Maximum Site Boundary Gamma Air Dose	0.019	
(mrad/year)		10
Maximum Site Boundary Beta Air Dose	0.018	
(mrad/year)		20
Maximum Off-Site Dose to Any Organ		
(mrem/year)	0.084	15
Maximum Dose to the Likely Most Exposed		
Member of the General Public (mrem/year)		
Whole Body	0.036	5
Skin	0.035	15
Max Organ (Thyroid)	0.084	15
LIQUID RELEASES		
Maximum Off-Site Dose (mrem)	-	
Whole Body	0.00	3
Max Organ (All except bone)	0.00	10
		40 CFR 190
GASEOUS RELEASES	DOSE	LIMITS
Maximum Dose to Individuals due to their		
Activities Inside the Site Boundary (mrem)		
Whole Body	0.038	25
Thyroid	0.064	· 75 `
Max Other Organ (Skin)	0.048	25

PERIOD: January 1, through December 31, 2008

Table 2

Offsite Radiation Dose Assessment - Monticello Supplemental Information

	·		
GASEOUS RELEASES			
Maximum Site Boundary Dose Location		· · ·	
(from Reactor Building Vents)			
Sector	SS	SE	
Distance (miles)	0.	40	
Substation			
Sector	S		
Distance from Plant Stack (miles)	0.2		
Distance from Reactor Building Vents	0.2		
Critical Receptor Location			
r			
Sector	SSW		
Distance from Reactor Building Vents (miles)	0.64		
Pathways	Plume, Ground, Inhalation, Vegetable		
Age Group	CHILD		
Organ	THYROID		
LIQUID RELEASES			
St. Paul Drinking Water Intake Location		· · · · ·	
Pathways	Drinking Water	Drinking Water, Fish	
Age Group	Infant	Adult	
Organ	Whole Body	GI Tract	
Dilution Factor (drinking water)	7:1	7:1	

PERIOD: January 1, through December 31, 2008

Bases for Radiation Dose Statements

Thermoluminescent dosimeters (TLD) are stationed around MNGP to measure the ambient gamma radiation field. Monitoring stations are placed near the site boundary and approximately five (5) miles from the reactor, in locations representing sixteen (16) compass sectors. Other locations are chosen to measure the radiation field at places of special interest such as nearby residences, meeting places and population centers. Control sites are located further than ten (10) miles from the site, in areas that should not be affected by plant operations. The results from the TLD's are reported in the Annual Radiological Environmental Monitoring Report (REMP). The results from this effort indicated no excess dose to offsite areas.

Additionally, NUREG-0543, METHODS FOR DEMONSTRATING LWR COMPLIANCE WITH THE EPA URANIUM FUEL CYCLE STANDARD (40 CFR PART 190) states in section IV, "As long as a nuclear plant site operates at a level below the Appendix I reporting requirements, no extra analysis is required to demonstrate compliance with 40 CFR Part 190". The organ and whole body doses reported in Table 1 are determined using 10 CFR 50 Appendix I methodology. The doses reported are well below the limits of Appendix I.