

NUREG-1437
Supplement 37

Generic Environmental Impact Statement for License Renewal of Nuclear Plants

Supplement 37

Regarding Three Mile Island Nuclear Station, Unit 1

Final Report

AVAILABILITY OF REFERENCE MATERIALS IN NRC PUBLICATIONS

NRC Reference Material

As of November 1999, you may electronically access NUREG-series publications and other NRC records at NRC's Public Electronic Reading Room at <http://www.nrc.gov/reading-rm.html>.

Publicly released records include, to name a few, NUREG-series publications; *Federal Register* notices; applicant, licensee, and vendor documents and correspondence; NRC correspondence and internal memoranda; bulletins and information notices; inspection and investigative reports; licensee event reports; and Commission papers and their attachments.

NRC publications in the NUREG series, NRC regulations, and *Title 10, Energy*, in the Code of *Federal Regulations* may also be purchased from one of these two sources.

1. The Superintendent of Documents
U.S. Government Printing Office
Mail Stop SSOP
Washington, DC 20402-0001
Internet: bookstore.gpo.gov
Telephone: 202-512-1800
Fax: 202-512-2250
2. The National Technical Information Service
Springfield, VA 22161-0002
www.ntis.gov
1-800-553-6847 or, locally, 703-605-6000

A single copy of each NRC draft report for comment is available free, to the extent of supply, upon written request as follows:

Address: U.S. Nuclear Regulatory Commission
Office of Administration
Reproduction and Mail Services Branch
Washington, DC 20555-0001

E-mail: DISTRIBUTION@nrc.gov
Facsimile: 301-415-2289

Some publications in the NUREG series that are posted at NRC's Web site address <http://www.nrc.gov/reading-rm/doc-collections/nuregs> are updated periodically and may differ from the last printed version. Although references to material found on a Web site bear the date the material was accessed, the material available on the date cited may subsequently be removed from the site.

Non-NRC Reference Material

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, and transactions, *Federal Register* notices, Federal and State legislation, and congressional reports. Such documents as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings may be purchased from their sponsoring organization.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at—

The NRC Technical Library
Two White Flint North
11545 Rockville Pike
Rockville, MD 20852-2738

These standards are available in the library for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from—

American National Standards Institute
11 West 42nd Street
New York, NY 10036-8002
www.ansi.org
212-642-4900

Legally binding regulatory requirements are stated only in laws; NRC regulations; licenses, including technical specifications; or orders, not in NUREG-series publications. The views expressed in contractor-prepared publications in this series are not necessarily those of the NRC.

The NUREG series comprises (1) technical and administrative reports and books prepared by the staff (NUREG-XXXX) or agency contractors (NUREG/CR-XXXX), (2) proceedings of conferences (NUREG/CP-XXXX), (3) reports resulting from international agreements (NUREG/IA-XXXX), (4) brochures (NUREG/BR-XXXX), and (5) compilations of legal decisions and orders of the Commission and Atomic and Safety Licensing Boards and of Directors' decisions under Section 2.206 of NRC's regulations (NUREG-0750).

Generic Environmental Impact Statement for License Renewal of Nuclear Plants

Supplement 37

Regarding Three Mile Island Nuclear Station, Unit 1

Final Report

Manuscript Completed: June 2009
Date Published: June 2009



ABSTRACT

This supplemental environmental impact statement (EIS) has been prepared in response to an application submitted by Exelon Generation Company, LLC to renew the operating license for Three Mile Island Nuclear Station, Unit 1 for an additional 20 years.

This supplemental EIS includes the preliminary analysis that evaluates the environmental impacts of the proposed action and alternatives to the proposed action. Alternatives considered include replacement power from new supercritical coal-fired generation and natural gas combined-cycle generation; energy conservation/energy efficiency; and a combination of alternatives that included natural gas combined-cycle generation, conservation/efficiency, and improvements to hydroelectric dams; and not renewing the license (the no-action alternative).

The NRC has determined that the adverse environmental impacts of license renewal for Three Mile Island Nuclear Station, Unit 1 are not so great that preserving the option of license renewal for energy-planning decisionmakers would be unreasonable. This determination is based on (1) the analysis and findings in the GEIS; (2) the Environmental Report submitted by Exelon Generation; (3) consultation with Federal, State, and local agencies; (4) the NRC staff's own independent review; and (5) the NRC staff's consideration of public comments received during the scoping process and draft supplement EIS comment period.

Table of Contents

Abstract	iii
Executive Summary	xv
Abbreviations and Acronyms	xxiii
1.0 Purpose and Need for Action	1-1
1.1 Proposed Federal Action	1-1
1.2 Purpose and Need for the Proposed Federal Action	1-1
1.3 Major Environmental Review Milestones	1-2
1.4 Generic Environmental Impact Statement	1-3
1.5 Supplemental Environmental Impact Statement	1-5
1.6 Cooperating Agencies	1-6
1.7 Consultations	1-6
1.8 Correspondence	1-7
1.9 Status of Compliance	1-9
1.10 References	1-11
2.0 Affected Environment	2-1
2.1 Facility Description	2-1
2.1.1 Reactor and Containment Systems	2-1
2.1.2 Radioactive Waste Management	2-5
2.1.2.1 Radioactive Liquid Waste	2-6
2.1.2.2 Radioactive Gaseous Waste	2-7
2.1.2.3 Solid Radioactive Waste	2-8
2.1.3 Nonradiological Wastes	2-9
2.1.3.1 Hazardous Waste	2-9
2.1.3.2 Residual Waste	2-10
2.1.3.3 Universal Waste	2-10
2.1.3.4 Mixed Waste	2-10
2.1.3.5 Permitted Discharges	2-11
2.1.3.6 Pollution Prevention and Waste Minimization	2-11
2.1.4 Plant Operation and Maintenance	2-12
2.1.5 Power Transmission System	2-12
2.1.6 Cooling and Auxiliary Water Systems	2-14
2.1.7 Facility Water Use and Quality	2-15
2.1.7.1 Ground Water Use	2-15
2.1.7.2 Surface Water Use	2-15
2.1.7.3 Surface Water Quality	2-16
2.2 Affected Environment	2-21
2.2.1 Land Use	2-21
2.2.2 Air and Meteorology	2-22

Table of Contents

2.2.2.1	Regional Air Quality Impacts.....	2-25
2.2.3	Ground Water Resources.....	2-25
2.2.3.1	TMI-1 Water Supply Wells.....	2-26
2.2.3.2	TMI-1 Monitoring Wells.....	2-27
2.2.4	Surface Water Resources.....	2-28
2.2.5	Description of Aquatic Resources.....	2-31
	Macroinvertebrates.....	2-31
	Plankton.....	2-32
	Fish.....	2-32
2.2.6	Terrestrial Resources.....	2-35
2.2.7	Threatened and Endangered Species.....	2-38
2.2.7.1	Aquatic Species.....	2-38
2.2.7.2	Terrestrial Species.....	2-39
	Federally Protected and Formerly Protected Terrestrial Species.....	2-39
	State Protected Terrestrial Species.....	2-40
2.2.8	Socioeconomic Factors.....	2-49
2.2.8.1	Housing.....	2-50
2.2.8.2	Public Services.....	2-51
	Water Supply.....	2-51
	Education.....	2-52
	Transportation.....	2-53
2.2.8.3	Offsite Land Use.....	2-54
	Dauphin County.....	2-54
	Lancaster County.....	2-55
2.2.8.4	Visual Aesthetics and Noise.....	2-56
2.2.8.5	Demography.....	2-57
	Transient Population.....	2-59
	Migrant Farm Workers.....	2-60
2.2.8.6	Economy.....	2-62
	Employment and Income.....	2-62
	Unemployment.....	2-63
	Taxes.....	2-63
2.2.9	Historic and Archaeological Resources.....	2-65
2.2.9.1	Cultural Background.....	2-65
2.2.9.2	Historic and Archaeological Resources.....	2-68
2.3	Related Federal and State Activities.....	2-70
2.4	References.....	2-71
3.0	Environmental Impacts of Refurbishment.....	3-1
3.1	Refurbishment Activities at TMI-1.....	3-2
3.2	Environmental Impacts of Refurbishment.....	3-4
3.2.1	Terrestrial Resources – Refurbishment Impacts.....	3-5
3.2.2	Threatened and Endangered Species.....	3-6
	3.2.2.1 Terrestrial Species.....	3-6
	3.2.2.2 Aquatic Species.....	3-6
3.2.3	Air Quality During Refurbishment (Non-Attainment and Maintenance Areas).....	3-7

Table of Contents

3.2.4	Housing Impacts.....	3-10
3.2.5	Public Services – Education (Refurbishment).....	3-10
3.2.6	Public Services – Public Utilities.....	3-10
3.2.7	Public Services – Transportation.....	3-11
3.2.8	Offsite Land Use (Refurbishment).....	3-12
3.2.9	Historic and Archaeological Resources.....	3-12
3.2.10	Environmental Justice.....	3-13
3.3	Evaluation of New and Potentially Significant Information on Impacts of Refurbishment.....	3-13
3.4	Summary of Impacts of Refurbishment.....	3-14
3.5	References.....	3-14
4.0	Environmental Impacts of Operation.....	4-1
4.1	Land Use.....	4-1
4.2	Air Quality.....	4-1
4.3	Ground Water.....	4-2
4.3.1	Ground Water Use Conflicts (plants using greater than 100 gpm).....	4-2
4.3.2	Ground Water Use Conflicts (make-up from a small river).....	4-2
4.4	Surface Water.....	4-3
4.4.1	Water Use Conflicts.....	4-4
4.5	Aquatic Resources.....	4-5
4.6	Terrestrial Resources.....	4-6
4.7	Threatened or Endangered Species.....	4-7
4.7.1	Aquatic Species.....	4-7
4.7.2	Terrestrial Species.....	4-7
4.8	Human Health.....	4-9
4.8.1	Generic Human Health Issues.....	4-9
4.8.2	Microbiological Organisms – Public Health.....	4-12
4.8.3	Electromagnetic Fields – Acute Effects (Electric Shock).....	4-15
4.8.4	Electromagnetic Fields – Chronic Effects.....	4-17
4.9	Socioeconomics.....	4-17
4.9.1	Generic Socioeconomic Issues.....	4-18
4.9.2	Housing Impacts.....	4-18
4.9.3	Public Services: Public Utility Impacts.....	4-19
4.9.4	Offsite Land Use – License Renewal Period.....	4-20
	Population-Related Impacts.....	4-20
	Tax Revenue-Related Impacts.....	4-21
4.9.5	Public Services: Transportation Impacts.....	4-21
4.9.6	Historic and Archaeological Resources.....	4-22
4.9.7	Environmental Justice.....	4-24
	Minority Population in 2000.....	4-26
	Low-Income Population in 2000.....	4-26
	Analysis of Impacts.....	4-29
	Subsistence Consumption of Fish and Wildlife.....	4-29

Table of Contents

4.10	Evaluation of New and Potentially Significant Information.....	4-31
4.11	Cumulative Impacts.....	4-32
4.11.1	Cumulative Impacts on Water Resources.....	4-32
4.11.2	Cumulative Impacts on Aquatic Resources.....	4-34
4.11.3	Cumulative Impacts on Terrestrial Resources.....	4-37
4.11.4	Cumulative Human Health Impacts.....	4-39
4.11.5	Cumulative Socioeconomic Impacts.....	4-41
4.11.6	Summary of Cumulative Impacts.....	4-42
4.12	References.....	4-43
5.0	Environmental Impacts of Postulated Accidents.....	5-1
5.1	Design Basis Accidents.....	5-1
5.2	Severe Accidents.....	5-2
5.3	Severe Accident Mitigation Alternatives.....	5-3
5.3.1	Introduction.....	5-3
5.3.2	Estimate of Risk.....	5-4
5.3.3	Potential Plant Improvements.....	5-6
5.3.4	Evaluation of Risk Reduction and Costs of Improvements.....	5-7
5.3.5	Cost-Benefit Comparison.....	5-7
5.3.6	Conclusions.....	5-9
5.4	References.....	5-9
6.0	Environmental Impacts of the Uranium Fuel Cycle and Solid Waste Management.....	6-1
6.1	References.....	6-2
7.0	Environmental Impacts of Decommissioning.....	7-1
7.1	References.....	7-1
8.0	Environmental Impacts of Alternatives.....	8-1
8.1	Supercritical Coal-Fired Generation.....	8-3
8.1.1	Air Quality.....	8-5
	Sulfur Oxides.....	8-6
	Nitrogen Oxides.....	8-6
	Particulates.....	8-7
	Carbon Monoxide.....	8-7
	Hazardous Air Pollutants.....	8-7
	Carbon Dioxide.....	8-8
	Summary of Air Quality.....	8-8
8.1.2	Ground Water Use and Quality.....	8-8
8.1.3	Surface Water Use and Quality.....	8-9
8.1.4	Terrestrial and Aquatic Ecology.....	8-9
	Terrestrial Ecology.....	8-9
	Aquatic Ecology.....	8-9
8.1.5	Human Health.....	8-10
	Radiological Human Health Risks.....	8-10
	PAH Human Health Risks.....	8-10

Table of Contents

Mercury Human Health Risks 8-11

NOx and SO₂ Human Health Risks..... 8-11

8.1.6 Socioeconomics 8-12

 Land Use..... 8-12

 Socioeconomics 8-13

 Transportation 8-14

 Aesthetics..... 8-14

 Historic and Archaeological Resources 8-15

 Environmental Justice 8-15

8.1.7 Waste Management 8-16

8.2 Natural Gas Combined-Cycle Generation..... 8-16

8.2.1 Air Quality..... 8-18

8.2.2 Ground Water Use and Quality..... 8-20

8.2.3 Surface Water Use and Quality 8-20

8.2.4 Terrestrial and Aquatic Ecology..... 8-20

 Terrestrial Ecology..... 8-20

 Aquatic Ecology..... 8-21

8.2.5 Human Health 8-21

8.2.6 Socioeconomics 8-21

 Land Use..... 8-21

 Socioeconomics 8-22

 Transportation 8-23

 Aesthetics..... 8-23

 Historic and Archaeological Resources 8-24

 Environmental Justice 8-24

8.2.7 Waste Management 8-25

8.3 Energy Conservation/Energy Efficiency..... 8-25

8.3.1 Air Quality..... 8-27

8.3.2 Ground Water Use and Quality..... 8-27

8.3.3 Surface Water Use and Quality 8-27

8.3.4 Terrestrial and Aquatic Ecology..... 8-27

 Terrestrial Ecology..... 8-27

 Aquatic Ecology..... 8-27

8.3.5 Human Health 8-28

8.3.6 Socioeconomics 8-29

 Land Use..... 8-29

 Socioeconomics 8-29

 Transportation 8-29

 Aesthetics..... 8-29

 Historic and Archaeological Resources 8-29

 Environmental Justice 8-29

8.3.7 Waste Management 8-30

8.4 Combination Alternative..... 8-30

8.4.1 Air Quality..... 8-31

Table of Contents

8.4.2	Ground Water Use and Quality.....	8-32
8.4.3	Surface Water Use and Quality.....	8-32
8.4.4	Terrestrial and Aquatic Ecology.....	8-32
	Terrestrial Ecology.....	8-32
	Aquatic Ecology.....	8-33
8.4.5	Human Health.....	8-33
8.4.6	Socioeconomics.....	8-33
	Land Use.....	8-33
	Socioeconomics.....	8-34
	Transportation.....	8-34
	Aesthetics.....	8-35
	Historic and Archaeological Resources.....	8-35
	Environmental Justice.....	8-35
8.4.7	Waste Management.....	8-36
8.5	Purchased Power.....	8-36
8.6	Alternatives Considered but Dismissed.....	8-36
8.6.1	Coal-Fired Integrated Gasification Combined-Cycle.....	8-37
8.6.2	New Nuclear.....	8-37
8.6.3	Wind Power.....	8-37
8.6.4	Solar Power.....	8-38
8.6.5	Wood Waste.....	8-38
8.6.6	Conventional Hydroelectric Power.....	8-39
8.6.7	Wave and Ocean Energy.....	8-39
8.6.8	Geothermal Power.....	8-39
8.6.9	Municipal Solid Waste.....	8-40
8.6.10	Biofuels.....	8-40
8.6.11	Oil-Fired Power.....	8-41
8.6.12	Fuel Cells.....	8-41
8.6.13	Delayed Retirement.....	8-41
8.7	No-Action Alternative.....	8-42
8.7.1	Air Quality.....	8-43
8.7.2	Ground Water Use and Quality.....	8-43
8.7.3	Surface Water Use and Quality.....	8-43
8.7.4	Aquatic and Terrestrial Ecology.....	8-43
	Terrestrial Ecology.....	8-43
	Aquatic Ecology.....	8-43
8.7.5	Human Health.....	8-43
8.7.6	Socioeconomics.....	8-44
	Land Use.....	8-44
	Socioeconomics.....	8-44
	Transportation.....	8-44
	Aesthetics.....	8-45
	Historic and Archaeological Resources.....	8-45
	Environmental Justice.....	8-45
8.7.7	Waste Management.....	8-45
8.8	Alternatives Summary.....	8-45

Table of Contents

8.9 References 8-47

9.0 Conclusion 9-1

9.1 Environmental Impacts of License Renewal 9-1

9.2 Comparison of Environmental Impacts of License Renewal and Alternatives 9-2

9.3 Resource Commitments 9-2

9.3.1 Unavoidable Adverse Environmental Impacts 9-2

9.3.2 Relationship Between Local Short-Term Uses of the Environment and the
Maintenance and Enhancement of Long-Term Productivity 9-3

9.3.3 Irreversible and Irretrievable Commitments of Resources 9-4

9.4 Recommendations 9-4

10.0 List of Preparers 10-1

11.0 Index 11-1

A. Comments Received on the Three Mile Island Nuclear Station, Unit 1,
Environmental Review A-1

B. NEPA Issues for License Renewal of Nuclear Power Plants B-1

C. Applicable Regulations, Laws, and Agreements C-1

D. Consultation Correspondences D-1

E. Chronology of Environmental Review Correspondence E-1

F. U.S. Nuclear Regulatory Commission Staff Evaluation of Severe Accident
Mitigation Alternatives (SAMAs) for Three Mile Island Nuclear Station, Unit 1 in
Support of License Renewal Application Review F-1

FIGURES

Figure 1-2. Environmental Issues Evaluated During License Renewal. 1-5

Figure 2-1. Location of Three Mile Island Nuclear Station, Unit 1, 50-mi (80-km)
Region 2-2

Figure 2-2. Location of Three Mile Island Nuclear Station, Unit 1, 6-mi (10-km) Region 2-3

Figure 2-3. Three Mile Island Nuclear Station, Unit 1, General Site Layout 2-4

Figure 2-4. Three Mile Island Nuclear Station Unit 1, Transmission System 2-13

Figure 2-5. Three Mile Island Nuclear Station, Unit 1, Inlet and Discharge
Temperatures 2-17

Figure 2-6. Three Mile Island Nuclear Station, Unit 1, Site Boundary Map 2-23

Table of Contents

Figure 2-7. Monthly Mean Flow of the Susquehanna River in 2004 and the Maximum, Mean, and Minimum Monthly Mean Flow Date for 1891–2004..... 2-30

Figure 2-8. Three Mile Island Nuclear Station, Unit 1, Site Area Over Map and Transmission Lines 2-36

Figure 4-1. Aggregate Minority Populations Within 50 Mi (80 km) of Three Mile Island Nuclear Station, Unit 1 4-27

Figure 4-2. Low Income Populations Within 50 Mi (80 km) of Three Mile Island Nuclear Station, Unit 1 4-28

TABLES

Table 2-1. Monthly Average, Minimum, and Maximum ΔT ($^{\circ}F$) Based on Automatic Temperature Sensors at the Intake Screen Pump House 2-18

Table 2-2. National Pollutant Discharge Elimination System Effluent Limitations for TMI-1 2-20

Table 2-3. Total Annual Ground Water Withdrawal (Gallons) and Average Daily Withdrawal Rate (Gallons) for Industrial Wells, A, B, and C and Combined for 2003–2005 2-27

Table 2-4. Rate of Tritiated Ground Water Migration to the Susquehanna River as Affected by Onsite Pumping and Background Levels of Tritium (Curies Per Year) 2-28

Table 2-5. American Shad Passage at the Conowingo, Holtwood, Safe Harbor, and Red Hill Dams on the Susquehanna River 2-34

Table 2-6. Listed Aquatic and Terrestrial Species 2-42

Table 2-7. TMI-1 Employee Residence By County 2-50

Table 2-8. Housing in Dauphin and Lancaster, Pennsylvania. 2-51

Table 2-9. Major Public Water Supply Systems 2-52

Table 2-10. Major Commuting Routes in the Vicinity of the Three Mile Island Nuclear Station and 2006 Average Annual Daily Traffic (AADT) Counts 2-53

Table 2-11. Population and Percent Growth in Dauphin County and Lancaster County, Pennsylvania, from 1970 to 2000, and Projected for 2010 and 2050 2-57

Table 2-12. Demographic Profile of the Population in the TMI-1 Two-County Socioeconomic Region of Influence in 2000 2-58

Table 2-13. Demographic Profile of the Population in the TMI-1 Two-County Socioeconomic Region of Influence in 2006 (Estimate) 2-59

Table 2-14. Seasonal Housing in Counties Located within 50 Miles of TMI-1 2-59

Table 2-15. Migrant Farm Worker and Temporary Farm Labor in Counties Located within 50 Miles of TMI-1 2-61

Table 2-16. Major Employers in Dauphin County in 2007 2-62

Table 2-17. Income Information for the TMI-1 Socioeconomic Region of Influence 2-63

Table 2-18. TMI-1 Property Tax Paid and Percentage of Dauphin County, Londonderry Township, and the Lower Dauphin School District from Property Tax Revenues, 2000 to 2005 2-64

Table 3-1. Issues Related to Refurbishment at TMI-1 3-1

Table 4-1. Land Use Issues 4-1

Table of Contents

Table 4-2. Air Quality Issue.....	4-1
Table 4-3. Ground Water Use and Quality Issues.....	4-2
Table 4-4. Surface Water Quality Issues.....	4-3
Table 4-5. Aquatic Resources Issues.....	4-6
Table 4-6. Terrestrial Resources Issues.....	4-6
Table 4-7. Threatened or Endangered Species.....	4-7
Table 4-8. Human Health Issues.....	4-9
Table 4-9. Results of Induced Current Analysis.....	4-16
Table 4-10. Socioeconomic Issues.....	4-18
Table 4-11. Summary of Cumulative Impacts on Resources Areas.....	4-42
Table 5-1. Issues Related to Postulated Accidents.....	5-1
Table 5-2. TMI-1 Internal Events Core Damage Frequency.....	5-5
Table 5-3. TMI-1 External Flooding Events Core Damage Frequency.....	5-5
Table 5-4. Breakdown of Population Dose by Containment Release Mode.....	5-6
Table 6-1. Issues Related to the Uranium Fuel Cycle and Solid Waste Management.....	6-1
Table 7-1. Issues Related Decommissioning.....	7-1
Table 8-1. Summary of Environmental Impacts of Supercritical Coal-Fired Generation Compared to Continued Operation of TMI-1.....	8-5
Table 8-2. Summary of Environmental Impacts of Natural Gas Combined-Cycle Generation Compared to Continued Operation of TMI-1.....	8-18
Table 8-3. Summary of Environmental Impacts of Energy Conservation/Energy Efficiency Compared to Continued Operation of TMI-1.....	8-26
Table 8-4. Summary of Environmental Impacts of the Combination Alternative Compared to Continued Operation of TMI-1.....	8-31
Table 8-5. Summary of Environmental Impacts of the No Action Alternative Compared to Continued Operation of TMI-1.....	8-42
Table 8-6. Summary of Environmental Impacts of Selected Alternatives Compared to Continued Operation of TMI-1.....	8-47
Table 10-1. List of Preparers.....	10-1
Table A-1. Commenters on the Scope of the Environmental Review.....	A-2
Table A-2. Commenters on the Draft Supplemental EIS.....	A-18
Table B-1. Summary of Issues and Findings.....	B-1
Table C-1. State Environmental Requirements.....	C-1
Table C-2. Federal, State, and Local Permits and Other Requirements.....	C-3
Table D-1. Consultation Correspondences.....	D-1
Table F-1.a TMI-1 Internal Events Core Damage Frequency.....	F-3
Table F-1.b TMI-1 External Flooding Events Core Damage Frequency.....	F-3
Table F-2. Breakdown of Population Dose by Containment Release Mode.....	F-4
Table F-3. TMI-1 PRA Historical Summary.....	F-6
Table F-4. TMI-1 Seismic Events Core Damage Frequency.....	F-9
Table F-5. TMI-1 Fire Areas and Their Contribution to Fire CDF.....	F-10
Table F-6. SAMA Cost/Benefit Screen Analysis for TMI-1.....	F-22

EXECUTIVE SUMMARY

Background

By letter dated January 8, 2008, Exelon Generation Company, LLC (Exelon Generation) submitted an application to the U.S. Nuclear Regulatory Commission (NRC) to issue a renewed operating license for Three Mile Island Nuclear Station, Unit 1 (TMI-1) for an additional 20-year period.

The following document and the review it encompasses are requirements of NRC regulations implementing Section 102 of the National Environmental Policy Act (NEPA), of the *United States Code* (42 U.S.C. 4321), in Title 10 of the *Code of Federal Regulations* (CFR), Part 51 (10 CFR Part 51). In 10 CFR 51.20(b)(2), the Commission indicates that issuing a renewed power reactor operating license requires preparation of an Environmental Impact Statement (EIS) or a supplement to an existing EIS. In addition, 10 CFR 51.95(c) states that the EIS prepared at the operating license renewal stage will be a supplement to the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437, Vol. 1 and 2 (NRC 1996, 1999).

Upon acceptance of Exelon Generation's application, we (the NRC staff) began the environmental review process described in 10 CFR Part 51 by publishing a Notice of Intent to prepare an EIS and conduct scoping. We conducted a site audit at the plant in late April 2008 and held public scoping meetings on May 1, 2008, in Middletown, Pennsylvania. In the preparation of this supplemental EIS for TMI-1, we reviewed Exelon Generation's environmental report and compared it to the GEIS, consulted with other agencies, conducted a review of the issues following the guidance set forth in NUREG-1555, Supplement 1: *Standard Review Plans for Environmental Reviews for Nuclear Power Plants; Supplement 1: Operating License Renewal* (NRC 2000), and considered the public comments received during the scoping process and on the draft supplemental EIS.

Proposed Action

Exelon Generation initialized the proposed Federal action—issuing a renewed power reactor operating license—by submitting an application for license renewal of TMI-1, for which the existing license (DPR-50) expires April 19, 2014. NRC's Federal action is the decision whether to renew the license for an additional 20 years.

Purpose and Need for Action

The purpose and need for the proposed action (issuance of a renewed license) is to provide an option that allows for power generation capability beyond the term of a current nuclear power plant operating license, and to meet future system generating needs, as determined by State, utility, and, where authorized, Federal (other than NRC) decisionmakers. This definition of purpose and need for action reflects the Commission's recognition that, unless there are findings in the safety review required by the Atomic Energy Act of 1954 or findings in the NEPA environmental analysis that would lead the NRC to reject a license renewal application, the NRC does not have a role in the energy-planning decisions of State regulators and utility officials as to whether a particular nuclear power plant should continue to operate.

If the renewed license is issued, State regulatory agencies and Exelon Generation will ultimately decide whether the plant will continue to operate based on factors such as the need for power or other matters within the State's jurisdiction or the purview of the owners. If the operating

Summary

license is not renewed, then the facility must be shut down on or before the expiration date of the current operating license—April 19, 2014.

Environmental Impacts of License Renewal

The supplemental EIS evaluates the potential environmental impacts of the proposed action. The environmental impacts from the proposed action can be SMALL, MODERATE, or LARGE. Exelon Generation and the NRC staff established separate processes for identifying and evaluating the significance of any new and significant information on the environmental impacts of license renewal of TMI-1. Neither Exelon Generation nor the NRC identified information that is both new and significant related to Category 1 issues that would call into question the conclusions in the GEIS. Similarly, neither the scoping process nor the NRC has identified any new issue applicable to TMI-1 that has a significant environmental impact. Therefore, the NRC staff relies upon the conclusions of the GEIS for all the Category 1 issues applicable to TMI-1.

Land Use

SMALL. The NRC did not identify any Category 2 impact issues for land use, nor did the staff identify any new and significant information during the environmental review. Therefore, there would be no impacts beyond those discussed in the GEIS.

Air Quality

SMALL. The NRC did not identify any Category 2 issues for the impact of transmission lines on air quality, nor did the staff identify any new or significant information during the environmental review. Therefore, for plant operation during the license renewal term, there are no impacts beyond those discussed in the GEIS.

However, air quality during refurbishment (in nonattainment and maintenance areas) is a Category 2 issue. Emission calculations for refurbishment activities at TMI-1 indicate that emissions are not expected to exceed emission budgets specified in the Pennsylvania State Implementation Plan, and on this basis, the NRC staff concludes that the impact of vehicle exhaust emissions resulting from refurbishment activities would be SMALL. Potential mitigation measures include implementation of best management practices for dust control and the use of staggered workforce shift changes to reduce the number of vehicles on the road at any one given time.

Ground Water Use and Quality

SMALL. Ground water use conflicts: potable and service water—plants using greater than 100 gallons per minute; and plants using cooling towers withdrawing make-up water from a small river) are Category 2 issues related to license renewal at TMI-1. Information provided by Exelon Generation, including Susquehanna River Basin Commission pump test data, shows that TMI-1 ground water withdrawal has no effect on offsite ground water wells and ground water supplies. In addition, the withdrawal of surface water from the Susquehanna River is a small percentage of overall river flow and does not affect ground water levels in the area.

Surface Water Use and Quality

SMALL. Water use conflicts—plants with cooling ponds or cooling towers using make-up water from a small river with low flow is a Category 2 issue related to license renewal at TMI-1. Withdrawals of Susquehanna River water by TMI-1 are less than 1.6 percent of the lowest daily mean flow and less than 0.1 percent of the average annual flow of the river. TMI-1 also

participates in the Cowanesque Lake water storage project, which releases water to the Susquehanna River during drought conditions. There are no Category 2 issues related to surface water use and quality during refurbishment activities.

Aquatic Resources

SMALL. With regard to operation of TMI-1 during the license renewal term, the NRC did not identify any Category 2 issues for aquatic resources, nor did the staff identify any new and significant information during the environmental review. Therefore, there are no impacts beyond those discussed in the GEIS. Besides Threatened and Endangered Species (discussed below), there are no Category 2 issues related to aquatic resources during refurbishment activities.

Terrestrial Resources

SMALL. With regard to operation of TMI-1 during the license renewal term, the NRC did not identify any Category 2 issues for terrestrial resources, nor did the staff identify any new or significant information during the environmental review. Therefore, there are no impacts beyond those discussed in the GEIS.

Impacts to terrestrial resources during refurbishment activities is a Category 2 issue. The majority of refurbishment activities will take place on existing facility grounds at TMI-1, and new, permanent structures will be constructed on previously disturbed land. Exelon Generation's steam generator vendor, AREVA NP, Inc. (AREVA) is required to obtain all necessary Federal and State environmental and construction permits to cover the transportation route of the new steam generators from Port Deposit, Maryland, to the TMI-1 site. Environmental and construction permits, as well as consultation correspondence with Pennsylvania and Maryland State resource agencies, will likely contain mitigation measures to minimize impacts to terrestrial resources, including installing silt fences to minimize sediment transport, the use of best management practices, and the restoration of cleared land upon completion of construction activities. Based on the environmental permit requirements and implementation of mitigation measures, impacts to terrestrial resources during refurbishment activities at the TMI-1 site and along the steam generator transportation route will be SMALL.

Threatened and Endangered Species

SMALL. Impacts to threatened and endangered species during the period of extended operation and during refurbishment activities are Category 2 issues. The U.S. Fish and Wildlife Service indicated that no known Federally-listed threatened and endangered species occur within the project area; therefore, the proposed project would not likely impact any Federally-listed species. The Pennsylvania Department of Natural Resources indicated that although several State-listed species of concern are known to occur in the vicinity of the TMI-1 project site, no impact to these species is anticipated. Furthermore, the Pennsylvania Fish and Boat Commission indicated that no adverse impacts to State-listed rare, candidate, threatened, or endangered aquatic species are expected from the proposed project.

Refurbishment activities will take place on existing facility grounds at the TMI-1 site, and new, permanent structures will be constructed on previously disturbed land; therefore, no impact to these species is anticipated.

Summary

With regard to the transportation of the new steam generators from Port Deposit, Maryland, to the TMI-1 site, AREVA is required to consult with the Pennsylvania Fish and Boat Commission, the Pennsylvania Game Commission, and the Pennsylvania Department of Natural Resources to determine if modifications to existing bridges, construction of temporary bridge by-passes, and other infrastructure modifications could impact threatened and endangered species along the steam generator transportation route. The consultation process will likely include mitigation measures to minimize potential impacts to threatened or endangered species that may be present in the vicinity of transportation route. AREVA will also require a joint permit for waterway construction work from the Pennsylvania Department of Environmental Protection and the U.S. Army Corps of Engineers. Approval of this permit is predicated on consultations with State resource agencies regarding impacts to threatened and endangered species.

Human Health

SMALL. With regard to Category 1 human health issues during the license renewal term—microbiological organisms (occupational health), noise, radiation exposures to public, occupational radiation exposures, and electromagnetic fields (chronic effects)—the staff did not identify any new or significant information during the environmental review. Therefore, there are no impacts beyond those discussed in the GEIS. Refurbishment activities are not expected to generate an amount of radioactive material that is significantly different from the historical radiological effluent releases which included refueling outage activities. Based on past regulatory compliance, the dose to a maximally exposed individual in the vicinity of TMI-1 for the refurbishment period is expected to continue to be a small fraction of the limits and standards specified in 10 CFR Part 20, Appendix I to 10 CFR Part 50, and 40 CFR Part 190.

Microbiological organisms (public health) and electromagnetic fields—acute effects (electric shock) are Category 2 human health issues. When thermal discharge from TMI-1 is at its maximum temperature and the Susquehanna River is at its maximum temperature, the resulting temperature of the mixed water in the vicinity of the TMI-1 discharge is approximately 91.3 degrees Fahrenheit, which is well outside the optimal growth temperature range of thermophilic microbiological organisms; therefore the impact is **SMALL**. Potential mitigation measures to reduce human health impacts include monitoring for thermophilic organisms in the water and sediments near the discharge, as well as prohibiting recreational use near the discharge plume. NRC staff reviewed Exelon Generation's analysis of electromagnetic fields—acute shock resulting from induced charges in metallic structures, and verified that none of TMI-1's in-scope transmission lines have the capability to induce greater than 5 milliamperes in a vehicle parked beneath the lines. This finding conforms with National Electric Safety Code provisions for preventing electric shock from induced current. Potential mitigation measures include limiting public access to transmission line structures, installing signs at road crossings, and increasing transmission line clearances. The NRC staff considers the GEIS finding of "uncertain" for electromagnetic fields—chronic effects still appropriate and will continue to follow developments on this issue.

Socioeconomics

SMALL. The NRC identified no Category 1 public service and aesthetic impacts applicable to TMI-1, or new and significant information during the environmental review. Therefore, there would be no impacts related to these issues beyond those discussed in the GEIS. Category 2 socioeconomic impacts include housing impacts, public services (public utilities), offsite land use, public services (public transportation), and historic and archaeological resources. Since TMI-1 is located in a high-density population area, and growth-control measures are not in effect, any changes in TMI-1 employment would have little noticeable effect on housing availability in the surrounding area. Exelon Generation has indicated they have no plans to add non-outage employees during the license renewal period; therefore non-outage employment levels at TMI-1 would remain relatively unchanged with no additional demand for public water and sewer services. This also applies to offsite land use and transportation issues. Because non-outage employment levels at TMI-1 would remain relatively unchanged during the license renewal period, there would be no land use impacts related to population or tax revenues, and no transportation impacts. Category 2 socioeconomic impacts related to refurbishment at TMI-1 would be **SMALL**, because the TMI-1 steam generator project is expected to require a one-time increase of outage workers for up to 70 days—a short duration of time.

No impacts to known historic and archaeological resources are expected from the continued operation of TMI-1 during the license renewal term. Exelon Generation has indicated no plans to change or modify the plant or transmission line structures. Based on the review of Pennsylvania Historical and Museum Commission files, archaeological surveys, assessments, and other information, the potential impacts on historic and archaeological resources at TMI-1 would be **SMALL**. Since TMI-1 is situated in an archaeologically sensitive area, development of a cultural resources management plan in addition to Exelon Generation's review procedures would serve to integrate cultural resource considerations with ongoing TMI-1 activities. Additionally, training of Exelon Generation staff in the Section 106 process would ensure that informed decisions are made when considering the effects of future projects on historic and archaeological resources. Lands that have not been surveyed should be investigated by a professional archaeologist prior to any ground disturbance. In addition, the historical farmstead site (36Da235) should be recorded and evaluated for eligibility. Because refurbishment activities will occur on previously disturbed land, the impacts associated with refurbishment are not expected to adversely affect historic or archaeological sites in the area of TMI-1. An analysis of minority and low-income populations residing within a 50-mile (80-kilometer) radius of TMI-1 indicated there would be no disproportionately high and adverse impacts to these populations from the continued operation of TMI-1 during the license renewal period. Based on recent monitoring results, concentrations of contaminants in native leafy vegetation, soils and sediments, surface water, and fish in areas surrounding TMI-1 have been low (at or near the threshold of detection) and seldom above background levels. Consequently, no disproportionately high and adverse human health impacts would be expected in special pathway receptor populations in the region as a result of subsistence consumption of fish and wildlife.

Severe Accident Mitigation Alternatives

Since TMI-1 had not previously considered alternatives to reduce the likelihood or potential consequences of a variety of highly uncommon but potentially serious accidents, NRC

Summary

regulation 10 CFR 51.53(c)(3)(ii)(L) requires that TMI-1 evaluate Severe Accident Mitigation Alternatives (SAMAs) in the course of license renewal review. SAMAs are potential ways to reduce the risk or potential impacts of uncommon but potentially severe accidents, which may include changes to plant components, systems, procedures, and training. Based on our review of potential SAMAs and Exelon Generation responses to the NRC staff's requests for additional information, we conclude that TMI-1 made a reasonable, comprehensive effort to identify and evaluate SAMAs. Based on the review of the SAMAs for TMI-1, and the plant improvements already made, we conclude that none of the potentially cost-beneficial SAMAs relate to adequately managing the effects of aging during the period of extended operation; therefore, they need not be implemented as part of the license renewal pursuant to 10 CFR Part 54.

Alternatives

We considered the environmental impacts associated with alternatives to license renewal. These alternatives include other methods of power generation and not renewing the TMI-1 operating license (the no-action alternative). Replacement power options considered were supercritical coal-fired generation, natural gas combined-cycle generation and, as part of the combination alternative, uprates to existing hydroelectric dams located in Pennsylvania. Wherever possible, we evaluated potential environmental impacts for these alternatives located both at the TMI-1 site and at some other unspecified alternate location. Energy conservation/energy efficiency, purchased power, and a combination alternative, which included natural gas combined-cycle generation, energy conservation/energy efficiency, and a series of uprates to hydroelectric dams, were also considered. We evaluated each alternative using the same impact areas that we used in evaluating impacts from license renewal. The results of this evaluation are summarized in the table on the following page.

Comparison of Alternatives

The coal-fired alternative is the least environmentally favorable alternative, due to the following: impacts to air quality from nitrogen oxides, sulfur oxides, particulate matter, polycyclic aromatic hydrocarbons, carbon monoxide, carbon dioxide, and mercury—and the corresponding human health impacts; construction impacts to aquatic, terrestrial, and potentially historic and archaeological resources are also factors that make the coal-fired alternative the least environmentally favorable alternative. The gas-fired alternative would have slightly lower air emissions, and impacts to aquatic, terrestrial, and historic and archaeological resources would vary depending upon location of the plant. Purchased power would likely have operational impacts that would include aspects of coal-fired, gas-fired, and existing nuclear generation.

The NRC notes that the energy conservation/energy efficiency alternative has SMALL impacts in all categories evaluated and, upon shut down of TMI-1, current operating impacts of TMI-1 would cease. Therefore, the energy conservation/energy efficiency alternative is the environmentally preferred alternative to license renewal. All other alternatives capable of meeting the needs currently served by TMI-1 entail potentially greater impacts than the proposed action of license renewal of TMI-1. The no-action alternative does not meet the purpose and need of this supplemental EIS, though if it triggers the energy conservation/energy efficiency action to replace the capacity currently supplied by TMI-1, it could result in an overall SMALL impact, as well.

Recommendation

The NRC has determined that the adverse environmental impacts of license renewal for TMI-1 are not so great that preserving the option of license renewal for energy-planning decisionmakers would be unreasonable. This determination is based on (1) the analysis and findings in the GEIS; (2) the Environmental Report submitted by Exelon Generation; (3) consultation with Federal, State, and local agencies; (4) the NRC staff's own independent review; and (5) the NRC staff's consideration of public comments received during the scoping process and draft supplement EIS comment period.

Alternative	Impact Area						
	Air Quality	Ground Water	Surface Water	Aquatic and Terrestrial Resources	Human Health	Socioeconomics	Waste Management
License Renewal	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL
Supercritical coal-fired alternative at a new site	MODERATE	SMALL	SMALL	SMALL to LARGE	SMALL to MODERATE	SMALL to LARGE	SMALL to MODERATE
Gas-fired alternative at the TMI-1 site	MODERATE	SMALL	SMALL	SMALL	SMALL	SMALL to MODERATE	SMALL
Gas-fired alternative at a new site	MODERATE	SMALL	SMALL	SMALL to LARGE	SMALL	SMALL to MODERATE	SMALL
Energy Conservation/ Energy Efficiency	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL
Combination of Alternatives	SMALL to MODERATE	SMALL	SMALL	SMALL	SMALL	SMALL to MODERATE	SMALL
No Action Alternative	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL to MODERATE	SMALL

ABBREVIATIONS AND ACRONYMS

ACC	averted cleanup and decontamination costs
AEA	Atomic Energy Act of 1954
AEC	U.S. Atomic Energy Commission
ALARA	as low as reasonably achievable
CDF	Core Damage Frequency
CEQ	Council on Environmental Quality
CFR	Code of Federal Regulations
CFS	cubic feet per second
COPC	chemicals of potential concern
CWA	Clean Water Act
DBA	design-basis accident
DCNR	Pennsylvania Department of Conservation and Natural Resources
DOE	U.S. Department of Energy
DPR	demonstration project reactor
DSM	demand-side management
EIA	Energy Information Administration (of DOE)
EIS	environmental impact statement
ELF-EMF	extremely low frequency-electromagnetic field
EMS	environmental management system
EOP	Emergency Operating Procedure
ER	environmental report
EPA	U.S. Environmental Protection Agency
ESA	Endangered Species Act
ESRP	Environmental Standard Review Plan, NUREG-1555, Supplement 1, Operating License Renewal
FAA	Federal Aviation Administration
FES	Final Environmental Statement
FR	Federal Register
FSAR	Final Safety Analysis Report
FWS	U.S. Fish and Wildlife Service
GDC	general design criteria
GEIS	Generic Environmental Impact Statement for License Renewal of Nuclear Plants, NUREG-1437

Abbreviations and Acronyms

GPD	gallons per day
GPM	gallons per minute
HLW	high-level waste
IPE	Individual Plant Examination
IPEEE	Individual Plant Examination of External Events
ISFSI	independent spent fuel storage installation
LLMW	low-level mixed waste
LLW	low-level waste
LNG	liquefied natural gas
LOCA	loss of coolant accident
LWR	light-water reactor
MGD	million gallons per day
MSA	Magnuson-Stevens Fishery Conservation and Management Act of 1996
Msl	mean sea level
MW	megawatt
MWe	megawatt-electric
MWt	megawatt-thermal
NA	not applicable
NAAQS	National Ambient Air Quality Standards
NAS	National Academy of Sciences
NCI	National Cancer Institute
NEPA	National Environmental Policy Act of 1969
NESC	National Electric Safety Code
NHPA	National Historic Preservation Act
NIEHS	National Institute of Environmental Health Sciences
NMFS	National Marine Fisheries Service
NOAA	National Oceanic and Atmospheric Administration
NRHP	National Register of Historic Places
NO _x	nitrogen oxide(s)
NPDES	National Pollutant Discharge Elimination System
NRC	U.S. Nuclear Regulatory Commission
NWPPC	Northwest Power Planning Council
ODCM	Offsite Dose Calculation Manual
PADEP	Pennsylvania Department of Environmental Protection
pCi/L	picocuries per liter

Abbreviations and Acronyms

PDS	plant damage state
PFBC	Pennsylvania Fish and Boat Commission
PGC	Pennsylvania Game Commission
PHMC	Pennsylvania Historical and Museum Commission
PM _{2.5}	particulate matter, 2.5 microns or less in diameter
PM ₁₀	particulate matter, 10 microns or less in diameter
PRA	Probabilistic Risk Assessment
PSA	Probabilistic Safety Assessment
PSD	prevention of significant deterioration
PSW	plant service water
PWR	pressurized water reactor
RAB	reactor auxiliary building
RAI	request for additional information
RCP	reactor coolant pump
REMP	radiological environmental monitoring program
rms	root mean square
ROW(s)	right-of-way(s)
SAMA	Severe Accident Mitigation Alternative
SAR	Safety Analysis Report
SER	Safety Evaluation Report
SHPO	State Historic Preservation Office
SO ₂	sulfur dioxide
SRBC	Susquehanna River Basin Commission
TMI-1	Three Mile Island Nuclear Station, Unit 1
TSCA	Toxic Substances Control Act
U	Uranium
UFSAR	Updated Final Safety Analysis Report
U.S.	United States
USACE	United States Army Corps of Engineers
U.S.C.	United States Code
USCB	U.S. Census Bureau
USDA	U.S. Department of Agriculture
VOCs	Volatile Organic Compounds
WHO	World Health Organization

1.0 PURPOSE AND NEED FOR ACTION

Under the U.S. Nuclear Regulatory Commission's (NRC's) environmental protection regulations in Title 10, Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions," of the *Code of Federal Regulations* (10 CFR Part 51), which implement the National Environmental Policy Act (NEPA), issuance or renewal of a nuclear power plant operating license requires the preparation of an environmental impact statement (EIS).

The Atomic Energy Act of 1954 originally specified that licenses for commercial power reactors be granted for up to 40 years with an option to renew for another 20 years. The 40-year licensing period was based on economic and antitrust considerations rather than on technical limitations of the nuclear facility.

The decision to seek a license renewal rests entirely with nuclear power facility owners and typically is based on the facility's economic viability and the investment necessary to continue to meet NRC safety and environmental requirements. The NRC makes the decision to grant or deny a license renewal application, based on whether the applicant has demonstrated that the environmental and safety requirements in the agency's regulations can be met during the period of extended operation.

1.1 Proposed Federal Action

On January 12, 2008, AmerGen Energy Company, LLC (AmerGen) initialized the proposed Federal action by submitting an application for license renewal of Three Mile Island Nuclear Station, Unit 1 (TMI-1), for which the existing license, DPR-50, expires April 19, 2014. The NRC's Federal action is the decision whether to renew the license for an additional 20 years.

On January 8, 2009, Exelon Generation Company, LLC (Exelon Generation) officially integrated the nuclear generation assets held by its subsidiary, AmerGen, into Exelon Generation and dissolved the AmerGen legal entity. Accordingly, throughout the supplemental EIS, AmerGen Energy Company, LLC and AmerGen, have been replaced with Exelon Generation Company, LLC and Exelon Generation, respectively.

1.2 Purpose and Need for the Proposed Federal Action

The purpose and need for the proposed action (issuance of a renewed license) is to provide an option that allows for power generation capability beyond the term of a current nuclear power plant operating license to meet future system generating needs, as such needs that may be determined by State, utility, and, where authorized, Federal (other than NRC) decisionmakers. This definition of purpose and need reflects the Commission's recognition that, unless there are findings in the safety review required by the Atomic Energy Act or findings in the NEPA environmental analysis that would lead the NRC to reject a license renewal application, the NRC does not have a role in the energy-planning decisions of State regulators and utility officials as to whether a particular nuclear power plant should continue to operate.

If the renewed license is issued, State regulatory agencies and Exelon Generation will ultimately decide whether the plant will continue to operate based on factors such as the need for power

Purpose and Need For Action

or other matters within the State's jurisdiction or the purview of the owners. If the operating license is not renewed, then the facility must be shut down on or before the expiration date of the current operating license—April 19, 2014.


Figure 1-1. Environmental Review Process.

The environmental review process provides opportunities for public involvement.

1.3 Major Environmental Review Milestones

Exelon Generation submitted an environmental report (AmerGen 2008a) as part of its license renewal application (AmerGen 2008) in January 2008. After reviewing the application and the environmental report for sufficiency, the NRC staff published a Notice of Acceptability and Opportunity for Hearing on March 14, 2008, in the *Federal Register* (Vol. 73, p. 13923, (73 FR 13923)). Then, on March 28, 2008, the NRC published another notice in the *Federal Register* (73 FR 16729) on its intent to conduct scoping, thereby beginning the 60-day scoping period.

The agency held two public scoping meetings on May 1, 2008, in Middletown, Pennsylvania. The NRC report entitled, "Environmental Impact Statement Scoping Process Summary Report for Three Mile Island Nuclear Station, Unit 1," dated August 8, 2008, presents the comments received during the scoping process in their entirety (NRC 2008b). Appendix A to this supplemental EIS presents the comments considered to be within the scope of the environmental license renewal review and the associated NRC responses.



To independently verify information provided in the environmental report, the NRC staff conducted a site audit at TMI-1 from April 28 through May 1, 2008. During the site audit, staff met with plant personnel, reviewed specific documentation, toured the facility, and met with interested Federal, State, and local agencies. The agency published a summary of that site audit and a list of the attendees in a report entitled, "Summary of Site Audit Related to the Review of the License Renewal Application for Three Mile Island Nuclear Station, Unit 1," dated August 5, 2008 (NRC 2008).

Upon completion of the scoping period and site audit, the staff compiled its findings in this document, the supplemental EIS (Figure 1-1). The draft supplemental EIS was published in December 2008. The NRC staff held two public meetings in Harrisburg, Pennsylvania, on February 24, 2009, to describe the preliminary results of the NRC environmental review, to answer questions, and to provide members of the public with information to assist them in formulating comments on the draft supplemental EIS. When the comment period ended on March 4, 2009, the NRC staff considered and addressed all of the comments received. These comments are addressed in Section A-2 of Appendix A, Comments Received on the Environmental Review, in this supplemental EIS.

The NRC has established a license renewal process that can be completed in a reasonable period of time with clear requirements to ensure safe plant operation for up to an additional 20 years of plant life. The safety review is conducted simultaneously with the environmental review. The staff documents the findings of the safety review in a safety evaluation report. The Commission considers the findings in both the supplemental EIS and the safety evaluation report in its decision to either grant or deny the issuance of a new license.

1.4 Generic Environmental Impact Statement

The NRC performed a generic assessment of the environmental impacts associated with license renewal to improve the efficiency of the license renewal. NUREG-1437, *Generic Environmental Impact Statement for License Renewal of Nuclear Power Plants*, documents the results of the NRC's systematic approach to evaluating the environmental consequences of renewing the licenses of individual nuclear power plants and operating them for an additional 20 years (NRC 1996, 1999)¹. The NRC staff analyzed in detail and resolved those environmental issues that could be resolved generically in the Generic Environmental Impact Statement (GEIS).

The GEIS establishes 92 separate issues for the NRC staff to independently verify. Of these, the staff determined that 69 are generic to all plants (Category 1), while 21 issues do not lend themselves to generic consideration (Category 2). Two other issues remained uncategorized; environmental justice and the chronic effects of electromagnetic fields must be evaluated on a site-specific basis. Appendix B to this report lists all 92 issues.

For each potential environmental issue, the GEIS (1) describes the activity that affects the environment, (2) identifies the population or resource that is affected, (3) assesses the nature and magnitude of the impact on the affected population or resource, (4) characterizes the

¹ The NRC originally issued the GEIS in 1996 and issued Addendum 1 to the GEIS in 1999. Hereafter, all references to the "GEIS" include the GEIS and Addendum 1.

Purpose and Need For Action

significance of the effect for both beneficial and adverse effects, (5) determines whether the results of the analysis apply to all plants, and (6) considers whether additional mitigation measures would be warranted for impacts that would have the same significance level for all plants.

The NRC's standard of significance for impacts was established using the Council on Environmental Quality terminology for "significant." The NRC established three levels of significance for potential impacts—SMALL, MODERATE, and LARGE, as defined below.

SMALL – Environmental effects are not detectable or are so minor that they will neither destabilize nor noticeably alter any important attribute of the resource.

MODERATE – Environmental effects are sufficient to alter noticeably, but not to destabilize, important attributes of the resource.

LARGE – Environmental effects are clearly noticeable and are sufficient to destabilize important attributes of the resource.

The GEIS includes a determination of whether the analysis of the environmental issue could be applied to all plants and whether additional mitigation measures would be warranted (Figure 1-2 on the following page). Issues are assigned a Category 1 or a Category 2 designation. As set forth in the GEIS, Category 1 issues are those that meet all of the following criteria:

- (1) The environmental impacts associated with the issue have been determined to apply either to all plants or, for some issues, to plants having a specific type of cooling system or other specified plant or site characteristics;
- (2) A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to the impacts (except for collective offsite radiological impacts from the fuel cycle and from high-level waste and spent fuel disposal); and
- (3) Mitigation of adverse impacts associated with the issue has been considered in the analysis, and it has been determined that additional plant-specific mitigation measures are likely not to be sufficiently beneficial to warrant implementation.


For generic issues (Category 1), no additional site-specific analysis is required in this supplemental EIS unless new and significant information is identified. Chapter 4 of this report presents the process for identifying new and significant information. Site-specific issues (Category 2) are those that do not meet one or more of the criterion for Category 1 issues, and therefore, additional site-specific review for these issues is required. The supplemental EIS documents the results of that site-specific review.

Significance indicates the importance of likely environmental impacts and is determined by considering two variables: **context** and **intensity**.

Context is the geographic, biophysical, and social context in which the effects will occur.

Intensity refers to the severity of the impact, in whatever context it occurs.

Figure 1-2. Environmental Issues Evaluated During License Renewal. 92 issues were initially evaluated in the Generic EIS. A site-specific analysis is required for 23 of those 92 issues.



1.5 Supplemental Environmental Impact Statement

The supplemental EIS presents an analysis that considers the environmental effects of the continued operation of TMI-1, alternatives to license renewal, and mitigation measures for minimizing adverse environmental impacts. Chapter 8 analyzes and compares the potential environmental impacts from alternatives, while Chapter 9 presents the preliminary recommendation as to whether or not the environmental impacts of license renewal are so great that preserving the option of license renewal would be unreasonable. The recommendation will be made after consideration of comments received during the public scoping period and on the supplemental EIS.

In the preparation of this supplemental EIS for TMI-1, the staff undertook the following activities:

Purpose and Need For Action

- reviewed the information provided in the Exelon Generation environmental report;
- consulted with other Federal, State, and local agencies;
- conducted an independent review of the issues during site audit; and
- considered the public comments received during the scoping process.

New information can be identified from a number of sources, including the applicant, the NRC, other agencies, or public comments. If a new issue is revealed, then it is first analyzed to determine whether it is within the scope of the license renewal evaluation. If it is not addressed in the GEIS then the NRC determines its significance and documents its analysis in the supplemental EIS.

New and significant information either (1) identifies a significant environmental issue not covered in the GEIS, or (2) was not considered in the analysis in the GEIS and leads to an impact finding that is different from the finding presented in the GEIS.

1.6 Cooperating Agencies

During the scoping process, no Federal, State, or local agencies were identified as cooperating agencies in the preparation of this supplemental EIS.

1.7 Consultations

The Endangered Species Act of 1973, as amended; the Magnuson-Stevens Fisheries Conservation and Management Act of 1996, as amended; and the National Historic Preservation Act of 1966 require that Federal agencies consult with applicable State and Federal agencies and groups before taking action that may affect endangered species, fisheries, or historic and archaeological resources, respectively. Below are the agencies and groups with whom the NRC consulted; Appendix D to this report includes copies of consultation documents.

Absentee-Shawnee Tribe of Oklahoma, Shawnee, Oklahoma
Advisory Council on Historic Preservation
Cayuga Nation, Versailles, New York
Delaware Nation, Anadarko, Oklahoma
Eastern Shawnee Tribe of Oklahoma, Seneca, Missouri
Oneida Indian Nation, Verona, New York
Oneida Nation of Wisconsin, Oneida, Wisconsin
Onondaga Nation, Nedrow, New York
Pennsylvania Historical and Museum Commission
Seneca-Cayuga Tribe of Oklahoma, Miami, Oklahoma
Seneca Nation of Indians, Salamanca, New York
Shawnee Tribe, Miami, Oklahoma
St. Regis Mohawk Tribe, Akwesasne, New York
Stockbridge-Munsee Band of the Mohican Nation – Wisconsin, Bowler, Wisconsin
Tonawanda Seneca Nation, Basom, New York

Tuscarora Nation, Lewiston, New York
 U.S. Fish and Wildlife Service, Pennsylvania Field Office

1.8 Correspondence

During the course of the environmental review, the NRC staff contacted the following Federal, State, regional, local, and tribal agencies. Appendix E to this report contains a chronological list of all documents sent and received during the environmental review.

- Absentee-Shawnee Tribe of Oklahoma, Shawnee, Oklahoma
- Advisory Council on Historic Preservation, Washington, D.C.
- Cayuga Nation, Versailles, New York
- Delaware Nation, Anadarko, Oklahoma
- Eastern Shawnee Tribe of Oklahoma, Seneca, Missouri
- Oneida Indian Nation, Verona, New York
- Oneida Nation of Wisconsin, Oneida, Wisconsin
- Onondaga Nation, Nedrow, New York
- Pennsylvania Department of Conservation and Natural Resources, Harrisburg, Pennsylvania
- Pennsylvania Department of Environmental Protection, Harrisburg, Pennsylvania
- Pennsylvania Department of Environmental Protection, South Central Regional Office, Harrisburg, Pennsylvania
- Pennsylvania Fish and Boat Commission, Bellefonte, Pennsylvania
- Pennsylvania Game Commission, Harrisburg, Pennsylvania
- Pennsylvania Historical and Museum Commission, Harrisburg, Pennsylvania
- Seneca-Cayuga Tribe of Oklahoma, Miami, Oklahoma
- Seneca Nation of Indians, Salamanca, New York
- Shawnee Tribe, Miami, Oklahoma
- St. Regis Mohawk Tribe, Akwesasne, New York
- Stockbridge-Munsee Band of the Mohican Nation – Wisconsin, Bowler, Wisconsin
- Susquehanna River Basin Commission, Harrisburg, Pennsylvania
- Tonawanda Seneca Nation, Basom, New York
- Tuscarora Nation, Lewiston, New York
- U.S. Fish and Wildlife Service, Pennsylvania Field Office, State College, Pennsylvania

A list of persons who received a copy of this supplemental EIS is provided below:

TMI-1 Site Vice President, Exelon Generation	Senior Vice President— Operations, Mid-Atlantic, Exelon Generation	Vice President—Licensing and Regulatory Affairs, Exelon Generation
Regional Administrator, Region 1, NRC	Chairman, Board of County Commissioners of Dauphin County	Chairman, Board of Supervisors of Londonderry Township
David Kern, NRC	Director—Licensing and Regulatory Affairs, Exelon Generation	David Allard, Pennsylvania Department of Environmental Protection

Purpose and Need For Action

1

Plant Manger – TMI-1, Exelon Generation	Regulatory Assurance Manager—TMI-1, Exelon Generation	Ronald Bellamy, NRC
Ronnie Gardner, AREVA NP Inc.	Judith Johnsrud, Sierra Club	Eric Epstein, TMI Alert
Correspondence Control Desk, Exelon Generation	Manager Licensing—TMI-1, Exelon Generation Company, LLC	Christopher Crane, Exelon Generation
Charles Pardee, Exelon Generation	Associate General Counsel, Exelon Generation	Chief Operating Officer, Exelon Generation
Senior Vice President—Operations Support, Exelon Generation	Frederic W. Polaski, Exelon Nuclear	Albert A. Fulvio, Exelon Nuclear
Rich Janati, Pennsylvania Department of Environmental Protection	Michael Murphy, Pennsylvania Department of Environmental Protection	Michael G. Brownell, Susquehanna River Basin Commission
Rachel Diamond, Pennsylvania Department of Environmental Protection	Nancy Ranek, Exelon Nuclear	Christopher Wilson, Exelon Nuclear
Michael P. Gallagher, Exelon Nuclear	Kathleen Yhip	William R. Geisel
Joseph Mirenzi	Anne Lovell, TetraTech NUS	James Oliver, TetraTech NUS
Larry Robbins	Mary Osborn	Michael R. Helfrich, Lower Susquehanna RiverKeeper
Linda Braasch, Harrisburg Diocesan Council of Catholic Women	Bradford S. Flynn	Douglas McLearn, Pennsylvania Historical and Museum Commission
Anne Norton-Miller, U.S. Environmental Protection Agency	Kimberly DePaul, U.S. Environmental Protection Agency	William S. Arguto, U.S. Environmental Protection Agency, Region 3
John J. Piazza, Three Mile Island Nuclear Station, Unit 1	David Atherholt	Joyce A. Scott, Harrisburg Diocesan Council of Catholic Women
Diane Little	Karen Walsh, Pennsylvania Energy Alliance	Paul Friesema, Northwestern University
John Garver, TriCounty Boat Club	Charles Alley	Scott Portzline, TMI Alert

1.9 Status of Compliance

Exelon Generation is responsible for complying with all NRC regulations and other applicable Federal, State, and local requirements; Appendix H to the GEIS describes some of the major Federal statutes. Table 1-1 lists the numerous permits and licenses issued by Federal, State, and local authorities for activities at TMI-1.

Table 1-1. Licenses and Permits. *Existing environmental authorizations for TMI-1 Operations.*

Permit	Number	Dates	Responsible Agency
Operating License	DPR-50	Issued: 4/19/1974 Expires: 4/19/2014	U.S. NRC
Consumptive Water Use Permit	Docket 19950302	Issued: 3/14/1980 Expires: 3/14/2010	Susquehanna River Basin Commission
Ground Water Withdrawal Permit	Docket 19961102	Issued: 1/26/1999 Expires: 11/26/2021	Susquehanna River Basin Commission
Synthetic Minor Operating Permit	22-05029	Issued: 1/1/2007 Expires: 12/31/2011	Pennsylvania Department of Environmental Protection
National Pollutant Discharge Elimination System Permit	PA 0009920	Issued: 10/30/2007 Expires: 10/31/2012	Pennsylvania Department of Environmental Protection
Maintenance Dredging Permit	CENAB-OP-RPA (AmerGen 197500083-4)	Issued: 1/3/2006 Expires: 12/31/2015	U.S. Army Corps of Engineers
Maintenance Dredging Permit	21275724	Issued: 1/13/1976 Expires: Not Listed	Pennsylvania Department of Environmental Protection
Public Water Supply Permit	22296501-T1	Issued: 1/20/2000 Expires: Not Listed	Pennsylvania Department of Environmental Protection

Purpose and Need For Action

Permit	Number	Dates	Responsible Agency
Public Water Supply Permit	22296501-T2	Issued: 1/20/2000 Expires: Not Listed	Pennsylvania Department of Environmental Protection
Acknowledgement of Notification of Regulated Waste Activity	PAR 000037861	Issued: 3/22/1999 Expires: Not Listed	U.S. Environmental Protection Agency
Storage Tank Registration/Permit Certificate	22-60170	Issued: 6/4/2008 Expires: 6/4/2009 (Annual Renewal)	Pennsylvania Department of Environmental Protection
Hazardous Materials Certificate of Registration	022307-701-002PR	Issued: 5/16/2007 Expires: 6/30/2010	U.S. Department of Transportation
Flammable and Combustible Liquid Storage Tank Approval	168,466	Issued: 6/12/1970 Expires: Not Listed	Pennsylvania Department of Labor and Industry
Flammable and Combustible Liquid Storage Tank Approval	168,465	Issued: 6/12/1970 Expires: Not Listed	Pennsylvania Department of Labor and Industry
Flammable and Combustible Liquid Storage Tank Approval	187,165	Issued: 11/17/1977 Expires: Not Listed	Pennsylvania Department of Labor and Industry
Flammable and Combustible Liquid Storage Tank Approval	203,271-B	Issued: 8/4/1989 Expires: Not Listed	Pennsylvania Department of Labor and Industry
Flammable and Combustible Liquid Storage Tank Approval	122-203,393	Issued: 9/22/1989 Expires: Not Listed	Pennsylvania Department of Labor and Industry
Sewage Disposal System Permit Modification	C179678 and C21434	Issued: 1/1/1995 Expires: Not Listed	Pennsylvania Department of Environmental Protection

Purpose and Need For Action

Permit	Number	Dates	Responsible Agency
Sewage Sludge Disposal Agreement	Letter Agreement	Issued: 6/20/2000 Expires: Not Listed	Pennsylvania Department of Environmental Protection
Environmental Laboratory Accreditation Certification	Reg. No. 22-00649	Issued: 4/17/2007 Expires: 4/30/2009 (Annual Renewal)	Pennsylvania Department of Environmental Protection
On Lot Sewage Disposal System Permit	U003282	Issued: 8/10/2007 Expires: Not Listed	Pennsylvania Department of Environmental Protection

1.10 References

10 CFR Part 51. Code of Federal Regulations, *Title 10, Energy*, Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions."

73 FR 13923. U.S. Nuclear Regulatory Commission, Washington, D.C., "Notice of Acceptance for Docketing of the Application and Notice of Opportunity for Hearing; Regarding Renewal of Facility Operating License No. DPR-50 for an Additional 20-Year Period; AmerGen Energy Company, LLC Three Mile Island Nuclear Station, Unit 1." *Federal Register*: Vol. 73, No. 51, pp. 13923–13925. March 14, 2008.

73 FR 16729. U.S. Nuclear Regulatory Commission, Washington, D.C., "Three Mile Island Nuclear Station, Unit 1; Notice of Intent to Prepare an Environmental Impact Statement and Conduct Scoping Process." *Federal Register*: Vol. 73, No. 61, pp. 16729–16731. March 28, 2008.

AmerGen (AmerGen Energy Company, LLC). 2008. "Three Mile Island Generating Station, Unit 1, License Renewal Application." ADAMS No. ML080220207.

AmerGen (AmerGen Energy Company, LLC). 2008a. "Three Mile Island Nuclear Station, Applicant's Environmental Report, License Renewal Operating Stage." Kennett Square, Pennsylvania. ADAMS Nos. ML080220255, ML080220257, ML080220261, and ML080220282.

Atomic Energy Act of 1954. 42 U.S.C. 2011, et seq.

Endangered Species Act of 1973. 16 U.S.C. 1531, et seq.

Magnuson-Stevens Fishery Conservation and Management Act, as amended by the *Sustainable Fisheries Act of 1996*. 16 U.S.C. 1855, et seq.

National Environmental Policy Act of 1969. 42 U.S.C. 4321, et seq.

Purpose and Need For Action

National Historic Preservation Act. 16 U.S.C. 470, et seq.

NRC (U.S. Nuclear Regulatory Commission). 1996. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*. NUREG-1437, Vol. 1 and 2, Washington, D.C. ADAMS No. ML061770605.

NRC (U.S. Nuclear Regulatory Commission). 1999. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Main Report*, "Section 6.3 – Transportation, Table 9.1, Summary of findings on NEPA issues for license renewal of nuclear power plants, Final Report." NUREG-1437, Vol. 1, Addendum 1, Washington, D.C.

NRC (U.S. Nuclear Regulatory Commission). 2008. "Summary of Site Audit Related to the Review of the License Renewal Application for Three Mile Island Nuclear Station, Unit 1." ADAMS No. ML081420398.

NRC (U.S. Nuclear Regulatory Commission). 2008b. "Environmental Impact Statement Scoping Process Summary Report, Three Mile Island Nuclear Station, Unit 1." ADAMS No. ML081920230.

2.0 AFFECTED ENVIRONMENT

Three Mile Island Nuclear Station, Unit 1 (TMI-1) is located in Londonderry Township of Dauphin County about 3 miles (mi) (4.8 kilometers [km]) south of Middletown, Dauphin County, and about 1.25 mi (2 km) east of the community of Goldsboro, York County. The site is approximately 10 mi (16 km) southeast of Harrisburg, Pennsylvania (AEC 1972). Figures 2-1 and 2-2 present the 50-mi (80-km) and 6-mi (10-km) vicinity maps, respectively. For purposes of the evaluation in this report, the "affected environment" is the environment that currently exists at and around TMI-1. Because existing conditions are at least partially the result of past construction and operation at the plant, the impacts of these past and ongoing actions and how they have shaped the environment are presented here. Section 2.1 of this report describes the facility and its operation, and Section 2.2 discusses the affected environment.

2.1 Facility Description

This assessment of the affected environment begins with a description of TMI-1, the source of potential environmental effects. TMI-1 is a pressurized-water reactor (PWR) utilizing once-through steam generators and licensed to operate at a power level of 2568 megawatt-thermal (MWt). Certain buildings and structures associated with Three Mile Island, Unit 2 (TMI Unit 2), which is owned by FirstEnergy Corporation (FirstEnergy), are intermingled with TMI-1 and its associated structures. TMI Unit 2 has been shut down since the accident in March 1979. Since December 1993, it has been in a stable, safe storage mode called post defueling monitored storage (AmerGen 2008).


The most conspicuous structures on the TMI-1 site are the four, 370-foot, hyperbolic, natural draft cooling towers. The two cooling towers to the south are inactive and were formerly utilized by the TMI Unit 2 reactor system. The two northern cooling towers are associated with the TMI-1 reactor. Other salient buildings on the TMI-1 site include the reactor building, auxiliary building, fuel-handling building, station blackout diesel generator building, intake screen and pump house, and the turbine building (AmerGen 2008). Figure 2-3 provides a general layout of the TMI-1 site.

2.1.1 Reactor and Containment Systems

TMI-1 is a single-unit plant with a Babcock and Wilcox PWR. Gilbert Associates, Inc. was the architect-engineer for TMI-1 (AEC 1972). TMI-1 received its construction permit in 1968 and its operating license in 1974, and began commercial operation on September 2, 1974. The initial licensed core thermal power of TMI-1 was 2535 MWt. In July 1988, the NRC approved a measurement uncertainty recapture uprate that increased the core thermal power by 1.3 percent to 2568 MWt (NRC 1996).

The reactor fuel is sintered low-enriched uranium dioxide pellets sealed in zirconium-based alloy tubing and caps (AmerGen 2008). Core reactivity is controlled by 69 movable control rod assemblies and borated water (boric acid is a neutron absorber). The control rods are silver-indium-cadmium alloy encapsulated in stainless steel. Control rods are used for short-term reactivity control associated with changes in power level and with changes in fuel burnup

Affected Environment



Legend

- ☆ Three Mile Island Nuclear Station Unit 1
- Interstate
- Major Road
- Urban Area
- State Boundary
- County Boundary
- Water

Figure 2-1. Location of Three Mile Island Nuclear Station, Unit 1, 50-mi (80-km) Region (Source: AmerGen 2008)







Figure 2-2. Location of Three Mile Island Nuclear Station, Unit 1, 6-mi (10-km) Region
 (Source: AmerGen 2008)




Figure 2-3. Three Mile Island Nuclear Station, Unit 1, General Site Layout
(Source: AmerGen 2008)

between adjustments in reactor coolant dissolved boron concentrations. If a reactor trip signal is received, all 69 control rod assemblies fall into the core by gravity (AEC 1972).

In the PWR power generation system, reactor heat is transferred from the primary coolant to a lower pressure secondary coolant loop, allowing steam to be generated in the steam supply system. The primary coolant loops each contain one steam generator, two centrifugal coolant pumps, and the interconnected piping. Reactor coolant is pumped from the reactor through the steam generators and back to the reactor inlet by two centrifugal coolant pumps located at the outlet of each steam generator. Each steam generator is a vertical straight tube-and-shell heat exchanger that produces superheated steam at a constant pressure over the reactor operating power range. Coolant flows downward through the tubes, and steam is generated on the lower pressure shell side. Steam then flows from the steam generators to the 1800-revolutions per minute, tandem compound, six-flow turbine generator, manufactured by General Electric (AEC 1972). NUREG/CR-5640, "Overview and Comparison of U.S. Commercial Nuclear Power Plant, Nuclear Power Plant System Source" (NRC 1990), provides a comprehensive overview and description of the PWR power generation system.

The primary containment is the reactor building and its associated isolation systems. The reactor building consists of a reinforced concrete slab and structure with cylindrical wall, a flat foundation mat, and a shallow dome roof. The 3-ft (1-meter [m]) concrete cylindrical wall is pre-stressed with a post-tensioning system in the vertical and horizontal directions. The dome roof is pre-stressed using a three-way post-tensioning system. The inside surface of the reactor building is lined with a carbon steel liner 3/4-inch (1.9 centimeter [cm]) thick for the cylinder and dome and 1/4-inch (0.63 cm) thick for the base.

2.1.2 Radioactive Waste Management

TMI-1 radioactive waste systems are designed to collect, treat, and dispose of the radioactive and potentially radioactive wastes that are byproducts of plant operations. Byproducts include: activation products created from the irradiation of reactor water and impurities contained in that water (which are principally metallic corrosion products); and fission products created by defective fuel cladding or uranium contamination within the reactor coolant system (AmerGen 2008). Operating procedures for radioactive waste systems ensure that radioactive wastes are safely processed and discharged from the plant within the limits set forth in 10 CFR Part 20, "Standards for Protection against Radiation," 10 CFR Part 50, "Domestic Licensing of Production and Utilization Facilities," the plant's technical specifications, and the TMI-1 offsite dose calculation manual (ODCM) (AmerGen 2007a).

Radioactive wastes resulting from plant operations are classified as liquid, gaseous, or solid. Liquid radioactive wastes are generated from liquids received directly from portions of the reactor coolant system or were contaminated by contact with liquids from the reactor coolant system. Gaseous radioactive wastes are generated from gases or airborne particulates vented from reactor and turbine equipment containing radioactive material. Solid radioactive wastes are solids from the reactor coolant system, solids that came into contact with reactor coolant system liquids or gases, or solids used in the reactor coolant system or steam and power conversion system operation or maintenance (AmerGen 2006a).

Affected Environment

Reactor fuel that has exhausted a certain percentage of its fissile uranium content is referred to as spent fuel. Spent fuel assemblies are removed from the reactor core and replaced with fresh fuel assemblies during routine refueling outages—typically every 24 months. Spent fuel assemblies are then stored for a period of time in the spent fuel pool in the reactor building.

The TMI-1 ODCM contains the methodology and parameters used to calculate offsite doses resulting from radioactive gaseous and liquid effluents, and the gaseous and liquid effluent monitoring alarm and trip setpoints used to verify the radioactive material being discharged meets regulatory limits (AmerGen 2007a). The ODCM also contains the radioactive effluent controls and radiological environmental monitoring activities and descriptions of the information that should be included in the annual radiological environmental operating report and annual radioactive effluent release report required by Appendix I, "Numerical Guides for Design Objectives and Limiting Conditions for Operation to Meet the Criterion 'As Low as is Reasonably Achievable' for Radioactive Material in Light-Water-Cooled Nuclear Power Reactor Effluents," to 10 CFR Part 50 and 10 CFR 50.36a, "Technical Specifications on Effluents from Nuclear Power Reactors," respectively.

2.1.2.1 Radioactive Liquid Waste

The TMI-1 radioactive liquid waste disposal system collects, holds, treats, processes, and monitors all liquid radioactive wastes for reuse or disposal. The system is divided into several subsystems so liquid wastes from various sources can be segregated and processed separately. Cross-connections between the subsystems provide additional flexibility for processing the wastes by alternate methods. The wastes are collected, treated, and disposed of according to their conductivity and/or radioactivity (AmerGen 2006a).

Radioactive liquid waste from TMI-1 is collected in sumps and drainage tanks and transferred to the appropriate subsystem collection tanks for subsequent treatment, disposal, or recycle. The liquid wastes are processed by a series of components which employ various processes specifically designed to provide maximum decontamination factors. The processing methods used include filtration, reverse osmosis, and/or demineralization. Following treatment, the processed wastes in the waste evaporator condensate tank, waste monitor tanks, or secondary liquid waste monitor tanks are analyzed for chemical and radioactive content before being discharged. In addition, the system can handle effluent streams that typically do not contain radioactive material, but that may, on occasion, become radioactive. Liquid radioactive wastes released to the west channel of the Susquehanna River are limited to the maximum extent possible to satisfy the design objectives of Appendix I to 10 CFR Part 50. Liquid discharges occur when the radioactive material has been analyzed and the projected dose to members of the public has been calculated to be within the values specified in the ODCM, 10 CFR Part 20, and Appendix I to 10 CFR Part 50 (AmerGen 2006a).

The NRC staff reviewed the TMI-1 radioactive effluent release reports for 2003 through 2007 for liquid effluents (AmerGen 2004b, 2005b, 2006b, 2007a, 2008b). Based on the liquid waste processing systems and effluent controls and performance from 2003 through 2007, the liquid discharges for 2007 are consistent with the radioactive liquid effluents discharged from 2003 through 2006. Variations on the amount of radioactive effluents released from year to year are expected based on the overall performance of the plant and the number and scope of outages and maintenance activities. The liquid radioactive wastes reported by TMI-1 are reasonable and no unusual trends were noted.

Exelon Generation intends to replace the TMI-1 steam generators before the period of extended operation. Such an action is not likely to significantly increase the amount of liquid radioactive effluents above the amount discharged during normal plant operations. This is because any liquids generated, processed, and released during the outage will be offset by the amount of liquid waste that would not be generated, processed, and released during normal plant operations. Based on the historical evaluation and because a significant increase in liquid effluents from the potential repair or replacement of the TMI-1 steam generators is not expected, similar quantities of radioactive effluents are expected to be generated during normal operations and outages from TMI-1 during the period of extended operations. The liquid releases during refurbishment will still be controlled and limited to satisfy the dose objectives of Appendix I to 10 CFR Part 50. These releases would result in doses to members of the public that are well below the as low as reasonably achievable (ALARA) dose design objectives, as discussed in Section 4.8.1 of this report.

2.1.2.2 Radioactive Gaseous Waste

The TMI-1 radioactive gas waste disposal system processes and disposes of routine radioactive gaseous effluent to the atmosphere. The system comprises reactor coolant drain tanks, miscellaneous waste storage tanks, waste gas, decay tanks, waste gas compressors, and charcoal and high efficiency particulate filters, to accumulate, store, and process the waste fission product gases. Before gaseous radioactive waste is released to the atmosphere through the plant vents, the gas must be analyzed to determine and document the amount of radioactivity being released (AmerGen 2006a).

TMI-1 discharges gaseous waste in accordance with the procedures and methodology described in the ODCM. The gaseous radioactive waste system is used to reduce radioactive materials in gaseous effluents before discharge to meet the dose limits in 10 CFR Part 20 and the ALARA dose design objectives in Appendix I to 10 CFR Part 50.

The NRC staff reviewed the TMI-1 radioactive effluent release reports for 2003 through 2007 for gaseous effluents (AmerGen 2004b, 2005b, 2006b, 2007a, 2008b). Based on the gaseous waste processing systems and effluent controls and performance from 2003 through 2007, the gaseous discharges for 2007 are consistent with the radioactive gaseous effluents discharged from 2003 through 2006. Variations on the amount of radioactive effluents released from year to year are expected based on the overall performance of the plant and the number and scope of outages and maintenance activities. The radioactive gaseous wastes reported by TMI-1 are reasonable and no unusual trends were noted.

Exelon Generation intends to replace the TMI-1 steam generators before the period of extended operation. This action is not likely to result in a significant increase in the amount of radioactive gaseous waste discharged over the amount discharged during normal plant operations, because any radioactive gaseous waste generated, processed, and released during the outage will be offset by the amount of radioactive gaseous waste that would not be generated, processed, and released during normal plant operations. Based on the historical evaluation and because no significant increase in radioactive gaseous effluents from the potential repair or replacement of the TMI-1 steam generators is anticipated, similar quantities of radioactive gaseous effluents are expected to be generated during normal operations and outages from TMI-1 during the period of extended operations. The radioactive gaseous waste releases to the environment during the refurbishment will still be controlled and limited to satisfy the dose

Affected Environment

objectives of Appendix I to 10 CFR Part 50. These releases would result in doses to members of the public that are well below the ALARA dose design objectives, as discussed in Section 4.8.1.

2.1.2.3 Solid Radioactive Waste

The TMI-1 radioactive solid waste disposal system is designed to safely collect, process, store, and prepare wet and dry solid radioactive waste materials for onsite storage and offsite shipment. The system consists of a wet process stream used to collect, process, dewater, and solidify wet solid wastes, and a dry process stream used to collect and package dry solid wastes. Wet solid wastes include spent resins, filter cartridges, and filter crud. Dry solid wastes include contaminated rags, clothing, paper, outage equipment, and other radioactively contaminated equipment (AmerGen 2006a). Transportation of the radioactive solid waste is conducted in accordance with NRC and U.S. Department of Transportation (DOT) regulations as specified in 10 CFR Part 61, "Licensing Requirements for Land Disposal of Radioactive Waste," and 10 CFR Part 71, "Packaging and Transportation of Radioactive Material."

The NRC staff reviewed the TMI-1 solid radioactive waste reports for 2003 through 2007 (AmerGen 2004b, 2005b, 2006b, 2007a, 2008b). The solid waste volumes and radioactivity amounts generated in 2007 are typical of previous annual waste shipments made by TMI-1. Variations in the amount of solid radioactive waste generated and shipped from year to year are expected based on the overall performance of the plant and the number and scope of maintenance work outages. The volume and activity of solid radioactive wastes reported by TMI-1 are reasonable and no unusual trends were noted.

Exelon Generation intends to replace the TMI-1 steam generators before the period of extended operation. Such an action is likely to result in a small increase in the amount of solid radioactive waste generated. This is based on an increase in the number of personnel working at the plant which will result in the generation of more solid waste during the outage and any other associated related work. An outage of this type will also result in an increased use of protective clothing, safety equipment, and filters, as well as a general increase in the generation of debris that will have to be disposed of as radioactive waste. The increased volume is expected to be within the range of solid waste that can be safely handled by TMI-1 during the period of extended operations. The transportation of the radioactive solid wastes related to the refurbishment activities will be conducted in accordance with NRC and DOT regulations as specified in 10 CFR Part 61 and 10 CFR Part 71.

Low-level mixed waste (LLMW) is waste that exhibits hazardous characteristics and contains low levels of radioactivity. LLMW has been regulated under multiple authorities. The U.S. Environmental Protection Agency (EPA) or State agencies regulate the hazardous component of LLMW through the Resource Conservation and Recovery Act (RCRA), and either the U.S. Department of Energy (DOE) or the NRC regulates the radioactive component. TMI-1 has not had any LLMW stored on site for the past 5 years and does not expect to have to store any in the foreseeable future.

The State of South Carolina's licensed low-level radioactive waste disposal facility, located in Barnwell, has limited the access from radioactive waste generators located in States that are not part of the Atlantic Low-Level Waste Compact. Pennsylvania is not a member of the Atlantic Low-Level Waste Compact. This has impacted the ability of TMI-1 to dispose of its low-level solid radioactive waste and necessitated the need for TMI-1 to store its low-level solid radioactive waste on site. TMI-1 has decided to store its low-level solid radioactive waste in the

solid waste staging facility (SWSF). The NRC staff has reviewed the TMI-1 SWSF plant procedure and has found that the SWSF performs no active function and was used for temporary staging of low-level radioactive waste before preparation for shipment and disposal. Because the SWSF is located outside and is exposed to the weather, the concrete structure and individual cells utilize gaskets, slots and weep holes, a drainage piping system, and a common sump, with its associated equipment and instrumentations, to protect the waste containers and to control the disposal of any effluent that may collect in the sump. TMI-1 has a monitoring, inspection, and testing program, which includes periodic evaluation of the operability and functional performance of active components of the SWSF system. The SWSF was designed to provide a controlled but ready access for material handling operations, to ensure that worker radiation exposures are controlled in accordance with the ALARA criteria, and to ensure that the offsite dose does not exceed any of the Federal limits specified in 10 CFR Part 20, as well as the EPA radiation standards in 40 CFR Part 190, "Environmental Radiation Protection Standards for Nuclear Power Operations."

2.1.3 Nonradiological Wastes

RCRA governs the disposal of solid and hazardous waste. RCRA regulations are contained in Title 40, "Protection of the Environment," Parts 239 through 299 (40 CFR 239, et seq.), of the *Code of Federal Regulations*. Parts 239 through 259 of Title 40 contain regulations for solid (nonhazardous) waste, and Parts 260 through 279 contain regulations for hazardous waste. RCRA Subtitle C establishes a system for controlling hazardous waste from "cradle to grave," and RCRA Subtitle D encourages States to develop comprehensive plans to manage nonhazardous solid waste and mandates minimum technological standards for municipal solid waste landfills (EPA 2007). Pennsylvania State RCRA regulations are administered by the Division of Hazardous Waste Management of the Pennsylvania Department of Environmental Protection (PADEP) and address the identification, generation, minimization, transportation, and final treatment, storage, or disposal of hazardous and nonhazardous wastes. TMI-1 generates nonradiological waste including oils, hazardous and nonhazardous solvents and degreasers, laboratory wastes, expired shelf-life chemicals and reagents, asbestos wastes, paints and paint thinners, antifreeze, nonroutine (i.e., project-specific) wastes, point-source discharges regulated under the National Pollutant Discharge Elimination System (NPDES), sanitary waste (including sewage), and routine, daily refuse (AmerGen 2008).

2.1.3.1 Hazardous Waste

Hazardous waste means solid waste, or a combination of solid wastes, which, because of its quantity, concentration, or physical, chemical, or infectious characteristics, may cause or contribute to an increase in mortality or serious illness. Such waste may also pose a significant present or potential hazard to human health or the environment if it is not properly treated, stored, transported, disposed of, or otherwise handled (40 CFR Part 261, "Identification and Listing of Hazardous Waste"). TMI-1 generates a variety of hazardous waste including spent and off-specification chemicals, laboratory chemical wastes, hazardous solvents and degreasers, and occasional project-specific wastes. TMI-1 is classified as a "small quantity generator" of hazardous waste because the plant generates less than 1000 kilograms of hazardous waste in 1 month, and no more than 6000 kilograms of hazardous waste may be accumulated on site at any one time (EPA 2007a).

Affected Environment

According to the EPA Envirofacts Warehouse, TMI-1 is classified as an active small quantity generator of hazardous wastes (EPA ID No. PAR000037861). The Envirofacts Warehouse database showed no violations for TMI-1 (EPA 2008a). During the site audit, the NRC viewed the TMI-1 waste accumulation building, which is a central facility designed for the safe and proper collection, sorting, packaging, and shipment of hazardous wastes. Also during the site audit, NRC staff reviewed Exelon Generation's hazardous waste procedures and determined they complied with applicable RCRA regulations.

2.1.3.2 Residual Waste

TMI-1 generates solid waste, as defined by RCRA, as part of routine plant maintenance, cleaning activities, and plant operations. In Pennsylvania, solid waste is further classified as either municipal waste or residual waste by PA Code Article VIII and Article IX, respectively, based on its origin. TMI-1 nonhazardous solid waste is classified as residual waste. In Pennsylvania, residual waste is defined as nonhazardous industrial waste, including solid, liquid, or gaseous waste material produced by industrial, mining, or agricultural operations (PA Code Article IX). In addition to plant garbage, residual wastes generated at TMI-1 include nonhazardous waste oil and oily debris resulting from maintenance of oil-filled equipment; nonhazardous sludge from the industrial water supply treatment facility, waste water facility, or air pollution control facility; nonhazardous solvents and degreasers; asbestos; antifreeze; and occasional project-specific nonhazardous wastes. In 2007 TMI-1 generated approximately 26 tons (t) (24 MT) of residual waste, not including approximately 198 t (179 MT) of garbage, of which approximately 188 t (170 MT) was incinerated at a resource recovery facility (AmerGen 2008d).

2.1.3.3 Universal Waste

Universal waste is hazardous waste that is generated in a variety of settings and by a vast community and poses collection and management problems and often is not appropriately managed under existing hazardous waste regulations. EPA classifies several hazardous wastes as universal wastes including batteries, certain pesticides, mercury-containing devices, and fluorescent lamps (40 CFR Part 273, "Standards for Universal Waste Management").

Pennsylvania has incorporated by reference the EPA regulations regarding universal wastes. TMI-1 is a small quantity handler of universal waste (meaning the facility cannot accumulate more than 5000 kilograms (approximately 11,000 pounds) of universal waste at any one time), generating common operational wastes such as lighting ballasts containing polychlorinated biphenyls (PCBs), lamps, and batteries. In 2007 TMI-1 generated approximately 7,271 pounds (3,298 kilograms) of universal wastes (AmerGen 2008d).

2.1.3.4 Mixed Waste

As previously discussed in Section 2.1.2.3, LLMW contains both low-level radioactive waste and RCRA hazardous waste (40 CFR Part 266, "Storage, Treatment, Transportation, and Disposal of Mixed-Waste"). Pennsylvania has incorporated by reference Federal regulations exempting LLMW from RCRA storage and treatment regulations, provided the waste meets specific conditions (PADEP 2001). TMI-1 has not generated any mixed waste in the past five years (AmerGen 2008d).

2.1.3.5 Permitted Discharges

TMI-1 generates two types of wastewater—industrial effluents and sanitary liquid wastes, both of which are discharged to the Susquehanna River according to the TMI-1 Individual Wastewater Discharge NPDES Permit No. PA0009920, enforced by PADEP (radioactive liquid waste is addressed in Section 2.1.2.1 of this report). Normal operating processes are used to control the pH of the reactor coolant prevent scale and corrosion in the cooling system and clean and defoul the condenser of biological organisms that generate chemical and biocide wastes. Waste liquids containing chemicals from these processes are combined with cooling tower blowdown and are discharged to the Susquehanna River according to the limitations contained in the TMI-1 NPDES permit. The industrial waste treatment system provides treatment of secondary plant sumps and drains to meet NPDES permit effluent limitations. Treatment includes settling and filtration to remove solids, an air flotation unit to remove oil and grease, and pH adjustment. TMI-1 has an onsite sewage treatment plant to treat sanitary wastewater generated by the plant. The sewage treatment plant averages approximately 11,000–12,000 gallons (41,640–45,420 liters [L]) of effluent per day; approximately 7,000 gallons (26,500 L) are treated effluent and approximately 4,000 gallons (15,140 L) are filtered water used to deliver chlorine gas to the effluent for disinfection. Digested sanitary sludge from the sewage treatment plant is analyzed for radionuclides and transferred to a PADEP-approved agriculture utilization facility for disposal (AmerGen 2008d). Section 2.1.7.3 of this report provides more information on TMI-1 NPDES permit and effluent limitations.

2.1.3.6 Pollution Prevention and Waste Minimization

Currently, TMI-1 implements a waste minimization program which consists of steps such as segregating hazardous and nonhazardous wastes, choosing nonhazardous substitutes when possible, recycling or reclaiming appropriate waste materials, monitoring expired chemicals to determine minimum stocking requirements to reduce recurring excess, finding alternate uses for excess materials, or returning unused materials to the manufacturer. During the summer of 2008, TMI-1 implemented a recycling program for common waste materials such as paper, plastic, and aluminum.

In support of nonradiological waste minimization efforts, the EPA Office of Pollution Prevention and Toxics established a clearinghouse that provides information regarding waste management and technical and operational approaches to pollution prevention. The EPA clearinghouse can be used as a source for additional opportunities for waste minimization and pollution prevention at TMI-1, as appropriate (EPA 2008b).

EPA also encourages the use of environmental management systems (EMSs) for organizations to assess and manage the environmental impact associated with their activities, products, and services in an efficient and cost-effective manner. EPA defines an EMS as “a set of processes and practices that enable an organization to reduce its environmental impacts and increase its operating efficiency.” EMSs help organizations fully integrate a wide range of environmental initiatives, establish environmental goals, and create a continuous monitoring process to help meet those goals. The EPA Office of Solid Waste especially advocates the use of EMSs at RCRA-regulated facilities to improve environmental performance, compliance, and pollution prevention (EPA 2008a). Introductory Web-based EMS training is available at the EPA Web

Affected Environment

site.² Exelon Generation has implemented an EMS at TMI-1, and TMI-1 is an ISO 14001-certified plant, which requires a commitment to continuous improvement, emergency response planning, and independent monitoring of all environmental impact areas including energy and water consumption, sewage discharge, airborne emissions, hazardous material and noise levels.

2.1.4 Plant Operation and Maintenance

Maintenance activities conducted at TMI-1 include inspection, testing, and surveillance to maintain the current licensing basis of the facility and to ensure compliance with safety and environmental requirements. Various programs and activities currently exist at TMI-1 to maintain, inspect, test, and monitor the performance of facility equipment. These maintenance activities include inspection requirements for reactor vessel materials, boiler and pressure vessel in-service inspection and testing, a maintenance structures monitoring program, and maintenance of water chemistry (AmerGen 2008c).


Additional programs include those implemented to meet technical specification surveillance requirements, those implemented in response to NRC generic communications, and various periodic maintenance, testing, and inspection procedures. Certain program activities are performed during the operation of the unit, while others are performed during scheduled refueling outages. Nuclear power plants must periodically discontinue the production of electricity for refueling, periodic in-service inspection, and scheduled maintenance. TMI-1 refuels on a 24-month interval (AmerGen 2008c).

2.1.5 Power Transmission System

TMI-1 is connected to the regional grid via four, 230-kilovolt (kV) transmission lines, which total 5.6 mi (9.0 km) in length. These transmission lines are owned by Exelon Generation, who purchased TMI-1 from FirstEnergy in 1999; however, FirstEnergy continues to operate and maintain the transmission lines and their right-of-ways (ROWs) (AmerGen 2008). Transmission lines considered in scope for license renewal are those constructed to connect the facility to the transmission system (10 CFR 51.53(c)(3)(ii)(H)); therefore, the four lines, Line No. 1091, Line No. 1092, Line No. 1051, and the TMI-1 to TMI-1 500-kV substation line, are considered in scope and are discussed below in detail.

All four transmission lines originate at the TMI-1 switchyard and are shown in Figure 2-4 on the following page. Line No. 1091 and Line No. 1092 extend 1.5 mi (2.4 km) northeast to the Middletown Junction Substation near Middletown, Pennsylvania. These lines share a 150-foot-wide (46-meter [m]) ROW. Line No. 1051 travels south for 4.1 mi (6.6 km) from the TMI-1 switchyard to the Jackson Substation, which is located near Jackson, Pennsylvania. The fourth line, unnumbered, travels from the TMI-1 switchyard 0.7 mi (1.1 km) to the TMI 500-kV substation. Line No. 1051 and the unnumbered line share a 150-foot-wide (46 m) ROW (AmerGen 2008).

² Web-based EMS training available URL: <http://www.epa.gov/epaoswer/ems/ems-101/ems101.htm>



Legend

- Transmission Line
- ▲ Substation





Figure 2-4. Three Mile Island Nuclear Station, Unit 1, Transmission System
(Source: AmerGen 2008)

Affected Environment

In total, FirstEnergy operates and maintains 5.6 mi (9.0 km) of transmission lines and maintains 142 acres (ac) (57 hectares [ha]) of transmission line ROWs (AmerGen 2008). The four lines cross the Susquehanna River in three locations, as shown in Figure 2-4. The lines do not cross any Federal, State, or local parks. FirstEnergy has vegetative maintenance procedures in place to prevent vegetation from interfering with the lines (FirstEnergy 2007). ROW vegetative maintenance practices use an integrated vegetation management approach that includes both mechanical and chemical control methods. Mechanical methods consist primarily of mowing, with supplementary pruning, felling, and hand trimming as needed. Chemical control methods consist of application of EPA-approved herbicides and tree-growth-regulating chemicals (FirstEnergy 2008). Procedures are in place to manage environmental incidents that might occur within the ROW, such as a chemical buildup in a wetland area. Exelon Generation, in conjunction with FirstEnergy staff, limits erosion around stream crossings and wetlands by using appropriate procedures and methods. ROWs that cross farmland or pastures are not maintained by FirstEnergy, as the land is cultivated by the local farmers. FirstEnergy will maintain the existing ROWs regardless of whether TMI-1 is granted a renewed operating license (AmerGen 2008).

2.1.6 Cooling and Auxiliary Water Systems

The TMI-1 circulating water system withdraws cooling water from, and discharges cooling tower blowdown to, the Susquehanna River. TMI-1 uses two hyperbolic natural draft cooling towers to dissipate heat from the plant's steam cycle to the atmosphere. Other systems that dissipate heat from the plant include the secondary services cooling system, the nuclear services cooling system, and the decay-heat cooling system (AEC 1972).

Water that is lost through cooling tower evaporation, wind, and as blowdown returned to the Susquehanna River is termed "makeup" water. Makeup water is obtained from the secondary services river water pumping system. The river intake structure is located on the shoreline of the Susquehanna River and is designed to pump under three river conditions—minimum river level of 271 ft (83 m) ("loss of the York Haven Dam"), normal river elevation of 278 ft (85 m), and flood levels. A deicing line operates during periods of subfreezing temperatures to prevent ice from forming and possibly blocking the intake structure. Under normal operation in subfreezing weather, condenser circulating water is the source of deicing water (AEC 1972).

River water enters the intake structure at a velocity of approximately 0.2 feet per second (ft/s) (0.06 m per second [m/s]), passes under a skimmer wall, travels through automated trash racks with 1-inch vertical bar spacing, through 3/8-inch mesh traveling screens, through the river water pumps, and lastly through 1/8-inch mesh strainers before entering the heat exchangers. Once in the heat exchangers, river water mixes with the circulating water in the circulating pumps. The circulating water pump building contains six circulating water pumps—three pumps feed each of the two, 102-inch-diameter mains (AEC 1972). The circulating water system contains a chemical injection system for controlling bacterial and algae growth and metal corrosion (AmerGen 2008). The chemical injection to the circulating water comprises sodium hypochlorite, sulfuric acid, sodium bromide, scale inhibitor, dispersants, and other associated chemicals (AmerGen 2008c).

Under normal operation, maximum withdrawal of makeup water from the Susquehanna River for cooling tower losses is approximately 15,250 gallons per minute (gpm) (34 cubic ft per second

[cfs], or 1 cubic meter per second [m^3/s]). Water is pumped to a high point on the site, and cooling tower blowdown is drained by gravity and discharged back to the Susquehanna River through a 48-inch-diameter river discharge line, which is located behind the natural shoreline downstream of the river intake structure. Cooling tower blowdown ranges from 3000 gpm (6.7 cfs, or $0.19 \text{ m}^3/\text{s}$) during normal operation to 6000 gpm (13.4 cfs, or $0.38 \text{ m}^3/\text{s}$) during maximum operation. Under normal conditions the discharge velocity is 2.7 ft/s (0.8 m/s) with a maximum value of 5.2 ft/s (1.6 m/s) (AEC 1972). The PADEP regulates plant discharges under NPDES Individual Wastewater Discharge Permit No. PA 0009920 (AmerGen 2008). Section 2.1.7.3 of this report discusses the discharges permitted from TMI-1.

The TMI-1 intake structure does not have a fish return system, therefore fish and other aquatic organisms that may become entrained in the TMI-1 intake structure and impinge on the trash racks, traveling screen, or mesh strainers are not returned to the river. However, the TMI-1 circulating water system is equipped with cooling towers, which is considered the best technology available for minimizing impingement and entrainment impacts to aquatic species. Also, as stated above, the flow velocity at the intake structure under normal operating conditions is approximately 0.2 ft/s (AmerGen 2008).

2.1.7 Facility Water Use and Quality

The TMI-1 circulating water system and the service water system both draw water from, and discharge to, the Susquehanna River. Onsite ground water wells also supply water for cooling water makeup, domestic water consumption, and other industrial uses. The following sections detail water use at TMI-1.

2.1.7.1 Ground Water Use

A portion of the water utilized by TMI-1 for its operation is ground water. Specifically, ground water is used for station fire service, makeup water to the demineralized water system, bearing lubrication for the screen house intake pumps, service water for onsite buildings and equipment, and drinking water. Onsite ground water is drawn from three service wells (installed in 1996) and two drinking water wells (one of which can also be used, when needed, to supply additional water to the service system). Two additional wells are located offsite and supply potable water to the Visitors Center and the Training Center/Simulator Building. Drinking water is treated on site using a zinc orthophosphate solution, and a sodium hypochlorite solution, as permitted by PADEP. The site also operates a sanitary wastewater treatment facility, with a capacity of up to 80,000 gallons per day (gpd) (302,833 liters per day [Lpd]) though the typical flow ranges from 10,000 gpd to 15,000 gpd (37,854 Lpd to 56,781 Lpd), with a maximum flow of 40,000 gpd (151,416 Lpd) during outages (AmerGen 2008).

2.1.7.2 Surface Water Use

Susquehanna River water is withdrawn for use in the circulating cooling water system through the intake structure located on the island's western bank. Under typical conditions the flow velocity at the intake structure is around 0.2 ft/s (0.06 m/sec), with a normal river elevation of 277 feet (84.4 m). Approximately 12,250 gpm (27.3 cfs, or $0.8 \text{ m}^3/\text{s}$) is withdrawn from the river under these conditions, and the maximum withdrawal of makeup water is approximately 15,250 gpm (34 cfs, or $1.0 \text{ m}^3/\text{s}$) (AmerGen 2008). The intake structure is designed to pump river water

Affected Environment

into the system during normal conditions and during extreme conditions such as the loss of the York Haven Dam and major flood levels (AmerGen 2008).

Cooling tower blowdown typically ranges from 3000 gpm to 6,000 gpm (6.68 to 13.4 cfs, or 0.2 to 0.4 m³/s) at its maximum. Water not lost by evaporation or drift from the cooling towers is discharged at a rate ranging from 2.7 ft/s to 5.2 ft/s (0.82 m/s to 1.58 m/s) at its maximum, in a manner complying with the plant's NPDES Individual Wastewater Discharge Permit No. PA 0009920 issued by PADEP in October 2007 (AEC 1972; AmerGen 2008).

The primary sources of river water consumption are evaporation and drift losses. TMI-1 has an SRBC (Susquehanna River Basin Commission) permit allowing for the consumptive use of river water of up to 18 million gpd (mgd) (68 million Lpd) (SRBC 1995). To abide by this permit, TMI-1 takes part in the Cowanesque Reservoir Water Allocation Project. This project keeps TMI-1 from having to shut down in the event of a severe drought in the Susquehanna River by allowing for water stored in the reservoir to be discharged downstream during such an emergency.


2.1.7.3 Surface Water Quality

Between the years 1974 and 1982, Metropolitan Edison and GPU Nuclear performed various studies on the water quality around Three Mile Island to evaluate the impacts of the plant on local water quality (Ichthyological Associates 1983). These studies utilized data on water chemistry, macroinvertebrates, larval and adult fishes, and thermal plume mapping. The last year with available data for both operating units is 1978 because of the accident at TMI Unit 2 in March 1979. During this period of combined operation of the two units, none of the water quality criteria violated the State requirements. The studies examined water quality parameters including turbidity, alkalinity, sulfate, total dissolved solids, total and dissolved copper, and total and dissolved zinc. The data were gathered near both the upstream and downstream discharge structures. Additional measurements of water temperature, pH, and dissolved oxygen were taken at various sampling locations (Ichthyological Associates 1983).

The studies concluded that mean levels for dissolved oxygen, turbidity, total copper, and total zinc peaked in April, whereas water temperature, alkalinity, sulfate, and total dissolved solids peaked in July. Dissolved zinc was highest in November. The data also showed that levels of alkalinity, sulfate, dissolved copper, and total zinc were generally higher values upstream, whereas levels of water temperature, dissolved oxygen, turbidity, total dissolved solids, and dissolved zinc were higher downstream (Ichthyological Associates 1979; 1983).

The Susquehanna River was tested for water temperature and showed a typical pattern of low temperatures in the winter, with highs in the late summer months. Water temperature data obtained immediately below the discharge indicated that the thermal effluent did not heat the surrounding water enough to exceed the temperatures mandated by the State. It also showed that the upstream and downstream temperatures did not differ by over 5 degrees Fahrenheit (°F) (Ichthyological Associates 1979; 1983). Water temperature data collected between March 1979 and 1982 represent ambient conditions because, following the TMI Unit 2 accident, both units were shut down, with TMI-1 not resuming operation until 1985.

In more recent years, Exelon Generation has collected water temperature data using an automatic temperature sensor located at the intake screen pump house and the discharge monitoring pit, which is before the discharge water is mixed with the river water. Figure 2-5 on the following page represents the recorded daily average discharge and intake temperatures



LEGEND

- Daily Average Inlet
- - - Daily Average Discharge




Figure 2-5. Three Mile Island Nuclear Station, Unit 1, Inlet and Discharge Temperatures
(Source: AmerGen 2007c)

between August 2005 and September 2007, with the 2006 maximum discharge recorded as 110.2°F (43.4 degrees Celsius [°C]) and the 2007 maximum as 101.1°F (38.4 °C) (recorded in August and September, respectively). Table 2-1 represents the calculated differences between discharge and intake temperature (ΔT) on a month-to-month basis recorded during the same time period. The maximum temperature difference recorded is 30.16 °F in April 2006 (AmerGen 2007c).

Table 2-1. Monthly Average, Minimum, and Maximum ΔT (°F) Based on Automatic Temperature Sensors at the Intake Screen Pump House

Year	Month	Average ΔT	Minimum ΔT	Maximum ΔT
2005	August	11.66	7.50	13.80
	September	11.04	2.76	16.46
	October	11.16	1.61	16.58
	November	5.98	0.78	14.67
	December	11.13	4.74	14.02
2006	January	9.47	6.30	10.77
	February	9.43	6.35	11.67
	March	12.23	5.32	17.04
	April	15.86	11.26	30.16
	May	16.10	7.13	20.61
	June	17.80	8.96	22.68
	July	16.59	9.72	21.17
	August	16.86	11.99	21.88
	September	18.84	10.26	21.56
	October	17.10	10.18	21.27
	November	16.04	4.83	22.41
	December	17.17	5.42	21.71
2007	January	16.88	11.35	20.22
	February	17.32	11.01	19.36
	March	17.35	9.64	24.37
	April	20.55	10.99	28.96
	May	21.01	15.97	27.08
	June	14.87	8.67	19.17
	July	15.01	11.62	18.04
	August	13.95	10.08	16.53
	September	15.56	8.74	20.95

Source: AmerGen 2007c

Historically, monitoring in the Susquehanna River has shown river flow to be a very influential parameter in determining water quality. Over the past few decades of recorded data, mean river flow fluctuated based on snow melt, spring runoff, rain, and periods of drought. A parameter analysis conducted using 17 years of water temperature, pH, and dissolved oxygen data, and 13 years of total dissolved solids data found that trends appear to relate more to meteorological

cycles, river flows, and land and water uses than to operations at the TMI-1 site. In addition, the data showed no significant impact of TMI-1 discharge on water quality (Normandeau 2007).

The water quality of the Lower Susquehanna River Basin has considerably improved since the 1970s. Water quality issues in this area were historically dominated by acid mine drainage discharges upstream, which have been considerably reduced, as well as sewage-treatment plant improvements, a ban on phosphate detergents, and improvement of agricultural practices. The concentration of nitrate, however, has been shown to be increasing. A 2002 water quality study conducted by the SRBC collected data from 25 stations along the river, as well as at the mouths of its three major tributaries. Six of these stations were determined to be moderately impaired, and 19 were designated as slightly impaired. Out of the 950 tested water quality data points, 79 were found to exceed the tolerance levels for aquatic life. According to the SRBC report, this is an indication of fairly good water quality (SRBC 2006).

In accordance with the Federal Water Pollution Control Act (or the Clean Water Act (CWA)), TMI-1 effluent discharges are regulated by NPDES Individual Wastewater Discharge Permit No. PA 0009920 issued and enforced by PADEP. Section 402 of the CWA states that "NPDES prohibits [discharges] of pollutants from any point source into the nation's waters except as allowed under an NPDES permit." The purpose of this permit is to regulate wastewater discharge to preserve the water quality of the surrounding water bodies. As of the most recent permit issued, there have been no notices of violation for the TMI-1 site. Information in this section was obtained from the TMI-1 NPDES. The applicant's license renewal environmental report includes a copy of the most recent TMI-1 NPDES permit (AmerGen 2008).

The most recent renewal of this permit occurred in October 2007. Table 2-2 on the following page shows the quantitative effluent limitations regulated under the NPDES permit. In addition to these effluent limitations, the permit also stipulates that during any 1-hour period, discharge may not affect the temperature of the receiving water body by more than 2 °F. No violations of this limit have been recorded.

The permit outlines the effluent limitations and monitoring requirements of 10 different discharge outfalls. In addition to the effluent limitations shown in Table 2-2, the permit also outlines the minimum number of sampling events that are required for each outfall, where necessary. Additionally, the discharge of "floating solids, visible foam, or other substances that produce color, tastes, odors, turbidity or settle to form deposits" are to be controlled, and pH is to be monitored, with the required levels being between 6.0 and 9.0.

Outfall 001 (the main station outfall) receives wastewater from the circulating cooling water, secondary service water, reactor building emergency cooling, decay heat, nuclear service water, liquid radioactive waste treatment, station blackout diesel cooling water, and several other minor sources. Its discharge limitations were calculated based on a maximum discharge rate of 81.02 mgd (306.7 million Lpd). Outfall 003 is an emergency outfall, meant to receive discharge from TMI-1 in the event that Outfall 001 is blocked. Outfall 004 is another emergency outfall which receives discharge from TMI-1 in the event that the TMI-1 mechanical draft cooling tower basin is blocked. Both of these emergency outfalls are based on the same rate of 81.02 mgd (306.7 million Lpd) as Outfall 001. If either of these outfalls is used, the facility is required to notify PADEP within 2 days to explain the composition of the discharge and the reason for its use.

Table 2-2. National Pollutant Discharge Elimination System Effluent Limitations for TMI-1

Outfall No.	Total Suspended Solids (mg/L)			Oil and Grease (mg/L)			CBOD-5 Day (mg/L)		Free Available Chlorine (mg/L)		Phosphorus (mg/L)		Total Residual Oxidants (mg/L)		Spectrus Hydrazine (mg/L)		Temperature (°F)		
	Avg. Month	Max. Daily	Inst. Max.	Avg. Month	Max. Daily	Inst. Max.	Avg. Month	Inst. Max.	Max. Daily	Inst. Max.	Avg. Month	Inst. Max.	Max. Daily	Inst. Max.	Max. Daily	Inst. Max.	Instant Max.	10/1-3/31	4/1-9/30
001	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	0.2	0.5	NLR	NLR	0.14	0.17	0.1	0.3	Not Detectable	110	115
003	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	0.2	0.5	NLR	NLR	0.14	0.17	0.1	0.3	Not Detectable	110	115
004	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	0.2	0.5	NLR	NLR	0.14	0.17	0.1	0.3	Not Detectable	NLR	NLR
005A	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR
005B	30	100	NLR	15	20	30	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR
006	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR
101	30	NLR	60	NLR	NLR	NLR	25	50	NLR	NLR	2.0	4	NLR	NLR	NLR	NLR	NLR	NLR	NLR
401	30	100	NLR	15	20	30	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR
501	30	100	NLR	15	20	30	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR
701	30	100	NLR	15	20	30	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR

Source: NPDES No. PA 0009920

NLR = No Longer Regulated

Outfall 101 receives wastewater from the sewage treatment plant, and its limitations are based on a discharge rate of 0.08 mgd (302,833 Lpd). In addition to the effluent limitations shown, the permit requires this outfall to be monitored for fecal coliform levels, which are restricted to an average monthly concentration of 200 per 100 milliliters from May to September, and 2000 per 100 milliliters from October to April. Outfall 401 receives wastewater from the industrial waste filter system, and its limitations are based on a discharge rate of 0.3 mgd (1.1 million Lpd). Outfall 501 receives wastewater from the TMI-1 secondary neutralizer tank, and its limitations are based on a discharge rate of 0.3 mgd (1.1 million Lpd). Outfall 701 receives wastewater from the industrial waste treatment system, and its limitations are based on a discharge rate of 0.3 mgd (1.1 million Lpd).

Outfall 005B receives wastewater from screen house desilting, dewatering of the TMI-1 natural draft cooling towers, fire brigade training, the fuel oil offloading station, industrial cooler maintenance, emergency diesel generator building floor drains, and operation of the east dike settling basin drain valve. The discharge rates upon which these limitations are based are not specified by the permit. Outfall 006 receives wastewater from intake screen wash and sluice water, the intake pump strainer backwash, and the intake chlorinator building floor drain. No discharge limitations are put on this outfall, but it does require the collection of all debris found on the intake screens which is not discharged into the Susquehanna River. The stormwater outfalls (SO) are 005A, SO1, SO2, SO3, and SO4. They do not have specific effluent limitations, but are required to be inspected annually or monitored for biochemical oxygen demand (BOD-5 Day), chemical oxygen demand, total suspended solids, total phosphorus, total Kjeldahl nitrogen, dissolved iron, oil and grease, and pH levels.

TMI-1 is required to report effluent monitoring data to PADEP using discharge monitoring reports. TMI-1 is also required to report, within 24 hours of their occurrence, any unexpected diversions of wastewater that exceed any listed effluent limitation, upsets that exceed or threaten to exceed any limitations, and any violations of maximum daily discharge limitations.

Part C of the NPDES permit specifies that waterborne releases of radioactive material must conform to the guidelines in Appendix I to 10 CFR Part 50. The facility must provide reports which describe quantities of unrestricted radioactive material released in effluent discharge to the PADEP Bureau of Radiation Protection and the NRC.

2.2 Affected Environment

This section provides general descriptions of the environment near TMI-1 as background information. This section also provides detailed descriptions where needed to support the analysis of potential environmental impacts of refurbishment and operation during the renewal term, as discussed in Chapters 3 and 4. Section 2.2.9 describes historic and archaeological resources in the TMI-1 area, and Section 2.3 describes the possible impacts associated with other Federal project activities.

2.2.1 Land Use

Three Mile Island covers approximately 370 acres (ac) (150 hectares [ha]), of which about 200 ac (81 ha) are occupied by the TMI-1 and TMI Unit 2 facilities. Exelon Generation owns the

Affected Environment

entire island except certain TMI Unit 2 facilities. Exelon Generation also owns all or a portion of some of the smaller islands in the vicinity of Three Mile Island and a portion of the eastern bank of the Susquehanna River. TMI-1 is surrounded by fencing and contains few areas that have not been developed or previously disturbed. As can be seen in Figure 2-6, the undeveloped land on the island is found south of the TMI-1 and TMI Unit 2 facilities. The majority of this undeveloped land lies under the 10-year flood level and is subject to seasonal variations in water level. The southern part of the island contains a wetland that was formed when borrow pits created during construction of a flood dike system, which surrounds the TMI-1 and TMI Unit 2 facilities, filled with water. The southern portion of the island also contains fallow field areas that are surrounded by a woodland buffer (AmerGen 2008).

The TMI-1 site encompasses several properties that total approximately 440 ac (162 ha). Included are Three Mile Island; St. John's Island and Evergreen Island (also referred to as "Sand Beach Island"), which are situated north of Three Mile Island and together total approximately 31 ac (13 ha); a 6.4-ac (2.6-ha) section of Shelley Island, which is part of the western half of the TMI-1 exclusion area; and a 32-ac (13-ha) strip of land east of Three Mile Island along the eastern shore of the Susquehanna River (AmerGen 2008).

Three Mile Island is approximately 11,000 ft long and 1,700 ft wide with the long axis aligned north to south in the river. It lies approximately 900 ft from the east bank of the Susquehanna River and approximately 6500 ft from the west bank of the river (see Figure 2-6 on the following page). The Susquehanna River makes a sharp change in directional flow from southeasterly to nearly due south just north of Three Mile Island where the river widens to approximately 1.5 mi (2.4 km). This widening resulted from the Red Hill and York Haven Dams, which transect the river on either side of the downstream end of Three Mile Island creating a barrier for the purpose of hydroelectric generation (AmerGen 2008). State Highway (SH)-441 parallels Three Mile Island to the east, and tracks of the Norfolk Southern Railroad parallel the Susquehanna River on the eastern and western banks. Shelley Island is located west of Three Mile Island in the middle of the river, and the borough of Goldsboro is located on the western bank of the river. The developed portion of the TMI-1 site is surrounded by a flood protection dike system. Access to the northern portion of Three Mile Island is by a bridge connecting the main entrance to the TMI-1 site and the mainland near the junction of SH-441 and Geyers Church Road. Another bridge connects the southern end of Three Mile Island with the east bank of the Susquehanna River near Falmouth on SH-441 in Lancaster County. The southern bridge serves as access to TMI-1 for some station operation personnel, refueling outage workers, and construction equipment. It also provides an alternate egress route.

2.2.2 Air and Meteorology

TMI-1 is located in Dauphin County, one of the four counties comprising the Harrisburg metropolitan area (AmerGen 2008). Pennsylvania is divided into 10 climate regions. Dauphin County belongs to Climate Region 5, along with Lycoming, Columbia, Montour, Union, Northumberland, Snyder, Mifflin, Juniata, and Perry Counties (PSC 2008). Data collected in the region since 1899 show that average winter temperature is 29.9 °F (1.2 degrees Celsius [°C]), rarely dropping below 20 °F (-6.7 °C), while average summer temperature is 61.15 °F (16.39 °C), with July being the hottest month (PSC 2008a).

Affected Environment







Figure 2-6. Three Mile Island Nuclear Station, Unit 1, Site Boundary Map
(Source: AmerGen 2008)

Affected Environment

Precipitation is fairly evenly distributed throughout the year. Annual precipitation amounts generally range between 30 to 48 inches, with occasional amounts reaching 54 to 58 inches. The greatest amounts of precipitation usually occur in the spring and summer months, while February is the driest month, amounting to about 2 inches less than the wettest months (PSC 2008b). As documented by Pennsylvania State climatologists, average mean snowfall from 1957 through 2007 was 35.4 inches (PSC 2008c).

The dominant wind direction throughout the State of Pennsylvania is from the west, with some seasonal variation. TMI-1 historical meteorological reports show that yearly winds from the northwest prevail, with stronger winds in winter (windspeed varies from 4 to 10 knots) and calmer winds in summer (windspeed varies from 0 to 6 knots). The median annual windspeed as reported by the National Weather Service station located in Harrisburg (approximately 10 mi [16 km] northwest of TMI-1) is 7.5 mi per hour (mph) (4.1 knots) (NCDC 2008; PSC 2008b). While the prevailing westerly winds result in most of the air masses that affect Pennsylvania (those originating from the interior of the continent), the Atlantic Ocean does have a limited influence on the climate of the State. Coastal storms can affect the day-to-day weather, primarily in the eastern section of the State.

Severe weather events in Pennsylvania are generally uncommon. Severe snowstorms are infrequent, but when they do occur, they can approach blizzard conditions. High winds have been known to cause huge drifts that can disrupt normal routines for several days. While the incidence of tornadoes is very low, the region has occasionally been hit with storms that caused loss of life and property damage. June is the month of highest tornado frequency, followed closely by July and August. The National Climatic Data Center (NCDC 2008a) reported 13 tornadoes in Dauphin County from 1950 through February 2008—three at F0, six at F1, and four at F2 strengths.³ The most destructive activity in Dauphin County occurred on April 5, 1977, and caused \$2.5 million in property damage (NCDC 2008b). There was also an occurrence of an F3 tornado on July 14, 2004 in Campbelltown, PA, located in Lebanon County, which caused approximately \$18 million in property damages (NOAA 2007).

The TMI-1 meteorological data monitoring system consists of Alpha and Bravo systems. Alpha system allows it to measure windspeed and direction at 100 ft (30 m) and 150 ft (46 m), ambient temperature at 33 ft (10 m), and differential temperature at 150 ft (46 m). Measurement of windspeed and direction on Bravo system is conducted at 100 ft, while ambient temperature is measured at 33 ft (10 m) and differential temperature is measured at 150 ft (46 m). The meteorological data are collected via e-mail sent by the TMI-1 chemistry department. It is sampled once per hour and stored in the meteorological database which is edited once a week; invalid data are deleted during the data review process performed by a meteorologist. The

³ The Fujita six-point scale (F0 to F5) is used to rate the intensity of a tornado based on the damage it inflicts to structures and vegetation. The lowest intensity is F0; the highest is F5. Fujita scale categories are based on estimated (not measured) sustained windspeeds compared against observed structural damage. An enhanced Fujita scale replaced the original Fujita scale in February 2007. The enhanced Fujita scale still uses six categories of tornado intensity (EF0 to EF5), but defines those categories differently. For additional information about the Fujita scale, see the following National Oceanic and Atmospheric Administration Web site and the hypertext links therein—<http://www.spc.noaa.gov/faq/tornado/f-scale.html>.

quality-assured meteorological data are then compiled into monthly, quarterly, and annual reports (AmerGen 2006).

2.2.2.1 Regional Air Quality Impacts

TMI-1 is located within the Mid-Atlantic Air Quality Control Region 3, as designated by the EPA. The Mid-Atlantic Air Protection Region 3 is represented by Delaware, the District of Columbia, Maryland, Pennsylvania, Virginia, and West Virginia. The Bureau of Air Quality of PADEP is responsible for regulating all air emission sources within the State. Pennsylvania's ambient air monitoring program is a result of the implementation of the Federal Clean Air Act on a State level. The State is divided into six air regions, and Dauphin County, where TMI-1 is located, belongs to the Southcentral Air Quality Region, which includes the counties of Adams, Bedford, Berks, Blair, Cumberland, Dauphin, Franklin, Fulton, Huntington, Juniata, Lancaster, Lebanon, Mifflin, Perry, and York. Dauphin County is a nonattainment area for fine particulate matter (PM_{2.5}) and a part of the Harrisburg-Lebanon-Carlisle PM_{2.5} nonattainment area, which includes Cumberland, Dauphin, and Lebanon Counties. There are two monitoring sites in the Harrisburg-Lebanon-Carlisle PM_{2.5} nonattainment area—one in Dauphin County (Harrisburg) and one in Cumberland County (Carlisle). PADEP also operates several types of PM_{2.5} monitors in Carlisle and Harrisburg (PADEP 2004).

TMI-1 is recognized as a synthetic minor facility by Pennsylvania State regulators because of the quantities of emissions of criteria pollutants released by its stationary sources; therefore operation of the sources is regulated by a State Only Operating Permit for Synthetic Minor Facility (AmerGen 2006d). TMI-1 has a number of stationary emission sources, including two auxiliary boilers, two fire service pump diesel engines, two emergency power generators, a blackout emergency generator, a security system uninterruptible power generator, and two substation emergency power generators. A number of sources do not require any work practice standards, test monitoring, recordkeeping, or reporting requirements, as defined by the PADEP permit for TMI-1. Some of these sources include three air compressors, the turbine building, vents, turbine oil vapor extractor, a 15,000-gallon (56,781 L) turbine lubricating oil storage tank, water and waste water treatment chemical storage tanks, water and waste water treatment system, two natural draft cooling towers, two mechanical draft industrial box coolers, diesel fuel and fuel oil storage tanks, and an emergency warehouse diesel-fueled fire pump. The generators are tested periodically to ensure their continued ability to perform their intended function, and there are procedures in place to ensure monitoring and emissions data reporting.

2.2.3 Ground Water Resources

Three Mile Island is one of a sequence of Triassic lowland deposits in an area known as the Gettysburg Basin. The island itself formed during the later stages of glaciation as a result of fluvial deposition (materials deposited by river flow) of glacial melt-water by the slow-moving flow of the Susquehanna River and the resulting steady accumulation of sediments to form the island.

Two aquifers are located beneath the TMI-1 site. The shallowest aquifer consists of surficial alluvial deposits under unconfined conditions. The alluvial layer is made up of silty sand, with some gravels and clay, and ranges from 7–19 ft (2.1–5.8 m) in thickness. This layer overlies

Affected Environment

layers of glacial outwash, which range from 12–21 ft (3.7–6.4 m) in thickness and are composed of dense gravel and silt.

The second and underlying aquifer is the Gettysburg shale, which is the primary aquifer in the area of the site. Ground water in the Gettysburg shale is under semi-confined conditions, based on information gathered during drilling operations on the island. The shale is found 19–28 ft (5.8–8.5 m) below the surface (AmerGen 2008). It is described as a tabular aquifer, meaning some beds within the Gettysburg shale are able to transmit water, while others are not. The range of permeability within the bedrock is primarily caused by varying frequencies of fractures (Conestoga-Rovers 2006). Within the bedrock, which dips to the northwest, ground water is found within joints, fractures, and bedding separations. Two major joint sets occur on the island, with one dipping nearly 90 degrees, and the other dipping 50–60 degrees in the southwestern direction. The hydraulic conductivity of the aquifer ranges from 2,126 ft–4,208 ft/yr (648.0–1282.6 m/yr).

The ground water conditions found in the upper aquifer (the alluvial deposits) are directed by the river itself, with the water table's maximum elevation centered in the middle of the island and gently sloping toward the island's shores. The Susquehanna acts as a boundary for this aquifer as the ground water flows into the river. The lower aquifer (the Gettysburg shale) is unlikely to receive flow from the river because of its lower flow characteristics, but could occur if pumping from the surface is heavy enough to cause infiltration.

2.2.3.1 TMI-1 Water Supply Wells

Of the 54 water supply wells found in a specified 1-mile radius of the TMI-1 site, only 7 are associated with the plant. Five of these wells are onsite, while the remaining two supply potable water to the Visitors Center and the Training Center/Simulator Building. The Visitors Center well is installed at a depth of 121 ft (36.8 m) and produces up to 10 gpm (0.02 cfs, or 0.001 m³/s), while the Training Center/Simulator Building well is at 100 ft (30 m) and can yield up to 30 gpm (0.07 cfs, or 0.002 m³/s) (Conestoga-Rovers 2006). From 2003–2005, these seven ground water wells yielded a combined total that averaged to about 95–115 gpm (0.21–0.25 cfs, or 0.006–0.007 m³/s) (AmerGen 2004; 2005; 2006e).

Of the five onsite wells, two (the Operations Support Facility/North Office Building [OSF] well and the Building 48 [48S] well) supply the plant's public water system. The 48S well is installed at a depth of 996 ft (303 m) and produces a maximum of 30 gpm (0.07 cfs, or 0.002 m³/s). The OSF well, at 775 ft (236 m), can yield a maximum of 40 gpm (0.09 cfs, or 0.003 m³/s) and can be used, if necessary, to supplement the water production of the three industrial makeup water wells (A, B, and C). These three service water wells are installed at 400 ft (122 m), 500 ft (152 m), and 400 ft (122 m), respectively. Their water is utilized for the fire service, makeup to the demineralized water system, bearing lubrication in the screen house pumps, and various other building and equipment uses. Table 2-3 on the following page shows the annual ground water withdrawal data for the three industrial wells (both individually and combined) for the years 2003–2005.

Table 2-3. Total Annual Ground Water Withdrawal (Gallons) and Average Daily Withdrawal Rate (Gallons) for Industrial Wells, A, B, and C and Combined for 2003–2005

Year	Well A		Well B		Well C		Total	
	Total Withdrawn (x1000)	Avg. Daily Withdrawal Rate	Total Withdrawn (x1000)	Avg. Daily Withdrawal Rate	Total Withdrawn (x1000)	Avg. Daily Withdrawal Rate	Total Withdrawn	Avg. Daily Withdrawal Rate
2003	20,648	55,805	12,895	34,851	15,664	42,335	49,207,000	132,992
2004	20,434	54,930	11,696	31,441	10,859	29,191	42,989,000	115,562
2005	19,080	51,429	6,229	16,790	6,787	18,294	32,096,000	86,512

Source: AmerGen 2004, AmerGen 2005, AmerGen 2006a

The SRBC originally approved the use of ground water by the TMI-1 site in 1996. Before doing so, two 48-hour pump tests were conducted at a rate of 168,750 gpd (638,788 Lpd), and no adverse impacts were determined (SRBC 1999). When TMI-1 applied to the SRBC in 1998 for an increase in ground water withdrawal from its three industrial wells (A, B, and C), the original pump test data were considered in addition to observations of plant operations. After deciding that there were no production impacts to any of the onsite wells (including OSF and 48S) or any wells along the eastern shore of the island, SRBC approved the increase. Currently, all three industrial wells may pump a maximum limit of 225,000 gpd (156 gpm, or 851,718 Lpd) on a 30-day average (SRBC 1999).

2.2.3.2 TMI-1 Monitoring Wells

The Three Mile Island Nuclear Station began installing ground water monitoring wells in 1980 to monitor for the ground water infiltration of radionuclides such as tritium. As tritium decays, it emits a low-energy beta particle that cannot travel far into either tissue or air. It is produced from man-made sources as well as natural processes. In 2006, the background concentration of tritium in the onsite ground water was said to be (at most) 200 picoCuries per liter (pCi/L) (Conestoga-Rovers 2006).

That same year, Exelon began a study to evaluate the possible impacts of plant operation on nearby ground water and surface water, leading to the installation of 31 new onsite ground water monitoring wells. The initiation of this Exelon project was considered Phase 1 of the ground water monitoring effort at TMI-1, with Phase 2 being the continuation of the ground water monitoring program that had been in place at the station for over 20 years. Samples were collected from up to 76 well locations and the concentration of tritium was not found to exceed the EPA drinking water standard of 20,000 pCi/L in any location, but was detected to be higher than the background concentration during both studies. Samples taken from offsite drinking water wells proved to have no detectable concentrations of tritium (AmerGen 2007).

As a result of these studies, Exelon Generation introduced the Radiological Ground Water Protection Program (RGPP) in 2007. The purpose of this program is to ensure the detection and adequate response to any possible radiological releases to ground water. The program includes 59 onsite monitoring wells (5 of which are the water supply wells mentioned in Section 2.2.3.1), which are sampled for tritium, strontium-90, and gamma-emitting radionuclides (Exelon 2007). Results from these samples are compared to the results of the 2006 studies, which now serve

Affected Environment

as the baseline monitoring round, to enable the use of trends, quickly identify contamination issues, and ensure that ground water quality is maintained.

In 2007 the RGPP successfully identified significantly elevated tritium levels in several monitoring wells from May–July, three of which were found to have exceeded the EPA standard of 20,000 pCi/L (peaking at 29,600 pCi/L in July). The facility was able to identify the problem and the source of the tritium leak, isolate the source, and then repair it. Once the problem was corrected, tritium levels returned to acceptable standards.

Conestoga-Rovers & Associates also calculated the rate and amount of tritiated ground water migrating to the Susquehanna River, and the results were confirmed again following the tritium leak incident (Conestoga-Rovers 2007). Table 2-4 shows the rate of migration as affected by the pumping of onsite water supply wells, as well as with and without background levels. Conestoga-Rovers concluded that the migration of tritium to the Susquehanna River was negligible, and that the amount of tritium entering the river in ground water was “minimal” (Conestoga-Rovers 2006).

Table 2-4. Rate of Tritiated Ground Water Migration to the Susquehanna River as Affected by Onsite Pumping and Background Levels of Tritium (Curies Per Year)

	Total Mass Flux with Background (Ci/yr)	Background Contribution (Ci/yr)	Total Mass Flux without Background (Ci/yr)
No Pumping	0.32	0.09	0.23
Tritium Captured by Pumping	0.20	0.013	0.18
With Pumping	0.12	0.074	0.05

Source: Conestoga-Rovers 2006

2.2.4 Surface Water Resources

TMI-1 is located at approximately river mile 58 on the Susquehanna River, about 10 mi (16 km) south of the city of Harrisburg, Pennsylvania, on the northern half of the 370-ac (150-ha) Three Mile Island (AmerGen 2008). Three Mile Island is almost 12,000 ft (3,700 m) long and up to 2200 ft (700 m) wide. The Susquehanna River ranges in width from 7,000 ft–8,400 ft (2,100–2600 m) at Three Mile Island, but narrows to less than 1,800 ft (500 m) wide within 3,500 ft (1,100 m) downstream of Three Mile Island (AmerGen 2008). Three Mile Island is the longest in a group of islands that divides the river into three channels (west, center, and east), as illustrated in Figure 2-6. The intake and discharge structures for TMI-1 are located along the western shore of Three Mile Island, in the center river channel (Ichthyological Associates 1983). As described in detail in Section 2.1.6, the Susquehanna River provides makeup water for and receives blowdown from the two TMI-1 cooling towers (AmerGen 2008).

The Susquehanna River forms from two main branches, the North Branch Susquehanna River and the West Branch Susquehanna River. The source of the North Branch is Ostego Lake in Cooperstown, New York. The North Branch flows somewhat south in a meandering fashion through Sunbury, Pennsylvania, where it joins with the shorter West Branch that begins in central-western Pennsylvania. The two branches combine to form the mainstem of the Susquehanna River, which is the largest tributary of the Chesapeake Bay. The Susquehanna River flows over 440 mi (708 km) from Ostego Lake to the Chesapeake Bay. Major tributaries of the Susquehanna River include the Juniata River, the West Branch Susquehanna River, and the Chemung River (SRBC 2006).

The Susquehanna River Basin includes portions of the Allegheny Plateau region of the Appalachian Mountains of Pennsylvania and New York, the rolling hills and farmland closer to Three Mile Island situated in the Piedmont Plateau of Pennsylvania, and the coastal plain to the Chesapeake Bay in Maryland. It drains over 27,500 square miles (mi^2) ($71,200 \text{ km}^2$) of central Pennsylvania, south-central New York, and a small portion of northeastern Maryland, and is the second-largest watershed in the eastern United States (SRBC 1999; SRBC 2006).


The Susquehanna River Basin is divided into six major subbasins: (1) the Upper Susquehanna Subbasin, (2) the Chemung Subbasin, (3) the Middle Susquehanna Subbasin, (4) the West Branch Susquehanna Subbasin, (5) the Juniata Subbasin, and (6) the Lower Susquehanna Subbasin, which is the location of TMI-1 (SRBC 2006). The Lower Susquehanna Subbasin is located primarily south and downstream of the other five subbasins. This subbasin drains about $5,900 \text{ mi}^2$ ($15,300 \text{ km}^2$) of urban and rural areas, ridges, and open valleys and empties into the Chesapeake Bay at Havre de Grace, Maryland. The ridges of this subbasin are primarily forested, and the valleys are predominantly used for agriculture. Other portions of this subbasin contain developed areas, with only limited abandoned mine lands. The cities of Harrisburg, Lancaster, and York are the largest populated areas in the Lower Susquehanna Subbasin (SRBC 2006a).

Susquehanna River flow is monitored by the United States Geological Survey (USGS) from a station located near Harrisburg. The river supplies about 19 million gpm (42,000 cfs, or $1200 \text{ m}^3/\text{s}$) of freshwater to the Chesapeake Bay, which is about half of the Chesapeake Bay's flow of freshwater (SRBC 2006). Figure 2-7 on the following page shows that in 2004, a year with above-average flows, the daily mean flow of the Susquehanna River through Harrisburg was 56,400 cfs (25 million gpm or $1600 \text{ m}^3/\text{s}$), compared to the historic annual mean flow of 34,500 cfs (15 million gpm or $1000 \text{ m}^3/\text{s}$). Daily mean flow in 2004 ranged from 9600 cfs (4 million gpm or $300 \text{ m}^3/\text{s}$) to 500,000 cfs (224 million gpm or $14,000 \text{ m}^3/\text{s}$). The lowest average annual mean flow recorded at the Harrisburg gauging station is about 16,900 cfs (8 million gpm or $500 \text{ m}^3/\text{s}$), with the lowest daily mean recorded as 1700 cfs (1 million gpm or $50 \text{ m}^3/\text{s}$) (Durlin and Schaffstall 2005).

The Susquehanna River is well known for the flooding damage it has caused in the past, with over 40 serious floods recorded since 1736 (Alliance for the Chesapeake Bay undated). To protect the site and possible contamination of the river during a serious flood event, the developed area of TMI-1 is bordered by a flood protection dike system (AmerGen 2008).

Affected Environment

Figure 2-7. Monthly Mean Flow of the Susquehanna River in 2004 and the Maximum, Mean, and Minimum Monthly Mean Flow Date for 1891–2004



Source: Durlin and Schaffstall 2005

Three Mile Island is located within a reservoir portion of the river adjacent to two dams, the run-of-the-river York Haven Dam and the smaller Red Hill Dam, as illustrated in Figure 2-6. The reservoir formed behind the two dams that includes part of Three Mile Island is known as York Haven Pond and Lake Frederick (AmerGen 2008). At normal levels Lake Frederick has a surface area of 2.3 mi² (596 ha) and extends 3.5 mi (5.6 km) upstream. The normal full pool elevation of Lake Frederick is 277 ft (84 m) above mean sea level, and the mean depth is 9 ft (2.7 m) (Ichthyological Associates 1983). Both dams are owned and operated by York Haven Power Company. The York Haven Dam runs diagonally downstream and southwest from the southern end of Three Mile Island and is over 9,200 ft (2,800 m) long. The dam connects Three Mile Island to the mainland on the western side of the river, and is the site of a 19–20 MWe hydroelectric plant, which controls river flow at Three Mile Island (AmerGen 2008). The dam is located at the Conewago Falls, where the river drops 19 ft (6 m) (Kapsch 2004). The 900-foot-long (290-m-long) Red Hill Dam is located at the midway point of Three Mile Island along the eastern side of the island and regulates the flow of the Susquehanna River in the eastern channel. Between the dam and Three Mile Island is a fish ladder where fish passage can be monitored (AmerGen 2008).

The larger water bodies that flow into the Susquehanna River near Three Mile Island include the Swatara Creek, East Conewago Creek, West Conewago Creek, and Fishing Creek. East Conewago Creek discharges into the Susquehanna River from the eastern shoreline adjacent to the southern access bridge to Three Mile Island (PADEP 2008).

The Susquehanna River Basin Commission (SRBC) performs bioassessments of the Susquehanna River, the six subbasins, and a number of streams within each subbasin to monitor water quality and the biological health of the river basin. As part of the Susquehanna Large River Assessment Project, the SRBC collected biological and water chemistry data at 25 stations in 2005 on the mainstem Susquehanna River and at the mouths of three tributaries. Nineteen of the stations were designated slightly impaired and six other stations were designated moderately impaired. However, less than 10 percent of the samples analyzed from the 25 stations exceeded levels of tolerance for aquatic life, indicating that the Susquehanna River maintains fairly good water quality. Five of the 25 stations were located in the Lower Susquehanna Subbasin. Thirty-one of the 44 samples obtained at these five stations in the Lower Susquehanna Subbasin were designated slightly impaired, and 12 of the samples were

designated moderately impaired. Only one of the samples was rated non-impaired (SRBC 2006).

In a comparison of surveys conducted in the Lower Susquehanna Subbasin in 1996 and 2005, biological conditions improved slightly, while some parameters for water quality improved and others degraded. The SRBC has attributed high levels of nutrients, sediments, and toxins in some samples to the prevalence of agricultural lands in the Lower Susquehanna Subbasin, along with areas of residential, commercial, and industrial development, and to some areas in the subbasin containing abandoned mine lands. Data collected in 2005 during the Lower Susquehanna Subbasin Survey, near the confluence of the Swatara Creek with the Susquehanna River and 2 miles upstream of Three Mile Island, rated the habitat as partially supporting, with elevated nutrient levels, elevated sodium, and nonimpaired biological conditions. Further upstream on Swatara Creek, acid mine drainage and development affected the watershed (SRBC 2006a).

2.2.5 Description of Aquatic Resources

Macroinvertebrates

Sampling was performed for macroinvertebrates above and below the TMI-1 discharge pipes from 1974–1982 (Ichthyological Associates 1975; 1976; 1983) and from 1986–1990 (Normandeau 2007; RMC 1991), with the most taxa (165) collected in 1982. Dominant taxa were aquatic tube worms (*Limnodrilus hoffmeisteri*), the larvae of Diptera–midges (*Chironomus decorus*), and mollusks (*Pisidium* spp.). Virginia river snail (*Elimia virginica*) and *L. hoffmeisteri* had the greatest biomass. Distributions varied seasonally, as did relative abundance, density, and biomass, particularly after the 1980 drought in this region (Ichthyological Associates 1983). Biological data collected in 1996 by the SRBC at Conewago Falls, immediately downstream of Three Mile Island, indicated that Ephemeroptera (mayflies) and Trichoptera (caddisflies) were two of the four dominant taxa in the samples. These families are typically found in water bodies of better water quality. Coleoptera (beetle larvae) were also dominant in the sample, with Amphipoda (shrimp-like crustaceans) the most dominant of the four taxa, indicating less than ideal water quality (SRBC 1996).

Macroinvertebrate samples collected by the SRBC 12 mi (19 km) downstream of Three Mile Island (river mile 45) and 20 mi (32 km) upstream of Three Mile Island (river mile 77) during the 1996 Lower Susquehanna River Subbasin Survey contained *Corbicula fluminea*—invasive Asiatic clams. Macroinvertebrate samples collected on the Susquehanna River at the Conewago Falls boat launch (river mile 57) contained *Corbicula* as well as the native pea clam (*Pisidium* spp.) (SRBC 1996), characterized by its extremely small size (0.5 in.) (Pennsylvania Sea Grant 2008a). Several species of snails (Gastropoda) were also identified from the boat launch samples, including *Ferrissia* spp., *Lymnaea* spp., *Physa* spp., and *Viviparus* spp. (SRBC 1996). No *Corbicula* or pea clams were collected at the sampling stations located at river mile 45 and river mile 77 during the 2005 Lower Susquehanna Subbasin Survey, and the only snails that were collected were *Leptoxis* spp. and *Pleurocera* spp. (SRBC 2005).

The nonnative mollusk Asiatic clam (*C. fluminea*) is present in the Susquehanna River and has been observed attached to the intake structures at TMI-1. *Corbicula* is a small bivalve originally from eastern Asia and Africa that has spread into many estuarine habitats and river beds of the

Affected Environment

United States. The adults typically do not grow over 1.5 in. in size. *Corbicula* tolerates polluted environments better than native mussels, which allows it to colonize areas that would most likely not be inhabited by native mussels. *Corbicula* is inadvertently spread by boats transported from one waterway to another, and can cause biofouling of intake structures and irrigation systems (Pennsylvania Sea Grant 2008). At TMI-1, a biocide is applied to the intake water as it reaches the screens to prevent any infestations by *Corbicula* (AmerGen 2008).

In the fall of 2008, another common, nonnative invasive mollusk, the zebra mussel (*Dreissena polymorpha*), was discovered in the southern portion of the Susquehanna River at the Conowingo Dam in Maryland (PADEP 2008b). The zebra mussel, originally from Europe, has spread through many states east of the Mississippi River. Zebra mussels were first discovered in a Pennsylvania waterway of the Susquehanna watershed in May of 2007, in Cowanesque Lake, which is near the New York State line (Alliance for the Chesapeake Bay 2007; Pennsylvania Sea Grant 2008b). In June 2007, zebra mussels were identified in the Susquehanna River mainstem in Oneonta, New York (Harman and Underwood 2008). And while conducting the Upper Susquehanna Subbasin Survey in 2007, SRBC discovered zebra mussels in the Susquehanna River at Great Bend, Pennsylvania, which was the furthest point downstream in the Susquehanna River mainstem that zebra mussels had been identified, until the recent siting at the Conowingo Dam by PADEP and Pennsylvania Fish and Boat Commission (PFBC) officials (SRBC 2008; Pennsylvania Sea Grant 2008b).

Plankton

Phytoplankton and zooplankton were studied in 1974 and 1975 at the intake and discharge structures at TMI-1. A total of 95 genera of phytoplankton were identified in 1975, with the division Chlorophyta (green algae) the most common, followed by the division Bacillariophyta (diatoms). Also identified were genera from the division Cyanophyta (blue-green algae), Pyrophyta (dinoflagellates), Euglenophyta (euglenoids), and Chrysophyta (yellow-green algae). A total of 85 taxa of zooplankton were identified in 1974 and 1975 at the TMI-1 intake and discharge structures. Cladocerans, rotifers, and copepods were the most abundant, and comprised 98.9 percent of the number of zooplankton that were identified (Ichthyological Associates 1975; 1976).

Fish

Several fish studies have been conducted by the facility in the vicinity of Three Mile Island from 1974–1982 using various sampling methods (trapnet, seine, and electrofishing), with a total of 58 different species captured. Flathead catfish (*Pylodictis olivaris*), channel catfish (*Ictalurus punctatus*), pumpkinseed (*Lepomis gibbosus*), smallmouth bass (*Micropterus dolomieu*), black crappie (*Pomoxis nigromaculatus*), and white crappie (*Pomoxis annularis*) dominated the catches, and the common carp (*Cyprinus carpio*) contained the greatest biomass in the catch (Ichthyological Associates 1983). A 1990 study that sampled fish in Lake Frederick found the most common fish collected, in descending order, were the mimic shiner (*Notropis volucellus*), the spotfin shiner (*Cyprinella spiloptera*), channel catfish, smallmouth bass, the tessellated darter (*Etheostoma olmstedii*), the spottail shiner (*Notropis hudsonius*), pumpkinseed, the white sucker (*Catostomus commersonii*), the bluntnose minnow (*Pimephales notatus*), and the common carp (RMC 1991). Fish sampling conducted from 2002–2005 in the vicinity of the Brunner Island steam electric station, located about 4 mi downstream from Three Mile Island,

has demonstrated species composition similar to the fish sampled in the vicinity of York Haven Dam. Creel surveys in the vicinity of Lake Frederick from 2007 when compared to the 1974–1982 study indicated that similar taxa of sportfish dominated the catch as well as walleye (*Sander vitreus*) and muskellunge (*Esox masquinongy*) (Normandeau 2007).

The American shad (*Alosa sapidissima*) is an anadromous fish that historically numbered in the millions along the entire Susquehanna River, but have substantially dropped in the last 100 years. Before 1904, millions of American shad migrated up the Susquehanna River for spawning, and over 2.5 million lb (1.1 million kg) of shad were commercially harvested during the peak of this fishery in 1885 (PFBC undated). Between 1904 and 1930, four hydroelectric dams were constructed along the lower Susquehanna River between Three Mile Island and close to the mouth of the Susquehanna River in Maryland, resulting in a loss of river access for shad above each dam: York Haven Dam (1904); Holtwood Dam (1910), Conowingo Dam (1928); and Safe Harbor Dam (1930). Safe Harbor is approximately 26 mi (42 km) south of Three Mile Island, Holtwood is approximately 33 mi (53 km) south, and Conowingo is approximately 48 mi (77 km) south. Construction of the Conowingo Dam in Maryland near the mouth of the Chesapeake Bay resulted in the complete loss of accessibility to spawning habitat for American shad and other anadromous fishes on the Susquehanna River. It also led to the closure of the shad industry, since fish could no longer pass through this first dam on the Susquehanna River (The Native Fish Conservancy 2008).

A combination of fish passage restoration projects performed at the Red Hill Dam, Safe Harbor Dam, Holtwood Dam, and Conowingo Dam over the past several decades has returned migratory access to American shad and other migratory fishes of the Susquehanna River. The construction of fish lifts, fish ladders, low-flow fish passages, and the completion of a fish passage facility at the Red Hill dam in 2000 has potentially opened the Susquehanna River to American shad and other anadromous fishes as far upriver as Binghamton, NY. Fish passage facilities are also being constructed on the tributaries of the Susquehanna River and on smaller streams where impasses may exist. Millions of shad larvae, fry, and fingerlings are stocked annually within the Chesapeake Bay watershed, including the Susquehanna River and its tributaries, with over 455 million American shad stocked in the Chesapeake Bay watershed since 1986 (CBP 2008). Cooperative stocking efforts between New York, Pennsylvania, and Maryland are attempting to rebuild the population of American shad (Sadzinski and Jarzynski undated).

Since the opening of the fishway in 2000 at the Red Hill Dam, York Haven Power Company has monitored this fishway for passage of American shad, gizzard shad (*Dorosoma cepedianum*), walleye, smallmouth bass, and other species. The numbers of American shad, gizzard shad, walleye, and smallmouth bass passing the Red Hill Dam fishway have fluctuated since 2000 (York Haven Power Company 2008). American shad passage at all four dams has continued to decline since 2006, as shown in Table 2-5 on the following page (PFBC 2008a). A number of factors can be causing the decrease in American shad numbers in the Susquehanna River, such as coast-wide declines in shad populations, low hatchery outputs, low wild juvenile survival, and fish passage effectiveness (PFBC 2008d). While predation on newly stocked American shad larvae may reduce the number that survive to adulthood (Johnson and Dropkin 1992), mortality at Susquehanna River stocking sites was less than 2 percent (PFBC 2008e).

Affected Environment

Table 2-5. American Shad Passage at the Conowingo, Holtwood, Safe Harbor, and Red Hill Dams on the Susquehanna River

Year	Conowingo ^(a)	Holtwood ^(b)	Safe Harbor ^(b)	Red Hill
2008	19,914	2,795	1,252	21
2007	25,464	10,338	7,215	192
2006	56,899	35,968	24,929	1,913
2005	68,853	34,189	24,425	1,772
2004	109,360	3,482	2,109	219
2003	125,135	25,254	16,646	2,536
2002	108,001	17,522	11,705	1,555
2001	193,574	109,976	89,816	16,200
2000	153,546	29,421	21,079	4,675
1999	69,712	34,702	34,150	--
1998	39,904	8,235	6,054	--
1997	90,971	28,063	20,828	--

(a) The Conowingo Dam fish lift was built in 1991, but did not pass fish until 1997.

(b) The Holtwood Dam and Safe Harbor Dam fish lifts came online in 1997.

Source: PFBC 2008a

Other fish besides American and gizzard shad, walleye, and smallmouth bass use the Red Hill fish ladder. While monitoring for American shad passage during a three-week period in 2008, data collected by the York Haven Power Company indicated that the gizzard shad was the species that most frequently passed up the ladder (15,930), followed by channel catfish (3,286), quillback (*Carpionodes cyprinus*) (2,045), walleye (905), carp (332), shorthead redhorse (*Moxostoma macrolepidotum*), and smallmouth bass (150). Several other species were also observed in lower numbers passing up the fish ladder (York Haven Power Company 2008).

The smallmouth bass is popular with recreational anglers on the Susquehanna River, but recent events have caused a concern with fisheries managers regarding the health of smallmouth bass and other fishes in the Susquehanna River. In the summers of 2005 and 2007, die-offs of mostly young smallmouth bass occurred in the Susquehanna River, Juniata River, and the West Branch Susquehanna River (PFBC 2008c). Mortality has been attributed to a bacterial infection caused by *Flavobacterium columnaris*, which results in large, visible lesions on infected fish. Greater than 50 percent of the young-of-the-year sampled in 2005 and 2007 in a study conducted by the PFBC had visible external lesions. Scientists from the USGS suspect that stress from low rainfall and correspondingly low flows and low dissolved oxygen levels with high temperatures played a key role in making these fish susceptible to colonization by *F. columnaris* (USGS 2008). Research was conducted in 2008 by the USGS and PFBC to determine the cause of these outbreaks (USGS 2008).

The Susquehanna River in the vicinity of Three Mile Island is used for recreational fishing for a variety of species, such as the smallmouth bass, flathead catfish, channel catfish, and walleye (McNally 2008; PFBC 2008). To enhance recreational fishing, the PFBC annually stocks several species of fish in the Susquehanna River, typically above Lake Frederick. From 1991–2008, species stocked by the PFBC within the Lower Susquehanna Subbasin included muskellunge and tiger muskellunge (*E. lucius* x *E. masquinongy*), walleye, striped bass (*Morone saxatilis*), Hickory shad (*Alosa mediocris*), and American shad. The stocking of striped bass in the Susquehanna River was discontinued in 2006 (PFBC 2008f).

The cold-water tributaries of the Susquehanna River are home to several species of trout. A number of streams in the vicinity of Three Mile Island and Harrisburg are stocked with trout for recreational fishing and to enhance the naturally reproducing populations. Several streams near Three Mile Island—such as the headwaters of a tributary of Swatara Creek, located less than 2 mi upriver of Three Mile Island—also contain naturally reproducing trout populations. The Yellow Breeches, located along the west shoreline of the Susquehanna River and opposite Three Mile Island, also contains a naturally reproducing population of trout, (PFBC 2008b). No essential fish habitat has been designated for any species along the Susquehanna River upstream of Conowingo Dam (NOAA undated).

The EPA has outlined a nationwide program for the analysis of fish to establish fish consumption advisories. This program includes a listing of parameters for tissue analysis including PCBs, pesticides, and heavy metals. To comply with this program, Pennsylvania has conducted fish tissue contaminant monitoring throughout the Commonwealth since 1976. Public health advisories, based on fish tissue contaminant levels, are published annually in the PFBC annual summary of fishing regulations and laws. Since 2002, Pennsylvania has issued a general Statewide advisory recommending that people consume no more than one meal per week of recreationally caught sport fish. The Commonwealth issues more restrictive advisories for specific water bodies.

For the reach of the Susquehanna River within the vicinity of the TMI-1 facility and the nearest major water bodies—including Swatara Creek, East Conewago Creek, West Conewago Creek, and Fishing Creek—Pennsylvania issued a health advisory to limit the consumption of smallmouth bass to no more than two meals per month due to mercury contamination (PFBC 2008g).

2.2.6 Terrestrial Resources

The TMI-1 site and its associated transmission lines are located within the Lower Susquehanna River Subbasin and span Lancaster, York, and Dauphin Counties. Before construction, the entire TMI-1 site was within the 10-year floodplain; however, today, only the southern, undisturbed portion of the island remains in the 10-year floodplain. Three Mile Island is approximately 370 ac (150 ha) and includes both the TMI-1 and TMI Unit 2 facilities. The buildings associated with plant generation and maintenance, parking lots, and onsite roads occupy 200 ac (81 ha) of the overall island area (AmerGen 2008). The remaining 170 ac (69 ha) are covered by fields, forested land, and wetlands with several intermittent ponds. Natural areas

Affected Environment






Figure 2-8. Three Mile Island Nuclear Station, Unit 1, Site Area Overview Map and Transmission Lines (Source: AmerGen 2008)

within the TMI-1 site and associated transmission line ROWs include upland; riparian; river floodplain forest communities; open fields; grasslands; and ponds, streams, and wetlands, whose primary water source is the Susquehanna River. Figure 2-8 is a map of Three Mile Island, the TMI-1 site, its associated transmission lines, and the surrounding area.

Preconstruction habitat at the TMI-1 site consisted of open field habitats with upland and riparian forests as well as wetlands, while the transmission line ROWs consisted mostly of forested and agricultural land. As a result of constructing the TMI-1 and TMI Unit 2 facilities on Three Mile Island, slightly more than half of the island became disturbed land. Continual maintenance of the transmission lines retains previously forested ROW land in an early successional state.

Upland areas at the TMI-1 site primarily support Virginia pine (*Pinus virginiana*), sweet birch (*Betula lenta*), flowering dogwood (*Cornus florida*), white oak (*Quercus alba*), northern red oak (*Quercus rubra*), black oak (*Quercus velutina*), and tuliptree (*Liriodendron tulipifera*). Common nonwoody species include fan-shaped clubmoss (*Lycopodium flabelliforme*), intermediate woodfern (*Dryopteris intermedia*), ground ivy (*Glechoma hederacea*), white avens (*Geum canadense*), common cinquefoil (*Potentilla simplex*), common blue violet (*Viola papilionacea*), and Swan's sedge (*Carex swanii*) (WHC 2005).

Forested riparian areas at the TMI-1 site support a mix of maples (*Acer* spp.), alders (*Alnus* spp.), birches (*Betula* spp.), and sycamores (*Platanus occidentalis*) (AmerGen 2008). Common tree species found in the river floodplain forests in and around the TMI-1 site are silver maple (*A. saccharinum*), river birch (*B. nigra*), and northern red oak (*Quercus rubra*). Nonwoody species found in river floodplain forests include ostrich fern (*Matteuccia struthiopteris*), mayapple (*Podophyllum peltatum*), dame's rocket (*Hesperis matronalis*), false mermaid (*Floerkea proserpinacoides*), Dutchman's breeches (*Dicentra cucullaria*), jumpseed (*Polygonum virginianum*), common blue violet (*Viola papilionacea*), and dogtooth violet (*Erythronium americanum*) (WHC 2005).

Open fields and grassland make up the predominant habitat on the southern end of Three Mile Island. Foxtail grasses (*Alopecurus* spp.) are the dominant genus; other grasses and sedges common to the TMI-1 site include Allegheny blackberry (*Rubus allegheniensis*), northern dewberry (*Rubus flagellaris*), white heath aster (*Symphotrichum ericoides*), white panicle aster (*Symphotrichum lanceolatum*), wrinkleleaf goldenrod (*Solidago rugosa*), common sheep sorrel (*Rumex acetosella*), common cinquefoil (*Potentilla simplex*), yellowfruit sedge (*Carex annectens*), creeping bentgrass (*Agrostis stolonifera*), little bluestem (*Andropogon scoparius*), poverty oatgrass (*Danthonia spicata*), and common timothy (*Phleum pratense*) (WHC 2005). Sycamores, sweetgum (*Liquidambar styraciflua*), basswood (*Tilia* spp.), and locust trees are found near the edges of the grasslands (AmerGen 2008).

The U.S. Fish and Wildlife Service (FWS) National Wetlands Inventory database indicates that wetlands, some of which are classified as significant habits, exist on the southern end of the TMI-1 site, as well as in the vicinity of the site along the Susquehanna River shoreline (FWS 2008). Figure 2-4 shows the location of the wetlands in proximity to the TMI-1 site. The onsite wetlands were formed when borrow pits were created during the construction of a dike system that surrounds the entire island (AmerGen 2008). The former borrow pits now have standing water approximately seven months of the year (AmerGen 2008). Dragonflies, amphibians, frogs,

Affected Environment

and salamanders are all common species in the wetland ecosystems on the TMI-1 site (WHC 2005).

Invasive plant species common to Pennsylvania floodplain forests include tree-of-heaven (*Ailanthus altissima*), Oriental bittersweet (*Celastrus orbiculatus*), and garlic mustard (*Alliaria officinalis*), which encroach upon woodland areas, while purple loosestrife (*Lythrum salicaria*), wild hops (*Humulus japonicus*), and Japanese knotweed (*Polygonum cuspidatum*) are known to colonize areas along the Susquehanna River (TNC 2005). Exelon Generation is not required to keep records of known invasive species and does not have programs or procedures in place to control terrestrial plant or animal invasive populations on the TMI-1 site.

A variety of wildlife exists on and in the vicinity of the TMI-1 site. Mammals common to the TMI-1 site include white-tailed deer (*Odocoileus virginianus*); raccoon (*Procyon lotor*); gray squirrel (*Sciurus carolinensis*); red fox (*Vulpes vulpes*); striped skunk (*Mephitis mephitis*); small insectivores, such as moles, shrews, and bats; and rodents, such as mice and voles (AmerGen 2008). Reptiles and amphibians common to the TMI-1 site include snakes, turtles, lizards, salamanders, and toads.

The TMI-1 site provides habitat to a variety of songbirds, upland game birds, waterfowl, and raptors. Exelon Generation maintains onsite nests for osprey (*Pandion haliaetus*), peregrine falcon (*Falco peregrinus*), and mallard duck (*Anas platyrhynchos*), as well as boxes for wood duck (*Aix sponsa*) (AmerGen 2008). In March 2008, Exelon Generation installed new wood duck houses on the southern end of the island in cooperation with the Susquehanna River Waterfowl Association (York Daily Record 2009).

Exelon Generation has several procedures for protecting the environment, including vegetation and wildlife, from impacts that could result from activities at TMI-1. The procedures require TMI-1 activity planners to complete an environmental review checklist to determine if a proposed activity requires further evaluation for environmental impacts and risk. If the environmental review checklist reveals that a planned activity could disturb vegetation or wildlife habitat, then an environmental evaluation must also be completed, and a qualified subject matter expert must evaluate the potential for adverse impacts on endangered or threatened wildlife and plant species or critical habitat. If the evaluation concludes that the proposed activity would result in an environmental impact, then the activity may not proceed until the impact has been resolved through avoidance, mitigation, or a compliance plan, when allowed by regulation.

2.2.7 Threatened and Endangered Species

Table 2-6, beginning on page 2-42 lists threatened, endangered, or candidate species known to occur in Dauphin County, in which TMI-1 is located, or York and Lancaster counties, through which transmission line ROWs associated with TMI-1 traverse.

2.2.7.1 Aquatic Species

One Federally listed and State-listed endangered species, the dwarf wedgemussel (*Alasmidonta heterodon*), was recorded in Lancaster County, but not in the vicinity of TMI-1 or in the waterways along the transmission line corridors. The black bullhead (*Amerius melas*), a State-listed species, has been recorded in Dauphin County (PNHP 2008), but is not known to

occur in the vicinity of TMI-1 or in the waterways along the transmission line corridors (AmerGen 2008).

The FWS indicated by letter dated April 23, 2008, that no Federally listed or proposed threatened or endangered species are known to occur within the project impact area, so no biological assessment or further consultation under the Endangered Species Act is required with the FWS (FWS 2008). PFBC indicated by letter dated June 3, 2008, that no adverse impacts to State-listed rare, candidate, threatened, or endangered aquatic species are expected from the proposed project (PFBC 2008h).

2.2.7.2 Terrestrial Species

Two Federally listed threatened or endangered terrestrial species, the bog turtle (*Glyptemys muhlenbergii*) and the northeastern bulrush (*Scirpus ancistrochaetus*), are potentially found in the vicinity of the TMI-1 site (FWS 2008). The bald eagle (*Haliaeetus leucocephalus*) and the peregrine falcon were formerly listed as Federally threatened and may also be found in the vicinity of the TMI-1 site. Eleven State-listed species were identified as species for consideration of the proposed license renewal of TMI-1, including the (1) osprey, (2) prothonotary warbler (*Protonotaria citrea*), (3) yellow-crowned night heron (*Nycticorax violacea*), (4) black-crowned night heron (*Nycticorax nycticorax*), (5) aster-like boltonia (*Boltonia* □ *steroids*), (6) Short's sedge (*Carex shortiana*), (7) flat-stemmed spike-rush (*Eleocharis compressa*), (8) ellisia (*Ellisia nyctelea*), (9) bronze copper (*Lycaena hyllus*), and the formerly Federally listed (10) bald eagle, and (11) peregrine falcon (DCNR 2008a; PGC 2008; AmerGen 2008; PNHP 2008). The American Holly (*Ilex opaca*), State-listed as endangered, has been documented as occurring on the TMI-1 site; however, neither the Pennsylvania Department of Conservation and Natural Resources (DCNR) nor the Pennsylvania Game Commission (PGC) has identified the species for consideration of the proposed license renewal of TMI-1 (AmerGen 2008; DCNR 2008a; PGC 2008; PNHP 2008).

Federally Protected and Formerly Protected Terrestrial Species

The northeastern bulrush and the bog turtle have ranges that include the TMI-1 project area, but neither species is known to occur on the TMI-1 site or along its associated transmission line ROWs (AmerGen 2008). Additionally, neither species was identified in the April 23, 2008, letter from FWS as species requiring consideration for this proposed action (FWS 2008).

On July 9, 2007, the FWS issued a *Federal Register* notice announcing the delisting of the bald eagle from the Federal List of Endangered and Threatened Wildlife (72 FR 37346). Eagles continue to be protected at the national level by the Bald and Golden Eagle Protection Act, as well as the Migratory Bird Treaty Act, and at the State level as a Pennsylvania-listed threatened species. The bald eagle is a large bird, even among raptor species, and can reach a weight of more than 13 lb (6 kg). The eagle has a white head and tail, with brown body feathers. Bald eagles eat fish, small mammals, birds, and occasionally carrion. Bald eagles are known to occur in Dauphin, Lancaster, and York Counties, and are seen regularly along the Susquehanna River. The eagle is occasionally seen on Three Mile Island; however, the closest known nest is 20 mi (32 km) south of TMI-1, near the Holtwood Dam (AmerGen 2008).

The peregrine falcon was removed from Federal listing in August 1999, but continues to be listed as endangered at the State level. Adult birds have a bluish-black head and wings, are 14–19-in. (36–48 cm) tall, and have a 39–43-in (99–109 cm) wingspan (Cornell 2003). Peregrine

Affected Environment

falcons nest on high cliffs near river systems and on bridges and tall buildings (PGC 2006). The species was not observed nesting in Pennsylvania from 1959 to 1987, coinciding with the population depletion between 1950 and 1970 caused by the species' sensitivity to DDT (Cornell 2003). Reintroduction efforts in Pennsylvania and neighboring states have facilitated the growth of the population since the early 1990s (PGC 2006). A breeding pair has nested on the TMI-1 reactor building every year since 2002 (AmerGen 2008). In an effort to protect the nesting pair and their young, Exelon Generation regularly communicates with FWS, DCNR, and PADEP (AmerGen 2008).

State Protected Terrestrial Species

The Pennsylvania State-listed threatened osprey occurs on the Susquehanna River shoreline throughout the project area, and osprey nests are known to occur on the TMI-1 site (AmerGen 2008). The osprey is a fairly large bird of prey with a body length of about 21–24 in. (53–61 cm) and a wingspan of 4.5–5.5 ft (1.4–1.7 m). Osprey feed exclusively on live fish (FWS 2008a). Individuals are brown with a white belly and have distinctive patches on their wings. The osprey has long, sharp talons, which are used for gripping fish. Females are larger than males, which is true for most birds of prey. The osprey's habitat includes rivers, lakes, and shallow water estuaries. Nesting often occurs on artificial structures such as flat-topped wooden platforms, meteorological towers, channel markers, and radio towers, where such structures are near shallow waters that support plentiful fish. Osprey pairs tend to be solitary nesters, and may colonize secure areas such as islands (USGS undated). Since 2004, ospreys have nested on the TMI-1 meteorological tower, located on the north end of Three Mile Island (AmerGen 2008). Exelon Generation built a 55-ft (17-m) nesting platform in an attempt to relocate the nesting pair to a location more secluded from human activity, but relocation efforts have been unsuccessful (AmerGen 2008). Although it is unknown why relocation efforts were unsuccessful, ospreys are known to pair for life and typically use the same nest site for many years (USGS undated). The ospreys at TMI-1 continue to successfully nest on the meteorological tower.

The Pennsylvania State-listed endangered aster-like boltonia, also a Pennsylvania species of special concern, grows on rocky shores and exposed, rocky river beds (DCNR 2008a). The boltonia is a tall, slender plant with stalks commonly growing to heights of 4–6 ft (1.2–1.8 m). The plant has white flowers with a yellow center, which appear between July and October (Fike 2008). The closest location of the boltonia to the TMI-1 site is the riverside outcrop community (Fike 1999).

Short's sedge, a species of special concern in Pennsylvania, occurs near wetlands along the Susquehanna River (PNHP 2008). Short's sedge is a grass-like plant, ranging in height from 8–35 in. (20–89 cm) (PNHP 2008b). The stems are light green, three-sided, and have no hairs (PNHP 2008b). Flowers, which grow on the top of each stem, are densely packed, brown cylindrical spikes and look like very small pinecones (PNHP 2008b). Short's sedge is known to occur near TMI-1 and its associated transmission line ROWs (PNHP 2008b; DCNR 2008a).

The flat-stemmed spike-rush, a grass-like plant in the sedge family, is listed as endangered in the Commonwealth of Pennsylvania (DCNR 2008a). DCNR also identifies the plant as a species of special concern (DCNR 2008a). The medium-to-dark green species grows 0.5–1.5 ft (15–46 cm) in height and has a uniform diameter of 0.04 in. (1 mm) (Hilty 2006b). Generally

one long, oval-shaped flower can be found per stalk. Flowers range in color from light-to-medium brown with small white spikes (Hilty 2006b).

The Pennsylvania-threatened ellisia is also a species of special concern for TMI-1 and the associated transmission line ROWs (DCNR 2008a). The 4–16-in. (10–41 cm) wildflower has pale green to pale purple stems and dark green, hairy leaves (Hilty 2006a). Individual flowers appear in May, span 0.25 in. (6.4 mm) in diameter, and have five small white petals surrounding a pale blue center (DCNR 2008a; Hilty 2006a). Ellisia is known to occur in the area of TMI-1 and its associated transmission line ROWs, and is generally found in damp, shady areas near stream banks with rich soils (DCNR 2008a; PNHP 2008a).

The bronze copper, a Pennsylvania species of special concern, is a butterfly that lives in wet meadows and marshes (DCNR 2008a). The DCNR does not currently rank the species as endangered, threatened, or rare because of a lack of or conflicting information about population trends (DCNR 2008a). The male is brown and the female is yellow-orange with black spots. In both sexes, the underside is orange with black spots. The bronze copper likes to perch on low, nontree plants ranging less than 3–4 ft (1–1.2 m) in size. When in its caterpillar phase, the species eats green leaves from plants.

The prothonotary warbler, a Pennsylvania species of special concern, is known to nest and forage in proximity to the TMI-1 site, according to PGC (PGC 2008); however, the species is not identified by the FWS or DCNR as rare, threatened, or endangered for the TMI-1 site. The warbler is a very colorful bird, with a bright yellow-golden head and underside, olive body, blue-gray wings and tail, and white underwings. Prothonotary warblers live and breed in wooded swamps, bottomland, flooded forests, and alongside slow-moving rivers. The warbler feeds primarily on caterpillars, insects, fruit, and seeds (Audubon 2008). Exelon Generation has no monitoring programs for the prothonotary warbler.

The Pennsylvania-endangered yellow-crowned night heron lives in proximity to the TMI-1 site (PGC 2008). Adult herons are approximately 2 ft (61 cm) tall with a long, slender appearance, have a 3–4-ft (1.0–1.2 m) wingspan, and are blue to gray in color. The species feeds mostly on fish. Exelon Generation has no monitoring programs in place for the yellow-crowned night herons, therefore their population numbers within the vicinity of TMI-1 are unknown.

The black-crowned night heron, listed in Pennsylvania as endangered, is a medium-sized heron with a stocky body and short legs and neck (PNHP 2008). The heron has a black crown; a black and white face, chest, and belly; and blue-gray wings. It feeds primarily on aquatic invertebrates, fish, and frogs. The PGC identifies the species as one of special concern because it nests near the TMI-1 site (PGC 2008). Exelon Generation has no monitoring programs in place for the black-crowned night heron; therefore, their population within the vicinity of TMI-1 is unknown.

Affected Environment

Table 2-6. Listed Aquatic and Terrestrial Species. *The species listed are Federally-listed, Pennsylvania-listed, or both that are threatened, endangered, or candidate species. These species may occur on the TMI-1 site, within the Susquehanna River, or within the transmission line corridors.*

Scientific Name	Common Name	Federal Status ^(a)	State Status ^(b)	Habitat
Fish				
<i>Ameiurus melas</i>	black bullhead		PE	Quiet backwaters
Reptiles and Amphibians				
<i>Glyptemys muhlenbergii</i>	bog turtle	T	PE	Wetlands, bogs, fens, meadows, and wet grassy areas
<i>Opheodrys aestivus</i>	rough green snake		PE	Hilly, forested, dry areas
<i>Pseudemys rubriventris</i>	redbelly turtle		PT	Aquatic species found in lakes, rivers, ponds, and marshes
Insects				
<i>Lycaena hylus</i>	bronze copper		SC	Low wet meadows and marshes, especially in river flood plains (DCNR 2008a)
Birds				
<i>Bartramia longicauda</i>	upland sandpiper		PT	Bogs, fens, grasslands, and pastures
<i>Botaurus lentiginosus</i>	American bittern		PE	Freshwater wetlands and shorelines
<i>Casmerodius albus</i>	great egret		PE	Aquatic and wetland habitats
<i>Cistothorus platensis</i>	sedge wren		PE	Wet meadows, freshwater marshes, and bogs
<i>Falco peregrinus</i>	peregrine falcon		PE	Cliffs, usually near riverine areas
<i>Haliaeetus leucocephalus</i>	bald eagle		PT	Forests near water bodies

Affected Environment

Scientific Name	Common Name	Federal Status ^(a)	State Status ^(b)	Habitat
<i>Nyctanassa violacea</i>	yellow-crowned night-heron		PE	Freshwater and saltwater marshes, wooded swamps, and shore areas
<i>Nycticorax nycticorax</i>	black-crowned night-heron		PE	Fresh and saltwater marshes, swamps, lakes, and wooded streams
<i>Pandion haliaetus</i>	osprey		PT	Close proximity to watery areas such as lakes, bogs, rivers, bay areas, and oceans
<i>Rallus elegans</i>	king rail		PE	Freshwater and brackish marshes
Mammals				
<i>Cryptotis parva</i>	least shrew		PE	Grasses, brushes, and weedy fields
<i>Neotoma magister</i>	Allegheny woodrat		PT	Rocky, forested areas
Plants				
<i>Agalinis auriculata</i>	eared false-foxglove		PE	Prairies, dry woods, and open fields
<i>Ammannia coccinea</i>	scarlet ammannia		PE	Moist, sandy shorelines
<i>Arethusa bulbosa</i>	swamp-pink		PE	Wetland areas
<i>Aristida purpurascens</i>	arrow-feathered three awned		PT	Moist areas, swamps, shores, and wetlands
<i>Arnica acaulis</i>	Leopard's-bane		PE	Wooded areas
<i>Asplenium bradleyi</i>	Bradley's spleenwort		PT	Exposed, barren areas; cliffs; and rocks
<i>Boltonia asteroides</i>	aster-like boltonia		PE,SC	Rocky shores and exposed rocky river beds (DCNR 2008a)
<i>Bouteloua curtipendula</i>	tall gramma		PT	Grasslands and barren areas
<i>Carex aquatilis</i>	water sedge		PT	Wetlands, ponds, marshes, and areas with standing water

Affected Environment

Scientific Name	Common Name	Federal Status ^(a)	State Status ^(b)	Habitat
<i>Carex bullata</i>	bull sedge		PE	Wetlands, ponds, marshes, and areas with standing water
<i>Carex diandra</i>	lesser panicled sedge		PT	Wetlands, ponds, marshes, and areas with standing water
<i>Carex polymorpha</i>	variable sedge		PE	Wetlands, ponds, marshes, and areas with standing water
<i>Carex prairea</i>	prairie sedge		PT	Wetlands, ponds, marshes, and areas with standing water
<i>Carex shortiana</i>	sedge		SC	Wet meadows, swamps, and wooded areas (DCNR 2008a)
<i>Carex sterilis</i>	sterile sedge		PT	Wetlands, ponds, marshes, and areas with standing water
<i>Carex tetanica</i>	sedge		PT	Wetlands, ponds, marshes, and areas with standing water
<i>Carex typhina</i>	cattail sedge		PE	Wetlands, ponds, marshes, and areas with standing water
<i>Chrysopsis mariana</i>	Maryland golden-aster		PT	Well-drained, open woods
<i>Cirsium horridulum</i>	horrible thistle		PE	Shores, marshes, or sandy fields
<i>Cladium mariscoides</i>	twig rush		PE	Wetlands, bogs, and freshwater shorelines
<i>Clitoria mariana</i>	butterfly-pea		PE	Dry, open areas on sandy soil
<i>Cynanchum laeve</i>	smooth swallow-wort		PE	Open areas or areas with slight ground cover
<i>Cyperus diandrus</i>	umbrella flatsedge		PE	Wetlands and wet meadows

Affected Environment

Scientific Name	Common Name	Federal Status ^(a)	State Status ^(b)	Habitat
<i>Cyperus refractus</i>	reflexed flatsedge		PE	Open dry fields, clearings, open forests, and sandy soils
<i>Cyperus retrorsus</i>	retrorse flatsedge		PE	Open dry fields, clearings, open forests, and sandy soils
<i>Cypripedium reginae</i>	showy lady's-slipper		PT	Bogs, swamps, wet meadows, and damp forests
<i>Dodecatheon radicans</i>	jeweled shooting-star		PT	Moist, shaded areas and river bluffs
<i>Eleocharis compressa</i>	flat-stemmed spike-rush		PE,SC	River banks with sandy soils and usually wet areas (DCNR 2008a)
<i>Eleocharis intermedia</i>	matted spike-rush		PT	Marshes, wetlands, and muddy areas
<i>Elephantopus carolinianus</i>	elephant's foot		PE	Dry, open woods
<i>Ellisia nyctelea</i>	ellisia		PT,SC	River banks and alluvial woods (DCNR 2008a).
<i>Epilobium strictum</i>	downy willow-herb		PE	Bogs, swamps, and wetlands
<i>Erigenia bulbosa</i>	harbinger-of-spring		PT	Wet, wooded areas
<i>Euphorbia purpurea</i>	glade spurge		PE	Cool, moist woods, swamps, and alongside streambanks
<i>Festuca paradoxa</i>	cluster fescue		PE	Wet, wooded areas and wet meadows
<i>Fimbristylis annua</i>	annual fimbry		PT	Swampy, damp grasslands, and wetlands
<i>Gaylussacia dumosa</i>	dwarf huckleberry		PE	Open areas in forest habitats
<i>Gymnopogon ambiguus</i>	broad-leaved beardgrass		PE	Glades, prairies, and open fields
<i>Helianthemum bicknellii</i>	Bicknell's hoary rockrose		PE	Woodlands, prairies, and open rocky areas

Affected Environment

Scientific Name	Common Name	Federal Status ^(a)	State Status ^(b)	Habitat
<i>Hypericum densiflorum</i>	bushy St. John's-wort		PT	Stream banks, pond and lake edges, and wet meadows
<i>Ilex opaca</i>	American holly		PT	Moist, sandy woodlands
<i>Iris cristata</i>	crested dwarf iris		PE	Wooded areas and ravines
<i>Iris prismatica</i>	slender blue iris		PE	Saltwater and freshwater marshes, shores, and wet meadows
<i>Iris verna</i>	dwarf iris		PE	Grassy areas and shaded woody areas
<i>Juncus arcticus var. littoralis</i>	baltic rush		PT	Wetland areas, wet meadows, and wet grassy areas
<i>Juncus brachycephalus</i>	small-headed rush		PT	Wetland areas, wet meadows, and wet grassy areas
<i>Juncus dichotomus</i>	forked rush		PE	Wetland areas, wet meadows, and wet grassy areas
<i>Juncus scirpoides</i>	scirpus-like rush		PE	Wetland areas, wet meadows, and wet grassy areas
<i>Linum intercursum</i>	sandplain wild flax		PE	Dry, open grasslands
<i>Linum sulcatum</i>	grooved yellow flax		PE	Glades, prairies, and open fields
<i>Lipocarpa micrantha</i>	common hemicarpa		PE	Pond and stream edges and wetlands
<i>Lobelia kalmii</i>	brook lobelia		PE	Pond and stream edges, wetlands, and wet areas
<i>Lobelia puberula</i>	downy lobelia		PE	Wet, wooded areas, and wetlands
<i>Ludwigia decurrens</i>	upright primrose-willow		PE	Swampy, damp grasslands, and wetlands
<i>Ludwigia polycarpa</i>	false loosestrife seedbox		PE	Swamps, marshes, wet meadows, and wetlands

Affected Environment

Scientific Name	Common Name	Federal Status ^(a)	State Status ^(b)	Habitat
<i>Lycopodiella appressa</i>	southern bog clubmoss		PT	Bogs, wetlands, and sandy banks
<i>Lyonia mariana</i>	stagger-bush		PE	Moist, sandy, and wooded areas
<i>Magnolia tripetala</i>	umbrella magnolia		PT	Wooded areas and forests
<i>Magnolia virginiana</i>	sweet bay magnolia		PT	Wooded areas and forests
<i>Matelea obliqua</i>	oblique milkvine		PE	Open wooded areas, rocky slopes, and wooded edges
<i>Melica nitens</i>	three-flowered melic-grass		PT	Dry, rocky woods, and open areas along edges
<i>Myriophyllum sibiricum</i>	northern water-milfoil		PE	Lakes, ponds, and streams
<i>Panicum scoparium.</i>	velvety panic-grass		PE	Prairies, glades, roadsides, and fields
<i>Passiflora lutea</i>	passion-flower		PE	Rich woods, rocky areas, and slopes
<i>Phemeranthus teretifolius</i>	round-leaved fame-flower		PT	Wooded areas
<i>Phlox ovata</i>	mountain phlox		PE	Sunny fields and open areas
<i>Phyllanthus caroliniensis</i>	Carolina leaf-flower		PE	Open fields
<i>Poa paludigena</i>	bog bluegrass		PT	Wet woods, bogs, and sedge meadows
<i>Polygala cruciata</i>	cross-leaved milkwort		PE	Wet, sandy meadows and marshes
<i>Polygala incarnata</i>	pink milkwort		PE	Open fields and semi-open forests
<i>Polygonum setaceum</i> <i>var. interjectum</i>	swamp smartweed		PE	Sandy wetlands and moist fields
<i>Potamogeton hillii</i>	Hill's pondweed		PE	Ponds, lakes, streams, and mostly submerged areas
<i>Potamogeton obtusifolius</i>	blunt-leaved pondweed		PE	Ponds, lakes, streams, and mostly submerged areas

Affected Environment

Scientific Name	Common Name	Federal Status ^(a)	State Status ^(b)	Habitat
<i>Potamogeton richardsonii</i>	red-head pondweed		PT	Ponds, lakes, streams, and mostly submerged areas
<i>Pycnanthemum torrei</i>	Torrey's mountain-mint		PE	Fields and open woods
<i>Quercus shumardii</i>	Shumard's oak		PE	Forest habitats
<i>Ranunculus fascicularis</i>	tufted buttercup		PE	Dry woods, glades, prairies, and roadsides
<i>Rhexia mariana</i>	Maryland meadow-beauty		PE	Wet meadows, freshwater marshes, bogs, and wetlands
<i>Rhododendron atlanticum</i>	dwarf azalea		PE	Wooded areas
<i>Rhynchospora capillacea</i>	capillary beaked-rush		PE	Open wetlands
<i>Ruellia strepens</i>	limestone petunia		PT	Moist, open woods and wetlands, and streambanks
<i>Scheuchzeria palustris</i>	pod-grass		PE	Marshes and bogs
<i>Schoenoplectus smithii</i>	Smith's bulrush		PE	Wetlands, shores, mudflats, and beaches
<i>Scirpus ancistrochaetus</i>	northeastern bulrush	E	PE	Small wetlands
<i>Scleria pauciflora</i>	few flowered nutrush		PT	Moist, sandy soils, wetlands, wet meadows, and bogs
<i>Scleria verticillata</i>	whorled nutrush		PE	Marshes, bogs, wetlands, and wet meadows
<i>Sericocarpus linifolius</i>	narrow-leaved white-topped aster		PE	Dry fields and open woods
<i>Sida hermaphrodita</i>	sida		PE	Open areas, floodplains, and some wet areas
<i>Sisyrinchium atlanticum</i>	eastern blue-eyed grass		PE	Fields, open woods, meadows, and edges of salt marshes
<i>Solidago simplex ssp. randii var. racemosa</i>	sticky golden-rod		PE	Riverbanks, open areas, and water edges

Scientific Name	Common Name	Federal Status ^(a)	State Status ^(b)	Habitat
<i>Solidago speciosa</i> var. <i>erecta</i>	slender golden-rod		PE	Dry, open fields, tall, grassy areas, and roadsides
<i>Sparganium androcladum</i>	branching bur-reed		PE	Swamps and shallows
<i>Spiranthes vernalis</i>	spring ladies'-tresses		PE	Wet or dry upland prairies, and roadsides
<i>Sporobolus clandestinus</i>	rough dropseed		PE	Prairies, glades, roadsides, fields, and rocky edges
<i>Sporobolus heterolepis</i>	prairie dropseed		PE	Open fields and prairies
<i>Symphyotrichum depauperatum</i>	serpentine aster		PT	Dry fields and open woods
<i>Thalictrum coriaceum</i>	thick-leaved meadow-rue		PE	Rocky, open, wooded areas, and with moist soils
<i>Triphora trianthophora</i>	nodding pogonia		PE	Dense forests
<i>Vernonia glauca</i>	tawny ironweed		PE	Meadows and upland forests
<i>Viburnum nudum</i>	possum-haw		PE	Moist woods, wetlands, and swamps
<i>Vittaria appalachiana</i>	Appalachian gametophyte fern		PT	Rock outcrop areas in fields and forests

(a) E = Federally endangered; T = Federally threatened

(b) PE = Pennsylvania endangered; PT = Pennsylvania threatened; SC = State species of concern

2.2.8 Socioeconomic Factors

This section describes current socioeconomic factors that have the potential to be directly or indirectly affected by changes in TMI-1 operations. TMI-1 and the communities that support it can be described as a dynamic socioeconomic system. The communities provide the people, goods, and services required by TMI-1 operations. TMI-1 operations, in turn, create the demand and pay for the people, goods, and services in the form of wages, salaries, and benefits for jobs and dollar expenditures for goods and services. The measure of the communities' ability to support the demands of TMI-1 depends on its ability to respond to changing environmental, social, economic, and demographic conditions.

The socioeconomic region of influence (ROI) is defined by the areas where TMI-1 employees and their families reside, spend their income, and use their benefits, thereby affecting the economic conditions of the region. The TMI-1 ROI consists of a two-county area (Dauphin and Lancaster counties) where approximately 71 percent of TMI-1 employees reside. The following

Affected Environment

sections describe the housing, public services, offsite land use, visual aesthetics and noise, population demography, and the economy in the ROI surrounding TMI-1.

Exelon Generation employs a permanent workforce of approximately 525 employees (AmerGen 2008). Approximately 97 percent live in Dauphin, Lancaster, Lebanon, York, Cumberland, Perry, and Berks Counties, PA (Table 2-7). The remaining 3 percent of the workforce are divided among 12 counties in Pennsylvania, ranging from one to five employees per county. Given the residential locations of TMI-1 employees, the most significant impacts of plant operations are likely to occur in Dauphin and Lancaster counties. The focus of the socioeconomic impact analysis in this supplemental environmental impact statement (EIS) is therefore on the impacts of TMI-1 on these two counties.

Refueling outages at TMI-1 occur at 24-month intervals. During refueling outages, site employment increases by as many as 1,400 workers for approximately 20 to 30 days (AmerGen 2008). Most of these workers are assumed to be located in the same geographic areas as the permanent TMI-1 staff.

Table 2-7. TMI-1 Employee Residence by County

County	Number of Employees	Percentage of Total
Dauphin, PA	196	37
Lancaster, PA	176	34
Lebanon, PA	57	11
York, PA	41	8
Cumberland, PA	26	5
Perry, PA	7	1
Berks, PA	6	1
Other	16	3
Total	525	100

Source: AmerGen 2008

2.2.8.1 Housing

Table 2-8 on the following page lists the total number of occupied and vacant housing units, vacancy rates, and median value in the two-county ROI. According to the 2000 census, there were over 291,000 housing units in the socioeconomic region, of which approximately 275,000 were occupied. The median value of owner-occupied units ranged from \$99,900 in Dauphin County to \$119,300 in Lancaster County. The vacancy rate was lower in Lancaster County (4.1 percent) than Dauphin County (7.6 percent).

By 2006, the number of housing units in Dauphin County grew to an estimated total of 115,896 units, an increase of more than 4,700 units, and the number of occupied units grew by more than 1,600 units to an estimated total of 104,336 units. As a result, the number of available vacant housing units in Dauphin County increased by more than 3,090 units to 11,560, or 10 percent of the available units. In addition, the estimated number of vacant housing units also increased in Lancaster County (USCB 2008).

Table 2-8. Housing in Dauphin and Lancaster Counties, Pennsylvania

	Dauphin	Lancaster	Region
2000			
Total	111,133	179,990	291,123
Occupied housing units	102,670	172,560	275,230
Vacant units	8,463	7,430	15,893
Vacancy rate (percent)	7.6	4.1	5.5
Median value (dollars)	99,900	119,300	109,600
2006*			
Total	115,896	192,351	308,247
Occupied housing units	104,336	184,581	288,917
Vacant units	11,560	7,770	19,330
Vacancy rate (percent)	10.0	4.0	6.3
Median value (dollars)	136,200	171,900	154,050

* Estimated

2.2.8.2 Public Services

This section presents a discussion of public services including water supply, education, and transportation.

Water Supply

Because TMI-1 is located in Londonderry Township (in Dauphin County) and most of the TMI-1 employees reside in Dauphin and Lancaster counties, the discussion of public water supply systems is limited to Dauphin and Lancaster counties.

Dauphin County

Dauphin County is currently served by 14 public water systems. Public water systems serve approximately 240,000 persons with approximately 74,000 connections (Dauphin County 2008). The largest populations served are those receiving water from United Water Pennsylvania (94,000 persons served), the Harrisburg Municipal Water Authority (66,500 persons), and the Pennsylvania American Water Company-Hershey (42,000 persons) (PADEP 2008). The

Affected Environment

sources for these public water systems are primarily surface water (i.e. various creeks, streams and a reservoir), while the majority of the smaller systems are dependent upon ground water sources (Dauphin County 2008). County planners state that there is currently ample water to meet demand. Table 2-9 lists the largest municipal water suppliers in Dauphin County.

Lancaster County

Lancaster County has more than 30 major public water systems providing services for larger communities in the county. Although these systems draw from ground water and surface water sources, they are becoming increasingly dependent on ground water to meet growing public demand. Over the last several decades, Lancaster County's population has grown at a faster rate than the Commonwealth of Pennsylvania, reflecting an increase in demand for water. Lancaster County currently has ample supply to meet the county's needs. However, county planning officials are concerned about future supplies. Table 2-9 lists some of the major community water supply systems in the two-county area.

Table 2-9. Major Public Water Supply Systems

Water Supplier ^a	Water Source ^{a, b}	Average Daily Production ^c	Design Capacity ^c	Population Served
Dauphin County				
Harrisburg Municipal Water Authority	SW	9	20	66,540
Pennsylvania American Water Company–Hershey	SW	6	9	42,398
United Water Pennsylvania	SW	11	16	94,000
Lancaster County				
City of Lancaster	SW	16	40	108,000
Columbia Water Company	SW	2	3	21,500
Elizabethtown Area Water	SW	1	2	15,000
Ephrata Area Joint Authority	SW	3	4	17,937
East Hempfield Water Authority	GW	2	3	16,761

(a) GW = ground water; SW = surface water;

(b) EPA 2008c

(c) Million gallons per day

Source: PADEP 2008a

Education

TMI-1 is located in the Lower Dauphin School District (PDE 2004), Dauphin County, which had an enrollment of approximately 3,950 students in 2006-2007 school year (PDE 2007a).

Including the Lower Dauphin School District, Dauphin County has 10 public school districts (PDE 2007a) with over 38,500 enrolled students (PDE 2007b). Lancaster County has a total of

16 public school districts (PDE 2007a). Total enrollment in Lancaster County public schools in the 2006-2007 school year was approximately 71,000 students (PDE 2007b).

Transportation

TMI-1 is located in the southwest corner of Dauphin County (near the northern border of Lancaster County), approximately 10 mi southeast of Harrisburg, Pennsylvania. Dauphin County is traversed by four interstate highways: 81, 83, 283, and 76. The nearest interstate, I-76, can be accessed approximately 7 mi north of TMI-1 (see Figures 2-1 and 2-2).

Road access to TMI-1 is via State Highway 441 (SH-441), which runs north to south on the east side of the Susquehanna River. There are two access roads to TMI-1, Liberty Lane to the north (North Access Road), and Constitution Drive to the south (South Access Road), and they both intersect with SH-441 (see Figure 2-6). The majority of the plant's operation workforce uses the northern entrance; a limited number of employees working on the southern portion of the station, as well as the outage and refurbishment workforces use the southern entrance (AmerGen 2008). Approximately 4–5 mi north of TMI-1, SH-441 intersects with I-76, which runs east to west (Figure 2–2). Exelon Generation and contractor employees traveling to TMI-1 from Harrisburg, Hummelstown, and Middletown from the north would use I-76, or a variety of interstate, State, and secondary roads to access SH-441. Workers traveling to TMI-1 from Elizabethtown, Mount Joy, and Lancaster from the south would also use a variety of State highways and secondary roads to access SH-441.

Employees traveling from the southwest would travel north to I-76, cross the Susquehanna River, and access SH-441 to reach TMI-1.

Table 2–10 on the following page lists commuting routes to TMI-1 and average annual daily traffic (AADT) volume values. The AADT values represent traffic volumes for a 24-hour period factored by both day of week and month of year.

Table 2-10. Major Commuting Routes in the Vicinity of the Three Mile Island Nuclear Station and 2006 Average Annual Daily Traffic (AADT) Counts

Roadway and Location	AADT ^(a)
State Highway 230, south of Interstate 76, near Harrisburg International Airport to Middletown	13,000–17,000
State Highway 441, just north of Interstate 76	6,400
State Highway 441, south of Interstate 76, near Middletown	7,100
State Highway 441, south of Interstate 76, near Royalton	6,700
State Highway 441, near northern entrance to Three Mile Island	3,300
State Highway 441, between Dauphin County border and intersection with State Highway 241 (Lancaster County)	4,200
State Highway 441, between intersection with State Highway 241 and intersection with State Highway 743 (Lancaster County)	5,100 – 6,300

Affected Environment

Table 2-10. Major Commuting Routes in the Vicinity of the Three Mile Island Nuclear Station and 2006 Average Annual Daily Traffic (AADT) Counts

Roadway and Location	AADT ^(a)
State Highway 441, between intersection with State Highway 743 and intersection with State Highway 772 (Lancaster County)	11,000
State Highway 441, between intersection with State Highway 772 and intersection with State Highway 23 (Lancaster County)	16,000
State Highway 441, between intersection with State Highway 23 and intersection with U.S. Route 30 (Lancaster County)	17,000
State Highway 441, between intersection with U.S. Route 30 and intersection with State Highway 462 Lancaster County)	12,000

Source: PennDOT 2008.

(a) All AADTs represent traffic volume during the average 24-hour day during 2006.

2.2.8.3 Offsite Land Use

Offsite land use conditions in Dauphin and Lancaster Counties are described in this section, because the majority of TMI-1 employees live in these two counties. In addition to the real estate taxes paid by Exelon Generation to Dauphin County, Dauphin and other counties in the vicinity of TMI-1 receive revenue from the taxes and fees paid by Exelon Generation and long-term contract employees residing in the region. In addition, changes in the number of workers employed at TMI-1 and the amount of taxes paid to local jurisdictions could affect land use conditions in these counties. The TMI-1 facility is located in southwestern Dauphin County. Lancaster County is located southeast of Dauphin County along the Susquehanna River.

Dauphin County

Dauphin County is approximately 525 mi² (1360 km²) and has 40 municipalities including the Pennsylvania State capital in Harrisburg (USCB 2008b). The county is located in south-central Pennsylvania, along the Susquehanna River. Dauphin County planners are concerned about future population growth and making growth decisions that will not overburden taxpayers. County planners are focused on revitalizing older developed areas of the county and managing growth that will not change its rural character.

Dauphin County planners are working to manage development within the county through the use of Planned Growth Areas. Dauphin County adopted the Regional Growth Management Plan produced by the Tri-County Regional Planning Commission (which includes Cumberland and Perry Counties). The goal is to focus development in and around Planned Growth Areas where services such as sewer, water, transit, highway access, and community facilities exist to maximize the investment in existing infrastructure (Dauphin County 2008).

The recently adopted Dauphin County Comprehensive Plan describes the following land use:

- Residential: 15 percent

- Public and semi-public lands: 26 percent (two-thirds comprised of state game lands and forest)
- Agricultural and undeveloped lands: 55 percent
- Industrial: 2 percent
- Transportation: less than 1 percent
- Commercial and service: less than 1 percent each.

In 2000, 34.5 percent of the county's residents lived in Harrisburg and 16 boroughs while others made their homes in townships and villages. As part of the 2008 Comprehensive Plan, the county considered future land use by including geographic planning sections. Northern Dauphin County is characterized by low-density residential development. Southeastern Dauphin County is characterized by medium-density residential development. Southwestern Dauphin County and Harrisburg are characterized by high-density mixed urban development (Dauphin County 2008).

Throughout the county, non-residential development occurs in a scattered fashion adjacent to roadways. The greatest concentration of non-residential development occurs between the city of Harrisburg and Derry Township, adjacent to U.S. Routes 83, 322, and 422. Limited non-residential land use has occurred on limited access intersections of Interstates 81 and 83 and the Pennsylvania Turnpike. The portions of the county located in the heart of the Susquehanna Valley contain the majority of agricultural activity. The northeastern tier of the county is mountainous and forested (Dauphin County 2008).

The Land Needs Concept forecasts land use needs by considering regional population growth trends, employment needs resulting from population growth, and real estate market projections. Previously, most planning did not take this picture into account and relied solely on population projections. The future land use map identifies land needed to accommodate population projections through 2020. All other land is designated as Rural Reserve/Agriculture for future evaluation and use (Dauphin County 2008).

Lancaster County

Lancaster County is approximately 949 mi² (2458 km²), nearly twice the size of Dauphin County in acreage and population, and has 60 municipalities (USCB 2008b). Farming plays a major role in Lancaster County, and land use planning focuses on preservation of agricultural areas. Farmland presently occupies 69 percent of the available land area in the county. Lancaster County and Municipal Planners are concerned about preserving the farming culture and heritage of the county, especially that of the Amish. Tourists visiting these areas add \$1.6 billion annually to the county's economy.

In 1993, the county adopted a Growth Management element to its Comprehensive Plan. Future growth would be directed to Designated Growth Areas (similar to Dauphin County's Planned Growth Areas) or areas already impacted by development to emphasize reinvestment in previously developed areas. The plan defined two types of growth areas as Urban Growth Areas and Village Growth Areas to manage future land use in the county (Lancaster County 2006). The growth areas have defined boundaries around a city, borough, or village, and include developed portions of surrounding townships and enough buildable land to meet future land use needs over a 20-year period. Since 1993, 39 growth areas have been established in

Affected Environment

Lancaster County. Between 1994 and 2002, residential land use outside Designated Growth Areas occurred at a net density of 0.8 dwellings per acre, while growth inside Designated Growth Areas occurred at a net density of 5.5 dwellings per acre (Lancaster County 2006).

Currently, the largest residential, commercial and industrial development concentrations are found in the City of Lancaster and surrounding areas. Development can also be found along major road corridors heading north and northwest (Interstate 76, U.S. 30, U.S. 222, and PA 283) through the county (Lancaster County 2006).

The Lancaster County Planning Commission is updating the Growth Management Plan element of the Lancaster County Comprehensive Plan. The update will plan for growth throughout the county through 2030, and it will be guided by the Policy Element of the Comprehensive Plan.

The growth management plan will:

- Examine current and projected growth patterns and infrastructure needs
- Review urban and village growth areas
- Address issues of concern within rural areas
- Provide recommendations to achieve sustainable growth that balances development with the preservation of farmland and open space.

2.2.8.4 Visual Aesthetics and Noise

TMI-1 is located on an island in the middle of the Susquehanna River. TMI-1 as a whole can be seen from the river, but is shielded on the land side for the most part by surrounding vegetation due to its position along the river in the Susquehanna River Valley. The cooling towers, turbine buildings, and reactor containment structures dominate the site's landscape and can be seen from the Susquehanna River.

With natural draft cooling towers, the most obvious aesthetic impact is the visible plume in the sky. The plumes are most persistent under certain meteorological conditions when the capacity for the atmosphere to hold additional water vapor is lowest. This occurs when relative humidity is high or air temperatures are low. Observations of cooling towers in the same region suggest that under certain meteorological conditions the visible plume could extend 1–2 mi (1.6–3.2 km) (AEC 1972).

Noise from TMI-1 can be detected offsite. Sources of noise from station operation include the cooling towers, turbines, and large pumps and cooling water system motors. Given the industrial nature of the station, noise emissions from the station are generally nothing more than an intermittent minor nuisance. Noise levels may sometimes exceed the 55 dBA level that the EPA uses as a threshold level to protect against excess noise during outdoor activities. However, according to the EPA this threshold does "not constitute a standard, specification, or regulation,"

The EPA generally uses 55 decibels (dBA) as the noise threshold level to protect against excess noise during outdoor activities. However, according to the EPA, this threshold does "not constitute a standard, specification, or regulation," but was intended to provide a basis for state and local governments establishing noise standards (EPA 1974).

but was intended to provide a basis for State and local governments establishing noise standards.

2.2.8.5 Demography

According to the 2000 Census, approximately 787,800 people lived within 20 mi (32 km) of TMI-1, which equates to a population density of 627 persons per square mile (AmerGen 2008). This density translates to the least sparse Category 4 density level (greater than or equal to 120 persons per square mile within 20 mi). Approximately 2,546,500 people live within 50 mi (80 km) of TMI-1 (AmerGen 2008). This equates to a population density of 325 persons per square mile. Applying the GEIS proximity measures, TMI-1 is classified as proximity Category 4 (greater than or equal to 190 persons per square mile within 50 mi). Therefore, according to the sparseness and proximity matrix presented in the GEIS, TMI-1 rankings of sparseness Category 4 and proximity Category 4 result in the conclusion that TMI-1 is located in a high population area.

Table 2-11 shows population projections and growth rates from 1970 to 2050 in Dauphin and Lancaster counties. The growth rate in Dauphin County showed an increase of 5.9 percent for the period of 1990 to 2000. County populations are expected to continue to grow in both counties in the next decades although Lancaster County's population is expected to increase at a higher rate through 2050.

Table 2-11. Population and Percent Growth in Dauphin County and Lancaster County, Pennsylvania, from 1970 to 2000, and Projected for 2010 and 2050

Year	Dauphin		Lancaster	
	Population	Percent Growth ^(a)	Population	Percent Growth ^(a)
1970	223,834	—	319,693	—
1980	232,317	3.8	362,346	13.3
1990	237,813	2.4	422,822	16.7
2000	251,798	5.9	470,658	11.3
2006	254,176	0.9	494,486	5.1
2010	256,478	1.9	499,261	6.1
2020	263,198	2.6	527,486	5.7
2030	270,543	2.8	554,611	5.1
2040	279,024	3.2	591,901	6.7
2050	286,710	2.7	623,536	5.3

— = No data available.

(a) Percent growth rate is calculated over the previous decade.

Sources: Population data for 1970–2000 (USCB 2008a); population data for 2006 (estimated) 2006 American Community Survey; population projections for 2010 – 2030 by Pennsylvania State Data Center, February 2008; population projections for 2040 and 2050 (calculated)

Affected Environment

The 2000 and 2006 (estimate) demographic profiles of the two-county region of influence population are presented in Table 2-12 and Table 2-13. In 2000, minority individuals (both race and ethnicity) comprised 15.5 percent of the total two-county population. The minority population was comprised largely of Black or African American and Hispanic or Latino residents.

Table 2-12. Demographic Profile of the Population in the TMI-1 Two-County Socioeconomic Region of Influence in 2000

	Dauphin	Lancaster	Region of Influence
Total Population	251,798	470,658	722,456
Race (percent of total population, not Hispanic or Latino)			
White	75.6	89.3	84.5
Black or African American	16.6	2.5	7.4
American Indian and Alaska Native	0.1	0.1	0.1
Asian	1.9	1.4	1.6
Native Hawaiian and Other Pacific Islander	0.0	0.0	0.0
Some other race	0.1	0.1	0.1
Two or more races	1.5	0.8	1.1
Ethnicity			
Hispanic or Latino	10,404	26,742	37,146
Percent of total population	4.1	5.7	5.1
Minority Population (including Hispanic or Latino ethnicity)			
Total minority population	61,451	50,292	111,743
Percent minority	24.4	10.7	15.5

Source: USCB 2008a

According to the U.S. Census Bureau's 2006 American Community Survey, minority populations in the two-county region were estimated to have increased by nearly 17,000 persons and comprised 17.2 percent of the total two-county population in 2006 (see Table 2-13). The largest increases in minority populations were estimated to occur in Hispanic or Latino and Asian populations. The Black or African American population increased by approximately 9.4 percent from 2000 to 2006, but remained relatively unchanged as a percentage of the total four-county population.

Table 2-13. Demographic Profile of the Population in the TMI-1 Two-County Socioeconomic Region of Influence in 2006 (Estimate)

	Dauphin	Lancaster	Region of Influence
Total Population	254,176	494,486	748,662
Race (percent of total population, not-Hispanic or Latino)			
White	73.5	87.6	82.8
Black or African American	17.2	3.0	7.8
American Indian and Alaska Native	0.2	0.1	0.1
Asian	2.4	1.5	1.8
Native Hawaiian and Other Pacific Islander	0.0	0.0	0.0
Some other race	0.1	0.2	0.2
Two or more races	1.5	0.9	1.1
Ethnicity			
Hispanic or Latino	12,910	32,894	45,804
Percent of total population	5.1	6.7	6.1
Minority Population (including Hispanic or Latino ethnicity)			
Total minority population	67,434	61,435	128,869
Percent minority	26.5	12.4	17.2

Source: USCB 2008a

Transient Population

Within 50 mi (80 km) of TMI-1, colleges and recreational opportunities attract daily and seasonal visitors who create demand for temporary housing and services. In 2007, there were approximately 63,000 students attending colleges and universities within 50 mi (80 km) of TMI-1 (IES 2008).

In 2000 in Dauphin County, 0.5 percent of all housing units were considered temporary housing for seasonal, recreational, or occasional use. By comparison, seasonal housing accounted for 0.4 percent and 2.8 percent of total housing units in Lancaster County and Pennsylvania, respectively (USCB 2008). Table 2-14 provides information on seasonal housing located within 50 mi of TMI-1.

Table 2-14. Seasonal Housing in Counties Located within 50 Miles of TMI-1

County ^(a)	Housing units	Vacant housing units: For seasonal, recreational, or occasional use	
		occasional use	Percent
Pennsylvania	5,249,750	148,230	2.8
Adams	35,831	672	1.9
Berks	150,222	744	0.5
Chester	163,773	571	0.3
Columbia	27,733	1,304	4.7
Cumberland	86,951	379	0.4
Dauphin	111,133	570	0.5
Franklin	53,803	572	1.1

Affected Environment

County ^(a)	Housing units	Vacant housing units: For seasonal, recreational, or occasional use	Percent
Juniata	10,031	945	9.4
Lancaster	179,990	808	0.4
Lebanon	49,320	458	0.9
Mifflin	20,745	1,082	5.2
Northumberland	43,164	246	0.6
Perry	18,941	1,270	6.7
Schuylkill	67,806	865	1.3
Snyder	14,890	495	3.3
York	156,720	946	0.6
County Subtotal	1,191,053	11,927	2.4 (avg.)
Maryland	2,145,283	38,880	1.8
Baltimore	313,734	1,212	0.4
Carroll	54,260	117	0.2
Cecil	34,461	1,410	4.1
Frederick	73,017	284	0.4
Harford	83,146	299	0.4
Washington	52,972	468	0.9
County Subtotal	611,590	3,790	1.1 (avg.)
County Total	1,802,643	15,717	2.0 (avg.)

USCB 2008

(a) Counties within 50 mi (80 km) of TMI-1 with at least one block group located within the 50-mile radius
 avg. = percent average for counties within the TMI-1 50-mile radius and excludes State percentage

Migrant Farm Workers

Migrant farm workers are individuals whose employment requires travel to harvest agricultural crops. These workers may or may not have a permanent residence. Some migrant workers may follow the harvesting of crops, particularly fruit, throughout the northeastern U.S. rural areas. Others may be permanent residents near TMI-1 who travel from farm to farm harvesting crops.

Migrant workers may be members of minority or low-income populations. Because they travel and can spend a significant amount of time in an area without being residents, migrant workers may be unavailable for counting by census takers. If uncounted, these workers would be "underrepresented" in USCB minority and low-income population counts.

Information on migrant farm and temporary labor was collected in the 2002 Census of Agriculture. Table 2-15 provides information on migrant farm workers and temporary farm labor (less than 150 days) within 50 mi (80 km) of TMI-1. According to the 2002 Census of Agriculture, approximately 25,000 farm workers were hired to work for less than 150 days and were employed on 5,800 farms within 50 mi (80 km) of TMI-1. The county with the largest number of temporary farm workers (5,841 workers on 1,627 farms) was Lancaster County, Pennsylvania.

In the 2002 Census of Agriculture, farm operators were asked for the first time whether any hired migrant workers, defined as a farm worker whose employment required travel that prevented the migrant worker from returning to their permanent place of residence on the same day. A total of 648 farms in the 50-mile radius of TMI-1 reported hiring migrant workers. Chester County reported the most farms (158) with hired migrant workers, followed by Lancaster County (126). By comparison, the 10 farms in Dauphin County host relatively small numbers of migrant workers. According to 2002 Census of Agriculture estimates, 425 temporary farm laborers (those working fewer than 150 days per year) were employed on 147 farms in Dauphin County, and as previously discussed 5,841 temporary farm workers were employed on 1,627 farms in Lancaster County (USDA 2002 Census of Agriculture).

Table 2-15. Migrant Farm Worker and Temporary Farm Labor in Counties Located within 50 Miles of TMI-1

County ^(a)	Number of farm workers working for less than 150 days	Number of farms hiring workers for less than 150 days	Number of farms reporting migrant farm labor	Number of farms with hired farm labor
Pennsylvania	13,512	10,232	41,606	745
Adams	293	211	2,437	88
Berks	549	383	2,128	28
Chester	710	494	2,470	158
Columbia	252	196	1,408	8
Cumberland	189	130	420	4
<i>Dauphin</i>	194	147	425	10
Franklin	482	342	1,819	27
Juniata	172	158	304	2
<i>Lancaster</i>	1,976	1,627	5,841	126
Lebanon	325	180	547	6
Mifflin	250	106	249	1
Northumberland	204	156	595	27
Perry	150	112	392	7
Schuylkill	173	128	556	10
Snyder	242	189	534	16
York	404	327	1,104	23
County Subtotal	6,565	4,886	21,229	541
Maryland	3,321	2,453	10,551	212
Baltimore	273	201	762	47
Carroll	244	169	414	6
Cecil	162	123	713	7
Frederick	294	223	1,269	17
Harford	148	101	406	26
Washington	188	129	443	4
County Subtotal	1,309	946	4,007	107
County Total	7,874	5,832	25,236	648

(a) Counties within 50 mi (80 km) of TMI-1 with at least one block group located within the 50-mi (80-km) radius
2002 Census of Agriculture – County Data; Table 7. Hired Farm Labor – Workers and Payroll: 2002

Affected Environment

2.2.8.6 Economy

This section contains a discussion of the economy, including employment and income, unemployment, and taxes.

Employment and Income

Between 2000 and 2006, the civilian labor force in Dauphin County increased 6 percent from 128,611 to 136,359. During the same time period, the civilian labor force in Lancaster County grew by nearly the same percentage (5.8 percent) (USCB 2008a).

In 2006, educational services, health care and social assistance represented the largest sector of employment in the two-county region followed closely by manufacturing and retail trade industry. The educational services, health care, and social assistance sector employed the most people in Dauphin County, followed by the retail trade and public administration sectors. A list of some of the major employers in Dauphin County in 2007 is provided in Table 2-16. As shown in the table, the largest private employer in Dauphin County was Hershey Foods Corporation.

Table 2-16. Major Employers in Dauphin County in 2007

Name	Name
Pennsylvania State Government	Harrisburg School District
Milton S Hershey	Giant Food Stores LLC
Hershey Foods Corporation	Wal-Mart Associates Inc.
HERCO Inc./ Hershey Entertainment and Resorts	Keystone Service Systems Inc.
Pinnacle Health System	Nationwide Mutual Insurance Company
Federal Government	United Concordia Companies Inc.
Pennsylvania Higher Education Assistance Agency	Diocese of Harrisburg
Tyco Electronics Corporation	DST Health Solutions Services
Central Dauphin School District	City of Harrisburg
United Parcel Service	ArcelorMittal Steelton LLC
Pennsylvania State University	D & H Distributing Company
Capital Blue Cross	Derry Township School District
Harrisburg Area Community College	ENERFAB Inc.
Dauphin County Government	Lower Dauphin School District
Milton S Hershey School and School Trust	C & S Wholesale Grocers

Center for Workforce Information and Analysis 2008

Income information for the TMI-1 region of influence is presented in Table 2-17. In 1999, the date of the last economic census, the two counties each had median household incomes above the Pennsylvania Commonwealth average. Per capita income, with the exception of Lancaster County, was also above the average for all of Pennsylvania. In 1999, only 7.8 percent of the population in Lancaster County was living below the official poverty level, while in Dauphin County and the Commonwealth of Pennsylvania, 9.7 and 11 percent of the respective populations were living below poverty level. The percentage of families living below the poverty level was about the same for Dauphin County and Pennsylvania as a whole. Lancaster County had a smaller percentage of families living below the poverty level (USCB 2008a).

Table 2-17. Income Information for the TMI-1 Socioeconomic Region of Influence

	Dauphin	Lancaster	Pennsylvania
Median household income 1999 (dollars)	41,507	45,507	40,106
Per capita income 1999 (dollars)	22,134	20,398	20,880
Percent of families living below the poverty level (2000)	7.5	5.3	7.8
Percent of individuals living below the poverty level (2000)	9.7	7.8	11.0

USCB 2008

Unemployment

In 2006, the annual unemployment averages in Dauphin and Lancaster Counties were 4.8 and 3.6 percent, respectively, which were lower than the annual unemployment average of 6.2 percent for the Commonwealth of Pennsylvania (USCB 2008a).

Taxes

Currently, Exelon Generation pays annual property taxes on TMI-1 to Dauphin County, Londonderry Township, and the Lower Dauphin School District. Prior to 2000, real estate taxes were paid to the Commonwealth of Pennsylvania for power generation, transmission, and distribution facilities. During that time, under authority of the Pennsylvania Utility Realty Tax Act (PURTA), real estate taxes collected from all utilities (water, telephone, electric, and railroads) were redistributed to the taxing jurisdictions within the Commonwealth. In Pennsylvania, these jurisdictions included counties, cities, townships, boroughs, and school districts. The distribution of PURTA funds was determined by formula, and was not necessarily based on the individual utility's effect on a particular government entity.

Under 1999 Amendments to PURTA, the assessment methodology for utilities was revised from the depreciated book value to the market value of utility property. Additionally, as of January 1, 2000, the owners of TMI-1 were required to begin paying real estate taxes directly to local jurisdictions, ceasing payments to the Commonwealth's PURTA fund. Accordingly, since that time, the owner of TMI-1 has periodically negotiated with local taxing jurisdictions regarding market value assessments of the station and the amount of taxes that will be paid.

While maintaining open appeals of the assessments from 1998 through 2002, Exelon Generation and the previous owners of TMI-1 entered into a Stipulation and Interim Settlement agreement with the taxing authorities, dated December 22, 2000 (2000 Stipulation). Under the 2000 Stipulation, Exelon Generation paid Dauphin County approximately \$146,900 annually in property taxes from 2000 through 2004. These payments represented approximately 0.2 to 0.3 percent of Dauphin County's total property tax revenues for that time period (see Table 2-18 on the following page).

Also from 2000 through 2004 under the 2000 Stipulation, Exelon Generation paid property taxes annually to Londonderry Township and Lower Dauphin School District in the amounts of \$30,000 and \$394,500, respectively. These payments represented approximately 0.5 to 0.7 percent of Londonderry Township's total property tax revenues and approximately 2.1 to 2.9 percent of total property tax revenues for the Lower Dauphin School District (see Table 2-18 on the following page).

Affected Environment

In 2005, Exelon Generation and PECO signed a settlement with the local taxing bodies (the 2005 Settlement) that both acknowledged the 1999 PURTA Amendments' change in the way TMI-1's value would be assessed and reported a corresponding reduction in assessed value. As a result, the 2005 Settlement slightly decreased Exelon Generation's property tax payments to Dauphin County, Londonderry Township, and the Lower Dauphin School District in comparison with payments made under the 2000 Stipulation. For 2005, Exelon Generation's property tax payments represented approximately 0.2 percent of Dauphin County's total property tax revenues, and approximately 1.7 percent of the Lower Dauphin School District's total property tax revenues (see Table 2-18).

From 2000 to 2005, Exelon Generation's annual property tax payments to both Dauphin County and Londonderry Township for TMI-1 represented less than 1 percent of each of their total property tax revenues. Annual property tax payments to the Lower Dauphin School District during the same time period represented an average of approximately 2.4 percent of the school district's total property tax revenues (see Table 2-18).

In July of 2008, Exelon Generation negotiated a new agreement with the three taxing entities (2008 Agreement) which provides for an increase in the property taxes Exelon Generation currently pays. The 2008 Agreement obligates Exelon Generation to pay a total of \$930,000 to the Lower Dauphin School District, Dauphin County and Londonderry Township. Annually, the school district will receive \$637,000, the county will receive \$254,634, and the township will receive \$37,665. These payments will begin in 2008 and continue through 2017.

Dauphin County property taxes are used to pay for county operations, the judicial system, public safety, public works, cultural and recreational programs, human services and conservation and development programs. Londonderry Township property taxes pay the operating costs for libraries, hospitals, roads, school districts, and fire departments. The continued availability of TMI-1 and the associated tax base is an important feature in the ability of the Dauphin County and Londonderry Township to continue to invest in infrastructure and to draw industry and new residents.

Table 2-18. TMI-1 Property Tax Paid and Percentage of Dauphin County, Londonderry Township, and the Lower Dauphin School District from Property Tax Revenues, 2000 to 2005

Entity	Year	Total Property Tax Revenue (millions of dollars)	Property Tax Paid by Exelon Generation (thousands of dollars)	Percent of Total Revenue
Dauphin County	2000	58.0	146.9	0.3
	2001	60.1	146.9	0.2
	2002	60.5	146.9	0.2
	2003	61.5	146.9	0.2
	2004	73.9	146.9	0.2
	2005	89.3	141.6	0.2

Entity	Year	Total Property Tax Revenue (millions of dollars)	Property Tax Paid by Exelon Generation (thousands of dollars)	Percent of Total Revenue
Londonderry Township	2000	4.0	30.0	0.7
	2001	4.8	30.0	0.6
	2002	5.1	30.0	0.6
	2003	5.6	30.0	0.5
	2004	6.3	30.0	0.5
	2005	6.4	21.0	0.3
Lower Dauphin School District	2000	13.8	394.5	2.9
	2001	14.1	394.5	2.8
	2002	15.8	394.5	2.5
	2003	17.5	394.5	2.3
	2004	18.6	394.5	2.1
	2005	20.1	343.0	1.7

Source: AmerGen 2008

2.2.9 Historic and Archaeological Resources

This section discusses the cultural background and the known historic and archaeological resources at the site of TMI-1 and in the surrounding area.

2.2.9.1 Cultural Background

The region around TMI-1, located on the northern end of Three Mile Island, contains prehistoric and historic Native American and Euro-American cultural resources. Three Mile Island was formed as a result of water deposited sands and gravels resting on deposits of sedimentary sandstones, siltstones, and clays (Smith 1977). TMI-1 lies within the Gettysburg Section of the Piedmont physiographic province, which is characterized by rolling low hills and valleys (DCNR 2008a). The Piedmont region contains some of the most agriculturally productive land in Pennsylvania both currently and historically, and is a favored area of settlement (Raber 1985). There are 369 properties in Dauphin, York, and Lancaster counties that are listed on the *National Register of Historic Places* (NRHP), and 19 properties are located within 6 mi (10 km) of TMI-1 (USDOI 2008). No NRHP listed properties are affected by operation of TMI-1. Paleo-Indians occupied North America approximately 15,000–10,000 years ago, subsisting on hunted game and gathered plant material. In the Pennsylvania area, Paleo-Indians migrated into an environment changed by retreating glacial ice. The climate in Pennsylvania at the time was wetter and cooler than it is today. Large areas of grasslands mixed with coniferous and deciduous forests were characteristic of the region (Raber 1985). Paleo-Indian populations were highly mobile and hunted large animals such as mastodons, bison, caribou, mammoths, horse, deer, giant beaver, moose, and elk (Raber 1985; Funk 1972). The primary artifact associated with the Paleo-Indian period is the Clovis point, a distinctive, fluted, lanceolate point that is

Affected Environment

widely distributed throughout Pennsylvania, especially in the Susquehanna and Delaware River valleys (AmerGen 2008). Regional studies indicate that there is a high probability for Clovis points to be found in the Susquehanna River Valley (Kent et al. 1971). Other tools commonly found at Pennsylvania Paleo-Indian sites include scrapers; spurred-end scrapers; drills; cores; bifaces; microblades; and small uniface, biface, and flake knives (AmerGen 2008).

During the Archaic Period, from approximately 10,000 years ago until about 3,000 years ago, subsistence strategies underwent changes to adapt to resource availability. As the glaciers retreated northward and larger animals disappeared from the region, humans adapted to exploit modern plants and smaller game animals. Like Paleo-Indians, early Archaic foragers were highly mobile (Carr 1998). As resource quality and the cultural means to access resources improved, archaeologists find evidence of larger populations by the end of the Archaic Period, a time when climate reached its modern condition. As a result of diversification of prey species, a shift in the design of hunting technology occurred. Prehistoric megafauna were replaced by deer, elk, bear, turkey and other species common to deciduous forests (Raber 1985). Projectile points also changed to smaller, barbed points (Raber 1985). Archaic people collected, hunted, and gathered most of what they needed for survival in their home territory. Large base camps found near major water sources provided a focal point for groups during the winter months. During this period, Archaic peoples developed well-defined seasonal foraging activities.

The "Woodland" culture existed from 3,000 years ago until European contact around 1,500 A.D. This period is defined by the introduction of horticulture to augment subsistence hunting and gathering. A reliance on agriculture led to the establishment of more permanent settlements during this period. The earliest evidence of agriculture in Pennsylvania was found at the Meadowcroft rock shelter where evidence of squash and maize (corn) appear in the archaeological record (Adovasio and Johnson 1981). Other characteristics of Woodland culture include an increase in population, the emergence of social hierarchy, expanded interregional trade, more elaborate burial rituals, the introduction of the bow and arrow, and the use of ceramics for storage and cooking (Cowin 1985).

The area around TMI-1 was home to a number of prehistoric populations. Evidence from archaeological sites in the region reflect the influences of Laurentian, Lamoka, Piedmont and later Hopewell cultural traditions (AmerGen 2008). Native Americans used the Susquehanna River and several overland paths and trails as their primary transportation routes. Native American societies in the region shared several important characteristics at the time of first contact with Europeans. These characteristics included an economic base that combined hunting and gathering with domesticated plants and an annual settlement pattern that varied in population size between semi-permanent river-side villages in summer, large camps in winter, and population dispersal among scattered camps in the spring and fall.

In the 1600s, Europeans came to the Pennsylvania area and came into contact with Late Woodland peoples known as the Delaware, Shawnee, Iroquois, and Susquehannock (AmerGen 2008). The Susquehannocks were an Iroquoian-speaking tribe that lived along the Susquehanna River in Pennsylvania and Maryland (PGA Undated). Living in Algonkian-speaking tribes' territory, they engaged in many wars (AmerGen 2008). The Susquehannocks lived about 20 miles downstream from Three Mile Island in a town called Sasquesahanaugh, located on the eastern side of the Susquehanna River at Washington Boro (AEC 1972).

Susquehannock populations were reduced by diseases brought by Europeans and by attacks from Marylanders and the Iroquois. By 1675, the Susquehannocks ceased to exist as a Nation (PGA Undated).

The rise of nation-states in Europe coincided with European land acquisition in North America. Wars in southern Germany caused many Germans to migrate to Pennsylvania. The struggle for religious freedom in England brought Quakers, Puritans, and Catholics to Pennsylvania (PHMC Undated-a). Captain John Smith was the first European to explore the region. In 1608, Smith journeyed from Virginia up the Susquehanna River and made contact with the Susquehannock Indians. Around this time, Henry Hudson's voyages document the relations between the European settlers and the Indian Nations occupying Pennsylvania (Raber 1985). Between 1609 and 1681, the Dutch, Swedes, and English inhabited and fought over the region which would later become eastern Pennsylvania. Ultimately, the English prevailed in Pennsylvania and the area fell under English rule (PHMC Undated-a). The effects of European contact upon Indian populations included death due to disease, increased intergroup warfare, and a dependence on European goods (Jennings 1968).

William Penn, a member of the Society of Friends, also known as Quakers, a persecuted religious sect in England petitioned the King of England for a haven in the New World. On March 4, 1681, the King granted the petition and named the new colony in honor of William Penn's father (PHMC Undated-a). Although William Penn was granted all of the land in Pennsylvania, he and his heirs chose not to grant or settle any part of it without first buying the claims of Native Americans who lived there. Most of Pennsylvania was purchased by 1768 and the remaining portion was purchased by the Commonwealth by 1789 (PHMC Undated-a). English, German, and Scotch-Irish immigrants eventually settled in the region.

As previously discussed, TMI-1 is located in Londonderry Township in Dauphin County. Dauphin County was created on March 4, 1785, from part of Lancaster County, and it was named for the French dauphin (prince), the king's eldest son (PHMC Undated-b). Harrisburg, the county seat, was named for its founder John Harris, and was incorporated as a borough in 1791 and chartered as a city in 1810 (PHMC Undated-b). John Harris, a native of Yorkshire, England, was one of the first emigrants to accompany William Penn (Harrisburg Websites Undated). In 1705, Harris secured a license to obtain land and around 1718, settled in the wilderness of what was to become Harrisburg (PHMC Undated-b). There are several islands within Londonderry Township, one of which is Three Mile Island, formerly called Elliot's Island and prior to that Conewago Island (Londonderry Township Undated).

Several historic canals were constructed on both sides of the Susquehanna River in the vicinity of TMI-1. The nearest canal, Pennsylvania Canal's Eastern Division (Eastern Division Canal) ran on the east side of the Susquehanna River for 43 mi (69 km) between Columbia, PA (Lancaster County) and Duncan's Island at the mouth of the Juniata River north of Harrisburg (Citizendium 2007). The Eastern Division Canal was originally owned and operated by the Commonwealth of Pennsylvania. Due to the cost of maintaining the canal and competition from railroads, the whole of Pennsylvania's Main Line canal system was sold to the Pennsylvania Railroad (PRR) in the 1850s. The PRR operated the canal until 1901, when it was replaced by the existing railroad, which is built on top of the old canal. Later, railroads became the predominant mode of freight transportation which resulted in the abandonment of the canals.

Affected Environment

2.2.9.2 *Historic and Archaeological Resources*

The islands in the Susquehanna River Valley were heavily utilized by prehistoric and historic native populations, as well as European immigrants. Three Mile Island was first purchased in 1749 by Thomas Cookson who served as Thomas Penn's Deputy Surveyor for Lancaster County (Huber 1982). The island was passed down through Cookson's extended family and sold to James Duffy in 1879 (Huber 1982). Duffy's son rebuilt and transformed an existing farm on the island into a tobacco producing station (Huber 1982). In 1904, ice and elevated levels of water from the winter thaw flooded the island and ruined Duffy's tobacco station. Duffy unknowingly sold the island to the York Haven Water and Power Company, which in turn sold the land to Metropolitan Edison in 1924 (Huber 1982). Between 1957 and the start of construction, 270 acres on Three Mile Island were leased for farming (AEC 1972). At the time, there was no access to the island by bridge, so equipment and produce were transported by barge. In addition to farming, there were 70 cabins on the island that were also leased (53 on the west side and 17 on the east side), along with a picnic area, a boat dock, and a well for drinking water (AEC 1972).

A search of the PHMC site file records identified nine prehistoric sites and one historic site on Three Mile Island. One additional historic site was identified on the island during NRC's walkover survey. Of the nine previously recorded sites, two sites (36Da51 and 36Da98) are not associated with any cultural period. Sites 36Da96, 36Da97, 36Da99, and 36Da100 contain material from Late Archaic to the Late Woodland period. Dates for these sites were based upon collected lithics, points, and pottery. Site 36Da96 was situated in a cultivated area near TMI-1 and TMI Unit 2 and was assigned a cultural designation of Late Archaic to Early Woodland. It is unclear if any portions of the 36Da96 site remain. Site 36Da97 was also located where TMI-1 and TMI Unit 2 are currently situated. The site form indicates that Woodland pottery was collected; however, no examples were available for study. Site 36Da97 was destroyed by construction of TMI-1 and TMI Unit 2. Sites 36Da99 and 36Da100 are large multi-component campsites. On their respective site forms, 36Da99 is listed as Late Archaic and 36Da100 as a Late Woodland site.

Site 36Da52 is also listed as primarily an Archaic site, but some Woodland components were also recovered there. This site was recorded by the William Penn Memorial Museum in 1967 (now known as the State Museum of Pennsylvania) perhaps as part of Ira Smith's salvage excavation. It is unclear whether or not Site 36Da52 was destroyed during the construction of TMI-1 and TMI Unit 2.

In 1967, prior to construction of TMI-1 and TMI Unit 2, a cultural resource study was conducted by the Pennsylvania Historical and Museum Commission (PHMC) (AEC 1972). Five areas of the island were tested, and one multi-component site (36Da50) was selected as the most likely candidate to yield information about the island's cultural sequence. The site was excavated and yielded a rich inventory of lithic and ceramic information dating to the Early and Middle Woodland periods. The types and quantities of lithic and ceramic artifacts recovered suggests that Three Mile Island was intermittently occupied by small groups of Early and Middle Woodland peoples utilizing the area for hunting and fishing (Smith 1977). At the time, 36Da50 was the largest Early to Middle Woodland site excavated in the Lower Susquehanna River Valley of Pennsylvania. Previous research in the area had primarily focused on small campsites

and rock shelters. In total, eight different ceramic types were recovered from the island along with eight categories of projectile points, ten types of flake tools, and four classes of bifacials and cleavers (Smith 1977). This suggests that Three Mile Island was used for securing and processing food (Smith 1977). In total, more than 1,000 artifacts were recovered spanning from 4,000 B.C. to 1,000-plus A.D.

In 1987, a paper was presented by two archaeologists at the Mid Atlantic Archaeological Conference Annual Meeting in Lancaster Pennsylvania for archaeological work conducted at Three Mile Island. The paper defined the cultural occupations of the island based on examining artifacts gathered by local collectors, reviewing previous archaeological reports, and performing limited testing on the island. Research and fieldwork (completed in 1986) indicated that the earliest occupation of Three Mile Island was during the Early Archaic period. Additionally, Early, Middle, and Late Woodland periods are also well represented. The continuous use of the island is surprising because experts believed that Late Woodland sites are comparatively infrequent on islands. To date, no Paleo-Indian artifacts have been found. While Three Mile Island was used continuously over the last 12,000 years, much of the cultural data, stratigraphy, and features relating to prehistoric occupations remain to be investigated (AmerGen 2008).

In 1988, the Curator of Archaeology from the State Museum of Pennsylvania performed an excavation of an historical burial site (36Da101) discovered eroding out of the river bank by a TMI-1 employee (Warfel 1988). According to PHMC survey records, 36Da101 is a large site that borders the riverbank and contains both Late Archaic and Late Woodland period artifacts in addition to the historic artifacts recovered during Warfel's excavation. As previously discussed, the island was extensively farmed in the 18th and 19th centuries (Warfel 1988). Residents of the island built houses, barns, and other structures. Records verify that children were born and adults died on the island, so the likelihood of additional burials is high (Warfel 1988). Fragmentary remains were collected and analysis of the bones and artifacts determined the burial dates to be in the 1860s–1880s time period and the bones to have originated from an adult male aged 50-plus years (Warfel 1988). The remains were collected and later reburied in a location near the original burial site. Artifacts associated with the burial were donated to the State Museum of Pennsylvania (AmerGen2008).

Another archaeological survey was conducted in 1998 for a proposed fish passage to be located on the east side of Three Mile Island. Previous research indicated that site 36Da51 was located in the vicinity of the project. PHMC records for 36Da51 did not indicate site type or cultural affiliation. Test units from the survey yielded some lithic flakes, fire-cracked rock, two pottery shards, and some historic artifacts. Analyses of the materials recovered indicated that further testing was not warranted. The portion of site 36Da51 that would be impacted by the proposed fish ladder did not meet any of the criteria for listing on the National Register of Historic Places.

As noted earlier, during the walkover survey of Three Mile Island an additional historic site was identified. Remnants of an historic farmstead were found in the woods. This farmstead is a large complex complete with foundations for approximately 10 buildings (possibly a house, barns, and other outbuildings). There is also a standing silo made from ceramic bricks. Further examination of the silo revealed manufacturing information at the base of the structure indicating that it was a NATCO Imperishable Silo, patented by the National Fire Proofing Company of Pittsburgh, Pennsylvania. The National Fire Proofing Company was purportedly established in 1889;

Affected Environment

however, financial records put the date of establishment closer to 1902 (University of Melbourne Undated). NATCO's imperishable silo is constructed of curved, hollowed blocks in which the courses are staggered (University of Melbourne Undated). This dates the silo to the first quarter of the 20th century. As a result of this discovery, Exelon Generation submitted a Pennsylvania Archaeological Site Survey Form along with photographs to the PHMC and the site was assigned State number 36Da235.

Another potential historic site on Three Mile Island is TMI Unit 2. On March 28, 1979, TMI Unit 2 experienced a loss of coolant accident that resulted in a partial core meltdown, and is considered the nation's worst commercial nuclear accident (Walker 2004). Although the structure is under 40 years of age, it can be considered potentially eligible for listing on the National Register of Historic Places under Criterion A, as a site of exceptional importance. In 1999, a historical marker was placed on Pennsylvania State Highway 441, commemorating the 20th anniversary of the TMI Unit 2 accident (AmerGen 2008).

2.3 Related Federal and State Activities

The NRC staff reviewed the possibility that activities of other Federal agencies might impact the renewal of the operating license for TMI-1. Any such activity could result in cumulative environmental impacts and the possible need for a Federal agency to become a cooperating agency in the preparation of the TMI-1 supplemental EIS.

The NRC staff has determined that there are no Federal projects that would make it desirable for another Federal agency to become a cooperating agency in the preparation of the supplemental EIS. Federal facilities and National Parks within 50 mi (80 km) of TMI-1 are listed below. There are no known American Indian lands within 50 mi (80 km) of TMI-1.

- Fort Indiantown Gap Military Reservation, Annville (closed)
- Blue Marsh Lake (U.S. Army Corps of Engineers)
- New Cumberland General Depot (U.S. Military Reservation)
- Mechanicsburg Naval Ship Parts Control Center
- Letterkenny Army Depot
- Gettysburg National Military Park
- Eisenhower National Historic Site
- Fort Ritchie Raven Rock Site
- U.S. Army Chemical Center
- Appalachian National Scenic Trail (various areas)

NRC is required under Section 102(2)(c) of the National Environmental Policy Act of 1969 (NEPA) to consult with and obtain the comments of any Federal agency that has jurisdiction by law or special expertise with respect to any environmental impact involved. NRC has consulted with the Advisory Council on Historic Preservation and the U.S. Fish and Wildlife Service. Federal Agency consultation correspondence and comments on the supplemental EIS are presented in Appendix D.

2.4 References

- 10 CFR 20. *Code of Federal Regulations*, Title 10, *Energy*, Part 20, "Standards for Protection Against Radiation."
- 10 CFR 50. *Code of Federal Regulations*, Title 10, *Energy*, Part 50, "Domestic Licensing of Production and Utilization Facilities."
- 10 CFR 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, "Requirements for Renewal of Operating Licenses for Nuclear Power Plants."
- 10 CFR 61. *Code of Federal Regulations*, Title 10, *Energy*, Part 61, "Licensing Requirements for Land Disposal of Radioactive Waste."
- 10 CFR 71. *Code of Federal Regulations*, Title 10, *Energy*, Part 71, "Packaging and Transportation of Radioactive Material."
- 10 CFR 100. *Code of Federal Regulations*, Title 10, *Energy*, Part 100, "Reactor Site Criteria."
- 25 PA Code VII § 262. *Pennsylvania Code*, Title 25, *Environmental Protection*, Article VII, *Hazardous Waste Management*, Section 262a, "Standards Applicable to Generators of Hazardous Waste."
- 25 PA Code VIII. *Pennsylvania Code*, Title 25, *Environmental Protection*, Article VIII, *Municipal Waste*.
- 25 PA Code IX. *Pennsylvania Code*, Title 25, *Environmental Protection*, Article IX, *Residual Waste*.
- 40 CFR 81. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 81, "Designation of Areas for Air Quality Planning Purposes."
- 40 CFR 190. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 190, "Environmental Radiation Protection Standards for Nuclear Power Operations."
- 40 CFR Part 261. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 261, "Identification and Listing of Hazardous Waste."
- 40 CFR 262. *Code of Federal Regulations*. Title 40, *Protection of Environment*, Part 262, "Standards Applicable to Generators of Hazardous Waste."
- 40 CFR 266. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 266, "Storage, Treatment, Transportation, and Disposal of Mixed-Waste."
- 40 CFR Part 273. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 273, "Standards for Universal Waste Management."
- 72 FR 37346, U.S. Fish and Wildlife Service. "Endangered and threatened wildlife and plants; removing the bald eagle in the lower 48 States from the list of endangered and threatened wildlife." *Federal Register*: Volume 72, No. 130, pp. 37346–37372. July 9, 2007.
- Adovasio and Johnson (Adovasio, James and William C. Johnson). 1981. "The Appearance of Cultigens in the Upper Ohio Valley: A View from Meadowcroft Rockshelter." *Pennsylvania Archaeologist*. Vol. 51 (1-2): pp. 63-80.

Affected Environment

AEC (U.S. Atomic Energy Commission). 1972. *Final Environmental Statement related to the operation of Three Mile Island Nuclear Station, Units 1 and 2. Metropolitan Edison Company, et al. Docket Nos. 50-289 and 50-320.* Directorate of Licensing. December. Washington, D.C. ADAMS No. ML080090250.

Alliance for the Chesapeake Bay. 2007. "Zebra Mussels Found in Pennsylvania Lake on Cowanesque River Near NY." *Chesapeake Bay Journal*. (September 2007). Available URL: <http://www.bayjournal.com/article.cfm?article=3149> (accessed June 12, 2008). ADAMS No. ML082381094.

AmerGen (AmerGen Energy Company, LLC). 2004. *Three Mile Island 2003 Annual Report, Record of Well Pumpage and Water Levels. Susquehanna River Basin Commission Permit No. 19961102.* Middletown, PA. ADAMS No. ML082880148.

AmerGen (AmerGen Energy Company, LLC). 2004a. *Three Mile Island Nuclear Station Unit 1 and Unit 2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket Nos. 50-289 and 50-320. Radiological Environmental Monitoring Program Report, 1 January through 31 December 2003.* Middletown, PA. ADAMS No. ML041250580.

AmerGen (AmerGen Energy Company, LLC). 2004b. *Three Mile Island Nuclear Station Unit 1 and Unit 2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket Nos. 50-289 and 50-320. Combined 2003 Annual Radioactive Effluent Release Report.* Middletown, PA. ADAMS No. ML041180052.

AmerGen (AmerGen Energy Company, LLC). 2005. *Three Mile Island 2004 Annual Report, Record of Well Pumpage and Water Levels. Susquehanna River Basin Commission Permit No. 19961102.* Middletown, PA. ADAMS No. ML082880148.

AmerGen (AmerGen Energy Company, LLC). 2005a. *Three Mile Island Nuclear Station Unit 1 and Unit 2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket Nos. 50-289 and 50-320. Radiological Environmental Monitoring Program Report. 1 January through 31 December 2004.* Middletown, PA. ADAMS No. ML051260258.

AmerGen (AmerGen Energy Company, LLC). 2005b. *Three Mile Island Nuclear Station Unit 1 and Unit 2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket Nos. 50-289 and 50-320. Combined 2004 Annual Radioactive Effluent Release Report.* Middletown, PA. ADAMS No. ML051260269.

AmerGen (AmerGen Energy Company, LLC). 2006. *Annual Report on the Meteorological Monitoring Program at the Three Mile Island Generating Station 2006.* Middletown, PA. ADAMS No. ML082110253.

AmerGen (AmerGen Energy Company, LLC). 2006a. *Three Mile Island Nuclear Station Unit-1 and Unit-2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket Nos. 50-289 and 50-320. Updated Final Safety Analysis Report.* Middletown, PA. ADAMS No. ML080800161.

AmerGen (AmerGen Energy Company, LLC). 2006b. *Three Mile Island Nuclear Station Unit-1 and Unit-2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket*

Nos. 50-289 and 50-320. *Combined 2005 Annual Radioactive Effluent Release Report*. Middletown, PA. ADAMS No. ML061230244.

AmerGen (AmerGen Energy Company, LLC). 2006c. *Three Mile Island Nuclear Station Unit-1 and Unit-2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket Nos. 50-289 and 50-320. Radiological Environmental Monitoring Program Report, 1 January through 31 December 2005*. Middletown, PA. ADAMS No. ML061220487.

AmerGen (AmerGen Energy Company, LLC). 2006d. *Three Mile Island, Unit 1, Enclosure A – Post Audit Environmental Information – Question ENV-070, Monthly Report on the Meteorological Monitoring Program, March 2007 through End (Non-Proprietary Version)*. “Three Mile Island Nuclear Station State Only Operating Permit for Synthetic Minor Facility: State Only Permit No: 22-05029.” Pp. 275-315. ADAMS No. ML082110253.

AmerGen (AmerGen Energy Company, LLC). 2006e. *Three Mile Island 2005 Annual Report, Record of Well Pumpage and Water Levels. Susquehanna River Basin Commission Permit No. 19961102*. ADAMS No. ML082880148.

AmerGen (AmerGen Energy Company, LLC). 2007. *Three Mile Island Nuclear Station Units 1 and 2 Annual Radiological Environmental Operating Report, 1 January Through December 2006*, Appendix F, “Annual Radiological Ground Water Protection Program Report, 1 January Through December 2006.” April. Middletown, PA. ADAMS No. ML081980698.

AmerGen (AmerGen Energy Company, LLC). 2007a. *Three Mile Island Nuclear Station Unit 1 and Unit 2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket Nos. 50-289 and 50-320. Combined 2006 Annual Radioactive Effluent Release Report (ODCM Revision 25 Enclosed)*. Middletown, PA. ADAMS No. ML071290369.

AmerGen (AmerGen Energy Company, LLC). 2007b. *Three Mile Island Nuclear Station Unit 1 and Unit 2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket Nos. 50-289 and 50-320. Radiological Environmental Monitoring Program Report, 1 January through 31 December 2006*. Middletown, PA. ADAMS No. ML071290163.

AmerGen (AmerGen Energy Company, LLC). 2007c. “Automatic Temperature Monitoring Data for TMI-1 Intake Screen Pumphouse and Discharge Monitoring Pit.” Middletown, PA. ADAMS No. ML081980678.

AmerGen (AmerGen Energy Company, LLC). 2008. *Three Mile Island Nuclear Station, Unit 1, Applicant’s Environmental Report, License Renewal Operating Stage*. ADAMS Nos. ML080220255, ML080220257, ML080220261, and ML080220282.

AmerGen (AmerGen Energy Company, LLC). 2008a. *Three Mile Island Nuclear Station Unit 1 and Unit 2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket Nos. 50-289 and 50-320. Radiological Environmental Monitoring Program Report, 1 January through 31 December 2007*. Middletown, PA. ADAMS No. ML081300255.

AmerGen (AmerGen Energy Company, LLC). 2008b. *Three Mile Island Nuclear Station Unit 1 and Unit 2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket Nos. 50-289 and 50-320. Combined 2007 Annual Radioactive Effluent Release Report*. Middletown, PA. ADAMS No. ML081300410.

Affected Environment

AmerGen (AmerGen Energy Company, LLC). 2008c. *Three Mile Island Generating Station, Unit 1, License Renewal Application*. Kennett Square, PA. ADAMS No. ML080220207.

AmerGen (AmerGen Energy Company, LLC). 2008d. *Three Mile Island, Unit 1, Enclosure A - Post Audit Environmental Information – Index Through Audit Question ENV-070, Monthly Report on the Meteorological Monitoring Program, February 2007 (Non-Proprietary Version)*. June 10. ADAMS No. ML082110252.

Audubon Society. 2008. "Prothonotary Warbler." Available URL: <http://audubon2.org/watchlist/viewSpecies.jsp?id=165> (accessed June 4, 2008). ADAMS No. ML082880486.

Carr, K.W. 1998. "The Early Archaic Period in Pennsylvania." *Pennsylvania Archaeologist*. Vol. 68. Issue 2, pp. 42-69.

Center for Workforce Information and Analysis. 2008. "Pennsylvania Department of Labor and Industry, Harrisburg, Pennsylvania." Available URL: <http://www.paworkstats.state.pa.us> (accessed September 12, 2008). ADAMS No. ML082880507.

CBP (Chesapeake Bay Program). 2008. "American Shad Management and Restoration." Available URL: <http://www.chesapeakebay.net/americanshadmanagement.aspx?menuitem=14771> (accessed July 18, 2008). ADAMS No. ML082381098.

Clean Air Act. 42 U.S.C. 7401, et seq. *United States Code*, Title 42, *The Public Health and Welfare*, Chapter 85, "Air Pollution Prevention and Control."

Conestoga-Rovers (Conestoga-Rovers & Associates). 2006. *Hydrogeologic Investigation Report, Fleetwide Assessment, Three Mile Island Generating Station, Middletown, Pennsylvania*. September. ADAMS Nos. ML081980689, ML081980691, ML081980692.

Conestoga-Rovers (Conestoga-Rovers & Associates). 2007. *Estimated Mass Flux of Tritiated Groundwater to the Susquehanna River, Three Mile Island Generating Station, Middletown, Pennsylvania*. October. ADAMS No. ML081980693.

Cornell (Cornell Lab of Ornithology). 2003. "Peregrine Falcon." Available URL: http://www.birds.cornell.edu/AllAboutBirds/BirdGuide/Peregrine_Falcon_dtl.html (accessed June 6, 2008). Accessible at ML073300303.

Cowin, Verna. 1985. "The Woodland Period." A Comprehensive State Plan for the Conservation of Archaeological Resources. Volume II. pp. 185-193. Edited by P. Raber. Pennsylvania Historical and Museum Commission. Harrisburg, PA.

CWA (*Clean Water Act*; or *Federal Water Pollution Control Act*). 33 U.S.C. 1251 et seq.

Dauphin County (Dauphin County Planning Commission). 2008. *Dauphin County Comprehensive Plan*. Available URL: <http://www.tcrpc-pa.org/dccompplan.htm> (accessed September 4, 2008). ADAMS No. ML082880507.

DCNR (Pennsylvania Department of Conservation and Natural Resources). 2008. "Gettysburg-Newark Lowland Section Piedmont Province." Available URL:

<http://www.dcnr.state.pa.us/topogeo/map13/13gnls.aspx> (accessed on September 23, 2008). ADAMS No. ML082880546.

DCNR (Pennsylvania Department of Conservation and Natural Resources). 2008a. Letter from R. Bowen, Environmental Review Specials, Pennsylvania Department of Conservation and Natural Resources, to L. Lund, Branch Chief, Division of License Renewal, Nuclear Regulatory Commission. Subject: Pennsylvania Natural Diversity Inventory Review, PNDI Number 19605, Three Mile Island Unit 1 License Renewal Species of Special Concern, Dauphin & Lancaster Counties." May 2, 2008. ADAMS No. ML081300048.

Durlin, R.R. and W.P. Schaffstall. 2005. *Water Resources Data Pennsylvania Water Year 2004, Water-Data Report PA-04-2*. U.S. Geological Survey. May. New Cumberland, PA. ADAMS No. ML081980705.

EPA (U.S. Environmental Protection Agency). 1974. "Information on Levels of Environmental Noise Requisite to Protect Public Health and Welfare with an Adequate Margin of Safety." Report 550/9-74-004, Washington, D.C. Available URL: <http://www.nonoise.org/library/levels74/levels74.htm>. March. (See also "EPA Identifies Noise Levels Affecting Health and Welfare." September 21, 2007. Available URL: <http://www.epa.gov/history/topics/noise/01.htm>.) Accessed March 2, 2009.

EPA (U.S. Environmental Protection Agency). 2000. *RCRA, Superfund & EPCRA Hotline Training Module. Introduction to: RCRA Statutory Overview*. EPA530-5-99-063. February. Available URL: <http://www.epa.gov/osw/inforesources/pubs/hotline/training/enforc.pdf> (accessed August 28, 2008). ADAMS No. ML082880301.

EPA (U.S. Environmental Protection Agency). 2007. *Hazardous Waste Generators Regulations*. May. Available URL: <http://www.epa.gov/osw/hazard/downloads/tool.pdf> (accessed October 14, 2008). ADAMS No. ML082880301.

EPA (U.S. Environmental Protection Agency). 2007a. "Wastes – Laws and Regulations." Available URL: <http://www.epa.gov/osw/laws-regs/index.htm> (accessed August 28, 2008). ADAMS No. ML082880301.

EPA (U.S. Environmental Protection Agency). 2008. "Environmental Management Systems (EMS)." Available URL: <http://www.epa.gov/ems/index.html> (accessed August 28, 2008). ADAMS No. ML082880301.

EPA (U.S. Environmental Protection Agency). 2008a. "EPA EnviroFacts Warehouse – Facility Detail Report – AmerGen Energy Three Mile Island Nuclear Station." Available URL: http://oaspub.epa.gov/enviro/fii_query_dtl_disp_program_facility?pgm_sys_id_in=PAR000037861&pgm_sys_acrnm_in=RCRAINFO (accessed August 28, 2008). ADAMS No. ML082880301.

EPA (U.S. Environmental Protection Agency). 2008b. "Pollution Prevention Information Clearinghouse (PPIC)." Available URL: <http://www.epa.gov/oppt/ppic/> (accessed August 28, 2008). ADAMS No. ML082880301.

EPA (U.S. Environmental protection Agency). 2008c. "Local Drinking Water Information, Pennsylvania Drinking Water, Envirofacts Data on Pennsylvania, County Search – Dauphin and Lancaster Counties – April 15, 2008." Searchable database. Available URL:

Affected Environment

http://oaspub.epa.gov/enviro/sdw_form_v2.create_page?state_abbr=PA (accessed September 2008).

ESA (*Endangered Species Act*). 16 U.S.C. 1531, et seq.

Exelon (Exelon Corporation, Inc.). 2007. *TMI Radiological Groundwater Protection Program (RGPP) Sample Point Data and Standard Control Limits*. CY-TM-170-400. December 16.

Fike, J. 1999. *Terrestrial and Palustrine Plant Communities of Pennsylvania*. Pennsylvania Natural Diversity Inventory. Chapter 8: Herbaceous Wetlands. Pennsylvania Natural Diversity Inventory. Available URL: <http://www.dcnr.state.pa.us/wrcf/fikebook/21chapter8.pdf> (accessed June 3, 2008). ADAMS No. ML082880541.

FirstEnergy (FirstEnergy Forest Services). 2007. *First Energy Vegetation Management Specifications*. ADAMS No. ML082110252.

FirstEnergy (FirstEnergy Forest Services). 2008. *Vegetation Control with Herbicides*. ADAMS No. ML082110252.

Funk, R.E. (Funk). 1972. "Early Man in the Northeast and Late Glacial Environment." *Man in the Northeast*. Vol. 4, pp. 7-39.

FWS (U.S. Fish and Wildlife Service). 2008. Letter from D. Densmore, Supervisor, U.S. Fish and Wildlife Service, Pennsylvania Field Office, to L. Lund, Branch Chief, Division of License Renewal, Nuclear Regulatory Commission. Subject: Three Mile Island Nuclear Station, Unit 1, License Renewal Application Review. April 23, 2008. ADAMS No. ML081280307.

FWS (U.S. Fish and Wildlife Service). 2008a. "Osprey: *Pandion haliaetus*." Available URL: <http://www.fws.gov/chesapeakebay/osprey.html> (accessed May 15, 2009). Accessible at ML082880486.

Harman, W.N. and E. Underwood. 2008. *Survey of the Pearly Freshwater Mussels (Unionidae:Bivalvia) of the Susquehanna River in a reach between Exits 14 and 15 of Interstate 88, Oneonta, NY*. State University of New York, College at Oneonta. Available URL: <http://www.oneonta.edu/academics/biofld/PUBS/ANNUAL/2007/Susquehanna%20DOT%20mus sel%20report%20for%20BFS%20AR.pdf> (accessed July 22, 2008). ADAMS No. ML082381099.

Harrisburg Websites. Undated. "Dauphin County History." Available URL: http://www.harrisburgwebsites.com/Publications/Dauphin_County_History.htm (accessed on September 29, 2008). ADAMS No. ML082880526.

Hilty, J. 2006a. "Aunt Lucy." Available URL: http://www.illinoiswildflowers.info/woodland/plants/aunt_lucy.htm (accessed June 3, 2008). Accessible at ML082880486.

Hilty, J. 2006b. "Flat-Stemmed Spike Rush." Available URL: http://www.illinoiswildflowers.info/grasses/plants/fs_spikerush.htm (accessed June 3, 2008). Accessible at ML082880486.

Huber, Elaine. 1982. "Three Mile Island Had a Sometime Stormy Past." *Lancaster Sunday News*. (July 4, 1982). ADAMS No. ML082110252.

Ichthyological Associates, Inc. 1975. *An Ecological Study of the Susquehanna River Near the Three Mile Island Nuclear Station - Annual Report for 1974*. February. Etters, PA. ADAMS No. ML082381102.

Ichthyological Associates, Inc. 1976. *An Ecological Study of the Susquehanna River Near the Three Mile Island Nuclear Station - Annual Report for 1975*. February. Etters, PA. ADAMS No. ML082381103.

Ichthyological Associates, Inc. 1983. *An Ecological Study of the Susquehanna River Near the Three Mile Island Nuclear Station - Annual Report for 1982*. April. Etters, PA. ADAMS No. ML081980679.

Institute of Educational Science (IES). 2008. U.S. Department of Education. National Center for Educational Statistics. "College Opportunities Online Locator." Zip Code 17057. Available online at <http://nces.ed.gov/ipeds/cool/RefineSearch.aspx> (accessed September 9, 2008).

Johnson, J.H. and D.S. Dropkin. 1992. "Predation on Recently Released Larval American Shad in the Susquehanna River Basin." *North American Journal of Fisheries Management* 12(3):504-508. ADAMS No. ML082381104.

Kapsch, Robert J. 2004. *Canals*. W.W. Norton & Company. U.S. p. 310.

Kent et al. (Kent, Barry C., Ira F. Smith III, and Catherine McCann eds.) 1971. *Foundations of Pennsylvania Prehistory. Pennsylvania Historical and Museum Commission Anthropological Series, #1*. Harrisburg, PA.

Lancaster County (Lancaster County Planning Commission). 2006. "The Growth Management Element of The Comprehensive Plan for Lancaster County, Pennsylvania prepared by the Lancaster County Planning Commission and Lancaster County Growth Management Update Task Force." April. Available URL: www.co.lancaster.pa.us/planning/lib/planning/balance_full_report.pdf (accessed October 5, 2006). ADAMS No. ML082880507.

Londonderry Township. Undated. "Londonderry Township Historical Society." Available URL: <http://www.londonderry.pa.org/history.php> (accessed on September 30, 2008). ADAMS No. ML082880526.

Lebanon County. 2005. "Union Canal of Pennsylvania." Available URL: http://dsf.pacounties.org/lebanon/cwp/view.asp?A=3&QUESTION_ID=479797 (accessed on September 30, 2008). ADAMS No. ML082880526.

McNally, B. 2008. "Small Times on the Susquehanna". Available URL: <http://www.boats.com/news-reviews/articledetail.html?lid=2284> (accessed July 10, 2008). ADAMS No. ML082880347.

The Native Fish Conservancy. 2008. "Migratory Fish Restoration and Passage on the Susquehanna River." Available URL: http://www.nativefish.org/articles/Migratory_Fish_Restoration.php (accessed June 10, 2008). ADAMS No. ML082381108.

Affected Environment

NCDC (National Climate Data Center). 2008. Comparative Climatic Data. Available URL: <http://www.ncdc.noaa.gov/oa/climate/online/ccd/avgwind.html> (accessed June 10, 2008). ADAMS No. ML082880549.

NCDC (National Climate Data Center). 2008a. "Storm Events." Searchable database. Available URL: <http://www4.ncdc.noaa.gov/cgi-win/wwcgi.dll?wwevent~storms> (accessed June 12, 2008).

NCDC (National Climate Data Center). 2008b. "Storm Events: Dauphin County, PA most destructive tornado event." Available URL: <http://www4.ncdc.noaa.gov/cgi-win/wwcgi.dll?wwevent~ShowEvent~135093> (accessed June 12, 2008). ADAMS No. ML082880549.

NEPA (*National Environmental Policy Act of 1969*). 42 U.S.C. 4321, et seq.

NOAA (National Oceanic and Atmospheric Administration). Undated. "Guide to Essential Fish Habitat Designations in the Northeastern United States." Available URL: <http://www.nero.noaa.gov/hcd/est.htm#MARYLAND> (accessed June 19, 2008). ADAMS No. ML082380111.

NOAA (National Oceanic and Atmospheric Administration). 2007. "Lebanon County Tornado, Jul 7 14, 2004." Available URL: <http://www.erh.noaa.gov/ctp/features/2004/July14/Lebanon.php> (accessed May 15, 2009). ADAMS No. ML091350465.

Normandeau (Normandeau Associates, Inc.). 2007. *Summary of Environmental Studies Near the Three Mile Island Nuclear Station*. October. Drumore, PA. ADAMS No. ML081980680.

NRC (U.S. Nuclear Regulatory Commission). 1976. *NUREG-0112. Final Supplement to the Final Environmental Statement Related to the Operation of Three Mile Island Nuclear Station, Unit 2, Metropolitan Edison Company et al., Docket No. 50-320*. Office of Nuclear Reactor Regulation, Washington, D.C. December. ADAMS No. ML080090250.

NRC (U.S. Nuclear Regulatory Commission). 1988. *Issuance of Amendment No. 143 to Facility Operating License No. DPR-50 for the Three Mile Island Nuclear Station, Unit No. 1*. Washington, D.C. ADAMS No. ML003779786.

NRC (U.S. Nuclear Regulatory Commission). 1990. *Overview and Comparison of U.S Commercial Nuclear Power Plant, Nuclear Power Plant System Source*. NUREG/CR-5640. Washington, D.C.

NRC (U.S. Nuclear Regulatory Commission). 1996. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*. NUREG-1437, Volumes 1 and 2, Washington, D.C. ADAMS No. ML061770605.

NRC (U.S. Nuclear Regulatory Commission). 1999. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Main Report*, "Section 6.3 – Transportation, Table 9.1, Summary of findings on NEPA issues for license renewal of nuclear power plants, Final Report." NUREG-1437, Volume 1, Addendum 1, Washington, D.C.

PADEP (Pennsylvania Department of Environmental Protection). 2001. "Overview of EPA's Final Rule on Storage, Treatment, Transportation and Disposal of Mixed Waste." Available URL:

<http://www.dep.state.pa.us/dep/subject/advcoun/llrw/2001/OverviewEPAFinalRuleMixedWaste.pdf> (accessed July 15, 2008). ADAMS No. ML082880301.

PADEP (Pennsylvania Department of Environmental Protection). 2004. *Pennsylvania Air Quality Monitoring 2004 Annual Report*. Division of Air Quality Monitoring. Harrisburg, PA. Available URL: <http://www.dep.state.pa.us/dep/deputate/airwaste/aq/aqm/aqreport/2004aqreport.pdf> (accessed August 16, 2008). ADAMS No. ML082880549.

PADEP (Pennsylvania Department of Environmental Protection). 2008. "eMapPA." Searchable database. Available URL: <http://www.emappa.dep.state.pa.us/emappa/viewer.htm> (accessed October 14, 2008).

PADEP (Pennsylvania Department of Environmental Protection). 2008a. "Survey Information. Water Supply Data for Dauphin and Lancaster Counties." Searchable database. Available URL: www.drinkingwater.state.pa.us/dwrs/HTM/DEP_frm.html (accessed September 9, 2008).

PADEP (Pennsylvania Department of Environmental Protection). 2008b. "Zebra Mussel Found on Susquehanna River at Conowingo Dam in Maryland." November 24. Available URL: <http://www.ahs2.dep.state.pa.us/newsreleases/default.asp?ID=5364&varqueryTyp> (accessed March 18, 2009). ADAMS No. ML090770897.

PDE (Pennsylvania Department of Education). 2004. Map of Pennsylvania School Districts and Intermediate Unit 15. March. Available URL: http://www.dot.state.pa.us/Internet/Bureaus/pdPlanRes.nsf/infoBPR_Education_PA_Intermediate_unit (accessed September 9, 2008). ADAMS No. ML082880507.

PDE (Pennsylvania Department of Education). 2007a. "Public School Enrollments by County, LEA, School, Grade and Gender Workbook 2006-2007." Excel database. July 12. Available URL: <http://www.pde.state.pa.us/k12statistics/lib/k12statistics/0607PubEnrCtySchGraGen.xls>. (accessed September 9, 2008).

PDE (Pennsylvania Department of Education). 2007b. "Public, Private and Nonpublic Schools Enrollments 2006-07." August. Available URL: <http://www.pde.state.pa.us/k12statistics/cwp/view.asp?a=3&q=129090> (accessed September 9, 2008). ADAMS No. ML082880507.

PennDOT (Pennsylvania Department of Transportation). 2008. "2006 Traffic Volume Map – Dauphin County." Searchable database. Available URL: <http://www.dot.state.pa.us/Internet/Bureaus/pdPlanRes.nsf/infoBPRTrafficInfoTrafficVolumeMap> (accessed September 9, 2008). ADAMS No. ML082880507.

Pennsylvania Sea Grant. 2008. "Aquatic Invasive Species of Pennsylvania. Asiatic Clam." Available URL: <http://www.pserie.psu.edu/seagrant/ais/watershed/clam.htm> (accessed June 11, 2008). ADAMS No. ML082381162.

Pennsylvania Sea Grant. 2008a. "Aquatic Invasive Species of Pennsylvania. Zebra Mussel/Quagga Mussel." Available URL: <http://www.pserie.psu.edu/seagrant/ais/watershed/mussel.htm> (accessed June 11, 2008). ADAMS No. ML082381267.

Affected Environment

Pennsylvania Sea Grant. 2008b. "Pennsylvania Zebra and Quagga Mussel Monitoring Network." Available URL: <http://seagrant.psu.edu/zm/index.htm> (accessed July 22, 2008). ADAMS No. ML082381268.

Pennsylvania State Data Center. 2008. *The Pennsylvania Bulletin – Pennsylvania State Data Center; Pennsylvania Population Projections; Public Review* [38 Pa.B. 1415] [Saturday, March 22, 2008] "Pennsylvania Preliminary Population Projections: 2000–2030." February. Available URL: <http://www.pabulletin.com/secure/data/vol38/38-12/524.html> (accessed September 9, 2008). ADAMS No. ML082880507.

PFBC (Pennsylvania Fish and Boat Commission). Undated. *Commercial Shad Landings*. Available URL: <http://www.fish.state.pa.us/education/whereshaddata.pdf> (accessed June 10, 2008). ADAMS No. ML082381111.

PFBC (Pennsylvania Fish and Boat Commission). 2008. "Biologist Reports, Susquehanna River Smallmouth Bass, Lancaster/York County." Available URL: http://www.fish.state.pa.us/images/fisheries/afm/2006/6x11_13accomac.htm (accessed June 11, 2008). ADAMS No. ML082381114.

PFBC (Pennsylvania Fish and Boat Commission). 2008a. "Susquehanna River American Shad." Available URL: (http://www.fish.state.pa.us/shad_susq.htm) (accessed June 11, 2008). ADAMS No. ML082381115.

PFBC (Pennsylvania Fish and Boat Commission). 2008b. *PA Stream Sections that Support Natural Reproduction of Trout*. Available URL: http://www.fish.state.pa.us/trout_repro.pdf (accessed June 11, 2008). ADAMS No. ML082381116.

PFBC (Pennsylvania Fish and Boat Commission). 2008c. *Susquehanna River Drainage YOY Smallmouth Bass Disease Investigations 2005 and 2007*. Available URL: http://www.fish.state.pa.us/pafish/bass_black/meetings/fish_committee2007sep/mortality07_05.pdf?bcsi_scan_B666A1DE717DB577=0&bcsi_scan_filename=mortality07_05.pdf (accessed June 3, 2008). ADAMS No. ML082880420.

PFBC (Pennsylvania Fish and Boat Commission). 2008d. Andrew Shiels—Personal communications. July 22, 2008. ADAMS No. ML082381123.

PFBC (Pennsylvania Fish and Boat Commission). 2008e. Michael Hendricks—Personal communications. July 22, 2008. ADAMS No. ML082381123.

PFBC (Pennsylvania Fish and Boat Commission). 2008f. "Historical WW/CW Species Stocking by County." Available URL: http://pfbc.state.pa.us/pfbc_webgis/WWCWStockingDetails_historical.aspx (accessed July 21, 2008). ADAMS No. ML082381124.

PFBC (Pennsylvania Fish and Boat Commission). 2008g. "2008 Pennsylvania Fishing Summary, Summary of Fishing Regulations and Laws". Available URL: <http://www.fish.state.pa.us/fishpub/summary/z00complete.pdf> (accessed July 23, 2008). ADAMS No. ML082880450.

PFBC (Pennsylvania Fish and Boat Commission). 2008h. Letter from C. Urban, Chief, Natural Diversity Section, Pennsylvania Fish & Boat Commission, Bellefonte, Pennsylvania, to S.

Lopas, Nuclear Regulatory Commission, Rockville, Maryland. Subject: Species Impact Review (SIR) – Rare, Candidate, Threatened and Endangered Species, Three Mile Island Nuclear Station, Londonderry Township/Borough, Dauphin County, PA. June 3, 2008. ADAMS No. ML081610104.

PGA (Pennsylvania General Assembly). Undated. "Pennsylvania on the Eve of Colonization." Available URL: http://www.legis.state.pa.us/WU01/VC/visitor/info/pa_history/pa_history.htm (accessed on October 1, 2008). ADAMS No. ML082880526.

PGC (Pennsylvania Game Commission). 2006. "Peregrine Falcon." Available URL: <http://www.pgc.state.pa.us/pgc/cwp/view.asp?a=486&q=160961> (accessed June 6, 2008). Accessible at ML073300495.

PGC (Pennsylvania Game Commission). 2008. Letter from J. Leigey, Division of Environmental Planning and Habitat Protection, Bureau of Wildlife Habitat Management, to L. Lund, Branch Chief, Division of License Renewal, Nuclear Regulatory Commission. Subject: State-Protected Bird and Mammal Species Review, Three Mile Island Nuclear Station License Renewal Application, Londonderry Township, Dauphin County, PA. May 14, 2008. ADAMS No. ML081500671.

PHMC (Pennsylvania Historical and Museum Commission). Undated-a. "Pennsylvania on the Eve of Colonization." Available URL: <http://www.phmc.state.pa.us/bah/pahist/colony.asp?secid=31> (accessed on October 1, 2008). ADAMS No. ML082880526.

PHMC (Pennsylvania Historical and Museum Commission). Undated-b. "Harrisburg: Pennsylvania's Capital City." Available URL: <http://www.phmc.state.pa.us/ppet/harrisburg/page1.asp?secid=31> (accessed on September 29, 2008). ADAMS No. ML082880526.

PNHP (Pennsylvania Natural Heritage Program). 2008. "State Species List, Update June 2008." Available URL: <http://www.naturalheritage.state.pa.us/Homepage.aspx> (accessed July 14, 2008). ADAMS No. ML082381127.

PNHP (Pennsylvania Natural Heritage Program). 2008a. "Ellisia; waterpod (*Ellizia nycetelea*)." Available URL: <http://www.naturalheritage.state.pa.us/factsheets/14002.pdf> (accessed June 3, 2008). Accessible at ML082880486.

PNHP (Pennsylvania Natural Heritage Program). 2008b. "Short's Sedge (*Carex shortiana*)." Available URL: <http://www.naturalheritage.state.pa.us/factsheets/15124.pdf> (accessed June 3, 2008). Accessible at ML082880486.

Raber (Raber, Paul. ed.). 1985. *A Comprehensive State Plan for the Conservation of Archaeological Resources*. Vol. II. Pennsylvania Historical and Museum Commission. Harrisburg, PA.

RCRA (Resource Conservation and Recovery Act). 40 CFR Part 239, et seq.

RMC (RMC Environmental Services). 1991. *An Ecological Study of the Susquehanna River Near The Three Mile Island Nuclear Station, Annual Report for 1990*. March. Drumore, PA. ADAMS No. ML081980683.

Affected Environment

Sadzinski, B. and Tony Jarzynski. Undated. "Shad School." Maryland Department of Natural Resources. Available URL: <http://dnr.md.gov/fisheries/education/shadschool.html> (accessed June 10, 2008). ADAMS No. ML082381161.

Smith III, Ira F. (Smith). 1977. *Early and Middle Woodland Campsites on Three Mile Island, Dauphin County, Pennsylvania*. Pennsylvania Historical and Museum Commission and Metropolitan Edison Company, Three Mile Island Nuclear Generating Station Project. Harrisburg, PA. January. Non-public reference per 37 Pa. C.S.A. § 506(c) and consultation with Pennsylvania Historical and Museum Commission.

SRBC (Susquehanna River Basin Commission). 1995. *GPU Nuclear Corporation. Three Mile Island Nuclear Station Unit 1, Application 199550302*. March. Harrisburg, PA. ADAMS No. ML081980711.

SRBC (Susquehanna River Basin Commission). 1996. Unpublished data. ADAMS No. ML082381269.

SRBC (Susquehanna River Basin Commission). 1999. *GPU Nuclear, Inc. Application 19961102 (Revised)*. January. Harrisburg, PA. ADAMS No. ML081980709.

SRBC (Susquehanna River Basin Commission). 2005. Unpublished data. ADAMS No. ML082381269.

SRBC (Susquehanna River Basin Commission). 2006. *Susquehanna Large River Assessment Project. Publication 245*. August. ADAMS No. ML082381271.

SRBC (Susquehanna River Basin Commission). 2006a. *Lower Susquehanna Subbasin Survey: A Water Quality and Biological Assessment, June – November 2005. Publication 247*. September. ADAMS No. ML082381273.

SRBC (Susquehanna River Basin Commission). 2008. Susan Buda—Personal communications. ADAMS No. ML082381269.

USCB (U.S. Census Bureau). 2008. "American FactFinder, American Community Survey of Dauphin and Lancaster Counties, Data Profile Highlights. Housing Characteristics for 2000 and 2006." Available URL: <http://factfinder.census.gov> (accessed August 16, 2008).

USCB (U.S. Census Bureau). 2008a. "Decennial Census 2000 Data, American FactFinder, American Community Survey of Dauphin and Lancaster Counties, Data Profile Highlights. Selected Economic Characteristics: 2006." Searchable database. Available URL: <http://factfinder.census.gov> (accessed September 12, 2008).

USCB (U.S. Census Bureau). 2008b. "State and County QuickFacts, 2006 Data of Dauphin and Lancaster Counties." Searchable database. Available URL: <http://quickfacts.census.gov> (accessed September 5, 2008).

USDA (U.S. Department of Agriculture). 2008. "2002 Census of Agriculture." Available URL: <http://www.nass.usda.gov/census/census02/volume1/pa/index2.htm> (accessed September 12, 2008). ADAMS No. ML082880507.

USDOJ (U.S. Department of the Interior). 2008. "Index by State and County, National Register Information System." Available URL: <http://www.nr.nps.gov/nrloc1.htm> (accessed on September 23, 2008). ADAMS No. ML082880722.

USGS (U.S. Geological Survey). Undated. "Biological and Ecotoxicological Characteristics of Terrestrial Vertebrate Species Residing in Estuaries. Osprey." Available URL: <http://www.pwrc.usgs.gov/bioeco/osprey.htm> (accessed on May 15, 2009). ADAMS No. ML091350285.

USGS (U.S. Geological Survey). 2008. "Temperature, Dissolved-Oxygen, and Nutrient Monitoring in the Susquehanna River – Summer 2008. A Project Proposal." Available URL: http://www.fish.state.pa.us/pafish/bass_black/meetings/susq2008project_proposal.pdf (accessed June 10, 2008). ADAMS No. ML082381274.

Walker, J. Samuel, *Three Mile Island: A Nuclear Crisis in Historical Perspective*, Berkeley: University of California Press, 2004.

Warfel, Stephen G. 1988. *A Report on the Discovery of a Human Skeleton at Three Mile Island, Dauphin County, Pennsylvania*. The State Museum of Pennsylvania. Harrisburg, PA. (March 21, 1988). Non-public reference per 37 Pa. C.S.A. § 506(c) and consultation with Pennsylvania Historical and Museum Commission.

York Daily Record. 2009. "TMI Project Makes Ducks Feel at Home." March 2. Available URL: http://ydr.inyork.com/ci_11814515?source=most_emailed (accessed March 18, 2009). ADAMS No. ML090771036.

York Haven Power Company. 2008. Unpublished data. June. ADAMS No. ML082880482.

3.0 ENVIRONMENTAL IMPACTS OF REFURBISHMENT

Facility owners or operators may need to undertake or, for economic or safety reasons, may choose to perform refurbishment activities in anticipation of license renewal or during the license renewal term. The major refurbishment class of activities characterized in the generic environmental impact statement (GEIS) (NRC 1996, 1999) is intended to encompass actions that typically take place only once in the life of a nuclear plant, if at all. Examples of these activities include, but are not limited to, replacement of boiling-water reactor recirculation piping and pressurized-water reactor steam generators. As noted in the GEIS, refurbishment activities could result in environmental impacts beyond those that occur during normal plant operations. For issues that meet Category 1 criteria, no additional plant-specific analysis is required in this supplemental environmental impact statement (EIS) unless new and significant information is identified. Category 2 issues are those that do not meet criteria for Category 1 and, therefore, additional plant-specific review of these issues is required. Refurbishment activities may affect a variety of environmental issues as listed in Table 3-1 below.

Table 3-1. Issues Related to Refurbishment at TMI-1

Issues	Category
<i>Surface Water Quality, Hydrology, and Use</i>	
Impacts of refurbishment on surface water quality	1
Impacts of refurbishment on surface water use	1
<i>Aquatic Ecology</i>	
Refurbishment	1
<i>Terrestrial Resources</i>	
Refurbishment impacts	2
<i>Threatened and Endangered Species</i>	
Threatened and Endangered Species	2
<i>Ground Water Use and Quality</i>	
Impacts of refurbishment on ground water use and quality	1
<i>Air Quality</i>	
Air quality during refurbishment (nonattainment and maintenance areas)	2
<i>Land Use</i>	
Onsite land use	1

Environmental Impacts of Refurbishment

Table 3-1 (continued). Issues Related to Refurbishment at TMI-1

<i>Human Health</i>	
Radiation exposures to the public during refurbishment	1
Occupational radiation exposures during refurbishment	1
<i>Socioeconomics</i>	
Public Services: Public Safety, Social Services, and Tourism and Recreation	1
Aesthetic Impacts (refurbishment)	1
Housing Impacts	2
Public Services: Education (refurbishment)	2
Public Services: Public Utilities	2
Offsite land use (refurbishment)	2
Public Services: Transportation	2
Historic and Archaeological Resources	2
<i>Environmental Justice</i>	
Environmental Justice	Uncategorized

Exelon Generation Company, LLC (Exelon Generation) plans to replace the two steam generators at Three Mile Island Nuclear Station, Unit 1 (TMI-1), with new, once-through, enhanced steam generators. As such, Exelon Generation and the NRC have analyzed steam generator replacement as a refurbishment activity, pursuant to Title 10, Section 51.53(c)(3)(ii), of the *Code of Federal Regulations* (10 CFR 51.53(c)(3)(ii)).

3.1 Refurbishment Activities at TMI-1

Steam generator replacement activities will take approximately 70 days to complete and will occur sometime between the refueling outage scheduled for October 2009 and the expiration of the original license period in April 2014. The original TMI-1 steam generators contain tubing made of alloy 600MA, which can degrade over time because of corrosion and mechanical stress from normal plant operation. Exelon Generation determined that both of the steam generators at TMI-1 are affected by degradation and should be replaced with new steam generators fitted with tubing made of alloy 690TT, which is more resistant to stress-corrosion cracking. Exelon Generation will also replace the hot-leg elbows, portions of the piping, and all existing steam generator insulation. Exelon Generation indicated that the steam generator refurbishment will

allow TMI-1 to operate safely throughout the period of license extension and will increase the steam generator blowdown system capacity (AmerGen 2008).

The replacement steam generators will be manufactured in France and transported to the TMI-1 site. Transportation of these large components (each steam generator weighs approximately 500 tons [454 metric tons]) will be by a combination of boat, barge, rail, and road (AmerGen 2008). The steam generators will be transferred to land at Port Deposit, Maryland. Preliminary bathymetry studies have provided reasonable assurance that dredging in the Susquehanna River will not be required to accommodate the transfer at that location (NRC 2008).

The route from Port Deposit to the TMI-1 site has been identified by Exelon Generation's steam generator vendor, and has preliminary approval from the Maryland State Highway Administration and the Pennsylvania Department of Transportation, pending final approval of engineering plans and environmental permitting. The steam generator route will encompass 13 miles (mi) (21 kilometers [km]) of Maryland roads and 62 mi (100 km) of Pennsylvania roads, including 21 stream crossings in Maryland and 29 stream crossings in Pennsylvania. Some bridges can support the weight of the steam generators and will require no modification, however, some bridges will require modifications (such as support beams or bracing) or overbridges, which are steel plates that span a length greater than the bridge to provide a deck for the transporters to drive over. Some bridges may need to be avoided entirely by constructing a temporary bridge bypass. Three bridges in Pennsylvania will require modifications, and at least two, and possibly four, temporary bridge by-passes will be constructed over Pequea Creek and Chicques Creek, and Conowingo Creek and Conoy Creek. Temporary stream bypasses will be removed after the transporters have crossed them, and the area will be returned to its original condition.

For transportation within the United States, Exelon Generation (or its vendor) will be required to meet all Federal, State, and local requirements that may be applicable to the following activities: dredge or fill activities performed in waterways as related to bridge modifications or bridge bypasses; temporary or permanent removal of route interferences (such as narrow tunnels and low-hanging overhead wires); and movement of wide or heavy loads over rail and roadways.

The following list details environmental permits and consultations that are required for steam generator transportation from Port Deposit to TMI-1. These permits and consultations are in addition to engineering approvals and permits required and issued by the Maryland State Highway Administration and the Pennsylvania Department of Transportation.

- Joint Permit Application – Engineering plans, stream and wetland water and hydrology impacts, hydraulic impact calculations; approved by the Pennsylvania Department of Environmental Protection (PADEP) and the U.S. Army Corps of Engineers (USACE). (Approval of the joint permit requires documentation of consultation with the State resource agencies described below.)
- Consultation with the Pennsylvania Historic Museum Commission (PHMC) – Determination of No Adverse Impact to Historic Resources (see PHMC 2009).
- Consultation with Pennsylvania Fish and Boat Commission (PFBC) – Stream impact assessment and threatened and endangered species impacts.
- Consultation with Pennsylvania Game Commission (PGC) – threatened and endangered species impacts.

Environmental Impacts of Refurbishment

- Consultation with Pennsylvania Department of Conservation and Natural Resources (DCNR) – threatened and endangered species impacts.
- Coordination letters where environmental studies will occur in Londonderry Township, Conoy Township, Marietta Borough, East Donegal Township, Manor Township, Pequea Township, Providence Township, Fulton Township, Little Britian Township, and West Nottingham Township.
- Erosion and Sediment Control Plans – Approved by Maryland Department of the Environment, Lancaster County, and Dauphin County.
- National Pollutant Discharge Elimination System Permit – Permit will address over night pullout locations, and must be approved by Maryland Department of the Environment, Lancaster County, and Dauphin County.

Once onsite, the steam generators will be moved via a heavy-duty, self-propelled modular transporter to a temporary, open-air, storage area that will be created without the need for ground disturbance. To permanently store the original steam generators after removal, a 5000-square-foot (ft²) (465 square meters [m²]) steam generator storage building will be constructed on the power block within the flood protection dike. The building will be approximately 90-ft-long by 50-ft-wide (27-m-long by 17-m-wide) and 30-ft-high (9 m). Design specifications include a watertight roof membrane and reinforced concrete thick enough to provide radiological shielding to ensure that dose rates will remain within the limits set in 10 CFR Part 20, “Standards for Protection Against Radiation” (AmerGen 2008).

The steam generator storage facility will be the only permanent structure built to support the refurbishment project. Temporary facilities will be used for offices, fabrication and welding activities, and laydown areas; however, the 4500-square-ft (418 m²) fabrication/weld test shop will have a permanent concrete slab, which will remain after the building is removed. Exelon Generation estimates that the total area to be disturbed for refurbishment activities will be less than 10 acres (ac) (4 hectares [ha]), and disturbance will all take place on the power block, which is previously disturbed property (AmerGen 2008).

To remove the old steam generators and install the new ones, a 26 ft by 25 ft (8 m by 7.6 m) opening will be created in the 3.5-foot thick (1-m-thick), reinforced concrete containment building by hydrodemolition (high-pressure water) and other mechanical methods. The process of creating this opening in the containment includes detensioning and removing tendons, removing concrete, cutting rebar, and cutting and removing a section of the steel liner. The original steam generators will be drained and cut away from the piping, and penetrations and openings will be welded closed. Loose radiological contamination will be removed, and a coating will be applied to the exterior of the original generators to seal any residual contamination in place (AmerGen 2008).

3.2 Environmental Impacts of Refurbishment

The following sections discuss the Category 2 issues associated with refurbishment activities at TMI-1. Any environmental impacts from refurbishment will be in addition to those associated with continued operation of TMI-1 for the period of license renewal; Chapter 4 of this report

discusses those issues.

3.2.1 Terrestrial Resources – Refurbishment Impacts

Section 2.2.6 of this supplemental EIS describes the terrestrial resources on and in the vicinity of the TMI-1 site. Section 2.1.5 describes the transmission line right-of-ways (ROWs). For purposes of this analysis, Sections 2.1.5 and 2.2.6 describe the geographic area considered in this evaluation.

The majority of steam generator replacement activities for TMI-1 will take place on existing facility grounds at the TMI-1 site. The replacement project will require laydown areas, a permanent holding facility for the old steam generators, and several temporary buildings to support the steam generator replacement activities. All new, permanent structures will be constructed on previously disturbed land. Temporary and permanent facilities will use less than 10 ac (4 ha) of land. Some minimal, short-term noise impacts from construction may occur. Exelon Generation will need to obtain all required State and Federal permits for construction of the facilities associated with refurbishment (AmerGen 2008).

The new steam generators will be delivered to TMI-1 from Port Deposit, Maryland, and will travel over land via flatbed vehicles. The route identified by Exelon Generation's steam generator vendor has preliminary approval from the Maryland State Highway Administration and the Pennsylvania Department of Transportation, pending final approval of engineering plans and environmental permitting. As discussed above, some bridges will require modifications such as steel support beams, some bridges will require no modification, and other bridges will be avoided entirely. Exelon Generation has identified at least three bridges in Pennsylvania that will require modification, and at least two temporary bridge by-passes will be constructed.

Temporary bridge by-passes will be removed after the transporters have crossed them, and the area will be returned to its original condition. Additional activities likely to occur during transport of the steam generator include increasing the height of telephone and electric power poles and removal and relocation of traffic signals along the roadways to allow for clearance of the steam generators. Impacts to terrestrial resources from these activities are expected to be negligible. Exelon Generation's steam generator vendor, AREVA NP, Inc. (AREVA), will repair and restore the transportation route to its original condition after transportation is complete.

On the basis of the information from the staff's review of Exelon Generation's environmental report for the TMI-1 proposed license renewal, the staff's site visit, the scoping process, comments on the draft supplemental EIS, and the evaluation of other reports and information, impacts to terrestrial resources during the proposed steam generator replacement will be SMALL. Mitigation measures that could reduce impacts to the terrestrial environment during construction of the onsite permanent storage building and temporary bridge by-passes include installing silt fences to minimize sediment transport, the use of best management practices, and the restoration of cleared land remaining after completion of construction. These mitigation measures could reduce impacts by reducing erosion and minimizing the movement of sediment, nutrients, and pollutants to surface and ground water resources.

Environmental Impacts of Refurbishment

3.2.2 Threatened and Endangered Species

3.2.2.1 Terrestrial Species

As discussed in Section 2.2.7 of this report, State and Federal agencies have recognized two Federally listed and 11 State-listed threatened, endangered, or special concern terrestrial species as occurring in the vicinity of the TMI-1 site and its associated transmission line ROWs. Additional facilities associated with refurbishment are not likely to exceed 10 ac (4 ha) in total land use; therefore no additional impacts to threatened and endangered species within the TMI-1 site and its associated transmission line ROWs are expected (AmerGen 2008). The steam generators will be transported over land from Port Deposit to the TMI-1 site, traveling 13 mi (21 km) of Maryland roads and 62 mi (100 km) of Pennsylvania Roads. Activities such as constructing bridge modifications and by-passes, and removing road obstructions are not likely to have additional impacts on the threatened or endangered species because they will be confined to previously developed land. However, as a condition of their USACE and PADEP joint permit for waterway work, AREVA must consult with PGC and DCNR regarding potential impacts to threatened and endangered terrestrial species in the vicinity of this work.

On the basis of information from the staff's review of Exelon Generation's environmental report for the TMI-1 proposed license renewal (AmerGen 2008), the staff's site visit, the scoping process, comments received on the draft supplemental EIS, and the evaluation of other reports and information, impacts to threatened or endangered terrestrial species during the proposed steam generator replacement will be SMALL. Mitigation measures will be similar to those used to minimize impacts to terrestrial resources.

3.2.2.2 Aquatic Species

As stated in Section 3.2.1, the implementation of best management practices, such as installing silt fences, during onsite refurbishment activities will mitigate the impact of sediment-laden runoff to surface waters and aquatic species. Water used during hydrodemolition of the containment building will be treated and monitored prior to discharge to the Susquehanna River. As such, refurbishment activities at the TMI-1 site will likely have a SMALL impact on Federally and State-listed threatened, endangered, or special concern aquatic species.

Section 3.1 notes that the path of delivery of the steam generators for the 75 mi (121 km) trip from Port Deposit, Maryland, to the TMI-1 site in Pennsylvania includes 21 stream crossings in Maryland and 29 stream crossings in Pennsylvania. It also includes the construction of 2–4 temporary bridge by-passes in Pennsylvania. Some instream work may be required for construction of the bridge by-passes, which can potentially disrupt various lifecycles of Federally and State-listed threatened, endangered, or special concern aquatic species.

AREVA has indicated that no anadromous fish are present at bridge by-pass locations, and that they are coordinating with the PFBC, DCNR, and PGC to determine if construction of temporary bridge by-passes could impact threatened or endangered aquatic species or their critical habitats. AREVA will be required to comply with any special conditions for protection of threatened and endangered species that may be contained in a joint permit for waterway construction work from the PADEP and USACE. Approval of the joint permit is predicated on the

State resource agency consultations described above. Any potential impacts to threatened or endangered aquatic species would need to be mitigated prior to approval of the joint permit.

Because the bridge by-passes are temporary, and AREVA is required to comply with Federal and State permits will likely include best management practices and mitigation for any impacts to threatened and endangered aquatic species, instream work related to bridge modifications or bridge by-passes along the steam generator transport route will likely have a SMALL impact on Federally or State-listed threatened, endangered, or special concern aquatic species.

3.2.3 Air Quality During Refurbishment (Non-Attainment and Maintenance Areas)

Air quality during refurbishment (nonattainment and maintenance areas) is a Category 2 issue. Table B-1 of Appendix A to Subpart B, "Environmental Effect of Renewing the Operating License of a Nuclear Power Plant," of 10 CFR Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions," notes the following:

- 1 Air quality impacts from plant refurbishment associated with license renewal are
- 2 expected to be small. However, vehicle exhaust emissions could be cause for concern at
- 3 locations in or near nonattainment or maintenance areas. The significance of the
- 4 potential impact cannot be determined without considering the compliance statues of
- 5 each site and the numbers of workers expected to be employed during the outage.

Specifically, 10 CFR 51.53(c)(3)(ii)(F) requires the following:

- 6 If the applicant's plant is located in or near a nonattainment or maintenance area, an
- 7 assessment of vehicle exhaust emissions anticipated at the time of peak refurbishment
- 8 work force must be provided in accordance with the Clean Air Act as amended.

The GEIS states the following:

The 1990 Clean Air Act amendments include a provision that no federal agency shall support any activity that does not conform to a state implementation plan designed to achieve the National Ambient Air Quality Standards (NAAQS) for criteria pollutants (sulfur dioxide, nitrogen dioxide, carbon monoxide, ozone, lead, and particulate matter less than 10 µm in diameter). On November 30, 1993, the U.S. Environmental Protection Agency (EPA) issued a final rule (58 FR 63214) implementing the new statutory requirements, effective January 31, 1994. The final rule requires that federal agencies prepare a written conformity analysis and determination for each pollutant where the total of direct and indirect emissions caused by proposed federal action would exceed established threshold emission levels in a nonattainment⁴ or maintenance area⁵.

Exelon Generation is planning to replace the two TMI-1 steam generators with enhanced once-through steam generators. Exelon Generation stated that an additional 900 temporary employees will be needed for the duration of the project, which is estimated to be 70 days

⁴ An area is designated "nonattainment" for a criteria pollutant if it does not meet the National Ambient Air Quality Standard (NAAQS) for the pollutant.

⁵ A maintenance area has been redesignated by a State from nonattainment to attainment; the State must submit to EPA a plan for maintaining the NAAQS as a revision to its State Implementation Plan.

Environmental Impacts of Refurbishment

(AmerGen 2008). Exelon Generation and their steam generator vendor have determined the steam generator route from Port Deposit, Maryland, to the TMI-1 site. The steam generators will travel through Cecil County, Maryland, and Lancaster and Dauphin Counties in Pennsylvania.

During steam generator replacement project activities at the TMI-1 site some minor and short-duration air quality impacts are expected to occur. The main sources of these air quality impacts will be fugitive dust from construction activities associated with the project and exhaust emissions from the motorized equipment and vehicles of workers.

The majority of the refurbishment activities will be performed inside existing buildings and will not cause additional atmospheric emissions. However, a permanent steam generator building and several temporary facilities will be constructed and some land will be used for laydown areas. During construction activities, some minor air quality impacts are expected to occur as a result of equipment emissions and fugitive dust from the operation of earth-moving and material-handling equipment. The small size of disturbed area and Exelon Generation's commitment to use best management practices, such as watering, silt fences, covering soil piles, and hydrodemolition, will minimize the amount of fugitive dust generated during operation of earth-moving and debris-hauling equipment.

Refurbishment activities are known to cause localized temporary increases in atmospheric concentrations of nitrogen oxides (NO_x), carbon monoxide, sulfur dioxide (SO₂), volatile organic compounds (VOCs), ammonia, and particulate matter (PM₁₀ and PM_{2.5}) as a result of exhaust emissions from workers' vehicles, diesel generators, and construction equipment. Federal agencies are prohibited from issuing a license for any activity that does not conform to an applicable implementation plan (40 CFR Part 51, "Requirements for Preparation, Adoption, and Submittal of Implementation Plans," and 40 CFR Part 93, "Determining Conformity of Federal Actions to State or Federal Implementation Plans"). TMI-1 is required to show conformity to the applicable Pennsylvania State Implementation Plans by analyzing vehicle exhaust emissions that will occur during the steam generator replacement project.

Exelon Generation stated, and the NRC staff has confirmed, that Cecil County, MD is in attainment for all criteria pollutants. Dauphin County and Lancaster County are designated as 8-hour ozone maintenance and particulate matter (PM_{2.5}) non-attainment areas. Using an EPA-approved screening model, Exelon Generation estimated the impacts of direct and indirect ozone and particulate emissions related to refurbishment on air quality in the nonattainment areas. The results of model calculations indicate that the emissions associated with the refurbishment activities at TMI-1 will conform to the Pennsylvania State Implementation Plans for the nonattainment areas (72 FR 40749).

PM_{2.5} emissions from mobile sources are generated from three general processes—(1) direct emissions from the tailpipes of cars, trucks, and other onroad vehicles, (2) reentrainment from materials found on the roadway (typically known as fugitive dust), and (3) secondary formation from precursor emissions such as SO₂, NO_x, VOCs and ammonia. EPA requires that PM_{2.5} conformity assessments consider NO_x and SO₂ emissions, however, VOC and ammonia emissions need only be considered if they are significant. No such determination has been made for Dauphin and Lancaster Counties.

Exelon Generation performed a preliminary screening analysis (using an EPA-approved model) of the emissions during the construction and outage stages of the steam generator replacement project for a period of 70 days.

Exelon Generation estimated total annual emissions of NO_x during the construction stage to be 21.27 tons per year (ton/yr), which is 0.16 percent of the total 2001 Dauphin County emissions and 21.27 percent of the EPA threshold level for this PM_{2.5} precursor. Total NO_x emissions during the outage stage were estimated to be 8.34 tons/yr, which is 0.06 percent of the total 2001 Dauphin County emissions and 8.34 percent of the EPA threshold level (AmerGen 2008a).

Total annual emissions of SO₂ during the construction stage were estimated to be 0.59 tons/yr, which is 0.01 percent of the total 2001 Dauphin County emissions. During the outage stage, total SO₂ emissions were estimated to be 0.12 tons/yr, which is less than 1 percent of the total 2001 Dauphin County emissions and 0.12 percent of the EPA threshold level (AmerGen 2008a).

Exelon Generation estimated total annual emissions of PM_{2.5} during the construction stage to be 1.5 tons/yr, which is 0.06 percent of the total 2001 Dauphin County emissions and 1.5 percent of the EPA threshold level. During the outage stage, total PM_{2.5} emissions were estimated to be 0.53 tons/yr, which is 0.02 percent of the total 2001 Dauphin County emissions and 0.53 percent of the EPA threshold level (AmerGen 2008a).

Dauphin County is part of the Harrisburg-Lebanon-Carlisle 8-hour ozone attainment area (basic maintenance area). Ground-level ozone is formed when NO_x and VOCs react in the presence of heat and sunlight. Exelon Generation estimated total annual emissions of VOCs during the construction stage to be 2.78 tons/yr, which is 0.02 percent of the total 2001 Dauphin County emissions and 5.55 percent of the EPA threshold level. During the outage stage, total VOC emissions were estimated to be 4.04 tons/yr, which is 0.03 percent of the total 2001 Dauphin County emissions and 8.09 percent of the EPA threshold level (AmerGen 2008a).

Exelon Generation is in the process of obtaining all applicable permits and approvals from Maryland and Pennsylvania State and local authorities. The transportation portion of the steam generator replacement project at TMI-1 would cause short term increases in emissions, which would not significantly affect Cecil, Dauphin and Lancaster counties' air quality. Emissions from the transportation of the steam generators would remain below EPA threshold levels. The results of the model calculations indicate that the emissions associated with the proposed action conform to the implementation plans for the nonattainment areas. Total direct and indirect emissions resulting from the replacement of the two TMI-1 steam generators are not expected to exceed emission budgets specified in the Pennsylvania State implementation plans and rates, established by the EPA, for nonattainment and maintenance areas as described in 40 CFR Part 51. On this basis, the NRC staff concludes that the impact of vehicle exhaust emissions during the steam generator replacement project will be SMALL. The NRC staff acknowledges that the applicant will use best management practices that could mitigate potential air quality impacts resulting from the TMI-1 steam generator replacement project. Additionally, the NRC staff also identified the use of staggered workforce shift changes to reduce the number of vehicles on the road at any one given time.

Environmental Impacts of Refurbishment

1 3.2.4 Housing Impacts

Housing impacts during refurbishment is a Category 2 issue. Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, notes the following:

Housing impacts are expected to be of small significance at plants located in a medium or high population area and not in an area where growth control measure that limit housing development are in effect. Moderate or large housing impacts of the workforce associated with refurbishment may be associated with plants located in sparsely populated areas or in areas with growth control measures that limit housing development.

Exelon Generation estimates that steam generator replacement would require a one-time increase in the number of refueling outage workers for up to 70 days at TMI-1. Approximately 900 workers would be needed to perform TMI-1 steam generator replacement project activities in addition to the normal number of refueling outage workers (AmerGen 2008).

The number of additional workers would cause a short-term increase in the demand for temporary (rental) housing units in the region beyond what is normally experienced during a refueling outage at TMI-1. Since TMI-1 is located in a high population area, and Dauphin and Lancaster counties are not subject to growth control measures that would limit housing development, any changes in TMI-1 employment would have little noticeable effect on housing availability in these counties. In addition, the number of available housing units has kept pace with or exceeded the increase in the county populations. However, the rental housing market in the region is very large and based on this information, employment-related housing impacts would be SMALL.

3.2.5 Public Services – Education (Refurbishment)

Public services: education (refurbishment) is a Category 2 issue. Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, notes that “Most sites would experience impacts of small significance but larger impacts are possible depending on site- and project-specific factors.”

As discussed in Section 3.2.4, Exelon Generation estimates that TMI-1 steam generator replacement would require a one-time increase in the number of refueling outage workers for up to 70 days at TMI-1 (AmerGen 2008). Due to the short amount of time needed to replace the steam generators, workers would not be expected to bring families and school-age children with them and therefore there would be no impact on educational services during this extended refueling outage.

3.2.6 Public Services – Public Utilities

Public services: public utilities is a Category 2 refurbishment issue. Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, notes that “An increased problem with water shortages at some sites may lead to impacts of moderate significance on public water supply availability.”

Since there is no water shortage in the TMI-1 region and the public water systems located in Dauphin and Lancaster Counties have excess capacity, any changes in TMI-1 and employee public water usage would have little noticeable affect on public water supply availability in these counties.

As discussed in Section 3.2.4, Exelon Generation estimates that steam generator replacement would require a one-time increase in the number of refueling outage workers for up to 70 days at TMI-1 (AmerGen 2008). The additional number of refueling outage workers needed to replace the steam generators would cause a short-term increase in the amount of public water and sewer services used in the immediate vicinity of TMI-1. Since the region has excess capacity water supply impacts would be very SMALL.

3.2.7 Public Services – Transportation

Public services: transportation is a Category 2 refurbishment issue. Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, notes the following:

Transportation impacts (level of service) of highway traffic generated during plant refurbishment and during the term of the renewed license are generally expected to be of small significance. However, the increase in traffic associated with additional workers and the local road and traffic control conditions may lead to impacts of moderate or large significance at some sites.

The additional number of refueling outage workers and truck material deliveries needed to support the replacement of the steam generators would cause a short-term level of service impact on access roads in the immediate vicinity of TMI-1. As previously discussed in Section 2.2.8.2, major commuting routes to TMI-1, including State Highway 441, are mostly rural and uncongested. Increased traffic volumes entering and leaving TMI-1 during refueling outages, which occur at intervals of approximately 24 months, has not degraded the level of service capacity on local roads. In addition, the TMI-1 site has two entrances. The entrance to the north is used by the operating work force. The entrance to the south is used by a limited number of operational employees working on the southern portion of the station and construction and outage workforces. According to Exelon Generation, during the refurbishment project, construction workers would use the southern entrance to the site. This could alleviate potential congestion problems at the northern site entrance.

Based on this information and due to the short time duration (up to 70 days) for the steam generator replacement project after the arrival of the steam generators, transportation (level of service) impacts in the vicinity of TMI-1 would be SMALL and would only occur during shift changes.

In addition, transporting the two new steam generators to TMI-1 would have a major impact on roads, highways, and bridges from Port Deposit, Maryland, to the TMI-1 site in Pennsylvania. Approximately 75 mi (121 km) of Federal, State, and local roads and highways in Maryland and Pennsylvania would be used to transport the two new replacement steam generators.

The trip will take approximately 20 to 25 days because the special trailers carrying the two steam generators can only travel about 5 miles per hour, and State law prohibits the movement

Environmental Impacts of Refurbishment

of the steam generators after dark. A convoy of escort vehicles will accompany the steam generators as they travel north to TMI-1. Interferences, such as traffic signals, low-hanging overhead telephone and power lines, and narrow roadway obstructions (e.g., guardrails) would have to be moved or removed entirely (e.g. trees). At various points along the transportation route, due to height restrictions and to avoid having to move large numbers of traffic signals and overhead wires, the steam generators will travel north in the southbound lanes, against traffic. Several bridges in Pennsylvania will also require overbridges, bracing, or other modifications to carry the load. Three-inch steel plating will be used to prevent the collapse of pipe culverts and stormwater pipes. Such activities would be temporary and localized causing short-term lane and road closures as as traffic backups, delays, and detours. Once the steam generator convoy has passed, roadways would be reopened and traffic would return to normal levels. Any damage to roadways, bridges, parking lots, buildings and other structures, stream crossings, and parks caused by the movement of the steam generators will be repaired and/or paid for by Exelon Generation's steam generator vendor, AREVA. Permits and approvals would be obtained from the appropriate Federal, State, and local agencies prior to the movement of the steam generators.

3.2.8 Offsite Land Use (Refurbishment)

Offsite land use (refurbishment) is a Category 2 issue. Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, notes that "Impacts may be of moderate significance at plants in low population areas."

Since TMI-1 is located in a high population area any changes in TMI-1 employment would have little noticeable affect on land use in the region. Due to the short amount of time needed to replace the steam generators, the additional number of refueling outage workers would not cause any permanent population- and tax revenue-related land use changes in the immediate vicinity of TMI-1.

3.2.9 Historic and Archaeological Resources

Historic and archaeological resources are a Category 2 refurbishment issue. Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, notes the following:

Generally, plant refurbishment and continued operation are expected to have no more than small adverse impacts on historic and archaeological resources.

However, the National Historic Preservation Act requires the Federal agency to consult with the State Historic Preservation Officer to determine whether there are properties present that require protection.

The area potentially affected by the steam generator replacement project is in an area that was previously disturbed by the construction of TMI-1 and TMI Unit 2. Ground disturbing activities associated with the project include the excavation of previously disturbed areas in the vicinity of TMI-1 and in several areas located south and west of the TMI Unit 2 cooling towers (AmerGen 2008b). A 5,000 ft² (465 m²) storage facility built to house the old steam generators and other

temporary structures will be constructed within the existing industrial footprint of the site (AmerGen 2008b).

Should Exelon Generation proceed with the steam generator project, all activities would be reviewed in accordance with Exelon Generation's site procedures which are designed to ensure that site investigations and consultations with the Pennsylvania Historical and Museum (PHMC; Pennsylvania's State Historic Preservation Office, PA SHPO) are conducted as needed, and that existing and unknown cultural resources are adequately protected. Exelon Generation has consulted with the PHMC. The PHMC determined that the project would have no effect on known historic and archaeological resources. However, should the project include additional ground disturbing activities beyond what is currently planned, then further consultation and mitigation would be necessary (PHMC 2009).

The delivery of the steam generators from the eastern shore of the Susquehanna River to TMI-1 could impact remnants of the Pennsylvania Canal's Eastern Division (Eastern Division Canal) which ran on the east side of the Susquehanna River. Prehistoric and historic properties along the route could be affected by vibrations from the movement of the heavy transporter over roadways and bridges. However, most activities would be temporary and localized. Permits and approvals would be obtained from the appropriate Federal, State, and local agencies prior to the movement of the steam generators.

The impacts associated with this activity are not expected to adversely impact historic or archaeological sites located in the vicinity of TMI-1 and TMI Unit 2. Therefore, the potential impacts from this activity on historic or archaeological resources would be SMALL. However, should archaeological resources be encountered during construction, work would cease until Exelon Generation environmental personnel perform an evaluation and consider possible mitigation measures through consultation with the PHMC.

3.2.10 Environmental Justice

Environmental justice is a Category 2 refurbishment issue. Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, notes that "The need for and the content of an analysis of environmental justice will be addressed in plant specific reviews."

Since TMI-1 is located in a high population area any changes in TMI-1 employment would have little noticeable effect on minority and/or low-income populations in the region. Due to the short amount of time (up to 70 days) needed to replace the TMI-1 steam generators and based on the analysis of impacts for the other resource areas discussed in Section 3.2, there would be no disproportionately high and adverse impacts on minority and low-income populations located in the immediate vicinity of TMI-1.

3.3 Evaluation of New and Potentially Significant Information on Impacts of Refurbishment

For all Category 1 issues related to refurbishment, the NRC staff has not identified any new and significant information during its review of the TMI-1 ER, the staff's environmental site audit, the scoping process, or the evaluation of other available information, including the July 17, 2008

Environmental Impacts of Refurbishment

telephone conference call between NRC and Exelon Generation, during which Exelon Generation's refurbishment plans were discussed (NRC 2008). Therefore, the NRC staff adopts the findings in the GEIS for Category 1 issues associated with refurbishment, and concludes that there would be no environmental impacts during the renewal term beyond those discussed in the GEIS for these issues.

3.4 Summary of Impacts of Refurbishment

For the nine Category 2 issues and environmental justice, the impacts of refurbishment at TMI-1 range from no impact to SMALL. For the refurbishment issues Public Services: Education, Offsite Land Use, and Environmental Justice, the NRC staff concludes that there would be no noticeable impact. For the refurbishment issues Terrestrial Ecology, Threatened or Endangered Species, Air Quality (Nonattainment and Maintenance Areas), Housing Impacts, Public Services: Public Utilities, Public Services: Transportation, and Historic and Archeological Resources, the NRC staff concludes that the potential environmental effects are of SMALL significance.

3.5 References

10 CFR 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions."

40 CFR 51. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 51, "Requirements for Preparation, Adoption, and Submittal of Implementation Plans."

40 CFR 93. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 93, "Determining Conformity of Federal Actions to State or Federal Implementations Plans."

72 FRN 40749. July 25, 2007. "Approval and Promulgation of Air Quality Implementation Plans; Pennsylvania; Redesignation of the Harrisburg-Lebanon-Carlisle Ozone Nonattainment Area to Attainment and Approval of the Area's Maintenance Plan and 2002 Base Year Inventory." *Federal Register*. Volume 72, No. 142, pp. 40749. Washington, D.C.

AmerGen (AmerGen Energy Company, LLC). 2008. *Three Mile Island Nuclear Station, Applicant's Environmental Report, License Renewal Operating Stage*. Kennett Square, Pennsylvania. ADAMS Nos. ML080220255, ML080220257, ML080220261, and ML080220282.

AmerGen (AmerGen Energy Company, LLC). 2008a. *Three Mile Island, Unit 1, Enclosure A - Post Audit Environmental Information - Question ENV-070, Monthly Report on the Meteorological Monitoring Program, March 2007 through End (Non-Proprietary Version)*. "TMI Refurbishment Emissions.xls." Pp. 432-439. June 10. ADAMS No. ML082110253.

AmerGen (AmerGen Energy Company, LLC). 2008b. *Three Mile Island, Unit 1, Enclosure A - Post Audit Environmental Information - Index through Audit Question ENV-070, Monthly Report on the Meteorology Program, February 2007 (Non-Proprietary Version)*. ADAMS No. ML082110252.

Environmental Impacts of Refurbishment

Clean Air Act. 42 U.S.C. 7401, et seq. *United States Code*, Title 42, *The Public Health and Welfare*, Chapter 85, "Air Pollution Prevention and Control."

Clean Water Act. 33 U.S.C. 26. *United States Code*, Title 33, *Navigation and Navigable Waters*, Chapter 26, "Water Pollution Prevention and Control"

NRC (U.S. Nuclear Regulatory Commission). 1996. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*. NUREG-1437, Volumes 1 and 2, Washington, D.C. ADAMS No. ML061770605.

NRC (U.S. Nuclear Regulatory Commission). 1999. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Main Report*, "Section 6.3-Transportation, table 9.1, Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants, Final Report." NUREG-1437, Volume 1, Addendum 1, Washington, D.C.

NRC (U.S. Nuclear Regulatory Commission). 2008. Summary of Telephone Conference Call Held on July 17, 2008, Between the U.S. Nuclear Regulatory Commission and AmerGen Energy Company, LLC, Concerning Follow-Up Questions Pertaining to the Three Mile Island Nuclear Station, Unit 1 License Renewal Environmental Review and Site Audit. Washington, D.C. ADAMS No. ML082120727.

PHMC (Pennsylvania Historical and Museum Commission). 2009. Letter from D. McLearn, Chief, Archaeology and Protection Division, Bureau of Historic Preservation, Pennsylvania Museum and Historical Commission, Harrisburg, Pennsylvania, to T. Scanlon, Michael Barker Jr., Inc., Harrisburg, Pennsylvania. Subject: ER 2007-1737-043-F, COE: Proposed Temporary Roadway and Bridge Improvements from Port Deposit, Maryland to Dauphin County, Pennsylvania for Oversize Vehicles. March 23, 2009. ADAMS No. ML091130569.

4.0 ENVIRONMENTAL IMPACTS OF OPERATION

This chapter addresses potential environmental impacts related to the period of extended operation of Three Mile Island Nuclear Station, Unit 1 (TMI-1). These impacts are grouped and presented according to resource. Generic issues (Category 1) rely on the analysis provided in the generic environmental impact statement (GEIS) prepared by the U.S. Nuclear Regulatory Commission (NRC) (NRC 1996, 1999) and are discussed briefly. NRC staff analyzed site-specific issues (Category 2) for TMI-1 and assigned them a significance level of SMALL, MODERATE, or LARGE. Some remaining issues are not applicable to TMI-1 because of site characteristics or plant features. Section 1.4 of this report explains the criteria for Category 1 and Category 2 issues and defines the impact designations of SMALL, MODERATE, and LARGE.

4.1 Land Use

Land use issues are listed in Table 4-1. The staff did not identify any Category 2 issues for land use. The staff also did not identify any new and significant information during the review of the environmental report (ER) (AmerGen 2008) prepared by Exelon Generation Company, LLC (Exelon Generation), the site audit, or the scoping process. Therefore, there are no impacts related to these issues beyond those discussed in the GEIS. For these issues, the GEIS concludes that the impacts are SMALL, and additional site-specific mitigation measures are not likely to be warranted.

Table 4-1. Land Use Issues. *Section 2.2.1 of this report describes the land use around TMI-1.*

Issues	GEIS Section	Category
Onsite land use	4.5.3	1
Power line right-of-way	4.5.3	1

4.2 Air Quality

The air quality issue applicable to TMI-1 is listed in Table 4-2. The staff did not identify any Category 2 issues related to the effects of transmission lines on air quality. Staff also did not identify any new and significant information during the review of Exelon Generation's ER (AmerGen 2008), the site audit, or the scoping process. Therefore, there are no impacts related to this issue beyond those discussed in the GEIS. For these issues, the GEIS concludes that the impacts are SMALL, and additional site-specific mitigation measures are not likely to be warranted.

Table 4-2. Air Quality Issue. *Section 2.2.2 of this report describes air quality in the vicinity of TMI-1.*

Issue	GEIS Section	Category
Air quality effects of transmission lines	4.5.2	1

4.3 Ground Water

The following sections discuss the Category 2 ground water issues applicable to TMI-1, which are listed in Table 4-3.

Table 4-3. Ground Water Use and Quality Issues. *Section 2.2.3 of this report discussed ground water use and quality at TMI-1.*

Issues	GEIS Section	Category
Ground Water use conflicts (potable and service water, plants using >100 gpm)	4.8.1.1	2
Ground Water use conflicts (plants using cooling towers withdrawing make-up water from a small river)	4.8.1.3	2

4.3.1 Ground Water Use Conflicts (plants using greater than 100 gpm)

The NRC specifies as issue 33 in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, that, “if the applicant’s plant...pumps more than 100 gallons (total onsite) of ground water per minute (gpm), an assessment of the impact of the proposed action on ground water use must be provided.” The NRC further states that “plants that use more than 100 gpm may cause ground water use conflicts with nearby ground water users,” (10 CFR 51.53[c][3][ii][C]). This applies to TMI-1 because, as discussed in Section 2.2.3.1 of this report, TMI-1 used between 95 and 115 gallons per minute (gpm) of ground water pumped from seven onsite wells from 2003 to 2005.

A ground water withdrawal rate of over 100 gpm has the potential to create a cone of depression large enough to affect offsite wells and ground water supplies, limiting the amount of ground water available for the area surrounding the plant. The Susquehanna River Basin Commission (SRBC) originally approved ground water withdrawal at a rate of 168,750 gallons per day (gpd) (117 gpm) at TMI-1 from wells A, B, and C after a process of simultaneous pump tests in 1995. In 1998, TMI-1 applied to SRBC for a ground water withdrawal upgrade. Based on information gathered during the original pumping tests, and after observing that there had been no impacts on the operation of the onsite Operations Support Facility/North Office Building (OSF) well, the Building 48 (48S) well, or any other onsite wells, or along the eastern shore of the Susquehanna River, SRBC approved a new ground water withdrawal rate of 225,000 gpd. After publication of the draft supplemental EIS, Exelon Generation submitted an application to SRBC to utilize the existing OSF well for both potable and industrial purposes, with no increase in the approved ground water withdrawal rate (Exelon Generation 2009).

After reviewing the information provided by the applicant, as well as the 1996 SRBC pump test data from wells A, B, and C, which showed no effect on nearby ground water wells, the NRC staff concludes that the impacts of TMI-1 ground water withdrawal on nearby ground water users would be SMALL.

4.3.2 Ground Water Use Conflicts (make-up from a small river)

The NRC specifies that, “if the applicant’s plant utilizes cooling towers or cooling ponds and withdraws makeup water from a river whose annual flow rate is less than 3.15×10^{12} cubic ft per

year (ft³/year) [(99,885 cubic ft per second (cfs)) ... [t]he applicant shall also provide an assessment of the impacts of the withdrawal of water from the river on alluvial aquifers during low flow," (10 CFR 51.53[c][3][ii][A]). For water use conflicts, the NRC further states, as issue 34 in Table B-1 of Appendix B to Subpart A of 10 CFR Part 51 that, "water use conflicts may result from surface water withdrawals from small water bodies during low flow conditions which may affect aquifer recharge, especially if other ground water or upstream surface water users come online before the time of license renewal...." This issue is applicable to TMI-1 because the plant uses cooling towers, and makeup water for its cooling systems is withdrawn from the Susquehanna River, which has an annual mean flow of approximately 1.09x10¹² ft³/yr (34,450 cfs), thus meeting the NRC's definition of a small river. Flow is monitored at the Harrisburg gauging station, about 11 mi (18 km) upstream of TMI-1.

Consumptive water losses at TMI-1 comprise a small fraction of the Susquehanna River flow at Lake Frederick (which is created by the damming of the Susquehanna River by the Red Hill Dam and the York Haven Dam), where TMI-1 is situated. The rate at which TMI-1 withdraws surface water is about 1.6 percent of the lowest daily mean flow of the Susquehanna River, which is less than 0.2 percent of the lowest annual mean flow and less than 0.1 percent of the average annual flow. TMI-1 is also part of the Cowanesque Lake water storage project, allowing the site 8,274 acre-feet of storage. During a period of severe drought, SRBC can direct the release of water to alleviate any impacts to the Susquehanna River caused by the consumptive loss from plant operations, allowing for the continuation of TMI-1 operations.

Furthermore, the Commonwealth of Pennsylvania requires facilities that withdraw or use more than 10,000 gpd (378,541 liters per day [Lpd]) of surface or ground water, such as TMI-1, to register and periodically report their water usage for Commonwealth water planning purposes. Thus, the NRC staff concludes that the impacts from consumptive water use on ground water would be SMALL.

4.4 Surface Water

The following sections discuss the surface water quality issues applicable to TMI-1 which are listed in Table 4-4. The staff did not identify any new and significant information during the review of Exelon Generation's ER (AmerGen 2008), the site audit, or the scoping process. Therefore, no impacts are related to these issues beyond those discussed in the GEIS. For these issues, the GEIS concludes that the impacts are SMALL, and additional site-specific mitigation measures are not likely to be warranted.

Table 4-4. Surface Water Quality Issues. Section 2.2.4 of this report describes surface water quality conditions at TMI-1.

Issues	GEIS Section	Category
Altered current patterns at intake and discharge structures	4.2.1.2.1	1
Altered salinity gradients	4.2.1.2.2	1
Temperature effects on sediment transport capacity	4.2.1.2.3	1
Scouring caused by discharged cooling water	4.2.1.2.3	1

Environmental Impacts of Operation

Issues	GEIS Section	Category
Eutrophication	4.2.1.2.3	1
Discharge of chlorine or other biocides	4.2.1.2.4	1
Discharge of sanitary wastes and minor chemical spills	4.2.1.2.4	1
Discharge of other metals in wastewater	4.2.1.2.4	1
Water use conflicts (plants with cooling ponds or cooling towers using make-up water from a small river with low flow)	4.3.2.1; 4.4.2.1	2

4.4.1 Water Use Conflicts

The NRC specifies that, "if the applicant's plant uses cooling towers or cooling ponds and withdraws makeup water from a river whose annual flow rate is less than 3.15×10^{12} cubic feet per year (ft^3/year) [$99,885$ cubic feet per second (cfs)], an assessment of the impact of the proposed action on the flow of the river and related impacts on instream and riparian ecological communities must be provided" (10 CFR 51.53[c][3][ii][A]). For water use conflicts, the NRC further states as issue 13 in Table B-1 of Appendix B to Subpart A of 10 CFR Part 51, "The issue has been a concern at nuclear power plants with cooling ponds and at plants with cooling towers. Impacts on instream and riparian communities near these plants could be of moderate significance in some situations." This issue is applicable to TMI-1 because the plant uses a cooling-tower-based heat dissipation system. Water used to replace that lost to evaporation in the cooling system is withdrawn from the Susquehanna River, which has an annual mean flow of approximately 1.09×10^{12} ft^3/yr (34,450 cfs), thus meeting the NRC's definition of a small river. Flow is monitored at the Harrisburg gauging station, about 11 mi (18 km) upstream of TMI-1.

In the GEIS, surface water conflicts are considered a Category 2 issue for two reasons:

- (1) Consumptive water use can adversely affect riparian vegetation and instream aquatic communities. Reducing the amount of water available to either the riparian zones or instream communities could result in impacts to threatened and endangered species, wildlife, and recreational uses of the water body. In addition, riparian vegetation performs several important ecological functions, including stabilizing channels and floodplains, influencing water temperature and quality, and providing habitat for aquatic and terrestrial wildlife.
- (2) Continuing operation of these facilities depends on the availability of water within the river from which they are withdrawing water. For facilities that are located on small bodies of water, the volume of water available is expected to be susceptible to droughts and to competing water uses within the basin. In cases of extreme drought, these facilities may be required to curtail operations if the volume of water available is not sufficient.

An additional potential effect of the withdrawal of water from a small river is that the withdrawal may have an impact on ground water levels and therefore, result in ground water use conflicts

(NRC 1996). The staff considers this to be a separate Category 2 issue, which is evaluated in Section 4.3 of this supplemental environmental impact statement (EIS).

The Susquehanna River meets the definition of a small river because, based on data taken 11 mi (18 km) upstream of TMI-1 at Harrisburg, the annual mean flow of the river is 1.09×10^{12} ft³/yr (34,450 cfs). Currently, TMI-1 is permitted to consume up to 18 million gpd, with its average estimated rate of withdraw being 24,000 gpm. The withdraws from TMI-1 are less than 1.6 percent of the Susquehanna River flow under the conditions of a typical drought period, less than 0.2 percent of the lowest annual mean flow of the river, and less than 0.1 percent of the average annual flow. In March 2009, Exelon Generation submitted an application to SRBC to modify TMI-1's Consumptive Water Use Docket No. 19950302 from 18 million gpd to 19.2 million gpd to accommodate TMI-1 water needs for possible future operations. Surface water withdrawals at TMI-1 were initiated prior to November 11, 1995 (when surface water withdrawals became subject to SRBC regulation) and have been in "grandfathered" status. Accordingly, Exelon Generation has also requested a maximum daily/maximum 30-day average water withdrawal of 122.8 million gpd (Exelon Generation 2009). These withdrawals are insignificant relative to the flow in the Susquehanna River and would not be expected to impact the river's aquatic and riparian ecological communities or the alluvial water-bearing material (aquifers).

Additionally, as detailed in Section 2.1.7.2 of this report, TMI-1 participates in the Cowanesque Lake water storage project and sponsors 8,274 acre-feet of water storage. SRBC monitors the flow of the Susquehanna River and, in the event of a drought emergency, it has the authority to signal the U.S. Army Corps of Engineers to release predetermined quantities of water from storage.

The staff has reviewed the available information, including that provided by the applicant, additional SRBC data, information gathered at the staff's site visit and the scoping process, and other available sources. Considering TMI-1's small consumptive water use relative to the flows in the Susquehanna River, as well as the potential for SRBC to release water into the river during periods of extreme drought, the NRC staff concludes that the impact of water use on the Susquehanna River at TMI-1 would be SMALL.

4.5 Aquatic Resources

Table 4-5 on the following page lists the issues related to aquatic resources applicable to TMI-1. No Category 2 issues are related to aquatic resource. The NRC staff did not identify any new and significant information during the review of the Exelon Generation ER (AmerGen 2008), the site audit, the scoping process, or the evaluation of other available information. Therefore, the staff concludes that there would be no impacts related to these issues beyond those discussed in the GEIS (NRC 1996). Regarding these issues, the GEIS concludes that the impacts are SMALL, and additional site-specific mitigation measures are not likely to warrant implementation.

Environmental Impacts of Operation

Table 4-5. Aquatic Resources Issues. Section 2.1.6 of this report describes the TMI-1 cooling water system; Section 2.2.5 describes the aquatic resources.

Issues	GEIS Section	Category
<i>For All Plants</i>		
Accumulation of contaminants in sediments or biota	4.2.1.2.4	1
Entrainment of phytoplankton and zooplankton	4.2.2.1.1	1
Cold shock	4.2.2.1.5	1
Thermal plume barrier to migrating fish	4.2.2.1.6	1
Distribution of aquatic organisms	4.2.2.1.6	1
Premature emergence of aquatic insects	4.2.2.1.7	1
Gas supersaturation (gas bubble disease)	4.2.2.1.8	1
Low dissolved oxygen in the discharge	4.2.2.1.9	1
Losses from predation, parasitism, and disease among organisms exposed to sublethal stresses	4.2.2.1.10	1
<i>For Plants with Cooling Tower-Based Heat Dissipation Systems</i>		
Entrainment of fish and shellfish in early life stages	4.3.3	1
Impingement of fish and shellfish	4.3.3	1
Heat shock	4.3.3	1

4.6 Terrestrial Resources

The issues related to terrestrial resources applicable to TMI-1 are discussed below and listed in Table 4-6. There are no Category 2 issues related to terrestrial resources for license renewal. The NRC staff did not identify any new and significant information during the review of the Exelon Generation ER (AmerGen 2008), the site audit, the scoping process, or the evaluation of other available information. Therefore, the NRC staff concludes that there would be no impacts related to these issues beyond those discussed in the GEIS (NRC 1996). Regarding these issues, the GEIS concludes that the impacts are SMALL, and additional site-specific mitigation measures are not likely to be sufficiently beneficial to implement.

Table 4-6. Terrestrial Resources Issues. Section 2.2.6 provides a description of the terrestrial resources at TMI-1 and in the surrounding area.

Issues	GEIS Section	Category
Cooling tower impacts on crops and ornamental vegetation	4.3.4	1

Issues	GEIS Section	Category
Cooling tower impacts on native plants	4.3.5.1	1
Bird collisions with cooling towers	4.3.5.2	1
Power line right-of-way management (cutting herbicide application)	4.5.6.1	1
Bird collisions with power lines	4.5.6.1	1
Impacts of electromagnetic fields on flora and fauna (plants, agricultural crops, honeybees, wildlife, livestock)	4.5.6.3	1
Floodplains and wetland on power line right-of-way	4.5.7	1

4.7 Threatened or Endangered Species

Table 4-7. Threatened or Endangered Species. Section 2.2.7 describes the threatened or endangered species on or near TMI-1.

Issue	GEIS Section	Category
Threatened or endangered species	4.1	2

4.7.1 Aquatic Species

One Federally- and State-listed endangered species, the dwarf wedgemussel (*Alasmidonta heterodon*), was recorded in Lancaster County, but not in the vicinity of TMI-1 or in the waterways along the transmission line corridors. The black bullhead (*Amerius melas*), a State-listed species, has been recorded in Dauphin County (PNHP 2008), but is not known to occur either in the vicinity of TMI-1 or in the waterways along the transmission line corridors (AmerGen 2008).

The U.S. Fish and Wildlife Service (FWS) indicated by letter dated April 23, 2008, that no Federally listed or proposed threatened or endangered species are known to occur within the project impact area; hence no biological assessment or further consultation with FWS, as required by the Endangered Species Act, is necessary (FWS 2008). The Pennsylvania Fish and Boat Commission (PFBC) indicated by letter dated June 7, 2007, that no adverse impacts to State-listed rare, candidate, threatened, or endangered aquatic species are expected from the proposed project (PFBC 2008).

4.7.2 Terrestrial Species

An evaluation of impacts to threatened and endangered terrestrial species requires consultation with appropriate agencies to determine whether such species are present and whether they would be adversely affected by continued operation of the TMI-1 site during the license renewal term. Sections 2.2.6 and 2.2.7 of this supplemental EIS discuss the characteristics and habitat of threatened and endangered species in the vicinity of the TMI-1 site.

Environmental Impacts of Operation

The NRC staff contacted FWS, the Pennsylvania Department of Conservation and Natural Resources (DCNR), and the Pennsylvania Game Commission (PGC) to request information that could assist in assessing the environmental impacts associated with license renewal. In response, on April 28, 2008, the FWS indicated that no known Federally-listed threatened or endangered species occur within the project area; therefore, the proposed project would not likely adversely affect any Federally-listed species (FWS 2008). In a May 2, 2008, letter to the NRC, DCNR stated that, although several species of concern are known to occur in the vicinity of the TMI-1 project site, no impact to these species is anticipated (DCNR 2008). In a May 14, 2008, letter to the NRC, PGC indicated that, "the renewal of the TMI Operating License is not anticipated to cause any adverse impacts to special concern species of birds and mammals that may be in the vicinity of the transmission line corridors associated with the electric generating station" (PGC 2008).

Two Federally-listed threatened or endangered species, the bog turtle (*Glyptemys muhlenbergii*) and the northeastern bulrush (*Scirpus ancistrochaetus*), are potentially found in the vicinity of the TMI-1 site (PNHP 2008). The bald eagle (*Haliaeetus leucocephalus*) and the peregrine falcon (*Falco peregrinus*) were formerly listed as Federally-threatened. Eleven State-listed threatened or endangered species have been determined to be species of special concern for the TMI-1 site, including the osprey (*Pandion haliaetus*), the prothonotary warbler (*Protonotaria citrea*), the yellow-crowned night heron (*Nycticorax violacea*), the black-crowned night heron (*Nycticorax nycticorax*), the aster-like boltonia (*Boltonia asteroides*), a sedge species (*Carex shortiana*), the flat-stemmed spike-rush (*Eleocharis compressa*), the ellisia (*Ellisia nyctelea*), the bronze copper (*Lycaena hyllus*), and the formerly Federally-listed birds, the bald eagle and peregrine falcon (DCNR 2008; PGC 2008; AmerGen 2008; PNHP 2008). Section 2.2.7 of this report describes these species in greater detail.

The NRC staff encourages Exelon Generation and FirstEnergy Corporation (FirstEnergy), who owns the transmission lines, to report the existence of any Federally- or State-listed endangered or threatened species within or near the transmission line right-of-ways (ROWs) to DCNR or FWS or both, if any such species are identified during the license renewal term. In particular, if any evidence of injury to or mortality of migratory birds or threatened or endangered species is observed within the corridor during the license renewal period, the NRC staff encourages Exelon Generation and FirstEnergy to promptly report this to the appropriate wildlife management agencies. Additionally, the NRC staff encourages Exelon Generation to continue reporting information concerning the peregrine falcon pair and their young that nest on the reactor building to the Commonwealth of Pennsylvania.

Operation of the TMI-1 site and its associated transmission lines is not expected to adversely affect any threatened or endangered species during the license renewal term. Therefore, the NRC staff concludes that adverse impacts to threatened or endangered species during the period of extend operation would be SMALL. The following mitigation measures are currently in place at the TMI-1 site are found to be adequate and minimize the effects of plant operation on terrestrial species. They include: nest construction and placement for several species (including the peregrine falcon and osprey), environmental review checklists, environmental evaluation forms, and best management practices.

4.8 Human Health

The human health issues applicable to TMI-1 are discussed below and listed in Table 4-8 for Category 1, Category 2, and uncategorized issues. Category 1 issues are discussed further in Section 4.8.1, and Category 2 and uncategorized issues are discussed in Sections 4.8.2 through 4.8.4.

Table 4-8. Human Health Issues. *Table B-1 of Appendix B to Subpart A of 10 CFR Part 51 contains more information on these issues.*

Issues	GEIS Section	Category
Microbiological organisms (occupational health)	4.3.6	1
Microbiological organisms (public health, for plants using small rivers)	4.3.6	2
Noise	4.3.7	1
Radiation exposures to public (license renewal term)	4.6.1, 4.6.2	1
Occupation radiation exposures (license renewal term)	4.6.3	1
Electromagnetic fields – acute effects (electric shock)	4.5.4.1	2
Electromagnetic fields – chronic effects	4.5.4.2	Uncategorized

4.8.1 Generic Human Health Issues

The staff did not identify any new and significant information during its review of the Exelon Generation ER, the site audit, or the scoping process. Therefore, there are no impacts related to Category 1 human health issues beyond those discussed in the GEIS. For these Category 1 issues, the GEIS concluded that the impacts are SMALL, and additional site-specific mitigation measures are not likely to be sufficiently beneficial to be warranted.

TMI-1 conducts an annual Radiological Environmental Monitoring Program (REMP) in which radiological impacts to the public and the environment surrounding the TMI-1 site are monitored, documented, and compared to the appropriate standards. The objectives of the REMP are to:

- Measure and evaluate the levels of radiation and radioactive material in the environs around the TMI-1 site to assess the radiological impacts, if any, of plant operation on the environment.
- Supplement the results of the radiological effluent monitoring program by verifying that the measurable concentrations of radioactive material and levels of radiation are not higher than expected based on the measurement of radioactive effluents and modeling for the applicable exposure pathways.
- Demonstrate compliance with the requirements of applicable Federal regulatory agencies.

Two reports summarize radiological information about the TMI-1 site—the annual radiological environmental operating report and the annual radioactive effluent release report. The TMI-1 offsite dose calculation manual (ODCM) specifies limits for all radiological releases (AmerGen

Environmental Impacts of Operation

2007). The ODCM is used to meet Federal standards and requirements. The TMI-1 REMP samples environmental media in the environs around the site to analyze and measure the radioactivity levels that may be present. The media samples are representative of the radiation exposure pathways to the public from all plant radioactive effluents. The REMP measures the aquatic and atmospheric environment, as well as the ambient gamma radiation, for radioactivity in the vicinity of the TMI-1 site. Ambient gamma radiation pathways include radiation from buildings and plant structures and airborne material that may be released from the plant. In addition, the REMP also measures background radiation (i.e., cosmic sources, global fallout, and naturally occurring radioactive material, including radon). Thermoluminescent dosimeters (TLDs) are used to measure direct radiation. The atmospheric environmental monitoring consists of sampling the air for particulates and radioiodine. Terrestrial environmental monitoring consists of analyzing samples of milk and food products. The aquatic environmental monitoring consists of analyzing samples of surface water, drinking water, stormwater, ground water, and fish and sediment from the Susquehanna River.

The NRC staff reviewed the TMI-1 radioactive environmental operating reports for 2003 through 2007 to look for any significant impacts to the environment or any unusual trends in the data (AmerGen 2004, 2005, 2006b, 2007a, 2008a). During 2007, no plant-related activation or fission products were detected in airborne and foodborne samples. The only radionuclide attributable to plant operation detected in 2007 was tritium, which was measured in samples of surface, storm, effluent, and drinking water (AmerGen 2008a). No unusual trends were noted and all reported data on the radionuclides detected in environmental samples were below applicable NRC reporting levels and showed no significant or measurable impact from the operations at TMI-1 (AmerGen 2008a).

The Pennsylvania Department of Environmental Protection (PADEP), Bureau of Radiation Protection (BRP), also conducts a comprehensive environmental radiation monitoring program in Pennsylvania that routinely samples and analyzes selected environmental media in conjunction with TMI-1. The BRP environmental radiation monitoring program includes TLDs for monitoring direct radiation and samples of air, vegetation, milk, drinking water, fish, and river sediment. The results of the BRP 2003–2004 environmental radiation monitoring program showed detectable levels of radioactivity attributable to operation of TMI-1. In 2003, low levels of tritium were detected in drinking water samples near the plant site, but no reactor-produced radionuclides were detected in the fish, produce, air or milk samples. However, radioactivity from remnants of atomic weapons testing and the accident at Chernobyl was detected in water and milk samples. The report concluded, “The results of the 2003 and 2004 environmental sampling program indicate that Pennsylvanians have not been exposed to levels of radiation above normal background. This has been determined by comparing samples collected around nuclear facilities with those from locations that would not be influenced by such facilities.” (PADEP 2008).

In addition to the routine REMP, the applicant established an onsite ground water protection program in 2006. The program is designed to monitor the onsite environment for indication of leaks from plant systems and pipes carrying liquids with radioactive material. The results were reported as Appendix F to the TMI-1 2007 annual radiological environmental operating report. The results indicated that tritium was detected in 15 ground water samples at three locations at concentrations greater than the U.S. Environmental Protection Agency (EPA) drinking water

standard (and the NRC reporting limit) of 20,000 picocuries per liter (pCi/L) (740,000 Becquerels per cubic meter [Bq/m³]). Tritium was detected in 47 of 68 ground water monitoring locations. The tritium concentrations ranged from 206 pCi/L (7622 Bq/m³) to 29,600 pCi/L (1,095,200 Bq/m³). Tritium that was detected in ground water at the station is believed to have been from a leak in the condensate de-ice line, historical releases, or background radiation or all three. There were no known active releases into the ground water at the TMI-1 site at the end of 2007. Based on the sample results, the applicant calculated that the potential dose to a member of the public from drinking this water was less than 0.008 millirems (mrem) (0.00008 milliSieverts [mSv]). This dose is a very small fraction of the dose design objective specified in Appendix I to 10 CFR Part 50, "Numerical Guide for Design Objectives and Limiting Conditions for Operation to Meet the Criterion 'As Low as is Reasonably Achievable' for Radioactive Material in Light-Water-Cooled Nuclear Power Reactor Effluents."

Historical data of releases from TMI-1 and the resultant dose calculations demonstrate that the amount of radiation received to a hypothetical maximally exposed individual in the vicinity of TMI-1 is a small fraction of the limits specified in 10 CFR Part 20, the as low as is reasonably achievable (ALARA) dose design objectives in Appendix I to 10 CFR Part 50, and EPA's radiation standards in 40 CFR Part 190, "Environmental Radiation Protection Standards for Nuclear Power Operations." For 2007, dose estimates were calculated based on actual liquid and gaseous effluent release data and conservative models to simulate the transport mechanisms. The TMI-1 2007 annual radioactive effluent release report (AmerGen 2008b) describes the results. The following summarizes the calculated hypothetical maximum dose to an individual located at the TMI-1 site boundary from liquid and gaseous effluents released during 2007:

- The maximum whole-body dose to an offsite member of the general public from liquid effluents was 0.056 mrem (0.00056 mSv), which is well below the 3-mrem dose criterion in 10 CFR Part 50, Appendix I.
- The maximum air dose at the site boundary from gamma radiation in gaseous effluents was 0.000365 mrad (0.00000365 mGy), which is well below the 10-mrad dose criterion in 10 CFR Part 50, Appendix I.
- The maximum air dose at the site boundary from beta radiation in gaseous effluents was 0.000326 mrad (0.00000326 mGy), which is well below the 20-mrad dose criterion in 10 CFR Part 50, Appendix I.
- The maximum organ dose (child thyroid) to an offsite member of the general public from radioactive iodine, tritium, and particulates in gaseous effluents was 0.00814 mrem (0.0000814 mSv), which is well below the 15-mrem dose criterion in 10 CFR Part 50, Appendix I.
- The maximum whole-body dose to an offsite member of the general public from all radioactive emissions (radioactive gaseous and liquid effluents and direct radiation shine) was 0.33 mrem (0.0033 mSv), below the 25-mrem standard in EPA's 40 CFR Part 190.

Based on the review and assessment of the TMI-1 radioactive waste system performance in controlling radioactive effluents and the resultant doses to members of the public in conformance with the ALARA criteria, the NRC staff found that the 2007 radiological data for TMI-1 are consistent, with reasonable variation attributable to operating conditions and outages, with the 5-year historical radiological effluent releases and resultant doses. These results

Environmental Impacts of Operation

demonstrate that TMI-1 is operating in compliance with Federal radiation protection standards contained in 10 CFR Part 50, Appendix I, 10 CFR Part 20, and 40 CFR Part 190. Continued compliance with regulatory requirements is expected during the license renewal term; therefore, the impacts from radioactive effluents are not expected to change.

The applicant plans to conduct refurbishment activities (i.e., replacement of steam generators) during the license renewal term. The applicant is expected to maintain radiological releases in accordance with its ODCM and regulatory requirements as it has in the past. Thus, the refurbishment activities are not expected to generate an amount of radioactive material that is significantly different from the historical radiological effluent releases which included refueling outage activities. The staff concludes that the dose to a member of the public and to plant workers from TMI-1 during routine operation and refurbishment activities is expected to continue to be a small fraction of the dose limits and standards specified in 10 CFR Part 20, 10 CFR Part 50, Appendix I, and 40 CFR Part 190. Therefore, based on there being no significant difference in radiological effluents with the addition of the refurbishment activities from the historical radiological effluent levels, the impacts from radioactive effluents are not expected to change.

4.8.2 Microbiological Organisms – Public Health

Table B-1 of Appendix B to Subpart A of 10 CFR Part 51 lists the effects of thermophilic microbiological organisms on human health as a Category 2 issue and requires the conduct of a plant-specific evaluation before license renewal for those plants using closed-cycle cooling that are located on a small river. The average annual flow of the Susquehanna River at the nearest measuring station to TMI-1 is approximately 1.09×10^{12} ft³/yr (3.08×10^{10} cubic meters per year (m³/yr)) (Durlin and Schaffstall 2005). This is less than the 3.15×10^{12} ft³/yr (9×10^{10} m³/yr), which is the threshold value in 10 CFR 51.53(c)(3)(ii)(G) for thermal discharge to a small river. Nevertheless, recreational uses of the Susquehanna River in the vicinity of TMI-1, which include boating, fishing, and swimming, create the potential for human exposure to thermophilic microbiological organisms. Consequently, the effects of its discharge on microbiological organisms must be addressed for TMI-1 license renewal.

The Category 2 designation is based on the magnitude of the potential public health impacts associated with thermal enhancement of enteric pathogens such as *Salmonella* spp. and *Shigella* spp., the *Pseudomonas aeruginosa* bacterium, the pathogenic strain of the free-living amoebae *Naegleria* spp., and a number of species from genus *Legionella* (NRC 1996). Thermophilic biological organisms generally occur at temperatures of 77 to 176 degrees Fahrenheit (°F) (25 to 80 degrees Celsius (°C)), with optimal growth occurring between 122 and 150 °F (50 and 66 °C) and minimum tolerance of 68°F (20 °C) (Joklik and Willett 1976). However, thermal preference and tolerances vary across the bacteria family.

P. aeruginosa is an opportunistic pathogen that causes serious and sometimes fatal infections in immunocompromised individuals by producing and releasing toxins. It has an optimal growth temperature of 99 °F (37 °C) (Todar 2007). *Legionella* spp. consists of at least 46 species and 70 serogroups and is responsible for Legionnaires' disease, with the onset of pneumonia in the first 2 weeks of exposure. Risk groups for *Legionella* spp. include the elderly, cigarette smokers, persons with chronic lung or immunocompromising disease, and persons receiving immunosuppressive drugs. *Legionella* spp. grows best at 90 to 105 °F (32 to 41 °C) (CDC

2007). *Salmonella typhimurium* and *Salmonella enteritidis* are two of the more common species of Enterobacteriaceae which cause fever, abdominal cramps, and diarrhea. *Salmonella* spp. can occasionally establish localized infection (e.g., septic arthritis) or can progress to sepsis. All ages can be affected, but groups at greatest risk for severe or complicated disease include infants, the elderly, and persons with compromised immune systems. *Salmonella* spp. occurs at temperatures between 50 and 120 °F (10 and 49 °C) (CDC 2007), with optimal growth occurring at 95 to 99 °F (35 to 37 °C) (ESR 2002). The pathogenic amoeba flagellate *Naegleria fowleri* is the causative agent of human primary amoebic meningoencephalitis. All ages can be affected, but groups at greatest risk for severe or complicated disease include infants, the elderly, and persons with compromised immune systems. *Naegleria* spp. is ubiquitous in nature and can be enhanced in thermally altered water bodies at temperatures ranging from 95 to 106 °F (35 to 41 °C) or higher, but this organism is rarely found in water cooler than 95 °F (35 °C), and infection rarely occurs at these water temperatures (Tyndall et al. 1989).

The maximum temperature of the discharge stream on September 11, 2007, was approximately 101.1 °F (38.4 °C), with a maximum ambient river temperature of 81.5 °F (27.5 °C) (AmerGen 2008). As described in the GEIS (NRC 1996), nuclear power plants that discharge to "small rivers" have the greatest chance of affecting the public by increases in thermophilic microbiological organism populations. A small river is defined as one with a monthly average flow rate of less than 2,800 m³/s (100,000 ft³/s). The annual average flow rate of the Susquehanna River at the nearest measuring station to TMI-1 is approximately 1.09x10¹² ft³/yr (3.08x10¹⁰ m³/yr), which equates to 978.1 cubic meters per second (m³/s) (34,540 cubic feet per second (ft³/s)) (Durlin and Schaffstall 2005). The average flow rate from the main station outfall is about 12,000 gpm (11.4 ft³/s). This flow rate is less than 1 percent of the annual average flow rate of the Susquehanna River. Thus, at a given volume of the discharge stream with a maximal temperature of 101.1 °F (38.4 °C), there will be approximately 100 equivalent diluting volumes of the Susquehanna River water with a maximal temperature of 81.5 °F (27.5 °C). When a higher temperature system comes in physical contact with a lower temperature system, there will be a net transfer of heat from the higher temperature system to the lower temperature system, until the two systems reach thermal equilibrium (Adkins 1984). As such, when the plant discharge temperature is at its maximum and the ambient Susquehanna River water is at its maximum, the temperature range of the Susquehanna River (below the discharge outfall) would maximally be 91.3 °F (33.0 °C). This temperature range is well outside the optimal growth temperature range of thermophilic microbiological organisms, which is between 122 °F and 150 °F (50 and 66 °C) (Joklik and Willett 1976). Hence, such organisms are not expected to cause any significant public health risks.

During the year, ambient river temperatures average 33.8 °F (1 °C) with a maximum temperature of 81.5 °F (27.5 °C) (NRC 1976). The maximum temperature of the discharge stream (at the discharge monitoring pit and before the water mixes with the Susquehanna River) on September 11, 2007, was approximately 101.1 °F (38.4 °C) (AmerGen 2008). The ambient river temperature was 81.5 °F (27.5 °C). Assume the temperature of the heated effluent area or mixing zone is 101.1 °F (38.4 °C), the lowest daily mean river flows are 34,540 ft³/s (978.1 m³/s) (Durlin and Schaffstall 2005), and the mixing zone is located 16 feet (4.88 meters) offshore and 82 feet (25 meters) downstream of the discharge monitoring pit (AmerGen 2008). These thermophilic microbiological organisms would be entrained through this thermal plume for about 30 seconds to less than five minutes, based on a river flow rate of 34,540 ft³/s (978.1 m³/s). Because the growth rate for thermophilic microbiological organisms is measured in hours to

Environmental Impacts of Operation

days (Hendricks 1972), it is not expected that the short period of plume passage would notably affect growth rates of thermophilic microbiological organisms compared to ambient river temperatures. Therefore, thermophilic microbiological organisms are not expected to cause any significant public health risks.

The current National Pollutant Discharge Elimination System (NPDES) permit requires TMI-1 to monitor fecal coliform in the plant's sewage treatment effluent. Fecal coliform bacteria are classified within the family Enterobacteriaceae. The most common species of fecal coliform is *Escherichia coli*, a prokaryotic, gram-negative, rod-shaped bacteria. The value of determining fecal coliform concentrations is to establish the extent to which the Susquehanna River has been polluted with fecal wastes. Their presence in the water indicates the potential for other pathogenic microbes, including those that cause typhoid fever, bacterial or viral gastroenteritis, or hepatitis A (NAS 2004). TMI-1 has been collecting river water samples once per quarter for fecal coliform analysis and has been implementing a disinfection program of the TMI-1 sewage treatment plant effluent in compliance with TMI-1 NPDES permit requirements. In addition, the NPDES permit requires TMI-1 to control disease-producing organisms during the swimming season (May 1 through September 30) through "effective disinfection" and to impose a fecal coliform count limit of 200 cells per 100 milliliters.

Exelon Generation consulted the PADEP Water Management Program to determine whether or not there was any concern about the potential occurrence of thermophilic microbiological organisms in the Susquehanna River at the TMI-1 location (AmerGen 2008). PADEP indicated that it agrees with Exelon Generation's conclusion that the discharge of cooling water from the operation of TMI-1 over the license renewal term would not stimulate growth of thermophilic pathogens (AmerGen 2008).

Available data assembled by the U.S. Centers for Disease Control and Prevention (CDC) for the years 1999 to 2004 (CDC 2001, 2002, 2002a, 2003, 2003a, 2004, 2005, 2006, 2007b) report no occurrence of waterborne disease outbreaks in the Commonwealth of Pennsylvania resulting from exposure to the thermophilic microbiological organisms *Naegleria fowleri* and *Pseudomonas aeruginosa* from the operation of TMI-1. Outbreaks of legionellosis, salmonellosis, or shigellosis that occurred in the Commonwealth of Pennsylvania were within the range of national trends (CDC 2001, 2002, 2002a, 2003, 2003a, 2004, 2005, 2006, 2007b) in terms of cases per 100,000 population or total cases per year, and the outbreaks were associated with hotel pools and spas.

The NRC staff independently reviewed the Exelon Generation ER and visited the TMI-1 site. Based on the evaluation previously stated, thermophilic microbiological organisms are not likely to present a public health hazard as a result of TMI-1 discharges to the Susquehanna River. The NRC staff concludes that impacts on public health from thermophilic microbiological organisms from continued operation of TMI-1 in the period of extended operation would be SMALL.

The staff identified a variety of measures that could mitigate the potential impacts of thermophilic microbiological organism resulting from continued operation of TMI-1. These mitigation measures include periodically monitoring for thermophilic microbiological organisms in the water and sediments near the discharge, as well as prohibiting recreational use near the discharge plume. These mitigation measures could reduce human health impacts by minimizing

public exposures to thermophilic microbiological organisms. The staff did not identify any cost-benefit studies applicable to the mitigation measures previously mentioned.

4.8.3 Electromagnetic Fields – Acute Effects (Electric Shock)

Based on the GEIS, the NRC found that electric shock resulting from direct access to energized conductors or from induced charges in metallic structures has not been a problem at most operating plants and generally is not expected to be a problem during the period of extended operation. However, a site-specific review is required to determine the significance of the electric shock potential along the portions of the transmission lines within the scope of the supplemental EIS.

The GEIS states that, without a review of the conformance of each nuclear plant transmission line with National Electrical Safety Code (NESC) (NESC 2007) rules, it is not possible to determine the significance of the electric shock potential. Evaluation of individual plant transmission lines is necessary because the issue of electric shock safety was not addressed in the licensing process for some plants. For other plants, land use in the vicinity of transmission lines may have changed, or power distribution companies may have chosen to upgrade line voltage. To comply with the requirements of 10 CFR 51.53(c)(3)(ii)(H), the applicant must provide an assessment of the potential shock hazard if the transmission lines that were constructed for the specific purpose of connecting the plant to the transmission system do not meet the recommendations of the NESC for preventing electric shock from induced currents.

An analysis of the conformance of the TMI-1 transmission lines with the NESC standard was conducted using computer-modeled data of induced current under the transmission lines. Objects located near the transmission lines can become electrically charged because of their immersion in the electromagnetic field surrounding the lines. This electrical charge results in a current that flows through the object to the ground. This current is called "induced" because there is no direct connection between the line and the object. The induced current can also flow to the ground through the body of a person who touches the electrically charged object. An object that is insulated from the ground can actually store an electrical charge, becoming what is called "capacitively charged." A person standing on the ground and touching a vehicle or a fence receives an electrical shock from the sudden discharge of the capacitive charge through the person's body to the ground. After the initial discharge, a steady-state current can develop, with the magnitude of the current depending upon several factors. These factors include the strength of the electric field (dependent on the voltage of the transmission line and its height and geometry), the size of the object on the ground, and the extent to which the object is grounded (AmerGen 2008).

As described above, four 230-kilovolt (kV) transmission lines were specifically constructed to distribute power from TMI-1 to the electrical grid. Exelon Generation began its analysis of these lines by identifying the limiting case for each line, that is, the configuration along each line where the potential for induced-current shock would be greatest. Once the limiting case was identified, the electric field strength for each transmission line was calculated, and the induced current was calculated. Exelon Generation calculated electric field strength and induced current using a computer code called ACDCLINE, produced by the Electric Power Research Institute. The results of this program have been field-verified through actual electrostatic field measurements by several utilities. The input parameters for the ACDCLINE program include the design

Environmental Impacts of Operation

features of the limiting-case scenario, the NESC requirement that line sag be determined at a conductor temperature of 120 °F, and the maximum vehicle size under the lines (a tractor-trailer). The analysis determined that none of the transmission lines has the capacity to induce greater than 5 milliamperes in a vehicle parked beneath the lines (Table 4-9). Therefore, the TMI-1 transmission lines conform to the NESC provisions for preventing electric shock from induced current (AmerGen 2008).

FirstEnergy has surveillance and maintenance procedures that provide assurance that design ground clearances will not change. These procedures include routine aerial inspections that check for evidence of clearance problems, including encroachments, broken conductors, broken or leaning structures, and signs of burning trees. In addition, ground-level inspections include examination of clearances at questionable locations, evaluation of the integrity of structures, and surveillance for dead or diseased trees that may fall on the lines. Problems noted during any inspection are identified for corrective action by the appropriate organization (AmerGen 2008).

Table 4-9. Results of Induced Current Analysis.

Transmission Line	Voltage (kilovolts)	Maximum Induced Current (milliamperes)
Line No. 1051-TMI-1 plant to Jackson	230	1.09
Line No. 1091-TMI-1 plant to Middletown Junction	230	1.38
Line No. 1092-TMI-1 plant to Middletown Junction	230	2.09
Line from TMI-1 plant to the 500-kV substation	230 ^(a)	1.33

(a) Line from TMI-1 plant to the 500-kV substation was designed to operate at 500 kilovolts, but it currently operates at 230 kilovolts

Source: AmerGen 2008

The staff has reviewed the available information, including the applicant's evaluation and computational results, the site visit, the scoping process, and other public sources of information. Based on this information, the staff evaluated the potential impacts of electric shock resulting from operation of TMI-1 and its associated transmission lines. The staff concludes that the potential impacts of electric shock during the renewal term would be SMALL.

The staff identified a variety of measures that could mitigate potential acute electromagnetic field impacts resulting from continued operation of the TMI-1 transmission lines. These mitigation measures include limiting public access to transmission line structures, installing signs at road crossings warning against idling beneath the lines, and increasing transmission line clearances.

These mitigation measures could reduce human health impacts by minimizing public exposures to electric shock hazards. NESC rules, as specified in Part 2, Rules 232C1c and 232D3c, contain provisions that are considered necessary for the protection of employees and the public from acute electromagnetic field hazards associated with transmission lines, which currently apply to TMI-1 and would apply during the period of extended operation. Exelon Generation currently meets these rules. The staff did not identify any cost benefit studies applicable to the

mitigation measures mentioned above.

4.8.4 Electromagnetic Fields – Chronic Effects

The GEIS did not designate the chronic effects of 60-hertz electromagnetic fields from power lines as either Category 1 or 2; such a designation will not occur until a scientific consensus is reached on the health implications of these fields.

The potential for chronic effects from these fields continues to be studied and is not known at this time. The National Institute of Environmental Health Sciences (NIEHS) directs related research through the U.S. Department of Energy (DOE). An NIEHS (1999) report contains the following conclusion which is supported by the recently published Environmental Health Criteria Monograph No. 238 (2007):

The NIEHS concludes that ELF-EMF [extremely low frequency-electromagnetic field] exposure cannot be recognized as entirely safe because of weak scientific evidence that exposure may pose a leukemia hazard. In our opinion, this finding is insufficient to warrant aggressive regulatory concern. However, because virtually everyone in the United States uses electricity and therefore is routinely exposed to ELF-EMF, passive regulatory action is warranted such as a continued emphasis on educating both the public and the regulated community on means aimed at reducing exposures. The NIEHS does not believe that other cancers or non-cancer health outcomes provide sufficient evidence of a risk to currently warrant concern.

This statement is not sufficient to cause the NRC staff to change its position with respect to the chronic effects of electromagnetic fields. This position is expressed in Footnote 5 to Table B-1 of Appendix B to Subpart A of 10 CFR Part 51 as follows:

If in the future, the Commission finds that, contrary to current indications, a consensus has been reached by appropriate Federal health agencies that there are adverse health effects from electromagnetic fields, the Commission will require applicants to submit plant-specific reviews of these health effects as part of their license renewal applications. Until such time, applicants for license renewal are not required to submit information on this issue.

The NRC staff considers the GEIS finding of “uncertain” still appropriate and will continue to follow developments on this issue.

4.9 Socioeconomics

The socioeconomic issues applicable to TMI-1 follow in Table 4-10 on the following page for Category 1, Category 2, and uncategorized issues.

Environmental Impacts of Operation

Table 4-10. Socioeconomic Issues. Section 2.2.9 of this report describes the socioeconomic conditions near TMI-1.

Issues	GEIS Section	Category
Housing Impacts	4.7.1	2
Public Services: public safety, social services, and tourism and recreation	4.7.3; 4.7.3.3; 4.7.3.4; 4.7.3.6	1
Public Services: public utilities	4.7.3.5	2
Public Services: education (license renewal)	4.7.3.1	1
Offsite Land Use (license renewal term)	4.7.4	2
Public Services: transportation	4.7.3.2	2
Historic and Archaeological Resources	4.7.7	2
Aesthetic Impacts (license renewal term)	4.7.6	1
Aesthetic impacts of transmission lines (license renewal term)	4.5.8	1
Environmental Justice	Not addressed ^(a)	Uncategorized ^(a)

(a) Guidance related to environmental justice was not in place at the time the GEIS and the associated revisions to 10 CFR Part 51 were prepared. Therefore, environmental justice must be addressed in plant-specific reviews.

4.9.1 Generic Socioeconomic Issues

The NRC staff reviewed and evaluated the TMI-1 ER, scoping comments, other available information, and visited TMI-1 in search of new and significant information that would change the conclusions presented in the GEIS. No new and significant information was identified during this review and evaluation. Therefore, it is expected that there would be no impacts related to these Category 1 issues during the period of extended operation beyond those discussed in the GEIS. For TMI-1, the staff incorporates the GEIS conclusions by reference. Impacts for Category 2 and uncategorized issues are discussed in Sections 4.9.2 through 4.9.7, below.

4.9.2 Housing Impacts

Appendix C to the GEIS presents a population characterization method based on two factors; sparseness and proximity (see Section C.1.4). Sparseness measures population density within 20 mi (32 km) of the site, and proximity measures population density and city size within 50 mi (80 km). Each factor has categories of density and size (see Table C.1). A matrix is used to rank the population category as low, medium, or high (see Figure C.1).

According to the 2000 Census, approximately 787,800 people lived within 20 mi (32 km) of TMI-1, which equates to a population density of 627 persons per square mile (AmerGen 2008). This density translates to the least sparse Category 4 (greater than or equal to 120 persons per

square mile within 20 mi [32 km]). Approximately 2,546,500 people live within 50 mi (80 km) of TMI-1 (AmerGen 2008). This equates to a population density of 325 persons per square mile. Applying the GEIS proximity measures, TMI-1 is classified as proximity Category 4 (greater than or equal to 190 persons per square mile within 50 mi [80 km]). Therefore, according to the sparseness and proximity matrix presented in the GEIS, TMI-1 rankings of sparseness Category 4 and proximity Category 4 result in the conclusion that TMI-1 is located in a high population area.

Table B-1 of Appendix B to Subpart A of 10 CFR Part 51 states that impacts on housing availability are expected to be of small significance in high-density population areas where growth control measures are not in effect. Since TMI-1 is located in a high population area, and Dauphin and Lancaster Counties are not subject to growth control measures that would limit housing development, any changes in TMI-1 employment would have little noticeable effect on housing availability in these counties. Since Exelon Generation has indicated that they have no plans to add non-outage employees during the license renewal period, non-outage employment levels at TMI-1 would remain relatively constant with no additional demand for permanent housing during the license renewal term. In addition, the number of available housing units has kept pace with or exceeded the increase in area population. Based on this information, there would be no impact on permanent housing during the license renewal term beyond what is currently being experienced.

However, Exelon Generation indicated in its ER that TMI-1 steam generators would be replaced prior to the license renewal term. Exelon Generation estimates that steam generator replacement would require a one-time increase in the number of refueling outage workers for up to 70 days at TMI-1 (AmerGen 2008). These additional workers would create an additional demand for temporary (rental) housing in the immediate vicinity of TMI-1. The impacts of TMI-1 steam generator replacement are discussed in Chapter 3 of this supplemental EIS.

4.9.3 Public Services: Public Utility Impacts

Impacts on public utility services are considered SMALL if there is little or no change in the ability of the system to respond to demand and thus there is no need to add capital facilities. Impacts are considered MODERATE if service capabilities are overtaxed during periods of peak demand. Impacts are considered LARGE if services (e.g., water, sewer) are substantially degraded and additional capacity is needed to meet ongoing demand. The GEIS indicated that, in the absence of new and significant information to the contrary, the only impacts on public utilities that could be significant are impacts on public water supplies.

Analysis of the impacts on the public water and sewer systems considered both plant demand and plant-related population growth. Section 2.2.8 of this supplemental EIS describes the TMI-1 permitted withdrawal rate and actual use of water.

Since Exelon Generation has indicated that they have no plans to add non-outage employees during the license renewal period, non-outage employment levels at TMI-1 would remain relatively unchanged with no additional demand for public water and sewer services. Public water systems in the region would be adequate to meet the demands of residential and industrial customers in the area. Therefore, impacts on public utility services by TMI-1 operation

Environmental Impacts of Operation

would be SMALL during the license renewal term because there would be no additional impact to public water and sewer services beyond what is currently being experienced.

As discussed in Section 4.9.2, Exelon Generation indicated in their ER that TMI-1 steam generators would be replaced prior to the license renewal term (AmerGen 2008). The additional number of refueling outage workers needed to replace the steam generators would cause a short-term increase in the amount of public water and sewer services used in the immediate vicinity of TMI-1. These impacts are discussed in Chapter 3 of this supplemental EIS.

4.9.4 Offsite Land Use – License Renewal Period

Table B-1 of Appendix B to Subpart A of 10 CFR Part 51 notes that “significant changes in land use may be associated with population and tax revenue changes resulting from license renewal.”

Section 4.7.4 of the GEIS defines the magnitude of land-use changes as a result of plant operation during the period of extended operation as follows:

SMALL - Little new development and minimal changes to an area's land-use pattern.

MODERATE - Considerable new development and some changes to the land-use pattern.

LARGE - Large-scale new development and major changes in the land-use pattern.

Tax revenue can affect land use because it enables local jurisdictions to provide the public services (e.g., transportation and utilities) necessary to support development. Section 4.7.4.1 of the GEIS states that the assessment of tax-driven land-use impacts during the license renewal term should consider (1) the size of the plant's payments relative to the community's total revenues, (2) the nature of the community's existing land-use pattern, and (3) the extent to which the community already has public services in place to support and guide development. If the plant's tax payments are projected to be small relative to the community's total revenue, tax-driven land-use changes during the plant's license renewal term would be SMALL, especially when the community has pre-established patterns of development and has provided adequate public services to support and guide development.

Section 4.7.2.1 of the GEIS states that if tax payments by the plant owner are less than 10 percent of the taxing jurisdiction's revenue, the significance level would be SMALL. If the plant's tax payments are projected to be medium to large relative to the community's total revenue, new tax-driven land-use changes would be MODERATE. If the plant's tax payments are projected to be a dominant source of the community's total revenue, new tax-driven land-use changes would be LARGE. This would be especially true when the community has no pre-established pattern of development or has not provided adequate public services to support and guide development.

Population-Related Impacts

Since Exelon Generation has indicated that they have no plans to add non-outage employees during the license renewal period, there would be no noticeable change in land use conditions in

the vicinity of TMI-1. Therefore, there would be no population-related land use impacts during the license renewal term beyond those already being experienced.

As discussed in Section 4.9.2, Exelon Generation indicated in their ER that TMI-1 steam generators would be replaced prior to the license renewal term (AmerGen 2008). Due to the short amount of time needed to replace the steam generators, the additional number of refueling outage workers would not cause any permanent population-related land use changes in the immediate vicinity of TMI-1. These impacts are discussed in Chapter 3 of this supplemental EIS.

Tax Revenue-Related Impacts

As previously discussed in chapter 2, Exelon Generation pays annual real estate taxes to Dauphin County, Londonderry Township, and the Lower Dauphin School District. For the three-year period from 2003 through 2005, tax payments to Dauphin County represented 0.2 percent of the County's total annual property tax revenues, and payments to Londonderry Township represented approximately 0.3 to 0.5 percent of the Township's total annual property tax revenues. Exelon Generation's tax payments to the Lower Dauphin School District, for the period 2003 through 2005, represented 1.7 to 2.3 percent of the District's total annual property tax revenues.

Since Exelon Generation started making payments to local jurisdictions, population levels and land use conditions in Dauphin County and Londonderry Township have not changed significantly, which might indicate that these tax revenues have had little or no affect on land use activities within the county. However, discontinuing the current level of tax revenues could have a negative economic impact on these jurisdictions and the Lower Dauphin School District.

Exelon Generation has indicated that they have no plans to add non-outage employees during the license renewal period, non-outage employment levels at TMI-1 would remain relatively unchanged. Accordingly, there would be no increase in the assessed value of TMI-1, and annual property tax payments to Dauphin County, Londonderry Township, and the Lower Dauphin School District would be expected to remain relatively unchanged throughout the license renewal period. Based on this information, there would be no land use impacts related to tax revenue during the license renewal term beyond those already being experienced.

As discussed in Section 4.9.2, Exelon Generation indicated in their ER that TMI-1 steam generators would be replaced prior to the license renewal term (AmerGen 2008). The replacement of the existing steam generators would not likely increase the assessed value of TMI-1, and property tax payments would remain unchanged. These impacts are discussed in Chapter 3 of this supplemental EIS.

4.9.5 Public Services: Transportation Impacts

Table B-1 of Appendix B to Subpart A of 10 CFR Part 51 states the following:

Transportation impacts (level of service) of highway traffic generated...during the term of the renewed license are generally expected to be of small significance. However, the increase in traffic associated with additional workers and the local road and traffic control conditions may lead to impacts of moderate or large significance at some sites.

Environmental Impacts of Operation

All applicants are required by 10 CFR 51.53(c)(3)(ii)(J) to assess the impacts of highway traffic generated by the proposed project on the level of service of local highways during the term of the renewed license.

| Since Exelon Generation has no plans to add non-outage employees during the license renewal period; there would be no noticeable change in traffic volume and levels of service on roadways in the vicinity of TMI-1. Therefore, there would be no transportation impacts during the license renewal term beyond those already being experienced.

| As discussed in Section 4.9.2, Exelon Generation indicated in their ER that TMI-1 steam generators would be replaced prior to the license renewal term (AmerGen 2008). The additional number of refueling outage workers and truck material deliveries needed to support the replacement of the steam generators would cause a one-time short-term transportation impact on access roads in the immediate vicinity of TMI-1. These impacts are discussed in Chapter 3 of this supplemental EIS.

4.9.6 Historic and Archaeological Resources

The National Historic Preservation Act (NHPA) requires Federal agencies to consider the effects of their undertakings on historic properties. Historic properties are defined as resources that are eligible for listing on the National Register of Historic Places (NRHP). The criteria for eligibility are listed in Title 36, "Parks, Forests, and Public Property," Part 60, Section 4, "Criteria for Evaluation," of the *Code of Federal Regulations* (36 CFR Part 60.4) and include (1) association with significant events in history; (2) association with the lives of persons significant in the past; (3) embodies distinctive characteristics of type, period, or construction, and (4) or sites or places that have yielded or are likely to yield important information (ACHP 2008). The historic preservation review process (Section 106 of the NHPA) is outlined in regulations issued by the Advisory Council on Historic Preservation in Title 36, "Parks, Forests, and Public Property," Part 800, "Protection of Historic Properties," of the *Code of Federal Regulations* (36 CFR Part 800). The issuance of a renewed operating license for a nuclear power plant is a federal action that could possibly affect either known or undiscovered historic properties located on or near the plant site and its associated transmission lines. In accordance with the provisions of the NHPA, the NRC is required to make a reasonable effort to identify historic properties in the area of potential effect. The area of potential effect (APE) for a license renewal action is the area at the power plant site and its immediate environs that may be impacted by post-license renewal land-disturbing operations or projected refurbishment activities associated with the proposed action. If no historic properties are present or affected, the NRC is required to notify the State Historic Preservation Office before proceeding. If it is determined that historic properties are present, the NRC is required to assess and resolve possible adverse effects of the undertaking. While Exelon Generation owns Three Mile Island, the APE is confined to the northern portion of the island where the plant is located. The following discussion summarizes the historic and archaeological research that has been conducted on the island.

| Exelon Generation contacted the Pennsylvania Historical and Museum Commission (PHMC) on May 22, 2007, requesting information on historic and archaeological resources and describing the proposed action (AmerGen 2008). In a letter dated June 4, 2007, the PHMC stated that the activities described in the proposed action should have no effect on historic and archaeological

resources (AmerGen 2008). The PHMC requested that if the applicant becomes aware of any unidentified historic buildings, structures, or archaeological resources located on site, or if the project could have an effect on historic properties, the PHMC should be contacted immediately (AmerGen 2008). In accordance with 36 CFR 800.8(c), the NRC contacted the PHMC (NRC 2008a), the Advisory Council on Historic Preservation (NRC 2008b), and the appropriate Federally-recognized Native American Tribes to initiate consultation. These letters are contained in Appendix D of this report.

As previously discussed in Section 2.2.9, a search of the PHMC site files identified nine prehistoric sites and one historic site on Three Mile Island. One of the sites, 36Da98 was a possible find spot reported by a local collector south of the powerblock. No time period was determined for the 36Da98 and portions of the site could still be intact and should be avoided. Sites 36Da96 and 36Da97 were located in a cultivated area which later became the construction site for TMI-1 and TMI Unit 2. Portions of the 36Da96 could also be intact due to its location on the edge of the construction zone. Site 36Da97 was destroyed by the construction of TMI-1 and TMI Unit 2. One additional site 36Da52 was recorded by the William Penn Memorial Museum in 1967. It is unclear whether 36Da52 was destroyed during the construction of TMI-1 and TMI Unit 2 because it was also situated on the edge of the construction area.

Site 36Da50 is a large multi-component occupation that was excavated prior to the construction of TMI-1 and TMI Unit 2. During the walkover survey, it was noted that the northernmost portions of 36Da50 remain and it is an area that should be avoided. Sites 36Da99, 36Da100, and 36Da101 are large multi-component occupation sites near the riverbank. 36Da101 also contains historic artifacts. Another prehistoric occupation site is 36Da51. While test units recovered a low concentration of artifacts, portions of this site may still be intact and should be avoided. These archaeological and historic sites have the potential to contribute a large amount of prehistoric information. Archaeological surveys and reports indicate that undisturbed portions of Three Mile Island could contribute to the archaeological record of the lower Susquehanna River valley. Archaeological investigations should be conducted if ground disturbing activities would occur in undisturbed areas of the island.

In addition to the prehistoric sites mentioned above, Three Mile Island also contains historic sites. As noted earlier, a historic farmstead was identified (36Da235) during NRC's walkover survey of Three Mile Island. A preliminary Pennsylvania Archaeological Site Survey form was completed by Exelon Generation, however, documentation is incomplete. This site must be recorded and evaluated for eligibility to the National Register of Historic Places (NRHP). Additionally, remnants of the Pennsylvania Canal's Eastern Division (Eastern Division Canal) are located on the eastern shore of the Susquehanna River next to Exelon Generation's property. Another potential resource of historic significance on Three Mile Island is TMI Unit 2. TMI Unit 2 could be considered potentially eligible for listing on the NRHP under Criterion A, as a site of exceptional importance, and Criteria Consideration G, as a property achieving significance within the past 50 years; but its eligibility has not yet been determined. While Exelon Generation does not own TMI Unit 2, Exelon Generation will cooperate with FirstEnergy Corporation and the PHMC to further record and evaluate both TMI Unit 2 and the historic farmstead for NRHP eligibility (Exelon 2009a).

Exelon Generation has indicated no plans to change or modify the plant or transmission line structures. However, because of the high potential for the presence of historic and archaeological resources, Exelon Generation should take care during continued operations and

Environmental Impacts of Operation

maintenance activities to not affect these resources. Exelon Generation's review procedures for onsite ground disturbing activities take into account the protection of historic and archaeological resources. Since publication of the draft supplemental EIS, Exelon Generation has revised its procedures to provide guidance regarding the protection of historic and archaeological resources, and has implemented a stop work provision if these resources are inadvertently discovered. It should be noted in the procedures that previously disturbed lands are areas that were disturbed by the construction of TMI-1 and TMI Unit 2. Plow zone disturbance (farming) is not considered previously disturbed land because the depth of disturbance is minimal. If ground disturbing activities are planned that may adversely affect these resources, then Exelon Generation should hire a qualified archaeologist to survey the proposed site prior to construction. To date, Exelon Generation has employed cultural resource management firms to ensure that ground disturbing activities would not adversely affect historic and archaeological resources.

Exelon Generation will develop and implement a cultural resources management plan (CRMP) that will consider the impacts of plant operation on historic and archaeological resources. The CRMP will also include periodic monitoring of erosion along shoreline areas (Exelon Generation 2009a). The CRMP will be developed in consultation with the PHMC and the NRC. Additionally Exelon Generation will receive Section 106 training (Exelon Generation 2009a).

As discussed in Chapter 3, Exelon Generation plans to replace the existing steam generators for TMI-1. A dedicated storage facility to house the replaced generators will be constructed within the existing industrial footprint of the site and will be located in an area that has been previously disturbed (AmerGen 2008). The NRC staff has reviewed the potential environmental impacts of this activity in Chapter 3 of this supplemental EIS.

No adverse impacts to known historic and archaeological resources are expected from the continued operation of TMI-1 during the license renewal term. Based on the review of PHMC files, archaeological surveys, assessments, and other information, the potential impacts on historic and archaeological resources at TMI-1 would be SMALL. Exelon Generation further mitigated the NRC finding of SMALL impact in the draft supplemental EIS by committing to develop and implement a CRMP and by training staff in the Section 106 process. The revised procedures and the CRMP integrate cultural resource considerations with ongoing TMI-1 activities. Staff training will aid Exelon Generation staff in making informed decisions when considering the effects of continued operations and future projects on historic and archaeological resources. As previously discussed, lands not previously surveyed should be investigated by a professional archaeologist prior to any ground disturbance. In addition, the historical farmstead site (36Da235) should be recorded and evaluated for eligibility.

4.9.7 Environmental Justice

Under Executive Order 12898 (59 FR 7629), Federal agencies are responsible for identifying and addressing potentially disproportionately high and adverse human health and environmental impacts on minority and low-income populations. In 2004, the Commission issued a Policy Statement on the Treatment of Environmental Justice Matters in NRC Regulatory and Licensing Actions (69 FR 52040), which states, "The Commission is committed

to the general goals set forth in Executive Order 12898, and strives to meet those goals as part of its NEPA review process.”

The Council of Environmental Quality (CEQ) provides the following information in its 1997 report entitled, “Environmental Justice: Guidance Under the National Environmental Policy Act”:

Disproportionately High and Adverse Human Health Effects. Adverse health effects are measured in risks and rates that could result in latent cancer fatalities, as well as other fatal or nonfatal adverse impacts on human health. Adverse health effects may include bodily impairment, infirmity, illness, or death.

Disproportionately high and adverse human health effects occur when the risk or rate of exposure to an environmental hazard for a minority or low-income population is significant (as defined by NEPA [National Environmental Policy Act]) and appreciably exceeds the risk or exposure rate for the general population or for another appropriate comparison group (CEQ 1997).

Disproportionately High and Adverse Environmental Effects. A disproportionately high environmental impact that is significant (as defined by NEPA) refers to an impact or risk of an impact on the natural or physical environment in a low-income or minority community that appreciably exceeds the environmental impact on the larger community. Such effects may include ecological, cultural, human health, economic, or social impacts. An adverse environmental impact is an impact that is determined to be both harmful and significant (as defined by NEPA). In assessing cultural and aesthetic environmental impacts, impacts that uniquely affect geographically dislocated or dispersed minority or low-income populations or American Indian tribes are considered (CEQ 1997).

The environmental justice analysis assesses the potential for disproportionately high and adverse human health or environmental effects on minority and low-income populations that could result from the operation of TMI-1 during the renewal term. In assessing the impacts, the following CEQ (1997) definitions of minority individuals and populations and low-income population were used:

Minority individuals. Individuals who identify themselves as members of the following population groups: Hispanic or Latino, American Indian or Alaska Native, Asian, Black or African American, Native Hawaiian or Other Pacific Islander, or two or more races meaning individuals who identified themselves on a Census form as being a member of two or more races, for example, Hispanic and Asian.

Minority populations. Minority populations are identified when (1) the minority population of an affected area exceeds 50 percent or (2) the minority population percentage of the affected area is meaningfully greater than the minority population percentage in the general population or other appropriate unit of geographic analysis.

Environmental Impacts of Operation

Low-income population. Low-income populations in an affected area are identified with the annual statistical poverty thresholds from the Census Bureau's Current Population Reports, Series PB60, on Income and Poverty.

Minority Population in 2000

According to the 2000 census data, 11 percent of the population (approximately 2,536,000 individuals) residing within a 50-mi (80-km) radius of TMI-1 identified themselves as minority individuals. The largest minority group was Black or African American (131,000 persons or 5.2 percent), followed by Hispanic or Latino of any race (107,000 or about 4.2 percent) (USCB 2003 – LandView 6). About 24.4 percent of the Dauphin County population identified themselves as minorities, with Black or African American the largest minority group (16.9 percent) followed by Hispanic or Latino (4.1 percent) (USCB 2008) (see Table 2-12).


The 50-mi (80 km) radius around TMI-1 includes 16 counties in Pennsylvania and six counties in Maryland. The geographic area includes any census block group with part of its area within the 50-mi (80 km) radius. Of the 1,931 census block groups located wholly or partly within the 50-mi (80 km) radius of TMI-1, 155 block groups were determined to have high density minority population percentages that exceeded the Pennsylvania average by 20 percentage points or more. The largest number of high density minority block groups was Black or African American, with 78 block groups that exceed the Pennsylvania average of 20 percent or more. These block groups are concentrated in urban areas with high population densities. The greatest number of high density block groups with minority populations are located in four Pennsylvania counties (Berks, Dauphin, Lancaster, and York). The closest high density minority population to TMI-1 is located in Harrisburg, Pennsylvania.

Based on the 2000 census data, Figure 4-1 shows the location of high density minority block groups within a 50-mi radius of TMI-1.

Low-Income Population in 2000

According to 2000 census data, approximately 36,000 families and 188,000 individuals (approximately 5.3 and 7.4 percent, respectively) residing within a 50-mi (80-km) radius of TMI-1 were identified as living below the Federal poverty threshold in 1999 (USCB 2003 – LandView 6). The 1999 Federal poverty threshold was \$17,029 for a family of four.

According to Census data, the median household income for Pennsylvania in 2006 was \$46,259, while 12.1 percent of the State population was determined to be living below the Federal poverty threshold. Dauphin County had higher median household incomes (\$49,093) and a lower percentage (10.1 percent) of individuals living below the poverty level when compared to the State. Lancaster County had a much higher median household income in 2006 (\$52,064) and a lower percentage (9.2 percent) of individuals living below the poverty level when compared to the State and Dauphin County (USCB 2008). Census block groups were considered high density low-income block groups if the percentage of households below the Federal poverty threshold exceeded the Pennsylvania average by 20 percent or more. Based on 2000 Census data, there were 66 block groups within the 50-mi (80 km) radius of TMI-1 that exceeded the Pennsylvania average for low income households by 20 percent or more. The majority of census block groups with low-income populations were located in two counties,



Legend

- ★ Three Mile Island Nuclear Station Unit 1
- Aggregate of Races Minority
- ▨ Water
- ▨ Urban Area
- ▭ State Boundary
- ▭ County Boundary





Figure 4-1. Aggregate Minority Populations Within 50 Mi (80 km) of Three Mile Island Nuclear Station, Unit 1 (AmerGen 2008)

Environmental Impacts of Operation




Figure 4-2. Low Income Populations Within 50 Mi (80 km) of Three Mile Island Nuclear Station, Unit 1 (AmerGen 2008)

Berks County (16 block groups) and Dauphin County (12 block groups) in Pennsylvania. The nearest high density low-income population to TMI-1 is located in Harrisburg, Pennsylvania. Figure 4-2 shows the location of high density low-income census block groups within a 50-mi (80-km) radius of TMI-1.

Analysis of Impacts

Consistent with the impact analysis for the public and occupational health and safety, the affected populations are defined as minority and low-income populations who reside within a 50-mi (80-km) radius of TMI-1. Based on the analysis of environmental health and safety impacts presented in this supplemental EIS for other resource areas, there would be no disproportionately high and adverse impacts to minority and low-income populations from the continued operation of TMI-1 during the license renewal period.

As discussed in Section 4.9.2, Exelon Generation indicated in their ER that TMI-1 steam generators would be replaced prior to the license renewal term. Exelon Generation estimates that steam generator replacement would require a one-time increase in the number of refueling outage workers for up to 70 days at TMI-1 (AmerGen 2008a). These additional workers would have little noticeable affect on minority and/or low-income populations in the region. These impacts are discussed in Chapter 3 of this supplemental EIS.

NRC also analyzed the risk of radiological exposure through the consumption patterns of special pathway receptors, including subsistence consumption of fish, native vegetation, surface waters, sediments, and local produce; absorption of contaminants in sediments through the skin; and inhalation of plant materials. The special pathway receptors analysis is important to the environmental justice analysis because consumption patterns may reflect the traditional or cultural practices of minority and low-income populations in the area.

Subsistence Consumption of Fish and Wildlife

Section 4-4 of Executive Order 12898 (1994) directs Federal agencies, whenever practical and appropriate, to collect and analyze information on the consumption patterns of populations who rely principally on fish and/or wildlife for subsistence and to communicate the risks of these consumption patterns to the public. In this supplemental EIS, NRC considered whether or not there were any means for minority or low-income populations to be disproportionately affected by examining impacts to American Indian, Hispanic, and other traditional lifestyle special pathway receptors. Special pathways that took into account the levels of contaminants in native vegetation, crops, soils and sediments, surface water, fish, and game animals on or near the TMI-1 site were considered.

Historic analyses of deer meat samples collected at TMI-1 from 1990 through 1997 found concentrations of cesium-137, tritium, and strontium-90. Cesium-137 was only detected in control samples (AmerGen 2008c). Since cesium-137 was not found in indicator samples, the presence of cesium-137 could be attributed to past fallout from nuclear weapons tests. Tritium was found in both indicator and control deer meat samples during this time period at concentrations similar to each other and similar to concentrations of tritium detected in other control food products such as milk, fruits, and vegetables (AmerGen 2008c). Since tritium occurs naturally in the environment and since the levels of concentrations were similar, the presence of tritium in both control and indicator samples therefore could not be directly attributed to TMI-1 operations. Strontium-90 was found in only one deer meat sample collected

Environmental Impacts of Operation

in 1992 and was consistent with the concentration found in one 1989 control sample (AmerGen 2008c). Therefore, the presence of strontium-90 in the deer meat sample could also be attributed to past fallout from nuclear weapons tests.

Exelon Generation has an ongoing comprehensive Radiological Environmental Monitoring Program (REMP) at TMI-1 to assess the impact of site operations on the environment. Samples are collected from the aquatic and terrestrial pathways in the vicinity of TMI-1 and TMI Unit 2. The aquatic pathways include fish, Susquehanna River surface water, ground water, and sediment. The terrestrial pathways include airborne particulates, milk, and food product garden (leaf)

vegetation, and direct radiation. During 2007, 1,718 analyses were performed on 1,318 collected samples of environmental media as part of the required REMP and showed no significant or measurable radiological impact from TMI-1 operations (AmerGen 2008b).

During 2007, cesium-137, strontium-90, and tritium were the only potentially plant-related radionuclides detected in environmental samples. No radionuclides other than naturally occurring and tritium were detected in the Susquehanna River water samples collected in 2007.

Tritium, the presence of which is likely to be due to plant operations, has been detected in the past, was detected in 8 of 24 surface water samples taken downstream of the effluent outfall in concentrations well below regulatory limits. Tritium was also detected in 3 of 36 drinking water samples at slightly above the lower limit of detection. Cesium-137 was identified in sediment samples in 2007 at very low levels (just above the lower limit of detection), and were not distinguishable from background levels (AmerGen 2008b).

Strontium-90 was detected in 11 of 21 milk samples collected in 2007. The amount of activity detected was consistent with those detected in the pre-operational years. Strontium-90 was also detected in 24 of 26 food product samples in both the indicator and control samples (AmerGen 2008b). The source of the strontium-90 could be attributed to residual fallout from weapons testing.

The results of the 2007 REMP demonstrate that routine operation at TMI-1 had no significant or measurable radiological impact on the environment. No elevated radiation levels were detected in the offsite environment as a result of plant operations and the storage of radioactive waste. The results of the REMP continue to demonstrate that the operation of TMI-1 does not result in a significant measurable dose to a member of the general population or adversely impact the environment as a result of radiological effluents. The REMP continues to demonstrate that the dose to a member of the public from the operation of TMI-1 remains significantly below the federally required dose limits specified in 10 CFR Part 20 and 40 CFR Part 190.

The PADEP BRP maintains a comprehensive environmental radiation monitoring program in Pennsylvania, as required by the "Radiation Protection Act" (No. 1984-147). The purpose of the program is to evaluate long-term trends in environmental radiation levels; assess the environmental impact of particular sites, such as TMI-1; and provide this information to the public. The BRP currently maintains off-site environmental radiation monitoring programs around five nuclear power plants in Pennsylvania including TMI-1. Monitoring stations serve as indicators of any effects from plant operation and at control locations, which are beyond the measurable influence of the facility. These stations also provide verification of utility effluent monitoring programs during routine operations.

Each year, BRP collects dosimetry, air, water, milk, fish, produce, and sediment samples in the vicinity of TMI-1. Fish samples were collected in the vicinity of the TMI-1 discharge and produce samples of cabbage were collected from a truck garden located 0.4 mi east of TMI-1 in 2003 and 2004. No reactor-related radioisotopes were detected in the fish and produce samples. BRP also found no traces of cesium-137 in milk samples taken monthly at two local farms. Cesium-137 was detected in sediment samples collected upstream (control) and downstream (indicator) of the TMI-1 discharge. The presence of cesium-137 could be attributed to fallout from past weapons testing and the accident at Chernobyl in April 1986. BRP also found no reactor-related radioisotopes in fish and produce samples collected in 2001 and 2002 (PADEP BRP 2008).

Based on recent monitoring results, concentrations of radiological contaminants in native leafy vegetation, soils and sediments, surface water, and fish in areas surrounding TMI-1 have been quite low (at or near the threshold of detection) and seldom above background levels. Consequently, no disproportionately high and adverse human health impacts would be expected in special pathway receptor populations in the region as a result of subsistence consumption of fish and wildlife.

4.10 Evaluation of New and Potentially Significant Information

New and significant information is (1) information that identifies a significant environmental issue not covered in the GEIS and codified in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, or (2) information that was not considered in the analyses summarized in the GEIS and that leads to an impact finding that is different from the finding presented in the GEIS and codified in 10 CFR Part 51.

In preparing to submit its application to renew the TMI-1 operating license, Exelon Generation developed a process to ensure that information not addressed in or available during the GEIS evaluation regarding the environmental impacts of license renewal for TMI-1 would be properly reviewed before submitting the ER, and to ensure that such new and potentially significant information related to renewal of the operating license for TMI-1 would be identified, reviewed, and assessed during the period of NRC review. Exelon Generation reviewed the Category 1 issues that appear in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, to verify that the conclusions of the GEIS remained valid with respect to TMI-1. This review was performed by personnel from TMI-1 and its support organization who were familiar with NEPA issues and the scientific disciplines involved in the preparation of a license renewal ER.

The NRC staff also has a process for identifying new and significant information. That process is described in detail in NUREG-1555, Supplement 1, *Standard Review Plans for Environmental Reviews for Nuclear Power Plants, Supplement 1: Operating License Renewal* (NRC 2000). The search for new information includes (1) review of an applicant's ER and the process for discovering and evaluating the significance of new information; (2) review of records of public comments; (3) review of environmental quality standards and regulations; (4) coordination with Federal, State, and local environmental protection and resource agencies; and (5) review of the technical literature. New information discovered by the NRC staff is evaluated for significance using the criteria set forth in the GEIS. For Category 1 issues where new and significant information is identified, reconsideration of the conclusions for those issues is limited in scope to

Environmental Impacts of Operation

the assessment of the relevant new and significant information. The scope of the assessment does not include other facets of the issue that are not affected by the new information.

The NRC staff has not identified any new and significant information on environmental issues listed in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, related to the operation of TMI-1 during the period of license extension. The NRC staff also determined that information provided during the public comment period did not identify any new issues that require site-specific assessment. The NRC staff reviewed the discussion of environmental impacts in the GEIS (NRC 1996) and conducted its own independent review (including the public scoping meetings held in May 2008) to identify new and significant information.

4.11 Cumulative Impacts

The NRC staff considered potential cumulative impacts in the environmental analysis of continued operation of TMI-1. For the purposes of this analysis, past actions are those related to the resources at the time of the power plant licensing and construction, present actions are those related to the resources at the time of current operation of the power plant, and future actions are considered to be those that are reasonably foreseeable through the end of plant operation including the period of extended operation. Therefore, the analysis considers potential impacts through the end of the current license terms as well as the 20-year renewal license term. The geographic area over which past, present, and future actions would occur is dependent on the type of action considered and a description follows for each impact area.

The impacts of the proposed action, as described in Sections 4.1–4.9, are combined with other past, present, and reasonably foreseeable future actions regardless of what agency (Federal or non-Federal) or person undertakes such other actions.

4.11.1 Cumulative Impacts on Water Resources

The SRBC regulates consumptive water use at TMI-1 and at all facilities drawing water from the Susquehanna River and the river basin. The SRBC is an independent agency that develops, effectuates, coordinates and adopts plans, policies, and programs related to water resources in the Susquehanna River basin (SRBC 2008). According to the SRBC, 89 percent of water use in the Lower Susquehanna River Basin (Lower Subbasin) is for power generation, 4.8 percent for industrial use, 4.2 percent for municipal use, 1.2 percent for agricultural use, and 0.8 percent for domestic use (SRBC 2007). TMI-1 has a permit with SRBC for consumptive use of river water up to 18 million gallons per day (mgd), on a 30-day average, for electric generation. TMI-1 also participates in the Cowanesque Lake water allocation project, which releases water to the Susquehanna River to augment flow during periods of drought (AmerGen 2008).

TMI-1 has seven onsite ground water wells, and uses ground water for various industrial operations and for drinking water on site, as permitted by the SRBC. This water is primarily drawn from the Gettysburg shale aquifer located directly beneath the site (AmerGen 2008). The SRBC monitors and manages ground water use in the area including and surrounding Three Mile Island under the "Groundwater Management Plan for the Susquehanna River Basin," which was initiated in 1993 (SRBC 2005). The SRBC estimates that the use of ground water in the

Susquehanna River Basin is approximately 390 mgd. The main use in the basin is to supply drinking water wells, with the largest consumers being public water suppliers (115 mgd), followed by mining sites (90 mgd), domestic consumers (80 mgd), industrial consumers (48 mgd), agricultural consumers (42 mgd), and commercial consumers (12 mgd) (SRBC 2005).

According to the most recently issued draft ground water management plan (SRBC 2005), the quality of ground water in the Susquehanna River Basin is generally good, with the most common impacts being the geology of the area and land use. Degradation of ground water in the area is largely a result of abandoned coal mines (acid mine drainage) as well as agricultural and residential use of pesticides and contaminants. A particular problem addressed by the SRBC is the diversion of stormwater runoff into sinkholes, which essentially delivers the water directly to the aquifer. Section 4.11.2 of this report discusses ground water quality and its impacts on aquatic resources of the Susquehanna River in more depth. Other significant issues outlined by the SRBC management plan include increases in land development, overuse of ground water resources, transfer of discharge wastewater to a different watershed, unregulated use of ground water resources, drought impacts, and the need for flow compensation for consumptive water users in the basin (SRBC 2005).

The potential cumulative effects of climate change on the Susquehanna River basin, whether from natural cycles in climate or related to anthropogenic activities, could result in a variety of changes to the surface and ground water resources in the Susquehanna River basin. A report issued by the Union of Concerned Scientists in October 2008 (UCS 2008) on climate change in Pennsylvania predicted that from the years 2010–2039, average annual temperatures across Pennsylvania could increase by 2.5–3.0 degrees Fahrenheit (°F). Temperatures will warm the most in summer and winter; fall and spring will experience smaller temperature increases. Extreme heat events in summer are expected to increase in number, intensity, and duration.

Some of the most significant anticipated impacts of climate change could result from changes in surface and ground water hydrology. Across Pennsylvania, precipitation is expected to increase by more than 5 percent above historical average, with increases in seasonal rainfall occurring mainly in spring and fall. More heavy rainfall events (defined as more than 2 inches of rain in a 24-hour period) are expected to occur. Increased rainfall would increase stream and river flow and recharge ground water aquifers, alleviating low-flow issues in the Susquehanna River during those periods. Adverse effects of heavy precipitation include impacts on water quality of surface and ground water, contamination of drinking wells, and more frequent flooding events. Conversely, warmer temperatures and changing timing and distribution of precipitation could lead to an increase in droughts during summer months. (UCS 2008) Warmer temperatures and heat waves could spur increased demand in electricity for cooling purposes, potentially resulting in power plants located on the Susquehanna River using more river water to support higher energy output—a cycle that would exacerbate low-flow conditions in the river.

The SRBC regulatory program, which includes the regulation of withdrawals, monitoring and enforcement duties, and the ability to designate protected areas, manages the basin's ground water resources. The regulatory program also allows for the development of ground water quality standards and conservation requirements. Additionally, the ground water management plan focuses on public outreach and education (SRBC 2005).

Environmental Impacts of Operation

Recently there has been strong interest in the development of gas well drilling of the Marcellus shale, a gas reservoir stretching from Pennsylvania into Ohio and West Virginia which some claim contains enough gas to satisfy U.S. demand for two years (Buurma 2008; SRBC 2008). With the recent success of drilling the Barnett shale in Texas and new technological advances in horizontal drilling, several drilling companies have taken serious interest in the Appalachian area (SRBC 2008). The gas drilling process involves both horizontal drilling and the use of a technique known as hydraulic fracturing or, "hydrofracking". Hydrofracking is the high-pressure injection of a combination of sand, water, and chemicals into rock to fracture it and make it more permeable (Buurma 2008). The chemicals used in hydrofracking, however, are toxic and have the potential to contaminate drinking water and ground water systems. There is less concern over the transfer of these chemicals into ground water supplies simply because the wells are far deeper (4,000 to sometimes 8,000 ft deep) than the water-bearing aquifers (SRBC 2008). However, there is concern over the disposal of the toxic drilling water and where and how it will be discharged. Before any drilling can begin, each company must apply to the SRBC for various water use permits. In August 2008, SRBC made the decision to require all natural gas drilling projects to apply for water withdrawal permits, regardless of the amount of water being withdrawn, as well as to raise the area's consumptive use mitigation fee (SRBC 2008).

To ensure that surface water and ground water resources of the Susquehanna River basin continue to meet the needs of the basin population, in addition to enforcing water use regulations, the SRBC coordinates with State and Federal agencies, conducts extensive water resources monitoring, project review, water withdrawal registration, drought coordination, flood management, low-flow management (i.e., water storage), reservoir feasibility studies, and ground water management (SRBC 2008). On the basis of this information, the independent review by the NRC staff concludes that the cumulative impact to water resources during the license renewal period would be SMALL.

4.11.2 Cumulative Impacts on Aquatic Resources

This section addresses past, present, and future actions that could result in adverse cumulative impacts on aquatic resources. For the purpose of this analysis, the geographic area considered for cumulative impacts on aquatic resources at TMI-1 is the Lower Subbasin, which is one of the six Susquehanna River major subbasins. The Lower Subbasin runs south from Sunbury in Northumberland County, PA, to Havre de Grace, MD. The lower Subbasin discharges into the Chesapeake Bay.

The Lower Subbasin, which drains approximately 5,809 square miles (mi²) (15,045 square kilometers [km²]) of land, is the most developed of the six Susquehanna River subbasins. The cities of Harrisburg, Lancaster, York, Lebanon, and Carlisle are contained within the Lower Subbasin. The subbasin is characterized by a mixture of land uses including residential areas, agricultural land, undeveloped land, forests, and recreational areas (SRBC 2008). The northern section of the Lower Subbasin consists primarily of forested areas interspersed with agriculture and residential areas, while the southern half of the subbasin is dominated by agriculture and urban areas, with some undeveloped areas, parks, and recreation areas (SRBC undated).

Almost a century of intensive anthracite coal mining within the Wyoming Valley seriously impaired the Susquehanna River's water quality and ecological resources. The river received

highly acidic, iron-rich drainage from numerous mining sites that operated from the late 1800s through the early 1970s. These sites were mostly in the upper subbasins of the Susquehanna River; however, the Lower Subbasin was also impacted due to the natural flow of the river and the movement of pollutants downstream. Anthracite mining in Pennsylvania reached its peak around 1930 and ceased almost entirely in 1972, in part because of the evolving fossil fuel economy and tightening water quality regulations. However, the mines continued to leak iron-contaminated acidic runoff to streams that fed the river for many years following their abandonment. In addition to high levels of total iron and other dissolved heavy metals, mining effluents were also responsible for the high sulfate content, and low pH and dissolved oxygen levels in the river (CBF 2006).

Between 1972 and 1981, considerable improvement in the water quality of the Susquehanna River was noted. During this period, the volume of mining effluents being discharged to the river decreased. The reduction in mining caused a decrease in solids, iron, and sulfate concentrations throughout the Susquehanna River. These trends on improved water quality have continued, and will most likely continue as long as mining is kept at a minimum.

Agriculture and livestock production in the Lower Subbasin have contributed to declines in river water quality. Nutrient discharges including nitrates, nitrogen, phosphorus, and orthophosphates from runoff of pesticide and fertilized agricultural and livestock lands have been a primary source of decreased water quality (CBF 2005). Agricultural practices from the land along the Lower Subbasin have caused decreased river water quality in the Chesapeake Bay (CBF 2005).

Numerous wastewater treatment plants are located along the Lower Subbasin, discharges from which can contribute to decreases in river water quality. Treated water leaving wastewater plants can have increased levels of phosphates, orthophosphates, and chlorine (SRBC 2006). During high storm events, untreated overflow from treatment plants can add additional nutrient runoff to the Susquehanna River.

As mentioned previously, the Lower Subbasin runs through more urban areas of Pennsylvania such as Harrisburg, Lancaster, and York. Urbanized areas contain more impervious surfaces than other land uses; this increases stormwater runoff to waterways and causes subsequent decreases in river water quality.

Anthropogenic sources of pollution will likely be an ongoing issue for the Susquehanna River. However, the SRBC, PADEP, and other environmental groups such as the Chesapeake Bay Foundation are working collaboratively in their efforts to conduct basin-wide monitoring and promote watershed protection and management. Furthermore, PADEP will continue to enforce water quality regulations through its NPDES permitting program. NPDES permits, issued by the PADEP Bureau of Water Supply and Wastewater Management, will continue to regulate municipal and industrial effluents to the Susquehanna River. The PADEP periodically reviews and renews NPDES permits; thus it is reasonable to predict that the improving trends in the Susquehanna River's water quality will likely continue throughout the license renewal period.

Construction of hydroelectric dams on the river in the Lower Subbasin has also created significant impacts on the aquatic ecosystem; and as power needs in Pennsylvania increase in the future, it is reasonable to predict potential upgrades and improvements to current dams on the Susquehanna River. Dams can change aquatic ecosystems by altering flow, sediment transport, critical habitats, water temperature, and chemistry (CBF 2006). As discussed in Section 2.2.5 of this supplemental EIS, the American shad (*Alosa sapidissima*) is an anadromous fish species

Environmental Impacts of Operation

that was once of major sport and commercial importance within the Susquehanna River. Currently, American shad are rarely found in the upper reaches of the river because dams constructed in the last 100 years have blocked the species' natural upstream migration. Between 1904 and 1932, four hydroelectric dams were constructed on the Susquehanna River. Fish passage facilities at these early dams were primitive and often prevented shad passage. The 1928 construction of the 95-ft-high (29-m-high) Conowingo Dam, located 10 mi (16 km) above the mouth of the Susquehanna River, effectively put an end to shad migration in the Susquehanna River, and at the time, authorities deemed the Conowingo Dam too high to include fish passage modifications in the dam's design. Fish ladders or lifts currently exist at all dams throughout the Lower Subbasin, however, in the years 2006–2008, shad populations have declined throughout all the dammed areas in the subbasin (PFBC 2008a).

Shad restoration attempts began in the mid-20th century with feasibility studies conducted by the Pennsylvania Fish Commission (now the PFBC). From 1970–1980, the first Conowingo fish lift was built, and hatchery cultures of fry were stocked in the Susquehanna River and its tributaries. From 1985–1994, increasing numbers of fry were stocked, and over 125,000 adult shad were stocked above the Conowingo Dam. Fry were stocked in the North Branch Susquehanna River in Pennsylvania and New York, Chemung River in New York, West Branch Susquehanna River, Juniata River, Susquehanna River near Montgomery Ferry, Conodoguinet Creek, Conestoga River, Swatara Creek, and West Conewago Creek. During this period, the annual return of shad grew from 1,500 to 60,000.

During the years of 1988–1997, a permanent fish passage facility was built at Conowingo Dam, and through a series of settlements with utility companies that owned Susquehanna River dams, fish elevators were constructed at the Holtwood and Safe Harbor dams. In 1997, the shad return at Conowingo exceeded 100,000 fish. In 1999 and 2000, a fish ladder was completed at the Red Hill Dam, and smaller upriver dams along the Susquehanna River and major tributaries were reopened to allow natural shad migration through Binghamton, NY. In 2001, American shad passage at the Conowingo Dam exceeded 190,000 fish. In 2008, the number of American shad passing the Conowingo Dam had decreased to less than 20,000 fish, with only 21 American shad passing the Red Hill (York Haven) Dam fish ladder at TMI-1 (PFBC 2008a). An assessment of the coast-wide stock of American shad by the Atlantic States Marine Fisheries Commission noted that American shad stocks are at an all-time low and not recovering, with the primary causes for the decline attributed to “overfishing, pollution loss, and habitat loss due to dam construction” (ASMFS 2007). Design flaws in existing fish ladders at dams also limit fish passage at dams located on the Susquehanna River (Greenwire 2008). The stocking program continues to be conducted annually in efforts to rebuild the American shad population in the Susquehanna River (PFBC 2007b).

Other fish such as the smallmouth bass (*Micropterus dolomieu*) have also experienced a decline in their Susquehanna River populations. Damming of the river, bacterial infections, river pollution, and low dissolved oxygen levels are some of the known reasons for smallmouth bass decline (PFBC 2008b).

Twenty major electric power generating plants are located in the Susquehanna River Basin. Plants in the Lower Subbasin that withdraw cooling water from the Susquehanna River include Brunner Island, a three-unit, coal-fired, 1483-megawatt (MW) plant located 5 mi (8 km) south of Harrisburg (PPL 2008), and Peach Bottom Atomic Power Station, a two-unit, 2130-MW nuclear

plant, located 18 mi (29 km) south of Lancaster (NRC 1996). PADEP and SRBC regulate these facilities with regard to their consumptive water use, NPDES-permitted discharges, and impact on aquatic resources in the Susquehanna River.

Potential cumulative effects of climate change on the Susquehanna River basin could result in a variety of changes to the aquatic resources in the Susquehanna River. Increases in average annual temperatures, extreme heat events, and the potential for more frequent drought conditions could increase Susquehanna River water temperatures. Water temperature increases could affect spawning patterns or success of aquatic organisms, as well as their distribution, including invasive species. Smallmouth bass is an example of a fish species that depends on cooler water for survival—warmer water contains lower levels of dissolved oxygen, creating areas of the river unsuitable for smallmouth survival. In addition to warmer water temperatures, low-flow conditions in the Susquehanna River could generally impact fish survival. Conversely, increased average rainfall and flood events in the fall and spring could change the nature of sediment and nutrient inputs in the river system, possibly impacting primary production, and ultimately the river food web. Increased frequency of floods could also impact the spawning success of aquatic species. (USC 2008; EPA 1997) The extent and magnitude of climate change impacts on aquatic resources in the Susquehanna River could be significant in the context of cumulative impacts on the river.

As discussed in Section 4.11.1 of this supplemental EIS, SRBC regulates consumptive water use at TMI-1 and at all facilities drawing water from the Susquehanna River. To ensure the water resources of the Susquehanna River Basin continue to meet the needs of the basin population, the SRBC coordinates with other State and Federal agencies and conducts extensive water resources monitoring, project review, water withdrawal registration, drought coordination, low-flow management (i.e., water storage), reservoir feasibility studies, and ground water management (SRBC 2007b).

The NRC staff concludes that the minimal aquatic impacts expected from the continued TMI-1 operations would not contribute to an overall decline in the condition of aquatic resources. However, the cumulative impacts on aquatic resources resulting from all past, present, and reasonably foreseeable future actions, including non-TMI-1 actions, would be SMALL to MODERATE.

4.11.3 Cumulative Impacts on Terrestrial Resources

This section addresses past, present, and future actions that could result in adverse cumulative impacts to terrestrial resources, including wildlife populations, upland habitats, wetlands, riparian zones, invasive species, protected species, and land use. For purposes of this analysis, the geographic area considered in the evaluation includes the TMI-1 site, the land owned by Exelon Generation along the eastern bank of the Susquehanna River, the wetlands on and in the vicinity of the TMI-1 site, and the in-scope transmission line ROWs identified in Section 2.1.5 of this report.

Before construction of the TMI-1 and TMI Unit 2 sites, terrestrial communities on Three Mile Island supported forest habitat, floodplain habitat, riparian areas, grasslands, and potential wetland habitat. Initial construction of the TMI-1 and TMI Unit 2 sites converted 200 ac (81 ha) of the island's 370 ac (150 ha) for plant facilities and industrial uses, which caused loss of

Environmental Impacts of Operation

terrestrial habitat (AmerGen 2008). A dike system was created during initial construction of the TMI-1 and TMI Unit 2 facilities, and a wetland habitat developed once the associated borrow pits began to fill with water (AmerGen 2008).

Construction of the transmission line ROWs maintained by FirstEnergy for the TMI-1 site resulted in subsequent changes to the plant species present within the ROWs. Because the length of in-scope transmission lines constructed for TMI-1 is relatively short (5.6 mi [9 km]), construction most likely did not affect wildlife in the vicinity of the lines. However, fragmentation resulting from the transmission line ROWs likely caused edge effects such as changes in light, wind, and temperature; an increased susceptibility to invasive species; and a possible reduction in habitat ranges for certain species. ROW maintenance has likely had past impacts and is likely to have present and future impacts on the terrestrial habitat, which may include the buildup of herbicide chemicals, prevention of natural succession stages, an increase in edge species, a decrease in interior species, and an increase in invasive species.

Neither Exelon Generation nor FirstEnergy manage invasive species on their land holdings; therefore, a potential exists for invasive species to be introduced on or in the vicinity of the TMI-1 site or its associated transmission line ROWs from present and future actions. Introduction of these species may contribute to the establishment of an invasive species population, which could compete with native populations for resources and degrade areas of terrestrial habitat.

As mentioned above, Brunner Island Power Plant is approximately 5 mi (8 km) south of TMI-1, and has three coal-fired units, totaling a 1,483-MW capacity (PPL 2008). Fossil plants release carbon dioxide, mercury, nitrogen oxides, and sulfur oxides, among other air emissions. Nitrogen oxides and sulfur oxides can combine with water to form acid rain, which can lead to erosion and changes in soil pH levels. Mercury can deposit on soils and surface water, and may then be taken up by plant or animal species, posing the risk of bioaccumulation. For these reasons, the Brunner Island Plant is likely to have current and future impacts to the terrestrial environment on the TMI-1 site and its surrounding area.

Two dams, the York Haven Hydroelectric Station, also known as Olympia Dam, and the Red Hill Dam, are both located less than 10 mi (16 km) from the TMI-1 project site. The Olympia Dam produces 19–20 megawatt electric (MWe) (AmerGen 2008). The Red Hill Dam does not produce electricity. Hydroelectric plants restrict the flow velocity of water downstream, which can lead to changes in downstream ecosystems. Because TMI-1 is located upstream of Olympia Dam, the plant is not likely to have cumulative impacts to the terrestrial environment on the TMI-1 site and its surrounding area.

Two wastewater treatment plants are located within 7 mi (11 km) of the TMI-1 site—the Borough of Middletown Wastewater Treatment Plant in Middletown, approximately 2 mi (3.2 km) north of the TMI-1 site, and the Fairview Sewerage Treatment Plant in New Cumberland, approximately 7 mi (11 km) north of the TMI-1 site. Both plants are on the Susquehanna River. Chemical discharges from these wastewater treatment plants that enter the Susquehanna River may have current and future impacts on the surrounding vegetation, wetlands, and wildlife. Bioaccumulation of chemical discharges from these treatment plants also poses a threat to terrestrial and riparian habitats as well as to wildlife species.

Prior and continued residential, commercial, and industrial development of Dauphin, Lancaster, and York Counties may impact terrestrial habitat in the vicinity of TMI-1 and the associated

transmission line ROWs. Increases in both commercial and residential development have occurred in these counties over the past 40 years. As this area continues to grow, additional runoff from roads and impervious surfaces, development adjacent to wetlands and riparian zones, and an increase in waste releases could have future impacts on the terrestrial habitat. Section 2.2.8.3 discusses offsite land use in the vicinity of TMI-1.

The potential cumulative effects of climate change could result in a variety of changes to terrestrial resources on and around the TMI-1 site. Increases in average annual temperature and increased frequency of heat waves, droughts, and heavy rainfall events all have the potential to impact wildlife populations, protected species, upland habitats, wetlands, riparian zones, and invasive species. Increased precipitation could change vegetation composition on Three Mile Island, potentially increasing wetlands, and decreasing riparian communities due to coastal erosion. Long-term effects of climate change on terrestrial resources could include a shift in forest composition or even an overall loss of forests, loss of bird diversity, a change in local mammal populations, and an increase in the range of invasive species and other pests. (EPA 1997)

The NRC staff believes that the cumulative impacts during the term of license renewal on terrestrial habitat and associated species, when added to past, present, and reasonably foreseeable future actions, would be SMALL.

4.11.4 Cumulative Human Health Impacts

The NRC and EPA developed radiological dose limits for protection of the public and workers to address the cumulative impact of acute and long-term exposure to radiation and radioactive material. These dose limits are codified in 10 CFR Part 20 and 40 CFR Part 190. This analysis includes the area within a 50-mi (80-km) radius of the TMI-1 site. The REMP conducted by Exelon Generation in the vicinity of the TMI-1 site measures the cumulative impact of radiation and radioactive materials from all sources, including the shut-down and defueled TMI Unit 2; Peach Bottom Atomic Power Station, Units 2 and 3; and Peach Bottom Unit 1, which has been shut down since October 1974.

In addition to the Unit 1 operating reactor, Three Mile Island also contains the remains of the TMI Unit 2 facility that had an accident with a partial fuel meltdown in 1979. TMI Unit 2 is permanently shut down and defueled. The damaged fuel and core debris was shipped offsite to a DOE facility. The facility has been in a monitored storage mode since December 1993 and will remain in that condition until the operating license for TMI-1 expires, at which time both plants will be decommissioned.

Even though TMI Unit 2 is defueled and in a monitored storage mode, there are still some controlled radioactive effluent discharges resulting from maintenance and cleanup activities. These radioactive discharges are a very small fraction of the radioactivity released from TMI-1. The calculated radiation doses to members of the public from all radioactive material released from the TMI-1 site are well within NRC's radiation safety limits. In addition to the radioactive effluent information, the staff reviewed the TMI-1 annual radiological environmental monitoring report. This report summarizes the results of environmental monitoring conducted in the environs around the TMI-1 site to determine the environmental impact from the radioactive

Environmental Impacts of Operation

releases from the entire TMI-1 site. No unusual trends or significant radiation levels were detected in the environment from the two units located on Three Mile Island.

Peach Bottom Atomic Power Station has two active nuclear reactor units (Units 2 and 3). Each unit includes a light-water boiling reactor and a steam-driven turbine generator. The facility's core power output from the two units is 3,458 megawatt-thermal (MWt). In addition to the operating units, the site also contains the shut-down Peach Bottom Atomic Power Station Unit 1. Unit 1 was a prototype, high-temperature, gas-cooled reactor that had a net electrical output of 40 MWe (115 MWt) and operated from 1966–1974. Since then it has been maintained in a storage mode. As part of normal operations, Peach Bottom Atomic Power Station, Units 2 and 3, release radioactive effluents, contributing to the cumulative dose impacts to members of the public and the environment.

As discussed in Section 4.8.1 of this report, the staff reviewed the radiological environmental radiation monitoring results for the five-year period from 2003–2007 as part of the cumulative impacts assessment. Cumulative radiological impacts from all uranium fuel cycle facilities, including those discussed above, within a 50-mi (80-km) radius of the TMI-1 site, are limited by the dose limits codified in 10 CFR Part 20 and 40 CFR Part 190. In Section 4.8 of this report, the NRC staff concluded that the impacts of radiation exposure from the operation of TMI-1 during the renewal term to the public would be SMALL. The NRC and the Commonwealth of Pennsylvania will regulate any future actions in the vicinity of the TMI-1 site that could contribute to cumulative radiological impacts.

The continued operation of TMI-1 has a low risk of causing outbreaks from thermophilic microbiological organisms associated with thermal discharges. Available data assembled by the CDC for the years 1999 to 2004 (CDC 2001, 2002, 2002a, 2003, 2003a, 2004, 2005, 2006, 2007b) report no occurrence of waterborne disease outbreaks in the Commonwealth of Pennsylvania resulting from thermophilic microorganisms *Naegleria fowleri* and *Pseudomonas aeruginosa* from the operation of TMI-1. Outbreaks of legionellosis, salmonellosis, or shigellosis that occurred in the Commonwealth of Pennsylvania were within the range of national trends in terms of cases per 100,000 population or total cases per year, and the outbreaks were associated with hotel pools and spas (CDC 2001, 2002, 2002a, 2003, 2003a, 2004, 2005, 2006, 2007b).

As part of its evaluation of cumulative impacts, the NRC staff also considered the effects of thermal discharges from other facilities on the Susquehanna River located within one mile upstream of TMI-1 that are also producing thermal effluents. Such facilities could promote the growth of thermophilic microbiological organisms. The NRC staff did not find any such facilities.

On the basis of these considerations, the NRC staff determined that the cumulative impacts to public health from thermophilic microbiological organisms resulting from operation of the TMI-1 thermal discharge to the aquatic environment or in the vicinity of the site would be SMALL.

The staff determined that the electric field-induced currents from the TMI-1 transmission lines are well below the NESC recommendations for preventing electric shock from induced currents. Therefore, the TMI-1 transmission lines do not detectably affect the overall potential for electric shock from induced currents within the analysis area. With respect to the chronic effects of electromagnetic fields, although the GEIS finding of “not applicable” is appropriate to TMI-1, the transmission lines associated with TMI-1 are not likely to detectably contribute to the regional

exposure to extremely low frequency electromagnetic fields. Therefore, the staff has determined that the cumulative impacts of the continued operation of the TMI-1 transmission lines would be SMALL.

4.11.5 Cumulative Socioeconomic Impacts

As discussed in Section 4.9 of this supplemental EIS, continued operation of TMI-1 during the license renewal term would have no impact on socioeconomic conditions in the region beyond those already being experienced. Since Exelon Generation has indicated that no additional workers would be hired during the license renewal term, overall expenditures and employment levels at TMI-1 would be expected to remain relatively constant with no additional demand for permanent housing, public utilities, and public services. In addition, since employment levels and the value of TMI-1 would not change, there would be no population and tax revenue-related land use impacts. There would also be no disproportionately high and adverse health and environmental impacts on minority and low-income populations in the region. Based on this and other information presented in this supplemental EIS, there would be no cumulative socioeconomic impacts from the continued operation of TMI-1 during the license renewal term beyond those already being experienced.

However, Exelon Generation indicated in its ER that TMI-1 steam generators would be replaced prior to the license renewal term. Exelon Generation estimates that steam generator replacement would require a one-time increase in the number of refueling outage workers for up to 70 days at TMI-1 (AmerGen 2008). These additional workers would create a one-time short-term increase in the demand for temporary (rental) housing, increase use of public water and sewer services, and transportation impacts on access roads in the immediate vicinity of TMI-1. Given the short amount of time needed to replace the steam generators, the additional number of refueling outage workers and truck material deliveries needed to support this one-time replacement of the TMI-1 steam generators could have a temporary cumulative effect on socioeconomic conditions in the vicinity of TMI-1. However, there would be no long-term cumulative socioeconomic impacts from TMI-1 steam generator replacement in the region.

As discussed in Section 4.9.6, continued operation of TMI-1 during the license renewal term would have a SMALL impact on historic and archaeological resources. Exelon Generation has no plans to construct additional facilities at TMI-1 related to license renewal. Any land disturbing activities would be carried out under Exelon Generation's corporate procedures that ensure the protection of cultural resources (AmerGen 2008). Exelon Generation does not anticipate any changes or additions to transmission line structures. Additionally, Exelon Generation plans to revise its procedures to provide clear guidance regarding consideration of potential impacts on historic and archaeological resources. This revision includes a "stop work" provision when cultural resources are inadvertently discovered (AmerGen 2008). Since Exelon Generation has committed to issue revised procedures, no additional adverse impacts to historic and archaeological resources are expected during the license renewal term. However, as noted in Section 4.9.6, there is the potential for prehistoric and historic archaeological resources to be present at TMI-1. Should project plans change, then further mitigation and consultation would be initiated by Exelon Generation with the PHMC. Based on this and other information presented in the supplemental EIS, the staff finds that there would be no cumulative historic and

Environmental Impacts of Operation

archaeological impacts from the continued operation of TMI-1 during the license renewal term beyond those that have already occurred.

Exelon Generation has indicated that it plans to replace TMI-1 steam generators prior to the license renewal term. Construction, decontamination, and laydown activities would be less than 10 ac (4 ha) and would be limited to previously disturbed areas (AmerGen 2008). Exelon Generation has consulted with the PHMC regarding this activity. The PHMC stated that the project would have no effect on historic and archaeological resources, however, should additional ground-disturbing activities occur, then further consultation with the PHMC would be required (AmerGen 2008).

4.11.6 Summary of Cumulative Impacts

We considered the potential impacts resulting from operation of TMI-1 during the period of extended operation and other past, present, and future actions in the vicinity of TMI-1. The preliminary determination is that the potential cumulative impacts resulting from TMI-1 operation during the period of extended operation would be SMALL to MODERATE.

Table 4-11. Summary of Cumulative Impacts on Resources Areas.

Resource Area	Impact	Discussion
Water Resources	SMALL	Impacts to water resources in the subbasin include increases in land development, overuse of ground water resources, unregulated use of ground water resources, drought impacts, and the need for flow compensation for consumptive water users. The SRBC regulates, monitors, and enforces withdrawals of ground water and surface water in the subbasin, and manages the subbasin's water resources. Continued operation of TMI-1 would have small cumulative impacts to water resources if compliance with SRBC regulations and participation in their water storage project is maintained.
Aquatic Resources	SMALL to MODERATE	Impacts to aquatic resources from continued operation of TMI-1 would have small cumulative impacts. Past impacts to Susquehanna River water quality have impacted aquatic resources; and continued impacts from agriculture, livestock production, and development will continue to impact aquatic resources. Regulation of point-source discharges by PADEP and of subbasin water use by the SRBC will continue to mitigate impacts. Continued operation and potential future uprates to dams on the Susquehanna River will also impact aquatic resources.

Terrestrial Resources	SMALL	ROW maintenance, emissions from the Bruner Island coal-fired power plant, invasive species, chemical discharges from nearby wastewater treatment plants, and development of Dauphin, Lancaster, and York Counties have all impacted terrestrial habitat and species in the vicinity of TMI-1, and would likely continue in the future.
Human Health	SMALL	The cumulative human health impacts of continued operation of TMI-1 from radiation exposure to the public, microbiological organisms from thermal discharge to the Susquehanna River, and electric-field-induced currents from the TMI-1 transmission lines would all be small.
Socioeconomics	N/A	There would be no cumulative impacts to socioeconomics during the license renewal period, and no long-term cumulative impacts from refurbishment. There would be no cumulative impacts to historic and archaeological resources during the license renewal period, including refurbishment, beyond those that have already occurred.

4.12 References

10 CFR 20. *Code of Federal Regulations*, Title 10, *Energy*, Part 20, "Standards for Protection Against Radiation."

10 CFR Part 50. *Code of Federal Regulations*, Title 10, *Energy*, Part 50, "Domestic Licensing of Production and Utilization Facilities."

10 CFR 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions."

10 CFR Part 61. *Code of Federal Regulations*, Title 10, *Energy*, Part 61, "Licensing Requirements for Land Disposal of Radioactive Waste."

10 CFR Part 71. *Code of Federal Regulations*, Title 10, *Energy*, Part 71, "Packaging and Transportation of Radioactive Material."

36 CFR Part 60. *Code of Federal Regulations*, Title 36, *Parks, Forests, and Public Property*, Part 60, Section 4, "Criteria for Evaluation."

36 CFR 800. *Code of Federal Regulations*, Title 36, *Parks, Forests, and Public Property*, Part 800, "Protection of Historic Properties."

40 CFR 190. *Code of Federal Regulations*, Title 40, *Protection of the Environment*, Part 190, "Environmental Radiation Protection Standards for Nuclear Power Operations."

Environmental Impacts of Operation

59 FRN 7629. Executive Order 12898. "Federal Actions to Address Environmental Justice in Minority Populations and Low-Income Populations." *Federal Register*. Vol. 59, No. 32, p. 7629. Washington, D.C. February 16, 1994.

69 FRN 52040. "Treatment of Environmental Justice Matters in NRC Regulatory and Licensing Actions." *Federal Register*. Vol. 69, No. 163, pp. 52040-52048. Washington, D.C. August 24, 2004.

ACHP (Advisory Council on Historic Preservation). 2008. "National Register Evaluation Criteria." Available URL: <http://www.achp.gov/nrcriteria.html> (accessed on October 10, 2008). ADAMS No. ML082880723.

Adkins, C.J. 1984. *Equilibrium Thermodynamics*, 3rd ed. Cambridge University Press.

AEC (U.S. Atomic Energy Commission). 1972. *Final Environmental Statement related to the operation of Three Mile Island Nuclear Station, Units 1 and 2. Metropolitan Edison Company, et al. Docket Nos. 50-289 and 50-320.* Directorate of Licensing. December. Washington, D.C. ADAMS No. ML080090250.

AmerGen (AmerGen Energy Company, LLC). 2004. *Three Mile Island Nuclear Station Unit-1 and Unit-2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket Nos. 50-289 and 50-320. Radiological Environmental Monitoring Program Report, 1 January through 31 December 2003.* Middletown, PA. ADAMS No. ML041250580.

AmerGen (AmerGen Energy Company, LLC). 2004a. *Three Mile Island Nuclear Station Unit-1 and Unit-2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket Nos. 50-289 and 50-320. Combined 2003 Annual Radioactive Effluent Release Report.* Middletown, PA. ADAMS No. ML041180052.

AmerGen (AmerGen Energy Company, LLC). 2005. *Three Mile Island Nuclear Station Unit-1 and Unit-2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket Nos. 50-289 and 50-320. Radiological Environmental Monitoring Program Report. 1 January through 31 December 2004.* Middletown, PA. ADAMS No. ML051260258.

AmerGen (AmerGen Energy Company, LLC). 2005a. *Three Mile Island Nuclear Station Unit-1 and Unit-2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket Nos. 50-289 and 50-320. Combined 2004 Annual Radioactive Effluent Release Report.* Middletown, PA. ADAMS No. ML051260269.

AmerGen (AmerGen Energy Company, LLC). 2006. *Three Mile Island Nuclear Station Unit-1 and Unit-2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket Nos. 50-289 and 50-320. Updated Final Safety Analysis Report.* Middletown, PA. ADAMS No. ML080800161.

AmerGen (AmerGen Energy Company, LLC). 2006a. *Three Mile Island Nuclear Station Unit-1 and Unit-2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket Nos. 50-289 and 50-320. Combined 2005 Annual Radioactive Effluent Release Report.* Middletown, PA. ADAMS No. ML061230244.

AmerGen (AmerGen Energy Company, LLC). 2006b. *Three Mile Island Nuclear Station Unit-1 and Unit-2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket*

Nos. 50-289 and 50-320. *Radiological Environmental Monitoring Program Report, 1 January through 31 December 2005*. Middletown, PA. ADAMS No. ML061220487.

AmerGen (AmerGen Energy Company, LLC). 2007. *Three Mile Island Nuclear Station Unit-1 and Unit-2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket Nos. 50-289 and 50-320. Combined 2006 Annual Radioactive Effluent Release Report* (ODCM Revision 25 Enclosed). Middletown, PA. ADAMS No. ML071290369.

AmerGen (AmerGen Energy Company, LLC). 2007a. *Three Mile Island Nuclear Station Unit-1 and Unit-2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket Nos. 50-289 and 50-320. Radiological Environmental Monitoring Program Report, 1 January through 31 December 2006*. Middletown, PA. ADAMS No. ML071290163.

AmerGen (AmerGen Energy Company, LLC). 2008. *Three Mile Island Nuclear Station, Unit 1, Applicant's Environmental Report, License Renewal Operating Stage*. Kennett Square, PA. ADAMS Nos. ML080220255, ML080220257, ML080220261, and ML080220282.

AmerGen (AmerGen Energy Company, LLC). 2008a. *Three Mile Island Nuclear Station Unit-1 and Unit-2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket Nos. 50-289 and 50-320. Radiological Environmental Monitoring Program Report, 1 January through 31 December 2007*. Middletown, PA. ADAMS No. ML081300255.

AmerGen (AmerGen Energy Company, LLC). 2008b. *Three Mile Island Nuclear Station Unit-1 and Unit-2 Operating License No. DPR-50 and Possession Only License No. DPR 73 Docket Nos. 50-289 and 50-320. Combined 2007 Annual Radioactive Effluent Release Report*. Middletown, PA. ADAMS No. ML081300410.

AmerGen (AmerGen Energy Company, LLC). 2008c. "Excerpts about meat sampling from the Annual Radiological Environmental Monitoring Program (REMP) Reports for the period from 1990 through 2001." *Three Mile Island, Unit 1, Enclosure A -Post Audit Environmental Information – Index Through Audit Question ENV-070, Monthly Report on the Meteorological Monitoring Program, February 2007 (Non-Proprietary Version)*. June 10. ADAMS No. ML082110252.

ASMFC (Atlantic States Marine Fisheries Commission). 2007. *Review of the Atlantic States Marine Fisheries Commission Fishery Management Plan for Shad and River Herring (Alosa spp.)*. October 3, 2007. Available URL: <http://www.asafc.org/speciesDocuments/shad/fmps/2007ShadFMPReviewfor2006.pdf> (accessed November 7, 2008). ADAMS No. ML083170642.

CBF (Chesapeake Bay Foundation). 2005. *The Mighty Susquehanna River: Pollution Degrades Our Streams, the River, and the Chesapeake Bay*. Available URL: http://www.cbf.org/site/DocServer/susquehanna_factsheet.pdf?docID=3443 (accessed July 18, 2008). ADAMS No. ML082381277.

CBF (Chesapeake Bay Foundation). 2006. *Waters at Risk; Pollution in the Susquehanna Watershed – Sources and Solutions*. Available URL: <http://www.cbf.org/site/DocServer/WatersAtRisk.pdf?docID=5724> (accessed August 21, 2008). ADAMS No. ML082880724.

CDC (Centers for Disease Control and Prevention). 2001. *Summary of Notifiable Diseases, United States 1999. Morbidity and Mortality Weekly Report, Vol. 48, No. 53*. April 6. Atlanta, GA.

Environmental Impacts of Operation

CDC (Centers for Disease Control and Prevention). 2002. *Summary of Notifiable Diseases United States, 2000. Morbidity and Mortality Weekly Report, Vol. 49, No. 53.* June 14. Atlanta, GA.

CDC (Centers for Disease Control and Prevention). 2002a. *Surveillance for Waterborne-Disease Outbreaks - United States, 1999-2000. Morbidity and Mortality Weekly Report, Vol. 51 (SS08).* November 22. Atlanta, GA.

CDC (Centers for Disease Control and Prevention). 2003. *Summary of Notifiable Diseases - United States, 2001. Morbidity and Mortality Weekly Report, Vol. 52, No. 40.* May 2. Atlanta, GA. May 2, 2003.

CDC (Centers for Disease Control and Prevention). 2003a. *Primary Amebic Meningoencephalitis - Georgia, 2002. Morbidity and Mortality Weekly Report, Vol. 50, No. 53.* October 10. Atlanta, GA.

CDC (Centers for Disease Control and Prevention). 2004. *Surveillance for Waterborne-Disease Outbreaks Associated with Recreational Water-United States, 2001-2002. Morbidity and Mortality Weekly Report, Vol. 53 (SS08).* October 22. Atlanta, GA.

CDC (Centers for Disease Control and Prevention). 2005. *Summary of Notifiable Diseases - United States, 2003. Morbidity and Mortality Weekly Report, Vol. 52, No. 54.* April 22. Atlanta, GA.

CDC (Centers for Disease Control and Prevention). 2006. *Summary of Notifiable Diseases - United States, 2004. Morbidity and Mortality Weekly Report, Vol. 53, No. 53.* June 16. Atlanta, GA.

CDC (Centers for Disease Control and Prevention). 2007. "Legionellosis: Legionnaires Disease and Pontiac Fever." Available URL: http://www.cdc.gov/ncidod/dbmd/diseaseinfo/legionellosis_g.htm (accessed on March 27, 2008). ADAMS No. ML080230326.

CDC (Centers for Disease Control and Prevention). 2007a. "Salmonellosis." Available URL: http://www.cdc.gov/ncidod/dbmd/diseaseinfo/salmonellosis_g.htm (accessed on March 27, 2008). ADAMS No. ML080230323.

CDC (Centers for Disease Control and Prevention). 2007b. *Summary of Notifiable Diseases - United States, 2005. Morbidity and Mortality Weekly Report, Vol. 54, No. 53.* March 30. Atlanta, GA.

CEQ (Council on Environmental Quality). 1997. *Environmental Justice: Guidance Under the National Environmental Policy Act.* Executive Office of the President. December 10.

Washington, DC. Available URL:

http://www.epa.gov/compliance/resources/policies/ej/ej_guidance_nepa_ceq1297.pdf (accessed August 18, 2008). ADAMS No. ML082520150.

DCNR (Pennsylvania Department of Conservation and Natural Resources). 2008. Letter from R. Bowen, Environmental Review Specials, Pennsylvania Department of Conservation and Natural Resources, to L. Lund, Branch Chief, Division of License Renewal, Nuclear Regulatory Commission. Subject: Pennsylvania Natural Diversity Inventory Review, PNDI Number 19605,

- Three Mile Island Unit 1 License Renewal Species of Special Concern, Dauphin & Lancaster Counties. May 2, 2008. ADAMS No. ML081300048.
- Durlin, R.R. and W.P. Schaffstall. 2005. *Water Resources Data Pennsylvania Water Year 2004, Water-Data Report PA-04-2*. U.S. Geological Survey. May. New Cumberland, PA. ADAMS No. ML081980705.
- EPA (U.S. Environmental Protection Agency). 1997. *Climate Change and Pennsylvania*. September. Available URL: [http://yosemite.epa.gov/OAR/globalwarming.nsf/UniqueKeyLookup/SHSU5BVMDY/\\$File/pa_impct.pdf](http://yosemite.epa.gov/OAR/globalwarming.nsf/UniqueKeyLookup/SHSU5BVMDY/$File/pa_impct.pdf) (accessed May 19, 2009). ADAMS No. ML091390884.
- ESR (Institute of Environmental Science & Research Limited). 2002. *Risk Profile: Salmonella (Non Typhoid) in Poultry (Whole and Pieces)*. Christchurch, New Zealand. October. Available URL: http://www.nzfsa.govt.nz/science/risk-profiles/salmonella-in-poultry-meat.pdf?bcsi_scan_513F405096A035F7=0&bcsi_scan_filename=salmonella-in-poul (accessed on March 27, 2008). ADAMS No. ML080880142.
- Exelon Generation (Exelon Generation Company, LLC). 2009. *Three Mile Island Nuclear Station Unit 1 License Renewal Updated Environmental Information*. "Combined Docket Application Water Withdrawals and Consumptive Use Three Mile Island Nuclear Station." March 25. Kennett Square, Pennsylvania. Pp. 55-107. ADAMS No. ML090890364.
- Exelon Generation (Exelon Generation Company, LLC). 2009a. "Three Mile Island Nuclear Station Unit 1 License Renewal Application Supplemental Updated Environmental Information." May 15. ADAMS No. ML091390217.
- FWS (United States Fish and Wildlife Service). 2008. Letter from D. Densmore, Supervisor, U.S. Fish and Wildlife Service, Pennsylvania Field Office, to L. Lund, Branch Chief, Division of License Renewal, Nuclear Regulatory Commission. Subject: Three Mile Island Nuclear Station, Unit 1, License Renewal Application Review. April 23, 2008. ADAMS No. ML081280307.
- Greenwire. 2008. *Renewable Energy: Hydropower Makes a Quiet Comeback*. October 28. Available URL: <http://www.eenews.net/Greenwire/2008/10/28/archive/4?terms=holtwood> (accessed November 7, 2008). ADAMS No. ML083170642.
- Hendricks, C.W. 1972. "Enteric Bacterial Growth Rates in River Water." *Applied Microbiology* 24(2):168-174.
- Joklik, W. K, and H. P. Willet. 1976. *Zinsser Microbiology*, 16th ed. Appleton-Century-Crofts, New York.
- NAS (National Research Council of the National Academies of Science). 2004. *Indicators for Waterborne Pathogens*. The National Academies Press, Washington, D.C.
- NESC (National Electrical Safety Code). 2007. Institute of Electrical and Electric Engineers. NY. ADAMS No. ML080880143.
- NHPA (*National Historic Preservation Act*). 1996. 16 U.S.C. 470, et seq.
- NIEHS (National Institute of Environmental Health Sciences). 1999. *NIEHS Report on Health Effects from Exposure to Power Line Frequency and Electric and Magnetic Fields*. Publication No. 99-4493, Research Triangle Park, NC.

Environmental Impacts of Operation

NRC (U.S. Nuclear Regulatory Commission). 1976. *NUREG-0112. Final Supplement to the Final Environmental Statement Related to the Operation of Three Mile Island Nuclear Station, Unit 2, Metropolitan Edison Company et al., Docket No. 50-320.* Office of Nuclear Reactor Regulation, Washington, D.C. December. ADAMS No. ML080090250.

NRC (U.S. Nuclear Regulatory Commission). 1981. *Final Environmental Statement Related to the Operation of Susquehanna Steam Electric Station. Pennsylvania Power & Light Company and Allegheny Electric Cooperative, Inc.* Docket Nos. 50-387 and 50-388. Office of Nuclear Reactor Regulation, Washington, D.C. June. ADAMS No. ML080150291.

NRC (U.S. Nuclear Regulatory Commission). 1996. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants.* NUREG-1437, Vol. 1 and 2, Washington, D.C. ADAMS No. ML061770605.

NRC (U.S. Nuclear Regulatory Commission). 1999. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Main Report, "Section 6.3 – Transportation, Table 9.1, Summary of findings on NEPA issues for license renewal of nuclear power plants, Final Report."* NUREG-1437, Vol. 1, Addendum 1, Washington, D.C.

NRC (U.S. Nuclear Regulatory Commission). 2000. *Standard Review Plan for Environmental Reviews for Nuclear Power Plants, Supplement 1: Operating License Renewal.* NUREG-1555, Supplement 1, Washington, D.C.

NRC (U.S. Nuclear Regulatory Commission). 2008. Letter from L. Lund, U.S. Nuclear Regulatory Commission, Washington, D.C., to J. Cutler, Pennsylvania Historical and Museum Commission, Harrisburg, Pennsylvania. Subject: "Three Mile Island Nuclear Station, Unit 1, License Renewal Application Review (File No. ER 07-1737-043-A)." ADAMS No. ML080930380.

NRC (U.S. Nuclear Regulatory Commission). 2008a. Letter from L. Lund, U.S. Nuclear Regulatory Commission, Washington, D.C., to C. Vaughn, Advisory Council on Historic Preservation, Washington, D.C. Subject: "Three Mile Island Nuclear Station, Unit 1, License Renewal Application Review." ADAMS No. ML080930296.

PADEP (Pennsylvania Department of Environmental Protection). 2008. *Environmental Radiation in Pennsylvania. 2003 and 2004 Annual Reports.* Available URL: http://www.dep.state.pa.us/brp/BRP_Info/Annual_Reports.htm (accessed August 18, 2008). ADAMS No. ML082880726.

PGC (Pennsylvania Game Commission). 2008. Letter from J. Leigey, Division of Environmental Planning and Habitat Protection, Bureau of Wildlife Habitat Management, to L. Lund, Branch Chief, Division of License Renewal, Nuclear Regulatory Commission. Subject: State-Protected Bird and Mammal Species Review, Three Mile Island Nuclear Station License Renewal Application, Londonderry Township, Dauphin County, PA. May 14, 2008. ADAMS No. ML081500671.

PFBC (Pennsylvania Fish & Boat Commission). 2007. *Migratory Fish Restoration and Passage on the Susquehanna River.* Available URL: http://www.fish.state.pa.us/pafish/shad/migratory_fish.pdf (accessed July 31, 2008). ADAMS No. ML080230330.

PFBC (Pennsylvania Fish & Boat Commission). 2008. Letter from C. Urban, Chief, Natural Diversity Section, Pennsylvania Fish & Boat Commission, Bellefonte, Pennsylvania, to S. Lopas, Nuclear Regulatory Commission, Rockville, Maryland. Subject: Species Impact Review (SIR) – Rare, Candidate, Threatened and Endangered Species, Three Mile Island Nuclear Station, Londonderry Township/Borough, Dauphin County, Pennsylvania. June 3, 2008. ADAMS No. ML081610104.

PFBC (Pennsylvania Fish & Boat Commission). 2008a. "Susquehanna River American Shad." Available URL: (http://www.fish.state.pa.us/shad_susq.htm) (accessed June 11, 2008). ADAMS No. ML082381115.

PFBC (Pennsylvania Fish & Boat Commission). 2008b. *Susquehanna River Drainage YOY Smallmouth Bass Disease Investigations 2005 and 2007*. URL: http://www.fish.state.pa.us/pafish/bass_black/meetings/fish_committee2007sep/mortality07_05.pdf?bcsi_scan_B666A1DE717DB577=0&bcsi_scan_filename=mortality07_05.pdf (accessed June 3, 2008). ADAMS No. ML082880420.

PFBC (Pennsylvania Fish & Boat Commission). 2008c. "2008 Pennsylvania Fishing Summary, Summary of Fishing Regulations and Laws". Available URL: <http://www.fish.state.pa.us/fishpub/summary/z00complete.pdf> (accessed July 23, 2008). ADAMS No. ML082880450.

PNHP (Pennsylvania Natural Heritage Program). 2008. "State Species List, Update June 2008." Available URL: <http://www.naturalheritage.state.pa.us/Homepage.aspx> (accessed July 14, 2008). ADAMS No. ML082381127.

PPL Corporation (PPL). 2008. "Bruner Island Fact Sheet." Available URL: <http://www.pplweb.com/ppl+generation/coal+plants/ppl+brunner+island+-+fact+sheet.htm> (accessed June 5, 2008). Accessible at ML08082381272.

SRBC (Susquehanna River Basin Commission). 2005. *Groundwater Management Plan for the Susquehanna River Basin*. June 8. Available URL: http://www.srbc.net/programs/docs/GW_Mngt_Plan_June2005/Groundwater_Mgt_Plan_2005.htm (accessed July 28, 2008). ADAMS No. ML082880727.

SRBC (Susquehanna River Basin Commission). 2006. *Lower Susquehanna Subbasin Survey: A Water Quality and Biological Assessment, June – November 2005, Publication 247*. September. Available URL: http://www.srbc.net/pubinfo/techdocs/Publication_247/LowerSusqRept.pdf (accessed August 21, 2008). ADAMS No. ML082381270.

SRBC (Susquehanna River Basin Commission). 2008. *Draft Comprehensive Plan for the Water Resources of the Susquehanna River Basin*. Harrisburg, PA. May. Available URL: http://www.srbc.net/planning/comp_plan_with_appendicies.pdf (accessed August 20, 2008). ADAMS No. ML082880729.

SRBC (Susquehanna River Basin Commission). Undated. "Lower Susquehanna Subbasin Information." Available URL: <http://www.srbc.net/subbasin/lowersus.htm> (accessed August 20, 2008). ADAMS No. ML082381278.

Todar, K. 2007. *Todar's Online Textbook of Bacteriology*. Available URL: <http://www.textbookofbacteriology.net> (accessed on July 27, 2007).

Environmental Impacts of Operation

Tyndall, R. L., et al. 1989. "Effect of thermal additions on the density and distribution of thermophilic amoebae and pathogenic *Naegleria fowleri* in a newly created cooling lake." *Applied Environmental Microbiology* 55:722–732.

UCS (Union of Concerned Scientists). 2008. *Climate Change in Pennsylvania – Impacts and Solutions for the Keystone State*. October. Available URL: http://www.ucsusa.org/assets/documents/global_warming/Climate-Change-in-Pennsylvania_Impacts-and-Solutions.pdf (accessed May 19, 2009). ADAMS No. ML091390883.

USCB (U.S. Census Bureau). 2003. *Landview 6 – Census 2000 Profile of General Demographic Characteristics DP-1 (100%) and Census Profile of Selected Economic Characteristics DP-3, Summary of Census Block Groups in a 50-mile Radius around TMI-1 (40.154569 Lat., - 76.725256 Long.)* December. Washington, D.C.

USCB (U.S. Census Bureau). 2008. "American FactFinder, Census 2000 Information," and "State and County QuickFacts on Dauphin and Lancaster Counties." Searchable databases. Available URLs: <http://factfinder.census.gov> and <http://quickfacts.census.gov> (accessed July 2008).

WHO (World Health Organization). 2007. *Extremely Low Frequency Fields Environmental Health Criteria Monograph No.238*. Geneva, Switzerland. Available URL: http://www.who.int/peh-emf/publications/elf_ehc/en/index.html (accessed October 14, 2008). ADAMS No. ML082880728.

5.0 ENVIRONMENTAL IMPACTS OF POSTULATED ACCIDENTS

This chapter describes the environmental impacts from postulated accidents that might occur during the period of extended operation. The term "accident" refers to any unintentional event outside the normal plant operational envelope that results in a release or the potential for release of radioactive materials into the environment. Two classes of postulated accidents are evaluated in the GEIS and are listed in Table 5-1 below. These are design-basis accidents (DBAs) and severe accidents.

Table 5-1. Issues Related to Postulated Accidents. *Two issues related to postulated accidents are evaluated under NEPA in the license renewal review, design-basis accidents and severe accidents.*

Issues	GEIS Section	Category
Design-basis accidents	5.3.2; 5.5.1	1
Severe accidents	5.3.3; 5.3.3.2; 5.3.3.3; 5.3.3.4; 5.3.3.5; 5.4; 5.5.2	2

5.1 Design Basis Accidents

In order to receive NRC approval to operate a nuclear power facility, an applicant for an initial operating license must submit a safety analysis report (SAR) as part of its application. The SAR contains the design criteria and design information for the proposed reactor and comprehensive data on the proposed site. The SAR also discusses various hypothetical accident situations and the safety features that are provided to prevent and mitigate accidents. The NRC staff reviews the application to determine whether or not the plant design meets the Commission's regulations and requirements and includes, in part, the nuclear plant design and its anticipated response to an accident.

DBAs are those accidents that both the licensee and the NRC staff evaluate to ensure that the plant can withstand normal and abnormal transients, and a broad spectrum of postulated accidents, without undue hazard to the health and safety of the public. A number of these postulated accidents are not expected to occur during the life of the plant, but are evaluated to establish the design basis for the preventive and mitigative safety systems of the facility. The acceptance criteria for DBAs are described in 10 CFR 50 and 10 CFR 100.

The environmental impacts of DBAs are evaluated during the initial licensing process, and the ability of the plant to withstand these accidents is demonstrated to be acceptable before issuance of the operating license. The results of these evaluations are found in license documentation such as the applicant's final safety analysis report (FSAR), the safety evaluation report (SER), the final environmental statement (FES), and Section 5.1 of this supplemental environmental impact statement (EIS). A licensee is required to maintain the acceptable design and performance criteria throughout the life of the plant, including any extended-life operation. The consequences for these events are evaluated for the hypothetical maximum exposed individual; as such, changes in the plant environment will not affect these evaluations. Because of the requirements that continuous acceptability of the consequences and aging management programs be in effect for the period of extended operation, the environmental impacts as

Environmental Impacts of Postulated Accidents

calculated for DBAs should not differ significantly from initial licensing assessments over the life of the plant, including the period of extended operation. Accordingly, the design of the plant relative to DBAs during the period of extended operation is considered to remain acceptable and the environmental impacts of those accidents were not examined further in the GEIS.

The Commission has determined that the environmental impacts of DBAs are of SMALL significance for all plants because the plants were designed to successfully withstand these accidents. Therefore, for the purposes of license renewal, design-basis accidents are designated as a Category 1 issue. The early resolution of the DBAs makes them a part of the current licensing basis of the plant; the current licensing basis of the plant is to be maintained by the licensee under its current license and, therefore, under the provisions of 10 CFR 54.30, is not subject to review under license renewal.

No new and significant information related to design-basis accidents was identified during the review of Exelon Generation's environmental report (ER) (AmerGen 2008a), site audit, scoping process, or evaluation of other available information. Therefore, there are no impacts related to these issues beyond those discussed in the GEIS.

5.2 Severe Accidents

Severe nuclear accidents are those that are more severe than DBAs because they could result in substantial damage to the reactor core, whether or not there are serious offsite consequences. In the GEIS, the staff assessed the impacts of severe accidents during the license renewal period, using the results of existing analyses and site-specific information to conservatively predict the environmental impacts of severe accidents for each plant during the renewal period.

Severe accidents initiated by external phenomena such as tornadoes, floods, earthquakes, fires, and sabotage have not traditionally been discussed in quantitative terms in FESs and were not specifically considered for the Three Mile Island Nuclear Station, Unit 1 (TMI-1) site in the GEIS (NRC 1996). However, the GEIS did evaluate existing impact assessments performed by NRC and by the industry at 44 nuclear plants in the United States and concluded that the risk from beyond design basis earthquakes at existing nuclear power plants is SMALL. The GEIS for license renewal performed a discretionary analysis of terrorist acts in connection with license renewal, and concluded that the core damage and radiological release from such acts would be no worse than the damage and release expected from internally initiated events. In the GEIS, the Commission concludes that the risk from sabotage and beyond design-basis earthquakes at existing nuclear power plants is small and additionally, that the risks from other external events are adequately addressed by a generic consideration of internally initiated severe accidents (NRC 1996).

Based on information in the GEIS, the Commission found that

The probability weighted consequences of atmospheric releases, fallout onto open bodies of water, releases to ground water, and societal and economic impacts from severe accidents are small for all plants. However, alternatives to

mitigate severe accidents must be considered for all plants that have not considered such alternatives.

We identified no new and significant information related to postulated accidents during the review of Exelon Generation's ER (AmerGen 2008a), the site audit, the scoping process, or evaluation of other available information. Therefore, there are no impacts related to these issues beyond those discussed in the GEIS. However, in accordance with 10 CFR 51.53(c)(3)(ii)(L), we have reviewed severe accident mitigation alternatives (SAMAs) for TMI-1. The results of the review are discussed in Section 5.3.

5.3 Severe Accident Mitigation Alternatives

Section 51.53(c)(3)(ii)(L) requires that license renewal applicants consider alternatives to mitigate severe accidents if the staff has not previously evaluated SAMAs for the applicant's plant in an EIS or related supplement or in an environmental assessment. The purpose of this consideration is to ensure that plant changes (i.e., hardware, procedures, and training) with the potential for improving severe accident safety performance are identified and evaluated. SAMAs have not been previously considered for TMI-1; therefore, the remainder of Chapter 5 addresses those alternatives.

5.3.1 Introduction

This section presents a summary of the SAMA evaluation for TMI-1 conducted by Exelon Generation Company, LLC (Exelon Generation) and the NRC staff's review of that evaluation. The NRC staff performed its review with contract assistance from Pacific Northwest National Laboratory. The NRC staff's review is available in full in Appendix F; the SAMA evaluation is available in full in Exelon Generation's ER.

The SAMA evaluation for TMI-1 was conducted with a four step approach. In the first step Exelon Generation quantified the level of risk associated with potential reactor accidents using the plant specific probabilistic risk assessment (PRA) and other risk models.

In the second step Exelon Generation examined the major risk contributors and identified possible ways (SAMAs) of reducing that risk. Common ways of reducing risk are changes to components, systems, procedures, and training. Exelon Generation identified 33 potential SAMAs for TMI-1. Exelon Generation performed an initial screening to determine if any SAMAs could be eliminated because they are not applicable to TMI-1 due to design differences, or have estimated implementation costs that would exceed the dollar value associated with completely eliminating all severe accident risk at TMI-1 related to power generation operations. No SAMAs were eliminated based on this screening, leaving all 33 for further evaluation.

In the third step Exelon Generation estimated the benefits and the costs associated with each of the SAMAs. Estimates were made of how much each SAMA could reduce risk. Those estimates were developed in terms of dollars in accordance with NRC guidance for performing regulatory analyses (NRC 1997). The cost of implementing the proposed SAMAs was also estimated.

Environmental Impacts of Postulated Accidents

Finally, in the fourth step, the costs and benefits of each of the remaining SAMAs were compared to determine whether the SAMA was cost beneficial, meaning the benefits of the SAMA were greater than the cost (a positive cost benefit). Exelon Generation concluded in its ER that several of the SAMAs evaluated are potentially cost-beneficial (AmerGen 2008a). However, in response to NRC staff inquiries regarding estimated benefits for certain SAMAs and lower cost alternatives, several additional potentially cost-beneficial SAMAs were identified (AmerGen 2008b).

The potentially cost-beneficial SAMAs do not relate to adequately managing the effects of aging during the period of extended operation; therefore, they need not be implemented as part of license renewal pursuant to 10 CFR Part 54. Exelon Generation's SAMA analyses and the NRC's review are discussed in more detail below.

5.3.2 Estimate of Risk

Exelon Generation submitted an assessment of SAMAs for TMI-1 as part of the ER (AmerGen 2008a). This assessment was based on the most recent TMI-1 PRA available at that time, a plant specific offsite consequence analysis performed using the MELCOR Accident Consequence Code System 2 (MACCS2) computer program, and insights from the TMI-1 Individual Plant Examination (IPE) (GPU 1993) and Individual Plant Examination of External Events (IPEEE) (GPU 1994).

The scope of the Level 1 PRA model includes both internal and external initiating events. The external events evaluated are external floods, seismic events, and internal fires. However, the external events models are neither integrated with the internal event model, nor maintained as living analyses, thereby necessitating a separate assessment of the risk (and risk reduction) for internal and external events. Exelon Generation placed particular emphasis on external flooding events since they dominate the calculated risk at TMI-1.

The baseline CDF for the purpose of the SAMA evaluation is approximately 2.37×10^{-5} per year for internal events (including internal flooding events), and 8.11×10^{-5} per year for external flooding events. Exelon Generation accounted for the potential risk reduction benefits associated with internal event- and external flooding-related SAMAs by separately quantifying the benefits using the internal event or external flooding model, respectively. For internal event-related SAMAs, Exelon Generation accounted for the potential risk reduction benefits associated with non-flooding external events (i.e., seismic and fire events) by doubling the estimated benefits for internal events. For seismic- and fire-related SAMAs, Exelon Generation separately estimated the risk reduction benefits using the seismic and fire risk models. The breakdown of CDF by initiating event for TMI-1 is provided in Tables 5-1 and 5-2 for internal events and external flooding events, respectively.

Table 5-2. TMI-1 Internal Events Core Damage Frequency

Initiating Event	CDF (Per Year)	% Contribution to CDF
Loss of Offsite Power	7.73×10^{-6}	32.6
Transients	5.80×10^{-6}	24.5
Small and Very Small LOCA	4.66×10^{-6}	19.7
Loss of Nuclear Service River Water	3.67×10^{-6}	15.5
Steam Generator Tube Rupture	9.93×10^{-7}	4.2
Internal Floods	4.50×10^{-7}	1.9
Large and Medium LOCA	2.06×10^{-7}	< 1
ISLOCA	1.80×10^{-7}	<1
Total CDF (internal events)	2.37×10^{-5}	100

Table 5-3 TMI-1 External Flooding Events Core Damage Frequency

External Flooding Event	CDF (Per Year)	% Contribution to CDF
>310 feet	6.37×10^{-5}	78.5
305 to 310 feet	1.71×10^{-5}	21.1
<305 feet	2.50×10^{-7}	< 1
Total	8.11×10^{-5}	100

As shown in these tables, internal event CDF is dominated by loss of offsite power events, transients, small loss of coolant accidents (LOCA), and loss of nuclear service water events. External flooding CDF is dominated by events with flood levels exceeding 305 feet mean sea level (msl).

Exelon Generation estimated the dose to the population within 50 mi (80 km) of the TMI-1 site to be approximately 0.323 person-sievert (Sv) (32.3 person-rem) per year (AmerGen 2008a) for internal events and 1.76 person-Sv (176 person-rem) per year for external flooding events (AmerGen 2008b). The breakdown of the total population dose by containment release mode is summarized in Table 5-4. Steam generator tube rupture (SGTR) accidents, and basemat melt-through are the dominant contributors to population dose risk from internal events. For external flooding events, late containment failures and early containment failure (less than 12 hours following accident initiation) are the dominant contributors to population dose risk.

Table 5-4. Breakdown of Population Dose by Containment Release Mode

Containment Release Mode	Internal Events		External Flooding Events	
	Population Dose (Person-Rem Per Year)	% Contribution	Population Dose (Person-Rem Per Year)	% Contribution
Steam generator tube rupture	11.7	36	0.1	<0.1
Interfacing system LOCA	1.0	3	negligible	0
Containment isolation failure	1.1	3	29	16
Early containment failure	5.6	17	61	35
Late containment failure (large)	0.3	1	15	9
Late containment failure (small)	1.7	5	66	37
Basemat melt-through	6.9	22	4	2
No containment failure	4.0	13	1	1
Total	32.3	100	176	100

¹One person-Rem = 0.01 person-Sv

The NRC staff has reviewed Exelon Generation's data and evaluation methods and concludes that the quality of the risk analyses is adequate to support an assessment of the risk reduction potential for candidate SAMAs. Accordingly, the staff based its assessment of offsite risk on the CDFs and offsite doses reported by Exelon Generation.

5.3.3 Potential Plant Improvements

Once the dominant contributors to plant risk were identified, Exelon Generation searched for ways to reduce that risk. In identifying and evaluating potential SAMAs, Exelon Generation considered insights from the plant-specific PRA, and SAMA analyses performed for other operating plants that have submitted license renewal applications. This search included reviewing insights from the plant-specific risk studies, and reviewing plant improvements considered in previous SAMA analyses. Exelon Generation identified 33 potential risk-reducing improvements (SAMAs) to plant components, systems, procedures and training. A detailed cost-benefit analysis was performed for each of the SAMAs.

The staff concludes that Exelon Generation used a systematic and comprehensive process for identifying potential plant improvements for TMI-1, and that the set of potential plant improvements identified by Exelon Generation is reasonably comprehensive and, therefore, acceptable.

5.3.4 Evaluation of Risk Reduction and Costs of Improvements

Exelon Generation evaluated the risk reduction potential of the candidate SAMAs. The SAMA evaluations were performed using realistic assumptions with some conservatism.

Exelon Generation estimated the costs of implementing the candidate SAMAs through the application of engineering judgment and the use of other licensee's estimates for similar improvements. The cost estimates conservatively did not include the cost of replacement power during extended outages required to implement the modifications, nor did they account for inflation.

The staff reviewed Exelon Generation's bases for calculating the risk reduction for the various plant improvements and concludes that the rationale and assumptions for estimating risk reduction are reasonable and generally conservative (i.e., the estimated risk reduction is higher than what would actually be realized). Accordingly, the staff based its estimates of averted risk for the various SAMAs on Exelon Generation's risk reduction estimates.

The staff reviewed the bases for the applicant's cost estimates. For certain improvements, the staff also compared the cost estimates to estimates developed elsewhere for similar improvements, including estimates developed as part of other licensees' analyses of SAMAs for operating reactors and advanced light-water reactors. The staff found the cost estimates to be reasonable, and generally consistent with estimates provided in support of other plants' analyses.

The staff concludes that the risk reduction and the cost estimates provided by Exelon Generation are sufficient and appropriate for use in the SAMA evaluation.

5.3.5 Cost-Benefit Comparison

The cost benefit analysis performed by Exelon Generation was based primarily on NUREG/BR 0184 (NRC 1997) and was executed consistent with this guidance. NUREG/BR-0058 has recently been revised to reflect the agency's revised policy on discount rates. Revision 4 of NUREG/BR-0058 states that two sets of estimates should be developed - one at 3 percent and one at 7 percent (NRC 2004). Exelon Generation performed the SAMA analysis using only a 3 percent discount rate (AmerGen 2008a) and based its decisions on potentially cost-beneficial SAMAs on these values. Use of only a 3 percent discount rate in the cost-benefit analysis is considered acceptable for the purposes of the SAMA evaluation since it would tend to result in identification of a greater number of potentially cost-beneficial SAMAs.

Exelon Generation identified nine potentially cost-beneficial SAMAs in the baseline analysis contained in the ER. The potentially cost-beneficial SAMAs are:

SAMA 8 – Automate reactor coolant pump trip on high motor bearing cooling temperature.

SAMA 11 – Enhance extreme external flooding mitigation equipment to address station blackout and loss of reactor coolant pump seal cooling scenarios.

Environmental Impacts of Postulated Accidents

SAMA 12 – Use the decay heat removal system as an alternate suction source for high pressure injection.

SAMA 16 – Automate high pressure injection on low pressurizer level.

SAMA 19 – Install battery backed hydrogen igniters or a passive hydrogen ignition system.

SAMA 21 – Install concrete shields to block direct pathways from the reactor pressure vessel to the containment wall and/or direct containment flooding early in external flooding scenarios.

SAMA 27 – Improve the 480V AC load center welds.

SAMA 32 – Pre-stage severe external flooding equipment.

SAMA 33 – Increase the flood protection height.

Exelon Generation performed additional analyses to evaluate the impact of parameter choices and uncertainties on the results of the SAMA assessment (AmerGen 2008a). If the benefits are increased by a factor of 2.75 to account for uncertainties, six additional SAMA candidates were determined to be potentially cost-beneficial:

SAMA 2 – Install damage-resistant high temperature reactor coolant pump seals with a portable 480V AC generator for extended emergency feedwater (EFW) operation.

SAMA 7 – Use fire service water as an alternate cooling source for the intermediate closed cooling water heat exchangers.

SAMA 15 – Automate swap to recirculation mode.

SAMA 23 – Develop alarm response procedures to direct operation of RR-V-5 on low reactor building emergency cooling flow.

SAMA 24 – Install damage-resistant high temperature reactor coolant pump seals with a diesel engine as an alternate drive for an EFW pump and a portable 480V AC generator for extended EFW operation.

SAMA 26 – Reroute cables so that they do not pass over ignition sources in fire zone CB-FA-2e or wrap them in fire proof material.

As a result of an additional sensitivity analysis and response to an NRC staff request, Exelon Generation identified two additional potentially cost-beneficial SAMAs (AmerGen 2008b):

SAMA 10 – Automate borated water storage tank refill.

SAMA 13 – Change instrument air system logic to automatically start IA-P-1A/B

The staff concludes that, with the exception of the potentially cost-beneficial SAMAs discussed above, the costs of the SAMAs evaluated would be higher than the associated benefits when they are considered independently.

5.3.6 Conclusions

The staff reviewed Exelon Generation's analysis and concluded that the methods used and the implementation of those methods were sound. The treatment of SAMA benefits and costs support the general conclusion that the SAMA evaluations performed by Exelon Generation are reasonable and sufficient for the license renewal submittal.

Based on its review of the SAMA analysis, the staff concurs with Exelon Generation's identification of areas in which risk can be further reduced in a cost-beneficial manner through the implementation of all or a subset of potentially cost-beneficial SAMAs. Given the potential for cost-beneficial risk reduction, the staff considers that further evaluation of these SAMAs by Exelon Generation is warranted. However, none of the potentially cost-beneficial SAMAs relate to adequately managing the effects of aging during the period of extended operation. Therefore, they need not be implemented as part of the license renewal pursuant to 10 CFR Part 54.

5.4 References

AmerGen (AmerGen Energy Company, LLC). 2008a. "Three Mile Island Nuclear Station, Applicant's Environmental Report, License Renewal Operating Stage." Kennett Square, Pennsylvania. ADAMS Accession Nos. ML080220255, ML080220257, ML080220261, and ML080220282.

AmerGen (AmerGen Energy Company, LLC). 2008b. Letter from Michael P. Gallagher, AmerGen Energy Company, LLC, to U.S. Nuclear Regulatory Commission Document Control Desk. Subject: "Response to NRC Request for Additional Information Related to Three Mile Island Nuclear Station 1 License Renewal Application (TAC No. MD7702)," dated July 17, 2008.

GPU (GPU Nuclear Corporation). 1993. Letter from T. G. Broughton, GPU, to U.S. NRC. Subject: Three Mile Island Nuclear Generation Station, Unit 1 (TMI-1), Operating License No. DPR-50, Docket No. 50-289, Response to Generic Letter 88-20, "Individual Plan Examinations for Severe Accident Vulnerabilities (IPE)". May 20, 1993.

GPU (GPU Nuclear Corporation). 1994. Letter from R. W. Keaten, GPU, to U.S. NRC. Subject: Three Mile Island Nuclear Generation Station, Unit 1 (TMI-1), Operating License No. DPR-50, Docket No. 50-289, Response to Generic Letter 88-20, Supplement 4, "Individual Plan Examination of External Events (IPEEE) for Severe Accident Vulnerabilities". December 29, 1994.

NRC (U.S. Nuclear Regulatory Commission). 1997. *Regulatory Analysis Technical Evaluation Handbook*. NUREG/BR 0184, Washington, D.C.

NRC (U.S. Nuclear Regulatory Commission). 2004. *Regulatory Analysis Guidelines of the U.S. Nuclear Regulatory Commission*. NUREG/BR-0058, Rev. 4, Washington, D.C.

6.0 ENVIRONMENTAL IMPACTS OF THE URANIUM FUEL CYCLE AND SOLID WASTE MANAGEMENT

This chapter addresses issues related to the uranium fuel cycle and solid waste management during the period of extended operation. The uranium cycle includes uranium mining and milling, the production of uranium hexafluoride, isotopic enrichment, fuel fabrication, reprocessing of irradiated fuel, transportation of radioactive materials, and management of low-level wastes and high-level wastes related to uranium fuel cycle activities. The generic environmental impact statement (GEIS) (NRC 1996, 1999) details the potential generic impacts of the radiological and nonradiological environmental impacts of the uranium fuel cycle and transportation of nuclear fuel and wastes, as listed in Table 6-1 below. The GEIS is based, in part, on the generic impacts provided in Table S-3, "Table of Uranium Fuel Cycle Environmental Data," in Title 10, Section 51.51(b), of the Code of Federal Regulations (10 CFR 51.51(b)), and in Table S-4, "Environmental Impact of Transportation of Fuel and Waste to and from One Light-Water-Cooled Nuclear Power Reactor," in 10 CFR 51.52(c). The GEIS also addresses the impacts from radon-222 and technetium-99.

The staff of the U.S. Nuclear Regulatory Commission (NRC) did not identify any new and significant information related to the uranium fuel cycle during the review of the Exelon Generation Company, LLC environmental report (AmerGen 2008), the site audit, and the scoping process. Therefore, there are no impacts related to these issues beyond those discussed in the GEIS. For these Category 1 issues, the GEIS concludes that the impacts are SMALL, except for the collective offsite radiological impacts from the fuel cycle and from high-level waste and spent fuel disposal.

Table 6-1. Issues Related to the Uranium Fuel Cycle and Solid Waste Management. *Nine generic issues are related to the fuel cycle and solid waste management. There are no site-specific issues.*

Issues	GEIS Section	Category
Offsite radiological impacts (individual effects from other than the disposal of spent fuel and high-level waste)	6.1, 6.2.1, 6.2.2.1, 6.2.2.3, 6.2.3; 6.2.4, 6.6	1
Offsite radiological impacts (collective effects)	6.1, 6.2.2.1, 6.2.3, 6.2.4, 6.6	1
Offsite radiological impacts (spent fuel and high-level waste disposal)	6.1, 6.2.2.1, 6.2.3, 6.2.4, 6.6	1
Nonradiological impacts of the uranium fuel cycle	6.1, 6.2.2.6, 6.2.2.7, 6.2.2.8, 6.2.2.9, 6.2.3, 6.2.4, 6.6	1
Low-level waste storage and disposal	6.1, 6.2.2.2, 6.4.2, 6.4.3, 6.4.3.1, 6.4.3.2, 6.4.3.3, 6.4.4, 6.4.4.1, 6.4.4.2,	1

Environmental Impacts of the Uranium Fuel Cycle and Solid Waste Management

Issues	GEIS Section	Category
Mixed waste storage and disposal	6.4.4.3, 6.4.4.4, 6.4.4.5, 6.4.4.5.1, 6.4.4.5.2, 6.4.4.5.3, 6.4.4.5.4, 6.4.4.6, 6.6	1
Onsite spent fuel	6.4.5.1, 6.4.5.2, 6.4.5.3, 6.4.5.4, 6.4.5.5, 6.4.5.6, 6.4.5.6.1, 6.4.5.6.2, 6.4.5.6.3, 6.4.5.6.4, 6.6 6.1, 6.4.6, 6.4.6.1, 6.4.6.2, 6.4.6.3, 6.4.6.4, 6.4.6.5, 6.4.6.6, 6.4.6.7, 6.6	1
Nonradiological waste	6.1, 6.5, 6.5.1, 6.5.2, 6.5.3, 6.6	1
Transportation	6.1, 6.3.1, 6.3.2.3, 6.3.3, 6.3.4, 6.6, Addendum 1	1

6.1 References

10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, “Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions.”

10 CFR Part 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, “Requirements for Renewal of Operating Licenses for Nuclear Power Plants.”

AmerGen (AmerGen Energy Company, LLC). 2008. “Three Mile Island Nuclear Station, Applicant’s Environmental Report, License Renewal Operating Stage.” Kennett Square, Pennsylvania. ADAMS Nos. ML080220255, ML080220257, ML080220261, and ML080220282.

NRC (U.S. Nuclear Regulatory Commission). 1996. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*, NUREG-1437, Vol. 1 and 2. Washington, D.C. ADAMS No. ML061770605.

Environmental Impacts of the Uranium Fuel Cycle and Solid Waste Management

NRC (U.S. Nuclear Regulatory Commission). 1999. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Main Report*, Section 6.3, "Transportation," Table 9.1, "Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants, Final Report." NUREG-1437, Vol. 1, Addendum 1. Washington, D.C.

7.0 ENVIRONMENTAL IMPACTS OF DECOMMISSIONING

Decommissioning is defined as the safe removal of a nuclear facility from service and the reduction of residual radioactivity to a level that permits release of the property for unrestricted use and termination of the license. The U.S. Nuclear Regulatory Commission (NRC) issued a generic environmental impact statement (GEIS) for decommissioning (NRC 2002) that evaluated the environmental impacts from the activities associated with the decommissioning of any reactor before or at the end of an initial or renewed license.

The NRC staff has not identified any new and significant information during the review of the Exelon Generation Company, LLC environmental report (AmerGen 2008), the site audit, or the scoping process. Therefore, there are no impacts related to these issues beyond those discussed in the GEIS (NRC 1996, 1999). For the issues listed in table 7-1 below, the GEIS concluded that the impacts are SMALL.

Table 7-1. Issues Related Decommissioning. *Decommissioning would occur regardless of whether or not Three Mile Island Nuclear Station, Unit 1, is shut down at the end of its current operating license or at the end of the period of extended operation. There are no site-specific issues related to decommissioning.*

Issues	GEIS Section	Category
Radiation doses	7.3.1; 7.4	1
Waste management	7.3.2; 7.4	1
Air quality	7.3.3; 7.4	1
Water quality	7.3.4; 7.4	1
Ecological resources	7.3.5; 7.4	1
Socioeconomic impacts	7.3.7; 7.4	1

7.1 References

AmerGen (AmerGen Energy Company, LLC). 2008. *Three Mile Island Nuclear Station, Applicant's Environmental Report, License Renewal Operating Stage*. Kennett Square, Pennsylvania. ADAMS Accession Nos. ML080220255, ML080220257, ML080220261, and ML080220282.

NRC (U.S. Nuclear Regulatory Commission). 1996. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*, NUREG-1437, Vols. 1 and 2. Washington, D.C. ADAMS No. ML061770605.

NRC (U.S. Nuclear Regulatory Commission). 1999. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Main Report*, "Section 6.3, Transportation, Table 9.1,

Environmental Impacts of Decommissioning

Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants, Final Report." NUREG-1437, Vol. 1, Addendum 1. Washington, D.C.

NRC (U.S. Nuclear Regulatory Commission). 2002. *Generic Environmental Impact Statement on Decommissioning of Nuclear Facilities: Supplement 1, Regarding the Decommissioning of Nuclear Power Reactors*. NUREG-0586, Supplement 1, Vol. 1 and 2. Washington, D.C.

8.0 ENVIRONMENTAL IMPACTS OF ALTERNATIVES

The National Environmental Policy Act (NEPA) mandates that each environmental impact statement (EIS) consider alternatives to any proposed major Federal action. NRC regulations implementing NEPA for license renewal require that a supplemental EIS “consider and weigh the environmental effects of the proposed action [license renewal]; the environmental impacts of alternatives to the proposed action; and alternatives available for reducing or avoiding adverse environmental impacts,” (10 CFR 51.71[d]). In this case, the proposed Federal action is issuing a renewed license for Three Mile Island Nuclear Station, Unit 1 (TMI-1), which will allow the plant to operate for 20 years beyond its current license expiration date. In this chapter, we examine the potential environmental impacts of alternatives to issuing a renewed operating license for TMI-1.

While NUREG-1437 “Generic Environmental Impact Statement for License Renewal of Nuclear Plants”, (GEIS; NRC 1996, 1999), reached generic conclusions regarding many environmental issues associated with license renewal, it did not determine which alternatives are reasonable or reach conclusions about site-specific environmental impact levels. As such, NRC staff must evaluate environmental impacts of alternatives on a site-specific basis.

Alternatives to the proposed action of issuing a renewed TMI-1 operating license must meet the purpose and need for issuing a renewed license; they must

“provide an option that allows for power generation capability beyond the term of a current nuclear power plant operating license to meet future system generating needs, as such needs may be determined by State, utility, and, where authorized, Federal (other than NRC) decisionmakers.”

The NRC staff ultimately makes no decision as to which alternative (or the proposed action) to implement, since that decision falls to utility, State, or other Federal officials to decide. Comparing the environmental effects of these alternatives will assist the NRC in deciding whether the environmental impacts of license renewal are so great that preserving the option of license renewal for energy-planning decisionmakers would be unreasonable (10 CFR 51.95[c][4]). If the NRC acts to issue a renewed license, all of the alternatives, including the proposed action, will be available to energy-planning decisionmakers. If the NRC decides not to renew the license (or takes no action at all), then energy-planning decisionmakers may no longer elect to continue operating TMI-1 and will have to resort to another alternative—which may or may not be one of the alternatives the NRC considers in this section—to meet their energy needs.

In evaluating alternatives to license renewal, we first select energy technologies or options currently in commercial operation, as well as some technologies not currently in commercial operation but likely to be commercially available by the time the current TMI-1 operating license expires.

Second, we screen the alternatives to remove those that cannot meet future system needs. Then, we screen the remaining options to remove those whose costs or benefits don't justify inclusion in the range of reasonable alternatives. Any alternatives remaining constitute

Alternatives

alternatives to the proposed action that the NRC evaluates in-depth throughout this section. At the end of the section, we will briefly address each alternative that we removed during screening.

The NRC staff initially considered 17 discrete potential alternatives to the proposed action, and narrowed the list to the four discrete alternatives and one combination alternative, which are considered in Sections 8.1 through 8.5.

Once we identify the in-depth alternatives, the staff refer to generic environmental impact evaluations in the GEIS. The GEIS provides overviews of some energy technologies available at the time of its publishing in 1996, though it does not reach any conclusions regarding which alternatives are most appropriate, nor does it precisely categorize impacts for each site. Since 1996, many energy technologies have evolved significantly in capability and cost, while regulatory structures have changed to either promote or impede development of particular alternatives.

Where applicable, our analyses draw on the GEIS and include updated information from sources like the Energy Information Administration (EIA), other organizations within the Department of Energy (DOE), the U.S. Environmental Protection Agency (EPA), industry sources and publications, and information submitted by the applicant (Exelon Generation Company, LLC [Exelon Generation]) in the Environmental Report (ER).

For each in-depth analysis, we analyze environmental impacts across seven impact categories: (1) air quality, (2) ground water use and quality, (3) surface water use and quality, (4) ecology, (5) human health, (6) socioeconomics, and (7) waste management. As in earlier chapters of this supplemental EIS, we use the NRC's three-level standard of significance—SMALL, MODERATE, or LARGE—to indicate the intensity of environmental effects for each alternative that we evaluate in-depth. By placing the detailed alternative analyses in this order, the NRC staff do not mean to imply which alternative would have the least impact, or which alternative an energy-planning decisionmaker would be most likely to implement.

Sections 8.1–8.5 contain our analyses of environmental impacts of alternatives to license renewal. Alternatives include a supercritical coal-fired plant (Section 8.1), a combined-cycle natural gas-fired power plant (Section 8.2), a conservation alternative (Section 8.3), and a combination of alternatives (Section 8.4), which includes some natural gas-fired capacity, uprates at hydropower dams in Pennsylvania, and about one-half of the conservation capacity utilized in Section 8.3. The NRC also considers a purchased-power alternative in Section 8.5. A

In-Depth Alternatives

- **Coal-fired Supercritical**
- **Natural-gas-fired Combined-cycle**
- **Conservation / Energy Efficiency**
- **Combination Alternative**
- **Purchased Power**

Other Alternatives Considered

- **Coal-fired IGCC**
- **Wind Power**
- **Solar Power (photovoltaic and concentrating)**
- **Wood Waste**
- **Conventional Hydroelectric Power**
- **Wave and Ocean Energy**
- **Geothermal Power**
- **Municipal Solid Waste**
- **Biofuels**
- **Oil-fired Power**
- **Fuel Cells**
- **Delayed Retirement**

Energy Outlook: Each year the Energy Information Administration (EIA), part of the U.S. Department of Energy (DOE), issues its updated *Annual Energy Outlook (AEO)*. *AEO 2008* indicates that coal and natural gas are likely to fuel most new electrical capacity through 2030, with significant contributions from new renewable sources and some growth in nuclear capacity (EIA 2008a), though all projections are subject to future developments in fuel price or electricity demand.

“Natural-gas-fired plants generally have lower capacity costs but higher fuel costs than coal-fired plants. As a result, coal-fired plants account for 40 percent of total capacity additions from 2006 to 2030, compared with a 36-percent share for natural gas. Renewable and nuclear plants tend to have high investment costs and relatively low operating costs. EIA 2005 and State RPS programs are expected to stimulate generation from renewable and nuclear plants, which represent 18 percent and 6 percent of total additions, respectively. The quantity and mix of capacity additions can also be affected by different fuel price paths or growth rates for electricity demand.”

discussion of alternatives considered but dismissed is included in Section 8.6. Finally, in Section 8.7, the NRC considers the environmental effects that could occur if NRC takes no action and does not issue a renewed license for TMI-1.

8.1 Supercritical Coal-Fired Generation

In this section, we evaluate the environmental impacts of supercritical coal-fired generation at an offsite location. Given that the available space at the TMI-1 site is smaller than the amount of space we predict a new coal-fired alternative would require, we will not consider a coal-fired alternative at the TMI-1 site. A summary of the environmental impacts from the coal-fired alternative compared to continued operation of TMI-1 is contained in Table 8-1 on page 8-5.

Coal-fired generation accounts for a greater share of U.S. electrical power generation than any other fuel (EIA 2007). Furthermore, the EIA projects that coal-fired power plants will account for the greatest share of capacity additions through 2030—more than natural gas, nuclear, or renewable generation options. While coal-fired power plants are widely used and likely to remain widely used, we acknowledge that future coal capacity additions may be affected by perceived or actual efforts to limit greenhouse gas emissions. For now, we consider a coal-

fired alternative to be a feasible, commercially-available option for providing electrical generating capacity beyond TMI-1's current license expiration.

Supercritical technologies are increasingly common in new coal-fired plants. Supercritical plants operate at higher temperatures and pressures than most existing coal-fired plants (beyond water's "critical point," where boiling no longer occurs and no clear phase change occurs between steam and liquid water). Operating at higher temperatures and pressures allows this coal-fired alternative to operate at a higher thermal efficiency than many existing coal-fired power plants. While supercritical facilities are more expensive to construct, they consume less fuel for a given output, reducing environmental impacts. Based on technology forecasts from EIA, we expect that a new, supercritical coal-fired plant beginning operation in 2014 would operate at a heat rate of 9,069 British thermal units per kilowatt-hour (Btu/kWh), or approximately 38 percent thermal efficiency (EIA 2008b).

Alternatives

In a supercritical coal-fired power plant, burning coal heats pressurized water. As the supercritical steam/water mixture moves through plant pipes to a turbine generator, the pressure drops and the mixture flashes to steam. The heated steam expands across the turbine stages, which then spin and turn the generator to produce electricity. After passing through the turbine, any remaining steam is condensed back to water in the plant's condenser.

In most modern U.S. facilities, condenser cooling water circulates through cooling towers or a cooling pond system (either of which are closed-cycle cooling systems). Older plants often withdraw cooling water directly from existing rivers or lakes and discharge heated water directly to the same body of water (called open-cycle cooling). For this analysis, the NRC assumed that a new supercritical coal-fired power plant would rely on closed-cycle cooling with cooling towers.

The plant likely would withdraw makeup water from nearby surface water sources and discharge blowdown (water containing concentrated dissolved solids and biocides) back to that same surface water. Cooling towers could be either natural draft (similar to the existing towers at TMI-1: tall towers powered only by the difference in density between heated, humid air, and surrounding cooler and usually drier air) or mechanical draft (shorter towers powered by mechanical fans).

In order to replace the 802 megawatt-electric (MWe) that TMI-1 currently supplies, the coal-fired alternative would need to produce roughly 850 megawatts (MW), using about 6 percent of power output for onsite power usage (AmerGen 2008). Onsite electricity usage powers scrubbers, cooling towers, coal-handling equipment, and other onsite electrical needs. A supercritical coal-fired power plant equivalent in capacity to TMI-1 would require slightly less cooling water than TMI-1 because the plant operates at a higher thermal efficiency.

Aside from cooling towers, other onsite structures would include the turbine building, boiler building, plant exhaust stack, coal pile, electrical switchyard, and a rail spur or coal dock. The GEIS (NRC 1996) estimated that a coal-fired alternative would require roughly 1.7 acres (ac) (1 hectare [ha]) per MWe capacity, or roughly 1,450 ac (587 ha). Exelon Generation indicated in their ER that the plant would require 129 ac (52 ha), a number more consistent with minimum utility needs as demonstrated by nearby power plants (including PPL Corporation's Brunner Island facility). We will adopt Exelon Generation's estimate for this analysis. Additional offsite land could be required for waste disposal, though much of the plant's ash and scrubber sludge could be reused in concrete and gypsum wallboard, respectively (ACAA 2007).

This 850 MWe power plant would consume 2.51 million tons (t) (2.28 million metric tons [MT]) of coal annually assuming an average heat content of 11,459 Btu/lb (EIA 2006). The EIA reported that most coal consumed in Pennsylvania originates in Pennsylvania. Coal would be mined either in underground mines or in surface mines, then mechanically processed and washed, before being transported—likely by rail—to the power plant site. Limestone for scrubbers would also arrive by rail. This coal-fired alternative would produce 404,000 t (366,000 MT) of ash and 263,000 t (238,000 MT) of scrubber sludge. Much of the coal ash and scrubber sludge could be reused, as noted above.

Environmental impacts from the coal-fired alternative will be greatest during construction. Site crews will clear the plant site of vegetation, prepare the site surface, and begin excavation before other crews begin actual construction on the plant and any associated infrastructure, including a rail spur to serve the plant and electricity transmission infrastructure connecting the

plant to existing transmission lines. Given available space onsite, the coal-fired alternative must be located elsewhere. Impacts resulting from a coal-fired unit offsite will vary depending on the nature of the site selected (e.g., a site that has never been developed will likely experience greater impacts than a site that was previously industrial; a site near other power plants or industrial facilities will likely experience smaller impacts than a site surrounded by farmland or relatively natural surroundings).

Table 8-1. Summary of Environmental Impacts of Supercritical Coal-Fired Generation Compared to Continued Operation of TMI-1.

	Supercritical Coal-Fired Generation		Continued TMI-1 Operation
	At TMI-1 site	At alternate site	
Air Quality	N/A	MODERATE	SMALL
Ground Water	N/A	SMALL	SMALL
Surface Water	N/A	SMALL	SMALL
Aquatic and Terrestrial Resources	N/A	SMALL to LARGE	SMALL
Human Health	N/A	SMALL to MODERATE	SMALL
Socioeconomics	N/A	SMALL to LARGE	SMALL
Waste Management	N/A	SMALL to MODERATE	N/A

8.1.1 Air Quality

Air quality impacts from coal-fired generation can be substantial because emissions contain significant quantities of sulfur oxides (SOx), nitrogen oxides (NOx), particulates, carbon monoxide (CO), and hazardous air pollutants such as mercury. However, many of these pollutants can be effectively controlled by various technologies.

TMI-1 is located within the Mid-Atlantic Air Quality Control Region, as designated by the EPA. The State is divided into six air regions and Dauphin County, where TMI-1 is located, belongs to the Southcentral Air Quality Region. Dauphin County is a nonattainment area for fine particulate matter (PM_{2.5}) and is part of the Harrisburg-Lebanon-Carlisle PM_{2.5} nonattainment area (which includes Cumberland, Dauphin and Lebanon counties). A new coal-fired generating plant developed at the TMI-1 site would need to comply with the new source performance standards for coal-fired plants set forth in 40 CFR 60 Subpart D(a), "Standards of Performance for Electric Utility Steam Generating Units for Which Construction is Commenced After September 18, 1978." The standards establish limits for particulate matter and opacity (40 CFR 60.42D(a)), sulfur dioxide (SO₂) (40 CFR 60.43D(a)), and NOx (40 CFR 60.44D(a)). A coal-fired power plant constructed elsewhere in Pennsylvania would also need to comply with applicable provisions of the Clean Air Act (CAA) (42 U.S.C. 7401), based on the attainment status of the selected alternate site.

Section 169A of the CAA establishes a national goal of preventing future and remedying existing impairment of visibility in mandatory Class I Federal areas when impairment results from man-made air pollution. In 1999, EPA issued a new regional haze rule (64 FR 35714). The rule specifies that for each mandatory Class I Federal area located within a state, the state must

Alternatives

establish goals that provide for reasonable progress towards achieving natural visibility conditions. The reasonable progress goals must provide an improvement in visibility for the most-impaired days over the period of the implementation plan and ensure no degradation in visibility for the least-impaired days over the same period (40 CFR 51.308(d)(1)). If a coal-fired plant were located close to a mandatory Class I area, additional air pollution control requirements would be imposed. There are no Mandatory Class I Federal areas in Pennsylvania, the closest is Brigantine Wilderness Area in New Jersey, roughly 125 miles east-southeast of TMI-1. At an alternate site, consideration may need to be given to the installation of additional air emission control systems if that site were in proximity to any Class I areas.

Pennsylvania regulates air emissions from power plants pursuant to terms of the Pennsylvania Air Pollution Control Act (APCA) (35 P.S. §§ 4001–4015). Regulations issued by the Pennsylvania Department of Environmental Protection (PADEP) adopt the EPA's CAA rules with modifications, to limit power plant emissions of SO_x, NO_x, particulate matter, and hazardous air pollutants (PADEP 2008). Depending where a new coal-fired facility is located within Pennsylvania, the facility will need to comply with the applicable Federal and State air regulations.

A supercritical coal-fired alternative would produce the following quantities of air pollutants:

Sulfur Oxides

A coal-fired alternative at the TMI-1 site would likely use wet, limestone-based scrubbers to remove SO_x. EPA indicates that this technology can remove more than 95 percent of SO_x from flue gases (EPA 2002). NRC projects total SO_x emissions would be 4,991 t (4,528.20MT) per year. SO_x emissions from a new coal-fired power plant would be subject to the requirements in Title IV of the CAA. Title IV was enacted to reduce emissions of SO₂ and NO_x, the two principal precursors of acid rain, by restricting emissions of these pollutants from power plants. Title IV caps aggregate annual power plant SO₂ emissions and imposes controls on SO₂ emissions through a system of marketable allowances. EPA issues one allowance for each ton of SO₂ that a unit is allowed to emit. New units do not receive allowances, but are required to have allowances to cover their SO₂ emissions. Owners of new units must therefore purchase allowances from owners of other power plants or reduce SO₂ emissions at other power plants they own. Allowances can be banked for use in future years. Thus, provided a new coal-fired power plant is able to purchase sufficient allowances to operate, it would not add to net regional SO₂ emissions, although it might do so locally.

Nitrogen Oxides

A coal-fired alternative at the TMI-1 site would most likely employ various available NO_x-control technologies including low-NO_x burners, over-fire air, and selective catalytic reduction. The EPA notes that when these emissions controls are used in concert, they can reduce NO_x emissions by up to 95 percent (EPA 1998a). Assuming the use of such technologies, NO_x emissions after scrubbing are estimated to be 628 t (570 MT) annually.

Section 407 of the CAA establishes technology-based emission limitations for NO_x emissions. A new coal-fired power plant would be subject to the new source performance standards for such plants as indicated in 40 CFR 60.44a(d)(1). This regulation, issued on Sept 16, 1998 (63 FR 49442), limits gas discharges to 200 nanograms (ng) of NO_x per joule (J) of gross energy output

(equivalent to 1.6 lb/MWh), based on a 30-day rolling average. The NRC estimates that the total annual NO_x emissions for a new coal-fired power plant with the modern emission controls identified in the previous paragraph would be approximately 12.4 percent of the new source performance standard mission rate. The EPA further controls the total amount of NO_x that can be emitted on a State-level basis. Annual budget for NO_x covered by allowances for 2009–2014 is 99,049 t (89,856 MT) (EPA 2005). A new coal-fired power plant would need to offset emissions through credit purchases or from a set-aside pool. It should be noted that NO_x emissions would have been subject to ozone-controlling elements of the Clean Air Interstate Rule (CAIR) had CAIR not been vacated by the D.C. Circuit Court in July of 2008. On September 24, 2008, EPA filed for a rehearing of the D.C. Circuit Court decisions. Until EPA, Congress, or the courts act, future NO_x regulatory approaches remain uncertain.

Particulates

A new coal-fired power plant would use fabric filters or electrostatic precipitators to remove particulates from flue gases. Exelon Generation indicates that fabric filters would remove 99.9 percent of particulate matter (AmerGen 2008). The EPA notes that filters or precipitators are each capable of removing in excess of 99 percent of particulate matter, and that SO₂ scrubbers further reduce particulate matter emissions (EPA 2002). As such, NRC staff believes Exelon Generation's removal factor is appropriate. Based on this, the new supercritical coal-fired plant would emit 161.27 t (146.3 MT) of total suspended particulates and approximately 37.09 t (33.65 MT) of PM₁₀ annually. In addition, coal burning would also result in PM_{2.5} emissions, and coal-handling equipment would introduce fugitive dust emissions when fuel is being transferred to on-site storage and then reclaimed from storage for use in the plant. During the construction of a coal-fired plant, on-site activities would also generate fugitive dust. Vehicles and motorized equipment would create exhaust emissions during the construction process. These impacts would be intermittent and short-lived, however, and to minimize dust generation construction crews would use applicable dust-control measures.

Carbon Monoxide

Based on EPA emission factors (EPA 1998), NRC staff estimates that the total CO emissions would be approximately 628 t (570 MT) per year.

Hazardous Air Pollutants

Following the D.C. Circuit Court's February 8, 2008, ruling that vacated its Clean Air Mercury Rule (CAMR), EPA is working to evaluate how it will regulate mercury emissions (EPA 2007). Before CAMR, EPA determined that coal- and oil-fired electric utility steam-generating units are significant emitters of hazardous air pollutants (HAPs) (EPA 2000a). EPA determined that coal plants emit arsenic, beryllium, cadmium, chromium, dioxins, hydrogen chloride, hydrogen fluoride, lead, manganese, and mercury (EPA 2000a). EPA concluded that mercury is the HAP of greatest concern and that (1) a link exists between coal combustion and mercury emissions, (2) electric utility steam-generating units are the largest domestic source of mercury emissions, and (3) certain segments of the U.S. population (e.g., the developing fetus and subsistence fish-eating populations) are believed to be at potential risk of adverse health effects resulting from mercury exposures caused by the consumption of contaminated fish (EPA 2000a). In light of the recent court decision, EPA will revisit mercury regulation, although it is possible that the agency will continue to regulate mercury as a HAP, thus requiring the use of best available control technology to prevent its release to the environment.

Alternatives

Carbon Dioxide

A coal-fired plant would also have unregulated carbon dioxide (CO₂) emissions during operations as well as during mining, processing, and transportation. Burning bituminous coal in the United States emits roughly 205.3 lb of CO₂ per million Btu (Hong and Slatick 1994). The supercritical coal-fired plant would emit approximately 5.914 million t (5.365 million MT) of CO₂ per year.

Summary of Air Quality

While the GEIS analysis mentions global warming from unregulated CO₂ emissions and acid rain from SO_x and NO_x emissions as potential impacts, it does not quantify emissions from coal-fired power plants. However, the GEIS analysis does imply that air impacts would be substantial (NRC 1996). The above analysis shows that emissions of air pollutants, including SO_x, NO_x, CO, and particulates, exceed those produced by the existing nuclear power plant, as well as those of the other alternatives considered in this section. Operational emissions of CO₂ are also much greater under the coal-fired alternative.⁶ Adverse human health effects such as cancer and emphysema have also been associated with air emissions from coal combustion, and are discussed further in Section 8.1.5.

The NRC analysis for a coal-fired alternative at an alternative site indicates that impacts from the coal-fired alternative would have clearly noticeable effects, but given existing regulatory regimes, permit requirements, and emissions controls, the coal-fired alternative would not destabilize air quality. Thus, the appropriate characterization of air impacts from coal-fired generation would be MODERATE. Existing air quality at the alternate location would result in varying needs for pollution control equipment to meet applicable local requirements, or varying degrees of participation in emissions trading schemes.

8.1.2 Ground Water Use and Quality

An off-site location for a coal-fired plant was assumed because Three Mile Island is too small to accommodate the area needed for this alternative. If the alternative site is adjacent to the Susquehanna River and operates 10 percent more efficiently than the current nuclear plant, most of the approximately 13,000 gallon per minute (gpm) for maximum cooling water withdrawal would be taken from the river, with an average consumptive loss of about 16 million gallons per day (mgd). The need for ground water at the plant would be minor, with supply wells used for potable drinking water and various service water functions. No effect on ground water quality would be apparent.

Construction of a coal-fired plant at a new site could have a localized effect on ground water due to temporary dewatering and run-off control measures. Because of its temporary nature, the impact of construction would be SMALL.

⁶ Table S-3 in 10 CFR 51.51 indicates that electrical energy consumed during the uranium fuel cycle to supply a 1,000 MW(e) reactor is equivalent to the electricity produced by a 45 MW(e) coal-fired power plant.

8.1.3 Surface Water Use and Quality

Again, an offsite location for a coal-fired plant was assumed because Three Mile Island is too small to accommodate the area needed for this alternative. If the alternative site is adjacent to the Susquehanna River, most of the approximately 13,000 gpm needed for maximum withdrawal would be taken from the river with an average consumptive loss of about 16 mgd. This consumptive loss is less than 0.1 percent of the average annual flow of the Susquehanna River, and as such the NRC concludes the impact of surface water use at an alternative site would be SMALL. A new coal-fired plant would be required to obtain a National Pollutant Discharge and Elimination System (NPDES) permit from the PADEP for regulation of industrial waste water, storm water, and other discharges. If the plant is operated within the limits of the permit, the impact of discharges on surface water quality would be SMALL.

8.1.4 Terrestrial and Aquatic Ecology

Terrestrial Ecology

As indicated in previous sections, constructing the coal-fired alternative will require 129 ac (52 ha) of land. Coal-mining operation will also affect terrestrial ecology in offsite coal mining areas, although some of the land is likely already disturbed by mining operations. On-site and offsite land disturbances form the basis for impacts to terrestrial ecology.

Impacts to terrestrial ecology will vary based on the degree to which the proposed plant site is already disturbed. On a previous industrial site, impacts to terrestrial ecology would be minor, unless substantial transmission line right-of-ways (ROWs), railways, or roads would need to be constructed through less disturbed areas. These construction activities may have a cumulative effect of fragmenting or destroying habitats. Any on-site or offsite water disposal by landfilling will also affect terrestrial ecology at least through the time period when the disposal area is reclaimed. Some areas onsite, such as buffer areas, may remain undeveloped and could serve as habitat for terrestrial species, though site lighting, noise, and activities may degrade the value of these ecosystems. Deposition of acid rain or other emissions can also affect terrestrial ecology. Given the emission controls discussed in Section 8.1.1, air deposition impacts may be noticeable, but are not likely to be devastating. Impacts to terrestrial resources from a coal-fired alternative would be SMALL, and occur mostly during construction.

Aquatic Ecology

A new coal-burning power plant constructed at an alternate site would need a source of water for the plant's cooling system (likely closed-cycled with cooling towers) as well as a discharge point for plant cooling tower blowdown. Aquatic impacts at an alternate site depend on location and ecology of the site, and the surface water body used for intake and discharge. These impacts are likely SMALL at a previously industrial site, owing to generally closer access to pipelines and transmission lines than at undeveloped sites. Impacts could range from SMALL to LARGE at previously undisturbed sites. Decreases in withdrawal from and discharge to the Susquehanna River may partially offset some aquatic impacts at an alternate site. Impacts will depend upon location and ecology of the site, and the surface water body used for intake and discharge.

Alternatives

8.1.5 Human Health

Human health risks of coal-fired power plants are described in general, in the GEIS Table 8-2 and Section 8.3.9. Cancer and emphysema are identified as potential health risks to occupational workers and members of the public (NRC 1996). The human health risks of coal-fired power plants, both to occupational workers and to members of the public, are greater than those of the current TMI-1 due to exposures to chemicals such as mercury; SO_x; NO_x; radioactive elements such as uranium and thorium; and polycyclic aromatic hydrocarbon (PAH) compounds, including benzo(a)pyrene. However, the current Federal and State regulatory frameworks pertaining to air emission standards allow for the adequate protection of occupational workers and members of the public. Therefore, the NRC staff has adopted (where applicable) the Federal and State air quality regulatory limits as significance thresholds for determining the human health risks associated with the operation of a new coal-fired power plant.

Radiological Human Health Risks

Coal contains uranium, thorium, and other naturally occurring radioactive elements. The U.S. Geological Survey (USGS) indicates that Western and Illinois Basin coals contain uranium and thorium at roughly equal concentrations, mostly between 1 and 4 parts per million (ppm), but also indicates that some coals may contain concentrations as high as 20 ppm of both elements (USGS 1997). A typical 1,000 MWe coal-fired plant could release roughly 5.2 t (4.7 MT) of uranium and 12.8 t (11.6 MT) of thorium to the atmosphere (Gabbard 1993). The USGS and Gabbard indicate that almost all of the uranium, thorium, and most decay products remain in solid coal wastes, especially in the fine glass spheres that constitute much of coal's fly ash. Modern emission controls, such as those included for this coal-fired alternative, allow for recovery of greater than 99 percent of these solid wastes (EPA 1998), thus retaining most of coal's radioactive elements in solid form rather than releasing them to the atmosphere. Even after concentration in coal waste, the level of radioactive elements remains relatively low—typically 10 to 100 ppm—and consistent with levels found in naturally occurring granitic rocks, shale, and phosphate rocks (USGS 1997). Natural radioactive material in rocks and soil account for about 29 millirem (mrem) or 8 percent of the radiation dose a person typically receives in a year from all sources (natural and manmade). Currently, there is no scientific evidence that radiation dose exposures of 29 mrem above the natural background dose would cause adverse human health impacts. The Biological Effect of Ionizing Radiation (BEIR) committee has calculated the lifetime attributable risk (LAR) of incidence and mortality for all solid cancers and for leukemia to be four to five persons per 100,000 persons exposed to 100 milliseiverts (mSv) (10 rem), which is over 20 times that of the natural background radiation dose of 360 mrem (NAS 2005). Therefore, the radiological human health risks from a 1,000 MWe coal-fired plant to occupational workers and members of the public would be SMALL.

PAH Human Health Risks

The EPA has classified seven PAHs—benzo(a)pyrene, benz(a)anthracene, chrysene, benzo(b)fluoranthene, benzo(k)fluoranthene, dibenz(a,h)anthracene, and indeno(1,2,3-cd)pyrene—as probable human carcinogens (EPA 199a, EPA 199b, EPA 1999c). PAHs have been detected in ambient air from sources including coal tar production plants, coking plants, and coal-gasification sites. Epidemiologic studies have reported an increase in lung cancer risks

in humans exposed to emission from coal tar production plants, coking plants, and coal-gasification sites. Each of these emissions mixtures contains a number of PAH compounds (ATSDR 1995, HHS 1993). The Occupational Safety and Health Administration (OSHA) has set a limit of 0.2 mg of PAHs per cubic meter (m^3) of air. Given that the plant must comply with OSHA regulatory limits, the health risks to occupational workers and members of the public from benzo[a]pyrene emission is expected be MODERATE.

Mercury Human Health Risks

As noted in Section 8.1.1, the EPA determined that coal-fired electric utility steam generating power plants were significant emitters of hazardous air pollutants and concluded that mercury is the hazardous air pollutant of greatest concern due to its persistence in the environment, potential to bioaccumulate, and toxicity to humans and the environment (65 FR 32214). Non-cancer risks of oral exposure to methyl-mercury have been observed to produce significant developmental effects in humans. Infants born to women who ingested high concentrations of methyl mercury exhibited central nervous system effects, such as mental retardation, ataxia, deafness, constriction of the visual field, blindness, and cerebral palsy. At lower methyl-mercury concentrations, developmental delays and abnormal reflexes were noted (ATSDR 1999, EPA 1997). No studies are available on the carcinogenic effects or cancer risks of methyl-mercury in humans, and only one available animal study reported renal tumors in mice; nevertheless, the EPA has classified methyl-mercury as a possible human carcinogen (EPA 1999d). The methyl-mercury dose resulting from emissions from a typical coal-fired power plant are uncertain. As noted in Section 8.1.1, EPA's CAMR regulation was vacated this year, and the near-term regulatory structure for mercury emission is uncertain. It is possible that EPA will return to regulating mercury as a HAP. The NRC staff expects that the EPA will implement new mercury regulations prior to the operational date of a coal-fired alternative. Because any new coal-fired plant will have to comply with EPA regulatory limits, the health risks to occupational workers and members of the public from mercury emissions is expected be MODERATE.

NOx and SO₂ Human Health Risks

NOx causes a wide variety of health risks and environmental impacts because of various compounds and derivatives in the family, including nitrogen dioxide, nitric acid, nitrous oxide, nitrates, and nitric oxide. NOx reacts with ammonia, moisture, and other compounds to form nitric acid and related particles. Human health risks include impacts to the respiratory system, damage to lung tissue, and premature death. Small particles penetrate deeply into sensitive parts of the lungs, and can cause or worsen respiratory diseases such as emphysema and bronchitis, and can aggravate existing heart disease (EPA 2008a). Environmental impacts include increased acidic deposition, and contributions to acid rain.

The combustion of fossil fuels (particularly coal) accounts for 50 percent of annual global SO₂ emissions. Human health risks of SO₂ include aggravation of asthma and chronic bronchitis, emphysema, impairment of pulmonary functions, respiratory irritation, and increased mortality. Environmental concentrations of 50-100 micrograms per cubic meter ($\mu g/m^3$) affect some plants species. SO₂ also contributes to the formation of acid rain in a similar manner as NOx (EPA 2008c).

As indicated in the Air Quality section, NOx and SO₂ emissions from coal-fired power plants are subject to the requirements in Title IV of the CAA. Because CAA regulations are based on human health or environmental criteria for setting permissible levels, it sets limits both to protect

Alternatives

public health (including the health of “sensitive” populations such as asthmatics, children and the elderly) and to protect public welfare (including protection against decreased visibility, and damage to animals, crops, vegetation, and buildings). Given that the plant must comply with CAA regulatory limits, the environmental impact and health risks to occupational workers and members of the public from NO_x and SO₂ is expected be MODERATE.

Summary

Regulatory agencies, including the EPA and State agencies, set air emission standards and requirements based on human health risks. These agencies also impose site-specific emission limits as needed to protect human health. Human health risks to occupational workers and to members of the public from a coal-fired power plant are expected be SMALL to MODERATE. Trading or offset mechanisms in nonattainment areas will act to prevent further degradation.

8.1.6 Socioeconomics

Land Use

The GEIS generically evaluates the impacts of nuclear power plant operations on land use both on and off each power plant site. The analysis of land use impacts focuses on the amount of land area that would be affected by the construction and operation of a new supercritical coal-fired power plant. Land-use impacts would vary depending on where the plant would be located and whether construction would take place on undeveloped land or within a previously disturbed (brownfield) area.

Exelon Generation indicated that approximately 129 ac (52 ha) would be necessary to support a coal-fired alternative capable of replacing TMI-1. The GEIS, however, estimates a need for up to 1,700 ac (688 ha) for a 1,000-MWe generating station (NRC 1996). This amount of land use would include other plant structures and associated infrastructure. By scaling the GEIS estimate, a 853-MWe plant could require up to approximately 1,450 ac (587 ha) of land for the plant site, transmission line ROWs, and a rail spur.

Based on land use for other power plants, the NRC staff believes the Exelon Generation estimate to be reasonable, although additional land may be used for buffer around plant structures or to support transmission lines and a rail spur. Even assuming additional land use for these purposes, total land required by the coal-fired alternative is unlikely to exceed 1,450 ac (587 ha) for all uses, excluding coal mining.

Many locations suitable for siting the coal-fired alternative (especially flat terrain areas along rivers similar to power plants currently located in this part of the United States) may have been disturbed by previous development. Brownfield sites, or sites that were previously used for industrial purposes, may be the most likely location for a new supercritical coal-fired power plant. Sites along rivers generally have easier access to transportation for coal fuel and major plant components, both by barge and train. Sites that have previously been used for industrial activities may also have existing rail spurs and dock or pier infrastructure and may be closer to transmission lines.

Coal mining introduces offsite land use impacts in addition to direct land use impacts from the construction and operation of new coal-fired power plants. Land disturbance would likely occur

in Pennsylvania, Ohio, or West Virginia because a significant amount of coal used in Pennsylvania power plants originates in these three States, although significant amounts of coal also come from Kentucky and western States like Wyoming (EIA 2006).⁷

According to analyses conducted for the GEIS, approximately 22,000 ac (8,903 ha) of land could be affected by coal mining and waste disposal in support of a 1,000-MWe coal plant during its operational life (NRC 1996). By scaling the GEIS estimate, an 853-MWe plant could require up to 18,800 ac (7,600 ha) of land to support a coal-fired power plant capable of replacing TMI-1; however, most of this land is located in existing coal-mining areas and has already been disturbed. The elimination of uranium fuel for TMI-1 could partially offset off site land use. In the GEIS, the NRC staff estimated that approximately 1,000 ac (405 ha) would not be needed for mining and processing uranium during the operating life of a 1,000-MWe nuclear power plant. For TMI-1, roughly 850 ac (344 ha) of uranium mining area would no longer be needed. However, an additional 159 ac (64 ha) of land would be needed for waste disposal during the 40 year plant life.⁸ This is a smaller amount of land area than was estimated by Exelon Generation in the ER (AmerGen 2008), because of higher ash and gypsum recycling rates.

Land use impacts could range from MODERATE to LARGE, depending on where the power plant is located. The amount of land required under the coal-fired alternative could be reduced by constructing new transmission lines in existing ROWs.

Socioeconomics

Socioeconomic impacts are defined in terms of changes to the demographic and economic characteristics and social conditions of a region. For example, the number of jobs created by the construction and operation of a new coal-fired power could affect regional employment, income, and expenditures. Job creation is characterized by two types: (1) construction-related jobs, which are transient, short in duration, and less likely to have a long-term socioeconomic impact; and (2) operation-related jobs in support of power plant operations, which have the greater potential for permanent, long-term socioeconomic impacts. Workforce requirements of power plant construction and operation for the coal-fired alternative were determined in order to measure their possible effect on current socioeconomic conditions.

Exelon Generation projected a maximum construction workforce of 1,328 (AmerGen 2008). The GEIS projects a workforce of 1,200 to 2,500 for a 1,000-MWe plant (when extrapolated, a workforce of 1,000 to 2,100 for an 853-MWe plant). The NRC staff believes that the Exelon Generation estimate is reasonable and is within the range provided by the GEIS. Furthermore, the upper-end estimate of the GEIS is probably too large.

During the five-year construction period, the communities surrounding the plant site would experience increased demand for rental housing and public services, although these effects would be moderated if the construction site is located near an urban area with many skilled

⁷ Western coal tends to have lower sulfur and somewhat lower heating content than eastern coal. Many power stations use western, subbituminous coal to reduce sulfur oxide emissions without having to install scrubber equipment. A power plant equipped with scrubbers is more likely to use local, higher sulfur coals rather than incurring the cost of shipping low-sulfur coal from western states.

⁸ Only half of the land area needed for waste disposal is directly attributable to the alternative of renewing the TMI-1 operating license for 20 years.

Alternatives

workers. The relative economic effect of these workers on local economy and tax base would vary over time.

After construction, local communities may be temporarily affected by the loss of construction jobs and associated loss in demand for business services, and the rental housing market could experience increased vacancies and decreased prices. As noted in the GEIS, the socioeconomic impacts at a rural construction site could be larger than at an urban site, because the workforce would have to move to be closer to the construction site. The impact of construction on socioeconomic conditions could range from SMALL to LARGE depending on whether the new power plant would be located at an urban or rural site. The socioeconomic impacts of power plant construction could be reduced if the power plant is located near an urban area with many skilled workers.

Exelon Generation estimated a power plant operations workforce of 92 (AmerGen 2008), while extrapolated GEIS estimates would call for up to 213 workers. The Exelon Generation estimate appears reasonable and is consistent with trends toward lowering labor costs by reducing the size of power plant operations workforces. Operations impacts will likely be SMALL to MODERATE, depending on whether the power plant is located near an urban or rural area.

Transportation

During five years of construction, up to 2,100 workers would be commuting to the construction site. This would increase the volume of traffic on roads leading to and coming from the construction site. Effects would vary depending on the number of site access roads. In addition to workers vehicles, trucks would deliver construction material and remove debris from the worksite. The number of additional vehicles on local roads could increase the overall effect. Trains or barges, or both, could be used to deliver large power plant components to the plant site.

Transportation impacts would be greatly reduced after construction of the power plant. The number of operations personnel commuting to and from the plant site would range from 92 to 213 workers. More significant, though, would be the frequent deliveries of coal and limestone to the plant site, most likely by rail, which would result in traffic delays at railroad crossings. Approximately 252 unit trains (trains with up to 100 cars carrying 100 t of coal per car for 10,000 t [9,070 MT] per train) per year would be necessary. Onsite coal storage would make it possible to receive several trains per day. Limestone would also be delivered by rail, which could cause additional traffic delays at railroad crossings (though considerably less rail traffic than that generated by coal deliveries). If coal and limestone were delivered by barge, rail transportation-related impacts to be would be reduced.

Overall, the coal-fired alternative would likely have SMALL to MODERATE transportation impacts in the vicinity of the power plant site, although the extent of impacts would depend on existing infrastructure capacity and demand, as well as whether coal and limestone would be delivered by rail or barge.

Aesthetics

Aesthetic resources are the natural and man-made features that give a particular landscape its character and aesthetic quality. The aesthetics impact analysis focuses on the degree of

contrast between the power plant and the surrounding landscape and the visibility of the power plant.

The coal-fired alternative's power plant could be up to 200 ft (61 m) tall and may be visible off site in daylight hours. The exhaust stack could be up to 600 ft (183 m) high (at least 500 ft [152 m] for good engineering practice). Additional visual impacts would occur if a natural-draft cooling tower is constructed. Similar to the cooling towers at TMI-1, the natural-draft cooling tower may be several hundred feet high and sometimes topped with condensate plumes. Mechanical draft towers would also generate condensate plumes but will be lower than the plumes from the natural-draft tower. Other buildings onsite may also affect aesthetics, as could construction of new transmission lines. Noise and light from plant operations, as well as lighting on plant structures, may be detectable off site.

If the coal-fired alternative is located along a river valley terrain, impacts may be moderated by higher elevation ridges along the valley rim, which could make it difficult to see and hear the plant outside of the river valley. Aesthetic impacts could be further mitigated if the plant were located in an industrial area adjacent to other industrial facilities and power plants. Overall, the aesthetic impacts associated with the coal-fired alternative would likely be SMALL to MODERATE, depending on the location of the site, topography, and proximity to other industrial facilities, as opposed to areas where visual resources are particularly valued.

Historic and Archaeological Resources

It is difficult to determine the effects on historic and archaeological resources when a specific location has not been selected. The potential for historic and archaeological resources can vary greatly depending on the location of the proposed site. To consider a project's effects on historic and archaeological resources, any proposed areas will need to be surveyed to identify and record historic and archeological resources, identify cultural resources, and develop possible mitigation measures to address any adverse effects from ground-disturbing activities. Studies will be needed for all areas of potential disturbance at the proposed plant site and along associated corridors where new construction will occur (e.g., roads, transmission corridors, rail lines, or other ROWs). In most cases, project proponents should avoid areas with the greatest sensitivity. Depending on the resource richness of the site ultimately chosen for the coal-fired alternative, impacts will range from SMALL to MODERATE.

Environmental Justice

The environmental justice impact analysis evaluates the potential for disproportionately high and adverse human health and environmental effects on minority and low-income populations that could result from the construction and operation of a new supercritical coal-fired power plant. Adverse health effects are measured in terms of the risk and rate of fatal or nonfatal adverse impacts on human health. Disproportionately high and adverse human health effects occur when the risk or rate of exposure to an environmental hazard for a minority or low-income population is significant and exceeds the risk or exposure rate for the general population or for another appropriate comparison group. The minority and low-income populations are subsets of the general public residing around the site, and all are exposed to the same hazards generated from various operations at the site.

Minority and low-income populations could be affected by the construction and operation of a new supercritical coal-fired power plant. Some of these effects have been identified in resource

Alternatives

areas discussed in this section. The extent of environmental justice effects is difficult to determine since it would depend in part on the location of the coal-fired power plant and whether a plant in a given location would contribute to impacts that are both adverse and disproportionate for minority or low-income populations. For example, increased demand for rental housing during construction could disproportionately affect low-income populations. However, demand for rental housing could be mitigated if the alternate plant site is constructed near a metropolitan area. Also, increased coal consumption may affect employment opportunities and environmental conditions in low-income regions in Pennsylvania, Ohio, or West Virginia.

Environmental justice impacts on minority and low-income populations from the construction and operation of a coal-fired alternative could range from SMALL to MODERATE and would depend on whether effects from the plant on minority and low-income populations are adverse and disproportionate.

8.1.7 Waste Management

Coal combustion generates several waste streams including ash (a dry solid) and sludge (a semi-solid by-product of emission control system operation). The NRC staff estimates that an 850-MWe power plant would generate 222,000 t (201,000 MT) of ash and approximately 55,200 t (50,000 MT) of scrubber waste per year, which would need to be disposed of onsite or in an offsite landfill (ACAA 2007). Based on industry-wide average recycling rates, of this waste, 182,000 t (165,000 MT) of the ash and 208,000 t (188,000 MT) of scrubber sludge could be recycled (ACAA 2007).

On-site disposal is likely to encompass approximately 159 ac (64 ha) over 40 years of operation. In addition to coal combustion wastes, a supercritical coal-fired alternative would also produce small amounts of domestic and hazardous wastes.

Waste impacts to ground water and surface water would extend beyond the operating life of the plant if leaching and runoff from the waste storage area makes its way into ground water or surface water. Disposal of the waste would noticeably affect land use and ground water quality if not properly managed, but with appropriate management and monitoring, impacts to ground water resources would be prevented. After closure of the landfill and revegetation, the disposal area would be available for other uses. Impacts of the waste generated by a coal-fired alternative are considered by the NRC to be SMALL to MODERATE.

8.2 Natural Gas Combined-Cycle Generation

In this section, we evaluate the environmental impacts of natural gas-fired combined-cycle generation at the TMI-1 site and at an alternate site. On page 8-18, Table 8-2 contains a summary of environmental impacts of natural gas combined-cycle generation in comparison to continued operation of TMI-1.

Natural gas fueled 20 percent of electric generation in the United States in 2006 (the most recent year for which data are available), accounting for the second greatest share of electrical power after coal (EIA 2007). Like coal-fired power plants, natural-gas-fired plants may be

affected by perceived or actual action to limit greenhouse gas emissions, though they produce markedly fewer greenhouse gases per unit of electrical output than coal-fired plants. Natural gas-fired power plants are feasible, commercially available options for providing electrical generating capacity beyond TMI-1's current license expiration.

Combined-cycle power plants differ significantly from coal-fired and existing nuclear power plants. They derive the majority of their electrical output from a gas-turbine cycle, and then generate additional power—without burning any additional fuel—through a second, steam-turbine cycle. The first, gas turbine stage (similar to a large jet engine) burns natural gas which turns a driveshaft that powers an electric generator. The exhaust gas from the gas turbine is still hot enough, however, to boil water to steam. Ducts carry the hot exhaust to a heat recovery steam generator, which produces steam to drive a steam turbine and produce additional electrical power. The combined-cycle approach is significantly more efficient than any one cycle on its own; efficiencies can exceed 60 percent. Since the natural-gas-fired alternative derives much of its power from a gas turbine cycle, and because it wastes less heat than either the coal-fired alternative or the existing TMI-1, it requires significantly less cooling water and smaller cooling towers.

In order to replace the 802 MWe that TMI-1 currently supplies, the NRC selected a gas-fired alternative that uses two General Electric S107H combined-cycle generating units. While any number of commercially-available combined-cycle units could be installed in a variety of combinations to replace the power currently produced by TMI-1, the S107H is a highly-efficient model that will help to minimize environmental impacts. Other manufacturers, like Siemens, offer similar high efficiency models. This gas-fired alternative produces a net 400 MWe per unit. Two units produce a total of 800 MWe, or nearly the same output as TMI-1.

The combined-cycle alternative operates at a heat rate of 5,690 Btu/kWh, or nearly 60 percent thermal efficiency (GE 2007). Allowing for onsite power usage, including cooling towers and site lighting, the gross output of these units would be roughly 830 MWe. As noted above, this gas-fired alternative would require much less cooling water than TMI-1, because it operates at a higher thermal efficiency and requires much less water for steam cycle condenser cooling. Cooling towers for this alternative would likely be mechanical draft-type towers approximately 65 ft (20 m) in height.

In addition to cooling towers, other visible structures onsite include the turbines and heat recovery steam generators (which may be enclosed in a single building), two exhaust stacks, an electrical switchyard, and, possibly, equipment associated with a natural gas pipeline, like a compressor station. The GEIS (NRC 1996) estimated that a 1,000 MWe gas-fired alternative would require 110 ac (40 ha), meaning this 830-MWe plant would require 92 ac (37 ha). Exelon Generation indicated that the plant would require 32 ac (13 ha), a number more consistent with minimum utility needs as demonstrated by nearby power plants (including Dominion Resources' Fairless Energy Works). We will adopt Exelon Generation's estimate for the purposes of the following analysis.

This 830 MWe power plant would consume 34.2 billion cubic feet (ft³) (970 million m³) of natural gas annually assuming an average heat content of 1,033 Btu/ft³ (EIA 2006). Natural gas would be extracted from the ground through wells, then treated to remove impurities (like hydrogen sulfide), and blended to meet pipeline gas standards, before being piped through the interstate

Alternatives

pipeline system to the power plant site. This gas-fired alternative would produce relatively little waste, primarily in the form of spent catalyts used for emissions controls.

Environmental impacts from the gas-fired alternative will be greatest during construction. Site crews will clear vegetation from the site, prepare the site surface, and begin excavation before other crews begin actual construction on the plant and any associated infrastructure, including a pipeline spur to serve the plant and electricity transmission infrastructure connecting the plant to existing transmission lines.

Constructing the gas-fired alternative on Exelon Generation property located immediately south of remaining TMI Unit 2 plant structures would allow the gas-fired alternative to make use of TMI-1's existing transmission system, as well as take advantage of an already cleared and graded section of Three Mile Island. During the environmental site audit, TMI-1 staff indicated that some of this land is occasionally used for parking during outages and could be used during TMI-1 and TMI Unit 2 decommissioning. Additional offsite land, land farther south on Three Mile Island, or remaining land around the new gas-fired plant may be available for occasional use to offset this land requirement.

A gas-fired unit constructed offsite may cause additional construction-related impacts depending on the nature of the site selected (e.g., a site that has never been developed will likely experience greater impacts than a site that was previously industrial; a site near other power plants or industrial facilities will likely experience smaller impacts than a site surrounded by farmland or relatively natural surroundings).

Table 8-2. Summary of Environmental Impacts of Natural Gas Combined-Cycle Generation Compared to Continued Operation of TMI-1.

	Natural Gas Combined-Cycle		Continued TMI-1 Operation
	At TMI-1 site	At alternate site	
Air Quality	MODERATE	MODERATE	SMALL
Ground Water	SMALL	SMALL	SMALL
Surface Water	SMALL	SMALL	SMALL
Aquatic and Terrestrial Resources	SMALL	SMALL TO LARGE	SMALL
Human Health	SMALL	SMALL	SMALL
Socioeconomics	SMALL TO MODERATE	SMALL TO MODERATE	SMALL
Waste Management	SMALL	SMALL	N/A

8.2.1 Air Quality

Dauphin County does not meet the National Ambient Air Quality Standards established by EPA under the CAA and is a nonattainment area for PM_{2.5}. A new gas-fired generating plant developed at the TMI-1 site would need to comply with the new source performance standards set forth in 40 CFR 60 Subpart D(a). The standards establish limits for particulate matter and opacity (40 CFR 60.42(a)), SO₂ (40 CFR 60.43(a)), and NO_x (40 CFR 60.44(a)).

A gas-fired power plant constructed elsewhere in Pennsylvania would need to comply with applicable provisions of the CAA, based on the attainment status of the selected alternate site. If a natural gas-fired plant were located close to a mandatory Class I area, additional air pollution control requirements could be imposed. Pennsylvania does not have any designated Class I wilderness areas, the closest being Brigantine, New Jersey. For an alternate site, consideration may need to be given to installation of additional air emission control systems if the plant could potentially affect visibility in any of the Class I areas.

Pennsylvania regulates air emissions from power plants pursuant to terms of the APCA, as discussed in Section 8.1.1. Regulations enforced by the PADEP adopt the EPA's CAA rules, with modifications, to limit power plant emissions of SO_x, NO_x, particulate matter, and hazardous air pollutants, among other matters (PADEP 2008). Depending where a new gas-fired facility is located within the State, that facility will need to comply with the applicable Federal and State air regulations.

NO_x is typically the pollutant of greatest concern for natural-gas-fired power plants. This gas-fired alternative relies on dry, low-NO_x burners, as well as selective catalytic reduction (SCR) to reduce NO_x emissions.

Pennsylvania and most other eastern states had been subject to requirements of 40 CFR 51.121(e), "Findings and requirements for submission of State implementation plan revisions relating to emissions of oxides of nitrogen," and the total amount of NO_x emissions allowed for the Pennsylvania State implementation plan was 257,928 t (233,988 MT) for the 2007 ozone season, and would have been subject to ozone-controlling elements of the Clean Air Interstate Rule (CAIR) had CAIR not been vacated by the D.C. Circuit Court in July of 2008. On September 24, 2008, EPA filed for a rehearing of the D.C. Circuit Court decisions. Until EPA, Congress, or the courts act, future NO_x regulatory approaches remain uncertain.

The NRC staff projects the following emissions for a gas-fired alternative based on data published by the EIA, on EPA emissions factors, and on performance characteristics for this alternative and its emissions controls:

- Sulfur dioxide – 60 tons per year (t/yr)
- Nitrogen oxides – 192 t/yr
- Carbon monoxide- 40 t/yr
- PM₁₀ – 33.5 t/yr

A natural gas-fired plant would also have unregulated CO₂ emissions and, in the case of this alternative to TMI-1, would emit approximately 1.99 million tons of CO₂ per year.

In December 2000, the EPA issued regulatory findings on emissions of hazardous air pollutants from electric utility steam-generating units (65 FR 32214). Natural gas-fired power plants were found by the EPA to emit arsenic, formaldehyde, and nickel. Unlike coal- and oil-fired plants, the EPA did not determine that emissions of hazardous air pollutants from natural gas-fired power plants should be regulated under Section 112 of the CAA.

Construction activities would also result in some air effects, including those from temporary fugitive dust, though construction crews would employ dust-control practices to limit this impact. Exhaust emissions would also come from vehicles and motorized equipment used during the

Alternatives

construction process, though these emissions are likely to be intermittent in nature and will occur over a limited period of time. As such, construction stage impacts would be SMALL.

The overall air-quality impacts of a new natural gas-fired combined cycle plant sited at TMI-1 or at an alternate site would be MODERATE.

8.2.2 Ground Water Use and Quality

The use of ground water for a natural gas combined cycle plant would likely be limited to supply wells for drinking water and possibly filtered service water for system cleaning purposes. The impact of ground water use would be SMALL. No effects on ground water quality would be apparent except during the construction phase when possible dewatering and run-off controls are used.

8.2.3 Surface Water Use and Quality

Consumptive use of surface water from the Susquehanna River, or from another body of water at an alternate site, would be much less for a gas-fired plant than the 18 mgd currently used on average by TMI-1. In addition, the discharge of waste water using this technology would be minimal. Impact on surface water resources at both the TMI-1 site and an alternate site would be SMALL.

8.2.4 Terrestrial and Aquatic Ecology

Terrestrial Ecology

As indicated in previous sections, constructing the natural gas alternative will require 32 ac (13 ha) of land. These land disturbances form the basis for impacts to terrestrial ecology. (Gas extraction and collection will also affect terrestrial ecology in offsite gas fields, although, as noted in Section 8.2.6, much of this land is likely already disturbed by gas extraction, and the incremental effects of this alternative on gas field terrestrial ecology are difficult to gauge.)

Impacts to terrestrial ecology will be minor because the selected site has been previously disturbed and is located on the southern end of the island. There is potential for disturbance of some areas with trees or manmade wetlands, and possible habitat fragmentation would occur. Construction of transmission line ROWs, a lengthy pipeline, or additional roads on undisturbed or less-disturbed areas could adversely impact terrestrial ecology by fragmenting or destroying habitats. However, a pipelined fuel source and a small workforce would help to minimize the need for additional transportation infrastructure.

In addition, construction onsite may eliminate onsite habitats and alter the site for a long period of time. Some areas onsite, such as any buffer areas, may remain undeveloped and could still harbor habitat for terrestrial species, though site lighting, noise, and activities may degrade the value of any remaining ecosystems. Deposition of air pollutants from this alternative may affect terrestrial ecology, but it is unlikely to be noticeable. Impacts to terrestrial resources from a natural gas combined-cycle alternative at both the TMI-1 site and an alternate site would like be SMALL.

Aquatic Ecology

Aquatic ecology actually benefits from the onsite, gas-fired alternative, as the combined-cycle plant rejects significantly less heat to the environment than the existing TMI-1, thus requiring less water. A gas-fired alternative would require less than half as much water as the existing plant due to its much higher thermal efficiency. As the onsite gas-fired alternative would continue to use the existing cooling system, impacts to aquatic ecology would also be minimal. Aquatic impacts at an alternate site depend on location and ecology of the site, and the surface water body used for intake and discharge. These impacts are likely smaller at urban or previously industrial sites, owing to generally closer access to pipelines and transmission lines than at undeveloped sites. Overall, the ecological impacts are considered SMALL at the TMI-1 site and could range from SMALL to LARGE at a different location, depending on the sensitivity of local aquatic communities.

8.2.5 Human Health

Like the coal-fired alternative discussed above, a gas-fired plant would emit criteria air pollutants, but generally in smaller quantities (except NO_x, which requires additional controls to reduce emissions). Human health risks of a gas-fired alternative are generally low, although in Table 8-2 of the GEIS (NRC 1996), the NRC staff identified cancer and emphysema as potential health risks from a gas-fired alternative. However, the current Federal and State regulatory frameworks, pertaining to air emission standards, allow for the adequate protection of occupational workers and members of the public. Therefore, the NRC staff has adopted (where applicable) the Federal and State air quality regulatory limits as significant thresholds for determining the human health risks associated with the operation of a new gas-fired power plant.

NO_x emissions contribute to ozone formation, which in turn contribute to human health risks. Emission controls on this gas-fired alternative maintain NO_x emissions well below air quality standards established for the purposes of protecting human health, and emissions trading or offset requirements mean that overall NO_x in the region would not increase. Health risks to workers may also result from handling spent catalysts that may contain heavy metals. Overall, human health risks to occupational workers and to members of the public from gas-fired power plant emissions sited at TMI-1 or at an alternate site would be similar to the risks described for coal-fired alternative and therefore, would likely be SMALL.

8.2.6 Socioeconomics

Land Use

As discussed in Section 8.1, the GEIS generically evaluates the impacts of nuclear power plant operations on land use both on and off each power plant site. The analysis of land use impacts focuses on the amount of land area that would be affected by the construction and operation of a natural gas-fired combined-cycle generation power plant at the TMI-1 site and at an alternate site. Land-use impacts would vary depending on where the plant would be located and whether construction would take place on undeveloped land or within a previously disturbed (brownfield) area.

Alternatives

Exelon Generation indicated that approximately 32 ac (13 ha) would be necessary to support a natural gas-fired alternative capable of replacing TMI-1. The GEIS, however, estimates 110 ac (45 ha) for a 1000-MWe generating station (NRC 1996). This amount of land use would include other plant structures and associated infrastructure. By scaling the GEIS estimate, an 853-MWe plant could require up to 92 ac (37 ha) of land. This amount of land will encompass the plant site at both TMI-1 and an alternate site, and transmission line ROWs at an alternate site. The NRC staff believes that the Exelon Generation estimate is reasonable. However, if additional land would be necessary for a buffer around plant structures or to support transmission lines at an alternate site and gas pipelines at both TMI-1 and at an alternate site, the NRC staff believes the GEIS estimate for land use provides a more useful approximation. Nevertheless, land use impacts from construction would be SMALL, and could be further reduced if the power plant is collocated with another generating station or on a previously industrial site like TMI-1. Impacts could be further mitigated at an alternate site by constructing new transmission lines in existing ROWs.

In addition to onsite land requirements, land will be required off site for natural gas wells and collection stations. The GEIS estimates that 3,600 ac (1,457 ha) would be required for wells, collection stations, and pipelines to bring the gas to a 1,000-MWe generating facility. If this land requirement were scaled directly with generating capacity, an alternative to TMI-1 could require up to 3,000 ac (1,200 ha) (though actual requirements will vary significantly). Most of this land requirement would occur on land where gas extraction already occurs. In addition, some natural gas that could be used by the new power plant may come from outside of the United States and would be delivered as liquefied gas. Effects from gas extraction are generally smaller than those for coal mining, as most land around a gas extraction site remains undisturbed, except for roads and collection pipe network. Site reclamation after natural gas extraction would be less involved than land previously used for coal mining.

The elimination of uranium fuel for TMI-1 could partially offset off site land requirements. In the GEIS, the NRC staff estimated that approximately 1,000 ac (405 ha) would not be needed for mining and processing uranium during the operating life of a 1,000-MWe nuclear power plant. For TMI-1, roughly 850 ac (344 ha) of uranium mining area would no longer be needed. Overall land use impacts from a gas-fired power plant would be SMALL to MODERATE, depending on local land use and the availability of land near the proposed site.

Socioeconomics

As discussed in Section 8.1, socioeconomic impacts are defined as changes to the demographic and economic characteristics and social conditions of a region. For example, the number of jobs created by the construction and operation of a new natural gas-fired power could affect regional employment, income, and expenditures. Job creation is characterized by two types: (1) construction-related jobs, which are transient, short in duration, and less likely to have long-term socioeconomic impacts; and (2) operation-related jobs in support of power plant operations, which have the greater potential for permanent, long-term socioeconomic impacts. Workforce requirements of power plant construction and operations for the gas-fired alternative were determined in order to measure their possible effect on current socioeconomic conditions.

The socioeconomic impacts from constructing and operating a gas-fired plant would have little noticeable effect. Compared to the coal-fired alternative, the small size of the construction and operations workforce would have little or no socioeconomic impact.

Exelon Generation indicated that a 483-member workforce would be required to construct the gas-fired alternative (AmerGen 2008). After construction, local communities may be temporarily affected by the loss of construction jobs and associated loss in demand for business services, and the rental housing market could experience increased vacancies and decreased prices. The impact of construction on socioeconomic conditions could range from SMALL to MODERATE depending on whether or not the new power plant would be located at TMI-1 or an alternate site. The socioeconomic impacts of power plant construction could be reduced if the power plant is located near an urban area with a large pool of skilled workers.

Following construction, a gas-fired alternative could provide up to 27 jobs, based on Exelon Generation estimates, or up to 125 jobs based on an extrapolated estimate from the GEIS. Depending on location, the small number of workers would not have a noticeable effect on socioeconomic conditions in the region. Therefore, socioeconomic impacts associated with operation of a gas-fired power plant would be SMALL.

Transportation

Transportation impacts associated with construction and operation of a two unit power plant under the gas-fired alternative would consist of commuting workers and truck deliveries of construction materials to the TMI-1 worksite. Transportation effects would vary depending on the characteristics of site access roads. In addition to commuting workers, trucks would deliver construction materials to the worksite. These vehicles would increase the overall number of vehicles on local roads. Pipeline construction and modification to existing natural gas pipeline systems may also have a short-term impact.

Conversely, transportation impacts would almost disappear during plant operations. The estimated number of operating personnel would be approximately 27 workers, although the GEIS indicates that as many as 125 operations workers could be required. Since fuel is transported by pipeline, most transportation infrastructure will experience little increased use from plant operations.

Since fuel would be transported by pipeline, the transportation infrastructure would experience little to no increased use from plant operations. Overall, the gas-fired alternative would have a SMALL impact on transportation conditions in the region around TMI-1. Transportation impacts may vary at an alternate site and would depend on roadway capacity and average daily volume.

Aesthetics

As discussed in Section 8.1, aesthetic resources are the natural and man-made features that give a particular landscape its character and aesthetic quality. The aesthetics impact analysis focuses on the degree of contrast between the power plant and the surrounding landscape and the visibility of the power plant.

The two gas-fired units could be approximately 100 ft (30 meters [m]) tall, with two exhaust stacks at least 175 ft (53 m) tall or taller depending on the topography at an alternate site. Some structures may require aircraft warning lights. If the plant is located near the existing TMI-1, impacts may be moderated as higher elevations and vegetation along the river valley could

Alternatives

make it difficult to see or hear the plant outside of the river valley. Power plant infrastructure would generally be smaller and less noticeable than TMI-1 containment and cooling tower. The mechanical draft cooling towers would be markedly shorter than the natural-draft towers located at TMI-1, but they would also generate condensate plumes and operational noise. Noise during power plant operations would be limited to industrial processes and communications.

In addition to seeing new power plant structures, the alternate plant site may require the construction of transmission lines and natural gas pipelines. The transmission lines would have a lasting visual effect on the landscape.

Noise from plant operations would be primarily limited to industrial processes and communications. Unlike the coal-fired alternative, pipelines would deliver natural gas fuel, thus eliminating the noises from fuel and waste handling and associated transportation equipment. Noise from the pipelines could be audible off site near compressors.

In general, aesthetic changes would be limited to the immediate vicinity of TMI-1 or an alternate site. Impacts would likely to be SMALL to MODERATE, depending on the amount of new transmission line required.

Historic and Archaeological Resources

The potential for historic and archaeological resources can vary greatly depending on the location of the proposed site. To consider a project's effects on historic and archaeological resources, any proposed areas will need to be surveyed to identify and record historic and archeological resources, identify cultural resources, and develop possible mitigation measures to address any adverse effects from ground disturbing activities. Studies will be needed for all areas of potential disturbance at the proposed plant site and along associated corridors where new construction will occur (e.g., roads, transmission corridors, rail lines, or other ROWs). In most cases, project proponents should avoid areas with the greatest sensitivity.

Depending on the resource richness of the site ultimately chosen for the gas-fired alternative, impacts will range from SMALL to MODERATE.

Environmental Justice

The environmental justice impact analysis evaluates the potential for disproportionately high and adverse human health and environmental effects on minority and low-income populations that could result from the construction and operation of a new natural gas-fired combined-cycle generation power plant. Adverse health effects are measured in terms of the risk and rate of fatal or nonfatal adverse impacts on human health. Disproportionately high and adverse human health effects occur when the risk or rate of exposure to an environmental hazard for a minority or low-income population is significant and exceeds the risk or exposure rate for the general population or for another appropriate comparison group. The minority and low-income populations are subsets of the general public residing around the site, and all are exposed to the same hazards generated from various power plant operations.

Minority and low-income populations could be disproportionately affected by the construction and operation of a new natural gas-fired power plant. Some of these effects have been identified in resource areas discussed in this section. For example, increased demand for rental housing during construction could disproportionately affect low-income populations. However, demand for rental housing could be mitigated if the alternate plant site is constructed near a

metropolitan area. Environmental justice impacts from the construction and operation of a gas-fired alternative could range from SMALL to MODERATE and would depend on whether effects from the plant on minority and low-income populations are adverse and disproportionate.

8.2.7 Waste Management

Minor quantities of waste are generated during burning of natural gas compared to other alternatives, however use of SCR to control NO_x will generate spent SCR catalysts and small amounts of solid waste products.

It is concluded in the GEIS by the NRC staff that gas-fired technology waste generation would be minimal (NRC 1996) and the waste impacts would be SMALL for a natural gas-fired combined-cycle plant sited at TMI-1 or at alternate site.

8.3 Energy Conservation/Energy Efficiency

In this section, the NRC staff evaluates the environmental impacts of a demand-side energy conservation or energy efficiency alternative. On the following page Table 8-3 summarizes the environmental impacts of energy conservation and energy efficiency compared to continued operation of TMI-1.

Though often used interchangeably, energy conservation and energy efficiency are different concepts. Energy efficiency typically means deriving a similar level of services by using less energy, while energy conservation simply indicates a reduction in energy consumption. Both fall into a larger category known as demand-side management (DSM). DSM measures—unlike the energy supply alternatives discussed in previous sections—address energy end uses. DSM can include measures that shift energy consumption to different times of day to reduce peak loads, measures that interrupt certain large customers during periods of high demand or measures that interrupt certain appliances during high demand periods, and measures like replacing older, less efficient appliances, lighting, or control systems. DSM also includes measures that utilities use to boost sales, such as encouraging customers to switch from gas to electricity for water heating.

Unlike other alternatives to license renewal, the GEIS notes that conservation is not a discrete power generating source; it represents an option that states and utilities may use to reduce their need for power generation capability (NRC 1996). In addition, conservation represents a possible option in case of the no-action alternative. The GEIS “assumes that conservation technologies produce enough energy savings to permit the closing of a nuclear plant.”

Prior to the implementation of Pennsylvania’s Alternative Energy Portfolio Standard (AEPS), several Pennsylvania foundations sponsored a study by engineering firm Black and Veatch to document the potential effects renewable energy, conservation/efficiency, and unconventional power sources like waste coal (Pietka 2004). The study distinguished between energy efficiency and conservation, and defined conservation as demand-side measures, and efficiency as supply-side measure like repowering or other power plant, transmission, or distribution improvements. Because Black and Veatch’s defined energy efficiency as only supply-side options, and because Black and Veatch defined conservation as including all demand-side measures to reduce electricity consumption, we will only use Black and Veatch’s conservation

Alternatives

estimates in the following section. Black and Veatch's analysis indicated 18,206 gigawatt-hours (GWh) of conservation could be achieved within 10-15 years of the study's 2004 publication date (Pletka 2004), or roughly three times the amount of electricity produced by TMI-1 in a given year. The total magnitude of these savings could be as large as 6872 MW, or more than eight times TMI-1's power output. Overall, Black and Veatch indicated that Pennsylvania had "good" conservation resources.

Since the study, PJM⁹ has instituted new measures to capture energy efficiency potential, and energy efficiency measures which now count for inclusion in the AEPS. The NRC had difficulty determining how much of the potential identified in the 2004 report remains available in Pennsylvania, though it appears unlikely that all or even most of this potential would already have been exploited. Beyond near-term potential, Black and Veatch's analysis identified an additional 70,000 GWh or 28,824 MW of conservation potential, some of which may be available at higher costs or on longer time horizons. Also, because TMI-1 sells power into the PJM interconnection, conservation in other nearby states may also help to offset power produced by TMI-1, even though sufficient capacity appears to exist in Pennsylvania alone. Therefore, the NRC staff chose to evaluate conservation as an alternative to license renewal.

A conservation alternative will produce different impacts than the other alternatives addressed. Unlike the discrete generation options, there is no major construction and few ongoing operational impacts. The most significant effects occur during installation or implementation or conservation measures, when old appliances may be disposed of, buildings may be retrofitted, or control devices may be installed. In some cases, increases in efficiency may come from better management of existing control systems. Many of these items may be recycled, though volumes of landfilled trash may still increase.

The GEIS generally indicates that impacts from a conservation alternative are small and that some postulated effects (like increases in mercury, polychlorinated biphenyls (PCBs), or chlorofluorocarbon (CFC) releases as fluorescent bulbs, old transformers or old refrigerators are replaced) may prove not to be significant as effective disposal methods can prevent health effects, and as more environmentally-benign alternatives have emerged (NRC 1996).

Table 8-3. Summary of Environmental Impacts of Energy Conservation/Energy Efficiency Compared to Continued Operation of TMI-1.

	Energy Conservation/Energy Efficiency	Continued TMI-1 Operation
Air Quality	SMALL	SMALL
Ground Water	SMALL	SMALL
Surface Water	SMALL	SMALL
Aquatic and Terrestrial Resources	SMALL	SMALL
Human Health	SMALL	SMALL
Socioeconomics	SMALL	SMALL
Waste Management	SMALL	N/A

⁹ PJM Interconnection is a regional transmission organization (RTO) that coordinates the movement of wholesale electricity in all or parts of 13 states and the District of Columbia, including Pennsylvania.

8.3.1 Air Quality

Implementation of the energy conservation alternative reduces direct fuel use and reduces environmental emissions resulting from plant fuel cycles, workers' commuting, and plant operation and maintenance. Improvements in efficiency may also reduce consumption of fuels used for space or water heating at the same time they reduce electrical consumption.

As noted above, no major construction would be required and few ongoing operational impacts would be experienced during implementation of the conservation alternative. The conservation alternative would likely cause only minor and short-duration air quality impacts—use of best management practices would minimize air quality impacts during installation of new appliances or systems. Implementation of energy conservation measures would improve efficiency of boilers and heating units and would help to reduce already low air emissions.

The overall impacts on air quality of the energy conservation and/or energy efficiency alternative would be SMALL.

8.3.2 Ground Water Use and Quality

The conservation alternative would not require any groundwater. It is possible that wastes produced during installation of improved equipment could have an effect on groundwater if leachate from landfills infiltrate groundwater, but this effect is not likely to be noticeably altered by a small increase in overall waste production, if any, associated with the conservation alternative. Overall impacts to groundwater are SMALL.

8.3.3 Surface Water Use and Quality

The impacts on surface water use and quality because of energy conservation efforts would be SMALL, but positive. The consumptive use of water from the Susquehanna River would certainly decrease as would the discharge of waste water streams.

8.3.4 Terrestrial and Aquatic Ecology

Terrestrial Ecology

Terrestrial ecology impacts would be SMALL. No additional land disturbances on or offsite would be required.

Aquatic Ecology

Impacts to aquatic resources would be SMALL, but positive, as withdrawals from and discharges to the Susquehanna River would cease, since the no-power generation alternative would take the place of TMI-1. If more energy is conserved than is produced by TMI-1, then positive impacts to aquatic resources could extend beyond the Susquehanna River to other water bodies. This net conservation of energy could result in less demand for power production at other plants and could lead to lower rates of water withdrawal and discharge at these power plants. The implementation of conservation measures, such as the increased use of mercury-containing compact fluorescent light bulbs and their impact to the environment after landfill

Alternatives

disposal, would result in SMALL impacts to the aquatic environment. While increased mercury levels in landfills could leach into adjacent waterways, State and local landfill regulations could reduce or eliminate such pollution.

8.3.5 Human Health

Energy demand reduction measures are specific procedures or technologies that are undertaken to reduce energy demands. Human health risks of the energy conservation alternative are minimal, although in Table 8-2 of the GEIS (NRC 1996) the NRC staff identified radon as the major potential health risk from the energy conservation alternative. Currently, there are no Federal or State regulatory frameworks pertaining to radon exposure standard, therefore, the NRC staff has chosen the EPA recommendation level of 4 picocuries per Liter (pCi/L) as a significant threshold for determining the human health risks associated with the energy conservation alternative.

Radon-222 is a naturally occurring radioactive noble gas that is formed from the decay of radium-226. Radiation exposure from radon-222 is indirect. Radon has a short half-life (4 days) and decays into other solid particulate radioactive nuclides that give off high energy alpha particles. These radioactive particles are inhaled and remain lodged in the lungs, causing continued exposure. People in affected localities can receive up to 10 mSv per year background radiation of radon-222. Radon-222 is thus the second leading cause of lung cancer after smoking, and accounts for 15,000 to 22,000 cancer deaths per year in the U.S. alone (Darby 1989). The general population is exposed to small amounts of polonium as a radon-daughter in indoor air; the isotopes polonium-214 and polonium-218 are thought to cause the majority of the estimated lung cancer deaths from radon (Darby 1989). A Bonneville Power Administration radon-222 exposure study found that radon-222 was a serious concern in new home construction if mitigation measures were not implemented. Cancer cases from radon-222 exposures were estimated to be 335 per 100,000 for baseline homes but as high as 767 cases per 100,000 for new homes with advanced infiltration control but no exhaust or mechanical ventilation (Pace 1991).

EPA recommends homes be fixed if the radon level is 4 pCi/L or more. Because there is no known safe level of exposure to radon, EPA also recommends that Americans consider fixing their homes for radon levels between 2 pCi/L and 4 pCi/L. The average radon concentration in the indoor air of America's homes is about 1.3 pCi/L. The average concentration of radon in outdoor air is 0.4 pCi/L, about 1/10th of EPA's 4 pCi/L action level (EPA 2008b). Given that a member of the public has taken appropriate mitigative actions—such as installing a more efficient ventilation system for radon removal, sealing cracks in basements, etc.—to achieve an indoor radon concentration below 2 pCi/L, the human health risks to members of the public from the energy conservation alternative would be within the range of the national average and would likely be SMALL.

8.3.6 Socioeconomics

Land Use

Since Exelon Generation would continue to use the existing transmission lines land use impacts of an energy efficiency alternative would be SMALL. Quickly replacing and disposing of old inefficient appliances could generate waste material and potentially increase the size of landfills. However, given the 10 to 15-year timeline for program development and implementation, the cost of replacements, and the average life of an appliance; the replacement process would probably be more gradual. Older appliances would simply be replaced by more efficient appliances as they fail (especially in the case of frequently replaced items, like lightbulbs). In addition, many items (like home appliances or industrial equipment) have substantial recycling value and would likely not be disposed of in landfills.

Socioeconomics

Socioeconomic effects of an energy efficiency program would be SMALL. As noted in the GEIS, the program would likely employ additional workers. Lower-income families could benefit from weatherization and insulation programs. This effect would be greater than the effect for the general population because low-income households experience home energy burdens more than four times larger than the average household (OMB 2007).

Transportation

Transportation impacts would be SMALL, because fewer employees would commute to TMI-1. Any transportation effects from the energy efficiency alternative would be widely distributed across the State, and would not be noticeable.

Aesthetics

Impacts from energy efficiency programs would be SMALL because TMI-1 would be decommissioned with no alternative power plant to replace it. The transmission lines would remain after plant decommissioning. Traffic to the plant would decrease, however, as would noise and emissions. Some noise impacts could occur in instances of energy efficiency upgrades to major building systems, though this impact would be intermittent and short-lived.

Historic and Archaeological Resources

Impacts from the energy conservation/energy efficiency alternative would be SMALL, since TMI-1 would be decommissioned with no alternative power plant to replace it. A separate environmental review would be conducted for decommissioning. That assessment will address the protection of historic and archaeological resources.

Environmental Justice

Weatherization programs could target low-income residents as a cost-effective energy efficiency option since low-income populations tend to spend a larger proportion of their incomes paying utility bills (according to the Office of Management and Budget, low income populations experience energy burdens more than four times as large as those of average households [OMB 2007]). Impacts to minority and low-income populations from energy efficiency programs would be SMALL, depending on program design and enrollment. The impacts from these programs may be disproportionate, but are not likely to be adverse.

Alternatives

8.3.7 Waste Management

The most significant effects occur during installation or implementation or conservation measures, when old appliances may be disposed of, buildings may be retrofitted, or control devices may be installed. Implementation of the recycling programs would help to decrease volumes of the generated waste, though volumes of the trash sent to the landfills may still increase.

According to the GEIS, impacts from a conservation alternative are minimal, and some postulated effects (like increases in mercury, PCBs, or CFC releases as fluorescent bulbs, old transformers or old refrigerators are replaced) may prove to be insignificant as more environmentally-benign alternatives have emerged, and if proper disposal methods are employed (NRC 1996).

Overall, the waste impacts would be SMALL for the energy conservation and/or energy efficiency alternative.

8.4 Combination Alternative

In this section, we evaluate the environmental impacts of a combination of alternatives. This combination will include a portion of the energy efficiency/conservation potential identified in Section 8.3, a portion of the combined-cycle gas-fired capacity identified in Section 8.2, and a series of uprates to existing hydroelectric dams. This alternative requires little new construction (only for the single gas-fired unit installed at the TMI-1 site and minor renovation at uprated dams). We acknowledge that we could also include some amount of wind power in this alternative as a companion to the hydropower uprates, though the NRC elected not to do so since constructing wind power facilities would likely increase the environmental impact of the combination alternative without a commensurate decrease in operating impacts from other portions of the combination alternative. Table 8-4 on the following page contains a summary of the environmental impacts of the combination alternative compared to continued operation of TMI-1.

In this alternative, slightly more than half of TMI-1's output (approximately 420 MW) would be replaced by conservation. Power uprates at existing hydroelectric dams will account for roughly 100 MWe of capacity (as identified in INEEL 1997) and 280 MWe will come from one GE S107FB combined cycle power plant. The only major construction we anticipate will happen at the current TMI-1 site where the combined-cycle gas-fired power plant would be constructed. No major construction should be necessary for the conservation portion, and relatively minor construction would occur at existing dams for purposes of power uprates.

The appearance of the single-unit gas-fired facility would be similar to that of the two-unit gas-fired alternative considered in Section 8.2, except smaller. We estimate that the single-unit gas-fired facility would require approximately 35 percent of the space necessary for the two-unit gas-fired facility considered in Section 8.2, and that all construction effects—as well as operational aesthetic, fuel-cycle, air quality, socioeconomic, land use, environmental justice, and water

consumption effects—will scale accordingly.¹⁰ Since the gas-fired portion of this alternative uses roughly a third of the available land south of TMI Unit 2 on Three Mile Island, Exelon Generation may still be able to use most of the available space for outage personnel and eventual decommissioning activities of TMI-1.

Table 8-4. Summary of Environmental Impacts of the Combination Alternative Compared to Continued Operation of TMI-1.

	Combination Alternative		Continued TMI-1 Operation
	At TMI-1 Site	At Alternate Site	
Air Quality	SMALL to MODERATE	MODERATE	SMALL
Ground Water	SMALL	SMALL	SMALL
Surface Water	SMALL	SMALL	SMALL
Aquatic and Terrestrial Resources	SMALL	SMALL	SMALL
Human Health	SMALL	SMALL	SMALL
Socioeconomics	SMALL to MODERATE	SMALL TO MODERATE	SMALL
Waste Management	SMALL	SMALL	N/A

8.4.1 Air Quality

As noted in Section 8.2.1, Dauphin County does not meet the National Ambient Air Quality Standards established by EPA under the CAA and is in a nonattainment area for PM_{2.5}. A new gas-fired generating plant developed at the TMI-1 site would need to comply with the new source performance standards set forth in 40 CFR 60 Subparts D(a). The standards establish limits for particulate matter and opacity, SO₂, and NO_x.

Pennsylvania and most other eastern states had been subject to requirements of 40 CFR 51.121(e), "Findings and requirements for submission of State implementation plan revisions relating to emissions of oxides of nitrogen," and the total amount of NO_x emissions allowed for the Pennsylvania State implementation plan was 257,928 t (233,988 MT) for the 2007 ozone season, and would have been subject to ozone-controlling elements of the Clean Air Interstate Rule (CAIR) had CAIR not been vacated by the D.C. Circuit Court in July of this year. On September 24, 2008, EPA filed for a rehearing of the D.C. Circuit Court decision. Until EPA, Congress, or the courts act, future NO_x regulatory approaches remain uncertain.

As noted in 8.2.1, NO_x is typically the pollutant of greatest concern for natural-gas-fired power plants. Like the plant in 8.2.1, this gas-fired portion of this alternative relies on dry, low-NO_x burners, as well as selective catalytic reduction (SCR) to reduce NO_x emissions.

For the combination alternative only one gas-fired unit would be built. Emissions of SO_x, NO_x, mercury, and particulate matter would be approximately 37 percent of those detailed in Section

¹⁰ The S107FB unit considered here is slightly less efficient than the S207H units considered in Section 8.2 (heat rate of 5950 btu/kWh for the S107FB versus 5690 btu/kWh for the S207H; GE 2007). We've calculated air quality impacts in the following sections accordingly.

Alternatives

8.2.1. A natural gas-fired plant would also have unregulated CO₂ emissions; a single-unit gas-fired facility would emit approximately 728,000 t (660,000 MT) of CO₂ per year.

As noted in 8.2.1, EPA has determined that natural gas-fired power plants emit arsenic, formaldehyde, and nickel. Unlike coal and oil-fired plants, EPA did not determine that emissions of hazardous air pollutants from natural gas-fired power plants should be regulated under Section 112 of the CAA.

Construction activities for the gas-fired unit as well as retrofits at existing dams would also result in some air effects, including those from temporary fugitive dust, though construction crews would employ dust-control practices to limit this impact. Exhaust emissions would also come from vehicles and motorized equipment used during the construction process, though these emissions are likely to be intermittent in nature and would occur over a limited period of time. Construction stage impacts would, therefore, be SMALL.

The overall air-quality impacts of the combination alternative—based largely on the impacts from a new, single-unit, natural gas-fired combined cycle plant sited at TMI-1—would be SMALL to MODERATE.

8.4.2 Ground Water Use and Quality

If the onsite gas-fired plant continued to use ground water for drinking water and service water, the total usage would likely be much less than TMI-1 uses, because many fewer workers are onsite, and because the gas-fired unit would have fewer auxiliary systems requiring service water. The current permitted withdrawal rate is 225,000 gpd, and pumping tests indicate this rate would not cause an effect on nearby supply wells. A reduction in this withdrawal rate means that impacts of the combination alternative would remain SMALL.

8.4.3 Surface Water Use and Quality

Using a combined alternative with conservation as a major component will reduce the amount of surface water consumed for cooling purposes. The maximum consumptive use would be reduced to a fraction of the 18 mgd used by the current nuclear plant. This represents less than 0.1 percent of the average annual flow rate in the river. The impact of this withdrawal would be SMALL.

8.4.4 Terrestrial and Aquatic Ecology

Terrestrial Ecology

Impacts to terrestrial ecology would be SMALL. ROW maintenance would continue, although no additional transmission lines would be necessary. The only construction activities that would occur for the combination alternative are the construction of a combined-cycle gas-fired power plant and any retrofit-related construction (largely internal) at existing dams. These activities would be confined to previously disturbed areas at the TMI-1 site, and would be relatively limited at dam sites. Some habitat fragmentation impacts on the southern part of the island may occur.

Aquatic Ecology

Aquatic ecology would actually benefit from the combination efficiency/conservation, hydroelectric power plant uprates, and gas-fired power plant alternative, as the combined-cycle plant would reject significantly less heat to the environment than the existing TMI-1, thus requiring less water. Impacts to aquatic resources would be SMALL, but positive, as withdrawals from and discharges to the Susquehanna River would be significantly less. Energy conservation and efficiency would likewise result in less withdrawals and discharges corresponding to a decreased demand for power generation as discussed in Section 8.3. Uprates to hydroelectric power plants to compensate for loss of power generation at TMI-1 could lead to slight increases in entrainment and impingement impacts at these hydroelectric plants, but these impacts would be regulated and likely SMALL.

8.4.5 Human Health

The human health risks of a combination of alternatives include those that have already been discussed in their respective sections (i.e. energy conservation and combined cycle gas-fired alternatives). The human health risks are uncertain, but considered to be SMALL given the combination of alternatives must comply with health-based Federal and State emission standards.

8.4.6 Socioeconomics

Land Use

As discussed in Section 8.1, the GEIS generically evaluates the impacts of nuclear power plant operations on land use both on and off each power plant site. The analysis of land use impacts focuses on the amount of land area that would be affected by the construction and operation of a single natural gas-fired unit power plant at the TMI-1 site and minor renovation of dams.

Approximately 11 ac (5 ha) would be necessary to support a single natural gas-fired unit combination alternative based on Exelon Generation estimates for a discrete gas-powered alternative. By scaling the GEIS estimate, a 280 MWe plant could require up to approximately 32 ac (13 ha) of land and would encompass available space at the TMI-1 site. The NRC staff believes that the Exelon Generation estimate is reasonable. However, if additional land were necessary for a buffer around plant structures and the construction of gas pipelines at TMI-1, the NRC staff believes the GEIS estimate provides a more useful approximation. Nevertheless, land use impacts from construction would be SMALL.

In addition to onsite land requirements, land will be required offsite for natural gas wells and collection stations. The GEIS estimates that 3,600 ac (1,457 ha) would be required for wells, collection stations, and pipelines to bring the gas to a 1000-MWe generating facility. If this land requirement were scaled directly with generating capacity, the combination alternative could require up to 1,025 ac (425 ha), though actual requirements will vary significantly. As previously discussed in Section 8.2, most of this land requirement would occur on land where gas extraction already occurs. In addition, some natural gas that could be used by the new power plant may come from outside of the U.S. and would be delivered as liquefied gas. Effects from gas extraction are generally smaller than those for coal mining, as most land around a gas

Alternatives

extraction site remains undisturbed, except for roads and collection pipe network. Site reclamation after natural gas extraction would be less involved than reclamation of land previously used for coal mining.

As previously discussed, the elimination of uranium fuel for TMI-1 could partially offset offsite land requirements. In the GEIS, the NRC staff estimated that approximately 1,000 ac (405 ha) would no longer be needed for mining and processing uranium during the operating life of a 1000-MWe nuclear power plant. For TMI-1, roughly 850 ac (344 ha) of uranium mining area would no longer be needed. Overall land use impacts from a single natural-gas-fired power plant unit under the combination alternative would be SMALL.

Socioeconomics

As discussed in Section 8.1, socioeconomic impacts are defined in terms of changes to the demographic and economic characteristics and social conditions of a region. For example, the number of jobs created by the construction and operation of a new single natural gas-fired power plant unit could affect regional employment, income, and expenditures. Job creation is characterized by two types: (1) construction-related jobs, which are transient, short in duration, and less likely to have long-term socioeconomic impacts; and (2) operation-related jobs in support of power plant operations, which have the greater potential for permanent, long-term socioeconomic impacts. Workforce requirements for power plant construction and operations for the combination alternative were determined in order to measure their possible effect on current socioeconomic conditions.

The socioeconomic impacts from constructing and operating a single unit natural-gas-fired plant and minor renovation of dams would have little noticeable effect. Compared to the coal-fired alternative, the small size of the construction and operations workforce would have little or no socioeconomic impact.

Exelon Generation indicated that a peak construction workforce of 169 workers would be required to construct this alternative (AmerGen 2008). After construction, local communities may be temporarily affected by the loss of the construction jobs and associated loss in demand for business services, and the rental housing market could experience increased vacancies and decreased prices. The impact of construction on socioeconomic conditions would be SMALL.

Following construction, a single unit gas-fired combination alternative could provide up to nine jobs, based on Exelon Generation estimates, or up to 44 jobs based on an extrapolated estimate from the GEIS. Socioeconomic impacts associated with the operation of a single unit natural-gas-fired power plant would be SMALL.

Transportation

Transportation impacts associated with construction and operation of a single unit gas-fired power plant under the combination alternative would consist of commuting workers and truck deliveries of construction materials to the TMI-1 worksite. These vehicles would increase the overall number of vehicles on local roads. Pipeline construction and modification to existing natural gas pipeline systems may also have an additional, short-term impact.

Conversely, transportation impacts would almost disappear during plant operations. The estimated number of operating personnel would be approximately nine workers, although, the GEIS indicates that as many as 44 operations workers could be required. Since fuel would be

transported by pipeline, the transportation infrastructure would experience little to no increased use from plant operations. Overall, the combination alternative would have a SMALL impact on transportation conditions in the region around TMI-1.

Aesthetics

As discussed in Section 8.1, aesthetic resources are the natural and man-made features that give a particular landscape its character and aesthetic quality. The aesthetics impact analysis focuses on the degree of contrast between the power plant and the surrounding landscape and the visibility of the power plant.

A single natural gas-fired unit located at TMI-1 could be approximately 100 ft (30 m) tall, with an exhaust stack of at least 175 ft (53 m) tall. The impact would be moderated as higher elevations and vegetation along the river valley could make it difficult to see or hear the power plant outside of the river valley. The alternative power plant infrastructure would generally be smaller and less noticeable than the current TMI-1 containment and cooling tower. The mechanical draft cooling towers would be markedly shorter than the natural-draft towers located at TMI-1, but they would also generate condensate plumes and operational noise. Noise during power plant operations would be limited to industrial processes and communications.

In addition to the power plant structures, construction of natural gas pipelines would have a short-term impact. Noise from the pipelines could be audible offsite near compressors.

In general, aesthetic changes would be limited to the immediate vicinity of TMI-1; therefore aesthetic impacts would be SMALL.

Historic and Archaeological Resources

As discussed in Section 8.2.6, depending on the resource richness of the site ultimately chosen for the gas-fired single unit as part of the combination alternative, impacts will range from SMALL to MODERATE.

Environmental Justice

The environmental justice impact analysis evaluates the potential for disproportionately high and adverse human health and environmental effects on minority and low-income populations that could result from the construction and operation of a single unit natural gas-fired power plant and uprates to existing hydroelectric dams. Adverse health effects are measured in terms of the risk and rate of fatal or nonfatal adverse impacts on human health. Disproportionately high and adverse human health effects occur when the risk or rate of exposure to an environmental hazard for a minority or low-income population is significant and exceeds the risk or exposure rate for the general population or for another appropriate comparison group. The minority and low-income populations are subsets of the general public residing around the site, all of whom are exposed to the same hazards generated from power plant operations.

Minority and low-income populations could be affected by the construction and operation of a new single unit natural gas-fired combined-cycle generation power plant at TMI-1. Some of these effects have been identified in resource areas discussed in this section. Effects on minority and low-income populations in the vicinity of TMI-1 would vary from construction to operations. Increased localized rental housing demand during construction in some locations could disproportionately affect low-income populations. Overall though, the impacts on minority and low-income populations from the combination alternative would likely be SMALL, as the

Alternatives

NRC staff finds that the potential for adverse impacts is smaller than for the gas-fired alternative, and any disproportionate impacts from implementing conservation are unlikely to be adverse.

8.4.7 Waste Management

As discussed in Sections 8.2.7 and 8.3.7, NRC staff concluded in the GEIS that gas-fired technology waste generation would be minimal (NRC 1996) and the waste impacts would be SMALL for a natural gas-fired combined-cycle plant sited at TMI-1 or at an alternate site; and impacts from a conservation alternative would be SMALL. Overall, the waste impacts from the combination alternative would be SMALL.

8.5 Purchased Power

Exelon Generation participates in the PJM Interconnection. This restructured energy supply system allows for the sale of energy across parts of 13 States and the District of Columbia (PJM 2008). Across the PJM, coal is the predominant fuel used for generation, accounting for 55.3 percent in 2007, followed by nuclear (33.9 percent), natural gas (7.7 percent), hydroelectric (1.7 percent), oil (0.5 percent), solid waste (0.7 percent), and wind (0.2 percent) (PJM 2008). Many of PJM's gas-fired units are actually able to burn fuel oil, as well, although gas utilization is much higher due to lower costs and emissions. Given the size and flexibility of PJM, the NRC staff considers it likely that purchased power could reasonably replace TMI-1.

Impacts would likely be similar to those of the above options located at alternate sites. If power purchases cause currently existing capacity to operate at higher capacity factors, however, rather than triggering new construction, then construction stage impacts would be eliminated. It is likely, then, that purchased power would come from older, less efficient plants than those considered in this chapter, from plants with once-through cooling, or from plants without modern emissions controls. Accordingly, impacts are difficult to quantify, although they are likely similar to those of other alternatives considered in Sections 8.2 through 8.4 in this supplemental EIS, as well as in the GEIS.

Given the location of TMI-1, it is unlikely that purchased power from outside the U.S. could replace TMI-1 capacity, regardless of whether or not either country has sufficient existing export capacity.

Since purchased power may come from a variety of generating resources, including coal, natural gas, nuclear, hydroelectric, and perhaps oil-fired installations (where impacts in previous NRC documents, including the supplemental EIS and the GEIS, were determined to be similar to or larger than those of natural-gas fired generation), NRC staff evaluation indicates that impacts from the purchased power alternative would be greater than the impacts of license renewal, and within the range of other alternatives considered in this chapter.

8.6 Alternatives Considered but Dismissed

In this section, the NRC staff presents the alternatives it initially considered for analysis as alternatives to license renewal of TMI-1, but later dismissed due to technical, resource

availability, or commercial limitations that currently exist and that the NRC staff believes are likely to continue to exist when the existing TMI-1 license expires. Under each of the following technology headings, the NRC staff indicates why it dismissed each alternative from further consideration.

8.6.1 Coal-Fired Integrated Gasification Combined-Cycle

While utilities across the U.S. have considered or are considering plans for integrated gasification combined-cycle (IGCC) coal-fired power plants, few IGCC facilities have yet been constructed. All facilities constructed in the U.S. to date have been smaller than TMI-1.

The technology, however, is commercially available and essentially relies on a gasifier stage and a combined-cycle turbine stage. Existing combined-cycle gas turbines (like the ones considered in Section 8.2) could be used as part of an IGCC alternative.

EIA indicates that IGCC and other advanced coal plants may become increasingly common in coming years (EIA 2008a, 2008b), though uncertainties about construction time periods and commercial viability in the near future leads NRC staff to believe that IGCC is an unlikely alternative to TMI-1 license renewal. For plants whose licenses expire at later dates, IGCC (with or without carbon capture and storage) may prove to be a viable alternative, though NRC did not evaluate IGCC as an alternative to TMI-1 license renewal.

8.6.2 New Nuclear

In its ER, Exelon Generation indicated that it is unlikely that a nuclear alternative could be sited, constructed and operational by the time the TMI-1 operating license expires in 2014 (AmerGen 2008). Sources in the nuclear industry have recently indicated that reactor projects currently under development are likely eight or nine years from completion (Nucleonics Week 2008), or possibly online in the 2016-2017 timeframe. While several new reactor proposals currently under development or undergoing NRC review are within the footprint of PJM, they are unlikely to be available prior to the expiration of the TMI-1 operating license. Further, potential plant owners or operators wishing to submit a new proposal specifically to offset the capacity of TMI-1 would require additional time to develop an application. Given the relatively short time remaining on the current TMI-1 operating license, NRC staff has not evaluated new nuclear generation as an alternative to license renewal.

8.6.3 Wind Power

Wind power, by itself, is not suitable for large baseload capacity. As discussed in Section 8.3.1 of the GEIS, wind has a high degree of intermittency and low average annual capacity factors (up to 30 to 40 percent). Wind power, in conjunction with energy storage mechanisms or another readily dispatchable power source, like hydropower, could serve as a means of providing baseload power. Current energy storage technologies are too expensive for wind power to serve as a large baseload generator.

The Commonwealth of Pennsylvania is mostly a wind power Class 1 region, although some areas, particularly along ridgelines, may provide wind classes ranging from 4 to 6 (DOE 2003).

Alternatives

Wind turbines are economical in wind power Classes 4 through 7, which have average windspeeds of 12.5 to 21.1 miles per hour (20 to 34 kilometers per hour) (DOE 2007).

Through the end of 2007, operators had installed 294 MWe in Pennsylvania (DOE 2008). While installed wind power capacity is relatively low, wind power installation in Pennsylvania has accelerated in recent years. As noted by the NRC staff in the supplemental EIS for the Susquehanna Steam Electric Station, PJM has a maximum potential of 6,658 MWe of wind capacity with an achievable potential of 665 MWe to 1,995 MWe. Given that this capacity will function at a 30–40-percent capacity factor, it is unlikely that there will be sufficient wind power potential to replace TMI-1.

Therefore, the NRC staff does not consider wind power to be a stand-alone alternative to TMI-1 license renewal.

8.6.4 Solar Power

Solar technologies use the sun's energy to produce electricity. Currently, the TMI-1 site receives approximately 4 to 4.5 kWh per square meter per day (approximately 0.4 kWh of solar radiation per square foot per day), as does much of Pennsylvania (NREL 2008), for solar collectors oriented at an angle equal to the installation's latitude. Since flat-plate photovoltaics tend to be roughly 25 percent efficient, a solar-powered alternative will require at least 3,590 to 4,040 ac (1,450 to 1,640 ha) of collectors to provide an amount of electricity equivalent to that generated by TMI-1. Space between parcels and associated infrastructure increase this land requirement. This amount of land, while large, is consistent with the land required for coal and natural gas fuel cycles. In the GEIS, the NRC staff noted that, by its nature, solar power is intermittent (i.e., it does not work at night and cannot serve baseload when the sun is not shining), and the efficiency of collectors varies greatly with weather conditions. A solar-powered alternative will require energy storage or a backup power supply to provide electric power at night. Given the challenges in meeting baseload requirements, the NRC staff did not evaluate solar power as an alternative to license renewal of TMI-1.

8.6.5 Wood Waste

In 1999, DOE researchers estimated that Pennsylvania has biomass fuel resources consisting of urban, mill, agricultural, and forest residues, as well as speculative potential for energy crops. Excluding potential energy crops, DOE researchers projected that Pennsylvania had 5,090,000 tons (4,617,570 metric tons) of plant-based biomass available at \$50 per ton delivered (Walsh et al. 2000; costs are in 1995 dollars). The Bioenergy Feedstock Development Program at Oak Ridge National Laboratory estimated that each air-dry pound of wood residue produces approximately 6,400 Btu of heat (ORNL 2007). Assuming a 33 percent conversion efficiency, using all biomass available in Pennsylvania at \$50 per ton—the maximum price the researchers considered—would generate roughly 6.3 terawatt hours of electricity. This is roughly the same as the amount of electrical energy produced by TMI-1 operating at 85 percent capacity for one year.

Walsh et al. (2000), go on to note that these estimates of biomass capacity contain substantial uncertainty, and that potential availability does not mean biomass will actually be available at

the prices indicated or that resources will be useably free of contamination. Some of these plant wastes already have reuse value, and would likely be more costly to deliver because of competition. Others, such as forest residues, may prove unsafe and unsustainable to harvest on a regular basis. As a result, the available resource potential is likely less than the estimated totals in Walsh et al., and the total resource is not likely to be sufficient to substitute for the capacity provided by TMI-1. As a result, the NRC staff has not considered a wood-fired alternative to TMI-1 license renewal.

8.6.6 Conventional Hydroelectric Power

According to researchers at Idaho National Energy and Environmental Laboratory, Pennsylvania has an estimated 2,217 MW of technically available, undeveloped hydroelectric resources at 104 sites throughout the State (INEEL 1997). This amount occurs primarily in small installations generating 10 MWe or less, though one site in Pennsylvania is capable of providing at least 100 MWe. These sites are scattered widely across the state, with a significant number in the Susquehanna River Basin region. The NRC staff notes that the total available hydropower potential is greater than the capacity considered for the other alternatives to license renewal of TMI-1, although INEEL indicates that many sites may not be available for development for a variety of reasons. Given the large numbers of individual installations needed to replace the TMI-1 capacity and the uncertainty surrounding available resource potential, the NRC staff did not evaluate hydropower as an alternative to license renewal. The NRC does, however, consider that the portion of this potential capacity that is available through upgrades at existing hydroelectric facilities could play a role in a combination alternative in Section 8.4.

8.6.7 Wave and Ocean Energy

Wave and ocean energy has generated considerable interest in recent years. Ocean waves, currents, and tides are often predictable and reliable. Ocean currents flow consistently, while tides can be predicted months and years in advance with well-known behavior in most coastal areas. Most of these technologies are in relatively early stages of development, and while some results have been promising, they are not likely to be able to replace the capacity of TMI-1 by the time its license expires. The NRC staff has previously evaluated the potential for wave or ocean energy to provide an alternative to license renewal for the Oyster Creek Nuclear Generating Station (OCNGS) in New Jersey, also part of PJM and located on the coast. In 2007, the NRC staff concluded that wave and ocean energy could not provide a feasible alternative to license renewal at OCNGS, a smaller plant than TMI-1 (NRC 2007). While testing of new technologies to produce electricity from the ocean continues, the NRC has not yet seen technological advances significant enough to consider wave and ocean energy as an alternative to TMI-1 license renewal.

8.6.8 Geothermal Power

Geothermal energy has an average capacity factor of 90 percent and can be used for baseload power where available. However, geothermal electric generation is limited by the geographical availability of geothermal resources (NRC 1996). As illustrated by Figure 8.4 in the GEIS, no

Alternatives

feasible eastern location for geothermal capacity exists to serve as an alternative to TMI-1. The NRC staff concluded that geothermal energy is not a reasonable alternative to license renewal at TMI-1.

8.6.9 Municipal Solid Waste

Municipal solid waste combustors incinerate waste to produce steam, hot water, or electricity. Combustors use three types of technologies—mass burn, modular, and refuse-derived fuel. Mass burning is currently the method used most frequently in the United States and involves no (or little) sorting, shredding, or separation. Consequently, toxic or hazardous components present in the waste stream are combusted, and toxic constituents are exhausted to the air or become part of the resulting solid wastes. Currently, approximately 89 waste-to-energy plants operate in the United States. These plants generate approximately 2,700 MWe, or an average of approximately 30 MWe per plant (Integrated Waste Services Association 2007). More than 25 average-sized plants will be necessary to provide the same level of output as the other alternatives to TMI-1 license renewal.

Estimates in the GEIS suggest that the overall level of construction impact from a waste-fired plant will be approximately the same as that for a coal-fired power plant. Additionally, waste-fired plants have the same or greater operational impacts than coal-fired technologies (including impacts on the aquatic environment, air, and waste disposal). The initial capital costs for municipal solid-waste plants are greater than for comparable steam-turbine technology at coal-fired facilities or at wood-waste facilities because of the need for specialized waste separation and handling equipment (NRC 1996).

The decision to burn municipal waste to generate energy is usually driven by the need for an alternative to landfills rather than energy considerations. The use of landfills as a waste disposal option is likely to increase in the near term as energy prices increase; however, it is possible that municipal waste combustion facilities may become attractive again.

Regulatory structures that once supported municipal solid waste incineration no longer exist. For example, the Tax Reform Act of 1986 made capital-intensive projects such as municipal waste combustion facilities more expensive relative to less capital-intensive waste disposal alternatives such as landfills. Also, the 1994 Supreme Court decision *C&A Carbone, Inc. v. Town of Clarkstown, New York*, struck down local flow control ordinances that required waste to be delivered to specific municipal waste combustion facilities rather than landfills that may have had lower fees. In addition, environmental regulations have increased the capital cost necessary to construct and maintain municipal waste combustion facilities.

Given the small average installed size of municipal solid waste plants and the unfavorable regulatory environment, the NRC staff does not consider municipal solid waste combustion to be a feasible alternative to TMI-1 license renewal.

8.6.10 Biofuels

In addition to wood and municipal solid-waste fuels, there are other concepts for biomass-fired electric generators, including direct burning of energy crops, conversion to liquid biofuels, and

biomass gasification. In the GEIS, the NRC staff indicated that none of these technologies had progressed to the point of being competitive on a large scale or of being reliable enough to replace a baseload plant such as TMI-1. After reevaluating current technologies, the NRC staff believes other biomass-fired alternatives are still unable to reliably replace the TMI-1 capacity. For this reason, the NRC staff does not consider other biomass-derived fuels to be feasible alternatives to TMI-1 license renewal.

8.6.11 Oil-Fired Power

EIA projects that oil-fired plants will account for very little of the new generation capacity constructed in the United States during the 2007 to 2030 time period. Further, EIA does not project that oil-fired power will account for any significant additions to capacity (EIA 2008a).

The variable costs of oil-fired generation tend to be greater than those of the nuclear or coal-fired options, and oil-fired generation tends to have greater environmental impacts than natural-gas-fired generation. In addition, future increases in oil prices are expected to make oil-fired generation increasingly more expensive. The high cost of oil has prompted a steady decline in its use for electricity generation. Thus the NRC staff did not consider oil-fired generation as an alternative to TMI-1 license renewal.

8.6.12 Fuel Cells

Fuel cells oxidize fuels without combustion and its environmental side effects. Power is produced electrochemically by passing a hydrogen-rich fuel over an anode and air (or oxygen) over a cathode and separating the two by an electrolyte. The only byproducts (depending on fuel characteristics) are heat, water, and CO₂. Hydrogen fuel can come from a variety of hydrocarbon resources by subjecting them to steam under pressure. Natural gas is typically used as the source of hydrogen.

At the present time, fuel cells are not economically or technologically competitive with other alternatives for baseload electricity generation. EIA projects that fuel cells may cost \$5,374 per installed kW (total overnight costs) (EIA 2008b), or 3.5 times the construction cost of new coal-fired capacity and 7.5 times the cost of new, advanced gas-fired, combined-cycle capacity. In addition, fuel cell units are likely to be small in size (the EIA reference plant is 10 MWe). While it may be possible to use a distributed array of fuel cells to provide an alternative to TMI-1, it would be extremely costly to do so. Accordingly, the NRC staff does not consider fuel cells to be an alternative to TMI-1 license renewal.

8.6.13 Delayed Retirement

Neither Exelon Generation nor its parent company, Exelon, has any plans to retire generating capacity within PJM (AmerGen 2008). As a result, delayed retirement is not a feasible alternative to license renewal. Other generation capacity may be retired within PJM prior to the expiration of the TMI-1 license, but this capacity is likely to be older, less efficient, and without modern emissions controls.

Alternatives

8.7 No-Action Alternative

This section will examine the environmental effects that will occur if NRC takes no action. No action in this case means that the NRC does not issue a renewed operating license for TMI-1, and the license expires at the end of the current license term, in April 2014. If the NRC takes no action, the plant will shutdown at or before the end of the current license. After shutdown, plant operators will initiate decommissioning according to 10 CFR 50.82, "Termination of License." Table 8-5 below contains a summary of the environmental impacts of the no-action alternative compared to continued operation of TMI-1.

We note that no action is the only alternative that we consider in-depth that does not satisfy the purpose and need for this supplemental EIS, because it does not provide power generation capacity. Furthermore, it would not meet the needs currently met by TMI-1, or the alternatives evaluated in sections 8.1 through 8.4. Assuming that a need currently exists for the power generated by TMI-1, the no-action alternative would require the appropriate energy planning decisionmakers to rely on an alternative to replace the capacity of TMI-1 or reduce the need for power.

In this section, we address only those impacts that arise directly as a result of plant shutdown. The NRC already addressed— in several other documents— environmental impacts from decommissioning and related activities. These documents include the *Final Generic Environmental Impact Statement on Decommissioning of Nuclear Facilities*, NUREG 0586, Supplement 1 (NRC 2002); the license renewal GEIS (Chapter 7; NRC 1996); and Chapter 7 of this supplemental EIS. These analyses either directly address or bound the environmental impacts of decommissioning whenever Exelon Generation ceases operating TMI-1.

We note that, even with a renewed operating license, TMI-1 will eventually shut down, and the environmental effects we address in this section will occur at that time. Since these effects have not otherwise been addressed in this supplemental EIS, we will address the impacts in this section. We expect that— as with decommissioning effects— shutdown effects will be similar whether they occur at the end of the current license or at the end of a renewed license.

Table 8-5. Summary of Environmental Impacts of the No Action Alternative Compared to Continued Operation of TMI-1.

	No Action		Continued TMI-1 Operation
	At TMI-1 site	At alternate site	
Air Quality	SMALL	N/A	SMALL
Ground Water	SMALL	N/A	SMALL
Surface Water	SMALL	N/A	SMALL
Aquatic and Terrestrial Resources	SMALL	N/A	SMALL
Human Health	SMALL	N/A	SMALL
Socioeconomics	SMALL to MODERATE	N/A	SMALL
Waste Management	SMALL	N/A	N/A

8.7.1 Air Quality

When the plant stops operating, there will be a reduction in emissions from activities related to plant operation, such as use of diesel generators and employees' vehicles. In Chapter 4, the NRC staff determined that these emissions would have a SMALL impact on air quality during the renewal term. Therefore, if the emissions decrease, the impact to air quality would also decrease and would be SMALL.

8.7.2 Ground Water Use and Quality

The use of ground water would diminish as plant personnel are removed from the site and operations cease. Some consumption of ground water may continue as a small staff remains onsite to maintain facilities prior to decommissioning. Overall impacts would be smaller than during operations, but would remain SMALL.

8.7.3 Surface Water Use and Quality

The rate of consumptive use of surface water would decrease as the plant is shut down and the reactor cooling system continues to remove the heat of decay. Wastewater discharges would also be reduced considerably. Shutdown would reduce the already SMALL impact on surface water resources and quality.

8.7.4 Aquatic and Terrestrial Ecology

Terrestrial Ecology

Terrestrial ecology impacts would be SMALL. No additional land disturbances on or offsite would occur.

Aquatic Ecology

If the plant were to cease operating, impacts to aquatic ecology would decrease, as the plant would withdraw and discharge less water than it does during operations. Shutdown would reduce the already SMALL impacts to aquatic ecology.

8.7.5 Human Health

Human health risks would be smaller following plant shutdown. The plant, which is currently operating within regulatory limits, would emit less gaseous and liquid radioactive material to the environment. In addition, following shutdown, the variety of potential accidents at the plant (radiological or industrial) would be reduced to a limited set associated with shutdown events and fuel handling and storage. In Chapter 4 of this supplemental EIS, the NRC staff concluded that the impacts of continued plant operation on human health would be SMALL. In Chapter 5, the NRC staff concluded that the impacts of accidents during operation were SMALL. Therefore, as radioactive emissions to the environment decrease, and as the likelihood and variety of

Alternatives

accidents decrease following shutdown, the NRC staff concludes that the risks to human health following plant shutdown would be SMALL.

In addition, the no-action alternative would require TMI-1 to initiate decommissioning activities. Environmental impacts from the activities associated with the decommissioning of any reactor before or at the end of an initial or renewed license are evaluated in the *Generic Environmental Impact Statement for Decommissioning of Nuclear Facilities: Supplement 1, Regarding the Decommissioning of Nuclear Power Reactors*, NUREG-0586, Supplement 1 (NRC 2002). The NRC's evaluation of the environmental impacts of decommissioning presented in NUREG-0586, Supplement 1, identifies a range of impacts for each environmental issue including human health risks. Based on information in the GEIS (NRC 1996) along with the information in Chapter 7 of this supplemental EIS, the Commission found that doses to the public will be well below applicable regulatory standards regardless of which decommissioning method is used. Occupational doses would increase no more than 1 person-rem caused by buildup of long-lived radionuclides during the license renewal term. Therefore, the human health risks to an occupational worker and to a member of the public, from the decommissioning of TMI-1, due to the no-action alternative, would be SMALL.

8.7.6 Socioeconomics

Land Use

Plant shutdown will not affect onsite land use. Plant structures and other facilities will likely remain in place until decommissioning. Most transmission lines at TMI-1 will remain in service after the plant stops operating. Maintenance of most existing transmission lines will continue as before. The NRC staff expects the impacts on land use from plant shutdown to be SMALL.

Socioeconomics

Plant shutdown will have a minimal impact on socioeconomic conditions in the region around TMI-1, primarily because of the plant's proximity to the Harrisburg-Carlisle metropolitan statistical area and its relatively small contribution to local services. Plant shutdown will eliminate up to 525–695 jobs and will reduce tax revenue in the region, though the TMI-1 contributions to local taxing jurisdictions are a small percentage of total revenue for each of the jurisdictions discussed in Chapter 4 of this supplemental EIS. The loss of these contributions, which may not entirely cease until after decommissioning, will have a SMALL impact, although job losses could increase the impact level slightly. Overall, the staff expects the impacts of plant shutdown to be SMALL to MODERATE. See Appendix J to NUREG 0586, Supplement 1 (NRC 2002), for additional discussion of the potential socioeconomic impacts of plant decommissioning.

Transportation

Traffic volumes on the roads in the vicinity of TMI-1 will decline after plant shutdown. Most of the reduction in traffic volume will be associated with the loss of jobs. The shipment of material to and from the plant will be reduced before decommissioning. Transportation impacts will be SMALL as a result of plant shutdown. Transportation impacts will increase if a new reactor or alternative energy facility is constructed on the TMI-1 site or in the immediate vicinity. Such impacts will be SMALL to MODERATE, but of short duration.

Aesthetics

Plant structures and other facilities will likely remain in place until decommissioning, although plumes from the plant's cooling towers are likely to disappear entirely. Noise caused by plant operation will cease. The NRC staff concludes that the aesthetic impacts of plant closure will be SMALL.

Historic and Archaeological Resources

Impacts from the no-action alternative would be SMALL, since TMI-1 would be decommissioned with no alternative power plant to replace it. A separate environmental review would be conducted for decommissioning. That assessment will address the protection of historic and archaeological resources.

Environmental Justice

Plant shutdown is unlikely to disproportionately affect minority and low-income populations. Impacts to all other resource areas would be SMALL to MODERATE. The communities in the immediate vicinity of TMI-1 do not have large populations of minority or low-income residents. Minority and low-income populations are generally concentrated in the urban areas of Harrisburg, Lancaster, and York. Thus, impacts from plant shutdown are likely to be SMALL. See Appendix J of NUREG 0586, Supplement 1 (NRC 2002), for additional discussion of these impacts.

8.7.7 Waste Management

After implementation of the no-action alternative, generation of high-level waste would stop and generation of low-level and mixed waste would decrease. Impacts from implementation of the no-action alternative are expected to be SMALL.

8.8 Alternatives Summary

In this chapter, we considered the following alternatives to TMI-1 license renewal: supercritical coal-fired generation, natural gas combined-cycle generation, energy conservation and energy efficiency, and a combination alternative. We also considered no action by the NRC and the effects it would have. The impacts for all alternatives are summarized in Table 8-6 on page 8-47.

The environmental impacts of the proposed action (issuing a renewed TMI-1 operating license) would be SMALL for all impact categories, except for the Category 1 issues of collective offsite radiological impacts from the fuel cycle, high level waste (HLW), and spent fuel disposal. The NRC staff did not assign a single significant level to these impacts, but the Commission determined them to be Category 1 issues nonetheless.

The coal-fired alternative is the least environmentally favorable alternative due to impacts to air quality from nitrogen oxides, sulfur oxides, particulate matter, PAHs, carbon monoxide, carbon dioxide, and mercury (and the corresponding human health impacts); and construction impacts to aquatic, terrestrial, and potential historic and archaeological resources. The gas-fired

Alternatives

alternative would have slightly lower air emissions, and impacts to aquatic, terrestrial, and historic and archaeological resources would vary depending upon location of the plant. Purchased power would likely have operational impacts that would include aspects of coal-fired, gas-fired, and existing nuclear generation.

The NRC notes that the energy conservation/energy efficiency alternative has SMALL impacts in all categories evaluated, and upon shut down of TMI-1, current operating impacts of TMI-1 would cease. Therefore, the energy conservation/energy efficiency alternative is the environmentally preferred alternative to license renewal. All other alternatives capable of meeting the needs currently served by TMI-1 entail potentially greater impacts than the proposed action of license renewal of TMI-1. The no-action alternative does not meet the purpose and need of this supplemental EIS, however if it triggers the energy conservation/energy efficiency action to replace the capacity currently supplied by TMI-1, it could result in an overall SMALL impact, as well.

Table 8-6. Summary of Environmental Impacts of Selected Alternatives Compared to Continued Operation of TMI-1.

Alternative	Impact Area						
	Air Quality	Ground Water	Surface Water	Aquatic and Terrestrial Resources	Human Health	Socioeconomics	Waste Management
License Renewal	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL
Supercritical coal-fired alternative at a new site	MODERATE	SMALL	SMALL	SMALL to LARGE	SMALL to MODERATE	SMALL to LARGE	SMALL to MODERATE
Gas-fired alternative at the TMI-1 site	MODERATE	SMALL	SMALL	SMALL	SMALL	SMALL to MODERATE	SMALL
Gas-fired alternative at a new site	MODERATE	SMALL	SMALL	SMALL to LARGE	SMALL	SMALL to MODERATE	SMALL
Energy Conservation/ Energy Efficiency	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL
Combination of Alternatives	SMALL to MODERATE	SMALL	SMALL	SMALL	SMALL	SMALL to MODERATE	SMALL
No Action Alternative	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL to MODERATE	SMALL

8.9 References

10 CFR 50. *Code of Federal Regulations*, Title 10, *Energy*, Part 50, "Domestic Licensing of Production and Utilization Facilities."

10 CFR 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions."

Alternatives

36 CFR 800. *Code of Federal Regulations*, Title 36, *Parks, Forests, and Public Property*, Part 800, "Protection of Historic Properties."

36 CFR Part 60. *Code of Federal Regulations*, Title 36, *Parks, Forests, and Public Property*, Part 60, Section 4, "Criteria for Evaluation."

40 CFR 51. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 51, "Requirements for Preparation, Adoption, and Submittal of Implementation Plans."

40 CFR 60. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 60, "Standards of Performance for New Stationary Sources."

63 FR 49442. Environmental Protection Agency, Washington, D.C., "Revision of Standards of Performance for Nitrogen Oxide Emissions From New Fossil-Fuel Fired Steam Generating Units; Revisions to Reporting Requirements for Standards of Performance for New Fossil-Fuel Fired Steam Generating Units." *Federal Register*. Vol. 63, NO. 179, pp. 49422–49455. September 16, 1998.

64 FR 35714. Environmental Protection Agency, Washington, D.C., "40 CFR Part 51, Regional Haze Regulations, Final Rule." *Federal Register*. Vol. 64, No. 126, pp. 35714–35774. July 1, 1999.

65 FR 32214. Environmental Protection Agency, Washington, D.C., "40 CFR Part 261, Notice of Regulatory Determination on Wastes from the Combustion of Fossil Fuels." *Federal Register*. Vol. 65, No. 99, pp. 32214–32237. May 22, 2000.

ACAA (American Coal Ash Association). 2007. "ACAA Releases 2006 CCP Production and Use Survey." August. Aurora, CO. Available URL: [http://www.acaa-usa.org/associations/8003/files/2006_CCP_Survey_\(Final-8-24-07\).pdf](http://www.acaa-usa.org/associations/8003/files/2006_CCP_Survey_(Final-8-24-07).pdf) (accessed October 14, 2008). ADAMS No. ML082880731.

Air Pollution Control Act. 35 P.S. §§ 4001–4015. *Pennsylvania Statutes*, Title 35, *Health and Safety*, Chapter 23, "Air Pollution."

AmerGen (AmerGen Energy Company, LLC). 2008. "Three Mile Island Nuclear Station, Applicant's Environmental Report, License Renewal Operating Stage." Kennett Square, PA. ADAMS Nos. ML080220255, ML080220257, ML080220261, and ML080220282.

ATSDR (Agency for Toxic Substances and Disease Registry). 1995. *Toxicological Profile for Polycyclic Aromatic Hydrocarbons (PAHs)*. Public Health Service, U.S. Department of Health and Human Services, Atlanta, GA.

ATSDR (Agency for Toxic Substances and Disease Registry). 1999. *Toxicological Profile for Mercury*. Public Health Service, U.S. Department of Health and Human Services. Atlanta, GA.

California Environmental Protection Agency (CalEPA). 1997. *Air Toxics Hot Spots Program Risk Assessment Guidelines: Technical Support Document for Determining Cancer Potency Factors. Draft for Public Comment*. Office of Environmental Health Hazard Assessment. Berkeley, CA.

Clean Air Act. 42 U.S.C. 7401, et seq. *United States Code*, Title 42, *The Public Health and Welfare*, Chapter 85, "Air Pollution Prevention and Control."

Darby, S. C. December 1989. "Health Risks of Radon and Other Internally Deposited Alpha Emitters-BEIR IV". *Biometrics* 45 (4): 1341–1342. National Research Council.

DOE (U.S. Department of Energy). 2008. "Installed U.S. Wind Capacity and Wind Project Locations." Interactive Maps. February 26, 2008. Available URL: http://www.eere.energy.gov/windandhydro/windpoweringamerica/wind_installed_capacity.asp (accessed April 18, 2008).

EIA (Energy Information Administration). 2006. "Cost and Quality of Fuel for Electric Plants, 2004 and 2005." DOE/EIA 0191(2006). Washington, D.C. Available URL: <http://www.eia.doe.gov/cneaf/electricity/cq/cqa2005.pdf> (accessed March 16, 2007). ADAMS No. ML082880730.

EIA (U.S. Department of Energy, Energy Information Administration). 2007. "Summary Statistics for the United States." Table ES1 from Electric Power Annual with data for 2006. Accessed at: <http://www.eia.doe.gov/cneaf/electricity/epa/epates.html> (accessed June 11, 2008). ADAMS No. ML082880730.

EIA (U.S. Department of Energy, Energy Information Administration). 2008a. *Annual Energy Outlook 2008 With Projections to 2030*. DOE/EIA 0383(2008). Washington, D.C. Available URL: [http://tonto.eia.doe.gov/FTP/forecasting/0383\(2008\).pdf](http://tonto.eia.doe.gov/FTP/forecasting/0383(2008).pdf) (accessed July 18, 2008). ADAMS No. ML082880730.

EIA (Energy Information Administration). 2008b. *Assumptions to the Annual Energy Outlook 2008 With Projections to 2030*. DOE/EIA 0554(2008). Washington, D.C. Available URL: [http://tonto.eia.doe.gov/FTP/forecasting/0554\(2007\).pdf](http://tonto.eia.doe.gov/FTP/forecasting/0554(2007).pdf) (accessed July 22, 2008). ADAMS No. ML082880730.

EPA (U.S. Environmental Protection Agency). 1997. *Mercury Study Report to Congress. Volume V: Health Effects of Mercury and Mercury Compounds*. Office of Air Quality Planning and Standards, Office of Research and Development. Washington, D.C.

EPA (U.S. Environmental Protection Agency). 1998. *Compilation of Air Pollutant Emission Factors, Volume 1: Stationary Point and Area Sources: AP 42, Fifth Edition*. "Section 1.1: Bituminous and Subbituminous Coal Combustion: Final Section Supplement E." Washington, D.C.

EPA (U.S. Environmental Protection Agency). 1999a. *Integrated Risk Information System (IRIS) on Polycyclic Organic Matter*. National Center for Environmental Assessment, Office of Research and Development. Washington, D.C.

EPA (U.S. Environmental Protection Agency). 1999b. *Integrated Risk Information System (IRIS) on Benzo(a)pyrene*. National Center for Environmental Assessment, Office of Research and Development. Washington, D.C.

EPA (U.S. Environmental Protection Agency). 1999c. *Integrated Risk Information System (IRIS) on Benz[a]anthracene*. National Center for Environmental Assessment, Office of Research and Development. Washington, D.C.

EPA (U.S. Environmental Protection Agency). 1999d. *Integrated Risk Information System (IRIS) on Methyl mercury*. National Center for Environmental Assessment, Office of Research and Development. Washington, D.C.

Alternatives

EPA (U.S. Environmental Protection Agency). 2000. "Regulatory Finding on the Emissions of Hazardous Air Pollutants from Electric Utility Steam Generating Units." Federal Register, Vol. 65, No. 245, pp. 79825–79831. Washington, DC. December 20, 2000.

EPA (U.S. Environmental Protection Agency). 2005. "Regional and State SO₂ and NOx Emissions Budgets." March. Washington, D.C. Available URL: <http://www.epa.gov/cair/pdfs/finaltech06.pdf> (accessed October 12, 2008). ADAMS No. ML082880732.

EPA (U.S. Environmental Protection Agency). 2007. "Clean Air Mercury Rule." Available URL: <http://www.epa.gov/air/mercuryrule/> (accessed July 9, 2007). ADAMS No. ML082880732.

EPA (U.S. Environmental Protection Agency). 2008a. "Nitrogen Oxide." Available URL: <http://www.epa.gov/air/urbanair/nox/hlth.html> (accessed July 19, 2008). ADAMS No. ML082880732.

EPA (U.S. Environmental Protection Agency). 2008b. "Radon Exposure." Available URL: <http://www.epa.gov/radon/healthrisks.html> (accessed July 19, 2008). ADAMS No. ML082880732.

EPA (U.S. Environmental Protection Agency). 2008c. "Sulfur Dioxides." Available URL: <http://www.epa.gov/air/urbanair/so2/> (accessed July 19, 2008). ADAMS No. ML082880732.

Gabbard, A. 1993. "Coal Combustion: Nuclear Resource or Danger." Oak Ridge National Laboratory Review. Oak Ridge National Laboratory, Oak Ridge, TN. Summer/ Fall 1993. Available URL: <http://www.ornl.gov/ORNLReview/rev26-34/text/colmain.html> (accessed May 23, 2007). ADAMS No. ML082880731.

GE (General Electric). 2007. "Gas Turbine and Combined Cycle Products." May 2007. Available URL: http://www.gepower.com/prod_serv/products/gas_turbines_cc/en/downloads/gasturbine_cc_products.pdf (accessed April 14, 2008). ADAMS No. ML082880731.

HHS (U.S. Department of Health and Human Services). 1993. *Hazardous Substances Data Bank*. National Toxicology Information Program, National Library of Medicine. Bethesda, MD.

INEEL (Idaho National Engineering and Environmental Laboratory). 1997. "U.S. Hydropower Resource Assessment for Pennsylvania." DOE/ID-10430(PA). Idaho Falls, ID. (December 1997). Available URL: <http://hydropower.inel.gov/resourceassessment/pdfs/states/pa.pdf> (accessed March 20, 2007). ADAMS No. ML082880730.

Integrated Waste Services Association. 2007. "Waste-to-Energy and the Production Tax Credit." Washington, DC. Available URL: <http://www.wte.org/docs/FactSheetPTC.pdf> (accessed May 24, 2007). ADAMS No. ML083050223.

NAS (National Academy of Sciences). 2005. *Health Risks from Exposure to Low Levels of Ionizing Radiation: Biological Effects of Ionizing Radiation (BEIR) VII, Phase 2, Seventh Ed.* Washington, D.C.

NRC (U.S. Nuclear Regulatory Commission). 1996. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*. NUREG-1437, Volumes 1 and 2, Washington, D.C. ADAMS No. ML061770605.

NRC (U.S. Nuclear Regulatory Commission). 1999. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Main Report*, "Section 6.3 – Transportation, Table 9.1, Summary of findings on NEPA issues for license renewal of nuclear power plants, Final Report." NUREG-1437, Volume 1, Addendum 1, Washington, D.C.

NRC (U.S. Nuclear Regulatory Commission). 2002. *Generic Environmental Impact Statement on Decommissioning of Nuclear Facilities: Supplement 1, Regarding the Decommissioning of Nuclear Power Reactors*. NUREG-0586, Supplement 1, Volumes 1 and 2. Washington, D.C.

NRC (U.S. Nuclear Regulatory Commission). 2007. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Supplement 28, Regarding Oyster Creek Nuclear Generating Station, Final Report – Main Report*. Washington, D.C.

NREL (National Renewable Energy Laboratory). 2008. "United States Atlas of Renewable Resources." Interactive Map. Available URL: <http://mapserve2.nrel.gov/website/ResourceAtlas/viewer.htm> (accessed April 18, 2008).

Nucleonics Week. 2008. "US new reactors more likely online in 2016 and beyond, NEI official says." Vol. 49, No. 15. April 10, 2008.

OMB (U.S. Office of Management and Budget). 2007. ExpectMore.gov. "Detailed Information on the Low Income Home Energy Assistance Program Assessment." Available URL: <http://www.whitehouse.gov/omb/expectmore/detail/10001059.2003.html> (accessed July 10, 2007). ADAMS No. ML082880730.

ORNL (Oak Ridge National Laboratory). 2007. "Bioenergy Conversion Factors." Available URL: http://bioenergy.ornl.gov/papers/misc/energy_conv.html (accessed November 6, 2007). ADAMS No. ML083050223.

Pace University Center for Environmental Legal Studies, *Environmental Cost of Energy*, Oceana Publications, NY, 1991.

PADEP (Pennsylvania Department of Environmental Protection). 2008. "Pennsylvania's Clear Air Plans." Available URL: http://www.dep.state.pa.us/dep/deputate/airwaste/aq/plans/Clean_air_plans.htm (accessed October 12, 2008). ADAMS No. ML082880732.

PJM (PJM Interconnection, Inc.). 2008. *2007 State of the Market Report, Volume 1: Introduction*. March. Available URL: <http://www2.pjm.com/markets/market-monitor/downloads/mmu-reports/2007-som-volume1.pdf> (accessed October 24, 2008). ADAMS No. ML083050232.

Pletka, R. 2004. "Potential Impact of an Advanced Energy Portfolio Standard in Pennsylvania." Presented at NREL Energy Analysis Forum, November 9, 2004. Available URL: <http://www.nrel.gov/analysis/forum/docs/2004/pletka.ppt> (accessed March 19, 2009). ADAMS No. ML090780880.

USGS (U.S. Geological Survey). 1997. "Radioactive Elements in Coal and Fly Ash: Abundance, Forms, and Environmental Significance; USGS Fact Sheet FS-163-97." Available URL: <http://greenwood.cr.usgs.gov/energy/factshts/163-97/FS-163-97.pdf> (accessed May 22, 2007). ADAMS No. ML082880731.

Alternatives

Walsh et al. (Walsh, M.E., R.L. Perlack, A. Turhollow, D. de la Torre Ugarte, D.A. Becker, R.L. Graham, S.A. Slinsky, and D.E. Ray). 2000. "Biomass Feedstock Availability in the United States: 1999 State Level Analysis." Available URL: <http://bioenergy.ornl.gov/resourcedata/index.html> (accessed May 22, 2007). ADAMS No. ML083050223.

9.0 CONCLUSION

This supplemental environmental impact statement (EIS) contains the preliminary environmental review of Exelon Generation Company, LLC's (Exelon Generation's) application for a renewed operating license for Three Mile Island Nuclear Station, Unit 1 (TMI-1) as required by Part 51 of Title 10, of the *Code of Federal Regulations* (10 CFR Part 51), the NRC's regulations that implement the National Environmental Policy Act (NEPA). Chapter 9 presents the conclusions and recommendations from the site-specific environmental review of TMI-1 and summarizes site-specific environmental issues of license renewal that were identified during the review. The environmental impacts of license renewal are summarized in Section 9.1; a comparison of the environmental impacts of license renewal and energy alternatives is presented in Section 9.2; unavoidable impacts of license renewal and energy alternatives and resource commitments are discussed in Section 9.3; and conclusions and NRC staff recommendations are presented in Section 9.4.

9.1 Environmental Impacts of License Renewal

Our review of site-specific environmental issues in this supplemental EIS leads us to conclude that issuing a renewed license would have SMALL impacts for the 21 Category 2 issues applicable to license renewal and refurbishment at TMI-1, as well as environmental justice and chronic effects of electromagnetic fields.

Mitigation measures were considered for each Category 2 issue, as applicable. For ground water and surface water use issues, current measures to mitigate the environmental impacts of plant operation were found to be adequate. Potential mitigation measures for reducing impacts from thermophilic microbiological organisms resulting from TMI-1's thermal discharge include periodically monitoring for thermophilic microbiological organisms in the water and sediments near the discharge, and prohibiting recreational use near the discharge plume. The staff identified a variety of measures that could mitigate potential acute electromagnetic field impacts resulting from continued operation of the TMI-1 transmission lines, including limiting public access to transmission line structures, installing signs at road crossings to warn against idling, and increasing transmission line clearances.

Mitigation measures that could reduce impacts to the terrestrial environment and threatened and endangered species during refurbishment activities include installing silt fences to minimize sediment transport, the use of best management practices, and restoring cleared land that remains after completion of construction. Mitigation measures to reduce potential air quality impacts resulting from refurbishment activities include implementation of best management practices for dust control to minimize emissions from construction activities, and the use of staggered workforce shift changes to reduce the number of vehicles on the road at any one given time.

No impacts to known historic and archaeological resources are expected from the continued operation of TMI-1 during the license renewal term. However, TMI-1 is situated in an archaeologically sensitive area and impact to archaeological resources is possible. Since publication of the draft supplemental EIS, Exelon Generation has revised its review procedures

Conclusion

for onsite ground disturbing activities to provide guidance regarding the protection of historic and archaeological resources, and has implemented a stop work provision if these resources are inadvertently discovered. Exelon Generation further mitigated the NRC finding of SMALL impact in the draft supplemental EIS by committing to develop and implement a cultural resources management plan (CRMP) and by training staff in the Section 106 process. Lands not previously surveyed should be investigated by a professional archaeologist prior to ground disturbance. In addition, the historical farmstead site (36Da235) should be recorded and evaluated for eligibility.

The NRC also considered cumulative impacts of past, present, and reasonably foreseeable future actions, regardless of what agency (Federal or non-Federal) or person undertakes them. The staff concluded that cumulative impacts of TMI-1 license renewal and refurbishment would be SMALL for potentially affected resources.

9.2 Comparison of Environmental Impacts of License Renewal and Alternatives

In the conclusion to Chapter 8, we determined that impacts from license renewal are generally less than the impacts of alternatives to license renewal, with the exception of energy conservation and energy efficiency. In comparing likely environmental impacts from supercritical coal-fired generation, natural gas combined-cycle generation, energy conservation and energy efficiency, and a combination alternative that included natural gas, conservation/efficiency, and uprates to existing hydroelectric dams, to environmental impacts from license renewal, we found that the energy conservation and energy efficiency alternative would result in the lowest environmental impact. Based on our analysis, we found that the impacts of license renewal are reasonable in light of the impacts from alternatives to the license renewal of TMI-1.

9.3 Resource Commitments

9.3.1 Unavoidable Adverse Environmental Impacts

Unavoidable adverse environmental impacts are impacts that would occur after implementation of all feasible mitigation measures. Implementing any of the energy alternatives considered in this supplemental EIS, including the proposed action, would result in some unavoidable adverse environmental impacts.

Minor unavoidable adverse impacts on air quality would occur due to emission and release of various chemical and radiological constituents from power plant operations. Nonradiological emissions resulting from power plant operations are expected to comply with U.S. Environmental Protection Agency (EPA) emissions standards, though the alternative of operating a fossil-fueled power plant in some areas may worsen existing attainment issues. Chemical and radiological emissions would not exceed the National Emission Standards for Hazardous Air Pollutants.

During nuclear power plant operations, workers and members of the public would face unavoidable exposure to radiation and hazardous and toxic chemicals. Workers would be

exposed to radiation and chemicals associated with routine plant operations and the handling of nuclear fuel and waste material. Workers would have higher levels of exposure than members of the public, but doses would be administratively controlled and would not exceed any standards or administrative control limits. In comparison, the alternatives entailing the construction and operation of a non-nuclear power generating facility would also result in unavoidable exposure to hazardous and toxic chemicals to workers and the general public.

The generation of spent nuclear fuel and waste material, including low-level radioactive waste, hazardous waste, and nonhazardous waste would also be unavoidable. In comparison, hazardous and nonhazardous wastes would also be generated at non-nuclear power generating facilities. Wastes generated during plant operations would be collected, stored, and shipped for suitable treatment, recycling, or disposal in accordance with applicable Federal and State regulations. Due to the costs of handling these materials, power plant operators would be expected to conduct all activities and optimize all operations in a way that generates the smallest amount of waste practical.

9.3.2 Relationship Between Local Short-Term Uses of the Environment and the Maintenance and Enhancement of Long-Term Productivity

The operation of power generating facilities would result in short-term uses of the environment as described in Chapters 4, 5, 6, 7, and 8. "Short term" is the period of time during which continued power generating activities would take place.

Power plant operations would necessitate short-term use of the environment and commitments of resources, and would also commit certain resources (e.g., land and energy) indefinitely or permanently. Certain short-term resource commitments would be substantially greater under most energy alternatives, including license renewal, than under the No Action Alternative due to the continued generation of electrical power as well as continued use of generating sites and associated infrastructure. During operations, all energy alternatives would entail similar relationships between local short-term uses of the environment and the maintenance and enhancement of long-term productivity.

Air emissions from power plant operations would introduce small amounts of radiological and nonradiological constituents to the region around the plant site. Over time, these emissions would result in increased concentrations and exposure, but are not expected to impact air quality or radiation exposure to the extent that public health and long-term productivity of the environment would be impaired.

Continued employment, expenditures, and tax revenues generated during power plant operations would directly benefit local, regional, and State economies over the short term. Local governments investing project-generated tax revenues into infrastructure and other required services could enhance economic productivity over the long term.

The management and disposal of spent nuclear fuel, low-level radioactive waste, hazardous waste, and nonhazardous waste would require an increase in energy and would consume space at treatment, storage, or disposal facilities. Regardless of the location, the use of land to meet waste disposal needs would reduce the long-term productivity of the land.

Conclusion

Power plant facilities would be committed to electricity production over the short term. After decommissioning these facilities and restoring the area, the land could be available for other future productive uses.

9.3.3 Irreversible and Irrecoverable Commitments of Resources

This section describes the irreversible and irretrievable commitments of resources that have been identified in this supplemental EIS. Irreversible resources refer to when primary or secondary impacts limit the future options for a resource. An irretrievable commitment refers to the use or consumption of resources that are neither renewable nor recoverable for future use. Irreversible and irretrievable commitment of resources for electrical power generation would include the commitment of land, water, energy, raw materials, and other natural and man-made resources required for power plant operations. In general, the commitment of capital, energy, labor, and material resources would also be irreversible.

The implementation of any of the energy alternatives considered in this supplemental EIS would entail the irreversible and irretrievable commitment of energy, water, chemicals, and, in some cases, fossil fuels. These resources would be committed during the license renewal term and over the entire life cycle of the power plant and would essentially be unrecoverable.

Energy expended would be in the form of fuel for equipment, vehicles, and power plant operations and electricity for equipment and facility operations. Electricity and fuels would be purchased from offsite commercial sources. Water would be obtained from existing water supply systems. These resources are readily available, and the amounts required are not expected to deplete available supplies or exceed available system capacities.

The irreversible and irretrievable commitment of material resources includes materials that cannot be recovered or recycled, materials that are rendered radioactive and cannot be decontaminated, and materials consumed or reduced to unrecoverable forms of waste. However, none of the resources used by these power generating facilities are in short supply, and, for the most part, are readily available.

Various materials and chemicals, including acids and caustics, would be required to support operations activities. These materials would be derived from commercial vendors, and their consumption is not expected to affect local, regional, or national supplies.

The treatment, storage, and disposal of spent nuclear fuel, low-level radioactive waste, hazardous waste, and nonhazardous waste would require the irretrievable commitment of energy and fuel and would result in the irreversible commitment of space in disposal facilities.

9.4 Recommendations

Based on (1) the analysis and findings in the GEIS; (2) information provided in the Environmental Report submitted by Exelon Generation; (3) consultation with Federal, State, and local agencies; (4) the NRC staff's own independent review; and (5) the NRC's staff's consideration of public comments received during the scoping process and the draft supplemental EIS public comment period, the NRC has determined that the adverse

Conclusion

environmental impacts of license renewal for TMI-1 are not so great that preserving the option of license renewal for energy-planning decisionmakers would be unreasonable.

10.0 LIST OF PREPARERS

This supplemental EIS was prepared by members of the Office of Nuclear Reactor Regulation, with assistance from other NRC organizations and contract support from Pacific Northwest National Laboratory.

Table 10-1. List of Preparers. *Pacific Northwest National Laboratory provided contract support for the severe accident mitigation alternatives (SAMA) analysis, presented in Chapter 5 and Appendix F.*

Name	Affiliation	Function or Expertise
Nuclear Regulatory Commission		
Briana Balsam	Nuclear Reactor Regulation	Ecology, Project Support
Dennis Beissel	Nuclear Reactor Regulation	Hydrology
Richard Bulavinetz	Nuclear Reactor Regulation	Aquatic Ecology
Andrew Carerra	Nuclear Reactor Regulation	Radiation Protection; Human Health
Jennifer Davis	Nuclear Reactor Regulation	Historic and Archaeological Resources
Nathan Goodman	Nuclear Reactor Regulation	Terrestrial Ecology
Stephen Klementowicz	Nuclear Reactor Regulation	Radiation Protection
Ekaterina Lenning	Nuclear Reactor Regulation	Air Quality
Dennis Logan	Nuclear Reactor Regulation	Ecology
Sarah Lopas	Nuclear Reactor Regulation	Project Manager, Nonradiological Waste
Robert Palla	Nuclear Reactor Regulation	Severe Accident Mitigation Alternatives
Jeffrey Rikhoff	Nuclear Reactor Regulation	Socioeconomics; Land Use; Environmental Justice
Andrew Stuyvenburg	Nuclear Reactor Regulation	Alternatives
Allison Travers	Nuclear Reactor Regulation	Hydrology
SAMA Contractor^(a)		
Steve Short	Pacific Northwest National Laboratory	Severe Accidents Mitigation Alternatives
Bruce Schmitt	Pacific Northwest National Laboratory	Severe Accidents Mitigation Alternatives
Tye Blackburn	Pacific Northwest National Laboratory	Severe Accidents Mitigation Alternatives

(a) Pacific Northwest National Laboratory is operated by Batelle for the U.S. Department of Energy

11.0 INDEX

- 1 accidents . xix, 5-1, 5-2, 5-3, 5-5, 8-43, A-16,
2 B-11, B-12, F-5
- 3 aesthetic xix, 2-56, 4-25, 8-14, 8-15, 8-23, 8-
4 24, 8-30, 8-35, 8-45
- 5 alternatives . iii, xix, xx, 1-30, 5-2, 5-3, 5-4, 8-
6 1, 8-2, 8-8, 8-25, 8-26, 8-30, 8-33, 8-42,
7 8-45, 8-46, 9-1, 9-2, 9-3, 9-4, 10-1, A-1,
8 A-15, A-16, A-17, B-12, E-6, E-7
- 9 archaeological resources . xix, 1-31, 2-21, 2-
10 65, 3-12, 3-13, 4-41, 4-42, 8-15, 8-24, B-
11 11, D-1
- 12 Barnwell.....2-8, A-15
- 13 biota 4-6, A-4, A-13, B-2, B-3
- 14 burnup2-1, B-16
- 15 chronic effects xviii, 1-28, 4-9, 4-17, 4-40, 9-
16 1, B-10
- 17 Clean Air Act 2-25, 2-74, 3-7, 3-15, 8-5, 8-48
- 18 closed-cycle cooling..... 4-12, 8-4, A-4, B-6
- 19 consumptive use... 2-16, 4-32, 4-34, 8-27, 8-
20 32, A-8
- 21 cultural resources 3-13, 4-41, 8-15, 8-24, C-
22 1
- 23 decommissioning.... 7-1, 8-18, 8-29, 8-31, 8-
24 42, 8-44, 8-45, 9-4, B-15, B-16, B-17
- 25 demography 2-50
- 26 design-basis accidents xxiii, 5-1, 5-2
- 27 discharges . xviii, 2-7, 2-15, 2-16, 2-18, 2-19,
28 2-21, 2-28, 2-31, 2-32, 3-6, 4-3, 4-6, 4-12,
29 4-13, 4-14, 4-15, 4-31, 4-33, 4-40, 8-4, 8-
30 9, 8-20, 8-21, 8-27, 8-43, 9-1, A-4, A-6, A-
31 7, A-8, A-11, A-12, B-1, B-3, B-4, B-9, C-
32 2, C-5
- 33 dose xviii, 2-5, 2-6, 2-7, 2-9, 3-4, 4-10, 4-11,
34 4-30, 4-39, 4-40, 5-5, 8-10, 8-11, A-11, A-
35 12, A-14, B-9, B-12, B-13, B-14, F-32, F-
36 33
- 37 dredging 3-3, C-6
- 38 education 2-51, 2-80, 2-82, 3-10, 4-18, 4-33,
39 4-42, B-10, B-11
- 40 electromagnetic fields . xviii, 1-28, 4-7, 4-17,
41 4-40, 9-1, B-7, B-10
- 42 entrainment..... 8-33, A-4, B-2, B-4
- 43 environmental justice 1-28, 3-13, 3-14, 4-18,
44 4-25, 4-29, 8-15, 8-24, 8-30, 8-35, 9-1, B-
45 17
- 46 EPA xxiii, 2-8, 2-9, 2-10, 2-11, 2-14, 2-25, 2-
47 27, 2-28, 2-35, 2-52, 2-56, 2-75, 2-78, 3-
48 7, 3-8, 3-9, 4-11, 4-39, 8-2, 8-5, 8-6, 8-7,
49 8-10, 8-11, 8-12, 8-18, 8-19, 8-28, 8-31,
50 8-49, 8-50, A-6, A-10, B-14, C-1, C-5
- 51 fish ladder2-30, 2-33, 2-34, 4-36
- 52 fish passage2-30, 2-33, 4-36
- 53 GEIS . xv, xvi, xvii, xviii, xix, xxiii, 1-28, 1-29,
54 1-31, 1-34, 2-57, 3-1, 3-7, 3-14, 4-1, 4-2,
55 4-3, 4-4, 4-5, 4-6, 4-7, 4-9, 4-15, 4-17, 4-
56 18, 4-19, 4-20, 4-31, 4-32, 4-40, 5-1, 5-2,
57 5-3, 6-10, 7-1, 8-1, 8-2, 8-4, 8-10, 8-12, 8-
58 13, 8-14, 8-17, 8-21, 8-22, 8-23, 8-25, 8-
59 26, 8-28, 8-29, 8-30, 8-33, 8-34, 8-36, 8-
60 42, 8-44, 9-4, A-1, A-4, A-9, A-14, A-15,
61 A-16, B-12
- 62 ground water . xvi, 2-15, 2-26, 2-27, 2-28, 2-
63 52, 3-1, 3-5, 4-2, 4-3, 4-5, 4-10, 4-30, 4-
64 32, 4-33, 4-34, 4-37, 4-42, 8-2, 8-8, 8-16,
65 8-20, 9-1, A-6, A-7, A-8, A-10, A-11, A-12,
66 A-13, B-5, B-6, C-1
- 67 hazardous waste.... 2-9, 2-10, 8-16, 9-3, 9-4,
68 C-5
- 69 high level waste B-12, B-13, B-14, B-15
- 70 impingement 8-33, A-4, B-2, B-4, B-5
- 71 invasive species..... 2-38, 4-37, 4-38
- 72 low level waste xxiv, A-15
- 73 mitigation ... xvi, xvii, xviii, 1-29, 1-30, 3-5, 3-
74 13, 4-1, 4-3, 4-5, 4-6, 4-9, 4-14, 4-16, 4-
75 34, 4-41, 5-3, 5-7, 8-15, 8-24, 8-28, 9-1,
76 9-2, 10-1, A-7, A-16, E-6, E-7, F-34
- 77 mixed waste..... xxiv, 2-8, 8-45, B-16
- 78 NEPA. xv, xxiv, 1-26, 1-37, 2-70, 2-78, 3-15,
79 4-25, 4-31, 4-48, 5-1, 6-12, 7-2, 8-1, 8-51,
80 9-1, A-1, B-1, B-13, B-14, D-1
- 81 no-action alternative. iii, xx, 8-25, 8-42, 8-44,
82 8-45

- nonattainmentxvi, 2-25, 3-1, 3-7, 3-9, 8-5, 8-18, 8-31, B-8
 nonnative 2-31, 2-32
 nonradiological waste 2-9, 2-11
 NPDES.. xxiv, 2-9, 2-11, 2-15, 2-16, 2-19, 2-21, 4-14, 4-35, 4-37, 8-9, A-4, A-5, A-8, B-2, C-1
 nuclides..... 8-28
 Pennsylvania Department of Conservation and Natural Resources xxiii, 2-39, 2-40, 2-41, 2-42, 2-43, 2-44, 2-45, 2-74, 2-75, 4-8, 4-46
 Pennsylvania Department of Environmental Protection ... xxiv, 2-9, 2-10, 2-11, 2-15, 2-16, 2-19, 2-21, 2-25, 2-30, 2-40, 2-51, 2-52, 2-78, 2-79, 4-10, 4-14, 4-30, 4-31, 4-35, 4-37, 4-48, 8-6, 8-9, 8-19, 8-51, A-5
 Pennsylvania Fish and Boat Commission ..xxv, 2-33, 2-34, 2-35, 2-39, 2-80, 4-7, 4-36, 4-48, 4-49
 Pennsylvania Game Commission .xxv, 2-39, 2-40, 2-41, 2-81, 4-8, 4-48
 Pennsylvania Historic and Museum Commission.... xxv, 2-81, 3-13, 4-41, 4-42
 postulated accidents 5-1, 5-3
 pressurized water reactor xxv
 radon-222..... 6-10, 8-28, B-12
 reactor..xv, xxiii, xxiv, xxv, 2-1, 2-5, 2-6, 2-7, 2-11, 2-12, 2-19, 2-40, 2-56, 3-1, 4-8, 4-10, 4-31, 4-39, 4-40, 5-1, 5-2, 5-3, 5-7, 5-8, 7-1, 8-43, 8-44, B-6, B-12, F-34, F-35
 refurbishment .xvi, xvii, xix, 2-7, 2-8, 2-21, 2-53, 3-1, 3-2, 3-4, 3-5, 3-6, 3-7, 3-8, 3-10, 3-11, 3-12, 3-13, 3-14, 9-1, 9-2, A-8, A-9, B-1, B-2, B-5, B-8, B-9, B-10, B-11, C-5
 replacement power iii, 5-7, F-34
 scoping...xv, xvi, 1-27, 1-28, 1-30, 1-31, 3-5, 3-6, 3-13, 4-1, 4-3, 4-5, 4-6, 4-9, 4-16, 4-18, 4-32, 5-2, 5-3, 6-10, 7-1, 9-4, A-1, A-2, E-2, E-3, E-4, E-5, E-6, E-7
 severe accidents (SAMA) .xxv, 5-3, 5-4, 5-6, 5-7, 5-8, 5-9, 10-1, A-16, F-5, F-15, F-34, F-35
 solid waste..2-8, 2-9, 2-10, 6-10, 8-10, 8-25, B-17, C-1
 spent fuel ...xxiv, 1-29, 2-6, 6-10, 6-11, 8-45, B-12, B-13, B-15, B-16
 steady-state current..... 4-15
 stormwater 2-21, 4-10, 4-33, A-8
 surface waterxvi, xix, 2-27, 2-52, 3-1, 3-6, 4-3, 4-10, 4-29, 4-30, 4-31, 4-38, 8-2, 8-4, 8-9, 8-16, 8-20, 8-21, 8-27, 8-32, 8-43, 9-1, A-7, A-8, A-9, A-12, B-1, B-6, C-1
 Susquehanna River Basin Commission xxv, 2-16, 2-19, 2-27, 2-29, 2-30, 2-31, 2-32, 2-82, 4-2, 4-3, 4-5, 4-32, 4-33, 4-34, 4-35, 4-37, 4-42, 4-49, A-5, A-6, A-7
 taxes 2-54, 2-62, 4-21, A-16
 threatened and endangered species . xvii, 1-31, 2-38, 2-39, 2-40, 2-41, 2-42, 2-49, 2-71, 3-6, 4-4, 4-7, 4-8, 9-1, A-9, A-11, B-3, B-8, C-1, C-6, D-1
 Three Mile Island Unit 2.xix, 2-1, 2-16, 2-21, 2-35, 2-72, 2-73, 2-78, 3-12, 3-13, 4-30, 4-37, 4-39, 4-48, 8-18, 8-31, A-2
 transmission corridors 8-15, 8-24
 transmission lines .. xviii, 2-12, 2-14, 2-35, 2-37, 4-1, 4-8, 4-15, 4-16, 4-18, 4-38, 4-40, 8-5, 8-9, 8-12, 8-13, 8-15, 8-18, 8-21, 8-22, 8-24, 8-29, 8-44, 9-1, B-8, B-11
 tritium .2-27, 2-28, 4-10, 4-29, 4-30, A-10, A-11, A-13
 U.S. Fish and Wildlife Service . xxiii, 2-37, 2-39, 2-40, 2-41, 2-76, 4-7, 4-8, 4-47, C-6
 universal waste 2-10
 uranium. 2-1, 2-5, 2-6, 4-40, 6-10, 8-8, 8-10, 8-13, 8-22, 8-34, B-12, B-15, B-16
 wastewater2-11, 2-15, 2-19, 2-21, 4-4, 4-33, 4-35, 4-38, A-8, B-2
 Yucca..... B-13, B-14, B-16

Appendix A

**Comments Received on the
Three Mile Island Nuclear Station, Unit 1,
Environmental Review**

A. Comments Received on the Three Mile Island Nuclear Station, Unit 1, Environmental Review

A.1 Comments Received During Scoping

The scoping process began on March 28, 2008 with the publication of the NRC's Notice of Intent to conduct scoping in the *Federal Register* (73 FR 16729). The scoping process included two public meetings held at The Elks Theatre and Londonderry Elementary School in Middletown, Pennsylvania on May 1, 2008. Approximately 90 people attended the meetings. After the NRC's prepared statements pertaining to the license renewal process, the meetings were open for public comments. Attendees provided oral statements that were recorded and transcribed by a certified court reporter. Transcripts of the entire meeting, as well as written statements submitted at the public meetings, were placed into the NRC as an attachment to the Scoping Summary Report dated August 8, 2008 (NRC 2008). In addition to the comments received during the public meetings, comments were received through the mail and email.

Each commenter was given a unique identifier so every comment could be traced back to its author. Table A-1 identifies the individuals who provided comments applicable to the environmental review and the Commenter ID associated with each person's set of comments. The individuals are listed in the order in which they spoke at the public meeting, and in alphabetical order for the comments received by letter or e-mail. To maintain consistency with the Scoping Summary Report, the unique identifier used in that report for each set of comments is retained in this appendix.

Specific comments were categorized and consolidated by topic. Comments with similar specific objectives were combined to capture the common essential issues raised by participants. Comments fall into one of the following general groups:

Specific comments that address environmental issues within the purview of the NRC environmental regulations related to license renewal. These comments address Category 1 (generic) or Category 2 (site-specific) issues or issues not addressed in the *Generic Environmental Impact Statement for License Renewal of Nuclear Power Plants* (GEIS). They also address alternatives to license renewal and related Federal actions.

General comments (1) in support of or opposed to nuclear power or license renewal or (2) on the renewal process, the NRC's regulations, and the regulatory process. These comments may or may not be specifically related to the TMI-1 license renewal application.

Comments that do not identify new information for the NRC to analyze as part of its environmental review.

Comments that address issues that do not fall within or are specifically excluded from the purview of NRC environmental regulations related to license renewal. These comments

Appendix A

typically address issues such as the Three Mile Island Unit 2 and the 1979 accident, emergency response and preparedness, security and terrorism, energy costs, energy needs, current operational safety issues, and safety issues related to operation during the renewal period.

Table A-1. Commenters on the Scope of the Environmental Review. *Each comment is identified along with their affiliation and how their comment was submitted.*

Commenter ID	Commenter	Affiliation	Comment Source	ADAMS Accession Number
TMI-A	Scott Portzline	TMI Alert	Afternoon Scoping Meeting; Written Comments	ML081300739 ML081330183
TMI-E	Andrew Dehoff	Susquehanna River Basin Commission	Afternoon Scoping Meeting	ML081300739
TMI-F	Eric Epstein	TMI Alert	Afternoon Scoping Meeting; Written Comments	ML081300739 ML081330183
TMI-H	Mary Osborn Ouassiai	Concerned Mothers, TMI Alert	Afternoon Scoping Meeting; Written Comments; Letter	ML081300739 ML081330183 ML081690678
TMI-J	Michael Helfrich	Lower Susquehanna RIVERKEEPER	Afternoon Scoping Meeting	ML081300739
TMI-N	Rachel S. Diamond; David J. Allard	Pennsylvania Department of Environmental Protection	Letter	ML081500598
TMI-O	Michael G. Brownell	Susquehanna River Basin Commission	Letter	ML081580174

Comments received during scoping applicable to this environmental review are presented in this section along with the NRC response. The comments that are general or outside the scope of the environmental review for TMI-1 are not included here, but can be found in the Scoping Summary Report (NRC 2008).

Scoping comments are grouped in the following categories:

- Aquatic Ecology
- Water Quality and Use
- Terrestrial Resources
- Air Quality
- Nonradiological Solid Waste and Hazardous Materials
- Socioeconomics

- Human Health
- Uranium Fuel Cycle and Waste Management
- Postulated Accidents
- Alternatives

A.1.1 Aquatic Ecology

Comment: I had – we've had some concerns lately with the area that Three Mile Island is in as far as fish health. We've had some fish kills there recently, and we believe, not caused necessarily by TMI, but in the vicinity there is a decline in some fish and a decline in small mouth bass that we were observing.

Let's see. We also have concerns with thermal pollution in this area, and although the amount it seems that is going into the river is much less than some of the other contributors, we would be interested to know if there were thermal shock zones in the area similar to Brunner Island which has problems there where the hot water is meeting the cold water at different times of the year.

So although I've talked to one of the NRC biologists earlier, and they said that approximately one dead fish found per day in the intakes, I'm interested in what's going on in the effluent, and also the temperatures of that effluent, and the temperature differences between the river temperatures and the effluent. (TMI-J-1)

Comment: And also with the thermal impact as brought up, where we are pre-boiling the fish that you catch, the 102 degree temperatures, we are going to see even increased temperatures with the droughts that are occurring across the nation, and the thermal impact of nuclear power plants is going to be pronounced in decades. (TMI-A-1)

Comment: "Whether the kills are legal or not, a former southern Lancaster County worker at the Peach Bottom nuclear plant said he was "sickened" by the large numbers of sport fish he saw sucked out of the Susquehanna. "When the water comes in, fish would swim in through tunnels and swim into wire baskets," said the man who lives in southern Lancaster County and asked that his name not be used. "There were hundreds and hundreds of fish killed each day. Stripers and bass and walleye and gizzard shad and all kinds of fish. It took a forklift to carry them out. "Every species in the river comes in there when they turn those big intakes on." (Intelligencer Journal, January 15, 2005) TMI has a similar system for disposing of the fish and other organisms that make it through the intake maze. "If they get that far, they're not going back," said Pete Ressler, a spokesman for TMI owner AmerGen. "They are dumped into a container and disposed of." Will this system function in the same manner for an additional 20 years? (TMI-F-7)

Comment: The Environmental Report states that in the early study (IA, 1979) the delta T did not exceed 5 degrees F while in the later study (2006 and 2007), delta T is often greater than 10 degrees F, and at one point was over 30 degrees. The cause for the increase in temperature change should be identified, and the potential adverse impacts assessed. Dramatic changes in temperature can be as detrimental, and sometimes more so, for long-term community sustainability than high temperatures. Any thermal assessments should also include the volume of discharged water, as that parameter is important to the delta T. (TMI-O-1)

Appendix A

Comment: AmerGen concludes that heat shock issue does not apply to TMI-1 because the unit does not use once-through cooling. However, it is conceivable that heat shock could be an issue during extremely low flows or during unusual operations (such as unexpected flow interruption or loss of York Haven pond). Such potential should be investigated. Again, without accurate determination of discharge water quantity and temperature, AmerGen's conclusion is unfounded. (TMI-O-2)

Comment: *Irreversible and Irrecoverable Resource Commitments.* There is no mention of the long-term implications to the resource of the facility's thermal discharge. (TMI-O-3)

Comment: *Short-Term Use Versus Long-Term Productivity of the Environment.* As with the previous issue, there is no recognition of the potential impact due to the facility's thermal discharge. (TMI-O-4)

Comment: The Environmental Report states the number of shad passed (total, high, and low), but does not compare those numbers to what was passed downstream at Safe Harbor. Although Safe Harbor is a significant distance downstream, the percentages should at least be mentioned as a comparison - and to put the overall restoration into context. As with previous two comments, the quantities of water withdrawn and discharged and their potential effects on shad movement should be assessed. (TMI-O-5)

Response: *The comments, in general, express concern regarding the impacts on aquatic organisms resulting from operation of the TMI-1 closed-cycle cooling system. To operate TMI-1, NRC regulations require Exelon Generation to comply with the Clean Water Act and its associated requirements imposed by the U.S. Environmental Protection Agency (USEPA), as part of their National Pollutant Discharge Elimination System (NPDES) permit. The NRC staff based its analysis of environmental impacts of the TMI-1 license renewal on the GEIS, which was issued in 1996, as amended in 1999. The effects of closed-cycle cooling system operation on aquatic biota are all Category 1 issues. In considering the effects of closed-cycle cooling systems on aquatic ecology in the GEIS, the staff evaluated the same issues that were evaluated for open-cycle systems, including impingement of fish and shellfish, entrainment of fish and shellfish early life stages, and thermal discharge effects. Based on reviews of literature and operation monitoring reports, consultations with utilities and regulatory agencies, and comments on the draft GEIS, these potential effects have not been shown to cause reductions in the aquatic populations near any existing nuclear power plants.*

No change in operation of the TMI-1 cooling system is expected during the license renewal term, so no change in effects of cooling towers on aquatic biota in the Susquehanna River is anticipated. However, as part of its review the NRC staff looked for any new and additional information that might call into question the conclusions reached in the GEIS for Category 1 issues - no new and significant information was identified, therefore, there are no impacts beyond those discussed in the GEIS.

With regard to comment TMI-O-1 concerning the temperature of TMI-1 discharge water, Section 2.1.7.3 discusses TMI-1's NPDES permit limitations, and states "...the permit also stipulates that during any 1-hour period, discharge may not affect the temperature of the receiving body by more than 2° F. No violations of this limit have been recorded."

Comment: It appears that all of the presented information and conclusions are based on data at least 18 years old. Reference is made to monitoring conducted from 1974-1982 and through 1990, but nothing more recent, and there is no mention of the quantity of water withdrawn and whether that has changed over time. The environmental assessment for relicensing should require the collection of new monitoring data and evaluation of that data and any changes it shows. (TMI-O-6)

Response: *The NRC staff believes there is sufficient information available to perform an assessment of the impacts of license renewal at TMI-1. Furthermore, NRC cannot require the collection of additional aquatic ecology data to support preparation of the supplemental environmental impact statement (EIS)—the Pennsylvania Department of Environmental Protection (PADEP) issues and enforces the TMI-1 NPDES permit and has the authority to require additional data collection. NRC staff used the best available information, drawing from a variety of sources including data collected by Exelon Generation, the Pennsylvania Fish and Boat Commission, the Susquehanna River Basin Commission, other governmental agencies, independent researchers, and others. If new and significant information becomes available in the future that demonstrates a significant impact to the aquatic environment as a result of continued station operation, the staff would expect PADEP to require modifications to station operation as necessary to protect aquatic resources through the NPDES permitting process.*

A.1.2 Water Quality and Use

Comment: I am Andrew Dehoff. I'm the director of planning and operations at the Susquehanna River Basin commission in Harrisburg. First off I'd like to thank NRC and AmerGen staff for including us in the informational briefings and the facility tours that took place earlier this week. It was very helpful.

SRBC is still at the stage of gathering information, and as such don't have comments, specific comments, ready to share today, but we will be submitting written comments by the deadline.

Preliminarily I can offer that SRBC's main concerns would be related to the water withdrawn from the river for plant operations, and the water used onsite, and also any changes to operations or equipment that would affect the water use on site. Some examples of other issues, we might be commenting on, would relate to the facility and its situation on the river. And by that I mean flood preparedness and drought preparedness, and the fact that there is a great deal more water use both upstream and downstream of TMI than there was when the plant began operating. Finally just a thank you to NRC for hosting this open house today, and giving us the opportunity to speak. (TMI-E)

Comment: How does the NRC plan to deal with the following water related issues and structural challenges caused by: Micro fouling versus macro foiling, micro biologically influenced corrosion, biofilm's disease causing bacteria such as Legionella and listeria, the difficulty in eliminating established biofilms, oxidizing versus nonoxidizing biocides, chlorine versus bleach, alkaline versus non-alkaline environments, possible decomposition into carcinogens, and the eastward migration of Asiatic clams, zebra mussels and the anticipated arrival quagga mussels? (TMI-F-8)

Appendix A

Comment: *Drinking Water.* In Section 2.91 of the Environmental Report (ER), Dauphin County is listed as having 14 public water systems. According to the Safe Drinking Water Act (SDWA) definition of a public water system, that number is incorrect. The SDWA definition of a public water supply is: *a system which provides water to the public for human consumption which has at least 15 service connections or regularly serves an average of at least 25 individuals daily at least 60 days out of the year.* The definition goes on to define a community water system as: *a public water system which serves at least 15 service connections used by year-round residents or regularly serves at least 25 year-round residences.* Dauphin County residents are currently served by 28 community public water supplies. The population listed for two of the largest community water supplies also appears to be incorrect; the population for United Water Pennsylvania and Pennsylvania American Water Company – Hershey should be verified with the water companies.

Table 2.9-1 of the ER lists the community public water supplies in Dauphin County that serve more than 10,000 persons. The data provided for United Water Pennsylvania should be verified because it is not correct. Also, Middletown Borough Water Authority should be included in this table. Middletown's population (including two consecutive water systems that receive all their water from Middletown) is 10,247 persons.

In Section 2.3, 4.15.1 and 4.15.2, the ER states that the plant does not use water from a public water system. The SDWA defines a nontransient noncommunity public water system as: *a public water system which is not a community water system that regularly serves at least 25 of the same persons over six months per year.* Based on this definition, the Three Mile Island facility is a public water system and provides potable water to the plant population. (TMI-N-1)

Comment: It was observed during the site tour that soil has eroded from around and behind the headwall at Outfall 001. Backfilling around and behind the headwall may be necessary to prevent damage to the discharge line. (TMI-N-2)

Comment: Although generally satisfied with the ground water explanation, the 'glacial' materials could not in fact have been deposited by glaciers as their limit of extent is some 20 miles north of TMI. Water in the Gettysburg shale is commonly considered to be semi-confined and not artesian. (TMI-O-7)

Comment: SRBC has approved Wells 1, 2, and 3 (aka A, B, C) for industrial water supply and is perplexed to learn that the OSF Well is also used to augment the supply of service water. If this is the case, the well would require review and approval by SRBC. (TMI-O-8)

Comment: *EPA-Regulated Facilities in Dauphin, Lancaster and York Counties.* Review of the impacts of extending TMI's license should include analysis of potential effects of TMI's water use and thermal discharge on the operations and/or waste assimilation capability of downstream withdrawals and discharges; likewise, the operation, withdrawals and discharges of upstream facilities should be analyzed for potential impacts to TMI's operations and thermal discharge assimilation. (TMI-O-9)

Comment: The potential for nearby power facilities to impact TMI's operations, and vice versa, should be evaluated. Of particular concern is operations during periods of severe low flow and extreme temperatures, including heat and river ice conditions. (TMI-O-10)

Comment: What is the auxiliary water? What are the provisions for backup supply? What is the source of auxiliary? Has it been sufficiently reviewed, and does it have the appropriate permits? (TMI-O-11)

Comment: AmerGen concludes that any impacts caused by TMI-1 make-up water withdrawal would be "SMALL" and would not warrant additional mitigation. What is the conclusion based on? How small is "SMALL"? The assumptions and conditions used in the analysis should be provided; they may not be valid if the same assumptions and conditions were used as in the original siting study 40 years ago. In particular, the amount of other consumptive water use on the river both upstream and downstream of TMI has changed dramatically, and will continue to grow. Natural hydrologic conditions may also have changed. Without a demonstration of accurate accounting for water withdrawal and discharge, it is impossible to assess potential impacts to downstream water users. (TMI-O-12)

Comment: The assessment should include the potential impact of all ground water wells on site. The conclusions presented in the Environmental Report are based on the well withdrawals already approved by SRBC; however, there is at least one additional unapproved well in production. The 1996 pump tests cited by AmerGen do not include any unapproved wells, and are thus insufficient to evaluate potential ground water use conflicts.

The use of additional unapproved wells has likely increased the quantity of ground water withdrawal on site. It appears that all ground water evaluations in the Environmental Report are based on the withdrawal quantity from approved wells only; all assessments involving ground water impacts or conflicts should be performed again using an accurate value for total ground water withdrawal.

Applicant should assess the potential ground water conflicts among wells in their own system, to ensure their long-term viability. (TMI-O-13)

Comment: What is the basis for the conclusion by AmerGen that the impacts of the river withdrawal to local ground water are small? The details of that analysis should be made available for review.

As the Environmental Report states, SRBC directs the release of storage on behalf of TMI during times of drought. However, the quantity released is equivalent only to the consumptive loss at the plant, and not the total withdrawal, which is considerably greater. Further, replacement releases are made only during very severe droughts, and not during moderate droughts and other short-term periods of unusually low flows. Thus, despite releases by SRBC, there remains the potential for ground water impacts due to the difference between total withdrawal and consumptive loss, and during periods of moderate and short-term severe droughts. These potential impacts should be assessed.

There is no documentation presented demonstrating that TMI-1's surface water withdrawal is capturing only river water, and not also drawing ground water from the adjacent aquifer. (TMI-O-14)

Comment: In addition to the impacts listed, other unavoidable impacts include thermal discharge and localized impacts of the river withdrawal. There may be others. (TMI-O-15)

Appendix A

Comment: Not listed among the resource commitments is the water demand. The water lost through plant operations is removed from the Susquehanna River Basin forever, and it is a cumulative loss that will continue through the end of license period. The long-term commitment and ultimate loss of that water renders it unavailable for use by any other power plant, water supply intake, recreational interest, aquatic habitat, or inflow to Chesapeake Bay. It is also important to note that renewal of the license commits that water in such a way that it is also unavailable to uses upstream of TMI, in order to ensure its continued availability for use at the plant. It is unexpected to find that AmerGen would overlook a resource as critical and integral to plant operations, as well as to the natural, social and economic development of the entire region, in its Environmental Report. (TMI-O-16)

Response: *The comments, in general, pertain to the plant's consumptive use of surface water from the Susquehanna River, ground water resources in the vicinity of TMI-1, the plant's use of ground water, and the plant's impact on surface and ground water quality. Surface and ground water use and water quality issues, including cumulative impacts, are Category 2 issues and are addressed in Sections 2.1.7, 2.2.3, 2.2.4, 4.3, and 4.4 of this supplemental EIS.*

As stated in Section 4.3.1, after publication of the draft supplemental EIS, Exelon Generation submitted an application to SRBC to utilize the existing OSF well for both potable and industrial purposes, with no increase in the approved ground water withdrawal rate (Exelon Generation 2009).

Comment: *Water Quality.* During steam generator replacement, high pressure water will be used to cut openings in the Unit 1 containment building. The containment building walls are made of concrete and are approximately 3 feet thick. According to AmerGen personnel, a temporary package plant will be used to treat wastewater from cutting activities (i.e., to settle suspended concrete particles and adjust pH) before discharge to the Susquehanna River. A temporary discharge permit is required for this plant. As an alternative, wastewater from this operation can be collect and sent off-site for treatment. Under no circumstances should this wastewater stream be sent to the existing wastewater treatment plant. Also, AmerGen should notify the DEP once the package plant is installed so DEP personnel can inspect it and sample the discharge. (TMI-N-3)

Comment: *Water Resources.* If transportation of the new generators along Pennsylvania highways or bridges requires any transportation system upgrades or other work, that work may encroach upon wetlands or waterways. Federal and State wetlands and stream encroachment permits or authorizations may be required for such encroachments. A 401 certification may also be necessary. Contrary to the statement made in the EIS, TMI's National Pollutant Discharge Elimination System (NPDES) permit (i.e., discharge permit) does not carry with it a new 401 certification. (TMI-N-4)

Comment: An erosion and sedimentation plan, and possibly a construction stormwater NPDES permit, will be required for earth disturbance associated with the new building construction. (TMI-N-5)

Response: *The comments pertain to Exelon Generation's planned replacement of the TMI-1 once-through steam generators. Environmental impacts of refurbishment activities are evaluated in Chapter 3 of this supplemental EIS. Impacts of refurbishment on ground water and*

surface water use and quality were examined in the GEIS and are Category 1 impacts. During its review the NRC did not identify any new and additional information that would call into question the conclusions reached in the GEIS for Category 1 issues. Chapter 3 also addresses the impact of refurbishment activities on threatened and endangered species, including aquatic species that may be impacted by erosion into and sedimentation of the Susquehanna River.

A.1.3 Terrestrial Resources

Comment: AmerGen should consider enhancement of the created open-water wetlands established on-site from the original plant excavations. Such enhancements would be used to offset any impacts to aquatic resources that may occur as the result of its intake or other project activities. (TMI-N-6)

Comment: What is the value and quality of the wetlands that have been formed from the borrow pits? Consideration should be given to undertaking some enhancement features - perhaps in conjunction with a local environmental group. (TMI-O-17)

Response: *The potential impacts of the continued operation of TMI-1 on terrestrial ecology is addressed in Sections 2.2.6 and 4.6. Impacts of continued operation on terrestrial ecology were examined in the GEIS and are Category 1 impacts. During its review, the NRC did not identify any new and additional information that would call into question the conclusions reached in the GEIS for Category 1 issues. Impacts of continued operation to protected terrestrial species is a Category 2 issue and is addressed in Sections 2.2.7 and 4.7 of this supplemental EIS.*

A.1.4 Air Quality

Comment: *Asbestos.* As the date of construction falls within the general timeframe when the use of asbestos-containing materials (ACM) was phased out, there is some possibility that ACM maybe be present on-site. In the event that the project includes disturbance of any ACM, it may be subject to the federal asbestos regulations found at 40 CFR Part 61, Subpart M, beginning at 40 CFR 61.140. (TMI-N-7)

Comment: *Fugitive Emissions.* Construction and earthmoving activities must comply with 25 Pa. Code Sections 123.1 and 123.2. These sections generally require that: 1) reasonable measures must be taken to minimize airborne dust nuisances from construction activities, 2) any dirt drag-out onto paved streets must be promptly removed, and 3) any airborne dust generated from construction activities may not visibly cross off-property. (TMI-N-8)

Response: *The comments pertain to impacts to air quality during Exelon Generation's planned replacement of the TMI-1 once-through steam generators. Impacts to air quality during refurbishment activities is a Category 2 issue and is evaluated in Section 3.2.3 of this supplemental EIS.*

A.1.5 Nonradiological Solid Waste and Hazardous Materials

Appendix A

Comment: AmerGen should consider deconstruction and salvage to reduce waste disposal to the extent possible. All construction and demolition waste that cannot be salvaged or recycled should be properly transported and disposed of at a DEP-permitted facility. Open burning of waste is not acceptable. (TMI-N-9)

Comment: Documentation should be provided demonstrating that the flood protection dike – or the location and storage of hazardous material – ensures there is protection from contamination during the flood of record. (TMI-O-18)

Response: *Nonradioactive waste management and pollution prevention is discussed in Section 2.1.3 of this supplemental EIS. The staff reviewed the plant's protocols for storing and managing hazardous materials on site, however, the Pennsylvania Department of Environmental Protection has ultimate authority in implementing regulations regarding the treatment, storage, and disposal of hazardous materials.*

A.1.6 Socioeconomics

Comment: How many people work at TMI-1? How many people worked at TMI-1 when AmerGen purchased the plant from GPU? How many people does the NRC project will be working at TMI-1 in 20 years? Can you factor economics, staffing levels, or the tax base into a relicensing decision? (TMI-F-10)

Response: *The comments are related to the socioeconomic impacts associated with the continued operation or closure of TMI-1. Socioeconomic impacts such as housing, transportation, employment, and land use are Category 2 issues and are addressed in Sections 2.2.8 and 4.9 of this EIS.*

A.1.7 Human Health

Comment: TMI is located on Susquehanna River so any leaking contaminants from waste storage facilities will flow towards and eventually into the Bay. There are no monitoring wells lining the shoreline. Tritium and other leaks – examples and NRC policy on self-monitoring - also exist at Three Mile Island. How has the NRC changed modified its relicensing process to evaluate tritium monitoring? (TMI-F-11)

Comment: It was reported last year that tritium was being found in the ground water. We would like to know the extent of that, where the plumes of this are; also whether we can expect this to be increasing. Don't know that much about it, so I'd like to learn a lot more. But obviously when we are dealing with radiation and things with potentially very long half-lives, bioaccumulate – or accumulation in the environment is definitely a concern. So even though we were all – supposedly our concerns were quelled last year that these levels were not very high, if this is an ongoing issue, we would definitely want to know more about that, and have some kind of comparison to a more virgin area, perhaps somewhere far from nuclear reactors, that we might be able to get a better comparison of that. (TMI-J-2)

Comment: In sections 2.2.3 and 5.1, the report mentions an Environmental Protection Agency (EPA) drinking water standard for tritium of 20,000 pCi/L, which is used as a reference value to

add perspective to results obtained in their ground water monitoring program. Based on the method EPA uses to calculate the maximum contaminant level (MCL) for beta particle and photo radioactivity (of which tritium is a constituent), the report should have referenced the fact that gross beta analysis is routinely conducted and tritium is the only constituent which is detected in the samples. The clarification would better explain what contaminants are analyzed for, which have been detected, and how they relate to EPA's drinking water standards. (TMI-N-10)

Comment: AmerGen references data presented in Section 2.3 on ground water resources at TMI, concluding that tritium in the on-site ground water is not a threat to nearby ground water sources because the Susquehanna River acts as a boundary between the island and the aquifers on the east and west shore. If that is the case, what amount of tritium is being delivered to and carried away by the Susquehanna River? What is the potential impact to the aquatic community of such delivery? Have the appropriate regulatory agencies been properly notified? (TMI-O-19)

Comment: I would be very interested in getting some biological studies of the macro-invertebrates in the area, including radiation testing. I would also like someone to look at the mussels. The mussels are very much ignored in the Susquehanna River, but throughout the United States, 70 percent of our mussel species are endangered or threatened. And the mussels are the longest living thing I believe in the river. Some mussels – we are not entirely sure how long some of them live, but some of them have been known to live 120 years. The ones that we know of in the Susquehanna live up to 40 years, and we think that testing the mussels would be a good gauge of telling radiological bioaccumulation. (TMI-J-3)

Comment: The greater number of adverse health effects from nukes occur predominantly downwind and go further than five miles, depend on atmospheric conditions and in the older plants (which now include all U.S. nukes) – case the classic mutations in flora and fauna exposed. Which includes much of the food we eat. Mutated tomatoes, yellow squash, zucchini, peaches, plums, corn, turnips and even a Heinz pickle have been grown, not only from TMI country a few other areas as well. Do you care? (TMI-H-1)

Comment: Are the existing monitoring wells adequate (appropriate locations and density) to capture any problems? Has the risk of radwaste on the island contaminating local aquifers or water supply wells been assessed? Is there any need to consider monitoring quality and quantity at some neighboring residences or businesses? (TMI-O-20)

Comment: Radioactive Liquid Waste Disposal System: There is no mention of restrictions to liquid radwaste discharge during periods of low flow. There should be an analysis of appropriate flow thresholds below which it is inadvisable to discharge radwaste. There is no discussion in the application of precautions against spills or other accidental introduction of radwaste to surface or ground water. (TMI-O-21)

Response: *NRC regulations require licensees to control and limit radioactive releases, including tritium, to the environment (the air and water) to very small amounts. As part of the NRC requirements for operating a nuclear power facility, licensees must keep releases of radioactive material into the environment during normal operations as low as is reasonably achievable (ALARA), as required by 10 CFR Part 50.36a, and comply with radiation dose limits*

Appendix A

for the public in 10 CFR Part 20. For liquid discharges from nuclear power plants, the ALARA standard is to keep the annual dose to a member of the public to no more than 3 mrem. In comparison, the annual dose to an average member of the public from background radiation is approximately 360 mrem per year. Sources of background radiation include cosmic sources, naturally occurring radioactive materials, including radon (except as a decay product of source or special nuclear material) and global fallout as it exists in the environment from the testing of nuclear explosive devices.

TMI-1 conducts a radiological environmental monitoring program (REMP) in which radiological impacts to the environment and the public around the TMI-1 site are monitored, documented, and compared to NRC standards. Exelon Generation summarizes the results of their REMP in an Annual Radiological Environmental Operating Report. The reports are publicly available on the NRC's public website. The purpose of TMI-1's REMP is to:

- Evaluate the relationship between quantities of radioactive material released from the plant and resultant radiation doses to individuals from principle pathways of exposure;
- Provide data on measurable levels of radiation and radioactive materials in the site environs;
- To verify in-plant controls for the containment of radioactive materials;
- To determine buildup of long-lived radionuclides in the environment and changes in background radiation levels;
- To provide reassurance to the public that the program is capable of adequately assessing impacts and identifying noteworthy changes in the radiological status of the environment; and
- To fulfill the requirements of the TMI-1 Technical Specifications.

The REMP samples environmental media in the environs around the site to analyze and measure the radioactivity levels that may be present. The media samples are representative of the radiation exposure pathways to the public from all plant radioactive effluents. The REMP measures direct radiation, the airborne, and the waterborne pathways for radioactivity in the vicinity of the TMI-1 site. Direct radiation pathways include radiation from buildings and plant structures and airborne material that may be released from the plant. In addition, the REMP also measures background radiation (i.e. cosmic sources, and naturally occurring radioactive material, including radon and global fallout). Thermoluminescent dosimeters (TLDs) are used to measure direct radiation. The airborne pathway includes measurements of air, precipitation, drinking water, and broad leaf vegetation samples. The waterborne pathway consists of measurements of surface water, drinking water, effluent water, storm water, ground water, and fish and sediment from the Susquehanna River.

For TMI-1, the waterborne pathway consists of Susquehanna River water, fish and invertebrates, aquatic vegetation, bottom sediment, and shoreline soil. The NRC requires that only commercially or recreationally important species in the vicinity of the discharge point be sampled and analyzed. Other species, like mussels, while present in the area, do not represent a significant dose pathway to humans and are not required to be discussed in the radiological environmental report.

The REMP provides measurements of radiation and of radioactive materials in those exposure pathways and for those radionuclides which lead to the highest potential radiation exposure to members of the public. It does not require that every type of environmental media or biota in the area be sampled and analyzed.

The results of the REMP are intended to supplement the results of the radiological effluent monitoring program by verifying that the measurable concentrations of radioactive material and levels of radiation are not higher than expected on the basis of the effluent measurements and modeling of the environmental exposure pathways. The two programs work together as a check against each other. The 2007 Annual Radiological Environmental Monitoring Report for TMI-1 can be viewed in the ADAMS Public Electronic Reading Room, at accession number ML081300255.

In addition to the routine REMP, starting in 2006, Exelon Generation implemented a ground water monitoring program at TMI-1. This monitoring program was added by Exelon Generation to assure that potential liquid release pathways were being thoroughly evaluated. The program is used to characterize any onsite contamination, to quantify and determine its potential onsite and offsite radiological impact to the workers, public and surrounding environment, and to aid in identification and repair of any leaking systems, structures, or components.

As noted in one of the comments, in September 2005, TMI-1 had a localized tritium leakage inside a utility access manway in the owner-controlled area. The highest concentration of tritium detected in one water sample from inside the manway was 45,000 picoCuries per liter. The U.S. Environmental Protection Agency's drinking water standard is 20,000 picoCuries per liter; however this water is not used for drinking. The leak was found and fixed. Sampling conducted at nearby ground water wells did not have elevated levels of tritium. State and federal officials were informed of the issue and kept updated throughout the event. A detailed discussion of the inspection performed by the NRC for this event can be found in the ADAMS Public Electronic Reading Room, at accession number ML062070664.

The radiological effluent monitoring and environmental monitoring programs are part of the NRC's routine inspection program of every nuclear power plant to ensure compliance with regulatory requirements. For license renewal, the NRC staff reviewed these areas and discussions are presented in Sections 2.1.2 and 4.8 of this supplemental EIS.

Comment: AmerGen has implemented a long-term ground water monitoring effort at TMI-1 referred to as the Radiological Ground Water Protection Program (RGPP). Prior to AmerGen's submittal of the license application to the Nuclear Regulatory Commission (NRC), DEP had requested that the licensee provide a description of the TMI-1 RGPP. Although the inclusion of this program in the license renewal application is not required by the Nuclear Regulatory Commission (NRC), AmerGen responded favorably to DEP's request. The program description, as included in the Environmental Section of the license renewal application (Appendix E), indicates that a primary purpose of the RGPP is to provide timely detection and response to any radiological releases to ground water. Based on the information provided in this document and DEP's independent review of the TMI-1 RGPP, it has concluded that AmerGen has taken appropriate measures to protect public health and safety and the environment, both during current and extended periods of TMI-1 operations. DEP will continue to monitor AmerGen's activities in this area. This effort includes frequent interactions with the TMI-1 Environmental

Appendix A

Monitoring Program staff and sampling of selected on-site monitoring wells, as deemed necessary. (TMI-N-11)

Response: *Sections 4.8 and 4.9.7 of this supplemental EIS contain the NRC staff's evaluation of the applicant's environmental monitoring program.*

Comment: DEP participated in the NRC's environmental audit of TMI-1 license renewal application during the week of April 28, 2008. At the time of the audit, DEP requested additional information regarding the Solid Waste Staging Facility (SWSF) at TMI-1. This facility is a passive system for temporary staging of radioactive waste prior to shipment to a disposal facility. The information requested by DEP includes a description of the system design, a description of the facility leak collection and monitoring systems, and a document identifying on-site monitoring wells within the SWSF area. DEP has reviewed the information provided by AmerGen and has no concerns. However, DEP staff will continue to perform on-site surveillances at the TMI site to verify the condition of the SWSF and to periodically review the sample results from the adjacent monitoring wells. (TMI-N-13)

Response: *This comment is general in nature, regarding the TMI-1 Solid Waste Staging Facility and on-site monitoring wells. The comment provided no new and significant information, and was not evaluated further.*

Comment: Have the owners of TMI-1 reassessed the National Academy of Science's statements on the harmful effects of low dose radiation exposure? After learning this from Dr. Helen Caldicott and Dr. Carl Johnson 29 years ago – the truth about the lower levels of radiation exposure has finally been realized by National Academy of Science! (TMI-H-2)

Response: *The GEIS evaluated human health issues and determined them to be a Category 1 issue. The amount of radioactive material released from nuclear power facilities is well measured, well monitored, and known to be very small. The doses of radiation that are received by members of the public as a result of exposure to nuclear power facilities are so low that resulting cancers have not been observed and would not be expected. A number of studies of cancer incidence in the vicinity of nuclear power facilities have been conducted and there are no studies to date that are accepted by the scientific community that show a correlation between radiation dose from nuclear power facilities and cancer incidence in the general public. The comments were noted but provided no new and significant information and were not evaluated further.*

A.1.8 Uranium Fuel Cycle and Waste Management

Comment: Paducah, Kentucky, talking about the – one speaker just a few minutes ago mentioned that there is no greenhouse gases released. That is not accounting for the mining and the whole fuel cycle which you would probably have to take into effect when they do an analysis, but the NRC is not going to look at that when it comes to operating this specific plant.

Paducah, Kentucky, emitted – one enrichment facility was emitting 88 percent of all United States CFC ozone-eating gas, 88 percent of all those produced gases came from that plant. That's – that was pretty bad. Fortunately they fixed some of those leaks in the refrigeration system. (TMI-A-4)

Response: *The carbon footprint of nuclear energy (including its fuel cycle) and alternative energy sources is an air quality issue. Air quality issues were evaluated in the GEIS and determined to be Category 1 issues. Although these comments do not provide any new and significant information on air quality pertaining to the relicensing of TMI-1, the carbon footprint of nuclear power versus other alternate energy sources is addressed in Chapter 8 (alternatives) of this EIS.*

Comment: Barnwell S.C. announced that it will close to generators on June 20, 2008. The NRC staff concluded that there was no new and significant information and therefore there would be no impacts of low level waste storage and disposal associated with the renewal term. The GEIS stated that, "...The maximum additional on-site land that may be required for low-level waste storage during the term of a renewed license and associated impacts will be small." TMI is located on Susquehanna River so any leaking contaminants from waste storage facilities will flow towards and eventually into the Bay. There are no monitoring wells lining the shoreline. We deserve to know what the LLRW storage plans are before the application is decided; so that the re-licensing decision does not prejudice any LLRW storage decision. Where will the LLRW going to be stored? For how long? And will the location be above the flood plain? (TMI-F-15)

Response: *The comment is related to the environmental impacts associated with Low Level Radioactive Waste Management (LLRW), which was evaluated in the GEIS and determined to be a Category 1 issue. The GEIS evaluated impacts associated with LLRW management for all plants, including TMI-1, and determined that the impact was small. During the plant-specific environmental review of TMI-1, the NRC staff reviewed the future actions planned to be taken at the TMI-1 site for the storage of LLRW (see Section 2.1.2.3) and did not identify any new and significant information that would call into the question the conclusions contained in the GEIS regarding LLRW.*

A.1.9 Postulated Accidents

Comment: A few points to address some other things that came up after I spoke. The atmospheric sciences, I saw that is part of the environmental concerns, seems to me recognition by the nuclear industry that the atmosphere is changing; that there is more energy; that global warming may be occurring. They are certainly advertising to that extent to have people view nuclear power more favorably.

And if that were true then we do need to study the fact that the weather has more energy, and tornadoes are more severe, floods are more severe. There is a trend growing. It's not hard to see that in the next 10 to 20 years there could be some serious problems with tornadoes at nuclear plants like what happened at Davis-Besse a few years ago where the control room operator said, when they went into a station blackout situation, that their hearts went into their throat until finally things started to settle down a little bit. But at first they had power problems where they couldn't even read their control panels.

So I'd like to see that issue also cross-ties in with the security issues, where the loss of off-site power and station blackout can be caused by terrorism. The same thing can happen with a tornado, and that we need redundancy systems for – to prevent station blackout. There has been some discussion of that with the security discussions, but with environmental impact

Appendix A

assessment including atmospheric sciences, I think that falls there too. So we've got to look at the floods. Don't forget, we had a bad flood in 1972, excuse me, the Agnes Flood, which flooded Three Mile Island. (TMI-A-6)

Comment: "AmerGen prepared this severe accident mitigation alternatives analysis... with support from its parent company, Exelon." In case of another accident at TMI, and since AmerGen received the support from its parent company, Exelon, will Exelon also be held liable for costs and damages to the offsite humans, fauna and flora? Based on the continuing adverse effects caused by TMI-1's brother plant, TMI-2, State, Federal, and local governments must demand accountability next time – as many failed their constituents while, while few helped. (TMI-H-5)

Comment: "Benefits, costs, and net value of implementing potential S.A.M.A.'s" – Your cost-risk benefits have never been humane – benefitting only corporate profits (as usual – the NRC's actions assist those they are to regulate instead of health and safety of those paying taxes to play their employees.) Remember Davis-Besse?

Cost-Risk benefits actually should only be for promoting and protecting the life and health of humans, flora and the planet. Corporate greed is the predominant cause of our earth in distress from global warming and also nuclear-atomic zapping! Bomb fallout and Chernobyl dust is still circling the planet and TMI mutations 29 years later are still growing – with another bumper crop this year! (TMI-H-6)

Comment: Ground Water use must be considered a significant issue due to the fact that nuclear plant uptake of water is only possible with what nature provides, and as the earthquakes in China (5/2008) caused flow of rivers to cease and become a lake instead – you must be prepared for the unexpected. Especially since TMI-1 and TMI-2 are on an earthquake fault line. Remember April 22, 1984, where the meter was set so high it didn't register the quake – but the control room operators did feel the 4.0 quake, centered in Lancaster County, under TMI and under my home as well. (TMI-H-16)

Comment: A reassessment of likely flood scenarios should be performed. The original assumptions related to the hydrology, flow patterns, and flood return intervals of the Susquehanna River are likely outdated, and certainly do not account for potential changes over the course of the extended license period due to climate change or other phenomena. (TMI-O-26)

Response: *The comments are related to the impacts of design basis accidents and severe accidents. The impacts of design basis accidents were evaluated in the GEIS and determined to be small for all plants; therefore, it is a Category 1 issue. The impact of severe accidents is a Category 2 issue and must have a site-specific evaluation. Additionally, alternatives to mitigate severe accidents must be considered for all plants that have not considered such alternatives. The applicant provided a severe accident mitigation alternatives (SAMA) analysis as part of the license renewal application for TMI-1. The NRC staff's review of the SAMA analysis is discussed in Section 5.3 and Appendix F of this supplemental EIS for TMI-1.*

A.1.10 Alternatives

Comment: Number one is conservation. Also energy created on site, on homes – not by greedy corporate energy producers. The hydrogen fuel cell home created by college students had a cost to build – but once built the cost of energy to operate the home was a big, fat zero = \$0. Antiquated machinery is currently still in use because the money goes to support and finance nukes. Ancient Greece used solar and so did Florida – until electricity came along.

The time to change was 29 years ago – you obviously did not learn the lessons – even after Chernobyl. Shut-down nuclear TMI-1, put windmills on your cooling towers, solar on your parking lots – hydro from your little dam – non-tritiated water for geothermal under your ground – waste and non-food biomass. And conservation! No more subsidies to you for your ultra-hazardous (atomic bomb making) method of energy production. But going solar is what I recommend for your future. So that our children will have a future. (TMI-H-4)

Comment: The assessment of alternatives in Chapter 7 is limited entirely to alternatives for power production in lieu of continued operation of TMI. An evaluation should also be conducted of alternatives to specific current operating practices at TMI that would allow continued generation at the plant, but with lesser impacts to the air, soil, and water resources of the region. Technology has advanced a great deal in the 40 years that have passed since the design of TMI-1, and its adoption and use on-site should be investigated as a condition of license renewal. (TMI-O-23)

Response: *The comments are related to the environmental impacts of alternatives to license renewal for TMI-1. Environmental impacts associated with various reasonable alternatives, including a combination of energy sources, conservation, coal and natural gas, to renewal of the operating licenses for TMI-1 is evaluated in Chapter 8 of this supplemental EIS.*

A.2 Comments Received on the Draft Supplemental EIS

Pursuant to 10 CFR Part 51, the staff transmitted the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants Regarding Three Mile Island Nuclear Station, Unit 1, Draft Report for Comment* (NUREG-1437, Supplement 37, referred to as the draft supplemental Environmental Impact Statement [EIS]) to Federal, State, and local government agencies, and interested members of the public. As part of the process to solicit public comments on the draft supplemental EIS, the staff:

- placed a copy of the draft supplemental EIS into the NRC's Public Electronic Reading Room, on its license renewal website, and at the Londonderry Township Municipal Building, the Middletown Public Library, and the Penn State Harrisburg Library, all in Middletown, Pennsylvania;
- sent copies of the draft supplemental EIS to the applicant, members of the public who requested copies, and certain Federal, state, and local agencies;
- published a notice of availability of the draft supplemental EIS in the *Federal Register* on December 9, 2008 (73 FR 74766);

Appendix A

- announced and held two public meetings in Harrisburg, Pennsylvania, on February 24, 2009, to describe the results of the environmental review and answer questions on the license renewal process;
- placed newspaper ads and issued press releases announcing the issuance of the draft supplemental EIS, the public meetings, and instructions on how to comment on the draft supplemental EIS; and
- established an email address to receive comments on the draft supplemental EIS through the Internet.

During the comment period, the staff received a total of nine comment letters and emails in addition to the comments received during the public meetings.

The staff has reviewed the public meeting transcripts and the comment letters that are part of the docket file for the application, all of which are available in the NRC's Public Document Room. This section of Appendix A contains a copy of each commenter's submission(s) during the comment period. For those that provided oral comments at the February 24 meetings, comments are taken from the meeting transcripts. Note that only comments from those transcripts are included in this document; however, the complete meeting transcripts can be accessed online or in-person from ADAMS at accession numbers ML090680558 and ML090680578.

Comment letters and emails are also available online in ADAMS. A cross-reference of the speaker or author of the comment, their affiliation (if stated), the comment source, the page where the start of the comment can be found, and the ADAMS accession number of the comment is provided in Table A-2.

Table A-2. Commenters on the Draft Supplemental EIS. *Commenters are identified in alphabetical order.*

Commenter	Affiliation	Comment Source	Page Number	ADAMS Accession Number
Marjorie Aamodt	Citizen	Email	A-20	ML090840462
Holly Angelic	Local citizen	Afternoon Meeting	A-25	ML090680558
Michael T. Chezik	U.S. Department of Interior	Letter	A-27	ML090840544
Andrew Dehoff	Susquehanna River Basin Commission	Afternoon Meeting	A-30	ML090680558
Eric Epstein	TMI Alert	Evening Meeting; Letter	A-31	ML090680578 ML090680388
Michael P. Gallagher	Exelon Generation Company, LLC	Letter	A-46	ML090680038

1

Commenter	Affiliation	Comment Source	Page Number	ADAMS Accession Number
Gregory H. Hanlon	FirstEnergy Corporation	Email	A-53	ML090840664
Judith Johnsrud	Sierra Club; Environmental Coalition on Nuclear Power	Evening Meeting	A-53	ML090680578
Thomas C. LeCrone	Local citizen	E-mail	A-55	ML090840537
Diane Little	Local citizen	Afternoon Meeting	A-56	ML090680558
Kevin Magerr	U.S. Environmental Protection Agency	Letter	A-60	ML090750180
Mary Osborn Ouassiai	Concerned Mothers; TMI Alert	Evening Meeting; Letter	A-62	ML090680578 ML090680766
Laura Piraino	Sierra Club	Evening Meeting	A-71	ML090680578
Scott Portzline	TMI Alert	Afternoon Meeting; Evening Meeting	A-71	ML090680558; ML090680578
Joyce Scott	Harrisburg Diocese and Council of Catholic Women	Afternoon Meeting	A-76	ML090680558
Linda Spears	(no affiliation stated)	E-mail	A-77	ML090840665
Karen Walsh	Pennsylvania Energy Alliance	Afternoon Meeting	A-77	ML090680558

A.2.1 Individual Comments and Responses

There was no significant new information provided on Category 1 issues, or information that required further evaluation on Category 2 issues. Therefore, the conclusions in the GEIS and draft supplemental EIS remained valid and bounding, and no further evaluation was performed. Comments without a supporting technical basis or without any new information are discussed in this appendix, and not in other sections of this report. Relevant references that address the issues within the regulatory authority of the NRC are provided where appropriate. Many of these references can be obtained from the NRC Public Document Room.

Appendix A

Where the comment or question resulted in a change in the text of the draft report, the corresponding response refers the reader to the appropriate section of this report where the change was made. Revisions to text in the draft report are designated by vertical lines beside the text.

Committer: Marjorie Aamodt, citizen

Re: Application submitted by AmerGen Energy Company, LLC to renew operating license for Three Mile Island Nuclear Station, Unit 1 for an addition twenty (20) years past year April, 2014.

Upon reading the U.S. Nuclear Regulatory Commission's preliminary assessment, Draft NUREG-1437, I find that you have not considered or adequately considered the following:

- (1) The five mile area population at the time of the 1979 accident at Unit 2 was identified by the Pennsylvania Department of Health and the Centers for Disease Control to be followed for the following twenty (20) years as their health status which was to be considered as decisive concerning the impact the accident had on human health, if any. The bottom-line is that the life-expectancy of people living within five miles of the TMI accident has been shortened as compared to vital statistics for the three counties adjacent to TMI. During the same time period, national life span increased six years. Incredibly the researcher did not appreciate the significance of her finding of shorter life expectancy for those living closest to the TMI accident whereas it is well-known to radiation biologists that shortened life span of a population is an expected result of exposure to ionizing radiation. (Talbot, Evelyn O. et al. Long Term Follow-Up of the residents of the Three Mile Island Accident Area: 1979-1998, 30 October 2002.
- (2) Clearly, the people living near TMI are continuously impacted by ionizing radiation already released to the environment since limited sampling found tritium in just about everything sampled. To disregard this exposure because the source "could not be directly attributed to TMI-1"* is not a responsible assessment of their environmental impact. (*Draft NUREG-1437, Supp.37, p.4-29)
- (3) Furthermore, the REMP program (Radiological Environmental Monitoring Program) takes far too few samples to disprove far higher concentrations of radioactivity, for instance "21 milk samples collected in 2007" and "26 food product samples". The fact that "11" of those milk samples and "24" of the food product samples contained Strontium-90 should be sufficient to move the NRC to prevent any further exposure due to the repair and continued operation of the TMI-1 reactor. It does not matter if the radiation in those food samples "could be attributed to residual fallout from weapons testing", the concentrations in the food supply of TMI area residents only shows that they are a population already impacted by exposure to ionizing radiation in their food supply and should not be additionally exposed by continued operation of the TMI-1 reactor. (Quotes, Id. 4-30)
- (4) Your analysis of the hazards of radon-222 is informative. This gas decays to "particulate radioactive nuclides that give off high energy alpha particles. These radioactive particles are inhaled and remain lodged in the lungs, causing continued exposure."* Isn't that what happens when particulate radioactive nuclides are routinely released from an operating nuclear power plant and are taken in by breathing or by eating food containing these particles which release not only alpha radiation but beta, gamma and X-rays directly to the cell? (* Id. 8-28)

(5) Lastly, I am amazed by the continued oversight of the inadequacy of a ten-mile emergency planning zone. In or around 1985, a study undertaken by the Three Mile Island Public Health Fund showed that emergency planning around TMI had to be for the twenty mile radius due to the unique topography. I am referring to a study made at Clark University, which was published in book form and was to be placed in the TMI area libraries.

(6) Whereas, the current owners are apparently addressing the matter of intrusion of terrorists on foot, are you satisfied that the health and safety of TMI area residents are protected from crash of a commercial airline due to terrorists' activity? Of course, you cannot be.

(7) My husband and I have great interest in the decision you are making. We have friends and family who have remained in Pennsylvania. We visit them on a regular basis and have considered returning to live in central Pennsylvania. We left our home near Coatesville, Pennsylvania simply due to the insensitivity of the majority of the Commissioners to the suffering of residents we uncovered in three communities in York County where cancer deaths rose to more than six times the expected number during within six years following the accident. We surveyed those neighborhoods after we learned on the occasion of a fifth-anniversary forum in Middletown that many residents had symptoms of acute radiation illnesses during the accident. Whereas correlation does not always indicate causation, in this instance it clearly did as follow-up studies at Columbia University and at the University of North Carolina, both studying the ten mile area population found significant increases in cancer incidence, and the latter study related the incidence to the relative distribution of accident radiation.

(8) I am heartened by your comprehensive address of the alternative sources for generating electricity. The people of central Pennsylvania can have electricity and jobs without incurring additional exposure to ionizing radiation.

I am hoping that your concern for the people of central Pennsylvania who have been exposed to fallout from weapons testing, routine releases from TMI-1 and TMI-2, the TMI and Chernobyl accident releases of potentially as many as 500 different kinds of radionuclides*, clean-up releases, and work-place clean-up and daily exposures of workers and of family by worker, will lead both the NRC and AmerGen to deny re-licensing of TMI-1. (*Kocker)

Response:

Ms. Aamodt's concerns include health effects of the following: the 1979 TMI Unit 2 accident; continued operation of TMI-1; and background radiation from fallout from weapons testing and the Chernobyl accident; and the potential crash of an aircraft into TMI-1. Ms. Aamodt also expresses approval of the analysis of alternatives presented in Chapter 8.

Comments regarding TMI Unit 2 and the radiological impact of the 1979 accident do not pertain to the scope of the TMI-1 license renewal review and were not evaluated further. TMI Unit 2 has been defueled and decontaminated to the extent the plant is in a safe, inherently stable condition suitable for long-term management. Additional information on TMI Unit 2 can be found on the NRC's public website: <http://www.nrc.gov/reading-rm/doc-collections/fact-sheets/3mile-isle.html>.

Regarding Ms. Aamodt's comments numbers (1), (2), (7), and (8), the staff acknowledges the articles and information provided, but they do not provide scientifically defensible information

Appendix A

that would cause the NRC to alter its position that the current radiation protection safety standards are protective of public health and safety and the environment.

The NRC's primary mission is to protect the public health, safety and the environment from the effects of radiation from nuclear reactors, materials, and waste facilities. The NRC's regulatory limits for radiological protection are set to protect workers and the public from the harmful health effects of radiation on humans. The limits are based on the recommendations of standards-setting organizations. Radiation standards reflect extensive scientific study by national and international organizations (International Commission on Radiological Protection [ICRP], National Council on Radiation Protection and Measurements [NCRP], and the National Academy of Sciences [NAS]) and are conservative to ensure that the public and workers at nuclear power plants are protected.

Health effects from exposure to radiation are dose-dependent, ranging from no effect at all to death. Above certain doses, radiation can be responsible for inducing diseases such as leukemia, breast cancer, and lung cancer. Very high (hundreds of times higher than a rem), short-term doses of radiation have been known to cause prompt (or early, also called "acute") effects, such as vomiting and diarrhea, skin burns, cataracts, and even death.

Although radiation may cause cancers at high doses and high dose rates, currently there are no reputable scientifically conclusive data that unequivocally establish the occurrence of cancer following exposure to low doses and dose rates, below about 0.1 Sievert (10 rem). However, radiation protection experts conservatively assume that any amount of radiation may pose some risk of causing cancer or a severe hereditary effect and that the risk is higher for higher radiation exposures. Therefore, a linear, no-threshold dose response relationship is used to describe the relationship between radiation dose and detriments such as cancer induction. Simply stated, any increase in dose, no matter how small, results in an incremental increase in health risk. This theory is accepted by the NRC as a conservative model for estimating health risks from radiation exposure, recognizing that the model probably over-estimates those risks.

Based on this theory, the NRC conservatively establishes limits for radioactive effluents and radiation exposures for workers and members of the public, as found in 40 CFR Part 190, Environmental Radiation Protection Requirements for Normal Operations in the Uranium Fuel Cycle, 10 CFR Part 20, Standards for Protection Against Radiation, and 10 CFR Part 50, Appendix I, Domestic Licensing of Production and Utilization Facilities, Numerical Guides For Design Objectives and Limiting Conditions for Operation to Meet the Criterion "As Low As is Reasonably Achievable" For Radioactive Material In Light-Water-Cooled Nuclear Power Effluents.

*Regulatory limits are placed on the radiation dose that members of the public might receive from all of the radioactive material released by the nuclear plant combined. Licensees are required to report liquid, gaseous, and solid effluent releases as well as the results of their radiological environmental monitoring program annually to the NRC. The annual effluent release and radiological environmental monitoring reports submitted to the NRC are available to the public in the ADAMS electronic reading room available through the NRC website:
<http://www.nrc.gov/reading-rm/adams.html>.*

The amount of radioactive material released from nuclear power facilities is well measured, well monitored, and known to be very small. The doses of radiation that are received by members of the public as a result of exposure to nuclear power facilities are so low that resulting cancers have not been observed and would not be expected. Although a number of studies of cancer incidence in the vicinity of nuclear power facilities have been conducted, there are no studies to date that are accepted by the scientific community that show a correlation between radiation dose from nuclear power facilities and cancer incidence in the general public. Specific studies that have been conducted include:

- In 1990, at the request of Congress, the National Cancer Institute conducted a study of cancer mortality rates around 52 nuclear power plants and 10 other nuclear facilities. The study covered the period from 1950 to 1984, and evaluated the change in mortality rates before and during facility operations. The study concluded there was no evidence that nuclear facilities may be linked causally with excess deaths from leukemia or from other cancers in populations living nearby.*
- In June 2000, investigators from the University of Pittsburgh found no link between radiation released during the 1979 accident at TMI Unit 2 and cancer deaths among nearby residents. Their study followed 32,000 people who lived within five miles of the plant at the time of the accident.*
- In 2000, the Illinois Public Health Department compared childhood cancer statistics for counties with nuclear power plants to similar counties without nuclear plants and found no statistically significant difference.*
- In January 2001, the Connecticut Academy of Sciences and Engineering issued a report on a study around the Haddam Neck nuclear power plant in Connecticut and concluded radiation emissions were so low as to be negligible.*
- The American Cancer Society in 2001 concluded that although reports about cancer clusters in some communities have raised public concern, studies show that clusters do not occur more often near nuclear plants than they do by chance elsewhere in the population. Likewise, there is no evidence that links Strontium-90 (Sr-90) with increases in breast cancer, prostate cancer, or childhood cancer rates. Radiation emissions from nuclear power plants are closely controlled and involve negligible levels of exposure for nearby communities.*
- Also in 2001, the Florida Bureau of Environmental Epidemiology reviewed claims that there are striking increases in cancer rates in southeastern Florida counties caused by increased radiation exposures from nuclear power plants. However, using the same data to reconstruct the calculations on which the claims were based, Florida officials were not able to identify unusually high rates of cancers in these counties compared with the rest of the State of Florida and the nation.*

To ensure that the plants are operated safely within these requirements, the NRC licenses the plants to operate, licenses the plant operators, and establishes technical specifications for the operation of each plant. The NRC provides continuous oversight of plants through its Reactor Oversight Process (ROP) to verify that they are being operated in accordance with NRC rules and regulations. The NRC has full authority to take whatever action is necessary to protect

Appendix A

public health and safety and may demand immediate licensee actions, up to and including a plant shutdown.

The NRC has issued regulations establishing clear requirements for license renewal to assure safe plant operation for extended plant life (codified in 10 CFR Parts 51 – Environmental Protection Regulations For Domestic Licensing and Related Regulatory Functions and 54 – Requirements For Renewal of Operating Licenses For Nuclear Power Plants). An applicant must provide the NRC with an evaluation that addresses the technical aspects of plant aging and describes the ways those aging effects will be managed. The applicant must also prepare an evaluation of the potential impact on the environment if the plant operates for up to an additional 20 years. During the review of the application for license renewal the NRC staff verifies the safety evaluations through inspections and reviews environmental issues associated with license renewal. The NRC staff has not identified any new and significant information during its independent review of the TMI-1 Environmental Report, Annual Radioactive Effluent Release reports, Annual Radiological Environmental Operating reports, and during the environmental site audit.

The NRC has already fully considered and addressed these issues and the comments do not present any significant new information or arguments that would warrant a change to the TMI-1 supplemental EIS.

Regarding Ms. Aamodt's comment number (3), the NRC requires every nuclear power plant to conduct a radiological environmental monitoring program (REMP) to monitor the environment around its facility for radioactivity released during operation. Various types of sample media (air, water, and food products) are collected in order to measure and evaluate the levels of radioactive material in the environs around the plant site to assess the radiological impacts, if any, of plant operation on the environment. The program is a check on the radiological effluent monitoring program to verify that the levels of radioactive materials in the environment are not higher than expected based on data from the radiation monitors at the plant's effluent release points. The REMP data is used to demonstrate compliance with NRC's reporting criteria for environmental samples. The NRC performs periodic inspections of every nuclear power plant's REMP to verify their compliance with NRC's radiation protection standards. The REMP performed at TMI-1 is conducted in accordance with NRC criteria.

Regarding Ms. Aamodt's comment number (4), the radioactive effluents discharged from nuclear power plants do contain radionuclides that during their radioactive decay process, give off alpha, beta, and gamma radiation. The particulates, if inhaled or ingested will result in a radiation dose to the individual. All nuclear plants were licensed with the expectation that they would release radioactive material to both the air and water during normal operation. Airborne and liquid releases of radionuclides from nuclear power plants must meet radiation dose-based limits specified in 40 CFR Part 190, 10 CFR Part 20, and the "as low as is reasonably achievable" (ALARA) criteria in 10 CFR Part 50, Appendix I. Regulatory limits are placed on the radiation dose that members of the public might receive from all of the radioactive material released by the nuclear plant. The NRC performs periodic inspections of every nuclear power plant to verify their strict compliance with NRC's radiation protection standards.

The NRC has already fully considered and addressed these issues and Ms. Aamodt's comments regarding radiological impacts of TMI-1 do not present any significant new information or arguments that would warrant a change to the TMI-1 supplemental EIS.

Regarding Ms. Aamodt's comment number (5) concerning the 10-mile emergency planning zone (EPZ): To facilitate a preplanned strategy for protective actions during an emergency, there are two EPZs around each nuclear power plant. The exact size and shape of each EPZ is a result of detailed planning which includes consideration of the specific conditions at each site, unique geographical features of the area, and demographic information. The plume exposure pathway EPZ has a radius of about 10 miles from the reactor site. Predetermined protective action plans are in place for this EPZ and are designed to avoid or reduce dose from potential exposure to radioactive materials. These actions include sheltering, evacuation, and the use of potassium iodide where appropriate. The ingestion exposure pathway EPZ has a radius of about 50 miles from the reactor site. Predetermined protective action plans are in place for this EPZ and are designed to avoid or reduce dose from potential ingestion of radioactive materials. These actions include a ban of contaminated food and water.

The Commission considered the need for a review of emergency planning issues in the context of license renewal during its rulemaking proceedings on 10 CFR Part 54, which included public notice and comment. As discussed in the Statement of Considerations for rulemaking (56 FR 64966), the programs for emergency preparedness at nuclear plants apply to all nuclear power plant licensees and require the specified levels of protection for each licensee regardless of plant design, construction, or license date. Requirements related to emergency planning are in the regulations at 10 CFR 50.47 and Appendix E to 10 CFR Part 50. These requirements apply to all operating licenses and will continue to apply to plants with renewed licenses. Through its standards and required exercises, the Commission reviews existing emergency preparedness plans throughout the life of any plant, keeping up with changing demographics and other site-related factors. Therefore, the Commission has determined that there is no need for a special review of emergency planning issues in the context of an environmental review for license renewal. The comment provides no new information, and does not pertain to the scope of license renewal under 10 CFR Part 51 and Part 54. No changes were made to the supplemental EIS.

Regarding Ms. Aamodt's comment number (6), concerning the impacts of an aircraft collision at TMI-1: the NRC's environmental review is confined to environmental matters relevant to the extended period of operation as requested by the applicant. Appropriate safeguards and security measures have been incorporated into the site security and emergency preparedness plans. Any required changes to emergency and safeguards contingency plans related to terrorist events will be incorporated and reviewed under the operating license—independent of license renewal. The comment provides no new information and does not pertain to the scope of license renewal under 10 CFR Parts 51 and 54. No changes were made to the supplemental EIS. Further discussion of aircraft impacts can be found on page A-58.

Commenter: Holly Angelic, local citizen

My name is Holly Angelic. I'm a resident of Middletown. But I'm wondering if there are any opportunities to other communities that are equally affected, like Goldsborough on the other side of the river, to also offer public comments. Or do they have to come all the way here? It

Appendix A

concerns me in terms of public participation and public comments. It seems that they are left out of this process or have been for this long. That's one of my questions. Just that everybody gets a chance to participate, the people of Goldsborough and the west shore are getting the public announcements, that's one of my questions.

I have a couple more too if we're just waiting for Scott. My quick question then before Scott comes back is, in a scoping meeting that I went to there was a lot of discussion about Unit 2. And, even though the NRC doesn't have to include Unit 2 in their environmental impact assessment, I'm wondering if they have done anything and to sort of follow up on the issue of the aircraft, the structure that's housing all that radioactivity, if the NRC has looked at that at all, even though they haven't had to.

Response:

The NRC placed ads in the Middletown Press and Journal, the York Daily Record and the York Sunday News, the Lancaster Intelligencer Journal, the Harrisburg Patriot-News, and the Sun Newspaper for the May 2008 scoping meetings, and the York Daily Record, the Lancaster Intelligencer Journal, and the Harrisburg Patriot-News for the February 2009 draft supplemental EIS meetings. The NRC typically chooses meeting locations that are close to the plant and easily accessible to the majority of the population surrounding the plant. The NRC realizes Goldsboro and communities west of the Susquehanna River had to travel a farther distance to reach the May 2008 and February 2009 meetings in Middletown and Harrisburg than those that live east of the river. However, comments on the scope of the environmental review and on the draft supplemental EIS were accepted via mail, email or telephone, and carried equal weight as those submitted in person at the public meetings. By placing ads in the local newspapers the NRC attempted to reach the general population surrounding the plant that is served by these news outlets.

TMI Unit 2 is discussed in Sections 2.2.9.2 and 4.9.6 regarding the historical significance of the site, and in Section 4.11.4, where TMI Unit 2 (along with Peach Bottom Atomic Power Station) is included in the discussion of cumulative human health impacts. Section 4.11.4 states that controlled radioactive discharges from TMI Unit 2 are a very small fraction of the radioactivity released from TMI-1, and the calculated radiation dose to members of the public from all radioactive material released from the TMI-1 site are well within NRC's radiation safety limits. No additional analyses regarding TMI-2 were done during the license renewal review of TMI-1.

Commenter: Michael T. Chezik, U.S. Department of the Interior



IN REPLY REFER TO:

United States Department of the Interior

OFFICE OF THE SECRETARY
Office of Environmental Policy and Compliance
Custom House, Room 244
200 Chestnut Street
Philadelphia, Pennsylvania 19106-2904



March 3, 2009

ER08/1285

Chief Rulemaking, Directives Editing Branch
U.S. NRC
Mail Stop T6-D59
Washington, D.C. 20555-0001

RE: Draft Generic Environmental Impact Statement, NUREG-1437, Supplement 37, for the License Renewal of Three Mile Island Nuclear Station, Unit 1; Dauphin County, Pennsylvania.

Dear Sir / Madame:

The Department of the Interior (Department) has reviewed the above-referenced Notice, dated December 9, 2008, regarding Three Mile Island Nuclear Station located in Londonderry Township, Dauphin County, Pennsylvania. AmerGen, LLC, proposes to renew its license to operate a nuclear power project at the existing Three Mile Island Nuclear Station.

The following comments are provided pursuant to the Endangered Species Act of 1973 (87 Stat. 884, as amended; 16 U.S.C. 1531 *et seq.*) to ensure the protection of federally listed endangered and threatened species, and the Fish and Wildlife Coordination Act (48 Stat. 401, as amended; 16 U.S.C. 661 *et seq.*) to ensure protection of other fish and wildlife resources.

FEDERALLY LISTED SPECIES

Except for occasional transient species, no federally listed or proposed, threatened or endangered species under our jurisdiction are known to occur within the project impact area. Therefore, based on currently available information, no biological assessment or further consultation under the Endangered Species Act is required with the Fish and Wildlife Service. Should project plans change, or if additional information on listed or proposed species becomes available, this determination may be reconsidered.

BALD EAGLE

Bald eagles are known to occur in the vicinity of the Three Mile Island facility. Although the bald eagle has been removed from the federal *List of Endangered and Threatened Wildlife*, and is therefore no longer protected under the Endangered Species Act, it continues to be protected under the Bald and Golden Eagle Protection Act (Eagle Act) and the Migratory Bird Treaty Act (MBTA). Both acts protect bald eagles by prohibiting killing, selling or otherwise harming

eagles, their nests or eggs. The Eagle Act also protects eagles from disturbance. "Disturb" means to agitate or bother a bald or golden eagle to a degree that causes, or is likely to cause, based on the best scientific information available, 1) injury to an eagle; 2) a decrease in its productivity, by substantially interfering with normal breeding, feeding, or sheltering behavior; or 3) nest abandonment, by substantially interfering with normal breeding, feeding, or sheltering behavior.

On June 4, 2007, the Service released several important documents related to the protection of bald eagles under the Eagle Act, including 1) a final rule establishing a regulatory definition of "disturb"; 2) a final environmental assessment of the "disturb" regulation; 3) *National Bald Eagle Management Guidelines*; and 4) a proposed rule to establish a permit for the take of bald and golden eagles. The proposed rule would establish regulations for issuing permits to take bald and golden eagles where the take is associated with, and not the purpose of, otherwise lawful activities. A second permit type would provide for permits to take bald and golden eagle nests for safety emergencies (of humans or eagles). All of these documents can be found at <http://www.fws.gov/migratorybirds/baldeagle.htm>.

A bald eagle nest is located approximately three miles northwest from the Three Mile Island facility. In addition, bald eagles are continuing to expand their breeding range along the Susquehanna River, and therefore may be found in previously undocumented locations near the facility. Consequently, we recommend that the applicant carefully evaluate the project type, size, location and layout in light of the *National Bald Eagle Management Guidelines* to determine whether or not bald eagles might be disturbed as a direct or indirect result of this project. If it appears that disturbance may occur, we recommend that the applicant consider modifying the project to be consistent with the *Guidelines*. If the applicant has questions about when and how to obtain a permit because he or she believes that the proposed project will disturb bald eagles, and he or she is not able to implement measures to avoid disturbance, please contact the Fish and Wildlife Service Migratory Bird Permit Program at 413-253-8643 or permitsr5mb@fws.gov.

Lastly, the applicant should incorporate state-of-the art methods to prevent raptor electrocution and collisions (see *Suggested Practices for Avian Protection on Power Lines: the State of the Art in 2006*, available from the Avian Power Line Interaction Committee at <http://www.aplic.org>). Siting new power lines as far as possible from known eagle nests would help reduce the electrocution/collision risk, as would equipping existing or new lines with features that would prevent raptor electrocution and collisions.

SPECIFIC COMMENTS

Section 2.2.7 Threatened and Endangered Species and Section 4.7 Threatened or Endangered Species. The DEIS (pages 4-8 and 4-9) indicates that the osprey (*Pandion haliaetus*) is one of the eleven State-listed threatened or endangered species that have been determined to be species of special concern for the TMI-1 site of the license renewal project. The DEIS (pages 4-8 and 4-9) states that mitigation measures for the osprey (and other species) currently in place at the TMI-1 site include nest construction and placement, and that "these current mitigation measures are found to be adequate." However, in a previous section, the DEIS contradicts this conclusion, claiming (page 2-40) that nesting relocation efforts by the State-listed, threatened osprey (*Pandion haliaetus*) have been unsuccessful, citing AmerGen

(2008) as the reference. It would benefit the public for the final EIS to include more specific information as to why such relocation efforts may not be successful, and include the results of scientific studies on such efforts, such as the undated US Geological Survey (USGS) citation which indicates that "ospreys typically pair for life and use the same nest site in successive years." The USGS reference also includes other relevant information and cites several additional references that may be useful in the analyses and evaluation of proposed mitigation measures to be included in the final EIS, such as studies which indicate that "Colonies [of ospreys] may arise in secure areas such as islands or lakes, but most pairs tend to be solitary nesters, separated from other nests by tens to hundreds of kilometers (McVey et al., 1993)." Available scientific information regarding nesting relocation measures would be important considerations for identifying appropriate mitigation measures and measuring the severity of the impact from the proposed project.

Table 2-6, pages 2-41 through 2-49. The correct designation in the footnote on page 2-49 for a State-listed threatened species should be "PT" and not "ST" as currently listed.


Section 2.4 References, page 2-76. The link to the U.S. Fish and Wildlife Service (2008a) citation (for ospreys) is not correct. The correct link should read as follows:
<http://www.fws.gov/chesapeakebay/osprey.html>.

Conclusions

The applicant should be directed to clarify or gather additional information on the questions identified above. This may entail conducting appropriate field studies to obtain site-specific information. We also ask that the Commission continue to coordinate with the Fish and Wildlife Service throughout the license renewal process.

Thank you for the opportunity to review and comment on this Draft Environmental Impact Statement. If you have any questions regarding this matter, please contact Lloyd Woosley of the USGS Environmental Affairs Program at (703) 350-8797, or Jennifer Kagel of the U. S. Fish and Wildlife Service's Pennsylvania Field Office at 814-234-4090.

Sincerely,



Michael T. Chezik
Regional Environmental Officer

Response:

The comments from the U.S. Department of Interior (DOI) state that based on currently available information, no biological assessment or further consultation with the U.S. Fish and Wildlife Service is necessary for the TMI-1 license renewal review under the Endangered Species Act. The letter moves on to state that a bald eagle nest is located approximately 3 miles northwest from TMI-1, and recommends that Exelon Generation evaluate future projects in light of the National Bald Eagle Management Guidelines to determine whether eagles may be disturbed. DOI also recommends that the applicant equip existing powerlines with features that would prevent raptor electrocution and death.

Section 2.2.7.2 Terrestrial Species has been edited to include information regarding osprey nesting habits, as described in the undated USGS online publication. The footnote in Table 2-6, Listed Aquatic and Terrestrial Species, has been corrected to reflect "Pennsylvania Threatened" versus "State Threatened." The U.S Fish and Wildlife Service 2008a reference has also been corrected.

Commenter: Andrew Dehoff, Susquehanna River Basin Commission

Thank you. My name is Andrew Dehoff. I'm the Director of Planning and Operations at the Susquehanna River Basin Commission. First off, in looking through the draft EIS, it seems that NRC has addressed most of the concerns that SRBC raised in the scoping process. And we're thankful for that. However, I do have a few comments.

We'll start with two minor comments about specific points in the EIS. First, some information that SRBC supplied regarding an invasive species, Zebra Mussels, indicated that they were only present in the headwaters of New York and the Great Bend portion of the Susquehanna River and Pennsylvania. Unfortunately, later in 2008 they were discovered at the Conowingo Dam in Maryland. So we can provide some updated information to you regarding that.

Second, the storage volumes that were cited as needed to mitigate for TMI's consumptive use during a drought were unfamiliar to us. We're not sure what the source of those were. And we'd just like the opportunity to discuss them with Exelon or NRC, where they came from.

Finally, a general comment. As you might guess, SRBC's main concern is related to withdrawals of water from the river. And, I'd like to comment on NRC's finding in Section 3.1 and Table 411 that conclude that the refurbishment and continued operations of the plant pose a small impact to the surface waters of the basin. The conclusion seems to be predicated on Exelon's compliance with SRBC's regulatory programs. While we appreciate NRC's confidence in our programs, we do hope that you'll remain involved in matters related to the potential impacts to the resources of the river, particularly as they relate to the upgrades and continued operations and cumulative impacts.

I am pleased to report that Exelon has recently submitted an application to SRBC for plant modifications related to replacement of the steam generators and also submitted information related to continued use of onsite wells. Exelon also indicated their intent to submit all appropriate applications for groundwater withdrawal, surface water withdrawal and consumptive water use by March 13th, at which time SRBC staff can begin its technical review.

In summary, we anticipate full cooperation from Exelon regarding those applications. And we look forward to continued coordination with NRC Staff. Thank you.

Response:

Section 2.2.5, Description of Aquatic Resources, has been updated to reflect that zebra mussels were discovered at the Conowingo Dam in 2008. The NRC could not find a reference for the figure of 4,250 acre-feet used in discussions of the Cowanesque Lake water storage project in Sections 4.3.2 Ground Water Use Conflicts and Section 4.4.1 Water Use Conflicts in the draft supplemental EIS. This figure has been removed from the final supplemental EIS text. The removal of the figure has not caused any change in the conclusions for this section.

Mr. Dehoff and SRBC express concern that the NRC's conclusions in Chapter 4 regarding water use are predicated on Exelon Generation's compliance with SRBC regulations. The NRC is pleased that during the license renewal review SRBC identified areas where Exelon Generation needed to modify their existing ground water withdrawal, surface water withdrawal, and consumptive use permits for the operation of TMI-1 and the planned refurbishment activities. The NRC will continue to work collaboratively with SRBC regarding water use and operating issues at existing plants, and the siting of potential new units, in the Susquehanna River basin.

Commenter: Eric Epstein, TMI Alert

Evening Meeting

Eric Epstein, Three Mile Island Alert. I've been around a while. I now have gout and I'm bald and fat. And I don't really care what people think what I have to say. And that's sad, because this is actually my third re-licensing proceeding. I think more than anybody else in America I've probably been intermittently involved with three processes that, frankly, I think have little to no value.

I read the entire GEIS. I'm not normally a big fan of fiction, but I did read it. I was going to offer comments to telling issues. These were my comments. I'm not going to submit them. It won't matter. It really won't matter. I read the entire document as I read the entire document at Peach Bottom, as I read the entire document at Susquehanna and it had no value.

The only thing I'm going to formally enter -- and I'll give it to you, Sarah -- is on your chronology of environmental review, there were 14 correspondences that you missed, among other things.

My comments tonight actually have very little to do with the re-licensing of Three Mile Island. I think Exelon is a smart company. They are a strategic company. If I were them I would try to re-license TMI -2. Frankly, TMI-2 would get through. I'm just telling you. And I said the same thing before in May. By the way, to the police, relax. Hopefully you're getting overtime for this. I have no idea why you're here. But relax and enjoy the evening. Actually, my neighbor could have used you the other night, they had a domestic issue.

TMI re-licensing, as with the re-licensing of every nuclear power plant, is a done deal. It's a smart move for Exelon. It doesn't cost a lot of money. In fact, the next generation of nuclear power plants is where the existing generation is. It's a smart move. They'd be nuts not to do it. In fact, that's why we didn't oppose or challenge re-licensing. In fact, that's why I settled with

Appendix A

Exelon. It made more sense. I'm here tonight, frankly, to congratulate the Nuclear Regulatory Commission on a job well done.

You know, from my experience, and I'm still involved in the re-licensing process at Susquehanna, the process is designed to fast track and approve, much better than you did the first time around, minimize public input, put a smiley face on a nuclear bail-out. You guys are doing a good job. Frankly, it's amazing. Because we litigate, intervene, that's TMI Alert. Before the EHB, before DEP, before the PUC.

You should really take a page from Pennsylvania public participation. They do, I think, a much better job. On a solemn note, I was just looking for answers to the 50 questions I submitted on May 1st. I don't think I'm ever going to get responses. Based on my experiences in re-licensing, what happens is you put a question in and what comes back, it's bizarre. You don't get your question back. You get this generic format. And then there's some response at the end that bears no relation to the question. You may want to work on that.

I did find some issues here. But what I'm going to do is just go through the process that I experienced as a human being, trying to offer input and comments on re-licensing.

Back on March 25th I contacted Sarah Lopas. And I said, I asked -- I kept all my notes because I'm anal and have no social life. And I asked for responses to questions that I was going to submit on May 1st. And she got back to me that day. And this was her response. She replied quickly. It was great. I will do my best to answer any of the environmental license renewal questions regarding TMI-1 or any questions you might have on the license renewal process in general regarding consumptive water use, groundwater monitoring, bio-fuel control of the circulating water system, da, da, da, da.

I was really getting into it and encouraged. So I can't make any definitive statements until December until we tentatively plan to publish the draft. And then she outlined the scoping period. And I thought initially, wow, this is pretty cool. We're getting off to a better start. I made initial contact with the representative from the NRC who, by the way, came to visit in Harrisburg.

And we had established a dialogue. So far so good. Not really. Not really. If you look hard, and I did when I read this, you can see how the NRC altered the intent in the content of my questions and then they melded them into a response. It's like this massaged composite format. I've never seen anything like it before. But you have to squint real hard, otherwise you miss it. And I'll give you an example.

One example, I spent a lot of time submitting really well defined and researched questions relating to invasive species, which is a problem not just for nuclear power plants, but for all power plants on the Susquehanna River. You'd have to get out your microscope, but you might find actually a reference to our questions on Asiatic clams and zebra mussels. Actually, if you want to and you have nothing else to do, and you want to join me in not having a life, you would go to 2.3, 2.32 and 2.3 -- you'd have to look hard. And then if you go back to the question we asked, I thought it was right on. By the way, the question is listed on A-5 of the appendix with no response. However, I persisted.

There's only one issue, frankly, after we settled with Exelon, that I really cared about more than any other issue, and that's emergency planning. And I think that should be obvious by what we've done at the NRC.

The EJ person, which I guess is your Environmental Justice person, which is really interesting because the NRC's definition of environmental justice bears no relation to DEP's definition of environmental justice. Just for shits and giggles I'll read you -- sorry, strike it, don't strike it, I don't care. Environmental Justice to the DEP is the fair treatment and meaningful involvement of all people, regardless of race, color, national origin or income with respect to the development of implementation.

I wrote a letter to Sarah. And she wrote back. She said he -- I guess there's some buddy named Jeff Rikhoff who I never met, who never contacted me, and apparently I'm never going to hear from him. He wasn't coming to the meeting on Thursday. And you were very nice. She said, I apologize for that, he has been CC'd on the email. I will ask him to give you a call to discuss this week.

That was May 5th, never heard from him. My phone number has been the same. The address remains the same. The bill collectors find me. My ex-wife finds me, he can find me. Hard to miss.

Since the NRC'S socioeconomic designant, Mr. Rikhoff, did not attend the May 1st meeting I followed up with Ms. Lopas and requested a meeting with the NRC representative on socioeconomic impacts.

Again, this is just my experience trying to get some questions. Two months later, this is in August, Mr. Rikhoff had not emailed me, but Ms. Lopas did and stated, actually, there are numerous EJ issues that we're still wanting to contact Mr. Rikhoff about. That's what I was saying to her. And she wrote. And again, Sarah's pretty good, the same day. If you have specific questions regarding environmental justice and the TMI-1 license renewal I can forward them on to him although, keep in mind, scoping is over.

So I'm not really sure how I was to be scoped if nobody contacted me. And we're putting the draft SEIS together, which is why I recommend waiting until the draft is published. All right, maybe miscommunication, maybe we missed each other. How does this all come together, what issue am I raising? The only issue -- that's okay, Sarah, because you'll ignore me again anyway.

The issue I'm raising is that of the Amish and the Mennonite, that I've been trying to raise for 25 or 30 years. It's very bizarre. It's that we have a special needs population who is not ambulatory, who does not use electronic devices, who was left behind during the last accident. I thought, very basic, just one issue we'll see if we can get some attention for. And this is what I wrote Ms. Lopas. One of the special needs populations that is also an EJ issue is the status of alerting and evacuating the Amish, who don't own cars or use phones or may not have access to potassium iodine. However the Amish, as well as some Mennonite sects, are mostly agricultural communities and will likely stay behind, which causes problems beyond their enclaves. For instance, the sale of their produce and livestock, chronic health issues, low birth weight from midwife delivery, dedicated water contamination, etcetera. And I said to you, that is

Appendix A

why we wanted to meet with a live human being. Visual inspections and the realities of these problems just don't drop off the sheep.

Furthermore, I thought based on the experience we had with Three Mile Island -- and for some people that's an ancient event -- and more recently the experience the Amish went through with Nickel Mines should have sensitized people to the need to include these people in a plan so that they're accounted for in the event of an accident or incident. The only issue I have pursued since May. Nothing. I would also point out, and I don't know, and at some point maybe somebody can explain this to me.

According to the GEIS, I figured, look, if we can make a population disappear we can probably make weather disappear. I don't know what a severe weather incident is. But, when I looked in the records, and I may be wrong, we've had an earthquake, a tornado and a drought the last couple of years. And they weren't included.

So, this isn't a criticism. I just and trying to find some idea of constitutes a severe event. This is it. I mean, I'm not going to come up and testify in this process or participate in the process anymore. We submitted 50 questions in the same format May 1st. I'm not going to get responses. TMI Alert is not going to get responses. We're okay with that. You know, we tried to work with the company. That's going so-so.

Based on my experiences at Susquehanna, I know even if I did get a response, the agency would distill and homogenize and tailor that response to meet some limited low-hanging NRC metric.

But part of the problem is me. And I recognize that. I mean, I can continue to participate in a regulatory white-out and a linguistic shell game. Or what I'm going to propose tonight is I can formally cease to exist. And I propose that I no longer exist. And my request to the NRC is simple. And I'd like a response. And I think this would probably make Exelon happy.

I would like you to expunge every comment, every piece of paper, letter or whatever I submitted. Get rid of it as if I -- what I just said tonight, get rid of it. What I want you to do is expunge everything that I've said or done relating to the re-licensing issue. And then I'll feel as if we're okay, that I've done what I was supposed to do. Because I tried to do what I was supposed to do. It didn't work. I realize that. I just think it would make everybody feel happy, certainly Ralph, Jan, Exelon, the NRC because I will not be coming back.

And, Sarah, can you do that? Everything I just said, can you take off the record and everything I testified before. Can you do that? Please get back to me because I don't want to put any more effort into it and I don't want to be a party to it.

And to the guy back there, I'm sorry, I should have told you I was going to do it before you got carpal tunnel issues. Poof, I'm gone. Have a nice evening.

Letter From Eric Epstein Dated February 24, 2009 (Please see ADAMS Accession Number ML090680166 for the complete document submission including supporting information.)

I. Background

I am not here to discuss relicensing. That's a done deal. Three Mile Island Unit-1 (TMI-1) will be relicensed as will every nuclear power plant that applies for a license extension. That's a fact of life. And that's why Three Mile Island Alert, Inc. (TMIA) did not challenge the license extension, and why I entered into a Settlement with Exelon.

The Nuclear Regulatory Commission (NRC's) relicensing process is designed to fast track and approve, minimize public input, and put a smily face on a nuclear bailout.

The Commission views "public participation" as a regulatory burden. The NRC's institutional hubris marks the agency's determination to return to the regulatory world of pre-March 28, 1979.

Tonight we're here to congratulate the Nuclear Regulatory Commission on it's partnership with nuclear industry. The Agency should be recognized on its successful efforts to collaborate with the American Nuclear Society, the Institute for Nuclear Power Operations, and the Nuclear Energy Institute.

On a solemn note, Three Mile Island Alert is still awaiting responses to the Testimony and questions I offered on behalf of TMI-Alert dating back to March 25, 2008 and officially filed on May 1 and 5, 2008.

While I reviewed the entire document and prepared detailed testimony relating to gaps in socioeconomics and emerging issues, I have opted not to enter those comments into the official record. Instead, I am only going to review the process as I experienced to date, and make additions to Appendix E: Chronology of Environmental Review.

II. The Process

Back on March 25, 2008, I asked for responses to the questions and issues TMIA planned to raise on May 1, 2008. Sarah Lopas, Project Manager Division of License Renewal replied quickly that same day at 11:19 am:

I will do my best to answer any of the environmental license renewal questions regarding TMI Unit 1, or any questions you might have on the license renewal process in general. Regarding consumptive water use, groundwater monitoring, biofoul control of the circulating water system, NPDES-regulated discharges to the Susquehanna, and fish kills - we are just in the very beginning stages of the preparing the draft EIS, so I can't make any definitive statements until December, when we tentatively plan to publish the draft. And of course we will have the draft EIS public meetings (tentatively scheduled for late January 2009) to answer questions on our findings, and take comments on the draft.

The FRN of Intent to Prepare an EIS/Conduct Scoping will be published March 31, and we'll be back up to Middletown for the scoping meetings on Thursday, May 1. The scoping comment period will end May 30, so I encourage you to submit your comments for consideration via email before then, or at the May 1 meetings. I'll forward the PDFs of the FRN and meeting notice on to you when they are available.

On May 5, 2008 at 9:15 Sarah Lopas, Project Manager Division of License Renewal even requested a copy of TMIA's testimony, "if you have it available, would it be possible to get a PDF (or Word) version of the most recent testimony you submitted? That will make it easier for me to put it in the Scoping Summary Report." I provided the material in PDF format that same day.

So far, so good. Not really.

If you look hard, you can see how the NRC altered the intent and content of TMIA's questions, and melded the responses into a massaged composite format. But you have to squint real hard, otherwise you won't be able to connect the regulatory dots. (4.32 through 4.42, A- 1 through A-8)

For example, despite well-defined and researched questions relating to invasive species, you would have to get out your microscope, but you can find references in the NRC evasive response to Asiatic Clams (2-3 and 2-32) and Zebra Mussels (2-32.)

The question is listed on A-5, but there no responses.

As part of the cost-benefit analysis of nuclear power plant licensing applications, the NRC is required to assess likely socioeconomic impacts of power plant construction and operation on local communities and the surrounding region. This is interesting relicensing standard since the NRC has no statutory authority to collect tariffs from licensees or enforce decommissioning savings.

However, I persisted.

On May 5, 2008, at 9:15 AM, Sarah Lopas wrote, "He [Jeff Rickoff] wasn't able to come to the meetings on Thursday - I apologize for that. He has been CC'ed on this email. I will ask him to give you a call to discuss sometime this week. "

Since the NRC's socioeconomic designate, Mr. Jeff Rickoff, did not attend the May 1, 2008 meeting, I followed up with Ms. Lopas and requested a meeting with the NRC representative on socioeconomic impacts.

Two months later Mr. Rickoff had not not contacted me. I e-mailed Ms. Lopas on August 05, 2008 4:00 and stated, "Actually there are numerous EJ issues and we're still waiting to be contacted by Jeff [Rickoff]."

¹ Environmental justice is the fair treatment and meaningful involvement of all people regardless of race, color, national origin or income with respect to the development, implementation and enforcement of environmental laws, regulations and policies. N E W S R E L E A S E COMMONWEALTH OF PENNSYLVANIA, Dept. of Environmental Protection, 1/27/2009

Appendix A

On August 5, 2008 at 4:14 pm Sarah Lopas wrote: "If you have specific questions regarding EJ (environmental justice) and the TMI-1 license renewal I can forward them on to him, although keep in mind scoping is over, and we're putting the draft SEIS together now. Which is why I recommend waiting until the draft is published so you can review the analysis and go from there.

I answered Ms. Lopas:

One of the special needs' populations that is also an EJ issue is the status of alerting and evacuating the Amish who don't own cars or use phones and may not have access to KI...

However, the Amish as well as some Mennonite sects (are mostly agricultural communities), and will likely stay behind which causes problems beyond their enclaves, i.e., sale of produce and livestock, chronic health issues, low birth weight for mid-wife delivery, dedicated water contamination, etc.

This is why we wanted to meet w/ a live a human: visual inspections and the reality of the problems we experienced in 1979 don't jump off of the pages.

The GEIS does not factor the special needs of Old Order Mennonites and Amish living with ten miles of Three Mile Island. As witnessed by ^{the} meltdown in 1979 and the Nickel Mines tragedy on September 30, 2006, this agricultural based population requires and deserves dedicated planning since they do not use telecommunication devices, operate motor vehicles or utilize electronics. (2-57, 2-62 and EJ 4.97)

Since the NRC can make a population disappear, I was curious if they could also rewrite weather patterns. Pleased note that under 4.10 III. Evaluation of New & Potentially Significant Information: This section has either omitted or failed To Identify Severe Weather Events. The NRC stated severe weather is "generally uncommon" (p. 2-24); however, an earthquake, tornado and drought have impacted the TMI vicinity in recent years.

• **Earthquake: December 27, 2008**

(Lebanon County, 12:04 a.m., 12/27/08) A 3.4 magnitude earthquake occurred northwest of the city of Lancaster, Lancaster County. The quake was felt by residents in Berks, Cumberland, Dauphin, Lebanon and Lancaster. No damage or injuries were reported.

The incident was terminated at 6:23 a.m.

Notifications: Departments of Health, Environmental Protection (Southcentral Regional Office and Headquarters) and Transportation, Public Utility Commission, Federal Emergency Operations Center, Turnpike Commission, PA-1 Call, Millersville University Geology Department, National Earthquake Information Center, State Police, affected counties and PEMA Central and Eastern Area Offices

• **F3 Tornado: July 14, 2004**

An F3 tornado, with wind speeds estimated between 175 and 200 mph, pounded Campbelltown in Lebanon County Pennsylvania. The severe storm which produced the tornado over 100 homes in a development in Campbelltown. This thunderstorm also produced a weaker F1 tornado in northern York County as it moved eastward on Wednesday afternoon. The storm injured twenty-four people in Campbelltown.

Pennsylvania Emergency Management (PEMA) reports showed that 32 houses were destroyed, 37 homes suffered major damage, and an additional 50 homes suffered some form of damage from the storm (Figure 1). Two people were hospitalized by the storm, one was critically injured. Fortunately, there were no fatalities with the tornado. In addition to the homes damaged winds that affected other areas of Dauphin and Lebanon Counties. A few farmhouses and houses in other areas of Lebanon County were damaged by the strong straight line winds.

Source: Lebanon County F3 Tornado , 14 July 2004 *Richard H. Grumm and Kevin Fitzgerald National Weather Service Office , State College, PA 16803*

• **Drought: Summer 2002**

During the 2002 drought nuclear power plants were exempted from water conservation efforts and participate in a "voluntary" program. In Pennsylvania, 24 counties were designated as "drought emergencies", and another 31 were on "drought watch.

III. Conclusion

I am submitting the same 50 questions in the same format from the May 1, 2008 meeting hoping somebody or something at the NRC will actually answer the questions.

Based on my prior experiences with relicensing at the Susquehanna Steam Electric Station, I realize that the NRC won't respond to the questions directly. The Agency will distill and homogenize and tailor their responses to meet some limited, low-hanging NRC metric(s).

However, I can continue to participate in regulatory "whiteout" and a linguistic shell game.

Or, in the alternative, I can formally cease to exist.

I choose not to be part of a perforated record.

Please expunge and strike all of my previous comments and Testimony.

Please disregard all of the comments I made this evening.

IV. Appendix E:

Chronology of Environmental Review

The information provided on the Timeline from E-1 to E-7 is incomplete and fails to include the following:

- May 1 and 5, 2008: TMLA's Testimony was submitted to the NRC.
- May 19, 2008: Joint Press Release: "Exelon and EFMR Sign Community Based Agreement."
- August 18, 2008 "Re: Findings and Responses of the NRC Office of the Inspector General Report on the License Renewal Program" from Senator Jeffrey E. Piccola (R-15th Senatorial District) and Rep. Eugene A. DePasquale (D-95th Legislative District)
- May 28, 2008 Letter to Peter Bramford from Douglas Beddel, for Communications Manager for TMI, Re: Relocation of Joint Information Center to Coatesville.
- July 23, 2008: Summary of Conference Call With AmerGen Company To Discuss Responses to Request for Additional Information For Sections 4.2 and 4.4 of the Three Mile Island Unit 1 License Renewal Application (TAC NO. MD 7701)
- August 20, 2008: Request for Additional Information For Sections 2.3. 3 and 2.3.4 of the Three Mile Island Unit 1 License Renewal Application (TAC NO. MD 7701)
- August 22, 2008: Summary of Conference Call With AmerGen Company To Discuss Responses to Request for Additional Information For Sections 2.2, 2.3., 2.4 and 2.5 of the Three Mile Island Unit 1 License Renewal Application (TAC NO. MD 7701)
- August 22, 2008: Request for Additional Information For Sections 2.2, 2.3, 2.4 and 2.5 of the Three Mile Island Unit 1 License Renewal Application (TAC NO. MD 7701)
- November 12, 2008: Three Mile Island Unit 1 - Request for Additional Information, Regarding Review of Steam Generator Inspection Report for the 2007 Outage (TAC NO. MD 8268)

Appendix A

- October 24, 2008 - Exelon Announces Third Quarter Results; Increases Fourth Quarter Common Dividend by 5 Percent

“Unrealized losses of \$60 million, or \$0.09 per diluted share, related to nuclear decommissioning trust fund investments primarily related to the AmerGen Energy Company, LLC (AmerGen) nuclear plants.”

- November 17, 2008: Summary of Conference Call With AmerGen Company To Discuss Responses to Request for Additional Information For Sections 2.3. and 2.3.4 of the Three Mile Island Unit 1 License Renewal Application (TAC NO. MD 7701)
- December 23, 2008: The Nuclear Regulatory Commission approved the formal transfer of the operation licenses for these facilities to Exelon Generation on Dec. 23, 2008, which was a key step in the final integration process.
- January 8, 2009: Exelon Generation today officially integrated the nuclear generation assets held by its AmerGen Energy Company LLC subsidiary into Exelon Nuclear and dissolved the AmerGen legal entity.

The Nuclear Regulatory Commission approved the formal transfer of the operation licenses for these facilities to Exelon Generation on Dec. 23, 2008, which was a key step in the final integration process.

- January 5, 2009: Request for Additional Information For Sections 2.3. and 2.3.4 of the Three Mile Island Unit 1 License Renewal Application (TAC NO. MD 7701)

Response:

Mr. Epstein's comments express general dissatisfaction with the NRC license renewal process and its opportunities for public participation. The NRC acknowledges his request to expunge his comments from the TMI-1 license renewal review environmental scoping and draft supplemental EIS comment proceedings, however, Mr. Epstein's comments will remain on the license renewal record. 10 CFR Part 2.390, Public Inspections, Exemptions, and Requests For Withholding, states that "final NRC records and documents, including but not limited to correspondence to and from the NRC regarding the issuance ... of a license, permit, order, or standard design approval, or regarding a rulemaking proceeding subject to this part shall not, in the absence of an NRC determination of a compelling reason for nondisclosure after a balancing of the interests of the person or agency urging nondisclosure, be exempt from disclosure..." Part 2.390(a) continues on to list categories of documents exempt from disclosure—none of Mr. Epstein's TMI-1 license renewal submissions fall under these document categories. Furthermore, Mr. Epstein's license renewal submissions do not fit the NRC's definition of "record" under the Privacy Act of 1974 regulations (10 CFR Part 9, Subpart B), "Record means any item, collection, or grouping of information about an individual that is maintained by the NRC, including, but not limited to, his education, financial transactions, medical history, employment history..." Because Mr. Epstein's submissions do not constitute a record under the Privacy Act, they cannot be exempted from disclosure under the Act.

The scoping process and comment period on the draft supplemental EIS are both part of the NRC's 10 CFR Part 51 regulations that implement the National Environmental Policy Act (NEPA). 10 CFR 51.29(b) states that at the conclusion of the scoping process the NRC staff will compile a summary of determinations and conclusions reached, i.e., the "Environmental Impact Statement Scoping Process Summary Report," which was issued in August 2008 for TMI-1. 10 CFR 51.73 requires that each draft EIS is distributed with a request for comments, while 10 CFR 51.91(a)(2) requires that comments received on the draft EIS be attached to the final EIS. The White House Council on Environmental Quality (CEQ) guidance on scoping states that every comment received during scoping should be addresses in some manner in the EIS, either by in-depth analysis or a short explanation as to why the comment was not examined further. Part 1502.9(b) of the CEQ regulations for implementing NEPA state, "Final environmental impact statements shall respond to comments as required in Part 1503 of this chapter. The agency shall discuss at appropriate points in the final statement any responsible opposing view which was not adequately discussed in the draft statement and shall indicate that agency's response to the issues raised."

Appendix E, Chronology of Environmental Review, contains documentation of correspondence between the NRC and external parties as part of its environmental review of the TMI-1 license renewal application. In-scope portions of Mr. Epstein's comments submitted at the public scoping meetings in May 2008 are included in Section A.1 of this supplemental EIS, and all of his scoping comments (available online in ADAMS at ML01330183) are included in the "Environmental Impact Statement Scoping Process Summary Report," issued in August 2008. The Scoping Process Summary Report is referenced at the end of this Appendix and is available online in ADAMS at ML081920230. Furthermore, Mr. Epstein's "50 questions," as contained in his May 2008 scoping comments, were addressed in the "Environmental Impact

Appendix A

Statement Scoping Process Summary Report.” Appendix E does not include correspondence unrelated to the environmental review, such as correspondence regarding the license renewal safety review or current plant operating issues. Appendix E also does not include press releases other than those written by the NRC. No changes were made to Appendix E as a result of Mr. Epstein’s submission.

*A discussion of zebra mussels (*Dreissena polymorpha*) and Asiatic clams (*Corbicula fluminea*) is contained in Section 2.2.5, Description of Aquatic Resources. At TMI-1 a biocide is applied to the intake water as it reaches the screen to prevent macrofouling of the cooling system. Section 2.1.3.5, Permitted Discharges, discusses how biocide wastes are discharged as plant wastewater according to the plant’s NPDES permit.*

The Campbelltown tornado incident included in Mr. Epstein’s comments was added to Section 2.2.2, Air and Meteorology. With regard to droughts, TMI-1 participates in the Cowanesque Lake water storage program, which is described further in Section 2.1.7.2, Surface Water Use, Section 4.3.2, Ground Water Use Conflicts, and Section 4.4.1, Water Use Conflicts. The SRBC and U.S. Army Corps of Engineers are the responsible agencies for making releases from Cowanesque Lake during periods of low flow in the Susquehanna River.

Section 5.2, Severe Accidents, states that severe accidents initiated by external phenomena such as tornadoes, floods, earthquakes, and fires were not specifically considered for TMI-1 in the GEIS (NRC 1996), however, the GEIS did evaluate existing impact assessments performed by the NRC and by the industry at 44 U.S. nuclear plants and concluded that the risk from beyond design basis earthquakes at existing nuclear power plants is SMALL. Even if such an event were to occur, the Commission would expect that resultant core damage and radiological releases would be no worse than those expected from internally initiated events. Based on the above, the commission concludes that the risk from beyond design basis earthquakes at existing nuclear power plants is small and additionally, that the risks from other external events are adequately addressed by a generic consideration of internally initiated severe accidents. Furthermore, the staff’s review of the SAMA analysis is discussed in Section 5.3, Severe Accidents Mitigation Alternatives, and supporting analyses are contained Appendix F. No changes to the supplemental EIS were made as a result of Mr. Epstein’s comment regarding earthquakes.

Mr. Epstein’s environmental justice concerns include the definition of environmental justice and emergency preparedness. Mr. Epstein expressed concern that NRC’s definition of environmental justice bears no relation to the Pennsylvania Department of Environmental Protection’s definition. Mr. Epstein also expressed a concern related to environmental justice that special needs populations, including members of the Amish and Mennonite communities, might be overlooked in the event of an alert and emergency evacuation.

Nuclear power plant owners, government agencies, and State and local officials work together to create a system for emergency preparedness and response that will serve all members of the public in the event of an emergency. The emergency plans for nuclear power plants cover preparations for evacuation, sheltering, and other actions to protect all residents near nuclear power plants in the event of a serious incident. The Commission has determined that there is no need for a special review of emergency planning issues in the context of an environmental review for license renewal. Therefore, decisions and recommendations concerning emergency

preparedness at nuclear plants are ongoing and outside the regulatory scope of license renewal. In addition, the environmental justice impact analysis conducted by the NRC and the definitions of minority and low-income populations based on Council of Environmental Quality (CEQ) guidance under NEPA are presented in Section 4.9.7, Environmental Justice, in the supplemental EIS. The analysis of impacts to minority and low-income populations, as defined by the CEQ, is explained in NRC's "Policy Statement on the Treatment of Environmental Justice Matters in NRC Regulatory and Licensing Actions" (69 FR 52040). No changes to the supplemental EIS were made in response to Mr. Epstein's comments.

Commenter: Michael Gallagher, Exelon Generation Company, LLC

February 27, 2009
Page 1 of 5
TMI-09-034
Attachment

**EXELON GENERATION COMPANY, LLC
COMMENTS ON NUREG-1437, SUPPLEMENT 37, DRAFT**

Exelon Generation Company, LLC submits the comments listed below in response to the U.S. Nuclear Regulatory Commission (NRC) "Notice of Availability of the Draft Supplement 37 to the Generic Environmental Impact Statement for License Renewal of Nuclear Plants, and Public Meeting for the License Renewal of Three Mile Island Nuclear Station, Unit 1," which was published in the *Federal Register* on December 9, 2008 (73 FR 74766).

General Comment

On January 8, 2009, Exelon Generation Company, LLC ("Exelon Generation") officially integrated the nuclear generation assets held by its subsidiary, AmerGen Energy Company, LLC ("AmerGen") into Exelon Generation and dissolved the AmerGen legal entity. Accordingly, throughout the TMI-1 License Renewal Supplemental EIS, replace "AmerGen Energy Company, LLC" and "AmerGen" with "Exelon Generation Company, LLC" and "Exelon Generation," respectively.

General Comment

Exelon Generation notes that in Chapters 3 and 4 of the TMI Supplemental EIS, the NRC presents Category 1 issues differently than was previously done in license renewal Supplemental EISs for other nuclear plants. Previously, Supplemental EISs for license renewal included, for each applicable Category 1 issue identified in the GEIS, a table that listed the issue and text that summarized the GEIS determination concerning the issue. Otherwise, the text of the Supplemental EISs did not address Category 1 issues or discuss site-specific information related to such issues. Exelon Generation suggests that, if site-specific information related to a Category 1 issue is presented in the TMI-1 Supplemental EIS, then it should be made clear whether the evaluation of impacts for that issue is adopted from the GEIS or takes into account the site-specific information.

Page 2-70, lines 2 & 3

Replace the sentence that reads: "On March 28, 1979, TMI Unit 2 experienced a loss of coolant accident that resulted in a partial core meltdown, and is considered the nation's worst commercial nuclear accident (Walker 2004)." with the following sentences: "On March 28, 1979, TMI Unit 2 experienced a loss of coolant accident that resulted in a partial core meltdown. Although the accident was the most serious in U.S. commercial nuclear power plant operating history, off-site releases of radioactivity were very small, and there were no deaths or injuries to plant workers or members of the public." This alternative text was derived from the "NRC Fact Sheet on the Three Mile Island Accident" (see <http://www.nrc.gov/reading-rm/doc-collections/fact-sheets/3mile-isle.html>).

Exelon Generation believes that the suggested alternative text for the quoted sentence on p. 2-70, lines 2 and 3, more clearly describes the TMI Unit 2 accident and its significance. Furthermore, "Walker 2004," which is the reference cited in the draft Supplemental EIS (p. 2-70, line 3), is not listed in Section 2.4, "References."

February 27, 2009
Page 2 of 5
TMI-09-034
Attachment

Page 2-70, lines 3 to 5

Page 4-23, lines 35 to 38

Lines 3 to 5 on p. 2-70 contain the following sentence: "Although the [TMI Unit 2] structure is under 40 years of age, it can be considered potentially eligible for listing on the National Register of Historic Places under Criterion A, as a site of exceptional importance."

Lines 35 to 38 on p. 4-23 contain the following sentences: "Another potential resource of historic significance on Three Mile Island is TMI Unit 2. TMI Unit 2 could be considered potentially eligible for listing on the NRHP under Criterion A, as a site of exceptional importance but its eligibility has not yet been determined."

For the following reasons, Exelon Generation suggests that the sentences on pages 2-70 and 4-23 quoted in this comment be deleted from the final TMI-1 License Renewal Supplemental EIS. Exelon Generation acknowledges the historic significance of the events that occurred at TMI Unit 2 on March 28, 1979. Consequently, Exelon Generation will cooperate with the owner of TMI Unit 2 to commemorate those events in a manner that does not interfere with the eventual decommissioning of either unit. However, Exelon Generation believes it is premature to speculate on whether such commemoration could involve the listing of TMI Unit 2 on the National Register of Historic Places.

Page 4-1, lines 8 & 9

The text states "Some remaining [GEIS] issues are not applicable to TMI-1 because of site characteristics or plant features." Exelon Generation recommends that, for completeness, all GEIS issues (Category 1 and Category 2) that do not apply to continued operation of TMI-1 or refurbishment activities be identified in an appendix to the Supplemental EIS. This could be easily accomplished by adding the information to the existing Supplemental EIS Appendix B, "NEPA Issues for License Renewal of Nuclear Power Plants."

Page 4-12, lines 5 to 7

Page xvi, lines 9 to 14

Page xviii, lines 9 & 10

The text on p. 4-12, lines 5 to 7 states:

"Based on the applicant's assertion that refurbishment activities are planned, slightly higher doses to members of the public, and the resultant environmental impacts, are expected from TMI-1 during the refurbishment period."

Also, the text on p. xvi, lines 9 to 14 and the text on p. xviii, lines 9 and 10, both state:

"Slightly higher radiation doses to members of the public are expected from TMI-1 during the refurbishment period."

None of these statements is supported by a reference citation or other information presented in the draft TMI-1 Supplemental EIS. Also, the statements are inconsistent with TMI-1 site-specific information provided to the NRC Staff during the TMI-1 site environmental audit (Responses to Questions ENV-53 and ENV-55).

The TMI-1 site-specific information indicates that replacing the steam generators at TMI-1 will not increase radiological effluents (liquid and gaseous) at TMI-1, and that members of the

(Continued)

public are projected to receive no radiation dose as a result of the TMI-1 steam generator replacement project.

Exelon Generation believes the NRC Staff's conclusions in the draft TMI-1 Supplemental EIS were not based on the TMI-1 site-specific information. Rather, it appears that the NRC Staff relied solely on the generic analysis of human health effects from radiation exposures during refurbishment presented in the GEIS (Appendix C).

Since the GEIS analysis determined that the impact on human health of refurbishment is a Category 1 issue, adoption of the GEIS findings without considering TMI-1 site-specific dose impacts is an acceptable approach because the GEIS analysis bounds the planned TMI-1 refurbishment. However, as Section 3.8.1.2 (p. 3-32) in the GEIS explains, the GEIS analysis used conservative assumptions, and the use of more realistic data should decrease dose estimates in most cases.

In Section 3.8.1.5 (p. 3-35), the GEIS further states that effluents and dose impacts observed at example reactor sites (Cooper, Monticello, Nine Mile Point-1, Peach Bottom-2, and Vermont Yankee) during major refurbishment activities, such as steam generator replacement in the case of PWRs, did not differ significantly from normal operation. Notwithstanding, the GEIS speculates that "during the 9-month outage, a greater amount of work will be performed and some of the effluents, especially atmospheric particulates and possibly some liquid effluents associated with decontamination, may be slightly greater than were found during the [actual] steam generator changeouts or recirculation piping replacements." Accordingly, the GEIS indicates that each licensee has the opportunity to provide site-specific information regarding radiation exposures to members of the public, which Exelon Generation did.

Based on the site-specific information provided for TMI-1, the TMI-1 Supplemental EIS should conclude that refurbishment is not expected to result in increased dose to any member of the public, even though the GEIS analysis concludes that doses to members of the public due to refurbishment would be slightly higher than during a normal refueling outage. The TMI-1 Supplemental EIS should acknowledge that the TMI-1 conditions are more protective than the bounding conditions assumed for the GEIS analysis.

Specifically, the three sentences quoted at the beginning of this comment should be replaced with the following sentence or its equivalent:

"Based on the applicant's assertion that refurbishment activities will not increase radiological effluents (liquid and gaseous) at TMI-1, doses to members of the public are expected to be unchanged from those resulting from normal operations."

In addition, surrounding text should be modified for consistency with the change, and NRC staff should consider moving the paragraph from p. 4-12, lines 5 to 11, into an appropriate location in Chapter 3 (Environmental Impacts of Refurbishment) because the contents of these lines deal with refurbishment impacts rather than impacts of operation. Consistent with its title, the contents of Chapter 4 (Environmental Impacts of Operation) should focus on environmental impacts of operation.

February 27, 2009
Page 4 of 5
TMI-09-034
Attachment

Page 8-16, line 3

The NRC Staff's environmental justice (EJ) analysis of the supercritical coal-fired generation alternative concludes that the impacts would range from "Small to Moderate and would depend on the location of the power plant site in proximity to minority and low-income populations."

While this statement is, to a degree, correct, the standard for assessing EJ impacts, as set forth in NUREG-1555, Supplement 1, Section 4.4.3, is whether impacts to minority and low-income populations would be significant and disproportionate. Thus, if the location of the coal-fired plant results in significant impacts to all local residents, regardless of their minority or low-income status, mitigation may not be warranted. The apt inquiry is whether location or other operational factors result in disproportionate impacts to the relevant minority and low-income populace. Exelon Generation recommends that NRC Staff review the EJ impacts analyses for other alternatives presented in Chapter 8 to verify that the appropriate standard of review is applied.

Page 8-45, lines 36 to 41

Page 8-46, lines 1 to 3

On pp. 8-45, lines 36 to 41 and 8-46, lines 1 to 3, the draft text states:

"The NRC notes that the energy conservation/energy efficiency alternative has SMALL impacts in all categories evaluated, and upon shut down of TMI-1, current operating impacts of TMI-1 would cease. Therefore, the energy conservation/energy efficiency alternative is the environmentally preferred alternative to license renewal. All other alternatives capable of meeting the needs currently served by TMI-1 entail potentially greater impacts than the proposed action of license renewal of TMI-1. The no-action alternative does not meet the purpose and need of this draft SEIS, however if it triggers the energy conservation/energy efficiency action to replace the capacity currently supplied by TMI-1, it could result in an overall SMALL impact, as well."

For the reasons set forth below, Exelon Generation disagrees that the energy conservation/energy efficiency alternative is "capable of meeting the needs currently served by TMI-1." While increased energy efficiency and energy conservation can play a role in long-term resource planning, there are considerable uncertainties about the costs and effectiveness of such proposals. As Black and Veatch notes in their work (Pietka, 2004) while there is the potential for reduction in required long-term energy use, achieving these potential reductions would require a wide variety of programs targeting behavior by many different sorts of customers. We have two major concerns. First, the historical record shows that while regulatory efforts and an increased awareness of efficiency and conservation has led to a slower rate of load growth over the last 30 years, load continues to grow and per capita electricity use has continued to increase. Second, while some of the potential savings alluded to in the Black and Veatch analysis will undoubtedly prove feasible and economical, it is unreasonable to assume that all of the potential programs they consider will ultimately prove feasible. The potential 10% savings they allude to in terms of total energy consumed must be considered an outer bound.

Exelon Generation believes that a more detailed look at the components of programs alluded to by Black and Veatch would result in a much lower expectation of economical and feasible

(Continued)

reductions in load through increased efficiency and conservation. The EIA forecasts for long-term electricity demand growth, which implicitly assume that long-term trends toward greater efficiency and conservation are extended in future decades, projects that long-term load growth from 2007 to 2030 will average over 1percent. (EIA, Annual Outlook 2009).

In addition to the uncertainty around the costs and effectiveness of potential conservation, it is also unclear how not granting license renewal to TMI would lead to the implementation of greater conservation and efficiency measures. If increased conservation and efficiency did not completely offset the reduction in generation that would accompany the shut-down of TMI, the remaining loss in generation would most likely be offset by higher use of fossil-fired generation, probably resulting in higher costs as well as additional emissions.

It is also important to note that many demand-side management programs essentially serve to peak-shave demand, and reduce peak demand by shifting this demand to other hours of the day where underlying demand is lower. While this may reduce the need for new generation in the peak hour, the level of underlying baseload generation – such as nuclear – is likely to be relatively unaffected.

References

Pletka, R. 2004. "Potential Impact of an Advanced Energy Portfolio Standard in Pennsylvania." Presented at NREL Energy Analysis Forum, November 9, 2004. Available at URL: <http://www.nrel.gov/analysis/forum/docs/2004/pletka.ppt>

EIA (U.S. Department of Energy, Energy Information Administration). 2009. Annual Energy Outlook 2009 Early Release Outlook. DOE/EIA 0383(2009). Washington, D.C. Available at URL: <http://www.eia.doe.gov/oiaf/aeo/pdf/overview.pdf>

Response:

The final supplemental EIS has been updated to reflect that AmerGen Energy Company, LLC, was dissolved into Exelon Generation Company, LLC.

Section 4.8.1, Generic Human Health Issues, opens with a paragraph stating that the staff did not identify any new and significant information during the license renewal review, and therefore, there are no impacts related to those issues beyond those discussed in the GEIS. This paragraph was edited to make it clear that "Generic Human Health Issues" represent Category 1 human health issues, which the GEIS concluded that impacts are SMALL. The remainder of Section 4.8.1 is a discussion of radiation exposures to the public and occupational radiation exposures and the information the staff reviewed to verify that the conclusions in the GEIS regarding these issues are valid for TMI-1.

The NRC did not make any changes to Section 2.2.9.2, Historical and Archaeological Resources, regarding the TMI Unit 2 1979 accident. The NRC believes the current sentence regarding the accident is sufficient. The Samuel J. Walker reference, Three Mile Island: A Nuclear Crisis in Historical Perspective, was corrected. No changes were made to Sections 2.2.9.2 and 4.9.6, Historical and Archaeological Resources, regarding TMI Unit 2 as potentially eligible for listing on the National Register of Historic Places (NRHP). To support the Pennsylvania Historical and Museum Commission (PHMC) in making their eligibility determination, Exelon Generation will work with FirstEnergy Corporation (the owner of TMI Unit 2) in arranging access for PHMC personnel to the TMI Unit 2 property (Exelon Generation 2009).

Table B-1, Summary of Issues and Findings, in Appendix B, NEPA Issues for License Renewal of Nuclear Power Plants, has been edited to identify which GEIS issues do not apply to TMI-1 either because TMI-1 does not use that cooling system, or does not feature some other specified plant or site characteristic.

Conclusions contained in the Executive Summary and in the last paragraph of Section 4.8.1, Generic Human Health Issues, have been edited to reflect that refurbishment activities at TMI-1 are not expected to generate an amount of radioactive material that is significantly different from historical radiological effluent releases, including refueling outage activities.

Mr. Gallagher's comment about environmental justice concerns environmental justice impact analysis of alternatives and the continued operation of TMI-1, as evaluated in the supplemental EIS and compared to the environmental justice review standard presented in NUREG-1555, Supplement 1, Section 4.4.6 (the comment erroneously cites Section 4.4.3). Specifically, the concern is whether impacts to minority and low-income populations would be significant and disproportionate. As discussed in the supplemental EIS, the disproportionate effect on minority and low-income populations from the construction and operation of a new power plant cannot be determined since it would depend on the proximity of these populations to the location of the new power plant. It is assumed that the site selected for a new power plant would take into consideration the potential effects of construction and operation on minority and low-income communities; and avoid creating, as much as possible, any disproportionate effects. Thus the impacts on minority and low-income populations from constructing and operating alternative power plants would likely range from SMALL to MODERATE. The appropriate standard of

Appendix A

review was applied. NRC staff have edited relevant text to clarify that disproportionate adverse impacts are the primary concern, and that location of potential alternatives may play a role in determining whether such impacts are ultimately disproportionate or not.

With regard to Mr. Gallagher's comment about whether energy conservation/energy efficiency is capable of meeting the needs currently served by TMI-1, the NRC staff has modified text in Section 8.3, Energy Conservation/Energy Efficiency, to indicate that energy efficiency or conservation could replace the capacity currently supported by TMI-1, rather than to indicate that denial of renewal could "trigger" conservation as a replacement for TMI-1. No additional changes have been made in response to this comment, for the following reasons:

- In the process of developing the TMI-1 draft supplemental EIS, NRC staff reviewed the study that supported the presentation ("Pletka 2004") that Exelon Generation references in the comment. NRC staff refers to the study in Chapter 8 of the supplemental EIS. The study indicates that Pennsylvania alone has 6,872 megawatts (MW) of "near-term" energy conservation potential. Only 11.7 percent of this potential would be necessary to satisfy the load served by TMI-1. Thus, as—*as Exelon Generation suggests*—most of this potential could "essentially serve to peak-shave demand and reduce peak demand by shifting this demand to other hours of the day..." and still allow for enough capacity to offset TMI-1. Further, the 10 percent figure Exelon Generation quotes for total energy savings—taken from the Pletka 2004 presentation—is based only on Black & Veatch's analysis of near-term potential. Black & Veatch identified 70,000 gigawatt-hours (GWh) in total potential, or nearly five times the 16,000 GWh figure cited as 10 percent of demand in Exelon Generation's source. Thus, the 10 percent figure is not an outer bound, as Exelon Generation asserts it should be. Black & Veatch note that conservation potential in Pennsylvania is good and that "[d]ecreased emphasis since deregulation has left an opportunity to implement energy conservation measures."
- The NRC staff notes that the analysis of conservation potential contained in the draft supplemental EIS is inherently conservative, in that the staff only considered Pennsylvania's conservation potential. TMI-1 operates within and serves the PJM Interconnection, which includes all or parts of many neighboring states. NRC staff did not consider the conservation potential available in neighboring states. In addition, the NRC staff did not include "efficiency" as identified by Black & Veatch. Black & Veatch described efficiency as improvements to existing supply-side resources.
- Finally, while Exelon Generation indicates that the Energy Information Administration projects long-term load growth of 1 percent through 2030 across the U.S., Pennsylvania must reduce its overall energy consumption as well as peak energy demand and in the coming years under the requirements of Act Number 129 (introduced as H.B. 2200, An Act Amending Title 66 [Public Utilities] of the Pennsylvania Consolidated Statutes). While the mandated reduction amount is less than the energy produced by TMI-1, estimates of potential offered by Black & Veatch in the preceding paragraphs suggest potential beyond the mandated amount. According the Federal Energy Regulatory Commission (FERC 2009), many neighboring states have similar programs. Maryland and Ohio have mandates to reduce consumption, Virginia has established a reduction

goal, Delaware has created a sustainable energy utility with a focus on energy efficiency and conservation, and New Jersey is currently considering an energy efficiency resource standard (FERC 2009). New York, though not a part of PJM, also has substantial energy efficiency goals, including an overall reduction in electricity consumption.

The NRC staff has made no changes in response to the comment aside from those identified in the first paragraph of the comment response.

Commenter: Gregory Hanlon, FirstEnergy Corporation

Comments regarding NUREG-1437, Supplement 37, draft; Generic Environmental Impact Statement (GEIS) for License Renewal of Nuclear Plants regarding Three Mile Island Nuclear Station, Unit 1 (TMI-1)

FirstEnergy appreciates the opportunity to provide comments on the draft GEIS Supplement for TMI-1.

In the discussions of Historic and Archeological Resources (sections 2.2.9 and 4.9.6), there is reference to potential eligibility for listing Three Mile Island Unit 2 (TMI Unit 2) on the National Register of Historic Places. As the parent company of GPU Nuclear, the owner of TMI Unit 2, FirstEnergy recognizes the historical significance of the 1979 events at TMI Unit 2 and their influence on the entire nuclear industry. Appropriate recognition of these events would not be expected to affect the ability to comply with decommissioning regulations at TMI Unit 2.

Contact: Gregory H. Hanlon, Director, Fleet Regulatory Affairs

Response:

The comment is noted. No changes were made to the supplemental EIS.

Commenter: Judith Johnsrud, Sierra Club and Pennsylvania Environmental Coalition on Nuclear Power

Thank you. Am I audible? Good. My name is Judith Johnsrud. I hold a Doctoral Degree in the Geography of Nuclear Energy. I have served as an intervener in the licensing of TMI, the operating license for TMI-1 and TMI-2, and TMI-1 restart following the accident.

I wanted to start my comments with the observation that, so far as I know, most of the preparation of the EIS was based on existing criteria of the Agency, of the NRC, and no special information was incorporated from what we may be learning as the result of climate change. I suggest to the NRC that it would be extremely important, as communities world-wide begin to cope with changes in climate that result in different consequences that may be far more damaging to the public than had been anticipated in the development of the EIS.

In addition to this, which I really urge the Agency and the Pennsylvania organization, I really urge them to take into consideration the importance of preparing for changes in the future, the 20 year future, hoping that there would not be another 20 year continuation beyond.

I have been asked to present a short presentation on behalf of another organization. In addition to Sierra Club I do direct the Pennsylvania-based Environmental Coalition on Nuclear Power.

Appendix A

And I'm on the boards of a number of other organizations, including the Optimistic Beyond Nuclear, which I commend to you all. The Radiation and Public Health Project has summarized some data that I think also need to be carefully considered, particularly for those who live within the vicinity within Dauphin County. Their statement begins, new data on high local disease rates suggest link with TMI. Harrisburg, updated data documenting high rates of infant mortalities, low weight births, child cancer deaths and thyroid cancer cases in Dauphin County suggest radioactive discharges from the Three Mile Island Unit 1 nuclear reactor that may be harming local citizens.

The analysis is presented today with the hope that they will be taken seriously by the Agency, by the NRC and by the utility. I'm quoted in their statement, continued high local disease rates in those most vulnerable to radiation exposure raise concerns.

And I want to add there that -- actually, he continues that the National Academy of Sciences in 1999 and again in 2005 concluded that there is not safe dose of ionizing radiation, that there may be damages that do not show up immediately, there may be damages that will no occur for a long time into the future but are the result of genetic alterations.

I've been following these issues for a number of years. And, I must say, that is a conclusion that many specialists in these fields have now reached, that we have allowed far more sources of radiation into our environment than we human beings and other species are capable of coping with safely.

The data that I want to present to you now very briefly come from the U.S. Centers for Disease Control and Prevention. And they show Dauphin County rates exceeded U.S. rates for the following conditions.

First, a plus 21.1 percent for births under 5 and a half pounds. A 24.2 percent for deaths among infants in the first month of life. A 28.6 percent for cancer deaths among children under the age of 20, in other words, those that were born in the aftermath of the accident at TMI-1.

FACILITATOR BO PHAM: Judith, excuse me, could you state which report you're reading from so we can get it in the record?

MS. JOHNSRUD: Yes, this is from Radiation and Public Health Project.

And, finally, of this short list, a 31.4 percent for the incidence of thyroid cancer among all ages. Reactors produce over 100 radioactive chemicals to generate electricity.

Most are stored as waste. But, of course, increasingly some of those low dose wastes are allowed to be released and recycled into consumer products. Some of these are routinely emitted from local air and water, entering human bodies through breathing and the food chain. These chemicals damage cells leading to cancer, especially thyroid cancers, and are especially harmful for infants and children. Three Mile Island, Unit 1 began its operation in 1974 but was closed in 1979 for a TMI-2 accident from 1979 to 1985 after the meltdown at Unit 2.

Like all reactors, this plant is licensed for 40 years. The NRC has granted 20 year extensions for some 51 of the 104 U.S. reactors. The NRC hearing is required by law. It takes place one month prior to the 30th anniversary of the 1979 meltdown, the worst nuclear accident of U.S. history. I hope that those of you who live in Dauphin County and those of you who have friends

and family who live in the county will take to heart the implications of this report from the Radiation and Public Health Project. Thank you.

Response:

In response to Ms. Johnsrud's comment concerning incorporating the impacts of global climate change into the supplemental EIS, a qualitative discussion of potential climate change impacts has been added to Section 4.11, Cumulative Impacts.

In response to Ms. Johnsrud's comment regarding low dose wastes being recycled into consumer products, and low doses routinely emitted from local air and water: all nuclear plants were licensed with the expectation that they would release radioactive material to both the air and water during normal operation. Airborne and liquid releases of radionuclides from nuclear power plants must meet radiation dose-based limits specified in 40 CFR Part 190, 10 CFR Part 20, and the ALARA criteria in 10 CFR Part 50, Appendix I. Regulatory limits are placed on the radiation dose that members of the public might receive from all of the radioactive material released by the nuclear plant. Licensees are required to report liquid, gaseous, and solid effluent releases as well as the results of their radiological environmental monitoring program annually to the NRC. The annual effluent release and radiological environmental monitoring reports submitted to the NRC are available to the public in the ADAMS electronic reading room available through the NRC website: <http://www.nrc.gov/reading-rm/adams.html>. The NRC's response to Ms. Marjorie Aamodt's comments on public health and radiation on pages A-21 through A-25 provide a more detailed description the NRC's radiation protection regulations.

The NRC does not allow nuclear power plants to release tools, equipment, scrap metal, trash, or any other material containing plant-related radioactive material for recycling and reuse. Prior to removal from the plant site, all material that was in radiation-controlled areas of the plant must be surveyed to ensure there is no detectable radiation. If any radiation is detected, the material must be controlled and handled as radioactive material in accordance with NRC regulations. It will not be released into the public environment for recycling or reuse.

The staff acknowledges the Radiation and Public Health Project study that Ms. Johnsrud cites, but this study does not provide scientifically defensible information that would cause the NRC to alter its position that the current radiation protection safety standards are protective of public health and safety and the environment.

The NRC has already fully considered and addressed these issues and Ms. Johnsrud's comments do not present any significant new information or arguments that would warrant a change to the TMI-1 supplemental EIS.

Commenter: Thomas C. LeCrone, local citizen

Dear NRC Staff,

Given the reality of global warming and the depletion of fossil fuels, I think that the Three Mile Island operating license should be renewed. The older technology used at Three Mile Island and the need for a "new generation" of nuclear facilities in the U.S. should limit the renewal license to no more than ten (10) years. It is my hope that the expansion of alternative fuels R & D will evolve into public support for additional nuclear power plants in the U.S. in the next three

Appendix A

to five years. At that point, Three Mile Island can and should be closed and a new Exelon Generation Company Nuclear plant licensed and opened in its place.

Pennsylvania utility companies received over \$12.5 billion in transition payments over the last 10 years as part of PA electric deregulation. Unfortunately not one new electric plant has been built in Pennsylvania during this same period. Limiting the renewal period will provide a framework for planning new generation capacity.

Thank you for your consideration of my thoughts on this important topic.

Response:

10 CFR Part 54, Requirements for Renewal of Operating Licenses for Nuclear Power Plants, states that a renewed license will be issued for a fixed period of time, which is the sum of the additional amount of time beyond the expiration of the operating license (not to exceed 20 years) that is requested in a renewal application, plus the remaining number of years on the current operating license. The total term of any renewed license may not exceed 40 years. An applicant may submit a license renewal application requesting a license extension for any length of time up to 20 years—there are no regulations stating that an applicant must apply for a 20-year license extension. However, no plant that has applied for license renewal has requested less than a 20-year license extension. TMI-1 has requested a 20-year license extension. If a renewed license is granted to TMI-1, the new expiration of the operating license would be April 19, 2034. However, if at any time TMI-1 cannot demonstrate compliance with NRC regulations and terms of the NRC-issued license, the NRC can revoke, suspend, or modify a license.

Commenter: Diane Little, local citizen

Hi, my name is Diane Little. I live in Lower Paxton Township. I'm not necessarily opposed to the re-licensing of the power station, because common sense dictates that we do need the energy.

But common sense also dictates that we are a little bit more prudent in one area that I have done some research on. This is with regard to the design-basis accidents potential. Basically, what the containment structure can withstand the impact of, how it is protected. And I just ask that, as part of the re-licensing, the NRC requires additional measures to strengthen the security from potential accidents or terrorist attacks with regard to aircraft. I believe that all nuclear power plants should have additional protection from aircraft. But, TMI is unique in that it is so close to the Harrisburg International Airport.

And, any that has ever gone there, it's like how is this planned? I don't get it. Anyway, according to the report, this is touched on briefly in the supplemental draft. It says, the Commission has determined that the environmental impact of DBA's, which is design-basis accidents, are of small significance for all plants because the plants are designed to successfully withstand these accidents.

However, if we go back to that old book that some of you have, remember this old book, on page 292, because I happened to read it, it says, and I have a copy of this. And this was put out through the Nuclear Regulatory Commission in 1980. And it says, give me a minute here. I'll just read it right from the book, then you know I'm not making it up. How's that? It says,

page 292, volume 2, part 1, Three Mile Island, a report to the Commissioners and to the public. And this is a special inquiry group of the NRC.

The evidence is that the TMI-2 facility is not capable of withstanding the impact of an aircraft weighing in excess of 200,000 pounds. Okay. It says it right there. And then it says, the containment structure and other structures designed to withstand certain aircraft impact events are of an adequate strength to withstand the impact of airplanes which can reasonably be expected to frequent Harrisburg International Airport.

Now, I did go down to the airport. And I did do some research. We all know that the airport, it's really not thriving. It's not doing a booming business. But, if you were to take -- let's just use common sense here. But if you were just to take, they said they have 195 operations per day. I think that's high. But that's what's on their website. If you were just to count the jet airplanes, and they have military aircraft. But, if they have 71,000 operations per year and say 13 percent of them are jet airplanes, that's about -- just bear with me -- that's like 9,000.

Well, originally in this report -- this is what gets me -- they calculate risk factors. You know you have to have risk factors. And the risk factor for the accident that did occur was a billion to one, they say. But it did occur. Anyway, the NRC -- and I say this respectfully, because, like I said, I'm not necessarily opposed to nuclear power, it says, at this time the Staff concluded that about 2,400 operations per year represented no undue risk to the health or to the safety of the public.

Okay. It says farther down, if it were to increase -- now 200,000 pounds is not a lot. The 747 is about 700,000 pounds. And they don't have them there much anymore. I don't know if they do at all. This is from talking to someone. Although, it does say on their website they do have a large aircraft, it says. Okay.

Conservatism in the crash probability analysis are consistent with the Staff's judgment that a significant increase in the frequency of operations is needed to justify a re-evaluation of the risk to the public of larger than design-basis aircraft -- that's aircraft over 200,000 pounds.

Corrective measures, such as restrictions of air space in the site of the vicinity or hardening of plant structures could potentially be undertaken. Alternatively, plant shutdown may be required if the crash probability becomes unacceptably high or large.

Now, what do we have? We have a unique situation with Three Mile Island Nuclear Station. The airport was well before nuclear power plant. And I'm not opposed to re-licensing if more prudent measures are taken.

Let's just use common sense. Probably a lot of you are thinking, it's a good idea to have a little bit more protection from aircraft, but it's kind of like doubling that emphasis if you have a nuclear power plant that's so close to an airport. And I know this hasn't been touched on much in the report. I did read the supplemental.

But, anyway, just one last point, there's a Congressional Research Service Report that was written August 8th, 2007. And this is Congressional Research Service, the Library of Commerce, prepared for members and committee of Congress. Anyway, and I'll give this report. It says the DBT, which is the design-basis threat final rule excluded aircraft attacks, which raise considerable controversy. In approving the rule NRC rejected a petition from the

Appendix A

Union of Concerned Scientist to require that nuclear plants be surrounded by aircraft barriers made of beams and cables. It's called the bedge hedge concept.

And critics of the rules charge that deliberate aircraft crashes were a highly plausible mode of attack. Anyway, basically what I see and I have read a majority of the report, the risk is "small." And small is pretty relative.

I really think that what was written in 1980 is a promise. And I think that it should be investigated because TMI does have a unique threat. And the new nuclear power plants are putting more safety measures into the design with the extra steel inside the containment structure.

Here's my closing. My closing is, okay, since there's going to be a lot of remodeling and construction at the TMI Nuclear Station I think it would be a good time, it would make sense to also consider doing some construction to improve security with regard to aircraft impact. Thank you.

Response:

Ms. Little's comment concerns the safety of TMI-1 in the event of an aircraft crash into the plant. She would like to see improvements in plant structures that could increase resistance to aircraft impact.

The NRC issued a final rule in February 2009 that requires applicants for new power reactors to assess the ability of their reactor designs to avoid or mitigate the effects of a large commercial aircraft impact. This new rule does not apply to existing power reactors.

The NRC believes that the best approach to dealing with threats from aircraft is through strengthening airport and airline security measures. Consequently, the NRC continues to work closely with the appropriate Federal agencies to enhance aviation security and thereby the security of nuclear power plants and other NRC-licensed facilities. Shortly after the September 11, 2001 attacks, NRC, working with representatives of the Federal Aviation Administration (FAA) and Department of Defense (DOD), determined that a Notice to Airmen (NOTAM), issued by the FAA, was the appropriate vehicle to protect the airspace above sensitive sites. This NOTAM strongly urged pilots to not circle or loiter over the following sites: nuclear/electrical power plants, power distribution stations, dams, reservoirs, refineries, or military installations.

Physically shielding (i.e., airplane-resistant cover) vital nuclear or non-nuclear installations from attacks by large aircraft being used as missiles is not the approach adopted by the Federal government to protect the nation. With respect to potential terrorist attacks by air, Federal government efforts have increased substantially since September 11, 2001. Those efforts include enhanced airline passenger and baggage screening, strengthened cockpit doors, and the Federal Air Marshals program, among others. Federal law enforcement and intelligence agencies have increased efforts to identify and mitigate potential aircraft related threats before they can be carried out. In more than one case, the DOD and FAA have acted to protect airspace above nuclear power plants in response to threats at the time thought to be credible but which were later determined to be non credible. These and other government wide efforts have improved protection against air attacks on all industrial facilities, both nuclear and non nuclear. The NRC, other agencies of the Federal government, the local governments, and the

licensees have taken comprehensive and in-depth actions to enhance NRC's defense-in-depth philosophy, including against air attacks. These actions have resulted in significant improvement of nuclear plant security.

Sections 5.2 Severe Accidents discusses the impacts of severe accidents, including sabotage. The GEIS findings state that compliance with the NRC regulatory requirements under 10 CFR Part 73, Physical Protection of Plants and Materials, provide reasonable assurance that the risk from sabotage is SMALL. Even if such events were to occur, the Commission would expect that resultant core damage and radiological releases would be no worse than those expected from internally initiated events. Based on the above, the commission concludes that the risk from sabotage at existing nuclear power plants is small and additionally, that the risks from other external events (such as floods, earthquakes, and tornados), are adequately addressed by a generic consideration of internally initiated severe accidents.

Furthermore, the NRC's environmental review is confined to environmental matters relevant to the extended period of operation requested by the applicant. Appropriate safeguards and security measures have been incorporated into the TMI-1 site security and emergency preparedness plans. Any required changes to emergency and safeguards contingency plans related to terrorist events will be incorporated and reviewed under the operating license— independent of license renewal. The comment provides no new information and does not pertain to the scope of license renewal under 10 CFR Part 51 and 54. No changes were made to the supplemental EIS.

Commenter: Kevin Magerr, U.S. Environmental Protection Agency, Region III



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION III
1650 Arch Street
Philadelphia, Pennsylvania 19103-2029

March 4, 2009

Chief, Rulemaking, Directives, and Editing Branch
U.S. NRC
Mail Stop T6-D59
Washington, D.C. 20555-0001

RE: Generic Draft Environmental Impact Statement for License Renewal of Nuclear Plants Supplement 37 Regarding Three Mile Island Nuclear Station, Unit 1 December 2008 CEQ #20080503

Dear Sir/Madam:

The U.S. Environmental Protection Agency (EPA), Region 3, reviewed the above-referenced document pursuant to the National Environmental Policy Act (NEPA), Council on Environmental Quality (CEQ) regulations (40CFR Parts 1500-1508), and Section 309 of the Clean Air Act. Based on our review of the Draft Environmental Impact Statement (DEIS), EPA has rated the environmental impacts of the preferred alternative as "EC" (Environmental Concerns) and the adequacy of the impact statement as "2" (Insufficient Information). A description of our rating system can be found at: <http://www.epa.gov/compliance/nepa/comments/ratings.html>.

The Generic DEIS states that the purpose and need for the proposed action (issuance of a renewed license) is to provide an option that allows for power generation capability beyond the term of the current nuclear power plant operating license, and to meet future system generating needs, as determined by State, utility and where authorized, Federal (other than NRC) decision-makers.

The Generic DEIS states on page 3-3 that the replacement generators needed for this project will be manufactured in France and transported to the Three Mile Island-1 site. Transportation will be a combination of boat, barge, rail, and road. AmerGen (project sponsor) will be required to meet all Federal, State, and local requirements that may be applicable to dredge or fill activities, temporary or permanent removal of route interferences (such as narrow tunnels, and low-hanging overhead wires), and movement of wide or heavy loads over rail and roadways. Examples include temporary redirecting of streams, cofferdams, weight-bearing modifications to bridges, etc. There may also be air quality impacts associated with the transportation of the generators that are not discussed in this document.

Printed on 100% recycled/recyclable paper with 100% post-consumer fiber and process chlorine free.
Customer Service Hotline: 1-800-438-2474

AmerGen has contracted a vendor to conduct a detailed study of the steam generator transport process. The transportation study is scheduled to be completed in spring 2009. Until the study is complete, AmerGen cannot provide specific information regarding potential transportation routes for the replacement steam generators, work areas within the routes, or Federal, State, or local permits required for potential routes. EPA requests that the Final Environmental Impact Statement include the additional information on the transport process, its potential impacts and efforts to avoid environmental impacts.

The project team should work with state and federal resource agencies as the project develops to avoid and minimize impacts to the public and environment. We also recommend coordinating with the appropriate state and federal agencies annually to address any impacts to listed species and their habitats.

Thank you for the opportunity to offer these comments. If you have any questions, please contact me at (215) 814-5724.

Sincerely,



Kevin Magerr
Environmental Engineer

Response:

The TMI-1 draft supplemental EIS received a rating of EC-2 (Environmental Concerns, Insufficient Information) from the U.S. Environmental Protection Agency because information regarding the transportation of the steam generators was unavailable at the time of publication for review and incorporation into the draft EIS findings. Since then, the NRC has received updated information from Exelon Generation and AREVA, the steam generator vendor, regarding the transportation route of the steam generators from Port Deposit, Maryland, to the TMI-1 site in Pennsylvania. This information has been incorporated into Chapter 3, Refurbishment. Exelon Generation has stated that it will coordinate with all appropriate state and Federal agencies to avoid or minimize environmental impacts, and will obtain all necessary permits required for the transportation and installation of the new steam generators.

Commenter: Mary Osborn Ouassiai, Concerned Mothers and TMI Alert

Mary Osborn. I'd like to know how many curies a day TMI Unit 1 releases, how many curies a month TMI-1 releases, how many curies a year TMI-1 releases. I know Unit 2 what they were releasing. But I don't know what Unit 1 does.

Response:

Information on how much radioactivity is released from a nuclear power plant is public information that is readily available in the ADAMS electronic reading room available through the NRC website: <http://www.nrc.gov/reading-rm/adams.html>. Every NRC licensed nuclear power plant, including TMI-1, is required to submit an annual radioactive effluent release report that contains a summary of all the types and amounts (i.e., curies) of radioactive material released into the environment. The report also contains the dose to members of the public calculated from the radioactive effluents. It is important to note that the NRC regulates the amount of radioactive effluent discharged from a nuclear power plant by radiation dose, not on the amount of curies. The dose is calculated based on the types and amounts of radioactive material discharged into the environment and dispersion models that account for the receptor (i.e., river, lake, or ocean) for the waste and the exposure pathway to a person. The dose will be different for each plant not just because of the amount of curies released but because of the different mixture of radionuclides each plant releases. Each radionuclide has its own specific dose conversion factor that is part of the dose calculation. The resulting dose from the effluents is required to be below NRC's radiation protection standards. No changes to the supplemental EIS were made based on this comment.

Letter Submitted by Mary Osborn Ouassiai dated February 27, 2009 (Please see ADAMS Accession Number ML090680766 for the complete document submission including articles Ms. Osborn references at the end of her comment.)

DOCKET # 50-289

Page 1. of 24.
plus 25.

Chief, Rules, Directives and Editing Branch
Division of Administrative Services
MAILSTOP T-6D59
U.S. NRC
WASHINGTON, DC 20555

DRAFT SEIS 37 NUREG-1437 TMI-UNIT ONE (Relicensing)

2-27-09
MSO

2.0 Affected Environment: For purposes of the evaluation in this report, the 'affected environment' is the environment that currently exists at and around TMI-1.
ISSUE > No information regarding distance - 1 foot or 50 miles? I live about 6 1/2 air miles N.N.W. and had metallic taste in March 1979; still have mutations growing all around @ + 25 miles. (See: ADAMS Accession Numbers ML081300739, & ML08130083, ML081690678.) What exactly is your definition of "affected environment"? My definition is the 50 mile radius - due to the fact you assign radiation doses to each member of the public living within 50 miles of the nuclear power plant. Also, the ARAC - Department of Energy fallout maps, showed TMI-2 fallout beyond 50 miles. (see attachment 11c)

2.1.2.1 Radioactive Liquid Waste: Amounts released into the river are sufficient to mutate the fish - I still receive comments from those fishing near TMI. (Eyes on the wrong side, no fins, etc.)

2.1.2.2 Radioactive Gaseous Waste: My questions at the 2-24-09 hearing at the Sheraton in Harrisburg = How many curies a day does TMI-1 release? How many curies a month does TMI-1 release? How many curies a year does TMI-1 release? These routine releases cause health effects downwind! It doesn't take just a nuclear accident to cause harm! TMI-1 releases contributed to numerous adverse effects to pets, farm animals & to humans in the late 1970's, prior to TMI-2 accident (see attachment 1. "FARMERS RIDICULE NRC ANIMAL...") Similar detrimental effects have occurred around other nuclear facilities (see attachment 2. "Dairy Farming Downwind From Nuclear Power".)

see attachment 11.

2-27-09
MAB

2.2.6 Terrestrial Resources: Just for the record & for future reference - pines, oaks & maples contaminated/irradiated by TMI-2 fallout continue to grow deformed &/or die - just like the Chernobyl trees! Also dogwoods & magnolias.

TABLE 2-6. Listed Aquatics & Terrestrial Species: My list of mutated, modified or abnormal flora is attached as attachment 3. The continued operation

page 3.

Table } of TMI-1 will add to the "CUMULATIVE"
2-6. } Burden of TMI fallout - not just to the
flora, but to humans + animals as
well.

3.1 Refurbishment Activities at TMI-1:
Will this permanent structure for
the steam generator be able to
withstand an impact of airplanes?

4.0 } Environmental Impacts of Operations:
thru } See each + every comment above, plus
4.7.2 } attachments.


4.8 Human Health: The NRC, TMI +
the nuclear industry continue to use
gamma doses as the radiation source
when in fact the predominate source
is beta. α , β + γ must all be
included in dose assignments +
assessments! Failure to accurately
assess the dosimetry has been one of
the unethical nuclear industries +
the NRC's method of "getting away
with murder!" "The ratio of beta
to gamma radiation may range as
high as 100 to 1,000 to one." And,
mR/hr - versus - mR/yr. (see attachment
5. Bunckel) See D.C. Kocher's
paper attached as # 6 - 240 radionuclides
of importance that are routinely released!

These 240 radionuclides affect the human body as well as flora & fauna. These issues must be ethically & honestly addressed. The nuclear establishment has "confused & deceived" for too long & has destroyed too much. All it takes is one radioactive zap --- internal is more damaging --- to injure, kill or mutate a cell at the vulnerable wrong time & place on our bodies. (see attachment ?)

2-27-09
TMIA

The NRC was supposedly created to protect humans & the environment. By its repeated failures to enforce its own laws & regulations, in essence, it is once again creating an accident waiting to happen... And -

You built a house without an outhouse -
How can you re-license? How can Congress allow you to continue to exist? It's time for a new AEC.



Submitted by,

Mary Osborn QUASSIAH
TMIA & Concerned Mothers

* P.S. my former husband worked @ TMI & I was told "they were taking so many short cuts - Unit 2 was never going to make it!!" - MAY 1978!

page 5.

Attachments:

1- Farmers Ridicule NRC Annual ... 2/1/2002

2- Dairy Farming Downwind ... 2/1/2002

3- TMI floral/mutation slide list ... TABLE 2-6

4- Dr. C. Johnson & Dr. R. Z. Morgan Ltr ... 4/8

5- Dr. J. Lurckel ... 4/8

6- D.C. Kocher (1 page only) ... 4/8

7- Safety Related Incidents ... TMI ... 4/10

8- Isotopes Found Again ... 4/10

9- Human Body Map
Where Radioactive Elements Concentrate
in The Body ... (see #6 above)

10- Dosimetry @ Reality (see #4 above)

11- TRANSPARENT OVERLAYS - A.R.A.C.
L.L.L. & D.O.E. (Maps) ... 2/012- Maine Yankee & Radon (it's downwind) } all ...
2/1/2002ALSO page 25: "silver dots" & stars = metallic
taste & thyroid ill.

Response:

Ms. Osborne's comments include concerns about the radiological impacts of the TMI Unit 2 1979 accident and the current operation of TMI-1, the NRC's definition of "affected environment" in Chapter 2, and the storage facility that will house the old steam generators at the TMI-1 site until the plant is decommissioned.

With regard to Ms. Osborn's question about the definition of the "affected environment": The description of the affected environment is affected by site- and plant-specific factors, and the degree of detail is scaled according to the anticipated magnitude of potential impacts. NUREG-1555, Supplement 1: Environmental Standard Review Plan, Standard Review Plans for Environmental Reviews for Nuclear Plants, Supplement 1: Operating License Renewal, states that the description of the affected environment should be sufficient to support land use and socioeconomic assessments. When describing the affected environment, the NRC will typically provide 6- and 10-mile (50- and 80-kilometer) maps of the site and vicinity. These maps may show site boundaries, the exclusion area, current site structures and facilities, county and local municipality boundaries, place names, residential areas, airports, industrial and commercial facilities, roads, railroads, major land uses, utilities rights-of-way, rivers and other bodies of water, wetlands, designated Federal, State, and local parks and natural areas, trust lands, historic and archaeological sites, Native American tribal lands, military reservations, and nonattainment and maintenance areas defined under the Clear Air Act, as amended.

With regard to Ms. Osborne's question about whether the steam generator storage facility will be resistant to aircraft impacts: the steam generator storage facility will be designed to include a watertight roof membrane and reinforced concrete thick enough to provide radiological shielding to ensure that dose rates will remain within the limits set in 10 CFR Part 20, "Standards for Protection Against Radiation." Similar to the responses to Ms. Little and Ms. Aamodt's comments regarding aircraft impacts at the TMI-1 site, the NRC's environmental review is confined to environmental matters relevant to the extended period of operation requested by the applicant. Appropriate safeguards and security measures have been incorporated into the site security and emergency preparedness plans. Any required changes to TMI-1 site emergency and safeguards contingency plans with regard to the new steam generator storage facility and potential terrorist events will be incorporated and reviewed under the operating license. The comment provides no new information and does not pertain to the scope of license renewal under 10 CFR Parts 51 and 54. No changes were made to the supplemental EIS.

Ms. Osborn provided the NRC staff with the following photocopied articles and information related to radiation health effects. "Farmers Ridicule NRC Animal – Many Problems Noted Before TMI" by Nancy Namoski; "Dairy Farming Downwind From Nuclear Power" by Chris Nord; slide from Mary Osborn with observations of deformed plants and flowers; letter from Carl J. Johnson, M.D. and Karl Z. Morgan, Ph.D. discussing the radiation exposures reported for military personnel during a nuclear bomb exercise at the Nevada Test Site; "The Bulletin of the Torrey Botanical Club" by James E. Gunckel, which discusses abnormalities in plants collected in the area of Three Mile Island after the accident; "Dose-Rate Conversion Factors for External Exposure to Photon and Electron Radiation from Radionuclides Occurring in Routine Releases from Nuclear Fuel Cycle Facilities" by D.C. Kocher in the April 1980 issue of Health Physics; "Safety Related Incidents at Three Mile Island Nuclear Power Plant" compiled from information

in the journal *Nuclear Safety*; "Isotopes Found In Area Again," by John M. Baer in the *Patriot* newspaper; "Where Radioactive Elements Concentrate in the Body," a drawing of a cutaway human body showing the organs where radionuclides can concentrate; "Three Mile Island Dosimetry Reality," a collection of notes and radiation information related to the accident at TMI; "Map of the area surrounding TMI"; a comment, "fallout is Blow'in the ...downwind..."; and a map of a neighborhood in the downwind location from TMI-1 showing the location of people experiencing metallic taste and thyroid illness. These articles are available in ADAMS at ML090680766.

The staff acknowledges the articles and information provided, but they do not provide scientifically defensible information that would cause the NRC to alter its position that the current radiation protection safety standards are protective of public health and safety and the environment.

The NRC's primary mission is to protect the public health and safety and the environment from the effects of radiation from nuclear reactors, materials, and waste facilities. The NRC's regulatory limits for radiological protection are set to protect workers and the public from the harmful health effects of radiation on humans. The limits are based on the recommendations of standards-setting organizations. Radiation standards reflect extensive scientific study by national and international organizations (International Commission on Radiological Protection [ICRP], National Council on Radiation Protection and Measurements [NCRP], and the National Academy of Sciences [NAS]) and are conservative to ensure that the public and workers at nuclear power plants are protected.

Health effects from exposure to radiation are dose-dependent, ranging from no effect at all to death. Above certain doses, radiation can be responsible for inducing diseases such as leukemia, breast cancer, and lung cancer. Very high (hundreds of times higher than a rem), short-term doses of radiation have been known to cause prompt (or early, also called "acute") effects, such as vomiting and diarrhea, skin burns, cataracts, and even death.

Although radiation may cause cancers at high doses and high dose rates, currently there are no reputable scientifically conclusive data that unequivocally establish the occurrence of cancer following exposure to low doses and dose rates, below about 0.1 Sievert (10 rem). However, radiation protection experts conservatively assume that any amount of radiation may pose some risk of causing cancer or a severe hereditary effect and that the risk is higher for higher radiation exposures. Therefore, a linear, no-threshold dose response relationship is used to describe the relationship between radiation dose and detriments such as cancer induction. Simply stated, any increase in dose, no matter how small, results in an incremental increase in health risk. This theory is accepted by the NRC as a conservative model for estimating health risks from radiation exposure, recognizing that the model probably over-estimates those risks. Based on this theory, the NRC conservatively establishes limits for radioactive effluents and radiation exposures for workers and members of the public, as found in 40 CFR Part 190, 10 CFR Part 20, and 10 CFR Part 50, Appendix I. Regulatory limits are placed on the radiation dose that members of the public might receive from all of the radioactive material released by the nuclear plant combined. Licensees are required to report liquid, gaseous, and solid effluent releases as well as the results of their radiological environmental monitoring program annually to the NRC. The annual effluent release and radiological environmental monitoring reports submitted to the

Appendix A

NRC are available to the public in the ADAMS electronic reading room available through the NRC website: <http://www.nrc.gov/reading-rm/adams.html>.

The amount of radioactive material released from nuclear power facilities is well measured, well monitored, and known to be very small. The doses of radiation that are received by members of the public as a result of exposure to nuclear power facilities are so low that resulting cancers have not been observed and would not be expected. Although a number of studies of cancer incidence in the vicinity of nuclear power facilities have been conducted, there are no studies to date that are accepted by the scientific community that show a correlation between radiation dose from nuclear power facilities and cancer incidence in the general public. Specific studies that have been conducted include:

- In 1990, at the request of Congress, the National Cancer Institute conducted a study of cancer mortality rates around 52 nuclear power plants and 10 other nuclear facilities. The study covered the period from 1950 to 1984, and evaluated the change in mortality rates before and during facility operations. The study concluded there was no evidence that nuclear facilities may be linked causally with excess deaths from leukemia or from other cancers in populations living nearby.
- In June 2000, investigators from the University of Pittsburgh found no link between radiation released during the 1979 accident at Three Mile Island power plant and cancer deaths among nearby residents. Their study followed 32,000 people who lived within five miles of the plant at the time of the accident.
- In 2000, the Illinois Public Health Department compared childhood cancer statistics for counties with nuclear power plants to similar counties without nuclear plants and found no statistically significant difference.
- In January 2001, the Connecticut Academy of Sciences and Engineering, issued a report on a study around the Haddam Neck nuclear power plant in Connecticut and concluded radiation emissions were so low as to be negligible.
- The American Cancer Society in 2001 concluded that although reports about cancer clusters in some communities have raised public concern, studies show that clusters do not occur more often near nuclear plants than they do by chance elsewhere in the population. Likewise, there is no evidence that links Sr-90 with increases in breast cancer, prostate cancer, or childhood cancer rates. Radiation emissions from nuclear power plants are closely controlled and involve negligible levels of exposure for nearby communities.
- Also in 2001, the Florida Bureau of Environmental Epidemiology reviewed claims that there are striking increases in cancer rates in southeastern Florida counties caused by increased radiation exposures from nuclear power plants. However, using the same data to reconstruct the calculations on which the claims were based, Florida officials were not able to identify unusually high rates of cancers in these counties compared with the rest of the State of Florida and the nation.

To ensure that the plants are operated safely within regulatory limits, the NRC licenses the plants to operate, licenses the plant operators, and establishes technical specifications for the operation of each plant. The NRC provides continuous oversight of plants through its Reactor Oversight Process (ROP) to verify that they are being operated in accordance with NRC rules

and regulations. The NRC has full authority to take whatever action is necessary to protect public health and safety and may demand immediate licensee actions, up to and including a plant shutdown.

The NRC staff has not identified any new and significant information during its independent review of the TMI-1 Environmental Report, Annual Radioactive Effluent Release reports, Annual Radiological Environmental Operating reports, and environmental site audit. The NRC has already fully considered and addressed these issues and the comments do not present any significant new information or arguments that would warrant a change to the TMI-1 supplemental EIS.

Commenter: Laura Piraino, Sierra Club

I just have a very brief statement. I was very encouraged that the NRC is considering energy efficiency as an alternative consideration and investment, which the Sierra Club very much supports, reducing demand through demand-side management, energy efficiency, green design construction, and technologies, particularly non-polluting renewable energy technologies.

But, coming from previously the College of Engineering at Penn State, I want to share with you a quote from a Department of Energy Office of Energy Efficiency and Renewable Energy report in 1997 since you're considering energy efficiency. A 30 percent improvement in U.S. building efficiency would reduce energy bills for Americans by 75 billion dollars in 15 years and eliminate the need for 80 new nuclear power plants over the next 20 years.

Building codes are up for review in the State of Pennsylvania. And that 30 percent improvement in building efficiency could be achieved through improved building codes. Thank you.

Response:

The NRC acknowledges Ms. Piraino's comment. No changes were made to Section 8.3, Energy Conservation/Energy Efficiency regarding this comment.

Commenter: Scott Portzline, TMI Alert

Afternoon Meeting

Sarah, you gave me -- yes, I'll have to take a few minutes. I have some questions. When there was a recent earthquake that didn't register at Three Mile Island, has that problem been resolved with the sensitivity of the monitoring? It's part of the environmental impact. Is there anyone that would like to answer that question? Is there a reason we have this meeting?

The only difference between this type of meeting here in the United States and in East Germany, they wouldn't even allow you to have a comment. But what good does it do you to give a comment or have concerns or public participation if we don't get answers? So, the whole setup is ridiculous. We don't get answers to our questions.

With the security issue that I brought up at the earlier meetings, I showed how there would be an environmental impact if they implemented security to deny intruders entrance to the bridges, access to the bridges or boats to go underneath that. Was that examined in your environmental impact analysis? Sarah is saying no. She's not at a microphone. No, that's out of scope. Again, what good does it do to raise an issue?

Appendix A

I didn't even ask a question. But I gave a comment and it wasn't even examined. The NRC has no problem with breaking its own rules. We filed a petition for rule making to have entrance guards, site protection officers at the entrances of nuclear plants. For seven years they sat on that decision and broke their own guidelines on more than 40 occasions. So, if I'm sitting here at a meeting and I interrupt or maybe seem a little bit out of line, I'm still 37 times shy of the 40 plus times the NRC hasn't followed their rules and guidelines.

Victor Gilinsky, former NRC Chairman, says that the public is virtually shut out of this process and that the NRC has been very effective at public input being squashed. That's exactly what's happening. It's really a waste of time to be here. But I still need to say what I think is right.

I think another problem, Sarah, that should come up with the water issue is you concluded that the impact would be small. But, you know, the weather is changing. We have more frequency of droughts and more frequency of floods. In particular with droughts, the impact could become at least moderate and possibly severe. Was that examined in the environmental impact? Can you respond on the record, please?

MS. LOPAS: Briefly. I'll just say real quickly that that's what the Cowanesque Water Storage Project looks to alleviate, is droughts. That's the short answer.

MR. PORTZLINE: So, in other words, they have an optimistic plan, an overly optimistic plan to release more water. Of course, if there's a drought, where'd you get it?

Let's see. I'd like to know how long the steam generators that are radioactive will be sitting in the parking lot at Three Mile Island and be monitored before they are taken away from the plant. Is there someone who can answer that question? I'd like to have it on the record, would that be all right. But you do have a court appointed transcription service. So these are official documents and records. Yet you don't want to have an official statement on those.

I've stated it enough times. We just keep bumping our heads on that same problem. I guess the last thing I'll do then, because this is largely just an exercise in suppression, suppression of actual, valuable, public exchange with our government.

Could you please turn on the computer? The little presentation is pretty much one of the portions of the same thing I presented a year ago. The most annoying problem to me with the environmental impact analysis is that the long-term waste storage, the financial considerations of that are not part of this rule or process.

So here we have a environmental impact analysis that excludes the largest issue of them all. And I don't know if we can play that video or not. You'll probably have to put a microphone next to the speaker. If Matt could put a microphone near the speaker that might do it. If it doesn't, we'll compensate or just stop. Okay. If it's not playable you'll be able to view it at the back.

But what it talks about is that the environmental impact analysis excluding the financial considerations of waste is a folly, one of mankind's greatest follies. Because the payment schedule will go on forever. And if you drew a one inch line on a sheet of paper and let that equal one year, keep drawing that line until you're 72,000 miles in space. And that's your payment schedule. How can that be fiscally responsible to pay for nuclear waste forever? We benefitted from nuclear waste for 50 years. But we're going to pay for it longer -- well, the sun will engulf the earth before you've made your last payment. I don't care if we need nuclear

energy or not. Fiscally it's a failure. Okay. I guess that's it. If you want to see the video, you can see it in the back. It will be online at TMIA.com pretty soon too.

Evening Meeting

For me that is the biggest problem that we have with environmental scoping, the most important issue of all the longest lasting is not even on the table. That's a real problem.

I agree with Eric. That's a very odd Houdini act he's involved with. I certainly understand the feeling because, as I said this afternoon, we filed a petition for rule-making with the Nuclear Regulatory Commission on entrance guards, site protection officers to be required at the entrances of all nuclear power plants. And, on 40 occasions, over a seven year period, the NRC did not follow its own guidelines and broke its own rules. So it really does feel like -- and is our experience, not just a feeling.

It's our experience that it doesn't do much good to participate in these hearings anymore, whether it be the annual safety assessment of Three Mile Island where we can ask questions and the NRC can answer but the company feels that it's not allowed to answer. At least that's what the Vice President told me at the last meeting. So he doesn't even know the rules of how the meeting goes. This gets to be old. And I'm not saying anything new tonight compared to what I said this afternoon.

But there is one leftover question, and that was the concerns about the steam generator that will be in the parking lot at Three Mile Island for a while. The answer given to me at the lunch break was that there is no regulation saying how long that can be there, that it will be monitored for radiation. I sure would like to see that monitoring be implemented into Eric's EMFR radiation monitoring network. They should have a feed to that information also.

So my question to Exelon here tonight, and I know there's a couple people at least from Exelon, what is the plan? How long will that steam generator be there? That's an expensive item to move because it's enormously heavy. And there's going to be failures in the nuclear industry just like there is in every other economic industry we have right now.

And there's going to be companies walking away. And so I think the State of Pennsylvania would be concerned too about what they're going to walk away from and to try to minimize Pennsylvania's exposure financially and radiologically.

So, how long will the steam generators remain at the parking lot, so to speak?

Why doesn't the Nuclear Regulatory Commission have a limitation? For how long they can store nuclear waste on their site. As long as you have a radioactive source term of this degree you have to have a license. And that's why even Unit 2 has to have a special license for post-fuel monitored storage. So there's a specific classification. I want to know what the specifics are for the Nuclear Regulatory Commission regarding the steam generator's storage and what Exelon's plans are. And if you haven't thought about that, you're not doing your job. And I want you to do your job.

Well, I would hope that Pennsylvania Department of Environmental Resources with their Bureau of Radiation Protection, I see Mike back there, I hope you're paying attention to what some of

Appendix A

the other states are doing, asking some hard questions and getting some court rules and getting some commitments.

And, I think with the economic crises that we have today, it changes as to whether we could have another flood that could impact even the storage of the steam generators, that Pennsylvania will make some demands here and play a little more hardball. I mean, this is the state that suffered the scariest and most dangerous accident in the United States. And you owe it to us, and so does the NRC, to give us good answers.

We're asking good questions. The last thing I want to say is, let me give you a quick lesson in security. That's what I do most of all, research in sabotage and terrorism in nuclear power plants. It will be 25 years come April. And cyber-security is of course the new frontier for terrorism. It happened right here in Harrisburg, actually, with a water treatment facility where a hacker was able to take control of what's called Scada system. The engineers here know what that means. And with that system they could disable the water treatment facility, poisoned us with large release of chlorine, possibly, done some nasty things.

And so, the NRC is quite familiar with what I'm talking about. So, when I give you my flash drive and you put it in your computer, and I appreciate that, so I can show the video, you've once again broken policy -- As she says, it's her personal computer, and so was -- what did you say? By the way, a true friend doesn't stab you in the back, he stabs you in the front. So that's why I'm making a public display of it. But I've had this conversation with the NRC on several other occasions. And it continues to happen. The laptop that was used by the person who infiltrated the Harrisburg Water Treatment Facility was also a home computer, a personal computer. And one day you'll find yourself at work with that and using that. Well, there's exceptions to everything. Maybe you won't. But it's not proper for the Nuclear Regulatory Commission to allow people access to their computer like this. There could be a worm. There could be a data monitor on my flash drive. I could have pulled information off of her computer right there. And so, what I'm proposing is that in the future people like me who want to show video presentation bring their own laptop and then it's only going through the projector, which has no -- well, I'm sure that capability is around the corner too. But I don't think that should be happening. Okay, that's it.

Response:

Mr. Portzline's concerns include the recent low-magnitude earthquake experienced in the Lancaster area, drought and water use issues at TMI-1, the disposal of spent fuel, and nuclear security issues.

Mr. Portzline's earthquake comment refers to the December 27, 2008, 3.3 magnitude earthquake that was felt in the Lancaster County area. Section 5.2, Severe Accidents, states that severe accidents initiated by external phenomena such as tornadoes, floods, earthquakes, and fires were not specifically considered for TMI-1 in the GEIS (NRC 1996), however, the GEIS did evaluate existing impact assessments performed by the NRC and by the industry at 44 U.S. nuclear plants and concluded that the risk from beyond design basis earthquakes at existing nuclear power plants is SMALL. Even if such events were to occur, the Commission would expect that resultant core damage and radiological releases would be no worse than those expected from internally initiated events. Based on the above, the commission concludes that

the risk from beyond design basis earthquakes at existing nuclear power plants is small and additionally, that the risks from other external events, such as floods, are adequately addressed by a generic consideration of internally initiated severe accidents. In addition, the staff's review of the SAMA analysis is discussed in Section 5.3, Severe Accidents Mitigation Alternatives, and supporting analyses are contained in Appendix F.

Mr. Portzline also refers to comments made at the May 1, 2008 scoping meetings regarding environmental impacts of security-related improvements at TMI-1. As was discussed in the August 2008 "Scoping Process Summary Report" (ADAMS No. ML081920230), security issues such as safeguards planning are not tied to license renewal, but are considered to be issues that need to be dealt with constantly as a part of the current operating licenses. Security issues are periodically reviewed and updated (and extended) at every operating plant. These reviews will continue throughout the period of any extended license. When issues related to security are discovered at a nuclear plant, they are addressed immediately, and any necessary changes are reviewed and incorporated under the operating license—such changes are not postponed until the period of extended operation. Proposed security changes (or any type of license amendment) that do not meet the NRC's criterion for Categorical Exclusion (detailed in 10 CFR Part 51.22) will require a NEPA review, and the NRC will perform an environmental assessment to review the impacts of the proposed action, i.e., the license amendment. The comments provide no new information and do not pertain to the scope of license renewal under 10 CFR Part 51 and 54. No changes were made to the final supplemental EIS.

With regard to Mr. Portzline's comment about the increasing frequency of droughts, TMI-1 participates in the Cowanesque Lake water storage program, which is described further in Section 2.1.7.2, Surface Water Use, Section 4.3.2, Ground Water Use Conflicts, and Section 4.4.1, Water Use Conflicts. SRBC and the U.S. Army Corps of Engineers are the responsible agencies for making releases from the Cowanesque Lake during periods of low flow in the Susquehanna River.

Mr. Portzline showed a brief presentation at the evening meeting that discussed the issue of spent fuel disposal. The safety and environmental effects of spent fuel storage on site have been evaluated by the NRC and, as set forth in the Waste Confidence Rule (10 CFR 51.23), the NRC generically determined that such storage could be accomplished without significant environmental impacts. In the Waste Confidence Rule, the Commission determined that spent fuel can be safely stored onsite for at least 30 years beyond the plant's life, including license renewal. Onsite spent fuel storage is considered a Category 1 issue, which was evaluated in the GEIS, NUREG-1437; therefore, accidents would be included within the analysis of the Category 1 issue of on site spent fuel storage. The GEIS is based upon the assumption that storage of the spent fuel onsite is not permanent. The GEIS considered a variety of spent fuel and waste storage scenarios, including onsite storage of these materials for up to 30 years following expiration of the operating license, transfer of these materials to a different plant, and transfer of these materials to an Independent Spent Fuel Storage Installation (ISFSI). For each potential scenario, the GEIS determined that existing regulatory requirements, operating practices, and radiological monitoring programs were sufficient to ensure that impacts resulting from spent fuel and waste storage practices would be SMALL, and therefore were a Category 1 issue.

Appendix A

Regarding Mr. Portzline's questions about the used steam generators: the used steam generators will be considered radioactive material and they must be controlled, handled, and stored in accordance with the NRC's radiation protection standards. The NRC has safety limits for the radiation dose to members of the public from all sources of radiation on the TMI site. This includes radiation from routine plant operation and any buildings containing radioactive material, including used steam generators. The radioactive material must be stored in a safe and secure condition under the full control of the licensee. The NRC routinely inspects the licensee's compliance with our safety regulations.

There are other nuclear power plants in the U.S. that store their used steam generators on their site in a safe and secure building. Because the buildings are typically designed with thick shielded walls, only very low levels of radiation are emitted in the local area of the building. Radiation levels outside of the plant site are typically not detectable above natural background radiation.

The NRC does not have a specific time limit for the storage of the used steam generators. The time limit is essentially tied to the Part 50 reactor operating license. When the operating license expires and the plant shuts down and starts decommissioning the site, the licensee will deal with the used steam generators in accordance with the NRC's safety regulations.

Regarding computer security at the NRC, on May 1, 2009, the NRC issued a security alert regarding USB thumb drive risks. The security alert stated, "Users should be aware of risks associated with use of USB thumb drives, a specific type of removable flash drive. Often USB devices are given away free at conferences and meetings, and these may contain malicious software. Also, USB devices infected with malware are intentionally planted in locations for individuals to find, use and infect their computers. These USB devices have been a source of the Conficker Worm.

To avoid introducing malicious software onto NRC systems, users should only employ NRC-issued USB thumb drives with NRC computers and networks and must not use NRC issued USB thumb drives on personally owned computers and networks."

Commenter: Joyce Scott, Harrisburg Diocese and Council of Catholic Women

Hello, I'm Joyce Scott from the HDCCW, which stands for the Harrisburg Diocese and Council of Catholic Women. On behalf of the Diocese and Council, I am representing our Commission Chair Linda Brash, who has had surgery and could not be here today.

The Harrisburg Diocese and Council is made up of nine districts. And we cover Conewago, which is Adams County, Cumberland Perry, the Dauphin County, Lancaster, Lebanon, North Umland, Sections of Franklin and York. So we're pretty wide-spread. This all came about because at the national level there's been a program in existence which I was a committee member of eight or nine years ago. And it's called CASE, and that's Children for A Safe Environment. And there's always been a concern for our children to live in a safe environment.

We got the opportunity -- I'm an immediate past president of the council. We got the opportunity two years ago to write a resolution. And, as I mentioned, Linda Braasch, one of her concerns, because she lives in Middletown, has been TMI. And we decided that we would write this

resolution, which we are in the process of submitting to National. And it does concern nuclear safety and children's environment.

I'd like to share with you right now a few comment that Linda has sent to me. And this may clear up some of the reasons I'm here today. Linda wrote, the promotion of nuclear energy, solar, wind and other technologies is what's needed to become energy independent. So we do recognize that. Create jobs and stabilize our economy, especially at this time. But we are seeking truth and justice and a safe, secure energy for the future, upholding our human dignity, respect for life and the integrity of our environment. And basically, that's what we are all about.

We feel before licensing is considered or implemented that there is a need for the Yucca Mountain site to be established and operating as a permanent repository for spent nuclear fuel before all of this takes place.

In addition, for the common good and our environment, establish a law to deny a license to a nuclear site that has had an accident with uncontrolled releases of radiation.

We can secure for our children the truth and justice of a safe, secure energy future. We do feel this is possible. Your response is gratefully appreciated. And I thank you.

Response:

In the Waste Confidence Rule (10 CFR 51.23), the Commission determined that spent fuel can be safely stored onsite for at least 30 years beyond the plant's life, including license renewal. Onsite spent fuel storage is considered a Category 1 issue, which was evaluated in the GEIS, NUREG-1437; the GEIS is based upon the assumption that storage of the spent fuel onsite is not permanent. The GEIS considered a variety of spent fuel and waste storage scenarios, including onsite storage of these materials for up to 30 years following expiration of the operating license, transfer of these materials to a different plant, and transfer of these materials to an Independent Spent Fuel Storage Installation (ISFSI). For each potential scenario, the GEIS determined that existing regulatory requirements, operating practices, and radiological monitoring programs were sufficient to ensure that impacts resulting from spent fuel and waste storage practices would be SMALL, and therefore were a Category 1 issue. The comment does not present any new and significant information, and no changes were made to the supplemental EIS.

Commenter: Linda Spears (no affiliation stated)

I fully support Nuclear Energy. Thank you for your consideration

Response:

The comment is in support of nuclear energy and is noted.

Comment: Karen Walsh, Pennsylvania Energy Alliance

Hello, my name is Karen Walsh. I'm the Executive Director of the Pennsylvania Energy Alliance. I want to thank you for the opportunity to speak here today in support of the re-licensing of Three Mile Island, Unit 1. As the Executive Director of the Pennsylvania Energy Alliance, I speak for a group of independent community leaders and organizations representing environmental, business, scientific, labor and healthcare interests. We have formed this

Appendix A

coalition to support nuclear energy and to advocate for additional clean, safe and reliable sources of electricity generation in our commonwealth.

As you know, Pennsylvania is the Nation's second largest producer of nuclear energy. One third of our electricity comes from this carbon-free source. Unfortunately, Pennsylvania also has the distinction of ranking fourth highest in the nation in carbon dioxide emissions, second highest in sulfur dioxide emissions, and fifth highest in nitrogen oxide emissions.

During the next ten years our electricity demand is expected to rise 1.5 percent a year. To meet our ever-increasing demand for electricity in a way that does not destroy our environment, we need a diverse energy mix that includes nuclear power, cleaner fossil fuels, renewable sources and energy efficiency. However, conservation alone will not offset the expected growth in our electricity use and renewable sources like wind and solar are unreliable.

Nuclear energy is the only source that can reliably generate electricity around the clock for millions of consumers with no harmful greenhouse gas emissions. Each year in the United States nuclear generated electricity avoids almost 700 million tons of carbon dioxide, three million tons of sulfur dioxide and one million tons of nitrogen oxide. TMI-1 serves as just one example of how nuclear power can provide a reliable source of electricity that does not contribute to global warming. By operating nuclear power instead of coal, the area around TMI-1 avoids 271 tons of carbon dioxide per hour. Avoiding 271 tons of carbon dioxide per hour is the equivalent of taking 29 SUVs or pickup trucks off the road for an entire year.

Furthermore, years of environmental monitoring has produced no evidence that TMI's Unit 1 operation negatively impacts Middletown and the surrounding communities. TMI officials annually perform 1,700 analyses on roughly 1,300 environmental samples from air, water, fish, cow's milk, soil and food products. In recent years TMI has teamed up with two state agencies, the Pennsylvania Bureau of Radiation Protection and the Pennsylvania Emergency Management Agency, to install a computer connection that provides both agencies with real-time radiation readings from in-plant monitors.

It's not surprising that a recent poll conducted by Terry Madonna Opinion Research found that nearly three quarters of the people who live near TMI Unit 1 have a favorable opinion of the facility. Knowing TMI's history of responsible environmental monitoring, the Pennsylvania Energy Alliance is pleased to know that the NRC's analyses have produced similar findings that TMI Unit 1 does not negatively impact the environment. This independent confirmation reaffirms our belief in TMI Unit 1 and its goal of providing a clean, safe and reliable source of electricity for over 800,000 homes in central Pennsylvania. Thank you.

Response:

Ms. Walsh's comments are supportive of license renewal of TMI-1. The comments are noted.

A.3 References

10 CFR 2. *Code of Federal Regulations*, Title 10, *Energy*, Part 2, "Rules of Practice for Domestic Licensing Proceedings and Issuance of Orders."

10 CFR 9. *Code of Federal Regulations*, Title 10, *Energy*, Part 9, "Public Records."

10 CFR 20. *Code of Federal Regulations*, Title 10, *Energy*, Part 20, "Standards for Protection Against Radiation."

10 CFR 50. *Code of Federal Regulations*, Title 10, *Energy*, Part 50, "Domestic Licensing of Production and Utilization Facilities."

10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions."

10 CFR 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, "Requirements for Renewal of Operating Licenses for Nuclear Power Plants."

40 CFR 190. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 190, "Environmental Radiation Protection Standards for Nuclear Power Operations."

69 FR 52040. U.S. Nuclear Regulatory Commission, Washington, D.C. "Policy Statement on the Treatment of Environmental Justice Matters in NRC Regulatory and Licensing Actions." *Federal Register*. Volume 69, No. 163, pp. 52040-52048. August 24, 2004.

73 FR 16729. U.S. Nuclear Regulatory Commission, Washington, D.C. "Three Mile Island Nuclear Station, Unit 1; Notice of Intent to Prepare an Environmental Impact Statement and Conduct Scoping Process." *Federal Register*. Vol. 73, No. 61, pp. 16729-16731. March 28, 2008.

73 FR 74766. U.S. Nuclear Regulatory Commission, Washington, D.C., "Three Mile Island Nuclear Station, Unit 1; Notice of Availability of the Draft Supplement 37 to the Generic Environmental Impact Statement for License Renewal of Nuclear Plants, and Public Meeting for the License Renewal of Three Mile Island Nuclear Station, Unit 1." *Federal Register*. Vol. 74, No. 4, pp. 470. January 6, 2009.

Act Number 129, *An Act Amending Title 66 (Public Utilities) of the Pennsylvania Consolidated Statutes*. Available URL:

<http://www.legis.state.pa.us/CFDOCS/Legis/PN/Public/btCheck.cfm?txtType=PDF&sessYr=2007&sessInd=0&billBody=H&billTyp=B&billNbr=2200&pn=4526> (accessed May 1, 2009).

Exelon Generation (Exelon Generation Company, LLC). 2009. "Three Mile Island Nuclear Station Unit 1 License Renewal Application Supplemental Updated Environmental Information." May 15. ADAMS No. ML091390217.

FERC (Federal Energy Regulatory Commission). 2009. "Electric Market Overview: Energy Efficiency Resource Standards (EERS) and Goals." April 3. Available URL: <http://www.ferc.gov/market-oversight/mkt-electric/overview/elec-ovr-eeeps.pdf> (accessed April 29, 2009).

Appendix A

NRC (U.S. Nuclear Regulatory Commission). 1996. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*. NUREG-1437, Volumes 1 and 2, Washington, D.C. ADAMS No. ML061770605.

NRC (U.S. Nuclear Regulatory Commission). 2000. *Standard Review Plan for Environmental Reviews for Nuclear Power Plants, Supplement 1: Operating License Renewal*. NUREG-1555, Supplement 1, Washington, D.C.

NRC (U.S. Nuclear Regulatory Commission). 2008. "Environmental Impact Statement Scoping Process Summary Report, Three Mile Island Nuclear Station, Unit 1." ADAMS Accession No. ML081920230.

Appendix B

NEPA Issues for License Renewal of Nuclear Power Plants

B. NEPA Issues for License Renewal of Nuclear Power Plants

Table B-1. Summary of Issues and Findings. *This table is taken from Table B-1 in Appendix B, Subpart A, to 10 CFR Part 51. Data supporting this table are contained in NUREG-1437, Generic Environmental Impact Statement for License Renewal of Nuclear Plants. Throughout this report, "Generic" issues are also referred to as Category 1 issues, and "Site-specific" issues are also referred to as Category 2 issues. If an issue is not applicable to Three Mile Island Nuclear Station, Unit 1 (TMI-1), either because TMI-1 does not have that type of cooling system, or some other specified plant or site characteristic, that is noted at the end of the finding.*

Issue	Type of Issue	Finding
Surface Water Quality, Hydrology, and Use		
Impacts of refurbishment on surface water quality	Generic	SMALL. Impacts are expected to be negligible during refurbishment because best management practices are expected to be employed to control soil erosion and spills.
Impacts of refurbishment on surface water use	Generic	SMALL. Water use during refurbishment will not increase appreciably or will be reduced during plant outage.
Altered current patterns at intake and discharge structures	Generic	SMALL. Altered current patterns have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Altered salinity gradients	Generic	SMALL. Salinity gradients have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term. <i>Not applicable to TMI-1.</i>
Altered thermal stratification of lakes	Generic	SMALL. Generally, lake stratification has not been found to be a problem at operating nuclear power plants and is not expected to be a problem during the license renewal term. <i>Not applicable to TMI-1.</i>
Temperature effects on sediment transport capacity	Generic	SMALL. These effects have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Scouring caused by discharged cooling water	Generic	SMALL. Scouring has not been found to be a problem at most operating nuclear power plants and has caused only localized effects at a few plants. It is not expected to be a problem during the license renewal term.

Appendix B

Issue	Type of Issue	Finding
Eutrophication	Generic	SMALL. Eutrophication has not been found to be a problem at operating nuclear power plants and is not expected to be a problem during the license renewal term.
Discharge of chlorine or other biocides	Generic	SMALL. Effects are not a concern among regulatory and resource agencies, and are not expected to be a problem during the license renewal term.
Discharge of sanitary wastes and minor chemical spills	Generic	SMALL. Effects are readily controlled through NPDES permit and periodic modifications, if needed, and are not expected to be a problem during the license renewal term.
Discharge of other metals in wastewater	Generic	SMALL. These discharges have not been found to be a problem at operating nuclear power plants with cooling-tower-based heat dissipation systems and have been satisfactorily mitigated at other plants. They are not expected to be a problem during the license renewal term.
Water use conflicts (plants with once-through cooling systems)	Generic	SMALL. These conflicts have not been found to be a problem at operating nuclear power plants with once-through heat dissipation systems. <i>Not applicable to TMI-1.</i>
Water use conflicts (plants with cooling ponds or cooling towers using make-up water from a small river with low flow)	Site-specific	SMALL OR MODERATE. The issue has been a concern at nuclear power plants with cooling ponds and at plants with cooling towers. Impacts on instream and riparian communities near these plants could be of moderate significance in some situations. See § 51.53(c)(3)(ii)(A). <i>Not applicable to TMI-1.</i>
Aquatic Ecology		
Refurbishment	Generic	SMALL. During plant shutdown and refurbishment there will be negligible effects on aquatic biota because of a reduction of entrainment and impingement of organisms or a reduced release of chemicals.

Issue	Type of Issue	Finding
Accumulation of contaminants in sediments or biota	Generic	SMALL. Accumulation of contaminants has been a concern at a few nuclear power plants but has been satisfactorily mitigated by replacing copper alloy condenser tubes with those of another metal. It is not expected to be a problem during the license renewal term.
Entrainment of phytoplankton and zooplankton	Generic	SMALL. Entrainment of phytoplankton and zooplankton has not been found to be a problem at operating nuclear power plants and is not expected to be a problem during the license renewal term.
Cold shock	Generic	SMALL. Cold shock has been satisfactorily mitigated at operating nuclear plants with once-through cooling systems, has not endangered fish populations or been found to be a problem at operating nuclear power plants with cooling towers or cooling ponds, and is not expected to be a problem during the license renewal term.
Thermal plume barrier to migrating fish	Generic	SMALL. Thermal plumes have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Distribution of aquatic organisms	Generic	SMALL. Thermal discharge may have localized effects but is not expected to affect the larger geographical distribution of aquatic organisms.
Premature emergence of aquatic insects	Generic	SMALL. Premature emergence has been found to be a localized effect at some operating nuclear power plants but has not been a problem and is not expected to be a problem during the license renewal term.
Gas supersaturation (gas bubble disease)	Generic	SMALL. Gas supersaturation was a concern at a small number of operating nuclear power plants with once-through cooling systems but has been satisfactorily mitigated. It has not been found to be a problem at operating nuclear power plants with cooling towers or cooling ponds and is not expected to be a problem during the license renewal term.

Appendix B

Issue	Type of Issue	Finding
Low dissolved oxygen in the discharge	Generic	SMALL. Low dissolved oxygen has been a concern at one nuclear power plant with a once-through cooling system but has been effectively mitigated. It has not been found to be a problem at operating nuclear power plants with cooling towers or cooling ponds and is not expected to be a problem during the license renewal term.
Losses from predation, parasitism, and disease among organisms exposed to sublethal stresses	Generic	SMALL. These types of losses have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Stimulation of nuisance organisms (e.g., shipworms)	Generic	SMALL. Stimulation of nuisance organisms has been satisfactorily mitigated at the single nuclear power plant with a once-through cooling system where previously it was a problem. It has not been found to be a problem at operating nuclear power plants with cooling towers or cooling ponds and is not expected to be a problem during the license renewal term.
Aquatic Ecology (for plants with once-through and cooling pond heat dissipation systems)		
Entrainment of fish and shellfish in early life stages	Site-specific	SMALL, MODERATE, OR LARGE. The impacts of entrainment are small at many plants but may be moderate or even large at a few plants with once-through and cooling-pond cooling systems. Further, ongoing efforts in the vicinity of these plants to restore fish populations may increase the numbers of fish susceptible to intake effects during the license renewal period, such that entrainment studies conducted in support of the original license may no longer be valid. See § 51.53(c)(3)(ii)(B). <i>Not applicable to TMI-1.</i>
Impingement of fish and shellfish	Site-specific	SMALL, MODERATE, OR LARGE. The impacts of impingement are small at many plants but may be moderate or even large at a few plants with once-through and cooling-pond cooling systems. See § 51.53(c)(3)(ii)(B). <i>Not applicable to TMI-1.</i>

Issue	Type of Issue	Finding
Heat shock	Site-specific	SMALL, MODERATE, OR LARGE. Because of continuing concerns about heat shock and the possible need to modify thermal discharges in response to changing environmental conditions, the impacts may be of moderate or large significance at some plants. See § 51.53(c)(3)(ii)(B). <i>Not applicable to TMI-1.</i>
Aquatic Ecology (for plants with cooling-tower-based heat dissipation systems)		
Entrainment of fish and shellfish in early life stages	Generic	SMALL. Entrainment of fish has not been found to be a problem at operating nuclear power plants with this type of cooling system and is not expected to be a problem during the license renewal term.
Impingement of fish and shellfish	Generic	SMALL. The impingement has not been found to be a problem at operating nuclear power plants with this type of cooling system and is not expected to be a problem during the license renewal term.
Heat shock	Generic	SMALL. Heat shock has not been found to be a problem at operating nuclear power plants with this type of cooling system and is not expected to be a problem during the license renewal term.
Ground Water Use and Quality		
Impacts of refurbishment on ground water use and quality	Generic	SMALL. Extensive dewatering during the original construction on some sites will not be repeated during refurbishment on any sites. Any plant wastes produced during refurbishment will be handled in the same manner as in current operating practices and are not expected to be a problem during the license renewal term.
Ground water use conflicts (potable and service water; plants that use <100 gpm)	Generic	SMALL. Plants using less than 100 gpm are not expected to cause any ground water use conflicts. <i>Not applicable to TMI-1.</i>
Ground water use conflicts (potable and service water, and dewatering plants that use >100 gpm)	Site-specific	SMALL, MODERATE, OR LARGE. Plants that use more than 100 gpm may cause ground water use conflicts with nearby ground water users. See § 51.53(c)(3)(ii)(C).

Appendix B

Issue	Type of Issue	Finding
Ground water use conflicts (plants using cooling towers withdrawing make-up water from a small river)	Site-specific	SMALL, MODERATE, OR LARGE. Water use conflicts may result from surface water withdrawals from small water bodies during low flow conditions which may affect aquifer recharge, especially if other ground water or upstream surface water users come on line before the time of license renewal. See § 51.53(c)(3)(ii)(A).
Ground water use conflicts (Ranney wells)	Site-specific	SMALL, MODERATE, OR LARGE. Ranney wells can result in potential ground water depression beyond the site boundary. Impacts of large ground water withdrawal for cooling tower makeup at nuclear power plants using Ranney wells must be evaluated at the time of application for license renewal. See § 51.53(c)(3)(ii)(C). <i>Not applicable to TMI-1.</i>
Ground water quality degradation (Ranney wells)	Generic	SMALL. Ground water quality at river sites may be degraded by induced infiltration of poor-quality river water into an aquifer that supplies large quantities of reactor cooling water. However, the lower quality infiltrating water would not preclude the current uses of ground water and is not expected to be a problem during the license renewal term. <i>Not applicable to TMI-1.</i>
Ground water quality degradation (saltwater intrusion)	Generic	SMALL. Nuclear power plants do not contribute significantly to saltwater intrusion. <i>Not applicable to TMI-1.</i>
Ground water quality degradation (cooling ponds in salt marshes)	Generic	SMALL. Sites with closed-cycle cooling ponds may degrade ground water quality. Because water in salt marshes is brackish, this is not a concern for plants located in salt marshes. <i>Not applicable to TMI-1.</i>
Ground water quality degradation (cooling ponds at inland sites)	Site-specific	SMALL, MODERATE, OR LARGE. Sites with closed-cycle cooling ponds may degrade ground water quality. For plants located inland, the quality of the ground water in the vicinity of the ponds must be shown to be adequate to allow continuation of current uses. See § 51.53(c)(3)(ii)(D). <i>Not applicable to TMI-1.</i>

Terrestrial Ecology		
Refurbishment impacts	Site-specific	SMALL, MODERATE, OR LARGE. Refurbishment impacts are insignificant if no loss of important plant and animal habitat occurs. However, it cannot be known whether important plant and animal communities may be affected until the specific proposal is presented with the license renewal application. See § 51.53(c)(3)(ii)(E).
Cooling tower impacts on crops and ornamental vegetation	Generic	SMALL. Impacts from salt drift, icing, fogging, or increased humidity associated with cooling tower operation have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term. <i>Not applicable to TMI-1.</i>
Cooling tower impacts on native plants	Generic	SMALL. Impacts from salt drift, icing, fogging, or increased humidity associated with cooling tower operation have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term. <i>Not applicable to TMI-1.</i>
Bird collisions with cooling towers	Generic	SMALL. These collisions have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Cooling pond impacts on terrestrial resources	Generic	SMALL. Impacts of cooling ponds on terrestrial ecological resources are considered to be of small significance at all sites. <i>Not applicable to TMI-1.</i>
Power line right of way management (cutting and herbicide application)	Generic	SMALL. The impacts of right-of-way maintenance on wildlife are expected to be of small significance at all sites.
Bird collisions with power lines	Generic	SMALL. Impacts are expected to be of small significance at all sites.
Impacts of electromagnetic fields on flora and fauna	Generic	SMALL. No significant impacts of electromagnetic fields on terrestrial flora and fauna have been identified. Such effects are not expected to be a problem during the license renewal term.

Appendix B

Floodplains and wetland on power line right of way	Generic	SMALL. Periodic vegetation control is necessary in forested wetlands underneath power lines and can be achieved with minimal damage to the wetland. No significant impact is expected at any nuclear power plant during the license renewal term.
Threatened and Endangered Species		
Threatened or endangered species	Site-specific	SMALL, MODERATE, OR LARGE. Generally, plant refurbishment and continued operation are not expected to adversely affect threatened or endangered species. However, consultation with appropriate agencies would be needed at the time of license renewal to determine whether threatened or endangered species are present and whether they would be adversely affected. See § 51.53(c)(3)(ii)(E).
Air Quality		
Air quality during refurbishment (non-attainment and maintenance areas)	Site-specific	SMALL, MODERATE, OR LARGE. Air quality impacts from plant refurbishment associated with license renewal are expected to be small. However, vehicle exhaust emissions could be cause for concern at locations in or near nonattainment or maintenance areas. The significance of the potential impact cannot be determined without considering the compliance status of each site and the numbers of workers expected to be employed during the outage. See § 51.53(c)(3)(ii)(F).
Air quality effects of transmission lines	Generic	SMALL. Production of ozone and oxides of nitrogen is insignificant and does not contribute measurably to ambient levels of these gases.
Land Use		
Onsite land use	Generic	SMALL. Projected onsite land use changes required during refurbishment and the renewal period would be a small fraction of any nuclear power plant site and would involve land that is controlled by the applicant.
Power line right of way	Generic	SMALL. Ongoing use of power line right of ways would continue with no change in restrictions. The effects of these restrictions are of small significance.

Human Health		
Radiation exposures to the public during refurbishment	Generic	SMALL. During refurbishment, the gaseous effluents would result in doses that are similar to those from current operation. Applicable regulatory dose limits to the public are not expected to be exceeded.
Occupational radiation exposures during refurbishment	Generic	SMALL. Occupational doses from refurbishment are expected to be within the range of annual average collective doses experienced for pressurized-water reactors and boiling-water reactors. Occupational mortality risk from all causes including radiation is in the mid-range for industrial settings.
Microbiological organisms (occupational health)	Generic	SMALL. Occupational health impacts are expected to be controlled by continued application of accepted industrial hygiene practices to minimize worker exposures.
Microbiological organisms (public health)(plants using lakes or canals, or cooling towers or cooling ponds that discharge to a small river)	Site-specific	SMALL, MODERATE, OR LARGE. These organisms are not expected to be a problem at most operating plants except possibly at plants using cooling ponds, lakes, or canals that discharge to small rivers. Without site-specific data, it is not possible to predict the effects generically. See § 51.53(c)(3)(ii)(G).
Noise	Generic	SMALL. Noise has not been found to be a problem at operating plants and is not expected to be a problem at any plant during the license renewal term.
Electromagnetic fields – acute effects (electric shock)	Site-specific	SMALL, MODERATE, OR LARGE. Electrical shock resulting from direct access to energized conductors or from induced charges in metallic structures have not been found to be a problem at most operating plants and generally are not expected to be a problem during the license renewal term. However, site-specific review is required to determine the significance of the electric shock potential at the site. See § 51.53(c)(3)(ii)(H).

Appendix B

Electromagnetic fields – chronic effects	Uncategorized	UNCERTAIN. Biological and physical studies of 60-Hz electromagnetic fields have not found consistent evidence linking harmful effects with field exposures. However, research is continuing in this area and a consensus scientific view has not been reached.
Radiation exposures to public (license renewal term)	Generic	SMALL. Radiation doses to the public will continue at current levels associated with normal operations.
Occupational radiation exposures (license renewal term)	Generic	SMALL. Projected maximum occupational doses during the license renewal term are within the range of doses experienced during normal operations and normal maintenance outages, and would be well below regulatory limits.
Socioeconomic Impacts		
Housing impacts	Site-specific	SMALL, MODERATE, OR LARGE. Housing impacts are expected to be of small significance at plants located in a medium or high population area and not in an area where growth control measures that limit housing development are in effect. Moderate or large housing impacts of the workforce associated with refurbishment may be associated with plants located in sparsely populated areas or in areas with growth control measures that limit housing development. See § 51.53(c)(3)(ii)(I).
Public services: public safety, social services, and tourism, and recreation	Generic	SMALL. Impacts to public safety, social services, and tourism and recreation are expected to be of small significance at all sites.
Public services: public utilities	Site-specific	SMALL OR MODERATE. An increased problem with water shortages at some sites may lead to impacts of moderate significance on public water supply availability. See § 51.53(c)(3)(ii)(I).
Public services: education (refurbishment)	Site-specific	SMALL, MODERATE, OR LARGE. Most sites would experience impacts of small significance but larger impacts are possible depending onsite- and project-specific factors. See § 51.53(c)(3)(ii)(I).

Public services: education (license renewal term)	Generic	SMALL. Only impacts of small significance are expected
Offsite land use (refurbishment)	Site-specific	SMALL OR MODERATE. Impacts may be of moderate significance at plants in low population areas. See § 51.53(c)(3)(ii)(I).
Offsite land use (license renewal term)	Site-specific	SMALL, MODERATE, OR LARGE. Significant changes in land use may be associated with population and tax revenue changes resulting from license renewal. See § 51.53(c)(3)(ii)(I).
Public services: transportation	Site-specific	SMALL, MODERATE, OR LARGE. Transportation impacts (level of service) of highway traffic generated during plant refurbishment and during the term of the renewed license are generally expected to be of small significance. However, the increase in traffic associated with the additional workers and the local road and traffic control conditions may lead to impacts of moderate or large significance at some sites. See § 51.53(c)(3)(ii)(J).
Historic and archaeological resources	Site-specific	SMALL, MODERATE, OR LARGE. Generally, plant refurbishment and continued operation are expected to have no more than small adverse impacts on historic and archaeological resources. However, the National Historic Preservation Act requires the Federal agency to consult with the State Historic Preservation Officer to determine whether there are properties present that require protection. See § 51.53(c)(3)(ii)(K).
Aesthetic impacts (refurbishment)	Generic	SMALL. No significant impacts are expected during refurbishment.
Aesthetic impacts (license renewal term)	Generic	SMALL. No significant impacts are expected during the license renewal term.
Aesthetic impacts of transmission lines (license renewal term)	Generic	SMALL. No significant impacts are expected during the license renewal term.
Postulated Accidents		
Design basis accidents	Generic	SMALL. The NRC staff has concluded that the environmental impacts of design basis accidents are of small significance for all plants.

Appendix B

Severe accidents	Site-specific	SMALL. The probability weighted consequences of atmospheric releases, fallout onto open bodies of water, releases to ground water, and societal and economic impacts from severe accidents are small for all plants. However, alternatives to mitigate severe accidents must be considered for all plants that have not considered such alternatives. See § 51.53(c)(3)(ii)(L).
------------------	---------------	---

Uranium Fuel Cycle and Waste Management

Offsite radiological impacts (individual effects from other than the disposal of spent fuel and high level waste)	Generic	SMALL. Off-site impacts of the uranium fuel cycle have been considered by the Commission in Table S-3 of this part. Based on information in the GEIS, impacts on individuals from radioactive gaseous and liquid releases including radon-222 and technetium-99 are small.
Offsite radiological impacts (collective effects)	Generic	The 100 year environmental dose commitment to the U.S. population from the fuel cycle, high level waste and spent fuel disposal excepted, is calculated to be about 14,800 person rem, or 12 cancer fatalities, for each additional 20-year power reactor operating term. Much of this, especially the contribution of radon releases from mines and tailing piles, consists of tiny doses summed over large populations. This same dose calculation can theoretically be extended to include many tiny doses over additional thousands of years as well as doses outside the U. S. The result of such a calculation would be thousands of cancer fatalities from the fuel cycle, but this result assumes that even tiny doses have some statistical adverse health effect which will not ever be mitigated (for example no cancer cure in the next thousand years), and that these doses projected over thousands of years are meaningful. However, these assumptions are questionable. In particular, science cannot rule out the possibility that there will be no cancer fatalities from these tiny doses. For perspective, the doses are very small fractions of regulatory limits, and even smaller fractions of natural background exposure to the same populations. Nevertheless, despite all the uncertainty, some

judgment as to the regulatory NEPA implications of these matters should be made and it makes no sense to repeat the same judgment in every case. Even taking the uncertainties into account, the Commission concludes that these impacts are acceptable in that these impacts would not be sufficiently large to require the NEPA conclusion, for any plant, that the option of extended operation under 10 CFR Part 54 should be eliminated. Accordingly, while the commission has not assigned a single level of significance for the collective effects of the fuel cycle, this issue is considered Category 1 [Generic].

Offsite radiological impacts (spent fuel and high level waste disposal)	Generic	<p>For the high level waste and spent fuel disposal component of the fuel cycle, there are no current regulatory limits for offsite releases of radionuclides for the current candidate repository site. However, if we assume that limits are developed along the lines of the 1995 National Academy of Sciences (NAS) report, "Technical Bases for Yucca Mountain Standards," and that in accordance with the Commission's Waste Confidence Decision, 10 CFR 51.23, a repository can and likely will be developed at some site which will comply with such limits, peak doses to virtually all individuals will be 100 millirem per year or less. However, while the Commission has reasonable confidence that these assumptions will prove correct, there is considerable uncertainty since the limits are yet to be developed, no repository application has been completed or reviewed, and uncertainty is inherent in the models used to evaluate possible pathways to the human environment. The NAS report indicated that 100 millirem per year should be considered as a starting point for limits for individual doses, but notes that some measure of consensus exists among national and international bodies that the limits should be a fraction of the 100 millirem per year. The lifetime individual risk from 100 millirem annual dose limit is about 3×10^{-3}.</p> <p>Estimating cumulative doses to populations over thousands of years is more problematic. The likelihood and consequences of events that could seriously compromise the integrity of a deep geologic repository were evaluated by the</p>
---	---------	--

Department of Energy in the "Final Environmental Impact Statement: Management of Commercially Generated Radioactive Waste," October 1980. The evaluation estimated the 70-year whole-body dose commitment to the maximum individual and to the regional population resulting from several modes of breaching a reference repository in the year of closure, after 1,000 years, after 100,000 years and after 100,000,000 years. Subsequently, the NRC and other federal agencies have expended considerable effort to develop models for the design and for the licensing of a high level waste repository, especially for the candidate repository at Yucca Mountain. More meaningful estimates of doses to population may be possible in the future as more is understood about the performance of the proposed Yucca Mountain repository. Such estimates would involve very great uncertainty, especially with respect to cumulative population doses over thousands of years. The standard proposed by the NAS is a limit on maximum individual dose. The relationship of potential new regulatory requirements, based on the NAS report, and cumulative population impacts has not been determined, although the report articulates the view that protection of individuals will adequately protect the population for a repository at Yucca Mountain. However, EPA's generic repository standards in 40 CFR Part 191 generally provide an indication of the order of magnitude of cumulative risk to population that could result from the licensing of a Yucca Mountain repository, assuming the ultimate standards will be within the range of standards now under consideration. The standards in 40 CFR Part 191 protect the population by imposing amount of radioactive material released over 10,000 years. The cumulative release limits are based on EPA's population impact goal of 1,000 premature cancer deaths worldwide for a 100,000 metric ton (MTHM) repository.

Nevertheless, despite all the uncertainty, some judgment as to the regulatory NEPA implications of these matters should be made and it makes no sense to repeat the same judgment in every case. Even taking the uncertainties into account, the

		Commission concludes that these impacts are acceptable in that these impacts would not be sufficiently large to require the NEPA conclusion, for any plant, that the option of extended operation under 10 CFR Part 54 should be eliminated. Accordingly, while the Commission has not assigned a single level of significance for the impacts of spent fuel and high level waste disposal, this issue is considered in Category 1 [Generic].
Nonradiological impacts of the uranium fuel cycle	Generic	SMALL. The nonradiological impacts of the uranium fuel cycle resulting from the renewal of an operating license for any plant are found to be small.
Low-level waste storage and disposal	Generic	SMALL. The comprehensive regulatory controls that are in place and the low public doses being achieved at reactors ensure that the radiological impacts to the environment will remain small during the term of a renewed license. The maximum additional on-site land that may be required for low-level waste storage during the term of a renewed license and associated impacts will be small. Nonradiological impacts on air and water will be negligible. The radiological and nonradiological environmental impacts of long-term disposal of low-level waste from any individual plant at licensed sites are small. In addition, the Commission concludes that there is reasonable assurance that sufficient low-level waste disposal capacity will be made available when needed for facilities to be decommissioned consistent with NRC decommissioning requirements.

Appendix B

Mixed waste storage and disposal	Generic	SMALL. The comprehensive regulatory controls and the facilities and procedures that are in place ensure proper handling and storage, as well as negligible doses and exposure to toxic materials for the public and the environment at all plants. License renewal will not increase the small, continuing risk to human health and the environment posed by mixed waste at all plants. The radiological and nonradiological environmental impacts of long-term disposal of mixed waste from any individual plant at licensed sites are small. In addition, the Commission concludes that there is reasonable assurance that sufficient mixed waste disposal capacity will be made available when needed for facilities to be decommissioned consistent with NRC decommissioning requirements.
On-site spent fuel	Generic	SMALL. The expected increase in the volume of spent fuel from an additional 20 years of operation can be safely accommodated onsite with small environmental effects through dry or pool storage at all plants if a permanent repository or monitored retrievable storage is not available.
Nonradiological waste	Generic	SMALL. No changes to generating systems are anticipated for license renewal. Facilities and procedures are in place to ensure continued proper handling and disposal at all plants.
Transportation	Generic	SMALL. The impacts of transporting spent fuel enriched up to 5 percent uranium-235 with average burnup for the peak rod to current levels approved by NRC up to 62,000 MWd/MTU and the cumulative impacts of transporting high-level waste to a single repository, such as Yucca Mountain, Nevada are found to be consistent with the impact values contained in 10 CFR 51.52(c), Summary Table S-4 – Environmental Impact of Transportation of Fuel and Waste to and from One Light-Water-Cooled Nuclear Power Reactor. If fuel enrichment or burnup conditions are not met, the applicant must submit an assessment of the implications for the environmental impact values reported in § 51.52.

Decommissioning		
Radiation doses	Generic	SMALL. Doses to the public will be well below applicable regulatory standards regardless of which decommissioning method is used. Occupational doses would increase no more than 1 man-rem caused by buildup of long-lived radionuclides during the license renewal term.
Waste management	Generic	SMALL. Decommissioning at the end of a 20-year license renewal period would generate no more solid wastes than at the end of the current license term. No increase in the quantities of Class C or greater than Class C wastes would be expected.
Air quality	Generic	SMALL. Air quality impacts of decommissioning are expected to be negligible either at the end of the current operating term or at the end of the license renewal term.
Water quality	Generic	SMALL. The potential for significant water quality impacts from erosion or spills is no greater whether decommissioning occurs after a 20-year license renewal period or after the original 40-year operation period, and measures are readily available to avoid such impacts.
Ecological resources	Generic	SMALL. Decommissioning after either the initial operating period or after a 20-year license renewal period is not expected to have any direct ecological impacts.
Socioeconomic impacts	Generic	SMALL. Decommissioning would have some short-term socioeconomic impacts. The impacts would not be increased by delaying decommissioning until the end of a 20-year relicense period, but they might be decreased by population and economic growth.
Environmental Justice		
Environmental Justice	Uncategorized	NONE. The need for and the content of an analysis of environmental justice will be addressed in plant-specific reviews.

Appendix C

Applicable Regulations, Laws, and Agreements

C. Applicable Regulations, Laws, and Agreements

The Atomic Energy Act authorizes States to establish programs to assume NRC regulatory authority for certain activities. For example, through the Agreement State Program, beginning on March 31, 2008, Pennsylvania assumed regulatory responsibility over certain byproduct, source, and small quantities of special nuclear material. The Pennsylvania Department of Environmental Protection (PADEP) is responsible for implementing State nuclear regulations, which are contained in Title 25 of the Pennsylvania (Pa) Code, *Environment*, Article V, *Radiological Health*, Chapters 215 through 240.

In addition to implementing some Federal programs, State legislatures develop their own laws. State statutes supplement as well as implement Federal laws for protection of air, water quality, and ground water. State legislation may address solid waste management programs, locally rare or endangered species, and historic and cultural resources.

The Clean Water Act (CWA) allows for primary enforcement and administration through State agencies, provided the State program is at least as stringent as the Federal program. The State program must conform to the CWA and to the delegation of authority for the Federal National Pollutant Discharge and Elimination System (NPDES) program from the EPA to the State. The primary mechanism to control water pollution is the requirement for direct dischargers to obtain an NPDES permit, or in the case of states where the authority has been delegated from the EPA, an SPDES permit, pursuant to the CWA. In Pennsylvania, the PADEP issues and enforces NPDES permits.

One important difference between Federal regulations and certain State regulations is the definition of waters regulated by the State. Certain state regulations may include underground waters, while the CWA only regulates surface waters.

C.1 State Environmental Requirements

Certain environmental requirements, including some discussed earlier, may have been delegated to State authorities for implementation, enforcement, or oversight. Table C-1 provides a list of representative State environmental requirements that may affect license renewal applications for nuclear power plants.

Table C-1. State Environmental Requirements. TMI-1 is subject to numerous State requirements regarding their environmental program. Those requirements are briefly described below. See Section 1.9 for TMI-1's compliance status with these requirements.

Law/Regulation	Requirements
Air Quality Protection	
Air Pollution Control Act, PA Public Law (P.L.) 2119 and 25 Pa Code Chapter 127	All emission sources at TMI-1 must obtain a Synthetic Minor Operating Permit prior to operation; the PADEP issues and enforces permits.

Appendix C

Table C-1. State Environmental Requirements. TMI-1 is subject to numerous State requirements regarding their environmental program. Those requirements are briefly described below. See Section 1.9 for TMI-1's compliance status with these requirements.

Law/Regulation	Requirements
Water Resources Protection	
<p><i>Clean Water Act</i> (CWA) (33 U.S.C. Section 1251 et seq.); Pennsylvania's Clear Streams Law, as amended (35 Pennsylvania Statute [P.S.] Section 691.1 et seq.)</p>	<p>The National Pollutant Discharge Elimination System (NPDES) permit is required for plant industrial, sanitary, and stormwater discharges to the Susquehanna River. The NPDES permit requires the compliance of each point source with authorized discharge levels, monitoring requirements, and other appropriate requirements. The PADEP is the responsible State agency for NPDES permitting.</p>
<p>CWA (33 U.S.C. Section 401)</p>	<p>The <i>Clean Water Act</i> Section 401 Water Quality Certification requires a Section 401 water quality certification and payment of applicable fees before the issuance of a Federal permit or license to conduct any activity that may result in any discharge to waters of the State. In Pennsylvania, State issuance of an NPDES permit constitutes 401 Certification.</p>
<p>Susquehanna River Basin Compact, P.L. 91-575, Article 3, Section 3.10; and Susquehanna River Basin Commission (SRBC) Regulation 803.61</p>	<p>Requires a permit to cover consumptive water use over 20,000 gallons per day (gpd) (over a 30-day average) of surface and ground water; the SRBC is the regulatory agency that issues and enforces consumptive water use permits.</p>
<p>Susquehanna River Basin Compact, P.L. 91-575, Article 3, Section 3.10; and SRBC Regulation 803.43</p>	<p>The Compact requires a permit to cover ground water withdrawals over 100,000 gpd or more (over a 30-day average) of surface water, ground water, or a combination of the two; the SRBC is the regulatory agency that issues and enforces ground water withdrawal permits.</p>
<p>P.L. 834, 204, 851, 1987, etc.</p>	<p>The U.S. Army Corps of Engineers issues maintenance dredging permits for maintenance dredging of the TMI-1 intake bay.</p>
<p>P.L. 555, as amended</p>	<p>Maintenance dredging of the TMI-1 intake bay in the Susquehanna River also requires a maintenance dredging permit issued by the PADEP.</p>
<p>Pennsylvania Safe Drinking Water Act (P.L. 206, No. 43)</p>	<p>The PADEP issues and enforces public water supply permits for operation TMI-1 plant site drinking water systems.</p>

Table C-1. State Environmental Requirements. TMI-1 is subject to numerous State requirements regarding their environmental program. Those requirements are briefly described below. See Section 1.9 for TMI-1's compliance status with these requirements.

Law/Regulation	Requirements
Waste Management and Pollution Prevention	
Pennsylvania Storage Tank and Spill Prevention Act (35 P.S. 6021.1016021.2104); 25 PA Code Chapter (Ch.) 245	The PADEP issues storage tank registration and permit certificates, which establish annual registration requirements for underground storage tanks containing petroleum or other regulated substances.
Pennsylvania Fire Marshall; Pennsylvania Storage Tank and Spill Prevention Act (35 P.S. 6021.1016021.2104); 25 PA Code Ch. 245	The Act requires a flammable and combustible liquid storage tank approval to construct or operate an underground storage tank containing flammable or combustible liquids.
71 P.S. Sections 510520; Sections 5 and 402 of The Clean Streams Law (35 P.S. 691.5 and 691.402); Section 9 of the Pennsylvania Sewage Facilities Act (35 P.S. Section 750.9).	The PADEP issues sewage sludge disposal agreements, which are required for the disposal of sewage sludge. The PADEP also issues on-lot sewage disposal system permits, and permit modifications for approvals of additional flows to on-lot sewage treatment systems.

C.2 Operating Permits and Other Requirements

Several operating permit applications may be prepared and submitted, and regulator approval and permits would be received prior to license renewal approval by the NRC. Table C-2 lists representative Federal, State, and local permits.

Appendix C

Table C-2. Federal, State, and Local Permits and Other Requirements. TMI-1 is subject to other requirements regarding various aspects of their environmental program. Those requirements are briefly described below.

License, Permit, or Other Required Approval	Responsible Agency	Authority	Relevance and Status
Air Quality Protection			
Approval (operating permit) for construction or modification of an air pollutant source.	PADEP	<i>Clean Air Act</i> , Title V, Sections 501-507 (42 U.S.C. 7661-7661f); Pa Code Ch.127	Exelon Generation may need to modify its existing Synthetic Minor Operating Permit, or apply for a new permit for temporary emissions associated with refurbishment.
Water Resources Protection			
NPDES permit for construction site storm water and other project-specific discharges.	PADEP	CWA (33 U.S.C. 1251 et seq.); 40 CFR Part 122; 25 Pa Code Ch. 92	Exelon Generation may need to modify the existing TMI-1 NPDES permit, or otherwise obtain authorization for temporary discharges associated with refurbishment.
Requires review and approval of any project that will result in consumptive use of water from the Susquehanna River.	SRBC	Susquehanna River Basin Compact; P.L. 91-575, Article 3, Section 3.10; 18 CFR Part 806; 25 Pa Code Ch. 806	Modifications to the existing TMI-1 consumptive water use permit may be necessary to supply water for refurbishment activities.
Requires any person withdrawing or diverting in excess of an average of 10,000 gpd for any consecutive 30-day period, from ground or surface water sources to register the amount of the withdrawal.	SRBC	Susquehanna River Basin Compact; P.L. 91-575, Article 3, Section 3.10; 18 CFR Part 807; 25 Pa Code Ch. 807	Refurbishment activities at TMI-1 may require additional ground water or surface water withdrawal; the existing TMI-1 water withdrawal permit may require modification.

Table C-2. Federal, State, and Local Permits and Other Requirements. TMI-1 is subject to other requirements regarding various aspects of their environmental program. Those requirements are briefly described below.

License, Permit, or Other Required Approval	Responsible Agency	Authority	Relevance and Status
Requires a permit be obtained before construction, modification, removal, destruction, or abandonment of an obstruction in a floodplain.	PADEP	Flood Plain Management Act (32 P.S. 679.101-679.601); 25 Pa Code Ch. 106	Exelon Generation is reviewing flood plain elevations associated with refurbishment activities; if avoidance is not possible, Exelon Generation will apply for appropriate permits.
A Spill Prevention Control and Countermeasures (SPCC) Plan is required for any facility that could discharge diesel fuel in harmful quantities into navigable waters or onto adjoining shorelines.	PADEP	CWA (33 U.S.C. 1251 et seq.); 40 CFR Part 112; 25 Pa Code Ch. 245	A SPCC Plan is required at nuclear power plants storing large volumes of diesel fuel or other petroleum products. Exelon Generation may need to modify its existing SPCC Plan, or develop a new plan to cover activities associated with refurbishment.
New Underground Storage Tanks System Registration is required within 30 days of bringing a new underground storage tank system into service.	PADEP	RCRA, as amended, Subtitle I (42 U.S.C. 6991a-6991i); 40 CFR §280.22; Storage Tank and Spill Prevention (35 P.S. 6021.101-6021.2104); 25 Pa Code, Ch. 245	Required if new underground storage tank systems would be installed during refurbishment at a nuclear power plant.
Waste Management and Pollution Prevention			
Registration and Hazardous Waste Generator Identification Number are required before a facility that generates over 100 kg (220 lb) per calendar month of hazardous waste ships the hazardous waste off-site	PADEP	RCRA, as amended (42 U.S.C. 6901 et seq.), Subtitle C; 25 Pa Code Articles VII (Hazardous Waste Management) and IX (Residual Waste	Generators of hazardous waste must notify EPA that the wastes exist and require management in compliance with RCRA. Exelon Generation will characterize wastes generated by refurbishment to determine proper disposal procedures and permit requirements.

Appendix C

Table C-2. Federal, State, and Local Permits and Other Requirements. TMI-1 is subject to other requirements regarding various aspects of their environmental program. Those requirements are briefly described below.

License, Permit, or Other Required Approval	Responsible Agency	Authority	Relevance and Status
		Management)	
Emergency Planning and Response			
Submission of a list of Material Safety Data Sheets is required for hazardous chemicals (as defined in 29 CFR Part 1910) that are stored onsite in excess of their threshold quantities.	State and local emergency planning agencies	Emergency Planning and Community Right-to-Know Act of 1986 (EPCRA), Section 311 (42 U.S.C. 11021); 40 CFR §370.20	Nuclear power plant operators are required to submit a List of Material Safety Data Sheets to State and local emergency planning agencies.
Transportation of Radioactive Wastes and Conversion Products Packaging, Labeling, and Routing Requirements for Radioactive Materials is required for packages containing radioactive materials that will be shipped by truck or rail.	U.S. Department of Transportation	HMTA (49 U.S.C. 1501 et seq.); Atomic Energy Act (AEA), as amended (42 U.S.C. 2011 et seq.); 49 CFR Parts 172, 173, 174, 177, and 397	When shipments of radioactive materials are made, nuclear power plant operators would comply with U.S. Department of Transportation packaging, labeling, and routing requirements.
Biotic Resource Protection			
Threatened and Endangered Species Consultation is required between the responsible Federal agencies and affected States to ensure that the project is not likely to: (1) jeopardize the continued existence of any species listed at the Federal or State level as endangered or threatened; or (2) result in destruction of critical habitat of such species.	U.S. Fish and Wildlife Service (FWS) and State agencies	<i>Endangered Species Act of 1973</i> , as amended (16 U.S.C. 1531 et seq.)	NRC would consult with FWS and State agencies regarding the impact of license renewal on threatened or endangered species or their critical habitats.
<i>Clean Water Act</i> Section 404 (Dredge and Fill) Permit is required to place dredged or fill material into waters of the U.S., including areas designated as	U.S. Army Corps of Engineers	CWA (33 U.S.C. 1251 et seq.); 33 CFR Parts 323 and	Any dredging or placement of fill material into wetlands within the jurisdiction of the U.S. Army Corps of Engineers at a nuclear power

Table C-2. Federal, State, and Local Permits and Other Requirements. TMI-1 is subject to other requirements regarding various aspects of their environmental program. Those requirements are briefly described below.

License, Permit, or Other Required Approval	Responsible Agency	Authority	Relevance and Status
<p>wetlands, unless such placement is exempt or authorized by a nationwide permit or a regional permit; a notice must be filed if a nationwide or regional permit applies.</p>		330	<p>plant would require a Section 404 permit. Exelon Generation is reviewing options for transportation of the new steam generators from Port Deposit, Maryland, to the TMI-1 site. If the selected route requires dredge or fill activities, Exelon Generation would have to apply for a section 404 permit.</p>
Cultural Resources Protection			
<p>Archaeological and Historical Resources Consultation is required before a Federal agency approves a project in an area where archaeological or historic resources might be located.</p>	<p>Pennsylvania Historic and Museum Commission</p>	<p><i>National Historic Preservation Act of 1966, as amended (16 U.S.C. 470 et seq.);</i> <i>Archaeological and Historical Preservation Act of 1974 (16 U.S.C. 469-469c-2);</i> <i>Antiquities Act of 1906 (16 U.S.C. 431 et seq.);</i> <i>Archaeological Resources Protection Act of 1979, as amended (16 U.S.C. 470aa-mm)</i></p>	<p>NRC would consult with the State and Tribal Historic Preservation Officers and representative Indian tribes regarding the impacts of license renewal and the results of archaeological and architectural surveys of nuclear power plant sites.</p>

Appendix D
Consultation Correspondence

D. Consultation Correspondences

The Endangered Species Act of 1973, as amended, the Magnuson-Stevens Fisheries Management Act of 1996, as amended; and the National Historic Preservation Act of 1966 require that Federal agencies consult with applicable State and Federal agencies and groups prior to taking action that may affect threatened and endangered species, essential fish habitat, or historic and archaeological resources, respectively. This appendix contains consultation documentation.

Table D-1. Consultation Correspondences. *This is a list of the consultation documents sent between the NRC and other agencies we are required to consult with based on NEPA requirements.*

Author	Recipient	Date of Letter
U.S. Nuclear Regulatory Commission (L. Lund)	U.S. Fish and Wildlife Service (D. Densmore)	April 4, 2008
U.S. Nuclear Regulatory Commission (L. Lund)	Oneida Indian Nation (R. Halbritter)	April 9, 2008 ^(a)
U.S. Nuclear Regulatory Commission (L. Lund)	Advisory Council on Historic Preservation (C. Vaughn)	April 15, 2008
U.S. Nuclear Regulatory Commission (L. Lund)	Pennsylvania Department of Conservation and Natural Resources (C. Firestone)	April 15, 2008
U.S. Nuclear Regulatory Commission (L. Lund)	Pennsylvania Fish and Boat Commission (C. Urban)	April 15, 2008
U.S. Nuclear Regulatory Commission (L. Lund)	Pennsylvania Game Commission (L. Leigey)	April 15, 2008
U.S. Nuclear Regulatory Commission (L. Lund)	Pennsylvania Historical and Museum Commission (J. Cutler)	April 15, 2008
Stockbridge-Munsee Tribal Historic Preservation Office (S. White)	U.S. Nuclear Regulatory Commission (L. Lund)	April 21, 2008

Appendix D

Author	Recipient	Date of Letter
U.S. Fish and Wildlife Service (D. Densmore)	U.S. Nuclear Regulatory Commission (L. Lund)	April 23, 2008
Pennsylvania Department of Conservation and Natural Resources (R. Bowen)	U.S. Nuclear Regulatory Commission (L. Lund)	May 2, 2008
Pennsylvania Game Commission (J. Leigey)	U.S. Nuclear Regulatory Commission (L. Lund)	May 14, 2008
Pennsylvania Fish and Boat Commission (C. Urban)	U.S. Nuclear Regulatory Commission (S. Lopas)	June 3, 2008
U.S. Department of Interior, U.S. Fish and Wildlife Service (M. Chezik)	U.S. Nuclear Regulatory Commission	March 3, 2009

(a) Similar letters went to fourteen other Native American Tribes listed in Section 1.8.

D.1 Consultation Correspondence

The following pages contain copies of the letters listed in Table D-1. Figures contained in the first letter (pages D-6 and D-7) were included with each letter mailed to consultation agencies.

April 4, 2008

Mr. David Densmore
U.S. Fish & Wildlife Service
Pennsylvania Field Office
315 South Allen Street, Suite 322
State College, PA 16801-4850

**SUBJECT: REQUEST FOR LIST OF PROTECTED SPECIES WITHIN THE AREA UNDER
EVALUATION FOR THE THREE MILE ISLAND NUCLEAR STATION, UNIT 1,
LICENSE RENEWAL APPLICATION REVIEW**

Dear Mr. Densmore:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application submitted by AmerGen Energy Company, LLC (AmerGen), for the renewal of the operating license for Three Mile Island Nuclear Station, Unit 1 (TMI-1). TMI-1 is located on Three Mile Island, which is situated in the Susquehanna River, in Londonderry Township of Dauphin County, Pennsylvania, about 2.5 miles north of the southern tip of Dauphin County. As part of the review of the license renewal application (LRA), the NRC is preparing a Supplemental Environmental Impact Statement (SEIS) under the provisions of Title 10 of the *Code of Federal Regulations* Part 51 (10 CFR Part 51), the NRC's regulation that implements the National Environmental Policy Act (NEPA) of 1969. The SEIS includes an analysis of pertinent environmental issues, including endangered or threatened species and impacts to fish and wildlife. This letter is being submitted under the provisions of the Endangered Species Act of 1973, as amended, and the Fish and Wildlife Coordination Act of 1934, as amended.

AmerGen is requesting renewal of its operating license for TMI-1 for a period of 20 years beyond the expiration of the current license term of April 2014. The proposed action would include the use and continued maintenance of existing plant facilities and transmission lines. For the purpose of license renewal, AmerGen plans to replace the TMI-1 steam generators, and estimates that the total area disturbed by construction, decontamination, and laydown activities would be less than 10 acres, all of which would be previously disturbed property within the bounds of the TMI-1 flood protection dike.

The TMI-1 site encompasses several properties that total approximately 440 acres, including: the physical plant location on 200 acres of the 370-acre Three Mile Island; St. John's Island and Evergreen Island (also referred to as "Sand Beach Island"), together totaling 31 acres; a 6.4-acre section of Shelley Island, which is part of the western half of the TMI-1 Exclusion Area; and a 32-acre strip of land east of Three Mile Island along the eastern shore of the Susquehanna River; please see the attached site boundary map. The TMI-1 site is surrounded by fencing and contains few areas of undeveloped or undisturbed land; undeveloped land on Three Mile Island lies south of TMI-1 facilities. The majority of this land lies under the ten-year flood level, and contains wetlands and fallow field areas surrounded by a woodland buffer. Riparian buffer areas are intact around the perimeter of the island, although forested riparian areas only occur on the southern part of the island.

D. Densmore

- 2 -

TMI-1 utilizes two hyperbolic natural draft cooling towers for dissipating heat from the plant steam cycle. The circulating water and service water systems withdraw water from the Susquehanna River, and are supplemented by three groundwater wells. TMI-1 has a permit with the Susquehanna River Basin Commission for consumptive use of river water up to 18 million gallons per day, on a monthly average, for electric generation. River water enters the intake structure located on the western bank of the island, passes under a skimmer wall, through automated trash racks with 1-inch vertical bar spacing, through 3/8-inch-mesh traveling screens, through the river water pumps, and finally through 1/8-inch-mesh strainers before entering the heat exchangers. Approximately 3000 gallons per minute of cooling tower blowdown are discharged to the Susquehanna River through a 48-inch-diameter river discharge line.

Four 230-kilovolt (kV) transmission lines totaling 5.6 miles of corridor and approximately 142 acres connect TMI-1 to the regional transmission system; please see the attached TMI-1 transmission system map. Two of these lines connect the plant with the substation at Middletown Junction, east of the Susquehanna River; each of these lines extends 1.5 miles. A third line extends for 4.1 miles to the west side of the Susquehanna River, where it connects to a 230-kV line terminating into the substation near Jackson – this line crosses the river twice. The fourth line extends 0.7 miles east across the Susquehanna River to the TMI-1 500-kV substation.

To support the SEIS preparation process and to ensure compliance with Section 7 of the Endangered Species Act, the NRC requests information on Federally listed, proposed, and candidate species and critical habitat that may be in the vicinity of TMI-1 and its associated transmission line corridors. In addition, please provide any information you consider appropriate under the provisions of the Fish and Wildlife Coordination Act.

The NRC staff plans to hold two public NEPA scoping meetings on May 1, 2008. The first session will be held in the afternoon and an identical session will be held later that evening. The afternoon session will be held at the Elks Movie Theatre, 4 West Emaus Street, Middletown, PA 17057. The evening session will be held at Londonderry Elementary School, 260 Schoolhouse Road, Middletown, PA 17057. The first meeting will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second meeting will convene at 7:00 p.m. and will continue until 10:00 p.m., as necessary. In addition, during the week of April 28, 2008, the NRC plans to conduct a site audit. You and your staff are invited to attend both the public meetings and the site audit. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is December 2008.

D. Densmore:

- 3 -

If you have any questions concerning the NRC staff's review of this license renewal application, please contact Ms. Sarah Lopas, License Renewal Project Manager, at 301-415-1147 or sl12@nrc.gov.

Sincerely,

/RA/

Louise Lund, Branch Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation


Docket No. 50-289


Enclosures:

1. Site Boundary Map
2. TML-1 Transmission System Map

cc/wencis.: See next page

Appendix D





Appendix D

April 09, 2008

The Honorable Raymond Halbritter
Nation Representative
Oneida Indian Nation
5218 Patrick Road
Verona, NY 13478

SUBJECT: REQUEST FOR SCOPING COMMENTS CONCERNING THE THREE MILE ISLAND NUCLEAR STATION, UNIT 1, LICENSE RENEWAL APPLICATION REVIEW

Dear Representative Halbritter:

The U.S. Nuclear Regulatory Commission (NRC or the staff) has recently received an application from AmerGen Energy Company, LLC (AmerGen), for the renewal of the operating license for the Three Mile Island Nuclear Station, Unit 1 (TMI-1), located on Three Mile Island, which is situated in the Susquehanna River, in Londonderry Township of Dauphin County, Pennsylvania. The NRC is in the initial stages of developing a Supplemental Environmental Impact Statement to the Generic Environmental Impact Statement (GEIS), which will document the impacts associated with the renewal of TMI-1. We would like your assistance in our review by providing input to the NRC's environmental review scoping process. The NRC's process includes an opportunity for public and inter-governmental participation in the environmental review. We want to ensure that you are aware of our efforts pursuant to Title 10 of the *Code of Federal Regulations* Part 51, Section 51.28(b). In addition, as outlined in 36 CFR 800.8(c), the NRC plans to coordinate compliance with Section 106 of the National Historic Preservation Act of 1966 through the requirements of the National Environmental Policy Act of 1969.

The NRC has also sent copies of this letter to the tribal contacts for the following Federally-recognized tribes: Absentee-Shawnee Tribe of Oklahoma; Cayuga Nation; Delaware Nation; Delaware Trust Board; Eastern Shawnee Tribe of Oklahoma; Oneida Indian Nation; Oneida Nation of Wisconsin; Onondaga Nation; Seneca Nation of Indians; Seneca-Cayuga Tribe of Oklahoma; St. Regis Mohawk Tribe; Shawnee Tribe; Stockbridge-Munsee Band of the Mohican Nation of Wisconsin; Tonawanda Seneca Nation; and Tuscarora Nation.

Under NRC regulations, the original operating license for a nuclear power plant is issued for up to 40 years. The license may be renewed for up to an additional 20 years if NRC requirements are met. The current operating license for TMI-1 will expire in April 2014. The proposed action would include the use and continued maintenance of existing plant facilities and transmission lines. For the purpose of license renewal, AmerGen plans to replace the TMI-1 steam generators, and estimates that the total area disturbed by construction, decontamination, and laydown activities would be less than 10 acres, all of which would be previously disturbed property within the bounds of the TMI-1 flood protection dike. Provided for your information is the TMI-1 site boundary map (Enclosure 1) and transmission system map (Enclosure 2).

The GEIS considered the environmental impacts of renewing nuclear power plant operating licenses for a 20-year period on all currently operating sites. In the GEIS the NRC staff identified 92 environmental issues and developed generic conclusions related to environmental

-2-

impacts for 69 of these issues that apply to all plants or to plants with specific design or site characteristics. For the remaining 23 issues, plant-specific analyses will be documented in a supplement to the GEIS. A supplemental environmental impact statement will be prepared for TMI-1 to document the staff's review of environmental impacts related to terrestrial ecology, aquatic ecology, hydrology, cultural resources, and socioeconomic issues (among others), and will contain a recommendation regarding the environmental acceptability of the license renewal action.

Please submit any comments that you may have to offer on the scope of the environmental review by May 30, 2008. Written comments should be submitted by mail to the Chief, Rules and Directives Branch, Division of Administrative Services, Mail Stop T-6D59, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001. Electronic comments may be submitted to the NRC by e-mail at ThreeMileIslandEIS@nrc.gov. At the conclusion of the scoping process, the NRC staff will prepare a summary of the significant issues identified and the conclusions reached, and mail a copy to you.

To accommodate interested members of the public, the NRC will hold two public scoping meetings for the TMI-1 license renewal supplement to the GEIS on May 1, 2008. The first session will be held in the afternoon and an identical session will be held later that evening. The afternoon session will be held at the Elks Movie Theatre, 4 West Emaus Street, Middletown, PA 17057. The evening session will be held at Londonderry Elementary School, 260 Schoolhouse Road, Middletown, PA 17057. The first meeting will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second meeting will convene at 7:00 p.m. and will continue until 10:00 p.m., as necessary. Additionally, the NRC staff will host informal discussions one hour before the start of each session.

The TMI-1 license renewal application and the GEIS are available on the internet at www.nrc.gov/reactors/operating/licensing/renewal/applications/three-mile-island.html. In addition, the following locations have agreed to make the license renewal application and the GEIS available for public inspection: Londonderry Township Municipal Building, 783 South Geyers Church Road, Middletown, PA 17057; Middletown Public Library, 20 North Catherine Street, Middletown, PA 17057; and Penn State Harrisburg Library, 351 Olmsted Drive, Middletown, PA 17057.

The staff expects to publish the draft supplemental environmental impact statement in December 2008. A copy of the document will be sent to you for your review and comment. The NRC will hold another set of public meetings in the site vicinity to solicit comments on the draft supplemental environmental impact statement. After consideration of public comments received, the NRC will prepare a final supplemental environmental impact statement, which is scheduled to be issued in July 2009.

Appendix D

-3-

If you need additional information regarding the license renewal review process, please contact Ms. Sarah Lopas, License Renewal Project Manager, at 301-415-1147 or at sl2@nrc.gov.

Sincerely,

IRA

Louise Lund, Branch Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-289

Enclosures:
As Stated

April 15, 2008

Ms. Charlene Dwin Vaughn
Assistant Director
Advisory Council on Historic Preservation
Office of Federal Agency Programs
1100 Pennsylvania Ave, NW, Suite 803
Washington, DC 20004

SUBJECT: THREE MILE ISLAND NUCLEAR STATION, UNIT 1, LICENSE RENEWAL
APPLICATION REVIEW

Dear Ms. Vaughn:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application to renew the operating license for Three Mile Island Nuclear Station, Unit 1 (TMI-1), located on Three Mile Island, which is situated in the Susquehanna River, in Londonderry Township of Dauphin County, Pennsylvania, about 2.5 miles north of the southern tip of Dauphin County. TMI-1 is operated by AmerGen Energy Company, LLC (AmerGen). The application for renewal was submitted by AmerGen in a letter dated January 8, 2008, pursuant to Title 10 of the *Code of Federal Regulations* Part 54 (10 CFR Part 54).

The NRC has established that, as part of the staff's review of any nuclear power plant license renewal action, a site-specific Supplemental Environmental Impact Statement (SEIS) to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants," NUREG-1437, will be prepared under the provisions of 10 CFR Part 51, the NRC's regulation that implements the National Environmental Policy Act of 1969 (NEPA). In accordance with 36 CFR 800.8(c), the SEIS will include analyses of potential impacts to historic and cultural resources.

On May 1, 2008, the NRC will conduct two public NEPA scoping meetings. The first session will be held in the afternoon and an identical session will be held later that evening. The afternoon session will be held at the Elks Movie Theatre, 4 West Etna Street, Middletown, PA 17057. The evening session will be held at Londonderry Elementary School, 260 Schoolhouse Road, Middletown, PA 17057. The first meeting will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second meeting will convene at 7:00 p.m. and will continue until 10:30 p.m., as necessary. You and your staff are invited to attend the public meetings. In addition, during the week of April 28, 2008, the NRC staff plans to conduct a site audit at TMI-1. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is December 2008.

Appendix D

C. Vaughn

-2-

If you have any questions or require additional information, please contact the License Renewal Project Manager, Ms. Sarah Lopas, at 301-415-1147 or by e-mail at sl2@nrc.gov.

Sincerely,

/RA/

Louise Lund, Branch Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-289

cc: See next page

April 15, 2008

Ms. Chris Firestone
Native Plant Program Manager
Bureau of Forestry (Plant Program)
Forestry Advisory Services
Pennsylvania Department of Conservation
and Natural Resources
P.O. Box 8552
Harrisburg, PA 17105-1673

SUBJECT: REQUEST FOR LIST OF STATE-PROTECTED SPECIES AND IMPORTANT HABITATS WITHIN THE AREA UNDER EVALUATION FOR THE THREE MILE ISLAND NUCLEAR STATION, UNIT 1, LICENSE RENEWAL APPLICATION REVIEW

Dear Ms. Firestone:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application submitted by AmerGen Energy Company, LLC (AmerGen), for the renewal of the operating license for Three Mile Island Nuclear Station, Unit 1 (TMI-1). TMI-1 is located on Three Mile Island, which is situated in the Susquehanna River, in Londonderry Township of Dauphin County, Pennsylvania, about 2.5 miles north of the southern tip of Dauphin County. As part of the review of the license renewal application (LRA), the NRC is preparing a Supplemental Environmental Impact Statement (SEIS) under the provisions of Title 10 of the *Code of Federal Regulations* Part 51 (10 CFR Part 51), the NRC's regulation that implements the National Environmental Policy Act (NEPA) of 1969. The SEIS includes an analysis of pertinent environmental issues, including endangered or threatened species and impacts to fish and wildlife.

AmerGen is requesting renewal of its operating license for TMI-1 for a period of 20 years beyond the expiration of the current license term of April 2014. The proposed action would include the use and continued maintenance of existing plant facilities and transmission lines. For the purpose of license renewal, AmerGen plans to replace the TMI-1 steam generators, and estimates that the total area disturbed by construction, decontamination, and laydown activities would be less than 10 acres, all of which would be previously disturbed property within the bounds of the TMI-1 flood protection dike.

The TMI-1 site encompasses several properties that total approximately 440 acres, including: the physical plant location on 200 acres of the 370-acre Three Mile Island; St. John's Island and Evergreen Island (also referred to as "Sand Beach Island"), together totaling 31 acres; a 6.4-acre section of Shelley Island, which is part of the western half of the TMI-1 Exclusion Area; and a 32-acre strip of land east of Three Mile Island along the eastern shore of the Susquehanna River; please see the enclosed site boundary map. The TMI-1 site is surrounded by fencing and contains few areas of undeveloped or undisturbed land; undeveloped land on Three Mile Island lies south of TMI-1 facilities. The majority of this land lies under the ten-year flood level, and contains wetlands and fallow field areas surrounded by a woodland buffer. Riparian buffer areas are intact around the perimeter of the island, although forested riparian areas only occur on the southern part of the island.

Appendix D

C. Firestone

-2-

Four 230-kilovolt (kV) transmission lines totaling 5.6 miles of corridor and approximately 142 acres connect TMI-1 to the regional transmission system; please see the enclosed TMI-1 transmission system map. Two of these lines connect the plant with the substation at Middletown Junction, east of the Susquehanna River; each of these lines extends 1.5 miles. A third line extends for 4.1 miles to the west side of the Susquehanna River, where it connects to a 230-kV line terminating into the substation near Jackson – this line crosses the river twice. The fourth line extends 0.7 miles east across the Susquehanna River to the TMI-1 500-kV substation.

To support the SEIS preparation process and to ensure compliance with Section 7 of the Endangered Species Act, the NRC requests information on state-listed, proposed, and candidate species and critical habitat that may be in the vicinity of TMI-1 and its associated transmission line corridors.

The NRC staff plans to hold two public NEPA scoping meetings on May 1, 2008. The first session will be held in the afternoon and an identical session will be held later that evening. The afternoon session will be held at the Elks Movie Theatre, 4 West Emaus Street, Middletown, PA 17057. The evening session will be held at Londonderry Elementary School, 260 Schoolhouse Road, Middletown, PA 17057. The first meeting will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second meeting will convene at 7:00 p.m. and will continue until 10:00 p.m., as necessary. In addition, during the week of April 28, 2008, the NRC plans to conduct a site audit. You and your staff are invited to attend both the public meetings and the site audit. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is December 2008.

If you have any questions concerning the NRC staff's review of this license renewal application, please contact Ms. Sarah Lopas, License Renewal Project Manager, at 301-415-1147 or by e-mail at sll2@nrc.gov.

Sincerely,

/RA/

Louise Lund, Branch Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-289

Enclosures:
As stated

cc w/encls: See next page

April 15, 2008

Mr. Christopher Urban
Chief of Natural Diversity Section
Pennsylvania Fish and Boat Commission
450 Robinson Lane
Bellefonte, PA 16823-9620

SUBJECT: REQUEST FOR LIST OF STATE-PROTECTED SPECIES WITHIN THE AREA
UNDER EVALUATION FOR THE THREE MILE ISLAND NUCLEAR STATION,
UNIT 1, LICENSE RENEWAL APPLICATION REVIEW

Dear Mr. Urban:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application submitted by AmerGen Energy Company, LLC (AmerGen), for the renewal of the operating license for Three Mile Island Nuclear Station, Unit 1 (TMI-1). TMI-1 is located on Three Mile Island, which is situated in the Susquehanna River, in Londonderry Township of Dauphin County, Pennsylvania, about 2.5 miles north of the southern tip of Dauphin County. As part of the review of the license renewal application (LRA), the NRC is preparing a Supplemental Environmental Impact Statement (SEIS) under the provisions of Title 10 of the *Code of Federal Regulations* Part 51 (10 CFR Part 51), the NRC's regulation that implements the National Environmental Policy Act (NEPA) of 1969. The SEIS includes an analysis of pertinent environmental issues, including endangered or threatened species and impacts to fish and wildlife.

AmerGen is requesting renewal of its operating license for TMI-1 for a period of 20 years beyond the expiration of the current license term of April 2014. The proposed action would include the use and continued maintenance of existing plant facilities and transmission lines. For the purpose of license renewal, AmerGen plans to replace the TMI-1 steam generators, and estimates that the total area disturbed by construction, decontamination, and laydown activities would be less than 10 acres, all of which would be previously disturbed property within the bounds of the TMI-1 flood protection dike.

The TMI-1 site encompasses several properties that total approximately 440 acres, including: the physical plant location on 200 acres of the 370-acre Three Mile Island; St. John's Island and Evergreen Island (also referred to as "Sand Beach Island"), together totaling 31 acres; a 6.4-acre section of Shelley Island, which is part of the western half of the TMI-1 Exclusion Area; and a 32-acre strip of land east of Three Mile Island along the eastern shore of the Susquehanna River; please see the enclosed site boundary map. The TMI-1 site is surrounded by fencing and contains few areas of undeveloped or undisturbed land; undeveloped land on Three Mile Island lies south of TMI-1 facilities. The majority of this land lies under the ten-year flood level, and contains wetlands and fallow field areas surrounded by a woodland buffer. Riparian buffer areas are intact around the perimeter of the island, although forested riparian areas only occur on the southern part of the island.

Appendix D

C. Urban

-2-

TMI-1 utilizes two hyperbolic natural draft cooling towers for dissipating heat from the plant steam cycle. The circulating water and service water systems withdraw water from the Susquehanna River, and are supplemented by three groundwater wells. TMI-1 has a permit with the Susquehanna River Basin Commission for consumptive use of river water up to 18 million gallons per day, on a monthly average, for electric generation. River water enters the intake structure located on the western bank of the island, passes under a skimmer wall, through automated trash racks with 1-inch vertical bar spacing, through 3/8-inch-mesh traveling screens, through the river water pumps, and finally through 1/8-inch-mesh strainers before entering the heat exchangers. Approximately 3000 gallons per minute of cooling tower blowdown are discharged to the Susquehanna River through a 48-inch-diameter river discharge line.

Four 230-kilovolt (kV) transmission lines totaling 5.6 miles of corridor and approximately 142 acres connect TMI-1 to the regional transmission system; please see the enclosed TMI-1 transmission system map. Two of these lines connect the plant with the substation at Middletown Junction, east of the Susquehanna River; each of these lines extends 1.5 miles. A third line extends for 4.1 miles to the west side of the Susquehanna River, where it connects to a 230-kV line terminating into the substation near Jackson – this line crosses the river twice. The fourth line extends 0.7 miles east across the Susquehanna River to the TMI-1 500-kV substation.

To support the SEIS preparation process and to ensure compliance with Section 7 of the Endangered Species Act, the NRC requests information on state-listed, proposed, and candidate species and critical habitat that may be in the vicinity of TMI-1 and its associated transmission line corridors. Please see the enclosed Species Impact Review (SIR) request form.

The NRC staff plans to hold two public NEPA scoping meetings on May 1, 2008. The first session will be held in the afternoon and an identical session will be held later that evening. The afternoon session will be held at the Elks Movie Theatre, 4 West Emaus Street, Middletown, PA 17057. The evening session will be held at Londonderry Elementary School, 260 Schoolhouse Road, Middletown, PA 17057. The first meeting will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second meeting will convene at 7:00 p.m. and will continue until 10:00 p.m., as necessary. In addition, during the week of April 28, 2008, the NRC plans to conduct a site audit. You and your staff are invited to attend both the public meetings and the site audit. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is December 2008.

**FISH AND BOAT COMMISSION
NATURAL DIVERSITY SECTION**

**PFBC-DES-NDS-1 (5/2/03) SPECIES IMPACT REVIEW (SIR) REQUEST FORM
COMMONWEALTH**

A. This form provides the site information necessary to perform a computer database search for species of special concern listed under the Endangered Species Act of 1973, the Wild Resource Conservation Act, the Pennsylvania Fish and Boat Code or the Wildlife Code.

B. Use only **one form** for each proposed project or location. Complete the information below and **mail** form to:
OF PENNSYLVANIA

Natural Diversity Section Division
of Environmental Services PA Fish
and Boat Commission 450
Robinson Lane Bellefonte, PA
16823 Fax: (814) 359-5175

C. This form, a cover letter including a project narrative, and accompanying maps should be sent to the above address for environmental reviews that only concern reptiles, amphibians, fishes and aquatic invertebrates. Reviews for other natural resources must be submitted to other appropriate agencies.

D. The absence of recorded information from our databases and files does not necessarily imply actual conditions on site. Future field investigations could alter this determination. The information contained in our files is routinely updated. A review is valid for one year.

E. Please send us only one (1) copy of your request – either by fax or by mail – not both. Mail is preferred to improve legibility of maps. Facsimile submission will not improve our response turn-around time.

F. Allow 30 days for completion of the review from the date of PFBC receipt. Large projects and workload may extend this review timeframe.

G. In any future correspondence with us following your receipt of the SIR response, please refer to the assigned SIR number at the top left of our cover letter.

H. FORMS THAT ARE NOT COMPLETED IN FULL WILL NOT BE REVIEWED.

PLEASE PRINT OR TYPE: If available, provide the potential conflict PNDI Search Number: **N/A**

PFBC response should be sent to Company/Agency: **U.S. Nuclear Regulatory Commission**

Form Preparer: **Sarah Lopas, License Renewal Project Manager**

Address: **U.S. Nuclear Regulatory Commission, 11555 Rockville Pike, Mail Stop O-11F1, Rockville, MD 20852**

Phone (8:00 AM to 4:00 PM): **301.415.1147**

Project Description: **Three Mile Island Nuclear Station, Unit 1, License Renewal (please see cover letter)**

Indicate if the project is: Transportation or Non-transportation **X** (check one)

Will the proposed project encroach directly or indirectly (e.g., runoff) upon wetlands or waterways? Circle one for each:

Wetlands: Yes No **UNKNOWN** Waterways: **YES** No Unknown

County: **Dauphin** Township/Municipality: **Londonderry**

Name of the United States Geological Survey (U.S.G.S.) 7.5 Minute Quadrangle Map where project is located: **Middletown**

Project size (in acres): **Approximately 276** Attach an 8.5" by 11" photocopy (**DO NOT REDUCE**) of the section of the U.S.G.S. Quadrangle Map which identifies the project location. On this map, indicate the location of the project center (if linear, depict both ends) and outline the approximate boundaries of the project area. Specify latitude/longitude of the project center.

Latitude: **40°/9.2' N**

Longitude: **72°/43.5' W**

FOR PFBC USE ONLY

SIR#	Quad Name	Data Source	Search Result-Potential Species Conflict	Action

April 15, 2008

Mr. James Leigey
Wildlife Impact Review Coordinator
Pennsylvania Game Commission
2001 Elmerton Avenue
Harrisburg, PA 17110-9797

SUBJECT: REQUEST FOR LIST OF STATE-PROTECTED SPECIES WITHIN THE AREA UNDER EVALUATION FOR THE THREE MILE ISLAND NUCLEAR STATION, UNIT 1, LICENSE RENEWAL APPLICATION REVIEW

Dear Mr. Leigey:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application submitted by AmerGen Energy Company, LLC (AmerGen), for the renewal of the operating license for Three Mile Island Nuclear Station, Unit 1 (TMI-1). TMI-1 is located on Three Mile Island, which is situated in the Susquehanna River, in Londonderry Township of Dauphin County, Pennsylvania, about 2.5 miles north of the southern tip of Dauphin County. As part of the review of the license renewal application (LRA), the NRC is preparing a Supplemental Environmental Impact Statement (SEIS) under the provisions of Title 10 of the *Code of Federal Regulations* Part 51 (10 CFR Part 51), the NRC's regulation that implements the National Environmental Policy Act (NEPA) of 1969. The SEIS includes an analysis of pertinent environmental issues, including endangered or threatened species and impacts to fish and wildlife.

AmerGen is requesting renewal of its operating license for TMI-1 for a period of 20 years beyond the expiration of the current license term of April 2014. The proposed action would include the use and continued maintenance of existing plant facilities and transmission lines. For the purpose of license renewal, AmerGen plans to replace the TMI-1 steam generators, and estimates that the total area disturbed by construction, decontamination, and laydown activities would be less than 10 acres, all of which would be previously disturbed property within the bounds of the TMI-1 flood protection dike.

The TMI-1 site encompasses several properties that total approximately 440 acres, including: the physical plant location on 200 acres of the 370-acre Three Mile Island; St. John's Island and Evergreen Island (also referred to as "Sand Beach Island"), together totaling 31 acres; a 6.4-acre section of Shelley Island, which is part of the western half of the TMI-1 Exclusion Area; and a 32-acre strip of land east of Three Mile Island along the eastern shore of the Susquehanna River; please see the enclosed site boundary map. The TMI-1 site is surrounded by fencing and contains few areas of undeveloped or undisturbed land; undeveloped land on Three Mile Island lies south of TMI-1 facilities. The majority of this land lies under the ten-year flood level, and contains wetlands and fallow field areas surrounded by a woodland buffer. Riparian buffer areas are intact around the perimeter of the island, although forested riparian areas only occur on the southern part of the island.

J. Leigey

- 2 -

Four 230-kilovolt (kV) transmission lines totaling 5.6 miles of corridor and approximately 142 acres connect TMI-1 to the regional transmission system; please see the enclosed TMI-1 transmission system map. Two of these lines connect the plant with the substation at Middletown Junction, east of the Susquehanna River; each of these lines extends 1.5 miles. A third line extends for 4.1 miles to the west side of the Susquehanna River, where it connects to a 230-kV line terminating into the substation near Jackson – this line crosses the river twice. The fourth line extends 0.7 miles east across the Susquehanna River to the TMI-1 500-kV substation.

To support the SEIS preparation process and to ensure compliance with Section 7 of the Endangered Species Act, the NRC requests information on state-listed, proposed, and candidate species and critical habitat that may be in the vicinity of TMI-1 and its associated transmission line corridors.

The NRC staff plans to hold two public NEPA scoping meetings on May 1, 2008. The first session will be held in the afternoon and an identical session will be held later that evening. The afternoon session will be held at the Elks Movie Theatre, 4 West Emaus Street, Middletown, PA 17057. The evening session will be held at Londonderry Elementary School, 260 Schoolhouse Road, Middletown, PA 17057. The first meeting will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second meeting will convene at 7:00 p.m. and will continue until 10:00 p.m., as necessary. In addition, during the week of April 28, 2008, the NRC plans to conduct a site audit. You and your staff are invited to attend both the public meetings and the site audit. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is December 2008.

If you have any questions concerning the NRC staff's review of this license renewal application, please contact Ms. Sarah Lopas, License Renewal Project Manager, at 301-415-1147 or by e-mail at sll2@nrc.gov.

Sincerely,

/RA/

Louise Lund, Branch Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-289

Enclosures:
As stated

cc w/encls: See next page

April 15, 2008

Jean Cutler, Deputy State Historic Preservation Officer
Pennsylvania Historical and Museum Commission
Bureau for Historic Preservation
Commonwealth Keystone Building, Second Floor
400 North Street
Harrisburg, PA 17120-0093

SUBJECT: THREE MILE ISLAND NUCLEAR STATION, UNIT 1, LICENSE RENEWAL
APPLICATION REVIEW (FILE NO. ER 07-1737-043-A)

Dear Ms. Cutler:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application to renew the operating license for Three Mile Island Nuclear Station, Unit 1 (TMI-1), located on Three Mile Island, which is situated in the Susquehanna River, in Londonderry Township of Dauphin County, Pennsylvania, about 2.5 miles north of the southern tip of Dauphin County. TMI-1 is operated by AmerGen Energy Company, LLC (AmerGen). The application for renewal was submitted by AmerGen in a letter dated January 8, 2008, pursuant to Title 10 of the *Code of Federal Regulations* Part 54 (10 CFR Part 54).

The NRC has established that, as part of the staff's review of any nuclear power plant license renewal action, a site-specific Supplemental Environmental Impact Statement (SEIS) to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants," NUREG-1437, will be prepared under the provisions of 10 CFR Part 51, the NRC's regulation that implements the National Environmental Policy Act of 1969 (NEPA). In accordance with 36 CFR 800.8(c), the SEIS will include analyses of potential impacts to historic and cultural resources.

In the context of the National Historic Preservation Act of 1966, as amended, the NRC staff has determined that the area of potential effect (APE) for a license renewal action is the area at the power plant site and its immediate environs that may be impacted by post-license renewal land-disturbing operations or projected refurbishment activities associated with the proposed action. The APE may extend beyond the immediate environs in those instances where post-license renewal land-disturbing operations or projected refurbishment activities specifically related to license renewal may potentially have an effect on known or proposed historic sites. This determination is made irrespective of ownership or control of the lands of interest.

On May 1, 2008, the NRC will conduct two public NEPA scoping meetings. The first session will be held in the afternoon and an identical session will be held later that evening. The afternoon session will be held at the Elks Movie Theatre, 4 West Emaus Street, Middletown, PA 17057. The evening session will be held at Londonderry Elementary School, 260 Schoolhouse Road, Middletown, PA 17057. The first meeting will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second meeting will convene at 7:00 p.m. and will continue until 10:00 p.m., as necessary. You and your staff are invited to attend. Your office will receive a

J. Cutler

- 2 -

copy of the draft SEIS along with a request for comments. The staff expects to publish the draft SEIS in December 2008. If you have any questions or require additional information, please contact Ms. Sarah Lopas, License Renewal Project Manager, by phone at 301-415-1147 or by e-mail at sll2@nrc.gov.

Sincerely,

/RA/

Louise Lund, Branch Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-289

cc w/encls: See next page

Stockbridge-Munsee Tribal Historic Preservation Office

RULES AND DIRECTIVES

Sherry White - Tribal Historic Preservation Officer

WI3447 Camp 14 Road

P.O. Box 70

Bowler, WI 54416

2008 APR 29 AM 8:49

RECEIVED

April 21, 2008

Chief
Rules & Directives Branch
Division of Administrative Services
Mail Stop T-6D59
U.S. Regulatory Commission
Washington, DC 20555-0001

RE: Three Mile Island Nuclear Station Unit
License Renewal Application Review

Dear Sir:


Thank you for contacting the Stockbridge-Munsee Tribe regarding the above referenced project. The Tribe is committed to protecting archaeological sites that are important to tribal heritage, culture and religion. Furthermore, the Tribe is particularly concerned with archaeological sites that may contain human burial remains and associated funerary objects.

As described in your correspondence, the proposed ground disturbing activity of this project is not in a region of archaeological interest to the Stockbridge-Munsee Tribe.

We appreciate your cooperation in notifying the Historic Preservation Office. Should you have any questions, feel free to contact me.

Sincerely,

Sherry White
Sherry White
Tribal Historic Preservation Officer



(715) 793-3970

Email: sherry.white@mohican-nsn.gov



United States Department of the Interior

FISH AND WILDLIFE SERVICE
 Pennsylvania Field Office
 315 South Allen Street, Suite 322
 State College, Pennsylvania 16801-4850



April 23, 2008

Louise Lund, Branch Chief
 Projects Branch 1
 Division of License Renewal
 Office of Nuclear Reactor Regulation
 Nuclear Regulatory Commission
 Washington, D.C. 20555-0001

Re: Three Mile Island Nuclear Station, Unit 1, License Renewal Application Review
 USFWS Project #2007-1764

Dear Ms. Lund:

This responds to your April 4, 2008, letter requesting information on threatened or endangered species or other natural resources of concern in the referenced project area. The following comments are provided pursuant to the Endangered Species Act of 1973 (87 Stat. 884, as amended; 16 U.S.C. 1531 *et seq.*) to ensure the protection of endangered and threatened species, and the Bald and Golden Eagle Protection Act (Eagle Act; 16 U.S.C. 668-668d).

Federally Listed Threatened or Endangered Species

Except for occasional transient species, no federally listed or proposed threatened or endangered species under our jurisdiction are known to occur within the project impact area. Therefore, based on currently available information, no biological assessment or further consultation under the Endangered Species Act is required with the Fish and Wildlife Service. Should project plans change, or if additional information on listed or proposed species becomes available, this determination may be reconsidered.

Bald Eagle

In a letter to Michael Gallagher of AmerGen (copy enclosed), dated June 7, 2007, we advised that a bald eagle nest is located on the west side of the Susquehanna River to the northwest of the Three Mile Island facility. At the time, the bald eagle was federally listed as threatened. However, the Fish and Wildlife Service has since published a final rulemaking to remove the bald eagle from the federal *List of Endangered and Threatened Wildlife* on July 9, 2007 (*Federal Register*, Vol. 72, No. 130). This rule became effective on August 8, 2007. Although the bald

Appendix D

eagle no longer receives protection under the Endangered Species Act, it continues to be protected under the Eagle Act and the Migratory Bird Treaty Act. Both acts protect bald eagles by prohibiting killing, selling or otherwise harming eagles, their nests or eggs. The Eagle Act also protects eagles from disturbance. Disturb means to agitate or bother a bald or golden eagle to a degree that causes, or is likely to cause, based on the best scientific information available, 1) injury to an eagle, 2) a decrease in its productivity, by substantially interfering with normal breeding, feeding, or sheltering behavior, or 3) nest abandonment, by substantially interfering with normal breeding, feeding, or sheltering behavior.

The Service has developed *National Bald Eagle Management Guidelines* to advise landowners, land managers and others who share public and private lands with bald eagles when and under what circumstances the protective provisions of the Eagle Act may apply to their activities. The *Guidelines* include general recommendations for land management practices that will benefit bald eagles; however, the document is intended primarily as a tool to provide those who seek information and recommendations regarding how to avoid disturbing bald eagles. Adherence to the *Guidelines* will benefit individuals, agencies, organizations and companies by helping them avoid violations of the law. The *Guidelines* can be found at <http://www.fws.gov/migratorybirds/baldeagle.htm>; any questions about the *Guidelines* or how they would apply to a particular project, can be directed to this office.

Transmission lines and their support structures within or close to the shores of the river would be ideal perching locations for foraging eagles. If the lines are not already equipped with features to prevent raptor electrocution and collisions, we recommend that any future upgrades be designed following the *Suggested Practices for Avian Protection on Power Lines: The State of the Art in 2006* (available from the Avian Power Line Interaction Committee at <http://www.aplic.org>).

Based on our review of the proposed project, it is our determination that this project will not disturb bald eagles. Because no take or disturbance is anticipated, none is authorized. If project plans change, please contact the Service to determine whether or not the project modifications will result in effects to bald eagles that may necessitate an Eagle Act permit or Endangered Species Act authorization.

Thank you for the opportunity to comment. Please direct any questions regarding this matter to Cindy Tibbott of my staff at 814-234-4090.

Sincerely,



David Densmore
Supervisor

Enclosures

Appendix D

Cc:
Michael Gallagher, AmerGen, 200 Exelon Way, KSA/2-E, Kennett Square, PA. 19348

CTibbott:clt 4/15/08
P:\Drafts\Drafts 2008\2007-1764 Three Mile Island.doc



Pennsylvania Department of Conservation and Natural Resources

Bureau of Forestry

May 2, 2008

Louise Lund, Branch Chief, Reactor Projects 1
MS O-11F1
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

C.C. Sarah Lopas
MS O-11F1
U.S. Nuclear Regulatory Commission
11555 Rockville Pike
Rockville, MD 20852

<i>Pennsylvania Natural Diversity Inventory Review, PNDI Number</i>	19605 (old #19248)
Three Mile Island Unit 1 License Renewal Species of Special Concern	
Dauphin & Lancaster Counties	


Dear Ms. Lund,

This responds to your request about a Pennsylvania Natural Diversity Inventory (PNDI) ER Tool "Potential Impact" or a species of special concern impact review. We screened this project for potential impacts to species and resources of special concern under the Department of Conservation and Natural Resources' responsibility, which includes plants, natural communities, terrestrial invertebrates and geologic features only.

PNDI records indicate that species and communities of special concern under DCNR's jurisdiction are known to occur in the vicinity of the above-mentioned project. Please see the attached list for species found in the vicinity of this project. No impact is anticipated since earth disturbance is expected to be "within the bounds of the Three Mile Island Flood Protection dike," as stated in April 15, 2008 letter to DCNR. If plans change to include disturbance outside of the Flood Protection dike area (particularly if more disturbance is required for Transmission Line No. 1051), please coordinate with our office as a survey may be requested.

This response represents the most up-to-date summary of the PNDI data files and is good for one (1) year from the date of this letter. An absence of recorded information does not necessarily imply actual conditions on-site. A field survey of any site may reveal previously unreported populations. Should project plans change or additional information on listed or proposed species become available, this determination may be reconsidered.

This finding applies to impacts to plants, natural communities, terrestrial invertebrates and geologic features only. To complete your review of state and federally-listed species of special concern, please be sure the U.S. Fish and Wildlife Service, the PA Game Commission and the Fish and Boat Commission has been contacted regarding this project either directly or by performing a search with the online PNDI-ER Tool found at www.naturalheritage.state.pa.us.


 Rebecca H. Bowen, Environmental Review Specialist
 DCNR/BOF/PNDI, PO Box 8552, Harrisburg, PA 17105 ~ Ph: 717-772-0258 ~ F: 717-772-0271 ~ [e-rbowen@state.pa.us](mailto:r-bowen@state.pa.us)

Stewardship Partnership Service

Bureau of Forestry

May 2, 2008

<i>Pennsylvania Natural Diversity Inventory Review, PNDI Number 19605 (old #19248)</i>
Three Mile Island Unit I License Renewal Species of Special Concern
Dauphin & Lancaster Counties

Plant Species of Special Concern

Scientific Name	Common Name	Current Status	Proposed Status	Habitat	Flowering time
<i>Boltonia asteroides</i>	Aster-like Boltonia	PE	PE	rocky shores and exposed rocky river beds	flowers July-Oct
<i>Carex shortiana</i>	Sedge	N	PR	calcareous wet meadows and swamps and rich woods	
<i>Eleocharis compressa</i>	Flat-stemmed Spike-rush	PE	PE	wet, sandy ground and river banks	
<i>Ellisia nyctelea</i>	Ellisia	PT	PT	damp, shady banks and rich alluvial woods	flowers in May

Additional Information:***Butterfly Species of Special Concern***

Scientific Name	Common Name	Global Rank	State Rank	Habitat	Larval Host
<i>Lycaena hyllus</i>	Bronze Copper	Globally Secure	Currently unrankable due to lack of information or due to substantially conflicting information about status or trends.	Low wet meadows / marshes, especially in river flood plains. Very large, floppy-flying copper.	Water dock (<i>Rumex orbiculatus</i>) and curled dock (<i>Rumex crispus</i>)

Geologic Features of Special Concern

Erosional Remnant made up of a series of large potholes in diabase in the bed of the Susquehanna from the Triassic Age is known to exist where the transmission lines cross the river towards York Haven.

Communities of Special Concern

There is also a Riverside Outcrop Community in the vicinity. This community is characterized by semi-permanently or seasonally flooded vegetation of the riverbed, banks and islands.

More information on this community may be found online in *Terrestrial & Palustrine Plant Communities of Pennsylvania* by Jean Fike, Pennsylvania Natural Diversity Inventory:
<http://www.dcnr.state.pa.us/wrcf/fikebook/21Chapter8.pdf> (page 55).

No impact anticipated; this list is for your own information.



COMMONWEALTH OF PENNSYLVANIA
PENNSYLVANIA GAME COMMISSION
2001 ELMERTON AVENUE, HARRISBURG, PA 17110-9797

May 14, 2008

Ms. Louise Lund
U.S. Nuclear Regulatory Commission
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation
Washington, D.C. 20555-0001

In re: State-Protected Bird and Mammal Species Review
Three Mile Island Nuclear Station
License Renewal, Application
Londonderry Township, Dauphin County, PA

Dear Ms. Lund:

This is in response to your request of April 15, 2008 regarding information on state-listed, proposed, and candidate species of birds or mammals, recognized by the Pennsylvania Game Commission (PGC), which may be in the vicinity of the Three Mile Island Nuclear Station (TMI).

Our office review has determined that Prothonotary Warblers (*Protonotaria citrea*), Bald Eagles (*Haliaeetus leucocephalus*), Yellow-crowned Night Herons (*Nycticorax violacea*), and Black-crowned Night Herons (*Nycticorax nycticorax*) have been documented nesting and foraging in proximity to the Three Mile Island Nuclear Station. Peregrine Falcons (*Falco peregrinus*) have been documented nesting on the Unit 1 Reactor Building, and Ospreys (*Pandion haliaetus*) have been documented nesting atop the weather station at the TMI.

The renewal of the TMI Operating License is not anticipated to cause any adverse impacts to special concern species of birds and mammals that may be in the vicinity of the transmission line corridors associated the electric generating station. No adverse impacts to ospreys and peregrine falcons are anticipated due to the license renewal since there has been ongoing coordination by the AmerGen Energy Company, LLC with the PGC regarding Best Management Practices for the endangered and threatened species nesting at TMI. This determination may be reconsidered if project plans change or extend beyond the present study area, or if additional information becomes available on state-listed species.

If you have any questions, please contact me at (717) 787-4250. Please be advised that this determination is only valid for one year from the date of this letter.

ADMINISTRATIVE BUREAUS:

PERSONNEL: 717-787-7836 ADMINISTRATION: 717-787-5670 AUTOMOTIVE AND PROCUREMENT: 717-787-6594
LICENSE DIVISION: 717-787-2084 WILDLIFE MANAGEMENT: 717-787-5529 INFORMATION & EDUCATION: 717-787-6286
WILDLIFE PROTECTION: 717-787-5740 WILDLIFE HABITAT MANAGEMENT: 717-787-6818 REAL ESTATE: 717-787-6568
AUTOMATED TECHNOLOGY SYSTEMS: 717-787-4076


WWW.PGC.STATE.PA.US

Ms. Louise Lund

2

May 14, 2008

Very truly yours,



James R. Leigey
Wildlife Impact Review Coordinator
Division of Environmental
Planning and Habitat Protection
Bureau of Wildlife Habitat Management

Cc: File



established 1866

Pennsylvania Fish & Boat Commission

Division of Environmental Services
Natural Diversity Section
450 Robinson Lane
Bellefonte, PA 16823-9620
(814) 359-5237 Fax: (814) 359-5175

June 3, 2008

IN REPLY REFER TO
SIR # 28464

SARAH LOPAS
UNITED STATES NUCLEAR REGULATORY COMMISSION
11555 ROCKVILLE PIKE
MAIL STOP 0-11F1
ROCKVILLE, MD 20852

RE: Species Impact Review (SIR) - Rare, Candidate, Threatened and Endangered Species
THREE MILE ISLAND NUCLEAR STATION
LONDONDERRY Township/Borough, DAUPHIN County, Pennsylvania

This responds to your inquiry about a Pennsylvania Natural Diversity Inventory (PNDI) Internet Database search "potential conflict" or a threatened and endangered species impact review. These projects are screened for potential conflicts with rare, candidate, threatened or endangered species under Pennsylvania Fish & Boat Commission jurisdiction (fish, reptiles, amphibians, aquatic invertebrates only) using the Pennsylvania Natural Diversity Inventory (PNDI) database and our own files. These species of special concern are listed under the Endangered Species Act of 1973, the Wild Resource Conservation Act, and the Pennsylvania Fish & Boat Code (Chapter 75), or the Wildlife Code. The absence of recorded information from our files does not necessarily imply actual conditions on site. Future field investigations could alter this determination. The information contained in our files is routinely updated. A Species Impact Review is valid for one year only.

NO ADVERSE IMPACTS EXPECTED FROM THE PROPOSED PROJECT

Except for occasional transient species, rare, candidate, threatened or endangered species under our jurisdiction are not known to exist in the vicinity of the project area. Therefore, no biological assessment or further consultation regarding rare species is needed with the Commission. Should project plans change, or if additional information on listed or proposed species becomes available, this determination may be reconsidered.

An element occurrence of a rare, candidate, threatened, or endangered species under our jurisdiction is known from the vicinity of the proposed project. However, given the nature of the proposed project, the immediate location, or the current status of the nearby element occurrence(s), no adverse impacts are expected to the species of special concern.

If you have any questions regarding this review, please contact the biologist indicated below:

<input type="checkbox"/> Jeff Schmid	814-359-5236	<input type="checkbox"/> Tina Walther	814-359-5186
<input checked="" type="checkbox"/> Nevin Welte	814-359-5234	<input type="checkbox"/> Bob Morgan	814-359-5129

I am enclosing a copy of our "SIR Request Form", which is to be used for all future species impact review requests. Please make copies of the attached form and use with all future project reviews. Thank you in advance for your cooperation and attention to this important matter of species conservation and habitat protection.

SIGNATURE:  DATE: June 3, 2008
Christopher A. Urban
Chief, Natural Diversity Section

Our Mission:

www.fish.state.pa.us

To protect, conserve and enhance the Commonwealth's aquatic resources and provide fishing and boating opportunities.



IN REPLY REFER TO:

United States Department of the Interior

OFFICE OF THE SECRETARY
Office of Environmental Policy and Compliance
Custom House, Room 244
200 Chestnut Street
Philadelphia, Pennsylvania 19106-2904



March 3, 2009

ER08/1285

Chief Rulemaking, Directives Editing Branch
U.S. NRC
Mail Stop T6-D59
Washington, D.C. 20555-0001

RE: Draft Generic Environmental Impact Statement, NUREG-1437, Supplement 37, for the License Renewal of Three Mile Island Nuclear Station, Unit 1; Dauphin County, Pennsylvania.

Dear Sir / Madame:

The Department of the Interior (Department) has reviewed the above-referenced Notice, dated December 9, 2008, regarding Three Mile Island Nuclear Station located in Londonderry Township, Dauphin County, Pennsylvania. AmerGen, LLC, proposes to renew its license to operate a nuclear power project at the existing Three Mile Island Nuclear Station.

The following comments are provided pursuant to the Endangered Species Act of 1973 (87 Stat. 884, as amended; 16 U.S.C. 1531 *et seq.*) to ensure the protection of federally listed endangered and threatened species, and the Fish and Wildlife Coordination Act (48 Stat. 401, as amended; 16 U.S.C. 661 *et seq.*) to ensure protection of other fish and wildlife resources.

FEDERALLY LISTED SPECIES

Except for occasional transient species, no federally listed or proposed, threatened or endangered species under our jurisdiction are known to occur within the project impact area. Therefore, based on currently available information, no biological assessment or further consultation under the Endangered Species Act is required with the Fish and Wildlife Service. Should project plans change, or if additional information on listed or proposed species becomes available, this determination may be reconsidered.

BALD EAGLE

Bald eagles are known to occur in the vicinity of the Three Mile Island facility. Although the bald eagle has been removed from the federal *List of Endangered and Threatened Wildlife*, and is therefore no longer protected under the Endangered Species Act, it continues to be protected under the Bald and Golden Eagle Protection Act (Eagle Act) and the Migratory Bird Treaty Act (MBTA). Both acts protect bald eagles by prohibiting killing, selling or otherwise harming

eagles, their nests or eggs. The Eagle Act also protects eagles from disturbance. "Disturb" means to agitate or bother a bald or golden eagle to a degree that causes, or is likely to cause, based on the best scientific information available, 1) injury to an eagle; 2) a decrease in its productivity, by substantially interfering with normal breeding, feeding, or sheltering behavior, or 3) nest abandonment, by substantially interfering with normal breeding, feeding, or sheltering behavior.

On June 4, 2007, the Service released several important documents related to the protection of bald eagles under the Eagle Act, including 1) a final rule establishing a regulatory definition of "disturb"; 2) a final environmental assessment of the "disturb" regulation; 3) *National Bald Eagle Management Guidelines*; and 4) a proposed rule to establish a permit for the take of bald and golden eagles. The proposed rule would establish regulations for issuing permits to take bald and golden eagles where the take is associated with, and not the purpose of, otherwise lawful activities. A second permit type would provide for permits to take bald and golden eagle nests for safety emergencies (of humans or eagles). All of these documents can be found at <http://www.fws.gov/migratorybirds/baldeagle.htm>.

A bald eagle nest is located approximately three miles northwest from the Three Mile Island facility. In addition, bald eagles are continuing to expand their breeding range along the Susquehanna River, and therefore may be found in previously undocumented locations near the facility. Consequently, we recommend that the applicant carefully evaluate the project type, size, location and layout in light of the *National Bald Eagle Management Guidelines* to determine whether or not bald eagles might be disturbed as a direct or indirect result of this project. If it appears that disturbance may occur, we recommend that the applicant consider modifying the project to be consistent with the *Guidelines*. If the applicant has questions about when and how to obtain a permit because he or she believes that the proposed project will disturb bald eagles, and he or she is not able to implement measures to avoid disturbance, please contact the Fish and Wildlife Service Migratory Bird Permit Program at 413-253-8643 or permitsr5mb@fws.gov.

Lastly, the applicant should incorporate state-of-the art methods to prevent raptor electrocution and collisions (see *Suggested Practices for Avian Protection on Power Lines: the State of the Art in 2006*, available from the Avian Power Line Interaction Committee at <http://www.aplic.org>). Siting new power lines as far as possible from known eagle nests would help reduce the electrocution/collision risk, as would equipping existing or new lines with features that would prevent raptor electrocution and collisions.

SPECIFIC COMMENTS

Section 2.2.7 Threatened and Endangered Species and Section 4.7 Threatened or Endangered Species. The DEIS (pages 4-8 and 4-9) indicates that the osprey (*Pandion haliaetus*) is one of the eleven State-listed threatened or endangered species that have been determined to be species of special concern for the TMI-1 site of the license renewal project. The DEIS (pages 4-8 and 4-9) states that mitigation measures for the osprey (and other species) currently in place at the TMI-1 site include nest construction and placement, and that "these current mitigation measures are found to be adequate." However, in a previous section, the DEIS contradicts this conclusion, claiming (page 2-40) that nesting relocation efforts by the State-listed, threatened osprey (*Pandion haliaetus*) have been unsuccessful, citing AmerGen

(2008) as the reference. It would benefit the public for the final EIS to include more specific information as to why such relocation efforts may not be successful, and include the results of scientific studies on such efforts, such as the undated US Geological Survey (USGS) citation which indicates that "ospreys typically pair for life and use the same nest site in successive years." The USGS reference also includes other relevant information and cites several additional references that may be useful in the analyses and evaluation of proposed mitigation measures to be included in the final EIS, such as studies which indicate that "Colonies [of ospreys] may arise in secure areas such as islands or lakes, but most pairs tend to be solitary nesters, separated from other nests by tens to hundreds of kilometers (McVey et al., 1993)." Available scientific information regarding nesting relocation measures would be important considerations for identifying appropriate mitigation measures and measuring the severity of the impact from the proposed project.

Table 2-6, pages 2-41 through 2-49. The correct designation in the footnote on page 2-49 for a State-listed threatened species should be "PT" and not "ST" as currently listed.


Section 2.4 References, page 2-76. The link to the U.S. Fish and Wildlife Service (2008a) citation (for ospreys) is not correct. The correct link should read as follows:
<http://www.fws.gov/chesapeakebay/osprey.html>.

Conclusions

The applicant should be directed to clarify or gather additional information on the questions identified above. This may entail conducting appropriate field studies to obtain site-specific information. We also ask that the Commission continue to coordinate with the Fish and Wildlife Service throughout the license renewal process.

Thank you for the opportunity to review and comment on this Draft Environmental Impact Statement. If you have any questions regarding this matter, please contact Lloyd Woosley of the USGS Environmental Affairs Program at (703) 350-8797, or Jennifer Kagel of the U. S. Fish and Wildlife Service's Pennsylvania Field Office at 814-234-4090.

Sincerely,



Michael T. Chezik
Regional Environmental Officer

Appendix E

Chronology of Environmental Review

E. Chronology of Environmental Review Correspondence

This appendix contains a chronological listing of correspondence between the U.S. Nuclear Regulatory Commission (NRC) and external parties as part of its environmental review for Three Mile Island Nuclear Station, Unit 1. All documents, with the exception of those containing proprietary information are available electronically from the NRC's Public Electronic Reading Room found on the Internet at the following Web address: <http://www.nrc.gov/reading-rm.html>. From this site, the public can gain access to the NRC's Agencywide Document Access and Management System (ADAMS), which provides text and image files of NRC's public documents in ADAMS. The ADAMS accession number for each document is included below.

E.1 Environmental Review Correspondence

January 8, 2008	Letter from AmerGen forwarding the application for renewal of operating license for Three Mile Island, Unit 1, requesting an extension of operating license for an additional 20 years (ADAMS Accession No. ML080220219).
January 25, 2008	Letter to AmerGen, "Receipt and Availability of the License Renewal Application for the Three Mile Island Nuclear Station, Unit 1" (ADAMS Accession No. ML073310128).
January 28, 2008	NRC press release announcing the availability of the license renewal application for Three Mile Island, Unit 1, for public inspection (ADAMS Accession No. ML080280293).
January 31, 2008	<i>Federal Register</i> notice, "AmerGen Energy Company, LLC; Notice of Receipt and Availability of Application for Renewal of Three Mile Island Nuclear Station, Unit 1, Facility Operating License No. DPR-50 for an Additional 20-Year Period" (73 FR 5877).
February 14, 2008	Notice of public meeting to discuss the license renewal process for the Three Mile Island Nuclear Station, Unit 1, license renewal application Review (ADAMS Accession No. ML080380505).
February 26, 2008	NRC press release announcing the public meeting to discuss the review of the license renewal application for Three Mile Island Nuclear Power Plant (ADAMS Accession No. ML080570365).
March 10, 2008	Letter to AmerGen transmitting "Determination of Acceptability and Sufficiency for Docketing, Proposed Review Schedule, and Opportunity for a Hearing Regarding an Application from AmerGen Energy Company, LLC, for Renewal of the Operating License for

Appendix E

Three Mile Island Nuclear Station, Unit 1" (ADAMS Accession No. ML080370352).

- March 10, 2008 NRC press release announcing opportunity to request hearing on license renewal application for Three Mile Island Nuclear Plant (ADAMS Accession No. ML080700892).
- March 14, 2008 *Federal Register* notice, "Notice of Acceptance for Docketing of the Application and Notice of Opportunity for Hearing; Regarding Renewal of Facility Operating License No. DPR-50 for an Additional 20-Year Period; AmerGen Energy Company, LLC Three Mile Island Nuclear Station, Unit 1" (73 FR 13923).
- March 21, 2008 Letter to AmerGen, "Three Mile Island Nuclear Station, Unit 1 License Renewal Application Online Reference Portal" (ADAMS Accession No. ML080710465).
- March 24, 2008 Letter to AmerGen forwarding *Federal Register* notice, "Three Mile Island Nuclear Station, Unit 1; Notice of Intent to Prepare and Environmental Impact Statement and Conduct Scoping," in support of the review of the license renewal application (ADAMS Accession No. ML080780085).
- March 26, 2008 Notice of public meeting to discuss the environmental scoping process for the Three Mile Island Nuclear Station, Unit 1, license renewal application review (ADAMS Accession No. ML080800502).
- March 28, 2008 *Federal Register* notice, "Three Mile Island Nuclear Station, Unit 1; Notice of Intent to Prepare an Environmental Impact Statement and Conduct Scoping Process" (73 FR 16729).
- March 31, 2008 Letter from AmerGen, "Editorial Corrections to the Three Mile Nuclear Station Unit 1 License Renewal Application Environmental Report" (ADAMS Accession No. ML080930302).
- March 31, 2008 Letter from AmerGen, "Three Mile Island Nuclear Station Unit 1 License Renewal Application Online Reference Portal" (ADAMS Accession No. ML080930301).
- April 1, 2008 Letter to AmerGen, "Environmental Site Audit Regarding Three Mile Island Nuclear Station, Unit 1, License Renewal Application" (ADAMS Accession No. ML080840029).
- April 3, 2008 Letter from AmerGen, "Three Mile Island Nuclear Station Unit 1 License Renewal Application Selected Environmental Report References" (ADAMS Accession No. ML081420193).

- April 4, 2008 Letter to David Densmore, U.S. Fish and Wildlife Service, request for list of protected species for the Three Mile Island Nuclear Station, Unit 1, license renewal review (ADAMS Accession No. ML080840027).
- April 9, 2008 Letter to The Honorable Raymond Halbritter, Nation Representative, Oneida Indian Nation, inviting participation in scoping process related to NRC's environmental review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML080980572).
- April 9, 2008 Letter to The Honorable Paul Spicer, Chief, Seneca-Cayuga Tribe of Oklahoma, inviting participation in scoping process related to NRC's environmental review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML080980572).
- April 9, 2008 Letter to The Honorable Barry Snyder, Sr., President, Seneca Nation of Indians, inviting participation in scoping process related to NRC's environmental review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML080980572).
- April 9, 2008 Letter to The Honorable Robert Chicks, Tribal Chairman, Stockbridge-Munsee Band of the Mohican Nation, Wisconsin, inviting participation in scoping process related to NRC's environmental review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML080980572).
- April 9, 2008 Letter to The Honorable Tony Gonyea, Faithkeeper, Onondaga Nation, inviting participation in scoping process related to NRC's environmental review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML080980572).
- April 9, 2008 Letter to The Honorable Gerald Dansforth, Chairwoman, Oneida Nation of Wisconsin, inviting participation in scoping process related to NRC's environmental review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML080980572).
- April 9, 2008 Letter to The Honorable Glenna Wallace, Chief, Eastern Shawnee Tribe of Oklahoma, inviting participation in scoping process related to NRC's environmental review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML080980572).
- April 9, 2008 Letter to The Honorable Kerry Holton, Tribal President, Delaware Nation, inviting participation in scoping process related to NRC's

Appendix E

environmental review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML080980572).

- April 9, 2008 Letter to The Honorable Clint Halftown, Heron Clan Representative, Cayuga Nation, inviting participation in scoping process related to NRC's environmental review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML080980572).
- April 9, 2008 Letter to The Honorable Scott Miller, Governor, Absentee-Shawnee Tribe of Oklahoma, inviting participation in scoping process related to NRC's environmental review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML080980572).
- April 9, 2008 Letter to The Honorable James Ransom, Chief, St. Regis Mohawk Tribe, inviting participation in scoping process related to NRC's environmental review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML080980572).
- April 9, 2008 Letter to The Honorable Roger Hill, Chief, Tonawanda Seneca Nation, inviting participation in scoping process related to NRC's environmental review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML080980572).
- April 9, 2008 Letter to The Honorable Leo Henry, Chief, Tuscarora Nation, inviting participation in scoping process related to NRC's environmental review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML080980572).
- April 9, 2008 Letter to The Honorable Ron Sparkmann, Chairman, Shawnee Tribe, inviting participation in scoping process related to NRC's environmental review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML080980572).
- April 15, 2008 Letter to Charlene Dwin Vaughn, Assistant Director, Advisory Council on Historic Preservation, regarding Three Mile Island Nuclear Station, Unit 1 license renewal review (ADAMS Accession No. ML080930296).
- April 15, 2008 Letter to Rich Janati, Chief, Division of Nuclear Safety, Bureau of Radiation Protection, Pennsylvania Department of Environmental Protection, regarding Three Mile Island Nuclear Station, Unit 1, license renewal (ADAMS Accession No. ML080860022).

- April 15, 2008 Letter to Rachel Diamond, Regional Director, Pennsylvania Department of Environmental Protection Southcentral Regional Office, regarding Three Mile Island Nuclear Station, Unit 1, license renewal review (ADAMS Accession No. ML080930617).
- April 15, 2008 Letter to Michael G. Brownell, Chief, Water Resources Management, Susquehanna River Basin Commission, regarding Three Mile Island Nuclear Station, Unit 1, license renewal review (ADAMS Accession No. ML080930632).
- April 15, 2008 Letter to Chris Firestone, Native Plant Program Manager, Pennsylvania Department of Conservation and Natural Resources, request for list of protected species and important habitats for the Three Mile Island Nuclear Station, Unit 1, license renewal review (ADAMS Accession No. ML080930247).
- April 15, 2008 Letter to Christopher Urban, Chief of Natural Diversity Section, Pennsylvania Fish & Boat Commission, request for list of State-protected species for the Three Mile Island Nuclear Station, Unit 1, license renewal review (ADAMS Accession No. ML080930486).
- April 15, 2008 Letter to James Leigey, Wildlife Impact Review Coordinator, Pennsylvania Game Commission, request for list of State-protected species for the Three Mile Island Nuclear Station, Unit 1, license renewal review (ADAMS Accession No. ML080930178).
- April 15, 2008 Letter to Jean Cutler, Deputy State Historic Preservation Officer, Pennsylvania Historic and Museum Commission, regarding Three Mile Island Nuclear Station, Unit 1, license renewal review (ADAMS Accession No. ML080930380).
- April 15, 2008 NRC press release announcing the Three Mile Island, Unit 1, license renewal environment scoping meeting (ADAMS Accession No. ML081060426).
- April 21, 2008 Letter from Sherry White, Tribal Historic Preservation Officer, Stockbridge-Munsee Tribal Historic Preservation Office, regarding Three Mile Island Nuclear Station, Unit 1, license renewal review (ADAMS Accession No. ML081280309).
- April 23, 2008 Letter from David Densmore, Supervisor, U.S. Fish and Wildlife Service, Pennsylvania Field Office, regarding Three Mile Island Nuclear Station, Unit 1, license renewal application review (ADAMS Accession No. ML081280307).

Appendix E

- April 23, 2008 Letter from Rebecca H. Bowen, Environmental Review Specialist, Pennsylvania Department of Conservation and Natural Resources, regarding Three Mile Island, Unit 1, license renewal species of special concern (ADAMS No. Accession ML081300048).
- May 2, 2008 Summary of public meetings related to the license renewal process for the Three Mile Island Nuclear Station, Unit 1, license renewal application (ADAMS Accession No. ML081000290).
- May 14, 2008 Letter from James R. Leigey, Wildlife Impact Review Coordinator, Pennsylvania Game Commission, regarding State-protected bird and mammal species review for Three Mile Island Nuclear Station license renewal application, Londonderry Township, Dauphin County, Pennsylvania (ADAMS Accession No. ML081500671).
- May 21, 2008 Letter to AmerGen, "Request for Additional Information Regarding Severe Accident Mitigation Alternatives for Three Mile Island Nuclear Station, Unit 1, License Renewal" (ADAMS Accession No. ML081330714).
- May 22, 2008 Summary of public environmental scoping meetings related to the review of the Three Mile Island Nuclear Station, Unit 1, license renewal application (ADAMS Accession No. ML081360648).
- June 3, 2008 Letter from Christopher A. Urban, Chief, Natural Diversity Section, Pennsylvania Fish & Boat Commission, regarding species impact review for Three Mile Island Nuclear Station, Londonderry Township/Borough, Dauphin County, Pennsylvania (ADAMS Accession No. ML081610104).
- June 3, 2008 Commission order denying Mr. Marvin Lewis's Petition to Intervene (ADAMS Accession No. ML081550359).
- June 10, 2008 Letter from AmerGen, "Three Mile Island Nuclear Station Unit 1 License Renewal Application Post-Audit Environmental Information" (ADAMS Accession No. ML082110260).
- June 12, 2008 Summary of conference call with AmerGen to discuss the severe accident mitigation alternatives and requests for additional information for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML081560666).
- July 17, 2008 Letter from AmerGen, "Response to NRC Request for Additional Information related to the Three Mile Island Nuclear Station Unit 1 License Renewal Application" (ADAMS Accession No. ML082040144).

August 4, 2008 Summary of site audit related to the review of the license renewal application for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML081420398).

August 5, 2008 Summary of telephone conference call held on July 17, 2008, between the NRC and AmerGen, concerning followup questions pertaining to the Three Mile Island Nuclear Station, Unit 1, license renewal environmental review and site audit (ADAMS Accession No. ML082120727).

August 5, 2008 Letter from AmerGen, "Three Mile Island Nuclear Station Unit 1 License Renewal Application Post-Audit Environmental Information" (ADAMS Accession No. ML082200589).

August 8, 2008 Letter to AmerGen regarding environmental scoping summary report associated with the staff's review of the application by AmerGen for renewal of the operating license for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML081920230).

September 8, 2008 Summary of conference call with AmerGen Energy Company, LLC, to discuss responses to severe accident mitigation alternatives request for additional information for Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML082340226).

December 3, 2008 Letter to AmerGen, "Notice of Availability of the Draft Plant-Specific Supplement 37 to the Generic Environmental Impact Statement for License Renewal of Nuclear Plants (GEIS) Regarding Three Mile Island Nuclear Station, Unit 1" (ADAMS Accession No. ML083100818).

December 3, 2008 Letter to U.S. Environmental Protection Agency, Office of Federal Activities, NEPA Compliance Division, regarding Notice of Availability of the draft plant-specific Supplement 37 to the Generic Environmental Impact Statement for License Renewal of Nuclear Plants Regarding Three Mile Island Nuclear Station, Unit 1" (ADAMS Accession No. ML083110491).

December 3, 2008 Letter to Doug McLearn, Chief, Division of Archaeology and Protection, Pennsylvania Historical and Museum Commission, regarding Notice of Availability of the draft plant-specific Supplement 37 to the Generic Environmental Impact Statement for License Renewal of Nuclear Plants Regarding Three Mile Island Nuclear Station, Unit 1" (ADAMS Accession No. ML083100943).

Appendix E

December 9, 2008	<i>Federal Register</i> notice, "Notice of Availability of the Draft Supplement 37 to the Generic Environmental Impact Statement for License Renewal of Nuclear Plants, and Public Meeting for the License Renewal of Three Mile island Nuclear Station, Unit 1" (73 FR 74766).
December 10, 2008	Notice of public meeting to discuss the draft supplemental environmental impact statement regarding Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML083290436).
Decemeber 19, 2008	NRC press release announcing availability of draft supplemental environmental impact statement regarding Three Mile Island, Unit 1 (ADAMS Accession No. ML083540649).
December 23, 2008	Letter to AmerGen, "Correction to December 9, 2008 Federal Register Notice for Three Mile Island Nuclear Station, Unit 1 License Renewal" (ADAMS Accession No. ML083470302).
January 6, 2009	Correction to <i>Federal Register</i> notice, "Notice of Availability of the Draft Supplement 37 to the Generic Environmental Impact Statement for License Renewal of Nuclear Plants, and Public Meeting for the License Renewal of Three Mile island Nuclear Station, Unit 1" (74 FR 470).
January 21, 2009	NRC press release announcing public meetings to discuss draft supplemental environmental impact statement regarding Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML090210126).
January 26, 2009	Letter from Exelon Generation, "Future Correspondence Concerning the License Renewal Application of Three Mile Island, Unit 1, and a Revision to the License Renewal Commitment List" (ADAMS Accession No. ML090280368).
January 28, 2009	NRC press release regarding cancellation of public meetings to discuss draft supplemental environmental impact statement regarding Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML090280117).
February 4, 2009	Notice of rescheduled public meeting to discuss the draft supplemental environmental impact statement regarding Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML090340443).
February 9, 2009	Letter to Exelon Generation, "Date and Location Correction to December 9, 2008 Federal Register Notice for Three Mile Island

Nuclear Station, Unit 1 License Renewal" (ADAMS Accession No. ML090350448).

February 17, 2009 Correction to *Federal Register* Notice, "Notice of Availability of the Draft Supplement 37 to the Generic Environmental Impact Statement for License Renewal of Nuclear Plants, and Public Meeting for the License Renewal of Three Mile Island Nuclear Station, Unit 1 (74 FR 7488).

February 18, 2009 NRC press release announcing rescheduled public meetings to discuss draft supplemental environmental impact statement regarding Three Mile Island Nuclear Station, Unit 1 (ADAMS Accession No. ML090490459).

February 27, 2009 Letter from Exelon Corporation, "Comments on *NUREG-1437, Supplement 37 draft*" (ADAMS Accession No. ML090680038).

March 3, 2009 Letter from Michael T. Chezick, Regional Environmental Officer, United States Department the Interior, "Draft Generic Environmental Impact Statement, NUREG-1437, Supplement 37, for the License Renewal of Three Mile Island Nuclear Station, Unit1; Dauphin County, Pennsylvania" (ADAMS Accession No. ML090840544).

March 4, 2009 Letter from Kevin Magerr, Environmental Engineer, U.S. Environmental Protection Agency, "Generic Draft Environmental Impact Statement for License Renewal of Nuclear Plants Supplement 37 Regarding Three Mile Island Nuclear Station, Unit 1 December 2008 CEQ #20080503" (ADAMS Accession No. ML090750180).

March 9, 2009 Summary of public meetings on the draft supplemental environmental impact statement regarding Three Mile Island Nuclear Station, Unit 1 License Renewal Review (ADAMS Accession No. ML090620419).

March 25, 2009 Letter from Exelon Generation, "Three Mile Island Nuclear Station Unit 1 License Renewal Updated Environmental Information" (ADAMS Accession No. ML090890364).

March 30, 2009 Letter from Exelon Generation, "Three Mile Island Nuclear Station Unit 1 License Renewal Updated Environmental Information" (ADAMS Accession No. ML090910407).

May 15, 2009 Letter from Exelon Generation, "Three Mile Island Nuclear Station Unit 1 License Renewal Application Supplemental Updated Environmental Information." (ADAMS Accession No. ML091390217).

Appendix F
U.S. Nuclear Regulatory Commission Staff Evaluation of
Severe Accident Mitigation Alternatives (SAMAs) for
Three Mile Island Nuclear Station, Unit 1
In Support of License Renewal Application Review

F. U.S. Nuclear Regulatory Commission Staff Evaluation of Severe Accident Mitigation Alternatives (SAMAs) for Three Mile Island Nuclear Station, Unit 1 in Support of License Renewal Application Review

F.1 Introduction

Exelon Generation Company, LLC (Exelon Generation) submitted an assessment of severe accident mitigation alternatives (SAMAs) for the Three Mile Island Nuclear Station, Unit 1 (TMI-1) as part of the environmental report (ER) (AmerGen 2008a). This assessment was based on the most recent TMI-1 probabilistic risk assessment (PRA) available at that time, a plant-specific offsite consequence analysis performed using the MELCOR Accident Consequence Code System 2 (MACCS2) computer code (NRC 1998a), and insights from the TMI-1 individual plant examination (IPE) (GPU 1993) and individual plant examination of external events (IPEEE) (GPU 1994). In identifying and evaluating potential SAMAs, Exelon Generation considered SAMA candidates that addressed the major contributors to core damage frequency (CDF) and population dose at TMI-1, as well as SAMA candidates for other operating plants which have submitted license renewal applications. Exelon Generation identified 33 potential SAMA candidates. Exelon Generation assessed the costs and benefits associated with each of the potential SAMAs, and concluded in the ER that several of the candidate SAMAs evaluated are potentially cost-beneficial.

Based on a review of the SAMA assessment, the U.S. Nuclear Regulatory Commission (NRC) issued a request for additional information (RAI) to Exelon Generation by letter dated May 21, 2008 (NRC 2008a). Key questions concerned: major plant and modeling changes incorporated within each evolution of the PRA model; justification for the multiplier used for external events; assumptions used to quantify the benefits for certain SAMAs; identification of an optimal subset of potentially cost-beneficial SAMAs; and further information on several specific candidate SAMAs and low cost alternatives. Exelon Generation submitted additional information by letters dated July 17, 2008 (AmerGen 2008b) and September 8, 2008 (NRC 2008b). In the responses, Exelon Generation provided: additional information regarding the PRA model development; additional justification for the treatment of external events; additional explanation and justification for the assumptions used to quantify SAMA benefits; a qualitative assessment identifying the potentially cost-beneficial SAMAs having the greatest risk reduction relative to the cost of implementation; and additional information regarding several specific SAMAs. Exelon Generation's responses addressed the NRC staff's concerns, and resulted in the identification of two additional potentially cost-beneficial SAMAs.

An assessment of SAMAs for TMI-1 is presented below.

F.2 Estimate of Risk for TMI-1

Exelon Generation's estimates of offsite risk at TMI-1 are summarized in Section F.2.1. The summary is followed by the NRC staff's review of Exelon Generation's risk estimates in Section F.2.2.

F.2.1 Exelon Generation's Risk Estimates

Two distinct analyses are combined to form the basis for the risk estimates used in the SAMA analysis: (1) the TMI-1 Level 1 and 2 analyses, which are represented by the current Level 1 (Exelon 2007a) and Level 2 (Exelon 2007b) internal events PRA and the original IPEEE (GPU 1994), and (2) a supplemental analysis of offsite consequences and economic impacts (essentially a Level 3 PRA) developed specifically for the SAMA analysis. The SAMA analysis is based on the most recent TMI-1 Level 1 and 2 PRA model available at the time of the ER, referred to as the 2004 Revision 2 Level 1 model (Exelon 2007a), and the Level 2 model of 2007 (Exelon 2007b). The scope of the Level 1 model includes both internal and external initiating events. The external events evaluated include external floods, seismic events, and internal fires. However, the external events models are not integrated with the internal events model, thereby necessitating a separate assessment of the risk (and risk reduction) for internal and external events. Exelon Generation placed particular emphasis on external flooding events since they dominate the calculated risk at TMI-1.

The baseline CDF for the purpose of the SAMA evaluation is approximately 2.37×10^{-5} per year for internal events (including internal flooding events), and 8.11×10^{-5} per year for external flooding events. Exelon Generation accounted for the potential risk reduction benefits associated with internal event-and external flooding-related SAMAs by separately quantifying the benefits using the internal event or external flooding model, respectively. For internal event-related SAMAs, Exelon Generation accounted for the potential risk reduction benefits associated with non-flooding external events (i.e., seismic and fire events) by doubling the estimated benefits for internal events. For seismic- and fire-related SAMAs, Exelon Generation separately estimated the risk reduction benefits using the seismic and fire risk models. This is discussed further in Sections F.2.2 and F.6.2.

The breakdown of CDF by initiating event is provided in Tables F-1a and F-1b for internal events and external flooding events, respectively. As shown in these tables, internal event CDF is dominated by loss of offsite power events, transients, small loss of coolant accidents (LOCA), and loss of nuclear service water events. External flooding CDF is dominated by events with flood levels exceeding 310 feet mean sea level (msl).

The Level 2 PRA model that forms the basis for the SAMA evaluation represents an updated version of the original IPE Level 2 model. The Level 1 core damage sequences are binned into Plant Damage State bins which provide the interface between the Level 1 and Level 2 models. The Level 2 model utilizes a single containment event tree (CET) containing both phenomenological and systemic events. CET nodes are evaluated using supporting fault trees and logic rules.

Table F-1.a TMI-1 Internal Events Core Damage Frequency		
Initiating Event	CDF (Per Year)	% Contribution to CDF
Loss of Offsite Power	7.73×10^{-6}	32.6
Transients	5.80×10^{-6}	24.5
Small and Very Small LOCA	4.66×10^{-6}	19.7
Loss of Nuclear River Water	3.67×10^{-6}	15.5
Steam Generator Tube Rupture	9.93×10^{-7}	4.2
Internal Floods	4.50×10^{-7}	1.9
Large and Medium LOCA	2.06×10^{-7}	< 1
ISLOCA	1.80×10^{-7}	<1
Total CDF (internal events)	2.37×10^{-5}	100

Table F-1.b TMI-1 External Flooding Events Core Damage Frequency		
External Flooding Event	CDF (Per Year)	% Contribution to CDF
>310 feet	6.37×10^{-5}	78.5
305 to 310 feet	1.71×10^{-5}	21.1
<305 feet	2.50×10^{-7}	< 1
Total	8.11×10^{-5}	100

The result of the internal events Level 2 model is a set of 39 release categories with their respective frequency and release characteristics. The release categories and their frequencies are presented in Table E.2-16 of the ER. The categories were defined based on the timing, duration, and magnitude of the release and whether the containment remains intact or is bypassed. The frequency of each release category was obtained by summing the frequency of the individual CET end states assigned to each release category. The 39 release categories were further collapsed into nine major source term groups having similar containment response. The nine major source term groups and their release characteristics are presented in Tables E.2-17 and E.2-18 of the ER. The release characteristics for these nine source term groups were developed from Modular Accident Analysis Program (MAAP) analyses performed specifically to support the SAMA analysis (AmerGen 2008b).

Appendix F

For external flooding events, a simplified version of the internal events CET was developed and used to map external flood sequences to representative release categories from the internal events analysis. The result of the analysis is a set of eight release categories with their respective frequencies. These release categories were subsequently collapsed into seven non-zero source term groups. The mapping of external flood sequences to source term group is presented in Tables E.2-21 and E.2-23 of the ER.

The offsite consequences and economic impact analyses use the MACCS2 code to determine the offsite risk impacts on the surrounding environment and public. Inputs for these analyses include plant-specific and site-specific input values for core radionuclide inventory, source term and release characteristics, site meteorological data, projected population distribution (within an 50-mile (mi) (80-kilometer [km]) radius for the year 2034, emergency response evacuation modeling, and economic data. The magnitude of the onsite impacts (in terms of clean-up and decontamination costs and occupational dose) is based on information provided in NUREG/BR-0184 (NRC 1997a).

Exelon Generation estimated the dose to the population within 50 mi (80 km) of the TMI-1 site to be approximately 0.323 person-sievert (Sv) (32.3 person-rem) per year (AmerGen 2008a) for internal events and 1.76 person-Sv (176 person-rem) per year for external flooding events (AmerGen 2008b). The breakdown of the total population dose by containment release mode is summarized in Table F-2. Steam generator tube rupture (SGTR) accidents, and basemat melt-through are the dominant contributors to population dose risk from internal events. For external flooding events, late containment failures and early containment failure (less than 12 hours following accident initiation) are the dominant contributors to population dose risk.

Containment Release Mode	Internal Events		External Flooding Events	
	Population Dose (Person-Rem Per Year)	% Contribution	Population Dose (Person-Rem Per Year)	% Contribution
Steam generator tube rupture	11.7	36	0.1	<0.1
Interfacing system LOCA	1.0	3	negligible	0
Containment isolation failure	1.1	3	29	16
Early containment failure	5.6	17	61	35
Late containment failure (large)	0.3	1	15	9
Late containment failure (small)	1.7	5	66	37
Basemat melt-through	6.9	22	4	2
No containment failure	4.0	13	1	1
Total	32.3	100	176	100

(a) One person-rem = 0.01 person-Sv

F.2.2 Review of Exelon Generation's Risk Estimates

Exelon Generation's determination of offsite risk at TMI-1 is based on the following major elements of analysis:

- The Level 1 and 2 risk models that form the bases for the IPE submittal (GPU 1993) and the IPEEE submittal (GPU 1994),
- The major modifications to the IPE model that have been incorporated in the 2004 Revision 2 Level 1 model (Exelon 2007a), and the Level 2 model of 2007 (Exelon 2007b)
- Assignment of severe accident source terms to external flooding sequences, and
- The MACCS2 analyses performed to translate fission product source terms and release frequencies from the Level 2 PRA model into offsite consequence measures.

Each of these analyses was reviewed to determine the acceptability of Exelon Generation's risk estimates for the SAMA analysis, as summarized below.

The NRC staff's review of the TMI-1 IPE is described in an NRC report dated December 19, 1996 (NRC 1996). Based on a review of the IPE submittal and responses to RAIs, the NRC staff concluded that the IPE submittal met the intent of GL 88-20 (NRC 1988); that is, the licensee's IPE process is capable of identifying the most likely severe accidents and severe accident vulnerabilities. Although no vulnerabilities were identified in the IPE, several improvements to the plant or procedures were identified. These improvements have been either implemented at the site or addressed in the SAMA evaluation process (AmerGen 2008a). These improvements are discussed in Section F.3.2.

There have been six revisions to the Level 1 model since the 1992 IPE submittal. Exelon Generation indicated that the 2004 Revision 2 Level 1 model reflects the TMI-1 configuration and design as of the model's completion date of June 2007, but that no plant changes have occurred since completion of the model that would impact the PRA. A comparison of internal events CDF between the 1992 IPE and the current PRA model indicates a decrease of approximately 43 percent (from 4.19×10^{-5} per year to 2.37×10^{-5} per year). A comparison of the contributors to the total CDF indicates that some have increased (e.g., loss of offsite power) while others have decreased (e.g., large and medium LOCA). A description of those changes that resulted in the greatest impact on the internal events CDF was provided in Section E.2.2 of the ER (AmerGen 2008a), and is summarized in Table F-3.

The CDF value from the 1992 IPE submittal (4.19×10^{-5} per year) is near the average of the CDF values reported in the IPEs for B&W plants. Figure 11.6 of NUREG-1560 shows that the IPE-based total internal events CDF for these plants ranges from approximately 1×10^{-5} to 7×10^{-5} per year, with an average CDF for the group of 3×10^{-5} per year (NRC 1997b). It is recognized that other plants have updated the values for CDF subsequent to the IPE submittals to reflect modeling and hardware changes. The current internal event CDF result for TMI-1 (2.37×10^{-5} per year, including internal flooding) is comparable to that for other plants of similar vintage and characteristics.

Appendix F

Table F-3. TMI-1 PRA Historical Summary		
PRA Version	Summary of Changes from Prior Model	CDF (per year)
1992	IPE Submittal (excluding internal flooding)	4.19×10^{-5}
2000 Update	August 2000 update (including internal flooding CDF of 3.0×10^{-6}) - Changed model from reliability block diagrams to fault tree structure - Updated plant unavailability and failure rates	4.10×10^{-5}
L2RV2	November 2001 update (including internal flooding CDF of 2.56×10^{-6}) - Linked Level 2 model directly with Level 1 sequences	3.95×10^{-5}
ABSA	July 2003 update (including internal flooding CDF of 3.5×10^{-7}) - Resolved Level A and B Facts and Observations (F&Os) from peer certification - Updated initiating event, component failure, unavailability, and common cause databases - Revised human reliability analysis (HRA) using the EPRI HRA Calculator - Updated success criteria and operator action timing based on thermal-hydraulic (MAAP) analyses - Refined internal flooding screening analysis	3.38×10^{-5}
2004 Rev. 0	December 2004 update (including internal flooding CDF of 2.6×10^{-7}) - Converted model from RISKMAN linked event tree model to CAFTA single event fault tree model - Updated Main Feedwater and Main Steam system models related to steam generator isolation for SGTR and secondary line breaks - Updated 4KV/480V AC power system model to include individual fault trees for 480V buses and motor control centers - Updated common cause failure data to NUREG/CR-5497 (NRC 1998b) - Added logic to evaluate system availability following offsite power recovery - Incorporated joint human error probability (JHEP) basic events	3.09×10^{-5}
2004 Rev. 1	June 2005 update (including internal flooding CDF of 3.7×10^{-7}) - Corrected errors discovered subsequent to the conversion to CAFTA	3.36×10^{-5}
2004 Rev. 2	June 2007 update (including internal flooding CDF of 4.5×10^{-7}) - Added new basic events for common cause failure of several components - Added new maintenance unavailability events to include maintenance on various components - Added human error probabilities (HEPs) for controlling emergency feedwater, cooldown of the RCS, and steam generator isolation - Revised loss of offsite power (LOOP) initiating event frequency - Modified Very Small LOCAs event tree	2.37×10^{-5}

The NRC staff considered the peer reviews performed for the TMI-1 PRA, and the potential impact of the review findings on the SAMA evaluation. In the ER (AmerGen 2008a), Exelon Generation described the formal industry peer review of the 2000 Update Model conducted in August 2000. The final report on the peer review stated that "it was the general assessment of the peer review team that the TMI-1 PRA can be effectively used to support applications involving risk significant determinations supported by deterministic analysis, once the technical issues and recommendations for enhancements that are noted in the element summaries and Fact and Observation Sheets are addressed to an appropriate level of quality." Exelon Generation stated in the ER that all "A" and "B" facts and observations (F&O) with the exception of one "B" level observation are closed, and that the unresolved "B" observation related to the need for independent technical and system engineer reviews of system notebooks and would have no significant impact on the SAMA evaluation. In response to an NRC staff RAI, Exelon Generation stated that no other peer reviews of the TMI-1 PRA have been conducted since the August 2000 peer review (AmerGen 2008b).

Given that the TMI-1 internal events PRA model has been peer reviewed and the peer review findings were either addressed or judged to have no adverse impact on the SAMA evaluation, and that Exelon Generation has satisfactorily addressed NRC staff questions regarding the PRA, the NRC staff concludes that the internal events Level 1 PRA model is of sufficient quality to support the SAMA evaluation.

As indicated above, the current TMI-1 PRA does not include an integral evaluation of external events. In the absence of such an analysis, Exelon Generation used the TMI-1 IPEEE, in conjunction with minor adjustments in seismic and fire risk results, to identify the highest risk accident sequences and the potential means of reducing the risk posed by those sequences, as discussed below.

The TMI-1 IPEEE was submitted in December 1994 (GPU 1994), in response to Supplement 4 of Generic Letter 88-20. This submittal included a seismic PRA, a fire-induced vulnerability evaluation, and risk analyses for external flooding, high winds, and other external events. While no fundamental weaknesses or vulnerabilities to severe accident risk in regard to external events were identified, several opportunities for risk reduction were identified and implemented when demonstrated to be cost effective as discussed below. In a letter dated July 9, 1999, the NRC staff concluded that the submittal met the intent of Supplement 4 to Generic Letter 88-20, and that the licensee's IPEEE process is capable of identifying the most likely severe accidents and severe accident vulnerabilities (NRC 1999).

The IPEEE analysis of external flooding events followed the screening and evaluation approaches described in Supplement 4 of GL 88-20 (NRC 1991). The TMI-1 IPEEE showed that external floods are the most important contributors to external event CDF. The IPEEE external flooding analyses employed a simplified external flooding PRA and containment performance analysis. The evaluation used flood flow frequency data provided by the Corps of Engineers (COE), an assessment of the effectiveness of TMI-1 design measures to protect safety-related structures and components from the probable maximum flood (PMF), flood scenario evaluation, and manual risk quantification. The CDF for each flood scenario was obtained by multiplying the frequency of a flood reaching a given flood elevation by the conditional core damage probability associated with that flooding scenario. The potential impact on containment performance and isolation was evaluated following the core damage evaluation.

Appendix F

The external flooding CDF from the IPEEE was estimated to be 8.11×10^{-5} year (GPU 1994). The dominant external flooding initiating events and their contributions to the external flooding CDF are provided in Table E.2-21 of the ER (AmerGen 2008a), and summarized in Table F-1.b.

While no external flooding vulnerabilities were identified in the IPEEE, one plant improvement was identified. This improvement involved installing a flood-resistant means of providing 480V AC power and pumps to provide reactor coolant pump (RCP) seal cooling and makeup to the steam generators in station blackout conditions. Exelon Generation indicated that this external flooding improvement was subsequently implemented (AmerGen 2008a). Based on the information provided in the ER and in responses to RAIs (AmerGen 2008b), the NRC staff finds the treatment of external flooding events to be reasonable for the purposes of the SAMA analysis.

The TMI-1 IPEEE seismic analysis employed a seismic PRA with a simplified seismic containment performance analysis consistent with NUREG-1407. The seismic approach employed plant walkdowns by seismic review teams to identify components and structures that may impact risk, development of seismic fragility values for seismic components and structures, and CDF quantification using a modified version of the IPE risk model and integration of the plant logic model with the seismic hazard curve. The seismic CDF was quantified using two different sets of seismic hazard curves -- those developed by the Electric Power Research Institute (EPRI) (EPRI 1989) and those provided by Lawrence Livermore National Laboratory (LLNL) (NRC 1994). The applicant determined the seismic CDF to be 3.21×10^{-5} per year using the EPRI hazard curve and 8.43×10^{-5} per year using the LLNL hazard curve. Table F-4 summarizes the seismic CDF by initiating event category for both the EPRI and LLNL seismic hazard curves. The IPEEE did not identify any seismic vulnerabilities nor did it identify any seismic outliers beyond those already identified and resolved within the scope of the Unresolved Safety Issue (USI) A-46 program. However, in the process of performing the IPEEE analysis, several plant improvements were identified. These improvements involved modifications to: reinforce 1P, 1R, 1S, and 1T load center gusset welds, add main control room ceiling supports, add seismic restraint for penetration pressurization tank PP-T-1A, modify the supports for the diesel-driven fire pump fuel oil tanks and battery racks, modify the anchorage for the decay heat closed cooling water heat exchangers, and modify the anchorage for the emergency diesel generator (EDG) air receivers. The structural improvements to the main control room ceiling, the penetration pressurization tank, and the EDG air receiver anchorage were subsequently implemented. The structural improvements to the remaining three components are addressed by candidate SAMAs (SAMAs 27, 28, and 30). This is discussed further in Section F.3.2. The NRC review and closure of USI A-46 for TMI-1 is documented in a letter dated August 12, 1998 (NRC 1998c).

Table F-4. TMI-1 Seismic Events Core Damage Frequency			
Initiating Event	Earthquake Range	CDF (per year)	
		EPRI	LLNL
SEIS1	0.052g to 0.2g	5.78×10^{-6}	1.26×10^{-5}
SEIS2	0.2g to 0.3g	1.04×10^{-5}	2.61×10^{-5}
SEIS3	0.3g to 0.5g	1.22×10^{-5}	3.25×10^{-5}
SEIS4	0.5g to 1.01g	3.71×10^{-6}	1.31×10^{-5}
Total Seismic CDF		3.21×10^{-5}	8.43×10^{-5}

To provide additional insight as to the appropriate seismic CDF to use for the SAMA evaluation, the NRC staff developed an independent estimate of seismic CDF for TMI-1 using the approximation method described in a paper by Robert P. Kennedy, entitled "Overview of Methods for Seismic PRA and Margin Analysis Including Recent Innovations" and using updated 2008 seismic hazard curve data from the U.S. Geologic Survey (USGS). This approach uses a median capacity (C_{50}) of 0.29g, based on the TMI-1 IPEEE high confidence of low probability of failure (HCLPF) value for critical equipment. The NRC staff's independent calculation estimates the seismic CDF for TMI-1 to be less than 3.3×10^{-5} per year. This is less than half of the IPEEE-reported screening value based on the LLNL seismic hazard curve (8.43×10^{-5} per year) and is essentially the same as the IPEEE-reported value based on the EPRI seismic hazard curve (3.21×10^{-5} per year). Based on the NRC staff's independent estimate of the seismic CDF, and the fact that structural improvements implemented since the IPEEE have not been accounted for in the estimate of seismic CDF, the NRC staff concludes that the seismic CDF is likely less than 3.2×10^{-5} per year.

The IPEEE fire analyses employed a progressive screening analysis, with quantification based on the IPE PRA model. EPRI's fire-induced vulnerability evaluation (FIVE) methodology was used with deviations. The evaluation was performed in nine steps: (1) identify critical areas of vulnerability, (2) identify components important to safety, (3) locate components important to safety, (4) review fire areas for growth and propagation, (5) evaluate component fragilities and failure modes, (6) review fire detection and suppression systems, (7) identify impacts on top events, (8) calculate screening CDF, and (9) perform detailed analysis of remaining fire areas using FIVE fire and damage modeling techniques. The total fire CDF from the IPEEE was estimated to be 2.4×10^{-5} year (GPU 1994). The dominant fire scenarios and their contributions to the fire CDF are listed in Table F-5. The IPEEE did not identify any fire vulnerabilities or improvements related to fire risk.

In the ER, Exelon Generation states that the use of the fire analysis results as a reflection of CDF may be inappropriate and that while the fire PRA is generally self-consistent within its calculational framework, the fire analysis does not compare well with the internal events PRA because of a number of conservative assumptions that have been included in the fire analysis process. The ER provides a list of fire analysis topics (involving technical inputs, data and modeling) that prevent the effective comparison of the CDF between the internal events PRA and the fire analysis. In response to an RAI requesting the applicability of the general topics to

Appendix F

the TMI-1 fire analysis (NRC 2008a), Exelon Generation provided several TMI-1-specific examples of conservatisms in the fire analysis, including: potential reduction in fire ignition frequencies, conservative fire protection system assumptions (e.g., automatic fire suppression systems are not credited), conservative target fire damage assumptions (e.g., a fire in a given area was assumed to destroy all equipment in the area), and conservative failure probabilities for human recovery actions (e.g., manual fire suppression or detection is not credited) (AmerGen 2008b). Based on the arguments regarding the conservatisms in the fire analysis presented in the ER and RAI responses, Exelon Generation assumed a total fire CDF of 2.16×10^{-5} per year in the SAMA analysis, which is the sum of the fire CDF for the five fire areas having a fire CDF greater than 1×10^{-6} per year. While this assumption appears to be non-conservative, Exelon Generation noted in Section E.6.26 of the ER that the fire CDF for fire area CB-FB-2e reported in the IPEEE (5.81×10^{-6} per year) contained an error that overestimated the fire CDF and that the correct value is 3.09×10^{-6} per year. As shown in Table F-5, using the corrected fire CDF for fire area CB-FB-2e results in a revised total fire CDF of 2.13×10^{-5} per year, and offsets Exelon Generation not including the CDF from fire areas having a fire CDF less than 1×10^{-6} per year.

Based on the information provided by the applicant, the NRC staff finds the treatment of fire events to be reasonable for the purposes of the SAMA analysis.

Table F-5. TMI-1 Fire Areas and Their Contribution to Fire CDF

Fire Area	Fire Area Description	CDF (per year)	
		IPEEE	Corrected IPEEE
CB-FA-2d	East Inverter Room	4.94×10^{-6}	4.94×10^{-6}
CB-FA-2e	West Inverter Room	5.81×10^{-6}	$3.09 \times 10^{-6(c)}$
CB-FA-3a	1D Switchgear Room	3.94×10^{-6}	3.94×10^{-6}
CB-FA-3b	1E Switchgear Room	4.96×10^{-6}	4.96×10^{-6}
CB-FA-4b	Control Room -- Console CR	1.96×10^{-6}	1.96×10^{-6}
CB-FA-4b	Control Room -- Panel CC	$8.40 \times 10^{-7(a)}$	$8.40 \times 10^{-7(a)}$
CB-FA-2	East Battery Room	$7.35 \times 10^{-7(a)}$	$7.35 \times 10^{-7(a)}$
	Other Scenarios	$8.15 \times 10^{-7(b)}$	$8.15 \times 10^{-7(b)}$
Total Fire CDF		2.4×10^{-5}	2.13×10^{-5}

- (a) Values provided in response to RAIs (AmerGen 2008b).
- (b) Value derived as the difference between the total fire CDF reported in the IPEEE and the fire CDFs reported for the seven fire areas.
- (c) Corrected value from Section E.6.26 of the ER (AmerGen 2008a).

The IPEEE analysis of high winds and other non-flooding external events followed the screening and evaluation approaches described in Supplement 4 of GL 88-20 (NRC 1991) and did not identify any significant sequences or vulnerabilities (GPU 1994). (Exelon Generation modeled external flooding events separately, as discussed above.) Based on this result, Exelon Generation concluded that these other external hazards, which were estimated to have a combined CDF of 1.33×10^{-6} per year, would not impact the conclusions of the SAMA analysis. Accordingly, they did not consider specific SAMAs for these events. This is discussed further in

Section F.3.2. Exelon Generation noted that the risks from deliberate aircraft impacts were explicitly excluded since this was being considered in other forums along with other sources of sabotage.

Using the CDF values reported in the ER, the non-flooding external events CDF would be approximately 4.5 times the internal events CDF (based on a seismic CDF of 8.43×10^{-5} per year, a fire CDF of 2.16×10^{-5} per year, a combined CDF from high winds and other non-flooding external events of 1.33×10^{-6} per year, and an internal events CDF of 2.37×10^{-5} per year). Accordingly, the total CDF from internal and non-flooding external events would be approximately 5.5 times the internal events CDF. However, in assessing the benefits for internal event-related SAMAs, Exelon Generation accounted for the potential risk reduction benefits associated with non-flooding external events (i.e., seismic and fire events) by doubling the estimated benefits for internal events. (This doubling was not applied to the seismic- and fire- related SAMAs, since those SAMAs are specific to external events.)

The NRC staff requested additional justification for increasing the internal events benefits by only a factor of two in view of the significant contribution to CDF from non-flooding external events (NRC 2008a). In the RAI response, Exelon Generation clarified that the seismic CDF reported in the ER (8.43×10^{-5} per year) is a screening value based on LLNL seismic hazard curves and was used only in evaluating the benefit of seismic-related SAMAs (discussed later). Exelon Generation indicated that, in order to not skew the external events CDF when comparing it to the internal events CDF, the seismic CDF based on the EPRI seismic hazard curves (3.21×10^{-5} per year) should be used in the multiplier development (AmerGen 2008b). In response to the same RAI, Exelon Generation provided several TMI-1-specific examples of conservatism in the seismic analysis, including: use of conservative methods to assess component seismic fragility, conservative seismic response assumptions (e.g., recovery of seismically-induced failure of the offsite power system is not credited), conservative seismic damage assumptions (e.g., failure of the main control room ceiling is always assumed to damage train B of Class 1E AC power), and conservative component failure probabilities (e.g., if a component fails in a seismic event then all similar components are assumed to fail) (AmerGen 2008b). Exelon Generation also noted that plant modifications to address seismic risk have been implemented since the IPEEE (as described above) and are not reflected in the IPEEE results. Exelon Generation further noted that the IPEEE fire CDF was based on conditional core damage probability values from the IPE internal events model, and that a re-quantification of the fire CDF based on the current internal events PRA would result in about a 43 percent reduction in fire CDF (from 2.16×10^{-5} per year to 1.22×10^{-5} per year). Using the adjusted seismic and fire CDF values, the total CDF for non-flooding external events (4.56×10^{-5} per year based on a seismic CDF of 3.21×10^{-5} per year, a fire CDF of 1.22×10^{-5} per year, and high winds/other non-flooding external event CDF of 1.33×10^{-6} per year) is approximately twice the internal events CDF. The NRC staff concludes that Exelon Generation's use of a multiplier of two in evaluating internal event-related SAMAs is reasonable for the purposes of the SAMA evaluation. This is discussed further in Section F.6.2.

The NRC staff reviewed the general process used by Exelon Generation to translate the results of the Level 1 PRA into containment releases, as well as the results of the Level 2 analysis, as described in the ER and in response to NRC staff requests for additional information (AmerGen 2009a and 2008b).

Appendix F

The Level 2 PRA model that forms the basis for the SAMA evaluation is referred to as the CAFTA Level 2 model of 2007 (Exelon 2007b). The model represents an updated version of the original IPE Level 2 model previously reviewed by the NRC staff. The Level 2 model utilizes a single containment event tree (CET), containing both phenomenological and systemic events, that is directly linked with the CAFTA 2004 Revision 2 Level 1 model. CET nodes are evaluated using supporting fault trees and logic rules. The model is fully described in TMI-PRA-001 (Exelon 2007b).

Exelon Generation characterized the internal events releases for the spectrum of possible radionuclide release scenarios using a set of 39 release categories. The release categories and their frequencies are presented in Table E.2-16 of the ER. The categories were defined based on the timing, duration, and magnitude of the release and whether the containment remains intact or is bypassed. The frequency of each release category was obtained by summing the frequency of the individual CET end states assigned to each release category. The 39 release categories were further collapsed into nine major source term groups having similar containment response. The nine major source term groups and their release characteristics are presented in Tables E.2-17 and E.2-18 of the ER. The release characteristics for these nine source term groups were developed from Modular Accident Analysis Program (MAAP) analyses performed specifically to support the SAMA analysis (AmerGen 2008b).

The core damage sequences developed for the external flooding model include the three major groups shown in Table F-1b. Of these groups, the floods above 310 feet and those below 305 feet are each represented by a single core damage sequence. The floods between 305 and 310 feet are represented by six sequences that were quantified using an ET developed specifically for the IPEEE external flooding evaluation. The descriptions and frequencies of these flood sequences are summarized in Table E.2-21 of the ER. Exelon Generation characterized the external flooding events releases for the spectrum of possible radionuclide release scenarios using a set of eight release categories from the internal events analysis, which were subsequently collapsed into seven non-zero source term groups. The source term frequencies associated with each of the flooding sequences is provided in Table E.2-23 of the ER. In response to an RAI, Exelon Generation provided additional information on the logic used to derive the source term frequencies for each of the flooding sequences (AmerGen 2008b). In response to another RAI, Exelon Generation provided a corrected frequency of 1.68×10^{-8} per year for source term RC-1 (SGTR) in Table E.2-23 of the ER (AmerGen 2008b).

The NRC staff's review of the Level 2 IPE concluded that it addressed the most important severe accident phenomena normally associated with large, dry containments, and identified no significant problems or errors (NRC 1996). The Level 2 PRA model was included in the TMI-1 peer review mentioned previously. It should be noted, however, that the current Level 2 model is a revision to version that was peer reviewed. The changes to the Level 2 model are described in Section E.2.2.3 of the ER (AmerGen 2008). Based on the NRC staff's review of the Level 2 methodology for both internal events and external flooding events and the responses to the RAIs concerning the Level 2 model, the NRC staff concludes that the Level 2 PRA provides an acceptable basis for evaluating the benefits associated with various SAMAs.

As indicated in the ER, the reactor core radionuclide inventory used in the consequence analysis was based on a 2002 plant-specific ORIGEN 2.1 calculation and corresponds to a 24-month refueling cycle and the licensed thermal power of 2568 MWt. All releases were modeled

as occurring at 51.6 meters (top of the reactor building). The thermal content of each of the releases is assumed to be $1.0E+07$ watts based on values provided in Sample Problem A in the MACCS2 user's manual (NRC 1998a) and NUREG/CR-4551 (NRC 1990a). Exelon Generation assessed the impact of alternatively assuming either a ground level release or an ambient (non-buoyant) plume. The results of these sensitivity cases showed that reducing the release height to ground level results in about a 5 percent decrease in population dose-risk, and reducing the thermal plume heat content to ambient conditions results in less than a 2 percent increase in population dose-risk.

The NRC staff reviewed the process used by Exelon Generation to extend the containment performance (Level 2) portion of the PRA to an assessment of offsite consequences (essentially a Level 3 PRA). This included consideration of the source terms used to characterize fission product releases for the applicable containment release categories and the major input assumptions used in the offsite consequence analyses. The MACCS2 code was utilized to estimate offsite consequences. Plant-specific input to the code includes the source terms for each release category and the reactor core radionuclide inventory (both discussed above), site-specific meteorological data, projected population distribution within a 50-mi (80-km) radius for the year 2034, emergency evacuation modeling, and economic data. This information is provided in Attachment E of the ER.

Exelon Generation used site-specific meteorological data for the 1998 calendar year as input to the MACCS2 code. The data were collected from the onsite meteorological tower. Data from 1998 through 2000 were also considered, but the 1998 data were chosen because they were the most complete and because results of a MACCS2 sensitivity analysis indicated that the 1998 data produced slightly more conservative results than the data sets for the other years. All of the missing data gaps were less than 2 hours and interpolation was used to fill the gaps. The NRC staff notes that previous SAMA analyses results have shown little sensitivity to year-to-year differences in meteorological data and concludes that the use of the 1998 meteorological data in the SAMA analysis is reasonable.

The population distribution the licensee used as input to the MACCS2 analysis was estimated for the year 2034, based on the U.S. Census Bureau population data for 2000, as provided by the SECPOP2000 program (NRC 2003), and the expected annual population growth rate. The baseline population was determined for each of sixteen directions and each of ten concentric rings (total of 160 sectors) out to a radius of 50 mi (80 km) surrounding the site. The transient population within 10 mi (16 km) of the site was included. U.S. Census block-group level population data is allocated to each sector based on the area fraction of the census block-groups in that sector. The 1990 and 2000 census data were used to determine a ten-year population growth factor for each of the 50-mi (80-km) radius rings. The population growth factor for each ring was applied uniformly to all sectors in the ring to calculate the year 2034 population distribution. Population sensitivity cases were performed in which the baseline 2034 population was increased by 30 percent, and then decreased to the year 2000 population data rather than the projected year 2034 population. The resulting population dose and offsite economic cost risk increased and decreased by approximately 30 percent, respectively. In response to an RAI regarding the sensitivity case using the year 2000 population, Exelon Generation clarified that the population change from year 2034 (to year 2000) was approximately 29 percent and that the change in offsite economic cost risk was consistent with

Appendix F

the change in population (AmerGen 2008b). The NRC staff considers the methods and assumptions for estimating population reasonable and acceptable for purposes of the SAMA evaluation.

The emergency evacuation model was modeled as a single evacuation zone extending out 10 mi (16 km) from the plant. Based on information in the ER, it was assumed that 95 percent of the population would evacuate. This assumption is conservative relative to the NUREG-1150 study (NRC 1990b), which assumed evacuation of 99.5 percent of the population within the emergency planning zone (EPZ). The evacuation time used in the SAMA analysis was based on a projection for the year 2034. The evacuees were assumed to begin evacuating 90 minutes after a General Emergency has been declared and to evacuate at an average radial speed of 1.18 miles per hour (mph) (0.53 meters per second [m/s]). This speed is the time weighted value accounting for season, day of the week, time of day, weather conditions, and special events. A sensitivity analysis was performed in which the evacuation speed was decreased by a factor of two (to 0.26 m/s). The result was a 15 percent increase in the total population dose. The NRC staff concludes that the evacuation assumptions and analysis are reasonable and acceptable for the purposes of the SAMA evaluation.

Much of the site-specific economic data was provided from SECPOP2000 (NRC 2003) by specifying the data for each of the counties surrounding the plant to a distance of 50 miles. SECPOP2000 utilizes economic data from the 1997 Census of Agriculture (USDA 1998). Generic economic data that applies to the region as a whole was taken from the MACCS2 sample problem input and revised when better information was available. Revised values included daily living expenses for people who have been evacuated and relocated, and the value of farm and non-farm wealth. The economic data were inflation-adjusted to the year 2006 using the consumer price index.

Exelon Generation addressed the impact on the SAMA analysis of three recently reported problems with SECPOP2000. These problems involved: (1) an inconsistency in the format in which several economic parameters were output from the SECPOP2000 code and input to the MACCS2 code, (2) an error that resulted in use of agricultural/economic data for the wrong counties in the SECPOP2000 calculations, and (3) an error that resulted in the economic data for some counties being handled incorrectly. Correction of the first of these errors is reflected in the baseline risk estimates provided in the ER. Correction of the second two errors was evaluated in a sensitivity analysis contained in the ER. Correction of the second two errors resulted in a decrease in population dose of approximately one percent and an increase in offsite economic cost risk of approximately 15 percent. The revised population dose results are reported in Section E.7.6.4 of the ER, and have been used as the basis for the NRC staff evaluation.

The NRC staff concludes that the methodology used by Exelon Generation to estimate the offsite consequences for TMI-1 provides an acceptable basis from which to proceed with an assessment of risk reduction potential for candidate SAMAs. Accordingly, the NRC staff based its assessment of offsite risk on the CDF and revised offsite doses reported by Exelon Generation.

F.3 Potential Plant Improvements

The process for identifying potential plant improvements, an evaluation of that process, and the improvements evaluated in detail by Exelon Generation are discussed in this section.

F.3.1 Process for Identifying Potential Plant Improvements

Exelon Generation's process for identifying potential plant improvements (SAMAs) consisted of the following elements:

- Review of the most significant basic events from the current, plant-specific PRA,
- Review of potential plant improvements identified in the TMI-1 IPE and IPEEE,
- Review of Phase II SAMAs from license renewal applications for six other U.S. nuclear sites,
- Review of dominant contributors to external flooding, seismic and fire events in the current external event risk models, and
- Review of other industry documentation discussing potential plant improvements.

Based on this process, an initial set of 33 candidate SAMAs, referred to as Phase I SAMAs, was identified. In Phase I of the evaluation, Exelon Generation performed a qualitative screening of the initial list of SAMAs using the following criteria:

- The SAMA is not applicable at TMI-1 due to design differences, or
- The SAMA has estimated costs that would exceed the dollar value associated with completely eliminating all severe accident risk at TMI-1.

Based on this screening, no SAMAs were eliminated leaving all 33 for further evaluation. These SAMAs, referred to as Phase II SAMAs, are listed in Table F.5-3 of the ER (AmerGen 2008a). In Phase II, a detailed evaluation was performed for each of the 33 SAMA candidates, as discussed in Sections F.4 and F.6 below.

Exelon Generation accounted for the potential risk reduction benefits associated with internal event- and external flooding-related SAMAs by separately quantifying the benefits using the internal event or external flooding model, respectively. For internal event-related SAMAs, Exelon Generation accounted for the potential risk reduction benefits associated with non-flooding external events (i.e., seismic and fire events) by doubling the estimated benefits for internal events. For seismic- and fire-related SAMAs, Exelon Generation separately estimated the risk reduction benefits using the seismic and fire risk models.

F.3.2 Review of Exelon Generation's Process

Exelon Generation's efforts to identify potential SAMAs focused primarily on areas associated with internal initiating events, but also included explicit consideration of potential SAMAs for external flooding, seismic, and fire events. The initial list of SAMAs generally addressed the accident sequences considered to be important to CDF from functional, initiating event, and risk reduction worth (RRW) perspectives at TMI-1, and included selected SAMAs from prior SAMA analyses for other plants.

Appendix F

Exelon Generation provided a tabular listing of the PRA basic events sorted according to their RRW (AmerGen 2008a). SAMAs impacting these basic events would have the greatest potential for reducing risk. Exelon Generation used a RRW cutoff of 1.01, which corresponds to about a one percent change in CDF given 100-percent reliability of the SAMA. This equates to a benefit of approximately \$52,000 (after the benefits have been multiplied to account for non-flood external events). External flooding contributions were not included in the benefit calculations establishing the RRW review threshold because the benefit of external flooding SAMAs are evaluated separately from the internal events model. Exelon Generation also provided and reviewed the large early release frequency (LERF)-based RRW events down to a RRW of 1.01. Exelon Generation correlated the basic events with highest risk importance in the Level 1 and 2 PRA with the SAMAs evaluated in Phase I or Phase II, and showed that, with a few exceptions, all of the significant basic events are addressed by one or more SAMAs (AmerGen 2008a). Of the basic events of high risk importance that are not addressed by SAMAs, each is closely tied to other basic events that had been addressed by one or more SAMAs.

The staff noted that basic event GADF-PALL6-CP2FS was identified in the Level 2 importance list review as being addressed by the same SAMAs as identified in the Level 1 importance list review for this same basic event but that this basic event was not listed in the Level 1 importance list (NRC 2008a). In response to the RAI, Exelon Generation clarified that this event contributes almost exclusively to station blackout (SBO) scenarios and is effectively addressed by SAMAs 2 and 11 (AmerGen 2008b).

Exelon Generation considered the potential plant improvements identified in the IPE and IPEEE in the identification of plant-specific candidate SAMAs for internal and external events, as summarized below.

The TMI-1 IPE identified five major procedural improvements. These enhancements are: (1) revise procedures to direct operators to throttle low pressure injection (LPI) prior to swapping the pump suction source from the borated water storage tank (BWST) to the containment sump, (2) revise accident management guidelines for SGTR events to direct the operators to isolate the failed steam generator and cooldown the primary system using the intact steam generator, (3) revise accident management guidelines for SGTR events in which isolation of the ruptured steam generator is not possible to direct the operators to refill the BWST to keep pace with reactor coolant system (RCS) inventory loss, (4) revise accident management guidelines to direct the operators to verify closure of the MU-14 valves after the transition to recirculation mode from high pressure injection (HPI) mode, and (5) include six specific operator actions in the licensed operator requalification training program. Exelon Generation noted that the first four improvements have been implemented and the fifth improvement has been partially implemented; therefore these improvements were not considered further in the SAMA analysis. The six operator actions associated with the fifth improvement included: (1) switchover to reactor sump recirculation following a LOCA, (2) properly throttling HPI flow after ES actuation, (3) tripping RCPs before seal damage after loss of nuclear services closed cooling water (NSCCW), (4) taking actions to prevent boron concentration when in recirculation following a LOCA, (5) refilling the BWST given SGTR, and (6) holding open or reopening RCP seal injection valve MU-V-20 on loss of instrument air. The first four operator actions have been implemented, and therefore were not considered further in the SAMA analysis. While Exelon

Generation has identified no specific training for the last two operator actions, failure to perform these actions is included in the TMI-1 PRA model. The importance list review conducted by Exelon Generation for the SAMA analysis identified failure of operator action (5) as an important contributor to CDF. SAMA 10 was identified to address this event. The RRW for failure of operator action (6) is less than the cutoff threshold of 1.01 for identifying potentially cost-beneficial SAMAs. Nevertheless, this and similar loss of instrument air events is addressed by SAMA 13.

The TMI-1 external flooding IPEEE identified one opportunity for improvement related to external flooding events. This enhancement was to install a flood-resistant means of providing 480V AC power and pumps to provide RCP seal cooling and makeup to the steam generators. Exelon Generation stated that this enhancement has been implemented and was credited in the IPEEE external floods CDF. Nevertheless, Exelon Generation further considered potential SAMAs for external floods and identified two opportunities for additional reduction of the external flooding risk, specifically, SAMA 32, pre-stage severe external flooding equipment, and SAMA 33, increase the flood protection height. The NRC staff questioned whether there was adequate time to install the TMI-1 flood gates in fast-developing floods, such as the flood surge produced by a hurricane, and requested justification for not identifying and evaluating potential SAMAs to reduce this response time (e.g., pre-staging of cranes needed to install the gates) (NRC 2008a). In response to the RAI, Exelon Generation clarified that TMI-1 staff have about 7.5 hours to install the six flood panels at the Intake Screen Pumphouse, which are the last flood gates to be installed if needed, but that TMI-1 staff only require at most about 3 hours to install these panels (AmerGen 2008b). Exelon Generation further clarified that TMI-1 staff have about 36 hours to install the many other flood gates, which is significantly more time than is needed to complete their installation (AmerGen 2008c). Based on these arguments, Exelon Generation determined that there were no additional potentially cost-beneficial SAMAs to mitigate external flooding events.

The TMI-1 seismic IPEEE identified six opportunities for improvements related to seismic events. The enhancements included: (1) add gusset weld reinforcements to load centers 1P, 1R, 1S, and 1T to improve seismic ruggedness, (2) install additional supports for the main control room (MCR) ceiling to prevent failure in seismic events, (3) install a restraint on penetration pressurization tank PP-T-1A to prevent seismic interaction with reactor building purge inlet isolation valve AH-V-1D, (4) modify the diesel fire pump battery and fuel oil tank supports to increase their seismic ruggedness, (5) modify the anchorage for the decay heat service heat exchangers (DC-C-2A/B) to improve their seismic ruggedness, and (6) modify the anchorage for the EDG air receivers to improve their seismic ruggedness. Exelon Generation stated that enhancements (2), (3), and (6) were subsequently implemented, and therefore were not considered further in the SAMA analysis. As noted in Section E.5.1.6.2.2 of the ER (AmerGen 2008a), SAMA 27, improve the 480V AC load center welds, SAMA 30, improve diesel fire pump fuel oil tank and battery rack supports, and SAMA 28, improve the decay heat service cooler (DC-C-2A/B) anchorages, were identified and retained for the Phase II evaluation to specifically address un-implemented enhancements (1), (4), and (5), respectively. Exelon Generation further reviewed the top contributors to seismic risk to identify additional areas for potential plant improvement and identified three opportunities for additional reduction of the seismic risk, specifically, SAMA 2, install damage resistant high temperature RCP seals with a portable 480V AC generator for extended emergency feedwater (EFW) operation (originally

Appendix F

identified based on internal events risk), SAMA 29, replace EDG ground resistors, and SAMA 31, modify specific containment penetration motor operated valves (MOVs) to fail closed.

The TMI-1 fire IPEEE did not identify any opportunities for improvements related to fire events (AmerGen 2008a). Nevertheless, Exelon Generation further reviewed the top contributors to fire risk to identify areas for potential plant improvement and identified two opportunities for additional reduction of the fire risk, specifically, SAMA 2 (described above) and SAMA 26, reroute cables so that they do not pass over ignition sources in fire zone CB-FA-2e or wrap these cables in fire proof material. In response to an RAI on the potential for SAMAs that could reduce the fire risk in other fire areas screened on low CDF, Exelon Generation evaluated the fire risk for two additional fire scenarios, CB-FA-2f (East Battery Room) and the CC panel from fire area CB-FA-4b, and identified no additional potentially cost-beneficial SAMAs to mitigate these fire scenarios (AmerGen 2008b).

The TMI-1 IPEEE did not identify opportunities for improvements related to high winds, accidental aircraft impact, and hazardous chemical release events (AmerGen 2008a). In Section E.5.1.6.5 of the ER, Exelon Generation states that the maximum benefit of completely eliminating the risk of these events is less than the \$50,000 minimum cost for implementing a SAMA. The NRC staff questioned the methodology used by Exelon Generation to calculate the maximum benefit of these events and asked Exelon Generation to provide a revised assessment of potential SAMAs based on the methodology presented by the NRC staff (NRC 2008a). In response to the RAI (AmerGen 2008b), Exelon Generation stated that the only types of SAMA candidates that would be potentially cost-beneficial utilizing the higher benefit values calculated utilizing the NRC methodology would be procedure changes, of which none could be identified to mitigate these types of events (AmerGen 2008b). Exelon Generation therefore identified no additional potentially cost-beneficial SAMAs to mitigate high winds, accidental aircraft impact, and hazardous chemical release events.

As discussed above, AmerGen's SAMA evaluation included SAMAs addressing unimplemented enhancements identified in the IPE and IPEEE, and SAMAs addressing additional enhancements based on a review of the dominant contributors to internal, external flooding, seismic, and fire events. Based on this information, the NRC staff concludes that the set of SAMAs evaluated in the ER addresses the major contributors to internal and external event CDF, that the opportunity for SAMAs related to both internal and external events has been adequately explored, and that it is unlikely that there are additional potentially cost-beneficial SAMA candidates.

The NRC staff noted that none of the initial 33 SAMA candidates were screened from further consideration in the Phase I evaluation, and questioned whether Exelon Generation had conducted a pre-screening process to develop this initial list (NRC 2008a). In response to the RAI, Exelon Generation stated that no formal pre-screening process had been used in the development of the Phase I SAMA list and that the list of 33 SAMA candidates represents the complete results of the SAMA identification process described in the ER (AmerGen 2008b).

For a number of the SAMAs evaluated in the ER, the information provided did not sufficiently describe the proposed modification. Therefore, the NRC staff asked the applicant to provide more detailed descriptions of the modifications for several of the Phase II SAMA candidates (NRC 2008a). In response to the RAI, Exelon Generation provided the requested information (AmerGen 2008b).

The NRC staff notes that the set of SAMAs submitted is not all inclusive, since additional, possibly even less expensive, design alternatives can always be postulated. However, the NRC staff concludes that the benefits of any additional modifications are unlikely to exceed the benefits of the modifications evaluated and that the alternative improvements would not likely cost less than the least expensive alternatives evaluated, when the subsidiary costs associated with maintenance, procedures, and training are considered.

The NRC staff concludes that Exelon Generation used a systematic and comprehensive process for identifying potential plant improvements for TMI-1, and that the set of potential plant improvements identified by Exelon Generation is reasonably comprehensive and therefore acceptable. This search included reviewing insights from the plant-specific risk studies, and reviewing plant improvements considered in previous SAMA analyses. While explicit treatment of external events in the SAMA identification process was limited, it is recognized that the prior implementation of plant modifications for external flooding, seismic, and fire events and the absence of external event vulnerabilities reasonably justifies examining primarily the internal events risk results for this purpose.

F.4 Risk Reduction Potential of Plant Improvements

Exelon Generation evaluated the risk-reduction potential of the 33 SAMAs that were applicable to TMI-1. The SAMA evaluations were performed using realistic assumptions with some conservatism. On balance, such calculations overestimate the benefit and are conservative.

For most of the SAMAs, Exelon Generation used model re-quantification to determine the potential benefits. The CDF and population dose reductions for internal events were estimated using the TMI-1 Level 1 and 2 PRA model (Version 2004 Revision 2) and for external flooding events were estimated using the IPEEE external flooding PRA model with plant damage states correlated to release categories from the internal events analysis. The changes made to the models to quantify the impact of SAMAs are detailed in Section E.6 of Appendix E to the ER (AmerGen 2008a). Table F-6 lists the assumptions considered to estimate the risk reduction for each of the evaluated SAMAs, the estimated risk reduction in terms of percent reduction in CDF and population dose, and the estimated total benefit (present value) of the averted risk. The estimated benefits reported in Table F-6 reflect the combined benefit in both internal and external events and reflect corrections to previously identified SECPOP2000 errors, as described in Section E.7.6 of Appendix E to the ER (AmerGen 2008a). The determination of the benefits for the various SAMAs is further discussed in Section F.6.

The NRC staff questioned the assumptions used in evaluating the benefits or risk reduction estimates of certain SAMAs provided in the ER (NRC 2008a). For SAMA 1, enhance the SBO EDG with auto start and load capability, the NRC staff requested the bases for the assumption for SAMA 1 that making modifications to automate start of the SBO EDG only reduces the probability of failure to start the SBO EDG by a factor of 10. In response, Exelon Generation clarified that most of the benefit for this SAMA is from preventing all seal LOCA cases resulting from the inability to provide power for RCP seal cooling within 13 minutes. In order to show that the results of this SAMA evaluation are not sensitive to the human error probability used in the modeling process, Exelon Generation set the probability to zero and showed that the change in

Appendix F

CDF was negligible (AmerGen 2008b). The NRC staff considers the assumptions, as clarified, to be reasonable and acceptable for purposes of the SAMA evaluation.

The NRC staff asked for clarification as to why SAMA 10, automate BWST refill, was assumed to prevent, rather than just delay core damage (NRC 2008a). In response to the RAI, Exelon Generation clarified that SAMA 10 would include the installation of a new, higher flow pump to ensure the BWST can be refilled at a rate greater than inventory is being lost through the steam generator tube rupture (AmerGen 2008b). The NRC staff considers the assumption, as clarified, to be reasonable and acceptable for purposes of the SAMA evaluation.

In a separate RAI on SAMA 10, the NRC staff asked Exelon Generation to provide an assessment of the impact on the net value of this SAMA if the benefit of mitigating ISLOCA events were considered in addition to the already estimated benefit of mitigating SGTR events (NRC 2008a). In response to the RAI, Exelon Generation re-evaluated this SAMA by assuming the SAMA also eliminates all ISLOCA events. This bounding assumption resulted in a CDF reduction of approximately 4.2 percent, compared to 3.4 percent reported in the ER, and a population dose-risk reduction of approximately 17 percent, compared to 14 percent reported in the ER (AmerGen 2008b). The NRC staff considers the assumption, as revised, to be reasonable and acceptable for purposes of the SAMA evaluation.

The NRC staff questioned the modeling assumption that seismic SAMA 27, improve the 480V AC load center welds (HCLPF of 0.12g), and seismic SAMA 28, improve the decay heat service cooler anchorages (HCLPF of 0.09g), would result in seismic failure probabilities similar to that for the BWST (HCLPF of 0.3g), given the design and functional dissimilarities between the respective components (NRC 2008a). In response to the RAI (AmerGen 2008b), Exelon Generation noted that SAMA 27 was shown to be cost-beneficial by a wide margin and that only extreme fragility data changes could impact this result, which is not likely. For SAMA 28, Exelon Generation compared the component failure probability data for decay heat service coolers, which is considered a good surrogate for heat exchangers, with the BWST failure probability data used in the IPEEE. Based on this comparison, Exelon Generation determined that they generally have similar failure probabilities for the initiating events evaluated in the IPEEE, and that use of the BWST values result in slightly larger averted cost-risk. The NRC staff considers the assumptions, as clarified, to be reasonable and acceptable for purposes of the SAMA evaluation.

For SAMAs that were specifically developed to address internal event issues, Exelon Generation increased the benefit that was derived from the internal events model by a factor 2 to account for the additional benefits that these SAMAs might have in external events other than external floods (primarily seismic and fire events). The benefits in external floods were separately quantified using the external flood risk model, where applicable (as noted in Table F-6), and combined with these benefits.

For SAMAs that specifically address seismic events (i.e., SAMAs 27 through 31), the reduction in seismic CDF and population dose was not directly calculated (in Table F-6 these are noted as NOT ESTIMATED). For these SAMAs, a bounding estimate of the impact of the SAMA was made based on general assumptions regarding: the approximate contribution to total risk from external events relative to that from internal events; the fraction of the external event risk attributable to seismic events; and the fraction of the seismic risk affected by the SAMA (based on information from the IPEEE). For example, Exelon Generation assumed that the contribution

to risk from external events (excluding external flooding events) is approximately equal to that from internal events, and that seismic events contribute about 80 percent of this external events risk. The seismic analysis was then used to identify the fraction of the seismic risk that could be eliminated by the potential enhancements.

The NRC staff notes that Exelon Generation's assumption that the seismic CDF is equivalent to 80 percent of the internal events CDF effectively results in a seismic CDF of 1.9×10^{-5} per year. In response an RAI, Exelon Generation noted that the seismic CDF reported in the IPEEE (based on use of the EPRI hazard curves) is 3.21×10^{-5} per year. Exelon Generation also identified a number of conservative assumptions in the IPEEE seismic analysis, and identified several seismic-related plant modifications that have been implemented but not reflected in the IPEEE risk results (AmerGen 2008b). As discussed in Section F.2.2, based on an independent estimate of the seismic CDF, and the fact that structural improvements implemented since the IPEEE have not been accounted for in the estimate of seismic CDF, the NRC staff expects that the seismic CDF would be less than 3.2×10^{-5} per year. The NRC staff assessed the impact that use of the higher seismic CDF (3.2×10^{-5} per year) would have on the cost effectiveness of the evaluated seismic SAMAs and found that the conclusions regarding these SAMAs would not be impacted.

For the SAMA that specifically addresses fire events (i.e., SAMA 26), the reduction in fire CDF and population dose also was not directly calculated. For this SAMA, a bounding estimate of the impact of the SAMA was made using a methodology similar to that described for seismic SAMAs. For example, it is assumed that the contribution to risk from external events (excluding external flooding events) is approximately equal to that from internal events, and that internal fires contribute 85 percent of this external events risk. The fire analysis was then used to identify the fraction of the fire risk that could be eliminated by potential enhancements in the applicable fire area. Exelon Generation's assumption that the fire CDF is equivalent to 85 percent of the internal events CDF effectively results in a fire CDF of 2.0×10^{-5} per year. As discussed in Section F.2.2, using the corrected fire CDF for fire area CB-FB-2e results in a revised total fire CDF of 2.13×10^{-5} per year. Thus, the fire CDF used in assessing the benefits for the fire-related SAMA is consistent with the revised total fire CDF.

While noting that Exelon Generation's assumptions that seismic CDF is 80 percent and fire CDF is 85 percent of the total non-flooding external events CDF appear internally inconsistent, the NRC staff concludes that the resulting seismic and fire CDFs are in general agreement with the seismic and fire CDFs and accompanying qualitative justification presented in Section F.2.2, and that Exelon Generation's risk reduction estimates for the seismic-and fire-related SAMAs are acceptable for purposes of the SAMA evaluation.

The NRC staff has reviewed Exelon Generation's bases for calculating the risk reduction for the various plant improvements and concludes that the rationale and assumptions for estimating risk reduction are reasonable and generally conservative (i.e., the estimated risk reduction is higher than what would actually be realized). Accordingly, the NRC staff based its estimates of averted risk for the various SAMAs on Exelon Generation's risk reduction estimates.

Appendix F

SAMA	Assumptions ^(d)	% Risk Reduction ^(b)		Total Benefit ^(c) (\$)		Cost (\$)
		CDF	Population Dose	Baseline	Baseline With Uncertainty	
4 – Provide alternate power to HPI pump minimum flow recirculation valves MU-V-36 and MU-V-37	The RRW for the basic event is below the cost-beneficial cutoff.	NOT ESTIMATED				
5 – Enhance valves MU-V-76A/B and MU-V-77A/B to allow for rapid alignment changes in accident conditions	IE: Reduce the probability of failure to align the "C" HPI pump to provide seal injection by a factor of 100.	6	3	240K	660K	3.2M
	EF: Reduce the risk for floods below 305' msl by 6.3 percent.	0	0			
6 – Add cross-ties within the trains of cooling systems – DHR, DHCCW, DHRW	IE: Modify fault tree to include cross-ties between Trains A and B of the DHRW system, between Trains A and B of the DHCCW system, between Trains A and B of the LPI system, and between Trains A and B of the DHR system.	13	5	410K	1.1M	2.8M
	EF: Eliminate power-recovered SBO events for floods between 305' and 310' msl when flood gates are correctly installed; eliminate all risk from floods below 305' msl.	~0	~0			
7 – Use fire service water as an alternate cooling source for the intermediate closed cooling water (ICCW) heat exchangers	IE: Modify fault tree to include cross-tie of the fire service water system to the ICCW heat exchangers.	13	6	470K	1.3M	1.0M
	EF: Eliminate all risk from floods below 305' msl.	~0	~0			
8 – Automate reactor coolant pump trip on high motor bearing cooling temperature	IE: Reduce the probability of failure to trip the RCPs upon loss of NSCCW by a factor of 10, and set corresponding JHEPs to 0.	13	23	1.3M	3.6M	150K
	EF: Does not mitigate external flooding	0	0			

Appendix F

SAMA	Assumptions ^(d)	% Risk Reduction ^(b)		Total Benefit ^(c) (\$)		Cost (\$)
		CDF	Population Dose	Baseline	Baseline With Uncertainty	
	scenarios.					
9 – Proceduralize local atmospheric dump valve (ADV) operation	The current model is conservative in that it does not credit existing procedures to perform local ADV operations. Crediting the existing procedures by assigning a human error probability of 0.1 for failure to locally operate ADVs on loss of air reduces RRW below the cost-beneficial cutoff.			NOT ESTIMATED		
10 – Automate BWST refill						
Baseline Case ^(e)	IE: Reduce the probability of failure to refill the BWST from 2.65E-02 to 1.0E-04, and set corresponding JHEPs to 0. Eliminate all ISLOCA events. EF: Does not mitigate external flooding scenarios.	4 0	17 0	1.3M ^(f)	3.5M ^(f)	3.8M
Sensitivity Case	IE: Reduce the probability of failure to refill the BWST from 1.0 to 1.0E-04, and set corresponding JHEPs to 0. Eliminate all ISLOCA events. EF: Does not mitigate external flooding scenarios.	17 ^(f) 0	50 ^(f) 0	6.3M ^(f)	17M ^(f)	3.8M
11 – Enhance extreme external flooding mitigation equipment to address SBO and loss of seal cooling scenarios	IE: Reduce the probability of failure to operate the EDGs and TD EFW pumps to 0. EF: For all floods, reduce the probability of failure to implement the external flooding measures to 1.0E-04 and reduce	34 93	25 93	17M	47M	4.3M

Appendix F

SAMA	Assumptions ^(d)	% Risk Reduction ^(b)		Total Benefit ^(c) (\$)		Cost (\$)
		CDF	Population Dose	Baseline	Baseline With Uncertainty	
	the probability of failure to provide flood-resistant AC power to 2.0E-02.					
12 – Use the DHR system as an alternate suction source for HPI	IE: Modify fault tree to include alignment of existing DHR valves DH-V-7A/B having a probability of failure of 0.1.	4	3	210K	580K	50K
	EF: Does not mitigate external flooding scenarios.	0	0			
13 – Change IA system logic to automatically start IA-P-1A/B after a low voltage trip in conjunction with an engineered safeguards actuation signal (ESAS)						
Baseline Case	IE: Reduce the probability of failure to start the air compressors using emergency power to 1.0E-05, and set corresponding JHEPs to 0.	3	4	330K	920K	950K
	EF: Does not mitigate external flooding scenarios.	0	0			
Sensitivity Case ^(g)	IE: Reduce the probability of failure to start the air compressors using emergency power to 1.0E-05, and set corresponding JHEPs to 0. Set the probability of failure to refill the BWST from 2.65E-2 to 1 (in both baseline and sensitivity case).	8	19	2.4M ^(f)	6.6M ^(f)	950K
	EF: Does not mitigate external flooding scenarios.	0	0			

Appendix F

SAMA	Assumptions ^(d)	% Risk Reduction ^(b)		Total Benefit ^(c) (\$)		Cost (\$)
		CDF	Population Dose	Baseline	Baseline With Uncertainty	
14 – Replace HPI pump cooling alignment valves with MOVs	IE: Modify fault trees for all three makeup pumps to include alignment of alternative cooling sources NSCCW and DHCCW from the MCR.	17	8	630K	1.73M	3.15M
	EF: Eliminate all risk from floods below 305' msl.	~0	~0			
15 – Automatic swap to recirculation mode	IE: Reduce the probabilities of failure to swap over from injection to recirculation mode within one minute and within ten minutes to 1.0E-05, and set corresponding JHEP to 0.	5	3	210K	576K	450K
	EF: Eliminate all manual recirculation failures for floods between 305' and 310' msl when flood gates are correctly installed and for floods below 305' msl.	0	0			
16 – Automate HPI injection on low pressurizer level	IE: Reduce the probability of failure to initiate HPI to 1.0E-04, and set corresponding JHEPs to 0.	6	26	1.8M	4.8M	1.1M
	EF: Reduce the risk for floods below 305' msl by the same percent reduction as the internal events CDF.	0	0			
17 – Auto isolate steam generators on high steam line flow	IE: Reduce the probability of failure to isolate the steam generators by a factor of 10, and set corresponding JHEP to 0.	1	1	55K	150K	950K
	EF: Does not mitigate external flooding scenarios.	0	0			
18 – Provide the capability to align	IE: Reduce the probability of failure to align	2	~0			

Appendix F

SAMA	Assumptions ^(d)	% Risk Reduction ^(b)		Total Benefit ^(c) (\$)		Cost (\$)
		CDF	Population Dose	Baseline	Baseline With Uncertainty	
the standby battery charger and the 1A/1B DC cross-tie from the MCR	the standby battery charger by a factor of 10. EF: Eliminate all manual battery charger alignment failures for floods between 305' and 310' msl when flood gates are correctly installed. Reduce the risk for floods below 305' msl by the same percent reduction as the internal events CDF.	0	~0	32K	89K	100K
19 – Install battery backed hydrogen igniters or a passive hydrogen ignition system	IE: Modify fault tree for early containment failures to represent addition of a hydrogen ignition system with an unavailability of 0.01 in all sequences, including LOOP and SBO scenarios. EF: For all floods with successful containment isolation, reduce early containment failure by the same percentage as for internal events, and reassign to late containment failure.	0	11			
		0	18	3.4M	9.4M	760K
20 – Extend the high pressure boundary through DHR valve DH-V-3 for ISLOCA isolation	IE: Completely eliminate all ISLOCA events. EF: Does not mitigate external flooding scenarios.	1	3			
		0	0	190K	520K	3.0M
21 – Install concrete shields to block direct pathways from the reactor pressure vessel (RPV) to the containment wall, and/or initiate containment flooding early in external flooding scenarios	IE: Reassign early containment failures due to liner melt-thru to either basemat failure (75 percent of events) or intact containment (25 percent of events). EF: Reassign early containment failures due to liner melt-thru to either basemat failure or intact containment depending on availability of containment spray in	0	3			
		0	7	1.3M	3.6M	1.2M

Appendix F

SAMA	Assumptions ^(d)	% Risk Reduction ^(b)		Total Benefit ^(c) (\$)		Cost (\$)
		CDF	Population Dose	Baseline	Baseline With Uncertainty	
	specific flood sequence.					
22 – Install an independent EFW system	IE: Modify fault trees to include the independent EFW system. EF: Eliminate all risk from floods below 305' msl.	6 ~0	17 ~0	1.4M	3.8M	5.0M
23 – Develop alarm response procedures to direct operation of RR-V-5 on low reactor building emergency cooling (RBEC) flow	IE: Reduce the probability of failure to open MOV RR-V-5 by a factor of 10. EF: Reduce the population dose risk and annual offsite economic cost risk for LOOP scenarios for floods below 305' msl by the same percent reduction as for internal events.	0 0	1 0	32K	89K	50K
24 – Install damage resistant high temperature RCP seals, a diesel engine as an alternate drive for an EFW pump, and a portable 480V AC generator for extended EFW operations	IE: Same as SAMA 2. In addition, completely eliminate failure of the TD EFW pump to operate. EF: Eliminate all SBO events for floods between 305' and 310' msl when flood gates are correctly installed; eliminate all risk from floods below 305' msl.	53 5	55 6	4.7M	13M	8.4M
25 – Install an additional EDG	IE: Eliminate all failures of the SBO EDG. EF: Eliminate all risk for floods between 305' and 310' msl when flood gates are correctly installed and from all floods below 305' msl.	9 5	9 6	1.6M	4.3M	6.0M
26 – Reroute cables so that they do not pass over ignition sources in fire zone CB-FA-2E	FE: Eliminate all cable damage due to fire in fire zone CB-FA-2E.	13	13	400K	1.1M	900K

Appendix F

SAMA	Assumptions ^(d)	% Risk Reduction ^(b)		Total Benefit ^(c) (\$)		Cost (\$)
		CDF	Population Dose	Baseline	Baseline With Uncertainty	
(West Inverter Room) or wrap them in fire proof material	EF: Does not mitigate external flooding scenarios.	0	0			
27 – Improve the 480V AC load center welds	SE: Reduce failure probabilities for 480V AC load centers 1P, 1R, 1S, and 1T to those corresponding to a HCLPF of 0.30g. EF: Does not mitigate external flooding scenarios.	NOT ESTIMATED 0	NOT ESTIMATED 0	1.4M	3.9M	580K
28 – Improve the decay heat service cooler (DC-C-2A/B) anchorages	SE: Reduce failure probabilities for decay heat service coolers to those corresponding to a HCLPF of 0.30g. EF: Does not mitigate external flooding scenarios.	NOT ESTIMATED 0	NOT ESTIMATED 0	51K	140K	580K
29 – Replace EDG ground resistors	SE: Eliminate all failures of the EDG ground resistors. EF: Does not mitigate external flooding scenarios.	NOT ESTIMATED 0	NOT ESTIMATED 0	28K	76K	800K
30 – Improve diesel fire pump fuel oil tank and battery rack supports	SE: Eliminate all failures of the FSW system supports. EF: Does not mitigate external flooding scenarios.	NOT ESTIMATED 0	NOT ESTIMATED 0	28K	76K	150K
31 – Modify specific containment penetration MOVs to fail closed	The estimated cost is greater than the entire seismic MACR.	NOT ESTIMATED				4.1M
32 – Pre-stage severe external flooding equipment	IE: Does not mitigate internal events scenarios.	0	0	14M	39M	1.7M

Appendix F

SAMA	Assumptions ^(d)	% Risk Reduction ^(b)		Total Benefit ^(c) (\$)		Cost (\$)
		CDF	Population Dose	Baseline	Baseline With Uncertainty	
	EF: For floods > 310' msl, reduce the probability of failure to implement the external flooding measures to 1.0E-02 and reduce the probability of failure to provide flood-resistant AC power to 2.0E-02. For floods between 305' and 310' msl, reduce the probability of failure to implement the severe flooding measures to 0.14.	84	84			
33 – Increase the flood protection height	IE: Does not mitigate internal events scenarios. EF: For floods > 310' msl, use same failure probability for installing flood doors as used for the 305' to 310' msl floods.	0 61	0 59	 9.8M	 27M	 2.7M

(a) SAMAs in bold are potentially cost-beneficial.

(b) First risk reduction value reflects results of changes made to the internal events PRA model and second risk reduction value reflects results of changes made to the external flooding PRA model (AmerGen 2008a).

(c) Estimated benefits reflect revised values provided after correction of SECPOP2000 errors, as reported in Section E.7.6.5 of the ER (AmerGen 2008a). Reported benefit values account for risk reduction in internal events, external floods, and other external events, including fire and seismic events.

(d) IE: internal events; EF: external flooding events; FE: fire events; SE: seismic events.

(e) Analysis and results for risk reduction estimates provided in response to NRC staff RAI 6.i (AmerGen 2008b).

(f) Values estimated by NRC staff using data available in the ER (AmerGen 2008a) and provided in response to RAIs (AmerGen 2008b).

(g) Analysis and results for risk reduction estimates provided in response to NRC staff RAI 6.f (AmerGen 2008b).

F.5 Cost Impacts of Candidate Plant Improvements

Exelon Generation estimated the costs of implementing the 33 candidate SAMAs through the application of engineering judgment and use of other licensees' estimates for similar improvements. The cost estimates conservatively did not include the cost of replacement power during extended outages required to implement the modifications, nor did they generally include contingency costs associated with unforeseen implementation obstacles (AmerGen 2008a, AmerGen 2008b). The cost estimates provided in the ER did not account for inflation, which is considered another conservatism.

The NRC staff reviewed the bases for the applicant's cost estimates (presented in Section E.6 of Attachment E to the ER). For certain improvements, the NRC staff also compared the cost estimates to estimates developed elsewhere for similar improvements, including estimates developed as part of other licensees' analyses of SAMAs for operating reactors and advanced light-water reactors. In response to an RAI requesting a more detailed description of the changes associated with SAMAs 1, 2, 3, 5, 6, 10, 11, 14, 15, 20, 21, 26, 27, 29, 29, 31, 32, and 33, Exelon Generation provided additional information detailing the analysis and plant modifications included in the cost estimate of each improvement (AmerGen 2008b). The staff reviewed the costs and found them to be reasonable, and generally consistent with estimates provided in support of other plants' analyses.

The NRC staff requested additional clarification on the estimated cost of \$950,000 for implementation of SAMAs 13 and 17 and \$1,100,000 for implementation of SAMA 16, which seem high for what appear to be just logic changes (NRC 2008a). In response to the RAI, Exelon Generation further described these modifications as involving the design, procurement, and installation of hardware, simulator modifications, and changes to procedures and training (AmerGen 2008b). Based on this additional information, the NRC staff considers these estimated costs to be reasonable and acceptable for purposes of the SAMA evaluation.

The NRC staff concludes that the cost estimates provided by Exelon Generation are sufficient and appropriate for use in the SAMA evaluation.

F.6 Cost-Benefit Comparison

Exelon Generation's cost-benefit analysis and the NRC staff's review are described in the following sections.

F.6.1 Exelon Generation's Evaluation

The methodology used by Exelon Generation was based primarily on NRC's guidance for performing cost-benefit analysis, i.e., NUREG/BR-0184, *Regulatory Analysis Technical Evaluation Handbook* (NRC 1997a). The guidance involves determining the net value for each SAMA according to the following formula:

$$\text{Net Value} = (\text{APE} + \text{AOC} + \text{AOE} + \text{AOSC}) - \text{COE} \text{ where,}$$

Appendix F

APE = present value of averted public exposure (\$)

AOC = present value of averted offsite property damage costs (\$)

AOE = present value of averted occupational exposure costs (\$)

AOSC = present value of averted onsite costs (\$)

COE = cost of enhancement (\$).

If the net value of a SAMA is negative, the cost of implementing the SAMA is larger than the benefit associated with the SAMA and it is not considered cost-beneficial. Exelon Generation's derivation of each of the associated costs is summarized below.

NUREG/BR-0058 has recently been revised to reflect the agency's policy on discount rates. Revision 4 of NUREG/BR-0058 states that two sets of estimates should be developed, one at 3 percent and one at 7 percent (NRC 2004a). Exelon Generation performed the SAMA analysis using only a 3 percent discount rate (AmerGen 2008a) and based its decisions on potentially cost-beneficial SAMAs on these values.

Averted Public Exposure (APE) Costs

The APE costs were calculated using the following formula:

APE = Annual reduction in public exposure (Δ person-rem per year)
x monetary equivalent of unit dose (\$2000 per person-rem)
x present value conversion factor (15.04 based on a 20-year period with a 3-percent discount rate).

As stated in NUREG/BR-0184 (NRC 1997a), it is important to note that the monetary value of the public health risk after discounting does not represent the expected reduction in public health risk due to a single accident. Rather, it is the present value of a stream of potential losses extending over the remaining lifetime (in this case, the renewal period) of the facility. Thus, it reflects the expected annual loss due to a single accident, the possibility that such an accident could occur at any time over the renewal period, and the effect of discounting these potential future losses to present value. For the purposes of initial screening, which assumes elimination of all severe accidents due to internal and external flooding events, Exelon Generation calculated an APE of approximately \$972,000 for internal events and \$5,290,000 for external flooding events for the 20-year license renewal period (AmerGen 2008b).

Averted Offsite Property Damage Costs (AOC)

The AOCs were calculated using the following formula:

AOC = Annual CDF reduction
x offsite economic costs associated with a severe accident (on a per-event basis)
x present value conversion factor.

For the purposes of initial screening, which assumes all severe accidents due to internal and external flooding events are eliminated, Exelon Generation calculated an annual offsite

economic risk of about \$129,000 for internal events and \$620,000 for external flooding events based on the Level 3 risk analysis. This results in a discounted value of approximately \$1,940,000 for internal events and \$9,320,000 for external flooding events for the 20-year license renewal period (AmerGen 2008b).

Averted Occupational Exposure (AOE) Costs

The AOE costs were calculated using the following formula:

$$\begin{aligned} \text{AOE} &= \text{Annual CDF reduction} \\ &\times \text{occupational exposure per core damage event} \\ &\times \text{monetary equivalent of unit dose} \\ &\times \text{present value conversion factor.} \end{aligned}$$

Exelon Generation derived the values for averted occupational exposure from information provided in Section 5.7.3 of the regulatory analysis handbook (NRC 1997a). Best estimate values provided for immediate occupational dose (3300 person-rem) and long-term occupational dose (20,000 person-rem over a 10-year cleanup period) were used. The present value of these doses was calculated using the equations provided in the handbook in conjunction with a monetary equivalent of unit dose of \$2000 per person-rem, a real discount rate of 3 percent, and a time period of 20 years to represent the license renewal period. For the purposes of initial screening, which assumes all severe accidents due to internal and external flooding events are eliminated, Exelon Generation calculated an AOE of approximately \$15,000 for internal events and \$50,000 for external flooding events for the 20-year license renewal period (AmerGen 2008b).

Averted Onsite Costs

Averted onsite costs (AOSC) include averted cleanup and decontamination costs and averted power replacement costs. Repair and refurbishment costs are considered for recoverable accidents only and not for severe accidents. Exelon Generation derived the values for AOSC based on information provided in Section 5.7.6 of NUREG/BR-0184, the regulatory analysis handbook (NRC 1997a).

Exelon Generation divided this cost element into two parts – the onsite cleanup and decontamination cost, also commonly referred to as averted cleanup and decontamination costs, and the replacement power cost.

Averted cleanup and decontamination costs (ACC) were calculated using the following formula:

$$\begin{aligned} \text{ACC} &= \text{Annual CDF reduction} \\ &\times \text{present value of cleanup costs per core damage event} \\ &\times \text{present value conversion factor.} \end{aligned}$$

The total cost of cleanup and decontamination subsequent to a severe accident is estimated in the regulatory analysis handbook to be $\$1.5 \times 10^9$ (undiscounted). This value was converted to present costs over a 10-year cleanup period and integrated over the term of the proposed license extension. For the purposes of initial screening, which assumes all severe accidents due to internal and external flooding events are eliminated, Exelon Generation calculated an

Appendix F

ACC of approximately \$462,000 for internal events and \$1,580,000 for external flooding events for the 20-year license renewal period (AmerGen 2008b).

Long-term replacement power costs (RPC) were calculated using the following formula:

RPC = Annual CDF reduction
x present value of replacement power for a single event
x factor to account for remaining service years for which replacement power is required
x reactor power scaling factor

Exelon Generation based its calculations on the value of 875 megawatt electric (MWe). Therefore, Exelon Generation applied a power scaling factor of 875/910 (the ratio of the actual power level to the “generic” plant power level in NUREG/BR-0184) to determine the replacement power costs. For the purposes of initial screening, which assumes all severe accidents due to internal and external flooding events are eliminated, Exelon Generation calculated an RPC of approximately \$126,000 for internal events and \$431,000 for external flooding events for the 20-year license renewal period (AmerGen 2008b). For the purposes of initial screening, which assumes all severe accidents due to internal and external flooding events are eliminated, Exelon Generation calculated the AOSC to be approximately \$588,000 for internal events and \$2,010,000 for external flooding events for the 20-year license renewal period.

Using the above equations, Exelon Generation estimated the total present dollar value equivalent associated with completely eliminating severe accidents from internal and external flooding events at TMI-1 to be about \$3.5M and \$16.7M, respectively, for a total of \$20.2M. Use of a multiplier of 2 to the internal events benefits (to account for external events other than external flooding events) increases the value to \$23.7M and represents the dollar value associated with completely eliminating all internal and external event severe accident risk at TMI-1, also referred to as the Modified Maximum Averted Cost Risk (MMACR).

Exelon Generation's Results

If the implementation costs for a candidate SAMA exceeded the calculated benefit, the SAMA was considered not to be cost-beneficial. In the baseline analysis contained in the ER (using a 3 percent discount rate), Exelon Generation identified nine potentially cost-beneficial SAMAs. The potentially cost-beneficial SAMAs are:

- SAMA 8 – Automate reactor coolant pump trip on high motor bearing cooling temperature.
- SAMA 11 – Enhance extreme external flooding mitigation equipment to address SBO and loss of RCP seal cooling scenarios.
- SAMA 12 – Use the decay heat removal (DHR) system as an alternate suction source for HPI.
- SAMA 16 – Automate HPI injection on low pressurizer level.
- SAMA 19 – Install battery backed hydrogen igniters or a passive hydrogen ignition system.

- SAMA 21 – Install concrete shields to block direct pathways from the reactor pressure vessel (RPV) to the containment wall and/or direct containment flooding early in external flooding scenarios.
- SAMA 27 – Improve the 480V AC load center welds.
- SAMA 32 – Pre-stage severe external flooding equipment.
- SAMA 33 – Increase the flood protection height.

Exelon Generation performed additional analyses to evaluate the impact of parameter choices and uncertainties on the results of the SAMA assessment (AmerGen 2008a). If the benefits are increased by a factor of 2.75 to account for uncertainties, six additional SAMA candidates were determined to be potentially cost-beneficial:

- SAMA 2 – Install damage-resistant high temperature RCP seals with a portable 480V AC generator for extended EFW operation.
- SAMA 7 – Use fire service water as an alternate cooling source for the intermediate closed cooling water (ICCW) heat exchangers.
- SAMA 15 – Automate swap to recirculation mode.
- SAMA 23 – Develop alarm response procedures to direct operation of RR-V-5 on low reactor building emergency cooling (RBEC) flow.
- SAMA 24 – Install damage resistant high temperature RCP seals with a diesel engine as an alternate drive for an EFW pump and a portable 480V AC generator for extended EFW operation.
- SAMA 26 – Reroute cables so that they do not pass over ignition sources in fire zone CB-FA-2e or wrap them in fire proof material.

These results, and the population dose and SAMA benefit estimates reported in the present document (e.g., in Tables F-2 and F-5), reflect corrections to previously identified SECPOP2000 errors (AmerGen 2008a, AmerGen 2008b).

Exelon Generation also performed a sensitivity analysis of SAMA 10, automate BWST refill, assuming the current manual BWST refill capability only delayed core damage, not prevented core damage as assumed in the baseline analysis (AmerGen 2008a). Based on this sensitivity analysis, SAMA 10 was determined to be potentially cost-beneficial.

In response to an RAI, Exelon Generation provided a sensitivity analysis of SAMAs 13 and 22 also assuming manual BWST refill capability only delayed, not prevented, core damage (AmerGen 2008b). The sensitivity analysis resulted in identification of SAMA 13 being potentially cost-beneficial.

The potentially cost-beneficial SAMAs, and Exelon Generation's plans for further evaluation of these SAMAs are discussed in more detail in Section F.6.2.

F.6.2 Review of Exelon Generation's Cost-Benefit Evaluation

The cost-benefit analysis performed by Exelon Generation was based primarily on NUREG/BR-0184

Appendix F

(NRC 1997a) and was executed consistent with this guidance.

NUREG/BR-0058 has recently been revised to reflect the agency's policy on discount rates. Revision 4 of NUREG/BR-0058 states that two sets of estimates should be developed, one at 3 percent and one at 7 percent (NRC 2004a). Exelon Generation performed the SAMA analysis using only a 3 percent discount rate (AmerGen 2008a) and based its decisions on potentially cost-beneficial SAMAs on these values. SAMA benefits produced using a 3 percent discount rate are greater than those produced using a 7 percent discount rate, and would tend to result in identification of a greater number of potentially cost-beneficial SAMAs. Since use of a 3 percent discount rate is conservative, the NRC staff concludes that use of only a 3 percent discount rate in the cost-benefit analysis is acceptable for the purposes of the SAMA evaluation.

SAMAs identified primarily on the basis of the internal events analysis could provide benefits in certain external events, in addition to their benefits in internal events. To account for the additional benefits in external events, Exelon Generation: (1) multiplied the internal event benefits by a factor of two for each SAMA, except those SAMAs that specifically address fire and seismic risk (SAMAs 26 through 31), and (2) separately estimated the benefits of reducing the risk of external floods for each SAMA using the external flooding risk model and an approach similar to that for internal events. Doubling the internal event estimate for SAMAs 26 through 31, or including a benefit for reducing external flooding risk would not be appropriate because these SAMAs are specific to fire and seismic risks and would not have a corresponding benefit on the risk from internal or external flooding events.

The NRC staff notes that using Exelon Generation's adjusted seismic and fire CDF values, the total CDF for non-flooding external events (4.56×10^{-5} per year) is approximately twice the internal events CDF. This would suggest that the internal events benefits be tripled rather than doubled to account for additional SAMA benefits in external events. However, there are several considerations that support the use of a lower external events multiplier, as summarized below.

- The external event CDF may be lower due to remaining conservatisms in the analysis. The seismic, fire, and high winds analyses were performed in support of the IPEEE, well before the current TMI-1 internal events PRA, and vary in their degree of completeness and conservatism. The general trend in PRA development since the IPEEE has been to remove conservative modeling practices as better techniques for assessing risk are developed. Recognizing the level of conservatism in the earlier analyses and the fact that seismic improvements implemented since the IPEEE are not accounted for in the seismic CDF, the NRC staff agrees with Exelon Generation's claim that the CDF for non-flooding external events would likely be lower than reported above.
- The significance of the external events multiplier is diminished by separate quantification of SAMA benefits in external floods and by consideration of additional SAMAs targeted specifically to seismic and fire events. Exelon Generation separately assessed the benefits that internal events-related SAMAs would provide in external flooding events (which are the largest risk contributors at TMI-1), and separately quantified the benefits of seismic- and fire-related SAMAs. The external events multiplier reflects only the additional benefits that internal events-related SAMAs provide in seismic and fire events. Use of an external events multiplier implicitly assumes that each SAMA would offer the same percentage reduction in external event CDF and population dose as it offers in

internal events. However, internal events-related SAMAs would likely have smaller benefits in seismic and fire events than in internal events, and smaller benefits than external event-related SAMAs would have in external events. Thus, the use of a somewhat lower external events multiplier is reasonable.

- The benefits of additional SAMAs would be reduced by implementation of the currently identified cost-beneficial SAMAs. Exelon Generation evaluated the impact on the SAMA results if the estimated total benefits (internal and external events) were increased by a factor of 2.75, and included any additional potentially cost-beneficial SAMAs identified in this analysis within the set of SAMAs that they intend to examine further for implementation. Exelon Generation's SAMA analysis resulted in identification of 17 potentially cost-beneficial SAMAs in seven unique categories. Although use of a higher external events multiplier (in the baseline and uncertainty analyses) might result in identification of additional potentially cost-beneficial SAMAs, the currently identified SAMAs would have a greater net value, and implementation of the most cost-effective SAMAs from the set of 17 would likely reduce the benefits of any additional SAMAs to the degree that they are no longer cost beneficial.

In consideration of the above factors, the NRC staff concludes that Exelon Generation's use of a multiplier of two in evaluating internal event-related SAMAs is reasonable for the purposes of the SAMA evaluation.

The NRC staff notes that of the nine SAMAs determined to be cost-beneficial in the baseline analysis, two of these, SAMAs 19 and 21, improve containment performance but do not impact CDF, and that similar SAMAs have not been found to be cost-beneficial in previous SAMA evaluations for PWR plants. As with previously evaluated PWR plants, these SAMAs also would not be cost-beneficial if just considering the benefit associated with internal events risk reduction (and multiplier accounting for non-flooding external events); the significant additional benefit associated with reduction of external flooding risk makes these SAMAs cost-beneficial at TMI-1. The relatively high estimated benefits for these SAMAs are the result of early containment failure due to SBO events caused by external flooding. The NRC staff found the evaluation of these SAMAs to be reasonable.

Exelon Generation considered the impact that possible increases in benefits from analysis uncertainties would have on the results of the SAMA assessment. In the ER, Exelon Generation presents the results of an uncertainty analysis of the internal events CDF which indicates that the 95th percentile value is a factor of 2.75 times the point estimate CDF. Exelon Generation considered whether any additional Phase I SAMAs might be retained for further analysis if the benefits (and MMACR) were increased by a factor of 2.75. However, since no SAMAs were screened from further analysis during the Phase I screening, the use of the 95th percentile CDF has no impact on the Phase I analysis.

Exelon Generation also considered the impact on the Phase II screening if the estimated benefits were increased by a factor of 2.75 (in addition to the multiplier of 2 for external events other than external floods). Six additional SAMAs became cost-beneficial in Exelon Generation's analysis (SAMAs 2, 7, 15, 23, 24, and 26, as described above). Although not cost-

Appendix F

beneficial in the baseline analysis, Exelon Generation included these six SAMAs within the set of potentially cost-beneficial SAMAs that they intend to examine further for implementation.

Exelon Generation did not develop a cost-risk analysis for three Phase II SAMAs:

- SAMA 4 – Provide alternate power to HPI pump minimum flow recirculation valves MU-V-36 and MU-V-37,
- SAMA 9 – Proceduralize local ADV operation, and
- SAMA 31 – Modify specific containment penetration MOVs to fail closed.

In the ER, Exelon Generation noted that the only events that could cause the valves in SAMA 4 to be “stranded closed” are those in which power was available to close the valves when directed by an engineered safeguards actuation signal (ESAS) and then power was lost before the valves could be re-opened prior to failure of the HPI pumps, which corresponds to an available time of 45 minutes out of 24 hours. To address this issue, Exelon Generation modified the fault tree to include a new basic event representing the fraction of time available to re-open the valves. For SAMA 9, Exelon Generation noted that TMI-1 already has procedures to perform local ADV operations that are not credited in the PRA model. To address this issue, Exelon Generation assigned a human error probability of 0.1 for the basic event representing local ADV operation. For both SAMAs 4 and 9, Exelon Generation’s analysis showed that both the CDF and LERF based RRW for the basic events is below the review cutoff of 1.01 for identifying and assessing SAMAs. For SAMA 31, Exelon Generation noted the estimated cost to replace existing isolation valves with “fail closed” AOVs was greater than the maximum averted cost risk for seismic events. The benefits of these SAMAs were therefore not evaluated. The NRC staff found this rationale to be reasonable.

Exelon Generation also provided the results of additional sensitivity analyses in the ER, including variations in MACCS2 input assumptions, assumptions regarding BWST refill capability and extreme flooding mitigation capability, and the impact of implementing SAMA 32 (pre-stage severe external flooding equipment) on the other potentially cost-beneficial SAMAs. The analyses of the variation in MACCS2 input assumptions and extreme flooding mitigation capability assumptions did not identify any additional potentially cost-beneficial SAMAs beyond those already identified through the uncertainty analysis.

The baseline SAMA analysis contained in the ER assumes that manual BWST refill is capable of preventing core damage for SGTR events at TMI-1. Exelon Generation indicated in the ER that the validity of this assumption has recently been called into question, and therefore included in the ER an additional evaluation of SAMA 10 assuming the current capability only delayed, not prevented, core damage (AmerGen 2008a). Based on these results, SAMA 10 was determined to be potentially cost-beneficial, but was not included among the set of potentially cost-beneficial SAMAs identified in the ER. In response to an NRC staff request for clarification regarding Exelon Generation’s plans for enhancement of the BWST refill capability, the licensee indicated that the SAMA process, in conjunction with other plant analyses, has identified the limited BWST refill capability as a potential area for improvement at TMI-1, and that this issue has been captured in the TMI-1 Corrective Action Program. Exelon Generation further stated that while the SAMA analysis does not explicitly evaluate the costs and benefits associated with only

enhancing the existing manual capability, this potential option will be considered further in conjunction with the automation of the BWST refill function, i.e., SAMA 10 (AmerGen 2008b).

The NRC staff asked the licensee to identify and re-assess any other SAMAs that may be impacted by the BWST manual refill capability assumption (NRC 2008a). In their response to the RAI, Exelon Generation stated that only those SAMAs that significantly impacted SGTR frequency would be impacted by this assumption, specifically SAMAs 2, 11, 13, 16, 22, and 24. Of these, SAMAs 2, 11, 16, and 24 were already identified as being potentially cost-beneficial and were not evaluated further. Exelon Generation re-assessed the benefits of SAMAs 13 and 22 assuming the current BWST refill capability only delayed, not prevented, core damage. Based on this re-assessment SAMA 13, change IA system logic to automatically start IA-P-1A/B after a low voltage trip in conjunction with an ESAS, would be potentially cost-beneficial (AmerGen 2008b).

The NRC staff notes that given the impact of BWST refill capability on the estimated benefits for many of these potentially cost-beneficial SAMAs, it would be prudent for Exelon Generation to either resolve the BWST issue prior to performing the more detailed evaluation of these SAMAs, or to conservatively assume that the current manual BWST refill capability is not effective when evaluating the potentially cost-beneficial SAMAs for implementation.

In summary, the NRC staff notes that the 15 potentially cost-beneficial SAMAs (SAMAs 2, 7, 8, 11, 12, 15, 16, 19, 21, 23, 24, 26, 27, 32, and 33) identified in either Exelon Generation's baseline analysis, or uncertainty analysis, are included within the set of SAMAs that Exelon Generation will consider further for implementation (AmerGen 2008a). In response to an RAI by the NRC staff (NRC 2008a), Exelon Generation stated that SAMAs 10 and 13 would also be included within the set of SAMAs to be considered for implementation (NRC 2008b).

In the ER, Exelon Generation evaluated the impact of implementing SAMA 32, pre-stage severe external flooding equipment, on the benefit estimate for the other potentially cost-beneficial SAMAs. Since SAMA 32 addresses external flooding risk only, implementing this SAMA has no effect on the internal events model and associated benefit results for the other cost-beneficial SAMAs, nor does it have any affect on non-external flooding external events and those SAMAs identified to specifically address seismic and fire risk. This sensitivity analysis was performed for the baseline case assumptions with uncertainty (the most conservative case) and resulted in one previously identified potentially cost-beneficial SAMA, SAMA 21, no longer being cost-beneficial.

In light of the many potentially cost-beneficial SAMAs identified in the ER, the NRC staff asked Exelon Generation to identify those SAMAs having higher priority for being considered for implementation based on risk reduction potential and implementation cost, and which SAMAs would no longer be cost-beneficial if these higher priority SAMAs were implemented (NRC 2008a). In response to the RAI (AmerGen 2008b), Exelon Generation performed a qualitative assessment to prioritize the cost-beneficial SAMAs into a "minimal SAMA set" addressing the most significant risk contributors. Those SAMAs determined to have the most cost-effective risk reduction potential for each of the major risk areas defined the "minimal SAMA set." Other cost-beneficial SAMAs were assigned to the "minimal SAMA set" category best representing the risk contributors each is mitigating. Exelon Generation determined that SAMAs 32 and 2 would have the highest priority based on their potential for significant reduction in risk (and relatively low implementation cost in the case of SAMA 32). Exelon Generation further identified SAMAs

Appendix F

12, 15, 16, 26, and 27 as a second tier priority based on their mitigation of plant risk contributors not addressed by SAMAs 32 and 2. The remaining cost-beneficial SAMAs were grouped into one of these seven high priority groups. The impact of these remaining potentially cost-beneficial SAMAs is expected to be reduced significantly if the higher priority SAMAs are implemented. The NRC considers this approach for prioritizing SAMAs to be reasonable.

The NRC staff concludes that, with the exception of the potentially cost-beneficial SAMAs discussed above, the costs of the other SAMAs evaluated would be higher than the associated benefits.

F.7 Conclusions

Exelon Generation compiled a list of 33 SAMAs based on a review of the most significant basic events from the plant-specific PRA, insights from the plant-specific IPE and IPEEE, Phase II SAMAs from license renewal applications for other plants, and review of other NRC and industry documentation. An initial screening was performed to remove SAMA candidates that (1) were not applicable at TMI-1 due to design differences or (2) had estimated costs that would exceed the dollar value associated with completely eliminating all severe accident risk at TMI-1. Based on this screening, no SAMAs were eliminated leaving all 33 candidate SAMAs for evaluation.

For the remaining SAMA candidates, a more detailed evaluation was performed as shown in Table F-6. The cost-benefit analyses showed that nine of the SAMA candidates were potentially cost-beneficial in the baseline analysis (SAMAs 8, 11, 12, 16, 19, 21, 27, 32, and 33).

Exelon Generation performed additional analyses to evaluate the impact of parameter choices and uncertainties on the results of the SAMA assessment. As a result, six additional SAMAs (SAMAs 2, 7, 15, 23, 24, and 26) were identified as potentially cost-beneficial. Exelon Generation further identified SAMA 10 as being potentially cost-beneficial based on the results of a sensitivity analysis. In addition, as a result of the NRC staff review, Exelon Generation concluded that SAMA 13 was also potentially cost-beneficial. Exelon Generation has indicated that all of these SAMAs (SAMAs 2, 7, 8, 10, 11, 12, 13, 15, 16, 19, 21, 23, 24, 26, 27, 32, and 33) will be considered further for implementation.

The NRC staff reviewed the Exelon Generation analysis and concludes that the methods used and the implementation of those methods were sound. The treatment of SAMA benefits and costs support the general conclusion that the SAMA evaluations performed by Exelon Generation are reasonable and sufficient for the license renewal submittal. Although the treatment of SAMAs for external events was somewhat limited, the likelihood of there being cost-beneficial enhancements in this area was minimized by improvements that have been realized as a result of the IPEEE process, separate analysis of external flooding events, and inclusion of a multiplier to account for external events.

The NRC staff concurs with Exelon Generation's identification of areas in which risk can be further reduced in a cost-beneficial manner through the implementation of the identified, potentially cost-beneficial SAMAs. Given the potential for cost-beneficial risk reduction, the NRC staff agrees that further evaluation of these SAMAs by Exelon Generation is warranted. However, these SAMAs do not relate to adequately managing the effects of aging during the period of extended operation. Therefore, they need not be implemented as part of license

renewal pursuant to Title 10 of the *Code of Federal Regulations*, Part 54.

F.8 References

AmerGen (AmerGen Energy Company, LLC). 2008a. "Three Mile Island Nuclear Station, Applicant's Environmental Report, License Renewal Operating Stage." Kennett Square, Pennsylvania. ADAMS Accession Nos. ML080220255, ML080220257, ML080220261, and ML080220282.

AmerGen (AmerGen Energy Company, LLC). 2008b. Letter from Michael P. Gallagher, AmerGen Energy Company, LLC, to U.S. Nuclear Regulatory Commission Document Control Desk. Subject: "Response to NRC Request for Additional Information Related to Three Mile Island Nuclear Station 1 License Renewal Application (TAC No. MD7702)," dated July 17, 2008. ADAMS No. ML082040144.

ETI (Earth Tech, Inc.). 2003. "Evacuation Time Estimates for the Three Mile Island Station Emergency Planning Zone". July 2003.

EPRI (Electric Power Research Institute). 1989. "Probabilistic Seismic Hazard Evaluation at Nuclear Plant Sites in the Central and Eastern United States: Resolution of the Charleston Issue," EPRI NP-6395-DI, Palo Alto, CA, April 1989.

Exelon (Exelon Corporation). 2007a. *TMI PRA Notebook, TMI-PRA-014 Quantification Notebook, TMI PRA Model 2004 Revision 2*, May 2007.

Exelon (Exelon Corporation). 2007b. *TMI PRA Notebook, TMI-PRA-015.2 Level 2 Containment Event Tree Analysis Notebook, TMI PRA Model 2004 Revision 2*, May 2007.

GPU (GPU Nuclear Corporation). 1993. Letter from T. G. Broughton, GPU, to U.S. NRC. Subject: Three Mile Island Nuclear Generation Station, Unit 1 (TMI-1), Operating License No. DPR-50, Docket No. 50-289, Response to Generic Letter 88-20, "Individual Plan Examinations for Severe Accident Vulnerabilities (IPE)". May 20, 1993.

GPU (GPU Nuclear Corporation). 1994. Letter from R. W. Keaten, GPU, to U.S. NRC. Subject: Three Mile Island Nuclear Generation Station, Unit 1 (TMI-1), Operating License No. DPR-50, Docket No. 50-289, Response to Generic Letter 88-20, Supplement 4, "Individual Plan Examination of External Events (IPEEE) for Severe Accident Vulnerabilities". December 29, 1994.

Kennedy, Robert P. 1999. "Overview of Methods for Seismic PRA and Margin Analysis Including Recent Innovations". Proceedings of the OECD-NEA Workshop on Seismic Risk, Tokyo, Japan, August 1999.

NRC (U.S. Nuclear Regulatory Commission). 1988. Generic Letter 88-20, "Individual Plant Examination for Severe Accident Vulnerabilities," November 23, 1988.

NRC (U.S. Nuclear Regulatory Commission). 1990a. *Evaluation of Severe Accident Risks: Quantification of Major Input Parameters*. NUREG/CR-4551, Vol. 2, Rev. 1, Part 7, Washington, D.C.

Appendix F

NRC (U.S. Nuclear Regulatory Commission). 1990b. *Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants*. NUREG-1150, Washington, D.C.

NRC (U.S. Nuclear Regulatory Commission). 1991. "Procedural and Submittal Guidance for the Individual Plant Examination of External Events (IPEEE) for Severe Accident Vulnerabilities," NUREG-1407, Washington, D.C, June 1991.

NRC (U.S. Nuclear Regulatory Commission). 1994. "Revised Livermore Seismic Hazard Estimates for 69 Nuclear Power Plant Sites East of the Rocky Mountains," NUREG-1488, Washington, D.C., April 1994.

NRC (U.S. Nuclear Regulatory Commission). 1996. "Review of Three Mile Island, Unit 1, Individual Plant Examination Submittal, (TAC No. M74480)," Washington, D.C., December 19, 1996.

NRC (U.S. Nuclear Regulatory Commission). 1997a. *Regulatory Analysis Technical Evaluation Handbook*. NUREG/BR-0184, Washington, D.C.

NRC (U.S. Nuclear Regulatory Commission). 1997b. *Individual Plant Examination Program: Perspectives on Reactor Safety and Plant Performance*. NUREG-1560, Washington, D.C.

NRC (U.S. Nuclear Regulatory Commission). 1998a. *Code Manual for MACCS2: User's Guide*. NUREG/CR-6613, Vol. 1, Washington, D.C.

NRC (U.S. Nuclear Regulatory Commission). 1998b. *Common-Cause Failure Parameter Estimations*. NUREG/CR-5497, Washington, D.C.

NRC (U.S. Nuclear Regulatory Commission). 1998c. "Safety Evaluation Report for USI A-46 Program Implementation at Three Mile Island Unit 1 (TAC No. M69486)," Washington, D.C., August 12, 1998.

NRC (U.S. Nuclear Regulatory Commission). 1999. "Review of Three Mile Island Nuclear Station, Unit 1 (TMI-1) Individual Plant Examination of External Events (IPEEE) Submittal (TAC Nos. M83685)," Washington, D.C., July 9, 1999.

NRC (U.S. Nuclear Regulatory Commission). 2003. *SECPOP2000: Sector Population, Land Fraction, and Economic Estimation Program*. NUREG/CR-6525, Rev. 1, Washington, D.C.

NRC (U.S. Nuclear Regulatory Commission). 2004. *Regulatory Analysis Guidelines of the U.S. Nuclear Regulatory Commission*. NUREG/BR-0058, Rev. 4, Washington, D.C.

NRC (U.S. Nuclear Regulatory Commission). 2008a. Letter from Sarah Lopas, U.S. NRC, to Michael P. Gallagher, AmerGen Energy Company, LLC. Subject: "Request for Additional Information Regarding Severe Accident Mitigation Alternatives for Three Mile Island Nuclear Station Unit 1, License Renewal (TAC No. MD7702)," May 21, 2008. ADAMS No. ML081330714.

NRC (U.S. Nuclear Regulatory Commission). 2008b. Letter from Sarah Lopas, U.S. NRC, to AmerGen Energy Company, LLC. Subject: "Summary of Conference Call with AmerGen Energy Company, LLC, to Discuss Responses to Severe Accident Mitigation Alternatives Request for Additional Information for Three Mile Island Nuclear Station Unit 1 (TAC No. MD7702)," September 8, 2008. ADAMS No. ML082340226.

USDA (U.S. Department of Agriculture). 1998. "1997 Census of Agriculture," National Agriculture Statistics Service, 1998. Available URL:
<http://www.nass.usda.gov/census/census97/volume1/vol1pubs.htm>.



<p>NRC FORM 335 (9-2004) NRCMD 3.7</p> <p style="text-align: center;">U.S. NUCLEAR REGULATORY COMMISSION</p> <p style="text-align: center;">BIBLIOGRAPHIC DATA SHEET <i>(See instructions on the reverse)</i></p>	<p>1. REPORT NUMBER (Assigned by NRC, Add Vol., Supp., Rev., and Addendum Numbers, if any.)</p> <p style="text-align: center;">NUREG-1437, Supp. 37</p>				
<p>2. TITLE AND SUBTITLE</p> <p>Generic Environmental Impact Statement for License Renewal of Nuclear Plants Supplement 37 Regarding Three Mile Island Nuclear Station, Unit 1 Final Report</p>	<p>3. DATE REPORT PUBLISHED.</p> <table border="1" style="width: 100%;"> <tr> <td style="width: 50%;">MONTH</td> <td style="width: 50%;">YEAR</td> </tr> <tr> <td style="text-align: center;">June</td> <td style="text-align: center;">2009</td> </tr> </table> <p>4. FIN OR GRANT NUMBER</p>	MONTH	YEAR	June	2009
MONTH	YEAR				
June	2009				
<p>5. AUTHOR(S)</p> <p>See Chapter 10 of report.</p>	<p>6. TYPE OF REPORT</p> <p style="text-align: center;">Technical</p> <p>7. PERIOD COVERED <i>(Inclusive Dates)</i></p>				
<p>8. PERFORMING ORGANIZATION - NAME AND ADDRESS <i>(If NRC, provide Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)</i></p> <p>Division of License Renewal Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Washington, DC 20555-0001</p>					
<p>9. SPONSORING ORGANIZATION - NAME AND ADDRESS <i>(If NRC, type "Same as above"; if contractor, provide NRC Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address.)</i></p> <p>Same as 8 above.</p>					
<p>10. SUPPLEMENTARY NOTES</p> <p>Docket No. 50-289</p>					
<p>11. ABSTRACT <i>(200 words or less)</i></p> <p>This supplemental environmental impact statement (EIS) has been prepared in response to an application submitted by Exelon Generation Company, LLC (Exelon Generation) to the Nuclear Regulatory Commission (NRC) to renew the operating license for Three Mile Island Nuclear Station, Unit 1 (TMI-1), for an additional 20 years under 10 CFR Part 54. The supplemental EIS includes the NRC's analysis that considers and weighs the environmental impacts of the proposed action, the environmental impacts of alternatives to the proposed action, and mitigation measures for reducing or avoiding adverse impacts. It also includes the NRC's recommendation regarding the proposed action.</p> <p>The NRC has determined that the adverse environmental impacts of license renewal for TMI-1 are not so great that preserving the option of license renewal for energy-planning decisionmakers would be unreasonable. This determination is based on (1) the analysis and findings in the GEIS; (2) the Environmental Report submitted by Exelon Generation; (3) consultation with Federal, State, and local agencies; (4) the NRC's staff's own independent review; and (5) the NRC staff's consideration of public comments received during the scoping process and draft supplement EIS comment period.</p>					
<p>12. KEY WORDS/DESCRIPTORS <i>(List words or phrases that will assist researchers in locating the report.)</i></p> <p>Three Mile Island Nuclear Station, Unit 1 TMI-1 Three Mile Island Supplement to the Generic Environmental Impact Statement GEIS National Environmental Policy Act NEPA License Renewal NUREG-1437</p>	<p>13. AVAILABILITY STATEMENT</p> <p style="text-align: center;">unlimited</p> <p>14. SECURITY CLASSIFICATION</p> <p><i>(This Page)</i></p> <p style="text-align: center;">unclassified</p> <p><i>(This Report)</i></p> <p style="text-align: center;">unclassified</p> <p>15. NUMBER OF PAGES</p> <p>16. PRICE</p>				



Federal Recycling Program



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**
WASHINGTON, DC 20555-0001

OFFICIAL BUSINESS