

Generic Environmental Impact Statement for License Renewal of Nuclear Plants

Supplement 41

Regarding Cooper Nuclear Station, Unit 1

Draft Report for Comment

AVAILABILITY OF REFERENCE MATERIALS IN NRC PUBLICATIONS

NRC Reference Material

As of November 1999, you may electronically access NUREG-series publications and other NRC records at NRC's Public Electronic Reading Room at <http://www.nrc.gov/reading-rm.html>.

Publicly released records include, to name a few, NUREG-series publications; *Federal Register* notices; applicant, licensee, and vendor documents and correspondence; NRC correspondence and internal memoranda; bulletins and information notices; inspection and investigative reports; licensee event reports; and Commission papers and their attachments.

NRC publications in the NUREG series, NRC regulations, and *Title 10, Energy*, in the Code of *Federal Regulations* may also be purchased from one of these two sources.

1. The Superintendent of Documents
U.S. Government Printing Office
Mail Stop SSOP
Washington, DC 20402-0001
Internet: bookstore.gpo.gov
Telephone: 202-512-1800
Fax: 202-512-2250
2. The National Technical Information Service
Springfield, VA 22161-0002
www.ntis.gov
1-800-553-6847 or, locally, 703-605-6000

A single copy of each NRC draft report for comment is available free, to the extent of supply, upon written request as follows:

Address: U.S. Nuclear Regulatory Commission
Office of Administration
Mail, Distribution and Messenger Team
Washington, DC 20555-0001
E-mail: DISTRIBUTION@nrc.gov
Facsimile: 301-415-2289

Some publications in the NUREG series that are posted at NRC's Web site address <http://www.nrc.gov/reading-rm/doc-collections/nuregs> are updated periodically and may differ from the last printed version. Although references to material found on a Web site bear the date the material was accessed, the material available on the date cited may subsequently be removed from the site.

Non-NRC Reference Material

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, and transactions, *Federal Register* notices, Federal and State legislation, and congressional reports. Such documents as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings may be purchased from their sponsoring organization.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at—

The NRC Technical Library
Two White Flint North
11545 Rockville Pike
Rockville, MD 20852-2738

These standards are available in the library for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from—

American National Standards Institute
11 West 42nd Street
New York, NY 10036-8002
www.ansi.org
212-642-4900

Legally binding regulatory requirements are stated only in laws; NRC regulations; licenses, including technical specifications; or orders, not in NUREG-series publications. The views expressed in contractor-prepared publications in this series are not necessarily those of the NRC.

The NUREG series comprises (1) technical and administrative reports and books prepared by the staff (NUREG-XXXX) or agency contractors (NUREG/CR-XXXX), (2) proceedings of conferences (NUREG/CP-XXXX), (3) reports resulting from international agreements (NUREG/IA-XXXX), (4) brochures (NUREG/BR-XXXX), and (5) compilations of legal decisions and orders of the Commission and Atomic and Safety Licensing Boards and of Directors' decisions under Section 2.206 of NRC's regulations (NUREG-0750).

Generic Environmental Impact Statement for License Renewal of Nuclear Plants

Supplement 41

Regarding Cooper Nuclear Station, Unit 1

Draft Report for Comment

Manuscript Completed: January 2010
Date Published: February 2010
Office of Nuclear Reactor Regulation

1 Proposed Action Issuance of renewed operating license DPR-46 for Cooper
2 Nuclear Station, Unit 1, in the city of Brownville, Nemaha County,
3 Nebraska.
4
5 Type of Statement Draft Supplemental Environmental Impact Statement
6
7 Agency Contact Bennett Brady
8 U.S. Nuclear Regulatory Commission
9 Office of Nuclear Reactor Regulation
10 Mail Stop O-11F1
11 Washington, D.C. 20555-0001
12 Phone: 301-415-2981
13 Email: Bennett.Brady@nrc.gov
14
15 Comments Any interested party may submit comments on this supplemental
16 environmental impact statement. Please specify NUREG-1437,
17 Supplement 41, draft, in your comments. Comments must be
18 received by April 6, 2010. Comments received after the expiration
19 of the comment period will be considered if it is practical to do so,
20 but assurance of consideration of late comments will not be given.
21 Comments may be emailed to CooperEIS@nrc.gov or mailed to:
22
23 Chief, Rulemaking, Directives, and Editing Branch
24 U.S. Nuclear Regulatory Commission
25 Mail Stop T6-D59
26 Washington, D.C. 20555-0001
27
28 Please be aware that any comments that you submit to the NRC
29 will be considered a public record and entered into the
30 Agencywide Documents Access and Management System
31 (ADAMS). Do not provide information you would not want to be
32 publicly available.
33

ABSTRACT

1
2 This draft supplemental environmental impact statement (SEIS) has been prepared in response
3 to an application submitted by Nebraska Public Power District (NPPD) to renew the operating
4 license for Cooper Nuclear Station, Unit 1, for an additional 20 years.

5 This draft SEIS includes the preliminary analysis that evaluates the environmental impacts of
6 the proposed action and alternatives to the proposed action. Alternatives considered include
7 replacement power from new supercritical coal-fired generation; natural gas combined-cycle
8 generation; a combination of alternatives that include natural gas combined-cycle generation,
9 energy conservation, and wind; and not renewing the license (the no-action alternative).

10 The preliminary recommendation is that the U.S. Nuclear Regulatory Commission (NRC)
11 determines that the adverse environmental impacts of license renewal for Cooper Nuclear
12 Station, Unit 1, are not so great that preserving the option of license renewal for energy-
13 planning decision makers would be unreasonable.

TABLE OF CONTENTS

1		
2	Abstract.....	v
3	Table of Contents.....	vii
4	Figures.....	xiii
5	Tables.....	xiv
6	Executive Summary.....	xvii
7	Background.....	xvii
8	Proposed Action.....	xvii
9	Purpose And Need For Action.....	xviii
10	Environmental Impacts of License Renewal.....	xviii
11	Land Use.....	xviii
12	Air Quality.....	xix
13	Ground Water Use and Quality.....	xix
14	Surface Water Use and Quality.....	xix
15	Aquatic Resources.....	xix
16	Terrestrial Resources.....	xix
17	Threatened and Endangered Species.....	xx
18	Human Health.....	xx
19	Socioeconomics.....	xx
20	Severe Accident Mitigation Alternatives.....	xxi
21	Alternatives.....	xxii
22	Comparison of Alternatives.....	xxii
23	Recommendation.....	xxiii
24	Abbreviations and Acronyms.....	xxv
25	1.0 Purpose and Need for Action.....	1-1
26	1.1 Proposed Federal Action.....	1-1
27	1.2 Purpose And Need for the Proposed Federal Action.....	1-1
28	1.3 Major Environmental Review Milestones.....	1-2
29	1.4 Generic Environmental Impact Statement.....	1-3
30	1.5 Supplemental Environmental Impact Statement.....	1-5
31	1.6 Cooperating Agencies.....	1-6
32	1.7 Consultations.....	1-6
33	1.8 Correspondence.....	1-7
34	1.9 Status of Compliance.....	1-9
35	1.10 References.....	1-11
36	2.0 Affected Environment.....	2-1
37	2.1 Facility Description.....	2-1
38	2.1.1 Reactor and Containment Systems.....	2-1
39	2.1.2 Radioactive Waste Management.....	2-5
40	2.1.2.1 Radioactive Liquid Waste.....	2-6
41	2.1.2.2 Radioactive Gaseous Waste.....	2-6
42	2.1.2.3 Radioactive Solid Waste.....	2-7
43	2.1.3 Nonradiological Waste Management.....	2-8

Table of Contents

1	2.1.3.1 Nonradioactive Waste Steams.....	2-8
2	2.1.3.2 Pollution Prevention and Waste Minimization	2-9
3	2.1.4 Plant Operation and Maintenance	2-10
4	2.1.5 Power Transmission System	2-10
5	2.1.6 Cooling and Auxiliary Water Systems.....	2-12
6	2.1.7 Facility Water Use and Quality	2-17
7	2.1.7.1 Ground Water Use and Quality	2-17
8	2.1.7.2 Surface Water Use and Quality.....	2-18
9	2.1.7.3 National Pollutant Discharge Elimination System	2-18
10	2.1.7.4 Dredging.....	2-20
11	2.2 Surrounding Environment.....	2-20
12	2.2.1 Land Use	2-20
13	2.2.2 Climate and Meteorology	2-23
14	2.2.2.1 Air Quality Impacts	2-24
15	2.2.3 Ground Water Resources	2-25
16	2.2.4 Surface Water Resources.....	2-25
17	2.2.5 Description of Aquatic Resources.....	2-26
18	2.2.5.1 Ecosystem Services Provided by Missouri River Aquatic Ecosystems.....	2-26
19	2.2.5.2 Conceptual Model of Midwestern Rivers.....	2-27
20	2.2.5.3 Description of the Missouri River Basin	2-28
21	2.2.5.4 Physical Features of the Missouri River near the Cooper Nuclear Station	2-30
22	2.2.5.5 Potentially Affected Aquatic Resources	2-31
23	2.2.5.6 Primary Producers: Phytoplankton, Periphyton, and Aquatic	
24	Macrophytes	2-31
25	2.2.5.7 Invertebrates: Zooplankton and Benthos	2-32
26	2.2.5.8 Larval Fish.....	2-34
27	2.2.5.9 Fish	2-35
28	2.2.6 Terrestrial Resources	2-36
29	2.2.7 Protected Species.....	2-39
30	2.2.7.1 Aquatic Species	2-48
31	2.2.7.2 Terrestrial Species	2-51
32	2.2.8 Socioeconomic Factors	2-55
33	2.2.8.1 Housing	2-56
34	2.2.8.2 Public Services.....	2-57
35	2.2.8.3 Offsite Land Use	2-61
36	2.2.8.4 Visual Aesthetics and Noise.....	2-62
37	2.2.8.5 Demography.....	2-63
38	2.2.8.6 Economy	2-69
39	2.2.9 Historic and Archaeological Resources	2-72
40	2.2.9.1 Cultural Background.....	2-72
41	2.2.9.2 Prehistoric Periods	2-72
42	2.2.9.3 Historic Period.....	2-73
43	2.2.10 Historic and Archaeological Resources at the Cooper Nuclear Station,	
44	Unit 1 Site.....	2-74
45	2.3 Related Federal and State Activities	2-75
46	2.4 References	2-76
47	3.0 Environmental Impacts of Refurbishment	3-1
48	3.1 References	3-4

1	4.0 Environmental Impacts of Operation.....	4-1
2	4.1 Land Use.....	4-1
3	4.2 Air Quality.....	4-1
4	4.3 Ground Water.....	4-2
5	4.3.1 Generic Ground Water Issues.....	4-2
6	4.3.2 Ground Water Use Conflicts.....	4-2
7	4.4 Surface Water.....	4-2
8	4.4.1 Generic Surface Water Issues.....	4-2
9	4.4.2 Water Use Conflicts.....	4-4
10	4.5 Aquatic Resources.....	4-4
11	4.5.1 Generic Aquatic Ecology Issues.....	4-4
12	4.5.2 Entrainment and Impingement.....	4-5
13	4.5.2.1 Introduction.....	4-5
14	4.5.2.2 History of Cooper Nuclear Station’s 316(b) Compliance.....	4-5
15	4.5.2.3 Analysis.....	4-6
16	4.5.3 Thermal Effects.....	4-9
17	4.5.4 Total Impacts on Aquatic Resources.....	4-9
18	4.6 Terrestrial Resources.....	4-11
19	4.7 Protected Species.....	4-11
20	4.7.1 Aquatic Species.....	4-11
21	4.7.2 Terrestrial Species.....	4-12
22	4.8 Human Health.....	4-14
23	4.8.1 Generic Human Health Issues.....	4-14
24	4.8.2 Microbiological Organisms.....	4-16
25	4.8.3 Electromagnetic Fields – Acute Shock.....	4-17
26	4.8.4 Electromagnetic Fields–Chronic Effects.....	4-18
27	4.9 Socioeconomics.....	4-18
28	4.9.1 Generic Socioeconomic Issues.....	4-19
29	4.9.2 Housing Impacts.....	4-20
30	4.9.3 Public Services: Public Utility Impacts.....	4-20
31	4.9.4 Offsite Land Use – License Renewal Period.....	4-20
32	4.9.4.1 Population-Related Impacts.....	4-21
33	4.9.4.2 Tax Revenue-Related Impacts.....	4-21
34	4.9.5 Public Services: Transportation Impacts.....	4-22
35	4.9.6 Historic and Archaeological Resources.....	4-22
36	4.9.7 Environmental Justice.....	4-24
37	4.9.7.1 Minority Population in 2000.....	4-26
38	4.9.7.2 Low-Income Population in 2000.....	4-28
39	4.9.7.3 Analysis of Impacts.....	4-32
40	4.9.7.4 Subsistence Consumption of Fish and Wildlife.....	4-32
41	4.10 Evaluation of New and Potentially Significant Information.....	4-34
42	4.11 Cumulative Impacts.....	4-34
43	4.11.1 Cumulative Impacts on Water Resources.....	4-35
44	4.11.2 Cumulative Impacts on Electromagnetic Fields and Thermophilic	
45	Microbiological Organisms.....	4-35
46	4.11.3 Cumulative Impacts on Aquatic Resources.....	4-36
47	4.11.4 Cumulative Impacts on Terrestrial Resources.....	4-40
48	4.11.5 Cumulative Air Quality Impacts.....	4-43
49	4.11.6 Cumulative Human Health Impacts.....	4-45
50	4.11.7 Cumulative Socioeconomic Impacts.....	4-45
51	4.11.8 Summary of Cumulative Impacts.....	4-46

Table of Contents

1 4.12 References 4-48

2 5.0 Environmental Impacts of Postulated Accidents 5-1

3 5.1 Design-Basis Accidents 5-1

4 5.2 Severe Accidents 5-2

5 5.3 Severe Accident Mitigation Alternatives 5-3

6 5.3.1 Introduction 5-3

7 5.3.2 Estimate of Risk 5-4

8 5.3.3 Potential Plant Improvements 5-5

9 5.3.4 Evaluation of Risk Reduction and Costs of Improvements 5-5

10 5.3.5 Cost-Benefit Comparison 5-6

11 5.3.6 Conclusions 5-7

12 5.4 References 5-8

13 6.0 Environmental Impacts of the Uranium Fuel Cycle, and Solid Waste Management,
14 and Greenhouse Gaseous Emissions 6-1

15 6.1 The Uranium Fuel Cycle 6-1

16 6.2 Greenhouse Gas Emissions 6-2

17 6.2.1 Existing Studies 6-2

18 6.2.1.1 Qualitative Studies 6-3

19 6.2.1.2 Quantitative 6-3

20 6.2.1.3 Summary of Nuclear Greenhouse Gas Emissions Compared to Coal 6-5

21 6.2.1.4 Summary of Nuclear Greenhouse Gas Emissions Compared to Natural
22 Gas 6-5

23 6.2.1.5 Summary of Nuclear Greenhouse Gas Emissions Compared to
24 Renewable Energy Sources 6-6

25 6.2.2 Conclusions: Relative GHG Emissions 6-7

26 6.3 References 6-9

27 7.0 Environmental Impacts of Decommissioning 7-1

28 7.1 Decommissioning 7-1

29 7.2 References 7-2

30 8.0 Environmental Impacts of Alternatives 8-1

31 8.1 Supercritical Coal-Fired Generation 8-3

32 8.1.1 Air Quality 8-4

33 8.1.1.1 Sulfur Oxides 8-5

34 8.1.1.2 Nitrogen Oxides 8-6

35 8.1.1.3 Particulates 8-6

36 8.1.1.4 Carbon Monoxide 8-6

37 8.1.1.5 Carbon Dioxide 8-6

38 8.1.1.6 Summary of Air Quality 8-7

39 8.1.2 Ground Water Use and Quality 8-7

40 8.1.3 Surface Water Use and Quality 8-7

41 8.1.4 Aquatic and Terrestrial Ecology 8-7

42 8.1.4.1 Aquatic Ecology 8-7

43 8.1.4.2 Terrestrial Ecology 8-8

44 8.1.5 Human Health 8-8

45 8.1.6 Socioeconomics 8-9

46 8.1.6.1 Land Use 8-9

47 8.1.6.2 Socioeconomics 8-10

1	8.1.6.3 Transportation	8-10
2	8.1.6.4 Aesthetics.....	8-11
3	8.1.6.5 Historic and Archaeological Resources	8-11
4	8.1.6.6 Environmental Justice	8-12
5	8.1.7 Waste Management.....	8-12
6	8.2 Natural Gas-Fired Combined-Cycle Generation.....	8-13
7	8.2.1.1 Air Quality.....	8-14
8	8.2.1.2 Sulfur and Nitrogen Oxides	8-15
9	8.2.1.3 Particulates	8-15
10	8.2.1.4 Hazardous Air Pollutants.....	8-15
11	8.2.1.5 Construction Impacts	8-15
12	8.2.2 Ground Water Use and Quality.....	8-16
13	8.2.3 Surface Water Use and Quality	8-16
14	8.2.4 Aquatic and Terrestrial Ecology.....	8-16
15	8.2.4.1 Aquatic Ecology	8-16
16	8.2.4.2 Terrestrial Ecology	8-17
17	8.2.5 Human Health.....	8-17
18	8.2.6 Socioeconomics.....	8-18
19	8.2.6.1 Land Use.....	8-18
20	8.2.6.2 Socioeconomics	8-18
21	8.2.6.3 Transportation	8-19
22	8.2.6.4 Aesthetics.....	8-19
23	8.2.6.5 Historic and Archaeological Resources	8-20
24	8.2.6.6 Environmental Justice	8-20
25	8.2.7 Waste Management.....	8-20
26	8.3 Combination Alternative	8-21
27	8.3.1 Air Quality	8-21
28	8.3.2 Ground Water Use and Quality.....	8-23
29	8.3.3 Surface Water Use and Quality	8-24
30	8.3.4 Aquatic and Terrestrial Ecology.....	8-24
31	8.3.4.1 Aquatic Ecology	8-24
32	8.3.4.2 Terrestrial Ecology	8-24
33	8.3.5 Human Health.....	8-25
34	8.3.6 Socioeconomics.....	8-25
35	8.3.6.1 Land Use.....	8-25
36	8.3.6.2 Socioeconomics	8-26
37	8.3.6.3 Transportation	8-27
38	8.3.6.4 Aesthetics.....	8-27
39	8.3.6.5 Historic and Archaeological Resources	8-28
40	8.3.6.6 Environmental Justice	8-28
41	8.3.7 Waste Management.....	8-29
42	8.4 Alternatives Considered but Dismissed.....	8-30
43	8.4.1 Offsite Coal- and Gas-Fired Capacity.....	8-30
44	8.4.2 Coal-Fired Integrated Gasification Combined-Cycle	8-30
45	8.4.3 New Nuclear	8-31
46	8.4.4 Energy Conservation and Energy Efficiency	8-31
47	8.4.5 Purchased Power	8-31
48	8.4.6 Solar Power	8-32
49	8.4.7 Biomass Waste.....	8-32
50	8.4.8 Hydroelectric Power.....	8-32
51	8.4.9 Wave and Ocean Energy.....	8-33

Table of Contents

1	8.4.10 Geothermal Power.....	8-33
2	8.4.11 Municipal Solid-Waste	8-33
3	8.4.12 Biofuels.....	8-34
4	8.4.13 Oil-Fired Power.....	8-34
5	8.4.14 Fuel Cells.....	8-34
6	8.4.15 Delayed Retirement.....	8-35
7	8.5 No-Action Alternative.....	8-35
8	8.5.1 Air Quality.....	8-35
9	8.5.2 Ground Water Use and Quality.....	8-35
10	8.5.3 Surface Water Use and Quality.....	8-36
11	8.5.4 Aquatic and Terrestrial Resources	8-36
12	8.5.4.1 Aquatic Ecology	8-36
13	8.5.4.2 Terrestrial Ecology	8-36
14	8.5.5 Human Health.....	8-36
15	8.5.6 Socioeconomics.....	8-36
16	8.5.6.1 Land Use.....	8-36
17	8.5.6.2 Socioeconomics.....	8-36
18	8.5.6.3 Transportation.....	8-37
19	8.5.6.4 Aesthetics.....	8-37
20	8.5.6.5 Historic and Archaeological Resources	8-37
21	8.5.6.6 Environmental Justice	8-37
22	8.5.7 Waste Management.....	8-37
23	8.6 Alternatives Summary	8-38
24	8.7 References	8-40
25	9.0 Conclusion	9-1
26	9.1 Environmental Impacts of License Renewal.....	9-1
27	9.2 Comparison of Environmental Impacts of License Renewal and Alternatives	9-2
28	9.3 Resource Commitments	9-2
29	9.3.1 Unavoidable Adverse Environmental Impacts.....	9-2
30	9.3.2 The Relationship between Local Short-Term Uses of the Environment and	
31	the Maintenance and Enhancement of Long-Term Productivity	9-3
32	9.3.3 Irreversible and Irrecoverable Commitments of Resources.....	9-3
33	9.4 Recommendations	9-4
34	10.0 List of Preparers.....	10-1
35	11.0 Index	11-1
36	12.0 List of agencies, organizations, and persons to whom copies of the supplemental	
37	environmental impact statement are sent	12-1
38	Appendix A. Comments Received on the Cooper Nuclear Station, Unit 1,	
39	Environmental Review	A-1
40	Appendix B. National Environmental Policy Act Issues for License Renewal of Nuclear	
41	Power Plants	B-1
42	Appendix C. Applicable Regulations, Laws, and Agreements	C-1

1 Appendix D. Consultation Correspondence D-1
 2 Appendix D.2 Biological Assessment Cooper Nuclear Station License Renewal Date
 3 2009 Docket No. 50-298 U.S. Nuclear Regulatory Commission Rockville,
 4 Maryland D.2-1
 5 Appendix E. Chronology of Environmental Review E-1
 6 Appendix F. U.S. Nuclear Regulatory Commission Staff Evaluation of Severe Accident
 7 Mitigation Alternatives for Cooper Nuclear Station, Unit 1 In Support of License
 8 Renewal Application Review F-1

9 **FIGURES**

10 Figure 1-1. Environmental Review Process 1-2
 11 Figure 1-2. Environmental Issues Evaluated During License Renewal. 1-5
 12 Figure 2.1-1. Location of Cooper Nuclear Station, Unit 1, 50-mile (80-kilometer) Region 2-2
 13 Figure 2.1-2. Location of Cooper Nuclear Station, Unit 1, 6-mile (10-kilometer) Region 2-3
 14 Figure 2.1-3. Cooper Nuclear Station, Unit 1, General Site Layout 2-4
 15 Figure 2.1.5-1. Cooper Nuclear Station, Unit 1 Transmission Line Corridor 2-12
 16 Figure 2.1.6-1. Cooper Nuclear Station, Unit 1, Intake Structure Plan 2-14
 17 Figure 2.1.6-2. Cooper Nuclear Station, Unit 1, Intake Structure Section 2-15
 18 Figure 2.1.6-3. Cooper Nuclear Station, Unit 1, Typical Dual Flow Screen 2-16
 19 Figure 2.2.1-1. Cooper Nuclear Station Facility Location 2-21
 20 Figure 2.2.1-2. Cooper Nuclear Station, Unit 1, Site Boundary Map 2-22
 21 Figure 2.2.5-1. Conceptual model showing primary external and internal variables with
 22 their interactions that govern the integrity of the aquatic biota of
 23 Midwestern streams 2-28
 24 Figure 2.2.6-1. Nontidal Wetlands Located on the Cooper Nuclear Station, Unit 1, Site 2-38
 25 Figure 4-1. Minority Blocks in 2000 within a 50-Mile Radius of Cooper Nuclear Station
 26 (Individual State) 4-27
 27 Figure 4-2. Minority Blocks in 2000 within a 50-Mile Radius of Cooper Nuclear Station
 28 (Combined State) 4-28
 29 Figure 4-3. Low-Income Block Groups with a 50-Mile Radius of Cooper Nuclear Station
 30 (Individual States) 4-30
 31 Figure 4-4. Low-Income Block with a 50-Mile Radius of Cooper Nuclear Station
 32 (Combined States) 4-31

1		
		TABLES
2	Summary of Environmental Impacts of Proposed Action and Alternatives.....	xxiii
3	Table 1-1. Licenses and Permits	1-10
4	Table 2.1.7-1. Effluent Limitations (mg/L) – National Pollutant Discharge Elimination	
5	System Permit for Cooper Nuclear Station, Unit 1.....	2-19
6	Table 2.2.7-1. Listed Aquatic and Terrestrial Species	2-39
7	Table 2.2.8-1. Cooper Nuclear Station, Unit 1 Employee Residence by County	2-56
8	Table 2.2.8.1-1. Housing in Nemaha, Otoe, and Richardson Counties in Nebraska and	
9	Atchison County in Missouri	2-57
10	Table 2.2.8.2–1. Public Water Supply Systems (thousand gallons per day)	2-59
11	Table 2.2.8.2-2. Major Commuting Routes in the Vicinity of Cooper Nuclear Station,	
12	Unit 1 in 2006 Average Annual Daily Traffic Count	2-61
13	Table 2.2.8.5-1. Population and Percent Growth in Nemaha, Otoe, and Richardson	
14	County, Nebraska, and Atchison County, Missouri, from 1970 to 2000	
15	and projected for 2006 to 2050	2-63
16	Table 2.2.8.5-2. Demographic Profile of the Population in the Cooper Nuclear Station	
17	Unit 1 Four-County Socioeconomic Region of Influence in 2000	2-64
18	Table 2.2.8.5-3. Demographic Profile of the Population in the Cooper Nuclear Station	
19	Four-County Socioeconomic Region of Influence in 2007, Estimated.....	2-65
20	Table 2.2.8.5-4. Seasonal Housing in Counties Located within 50 Miles of the Cooper	
21	Nuclear Station, Unit 1	2-66
22	Table 2.2.8.5-5. Migrant Farm Workers and Temporary Farm Labor in Counties	
23	Located within 50 Miles of the Cooper Nuclear Station, Unit 1.....	2-68
24	Table 2.2.8.6-1. Major Employers in Nemaha County	2-69
25	Table 2.2.8.6-2. Estimated Income Information for the Cooper Nuclear Station Region	
26	of Influence in 2007	2-70
27	Table 2.2.8.6-3. Cooper Nuclear Station, Unit 1 Estimated Tax Distribution, 2005–2007	2-71
28	Table 3-1. Category 1 Issues for Refurbishment Evaluation	3-2
29	Table 3-2. Category 2 Issues for Refurbishment Evaluation	3-3
30	Table 4-1. Land Use Issues	4-1
31	Table 4-2. Category 1 Surface Water Issues.....	4-3
32	Table 4-3. Aquatic Resources Issues	4-4
33	Table 4-5. Human Health Issues	4-14
34	Table 4-6. Category 1 Issues Applicable to Socioeconomics during the Renewal Term.....	4-19
35	Table 4-7. Category 1 Issues Applicable to Socioeconomics and Environmental Justice	
36	during the Renewal Term	4-19
37	Table 4-8. Intakes	4-39
38	Table 4-9. Stastny 2004.....	4-40
39	Table 4-10. Summary of Cumulative Impacts on Resources Areas	4-47
40	Table 5-1. Cooper Nuclear Station, Unit 1, Core Damage Frequency for Internal	
41	Events.....	5-4
42	Table 5-2. Breakdown of Population Dose by Containment Release Mode	5-5
43	Table 6-1. Issues Related to the Uranium Fuel Cycle and Solid Waste Management	6-2
44	Table 6-2. Nuclear Greenhouse Gas Emissions Compared to Coal	6-5
45	Table 6-3. Nuclear Greenhouse Gas Emissions Compared to Natural Gas.....	6-6
46	Table 6-4. Nuclear Greenhouse Gas Emissions Compared to Renewable Energy	
47	Sources.....	6-7
48	Table 7-1. Category 1 Issues Applicable to the Decommissioning of CNS-1 Following	
49	the Renewal Term	7-1

1 Table 8-1. Summary of Environmental Impacts of the Supercritical Coal-Fired
2 Alternative Compared to Continued Operation of CNS-18-13
3 Table 8-2. Summary of Environmental Impacts of the Natural Gas-Fired Combined-
4 Cycle Generation Alternative Compared to Continued Operation of CNS-
5 18-21
6 Table 8-3. Summary of Environmental Impacts of the Combined Alternative Compared
7 to Continued Operation of CNS-1 8-30
8 Table 8-4. Summary of Environmental Impacts of the No Action Alternative Compared
9 to Continued Operation of CNS-1 8-37
10 Table 8-5. Summary of Environmental Impacts Proposed Action and Alternatives.....8-39
11 B-1
12 Table 10-1. List of Preparers 10-1
13 Table A-1. Commenters on the Scope of the Environmental Review A-2
14 Table B-1. Summary of Issues and Findings. *This table is taken from Table B-1 in*
15 *Appendix B, Subpart A, to 10 CFR Part 51* B-1
16 Table C-1. Federal Environmental Requirements..... C-1
17 Table D-1. Consultation Correspondences..... D-1
18 Table F-1. Cooper Nuclear Station Core Damage Frequency for Internal Events..... F-3
19 Table F-2. Breakdown of Population Dose by Containment Release Mode F-4
20 Table F-3. Cooper Nuclear Station Probabilistic Safety Assessment Historical
21 Summary F-5
22 Table F-4. Cooper Nuclear Station Fire Compartments and Their Contributions to Fire
23 Core Damage Frequency F-8
24 Table F-5. Severe Accident Mitigation Alternatives Cost/Benefit Screening Analysis for
25 Cooper Nuclear Station F-21
26

EXECUTIVE SUMMARY

1

2 BACKGROUND

3 By letter dated September 24, 2008, Nebraska Public Power District (NPPD) submitted an
4 application to the U.S. Nuclear Regulatory Commission (NRC) to issue a renewed operating
5 license for Cooper Nuclear Station, Unit 1 (CNS-1), for an additional 20-year period.

6 Pursuant to 10 CFR 51.20(b)(2), the Commission indicates that a renewal of a power reactor
7 operating license requires preparation of an environmental impact statement (EIS) or a
8 supplement to an existing EIS. In addition, 10 CFR 51.95(c) states that the Commission shall
9 prepare an environmental impact statement, which is a supplement to the Commission's
10 NUREG-1437, "Generic Environmental Impact Statement (GEIS) for License Renewal of
11 Nuclear Plants" (May 1996), (NRC, 1996).

12 Upon acceptance of NPPD's application, the NRC staff began the environmental review process
13 described in 10 CFR Part 51 by publishing a Notice of Intent to prepare a supplemental EIS and
14 conduct scoping. In preparation of this SEIS for CNS-1, the NRC staff performed the following:

- 15 • Conducted public scoping meetings on February 25, 2009, in Brownville
16 and Auburn, NE
- 17 • Conducted a site audit at the plant in late March 2009
- 18 • Reviewed NPPD's environmental report (ER) and compared it to the GEIS
- 19 • Consulted with other agencies
- 20 • Conducted a review of the issues following the guidance set forth in
21 NUREG-1555, Standard Review Plans for Environmental Reviews for
22 Nuclear Power Plants, Supplement 1: Operating License Renewal (NRC,
23 2000)
- 24 • Considered public comments received during the scoping process.

25 PROPOSED ACTION

26 NPPD initiated the proposed Federal action—issuing a renewed power reactor operating
27 license—by submitting an application for license renewal of CNS-1, for which the existing
28 license DPR-46 will expire on January 18, 2014. The NRC's Federal action is the decision
29 whether or not to renew the license for an additional 20 years.

1 **PURPOSE AND NEED FOR ACTION**

2 The purpose and need for the proposed action (issuance of a renewed license) is to provide an
3 option that allows for power generation capability beyond the term of the current nuclear power
4 plant operating license, and to meet future system generating needs, as determined by State,
5 utility, and, where authorized, Federal (other than NRC) decision makers. This definition of
6 purpose and need for action reflects the recognition that, unless there are findings in the safety
7 review required by the Atomic Energy Act of 1954 (AEA) or findings in the NEPA environmental
8 analysis that would lead to the rejection of a license renewal application, the NRC does not
9 have a role in the energy-planning decisions of State regulators and utility officials as to whether
10 a particular nuclear power plant should continue to operate.

11 If the operating license is not renewed, then the facility must be shut down on or before the
12 expiration date of the current operating license, January 18, 2014.

13 **ENVIRONMENTAL IMPACTS OF LICENSE RENEWAL**

14 The SEIS evaluates the potential environmental impacts of the proposed action. The
15 environmental impacts from the proposed action are designated as SMALL, MODERATE, or
16 LARGE. As set forth in the GEIS, Category 1 issues are those that meet all of the following
17 criteria:

- 18 (1) The environmental impacts associated with the issue is determined to apply either to all
19 plants or, for some issues, to plants having a specific type of cooling system or other
20 specified plant or site characteristics.
- 21 (2) A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to
22 the impacts, except for collective offsite radiological impacts from the fuel cycle and from
23 high-level waste and spent fuel disposal.
- 24 (3) Mitigation of adverse impacts associated with the issue is considered in the analysis and
25 it has been determined that additional plant-specific mitigation measures are likely not to
26 be sufficiently beneficial to warrant implementation.

27 For Category 1 issues, no additional site-specific analysis is required in this draft SEIS unless
28 new and significant information is identified. Chapter 4 of this report presents the process for
29 identifying new and significant information. Site-specific issues (Category 2) are those that do
30 not meet one or more of the criterion for Category 1 issues; therefore, an additional
31 site-specific review for these nongeneric issues is required, and the results are documented in
32 the SEIS. The NRC staff has reviewed NPPD's established process for identifying and
33 evaluating the significance of any new and significant information on the environmental impacts
34 of license renewal of CNS-1. Neither NPPD nor NRC identified information that is both new and
35 significant related to Category 1 issues that would call into question the conclusions in the
36 GEIS. Similarly, neither the scoping process nor the NRC staff has identified any new issue
37 applicable to CNS-1 that has a significant environmental impact. The NRC staff, therefore, relies
38 upon the conclusions of the GEIS for all Category 1 issues applicable to CNS-1.

39 **LAND USE**

40 SMALL. The NRC staff did not identify any Category 2 issues for land use, nor did the staff
41 identify any new and significant information during the environmental review. Therefore, there

1 would be no impacts beyond those discussed in the GEIS. As stated in the GEIS, the impacts
2 associated with these Category 1 issues were determined to be SMALL, and plant-specific
3 mitigation measures are not sufficiently beneficial to be warranted.

4 **AIR QUALITY**

5 SMALL. The NRC did not identify any Category 2 issues for air quality impacts, nor did the staff
6 identify any new or significant information during the environmental review. Therefore, for plant
7 operation during the license renewal term, there are no impacts beyond those discussed in the
8 GEIS.

9 **GROUND WATER USE AND QUALITY**

10 SMALL. The staff did not identify any new and significant information in regard to Category 1 or
11 generic ground water issues. Ground water use conflicts: potable and service water—plants
12 using greater than 100 gallons per minute (gpm) is a Category 2 issue related to license
13 renewal at CNS-1. Because of the limited radius of influence of CNS-1 wells in the unconfined
14 aquifer, no public ground water supplies are close enough to CNS-1 to be impacted by ground
15 water use at the station. There are no well-head protection areas or Environmental Protection
16 Agency (EPA) designated sole source aquifers in the vicinity of CNS-1. Therefore, the impact of
17 ground water use by CNS-1 is SMALL.

18 **SURFACE WATER USE AND QUALITY**

19 SMALL. The staff did not identify any new information and issues during its review. Therefore,
20 no Category 2 surface water issues were identified for the CNS-1 license renewal term. The
21 surface water issues related to CNS-1 are Category 1. Therefore, no impacts are related to
22 these issues beyond those discussed in the GEIS. For these issues, the NRC staff concludes in
23 the GEIS that the impacts are SMALL.

24 **AQUATIC RESOURCES**

25 SMALL. With regard to operation of CNS-1 during the license renewal term, the NRC staff
26 identified the following Category 2 issues for aquatic resources: entrainment and impingement
27 of fish and shellfish, and heat shock. The NRC staff reviewed the available information and
28 concludes that the weight of evidence indicates a SMALL level of impact on aquatic resources
29 due to impingement and entrainment at CNS-1. NPPD has implemented some impingement
30 mitigation measures and plans to implement others. After reviewing the available information,
31 the NRC staff concludes that the level of thermal impact on the aquatic community by renewing
32 CNS-1's operating license is SMALL.

33 In addition to the impact on aquatic resources due to entrainment and impingement of fish and
34 shellfish and heat shock, the NRC staff reviewed field studies on the total impact of CNS-1's
35 cooling water system operation on aquatic resources. The NRC staff concludes that the level of
36 impact on aquatic resources due to all aspects of CNS-1's cooling system operation is SMALL.

37 **TERRESTRIAL RESOURCES**

38 SMALL. The NRC staff identified no Category 2 issues related to terrestrial resources for license
39 renewal. The NRC staff did not identify any additional new and significant information during
40 review of the NPPD's ER, the site audit, the scoping process, or the evaluation of other
41 available information. Therefore, the NRC staff concludes that there are no additional impacts
42 related to these issues beyond those discussed in the GEIS. The GEIS further concludes that

1 since the impacts are SMALL, additional site-specific mitigation measures are not likely to be
2 sufficiently beneficial to implement.

3 **THREATENED AND ENDANGERED SPECIES**

4 SMALL. Impact to threatened and endangered species during the period of extended operation
5 includes one Category 2 issue, the conservation of pallid sturgeon. NPPD has been involved
6 with several organizations in a conservation agreement regarding pallid sturgeon, which could
7 have a positive impact on the pallid sturgeon population. Operation of the CNS-1 site and its
8 associated transmission lines has not been known, nor is expected, to adversely affect any
9 threatened or endangered species during the license renewal term. The NRC staff, therefore,
10 concludes that adverse impacts to threatened or endangered species during the license renewal
11 term would be SMALL.

12 **HUMAN HEALTH**

13 SMALL. The NRC staff's review of the historical radioactive releases from CNS-1 and the
14 resultant dose calculation demonstrate that CNS-1 is operating in compliance with Federal
15 radiation protection standards. Continued compliance with regulatory requirements is expected
16 during the license renewal term. Therefore, the impacts from radioactive effluents are not
17 expected to change during the license renewal term.

18 The NRC staff did not identify any new and significant information during its review. Therefore,
19 there are no impacts related to these issues beyond those discussed in the GEIS. For these
20 issues, the NRC's conclusion in the GEIS was that the impacts are SMALL and additional site-
21 specific mitigation measures are not likely to be sufficiently beneficial to be warranted.

22 Microbiological organisms (public health) and electromagnetic fields— acute effects (electric
23 shock) are Category 2 human health issues. The NRC staff reviewed all documents applicable
24 to the microbiological organisms issue and concludes that thermophilic microbiological
25 organisms are not likely to present a public health hazard as a result of CNS-1 discharges to the
26 Missouri River. The NRC staff concludes that impacts on public health from thermophilic
27 microbiological organisms from continued operation of CNS-1 in the license renewal period are
28 SMALL.

29 The NRC staff has reviewed the available information, including the applicant's evaluation and
30 computational results. Based on this information, the NRC staff evaluated the potential impacts
31 for electric shock resulting from operation of CNS-1 and its associated transmission lines. The
32 staff concludes that the potential impacts from electric shock during the renewal period are
33 SMALL.

34 **SOCIOECONOMICS**

35 SMALL. For Category 1 issues (public services and aesthetic impacts), the NRC staff identified
36 no new and significant information during the environmental review. Therefore, there would be
37 no impacts beyond those discussed in the GEIS. Category 2 socioeconomic impacts include
38 housing impacts, public services (public utilities), offsite land use, public services (public
39 transportation), and historic and archaeological resources.

40 Since NPPD has no plans to add additional employees during the license renewal period except
41 during outages, employment levels at CNS-1 would remain relatively constant with no additional
42 demand for permanent housing during the license renewal term. Based on this information,
43 there would be no impact on housing during the license renewal term beyond what has already
44 been experienced.

1 For the same reason, demand for public water services will remain relatively unchanged with no
2 additional demand. Public water systems in the region would be adequate to meet the demands
3 of residential and industrial customers in the area. Therefore, there would be no additional
4 impact to public water services during the license renewal term beyond what is currently being
5 experienced.

6 Since non-outage employment levels at CNS-1 would remain relatively constant during the
7 license renewal period, there would be no land use impacts related to population or tax
8 revenues, and no transportation impacts. Therefore, offsite land use and transportation issues
9 would remain relatively unchanged.

10 No impacts to known historic and archaeological resources are expected from the continued
11 operation of CNS-1 during the license renewal term. The CNS-1 site is situated in an area
12 where historic and archaeological resources could be located several feet beneath the ground
13 surface. NPPD has instituted a stop work order within its Cultural Resource Protection Plan to
14 ensure that proper notification is taken to protect these resources should they be discovered.
15 Based on review of Nebraska State Historical Society (NSHS) files (archaeological surveys,
16 assessments, and other information), the potential impacts of continued operations and
17 maintenance on historic and archaeological resources at CNS-1 would be SMALL.

18 In reviewing potential social environmental justice impacts(i.e., potential disproportionately high
19 and adverse human health and environmental impacts on minority and low-income populations),
20 an analysis of minority and low-income populations residing within a 50-mile (80-km) radius of
21 CNS-1 indicated there would be no disproportionately high and adverse impacts to these
22 populations from the continued operation of CNS-1 during the license renewal period. Based on
23 recent monitoring results, concentrations of contaminants in native leafy vegetation, soils and
24 sediments, surface water, and fish in areas surrounding CNS-1 have been low (at or near the
25 threshold of detection) and seldom above background levels. Consequently, no
26 disproportionately high and adverse human health impacts are expected in special pathway
27 receptor populations in the region as a result of subsistence consumption of fish and wildlife.

28 **SEVERE ACCIDENT MITIGATION ALTERNATIVES**

29 Since CNS-1 had not previously considered alternatives to reduce the likelihood or potential
30 consequences of a variety of highly uncommon but potentially serious accidents, NRC
31 regulation 10 CFR 51.53(c)(3)(ii)(L) requires that CNS-1 evaluate Severe Accident Mitigation
32 Alternatives (SAMAs) in the course of the license renewal review. SAMAs are potential ways to
33 reduce the risk or potential impacts of uncommon but potentially severe accidents, and may
34 include changes to plant components, systems, procedures, and training.

35 NRC staff reviewed the ER's evaluation of potential SAMAs. Subsequent to the ER, a problem
36 with the process used to numerically average the site-specific meteorological data was
37 identified. NPPD performed a re-analysis of the population dose risk and offsite economic cost
38 risk using corrected meteorological data, and found that the population dose and offsite
39 economic cost values for each of the release categories would be slightly less than reported in
40 the ER, and that the conclusions of the SAMA remain valid.

41 NRC staff reviewed NPPD's re-analysis and the methods used by NPPD as submitted by NPPD
42 and agrees that the error was conservative relative to the average population dose and offsite
43 economic cost and that no SAMAs were inappropriately excluded from consideration in the LRA
44 as a result of the error.

Executive Summary

1 Based on the staff's review and the supplemental information provided by NPPD, the NRC staff
2 concluded that none of the potentially cost-beneficial SAMAs relate to adequately managing the
3 effects of aging during the period of extended operation. Therefore, they need not be
4 implemented as part of the license renewal pursuant to 10 CFR Part 54.

5 **ALTERNATIVES**

6 The NRC staff considered the environmental impacts associated with alternatives to license
7 renewal. These alternatives include other methods of power generation and not renewing the
8 CNS-1 operating license (the no-action alternative). Replacement power options considered
9 were supercritical coal-fired generation, natural gas combined-cycle generation, and a
10 combination alternative that includes a portion of the combined-cycle gas-fired capacity, a
11 conservation capacity component, and a wind power component. The NRC staff initially
12 considered a number of additional alternatives for analysis as alternatives to license renewal of
13 CNS-1; these were later dismissed due to technical, resource availability, or commercial
14 limitations that currently exist and that the NRC staff believes are likely to continue to exist when
15 the existing CNS-1 license expires. The no-action alternative by the NRC staff and the effects it
16 would have were also considered.

17 Where possible, the NRC staff evaluated potential environmental impacts for these alternatives
18 located both at the CNS-1 site and at some other unspecified alternate location. Energy
19 conservation and energy efficiency; purchased power, and a combination alternative, which
20 included natural gas combined-cycle generation, energy conservation and wind power were
21 also considered. The NRC staff evaluated each alternative using the same impact areas that
22 were used in evaluating impacts from license renewal. The results of this evaluation are
23 summarized in the table on the following page.

24 **COMPARISON OF ALTERNATIVES**

25 The coal-fired alternative is the least environmentally favorable alternative, due to its impacts to
26 air quality from nitrogen oxides (NO_x), sulfur oxides (SO_x), particulate matter (PM), polycyclic
27 aromatic hydrocarbons (PAHs), carbon monoxide (CO), carbon dioxide (CO₂), and mercury—
28 and the corresponding human health impacts; construction impacts to aquatic, terrestrial, and
29 potentially historic and archaeological resources are also factors that make the coal-fired
30 alternative the least environmentally favorable alternative.

31 The gas-fired alternative would have slightly lower air emissions, and impacts to aquatic,
32 terrestrial, historic, and archaeological resources would vary depending upon location of the
33 plant. Purchased power would likely have operational impacts that would include aspects of
34 coal-fired, gas-fired, and existing nuclear generation.

35 All other alternatives capable of meeting the energy needs currently served by CNS-1 entail
36 potentially greater impacts than the proposed action of license renewal of CNS-1. The no-action
37 alternative does not meet the needs currently served by CNS-1. However, if the no-action
38 alternative was selected and this was to trigger the energy conservation and energy efficiency
39 action to replace the capacity currently supplied by CNS-1, it could result in an overall SMALL
40 impact.

1 Summary of Environmental Impacts of Proposed Action and Alternatives.

Alternative	Impact Area						
	Air Quality	Ground Water	Surface Water	Aquatic and Terrestrial Resources	Human Health	Socioeconomics	Waste Management
License renewal	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL
Supercritical coal-fired alternative at the CNS-1 site	MODERATE	SMALL	SMALL	SMALL to MODERATE	SMALL	SMALL to LARGE	MODERATE
Gas-fired alternative at the CNS-1 site	SMALL TO MODERATE	SMALL	SMALL	SMALL to MODERATE	SMALL	SMALL to MODERATE	SMALL
Combination of alternatives	SMALL TO MODERATE	SMALL	SMALL	SMALL to LARGE	SMALL to MODERATE	SMALL to MODERATE	SMALL
No-action alternative	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL to MODERATE	SMALL

2 RECOMMENDATION

3 Our preliminary recommendation is that the Commission determines that the adverse
 4 environmental impacts of license renewal for CNS-1 are not so great that preserving the option
 5 of license renewal for energy planning decision makers would be unreasonable. This
 6 recommendation is based on:

- 7 (1) the analysis and findings in the GEIS
- 8 (2) information submitted in the NPPD's ER
- 9 (3) consultation with other Federal, State, and local agencies
- 10 (4) review of other pertinent studies and reports
- 11 (5) consideration of public comments received during the scoping process.

ABBREVIATIONS AND ACRONYMS

1		
2	AADT	average annual daily traffic
3	ACC	averted cleanup and decontamination costs
4	ADV	atmospheric dump valve
5	AEA	Atomic Energy Act of 1954
6	AEC	U.S. Atomic Energy Commission
7	AEO	Annual Energy Outlook
8	ALARA	as low as reasonably achievable
9	AMSL	above mean sea level
10	APE	area of potential effect
11		
12	BA	biological assessment
13	BACT	best available control technology
14	Btu/kWh	British thermal units/kilowatt hours
15	BWR	boiling water reactor
16	BWST	borated water storage tank
17		
18	CAA	Clean Air Act
19	CAFTA	cutest and fault tree analysis
20	CAMR	Clean Air Mercury Rule
21	CDC	Center for Disease Control
22	CDF	core damage frequency
23	CDM	Clean Development Mechanism
24	CENRAP	Central Regional Air Planning Association
25	CEQ	Council on Environmental Quality
26	CESQG	Conditionally Exempt Small Quantity Generator
27	CET	containment event tree
28	CFR	<i>Code of Federal Regulations</i>
29	cfs	cubic feet per second
30	CH ₄	methane
31	CNS-1	Cooper Nuclear Station, Unit 1
32	CO	carbon monoxide
33	CO ₂	carbon dioxide
34	CRA	Conestoga Rover Associates

Abbreviations and Acronyms

1	CRT	cathode ray tube
2	CWA	Clean Water Act
3	CWERCLA	Comprehensive Environmental Response, Compensation, and Liability
4		
5		
6	DBA	design-basis accident
7	DDE	insecticide, dichlorodiphenyldichloroethylene
8	DDT	insecticide, dichlorodiphenyltrichloroethane
9	DHCCW	decay heat closed cooling water
10	DHHS	Department of Health and Human Services
11	DHR	decay heat removal
12	DHRW	decay heat river water system
13	DNR	Department of Natural Resources
14	DOE	Department of Energy
15	DOT	Department of Transportation
16	DPR	demonstration power reactor
17	DPS	Department of Public Safety
18	DSEIS	draft supplemental environmental impact statement
19	DSM	demand-side management
20		
21	EDG	emergency diesel generator
22	EFW	emergency feedwater
23	EIA	Energy Information Administration
24	EIS	environmental impact statement
25	ELF-EMF	extremely low frequency-electromagnetic field
26	EMF	electromagnetic fields
27	EMS	environmental management system
28	E.O.	Executive Order
29	ER	environmental report
30	EPA	Environmental Protection Agency
31	EPCRA	Emergency Planning and Community Right-to-Know Act
32	EPRI	Electric Power Research Institute
33	EPZ	emergency planning zone
34	ESA	Endangered Species Act
35	ESAS	engineered safeguards actuation signal

1	ESRP	Environmental Standard Review Plan
2		
3	F&O	fact and observation
4	FCS	Fort Calhoun Station
5	FES	final environmental statement
6	FIVE	fire-induced vulnerability evaluation
7	FR	<i>Federal Register</i>
8	FSAR	final safety analysis report
9		
10	g C _{eq} /kWh	grams of CO ₂ equivalents per kilowatt-hour
11	GEIS	generic environmental impact statement
12	GHG	greenhouse gas
13	gpm	gallons per minute
14		
15	HAP	hazardous air pollutant
16	HCLPF	high confidence in low probability of failure
17	HFC	hydrofluorocarbons
18	HFE	hydrofluorinated ethers
19	HID	high intensity discharge (light)
20	HLW	high-level waste
21	HPI	high-pressure injection
22	HRA	human reliability analysis
23		
24	ICCW	immediate closed cooling water
25	IEEE	Institute of Electrical and Electronics Engineers
26	IGCC	integrated gasification combined-cycle
27	Inc.	incorporated
28	IPCC	Intergovernmental Panel on Climate Change
29	IPE	individual plant examination
30	IPEEE	individual plant examination of external events
31	ISFSI	independent spent fuel storage installation
32	ISLOCA	interfacing-systems loss-of-coolant accident
33		
34	J	joule
35	JHEP	joint human error probability

Abbreviations and Acronyms

1		
2	LERF	large early release frequency
3	LLC	limited liability corporation
4	LLMW	low level mixed waste
5	LLNL	Lawrence Livermore National Laboratory
6	LLW	low-level radioactive waste
7	LOCA	loss of coolant accident
8	LOOP	loss of offsite power
9	LPI	low pressure injection
10	LQG	Large Quantity Generator
11		
12	MAAP	modular accident analysis program
13	MACCS2	MELCOR Accident Consequence Code System 2
14	MCR	main control room
15	MDC	Missouri Department of Conservation
16	MDNR	Missouri Department of Natural Resources
17	MOV	motor operated valve
18	mrad	milliradiation absorbed dose
19	mrem	milliroentgen equivalent man (mrem)
20	MSA	Magnuson-Stevens Fishery Conservation and Management Act of
21		1996
22	msl	mean sea level
23	MT	metric tonnes
24	MW	megawatt
25	MWd/MTU	megawatt-days per metric ton uranium
26	MWe	megawatt-electric
27	MWt	megawatt-thermal
28		
29	N ₂ O	nitrous oxide
30	NA	not applicable
31	NAAQS	National Ambient Air Quality Standards
32	NAC	Nebraska Administrative Code
33	NAQR	Nebraska Air Quality Regulations
34	NAS	National Academy of Sciences
35	NCDC	National Climatic Data Center

Abbreviations and Acronyms

1	NDED	Nebraska Department of Education
2	NDEQ	Nebraska Department of Environmental Quality
3	NDOR	Nebraska Department of Roads
4	NDNR	Nebraska Department of Natural Resources
5	NEPA	National Environmental Policy Act of 1969
6	NESC	National Electric Safety Code
7	NF ₃	nitrogen trifluoride
8	ng	nanograms
9	NGPC	Nebraska Game and Parks Commission
10	NHHS	Nebraska Department of Health and Human Services
11	NHPA	National Historic Preservation Act
12	NIEHS	National Institute of Environmental Health Sciences
13	NMFS	National Marine Fisheries Service
14	NNRD	Nemaha Natural Resources District
15	NOAA	National Oceanic and Atmospheric Administration
16	NO ₂	nitrogen dioxide
17	NO _x	nitrogen oxide(s)
18	NPDES	National Pollutant Discharge Elimination System
19	NPPD	Nebraska Public Power District
20	NRC	U.S. Nuclear Regulatory Commission
21	NRCC	National Research Council
22	NRHP	National Register of Historic Places
23	NSCCW	nuclear service closed cooling water
24	NSHS	Nebraska State Historical Society
25	NSR	New Source Review
26	NWPCC	Nebraska Water Pollution Control Council
27	NWS	National Weather Service
28		
29	ODAM	Offsite Dose Assessment Manual
30	ODCM	Offsite Dose Calculation Manual
31	ODNR	Ohio Department of Natural Resources
32	OMB	Office of Management and Budget
33	OPPD	Omaha Public Power District
34		
35	PAH	polycyclic aromatic hydrocarbon

Abbreviations and Acronyms

1	PCB	polychlorinated biphenyl
2	pCi/L	picocuries per liter
3	PDS	plant damage state
4	PFC	perfluorocarbons
5	PILOT	payments in lieu of taxes
6	PM	particulate matter
7	PM _{2.5}	particulate matter, 2.5 microns or less in diameter
8	PM ₁₀	particulate matter, 10 microns or less in diameter
9	PMF	probably maximum flood
10	PRA	probabilistic risk assessment
11	PWR	pressurized water reactor
12		
13	RAI	request for additional information
14	RBEC	reactor building emergency cooling
15	RBWMD	Rainwater Basin Wetland Management District
16	RCP	reactor coolant pump
17	RCRA	Resource Conservation and Recovery Act
18	RCS	reactor coolant system
19	REMP	radiological environmental monitoring program
20	RKm	river kilometer
21	RM	river mile
22	rms	root mean square
23	ROI	region of influence
24	ROW(s)	right-of-way(s)
25	RPMA	recovery priority management area
26	RPO	regional planning organization
27	RPV	reactor pressure vessel
28	RRW	risk reduction worth
29	RWD	Rural Water District
30		
31	SAMA	Severe Accident Mitigation Alternative
32	SAR	safety analysis report
33	SBO	station blackout
34	SC	species of concern
35	SCDHEC	South Carolina Department of Health and Environmental Control

Abbreviations and Acronyms

1	SCR	selective catalytic reduction
2	SEIS	supplemental environmental impact statement
3	SER	safety evaluation report
4	SF ₆	sulfur hexafluoride
5	SGTR	steam generator tube rupture
6	SHPO	State Historic Preservation Office
7	SO ₂	sulfur dioxide
8	SO ₃	sulfur trioxide
9	SO _x	sulfur oxide(s)
10	SPDES	State Pollutant Discharge Elimination System
11	SQG	Small Quantity Generator
12	Sv	sievert
13		
14	TDEC	Tennessee Department of Environment and Conservation
15	TSP	total suspended particles
16	TSS	total suspended solids
17		
18	U	Uranium
19	UDEQ	Utah Department of Environmental Quality
20	UNL	University of Nebraska-Lincoln
21	U.S.	United States
22	USFWS	U.S. Fish and Wildlife Service
23	USACE	United States Army Corps of Engineers
24	U.S.C.	<i>United States Code</i>
25	USCB	U.S. Census Bureau
26	USDA	U.S. Department of Agriculture
27	USGCRP	United States Global Change Research Program
28	USGS	U.S. Geological Survey
29	USI	unresolved safety issue
30		
31	VOC	volatile organic compound
32		
33	WGA	Western Governors Association
34	WHO	World Health Organization

1 **1.0 PURPOSE AND NEED FOR ACTION**

2 Issuance of a renewal of a nuclear power plant operating license requires the preparation of a
3 supplemental environmental impact statement (SEIS) under the U.S. Nuclear Regulatory
4 Commission's (NRC's) environmental protection regulations in Title 10, Part 51, "Environmental
5 Protection Regulations for Domestic Licensing and Related Regulatory Functions," of the *Code*
6 *of Federal Regulations* (10 CFR Part 51.20).

7 The Atomic Energy Act of 1954 (AEA) originally specified that licenses for commercial power
8 reactors be granted for up to 40 years, but permitted license renewal. The 40-year licensing
9 period was based on economic and antitrust considerations rather than on technical limitations
10 of the nuclear facility.

11 The decision to seek a license renewal rests with the nuclear power facility owners and typically
12 is based on the facility's economic viability and the investment necessary to continue to meet
13 NRC safety and environmental requirements. The NRC grants or denies a license renewal
14 application based on whether or not the applicant demonstrates that agency regulations for
15 environmental and safety requirements can be met during the period of extended operation.

16 **1.1 PROPOSED FEDERAL ACTION**

17 Nebraska Public Power District (NPPD) initiated the proposed Federal action by submitting an
18 application for license renewal of the Cooper Nuclear Station, Unit 1 (CNS-1), for which the
19 existing license, DPR-46, expires January 18, 2014. The NRC's Federal action is the proposed
20 decision to renew the license for an additional 20 years.


21 **1.2 PURPOSE AND NEED FOR THE PROPOSED FEDERAL ACTION**

22 The purpose and need for the proposed Federal action (i.e., the issuance of a renewed license)
23 is to provide an option that allows for power generation capability, beyond the term of a current
24 nuclear power plant operating license, to meet future system generating needs, as such needs
25 may be determined by State, utility, and, where authorized, Federal decisionmakers (other than
26 NRC). This definition of purpose and need for the proposed Federal action reflects the NRC's
27 recognition that, unless there are findings in the safety review required by the AEA or findings in
28 the National Environmental Policy Act (NEPA) environmental analysis that would lead the NRC
29 not to issue a renewal, the NRC does not have a role in the energy-planning decisions of State
30 regulators and utility officials as to whether or not a particular nuclear power plant should
31 continue to operate.

32 If the NRC renews the operating license, State regulatory agencies and NPPD decide whether
33 or not the plant will continue to operate based on factors such as the need for power within the
34 State's jurisdiction or the purview of the owners. If the NRC does not renew CNS-1's DPR-46
35 operating license, the facility must be shut down on or before the expiration date of the current
36 operating license, January 18, 2014.

1 **1.3 MAJOR ENVIRONMENTAL REVIEW MILESTONES**

2 **Figure 1-1. Environmental Review Process.** *The environmental review process provides*
3 *opportunities for public involvement.*



1 NPPD submitted an environmental report (ER) as part of its license renewal application (NPPD,
2 2008a) in September 2008. After reviewing the application and the ER for sufficiency, the NRC
3 staff published a Notice of Acceptability and Opportunity for Hearing on December 30, 2008, in
4 the *Federal Register* (73 FR 79921). On January 26, 2009, the NRC published another notice in
5 the *Federal Register* (74 FR 4476) on its intent to conduct scoping, thereby beginning the 60-
6 day scoping period.

7 The agency held two public scoping meetings on February 25, 2009, in Brownville, Nebraska,
8 and Auburn, Nebraska. The NRC report entitled “Environmental Impact Statement Scoping
9 Process Summary Report for Cooper Nuclear Station, Unit 1,” dated May 29, 2009, presents the
10 comments received during the scoping process in their entirety (NRC, 2009a). Appendix A to
11 this SEIS presents the comments considered to be within the scope of the environmental
12 license renewal review and the associated NRC responses.

13 To independently verify information provided in the ER, the NRC staff conducted a site audit at
14 CNS-1 from March 30 through April 3, 2009. During the site audit, staff met with plant
15 personnel, reviewed specific documentation, toured the facility, and met with interested Federal,
16 State, and local agencies. The agency published a summary of that site audit and a list of the
17 attendees in a report entitled, “Summary of Site Audit Related to the Review of the License
18 Renewal Application for Cooper Nuclear Station, Unit 1,” dated April 30, 2009 (NRC, 2009b).

19 Figure 1-1 shows the major milestones in the public review of the EIS. Upon completion of the
20 scoping period and site audit, the staff compiled its findings in this draft SEIS, which is being
21 made available for public comment for 75 days. During this comment period, NRC staff will host
22 public meetings and collect public comments. Based on the information gathered, the staff will
23 amend the draft SEIS findings as necessary, and publish a final SEIS.

24 The NRC has established a license renewal process that can be completed in a reasonable
25 period of time with clear requirements to ensure safe plant operations for up to an additional 20
26 years of plant life. The safety review is conducted simultaneously with the environmental review.
27 The staff documents the findings of the safety review in a safety evaluation report (SER). The
28 Commission considers the findings in both the SEIS and the SER in its decision to either grant
29 or deny the issuance of a new license.

30 **1.4 GENERIC ENVIRONMENTAL IMPACT STATEMENT**

31 The NRC performed a generic assessment of the environmental impacts associated with
32 license renewal to improve the efficiency of the license renewal. NUREG-1437, *Generic
33 Environmental Impact Statement (GEIS) for License Renewal of Nuclear Power Plants*,¹
34 documents the results of the NRC staff’s systematic approach to evaluating the environmental
35 consequences of renewing licenses of individual nuclear power plants and operating them for
36 an additional 20 years (NRC 1996, 1999). The NRC staff analyzed and dispositioned those
37 environmental issues that could be dispositioned generically in the GEIS.

38 The GEIS includes a determination of whether or not the analysis of the environmental issue
39 could be applied to all plants and if additional mitigation measures are warranted (Figure 1-2).

¹ NUREG-1437, “Generic Environmental Impact Statement (GEIS) for License Renewal of Nuclear Power Plants,”
Volume 1 and 2, May 1996, Washington, D.C.

Purpose and Need for Action

- 1 Issues are assigned a designation: a Category 1 (generic to all plants) or a Category 2 (not
2 generic to all plants). As set forth in the GEIS, Category 1 issues are those that meet all of the
3 following criteria:
- 4 (1) The environmental impacts associated with the issue is determined to apply either to all
5 plants or, for some issues, to plants having a specific type of cooling system or other
6 specified plant or site characteristics.
 - 7 (2) A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to
8 the impacts, except for collective offsite radiological impacts from the fuel cycle and from
9 high-level waste and spent fuel disposal.
 - 10 (3) Mitigation of adverse impacts associated with the issue is considered in the analysis and
11 it has been determined that additional plant-specific mitigation measures are likely not to
12 be sufficiently beneficial to warrant implementation.

13 For Category 1 issues, no additional site-specific analysis is required in this draft SEIS unless
14 new and significant information is identified. Chapter 4 of this report presents the process for
15 identifying new and significant information. Site-specific issues (Category 2) are those that do
16 not meet one or more of the criterion for Category 1 issues; therefore, an additional
17 site-specific review for these nongeneric issues is required, and the results are documented in
18 the SEIS.

19 The GEIS establishes 92 issues for the NRC staff to independently verify. Of these 92, the staff
20 determined that 69 are Category 1, while 21 issues do not lend themselves to generic
21 consideration (Category 2). Two other issues remained uncategorized and must be evaluated
22 on a site-specific basis: environmental justice and the chronic effects of electromagnetic fields.
23 Refer to Appendix B of this draft SEIS for a list of all 92 issues.

24 For each potential environmental issue, the GEIS
25 (1) describes the activity that affects the
26 environment, (2) identifies the population or
27 resource that is affected, (3) assesses the nature
28 and magnitude of the impact on the affected
29 population or resource, (4) characterizes the
30 significance of the effect for both beneficial and
31 adverse effects, (5) determines whether or not the
32 results of the analysis apply to all plants, and (6)
33 considers whether or not additional mitigation
34 measures are warranted for impacts that would
35 have the same significance level for all plants.

Significance indicates the importance of likely environmental impacts and is determined by considering two variables: **context** and **intensity**. **Context** is the geographic, biophysical, and social context in which the effects will occur. **Intensity** refers to the severity of the impact, in whatever context it occurs.


36 The NRC's standard of significance for impacts was established using the Council on
37 Environmental Quality (CEQ) terminology for "significant." The NRC established three levels of
38 significance for potential impacts—SMALL, MODERATE, and LARGE, as defined below:

39 **SMALL** – Environmental effects are not detectable or are so minor that they will neither
40 destabilize nor noticeably alter any important attribute of the resource.

41 **MODERATE** – Environmental effects are sufficient to alter noticeably, but not to destabilize,
42 important attributes of the resource.

1 **LARGE** – Environmental effects are clearly noticeable and are sufficient to destabilize important
 2 attributes of the resource.

3 **Figure 1-2. Environmental Issues Evaluated During License Renewal.** *Ninety-two issues*
 4 *were evaluated in the GEIS. A site-specific analysis is required for 23 of those 92 issues.*



5

6 **1.5 SUPPLEMENTAL ENVIRONMENTAL IMPACT STATEMENT**

7 The SEIS presents an analysis that considers the environmental effects of the continued
 8 operation of CNS-1, alternatives to license renewal, and mitigation measures for minimizing
 9 adverse environmental impacts. Chapters 5, 6, and 7 analyze the environmental impact of
 10 postulated accidents, the uranium fuel cycle and greenhouse gas emissions, and
 11 decommissioning, respectively. Chapter 8 analyzes and compares the potential environmental
 12 impacts from alternatives, and Chapter 9 presents the preliminary recommendation to the
 13 Commission as to whether or not the environmental impacts of license renewal are so great that
 14 preserving the option of license renewal would be unreasonable. The recommendation will be
 15 made after consideration of the draft SEIS.

Purpose and Need for Action

1 In preparation of this draft SEIS for CNS-1, the staff undertook the following activities:

- 2 • reviewed information provided in the NPPD ER
- 3 • consulted with other Federal, State, and local agencies
- 4 • conducted an independent review of the issues during site audit
- 5 • considered public comments received during the scoping process

6 New information can be identified from a
7 number of sources, including the applicant,
8 the NRC, other agencies, or public
9 comments. If a new issue is revealed, then
10 it is first analyzed to determine whether it is
11 within the scope of the license renewal
12 evaluation. If the issue is not addressed in
13 the GEIS, then the NRC determines its
14 significance and documents its analysis in
15 the SEIS.

New and significant information either:
(1) identifies a significant environmental issue
not covered in the GEIS, or (2) was not
considered in the analysis in the GEIS and
leads to an impact finding that is different from
the finding presented in the GEIS.

16 **1.6 COOPERATING AGENCIES**

17 During the scoping process, no Federal, State, or local agencies were identified as cooperating
18 agencies in the preparation of this SEIS.

19 **1.7 CONSULTATIONS**

20 The Endangered Species Act of 1973, as amended; the Magnuson-Stevens Fisheries
21 Conservation and Management Act of 1996, as amended; and the National Historic
22 Preservation Act of 1966, require that Federal agencies consult with applicable State and
23 Federal agencies and groups before taking action that may affect endangered species,
24 fisheries, or historic and archaeological resources, respectively. Below are the agencies and
25 groups with whom the NRC consulted; Appendix D to this report includes copies of consultation
26 documents.

27 Advisory Council on Historic Preservation
28 Department of Health and Human Services
29 Iowa Tribe of Kansas and Nebraska
30 Iowa Tribe of Oklahoma
31 Kickapoo Tribe in Kansas
32 Nebraska Game and Parks Commission
33 Nebraska Department of Natural Resources
34 Nebraska State Historic Society
35 Missouri State Historic Society
36 Omaha Tribe of Nebraska

- 1 Otoe-Missouria Tribe of Indians
- 2 Prairie Band of Potawatomi Indians
- 3 Sac and Fox Nation of Missouri
- 4 Sac and Fox Tribe of the Mississippi in Iowa
- 5 Sac and Fox Nation of Oklahoma
- 6 U.S. Army Corps of Engineers
- 7 U.S. Fish and Wildlife Service, Grand Island, NE Field Office

8 **1.8 CORRESPONDENCE**

9 During the course of the environmental review, the NRC staff contacted the following Federal,
10 State, regional, local, and tribal agencies. Appendix E to this report contains a chronological list
11 of all documents sent and received during the environmental review.

- 12 Advisory Council on Historic Preservation
- 13 Department of Health and Human Services
- 14 Iowa Tribe of Kansas and Nebraska
- 15 Iowa Tribe of Oklahoma
- 16 Kickapoo Tribe in Kansas
- 17 Nebraska Game and Parks Commission
- 18 Nebraska Department of Health and Human Services
- 19 Nebraska Department of Natural Resources
- 20 Nebraska State Historic Preservation Office
- 21 Missouri State Historic Preservation Office
- 22 Omaha Tribe of Nebraska
- 23 Otoe-Missouria Tribe of Indians
- 24 Prairie Band of Potawatomi Indians
- 25 Sac and Fox Nation of Missouri
- 26 Sac and Fox Tribe of the Mississippi in Iowa
- 27 Sac and Fox Nation of Oklahoma
- 28 U.S. Army Corps of Engineers
- 29 U.S. Environmental Protection Agency, Kansas City, KS Field Office
- 30 U.S. Fish and Wildlife Service, Grand Island, NE Field Office

Purpose and Need for Action

1 A list of persons who received a copy of this draft SEIS is provided below:

Mr. Ronald D. Asche President and Chief Executive Officer Nebraska Public Power District 1414 15th Street Columbus, NE 68601	Mr. Gene Mace Nuclear Asset Manager Nebraska Public Power District P.O. Box 98 Brownville, NE 68321	Mr. John C. McClure Vice President and General Counsel Nebraska Public Power District P.O. Box 499 Columbus, NE 68602-0499
Mr. David Van Der Kamp Licensing Manager Nebraska Public Power District P.O. Box 98 Brownville, NE 68321	Mr. Michael J. Linder, Director Nebraska Department of Environmental Quality P.O. Box 98922 Lincoln, NE 68509-8922	Chairman Nemaha County Board of Commissioners Nemaha County Courthouse 1824 N Street Auburn, NE 68305
Mr. Stewart B. Minahan Vice President Nuclear and Chief Nuclear Officer Cooper Nuclear Station 72676 – 648A Avenue Brownville, NE 68321	Ms. Julia Schmitt, Manager Radiation Control Program Nebraska Health & Human Services R&L Public Health Assurance 301 Centennial Mall, South P.O. Box 95007 Lincoln, NE 68509-5007	Deputy Director for Policy Missouri Department of Natural Resources P.O. Box 176 Jefferson City, MO 65102-0176
Senior Resident Inspector U.S. Nuclear Regulatory Commission P.O. Box 218 Brownville, NE 68321	Regional Administrator, Region IV U.S. Nuclear Regulatory Commission 612 E. Lamar Blvd, Suite 400 Arlington, TX 76011-4125	Director, Missouri State Emergency Management Agency P.O. Box 116 Jefferson City, MO 65102-0116
Chief, Radiation and Asbestos Control Section Kansas Department of Health and Environment Bureau of Air and Radiation 1000 SW Jackson, Suite 310 Topeka, KS 66612-1366	Ms. Melanie Rasmussen Radiation Control Program Director Bureau of Radiological Health Iowa Department of Public Health Lucas State Office Building, 5th Floor 321 East 12th Street Des Moines, IA 50319	Mr. Keith G. Henke, Planner Division of Community and Public Health Office of Emergency Coordination 930 Wildwood Drive P.O. Box 570 Jefferson City, MO 65102
Mr. Art Zaremba, Director of Nuclear Safety Assurance Nebraska Public Power District P.O. Box 98 Brownville, NE 68321	Mr. John F. McCann, Director Licensing, Entergy Nuclear Northeast Entergy Nuclear Operations, Inc. 440 Hamilton Avenue White Plains, NY 10601-1813	Mr. Mike Boyce Cooper Strategic Initiatives Manager Cooper Nuclear Station 72676 – 648A Avenue Brownville, NE 68321
Mr. Garry Young License Renewal Manager Entergy Nuclear 1448 S.R. 333, N-GSB-45 Russellville, AR 72802	Mr. Alan Cox License Renewal Technical Manager Entergy Nuclear 1448 S.R. 333, N-GSB-45 Russellville, AR 72802	Mr. Dave Lach LRP Entergy Project Manager Entergy Nuclear 1448 S.R. 333, N-GSB-45 Russellville, AR 72802
Mr. Jerry Perry 500 S. Main Street Rock Port, MO 64482	Ms. Yolanda Peck 1008 Central Avenue Auburn, NE 68305	Ms. Kendall Neiman 830 Central Avenue Auburn, NE 68305
Ms. Annie Thomas 1522 I Street Auburn, NE 8305	Mr. John Chaney 1101 17th Street Auburn, NE 68305	Mr. Darrell Kruse 2415 McConnell Avenue Auburn, NE 68305

Ms. Daryl J. Obermeyer 64381 727A Road Brownville, NE 68321	Ms. Sherry Black, Director Auburn Memorial Library 1810 Courthouse Avenue Auburn, NE 68305	Board of Brownville, NE Attn: Chairman Marty Hayes P.O. Box 67 223 Main Street Brownville, NE 68321
Mr. Bob Engles Mayor of Auburn, NE 1101 J Street Auburn, NE 68305	Ms. Jo Stevens Mayor of Rock Port, MO 500 S. Main Street Rock Port, MO 64482	Mr. John Cochran U.S. Fish and Wildlife Service Ecological Services Nebraska Field Office 203 West Second Street Grand Island, NE 68801
Mr. John Askew Regional Administrator U.S. EPA Region 7 901 N. 5th Street Kansas City, KS 66101	Ms. Joann Scheafer, Director Nebraska Department of Health & Human Services 301 Centennial Mall South Lincoln, NE 68509	Mr. Doyle Childers, Director Missouri Department of Natural Resources P.O. Box 176 Jefferson City, MO 65102
Mr. Mark Miles State Historic Preservation Officer Department of Natural Resources P.O. Box 176 Jefferson City, MO 65102	Mr. Michael J. Smith State Historic Preservation Officer Nebraska State Historical Society P.O. Box 82554 Lincoln, NE 68501	Mr. Robert Puschendorf Nebraska State Historical Society 1500 R Street P.O. Box 82554 Lincoln, NE 68501-2554
Mr. Seth Greenburg Environment, Planning, and Infrastructure Research Assistant ICF International 9300 Lee Highway Fairfax, VA 22031	Mr. Matthew Leaf KTNC/KLZA Radio 1602 Stone St Falls City, NE 68335	Mr. Daryl J. Obermeyer ADC 64381 727A Road Brownville, NE 68321
Mr. Ron Asche NPPD 1414 15 th St. Columbus, NC 68601	Ms. Carla Mason ADC 820 Central Avenue Auburn, NE 68305	Mr. Jim Thomas Enercon 5100 E. Skelton Street, 450 Tulsa, OK 74135

1 **1.9 STATUS OF COMPLIANCE**

2 NPPD is responsible for complying with all NRC regulations and other applicable Federal, State,
3 and local requirements. Appendix H to the GEIS describes some of the major Federal statutes.
4 Table 1-1 on the following page lists the numerous permits and licenses issued by Federal,
5 State, and local authorities for activities at CNS-1.

Purpose and Need for Action

1 **Table 1-1. Licenses and Permits.** *Existing environmental authorizations for CNS-1 operations.*

Permit	Number	Dates	Responsible Agency
Operating License	DPR-46	Issued: 1/18/1974 Expires: 1/18/2014	NRC
National Pollutant Discharge Elimination System (NPDES) Permit	NE0001244	Expires: 6/30/2012	Nebraska Department of Environmental Quality (NDEQ)
General NPDES Permit	NER000059	Expires: 9/17/2012	NDEQ
Permit to Construct an Air Contaminant Source	Not Applicable (NA)	NA	NDEQ
Hazardous Waste Generator Identification	NED1055071064-2	NA	NDEQ
Class V Well Underground Injection	NE0208256	Expires: 11/16/2010	NDEQ
Well Registration	G-030088	NA	Nebraska Department of Natural Resources (NDNR)
Well Registration	G-030089	NA	NDNR
Well Registration	G-040718	NA	NDNR
Well Registration	G-100339	NA	NDNR
Well Registration	G-100340	NA	NDNR
Well Registration	G-149001A	NA	NDNR
Well Registration	G-149001B	NA	NDNR
Well Registration	G-149001C	NA	NDNR
Well Registration	G-149001D	NA	NDNR
Well Registration	G-149001E	NA	NDNR
Well Registration	G-149001F	NA	NDNR
Well Registration	G-149001G	NA	NDNR
Well Registration	G-149001H	NA	NDNR
Well Registration	G-149001I	NA	NDNR
Well Registration	G-149001J	NA	NDNR
Well Registration	G-149001K	NA	NDNR
Water withdrawal permit	D-1071	NA	NDNR
Class III Public Water Supply System Permit	NE3150505	NA	Nebraska Health and Human Services (NHHS) System
401 Certification	NA	NA	Nebraska Water Pollution Control Council (NWPPCC)
CNS-1 Radioactive Waste Transport Permit	0218-26-08-X	12/31/2008	South Carolina Department of Health and Environmental Control (SCDHEC)

Permit	Number	Dates	Responsible Agency
CNS-1 Radioactive Waste License for Delivery	T-NE002-L08	12/31/2008	Tennessee Department of Environment and Conservation (TDEC), Division of Radiological Health
Generator Site Access Permit	0111000042	1/3/2009	Utah Department of Environmental Quality (UDEQ), Division of Radiological Health

1 1.10 REFERENCES

- 2 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, “Environmental
3 Protection Regulations for Domestic Licensing and Related Regulatory Functions.”
- 4 Atomic Energy Act of 1954 (AEA). 42 U.S.C. 2011, et seq.
- 5 Endangered Species Act of 1973 (ESA). 16 U.S.C. 1531, et seq.
- 6 Magnuson-Stevens Fishery Conservation and Management Act, as amended by the
7 Sustainable Fisheries Act of 1996. 16 U.S.C. 1855, et seq.
- 8 National Environmental Policy Act of 1969 (NEPA). 42 U.S.C. 4321, et seq.
- 9 National Historic Preservation Act (NHPA). 16 U.S.C. 470, et seq.
- 10 Nebraska Public Power District (NPPD). 2008. *License Renewal Application, Cooper Nuclear
11 Station*, “Appendix E, Applicant’s Environmental Report, Operating License Renewal Stage.”
12 ADAMS Accession No. ML083030246.
- 13 Nebraska Public Power District (NPPD). 2008a. *Cooper Nuclear Station, License Renewal
14 Application*. ADAMS Accession No. ML083030227.
- 15 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement
16 for License Renewal of Nuclear Plants*. NUREG-1437, Volumes 1 and 2, Washington, D.C. .
17 ADAMS Accession Nos. ML040690705 and ML040690738.
- 18 U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement
19 for License Renewal of Nuclear Plants, Main Report*, “Section 6.3 – Transportation, Table 9.1,
20 Summary of findings on NEPA issues for license renewal of nuclear power plants, Final Report.”
21 NUREG-1437, Volume 1, Addendum 1, Washington, D.C. ADAMS Accession No.
22 ML0400690720.
- 23 U.S. Nuclear Regulatory Commission (NRC). 2009a. “Environmental Impact Statement,
24 Scoping Process, Summary Report, Cooper Nuclear Station, Unit 1.” Brownville, Nebraska.
25 ADAMS Accession No. ML091200017.
- 26 U.S. Nuclear Regulatory Commission (NRC). 2009b. “Summary of Site Audit Related to the
27 Review of the License Renewal Application for Cooper Nuclear Station, Unit 1 (TAC NOS.
28 MD9763 and MD9737).” ADAMS Accession No. ML090970414.

2.0 AFFECTED ENVIRONMENT

Cooper Nuclear Station, Unit 1 (CNS-1) is located in Nemaha County, Nebraska, 2.25 miles southeast of Brownville, Nebraska, approximately 60 miles southeast of Lincoln, Nebraska and 65 miles south of Omaha, Nebraska. CNS-1 is bounded on the east by the Missouri River and by non-Nebraska Public Power District (NPPD) owned property on the north, south, and west. Figure 2.1-1 shows a map of a 50-mile radius around CNS-1. Figure 2.2-2 shows the area within a six-mile radius of CNS-1. The site is owned and operated by NPPD. The site structures for CNS-1 span approximately 55 acres of the site's total area of approximately 1,359 acres, including 239 acres on the opposite bank (east) of the Missouri River in Atchison County, Missouri. Over 99 percent of the acreage in Nemaha County is used for agriculture and farming. A significant portion of NPPD property at CNS-1, 234 acres in Missouri and 715 acres in Nebraska, is currently leased for agricultural activities such as farming and raising livestock.

2.1 FACILITY DESCRIPTION

The principal structures at CNS-1 consist of the reactor building, turbine building (including service area appendages), control building, controlled corridor, radwaste building, augmented radwaste building, intake structure, off-gas filter building, elevated release point, diesel generator building, multi-purpose facility, railroad airlock, drywell and suppression chamber, miscellaneous circulating water system structures (e.g., circulating water conduits, seal well), optimum water chemistry gas generator building, and office building. Predominant features are the 290-foot tall reactor building, the 325-foot tall elevated release point, and the 328.8-foot tall meteorological tower.

The reactor and nuclear steam supply systems for the site, along with the mechanical and electrical systems required for the safe operation of CNS-1, are primarily located in the containment structure. These vital components of the station are located in a protected area that is completely enclosed by a security fence, with access to the station controlled at a security gate. A plant security system monitors the protected area, as well as the buildings within the station. Normal access to the site is by a paved entrance road built across the site from Nemaha County Road 648A Avenue, located on the west side of the property. No residences are permitted within the CNS-1 exclusion area boundary.


2.1.1 Reactor and Containment Systems

CNS-1 is a single-unit boiling-water reactor (BWR) plant with a nuclear steam supply system supplied by General Electric Company and a turbine generator set supplied by Westinghouse Electric Corporation. CNS-1 achieved commercial operation in 1974 with an initial licensed core thermal power of 2,381 megawatt-thermal (MWt). In 2008, with U.S Nuclear Regulatory Commission (NRC) approval, the applicant performed a measurement uncertainty recapture uprate that increased the core thermal power by 1.62 percent to its current level of 2,419 MWt and 830 megawatt-electric (Mwe) (NPPD, 2008). Figure 2.1-3 shows the general layout of the buildings at CNS-1.



1

2 **Figure 2.1-2. Location of Cooper Nuclear Station, Unit 1, 6-mile (10-kilometer) Region**
3 *(Source: NPPD, 2008)*



1
 2 **Figure 2.1-3. Cooper Nuclear Station, Unit 1, General Site Layout** (Source: NPPD, 2008)

3 The reactor fuel is low-enriched high density ceramic uranium dioxide fuel pellets stacked within
 4 a Zircaloy-2 cladding tube, which is evacuated, back-filled with helium, and sealed by welding
 5 Zircaloy plugs in each end. NPPD currently operates CNS-1 with an individual rod average
 6 burnup of not more than 62,000 megawatt-days per metric ton uranium (MWd/MTU) (NPPD,
 7 2008).

8 The CNS-1 containment system utilizes a multibarrier concept consisting of two systems, a
 9 primary containment, which is a pressure suppression system, and a secondary containment,
 10 which minimizes the release of radioactive materials.

1 The primary containment houses the reactor pressure vessel, the reactor coolant recirculation
2 system, and other branch connections of the reactor coolant system. Primary containment is a
3 pressure suppression system consisting of a drywell, a suppression chamber which stores a
4 large volume of water, a connecting vent system between the drywell and suppression pool,
5 isolation valves, portions of the emergency core cooling system, and other service equipment.
6 The drywell is a steel pressure vessel in the shape of an inverted light bulb, and the suppression
7 chamber is a torus-shaped steel pressure vessel, often referred to as the torus, located below
8 and encircling the drywell.

9 Secondary containment encloses the primary containment system, refueling and reactor
10 servicing areas, new and spent fuel storage facilities, and other reactor auxiliary systems.
11 Secondary containment serves as the primary containment, when required, during reactor
12 refueling and maintenance operations, when primary containment is inoperable and as an
13 additional barrier when primary containment is operable (NPPD, 2008).

14 **2.1.2 Radioactive Waste Management**

15 The radioactive waste system for CNS-1 collects, treats, and disposes of radioactive and
16 potentially radioactive wastes that are byproducts of plant operations. The byproducts are
17 activation products resulting from the irradiation of reactor water and impurities therein
18 (principally metallic corrosion products) and fission products resulting from defective fuel
19 cladding or uranium contamination within the reactor coolant system. Operating procedures for
20 the radioactive waste system ensure that radioactive wastes are safely processed and
21 discharged from the plant within the limits set forth in Title 10 of the *Code of Federal*
22 *Regulations* (CFR) Part 20, "Standards for Protection against Radiation," 10 CFR Part 50,
23 "Domestic Licensing of Production and Utilization Facilities," the plant's technical specifications,
24 and the CNS-1 offsite dose assessment manual (ODAM) (NPPD, 2008).

25 Radioactive wastes resulting from plant operations are classified as liquid, gaseous, or
26 solid. Radioactive liquid wastes are generated from liquids received directly from portions of the
27 reactor coolant system or were contaminated by contact with liquids from the reactor coolant
28 system. Radioactive gaseous wastes are generated from gases or airborne particulates vented
29 from reactor and turbine equipment containing radioactive material. Radioactive solid wastes
30 are solids from the reactor coolant system, solids that come into contact with reactor coolant
31 system liquids or gases, or solids used in the reactor coolant system or steam and power
32 conversion system operation or maintenance (NPPD, 2008).

33 Reactor fuel that has exhausted a certain percentage of its fissile uranium content is referred to
34 as spent fuel. Spent fuel assemblies are removed from the reactor core and replaced with fresh
35 fuel assemblies during routine refueling outages. Spent fuel assemblies are stored in the spent
36 fuel pool in the reactor building. In addition to the spent fuel pool, spent nuclear fuel is expected
37 to be stored in dry casks during the license renewal term.

38 The CNS-1 ODA contains the methodology and parameters used to calculate offsite doses
39 resulting from radioactive gaseous and liquid effluents, and the gaseous and liquid effluent
40 monitoring alarm and trip setpoints used to verify that the radioactive material being discharged
41 meets regulatory limits. The ODA also contains the radioactive effluent controls and
42 radiological environmental monitoring activities and descriptions of the information that is
43 included in the annual radiological environmental operating report and annual radioactive
44 effluent release report (NPPD, 2008).

1 2.1.2.1 *Radioactive Liquid Waste*

2 The CNS-1 liquid waste disposal system collects, holds, treats, processes, and monitors all
3 liquid radioactive wastes for reuse or disposal. The function of the radioactive waste system is
4 to reclaim the liquid phase of the wet solid wastes for reuse within the station and to prepare the
5 solid waste for offsite shipment while minimizing radiation exposure to the workers. Prior to
6 offsite shipment to a licensed burial ground, solid wastes may be stored on site in shielded
7 areas. The solid waste processing systems are located in the radioactive waste building and
8 augmented radioactive waste building. Liquid radioactive waste is collected in sumps and
9 drainage tanks and transferred to the appropriate subsystem collection tanks for treatment,
10 disposal, or recycle. The waste processing selectively removes the radioactive material from the
11 liquid. The processing methods used include filtration and/or demineralization. The system can
12 also handle effluent streams that typically do not contain radioactive material, but may on
13 occasion, be radioactive. The applicant limits, to the extent possible, the amount of liquid
14 radioactive wastes discharged to the Missouri River. For example, there were no liquid
15 radioactive discharges from CNS-1 into the Missouri River in 2007. Liquid discharges are made
16 only after the radioactive material has been analyzed and the projected dose to members of the
17 public has been calculated to be within the values specified in the ODAM, 10 CFR Part 20; and
18 Appendix I to 10 CFR Part 50 (NPPD, 2008).

19 The NRC staff reviewed the CNS-1 radioactive effluent release reports for 2003 through 2007
20 for liquid effluents (NPPD 2004, 2005, 2006, 2007, 2008b). Based on the liquid waste
21 processing system's performance from 2003 through 2007, the liquid discharges for 2007 are
22 consistent with the radioactive liquid effluents discharged from 2003 through 2006. Variations on
23 the amount of radioactive effluents released from year to year are expected, based on the
24 overall performance of the plant and the number and scope of outages and maintenance
25 activities. The radioactive liquid wastes reported by CNS-1 are reasonable and no unusual
26 trends were noted.

27 2.1.2.2 *Radioactive Gaseous Waste*

28 The CNS-1 gaseous waste disposal system processes and disposes of radioactive gaseous
29 effluent to the atmosphere. The off-gas system (non-augmented) includes subsystems that
30 process and dispose of the gases from the main condenser air ejectors, the startup mechanical
31 vacuum pumps, and the gland steam condensers. The processed gases are routed to the
32 elevated release point for dilution and release to the atmosphere. Radiation monitors monitor
33 the gaseous discharges (NPPD, 2008).

34 CNS-1 discharges gaseous waste in accordance with the procedures and methodology
35 described in the ODAM. The radioactive gaseous waste system is used to reduce radioactive
36 materials in gaseous effluents before discharge to meet the dose limits in 10 CFR Part 20 and
37 the dose design objectives in Appendix I to 10 CFR Part 50.

38 The NRC staff reviewed the CNS-1 radioactive effluent release reports for 2003 through 2007
39 for gaseous effluents (NPPD 2004, 2005, 2006, 2007, 2008b). Based on the gaseous waste
40 processing system's performance from 2003 through 2007, the gaseous discharges for 2007
41 are consistent with the effluents discharged from 2003 through 2006. Variations on the amount
42 of radioactive effluents released from year to year are expected, based on the overall
43 performance of the plant and the number and scope of outages and maintenance activities. The
44 radioactive gaseous wastes reported by CNS-1 are reasonable and no unusual trends were
45 noted.

1 2.1.2.3 *Radioactive Solid Waste*

2 The CNS-1 radioactive solid waste disposal system collects, stores, and processes wet and dry
3 solid waste for packaging and shipment offsite. The system consists of a wet process, which
4 collects, processes, dewateres, and solidifies wet solid wastes, and a dry process, which collects
5 and packages dry solid wastes. Wet solid wastes include spent resins, filter cartridges, and filter
6 crud. Dry solid wastes include contaminated rags, clothing, paper, outage equipment, and other
7 radioactively contaminated equipment. CNS-1 uses a combination of onsite processing and an
8 offsite vendor to process radioactive wastes for disposal. Transportation of the radioactive solid
9 waste is conducted in accordance with NRC and U.S. Department of Transportation (DOT)
10 regulations as specified in 10 CFR Part 61, "Licensing Requirements for Land Disposal of
11 Radioactive Wastes," and 10 CFR Part 71, "Packaging and Transportation of Radioactive
12 Material" (NPPD, 2008).

13 The State of South Carolina's licensed low-level radioactive waste (LLW) disposal facility,
14 located in Barnwell, has limited the access from radioactive waste generators located in States
15 that are not part of the Atlantic Low-Level Waste Compact. Nebraska is not a member of the
16 Atlantic Low-Level Waste Compact. This has had a minimal affect on CNS-1's ability to dispose
17 of its solid LLW. It uses the licensed LLW disposal site operated by Envirocare in Clive, Utah for
18 its Class A waste. The applicant has onsite storage capacity to store its Class B and C
19 radioactive waste during the license renewal term.

20 In 2007, preparation work began for the construction of an independent spent fuel storage
21 installation (ISFSI) located on the north end of the CNS-1 site in an area that was previously
22 disturbed. The ISFSI will provide storage space for spent fuel storage casks. The ISFSI, in
23 combination with the existing spent fuel pool, will store spent fuel assemblies generated during
24 the license renewal term. Operation of the ISFSI will be in accordance with NRC regulations to
25 ensure the spent fuel is stored safely and that worker and public radiation exposures are
26 controlled in accordance with the dose limits specified in 10 CFR Part 20, as well as the
27 Environmental Protection Agency's (EPA) radiation standards in 40 CFR Part 190,
28 "Environmental Radiation Protection Standards for Nuclear Power Operations" (NPPD, 2008).

29 The NRC staff reviewed the CNS-1 LLW reports for 2003 through 2007 (NPPD 2004, 2005,
30 2006, 2007, 2008b). The solid waste volumes and radioactivity amounts generated in 2007 are
31 typical of previous annual waste shipments made by CNS-1. Variations in the amount of solid
32 radioactive waste generated and shipped from year to year are expected, based on the overall
33 performance of the plant and the number and scope of outages and maintenance activities. The
34 volume and activity of solid radioactive wastes reported by CNS-1 are reasonable and no
35 unusual trends were noted.

36 No plant refurbishment activities were identified by the applicant as necessary for the continued
37 operation of CNS-1 through the license renewal term. Routine plant operational and
38 maintenance activities currently performed will continue during the license renewal term. Based
39 on the past performance of the radioactive waste system, and the lack of any planned
40 refurbishment activities, similar amounts of radioactive solid waste are expected to be
41 generated during the license renewal term.

1 **2.1.3 Nonradiological Waste Management**

2 CNS-1 generates nonradioactive wastes as part of routine plant maintenance, cleaning
3 activities, and plant operations. Resource Conservation and Recovery Act (RCRA) governs the
4 disposal of solid and hazardous waste. RCRA regulations are contained in Title 40, "Protection
5 of the Environment," Parts 239 through 299 (40 CFR 239, et seq.), of the CFR. Parts 239
6 through 259 of Title 40 contain regulations for solid (nonhazardous) waste, and Parts 260
7 through 279 contains regulations for hazardous waste. RCRA Subtitle C establishes a system
8 for controlling hazardous waste from "cradle to grave," and RCRA Subtitle D encourages States
9 to develop comprehensive plans to manage nonhazardous solid waste and mandates minimum
10 technological standards for municipal solid waste landfills. Nebraska State RCRA regulations
11 are administered by the Nebraska Department of Environmental Quality (NDEQ) and address
12 the identification, generation, minimization, transportation, and final treatment, storage, or
13 disposal of hazardous and nonhazardous waste.

14 *2.1.3.1 Nonradioactive Waste Steams*

15 CNS-1 generates solid waste, defined by RCRA, as part of routine plant maintenance, cleaning
16 activities, and plant operations. Nebraska is a part of EPA Region 7 and its Solid Waste
17 program. In 1985, the EPA authorized NDEQ to administer portions of the RCRA program in the
18 State of Nebraska that are incorporated in Title 128 (Nebraska Hazardous Waste Regulations)
19 of Nebraska Administrative Code (NAC). NAC Title 128 was updated in 2004 to keep current
20 with Federal RCRA regulations.

21 The EPA classifies certain nonradioactive wastes as hazardous based on characteristics
22 including ignitability, corrosivity, reactivity, or toxicity (identification and listing of hazardous
23 waste is available in 40 CFR Part 261). State-level regulators may add wastes to the EPA's list
24 of hazardous wastes. RCRA provides standards for the treatment, storage, and disposal of
25 hazardous waste for hazardous waste generators (regulations are available in 40 CFR Part
26 262).

27 The EPA recognizes three main types of the hazardous waste generators (40 CFR 260.10)
28 based on the quantity of the hazardous waste produced: Large Quantity Generators (LQGs),
29 that generate 2,200 pounds (1,000 kg) per month or more of hazardous waste, more than
30 2.2 pounds (1 kg) per month of acutely hazardous waste, or more than 220 pounds (100 kg) per
31 month of acute spill residue or soil; Small Quantity Generators (SQGs) that generate more than
32 220 pounds (100 kg), but less than 2,200 pounds (1,000 kg) of hazardous waste per month;
33 and, Conditionally Exempt Small Quantity Generators (CESQGs) that generate 220 pounds
34 (100 kg) or less per month of hazardous waste, or 2.2 pounds (1 kg) or less per month of
35 acutely hazardous waste, or less than 220 pounds (100 kg) per month of acute spill residue or
36 soil. State of Nebraska has incorporated the EPA's regulations regarding hazardous wastes and
37 recognizes CNS-1 as a conditionally exempt small quantity generator of hazardous wastes
38 under Title 128, Chapter 8 of NDEQ Administrative Code. CNS-1 generates small amounts of
39 hazardous wastes including spent and expired chemicals, laboratory chemical wastes, and
40 occasional project-specific wastes. As reported in the NPPD environmental report (ER), CNS-1
41 produced no hazardous waste in 2003, 1,112 pounds (504 kg) in 2004, 4,285 pounds (1,944 kg)
42 in 2005, 5,317 pounds (2,412 kg) in 2006, and 308 pounds (140 kg) in 2007 (NPPD, 2008). The
43 increase in quantity of the hazardous waste produced by CNS-1 in 2005–2006 was due to large
44 volumes of paint used during outages, as was confirmed by the NRC staff during the site audit.
45 Used oil, produced during operation of CNS-1, is sent offsite to the EPA-approved hazardous
46 waste disposal facility (NPPD, 2009c).

1 The EPA classifies several hazardous wastes as universal wastes; these include batteries,
2 pesticides, mercury-containing items, and fluorescent lamps. NDEQ has incorporated the EPA's
3 regulations (40 CFR Part 273) regarding universal wastes in Chapter 25 of Title 128 of the NAC.
4 NDEQ defines used batteries, pesticides, mercury-containing items, spent non-TCLP
5 fluorescent and HID lamps, cathode ray tubes (CRTs) and electronics as universal waste and
6 such wastes make up the majority of the hazardous wastes produced by CNS-1. The NPPD ER
7 reports that in 2007 CNS-1 produced 20,860 pounds (9,462 kg) of electronic waste, 6,190
8 pounds (2,808 kg) of lamps and 25,200 pounds (11,431 kg) of batteries (NPPD, 2008).

9 CNS-1 does not routinely chlorinate circulating water systems; however the periodic use of
10 chlorine/bromine in the circulating water system and cooling water system is allowed in CNS-1
11 National Pollutant Discharge Elimination System (NPDES) permit No. NE0001244 (NPPD,
12 2008). Radioactive liquid waste is addressed in Section 2.1.2. Section 2.1.7.3 provides more
13 information on CNS-1 NPDES permit and permitted discharges.

14 The Emergency Planning and Community Right-to-Know Act (EPCRA) requires applicable
15 facilities to provide information on hazardous and toxic chemicals to local emergency planning
16 authorities and the EPA (Title 42, Section 11001, of the *United States Code* (42 USC 11001)).
17 On October 17, 2008, the EPA finalized several changes to the Emergency Planning (Section
18 302), Emergency Release Notification (Section 304) and Hazardous Chemical Reporting
19 (Sections 311 and 312) regulations that were proposed on June 8, 1998 (63 FR 31268). CNS-1
20 is subject to Federal EPCRA reporting requirements, and thus submits an annual Section 312
21 (Tier II) report on hazardous substances to local emergency agencies.

22 Low-level mixed wastes (LLMW) are wastes that contain both LLW and RCRA hazardous waste
23 (40 CFR 266.210). The EPA (or any authorized State agency) regulates the hazardous
24 component of the mixed waste through RCRA, and the NRC regulates radioactive waste subject
25 to the Atomic Energy Act (AEA). CNS-1, as a conditionally exempt small quantity generator
26 under RCRA Subtitle C, periodically produces small amounts of LLMW, mainly from the use of
27 liquid cleaners, and sends it offsite for disposal to an approved disposal facility.

28 2.1.3.2 *Pollution Prevention and Waste Minimization*

29 NPPD established company-wide recycle programs at its major and minor facilities, with a
30 growing Green Team, that focuses on pollution prevention, waste minimization, and education
31 of personnel. CNS-1 implements this program and participates in Green Team activities. NPPD
32 compiles an annual recycling report that summarizes recycling efforts at various locations
33 including CNS-1. As a result of the CNS-1 recycling efforts 51.2 tons (46 metric tonnes (MT) of
34 the office paper, 6,800 pounds (3.1 MT) of batteries, 8,500 pounds (3.9 MT) of electronic waste
35 and 2,675 pounds (1.2 MT) of fluorescent lamps were recycled in 2008 as stated in *Nebraska*
36 *Public Power District 2008 Recycling Report* (NPPD, 2008).

37 In support of nonradiological waste minimization efforts, the EPA's Office of Prevention and
38 Toxics has established a clearinghouse that provides information regarding waste management
39 and technical and operational approaches to pollution prevention (EPA, 2009a). The EPA's
40 clearinghouse can be used as a source for additional opportunities for waste minimization and
41 pollution prevention at CNS-1, as appropriate.

1 The EPA also encourages the use of Environmental Management Systems (EMSs) for
2 organizations to assess and manage the environmental impact associated with their activities,
3 products, and services in an efficient and cost-effective manner. The EPA defines an EMS as “a
4 set of processes and practices that enable an organization to reduce its environmental impacts
5 and increase its operating efficiency.” EMSs help organizations fully integrate a wide range of
6 environmental initiatives, establish environmental goals, and create a continuous monitoring
7 process to help meet those goals. The EPA Office of Solid Waste especially advocates the use
8 of EMSs at RCRA-regulated facilities to improve environmental performance, compliance, and
9 pollution prevention (EPA, 2009).

10 **2.1.4 Plant Operation and Maintenance**

11 Maintenance activities conducted at CNS-1 include inspection, testing, and surveillance to
12 maintain the current licensing basis of the facility and to ensure compliance with environmental
13 and safety requirements. Various programs and activities currently exist at CNS-1 to maintain,
14 inspect, test, and monitor the performance of facility equipment. These maintenance activities
15 include inspection requirements for reactor vessel materials, boiler and pressure vessel in-
16 service inspection and testing, maintenance structures monitoring program, and maintenance of
17 water chemistry.

18 Additional programs include those implemented to meet technical specification surveillance
19 requirements, those implemented in response to the NRC generic communications, and various
20 periodic maintenance, testing, and inspection procedures. Certain program activities are
21 performed during the operation of the unit, while others are performed during scheduled
22 refueling outages. Nuclear power plants must periodically discontinue the production of
23 electricity for refueling, periodic in-service inspection, and scheduled maintenance. CNS-1
24 refuels on an 18-month interval.

25 **2.1.5 Power Transmission System**

26 The NPPD notes in their ER that four transmission lines, owned and operated by NPPD, are
27 considered in scope for license renewal. Three of these four lines are numbered and connect
28 CNS-1 to the regional grid via 345-kilovolt (kV) transmission lines, and total approximately
29 148 miles (238 km). Two of these numbered lines, NPPD TL301 and NPPD TL3502, form a
30 transmission line corridor extending 145 miles (233 km) west-northwest from CNS-1 in Nemaha
31 County and ending within 4 miles (6 km) east of Grand Island in Merrick County. Line NPPD
32 TL3501 originates at CNS-1 and extends approximately 64 miles (103 km) west-northwest to
33 the Mark T. Moore substation, located 1.5 miles (2.4 km) north of Hallam, Nebraska. Line NPPD
34 TL3502 extends approximately 83 miles (134 km) west-northwest from the Moore substation
35 and ends east of Grand Island, crossing the Platte River within one mile of the Grand Island
36 substation (Figure 2.1.5-1). This transmission line right-of-way (ROW) originating from the CNS-
37 1 switchyard spans Nemaha County, Johnson County, Gage County, Lancaster County, Saline
38 County, Fillmore County, York County, Hamilton County, and Merrick County, Nebraska. Line
39 NPPD TL3504 originates at CNS-1 and extends 0.6 miles (1 km) east from the plant and
40 midway to the Missouri River, where it connects with a transmission line owned by Mid-America
41 Energy that is not considered in scope. A fourth unnumbered transmission line in the scope of
42 license renewal connects from the plant to the switchyard and is also considered in scope
43 (NPPD, 2008).

1 There are several additional transmission lines originating at the CNS-1 switchyard that are
2 neither owned nor operated by CNS-1. Two transmission lines originating at the CNS-1
3 switchyard are owned by Omaha Public Power District (OPPD), and a third is owned by Aquila.
4 As these three transmission lines are not owned or under the control of NPPD, they are not
5 within the scope of license renewal for CNS-1 (NPPD, 2008).


6 The transmission lines do not cross any Federal, State, or local parks (NPPD, 2008). However,
7 the western half of the transmission line corridor traverses counties that are part of the U.S. Fish
8 and Wildlife Service's (USFWS) Rainwater Basin Wetland Management District (RBWMD). The
9 RBWMD contains 61 tracts of wetlands comprising over 21,000 acres scattered over 14
10 counties in southeastern Nebraska, and are managed to provide resting stops for millions of
11 migratory birds (USFWS, 2009h).

12 Farming occurs virtually unimpeded under the majority of the transmission lines, and only the
13 footprints of the poles are not used for crops (NPPD, 2008). On the CNS-1 property the
14 agricultural land is managed by a single farmer under an agreement with NPPD. According to
15 staff of NPPD, approximately 70 percent of the transmission line corridor beyond the CNS-1 site
16 traverses cropland, and NPPD has easements with the individual property owners to perform
17 maintenance activities along the corridor. Where the remaining 30 percent of the transmission
18 line corridor crosses forested areas, including wetlands and streams, NPPD has vegetative
19 maintenance procedures in place to prevent vegetation from interfering with the lines (NPPD,
20 2006b).

21 NPPD utilizes an integrated management approach to maintain vegetation along the
22 transmission line ROW that includes both mechanical and chemical control methods.
23 Mechanical control methods in the non-cultivated areas include clearing only woody plants with
24 growth habits that may interfere with the transmission lines or the removal of tall trees that may
25 fall onto the transmission line tower poles. Chemical treatment is used to control brush and re-
26 growth of stumps following mechanical cutting (NPPD, 2006b). Native grasses and low-lying
27 woody plants are allowed to grow below the power lines within the forested ROWs (NPPD,
28 2008). All tree trimming performed by NPPD follows ANSI guidelines for maintaining safe
29 clearance and operation of the electrical systems. Chemical control methods adhere to the
30 State of Nebraska, Department of Agriculture guidelines for application of restricted-use
31 herbicides. All personnel involved with herbicide applications are trained and certified on the
32 application of restricted-use herbicides by the State of Nebraska or a reciprocating State. For
33 mechanical vegetation management in wetlands or along the shoreline of the Missouri River,
34 NPPD contacts the U.S. Army Corps of Engineers (USACE) to determine if there is a need to
35 obtain a Section 404 permit (NPPD, 2006b). NPPD staff has indicated that no chemical
36 treatment of vegetation is performed in wetlands. Chapter 3 of the NPPD Corporate
37 Environmental Manual (NPPD, 2007b) includes provisions for NPPD personnel and
38 vendors/contractors to follow for any land disturbance activities, including work performed in
39 wetlands or along riverbanks.

Affected Environment

- 1 ROW aerial inspections occur bi-monthly, and there is an annual foot patrol inspection;
- 2 additional patrols are conducted following severe storms. Maintenance activities are performed
- 3 in compliance with the Endangered Species Act (ESA), the Bald and Golden Eagle Protection
- 4 Act, and the Migratory Bird Treaty Act. Birds that are nesting are protected except for nests of
- 5 pigeons, house sparrows, and starlings (NPPD, 2006b).



6 **Figure 2.1.5-1. Cooper Nuclear Station, Unit 1 Transmission Line Corridor**
7 *(Modified from NPPD, 2008 CNS-1 ER.)*

8 **2.1.6 Cooling and Auxiliary Water Systems**

9 CNS-1 lies on the western shore of the Missouri River, withdraws river water for its once-
10 through cooling system, and discharges heated water back to the river. Unless otherwise cited,
11 NRC staff drew information about CNS-1's cooling and auxiliary water systems from NPPD
12 (2006c) and the applicant's ER. In the vicinity of the plant, the Missouri River has a regulated
13 minimum flow of 31,000 cubic feet per second (cfs) (878 cubic meters per second (m³/sec)) to
14 the southeast. The circulating water intake structure is located on the western shore of the river
15 behind a guide wall and submerged weir meant to reduce the amount of suspended sediment in
16 the cooling water. The weir attaches to shoreline structures north of the intake and then runs
17 parallel to the face of the intake at a distance of 14.25 feet (4.3 m). The wall continues past the
18 intake and ends 40 feet (12 m) downstream of the downstream corner of the intake structure. In
19 a line riverward of the weir wall and extending downstream of it, 23 sheet pile vanes (10 ft wide
20 by 6 ft high, 3 m wide by 2 m high) oriented at a 22 degree angle to the weir redirect sand and
21 gravel outward from the weir and the intake structure. After flowing generally south along the

1 weir and vanes, river water must reverse course and turn northwest to move between the weir
2 and shore and reach the intake bays. Water velocity between the weir wall and the cooling
3 water intake structure is about 4 ft/sec (1.2 m/sec).


4 In winter, about 25 to 30 percent of main condenser discharge water recirculates through an ice
5 control tunnel at the front of the intake structure and discharges in front of the trash rack to
6 prevent icing. Water flows beneath a curtain wall at about 1.1 ft/sec (0.3 m/sec). Water enters
7 the five intake bays, four of which provide circulating water and are 22 feet (6.7 m) wide and one
8 of which provides service water and is 22.5 feet (6.8 m) wide. The incoming water then flows
9 through trash racks, 3/8 inch (1.0 cm) vertical bars separated 3 inches (7.6 cm) on center, at up
10 to 0.7 ft/sec (20 cm/sec).

11 The circulating water intake bays each separate into two screen bays and the service water
12 intake bay narrows before water encounters the traveling screens, which are oriented at right
13 angles to the flow. Water filters twice through nine 1/8 by 1/2-in. (.3 cm by 1.3 cm) smooth-top
14 mesh modified dual-flow traveling screens (eight for circulating water and one for service water).
15 The upward pass is in the front and the downward pass is behind the screens, that rotate
16 continuously at 8.2 ft/min (2.5 m/min). The intake water velocity at the screens is about 2 ft/sec
17 (0.6 m/sec).

18 After the 4.2-ft (1.28-m) wide traveling screen panels rotate over the upper cog and begin
19 moving down, a high pressure (30–60 psig, 200–400 kPa) screen wash of 3000 gallons per
20 minute (gpm) (0.19 m³/sec) supplied by the service water pumps removes fish and debris, which
21 return together to the river through an 18-in (0.46-m) diameter steel pipe that discharges
22 downstream from the intake. Although the screens are fitted with fish baskets, the system has
23 neither a low-pressure spray system to more gently remove fish from the screens nor a fish
24 return trough to convey fish and other aquatic organisms back to the river separately from
25 potentially damaging debris. Debris loads are about 10 cubic yards per month (8 m³/month).


26 CNS-1 plans to install “dual-flow conversion screen fish handling systems” during its current
27 operational term. This system will have low pressure (5 to 10 psi, 35-70 kPa) fish washing
28 sprays on both the ascending and descending screens and a fish return trough that is separate
29 from the debris trough. A recovery basket will collect fish and other aquatic organisms washed
30 from the screens, and the fish trough will return them to the river. Figure 2.1.6-1, Figure 2.1.6-2,
31 and Figure 2.1.6-3 show the CNS-1 intake structures.

Affected Environment




1

2 **Figure 2.1.6-1. Cooper Nuclear Station, Unit 1, Intake Structure Plan**
3 (Source: NPPD, 2008)



1
2 **Figure 2.1.6-2. Cooper Nuclear Station, Unit 1, Intake Structure Section**
3 (Source: NPPD, 2008)



1

2 **Figure 2.1.6-3. Cooper Nuclear Station, Unit 1, Typical Dual Flow Screen**
3 (Source: NPPD, 2008)

1 After water passes through the traveling screens, the two screen bays of each intake bay rejoin
 2 behind the screens. The four circulating water pumps, one per bay, draw water from the bays
 3 and provide up to 159,000 gpm (10 m³/sec) each. The four service water pumps in the fifth bay
 4 provide a combined flow of 32,000 gpm (2 m³/sec). Water from the circulating water pumps
 5 travels to and circulates through the condenser, where it cools steam from the turbines.
 6 Because of the scouring from the suspended sediment, CNS-1 typically does not need to
 7 chlorinate the circulating water to control biological film fouling, although it has the capacity to
 8 chlorinate or brominate if needed. NPPD is studying the effectiveness of these options.

9 Water temperature increases about 17.8°F (10°C) as it passes through the condenser tubes.
 10 From the condenser, circulating cooling water flows through concrete tunnels to a seal well
 11 structure and then to the discharge canal, where it travels about 1,000 feet (300 m) to discharge
 12 to the river at a slight angle. Water velocity at the discharge is about 1 ft/sec (0.3 m/sec) at
 13 average river flow and about 5.6 ft/sec (1.7 m/sec) during low flows. The travel time from the
 14 intake structure to the discharge is about 20 minutes at high river flow and 10 to 12 minutes at
 15 low flow.

16 Cooling water flow varies with electrical load and ambient river water temperature. At full load
 17 during summer, the expected circulating water system flow is highest: about 636,000 gpm
 18 (40 m³/sec). Circulating water flow is lower under other conditions. In comparison, the lowest
 19 river flow at CNS-1 is about 3,000 cfs. Under the worst conditions, the circulating water system
 20 flow would be about 47 percent of Missouri River flow. Stone riprap at the discharge structure
 21 prevents the discharge from eroding the river bottom.

22 **2.1.7 Facility Water Use and Quality**

23 CNS-1 has a once-through circulating water system withdrawing cooling water from and
 24 discharging to the Missouri River. Each of the four facility circulating water pumps can draw a
 25 maximum of 159,000 gpm. The four service water pumps provide a combined flow of 32,000
 26 gpm. In addition, CNS-1 uses two wells to supply potable ground water to the facility, two wells
 27 to supply water to pump seals and one well for fire protection training (NPPD, 2008).

28 *2.1.7.1 Ground Water Use and Quality*

29 The CNS-1 property overlies the Missouri River Stream Valley Aquifer (described in Section
 30 2.2.3) which consists of interbedded alluvial sand, silt, clay, and gravel ranging in thickness
 31 between 62 and 71 feet (18.9 and 21.6 m) (NDNR, 2008). Saturated thickness of the aquifer
 32 averages approximately 50 feet (15.2 m). In the area of CNS-1, the alluvial aquifer is in
 33 hydraulic contact with the Missouri River with seasonal discharge to the river during lower river
 34 stage and recharge from the river during high stage (NPPD, 2008c). Ground water usually flows
 35 from west to east towards the river, but will flow east to west when river levels are high in the
 36 spring.

37 The two potable water supply wells completed in the alluvial aquifer are registered with the
 38 Nebraska Department of Natural Resources (NDNR) and have a current combined pumping
 39 capacity of 250 gpm (0.016 m³/s) (NDNR, 2008). Normal operations require pumping only one
 40 well at a time to supply 125 gpm (0.008 m³/s). The wells together operate as a Nebraska Public
 41 Water Supply System under permit number NE3150505 from the Nebraska Department of
 42 Health and Human Services (NHHSS, 2000). The water is chlorinated, distributed onsite, and
 43 operated with preventive maintenance and cross connection/backflow prevention programs.
 44 NPPD plans to replace the two drinking water wells with two similar new wells in the near future.

Affected Environment

1 A third alluvial aquifer well registered with the NDNR used for fire protection training has a
2 capacity of 750 gpm (0.047 m³/s). Two additional wells, River Wells A and B, have a capacity of
3 150 gpm (0.01 m³/s) each and are used to supply water for pump seals.

4 NPPD CNS-1 also has authorization number NE0208256 from the NDEQ to conduct
5 underground injection of storm water run-off within the protected area using storm water
6 drainage wells (dry wells) (NDEQ, 2000). These wells look like storm drains but contain gravel
7 at the bottom that allows the collected storm water to seep into the fill material above the water
8 table. This water eventually reaches the water table and disperses.

9 Ground water monitoring at CNS-1 is conducted by sampling 14 monitoring wells, eleven of
10 which were installed to measure the concentration of tritium in ground water. Three of the wells
11 are piezometers installed as part of the ISFSI Project. NPPD has documented seven instances
12 of liquid radiological releases since the licensing of CNS-1 in 1974, but none of the releases is a
13 current source of ground water contamination (CRA, 2007). Preliminary sampling and analysis
14 results from the ground water monitoring program for tritium will be submitted and summarized
15 in the final SEIS.

16 2.1.7.2 *Surface Water Use and Quality*

17 CNS-1 employs a once-through cooling system using water from the Missouri River. Wing dams
18 on the Missouri side of the river are designed to force flow into the central channel of the river.
19 Flow in the river is channelized and carries a heavy sediment load. Sedimentation at the CNS-1
20 intake is minimized by turning vanes and a sheet-pile wall set in the river that direct sediment
21 away from the intake structure.

22 Surface water quality data in the CNS-1 vicinity are provided by USACE low flow studies in
23 support of the Missouri River Master Water Control Manual. Results show relatively small
24 ranges of values of temperature, pH, and dissolved oxygen, but wider variations of suspended
25 solids (USACE, 2007). None of the samples from downstream of CNS-1 showed effects from
26 operating the CNS-1 once-through cooling system. However, the NDEQ, under the authority of
27 the Clean Water Act, has designated the Missouri River in the reach from the Platte River to the
28 Kansas border as impaired for primary contact recreation and fish consumption due to the
29 presence of fecal coliform and polychlorinated biphenyls (PCBs). Beneficial uses of surface
30 water identified in the CNS-1 area are for agricultural and industrial water supply (NDEQ, 2004).

31 2.1.7.3 *National Pollutant Discharge Elimination System*

32 The Nebraska Department of Health, Water Pollution Control Council, originally authorized
33 CNS-1 to use water from and discharge to the Missouri River. Discharge is regulated by
34 Nebraska NPDES permit NE-0001244 which identifies effluent limitations, monitoring
35 requirements and other conditions to comply with NDEQ Title 117 and Title 119, Chapter 27
36 (NPDES permits rules and regulations) and 40 CFR Part 423 (NPPD, 2008). The effluent
37 limitations for each outfall are shown in Table 2.1.7-1.

1 **Table 2.1.7-1. Effluent Limitations (mg/L) – National Pollutant Discharge Elimination**
 2 **System Permit for Cooper Nuclear Station, Unit 1**

Total Suspended Solids			Oil and Grease		Total Residual Chlorine		Temperature-F	
Outfall No.	Avg. Month	Max. Daily	Avg. Month	Max. Daily	Avg. Month	Max. Daily	Max. current	Max. proposed
001	NLR	NLR	NLR	NLR	0.01	0.02	109.4	115.7
002a	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR
002b	30	100	NLR	10	NLR	NLR	NLR	NLR
002c	30	100	NLR	10	NLR	NLR	NLR	NLR
003	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR
004	30	100	NLR	10	NLR	NLR	NLR	NLR
005	30	100	15	20	NLR	NLR	NLR	NLR
006	NLR	NLR	NLR	NLR	NLR	NLR	NLR	NLR
008	30	100	NLR	10	NLR	NLR	NLR	NLR
009	30	100	NLR	10	NLR	NLR	NLR	NLR

NLR = No Limit Required

3 Outfall 001, the main discharge canal outfall for the circulating water system, is located
 4 approximately 1000 feet downstream of the CNS-1 intake structure and empties to the Missouri
 5 River. The once-through service water and equipment non-contact cooling water discharges
 6 through Outfall 006, which empties into the discharge canal. Outfall 004 discharges overflow
 7 from the reverse osmosis treatment system and boiler blowdown and also empty into the
 8 circulating water discharge canal.

9 Outfalls 002a, 002b, and 002c discharge water from roof drain sumps outside the power block,
 10 from clear well discharge, and HVAC blowdown, respectively. Along with the intake screen
 11 backwash discharged through Outfall 003, Outfalls 002a, b, and c discharge to the Missouri
 12 River. Outfall 005 discharges batch volumes of sanitary waste from the sewage lagoon system.
 13 The discharge is sprayed on nearby farm land and is not directly connected to area surface
 14 water bodies. Outfall 008 discharges demineralized well water from the primary plant system's
 15 waste sample tank and have had only one discharge in the last five years. Outfall 009
 16 discharges demineralized well water from the sample tank floor drains in the radioactive control
 17 area. This outfall has not had a discharge in the last five years.

18 The only NPDES non-compliance reported in the last five years was total suspended solids
 19 (TSS) at Outfall 004 on August 31, 2008. The TSS averaged 37.4 milligrams per liter (mg/l)
 20 which exceeds the monthly daily permit limit of 30.0 mg/l . The cause of this small excess was
 21 found to be the presence of fish in the reverse osmosis treatment settling pond. The fish,
 22 introduced to the pond by flooding in 2008, stirred up bottom sediment and caused the sample
 23 to contain higher than average TSS. The treatment system did not cause the excess.

1 In addition to the NDEQ industrial wastewater NPDES permit, CNS-1 has an industrial storm
2 water discharge permit NER000059 for storm water discharge outside the power block area.
3 Inside the power block area, storm water discharge is directed to storm water drainage wells
4 permitted as Class V underground injection wells by the NDEQ under permit NE0208256. The
5 storm water enters the storm drains and disperses in the vadose zone (i.e., the portion of the
6 earth between the top of the ground surface and the water table) above the local water table
7 before it likely discharges to the Missouri River.

8 2.1.7.4 *Dredging*

9 CNS-1 has a USACE dredging permit NE 01-10322 to conduct maintenance dredging of the
10 CNS-1 intake structure. A typical dredging event removes approximately 350 cubic yards
11 (267.6 m³) of sediment outside the main channel and discharges the dredged material
12 downstream in the Missouri River (USACE, 2002).

13 2.2 SURROUNDING ENVIRONMENT

14 The vicinity of CNS-1 is sparsely populated with zero population within a one-half mile radius of
15 the plant. Brownville, Nebraska, the nearest developed community, had a 2005 population of
16 approximately 137. The largest town within 6 miles, Nemaha, Nebraska, located 2.5 miles
17 southwest, had a 2005 population of approximately 177. The largest town with industry within 10
18 miles is Auburn, Nebraska, located to the west, with a 2005 population of approximately 3,076.
19 Nebraska City, located approximately 24 miles northwest of the site, is the closest major town
20 with a 2005 population of 7,035. Maryville, Missouri, located approximately 40 miles east of the
21 plant, is the largest community within 50 miles with a 2005 population of approximately 10,567
22 (NPPD, 2008).

23 CNS-1 is located on the Missouri River at RM 532.5. In the vicinity of CNS-1, on average the
24 Missouri River is approximately 800 feet wide and 28 feet deep. Under the present flow
25 regulation, a minimum Nebraska City flow of 31,000 cfs is maintained for navigational purposes
26 beginning in March and extending through November. During the winter months, a minimum
27 flow of 3,000 cfs is required for sanitary purposes. The flow is highly channelized with swift flows
28 and heavy sediment transport.


29 The site is located on a constructional plain bordering the west bank of the Missouri River
30 situated on the first bottomland of the broad, nearly level, flood plain. The USACE has stabilized
31 the channel by use of pile dikes and bank protection. Earthen levees running parallel with the
32 Missouri River, and flood protection levees were constructed in the area to prevent meandering
33 of the river within the alluvial flood plain. The eastern bank of the Missouri River is chiefly a
34 densely forested land similar to the un-farmable bluffs that run parallel to the Missouri River. To
35 the west there are bluffs that peak at 1,100 feet, but average 1,000 feet along the stretch of river
36 from Brownville to Nemaha. Beyond the bluffs, the land is a gently rolling flood plain.

37 There are several Native American lands within a 50-mile radius of CNS-1 including the Sac
38 and Fox Reservation, Iowa Reservation, and Kickapoo Reservation. There are also several
39 local and county parks, golf courses, forest lands, wildlife areas, and other public recreation
40 lands within a 50-mile radius of CNS-1 (NPPD, 2008).

41 2.2.1 Land Use

42 CNS-1 is located on approximately 1,359 acres (550 hectares (ha)) of land owned and operated
43 by NPPD, including 239 acres (97 ha) on the opposite bank (east) of the Missouri River in

1 Atchison County, Missouri, see Figure 2.2.1. Of the 1,359 acres (550 ha), 949 acres (384 ha)
 2 are currently leased for agricultural activities such as farming and livestock: 234 acres (95 ha) in
 3 Missouri and 715 acres (289 ha) in Nebraska. The 234 acres (95 ha) on the Missouri side of the
 4 river intermittently flood and are mostly wooded wetlands, with 40 of these acres (16 ha) cleared
 5 for agricultural activities. The developed portion of the plant site consisting of the power plant
 6 structure and associated buildings, maintenance facilities, parking lots, and roads occupies
 7 approximately 55 acres (22 ha) of the site (NPPD, 2008).




8
 9 **Figure 2.2.1-1. Cooper Nuclear Station Facility Location**

10 The immediate area around the station is completely enclosed by a security fence, with access
 11 to the station controlled at a security gate. The exclusion area, as defined by 10 CFR 100.3,
 12 surrounds the plant site as shown in Figure 2.2.1-2. The plant site can be accessed by road on

Affected Environment

1 the west side or from the Missouri River on the east. Road access to the plant site is from
2 Nemaha County 648A Avenue. A railroad spur connected to the site during construction was
3 abandoned by the Burlington Northern Railroad. The Steamboat Trace Recreational Trail runs
4 north and south through NPPD property west of the station along the abandoned railroad right-
5 of-way (ROW). The nearest residences lie 0.9 miles beyond the site boundary to the northwest
6 (NPPD, 2008).



7

8 **Figure 2.2.1-2. Cooper Nuclear Station, Unit 1, Site Boundary Map**
9 (Source: NPPD, 2008a)

1 2.2.2 Climate and Meteorology

2 Nebraska is located in the middle portion of the Great Plains. The Great Plains occupy a large
3 region extending from southern Canadian provinces and parts of States such as Montana, North
4 Dakota, and Minnesota and southward to Texas, New Mexico, and Louisiana (David J. Wishart,
5 2004). Nemaha County, where CNS-1 is located, is a part of the Dissected Till Plains that
6 occupy much of Iowa, eastern Nebraska, northwestern Missouri, and small areas of
7 northwestern Illinois, southern Minnesota, and northeastern Kansas. Moderately dissected,
8 glaciated, flat-to-rolling terrain that slopes gently toward the Missouri and Mississippi River
9 valleys characterizes this area.

10 Nebraska has a highly variable continental climate, with a large range of both diurnal and
11 annual temperatures and considerable diversity. There are significant precipitation and
12 temperature variations from east to west of Nebraska. The climate of eastern Nebraska is
13 classified as Dfa by Köppen Climate Classification System: a humid continental climate with hot
14 summers and year round precipitation.

15 The State of Nebraska belongs to the High Plains National Oceanic and Atmospheric
16 Administration (NOAA) Regional Climate Center, which is a Federal-State cooperative effort.
17 The two closest NOAA National Weather stations, which provide the most current
18 meteorological data for the area, are in Lincoln and Omaha, NE, and are located 61 miles
19 (98 km) northwest and 62 miles (100 km) north from CNS-1 respectively.

20 Strong northwestern winds during winter bring cold Arctic air masses from Canada. Occasional
21 low-pressure systems moving from southwestern States cause high winter winds and severe
22 blizzards. The average annual wind speed for the National Weather Service (NWS) Station
23 located in Lincoln, NE, is 10.1 mph (8.8 knots) and 10.5 mph (9.1 knots) for the Omaha NWS
24 Station (NCDC 2009). In the summer, winds are predominantly from the south. Annual normals
25 for the 1971–2000 30-year period, provided by the University of Lincoln, indicate that the annual
26 mean temperature was 51.1°F (10.6°C), with a minimum annual temperature of 39.3°F (4°C),
27 and a maximum annual temperature of 62.8°F (17.1°C) (UNL, 2009).

28 The occurrence of severe weather events in Nebraska is high. During 1950–2009, Nemaha
29 County reported 274 storm events, mostly consisting of tornadoes and high winds with
30 thunderstorms and hail. According to the National Climatic Data Center (NCDC), 17 tornadoes
31 were reported in Nemaha County from January, 1950 to February, 2009: 5 @ F0, 7 @ F1, 4 @
32 F2, and 1 @ F3 strengths (NCDC, 2009a). Occurrence of floods in Nemaha County is less than
33 1 per year. Usually they do not cause any significant damage; however, the Auburn flood of
34 1996 caused \$680,000 in property damage and \$2.1 million in crop damage.

35 Nebraska has wide ranges of precipitation from year to year with a steady decrease of rainfall
36 from east to west. East and southeast areas of Nebraska receive significantly more precipitation
37 than other areas of the State, where drought is not uncommon. According to the 1971–2000
38 annual normals for Lincoln, Nebraska, annual precipitation was 28.37 inches (72 cm) (UNL,
39 2009).

40 Sections 101(b)(1), 110, 169(a)(2), and 301(a) of the Clean Air Act as amended (42 U.S.C.
41 7410, 7491(a)(2), 7601(a) established Mandatory Class I Federal Areas where visibility is an
42 important value. There are no Mandatory Class I Federal areas in the State of Nebraska. The
43 closest Mandatory Class I Federal area is Hercules-Glades Wilderness Area, which is located

Affected Environment

1 295 miles southeast of CNS-1 in the State of Missouri. Due to the significant distance from the
2 site, no adverse impacts on Class I areas are anticipated from CNS-1 operation.

3 2.2.2.1 *Air Quality Impacts.*

4 CNS-1 is located in Nemaha County, Nebraska, which belongs to EPA Region 7. There are no
5 counties designated by the EPA as nonattainment or maintenance for any of the criteria
6 pollutants in the 50-mile (81 km) vicinity of CNS-1. Douglas County, Nebraska, located
7 approximately 72 miles (116 km) from CNS-1, is the closest maintenance county for lead.

8 The Nebraska Division of Air Quality of the NDEQ has primary responsibility for regulating air
9 emission sources within the State of Nebraska. The NDEQ, with assistance from Lincoln-
10 Lancaster County Health Department and Douglas County Health Department, conducts
11 ambient air monitoring in Nebraska, operating 28 sites throughout the State with 34 monitors.
12 The EPA and National Atmospheric Deposition Program also monitor air quality in Nebraska,
13 which participates in the EPA's AIRNow Network that allows for continuous monitoring of the
14 criteria pollutants and informs the public of current environmental conditions. NDEQ compiles an
15 annual air quality report (NDEQ, 2008). In compliance with 40 CFR §58.10, NDEQ submitted a
16 Network Plan for EPA review and approval that reflects changes to the ambient air monitoring
17 program in Nebraska (NDEQ, 2009).

18 CNS-1 has a number of stationary emission sources, such as three standby emergency power
19 supply diesel generators, auxiliaries required for safe starting and continuous operation, and
20 several petroleum fuel storage tanks, which do not require the facility to secure Title V permit.
21 CNS-1 is granted a low emitter status by the NDEQ Air Quality Section due to the actual
22 quantities of emissions that are required to meet criteria and not to exceed thresholds for the
23 emissions of pollutants defined in Chapter 5, Title 129 of Nebraska Administrative Code: for the
24 emissions of particulate matter PM₁₀, carbon monoxide (CO), volatile organic compounds
25 (VOC), oxides of nitrogen (NO_x), SO₂ or SO₃ or any combination of the two (SO_x), single
26 Hazardous Air Pollutant (HAP) or Hazardous Air Pollutant (HAPs) and lead. As reported and
27 submitted to NDEQ, actual total emissions from all sources at CNS-1 from 2004 to 2008 were
28 11.52 tons (10.45 MT) per year, 10.73 tons (9.73 MT) per year, 13.21 tons (10.73 MT) per year,
29 11.43 tons (10.37 MT) per year, and 9.85 tons (8.94 MT) per year respectively. Highest
30 emissions from 2004 to 2008 were reported in 2006: 0.16 tons (0.15 MT) per year of PM₁₀,
31 2.41 tons (2.19 MT) per year of CO, 0.22 tons (0.20 MT) per year of VOC, 9.0 tons (8.16 MT)
32 per year of NO_x, 1.41 tons (1.28 MT) per year of Sox, and 0.01 tons (0.009 MT) per year of
33 single HAP (NPPD, 2009c). The generators are tested periodically to ensure their continued
34 ability to perform their intended function; and there are procedures in place to ensure
35 continuous monitoring, sampling, and filtering of the oil. Used oil is collected for offsite disposal.
36 Used oil disposal is discussed further in the waste management section.

37 CNS-1 operates a meteorological system that consists of two monitoring sites at the ground
38 elevation of approximately 889 feet (271 m) above mean sea level (AMSL). The first monitoring
39 site accommodates a 328-foot (100-m) primary meteorological tower and a 32.8-foot (10-m)
40 back up tower. The former is located approximately 3,230 feet (985 m) and the latter is located
41 approximately 1,597 feet (487 m) from the northwest corner of the reactor building respectively.
42 The second monitoring site, a 328-foot (100-m) meteorological tower, with equipment and
43 monitoring system that is nearly identical to the original 328-foot (100-m) tower, was recently
44 built approximately 2,000 feet (610 m) northwest of the first site. There are two independent
45 identical dual sensors, system A and system B, mounted onto the 328-foot (100-m) primary
46 meteorological tower measuring temperature, wind speed, and direction at 32.8 feet (10 m), 197

1 feet (60 m) and 328 feet (100 m). Vertical temperature differential is measured with temperature
2 sensors between all three levels. A relative humidity sensor is positioned at the 32.8 feet (10 m)
3 level. Precipitation is measured at ground level (NPPD, 2008).

4 The meteorological data (15-minute and hourly average) is run through meteorological data
5 validation software that checks and flags data discrepancies and inputs it to the CNS-1 plant
6 computer. In the case of a complete system failure, the National Weather Service Office,
7 located in Valley, Nebraska provides backup meteorological data by telephone or National
8 Warning System (NPPD, 2008).

9 **2.2.3 Ground Water Resources**

10 As described by the United States Geological Survey (USGS, 1997), the Western Interior Plains
11 Bedrock Aquifer System is present beneath the CNS-1 site but contains no fresh water. The
12 only freshwater aquifer system beneath the site consists of unconsolidated alluvial deposits of
13 the Missouri River Stream Valley Aquifer and glacial deposits of the Glacial Drift Aquifer. These
14 deposits are reworked and difficult to distinguish within the main river valley. All of the onsite
15 wells are completed in these deposits and the aquifer is under unconfined (water-table)
16 conditions (NPPD, 2008).

17 As part of a hydrogeologic investigation undertaken by CNS-1 for the study of radioisotopes in
18 ground water, CRA reviewed water use in the area surrounding the station and searched the
19 NDNR water-well database for all wells in Nemaha County. Three irrigation wells, completed in
20 the shallow unconsolidated aquifer, are located between two and three miles southwest of CNS-
21 1. Four farm wells within one mile of the station, all only 15 feet deep, produce a limited amount
22 of ground water. None of these wells are impacted by ground water pumping at CNS-1 because
23 the station wells are screened in an unconfined aquifer and have limited radii of influence. A
24 search of wells by NPPD in Atchison County, Missouri, across the river from CNS-1 identified no
25 wells within two miles of the station. In addition, the Missouri River serves as a ground water
26 recharge/discharge boundary.

27 Because of the limited radius of influence of CNS-1 wells completed in the unconfined aquifer,
28 no public ground water supplies are close enough to CNS-1 to be impacted by ground water
29 use at the station. There are no well-head protection areas or EPA-designated sole source
30 aquifers in the vicinity of CNS-1 (CRA, 2007).

31 **2.2.4 Surface Water Resources**

32 CNS-1 is within the Nemaha River Basin whose water resources are managed by the Nemaha
33 Natural Resources District (NNRD). The basin is defined as those areas south of the Platte
34 River that drain directly into the Missouri River. Total area of the basin is 2,800 square miles
35 (7,252 km²) (NPPD, 2008).

36 Flow of the Missouri River at CNS-1 is partially controlled by the Gavins Point Dam located
37 approximately 200 miles (321 km) upstream near Yankton, South Dakota. The USACE
38 constructed and operates six of the seven main-stem dams on the Missouri River; the U.S.
39 Bureau of Reclamation operates the seventh dam located east of Helena, Montana. The
40 confluence of the Platte and Missouri rivers is located 63 miles (101 km) north of CNS-1. The
41 Platte River discharges a significant amount of sediment into the Missouri, much of which is
42 carried downriver to CNS-1 and beyond (NPPD, 2008).

1 At the CNS-1, the Missouri River is approximately 800 feet (244 m) wide and 28 feet (8.5 m)
2 deep in the main channel. As currently regulated by the USACE, the minimum flow in the river
3 for navigation purposes in March through November at Nebraska City, NE, 30 miles (48.3 km)
4 north of CNS-1, is 31,000 cfs (m^3/s). In December through February, the minimum flow
5 permitted is 3,000 cfs (85 m^3/s), primarily for sanitary purposes. The lowest flow recorded at
6 Nebraska City was 4,320 cfs (122 m^3/s) in 1957. If a severe drought occurs, USACE would
7 shorten the navigation season to keep upstream reservoirs high enough to maintain minimum
8 sanitary flows. Water release schedules and priorities for the dams are contained in the USACE
9 Master Manual (USACE, 2004).

10 Water level elevations in the river at CNS-1 range from 874.5 to 899.0 feet (266.5 to 274 m)
11 AMSL with an average level of 880.0 feet (268 m). The mean annual discharge of the river at
12 Nebraska City is 42,160 cfs (1,194 m^3/s) as measured and calculated for the years since 1948
13 when the upstream impoundments started to control flows. Because the river has been
14 channelized and has a relatively uniform cross-section, flow velocity is up to 3 miles per hour
15 (3.8 kmh), which is significantly higher than historic flows prior to completion of the major
16 impoundments (NAS, 2002).

17 Significant changes in the Missouri River due to management practices include loss of natural
18 flood and low flow processes, straightening of meanders, bank stabilization, and reduction of
19 temperature variation. These changes, although ecologically significant, result in a more stable
20 water supply for CNS-1.

21 **2.2.5 Description of Aquatic Resources**

22 *2.2.5.1 Ecosystem Services Provided by Missouri River Aquatic Ecosystems*

23 The Missouri River has provided and continues to provide many ecological services to people
24 living within its basin. The phrase ecosystem services “refers to a wide range of conditions and
25 processes through which natural ecosystems, and the species that are part of them, help
26 sustain and fulfill human life” (Daily et al., 1997). These services are intrinsic to the river itself
27 and go beyond the obvious constructed economic services of providing a route for
28 transportation or a source of water for irrigation and public consumption.

29 Daily et al. (1997) provide examples of general ecosystem services, and NRC staff identified the
30 following ecosystem services specifically provided by the Missouri River. The Missouri River
31 supports birds and other wildlife through fish, insect, and other food webs and also provides
32 recreation and commercial fishing. The river supports populations of mussels that once were a
33 major source of food, tools, and jewelry for Native Americans and later a source of buttons and
34 starting nuclei for cultured pearls. It provides drinking water that supports many forms of
35 domestic animals and wildlife and helps maintain biodiversity from which we derive key
36 ingredients of our agricultural, pharmaceutical, and industrial enterprises. The river supports the
37 aquatic phase of insect predators that help control agricultural and other pests.


38 Within the Missouri River ecosystem, bacteria, algae, fungi, and invertebrates absorb waste
39 nutrients and break down, detoxify, and decompose various wastes and, in doing so, purify
40 water. Living and nonliving components of the aquatic ecosystem participate in the oxygen,
41 carbon, and nitrogen cycles and help mediate concentrations of oxygen and carbon dioxide in
42 the air. Bacteria, fungi, and invertebrates that break down wastes and organic matter, help
43 make the soil fertile where suspended solids that the river deposits following floods. In doing
44 this, the river helps cycle and move nutrients. The river also helps disperse seeds of some
45 natural vegetation. The Missouri River helps maintain the balance of recharge to the ground

1 water and cycling of water back to air as part of moderating the water cycle. The river also
2 provides aesthetic beauty, intellectual stimulation, and opportunities for education.

3 2.2.5.2 *Conceptual Model of Midwestern Rivers*

4 Karr et al. (1985) summarized the history and sources of degradation of Midwestern rivers. The
5 conclusions, which they illustrate with examples from the Maumee and Illinois rivers are
6 applicable to understanding the aquatic resources of the Missouri River near CNS-1 today. Karr
7 et al. (1985) found that the human activity with the greatest impact on Midwestern fish
8 communities was agriculture, which lowers the water table and supplies excess nutrients;
9 navigational locks and channels in large rivers; impoundments, levees, and milldams; discharge
10 of wastes that consume oxygen and toxic contaminants; overconsumption of water; and
11 introduction of exotic species. The authors presented a conceptual model to illustrate the links
12 between these activities and those for recovery and restoration and Midwestern river fish
13 communities.

14 In their conceptual model (Figure 2.2.5-1), five primary variables affect the integrity of aquatic
15 biota. (1) The energy source may be primarily allochthonous (not formed in situ, but originating
16 in another place) organic matter or primary production. As well as the amount of energy, the
17 size distribution of organic particles affects aquatic communities. (2) Water quality includes such
18 factors as temperature, turbidity, dissolved oxygen concentration, soluble organic and inorganic
19 materials, metals, and toxic substances. (3) Habitat structure includes such things as bottom
20 type (e.g., hard substrata, sand); water depth; current velocity; availability of spawning, nursery,
21 and hiding places; and habitat diversity. (4) Flow regime indicates water volume, seasonality
22 and temporal distribution of flow and water volume, and frequency of flooding. (5) Trophic
23 interactions among biotic components include such factors as competition, predation, disease,
24 and parasitism. Natural changes and human activities act through these five primary variables
25 effecting the integrity of aquatic biota to cause changes in aquatic communities. The following
26 summary of natural and human history in the Missouri watershed, represented in Figure 2.2.5-1,
27 shows continual changes in the factors that influence the structure and function of aquatic
28 communities in this Missouri River .



1

2 **Figure 2.2.5-1. Conceptual model showing primary external and internal variables with**
 3 **their interactions that govern the integrity of the aquatic biota of Midwestern streams**
 4 **(After Karr et al., 1985)**

5 *2.2.5.3 Description of the Missouri River Basin*

6 The nature of Missouri River aquatic resource communities strongly reflects the formation and
 7 history of the Prairie region it drains. The Missouri River basin is large, and its present ecology
 8 was formed fairly recently on a geological and evolutionary time scale. Because of its size, the
 9 basin encompasses many diverse habitats on regional and local levels. Because it is fairly
 10 recent, many species that live in the basin are not endemic but have evolved elsewhere and
 11 moved into the basin. The present ecology of aquatic communities reflects a history of change
 12 both prehistoric and historic and of habitat diversity within seasons and across various
 13 geographic scales.

14 The modern Missouri River basin is the second largest in the United States and drains about a
 15 sixth of the conterminous United States as well as part of Canada, including all or parts of
 16 10 U.S. States, 2 Canadian provinces, and 25 Native American lands or tribal reservations.
 17 Many of the Missouri River's tributaries drain east to the main stem, which flows roughly
 18 southeast. Starting from the west, the river basin drains three physiographic divisions: the
 19 Rocky Mountain System, which contributes a little over 10 percent of total flow; the Interior
 20 Plains; and the Interior Highlands. Most of the river flows through the highly erodible soils of the
 21 Great Plains and Central Lowlands' physiographic provinces of the Interior Plains division,
 22 which produces high turbidity and sediment transport (Galat et al., 2005b).

23 Change and perturbation heavily influence the ecology of the Missouri River, including the
 24 aquatic ecology. Glaciers covered much of the basin during the last ice age and helped
 25 determine the course of the modern Missouri River and its tributaries as well as land forms and
 26 soils. The modern prairie drained by the Missouri River is relatively young and formed in the last
 27 several million years so that much of the flora and fauna have colonized from surrounding
 28 ecosystems and few species evolved in and are endemic to the prairie (Benedict et al., 1996).
 29 Between the last ice age, which ended about 10,000 years ago, and the beginning of recorded

1 history of the prairie, invasion and colonization of the basin by plants and animals, and later
2 humans, and extinction of nearly all large mammal species brought further change. Early human
3 settlement probably had limited effects on the ecology of the basin until the twentieth century,
4 when the Federal government intervened to encourage further settlement and development
5 (National Research Council, 2002).

6 Increased settlement occurred through the 1800s, and irrigated agriculture resulted in the early
7 construction of first small and then larger dams in the late 1800s. From the mid-1820s through
8 the 1870s, the Federal government worked to remove large tree snags from the Missouri River
9 to improve navigation. The USACE began stabilizing the river banks in the late 1880s.
10 Construction of hydropower dams began in the late 1800s. Several irrigation projects began in
11 1904, and by the 1930s, most of the tributaries of the Missouri River had one or more dams. In
12 the late 1920's, the USACE began a program that combined bank stabilization with dike
13 construction and strategic dredging designed to narrow the river and eliminate meandering.
14 Where the USACE eliminated wide bends in the river and narrowed the channel, the river's
15 velocity increased, and in some places the river became self-scouring. The subsequent Federal
16 Pick-Sloan Plan in 1944 led to the construction of six main-stem dams and dedicated upstream
17 storage to three primary uses: hydropower generation, navigation enhancement, and flood
18 control (National Research Council, 2002).

19 Today the Missouri River is highly regulated, with about 1,200 single-purpose and
20 100 multipurpose reservoirs, including six reservoirs on the main stem (Galat et al. 2005a,
21 2005b). The aquatic community has been highly influenced by damming and channelization.
22 The reservoirs have changed lentic (i.e., pertaining to still or standing water) habitat into lotic
23 (i.e. pertaining to flowing or running water) habitat and impair migration of fish and other aquatic
24 organisms. Construction of structures such as dikes, levees, stabilization structures, and dams
25 have added hard substrata, or replaced soft substrata with hard substrata in aquatic habitats.
26 The reservoirs, channels, and structures affect physical habitat, water temperature and quality,
27 flow regimes, suspended sediment loads, and light penetration, and many other attributes of the
28 aquatic ecosystem (Galat et al. 2005a, 2005b). The prairie is subject to frequent perturbations
29 on time scales that range from shorter than a year to those spanning decades or millennia, such
30 as fire, draught, flooding, grazing, storms, and local events such as digging activities of animals
31 (Benedict et al. 1996). All of these influences affect aquatic habitats and communities.

32 The climate in the basin is semi-arid, and both direct precipitation and snow melt contribute to
33 the flow, which results in a seasonal succession of low and high flows. Before dam construction
34 and regulation, river flows peaked twice a year: A smaller peak in March through April as snow
35 and ice melted in the middle and upper basins and the prairie, and a second, larger peak in
36 June as the result of melting snows in the Rocky Mountains and precipitation over the prairie.
37 Overbank flooding was common during peak flows. Flows then declined in July and remained
38 low until spring (Galat et al., 2005a).

39 Before dam construction and regulation of the river, the variation in flow drove changes in the
40 river channel's location, form, and volume of sediment transported. The river carried large
41 amounts of sediment and was known as the "Big Muddy." During high flows, erosion could be
42 severe. As flooding subsided, the river deposited substantial amounts of sediments on flood
43 plains. In a dynamic equilibrium, the river redistributed sediments between its channel and
44 floodplain. The channel was braided to highly sinuous and "characterized by log jams, snags,
45 whirlpools, chutes, bars, cut-off channels, and secondary channels around bars" (National
46 Research Council 2002). Sand bars shifted frequently. "A typical cross-section of the
47 pre-regulation Missouri River contained a deep channel, multiple side channels, oxbow lakes,

Affected Environment

1 islands, sand bars and dunes, and backwater habitats interspersed by areas of higher land.”
2 The seasonal pattern of flow and temperature cued many natural processes, such as fish
3 spawning, insect emergence, and seed germination. The diverse habitat with frequent
4 disturbance supported high biodiversity and biological productivity (National Research Council,
5 2002).

6 In the post-regulation Missouri River, main stem dams dampen the high variation in flows below
7 them, and the extremely high and low flows no longer occur. Dredging and channelization have
8 eliminated much of the temporal and spatial variation. In channelized areas, a typical cross
9 section of the post-regulation Missouri River is trapezoidal rather than varied, and in places,
10 complex. Suspended sediment loads now drop from suspension in the relatively still water of
11 reservoirs behind dams, where clearer water supports greater primary productivity and aquatic
12 species that hunt by vision. Channel degradation occurs below the dams while sedimentation
13 accumulates in reservoirs, and these processes slowly change aquatic habitats. Seasonal cues
14 to biological processes are muted. Fish no longer use floodplains seasonally for spawning and
15 as nursery areas for their young. The water, sediment, and nutrients that once spread across
16 the flood plains are now contained within the channel and reservoirs. In the change from pre-to
17 post-regulation, some aquatic species thrived, and some, such as pallid sturgeon
18 (*Scaphirhynchus albus*) and sauger (*Sander canadense*), experienced sharp reductions.
19 Overall, the less diverse habitat and decreased disturbance of the post-regulation Missouri
20 River support lower biodiversity and lower biological productivity (National Research Council,
21 2002).

22 The biological classifications of its terrestrial ecosystems, land uses, and the distribution of fish
23 in the entire basin and in the main stem illustrate the spatial diversity of the Missouri River. The
24 Missouri River flows through and drains six terrestrial ecoregions: North Central Rockies
25 Forests, Montana Valley and Foothill Grasslands, Northwestern Mixed Grasslands, Northern
26 Mixed Grasslands, Central Tall Grasslands, and the Central Forest/Grassland Transition Zone
27 (Galat et al. 2005b). Within 3 miles (5 km) of the river, however, most of the land use is in
28 cropland (33 percent), grassland (26 percent), and developed land (17 percent) (Galat et al.
29 2005b). Abell et al. (2000, 2008) define three aquatic ecoregions of the Missouri River primarily
30 on the basis of fish distribution: the Upper Missouri, Middle Missouri, and the Central Prairie.

31 Based on geomorphology and hydrology, Galat et al. (2005a and 2005b) recognize three zones
32 of the Missouri River main stem: The upper zone, from the origin of the Missouri River to Fort
33 Peck Lake, Montana, which is the first major impoundment, is unchannelized and largely flows
34 freely; the middle zone, from the upper end of Fort Peck Lake to the Gavins Point Dam, which
35 forms Lewis and Clark Lake, is not channelized but has impoundments, and can be subdivided
36 into a reservoir zone made up of individual impoundments separated by an inter-reservoir,
37 riverine zone that connects them; and the lower zone, from Gavins Point Dam to the confluence
38 with the Mississippi River, is channelized and has bank stabilization and floodplain levees.
39 CNS-1 lies within the lower, channelized zone.

40 2.2.5.4 *Physical Features of the Missouri River near the Cooper Nuclear Station*

41 CNS-1 is located on the west bank of the Missouri River at RM 532.5 (1,960 river miles). The
42 bottom contour of the river at CNS-1 is roughly trapezoidal. The Missouri River channel in front
43 of CNS-1 is at an elevation of about 860 to 865 feet (262 to 265 m) AMSL compared to the
44 natural grade level of the flood plain around CNS-1 of 890 feet (271 m) AMSL. On average, the
45 river is about 800 feet (245 m) wide and 28 feet (8.5 m) deep in the vicinity of CNS-1. Riprap
46 covers some areas of shoreline near the CNS-1, and soft sediments are typically composed of

1 medium to coarse sand. Pile dikes and shoreline protection stabilize the channel. Gavins Point
 2 Dam, located about 200 river miles (322 river kilometers (Rkm)) upstream in Yankton, South
 3 Dakota, largely controls the flow of the Missouri River at CNS-1. The flow changes seasonally,
 4 but the annual mean river flow from 1930 through 2001 was 38,251 cfs (1,083 m³/sec) at the
 5 USGS gauging station located about 30 river miles (48 Rkm) upstream at Nebraska City,
 6 Nebraska. NPPD owns the 345 kV transmission line designated as TL3504 that passes over the
 7 Missouri River at CNS-1; at the center of the Missouri River, transmission line ownership
 8 changes (NPPD, 2008).

9 2.2.5.5 *Potentially Affected Aquatic Resources*

10 Several publications and reviews provide comprehensive descriptions of the Missouri River
 11 aquatic ecosystems, including National Research Council (2002), Galat et al. (2005a, 2005b),
 12 and USACE (2004). From the headwater streams to the main stem Missouri River, aquatic
 13 communities show the affects of man's activities. Rabeni (1996) summarized the state of the
 14 fish and aquatic resources of the prairie ecosystem as follows:

15 The ecological integrity of most prairie streams has been compromised, because
 16 every important relation has been affected: flow conditions by dewatering, altered
 17 land-use, and disruption of headwaters; energy source balance by the increase
 18 of instream primary production with nutrients and less shading; water quality by
 19 modern synthetic compounds and organic wastes; physical habitat by
 20 channelization and riparian degradation; and the biotic balance by the
 21 introduction of fish predators and competitors and elimination of important food
 22 sources.

23 Comparing this description to Karr et al.'s (1985) conceptual model of Midwestern rivers
 24 (Figure 2.2.5-1), one can see that human activities have adversely affected all aspects of the
 25 environment that influence the integrity of aquatic communities.

26 Much of the information summarized below is from a compendium of studies (Hesse et al.,
 27 1982b) conducted in the late 1960s and early 1970s to provide ecological information for
 28 assessing the impacts of Fort Calhoun and Cooper Nuclear Stations, both on the Missouri
 29 River. Fort Calhoun Station is a nuclear generating unit located at river mile marker (RM) 646.0
 30 (1,040 Rkm), about 113.5 river miles (183 Rkm) north of CNS-1, which is located at RM 532.5
 31 (857 Rkm); the aquatic communities at the two stations are similar.

32 2.2.5.6 *Primary Producers: Phytoplankton, Periphyton, and Aquatic Macrophytes*

33 Before the completion of the dams on the main stem, phytoplankton abundance was low due to
 34 the high turbidity and current velocity and the lack of still water habitats. Although dams now
 35 replace lotic habitat with lentic habitat where sedimentation increases water clarity, the limiting
 36 factor for algal growth in much of the river is still light, not nutrients, due to turbidity (Galat et al.,
 37 2005b).

38 Galat et al. (2005a, in Rivers of North America) summarized the ecology of planktonic algae and
 39 cyanobacteria in the Missouri River basin. Most of the information dated from the 1980s or
 40 before. Reetz (1982) reported results of phytoplankton studies conducted in the Missouri River
 41 in the vicinity of CNS-1 and Fort Calhoun (Nuclear) Station, about 113.5 RM (183 Rkm) north of
 42 CNS-1, from 1974 through 1977. The composition of the phytoplankton community through the
 43 year was largely determined by discharges from Lewis and Clark Lake (RM 811, Rkm 1,305),
 44 which is 278.5 river miles (448 Rkm) upstream, with modifications due to "production in
 45 backwater areas of the unchannelized river, production in pools behind the trail dikes in the

1 channelized portion, input of phytoplankton from tributaries, and the scouring of periphytic
2 forms” (Reetz, 1982, p. 73). While the species may have changed over the last several decades
3 since Reetz’s 1982 studies, the process he describes likely remains unchanged. Although Reetz
4 (1982) could discern no clear trend in phytoplankton abundance at CNS-1 for the 1974–1977
5 study period, carbon fixation rates were generally lower in winter and highest in mid-summer.
6 Carbon fixation is the photosynthetic process by which plants convert carbon dioxide (and
7 water) to sugar (and oxygen).

8 Reetz (1982) compared phytoplankton functions at the intake and discharge of both CNS-1 and
9 Fort Calhoun Station. Initial (7-hour) differences in carbon fixation rates at CNS-1 ranged from
10 an average of about 17 percent inhibition during summer to no change during winter. The
11 inhibition in the summer months appeared to depend on absolute discharge temperature and
12 the highest inhibition rates (above 26 percent) occurred when absolute discharge temperatures
13 exceeded 101 °Fahrenheit (38.5 °C). Recovery from initial inhibition at CNS-1 occurred within
14 48 hours. While the river would carry phytoplankton far downstream in 48 hours so that a
15 substantial part of the river would be affected, Reetz (1982) concluded that the low rate of water
16 use by CNS-1 compared to river flow combined with the rapid mixing of the thermal plume
17 would make the effects relatively unnoticeable.

18 Farrall and Tesar (1982) reported results of periphytic algae studies conducted in the Missouri
19 River in the vicinity of CNS-1 from 1972 through 1977, and Fort Calhoun Station from 1974 and
20 1975. Periphytic algae are those algae attached to solid surfaces under water such as rocks,
21 logs, pilings and other structures. Because they remain in one place, periphytic algae colonizing
22 natural and artificial substrata can be used as indicators of environmental effects. Algae fix
23 carbon through photosynthesis and are a base of food webs. In some rivers, such as the
24 Missouri River, organic matter from land and upstream sources is often another base of local
25 aquatic food webs. Farrell and Tesar (1982) did not detect changes in the diversity, density, and
26 biovolume of periphytic algae related to water temperature in the vicinity of CNS-1, although
27 species composition did reflect water temperature. Although these results may generally be
28 indicative of periphyton responses and processes at CNS-1 today, species composition and
29 magnitude of response, which depends on the species involved, may have changed over the
30 decades since Ferral and Tesar’s (1982) studies.

31 High turbidity, unstable substrates, and variable currents almost exclude aquatic macrophytes
32 from the Missouri River (Galat et al. 2005, in Rivers of North America), and NRC staff found no
33 studies of these macrophytes in the vicinity of CNS-1.

34 2.2.5.7 *Invertebrates: Zooplankton and Benthos*

35 Repsys and Rogers (1982) reported results of invertebrate zooplankton studies conducted in
36 the Missouri River in the vicinity of CNS-1 and Fort Calhoun Station from 1972 through 1977.
37 Zooplanktons are animals suspended in the water column and typically contain permanent
38 residents of the water column; temporary members swept up by currents, etc.; and organisms
39 that spend only part of their life cycle in the water column, such as insect and fish eggs and
40 larvae. Zooplankters eat algae and bacteria, protozoans, other zooplankton, detritus, fish eggs
41 and larvae, or a combination of these, and, in turn, are eaten by other invertebrates, fish, and
42 amphibians. In general, zooplanktons are more adapted to the lentic environment of lakes and
43 reservoirs than the lotic environment of streams and rivers. In flowing water environments,
44 currents and suspended sand can buffet zooplankters and cause mechanical damage, while
45 smaller suspended silt and clay particles can adhere to their bodies and interfere with
46 respiration and feeding.

1 Repsys and Rogers (1982) concluded that the zooplankton community near CNS-1 appears to
2 be largely determined by upstream reservoirs, where the lotic environment encourages their
3 production. The most common groups they collected include copepods and cladocerans (both
4 crustaceans) and rotifers. While the general pattern of abundance in the study indicated
5 relatively high crustacean peaks in late fall to spring and reduced populations during summer
6 and early autumn, the pattern was poorly defined. The authors concluded that the seasonality of
7 zooplankton densities in the limnetic Lake Francis Case, which is more like a natural lake and
8 has high zooplankton production, influenced through releases the pattern of zooplankton
9 downstream in the smaller and less productive Lewis and Clark Lake, which in turn influenced
10 through releases the pattern of zooplankton downstream at CNS-1.

11 Decreasing zooplankton densities in the river indicated to them that zooplankton populations
12 originating in the highly productive Lake Francis Case experienced considerable mortality on the
13 downriver journey to CNS-1. Repsys and Rogers (1982) also investigated the effects of CNS-1
14 on zooplankton populations in 1974 through 1978. High absolute discharge temperatures
15 $\geq 95^{\circ}\text{F}$ (35°C) critically affected zooplankton survival, as did duration of exposure. Repsys and
16 Rogers (1982) concluded that entrainment losses were small when compared to the large
17 downstream decreases in zooplankton. Without further studies, NRC staff concludes that these
18 general patterns and processes most likely still occur, although species composition and
19 magnitude of response, which depends on the species involved, may have changed over the
20 decades since Repsys and Rogers' (1982) studies.

21 Carter et al. (1982) reported results of benthic infaunal and epifaunal (called aufwuchs on the
22 artificial substrate samples employed by Carter et al.) invertebrate studies conducted in the
23 Missouri River in the vicinity of CNS-1 and Fort Calhoun Station from 1973 through 1977.
24 Benthic infauna refers to the organisms that live in underwater sediments, and benthic epifauna
25 refers to organisms that live on underwater surfaces. Benthic invertebrates form a complex
26 community. Various members may eat algae filtered from the water column, suspended detritus
27 and organisms, sediments, periphytic algae and bacteria, other benthic organisms, and fish
28 eggs and larvae. Carter et al. (1982) report that the channel area of the Missouri River in the
29 vicinity of CNS-1 is largely unsuitable for macroinvertebrates because of continuous shifting and
30 scouring of bottom sediments. In the lee of wing dikes, sedimentation occurs during periods of
31 low flow and supports infaunal communities that may be lost due to scouring during periods of
32 high flow. The seasonal diversity of the benthic community in this area is inversely related to the
33 variability of the flow as measured on a daily basis (Carter et al., 1982): benthic diversity is
34 higher when flows are stable. The most common members of the benthic community are
35 oligochaete worms, primarily tubificids, which live in tubes and may avoid direct contact with the
36 currents, and secondarily naids, which live in the surface layers of sediments and may be
37 subject to low level scouring. Another numerically important group was insect larvae of the
38 family Chironomidae, or non-biting midges (flies). All of these groups are indicative of
39 organically enriched sediments and tolerate low dissolved oxygen levels and so have been
40 designated as indicators of poor water quality (Barbour et al., 1999).

41 Epifaunal invertebrates in this section of the river are typically found on dikes and riprap. Carter
42 et al. (1982) report that the most common members on dykes and artificial substrate samplers
43 were chironomid, trichopteran (caddisfly), and ephemeropterid (mayfly) larvae. The caddisfly
44 larvae found here are typically net spinners and filter feeders whose survival depends on
45 currents. The chironomid larvae included grazers, predators, and tube-dwellers. The insect
46 larvae are seasonal members of the macroinvertebrate community that become terrestrial after
47 emergence. Carter et al. (1982) were not able to detect consistent changes in the epifaunal
48 invertebrate community due to the operation of CNS-1.

1 2.2.5.8 Larval Fish

2 Hergenrader et al. (1982) report the results of both field and entrainment studies on larval fish in
3 the vicinity of CNS-1 in 1974 through 1976. Several life stages of fish may occur in the plankton,
4 where they are called ichthyoplankton, and may be subject to entrainment at power plants:
5 eggs; larvae, which include both yolk-sac and post yolk-sac larvae and have little or no fin
6 development; post larvae, which have fully developed fins but bodies that have not yet reached
7 the adult form; and juveniles, which have attained the adult form but are still immature. Eggs
8 and juveniles in the collections near CNS-1 were not commonly caught, and made up two
9 percent and one percent, respectively, of all ichthyoplankton. Larval fish were common in the
10 drift near CNS-1 from May through July, and the numerically dominant fish larvae were
11 freshwater drum, catostomids (e.g., suckers), cyprinids (e.g., minnows), and carp. Larval fish
12 were rare or absent in other months. Although freshwater drum comprised only about five
13 percent of adult fish in the vicinity of CNS-1, since they are pelagic spawners, spawning in the
14 open water column, they contributed 70 to 90 percent of the larvae. Other species commonly
15 found as larvae in the drift, common carp (*Cyprinus carpio*), catostomids, gizzard shad
16 (*Dorosoma cepedianum*), and goldeneye (*Hiodon alosoides*), are also either random or pelagic
17 spawners. The larvae of most of the game fish in the area—white bass (*Morone chrysops*),
18 sunfish (*Lepomis* spp.), crappie (*Pomoxis* spp.), sauger (*Stizostedion canadense*), walleye
19 (*Sander vitreus*), and channel catfish (*Ictalurus punctatus*)—were relatively under-represented
20 because most of these fish either build nests or spawn randomly, most have adhesive and
21 demersal (sinking) eggs, and some of these species provide parental care of the eggs and
22 larvae.

23 Depending on the species, the sources of the larvae near CNS-1 included the upstream Louis
24 and Clark Lake, tributaries, cut-off chutes, and backwaters. Densities of ichthyoplankton also
25 depended on time of year, river flow, horizontal position in the river (cutting bank, mid-channel,
26 or filling bank), depth and patterns of vertical migration, and growth and mortality rates
27 (Hergenrader et al., 1982).

28 Hergenrader et al. (1982) also report on entrainment mortality. NRC staff conclude that little can
29 be learned from their direct observations of entrainment mortality because the control mortality
30 measured at the intake was very high, which makes estimation of plant-induced mortality
31 impossible, and because they only observed immediate mortality (typically 20 to 40 minutes
32 after collection), which does not provide an estimate of longer-term or chronic mortality. Injured
33 larvae may not die immediately, and today the standard holding time for fish larvae in short-term
34 chronic toxicity tests with a survival endpoint is typically seven days (EPA, 2002) in order to
35 account for mortality that is not immediate. In order to determine if entrainment (and
36 impingement) were having an effect on the fish populations in the area, Hergenrader et al.
37 (1982) looked for changes in adult fish populations resulting from impacts to ichthyoplankton but
38 detected none. They concluded that either no significant changes occurred or “[t]oo few
39 resources (financial, technical, equipment, labor) were applied over too small a time frame in too
40 restricted an area to detect the changes which have occurred.”

1 2.2.5.9 *Fish*

2 Galat et al. (2005a, 2005b) report about 183 fish species from the Missouri River, of which
 3 about 136 were found in the main channel. No fish species are unique to the main stem (i.e.,
 4 endemic species), and just two are endemic to the Missouri River basin. About three quarters of
 5 Missouri River fish species are native, that is, they live and survive in the river under natural
 6 conditions and have not been introduced by human activity. The majority of the species (68
 7 percent) belong to just five families: Cyprinidae (e.g., carp, chub, dace, shiners, minnows);
 8 Catostomidae (e.g., suckers, chubsuckers, redhorse, buffalo); Salmonidae (e.g., trout, salmon,
 9 whitefish); Centrarchidae (e.g., sunfish; crappies; freshwater basses, but not striped bass and
 10 white bass); and Ictaluridae (e.g., catfish, bullhead, madtom). About half of the species are “Big-
 11 River species,” meaning that they occur primarily in the main channel. Lists of species from the
 12 Missouri River can be found in Galat et al. (2005a) and USACE (2003, as reproduced in the
 13 ER).

14 Galat et al. (2005a) present summary data from which the NRC staff made several
 15 observations. The study lists 53 species as prevalent or common in the Central Lowlands
 16 physiographic province that includes CNS-1. The species were assigned to mutually exclusive
 17 guilds: most (27 spp.) are macrohabitat generalists and the rest distribute evenly between fluvial
 18 specialists and fluvial dependents (12 species each). The generalists may inhabit either
 19 reservoirs or river segments that connect them, while the other two groups are either
 20 specialized for or dependent on flowing river habitat. The high proportion of generalists reflects
 21 the variability and history of continued change in the Missouri River system. In terms of habitat,
 22 46 of the prevalent fish species in the Central Lowlands have been found in the channel and
 23 channel borders, 9 in floodplains, and 8 in reservoirs, including the species that can be found in
 24 more than one of these habitats. The high proportion found in the channel and channel border
 25 reflects the history of the river as a flowing water body before regulation and formation of
 26 reservoirs. With the main channel and channel borders, 35 species are associated with the main
 27 channel, 9 with channel borders, and 8 are “waifs,” that is, removed from their original habitats.

28 CNS-1 is located below the Gavins Point Dam, the last of the six major dams, in a riverine
 29 environment that extends unimpeded to the mouth of the Missouri River at St. Louis. The upper
 30 section of this reach is unchannelized north of Sioux City, Iowa with such diverse habitat
 31 characteristics as chutes, backwater marshes, sandbars, islands, snags, deep pools, and
 32 variable current velocities. The environment is changing due to the downstream effects of
 33 Gavins Point Dam and the sedimentation that occurs behind it as well as some armoring of the
 34 riverbed and bank stabilization, which cause channel degradation and siltation of shallow areas,
 35 with associated loss of marshes, backwaters and chute habitats (USACE, 2004, p.100).
 36 Downstream of Sioux City, construction of dikes, revetments and channelization result in a less
 37 diverse environment. Yet, the most common fish species are similar in the unchannelized and
 38 channelized portions of the river. These include emerald shiner (*Notropis antheroides*), river
 39 carpsucker (*Carpionodes carpio*), channel catfish (*Ictalurus punctatus*), gizzard shad (*Dorosoma*
 40 *cepedianum*), red shiner (*Notropis lutrensis*), shorthead redhorse (*Moxostoma macrolepidotum*),
 41 common carp (*Cyprinus carpio*), and goldeye (*Hiodon alosoides*). Big river fish in the lower river
 42 and its major tributaries include pallid (*Scaphirhynchus albus*), shovelnose sturgeon
 43 (*Scaphirhynchus albus*), and paddlefish (*Polyodon spathula*) (USACE, 2004).

44 The aquatic community, particularly the fish community, may not be stable and may still be
 45 changing in response to historical changes in land use, river regulation, and other human
 46 activities. For example, USACE (2004) reports that the benthic fish community appears to be
 47 changing based on 1996 and 1997 studies. The diversity of species in the unchannelized

1 section appears to be increasing, possibly due to the diverse habitats. Typically more species
2 are found at shallow depth (less than 2 meters) and slower water velocities (less than
3 0.6 m/sec), and fish in the unchannelized section are most abundant in the backwater areas. In
4 the channelized segment below Sioux City, most fish near revetments and dikes. Although
5 surveys have found the most fish in this segment in side channels, but few such habitats
6 remain. USACE (2004) reported that ecologists know very little of the mechanisms that control
7 fish production in the channelized segment of the river.

8 Other investigators have reached similar conclusions. Rabeni (1996) found that “[d]rastic
9 changes in the streams and rivers of the prairie region and their fish fauna have occurred in the
10 last 150 years.” More recently, NRC (2003) reported that:

11 The aquatic resources in the vicinity of Fort Calhoun Station are associated with
12 the Missouri River. The species composition of the fish community in this reach
13 of the river has changed significantly (due to channelization) from the 1973 to
14 1977 fish studies associated with the initial licensing of Fort Calhoun Station and
15 its operations.

16 **2.2.6 Terrestrial Resources**

17 The CNS-1 site is located within the Missouri alluvial plains level IV ecoregion in Nebraska and
18 Missouri, and lies near the western limit of a relatively flat, 6-mile-wide (10 km) alluvial
19 floodplain. Natural relief on the CNS-1 site is limited to about 10 feet (3 m). Much of this
20 floodplain has been ditched and drained for farming, with numerous levees constructed for flood
21 protection. Immediately west of the CNS-1 site and running north-south are bluffs rising
22 approximately 170 feet (52 m) above the CNS-1 property and the Missouri River (NPPD, 2008)
23 that transition into the Nebraska/Kansas loess hills level IV ecoregion (USGS, 2001).

24 According to the ER, the CNS-1 facilities are located within 55 acres (22 ha) of a 1,121-acre
25 (454 ha) site in Nemaha County, Nebraska, adjacent to the western bank of the Missouri River
26 at RM 532.5. There is an additional 239 acres (97 ha) of undeveloped CNS-1 property across
27 the Missouri River and adjacent to its east bank in Atchison County, Missouri. The CNS-1
28 property in Nebraska is bordered on the west by Nemaha County Road 648A Avenue, the
29 Missouri River on the east, and by agricultural lands on the north and south sides. The CNS-1
30 property in Missouri is adjacent to the eastern bank of the Missouri River and is bordered by
31 cropland on its north, south, and east sides (Figure 2.2.1-1) (NPPD, 2008).

32 On the Nebraska side of the CNS-1 site, approximately 900 acres (364 ha) are currently used
33 for agricultural activities. There are also more than 120 additional acres (49 ha) of vegetated,
34 non-agricultural land located primarily contiguous with the riverbank but extending inland in
35 some areas into the farm fields on the site. Most of these vegetated areas are classified as
36 palustrine forested, scrub-shrub, and emergent wetlands (USFWS, 2009a) and include two
37 segments of intermittent streams and, according to NPPD staff, a 55-acre (22 ha) wetland
38 mitigation site. One wetland area is located in the middle of a farm field in the south-central part
39 of the property (Figure 2.2.6-1). The USFWS has identified over 700 wetlands within a 6.0-mile
40 (10 km) radius of CNS-1 (USFWS, 2007b). The remaining acreage on the Nebraska side
41 includes the riverbank, streams and canals, and transmission line corridors. Several segments
42 of intermittent streams are subject to plowing, which may impact wetland resources (NPPD
43 2008a). NPPD staff noted that these intermittent streams drain south from the CNS-1 site into
44 the adjacent USACE Langdon Bend Wetlands Restoration Project and into the Little Nemaha
45 River, and finally into the Missouri River (NDNR, 2009). The Langdon Bend project is one

1 component of the larger Missouri River Mitigation Project (USACE, 2004b). Additional surface
2 water at the CNS-1 site drains from the wetlands and fields directly into the Missouri River by
3 way of manmade drainage ditches and into the Little Nemaha River by way of the intermittent
4 tributary system. However, NPPD staff indicated that the farm fields and wetland areas still
5 flood, primarily from overland drainage, and occasionally because of overbank flow from the
6 Missouri River.

7 NPPD staff indicated that a system of levees on the Nebraska side of the CNS-1 site is
8 designed to protect the CNS-1 reactor and support buildings from a 200-year flood event.
9 Additional levees have been constructed along both sides of the Missouri River floodplain
10 through the entire CNS-1 site. Levee construction on the Missouri River was initiated in 1945 as
11 part of a Federal project implemented in 1912 to deepen and widen the Missouri River for
12 navigation purposes. Earthen levees were constructed along the eastern border of the CNS-1
13 property located in Missouri.

14 On the Nebraska side of the river, the alluvial bottomland and rolling floodplains are dominated
15 by cottonwood (*Populus deltoides*), green ash (*Fraxinus pennsylvanica*), boxelder (*Acer*
16 *negundo*), elm (*Ulmus spp.*), lowland tallgrass prairie, big bluestem (*Andropogon gerardii*),
17 prairie cordgrass (*Spartina pectinata*), switchgrass (*Panicum virgatum*) and several sedges
18 (USGS, 2001).

19 In Missouri on the CNS-1 property, approximately 200 acres (81 ha) of the 239 acres (97 ha)
20 are classified as palustrine forested wetlands and flood periodically. NRC staff noted during the
21 site audit evidence of flood water from the Missouri River reaching over four feet high on some
22 trees on the Missouri side of the CNS-1 property. The two transmission line corridors running
23 east-west through the Missouri property (not in scope) are primarily emergent wetlands where
24 the transmission lines do not cross cropland. Less than 40 acres (16 ha) of the 239 acres (97
25 ha) have been cleared and are used for agricultural activities (NPPD, 2008).

26 The forested riparian areas on the Missouri side of the CNS-1 property are dominated by
27 cottonwood, American sycamore (*Platanus occidentalis*), silver maple (*Acer sacharrinum*), black
28 willow (*Salix nigra*), boxelder, buttonbush (*Cephalanthus occidentalis*), and false indigo
29 (*Amorpha fruticosa*) (NRCS, 2007). The two transmission line corridors located on the Missouri
30 side are dominated primarily by emergent wetlands vegetation, similar to the grasses described
31 on the Nebraska side, as well as some scrub-shrub wetlands vegetation.


32 Several exotic invasive plant species are located along the riverbank of the CNS-1 site, and
33 include purple loosestrife (*Lythrum salicaria*) and reed canary grass (*Phalaris arundinacea*)
34 (NRCS, 2007). The common reed (*Phragmites australis*) is another exotic invasive species
35 found along the riverbank in the vicinity of the CNS-1 site that was recently added to the list of
36 noxious weeds by the Nebraska Department of Agriculture (NDA, 2008).

37 While much of the CNS-1 site and vicinity is agricultural land, there are a number of wooded
38 areas and hedgerows that provide habitat for several species of mammals common to this
39 region, including coyote (*Canis latrans*), white-tailed deer (*Odocoileus virginianus*), raccoon
40 (*Procyon lotor*), eastern cottontail rabbit (*Sylvilagus floridanus*), muskrat (*Ondatra zibethicus*),
41 mink (*Mustela vison*), bobcat (*Lynx rufus*), mice (Bailey, 2007).

42 The CNS-1 site provides habitat to a variety of game birds and resident and neo-tropical
43 migratory songbirds primarily along the transmission line corridor and within the wooded
44 wetland and scrub-shrub habitat on both sides of the river, some of which were observed by

Affected Environment

1 NRC staff during the site audit. Species of game birds that are commonly found in the vicinity of
2 CNS-1 include the northern bobwhite quail (*Colinus virginianus*), the ring-necked pheasant
3 (*Phasianus colchicus*), the wild turkey (*Meleagris gallopavo*), and the greater prairie chicken
4 (*Tympanuchus cupido*). Other birds commonly found on CNS-1 property and the transmission
5 line corridor include cliff swallows (*Petrochelidon pyrrhonota*), the American kestrel (*Falco*
6 *sparverius*), the turkey vulture (*Cathartes aura*), the killdeer (*Charadrius vociferus*), the horned
7 lark (*Eremophila alpestris*), and the American bald eagle (*Haliaeetus leucocephalus*) (Bailey,
8 2007; UNSM, 2007a). There is an active bald eagle nest on the Missouri side of the CNS-1
9 property with a breeding pair of eagles that have produced a number of chicks over the past
10 several years (NPPD, 2008). Although no longer protected under the ESA, the bald eagle is still
11 protected from any take without a permit under the Bald and Golden Eagle Protection Act (50
12 CFR Part 22) (NPPD, 2008).



13
14 **Figure 2.2.6-1. Nontidal Wetlands Located on the Cooper Nuclear Station, Unit 1, Site**
15 (Source: USFWS, 2009a; National Wetlands Inventory; Nemaha Quad; NPPD, 2008a). (Note
16 that the wetlands polygon is approximate, and includes the 55-acre (22-ha) NPPD wetlands
17 mitigation site.)

18 The CNS-1 is located along an overlapping section of the Mississippi and Central Flyways, with
19 20 waterfowl species following the Missouri River during fall and spring migrations. These
20 waterfowl may utilize the wetlands located on the CNS-1 site (NPPD, 1971) and its vicinity. The
21 ER contains information on observed bird mortality at CNS-1 from 2003–2006, including a great

1 horned owl (*Bubo virginianus*), three additional birds, and the death in 2006 from West Nile
 2 Virus of a juvenile bald eagle found near CNS-1 (NPPD, 2008).

3 Several amphibians and reptiles are found or are potentially found in the vicinity of CNS-1 and
 4 the transmission line corridor. Reptiles include the painted turtle (*Chrysemys picta*), the common
 5 snapping turtle (*Chelydra serpentina*), the eastern rat snake (*Elaphe obsoleta*), two species of
 6 garter snakes (*Thamnophis* spp.), and the prairie kingsnake (*Lampropeltis calligaster*).
 7 Amphibians include the Cope's gray treefrog (*Hyla chrysoscelis*), the northern cricket frog (*Acris*
 8 *crepitans*), the northern leopard frog (*Rana pipiens*), and the bullfrog (*Rana catesbeiana*)
 9 (UNSM, 2007b).

10 **2.2.7 Protected Species**

11 National Marine Fisheries Service (NMFS) and USFWS are responsible for listing aquatic and
 12 terrestrial species as threatened and endangered at the Federal level, as delegated by the ESA.
 13 The State may list additional species that are regionally threatened or endangered. For the
 14 purposes of this Supplemental EIS, we have included all Federally and State-listed species that
 15 occur or potentially occur in Nemaha County, Nebraska (the location of CNS-1) and Johnson,
 16 Gage, Lancaster, Saline, Fillmore, York, Hamilton, and Merrick Counties, Nebraska, as well as
 17 Atchison County, Missouri (Illinois Wildflowers, 2009; Kansas Wildflowers and Grasses, 2009;
 18 MOBOT, 2009; MDC, 2009b; MDC, 2009c; Missouri Plants, 2007; NatureServe, 2009d;
 19 NatureServe, 2009e; NGPC, 2008; NGPC, 2009c; NPPD, 2008a; NRCS, 2009; USFWS, 2008a;
 20 USFWS, 2009b; USGS, 2006; USGS, 2008; UWYO, 2002), where transmission line corridors
 21 associated with CSN-1 lie (Table 2.2.7-1). On January 15, 2008, the NPPD contacted the
 22 USFWS regional offices in Nebraska and Missouri, the NGPC, and the MDC regarding any
 23 concerns these Federal and State natural resources agencies may have as a result of the
 24 license renewal action as CNS-1. The NGPC has not commented upon potential impacts to
 25 Federally or State-listed threatened or endangered species, but has provided an updated list of
 26 Nebraska species of concern (NGPC, 2009c).

27 **Table 2.2.7-1. Listed Aquatic and Terrestrial Species**

28 *The species listed are Federally-listed, Nebraska-listed and/or Missouri-listed as threatened,*
 29 *endangered, or State species of concern (SC). State SC may be further classified as S-1, S-2,*
 30 *S, or SX as described at the bottom of this table. The listed species may occur on the CNS-1*
 31 *site or in its vicinity, within the Missouri River, or within the transmission line corridors.*
 32

Scientific Name	Common Name	Federal Status ^a	State Status ^{b,c}	Habitat
Fish				
<i>Acipenser fulvescens</i>	Lake sturgeon	-	T (NE)	Large turbid rivers
<i>Cycleptus elongates</i>	Blue sucker	-	T (NE)	Rivers
<i>Fundulus zebrinus</i>	Plains killifish	-	SC (MO)	Streams and lakes
<i>Hybognathus argyritis</i>	Western silvery minnow	-	SC (MO)	Creeks and backwaters
<i>Hybognathus placitus</i>	Plains minnow	-	SC (MO)	Perennial plains streams

Affected Environment

Scientific Name	Common Name	Federal Status ^a	State Status ^{b,c}	Habitat
<i>Macrhybopsis meeki</i>	Sicklefin chub	-	T (NE)	Free-flowing rivers with high turbidity
<i>Macrhybopsis gelida</i>	Sturgeon chub	-	E (NE)	Free-flowing rivers with high turbidity
<i>Platygobio gracilis</i>	Flathead chub	-	E (MO)	Main stem Missouri River and small streams
<i>Scaphirhynchus albus</i>	Pallid sturgeon	E	E	Main stem Missouri and Mississippi rivers
Reptiles and Amphibians				
<i>Agkistrodon contortrix</i>	Copperhead	-	S2 (NE)	In or near deciduous forest in hilly situations; vicinity of rock outcrops; floodplains; mesic situations near water in the arid west.
<i>Ambystoma texanum</i>	Smallmouth salamander	-	S1 (NE)	Adults migrate from upland, mesic forests to breed in fishless, seasonal, and semipermanent wetlands.
<i>Carphophis vermis</i>	Western wormsnake	-	S2 (NE)	Woodlands; forest edge; moist, rocky, hillsides; riparian corridors in prairies; burrowing in or using soil, fallen logs, debris.
<i>Crotalus horridus</i>	Timber rattlesnake	-	S1 (NE)	Riparian; forested and scrub-shrub wetlands; high, dry ridges; hilltop rock outcrops in thick woods.
<i>Elaphe vulpina vulpine</i>	Western fox snake	-	E (MO)	Farmlands, prairies, stream valleys, woods, and dune habitats.
<i>Eumeces obsoletus</i>	Great plains skink	-	S2 (MO)	Open plains; rolling grasslands with few trees and scattered rocks. Takes refuge under rocks, logs; other cover.
<i>Lampropeltis calligaster</i>	Yellow-bellied kingsnake	-	S2 (NE)	Prairies, (including sand prairies), open grassland, forest edge; fields; ditches; woodlands; stream valleys and bluffs.
<i>Lampropeltis getula</i>	Common kingsnake	-	S1 (NE)	Open coniferous forest; prairie; desert; woodland; swamps; coastal marshes; river bottoms; farmland; chaparral.
<i>Liochlorophis vernalis</i>	Smooth green snake	-	S1 (NE) SX (MO)	Meadows, grassy marshes, moist grassy fields at forest edges, stream borders; mountain shrublands, bogs, abandoned farmland; vacant lots. Extirpated in MO.

Scientific Name	Common Name	Federal Status ^a	State Status ^{b,c}	Habitat
<i>Ophisaurus attenuatus</i>	Slender glass lizard	-	S1 (NE)	Open grassland; prairie; open and woodland edge; scrubby areas; fallow fields; near streams and ponds; often in habitats with sandy soil.
<i>Rana pipiens</i>	Northern leopard frog	-	S2 (MO)	Springs, slow streams, marshes, bogs, ponds, canals, flood plains, reservoirs, and lakes; permanent water with rooted aquatic vegetation; wet meadows and fields. Overwinters usually underwater.
<i>Regina grahamii</i>	Graham's crayfish snake	-	S2 (NE)	Sluggish and still waters and their vegetated margins; marshes, swamps; roadside ditches.
<i>Sistrurus catenatus</i>	Massasauga rattlesnake	-	T (NE) E (MO)	Wetlands, grassland/herbaceous, old field, savanna, shrubland/chaparral, woodlands.
<i>Thamnophis proximus</i>	Western ribbonsnake	-	S2 (NE)	Semiaquatic. Wide range shrubby habitats near lakes, ponds, sloughs, ditches, swamps, and marshes.
Birds				
<i>Ammodramus henslowii</i>	Henslow's sparrow	-	S2 (NE)	Grassland; open fields and meadows; shrubby vegetation; damp or low-lying areas.
<i>Bonasa umbellus</i>	Ruffed grouse	-	SX (NE)	Presumed extirpated. Dense forest with some deciduous trees; both wet and relatively dry situations.
<i>Charadrius melodus</i>	Piping plover	T	T (NE)	Sandy upper beaches with sparse vegetation, sparsely vegetated shores and islands of shallow lakes, ponds, rivers, and impoundments.
<i>Falco peregrinus</i>	Peregrine falcon	-	S1 (NE) S1 (MO)	Various open situations with suitable nesting cliffs; tall buildings with ledges. Non-breeding – occurs in farmlands, marshes, lakeshores, river mouths, tidal flats, urban areas.
<i>Grus American</i>	Whooping crane	E	E (NE)	Wetlands, wet meadows, sandbars and shallow water in rivers.
<i>Lanius ludovicianus</i>	Loggerhead shrike	-	S2 (MO)	Open country with scattered trees and shrubs, savanna, desert scrub, open woodland; often perches on poles, wires or fence posts.

Affected Environment

Scientific Name	Common Name	Federal Status ^a	State Status ^{b,c}	Habitat
<i>Laterallus jamaicensis</i>	Black rail	-	S1 (NE) S1 (MO)	Breeding and non-breeding: shallow portions of salt, brackish, and freshwater marshes; pond borders; wet meadows; and grassy swamps.
<i>Numenius borealis</i>	Eskimo curlew	E	SX (NE)	Possibly extinct. Non-breeding: grasslands; pastures; plowed fields; and less frequently, marshes and mudflats. Nests in open Arctic tundra.
<i>Rallus elegans</i>	King rail	-	S1 (NE) S1 (MO)	Freshwater marshes, upland-wetland marsh edges, flooded farmlands, shrub swamps.
<i>Sterna antillarum athalassos</i>	Interior least tern	E	E (NE) S1 (MO)	Bare sand bars and sandy shorelines of large rivers, lakes and sand pits.
<i>Strix varia</i>	Barred owl	-	S2 (NE)	Dense woodland and forest, swamps, wooded river valleys.
<i>Thryothorus ludovicianus</i>	Carolina wren	-	S2 (NE)	Open deciduous woodland; thickets; undergrowth; parks; forest edge; pine barrens; shrubbery of residential areas.
<i>Tryngites subruficollis</i>	Buff-breasted sandpiper	-	S1 (NE)	Migratory through NE. Short grass plains and dry uplands. Man-altered habitats – fields; golf courses; runways.
Mammals				
<i>Glaucomys volans</i>	Southern flying squirrel	-	T (NE)	Red oak-basswood-ironwood forest.
<i>Lontra canadensis</i>	River otter	-	T (NE)	Streams, lakes, ponds, swamps, marshes, estuaries (in some areas), exposed outer coast.
<i>Microtus pinetorum</i>	Woodland vole	-	S1 (NE)	Wide variety of habitats; prefers upland wooded areas with thick layer of loose soil and humus in shallow burrows.
<i>Mustela nigripes</i>	Black-footed ferret	E	E (NE)	Limited to open habitat and burrows used by prairie dogs; grasslands and shrub steppe.
<i>Perognathus flavescens</i>	Plains pocket mouse	-	S2 (MO)	Tallgrass prairie, sandy-loose soil prairies.
<i>Spermophilus franklinii</i>	Franklin's ground squirrel	-	S2 (MO)	Tallgrass and mid-grass prairies; riparian areas; forest-field edges, fields, hedgerows, unmowed strips of railroad rights-of-way and roadsides.
<i>Spilogale putorius interrupta</i>	Plains spotted skunk	-	S1 (NE) E (MO)	Forested areas; habitats with significant cover; open and brushy areas; rocky canyons and outcrops in woodlands and prairies

Scientific Name	Common Name	Federal Status ^a	State Status ^{b,c}	Habitat
<i>Myotis sodalis</i>	Indiana bat	E	E (MO)	Hibernates in caves; foraging habitats include riparian areas, upland forests, ponds, and fields.
Insects				
<i>Atrytone arogos iowa</i>	Iowa skipper	-	S1 (NE)	Short grass prairie in Colorado to mesic or dry tall grass prairie.
<i>Cicindela nevadica lincolniana</i>	Salt Creek tiger beetle	E	E (NE)	Eastern Nebraska saline wetlands and their associated streams.
<i>Cicindela togata</i>	White-cloaked tiger beetle	-	S1 (NE)	Very open saline areas far from vegetation. Salt flats, salt marshes, saline lakeshores.
<i>Melanoplus packardii</i>	Packard's grasshopper	-	S2 (MO)	Bare, somewhat grassy beaches; sandy woods, always on dry sand and not on vegetation.
<i>Nicrophorus americanus</i>	American burying beetle	-	S1 (NE) SH (MO)	Broad vegetational tolerances. Mature forest; grassland; old field shrubland.
Plants				
<i>Agalinis purpurea</i>	Large-purple false foxglove	-	S1 (NE)	Moist sand prairies; sandy savannas, paths and openings in sandy woodlands; boggy areas; occasional disturbance.
<i>Anagallis minima</i>	Chaffweed	-	S1 (NE)	Bare damp ground, by roadsides.
<i>Anemone cylindrical</i>	Thimbleweed	-	S2 (MO)	Dry open woods, slopes, prairies, along railroad grades.
<i>Arisaema dracontium</i>	Green dragon	-	S2 (NE)	Moist deciduous woodlands; shady seeps; and wooded areas adjacent to springs and vernal pools.
<i>Arnoglossum atriplicifolium</i>	Pale Indian-plantain	-	S2 (NE)	Full to partial sun; prairies, woods; in sandy, loamy soil.
<i>Asclepias amplexicaulis</i>	Clasping milkweed	-	S1 (NE)	Prairies; glades; rocky open woods; roadsides; railroads.
<i>Asclepias purpurascens</i>	Purple milkweed	-	S1 (NE)	Rocky open woods, glades; prairies; stream banks; wet meadows; valleys; thickets; roadsides.
<i>Astragalus lotiflorus</i>	Low milk vetch	-	S2 (MO)	Dry native prairie in areas where the shortgrasses like blue grama grow.
<i>Bidens polylepis</i>	Awnless beggar-ticks	-	S2 (NE)	Wet prairies and meadows; swampy woods; roadsides; disturbed grounds.
<i>Blephilia hirsuta</i>	Hairy Woodmint	-	S1 (NE)	Rich, moist, shady woods, slopes and valleys.

Affected Environment

Scientific Name	Common Name	Federal Status ^a	State Status ^{b,c}	Habitat
<i>Bouteloua gracilis</i>	Blue grama	-	S1 (MO)	Dryish soils on upland short grass prairies and along railroad tracks.
<i>Bouteloua hirsute var. hirsuta</i>	Hairy grama	-	S2 (MO)	Shortgrass prairies.
<i>Brachyelytrum erectum</i>	Bearded shorthusk	-	S2 (NE)	Mesic upland forests; bottomland forests; occasional dry upland forest.
<i>Buchloe dactyloides</i>	Buffalo grass	-	SH (MO)	Possibly extirpated
<i>Carex bushii</i>	Bush's sedge	-	S1S2 (NE)	Moist prairies, fields, and meadows in full sun (ODNR 1998).
<i>Carex crus-corvi</i>	Ravenfoot sedge	-	S1 (NE)	Wet meadows and swamps (MSU 2007).
<i>Carex frankii</i>	Frank's sedge	-	S1S2 (NE)	Edges of wet woods; seasonally wet meadows (USU 2006).
<i>Carex sprengei</i>	Longbeak sedge	-	S1 (MO)	Moist soil on bottomlands and streambanks; cliffs and rocky slopes.
<i>Castilleja sessiliflora</i>	Downy painted cup	-	S2 (MO)	Dry prairies and rocky hillsides.
<i>Coeloglossum viride</i>	Long-bract Green orchis	-	S1 (NE)	Sub-arid soil in damp open woods; mesic to wet woodlands, thickets and shrub boarders; disturbed areas.
<i>Corallorhiza wisteriana</i>	Spring coralroot	-	S1 (NE)	Terrestrial in moist hardwood forests and hammocks. Mycorrhizal with fungi.
<i>Cornus racemosa</i>	Gray dogwood	-	S1 (NE)	Thickets and moist soil in riparian zones, roadsides, on sandy slopes and limestone ridges.
<i>Corydalis aurea</i>	Golden Corydalis	-	S1 (NE)	Rocky or sandy soils along lakes or ponds or in open woods.
<i>Cypripedium calceolus</i>	Yellow lady's-slipper	-	S1 (NE)	Rich, humus and decaying leaf litter in wooded areas, often on rocky wooded hillsides.
<i>Cypripedium candidum</i>	Small white lady's slipper	-	T (NE) S1 (MO)	Mesic/wet blacksoil prairie; glacial till hill prairie, sedge meadow, glade. Calcareous soils. Extirpated/possibly extirpated in MO.
<i>Dalea enneandra</i>	Nine-anther dalea	-	S2 (MO)	Grassland and prairie.
<i>Dasistoma macrophylla</i>	Mullein foxglove	-	S1 (NE)	Rich woodlands, often along streams.
<i>Desmodium cuspidatum</i>	Toothed tick-trefoil	-	S2? (NE)	Dry or rocky woods; thickets; bluffs; base of slopes; ridges; ravines; valleys.

Scientific Name	Common Name	Federal Status ^a	State Status ^{b,c}	Habitat
<i>Dracocephalum parviflorum</i>	American dragonhead	-	S1 (NE)	Woodland; shrublands; openings.
<i>Eleocharis atropurpurea</i>	Purple spikerush	-	S1 (NE) S1 (MO)	Banks; hammocks; irrigation ditches; lake and pond margins.
<i>Eleocharis wolfii</i>	Wolf's spikerush	-	S2 (NE)	Marshes, wet to wet-mesic prairies, wetland margins; wet ditches, sandy roadsides, mud flats.
<i>Erysimum inconspicuum</i>	Small-flower prairie wallflower	-	S2 (NE)	Dry native prairie; found where grazing is light or moderate.
<i>Erythronium mesochoreum</i>	Midland fawnlily	-	S2 (NE)	Prairies and open woods; occasionally found in cut-over woods.
<i>Galearis spectabilis</i>	Showy orchis	-	S1 (NE)	Floodplains.
<i>Gastrophryne olivacea</i>	Great Plains narrowmouth toad		S2 (NE)	Variable. Creeks; pools; temporary pools; grasslands; rocky wooded hills; rotten logs; burrows under rocks.
<i>Gentiana alba</i>	Yellow gentian	-	S1 (NE)	Mesic black soil prairies; upland forests; rocky bluffs.
<i>Helianthemum bicknellii</i>	Plains frostweed	-	S1S2 (NE)	Sandy soil of open woodlands and prairie areas.
<i>Heliotropium curassavicum</i> var. <i>curassavicum</i>	Seaside Heliotrope	-	S1 (NE) S1 (MO)	Dry or moist saline and alkaline areas; seasonal flooding.
<i>Isoetes melanopoda</i>	Blackfoot quillwort	-	S1 (NE)	Submerged or in wet soil of swales and temporary ponds.
<i>Lactuca tatarica</i> var. <i>pulchella</i>	Blue lettuce	-	S1 (MO)	Plains, foothills, montane; meadows, roadside ditches.
<i>Lespedeza violacea</i>	Violet bush-clover	-	S1 (NE)	Edges of open upland woods, roadsides; thickets; rocky prairies; dry, rocky soils.
<i>Leucospora multifida</i>	Narrowleaf paleseed	-	S1 (NE)	Shores and stream banks, often where sandy.
<i>Liatris squarrosa</i> var. <i>hirsuta</i>	Glades gayfeather	-	S1? (NE)	Diverse; including dry, sandy, upland prairies.
<i>Melica nitens</i>	Three-flower melicgrass	-	S1 (NE)	Open woods; moist canyon slopes; canyon bottoms; roadsides; rocky grasslands; streambanks.
<i>Monotropa uniflora</i>	Indian-pipe	-	S1 (NE)	Non-green herb parasitic on roots of pines.
<i>Neeragrostis reptans</i>	Hairy creeping lovegrass	-	S1 (NE) SH (MO)	Wet sandy or muddy stream banks and alluvial bar.
<i>Nothocalais cuspidate</i>	Prairie dandelion	-	S2 (MO)	Dry upland areas of prairies, hill prairies, and rocky slopes.
<i>Nymphaea odorata</i>	American water-lily	-	S2 (NE)	Lakes; lake margins; ponds; quiet bays in lakes and rivers; slow-moving streams; ponds.

Affected Environment

Scientific Name	Common Name	Federal Status ^a	State Status ^{b,c}	Habitat
<i>Orobanche uniflora</i>	One-flowered broomrape	-	S1 (NE)	Parasitic. Wooded slopes; lowland; rocky base of bluffs.
<i>Oxytropis lambertii</i> var. <i>lambertii</i>	Locoweed	-	S2 (MO)	Extirpated/possibly extirpated.
<i>Packera glabella</i>	Grassleaf ragwort		S1 (NE)	Moist-to-wet habitat. (UT 2009)
<i>Panax quinquefolium</i>	American ginseng	-	T (NE)	Rich, cool, moist but not extremely wet woods, under a closed canopy; slopes; ravines.
<i>Paronychia canadensis</i>	Forked nailwort	-	S1 (NE)	Dry sandy or rocky places.
<i>Pediomelum argophyllum</i>	Silvery psoralea	-	S2 (MO)	Moist prairies, rocky hillsides, lowlands, stream valleys, and open woodlands.
<i>Pellaea atropurpurea</i>	Purple-stem cliffbrake	-	S2 (NE)	Crevices of rock outcrops, bluffs and boulders; sinkholes; dry soils adjacent to dolomite glades.
<i>Penstemon grandiflorus</i>	Large beard-tongue	-	S1 (MO)	Prairie bluffs in open grassy places.
<i>Penstemon tubiflorus</i>	White-wand beardtongue	-	S1 (NE)	Rich loam or sand loam soil from open prairies to deciduous forests; disturbed areas; rocky glades; along railroads.
<i>Platanthera praeclara</i>	Western prairie fringed orchid	T	T (NE) E (MO)	Tallgrass prairie; moist, calcareous or subsaline prairies and sedge meadows (many flooded for a period of 1-2 weeks during the year).
<i>Podophyllum peltatum</i>	Mayapple	-	S2 (NE)	Rich cove forests; mesic hardwood forests; low topographic positions.
<i>Quercus alba</i>	White oak	-	S1 (NE)	Deciduous forests; mesic; bottomland soil.
<i>Ruellia strepens</i>	Limestone wild petunia	-	S2 (NE)	Moist woods, around ponds and lakes, along streams.
<i>Salicornia rubra</i>	Western glasswort	-	S1 (NE)	Saline or alkaline soil of flats, shores, seepage areas and ditches.
<i>Schoenoplectus saximontanus</i>	Rocky Mountain bulrush	-	S1 (NE) S1 (MO)	Damp soils to emergent, freshwater ponds; ditches, often drying; disturbed and sandy areas.
<i>Senna marilandica</i>	Maryland senna	-	S1S2 (NE)	Prairie ravines, open woods, thickets, disturbed areas, and bases of slopes and bluffs; dry, gravelly soils.
<i>Sparganium chlorocarpum</i>	Greenfruit bur-reed	-	S2 (NE)	Shallow water or mud of marshes, streams, ditches and ponds, where the water is fairly fresh.

Scientific Name	Common Name	Federal Status ^a	State Status ^{b,c}	Habitat
<i>Spiranthes vernalis</i>	Twisted ladies'-tresses	-	S2? (NE)	Moist open areas, meadows, swales, bogs.
<i>Symphoricarpos occidentalis</i>	Wolfberry	-	S1 (MO)	Open prairies, and moist, low ground around streams or lakes.
<i>Trifolium reflexum</i>	Buffalo clover	-	S1 (NE)	Rocky open woods; glades; old fields; prairies.
<i>Triodanis perfoliata var. biflora</i>	Claspingleaf Venus'-looking-glass	-	S1 (NE)	Dry sandy or gravelly prairies, pastures, waste ground, and occasionally woodlands.
<i>Verbena simplex</i>	Narrowleaf vervain	-	S1 (NE)	Dry, open waste areas, rocky prairie hillsides, and roadsides.
<i>Veronicastrum virginicum</i>	Culver's-root	-	S1 (NE)	Varied habitats. Moist tallgrass prairie and prairie remnants, moist woods, woodland borders, thickets, fields and meadows, stream banks and terraces.
<i>Viola palmata</i>	Palmate-leaved violet	-	S2 (NE)	Dry upland woodlands, rocky wooded slopes, and thinly wooded bluffs.
<i>Vitis cinerea</i>	Pigeon grape	-	S1 (NE)	Low woods, floodplains, along streams, marshes, bottomlands.
<i>Yucca glauca</i>	Small soapweed yucca	-	S2 (MO)	Loess hill prairies.

1 ^a E = Endangered; T = Threatened
2 ^b NE = Nebraska; MO = Missouri
3 ^cS = State listing; S1 = critically imperiled; S2 = imperiled; SX - presumed extirpated; SH - possibly extirpated. Note
4 that S3 species ("vulnerable") are not included in this list in order to maintain a less-expansive list.
5 Sources: NGPC, 2008; NGPC, 2009c; MDC, 2009b; MDC, 2009c; USFWS, 2008a; USFWS, 2009b; University of
6 Wisconsin (UW), 2009.

1 2.2.7.1 *Aquatic Species*

2 Table 2.2.7-1 presents aquatic species that are listed as protected by the USFWS, the State of
3 Nebraska, and the State of Missouri that have the potential to occur in counties near CNS-1 or
4 along the transmission corridors. One fish species is listed by USFWS for Nemaha County,
5 Nebraska: the pallid sturgeon (*Scaphirhynchus albus*) (USFWS, 2007). Regarding State-listed
6 species, Hesse et al. (1982) report the identification of several fish species then listed as
7 threatened or endangered by Iowa, Missouri, or Nebraska, based on studies from 1971 through
8 1977 from the channelized Missouri River in the reach from Fort Calhoun Station to CNS-1.
9 These included skipjack herring (*Alosa chrysochloris*, listed in Iowa), sturgeon chub
10 (*Macrhybopsis gelida*, listed in Iowa and Missouri), blue sucker (*Cycleptus elongates*, listed in
11 Missouri), plains killifish (*Fundulus kansae*, listed in Missouri), and burbot (*Lota lota*), listed in
12 Missouri). Of these, they collected a single sturgeon chub (in 1977), three plains killifish (in
13 1971), ten burbot, and consistent low numbers of blue suckers near CNS-1. MDC (2009) no
14 longer lists sturgeon chub, plains killifish or burbot, and Iowa no longer lists the sturgeon chub
15 (Iowa Administrative Code, Chapter 77). Fish species that the States of Missouri and Nebraska
16 currently list and that Hesse et al. (1982) collected near CNS-1 or in the reach between CNS-1
17 and FCS in the 1971 through 1977 studies include sturgeon chub, blue sucker, and plains
18 killifish. NRC staff did not find more recent data on fish species living in the Missouri River near
19 CNS-1, but lack of captures does not necessarily indicate absence of uncommon species in any
20 case.

21 Life History of Pallid Sturgeon

22 Sturgeons are members of an order of fish (Acipenseriformes) that probably evolved in the
23 Devonian age. Living members of this order in North America include the paddlefish and eight
24 sturgeon species. The paddlefish (*Polyodon spathula*) and three sturgeon species, the lake
25 sturgeon (*Acipenser fulvescens*), pallid sturgeon (*Scaphirhynchus albus*), and the shovelnose
26 sturgeon (*S. platyrhynchus*), live in the Missouri and Mississippi rivers. In the past, commercial
27 fishermen harvested all three of the sturgeon species in the Missouri and Mississippi rivers.
28 Today pallid sturgeon are a Federally-listed endangered species, and lake sturgeon are listed
29 as endangered by Nebraska. The life history information below is from Dryer and Sandvol
30 (1993) and USFWS (2007) if not otherwise cited.

31 Pallid sturgeons have a flattened snout, a long tail, and rows of bony armor plates. The upper
32 side is convex and the lower side is straight. They have an inferior (bottom-facing) mouth and
33 eat invertebrates, such as the immature stages of insects, and fish. The body shape is well
34 adapted swimming close to the bottom of relatively fast flowing, large rivers. The diet, inferior
35 mouth, and barbels in front of the mouth are well adapted to feeding on or near the bottom in
36 highly turbid environments.

37 The USFWS listed pallid sturgeon as endangered in 1990. The historic abundance of pallid
38 sturgeon is somewhat vague since biologists did not recognize it as a separate species from
39 shovelnose sturgeon until 1905, but its historical range probably extended from the middle and
40 lower Mississippi River in the south up through the Missouri River and lower reaches of the
41 Platte, Kansas, and Yellowstone rivers in the north and west. The pallid sturgeon is one of the
42 largest fish species in those rivers. Available information suggests that the pallid sturgeon was
43 not a common species since the time of European settlement. Today pallid sturgeon are among
44 the rarest fish of the Missouri and Mississippi River basins, and the present range includes the
45 States of Montana, North and South Dakota, Nebraska, Iowa, Kansas, Missouri, Illinois,
46 Kentucky, Arkansas, Mississippi, and Louisiana. The populations are largely older fish that will
47 die off in the near future.

1 Fisheries biologists know little about pallid sturgeon reproduction or even preferred spawning
2 habitats and conditions. Hurley et al. (2004) tracked sonically-tagged pallid sturgeon in the
3 Mississippi River and found that they exhibited positive selection for the main-channel border,
4 downstream island tips, between-wing-dam, and wing-dam-tip habitats; they showed negative
5 selection for main-channel, downstream of wing dams, and upstream of wing dam habitats. The
6 sturgeon exhibited little habitat selection for temperature or dam discharge. The authors
7 concluded that habitat enhancement and restoration of habitat diversity might be necessary for
8 recovery of pallid sturgeon.

9 Reports of pallid sturgeon reproduction are rare. The USGS (2007), NGPC, and the USACE
10 confirmed spawning of two female pallid sturgeon in the upstream reaches of the lower Missouri
11 River in May 2007. The capture of young pallid sturgeon that would verify natural reproduction
12 are also rare: none were captured between 1978 and a Mississippi River trawl survey in 1998
13 through 2000 using equipment designed to capture larval fish in deep, turbulent water (Hrabik et
14 al., 2007). Hrabik et al. (2007) concluded that those latest captures verified reproduction,
15 possibly from the lower Missouri River to the upper and lower Mississippi River, although they
16 also found no evidence of recruitment of pallid sturgeon because they captured no juveniles
17 after 374 trawl hauls that captured over 21,735 fish in that 1998 through 2000 survey. Wildhaber
18 et al. (2007) suggest that one or more of the following factors may be responsible for the lack of
19 finding larval pallid sturgeon and of recruitment: lack of successful spawning, low recruitment,
20 high mortality, ineffective sampling methods, inadequate sampling of drift and settling locations,
21 or rapid dispersal and washout of sturgeon larvae in the Missouri and Mississippi rivers. Pallid
22 sturgeon larvae are indistinguishable from those of the congeneric shovelnose sturgeon, which
23 may also help to explain the paucity of reported collections in the past. Also, the construction of
24 dams and other structures with resulting habitat change and the elimination of shallow areas in
25 the river with little or no flow have probably deprived sturgeon of critical nursery areas needed
26 for the survival of immature sturgeon (MDC, 2009).

27 Larval pallid and shovelnose sturgeon become strongly photopositive and migrate upwards
28 toward the light starting the first day after hatching. As a result, they remain far above the
29 bottom, even at the water surface, and migrate far downriver (Kynard et al., 2002). Cultured
30 yearling pallid sturgeon in laboratory studies also migrate downstream during summer and fall,
31 which suggests a two-stage (larval, then yearling) downriver migration in the first year of life.
32 Adult sturgeons are also highly migratory and often migrate hundreds of miles in a year.

33 The young of both shovelnose and pallid sturgeon eat invertebrates, but as pallid sturgeon
34 grow, they become more piscivorous. Gerrity and Guy (2006) found that the diet of juvenile
35 pallid sturgeon of age 6 and 7 was mostly fish, compared to the diet of shovelnose sturgeon,
36 which is mainly aquatic insects. Sturgeon chub (*Macrhybopsis gelida*) and sicklefin chub (*M.*
37 *meeki*) together comprised 79 percent of the number of identifiable fish in juvenile pallid
38 sturgeon stomachs. Populations of these two cyprinid minnows have declined throughout much
39 of the Missouri River due to the construction of dams and man's other alterations of river
40 habitat. While the population of the piscivorous pallid sturgeon has declined in the Missouri and
41 Mississippi rivers, the population of its similar, insectivorous congener, shovelnose sturgeon,
42 has not declined. Gerrity and Guy (2006) concluded that the prevalence of sicklefin chub and
43 sturgeon chub as a food resource of juvenile pallid sturgeon may help explain the decline of
44 pallid sturgeon populations and that recovery and management of native cyprinids is a
45 potentially important step in the recovery of pallid sturgeon.

46 Male pallid sturgeons are believed to mature at 7 to 9 years after which they spawn at intervals
47 of 2 to 3 years. Females may reach sexual maturity at 7 to 15 years and spawn at intervals up

Affected Environment

1 to 10 years. Individuals may reach ages of 60 years or more and reach lengths of 6 feet (2 m).
2 Like many other fish species, the largest individuals are found farthest north in the species'
3 range and maximum size decreases with distance south. For example, the maximum weight of
4 pallid sturgeon in the upper Missouri River in Montana and North Dakota is 86 pounds (39 kg),
5 in the Missouri River in South Dakota and Nebraska 46 pounds (21 kg), and in the Mississippi
6 River 26 pounds (12 kg). They become much larger than shovelnose sturgeon, which rarely
7 weigh more than 8 pounds (3.6 kg).

8 While they were successful in the historical Missouri and Mississippi rivers, with the high flow
9 and turbidity and diverse habitats of floodplains, backwaters, chutes, sloughs, islands, sand and
10 gravel bars, and both braided and main channels, they are not so well adapted to the Missouri
11 and Mississippi rivers today with the construction of dams that isolated subpopulations,
12 channelization, controlled flow, and elimination of habitat diversity. USFWS (2007) concludes
13 that man's activities have adversely affected all of the 3,350 miles (5,390 km) of river habitat
14 within their range, and habitat alteration and loss may be the biggest threat to their existence.
15 Other threats may include hybridization with shovelnose sturgeon, commercial fishing, and
16 exposure to environmental contaminants such as polychlorinated biphenyls, cadmium, mercury,
17 selenium, chlordane DDT, DDE, and dieldrin, all of which have been found in pallid sturgeon
18 tissue in the past.

19 During the early 1990s, the MDC developed "action plans" for lake and pallid sturgeon with a
20 goal of reestablishing self-sustaining populations so they can be delisted as endangered
21 species and ultimately provide limited sport fisheries. These plans stress the restoration of both
22 species through habitat improvement, artificial propagation, protection, research, management,
23 and education (MDC, 2009). As part of this effort, the MDC's Blind Pony Fish Hatchery has
24 raised and stocked over 13,000 fingerling pallid sturgeon and 200,000 fingerling lake sturgeon
25 into the Missouri and Mississippi rivers (MDC, 2009). In addition to these efforts, the USGS
26 (Wildhaber et al., 2007) has developed a conceptual life history to organize the understanding
27 about the complex life history of *Scaphirhynchus* sturgeons and improve understanding of the
28 effects of management actions on the ecological requirements of pallid and shovelnose
29 sturgeons. The USFWS's Pallid Sturgeon Recovery Plan (Dryer and Sandvol, 1993) designated
30 six recovery priority management areas (RPMAs) for implementation of recovery tasks, and
31 CNS-1 is located within RPMA 4.

32 In 2000, the USACE, which provides the primary operation management of the Missouri River,
33 asked the USFWS for formal consultation under the ESA on the Operations of the Missouri
34 River Main Stem System, and related Operations of the Kansas River Tributary Reservoirs, and
35 the Operations and Maintenance of the Missouri River Bank Stabilization and Navigation Project
36 (USFWS, 2000). The USACE had prepared biological assessments for these projects and
37 determined that their operations may affect listed species, including the endangered pallid
38 sturgeon. The USFWS found that the proposed actions were likely to jeopardize the continued
39 existence of pallid sturgeon, as well as the endangered least tern and threatened piping plover,
40 though not the then-threatened bald eagle. Working together, the USACE and the USFWS
41 developed Reasonable and Prudent Alternatives under the ESA to help insure the continued
42 existence of the three species by returning some natural form and function to sections of the
43 Missouri and Kansas rivers. Under the Alternatives, the following five actions are designed for
44 pallid sturgeon: (1) enhance flow by including a spring release from Fort Peck dam and a spring
45 rise and summer drawdown from Gavins Point dam to provide spawning clues and enhance
46 aquatic habitat; (2) restore, create, enhance, acquire, or conserve habitat; (3) unbalance the
47 upper reservoirs, (4) use an adaptive management process combined with monitoring; and (5)

1 increase pallid sturgeon propagation and augmentation efforts while the habitat and hydrology
2 improvements are being implemented.

3 USFWS (2003a, 2003b) issued a Supplemental Biological Opinion that applied only to
4 operations in 2003 due to a continuing drought. It represented a collaborative effort between the
5 USFWS and the USACE and considered habitat conditions and new information not considered
6 in the November 2000 biological opinion. The USACE changed flow regime in the Missouri
7 River and the USFWS stocked year-old pallid sturgeon, both as interim measures in 2003.
8 USFWS (2003a, 200b) reported that the long-term survival of pallid sturgeon will depend on a
9 more natural hydrograph consisting of an increase in spring flows and declining summer flows.

10 2.2.7.2 Terrestrial Species

11 Federally Protected Species

12 Eight animal and plant species Federally-listed as threatened or endangered (Table 2.2.7-1) are
13 known to occur or to potentially occur on terrestrial habitat within the vicinity of CNS-1 or along
14 the associated in-scope transmission line corridor. The ranges of four of these species, the
15 Indiana bat (*Myotis sodalis*), the western prairie fringed orchid (*Platanthera praeclara*), the
16 piping plover (*Charadrius melodus*), and the interior least tern (*Sterna antillarum athalassos*)
17 may include the CNS-1 site. The Indiana bat and interior least tern are listed as endangered,
18 and the western prairie fringed orchid and piping plover are listed as threatened
19 (USFWS, 2008a; USFWS, 2009b).

20 Seven Federally-listed species are potentially present along the transmission line corridor,
21 including the western prairie fringed orchid. The endangered species are the Salt Creek tiger
22 beetle (*Cincindela nevadica lincolniiana*), the black-footed ferret (*Mustela nigripes*), the interior
23 least tern, the Eskimo curlew (*Numenius borealis*), and the only known wild population of
24 whooping crane (*Grus americana*). The Eskimo curlew is extirpated from Nebraska and is
25 globally extinct or near-extinct. The piping plover is listed as a threatened species and may be
26 found along the western limit of the transmission line corridor by the Platte River, along with the
27 interior least tern and whooping crane (NatureServe, 2009e; USFWS 2008a, 2009b, 2009c).

28 While threatened piping plovers have not been observed along the CNS-1 shoreline, they have
29 been found along the Missouri River in close proximity to CNS-1 and along the Platte River near
30 the western limit of CNS-1 transmission line NPPD TL3502 (USFWS 2002, 2009c; NatureServe,
31 2009a). The piping plover is a small shorebird with a white underbelly and pale brownish upper
32 parts, with an average length of 6–7 inches (16–18 cm) and a wingspan of about 15 inches (38
33 cm). The plover has a small black ring around the base of its neck and a black band over its
34 eyes on its forehead (NatureServe, 2009a, USFWS, 1997). Piping plover habitat includes river
35 channels, their associated sandbars and islands, and their sparsely vegetated shorelines and
36 peninsulas (USFWS, 2002). Even though the shoreline along the Missouri River at CNS-1 does
37 not contain the characteristics required by piping plovers for nesting, but they have been
38 reported in the vicinity of CNS-1. Critical habitat has been designated for the northern Great
39 Plains breeding population of the piping plover along portions of the Platte River in Hamilton
40 County and Merrick County, which is the location of the transmission line crossing of the Platte
41 River near Grand Island, Nebraska. Critical habitat has also been designated along the Missouri
42 River near the Nebraska-South Dakota border, but not in the vicinity of the CNS-1 site (NPPD,
43 2008a; USFWS, 2002). The destruction or degradation of their habitat and poor breeding
44 success caused by predation are the major reasons for the decline of piping plover populations.
45 Dam construction and channelization of the Missouri River have caused the loss of sandbar
46 nesting habitat for the piping plover (USFWS 1997, 2002).

Affected Environment

1 Interior least terns are found along portions of the Missouri River in North Dakota, and also nest
2 along portions of the Platte River and its tributaries in Hamilton County and Merrick County,
3 Nebraska, near the western limit of transmission line NPPD TL3502 (NatureServe, 2009b;
4 NGPC, 2009a). The interior least tern is a swallow-like bird 8–9 inches (22–24 cm) long with a
5 wingspan of about 20 inches (31 cm). It has a pale gray and white body with a glossy black
6 crown, and a long black-tipped yellow-orange bill. The interior least tern nests in habitat similar
7 to that used by piping plovers. Threats to the interior least tern are also similar to those of the
8 piping plover, with sand and gravel pits now providing some of the only available nesting habitat
9 for least terns (NGPC, 2009a; USFWS, 2008b).

10 The current range of the Indiana bat includes Atchison County, Missouri, on the east side of the
11 Missouri River from CNS-1, but does not include Nebraska (USFWS, 2008a; MDC 2009b,
12 2009c). The Indiana bat is a medium-sized bat about two inches (5 cm) long and weighing
13 about one-quarter ounce (7 gm) (NYS DEC, 2009) with a wingspan of about eight inches
14 (20 cm) and brownish-gray fur (MDC, 2009a). The Indiana bat hibernates in caves during the
15 winter and migrates to streams and rivers in wooded areas in the summer where they roost
16 under loose tree bark (NYS DEC, 2009; MDC, 2009a). Critical habitat for the Indiana bat has
17 been designated in Missouri but not in Atchison County (USFWS, 2008a). A number of factors
18 have contributed to population declines for the Indiana bat; a primary cause for their decline has
19 been from humans disturbing bats hibernating in caves during the winter. Stream
20 channelization, deforestation, and agricultural development threaten the habitat of Indiana bats
21 in their summer range (MDC, 2009a).

22 The western prairie fringed orchid occurs both in Nebraska and Missouri. It is found in Otoe
23 County, located immediately north of Nemaha County, which is the location of CNS-1. It is also
24 found in Atchison County, Missouri, the location of the Missouri portion of the CNS-1 property
25 (USFWS 2008a, 2009b). The western prairie fringed orchid produces flower stalks up to about 4
26 feet (133 cm) tall, with up to 40 one inch (2.5 cm) white flowers, attached to the stalk
27 (USFWS, 2003; MN DNR, 1991). It grows in moderately wet to wet prairies and meadows and is
28 occasionally found in old fields and roadside ditches. Habitat loss through conversion to
29 cropland is the greatest threat to populations of the western prairie fringed orchid
30 (USFWS, 2003).

31 The only known existing wild population of whooping cranes migrates along the Platte River at
32 the western limit of the CNS-1 transmission line corridor near Grand Island. The whooping
33 crane is a large white crane standing as tall as 5 feet (1.5 m) with a wingspan of 8 feet (2.5 m)
34 and weighing over 17 pounds (8 kg), making it the largest bird in North America and one of the
35 three largest cranes in the world (NGPC, 2009b). Adult whooping cranes have a red crown and
36 black forehead with black primary feathers visible during flight (USFWS, 2009k). Whooping
37 cranes live and breed in wetlands, and feed primarily on crabs, small fish and other
38 invertebrates (NGPC, 2009b; NatureServe, 2008a). Whooping cranes declined to the brink of
39 extinction in the first half of the 20th century mainly caused by a loss of habitat to agriculture,
40 human disturbance of nesting areas for eggs, and uncontrolled hunting for meat and plumage.
41 By 1941, only 14 whooping cranes existed (NatureServe, 2008a; NGPC, 2009b). Current
42 threats to their population include habitat degradation, low productivity associated with drought
43 and/or winter malnutrition, collisions with power lines along their migration routes, and severe
44 weather phenomena during nesting season (NatureServe, 2008a; USFWS, 2009c).

45 There are currently three populations of whooping cranes totaling less than 400 adult and
46 juvenile birds, including one wild population and two experimental, nonessential populations.
47 The wild population of whooping cranes overwinters in the Aransas National Wildlife Refuge in

1 Texas, and migrates north in the spring to one small breeding area in Canada (USFWS, 2009g).
2 The wild population uses the Platte River and its tributaries and surrounding wetlands along its
3 migratory corridor in the spring and fall. CNS-1 transmission line NPPD TL3502 crosses the
4 Platte River along the whooping crane migratory corridor one mile from the endpoint of the
5 transmission line near Grand Island, Nebraska. Critical habitat has been designated for
6 whooping cranes on the Platte River, located approximately 25 miles (40 km) southwest of
7 Grand Island (USFWS, 1978). One of the two experimental populations breeds in Idaho and
8 overwinters in Utah. The second experimental population breeds in Wisconsin and overwinters
9 in Florida and several other southeastern States (NatureServe, 2008a).

10 Captive breeding programs over the past several decades have increased whooping crane
11 populations sufficiently to allow creation of the two experimental populations. As of April 2008,
12 however, there were still less than 400 adult and juvenile whooping cranes in existence between
13 these three flocks. Both the wild population and the experimental populations still suffer
14 significant mortality attributable to severe weather, lack of food, and collisions with power lines.
15 The wild Aransas population lost 57 adult and juvenile whooping cranes between spring 2008
16 and winter 2009, for a loss of 21 percent of its population in 12 months. The spring 2009 flock of
17 whooping cranes at Aransas totaled 247 birds (Stehn, 2009).

18 The NPPD has coordinated efforts with the USFWS to address the potential risk of bird
19 collisions with transmission line NPPD TL3502, which crosses the Platte River near the end of
20 the CNS-1 transmission line corridor, located approximately 4 miles (6 km) east of Grand Island,
21 Nebraska. The Federally-endangered whooping crane (*Grus Americana*), the interior least tern
22 (*Sterna antillarum athalassos*), and the Federally threatened piping plover (*Charadrius*
23 *melodius*) utilize the Platte River and associated wetlands around Grand Island for different
24 portions of their lifecycle, such as for migration, resting, feeding, and nesting, and risk collisions
25 with the NPPD transmission line. The USFWS has indicated that collisions with transmission
26 lines are the main cause of whooping crane mortality during their migrations (USFWS, 2009c).
27 On May 8, 2009, the NPPD informed the USFWS that NPPD had agreed to mark that portion of
28 the NPPD transmission line that crosses the Platte River with bird flight diverters to increase the
29 visibility of the transmission line and reduce the risk of birds colliding with the line (NPPD, 2009).
30 The USFWS replied to NPPD on June 8, 2009, informing them that NPPD had satisfactorily
31 addressed the concerns of the USFWS regarding bird collisions (USFWS, 2009i).

32 The extremely rare Salt Creek tiger beetle is found only in the northern third of Lancaster
33 County, Nebraska (Cornell University, 2008; USFWS, 2005; NatureServe, 2008b). The
34 transmission line corridor for CNS-1 traverses the southern portion of Lancaster County (NPPD,
35 2008). The Salt Creek tiger beetle is about one-half inch (1.0 cm) long and is metallic brown to
36 dark olive green above with a metallic dark green underside (USFWS 2005, 2009h). The tiger
37 beetle is an active predator, grasping other small invertebrates for prey with its mandibles. The
38 Salt Creek tiger beetle, limited to three populations totaling less than 150 adults, is found only in
39 saline wetlands and along muddy banks of associated streams and tributaries of Little Salt
40 Creek in Lincoln, Nebraska. Threats to the remaining populations of the Salt Creek tiger beetle
41 include habitat loss and degradation caused by development, increased water runoff and
42 sediment runoff from urban areas, eroding banks associated with development, bank
43 stabilization projects, pollution, pesticides, and habitat loss and degradation from grazing and
44 cultivation (Cornell University, 2008; USFWS, 2005). On December 12, 2007, the USFWS
45 proposed the designation of critical habitat for the Salt Creek tiger beetle (USFWS, 2009i).

46 The black-footed ferret is considered to be one of the most endangered mammals in the United
47 States, and has the potential to survive in Hamilton County and Merrick County, Nebraska, near

Affected Environment

1 the western limit of transmission line NPPD TL3502 (USFWS, 2009b; NPPD, 2008a). It is a
2 member of the weasel family (*Mustelidae*), and is the only ferret native to North America. The
3 black-footed ferret's distinctive coloration includes a black face mask, black feet, and a black-
4 tipped tail, with a light yellow-buff color on its back and body. It is approximately 6 inches
5 (15 cm) tall, 18–24 inches (50–60 cm) long including a 6-inch (15 cm) tail, and weighs
6 1.5–2.5 pounds (0.7–1.1 kg) (Defenders of Wildlife, 2009; NatureServe, 2009c; USFWS 2000,
7 2009j).

8 Black-footed ferrets once ranged throughout the Great Plains region of the United States and
9 part of southern Canada. They live primarily on the open prairie and spend most of their time
10 underground in prairie dog burrows, relying on prairie dogs as their prey. Through the first half
11 of the twentieth century, the conversion of open prairie to farmland, the shooting and poisoning
12 of prairie dogs to eliminate them from livestock grazing areas, and sylvatic plague wiped out
13 large numbers of prairie dogs and correspondingly decimated the black-footed ferret population.
14 The black-footed ferret was feared extinct by the mid 1970s, until a small population of 130 was
15 identified in Wyoming in 1981 (Black-footed Ferret Recovery Implementation Team, 2009;
16 Defenders of Wildlife, 2009; USFWS, 2000). A captive breeding program over the last 25 years
17 has increased their population from a low of 18 wild black-footed ferrets to their present number
18 of 750 living in the wild, including an experimental nonessential population, and 250 living in
19 captive breeding facilities (USFWS 2000, 2009j). Current threats to the black-footed ferret still
20 include their reliance on prairie dogs as their food source, the corresponding prairie dog
21 management practices implemented by agricultural interests competing for land, and the
22 reduction and fragmentation of prairie dog populations to less than five percent of their historic
23 range (Defenders of Wildlife, 2009; NatureServe, 2009c).

24 State Protected Species

25 A total of 115 terrestrial species (41 terrestrial animal species and 74 terrestrial plant species)
26 are protected by Nebraska and Missouri, and are listed as endangered, threatened, or species
27 of special concern (S1; S2; SX; SH) (Table 2.2.7-1). Ninety-three of the protected species occur
28 in Nebraska, and 37 of the protected species are in Atchison County, Missouri. These 115
29 species have the potential to inhabit the counties within the vicinity of CNS-1 and/or the
30 transmission line corridor, including Nemaha County, Johnson County, Gage County, Lancaster
31 County, Saline County, Fillmore County, York County, Hamilton County, and Merrick County,
32 Nebraska, and Atchison County, Missouri. These 41 animal species include 14 bird species, 12
33 reptile species, 2 amphibian species, 8 mammal species, and 5 insect species (NGPC 2008,
34 2009c; MDC 2009b, 2009c; USFWS 2008a, 2009b). The NPPD has indicated that no currently
35 Federally or State-listed terrestrial plant or animal species have been observed on CNS-1
36 property (NPPD, 2008).

37 Forty-nine of the protected species inhabit Nemaha County, Nebraska, the location of CNS-1,
38 including 15 species of mammals, birds, reptiles, and amphibians, and 34 species of plants
39 (Table 2.2.7-1). Nebraska lists two mammals, the southern flying squirrel (*Glaucomus volans*)
40 as threatened and the woodland vole (*Microtus pinetorum*) as a species of concern. Both
41 species occur in Nemaha County. Six bird species protected by Nebraska that occur in Nemaha
42 County include the ruffed grouse (*Bonasa umbellus*), the whip-poor-will (*Caprimulgus*
43 *vociferous*), the peregrine falcon (*Falco peregrinus*), the barred owl (*Strix varia*), the blue-gray
44 gnatcatcher (*Polioptila caerula*), and the Carolina wren (*Thryothorus ludovicianus*)
45 (NatureServe, 2009e; NGPC, 2009c). The peregrine falcon was once a Federally-listed species,
46 but was delisted in 1999. The bald eagle (*Haliaeetus leucocephalus*), an S3 designation, has
47 been observed on both sides of the Missouri River on CNS-1 property. The bald eagle was

1 likewise a listed species, but was delisted in 2007. Both the peregrine falcon and the bald eagle
 2 are protected under the Migratory Bird Treaty Act, and the bald eagle is also protected under
 3 the Bald and Golden Eagle Protection Act. There is an active bald eagle nest adjacent to a field
 4 on the Missouri side of the CNS-1 property. Six Nebraska State protected reptiles and one
 5 amphibian known to inhabit Nemaha County include the western wormsnake (*Carphophis*
 6 *vermis*), the yellow-bellied kingsnake (*Lampropeltis calligaster*), the common kingsnake
 7 (*Lampropeltis getula*), the smooth green snake (*Liochlorophis vernalis*), Graham's crayfish
 8 snake (*Regina grahamii*), the Massasauga rattlesnake (*Sistrurus catenatus*), and the
 9 smallmouth salamander (*Ambystoma texanum*) (NatureServe, 2009e, NGPC, 2009c).

10 Nebraska lists 27 animal species and 39 plant species that are protected and occur or
 11 potentially occur in the counties traversed by the transmission line. Species listed as
 12 endangered by Nebraska that occur or potentially occur in the counties traversed by the
 13 transmission line corridor include the whooping crane, interior least tern, Salt Creek tiger beetle,
 14 American burying beetle (*Nicrophorus americanus*), Eskimo curlew, and black-footed ferret.
 15 Species listed as threatened by Nebraska that occur or potentially occur in the counties
 16 traversed by the transmission line corridor include the Massasagua rattlesnake, the piping
 17 plover, and the river otter (*Lontra canadensis*) (NatureServe, 2009e; NGPC, 2009c).

18 The 37 protected species in Atchison, County, Missouri (the eastern portion of the CNS-1 site),
 19 include 16 species of mammals, birds, reptiles, amphibians, and insects, and 21 species of
 20 plants. Two mammals that potentially occur on the CNS-1 site in Missouri include the State
 21 endangered Indiana bat (*Myotis sodalis*) and the plains spotted skunk (*Spilogale putorius*
 22 *interrupta*). Other State protected mammals include the plains pocket mouse (*Perognathus*
 23 *flavescens*) and Franklin's ground squirrel (*Spermophilus franklinii*). Five bird species protected
 24 by Missouri also are in Atchison County, and include the peregrine falcon, the loggerhead shrike
 25 (*Lanius ludovicianus*), the black rail (*Laterallus jamaicensis*), the king rail (*Rallus elegans*), and
 26 the interior least tern. Four reptiles protected by Missouri and known to inhabit Atchison County
 27 are the western fox snake (*Elaphe vulpine*), the smooth green snake, the Massasauga
 28 rattlesnake, listed as State endangered, and the Great Plains skink (*Eumeces obsoletus*). One
 29 amphibian protected by Missouri and known to inhabit Atchison County is the northern leopard
 30 frog (*Rana pipiens*). Two insect species are protected by Missouri and found in Atchison,
 31 County, and include Packard's grasshopper (*Melanoplus packardii*), and the American burying
 32 beetle. The western prairie-fringed orchid is State listed as endangered (MDC 2009b, 2009c;
 33 NatureServe 2009d).

34 **2.2.8 Socioeconomic Factors**

35 This section describes current socioeconomic factors that have the potential to be directly or
 36 indirectly affected by changes in operations at the CNS-1. The CNS-1 and the people and
 37 communities surrounding it can be described as a dynamic socioeconomic system. The nuclear
 38 power plant requires people, goods, and services from local communities to operate the plant;
 39 and the communities, in turn, provide the people, goods, and services to run the plant. CNS-1
 40 employees residing in the community receive income from the plant in the form of wages,
 41 salaries, and benefits, and spend this income on goods and services within the community,
 42 thereby creating additional opportunities for employment and income. People and businesses in
 43 the community also receive income for the goods and services sold to CNS-1. Payments for
 44 these goods and services create additional employment and income opportunities in the
 45 community. The measure of a communities' ability to support the operational demands of
 46 CNS-1 depends on the ability of the community to respond to changing socioeconomic
 47 conditions.

Affected Environment

1 The socioeconomic region of influence (ROI) is defined by the areas where CNS-1 employees
2 and their families reside, spend their income, and use their benefits, thereby affecting the
3 economic conditions of the region. The CNS-1 ROI consists of a four-county area (Nemaha,
4 Otoe, and Richardson counties in Nebraska and Atchison County in Missouri) where
5 approximately 90 percent of CNS-1 employees reside. The following sections describe the
6 housing, public services, offsite land use, visual aesthetics and noise, population demography,
7 and the economy in the ROI surrounding CNS-1.

8 NPPD employs a permanent workforce of approximately 750 employees (NPPD, 2008).
9 Approximately 90 percent live in Nemaha, Otoe, and Richardson counties, Nebraska, and
10 Atchison County, Missouri (Table 2.2.8-1). Most of the remaining 10 percent of the workforce
11 are divided among 23 counties in Iowa, Kansas, Missouri, and Nebraska with numbers ranging
12 from 1 to 13 employees per county. Given the residential locations of CNS-1 employees, the
13 most significant impacts of plant operations are likely to occur in Nemaha, Otoe, Richardson,
14 and Atchison counties. The focus of the socioeconomic impact analysis in this supplemental
15 environmental impact statement (SEIS) is therefore on the impacts of the CNS-1 on these four
16 counties.

17 **Table 2.2.8-1. Cooper Nuclear Station, Unit 1 Employee Residence by County**

County	Number of Employees	Percentage of Total
Nemaha, NE	359	48
Otoe, NE	108	14
Atchison, MO	106	14
Richardson, NE	100	13
Fremont, IA	13	2
Holt, MO	12	2
Cass, NE	11	2
Other	41	5
Total	750	100

Source: NPPD, 2008a

18 Refueling outages at the CNS-1 normally occur at 18-month intervals. During refueling outages,
19 site employment increases by as many as 700 to 900 workers for approximately 30 days
20 (NPPD, 2008). Most of these workers are assumed to be located in the same geographic areas
21 as CNS-1 employees.

22 2.2.8.1 Housing

23 Table 2.2.8.1-1 lists the total number of occupied and vacant housing units, vacancy rates, and
24 median value in the four-county ROI. According to the 2000 Census, there were approximately
25 17,700 housing units in the socioeconomic region, of which approximately 15,800 were
26 occupied. The median value of owner-occupied housing units in the three Nebraska counties
27 ranged from \$38,900 in Richardson County to \$78,000 in Otoe County. The vacancy rate was
28 the lowest in Otoe County (7.7 percent) and highest in Richardson County (12.4 percent).
29 Atchison County, Missouri, has the smallest number of total and vacant housing units among
30 the four counties (USCB, 2009).

1 By 2007, the estimated number of housing units grew in all three counties by approximately
 2 3 percent of their total inventories. In Nemaha County the number of housing units grew to an
 3 estimated total of 3,540 units in 2007, an increase of more than 100 units. In Otoe County the
 4 number of housing units grew by more than 390 units to an estimated total of 6,955 units or
 5 approximately 6 percent. The estimated total number of housing units also increased slightly in
 6 Atchison County, Missouri (USCB, 2009).

7 **Table 2.2.8.1-1. Housing in Nemaha, Otoe, and Richardson Counties in Nebraska and**
 8 **Atchison County in Missouri**

	Nemaha	Otoe	Richardson	Atchison	ROI
2000					
Total	3,439	6,567	4,560	3,103	17,669
Occupied housing units	3,047	6,060	3,993	2,722	15,822
Vacant units	392	507	567	381	1,847
Vacancy rate (percent)	11.4	7.7	12.4	12.3	10.5
Median value (dollars)	58,200	78,000	38,900	49,800	56,225
2007*					
Total	3,540	6,955	4,563	3,129	18,187

* Estimated occupied housing units, vacancy, and median value data is not available for all counties.

Source: USCB, 2009a.

9 **2.2.8.2 Public Services**

10 This section presents information regarding public services including water supply, education,
 11 and transportation.

12 Water Supply

13 Because 90 percent of workers at CNS-1 reside in Nemaha, Otoe, and Richardson counties,
 14 Nebraska and Atchison County, Missouri, the discussion of public water supply systems is
 15 limited to these counties. In Table 2.2.8.2-1, information about municipal water suppliers in
 16 these counties, their permitted capacities and/or maximum design yields, reported annual peak
 17 usage, and population served are presented. The primary source of potable water in the vicinity
 18 of the CNS-1 is ground water. Most of Nemaha, Atchison, and Richardson counties are not
 19 served by community water supplies. Private ground water wells supply much of the water to
 20 residents in the area.

21 There are four wellhead protection areas within 10 miles of CNS-1: Village of Nemaha, Nemaha
 22 County Rural Water District (RWD) No. 1, City of Auburn, and Village of Stella. CNS-1 does not
 23 use public water systems for cooling or process water systems. NPPD relies on ground water
 24 wells and surface water from the Missouri River for all of its water needs at the CNS-1. Two
 25 wells supply potable water to the facility (NPPD, 2008).

26 Community water supply systems in Nemaha County include the City of Auburn, the City of
 27 Nemaha, Nemaha County RWD No. 1, Nemaha County RWD No. 2, and the City of Peru. The
 28 Village of Brownville no longer uses its own supply wells, but is connected to Nemaha County
 29 RWD No. 1 (NPPD, 2008). The Auburn Board of Public Works operates the Auburn Municipal
 30 Water System. Eleven wells can provide up to 1,728,000 gallons of water per day. The system
 31 provides an average of 700,000 gallons of water per day and can meet a peak demand of

Affected Environment

- 1 1,181,700 gallons per day. The system has a storage capacity of 1,650,000 gallons (NDED and
2 NPPD, 2008a). The Nemaha municipal water system serves the Village of Nemaha and
3 provides an average of 17,500 gallons of water per day and can meet a peak demand of 30,000
4 gallons per day. The system has a rated capacity of 216,000 gallons per day (NPPD, 2008).
- 5 Nemaha County RWD No. 1 has a rated capacity of 100,000 gallons per day with a peak
6 demand of 90,000 gallons per day. The Nemaha County RWD No. 1 public water system serves
7 rural Nemaha County including the Village of Brownville. Nemaha County RWD No. 2 has an
8 average service demand of 206,300 gallons per day. The storage capacity is reported to be
9 230,000 gallons (NPPD, 2008).
- 10 The Peru Municipal Water System serves the municipality of Peru in Nemaha County. The Peru
11 system has a rated capacity of 576,000 gallons per day with an average of 83,000 gallons and a
12 peak demand of 113,500 gallons per day (NPPD, 2008).
- 13 Nebraska City Utilities provides water to the residents of Nebraska City in Otoe County. This
14 water system has a rated capacity of 6,300,000 gallons per day with an average of 2,500,000
15 gallons and a peak demand of 3,500,000 gallons per day (Great Plains Energy, 2009).
- 16 Falls City provides water to approximately 4,800 residents in Richardson County. The water
17 system has a rated capacity of 2,160,000 gallons per day with an average of 690,000 gallons
18 and a peak demand of 1,528,000 gallons per day (Great Plains Energy, 2009).
- 19 Richardson County RWD No. 1 and the Village of Shubert have community water systems
20 within ten miles of CNS-1. Richardson County RWD No. 1 system has a capacity of 230,000
21 gallons per day with an average demand of 100,000 gallons per day. The Village of Shubert
22 operates a municipal water system with a capacity of 204,000 gallons per day, with an average
23 daily demand of 22,800 gallons (NPPD, 2008).
- 24 Almost all potable water use within Atchison County is from ground water supplied from wells,
25 with the exception of Westboro, Missouri which purchases water from a surface water source.
26 The Rock Port Municipal Water System on average supplies approximately 300,000 gallons per
27 day with a system capacity of approximately 720,000 gallons per day (MDNR, 2008).

1 **Table 2.2.8.2–1. Public Water Supply Systems (thousand gallons per day)**

Water Supplier ^a	Water Source ^a	Average Daily Demand	System Capacity	Population Served ^a
Nemaha County, Nebraska				
City of Auburn	GW	1,182	1,728	3,217
Village of Nemaha	GW	30	216	188
City of Peru	GW	114	576	923
Nemaha County RWD No. 1	GW	90	100	800
Nemaha County RWD No. 2	GW	206	230	1,315
Otoe County, Nebraska				
City of Nebraska	GW	2,500	6,300	7,192
Richardson County, Nebraska				
City of Falls City	GW	690	2,160	4,761
Richardson County RWD No. 1	GW	100	230	805
Village of Shubert	GW	23	204	240
Atchison County, Missouri				
Fairfax	GW	185	308	645
Public Water System District No. 1 of Atchison County	GW	171	1,310	831
City of Rock Port	GW	300	720	726
Tarkio Board of Public Works	GW	225	756	1,957
Westboro	SW	20	75	160

2 GW = ground water; SW = surface water; RWD = rural water district

3 ^a EPA, 2009b

4 Source: EPA, 2009b; Nebraska Department of Economic Development (NDED and NPPD, 2008a; NPPD, 2008a;
5 Great Plains Energy, 2009; MDNR, 2008.

6 Education

7 The CNS-1 is located in the Auburn Public School District, Nemaha County, which has an
8 enrollment of approximately 882 students in the 2008–2009 school year (Nebraska Department
9 of Education (NDE, 2009). Nemaha County has 2 public school districts with over 1,100 enrolled
10 students (NDE, 2009). Otoe and Richardson counties have 4 school districts each (NDE, 2008).
11 Total enrollment in Otoe and Richardson County schools in the 2008–2009 school year was
12 approximately 2,900 and 1,600 students, respectively (NDE, 2009).

13 Transportation

14 Several highways serve as transportation corridors within Nemaha and Atchison counties. The
15 primary highways in Nemaha County include U.S. Highways 75 and 136 and Nebraska State
16 Highways 62, 67, and 105. Access to the site is by Nemaha County Road 648A Avenue located
17 on the west side of CNS-1 property. County Road 648A Avenue intersects US Highway 136
18 which runs east to west, north of CNS-1 at Brownville, Nebraska. State Highway 67 traverses
19 Nemaha County north to south to the west of CNS-1. U.S. Highway 75 bisects Nemaha County
20 running north to south. Plant workers living east and west of CNS-1 travel on U.S. Highway 136

Affected Environment

1 to Nemaha County Road 648A Avenue to the site access road, and workers living north and
2 south travel on U.S. Highway 75 and Nebraska State Highway 67 to U.S. Highway 136.

3 The primary highways in Atchison County, Missouri on the east side of the Missouri River
4 include Interstate 29 (I-29), U.S. Highways 136, 59, and 275, Missouri State Highways 46 and
5 111, and County Roads B, M, and T. I-29 runs north to south through Atchison County roughly
6 parallel to the river between Council Bluffs, Iowa northeast of CNS-1 and St. Joseph, Missouri,
7 southeast of CNS-1. CNS-1 employees who reside in Missouri can access the site by using
8 either U.S. Highways 136 or 159, which cross the Missouri River at Brownville and Rulo,
9 Nebraska (in Richardson County), respectively. U.S. Highway 136 bisects Atchison County east
10 to west in Missouri, similar to Nemaha County on the west side of the river. Atchison County is
11 also bisected by U.S. Highway 59 which runs north to south through the central portion of the
12 county.

13 Primary highways in Richardson County include U.S. Highways 73, 75, and 159 and State
14 Highways 8, 62, 67, and 105. U.S. Highway 75 runs north and south through both Nemaha and
15 Richardson counties. U.S. Highway 159 crosses the river downstream of CNS-1 at Rulo,
16 Nebraska, from Holt County, Missouri.

17 The primary highways in Otoe County include U.S. Highways 50 and 75 and Nebraska State
18 Highways 2, 43, 66A, 67, and 128. Otoe County is bisected north to south by U.S. Highway 50
19 and Nebraska State Highway 2. Access to Otoe County directly from CNS-1 is primarily from
20 Nebraska State Highway 67 and U.S. Highway 75.

21 Table 2.2.8.2-2 lists commuting routes to CNS-1 and average annual daily traffic (AADT)
22 volume values. The AADT values represent traffic volumes for a 24-hour period factored by both
23 day of week and month of year.

1 **Table 2.2.8.2-2. Major Commuting Routes in the Vicinity of Cooper Nuclear Station, Unit 1**
 2 **in 2006 Average Annual Daily Traffic Count**

Roadway and Location	Average Annual Daily Traffic (AADT) ^a
U.S. Highway 136 (between State Highway 67 and Brownville, NE)	2,905
U.S. Highway 136 (between Brownville, NE and Missouri River)	2,615
U.S. Highway 136 (between Interstate 29 and the Missouri River in Missouri)	2,487
U.S. Highway 136 at Rock Port, MO	3,194
U.S. Highway 136 (between Auburn, NE and State Highway 67)	3,205
State Highway 67 (between Nemaha, NE and Brownville, NE)	960
State Highway 67 at Nemaha, NE	770
State Highway 67 south of CNS-1	625
State Highway 67 at Peru, NE	1,025
U.S. Highway 75 (between State Highway 67 and U.S. Highway 136, Auburn, NE)	5,220
U.S. Highway 75 (near Julian, NE)	4,640
U.S. Highway 75 (south of Nebraska City, NE)	5,585
Interstate 29 north of U.S. Highway 136 in Missouri	10,325
Interstate 29 south of U.S. Highway 136 in Missouri	11,832

Source: NDOR, 2007; MOBOT, 2007.

^a All AADTs represent traffic volume during the average 24-hour day during 2006.

U.S.=United States

3 **2.2.8.3 Offsite Land Use**

4 Offsite land use conditions in Nemaha County, Otoe County, Richardson County, and Atchinson
 5 County, are described in this section. In addition to property taxes, Nemaha and other counties
 6 in the vicinity of CNS-1 receive revenue from sales taxes and fees paid by NPPD and its
 7 employees residing in the region. Changes in the number of workers at CNS-1 and tax
 8 payments to local jurisdictions could affect land use conditions in these counties.

9 CNS-1 is located in eastern Nemaha County. Otoe, Richardson, and Atchison counties are
 10 located along the Missouri River, north, south, and east of Nemaha County, respectively. The
 11 four-county area near CNS-1 is rural and largely unincorporated. Less than half of the
 12 population in the four-county area lives in incorporated towns and villages. Most of the land in
 13 the four-county area is in agricultural use or is forest or open land. Only a small percentage of
 14 the land has been developed for residential, commercial, or industrial purposes. Forested areas
 15 are generally limited to narrow strips of land along streams and rivers and steep, hilly areas
 16 unsuitable for agriculture.

Affected Environment

1 Nemaha, Richardson, and Atchison counties have seen a steady decline in population over the
2 past 50 years as residents leave farms to seek employment in larger cities and towns. Most
3 towns and villages located within a 50-mile radius of CNS-1 are small and primarily support
4 agricultural communities. The closest communities to CNS-1 are the Village of Brownville,
5 located approximately two miles northwest of CNS-1 and the town of Nemaha to the south.
6 Industrial developments in the four-county area are located in the larger communities of Auburn
7 and Nebraska City, Nebraska, and Marysville, Missouri.

8 Nemaha County occupies approximately 409 square miles (262,000 ac) (USCB, 2009c).
9 Approximately 213,000 acres or 81 percent of the land in Nemaha County was used for
10 agriculturally related activities in 2007. There were 449 farms, with most of the agricultural land
11 devoted to cropland (80 percent) and pasture (12 percent) (USDA, 2009). Nemaha County does
12 not have county-wide zoning regulations although the city of Auburn has local zoning
13 regulations (NPPD, 2008).

14 Otoe County occupies roughly 616 square miles (394,000 ac) (USCB, 2009c). The largest
15 category of land use, approximately 322,000 acres or 82 percent, is devoted to agriculture in
16 Otoe County, with 804 farms in 2007. Approximately 80 percent of the agricultural land is in
17 cropland and approximately 11 percent pasture (USDA, 2009). Otoe County has county-wide
18 zoning regulations to manage future growth and development in the county.

19 Richardson County occupies roughly 553 square miles (354,000 ac) (USCB, 2009c). The
20 largest category of land use, approximately 279,000 acres or 79 percent, is devoted to
21 agriculture in Richardson County, with 707 farms in 2007. Approximately 75 percent of the
22 agricultural land is cropland and approximately 14 percent, pasture (USDA, 2009). Richardson
23 County does not have county-wide zoning regulations although the City of Falls city has local
24 zoning regulations (NPPD, 2008).

25 Atchison County, Missouri occupies approximately 545 square miles (349,000 ac)
26 (USCB, 2009c). Approximately 87 percent of Atchison County land is used for agricultural
27 purposes. In 2007, the county had 501 farms on approximately 304,000 acres. Major
28 agricultural uses consist of croplands (87 percent) and 6 percent pasture (USDA, 2009).
29 Atchison County currently does not have county-wide zoning regulations to manage future
30 growth and development (NPPD, 2008).

31 No significant change in land use is anticipated for the future in these four counties. Land use
32 trends reflect a slow, but steady overall decline in population in the region. Limited potential
33 commercial and urban development occurs in the small urban areas where public services and
34 utilities are available. No significant changes in future agricultural acreage, farm size, and land
35 uses are anticipated for the four-county region near CNS-1.

36 2.2.8.4 *Visual Aesthetics and Noise*

37 CNS-1 can be seen from the river, but is partly shielded by vegetation along the river.
38 Predominant features are the reactor building, which is approximately 290 feet tall, the elevated
39 release point (325 feet) and meteorological tower (328.8 feet). The turbine building and reactor
40 containment structures dominate the landscape of the site. The 239 undeveloped acres of
41 CNS-1 site on the Missouri (east) side of the river provides a wooded view from the river.

42 Noise from nuclear plant operations can be detected offsite. Sources of noise at CNS-1 include
43 the turbines and large pump motors. Given the industrial nature of the station, noise emissions
44 from the station are generally nothing more than an intermittent minor nuisance. However, noise

1 levels may sometimes exceed the 55 dBA level that the EPA uses as a threshold level to protect
 2 against excess noise during outdoor activities (EPA, 1974). However, according to the EPA this
 3 threshold does “not constitute a standard, specification, or regulation,” but was intended to
 4 provide a basis for State and local governments establishing noise standards.

5 **2.2.8.5 Demography**

6 According to the 2000 Census, approximately 18,318 people lived within 20 miles of CNS-1,
 7 which equates to a population density of 15 persons per square mile (NPPD, 2008). This
 8 density translates to Category 1, Most sparse (less than 40 persons per square mile and no
 9 community with 25,000 or more persons within 20 miles). Approximately 160,211 people live
 10 within 50 miles of CNS-1 (NPPD, 2008). This equates to a population density of 20 persons per
 11 square mile. Applying the *Generic Environmental Impact Statement (GEIS) for License Renewal*
 12 *of Nuclear Plants* NUREG-1437 proximity measures, CNS-1 is classified as proximity Category
 13 1 (no city with 100,000 or more persons and less than 50 persons per square mile within 50
 14 miles). Therefore, according to the sparseness and proximity matrix presented in the GEIS,
 15 CNS-1 rankings of sparseness Category 1 and proximity Category 1 result in the conclusion that
 16 CNS-1 is located in a low population area.

17 Table 2.2.8.5-1 shows population projections and growth rates from 1970 to 2050 in Nemaha,
 18 Otoe, and Richardson County, Nebraska, and Atchison County, Missouri. The growth rate in
 19 Nemaha County showed a decrease of 5.1 percent for the period of 1990 to 2000. County
 20 populations are expected to continue to decline in Nemaha, Richardson, and Atchison counties
 21 in the next decades although Otoe County’s population is expected to increase through 2050.

22 **Table 2.2.8.5-1. Population and Percent Growth in Nemaha, Otoe, and Richardson**
 23 **County, Nebraska, and Atchison County, Missouri, from 1970 to 2000 and projected for**
 24 **2006 to 2050**

Year	Nemaha, NE		Otoe, NE		Richardson, NE		Atchison, MO	
	Population	Percent Growth ^a	Population	Percent Growth ^a	Population	Percent Growth ^a	Population	Percent Growth ^a
1970	8,976	—	15,576	—	12,277	—	9,240	—
1980	8,367	-6.8	15,183	-2.5	11,315	-7.8	8,605	-6.9
1990	7,980	-4.6	14,252	-6.1	9,937	-12.2	7,457	-13.3
2000	7,576	-5.1	15,396	8.0	9,531	-4.1	6,430	-13.8
2007	7,039	-7.1	15,647	1.6	8,351	-12.4	6,108	-5.0
2010	6,767	-10.7	15,704	2.0	8,408	-11.8	5,927	-7.8
2020	6,456	-4.6	16,399	4.4	7,892	-6.1	5,559	-6.2
2030	6,033	-6.6	17,414	6.2	7,398	-6.3	5,280	-5.0
2040	5,685	-5.8	18,216	4.6	6,889	-6.9	4,942	-6.4
2050	5,318	-6.5	19,071	4.7	6,384	-7.3	4,618	-6.5

— = No data available.

^aPercent growth rate is calculated over the previous decade.

Sources: Population data for 1970 through estimated population data for 2006 (USCB, 2009); population projections for 2010–2030 by Bureau of Business Research (BBR), University of Nebraska-Lincoln, Nebraska Population Projections (2008) and Missouri State Demographer, Office of Administration, No Date; population projections for 2040 and 2050 (calculated).

Affected Environment

1 Demographic Profile

2 The 2000 and 2006 (estimate) demographic profiles of the four-county ROI population is
 3 presented in Table 2.2.8.5-2 and Table 2.2.8.5-3. In 2000, minorities (race and ethnicity
 4 combined) comprised 3.8 percent of the total four-county population. The minority population is
 5 composed of Hispanic or Latino and American Indian residents.

6 **Table 2.2.8.5-2. Demographic Profile of the Population in the Cooper Nuclear Station**
 7 **Unit 1 Four-County Socioeconomic Region of Influence in 2000**

	Nemaha, NE	Otoe, NE	Richardson, NE	Atchison, MO	Region of Influence
Total Population	7,576	15,396	9,531	6,430	38,933
Race (percent of total population, Not-Hispanic or Latino)					
White	97.1	96.3	95.1	96.6	96.2
Black or African American	0.4	0.2	0.2	2.1	0.5
American Indian and Alaska Native	0.2	0.2	2.1	0.2	0.7
Asian	0.6	0.2	0.1	0.1	0.3
Native Hawaiian and Other Pacific Islander	0.0	0.0	0.0	0.0	0.0
Some other race	0.0	0.0	0.0	0.0	0.0
Two or more races	0.6	0.6	1.4	0.3	0.7
Ethnicity					
Hispanic or Latino	76	377	100	43	596
Percent of total population	1.0	2.4	1.0	0.7	1.5
Minority Population (including Hispanic or Latino ethnicity)					
Total minority population	218	574	469	219	1,480
Percent minority	2.9	3.7	4.9	3.4	3.8

8 Source: USCB, 2009

9 According to the USCB's 2007 estimates published in 2009, minority populations in the four-
 10 county region were estimated to have increased by over 500 persons and comprised 5.4
 11 percent of the total four county population (see Table 2.2.8.5-3). Most of this increase was due
 12 to an estimated influx of Hispanic or Latinos (over 320 persons), an increase in population of
 13 over 55 percent from 2000. This was the largest percentage increase of any minority population
 14 and a one percent increase in Hispanic or Latino population when compared to the total four-
 15 county population. The next highest percentage increase in minority population was Asian, an
 16 increase of over 51 percent from 2000. However, this resulted in only a very slight increase in
 17 population as a percentage of the total four-county population.

1 **Table 2.2.8.5-3. Demographic Profile of the Population in the Cooper Nuclear Station**
 2 **Four-County Socioeconomic Region of Influence in 2007, Estimated**

	Nemaha, NE	Otoe, NE	Richardson, NE	Atchison, MO	Region of Influence
Total Population	7,039	15,647	8,351	6,108	37,145
Race (percent of total population, not Hispanic or Latino)					
White	95.9	94.1	93.9	95.6	94.6
Black or African American	0.6	0.5	0.3	2.3	0.7
American Indian and Alaska Native	0.3	0.4	2.6	0.3	0.9
Asian	0.8	0.3	0.5	0.3	0.4
Native Hawaiian and Other Pacific Islander	0.0	0.0	0.0	0.0	0.0
Some other race	*	*	*	*	*
Two or more races	0.6	0.8	1.4	0.3	0.8
Ethnicity					
Hispanic or Latino	126	612	111	73	922
Percent of total population	1.8	3.9	1.3	1.2	2.5
Minority Population (including Hispanic or Latino ethnicity)					
Total minority population	288	930	506	269	1,993
Percent minority	4.1	5.9	6.1	4.4	5.4

3 * Some other race was eliminated from the Census estimate.

4 Source: USCB, 2009

5 Transient Population

6 Within 50 miles (80 km) of the CNS-1, colleges and recreational opportunities attract daily and
 7 seasonal visitors who create demand for temporary housing and services. In 2009, there were
 8 approximately 8,018 students attending colleges and universities within 50 miles (80 km) of the
 9 CNS-1 (IES, 2009).

10 In 2000 in Nemaha County, 1.6 percent of all housing units are considered temporary housing
 11 for seasonal, recreational, or occasional use. By comparison, seasonal housing accounted for
 12 0.6 percent, 1.3 percent, and 1.6 percent of total housing units in Otoe and Richardson counties
 13 and Nebraska, respectively (USCB, 2009). Seasonal housing accounted for 1.2 percent and
 14 2.7 percent of total housing units in Atchison County and Missouri, respectively (USCB, 2009).
 15 Table 2.2.8.5-4 provides information on seasonal housing for the 24 counties located all or
 16 partly within 50 miles of the CNS-1.

1 **Table 2.2.8.5-4. Seasonal Housing in Counties Located within 50 Miles of the Cooper**
 2 **Nuclear Station, Unit 1**

County ^a	Housing units	Vacant housing units: For seasonal, recreational, or occasional use	Percent	
Iowa	1,232,511	16,472	1.3	
Fremont	3,514	56	1.6	
Mills	5,671	64	1.1	
Montgomery	5,399	38	0.7	
Page	7,302	47	0.6	
Taylor	3,199	19	0.6	
County Subtotal	25,085	224	0.9	(avg.)
Kansas	1,131,200	9,639	0.9	
Atchison	6,818	47	0.7	
Brown	4,815	36	0.7	
Doniphan	3,489	28	0.8	
Jackson	5,094	42	0.8	
Marshall	4,999	46	0.9	
Nemaha	4,340	35	0.8	
County Subtotal	29,555	234	0.8	(avg.)
Missouri	2,442,017	66,053	2.7	
Andrew	6,662	58	0.9	
Atchison	3,103	38	1.2	
Holt	2,931	391	13.3	
Nodaway	8,909	60	0.7	
County Subtotal	21,605	547	4.0	(avg.)
Nebraska	722,668	11,912	1.6	
Cass	10,179	541	5.3	
Gage	10,030	56	0.6	
Johnson	2,116	14	0.7	
Lancaster	104,217	303	0.3	
Nemaha	3,439	56	1.6	
Otoe	6,567	37	0.6	
Pawnee	1,587	78	4.9	
Richardson	4,560	59	1.3	
Sarpy	44,981	211	0.5	
County Subtotal	187,676	1,355	1.7	(avg.)
County Total	263,921	2,360	1.2	(avg.)

Source: USCB, 2009

^a Counties within 50 miles of the CNS-1 that are totally or partially located within the 50-mile radius.
 avg. = percent average for counties within the CNS-1 50-mile radius and excludes State percentage.

1 Migrant Farm Workers

2 Migrant farm workers are individuals whose employment requires travel to harvest agricultural
3 crops. These workers may or may not have a permanent residence. Some migrant workers
4 follow the harvesting of crops, particularly fruit, throughout rural areas of the United States.
5 Others may be permanent residents near the CNS-1 who travel from farm to farm harvesting
6 crops.

7 Migrant workers may be members of minority or low-income populations. Because they travel
8 and can spend a significant amount of time in an area without being actual residents, migrant
9 workers may be unavailable for counting by census takers. If uncounted, these workers would
10 be “underrepresented” in USCB minority and low-income population counts.

11 Information on migrant farm and temporary labor was collected in the 2007 Census of
12 Agriculture. Table 2.2.8.5-5 provides information on migrant farm workers and temporary farm
13 labor (less than 150 days) within 50 miles of the CNS-1. According to the 2007 Census of
14 Agriculture, approximately 7,000 farm workers were hired to work for less than 150 days and
15 were employed on 3,300 farms within 50 miles of the CNS-1. The county with the largest
16 number of temporary farm workers (774 workers on 280 farms) was Lancaster County,
17 Nebraska (USDA, 2009).

18 In the 2007 Census of Agriculture, farm operators were asked for the first time whether or not
19 any hired migrant workers, defined as a farm worker whose employment required travel that
20 prevented the migrant worker from returning to their permanent place of residence the same
21 day. A total of 87 farms in the 50-mile radius of the CNS-1 reported hiring migrant workers in the
22 2007 Census of Agriculture. Nodaway County, Missouri, and Lancaster County, Nebraska
23 reported the most farms (18 and 17, respectively) with hired migrant workers, followed by
24 Nemaha County, Nebraska with 10 farms (USDA, 2009).

25 According to the 2007 Census of Agriculture estimates, 195 temporary farm laborers (those
26 working fewer than 150 days per year) were employed on 84 farms in Nemaha County, and 311
27 and 323 temporary farm workers were employed on 145 and 143 farms in Otoe and Richardson
28 counties, respectively (USDA, 2009). Atchison County, Missouri, had 226 temporary farm
29 workers employed on 99 farms (USDA, 2009).

1 **Table 2.2.8.5-5. Migrant Farm Workers and Temporary Farm Labor in Counties Located**
 2 **within 50 Miles of the Cooper Nuclear Station, Unit 1**

County ^a	Number of farms with hired farm labor ^b	Number of farms hiring workers for less than 150 days ^b	Number of farm workers working for less than 150 days ^b	Number of farms reporting migrant farm labor ^b
Iowa	23,287	19,204	50,266	123
Fremont	126	95	247	2
Mills	91	70	NA	0
Montgomery	118	100	187	0
Page	189	158	276	0
Taylor	134	103	259	1
County Subtotal	658	526	969	3
Kansas	14,437	11,558	30,682	193
Atchison	115	105	231	0
Brown	171	142	333	3
Doniphan	130	108	211	0
Jackson	145	128	319	2
Marshall	246	209	498	3
Nemaha	289	250	584	10
County Subtotal	1,096	942	2,176	18
Missouri	18,263	15,052	33,424	745
Andrew	134	113	258	2
Atchison	134	99	226	2
Holt	136	105	214	1
Nodaway	308	251	472	18
County Subtotal	712	568	1,170	23
Nebraska	14,603	11,261	29,583	468
Cass	148	119	273	4
Gage	322	272	585	7
Johnson	120	105	NA	5
Lancaster	310	280	774	17
Nemaha	107	84	195	3
Otoe	175	145	311	2
Pawnee	91	83	NA	0
Richardson	164	143	323	3
Sarpy	87	69	218	2
County Subtotal	1,524	1,300	2,679	43
County Total	3,990	3,336	6,994	87

Source: 2007 Census of Agriculture - County Data (USDA, 2009)

^a Counties within 50 miles of the CNS-1 that are totally or partially located within the 50-mile radius

^b Table 7. Hired Farm Labor - Workers and Payroll: 2007

1 2.2.8.6 *Economy*

2 This section contains a discussion of the economy, including employment and income,
3 unemployment, and taxes.

4 Employment and Income

5 Between 2000 and 2007, the civilian labor force in Nemaha County decreased 9.4 percent from
6 3,931 to 3,560. During the same time period, the civilian labor force in Otoe County grew by 13
7 percent. By 2007, the civilian labor force in Richardson and Atchison counties decreased by
8 6.3 and 2.4 percent, respectively (USCB, 2009).

9 In 2000, educational, health, and social services represented the largest sector of employment
10 in the four-county region followed by manufacturing. The educational, health, and social
11 services sector employed the most people in Nemaha County followed by transportation,
12 warehousing, and utilities sectors. A list of some of the major employers in Nemaha County is
13 provided in Table 2.2.8.6-1. As shown in the table, the largest employer in Nemaha County is
14 the CNS-1.

15 **Table 2.2.8.6-1. Major Employers in Nemaha County**

Firm	Number of Employees
Cooper Nuclear Station	750
Armstrong Cabinets	162
Peru State College	160
Auburn Public Schools	142
Nemaha County Good Samaritan Home	75
Magnolia Metals, Inc.	65
Nemaha County Hospital	65
Nemaha County Government	48
Johnson-Brock Public Schools	44

Source: NDE, 2009 and NPPD, 2009

16 Estimated income information for the CNS-1 region of influence is presented in Table 2.2.8.6-2.
17 According to the USCB's 2007 estimates, median household income averages in Nemaha,
18 Otoe, Richardson, and Atchison counties were below their respective State median household
19 income averages. In 1999, per capita income in the four counties was also below both State
20 averages. In 2007, an estimated 13.3 and 13.4 percent of the county populations in Nemaha
21 and Richardson counties were living below the official poverty level, while the percentage for the
22 State of Nebraska as a whole was 11.1 percent. Conversely, Otoe County was estimated to
23 have the smallest percentage of persons living in poverty (9.4 percent). In Atchison County an
24 estimated 14.0 percent of the county population was living below the official poverty level, while
25 the percentage for the State of Missouri as a whole was 13.3 percent.

1 **Table 2.2.8.6-2. Estimated Income Information for the Cooper Nuclear Station Region of**
 2 **Influence in 2007**

	Nemaha	Otoe	Richardson	Nebraska	Atchison	Missouri
Median household income (dollars)	41,024	45,018	36,092	47,072	38,114	45,012
Per capita income in 1999 (dollars)	17,004	17,752	16,460	19,613	16,956	19,936
Percent of individuals living below the poverty level	13.3	9.4	13.4	11.1	14.0	13.3

3 Source: USCB 2009

4 Unemployment

5 According to the USCB's 2007 estimates, the unemployment rates in Nemaha, Otoe, and
 6 Richardson counties were 3.9, 3.0 and 4.0 percent, respectively, which was slightly lower than
 7 the unemployment rate of 4.8 percent for the State of Nebraska (USCB, 2009). The
 8 unemployment rate in Atchison County was 4.3 percent, which was much lower than the
 9 6.5 percent for the State of Missouri (USCB, 2009).

10 Taxes

11 As a not-for-profit public corporation and political subdivision of the State of Nebraska, NPPD is
 12 exempt from paying income or property taxes. Instead, in lieu of tax, other payments are made
 13 to State, county, and local governments in which NPPD provides retail electric power.

14 According to the Nebraska State Constitution Article VIII, Section 11:

15 Every public corporation and political subdivision organized primarily to provide
 16 electricity or irrigation and electricity shall annually make the same payments in
 17 lieu of taxes as it made in 1957, which payments shall be allocated in the same
 18 proportion to the same public bodies or their successors as they were in 1957.

19 The legislature may require each such public corporation to pay to the treasurer
 20 of any county in which may be located any incorporated city or village, within the
 21 limits of which such public corporation sells electricity at retail, a sum equivalent
 22 to five (5) per cent of the annual gross revenue of such public corporation derived
 23 from retail sales of electricity within such city or village, less an amount
 24 equivalent to the 1957 payments in lieu of taxes made by such public corporation
 25 with respect to property or operations in any such city or village. The payments in
 26 lieu of taxes as made in 1957, together with any payments made as authorized in
 27 this section shall be in lieu of all other taxes, payments in lieu of taxes, franchise
 28 payments, occupation and excise taxes, but shall not be in lieu of motor vehicle
 29 licenses and wheel taxes, permit fees, gasoline tax and other such excise taxes
 30 or general sales taxes levied against the public generally.

31 So much of such five percent as is in excess of an amount equivalent to the
 32 amount paid by such public corporation in lieu of taxes in 1957 shall be
 33 distributed in each year to the city or village, the school districts located in such
 34 city or village, the county in which such city or village is located, and the State of
 35 Nebraska, in the proportion that their respective property tax mill levies in each
 36 such year bear to the total of such mill levies (Neb. Const. art. VIII, sec. 11
 37 (1958); Adopted 1958,).

1 NPPD is Nebraska's largest electric utility, with a chartered territory including all or parts of 91 of
 2 Nebraska's 93 counties. NPPD pays monies in lieu of property taxes to the counties in which it
 3 provides retail electric power. As part of NPPD's generation capacity, a portion of the in lieu of
 4 tax payments and payments to retail communities may be attributed to CNS-1.

5 NPPD paid approximately \$6.6 million in 2006 and \$7.0 million in 2007 in lieu of taxes to the 91
 6 counties in which NPPD is chartered (NPPD, 2008). Each county receives 5 percent of the total
 7 gross revenues NPPD receives from electricity sales within the county. The actual in lieu of tax
 8 allocation attributable to CNS-1 is not recorded by NPPD. NPPD's power generation units
 9 provide power to the grid, and county retail sales are then from the grid. However, CNS-1
 10 represents approximately 24 percent of NPPD's power generation capacity. Based on 24
 11 percent generation, the payments in lieu of tax that could be attributed to CNS-1 were
 12 approximately \$1.6 million in 2006 and \$1.7 million in 2007 (see Table 2.2.8.6-3).

13 NPPD also pays back 12 percent of the total gross revenues received from retail communities,
 14 which amounted to approximately \$17.5 million in 2006 and \$18.3 million in 2007 (NPPD, 2008).
 15 Based on 24 percent of NPPD's total generation capacity, CNS-1's contribution to retail
 16 communities was \$4.2 million in 2006 and \$4.4 million in 2007 (see Table 2.2.8.6-3).

17 Since NPPD's charter is to provide electricity to customers throughout the State, these
 18 payments would continue regardless of whether or not the CNS-1 is operating.

19 NPPD pays sales/use taxes on purchases made by CNS-1. As shown in Table 2.2.8.6-3,
 20 CNS 1 paid \$943,020 in sales/use taxes in 2007; \$1,353,435 in 2006. City sales taxes are paid
 21 to the town of Auburn, Nebraska. NPPD also pays a special assessment for the Brownville-
 22 Nemaha Levee District that is paid to the county treasurer (NPPD, 2008b). As shown in Table
 23 2.2.8.6-3, the total taxes and payments to the State, counties, and retail communities
 24 attributable to CNS-1 in 2006 were approximately \$7.2 million and \$7.1 million in 2007.

25 **Table 2.2.8.6-3. Cooper Nuclear Station, Unit 1 Estimated Tax Distribution, 2005–2007**

Tax	2005	2006	2007
Nebraska State Sales/Use Tax	\$1,082,780	\$1,353,435	\$943,020
City of Auburn, NE Sales/Use Tax	240	455	40
Special Assessment on Brownville-Nemaha Levee Paid to Nemaha County	5,090	5,090	5,090
Nemaha County, NE Real Estate Taxes	10,865	10,980	11,140
Atchison County, MO Real Estate Taxes	145	145	140
Nebraska in Lieu of Taxes to Counties with NPPD Retail Electric Sales Attributed to the CNS-1	1,607,135	1,595,752	1,687,056
Payments to Retail Communities Attributed to CNS-1	4,267,771	4,233,381	4,436,089
Total	\$6,976,031	\$7,201,244	\$7,084,582

26 Source: NPPD, 2008b

1 **2.2.9 Historic and Archaeological Resources**

2 This section discusses the cultural background and the known historic and archaeological
3 resources at the CNS-1 site and in the surrounding area.

4 **2.2.9.1 Cultural Background**

5 CNS-1 is located on a 1,120 acre tract in the floodplain on the west bank of the Missouri River in
6 Nemaha County, Nebraska. To the west of the site are bluffs. CNS-1 also owns an additional
7 239 acres on the eastern side of the river in Atchison County, Missouri. The eastern bank is a
8 densely forested area that periodically floods, with bluffs that run parallel to the river. The region
9 around CNS-1 site contains prehistoric and historic Native American and Euro-American cultural
10 resources. Twelve properties in Nemaha County are listed in the *National Register of Historic*
11 *Places* (NRHP) (NPS, 2009). The nearest NRHP property is the Captain Meriwether Lewis
12 Dredge. Seven NRHP properties are located in Atchison County.

13 **2.2.9.2 Prehistoric Periods**

14 First Arrivals

15 CNS-1 is situated in the Missouri River Valley on the eastern edge of the Central Great Plains
16 and northwest edge of the Missouri Prairie-Timberlands. The first peoples began emigrating into
17 the region toward the end of the Pleistocene (pre-Clovis ca. 11,500 years ago). There is a
18 growing body of evidence indicating that a "First Arrivals" archeological period (circa. 13,000
19 and 17,000 years ago) preceded the Paleo-Indian period. A handful of sites in the Central Plains
20 date between about 13,000 and 17,000 years ago, however, most of these sites have limited
21 evidence of human occupation (Hofman, 1996). Acceptance of archeological remains older than
22 the long accepted Clovis Culture remains controversial (Hofman, 1996; Holen, 1994).

23 Paleo-Indian Period

24 The Clovis Culture (ca. 11,500 years ago) is the earliest dated and accepted evidence of human
25 habitation during the Paleo-Indian period in the New World. The climate during the Paleo-Indian
26 period was much cooler and wetter than today. The eastern edge of the Central Plains was
27 broad open grassland occupied by great herds of now extinct animals. Paleo-Indian populations
28 were highly mobile and left little evidence of their activities. Most Paleo-Indian sites would have
29 been short-term occupations (campsites). Paleo-Indian peoples subsisted on hunted game and
30 gathered plant material. Distinctive point styles and variations in other tool types defined the
31 Clovis, Folsom, Midland, and later Paleo-Indian groups (Hofman, 1996). To date, no early sites
32 have been identified in Nemaha or Atchison counties, but such resources may exist as deeply
33 buried deposits along relic terraces.

34 Archaic Period

35 During the Archaic Period, subsistence hunting and gathering underwent changes to adapt to
36 resource availability. As glaciers retreated northward and larger animals disappeared from the
37 region, humans adapted to modern plants and smaller game animals. The Dalton Culture
38 (circa 8,500 to 7,500 years ago) is generally identified as late Paleo-Indian or Early Archaic
39 period or as a transition between the two (O'Brien and Wood, 1995). The Archaic period is
40 subdivided into the following periods: Early Archaic Logan Creek Complex (circa 7,500 to 6,000
41 years ago), Middle Archaic Jacomo Complex (circa 5,500 to 5,000 years ago) and Late Archaic
42 Nebo Hill Complex (circa 4,500 to 2,500 years ago). Early Archaic people did not appear to
43 establish permanent settlements, though there is evidence that some locations were utilized

1 frequently. Archaic people collected, hunted, and gathered most of what they needed for
2 survival in their home territory with a wider range of tools.

3 Climatic conditions during the Archaic Period entered a warmer/dryer phase around 5,500 years
4 ago. Late Archaic cultures began to settle in the Missouri River Valley about 3,000 years ago.
5 Archaeological evidence indicates that larger; semi-permanent warm weather settlements were
6 established along the higher terraces, while winter encampments were located in upland areas
7 along small streams. Archaic sites identified in the CNS-1 area typically consist of lithic scatters
8 with various dart points identified as "Archaic".

9 Woodland Period

10 The Woodland period (circa. 2,500 to 1,000 years ago) is defined by the introduction of
11 agriculture to augment subsistence hunting and gathering. The reliance on agriculture led to the
12 establishment of permanent settlements during this period. Other characteristics of Woodland
13 culture include increased population, emergence of social hierarchy, expanded interregional
14 trade, elaborate ceremonialism with stone-lined graves and burial mounds, and the introduction
15 of the bow and arrow.

16 During the middle Woodland period (circa 2,000 to 1,500 years ago), indigenous groups began
17 increasing in population). Woodland peoples spread along valleys over the entire eastern half of
18 Nebraska, western part of Iowa, and parts of South Dakota and Kansas. These people were
19 forager-gardeners living in small villages along the higher valley terraces. Several Middle
20 Woodland sites have been identified in Nemaha and Atchison counties.

21 During the late Woodland period (circa 1,500 to 1,100 years ago), larger middle Woodland
22 villages were abandoned in favor of smaller camps and individual home sites, generally in the
23 uplands away from the river bottoms. The number of burial mounds increased dramatically.
24 Most of the mounds were small and low with distinctive rock structures. Many mounds have
25 been lost to plowing, but rock structures around graves are commonly found on bottom terraces
26 and points on both sides of the river.

27 Plains Village Period

28 Around 1,000 years ago, most groups had established permanent villages. The Plains Village
29 peoples were farmers and bison hunters living in larger villages along the river terraces. Smaller
30 hamlets, hunting camps, and kill sites have also been recorded in the uplands. This culture
31 disappeared about 700 years ago for unknown reasons. Climatic conditions during this time
32 were becoming warmer and dryer, and drought may have forced people out of traditional
33 farming areas. Additionally, there was an influx of people coming onto the Plains from the
34 northeast and west that may have made living in the region untenable.

35 2.2.9.3 *Historic Period*

36 Historic Tribes and Fur Traders

37 The eighteenth and nineteenth centuries brought the first wave of Europeans to the east Central
38 Plains region. French, and later Spanish land claims, inspired trade and exploration of the
39 Missouri River Valley. French fur traders were known to visit the area. Indian populations were
40 subsequently displaced.

41 Traffic along the Missouri River increased after the Louisiana Purchase in 1803. The Lewis and
42 Clark expedition of 1804 paved the way for subsequent U.S. military expeditions and the

Affected Environment

1 establishment of trading posts and missions. On July 13, 1804, the Lewis and Clark expedition
2 passed the remains of a trading post said to have been where Benet of St. Louis traded with the
3 Otoe and Pawnee for two years. Other American Indian groups that passed through the area
4 included the Omaha, Osage, Delaware, Pottawatomi, Sauk and Fox, Winnebago, and Miami.

5 On July 15, 1804, the Lewis and Clark party camped along a rise on the west side of a bend in
6 the river. There is some dispute about the actual location of the encampment. Nebraska
7 researchers place the camp on the Missouri side of the present river channel and Missouri
8 historians place the camp roughly where the CNS-1 is located.

9 Historic accounts of the Lewis and Clark expedition describe a beautiful valley filled with grape
10 vines and wild cherries, which first attracted settlers to the area in the 1840s
11 (Plamondon, 2000). Settlement was gradual, but steadily spread along the eastern side of the
12 river (National Historical Company, 1882). The Kansas-Nebraska Act of 1854 created the
13 Nebraska Territory. Nemaha County was established a year later (Heritage, 2004). Settlement
14 along the river increased in the 1850s with Brownville, Nebraska, being established as a major
15 steamboat port and shipping point. The towns of Nemaha, Brownville, and Peru prospered
16 along the bluffs above the Missouri River, and settlement of the interior away from the river
17 remained low until the Nebraska Railway Company reached the area in 1874 (Heritage, 2004).
18 An 1865 Government Land Office plat showed two farmsteads located on or near the area
19 occupied by the CNS-1. By 1911, there were nine homesteads and a school.

20 The arrival of railroads spurred the development of the interior areas away from the river at the
21 expense of the towns located along the bluff tops. Brownville rapidly declined because of this.
22 The building of the Brownville Bridge in 1939 connected the two sides of the river but did little to
23 alleviate the town's economic downfall.

24 Construction of CNS-1 began in 1968. Consumers Public Power District (CPPD) planned and
25 financed the construction and became NPPD on January 1, 1970 (NPPD, 2008).

26 **2.2.10 Historic and Archaeological Resources at the Cooper Nuclear Station, Unit 1 Site**

27 No prehistoric or historic sites listed or eligible for listing on the NRHP or the State historic
28 registers are located on the CNS-1 site. Historic archaeological sites have been identified within
29 a 6-mile radius of the site. A great deal of archaeological and historical research has been
30 conducted within both Nemaha County, Nebraska and Atchison County, Missouri. The bluffs
31 along either side of the Missouri River and the higher terraces along the river valley bottom
32 lands were favored habitation sites for prehistoric and historic people.

33 Only one previous historical survey has been conducted on the CNS-1 property. This survey
34 evaluated the eligibility of the William Dawson House located in the southwest corner of the
35 CNS-1 site near the bluff for listing on the NRHP. The William Dawson House (Site # NH00-69)
36 was recorded in Nebraska historic archives but was not included on the NRHP. The Dawson
37 House was torn down in 1970, shortly after it was recorded.

38 A formal survey of the entire CNS-1 property has not been completed, however, a number of
39 archaeological surveys have been conducted in the surrounding area. In the 1930s, A.T. Hill
40 and Paul Cooper walked the bluffs along both sides of the river valley in search of Woodland
41 mound sites. The Whitten Archeological Site, Archeological Survey No. 25NH4, was excavated
42 along the bluffs north of the CNS-1 site. Despite the fact that the mounds were reportedly
43 leveled by cultivation, excavations succeeded in locating two concentrations of human remains

1 along with grave goods and other artifacts (Hill and Cooper, 1937). The Nebraska State
 2 Historical Society Site Survey Form notes that: "... (two) skeletons were sent to U.S. National
 3 Museum in accordance with our WPA (Works Progress Administration) contract." The note is
 4 dated June 21, 1944. It is unclear from the archaeological site description if the Whitten site
 5 extended onto the CNS-1 property.

6 In April 2007 and March 2008, NPPD contracted with Enercon Services, Inc. to conduct a
 7 Phase 1A Literature Review and Archeological Sensitivity Assessment for the CNS-1 site. The
 8 55 acres occupied by the CNS-1 were heavily disturbed. The Enercon study identified two
 9 probable prehistoric lithic scatters and three former historic home sites on the CNS-1 site. The
 10 report also noted the potential for additional prehistoric and historic resources to be found
 11 throughout the area. Enercon also noted the potential for a camp site occupied by the Lewis and
 12 Clark Expedition in 1804 being located on CNS-1 property. The exact location of this campsite
 13 remains unknown.

14 **2.3 RELATED FEDERAL AND STATE ACTIVITIES**

15 The NRC staff reviewed the possibility that activities of other Federal agencies might impact the
 16 renewal of the operating license for the CNS-1. Any such activity could result in cumulative
 17 environmental impacts and the possible need for a Federal agency to become a cooperating
 18 agency in the preparation of the CNS-1 SEIS.

19 The NRC has determined that there are no Federal projects that would make it desirable for
 20 another Federal agency to become a cooperating agency in the preparation of the SEIS.
 21 Federal lands, facilities, national wildlife refuges, forests, and parks within 50 miles of the CNS-1
 22 are listed below.

- 23 • Langdon Bend, 1 mile south-southeast (USACE)
- 24 • Derion Bend, 8 miles southeast (USACE)
- 25 • Nishnabotna, 9 miles north-northwest (USACE)
- 26 • Corning, 12 miles southeast (USACE)
- 27 • Kansas Bend, 12 miles north-northwest (USACE)
- 28 • Thurnau, 15 miles southeast (USACE)
- 29 • Lower Hamburg Bend, 15 miles north-northwest (USACE)
- 30 • Hamburg Bend, 17 miles north-northwest (USACE)
- 31 • Rush Bottom Bend, 22 miles southeast (USACE)
- 32 • Sac and Fox Reservation, 23 miles south-southeast (U.S. Department of
 33 the Interior, Bureau of Indian Affairs)
- 34 • Iowa Reservation, 26 miles south-southeast (U.S. Department of the
 35 Interior, Bureau of Indian Affairs)

Affected Environment

- 1 • Squaw Creek National Wildlife Refuge, 28 miles southeast (USFWS)
- 2 • Copeland Bend, 29 miles north-northwest (USACE)
- 3 • Auldson Bar, 36 miles north-northwest (USACE)
- 4 • Noddleman Island, 39 miles north-northwest (USACE)
- 5 • Tobacco Island, 43 miles north-northwest (USACE)

6 NRC is required under Section 102(2)(c) of the National Environmental Policy Act of 1969
7 (NEPA) to consult with and obtain the comments of any Federal agency that has jurisdiction by
8 law or special expertise with respect to any environmental impact involved. Federal Agency
9 consultation correspondence and comments on the SEIS are presented in Appendix E.

10 **2.4 REFERENCES**

- 11 10 CFR Part 20. *Code of Federal Regulations*, Title 10, *Energy*, Part 20, “Standards for
12 Protection Against Radiation.”
- 13 10 CFR Part 50. *Code of Federal Regulations*, Title 10, *Energy*, Part 50, “Domestic Licensing of
14 Production and Utilization Facilities.”
- 15 10 CFR Part 61. *Code of Federal Regulations*, Title 10, *Energy*, Part 61, “Licensing
16 Requirements for Land Disposal of Radioactive Waste.”
- 17 10 CFR Part 71. *Code of Federal Regulations*, Title 10, *Energy*, Part 71, “Packaging and
18 Transportation of Radioactive Material.”
- 19 50 CFR Part 22. *Code of Federal Regulations*, Title 50. *Wildlife and Fisheries*, Part 22,
20 “Pastports and Visas.”
- 21 Abell, R., Olson, D., et al. 2000. *Freshwater Ecoregions of North America*. Island Press,
22 Washington, D.C.
- 23 Abell, R., et al. 2008. *Freshwater Ecoregions of the World: A New Map of Biogeographic Units*
24 *for Freshwater Biodiversity Conservation*. *BioScience* 58(5), pp. 403–414.
- 25 Bailey, G. 2007. Personal communication with K. Shannon, Enercon Services, Nebraska Game
26 and Park Commission. January 25, 2007. Lincoln, Nebraska. ADAMS Accession No.
27 ML092400166.
- 28 Barbour, M.T., J. Gerritsen, B.D. Snyder, and J.B. Stribling. 1999. *Rapid Bioassessment*
29 *Protocols for Use in Streams and Wadeable Rivers: Periphyton, Benthic Macroinvertebrates*
30 *and Fish*. Second Edition. EPA 841-B-99-002. U.S. Environmental Protection Agency; Office of
31 Water; Washington, D.C.
- 32 Benedict, R.A., P.W. Freeman, and H.H. Genoways. 1996. Chapter 11: Prairie Legacies—
33 Mammals. Pages 149-160 in F.B. Samson and F.L. Knopf (eds.), *Prairie Conservation:*
34 *Preserving North America’s Most Endangered Ecosystem*. Island Press, Washington, D.C.
- 35 Black-footed Ferret Recovery Implementation Team. 2009. Black-footed ferret Recovery
36 Program. Ferret Facts. Available URL: <http://www.blackfootedferret.org/history-decline.htm>
37 (accessed July 30, 2009).

- 1 Bureau of Business Research (BBR). 2008. University of Nebraska-Lincoln. College of Business
 2 Administration. Nebraska Population Projections, 2005, 2010, 2015, 2020, 2025, and 2030.
 3 Available URL: <http://www.bbr.unl.edu/PopProjections/> (accessed April 17, 2009).
- 4 Carter, S.R., K.R. Bazata, and D.L. Anderson. 1982. Chapter 7: Macroinvertebrate communities
 5 of the channelized Missouri River near Two Nuclear Power Stations. Hesse, L.W., G.L.
 6 Hergenrader, H.S. Lewis, S.D. Reetz, and A.B. Schlesinger (eds.), *The Middle Missouri River: A*
 7 *Collection of Papers on the Biology with Special Reference to Power Station Effects*. The
 8 Missouri River Group, Norfolk, Nebraska, pp. 146–182.
- 9 Conestoga Rover and Associates (CRA). 2007. Hydrogeologic Investigation Work Plan, Ground
 10 Water Protection Initiative, Cooper Nuclear Station, Brownsville, Nebraska.
- 11 Cornell University. 2008. Insect Conservation Biology. *Cicindela nevadica lincolniana*, Salt
 12 Creek tiger beetle. Available URL: [http://courses.cit.cornell.edu/icb344/abstracts/salt-creek-](http://courses.cit.cornell.edu/icb344/abstracts/salt-creek-tiger-beetle.htm)
 13 [tiger-beetle.htm](http://courses.cit.cornell.edu/icb344/abstracts/salt-creek-tiger-beetle.htm) (accessed March 9, 2009).
- 14 Daily, G.C., S. Alexander, P.R. Ehrlich, L. Goulder, J. Lubchenco, P.A. Matson, H.A. Mooney,
 15 S. Postel, S.H. Schneider, D. Tilman, and G.M. Woodwell. 1997. *Ecosystem services: Benefits*
 16 *supplied to human societies by natural ecosystems*. Issues in Ecology 2:1–16.
- 17 Defenders of Wildlife. 2009. Black-footed ferret (*Mustela nigripes*). Available URL:
 18 http://www.defenders.org/wildlife_and_habitat/wildlife/black-footed_ferret.php
 19 (accessed March 9, 2009).
- 20 Dryer, M.P., and A.J. Sandvol 1993. "Recovery plan for the pallid sturgeon *Scaphirhynchus*
 21 *albus*." U.S. Fish and Wildlife Service, Bismarck, North Dakota. 55 pp.
- 22 Environmental Protection Agency (EPA). 1974. "Information on Levels of Environmental Noise
 23 Requisite to Protect Public Health and Welfare with an Adequate Margin of Safety." Report
 24 550/9-74-004, Washington, D.C. Available URL:
 25 <http://www.nonoise.org/library/levels74/levels74.htm>. March. (See also "EPA Identifies Noise
 26 Levels Affecting Health and Welfare." September 21, 2007. Available URL:
 27 <http://www.epa.gov/history/topics/noise/01.htm>.) (accessed March 2, 2009).
- 28 Environmental Protection Agency (EPA). 2002. *Short-term Methods for Estimating the Chronic*
 29 *Toxicity of Effluents and Receiving Waters to Freshwater Organisms*, Fourth Edition. EPA-821-
 30 R-02-013. Office of Water, Washington, D.C.
- 31 Environmental Protection Agency (EPA). 2009a. "Office of Solid Waste." Available URL:
 32 <http://www.epa.gov/osw/> (accessed May 2009).
- 33 Environmental Protection Agency (EPA). 2009b. "Safe Drinking Water Information System,
 34 County Search – January 29, 2009," Nemaha, Otoe, and Richardson Counties, Nebraska, and
 35 Atchison County, Missouri. Available URL: <http://www.epa.gov/safewater/dwinfo/index.html>.
 36 (accessed April 7, 2009).
- 37 Environmental Protection Agency (EPA). 2009c. "Waste minimization." Available URL:
 38 <http://www.epa.gov/osw/hazard/wastemin/minimize/faqs.htm#wastemin> (accessed May 2009).
- 39 Federal Register, Vol 63, Number 109. Page 31267-31317 (63 FR 31268). Emergency
 40 Planning and Community Right-to-Know Programs; Amendments to Hazardous Chemical
 41 Reporting Thresholds, Streamlining Requirements, June 8, 1998
- 42 Farrell, J.R. and M.A. Tesar. 1982. Chapter 5: Periphytic algae in the channelized Missouri
 43 River with special Emphasis on apparent optimal temperatures. Hesse, L.W., G.L. Hergenrader,
 44 H.S. Lewis, S.D. Reetz, and A.B. Schlesinger (eds.), *The Middle Missouri River: A Collection of*

- 1 *Papers on the Biology with Special Reference to Power Station Effects*. The Missouri River
2 Group, Norfolk, Nebraska, pp. 84–123.
- 3 Galat, D.L., C.R. Berry, Jr., E.J. Peters, and R.G. White. 2005a. Missouri River Basin. A.C.
4 Benke and C.E. Cushing (eds.), *Rivers of North America*. Elsevier Academic Press, New York,
5 pp. 84–123.
- 6 Galat, D.L., C.R. Berry, Jr., W.M. Gardner, J.C. Hendrickson, G.E. Mestl, G.J. Power, C. Stone,
7 and M.R. Winston. 2005b. *Spatiotemporal patterns and changes in Missouri River Fishes*.
8 American Fisheries Society Symposium 45:249–291.
- 9 Gerrity, P.C. and C. Guy. 2006. *Juvenile pallid sturgeon are piscivorous: A call for conserving*
10 *native cyprinids*. Transactions of the American Fisheries Society 135:604–609.
- 11 Great Plains Energy, Inc. 2009. LocationOne® Copyright 2001–2009, Nebraska City, Nebraska
12 and Falls City, Nebraska. Available URL: <http://www.fallscityedge.com/linkslibrary.asp>
13 [#City, County and State](#). Community Quick Facts, IEDC Tables. Printable Brochure.
14 (accessed April 10, 2009).
- 15 Heritage Research, Ltd. (Heritage). 2004. *Nemaha County: Nebraska Historic Building Survey*.
16 Heritage Research Ltd. Historical/Environmental Consultants, Menomonee Falls, Wisconsin.
17 August 2004.
- 18 Hergenrader, G.L., L.G. Harrow, R.G. King, G.F. Cada, and A.B. Schlesinger, 1982. Chapter 8:
19 Larval fishes in the Missouri River and the effects of entrainment. Hesse, L.W., G.L.
20 Hergenrader, H.S. Lewis, S.D. Reetz, and A.B. Schlesinger (eds.), *The Middle Missouri River: A*
21 *Collection of Papers on the Biology with Special Reference to Power Station Effects*. The
22 Missouri River Group, Norfolk, Nebraska, pp. 184–223.
- 23 Hesse, L.W., Q.P. Bliss, and G.J. Zuerlein. 1982a. Chapter 9: Some aspects of the ecology of
24 adult fishes in the channelized Missouri River with special reference to the effects of two nuclear
25 power generating plants. Hesse, L.W., G.L. Hergenrader, H.S. Lewis, S.D. Reetz, and A.B.
26 Schlesinger (eds.), *The Middle Missouri River: A Collection of Papers on the Biology with*
27 *Special Reference to Power Station Effects*. The Missouri River Group, Norfolk, Nebraska,
28 pp. 224–276.
- 29 Hesse, L.W., G.L. Hergenrader, H.S. Lewis, S.D. Reetz, and A.B. Schlesinger. 1982b. *The*
30 *Middle Missouri River: A Collection of Papers on the Biology with Special Reference to Power*
31 *Station Effects*. The Missouri River Group, Norfolk, Nebraska.
- 32 Hill, A.T., and P. Cooper. 1937. “The Archaeological Campaign of 1937.” *Nebraska History*
33 *Magazine*. 18(4):241–359.
- 34 Hofman, Jack L. 1996. “Early Hunter-Gatherers of the Central Great Plains: Paleoindian and
35 Mesoindian (Archaic) Cultures.” *Archeology and Paleoecology of the Central Great Plains*.
36 Arkansas Archeological Survey Research Series No. 48.
- 37 Holen, Steven R. 1994. “Did Someone Eat the La Sena Mammoth? *The Cellars of Time:*
38 *Paleontology and Archaeology in Nebraska*. NEBRASKAland Magazine. Vol. 72, No. 1.
39 Nebraska Game and Parks Commission.
- 40 Hrabik, R. A., Herzog, D. P., Ostendorf, D. E., and Petersen, M. D. 2007. *Larvae provide first*
41 *evidence of successful reproduction by pallid sturgeon, Scaphirhynchus albus, in the Mississippi*
42 *River*. Journal of Applied Ichthyology 23(4):436–443.
- 43 Hurleya, K.L., R.J. Sheehan, R.C. Heidinger, P.S. Wills, and B. Clevensine. 2004. *Habitat Use*
44 *by Middle Mississippi River Pallid Sturgeon*. Transactions of the American Fisheries Society
45 133:1033–1041.

- 1 Illinois Wildflowers. 2009. Available URL: <http://www.illinoiswildflowers.info/index.htm> (accessed
2 May 11, 2009).
- 3 Institute of Educational Science (IES). 2009. U.S. Department of Education, National Center for
4 Educational Statistics. "College Opportunities Online Locator." Zip Code 68321. Data release
5 date March 6, 2009. Available URL: <http://nces.ed.gov/ipeds/cool/RefineSearch.aspx> (accessed
6 April 17, 2009).
- 7 Kansas Wildflowers and Grasses. 2009. Available URL: <http://www.kswildflower.org/index.php>
8 (accessed May 11, 2009).
- 9 Karr, J.R., L.A. Toth, and D.R. Dudley. 1985. *Fish Communities of Midwestern Rivers: A History
10 of Degradation*. BioScience 15(2):90–95.
- 11 Kynard, B., E. Henyey, and M. Horgan. 2002. *Ontogenetic behavior, migration, and social
12 behavior of pallid sturgeon, Scaphirhynchus albus, and shovelnose sturgeon, S. platyrhynchus,
13 with notes on the adaptive significance of body color*. Environmental Biology of Fishes
14 63:389–403.
- 15 Missouri Conservation Department. 2009. Missouri Species and communities of Concern
16 Checklist. January 2009. Available at URL: <http://mdc4.mdc.mo.gov/Documents/145.pdf>
17 (accessed March 17, 2009).
- 18 Missouri Department of Natural Resources (MDNR). 2008. Census of Missouri Public Water
19 Systems 2008. Division of Environmental Quality. Water Protection Program, Public Drinking
20 Water Branch. January 24, 2008. Available URL: <http://www.dnr.mo.gov/pubs/pub2250.pdf>
21 (accessed April 7, 2009).
- 22 Missouri Plants. 2007. Photographs and descriptions of the flowering and non-flowering plants
23 of Missouri, USA. February 2007. Available URL: <http://www.missouriplants.com/> (accessed
24 April 21, 2009).
- 25 Missouri State Demographer. (ND). Missouri Population Projections by County 2000 to 2030.
26 Available URL: <http://oa.mo.gov/bp/projections/totalpop.html>
27 (accessed April 17, 2009).
- 28 Missouri Botanical Garden (MOBOT). 2009. Plant Finder. Available URL:
29 <http://www.mobot.org/gardeninghelp/plantfinder/Alpha.asp> (accessed May 6, 2009).
- 30 Missouri Department of Conservation (MDC). 2009a. Endangered Species Guidesheet. Indiana
31 bat – *Myotis sodalis*. Available URL: <http://mdc.mo.gov/nathis/endangered/endanger/bat/>
32 (accessed March 4, 2009).
- 33 Missouri Department of Conservation (MDC). 2009b. MDC Heritage Database Results for
34 Atchison County. Available URL: [http://mdc.mo.gov/cgi-
35 bin/heritage/search.cgi?county=Atchison](http://mdc.mo.gov/cgi-bin/heritage/search.cgi?county=Atchison) (accessed April 21, 2009).
- 36 Missouri Department of Conservation (MDC). 2009c. Missouri Species and Communities of
37 Conservation Concern, Checklist. January 2009.
- 38 Missouri Department of Conservation (MDC). 2009d. Letter from D. Brown, Policy Coordinator,
39 Missouri Department of Conservation, Headquarters, to R. Bulavinetz, Aquatic Ecologist,
40 Division of License Renewal, Nuclear Regulatory Commission. Subject: Cooper Nuclear Plant.
41 March 26, 2009. ADAMS Accession No. ML091030465.
- 42 Minnesota Department of Natural Resources (MN DNR) 1991. Western prairie fringed orchid: a
43 threatened Midwestern prairie plant. Available URL:

Affected Environment

- 1 http://files.dnr.state.mn.us/natural_resources/ets/fringed_orchid.pdf?bcsi_scan_B6C3A1920618
2 [BACA=0&bcsi_scan_filename=fringed_orchid.pdf](http://files.dnr.state.mn.us/natural_resources/ets/fringed_orchid.pdf?bcsi_scan_B6C3A1920618) (accessed March 4, 2009).
- 3 Missouri Botanical Garden (MOBOT). 2009. Plant Finder. Available URL:
4 <http://www.mobot.org/gardeninghelp/plantfinder/Alpha.asp> (accessed May 6, 2009).
- 5 Michigan State University (MSU). 2007. Michigan Natural Features Inventory.
6 Rare Species Explorer (Web Application). Available URL:
7 <http://web4.msue.msu.edu/mnfi/explorer/species.cfm?id=15154> (accessed May 11, 2009).
- 8 National Academies of Sciences (NAS). 2002. *The Missouri River Ecosystem*. National
9 Research Council, National Academies Press, Washington, D.C.
- 10 National Climatic Data Center (NCDC). 2009. *Wind - Average wind speed*. Available URL:
11 <http://lwf.ncdc.noaa.gov/oa/climate/online/ccd/avgwind.html> (accessed May, 2009).
- 12 National Climatic Data Center (NCDC). 2009a. *Query results: Tornado occurrences in Nemaha*
13 *County, NE, 1950 – 2009*. ADAMS Accession No. ML091750118.
- 14 National Historical Company. 1882. *History of Holt and Atchison Counties, Missouri*. National
15 Historical Company, St. Joseph, Missouri.
- 16 National Park Service (NPS). 2009. National Register of Historic Places Information System,
17 Nemaha County, Nebraska. Available URL: www.nr.nps.gov (accessed July 28, 2009).
- 18 National Park Service (NPS). 2009. National Register of Historic Places Information System,
19 Atchison County, Missouri. Available online at: www.nr.nps.gov (accessed July 28, 2009).
- 20 National Research Council, Committee on Missouri River Ecosystem Science. 2002. *The*
21 *Missouri River Ecosystem: Exploring the Prospects for Recovery*. National Academy Press,
22 Washington, D.C. 188 pp. [Note: on CD from Cooper]
- 23 Natural Resource Conservation Service (NRCS). 2000. Missouri EPA Ecoregion Map. Available
24 URL: http://www.mo.nrcs.usda.gov/technical/nat_res_data/mo_ecoregion/out/usepa.pdf
25 (accessed April 17, 2009).
- 26 Natural Resource Conservation Service (NRCS). 2007. List of common plants found along the
27 Missouri River in Atchison Co., Missouri.
- 28 Natural Resource Conservation Service (NRCS). 2009. Plants Database. Plants Profile.
29 Available URL: <http://plants.usda.gov/index.html> (accessed May 6, 2009).
- 30 NatureServe. 2008a. NatureServe Explorer. Version 7.1. Whooping Crane. Available URL:
31 <http://www.natureserve.org/explorer/servlet/NatureServe?searchSciOrCommonName=whoopin>
32 [g+crane](http://www.natureserve.org/explorer/servlet/NatureServe?searchSciOrCommonName=whoopin) (accessed March 9, 2009).
- 33 NatureServe. 2008b. NatureServe Explorer. Version 7.1. Salt Creek tiger beetle. Available URL:
34 <http://www.natureserve.org/explorer/servlet/NatureServe?searchSciOrCommonName=salt+cree>
35 [k+tiger+beetle](http://www.natureserve.org/explorer/servlet/NatureServe?searchSciOrCommonName=salt+cree) (accessed March 9, 2009).
- 36 NatureServe. 2009a. NatureServe Explorer. Version 7.1. Piping Plover. Available URL:
37 <http://www.natureserve.org/explorer/servlet/NatureServe?searchSciOrCommonName=piping+pl>
38 [over&x=8&y=10](http://www.natureserve.org/explorer/servlet/NatureServe?searchSciOrCommonName=piping+pl) (accessed March 3, 2009).
- 39 NatureServe. 2009b. NatureServe Explorer. Version 7.1. Interior least tern. Available URL:
40 <http://www.natureserve.org/explorer/servlet/NatureServe?searchName=Sterna+antillarum>
41 (accessed March 3, 2009).

- 1 NatureServe. 2009c. NatureServe Explorer. Version 7.1. Black-footed ferret. Available URL:
 2 <http://www.natureserve.org/explorer/servlet/NatureServe?searchSciOrCommonName=black+fo>
 3 [ted+ferret](http://www.natureserve.org/explorer/servlet/NatureServe?searchSciOrCommonName=black+fo) (accessed March 9, 2009).
- 4 NatureServe. 2009d. NatureServe Explorer. Version 7.1. Plant/Animal Records for Atchison
 5 County, Missouri. Available URL:
 6 http://www.natureserve.org/explorer/servlet/NatureServe?loadTemplate=tabular_report.wmt&pa
 7 [ging=home&save=all&sourceTemplate=reviewMiddle.wmt](http://www.natureserve.org/explorer/servlet/NatureServe?loadTemplate=tabular_report.wmt&pa) (accessed March 9, 2009).
- 8 NatureServe. 2009e. NatureServe Explorer. Version 7.1. Plant/Animal Records for Nebraska
 9 Counties. Available URL: <http://www.natureserve.org/explorer/servlet/NatureServe>
 10 (accessed March 9, 2009).
- 11 Nebraska Administrative Code (NAC), Title 128, Nebraska Hazardous Waste Regulations,
 12 December 5, 2004
- 13 Nebraska State Constitution Article VIII-11. Nebraska State Constitution
- 14 Nebraska Department of Agriculture (NDA). 2008. Press Release: NDA Adds Phragmites to
 15 Noxious Weed List Under Temporary Order. April 15, 2008. Available URL:
 16 <http://www.agr.state.ne.us/newsrel/april2008/phragmites.htm> (accessed March 9, 2009).
- 17 Nebraska Department of Economic Development (NDED) and Nebraska Public Power District
 18 (NPPD). 2008. Nebraska Community “Fast Facts” Profile, Auburn, Nebraska. Available URL:
 19 <http://sites.nppd.com/aedc/fastfacts.asp?city=Auburn> (accessed April 10, 2009).
- 20 Nebraska Department of Economic Development and Nebraska Public Power District (NPPD).
 21 2009. “Nebraska Community 'Fast Facts' Profile, Auburn, Nebraska—Date Generated:
 22 4/10/2009.” Fast Facts Community Profiles sponsored by Nebraska Department of Economic
 23 Development and Nebraska Public Power District. Available online at
 24 <http://sites.nppd.com/aedc/fastfacts.asp?form=CP&city=Auburn&submit=Run+Report>.
 25 Accessed on April 10, 2009.
- 26 Nebraska Department of Education (NDE) Data Center. 2009. 2008–2009 County Membership
 27 by Grade. March 6, 2009. Available URL:
 28 <http://ess.nde.state.ne.us/DataCenter/DataInformation/> and link to County Membership by
 29 Grade (accessed April 15, 2009).
- 30 Nebraska Department of Environmental Quality (NDEQ). 2000. Permit No. NE0208256 for
 31 Class V Underground Injection Wells.
- 32 Nebraska Department of Environmental Quality (NDEQ). 2004. 2004 Nebraska Surface Water
 33 Quality Integrated Report. Lincoln, Nebraska. March 2004.
- 34 Nebraska Department of Environmental Quality (NDEQ). 2008. *Annual Air Quality Report*
 35 *Nebraska Air Quality 2007. Nebraska Department of Environmental Quality, Air Quality Division.*
 36 ADAMS Accession No. ML091750103
- 37 Nebraska Department of Environmental Quality (NDEQ). 2009. *2009 Ambient Air Monitoring*
 38 *Network Plan*. ADAMS Accession No. ML091750088
- 39 Nebraska Health and Human Services System (NHHSS). 2000. Permit No. NE3150505 for
 40 Non-Community Public Water Supply System.
- 41 Nebraska Department of Natural Resources (NDNR) 2009. Statewide aerial maps. Available
 42 URL: <http://dnrmap2.dnr.state.ne.us/website/doqviewer/viewer.htm> (accessed April 16, 2009).

Affected Environment

- 1 Nebraska Department of Natural Resources (NDNR). 2008. Registered Ground Water Wells
2 Data Retrieval. Available URL <http://www.dnr.state.ne.us/dnrnews/news2009/April2009.pdf>
3 (accessed February 13, 2009).
- 4 Nebraska Department of Roads (NDOR). 2007. Traffic Volume Maps and Info. Available URL:
5 <http://www.nebraskatransportation.org/maps/#traffvol>. (accessed April 14, 2009).
- 6 Nebraska Legislature. 2008. Constitution Article VIII, Section 11. Available URL:
7 <http://uniweb.legislature.ne.gov/laws/articles.php?article=VIII-11>. (accessed April 16, 2009).
- 8 Nebraska Public Power District (NPPD). 1971. *Applicant's Environmental Report, Operating*
9 *License Stage, Cooper Nuclear Station*.
- 10 Nebraska Public Power District (NPPD). 2004a. Cooper Nuclear Station, *Annual Radioactive*
11 *Effluent Release Report for 2003*. Brownville, Nebraska. ADAMS Accession No. ML041190422.
- 12 Nebraska Public Power District (NPPD). 2005a. Cooper Nuclear Station, *Annual Radioactive*
13 *Effluent Release Report for 2004*. Brownville, Nebraska. ADAMS Accession No. ML051220511.
- 14 Nebraska Public Power District (NPPD). 2006a. Cooper Nuclear Station, *Annual Radioactive*
15 *Effluent Release Report for 2005*. Brownville, Nebraska. ADAMS Accession No. ML061240548.
- 16 Nebraska Public Power District (NPPD). 2006b. Nebraska Public Power District Power Line
17 Rights-of-way Vegetation Management Program.
- 18 Nebraska Public Power District (NPPD). 2006c. Proposal for Information Collection, Cooper
19 Nuclear Station. January 2006. ADAMS Accession No. ML092510103
- 20 Nebraska Public Power District (NPPD). 2007a. Cooper Nuclear Station, *Annual Radioactive*
21 *Effluent Release Report for 2006*. Brownville, Nebraska. ADAMS Accession No. ML071240393.
- 22 Nebraska Public Power District (NPPD). 2007b. *Corporate Environmental Manual*. Chapter 3:
23 Land Disturbing Activities. December 2007.
- 24 Nebraska Public Power District (NPPD). 2007c. *2006 Annual Report*. Available URL:
25 http://www.nppd.com/newsroom/annual_report_2006/06financials.pdf. (accessed April 16,
26 2009).
- 27 Nebraska Public Power District (NPPD). 2008. *License Renewal Application, Cooper Nuclear*
28 *Station*, Appendix E, Applicant's Environmental Report, Operating License Renewal Stage.
29 ADAMS Accession No. ML083030246.
- 30 Nebraska Public Power District (NPPD). 2008b. Cooper Nuclear Station, *Annual Radioactive*
31 *Effluent Release Report for 2007*. Brownville, Nebraska. ADAMS Accession No. ML081300029.
- 32 Nebraska Public Power District (NPPD). 2008c. *2007 Annual Report*. Available URL:
33 http://www.nppd.com/newsroom/annual_report_2007/07financials.pdf.
34 (accessed April 16, 2009).
- 35 Nebraska Public Power District (NPPD). 2008d. Letter from Joe Citta, NPPD to Robert Harms,
36 USFWS re: Cooper Nuclear Station License Renewal—Habitat Development Proposal.
37 September 26, 2008. ADAMS Accession No. ML092520156.
- 38 Nebraska Public Power District (NPPD). 2009a. Letter from Joe L. Citta, Jr., Corporate
39 Environmental Manager, NPPD, to June M. DeWeese, Nebraska Field Supervisor, U.S. Fish
40 and Wildlife Service, Grand Island. Subject: Cooper Nuclear Plant. May 8, 2009.
41 ADAMS Accession No. ML091830056.
- 42 Nebraska Public Power District (NPPD). 2009b. "About Us." Available URL:
43 <http://www.nppd.com/About%5FUs/>. (accessed April 14, 2009).

- 1 Nebraska Public Power District (NPPD). 2009c. Response to Request for Additional Information
 2 for License Renewal Application Environmental Report Cooper Nuclear Station, Docket No. 50-
 3 298, DPR-46, Attachment 1: *Low Emitter Status for NPPD's Cooper Nuclear Station, NDEQ*
 4 *Facility ID #36750*. March 27, 2009. ADAMS Accession No. ML091600712.
- 5 Nebraska Game and Parks Commission (NGPC). 2008. Estimated Current Ranges of
 6 Threatened and Endangered Species: List of Species by County. Available URL:
 7 <http://www.ngpc.state.ne.us/wildlife/programs/nongame/TandESpecies.pdf>
 8 (accessed April 21, 2009).
- 9 Nebraska Game and Parks Commission (NGPC). Spring Migration Guide. About Whooping
 10 Cranes. Available URL: <http://www.ngpc.state.ne.us/wildlife/guides/migration/whooping.asp>
 11 (accessed March 9, 2009).
- 12 Nebraska Game and Parks Commission (NGPC). 2009b. Nebraska Wildlife Species. Least
 13 Tern, an Endangered Species. Available URL: <http://www.ngpc.state.ne.us/wildlife/ltern.asp>
 14 (accessed March 3, 2009).
- 15 Nebraska Game and Parks Commission (NGPC). 2009c. Species-by-County List for Selected
 16 Nebraska Counties. May 8, 2009. ADAMS Accession No. ML092110589.
- 17 New York State Department of Environmental Conservation (NYSDEC). 2009. Indiana Bat Fact
 18 Sheet. Available URL: <http://www.dec.ny.gov/animals/6972.html> (accessed March 4, 2009).
- 19 Ohio Department of Natural Resources (ODNR). 1998. Species Fact Sheet. *Carex bushii*
 20 *Mackenzie*, Bush's Sedge. Available URL:
 21 http://www.dnr.state.oh.us/Portals/3/Abstracts/Abstract_pdf/C/Carex_bushii.pdf
 22 (accessed May 11, 2009).
- 23 O'Brien, Michael J. and Raymond Wood. 1995. *The Prehistoric Archeological Record. Holocene*
 24 *Human Adaptations in the Missouri Prairie – Timberlands*. Arkansas Archeological Survey
 25 Research Series No. 45.
- 26 Plamondon II, Martin. 2000. *Lewis and Clark Trail Maps: A Cartographic Reconstruction, Vol. 1*.
 27 Washington State University Press.
- 28 Rabeni, C.F. 1996. Chapter 8: Prairie Legacies—Fish and Aquatic Resources. Pages 111-
 29 124 in F.B. Samson and F.L. Knopf (eds.), *Prairie Conservation: Preserving North America's*
 30 *Most Endangered Ecosystem*. Island Press, Washington, D.C.
- 31 Reetz, S.D. 1982. Chapter 4: Phytoplankton studies in the Missouri River at Fort Calhoun
 32 Station and Cooper Nuclear Station. Hesse, L.W., G.L. Hergenrader, H.S. Lewis, S.D. Reetz,
 33 and A.B. Schlesinger (eds.), *The Middle Missouri River: A Collection of Papers on the Biology*
 34 *with Special Reference to Power Station Effects*. The Missouri River Group, Norfolk, Nebraska,
 35 pp. 71–83.
- 36 Repsys, A.J. and G.D. Rogers. 1982. Chapter 6: Zooplankton studies in the channelized
 37 Missouri River. Hesse, L.W., G.L. Hergenrader, H.S. Lewis, S.D. Reetz, and A.B. Schlesinger
 38 (eds.), *The Middle Missouri River: A Collection of Papers on the Biology with Special Reference*
 39 *to Power Station Effects*. The Missouri River Group, Norfolk, Nebraska, pp.124–145.
- 40 Stehn, Tom. 2009. Tom Stehn's Whooping Crane Report. Update: April 20, 2009, from the
 41 USFWS Whooping Crane Census Flight. Available URL:
 42 http://www.birdrockport.com/tom_stehn_whooping_crane_report.htm (accessed April 20, 2009).
- 43 University of Nebraska-Lincoln (UNL). 2009. *Lincoln, NE Weather and Climate. Lincoln monthly*
 44 *and annual normals 1971–2000*. Available URL: [http://www.lincolnweather.org/Lincoln-Monthly-](http://www.lincolnweather.org/Lincoln-Monthly-Normals.html)
 45 [Normals.html](http://www.lincolnweather.org/Lincoln-Monthly-Normals.html) (accessed June, 2009).

Affected Environment

- 1 University of Nebraska State Museum-Division of Zoology (UNSM). 2007a. Database report,
2 Birds of Nemaha County. T.E. Labeledz.
- 3 University of Nebraska State Museum-Division of Zoology (UNSM) 2007b. Database report,
4 Reptiles and amphibians of Nemaha County. T.E. Labeledz.
- 5 University of Wyoming (UWYO). 2002. State Species Abstract. Wyoming Natural Diversity
6 Database. *Dalea enneandra*. Nine-anther dalea. January 2002. Available URL:
7 http://www.uwyo.edu/wynddsupport/docs/Reports/SpeciesAbstracts/Dalea_enneandra.pdf
8 (accessed May 6, 2009).
- 9 U.S. Army Corps of Engineers (USACE). 2002. Permit No. NE01-10322 for Maintenance
10 Dredging of the CNS-1 Water Intake Structure.
- 11 U.S. Army Corps of Engineers (USACE). 2004. Missouri River Master Water Control Manual,
12 Final Environmental impact Statement Review and Update. March 2004. Northwestern Division,
13 Omaha, Nebraska.
- 14 U.S. Army Corps of Engineers (USACE). 2004b. Missouri River Mitigation Project. July 2004.
15 Available URL:
16 http://www.nwk.usace.army.mil/projects/mitigation/sites/hamburg_area/lanben.htm (accessed
17 April 15, 2004).
- 18 U.S. Army Corps of Engineers (USACE). 2007. Missouri River Mitigation Project. Available
19 URL: <http://www.nwk.usace.army.mil/projects/mitigation/>
- 20 U.S. Department of Agriculture (USDA). 2009. 2007 Census of Agriculture. Iowa, Kansas,
21 Missouri, Nebraska. Released February 4, 2009. Available URL:
22 http://www.agcensus.usda.gov/Publications/2007/Online_Highlights/County_Profiles/index.asp.
23 (accessed April 17, 2009).
- 24 U.S. Census Bureau (USCB). 2009a. Surveys of Nemaha, Otoe, and Richardson Counties
25 Nebraska and Atchison County, Missouri. Housing data for 2000 and 2007. Available URL:
26 <http://factfinder.census.gov> and <http://quickfacts.gov>
- 27 U.S. Census Bureau (USCB). 2009b. Decennial Census 1900 to 1990 and 2000 Data and State
28 and County QuickFacts for Nemaha County, Otoe County, and Richardson County, Nebraska,
29 and Atchison County, Missouri. Available URL: <http://quickfacts.census.gov> (accessed March
30 25, 2009).
- 31 U.S. Census Bureau (USCB). 2009c. State and County QuickFacts for Nemaha County, Otoe
32 County, and Richardson County, Nebraska, and Atchison County, Missouri. Available URL:
33 <http://quickfacts.census.gov> (accessed March 25, 2009).
- 34 U.S. Fish and Wildlife Service (USFWS). 1978. 50 CFR Part 17. Endangered and Threatened
35 Wildlife and Plants; Determination of Critical habitat for the Whooping Crane, Vol. 43, pp.
36 20938–20942.
- 37 U.S. Fish and Wildlife Service (USFWS). 1997. "Piping plover (*Charadrius melodus*). An
38 example of U.S./Canada Cooperation in the protection and recovery of endangered species".
39 Available URL: <http://www.fws.gov/endangered/canada/plover.htm> (accessed March 3, 2009).
- 40 U.S. Fish and Wildlife Service (USFWS). 2000. Fact Sheet. Black-footed ferret (*Mustela*
41 *nigripes*). Available URL:
42 <http://www.fws.gov/mountain-prairie/species/mammals/blackfootedferret/revfact.chy.pdf>
43 (accessed March 9, 2009).

- 1 U.S. Fish and Wildlife Service (USFWS). 2000b. Biological Opinion Regarding Missouri River
2 Operations. November 2000. Available URL:
3 <http://www.nwd-mr.usace.army.mil/mmanual/opinion.html>. (accessed June 16, 2009).
- 4 U.S. Fish and Wildlife Service (USFWS). 2002. 50 CFR Part 17. Endangered and Threatened
5 Wildlife and Plants; Designation of Critical Habitat for the Northern Great Plains Breeding
6 Population of the Piping Plover; Final Rule, Vol. 67, pp. 57637–57717.
- 7 U.S. Fish and Wildlife Service (USFWS). 2003a. Questions and Answers Regarding the U.S.
8 Fish and Wildlife Service’s Supplemental Biological Opinion for the 2003 Missouri River
9 Operations. Mountain Prairie Region. Updated March 21, 2003. Available URL:
10 http://www.fws.gov/mountain%2Dprairie/missouririver/q&a_04222003.htm.
11 (accessed June 17, 2009).
- 12 U.S. Fish and Wildlife Service (USFWS). 2003. U.S. Fish and Wildlife Service 2003 Biological
13 Opinion on the Operation of the Missouri River Main Stem Reservoir System, Operation and
14 Maintenance of the Missouri River Bank Stabilization and Navigation Project, and Operation of
15 the Kansas River Reservoir System. December 16, 2003. Available URL:
16 <http://www.nwd-mr.usace.army.mil/mmanual/FinalBO2003.pdf>. (accessed June 17, 2009).
- 17 U.S. Fish and Wildlife Service (USFWS). 2005. News Release October 6, 2005. “Service lists
18 Salt Creek tiger beetle as endangered”. Available URL:
19 <http://www.fws.gov/mountain-prairie/PRESSREL/05-72.htm> (accessed March 4, 2009).
- 20 U.S. Fish and Wildlife Service (USFWS). 2007a. Species Profile, Pallid sturgeon,
21 *Scaphirhynchus albus*. Available URL: <http://www.fws.gov/moriver/PSPROFILE.htm>.
22 (accessed March 16, 2007).
- 23 U.S. Fish and Wildlife Service (USFWS). 2007b. National Wetlands Inventory, Wetlands
24 Mapper. Available URL: <http://www.fws.gov/wetlands/data/index.html>
25 (accessed April 17, 2009).
- 26 U.S. Fish and Wildlife Service (USFWS). 2008a. Endangered Species, Missouri, County
27 Distribution of Federally-Listed, Threatened, Endangered, Proposed, and Candidate Species.
28 USFWS, Columbia, Missouri. November 2008. Available URL:
29 <http://www.fws.gov/midwest/endangered/lists/missouri-cty.html> (accessed April 17, 2009).
- 30 U.S. Fish and Wildlife Service (USFWS). 2008b. North Dakota Field Office. Mountain-Prairie
31 Region. Least Tern (*Sterna antillarum*). December 2008. Available URL:
32 http://www.fws.gov/northdakotafieldoffice/endspecies/species/least_tern.htm
33 (accessed February 26, 2009).
- 34 U.S. Fish and Wildlife Service (USFWS). 2008c. Indiana Bat. Finding on Petition to Revise
35 Critical Habitat. December 2008. Available URL:
36 http://www.fws.gov/midwest/endangered/mammals/inba/inba_chpetfindg_gandas.html
37 (accessed June 3, 2009).
- 38 U.S. Fish and Wildlife Service (USFWS). 2009a. National Wetlands Inventory. Nemaha quad.
39 Available URL: <http://www.fws.gov/wetlands/data/> (accessed April 15, 2009).
- 40 U.S. Fish and Wildlife Service (USFWS). 2009b. Endangered Species, Nebraska, Federally
41 Listed and Proposed, Endangered, Threatened, Experimental, and Candidate Species -
42 Nebraska Counties. Ecological Services, Nebraska Field Office. Available URL:
43 <http://www.fws.gov/mountain-prairie/endspp/countylists/nebraska.pdf>
44 (accessed April 17, 2009).

Affected Environment

- 1 U.S. Fish and Wildlife Service (USFWS). 2009c. Personal e-mail from Robert Harms, Fish and
2 Wildlife Biologist, Grand Island Field Office, to R. Bulavinetz, Aquatic Ecologist, Division of
3 License Renewal, Nuclear Regulatory Commission. Subject: Cooper Nuclear Plant. March 16,
4 2009. ADAMS Accession No. ML092110590.
- 5 U.S. Fish and Wildlife Service (USFWS). 2009d. National Wetlands Inventory. Nemaha quad.
6 Available URL: <http://www.fws.gov/wetlands/data/> (accessed April 15, 2009).
- 7 U.S. Fish and Wildlife Service (USFWS). 2009e. Endangered Species, Nebraska, Federally
8 Listed and Proposed, Endangered, Threatened, Experimental, and Candidate Species -
9 Nebraska Counties. Ecological Services, Nebraska Field Office. Available URL:
10 <http://www.fws.gov/mountain-prairie/endspp/countylists/nebraska.pdf>
11 (accessed April 17, 2009).
- 12 U.S. Fish and Wildlife Service (USFWS). 2009f. Personal e-mail from Robert Harms, Fish and
13 Wildlife Biologist, Grand Island Field Office, to R. Bulavinetz, Aquatic Ecologist, Division of
14 License Renewal, Nuclear Regulatory Commission. Subject: Cooper Nuclear Plant. March 16,
15 2009. ADAMS Accession No. ML092110590.
- 16 U.S. Fish and Wildlife Service (USFWS). 2009g. Whooping crane (*Grus americana*). Available
17 URL: <http://ecos.fws.gov/speciesProfile/SpeciesReport.do?sPCODE=B003> (accessed March 9,
18 2009).
- 19 U.S. Fish and Wildlife Service (USFWS). 2009h. Endangered Species Fact Sheet. Salt Creek
20 tiger beetle. February 2009. Available URL: [http://www.fws.gov/mountain-
21 prairie/species/invertebrates/saltcreektiger/](http://www.fws.gov/mountain-prairie/species/invertebrates/saltcreektiger/)
22 (accessed March 9, 2009).
- 23 U.S. Fish and Wildlife Service (USFWS). 2009i. "Designation of Critical Habitat for the Salt
24 Creek tiger beetle (*Cicindela nevadica lincolniana*)." *Federal Register* Vol. 72, No. 238,
25 pp. 70715–70758.
- 26 U.S. Fish and Wildlife Service (USFWS). 2009j. Black-footed ferret (*Mustela nigripes*). Available
27 URL: <http://ecos.fws.gov/speciesProfile/SpeciesReport.do?sPCODE=A004> (accessed March 9,
28 2009).
- 29 U.S. Fish and Wildlife Service (USFWS). 2009k. Rainwater Basin Wetland Management District.
30 Available URL: <http://www.fws.gov/Refuges/profiles/index.cfm?id=64530> (accessed April 29,
31 2009).
- 32 U.S. Fish and Wildlife Service (USFWS). 2009l. Letter from June M. DeWeese, Nebraska Field
33 Supervisor, U.S. Fish and Wildlife Service, Grand Island, to Joe L. Citta, Jr., Corporate
34 Environmental Manager, NPPD. Subject: Cooper Nuclear Station. June 8, 2009. ADAMS
35 Accession No. ML091830055.
- 36 U.S. Geological Survey (USGS). 1997. Ground Water Atlas of the United States, Kansas,
37 Missouri, and Nebraska, HA 730-D. Available URL: <http://capp.water.usgs.gov>.
- 38 U.S. Geological Survey (USGS). 2001. Ecoregions of Nebraska and Kansas (color poster with
39 map, descriptive text, summary tables, and photographs). Available URL:
40 http://www.epa.gov/wed/pages/ecoregions/ksne_eco.htm (accessed April 29, 2009).
- 41 U.S. Geological Survey (USGS). 2006. Northern Prairie Wildlife Research Center. Native
42 Grasslands of the North Dakota Grasslands. August 2006. Available URL:
43 <http://www.npwrc.usgs.gov/resource/plants/wildflwr/> (accessed May 6, 2009).
- 44 U.S. Geological Survey (USGS). 2007. Sturgeon Research Update: Confirmed Pallid Sturgeon
45 Spawning in the Missouri River in 2007. USGS Fact Sheet 2007–3053, July 2007.

- 1 U.S. Geological Survey (USGS). 2008. Search USGS. September 2008. Available URL:
2 <http://search.usgs.gov/> (accessed March 9, 2009).
- 3 U.S. Nuclear Regulatory Commission (NRC). 2003. *Generic Environmental Impact Statement*
4 *for License Renewal of Nuclear Plants Supplement 12 Regarding Fort Calhoun Station, Unit 1.*
5 NUREG-1437, Supplement 12. ADAMS Accession No. ML032230075.
- 6 Utah State University (USU) 2006. Fact Sheet. *Carex frankii* Kunth. Available URL:
7 http://utc.usu.edu/factsheets/CarexFSF/Carex_frankii.htm (accessed May 11, 2009).
- 8 University of Texas (UT). 2009. Wildflower Center. Native Plant Database. February 2009.
9 Available URL: http://www.wildflower.org/plants/result.php?id_plant=PAGL17.
10 (accessed May 11, 2009).
- 11 University of Wisconsin (UW). 2009. Robert W. Freckmann Herbarium. Available URL:
12 [http://wisplants.uwsp.edu/scripts/searchphotographer.asp?photographer=Robert%20R.%20Kow](http://wisplants.uwsp.edu/scripts/searchphotographer.asp?photographer=Robert%20R.%20Kowal)
13 [al](#) (accessed April 21, 2009).
- 14 University of Wyoming. (UWYO) 2002. State Species Abstract. Wyoming Natural Diversity
15 Database. *Dalea enneandra*. Nine-anther dalea. January 2002. Available URL:
16 http://www.uwyo.edu/wynddsupport/docs/Reports/SpeciesAbstracts/Dalea_enneandra.pdf
17 (accessed May 6, 2009).
- 18 Wildhaber, M.L., DeLonay, A.J., Papoulias, D.M., Galat, D.L., Jacobson, R.B., Simpkins, D.G.,
19 Braaten, P.J., Korschgen, C.E., and Mac, M.J. 2007. A conceptual life-history model for pallid
20 and shovelnose sturgeon. U.S. Geological Survey Circular 1315. U.S. Geological Survey,
21 Reston, Virginia. 18 pp.
- 22 Wishart, David J., ed. 2004. *Encyclopedia of the Great Plains*. University of Nebraska Press

3.0 ENVIRONMENTAL IMPACTS OF REFURBISHMENT

Environmental issues associated with refurbishment activities are discussed in NUREG-1437, “*Generic Environmental Impact Statement (GEIS) for License Renewal of Nuclear Plants*,” Volumes 1 and 2 (NRC 1996). The GEIS includes a determination of whether or not the analysis of the environmental issues can be applied to all plants and whether or not additional mitigation measures are warranted. Issues are then assigned a Category 1 or a Category 2 designation. As set forth in the GEIS, Category 1 issues are those that meet all of the following criteria:

- (1) The environmental impacts associated with the issue have been determined to apply to all plants, or for some issues, apply only to plants having a specific type of cooling system or other specified plant or site characteristics.
- (2) A single significance level (SMALL, MODERATE, or LARGE) has been assigned to the impacts (except for collective offsite radiological impacts from the fuel cycle and from high-level waste and spent fuel disposal).
- (3) Mitigation of adverse impacts associated with the issue has been considered in the analysis. It has been determined that additional plant-specific mitigation measures are likely not to be sufficiently beneficial to warrant implementation.

For issues that meet the three Category 1 criteria, no additional plant-specific analysis is required in this supplemental environmental impact statement (SEIS) unless new and significant information is identified.

Category 2 issues are those that do not meet one or more of the criteria for Category 1, therefore, an additional plant-specific review of these issues is required.

License renewal actions include refurbishment for the extended plant life. These actions may have an impact on the environment that requires evaluation, depending on the type of action and the plant-specific design. Environmental issues associated with refurbishment, which were determined to be Category 1 issues, are listed in Table 3-1.

Environmental issues related to refurbishment considered in the GEIS that are inconclusive for all plants, or for specific classes of plants, are Category 2 issues. These are listed in Table 3-2.

The potential environmental effects of refurbishment actions are identified, and the analysis will be summarized within this section, if such actions are planned. Nebraska Public Power District (NPPD) indicated that it has performed an evaluation of systems, structures, and components pursuant to Section 54.21 of Title 10 of the *Code of Federal Regulations* (10 CFR 54.21) to identify the need to undertake any major refurbishment activities that are necessary to support continued operation of CNS-1 during the requested 20-year period of extended operation. Items that are subject to aging and might require refurbishment to support continued operation during the renewal period are listed in Table B.2 of the GEIS.

1 **Table 3-1. Category 1 Issues for Refurbishment Evaluation**

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Sections
Surface Water Quality, Hydrology, and Use (for all plants)	
Impacts of refurbishment on surface water quality	3.4.1
Impacts of refurbishment on surface water use	3.4.1
Aquatic Ecology (for all plants)	
Refurbishment	3.5
Ground Water Use and Quality	
Impacts of refurbishment on ground water use and quality	3.4.2
Land Use	
Onsite land use	3.2
Human Health	
Radiation exposures to the public during refurbishment	3.8.1
Occupational radiation exposures during refurbishment	3.8.2
Socioeconomics	
Public services: public safety, social services, and tourism and recreation	3.7.4; 3.7.4.3; 3.7.4.4; 3.7.4.6
Aesthetic impacts (refurbishment)	3.7.8

1 **Table 3-2. Category 2 Issues for Refurbishment Evaluation**

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Sections	10 CFR 51.53 (c)(3)(ii) Subparagraph
Terrestrial Resources		
Refurbishment impacts	3.6	E
Threatened or Endangered Species (for all plants)		
Threatened or endangered species	3.9	E
Air Quality		
Air quality during refurbishment (nonattainment and maintenance areas)	3.3	F
Socioeconomics		
Housing impacts	3.7.2	I
Public services: public utilities	3.7.4.5	I
Public services: education (refurbishment)	3.7.4.1	I
Offsite land use (refurbishment)	3.7.5	I
Public services, transportation	3.7.4.2	J
Historic and archaeological resources	3.7.7	K
Environmental Justice		
Environmental justice ²	Not addressed	Not addressed

2 The results of the evaluation of systems, structures, and components for CNS-1, as required by
 3 10 CFR 54.21, do not identify the need to undertake any major refurbishment or replacement
 4 actions associated with license renewal to support the continued operation of
 5 CNS-1 beyond the end of the existing operating license.

² Guidance related to environmental justice was not in place at the time the U.S. Nuclear Regulatory Commission (NRC) prepared the GEIS and the associated revision to 10 CFR Part 51. If an applicant plans to undertake refurbishment activities for license renewal, the applicant's environmental report (ER) and the NRC staff's environmental impact statement must address environmental justice.

1 **3.1 REFERENCES**

2 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, “Environmental
3 Protection Regulations for Domestic Licensing and Related Regulatory Functions.” 10 CFR
4 Part 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, “Requirements for Renewal of
5 Operating Licenses for Nuclear Power Plants.”

6 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement*
7 *for License Renewal of Nuclear Plants*. NUREG-1437, Volumes 1 and 2, Office of Nuclear
8 Regulatory Research, Washington, D.C. ADAMS Accession Nos. ML040690705 and
9 ML040690738

10 U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement*
11 *for License Renewal of Nuclear Plant*. NUREG-1437, Volume 1, Addendum 1, Office of Nuclear
12 Reactor Regulation, Washington, D.C. ADAMS Accession No. ML0400690720.

4.0 ENVIRONMENTAL IMPACTS OF OPERATION

This chapter addresses potential environmental impacts related to the period of extended operation of Cooper Nuclear Station, Unit 1 (CNS-1). These impacts are grouped and presented according to resource. Generic issues (Category 1) rely on the analysis provided in NUREG-1437, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (May 1996) (GEIS) prepared by the U.S. Nuclear Regulatory Commission (NRC, 1996) and are discussed briefly. NRC staff analyzed site-specific issues (Category 2) for CNS-1 and assigned them a significance level of SMALL, MODERATE, LARGE or not applicable to CNS-1 because of site characteristics or plant features. Section 1.4 of this report explains the criteria for Category 1 and Category 2 issues and defines the impact designations of SMALL, MODERATE, and LARGE.

4.1 LAND USE

Section 2.2.1 of this report describes the land use around CNS-1.

Table 4-1, "Land Use Issues" lists Category 1 issues (from 10 CFR Part 51, Subpart A, Appendix B, Table B-1), which are applicable to onsite land use and power line right-of-way impacts during the renewal term. As stated in the GEIS, the impacts associated with the Category 1 issues were determined to be SMALL, and plant-specific mitigation measures would not be sufficiently beneficial to be warranted.

The NRC staff reviewed and evaluated the CNS-1 environmental report (ER), scoping comments, other available information, and visited the CNS-1 in search of new and significant information that would change the conclusions presented in the GEIS. No new and significant information was identified during this review and evaluation. The staff did not identify any Category 2 issues for land use. Therefore, it is expected that there would be no impacts related to the Category 1 issues during the renewal term beyond those discussed in the GEIS.

Table 4-1. Land Use Issues

Issues	GEIS Section	Category
Onsite land use	4.5.3	1
Power line right-of-way	4.5.3	1

4.2 AIR QUALITY

Section 2.2.2 of this report describes air quality in the vicinity of CNS-1. One Category 1 air quality issue is applicable to CNS-1: air quality effects of transmission lines. No Category 2 issues have been identified for air quality. The NRC staff did not identify any new and significant information during the review of NPPD's ER, the site audit, or during the scoping process. No major facility construction or refurbishments are planned to occur during the license renewal period. Therefore, there are no impacts related to this issue beyond those discussed in the GEIS. For these issues, the GEIS concluded that the impacts are designated as SMALL.

1 **4.3 GROUND WATER**

2 **4.3.1 Generic Ground Water Issues**

3 Section 2.2.3 of this report discusses ground water use and quality at CNS-1. The staff did not
4 identify any new and significant information in regard to Category 1 or generic ground water
5 issues during the review of the NPPD's ER, the site visit, or the scoping process. Therefore, no
6 impacts are related to these issues beyond those discussed in the GEIS. For these issues, the
7 NRC staff in the GEIS concludes that the impacts are SMALL and additional site-specific
8 mitigation measures are not warranted.

9 **4.3.2 Ground Water Use Conflicts**

10 The Category 2 ground water issue applicable to CNS-1 is ground water use conflicts (potable
11 and service water, plants using >100 gpm). CNS-1 has two potable water supply wells
12 completed in the alluvial aquifer that have a current combined pumping capacity of 250 gallons
13 per minute (gpm). Normal operations require only one well to be pumped at a time, supplying
14 125 gallons per minute. The water is chlorinated, distributed onsite, and operated with
15 preventive maintenance and cross connection or backflow prevention programs. The two
16 drinking water wells are scheduled to be replaced with two similar new wells in the near future
17 (NPPD, 2008).

18 A third alluvial aquifer well at CNS-1 is used for fire protection training and has a capacity of 750
19 gallons per minute. Two additional wells, River Wells A and B, are used to supply water for
20 facility pump seals. These wells each have a capacity of 150 gallons per minute (NPPD, 2008).

21 As part of a hydrogeologic investigation for the study of radioisotopes in ground water and water
22 use in the area surrounding the station, NPPD searched the Nebraska Department of Natural
23 Resources (NDNR) water well database for all wells in Nemaha County. Three irrigation wells,
24 completed in the shallow unconsolidated aquifer, are located between 2 and 3 miles southwest
25 of CNS-1. Four farm wells within 1 mile of the station, all only 15 feet deep, produce a limited
26 amount of ground water. None of these wells are impacted by ground water pumping at CNS-1
27 because the station wells are screened in an unconfined aquifer and have limited radii of
28 influence. A search of wells by NPPD in Atchison County, Missouri, across the river from CNS-
29 1, identified no wells within 2 miles of the station. In addition, the Missouri River serves as a
30 ground water recharge and discharge boundary. Therefore, the NRC staff concludes no effect of
31 pumping the shallow aquifer at CNS-1 would likely be measurable on the Missouri side of the
32 river.

33 Because of the limited radius of influence of CNS-1 wells completed in the unconfined aquifer,
34 no public ground water supplies are close enough to CNS-1 to be impacted by ground water
35 use at the station. There are no well-head protection areas or EPA designated sole source
36 aquifers in the vicinity of CNS-1 (CRA, 2007). Therefore, the impact of ground water use by
37 CNS-1 is SMALL and no mitigation measures are warranted.

38 **4.4 SURFACE WATER**

39 **4.4.1 Generic Surface Water Issues**

40 The following sections discuss the surface water quality issues applicable to CNS-1, which are
41 listed in Table 4-2. The staff did not identify any Category 2 issues related to surface water

1 issues in the GEIS. In addition, the staff did not identify any new and significant information with
 2 respect to the Category 1 issues below during the review of NPPD's ER, the site audit, or the
 3 scoping process. Therefore, no impacts are related to these issues beyond those discussed in
 4 the GEIS. For these issues, the NRC staff in the GEIS concludes that the impacts are SMALL,
 5 and additional site-specific mitigation measures are not warranted.

6 **Table 4-2. Category 1 Surface Water Issues**

Issues	GEIS Section	Category
Altered current patterns at intake and discharge structures	4.2.1.2.1	1
Temperature effects on sediment transport capacity	4.2.1.2.3	1
Scouring caused by discharged cooling water	4.2.1.2.3	1
Discharge of chlorine or other biocides	4.2.1.2.4	1
Discharge of sanitary wastes and minor chemical spills	4.2.1.2.4	1
Discharge of other metals in wastewater	4.2.1.2.4	1
Water use conflicts for plants with once-through cooling systems	4.2.1.3	1

7 The following briefly describes the GEIS conclusions for these issues:

8 Altered current patterns at intake and discharge structures. Altered current
 9 patterns have not been found to be a problem at operating nuclear power plants
 10 and are not expected to be a problem during the license renewal term.

11 Temperature effects on sediment transport capacity. These effects have not
 12 been found to be a problem at operating nuclear power plants and are not
 13 expected to be a problem during the license renewal term.

14 Scouring caused by discharged cooling water. Scouring has not been found to be
 15 a problem at most operating nuclear power plants and has caused only localized
 16 effects at a few plants. It is not expected to be a problem during the license
 17 renewal term.

18 Discharge of chlorine or other biocides. The effects are not a concern among
 19 regulatory and resource agencies, and are not expected to be a problem during
 20 the license renewal term.

21 Discharge of sanitary wastes and minor chemical spills. Effects are readily
 22 controlled through the National Pollutant Discharge Elimination System (NPDES)
 23 permit. Periodic modifications are granted, if needed, and are not expected to be
 24 a problem during the license renewal term.

25 Discharge of other metals in wastewater. These discharges have not been found
 26 to be a problem at operating nuclear power plants and are permitted through the
 27 NPDES system. They are not expected to be a problem during the license
 28 renewal term.

29 With respect to “water use conflicts for plants with once through cooling systems” the
 30 NRC staff notes that continuing operation of CNS-1 depends on the availability of water
 31 from the Missouri River. The volume of water available may be susceptible to droughts
 32 and to competing water uses within the basin. In cases of extreme drought, these
 33 facilities may be required to curtail operations if the volume of water available is not
 34 sufficient. As described in Section 2.0, the flow in the Missouri River is not expected to

Environmental Impacts of Operation

1 decrease to the point cooling water restrictions would be imposed. This remains a
2 Category 1 issue with SMALL impact.

3 For all of these Category 1 issues in Table 4-2, the NRC staff has not identified any new and
4 significant information during its review of the NPPD's ER, the staff's site visit, the scoping
5 process, or the evaluation of other available information. Therefore, the NRC staff concludes
6 that there were no other surface water issues.

7 **4.4.2 Water Use Conflicts**

8 There were no Category 2 surface water issues identified for the CNS-1 license renewal term.

9 **4.5 AQUATIC RESOURCES**

10 Section 2.1.6 of this report describes the CNS-1 cooling water system; Section 2.2.5 describes
11 the aquatic resources. The Category 1 and Category 2 issues related to aquatic resources
12 applicable to CNS-1 are discussed below and listed in Table 4-3.

13 **Table 4-3. Aquatic Resources Issues**

Issues	GEIS Sections	Category
For All Plants		
Accumulation of contaminants in sediments or biota	4.2.1.2.4	1
Entrainment of phytoplankton and zooplankton	4.2.2.1.1	1
Cold shock	4.2.2.1.5	1
Thermal plume barrier to migrating fish	4.2.2.1.6	1
Distribution of aquatic organisms	4.2.2.1.6	1
Premature emergence of aquatic insects	4.2.2.1.7	1
Gas supersaturation (gas bubble disease)	4.2.2.1.8	1
Low dissolved oxygen in the discharge	4.2.2.1.9	1
Losses from predation, parasitism, and disease among organisms exposed to sublethal stresses	4.2.2.1.10	1
Stimulation of nuisance organisms	4.2.2.1.11	1
For Plants with Once-Through and Cooling Pond Heat Dissipation Systems		
Entrainment of fish and shellfish in early life stages	4.1.2	2
Impingement of fish and shellfish	4.1.3	2
Heat shock	4.1.4	2

14 **4.5.1 Generic Aquatic Ecology Issues**

15 The NRC staff did not identify any new and significant information related to the Category 1
16 issues listed above during the review of the NPPD's ER, the site audit, or the scoping process.
17 Therefore, there are no impacts related to these issues beyond those discussed in the GEIS.
18 For these issues, the GEIS concludes that the impacts are designated as SMALL, and
19 additional site-specific mitigation measures are not likely to be sufficiently beneficial to be
20 warranted.

1 **4.5.2 Entrainment and Impingement**

2 4.5.2.1 *Introduction*

3 Entrainment and impingement of aquatic organisms are site-specific (Category 2) issues for
4 assessing impacts of license renewal at plants with once-through cooling systems. Entrainment
5 is the taking in of organisms with the cooling water. The organisms involved are generally of
6 small size, dependent on the screen mesh size, and include phyto- and zooplankton, fish eggs
7 and larvae, shellfish larvae, and many other forms of aquatic life. Impingement is the
8 entrapment of organisms against the cooling water intake screens.

9 A particular life stage of a species can be subject to both entrainment and impingement if some
10 individuals are impinged on screens while others pass through and are entrained (EPA, 1977).
11 Section 316(b) of the Clean Water Act (33 *United States Code* (U.S.C.) §1326(b)) requires that:

12 Any standard established pursuant to section 1311 of this title or section 1316 of
13 this title and applicable to a point source shall require that the location, design,
14 construction, and capacity of cooling water intake structures reflect the best
15 technology available for minimizing adverse environmental impact available for
16 minimizing adverse environmental impact.

17 The adverse environmental impacts of cooling water intake occur through both
18 impingement and entrainment. Exhaustion, starvation, asphyxiation, descaling, and
19 physical stresses may kill or injure impinged organisms. Heat, physical stress, or
20 chemicals used to clean the cooling system may kill or injure the entrained organisms.

21 4.5.2.2 *History of Cooper Nuclear Station's 316(b) Compliance*

22 The ER section 4.2.5 provides the history of CNS-1's compliance with the Section 316(a) and
23 316(b) of the Clean Water Act (33 *United States Code* (U.S.C.) §1326(a) and 1326(b)). NDEQ
24 (1977) found, after reviewing CNS-1's revised 316(b) documentation on the effects of the intake
25 structure on fish populations, that the structure met the minimum requirements of Section 316(b)
26 of the CWA. NDEQ (1977) also voiced concerns regarding the fate of fish entrapped in the
27 forebay area, however, and noted that "should problems develop in this area in the future, more
28 adequate fish protection devices may be warranted." NPPD (2008, pages 4–25) discontinued
29 entrapment monitoring at CNS-1 about a year later in January 1978.

30 CNS-1 conducted impingement sampling from 1974 through 1978. NPPD (2008) lists the
31 annual impingement rates from 1975, 1976, and 1977, respectively, as follows: 45,990 fish,
32 63,245 fish, and 40,296 fish. NPPD (2008) does not present the annual impingement rate for
33 1974, but gives the daytime and nighttime rates as 19.8 and 38.1 fish/hour. Assuming 12-hour
34 day and night sampling periods (Hazleton, 1979) and extrapolating to 365 days per year, the
35 NRC staff calculated a yearly rate of 253,600 fish impinged in 1978. NPPD (2008) also did not
36 present the annual rate for 1978. The total impingement for 27 hours of sampling in 1978 was
37 266 fish (Hazleton, 1979). Extrapolating to 365 days per year, the NRC staff calculated a yearly
38 rate of about 86,300 fish impinged in 1978. These annual rates can only be rough estimates
39 accompanied by a moderate degree of uncertainty, but they are useful for understanding the
40 order of magnitude of impingement.

41 NPPD (2008) reports that gizzard shad, freshwater drum, and river carpsucker make up the
42 majority of impinged fish in the 1974 through 1978 studies. Based on data from the ER (NPPD,
43 2008, Table 1.3-1), the contribution of these three species to total impingement numbers ranged

Environmental Impacts of Operation

1 from 73 to 91 percent for the period of 1974 through 1978. Hazleton (1979, Table 7.1)
2 categorizes the occurrence of gizzard shad, freshwater drum, and river carpsucker in the area
3 around the CNS-1 as “common” based on electroshocking and seining during the pre- and post-
4 operational period, 1970 through 1978. The age class of the majority of fish impinged each year
5 was young of the year, and most impingement occurred at night (NPPD, 2008, page 4–24).

6 According to NPPD’s (NPPD, 2008d) 316(b) Compliance Strategy Report for 2007, “to help
7 address the 316(b) requirements, NPPD installed Brackett-Green dual flow screens with
8 modified Ristroph fish buckets in 2005 and 2006.” CNS-1 has not completed the fish protection
9 system and plans to install, during a 2011 refueling outage, a fish handling system consisting of
10 inside and outside sprays to wash fish from the screens and a separate fish return trough
11 (NPPD, 2008, pgs 4–11). The plant’s service water system would supply water for the spray
12 wash. The new screens, fish handling system, and fish return trough primarily affect
13 impingement but not entrainment.

14 CNS-1’s original 316(a) and 316(b) demonstration (Nalco, 1975, Tables 4.4-48 through 4.4-50)
15 reported entrainment mortality (intake vs. discharge and after an unspecified holding period) but
16 not the number of fish entrained, both of which are necessary for a full assessment of the
17 effects of entrainment. Nalco (1975, Tables 4.4-50 and 4.451) also reported mortality of fish
18 larvae after an unspecified holding period, after passage through the thermal plume. Following
19 NDEQ’s (1977) review of CNS-1’s revised 316(b) documentation, NPDES permits have not
20 required subsequent entrainment monitoring and assessment (NPPD, 2008, page 4–11). U.S.
21 Atomic Energy Commission (AEC) (1973, page V–15) found that it could describe the potential
22 loss of fish eggs and larvae only in terms of the fraction of river flow taken by the plant, which in
23 spring and early summer when many of the fish species spawned, was about 4 percent. During
24 unusually low summer flows, this fraction would be greater and the fraction of river flow taken by
25 the plant should be no more than 20 percent (NPPD, 2008). AEC (1973) found that the
26 percentage loss of fish eggs and larvae originating upstream of the plant was probably much
27 less than the fractional flow because the sampled fish species were spawning in protected
28 areas.

29 In its guidelines for ecological risk assessment, the EPA (1998) recommends use of multiple
30 lines of evidence for characterizing and describing risk. The use of lines of evidence can be
31 quantitative or qualitative. The NRC staff adopted a qualitative approach for the impact analysis
32 here. One line of evidence is the regulatory history itself. Although any final determinations
33 regarding CNS-1’s 316(b) demonstration await the EPA’s publication of new Phase II rules.
34 Phase II rules were published in 2004, suspended in 2007, and are awaiting new Phase II rules
35 at the time this SEIS was developed.

36 The NRC staff find that the history of regulation reviewed above does not show regulatory
37 concern that the potential effects of impingement and entrainment constitute adverse impacts.

38 4.5.2.3 Analysis

39 At NRC’s environmental audit at CNS-1 in 2009 and in scoping comments (EPA, 2009), the
40 EPA voiced concern regarding the age of the data (over three and a half decades) used in the
41 ER to support NPPD’s assertion in their ER that CNS-1’s impingement and entrainment
42 produced a SMALL impact level on aquatic populations. To assess whether the Missouri River
43 aquatic resources near CNS-1 are stable (as described in Section 2.2.5 of this SEIS), the NRC
44 staff performed the following analysis.

1 The NRC staff examined the question of how the age of the data might affect the conclusions
2 regarding entrainment and impingement at CNS-1. The NRC staff found that the argument used
3 in the NPPD's ER is inconsistent because it assumed at different points that the aquatic
4 resources are both stable and unstable, although in fact they cannot be both. In describing the
5 aquatic resources, the ER stated that fish communities have long been responding to changes
6 in the river brought on by man's activities.

7 The NRC staff reached the conclusion of resource instability from a review of literature
8 (presented in Chapter 2) on the natural and human history of the watershed. The changes are
9 well documented: The present Missouri River is relatively new in geological terms and was
10 partly formed by the last glaciation. As a result, most species in the region have not evolved in
11 place but have colonized from surrounding environments that may have had somewhat different
12 ecologies. Man has changed the river almost constantly, particularly since European settlement.
13 Particularly influential were the early impoundments and withdrawals for irrigation and later
14 dams built for various purposes (e.g., flood control, hydroelectric power, transportation,
15 irrigation). Numerous diversions now withdraw river water for both consumptive and non-
16 consumptive uses. Dredging, bank stabilization, construction of levees, dikes, revetments, and
17 other structures have changed the course of the river, its hydrological cycles, water current
18 velocity, water levels, patterns of sediment suspension and deposition, suspended sediment
19 levels, substrate types, and other aspects of fish habitat. Agriculture, industrialization, the CWA,
20 and other regulations and associated activities have affected levels of contaminants in water
21 and sediments, dissolved oxygen levels, and other water quality parameters that affect aquatic
22 populations. Future changes to the Missouri River, for example, those flowing from the Missouri
23 River Ecosystem Restoration Plan, can be foreseen. Aquatic populations respond to these
24 habitat changes.

25 The effects of impingement and entrainment on fish populations depend in part on the identity,
26 numbers, and population structure of the affected populations. But the reviews of aquatic
27 resources in the NPPD's ER and Section 2.2.5 in this supplemental environmental impact
28 statement (SEIS) show that the aquatic populations are not static or stable.

29 The observation that the aquatic resources of the Missouri River are not static or stable affects
30 NRC's assignment of its level of impact in two ways. First is the concern voiced by the EPA
31 (2009): the age of the impingement and entrainment data brings into question "whether these
32 data are representative of current river condition and ecological impact." Second, NRC partially
33 defines its levels of impact in terms of stability: for example, NRC's definition of a small impact
34 level is that "environmental effects are not detectable or are so minor that they will neither
35 destabilize nor noticeably alter any important attribute of the resource" and the definition of large
36 impact is that "environmental effects are clearly noticeable and are sufficient to destabilize
37 important attributes of the resource." In applying its definitions of impact levels to effects of
38 CNS-1 on Missouri River aquatic resources, NRC chose an approach that can accommodate
39 the observations that the aquatic resources are changing constantly in response to many
40 environmental variables and are not stable in the sense of unchanging or static.

41 Another line of evidence is the ecology of adult and juvenile fish living in the Missouri River. The
42 ER reports that water velocity at CNS-1's intake screens is about 2 feet per second, whereas
43 "historical river velocities were usually 0.98–2.62 feet per second, but downstream from Gavins
44 Point Dam velocities between 2.62 feet per second and 4.27 feet per second occur more
45 frequently than they did historically (Berry et al. p. 6)." These observations suggest that fish in
46 the Missouri River should be adapted to living in water with velocities well in excess of the
47 current that occurs at the intake screens. So while the identity, numbers, and population

Environmental Impacts of Operation

1 structure of the potentially affected fish populations may have changed over the last decades,
2 present fish populations are most likely no less able to escape or avoid adverse impact than
3 those present when the impingement and entrainment studies were performed.

4 A third line of evidence lies in the general ecology of fish eggs and larvae subject to
5 entrainment. The generalities about the pattern of fish eggs and larvae in the Missouri River drift
6 vulnerable to entrainment at CNS-1 are probably similar to those reported by Hergenrader et al.
7 (1982) in the vicinity of CNS-1 in 1974 through 1976, although the relative and absolute
8 abundances, and perhaps some species, may have changed. Fish eggs and juveniles are
9 probably still a small part of all ichthyoplankton and most common from May through July. The
10 numerically dominant fish larvae are probably still those of pelagic spawners such as freshwater
11 drum, catostomids (e.g., suckers), cyprinids (e.g., minnows), common carp (*Cyprinus carpio*),
12 gizzard shad (*Dorosoma cepedianum*), and goldeneye (*Hiodon alosoides*). The larvae of fish
13 that build nests or spawn randomly, have adhesive and demersal (sinking) eggs, or provide
14 parental care of the eggs and larvae, such as centrarchids (e.g., white bass (*Morone chrysops*),
15 sunfish (*Lepomis* spp.), and crappie (*Pomoxis* spp.)), percids (e.g., sauger (*Stizostedion*
16 *canadense*) and walleye (*Sander vitreus*)), and channel catfish (*Ictalurus punctatus*) are
17 probably still relatively under-represented.

18 Another line of evidence is the fraction of Missouri River flow withdrawn by CNS-1. AEC (1973,
19 page V-15) found that it could describe the potential loss of fish eggs and larvae only in terms
20 of the fraction of river flow taken by the plant, which in spring and early summer when many of
21 the fish species spawned was estimated at 4 percent. During unusually low summer flows, the
22 fraction of river flow taken by the plant should be no more than 20 percent (NPPD, 2008). AEC
23 (1973) also found that the percentage loss of fish eggs and larvae originating upstream of the
24 plant was probably much less than this because of the protected areas that these species used
25 for spawning. These are very general ways of analyzing impact, and, within their limitations,
26 these generalities are probably still true today, although once again, the identity of the species
27 affected may have changed over time.

28 The available lines of evidence for assessing impact level for aquatic resources subject to
29 impingement and entrainment at CNS-1 are as follows: (1) the lack of a history of regulatory
30 action indicates no appreciable adverse impact; (2) while fish populations may have changed
31 over the decades, present fish populations are most likely no less able to escape or avoid
32 adverse impact than those present when the impingement and entrainment studies were
33 performed; (3) the generalities about the pattern of fish eggs and larvae in the Missouri River
34 drift vulnerable to entrainment at CNS-1 are probably similar to those reported in past studies
35 that found little or no adverse effects of plant operation; (4) the relative fraction of river flow
36 withdrawn by the plant remains small, and most fish species still have refugia that protect the
37 populations from adverse effects of impingement and entrainment; (5) CNS-1 now has dual flow
38 screens with modified Ristroph fish buckets and NPPD plans to install a fish handling system
39 consisting of inside and outside sprays to wash fish from the screens and a separate fish return
40 trough to mitigate adverse effects of impingement, and (6) the NDEC conclusion based on
41 monitoring and studies conducted by the Omaha Public Power District near both Fort Calhoun
42 Station and CNS-1 that losses due to entrainment were within the acceptable range.

43 Although the NRC staff reached the conclusion that aquatic resources are not stable, the NRC
44 staff finds that, although these changes may have occurred, the impact on aquatic resources
45 due to impingement and entrainment at CNS-1 is SMALL. The NRC staff has reviewed the
46 available information, including that provided by the applicant, the staff's site visit, the State of
47 Missouri, the 316(b) demonstration, and other public sources. Although no recent impact studies

1 have been performed, the NRC staff concludes that the weight of evidence from past studies,
2 biological inference, and regulatory history indicates a SMALL level of impact on aquatic
3 resources due to impingement and entrainment at CNS-1. NPPD has implemented some
4 impingement mitigation measures and plans to implement others.

5 **4.5.3 Thermal Effects**

6 For plants with once-through cooling systems and cooling pond heat dissipation systems,
7 NRC's GEIS (1996) lists the effects of heat shock as an issue requiring plant-specific evaluation
8 before license renewal (Category 2). NRC (1996) made impacts on fish and shellfish resources
9 resulting from heat shock a site-specific issue because of continuing concerns about thermal
10 discharge effects and the possible need to modify thermal discharges in the future in response
11 to changing environmental conditions.

12 Information considered includes the type of cooling system (once-through in this case),
13 evidence of a CWA Section 316(a) variance or equivalent State documentation, and other
14 information. To perform this evaluation, the staff reviewed the CNS-1's ER to NRC (NPPD,
15 2008); visited the CNS-1 site; reviewed the facility's 316(a) demonstration (Nalco, 1975) dated
16 October 23, 1975 and submitted to the NDEQ; and reviewed the applicant's State of Nebraska
17 NPDES Permit No. NE0001244 issued on July 1, 2007 and in force until July 30, 2012 (found in
18 Attachment C of NPPD, 2008).

19 The latest fact sheet for the NPDES permit summarizes the thermal limits for the effluent and
20 the bases of the limits. The EPA assisted NDEQ in conducting the assessment of mixing cooling
21 water from CNS-1 with ambient Missouri River water for the permit. The permit limits are based
22 on a modeled limit of a 90 °F "heat cap" or maximum at the end of the 5,000-foot mixing zone.
23 According to the fact sheet: "Based on a ΔT of 23.9°F, the permit limit for the Cooper Nuclear
24 power plant is 109.4 °F. The maximum instream river temperature where the heat cap is met is
25 85.54 °F (29.7 °C)" (NDEQ, 2007).

26 The NPDES permit limits are set for the protection of aquatic life (NDEQ, 2007). In addition to
27 upper thermal limits, shutdown of the plant in winter could cause sudden decreases of
28 temperature that could cause thermal shock and mortality in fish attracted to or living in the
29 thermal discharge and discharge canal (NPPD, 2008), although these events would probably be
30 rare.

31 After reviewing the available information, NRC concludes that the level of thermal impacts to the
32 aquatic community due to renewing CNS-1's operating license is designated as SMALL.

33 **4.5.4 Total Impacts on Aquatic Resources**

34 In addition to the information presented for impingement, entrainment, and thermal effects
35 individually, the results of some field studies performed in the past and summarized in section
36 2.2.5 provide information on the total impacts of CNS-1's cooling water system operation on
37 aquatic resources. Field studies comparing aquatic communities at locations upstream and
38 downstream from CNS-1 reflect the total impact of entrainment, impingement, and thermal
39 effects.

40 Reetz (1982) reported that initial (7-hour) differences in carbon fixation rates of phytoplankton at
41 CNS-1 between intake and discharge sampling locations ranged from an average of about 17
42 percent inhibition during summer to no change during winter. The inhibition in the summer

Environmental Impacts of Operation

1 months appeared to depend on absolute discharge temperature: the highest inhibition rates
2 (above 26 percent) occurred when absolute discharge temperatures exceeded 38.5 °C (101 °F).
3 Recovery from initial inhibition at CNS-1 occurred within 48 hours. While the river would carry
4 phytoplankton far downstream in 48 hours so that a substantial part of the river would be
5 affected, Reetz (1982) concluded that the low rate of water use by CNS-1 compared to river
6 flow combined with the rapid mixing of the thermal plume would make the effects relatively
7 unnoticeable.

8 Periphytic algae are those algae that are attached to solid surfaces under water such as rocks,
9 logs, pilings, and other structures. Farrall and Tesar (1982) reported results of periphytic algae
10 studies conducted in the Missouri River in the vicinity of CNS-1 from 1972 through 1977.
11 Because they remain in one place, periphytic algae colonizing natural and artificial substrata are
12 used as indicators of environmental effects. Farrell and Tesar (1982) did not detect changes in
13 the diversity, density, and biovolume of periphytic algae related to water temperature in the
14 vicinity of CNS-1, although species composition did reflect water temperature. Although these
15 results may generally be indicative of periphyton responses and processes at CNS-1 today,
16 species composition and magnitude of response, which depends on the species involved, may
17 have changed over the decades since Ferral and Tesar's (1982) studies.

18 Reepsys and Rogers (1982) investigated the effects of CNS-1 on zooplankton populations in
19 1974 through 1978. High absolute discharge temperatures (≥ 35 °C or 95 °F) critically affected
20 zooplankton survival, as did duration of exposure. Reepsys and Rogers (1982) concluded that
21 entrainment losses were small when compared to the large downstream decreases in
22 zooplankton. Without further studies, NRC concludes that these general patterns and processes
23 most likely still occur, although species composition and magnitude of response, which depends
24 on the species involved, may have changed over the decades since Reepsys and Rogers' (1982)
25 studies.

26 Carter et al. (1982) reported results of benthic infaunal and epifaunal invertebrate studies
27 conducted in the Missouri River in the vicinity of CNS-1 and Fort Calhoun Station (FCS) from
28 1973 through 1977. Benthic infauna refers to the organisms that live in underwater sediments,
29 and benthic epifauna refers to organisms that live on underwater surfaces. Like periphyton,
30 benthic invertebrates are often used as indicators of impacts because they are relatively
31 immobile and sensitive to local environmental conditions. Carter et al. (1982) were not able to
32 detect consistent changes in the epifaunal invertebrate community due to operation of CNS-1.

33 Hergenrader et al. (1982) reported the results of both field and entrainment studies on larval fish
34 in the vicinity of CNS-1 in 1974 through 1976. In order to determine if entrainment (and
35 impingement) were having an effect on the fish populations in the area, Hergenrader et al.
36 (1982) looked for changes in adult fish populations resulting from impacts to larval fish, but
37 detected none. They concluded that either no significant changes occurred or "Too few
38 resources (financial, technical, equipment, labor) were applied over too small a time frame in too
39 restricted an area to detect the changes which had occurred."

40 The aquatic community, particularly the fish community, may not be stable and may still be
41 changing in response to historical changes in land use, river regulation, and other human
42 activities. For example, the U.S. Army Corps of Engineers (USACE) (2004) reports that the
43 benthic fish community appears to be changing based on 1996 and 1997 studies. Whatever the
44 total effects of CNS-1 on the fish community were in the past, the installation of the modified
45 dual-flow traveling screens in 2006 and future installation of a low-pressure screen wash and
46 fish return trough would mitigate those impacts.

1 While the species and their numbers would have changed over the last decades, the results
 2 summarized above reflect general ecological responses.

3 The NRC staff concludes level of impact on aquatic resources due to all aspects of CNS-1's
 4 cooling system operation is SMALL.

5 **4.6 TERRESTRIAL RESOURCES**

6 Section 2.2.6 of this document provides a description of the terrestrial resources at CNS-1 and
 7 in the surrounding area. The issues related to terrestrial resources applicable to CNS-1 are
 8 discussed below and listed in Table 4-4. No Category 2 issues are related to terrestrial
 9 resources for license renewal. The NRC staff did not identify any additional new and significant
 10 information during review of the NPPD ER, the site audit, the scoping process, or the evaluation
 11 of other available information. Therefore, the NRC staff concludes that there would be no
 12 impacts related to these issues beyond those discussed in the GEIS (NRC, 1996). The GEIS
 13 concludes that the impacts are SMALL and additional site-specific mitigation measures are not
 14 likely to be sufficiently beneficial to implement.

15 **Table 4-4. Terrestrial Resources Issues**

Issues	GEIS Section	Category
Power line right-of-way management (cutting herbicide application)	4.5.6.1	1
Bird collisions with power lines	4.5.6.1	1
Impacts of electromagnetic fields on flora and fauna (plants, agricultural crops, honeybees, wildlife, livestock)	4.5.6.3	1
Floodplains and wetlands on power line right-of-way	4.5.7	1

16 **4.7 PROTECTED SPECIES**

17 **4.7.1 Aquatic Species**

18 Section 2.2.7 of this document describes the threatened or endangered species on or near
 19 CNS-1. The impact to threatened and endangered species is a Category 2 issue and is
 20 discussed below.

21 One Federally-listed aquatic species may occur in the Missouri River near CNS-1: pallid
 22 sturgeon. NPPD (2008) summarizes interactions between NPPD and both State and Federal
 23 agencies regarding conservation of pallid sturgeon.

24 In March 2006, before filing a license renewal application with NRC, NPPD voluntarily
 25 participated in meetings with the U.S. Fish and Wildlife Service (USFWS), the Nebraska Game
 26 and Parks Commission (NGPC), the NDEQ, the NDNR, the EPA, and the USACE regarding
 27 conservation actions to improve the habitat of pallid sturgeon. NPPD (2008) summarizes those
 28 meetings. Early in the discussions, the USFWS and NGPC showed interest in developing
 29 existing habitat on a parcel of property south of CNS-1 at Langdon Bend and later also on CNS-
 30 1 property on the Nebraska side of the Missouri River adjacent to Langdon Bend. They hoped to
 31 enhance pallid sturgeon habitat by building a chute to connect the active river channel with the
 32 old river area.

Environmental Impacts of Operation

1 NPPD had problems with this proposal. Implementing the proposal would reduce CNS-1's
2 mixing zone, which now extends 5,000 feet south of CNS-1 along the Nebraska side of the
3 Missouri River, to less than 2,500 feet. Reducing the mixing zone would reduce CNS-1's
4 capacity to generate electricity, particularly during summer. The proposal also posed other
5 negative safety and environmental concerns for CNS-1. As an alternative, NPPD then offered to
6 contribute funds toward other new or existing projects on the Missouri River. The USFWS
7 rejected this funding alternative in favor of increasing the amount of land for habitat
8 development.

9 To meet the goal of improving habitat for pallid sturgeon, NPPD offered a conservation
10 easement of about 230 acres of land that it owns on the Missouri side of the Missouri River,
11 opposite CNS-1, for the purposes of habitat development. USFWS indicated interest in the
12 proposal, and asked NPPD to also acquire an adjacent property of about 150 acres so that the
13 entire bend in the river could be developed into better habitat. When the property owner refused
14 to sell the land, NPPD offered a revised, final proposal to participate in and promote habitat
15 development along the Missouri River. It proposed to revisit the USFWS's and NGPC's interest
16 in a suitable conservation easement and Memorandum of Understanding to enable habitat
17 development on NPPD's approximately 230 acre parcel on the Missouri side of the river.
18 Further, because NPPD recognized that this parcel alone would not meet USFWS's and
19 NGPC's conservation habitat development goals, NPPD indicated its willingness to make an
20 additional payment of \$250,000 to be applied toward another conservation habitat development
21 project on the Missouri River at the direction of USFWS and NGPC. At the time of writing this
22 SEIS, the involved parties are discussing details of the conservation agreement.

23 Plans for and construction of a chute on the parcel may also involve the owners of the
24 transmission lines and supports that cross the property.

25 NPPD does not own these lines, although CNS-1 provides power to them.

26 The probability that CNS-1 will entrain, impinge, or otherwise affect pallid sturgeon eggs or
27 larvae is low. Hazleton (1979) collected adult and juvenile fish from seven locations in the
28 vicinity of CNS-1 from 1970 through 1978 and reported no pallid sturgeon captured. They also
29 conducted impingement sampling from 1974 through 1978 and reported no pallid sturgeon
30 impinged. Based on 374 trawl hauls that captured over 21,735 fish in a 1998 through 2000
31 survey, Hrabik et al. (2007) concluded pallid sturgeon may reproduce in the lower Missouri
32 River and the upper and lower Mississippi River, although no fish may survive to recruitment.
33 NPPD's involvement in the conservation agreement for pallid sturgeon; however, could have a
34 positive impact on the population.

35 The information available indicates that NRC level of impact associated with license renewal is
36 SMALL. Although NRC also concludes that the continued operation of CNS-1 for an additional
37 20 years may affect, but is not likely to adversely affect, the pallid sturgeon, the NRC staff
38 prepared a biological assessment, which appears in Appendix D.

39 **4.7.2 Terrestrial Species**

40 An evaluation of impacts to threatened and endangered terrestrial species requires consultation
41 with appropriate agencies to determine whether or not such species are present and whether or
42 not these species would be adversely affected by continued operation of the CNS-1 site during
43 the license renewal term.

1 NPPD has coordinated efforts with the USFWS to address the potential risk of
2 Federally-listed migratory birds colliding with transmission line NPPD TL3502, as discussed in
3 section 2.2.7.

4 Four Federally-listed endangered and threatened species, the Indiana bat (*Myotis sodalis*), the
5 western prairie fringed orchid (*Platanthera praeclara*), the piping plover, and the interior least
6 tern are potentially found in the vicinity of the CNS-1 site (NPPD, 2008). Seven Federally-listed
7 species are also found or potentially found within the counties spanning the transmission line
8 corridor, including the western prairie fringed orchid, the Salt Creek tiger beetle (*Cincindela*
9 *nevadica lincolniana*), the black-footed ferret (*Mustela nigripes*), the interior least tern, the piping
10 plover, the Eskimo curlew (*Numenius borealis*), and the only known wild population of whooping
11 cranes (USFWS 2007; USFWS 2008; USFWS 2009). The Eskimo curlew is listed as extirpated
12 from Nebraska, and is globally extinct or near-extinct (NatureServe, 2009).

13 There are 115 State-listed threatened or endangered species that occur or have the potential to
14 occur in the vicinity of CNS-1 in Nemaha County, within the counties spanning the transmission
15 line corridor in Nebraska, and in Atchison County, Missouri (NGPC, 2008; MDC, 2009b). These
16 115 species are listed in Table 2.2.7-1 along with information on their habitat requirements. No
17 longer included in this list is the American bald eagle (*Haliaeetus leucocephalus*), which was
18 formerly a Federally-listed bird. There is an active bald eagle's nest on the Missouri side of the
19 CNS-1 property with a breeding pair of eagles that have produced a number of chicks over the
20 past several years (NPPD, 2008). Although no longer protected under the Endangered Species
21 Act (ESA), the bald eagle is still protected under the Migratory Bird Treaty Act, and is also
22 protected under the Bald and Golden Eagle Protection Act from any take of a bald eagle without
23 a permit. According to the ER, NPPD attempts to minimize disturbance to the eagles during the
24 infrequent site activities performed on the Missouri side of the CNS-1 site (NPPD, 2008).

25 The staff requests that NPPD report the existence of any Federally-listed or State-listed
26 endangered or threatened species within the CNS-1 site or near the transmission line corridor to
27 NGPC, MDC, and the USFWS, if any such species are identified during the license renewal
28 term. In addition, the NPPD is required to promptly report to the appropriate wildlife
29 management agencies and to NRC, any evidence of injury to, or mortality of, migratory birds or
30 threatened or endangered species observed within the transmission line corridor, especially
31 injury to, or mortality of, Federally-listed whooping cranes, interior least terns, and piping plovers
32 along the Platte River near the western limit of CNS-1 transmission line NPPD TL3502, near
33 Grand Island, NE.

34 From the review of the available information, NRC staff finds that operation of the CNS-1 site
35 and its associated transmission lines has not been known to, nor is it expected to, adversely
36 affect any threatened or endangered species during the license renewal term. Mitigation
37 measures currently in place at the CNS-1 site include bird flight diverters on the transmission
38 lines within the CNS-1 facility, minimization of activity near the eagle's nest on the Missouri side
39 of the CNS-1 site, a right-of-way (ROW) vegetation management program, and best
40 management practices. The NPPD is also coordinating with USFWS staff to install bird diverters
41 on transmission line NPPD TL3502 where it traverses the Platte River. These bird flight
42 diverters will minimize potential impacts to whooping cranes, interior least terns, piping plovers,
43 and other migratory birds. All of these current and proposed mitigation measures minimize the
44 effects of plant operation on terrestrial species, and are found to be adequate. Therefore, the
45 NRC staff concludes that adverse impacts to threatened or endangered species during the
46 license renewal term would be SMALL.

1 **4.8 HUMAN HEALTH**

2 Table B-1 of Appendix B to Subpart A of 10 CFR Part 51 contains more information on these
 3 issues. The human health issues applicable to CNS-1 are discussed below and listed in Table
 4 4-5 for Category 1, Category 2, and uncategorized issues.

5 **Table 4-5. Human Health Issues**

Issues	GEIS Section	Category
Microbiological organisms (occupational health)	4.3.6	1
Microbiological organisms (public health, for plants using small rivers)	4.3.6	2
Noise	4.3.7	1
Radiation exposures to public (license renewal term)	4.6.1, 4.6.2	1
Occupation radiation exposures (license renewal term)	4.6.3	1
Electromagnetic fields – acute effects (electric shock)	4.5.4.1	2
Electromagnetic fields – chronic effects	4.5.4.2	Uncategorized

6 **4.8.1 Generic Human Health Issues**

7 The staff did not identify any new and significant information during its review of the NPPD’s ER,
 8 the site audit, or the scoping process. Therefore, there are no impacts related to these issues
 9 beyond those discussed in the GEIS. For these issues, the NRC staff in the GEIS concluded
 10 that the impacts are SMALL, and additional site-specific mitigation measures are not likely to be
 11 sufficiently beneficial to be warranted.

12 CNS-1 conducts an annual radiological environmental monitoring program (REMP) in which
 13 radiological impacts to the employees, the public, and the environment in the environs around
 14 the CNS-1 site are documented. The report contains a discussion of the data relative to pre-
 15 plant operation baseline data. The objectives of the REMP include the following:

- 16 • Measure and evaluate the levels of radiation and radioactive material in the
 17 environs around the CNS-1 site to assess the radiological impacts, if any, of
 18 plant operation on the environment.
- 19 • Supplement the results of the radiological effluent monitoring program by
 20 verifying that the measurable concentrations of radioactive material and
 21 levels of radiation are not higher than expected based on the measurement
 22 of radioactive effluents and modeling for the applicable exposure pathways.
- 23 • Demonstrate compliance with the requirements of applicable Federal
 24 regulatory agencies.

25 Two reports summarize radiological information about the CNS-1 site; the annual radiological
 26 environmental operating report and the annual radioactive effluent release report. The media
 27 samples are intended to be representative of the radiation exposure pathways to the public from
 28 all plant radioactive effluents. The REMP measures the aquatic, terrestrial, and atmospheric
 29 environment, as well as the ambient gamma radiation, for radioactivity. Ambient gamma

1 radiation pathways include radiation from buildings and plant structures and airborne material
 2 that may be released from the plant. In addition, the REMP also measures background radiation
 3 (i.e., cosmic sources, global fallout, and naturally occurring radioactive material, including
 4 radon). Thermoluminescent dosimeters (TLDs) are used to measure direct radiation. The
 5 atmospheric environmental monitoring consists of sampling the air for particulates and
 6 radioiodine. Terrestrial environmental monitoring consists of analyzing samples of milk and food
 7 products. The aquatic environmental monitoring consists of analyzing samples of surface water,
 8 drinking water, ground water, fish, and sediment from the Missouri River. There is also an onsite
 9 ground water protection program designed to monitor the onsite plant environment for
 10 indications of leaks from plant systems and pipes carrying radioactive liquid.

11 The NRC staff reviewed the CNS-1 radioactive environmental operating reports for 2003
 12 through 2007 to look for any significant impacts to the environment or any unusual trends in the
 13 data (NPPD 2004, 2005, 2006, 2007, 2008e). The staff's review of the REMP reports showed
 14 no unusual trends in the data and showed no measurable impact from the operations at CNS-1
 15 on the environment.

16 Historical data on radioactive releases from CNS-1 and the resultant dose calculations
 17 demonstrate that the amount of radiation received to a hypothetical maximally exposed
 18 individual in the vicinity of CNS-1 is a small fraction of the dose limits specified in 10 CFR Part
 19 20, the as low as reasonably achievable (ALARA) dose design objectives in Appendix I to 10
 20 CFR Part 50, and the EPA's radiation standards in 40 CFR Part 190, "Environmental Radiation
 21 Protection Standards for Nuclear Power Operations." Dose estimates for members of the public
 22 are calculated based on liquid and gaseous effluent release data and atmospheric and aquatic
 23 transport models. The CNS-1 2007 annual radioactive effluent release report (NPPD, 2008f)
 24 contains a detailed presentation of the radioactive discharges and the resultant calculated
 25 doses. The following summarizes the calculated hypothetical maximum dose to an individual
 26 located at the CNS-1 site boundary from radioactive liquid and gaseous effluents released
 27 during 2007:

- 28 • The maximum whole-body dose to an offsite member of the general public
 29 from liquid effluents was 0 milliroentgen equivalent man (mrem) (0 mSv
 30 (milli-siervert)) because there were no radioactive liquid discharges during
 31 2007. In 2006, the maximum whole-body dose to an offsite member of the
 32 general public from liquid effluents was 0.1326 mrem (0.0031mSv), which is
 33 below the 3 mrem (0.03 mSv) dose criteria in Appendix I to 10 CFR Part 50.
- 34 • The maximum air dose at the site boundary from gamma radiation in
 35 gaseous effluents was 6.22 E-04 milliradiation absorbed dose (mrad) (6.22
 36 E-6 mGy), which is below the 10 mrad (0.05 mGy (milligray)) dose criteria
 37 in Appendix I to 10 CFR Part 50.
- 38 • The maximum air dose at the site boundary from beta radiation in gaseous
 39 effluents was 4.03 E-04 mrad (4.03 E-06 mGy), which is below the 20 mrad
 40 dose criteria in Appendix I to 10 CFR Part 50.
- 41 • The maximum whole-body dose to an offsite member of the general public
 42 from direct radiation shine was approximately 0.5 mrem (0.005 mSv).
 43 (NPPD; 2009a)

1 The NRC staff's reviewed and assessed the CNS-1 radioactive waste system performance in
2 controlling radioactive effluents and the resultant doses to members of the public in
3 conformance with the ALARA criteria. The NRC staff found that the 2007 radiological data for
4 CNS-1 are consistent, with reasonable variation attributable to operating conditions and outages
5 and with the 5-year historical radiological effluent releases and resultant doses (NPPD, 2004a,
6 2005a, 2006a, 2007a, 2008f). These results demonstrate that CNS-1 is operating in compliance
7 with Federal radiation protection standards contained in Appendix I to 10 CFR Part 50, 10 CFR
8 Part 20, and 40 CFR Part 190. Continued compliance with regulatory requirements is expected
9 during the license renewal term; therefore, the impacts from radioactive effluents are not
10 expected to change during the license renewal term.

11 The applicant has no plans to conduct refurbishment activities during the license renewal term.
12 The applicant is expected to maintain radiological releases in accordance with its Offsite Dose
13 Assessment Manual (ODAM) and regulatory requirements as it has in the past. Thus, their
14 radiological effluent releases are not expected to be significantly different from the historical
15 radiological effluent releases. The dose to a maximally exposed individual in the vicinity of CNS-
16 1 for the refurbishment period is expected to continue to be a small fraction of the limits and
17 standards specified in 10 CFR Part 20, Appendix I to 10 CFR Part 50, and 40 CFR Part 190.

18 **4.8.2 Microbiological Organisms**

19 The effects of thermophilic microbiological organisms on human health, listed in Table B-1 of
20 Appendix to Subpart A of 10 CFR Part 51, are categorized as a Category 2 issue and require
21 plant-specific evaluation during license renewal process for the plants located on the small river,
22 that use closed-cycle cooling. The average annual flow of the Missouri River at the nearest point
23 to a CNS-1 measuring station is approximately 1.2×10^{12} ft³/yr (3.4×10^{10} m³/yr), which is less than
24 3.15×10^{12} ft³/year (9×10^{10} m³/year), the rate for which an assessment of the impact of the
25 proposed action on public health from thermophilic organisms in the affected water is required
26 by 10 CFR 51.53(c)(3)(ii)(G). Therefore, the effects on public health must be addressed.

27 The Category 2 designation is based on the magnitude of the potential public health impacts
28 associated with thermal enhancement of the enteric pathogens such as *Salmonella* spp. and
29 *Shigella* spp., the *Pseudomonas aeruginosa* bacterium, the pathogenic strain of the free-living
30 amoebae *Naegleria* spp., and *Legionella* spp. bacteria (NRC, 1996). Thermophilic
31 microorganisms generally occur at temperatures of 77 °F to 176 °F (25 °C to 80 °C) with an
32 optimal growth temperature range of 122 °F–150 °F (50 °C–66 °C), minimum and maximum
33 temperature tolerances of 68 °F (20 °C) and 158 °F (70 °C), respectively; however, thermal
34 preferences and tolerances vary across bacterial groups. Pathogenic thermophilic
35 microbiological organisms that are of concern during nuclear power reactor operation typically
36 have optimal growing temperatures of approximately 99 °F (37 °C) (Joklik and Smith, 1972).

37 *Pseudomonas aeruginosa* is an opportunistic pathogen that causes serious and sometimes fatal
38 infections in immunocompromised individuals. The organism produces toxins harmful to
39 humans and animals. It has an optimal growth temperature of 99 °F (37 °C) (Todar, 2007)
40 *Legionella* spp. consists of at least 46 species and 70 serogroups. It is responsible for
41 Legionnaires' disease, with the onset of pneumonia in the first two weeks of exposure. Risk
42 groups for *Legionella* spp. include elderly, cigarette smokers, persons with chronic lung or
43 immunocompromising diseases, and persons receiving immunosuppressive drugs.

44 The ambient temperatures of the Missouri River near CNS-1 vary from freezing (approximately
45 32 °F (0 °C)) in the winter to 87 °F–89 °F (30.5 °C–31.6 °C) in the summer; therefore, ambient

1 river conditions are not likely to support the proliferation of the pathogenic organisms of
2 concern. According to the data submitted by NPPD to the NDEQ for the period January 2003 to
3 September 2005, the mean monthly average temperature of the thermal discharge at outfall 001
4 was 75.7 °F (24.3 °C). The reported maximum daily temperature, which occurs temporarily for
5 the short time during periodic condenser backwash, was 109.2 °F (42.9 °C). The highest
6 monthly average discharge temperature was 101.7 °F (38.7 °C) in August 2003 and 101.3 °F
7 (38.5 °C) in July 2005, which is consistent with the historical data showing that monthly average
8 discharge temperatures at or above 95 °F (35 °C) occur only during July and August. Ambient
9 temperatures of the Missouri River stay below 77 °F (25 °C) from October to April; therefore,
10 ambient river conditions are not likely to support the proliferation of pathogenic organisms of
11 concern.

12 NPPD consulted the Nebraska Department of Public Health and Human Services (DHHS) and
13 the Missouri Department of Public Safety (DPS) to determine if there was any concern about the
14 potential occurrence of thermophilic microbiological organisms in the Missouri River at the CNS-
15 1 location. Nebraska DHHS and Missouri DPS stated that no occurrences of infections caused
16 by *Naegleria fowleri* from the Missouri River in the CNS-1 vicinity were documented (NPPD,
17 2008).

18 Available data assembled into biannual reports by the Center for Disease Control (CDC) for the
19 years 1999 to 2006 (CDC 2000, 2002, 2004, 2006) indicate no occurrence of waterborne
20 disease outbreaks in the State of Nebraska resulting from exposure to the thermophilic
21 microbiological organisms *Naegleria fowleri* and *Pseudomonas aeruginosa* from the operation
22 of CNS-1.

23 The NRC staff reviewed all documents, applicable to this Category 2 issue, including NPPD's
24 ER, NPDES permit, and CDC reports. The NRC staff concludes that, thermophilic
25 microbiological organisms are not likely to present a public health hazard as a result of CNS-1
26 discharges to the Missouri River.

27 The NRC staff concludes that impacts on public health from thermophilic microbiological
28 organisms from continued operation of CNS-1 in the license renewal period would be SMALL.

29 **4.8.3 Electromagnetic Fields – Acute Shock**

30 Based on the GEIS, the Commission found that electric shock resulting from direct access to
31 energized conductors or from induced charges in metallic structures has not been a problem at
32 most operating plants and generally is not expected to be a problem during the period of
33 extended operation; however, a site-specific review is required to determine the significance of
34 the electric shock potential along the portions of the transmission lines within the scope of the
35 SEIS.

36 The GEIS states that it is not possible to determine the significance of the electric shock
37 potential without a review of the conformance of each nuclear plant transmission line with
38 National Electric Safety Code (NESC) (Institute of Electrical and Electronics Engineers (IEEE)
39 2007) criteria. Evaluation of individual plant transmission lines is necessary because the issue
40 of electric shock safety was not addressed in the licensing process for some plants. For other
41 plants, land use in the vicinity of transmission lines may have changed, or power distribution
42 companies may have chosen to upgrade line voltage. To comply with 10 CFR 51.53(c)(3)(ii)(H),
43 the applicant must provide an assessment of the potential shock hazard if the transmission lines
44 that were constructed for the specific purpose of connecting the plant to the transmission

Environmental Impacts of Operation

1 system do not meet the recommendations of the NESC for preventing electric shock from
2 induced currents.

3 All transmission lines associated with CNS-1 were constructed in accordance with NESC and
4 industry guidance in effect at that time (1973). The transmission facilities are maintained to
5 ensure continued compliance with current standards. The transmission line assessment
6 program, implemented at CNS-1, ensures continued monitoring and documenting of current
7 conditions of the transmissions lines, along with maintenance, and compliance with current
8 standards. Bimonthly aerial patrols and additional special patrols after severe storms are
9 performed in order to identify any ground clearance problems and the integrity of the
10 transmission line structures. Ground inspections are conducted by transmission line technicians
11 on an annual basis (NPPD, 2008).

12 Since the lines were constructed, a new criterion has been added to the NESC for power lines
13 with voltages exceeding 98 kV. NPPD has reviewed the transmission line clearances and
14 configurations for compliance with this criterion (NPPD, 2008) and determined that all
15 transmission lines within the scope of this review meet the NESC code. No induced shock
16 hazard to the public should occur, since the lines are operating within original design
17 specifications and meet current NESC clearance standards.

18 The NRC staff has reviewed the available information, including the applicant's evaluation and
19 computational results. Based on this information, the NRC staff evaluated the potential impacts
20 for electric shock resulting from the operation of CNS-1 and its associated transmission lines.
21 NRC staff concludes that the potential impacts from electric shock during the renewal period
22 would be SMALL.

23 **4.8.4 Electromagnetic Fields–Chronic Effects**

24 In the GEIS, the chronic effects of 60-Hz EMFs from power lines were not designated as
25 Category 1 or 2, and will not be until a scientific consensus is reached on the health implications
26 of these fields. The Commission rules do not require the license renewal application to include
27 information on this issue.

28 **4.9 SOCIOECONOMICS**

29 Category 1 issues in 10 CFR Part 51, Subpart A, Appendix B, Table B-1, that are applicable to
30 socioeconomic impacts during the renewal term are listed in Table 4-6. As stated in the GEIS,
31 the impacts associated with these Category 1 issues were determined to be SMALL, and plant-
32 specific mitigation measures would not be sufficiently beneficial to be warranted.

33 NRC staff reviewed and evaluated the CNS-1 ER, scoping comments, other available
34 information, and visited CNS-1 in search of new and significant information that would change
35 the conclusions presented in the GEIS. No new and significant information was identified during
36 this review and evaluation. Therefore, it is expected that there would be no impacts related to
37 these Category 1 issues during the renewal term beyond those discussed in the GEIS.

1 **Table 4-6. Category 1 Issues Applicable to Socioeconomics during the Renewal Term**

Issues	GEIS Section	Category
Public Services: public safety, social services, and tourism and recreation	4.7.3.3; 4.7.3.4; 4.7.3.6	1
Public Services: education (license renewal)	4.7.3.1	1
Aesthetic Impacts (license renewal term)	4.7.6	1
Aesthetic impacts of transmission lines (license renewal term)	4.5.8	1

2 **4.9.1 Generic Socioeconomic Issues**

3 The following briefly describes the GEIS conclusions, as stated in Table B-1 of 10 CFR Part 51,
4 Subpart A, Appendix B, for each of the socioeconomic Category 1 issues:

5 Public services: public safety, social services, and tourism and recreation. Impacts to
6 public safety, social services, and tourism and recreation are expected to be of small
7 significance at all sites.

8 Public services: education (license renewal term). Only impacts of small significance are
9 expected.

10 Aesthetic impacts (license renewal term). No significant impacts are expected during the
11 license renewal term.

12 Aesthetic impacts of transmission lines (license renewal term). No significant impacts
13 during the license renewal term.

14 No new and significant information was identified for these issues during the review. Therefore,
15 it is expected that there would be no impacts during the renewal term beyond those discussed
16 in the GEIS.

17 Table 4-7 lists the Category 1 socioeconomic issues, which require plant-specific analysis, and
18 an environmental justice impact analysis, that was not addressed in the GEIS.

19 **Table 4-7. Category 1 Issues Applicable to Socioeconomics and Environmental Justice**
20 **during the Renewal Term**

Issues	GEIS Section	Category
Public Services: public safety, social services, and tourism and recreation	4.7.3; 4.7.3.3; 4.7.3.4; 4.7.3.6	1
Public Services: education (license renewal)	4.7.3.1	1
Aesthetic Impacts (license renewal term)	4.7.6	1
Aesthetic impacts of transmission lines (license renewal term)	4.5.8	1
Environmental Justice	Not addressed ^(a)	Uncategorized ^(a)

^(a) Guidance related to environmental justice was not in place at the time the GEIS was prepared. Environmental justice must be addressed in plant-specific reviews.

1 **4.9.2 Housing Impacts**

2 According to the 2000 Census, approximately 18,318 people lived within 20 miles of CNS-1,
3 which equates to a population density of 15 persons per square mile (NPPD, 2008). The NRC
4 staff defined in the GEIS this density to be most sparse (less than 40 persons per square mile
5 and no community with 25,000 or more persons within 20 miles) and determined it to be
6 Category 1. Approximately 160,211 people live within 50 miles of CNS-1 (NPPD, 2008). This
7 equates to a population density of 20 persons per square mile. Applying the GEIS proximity
8 measures, CNS-1 is classified as proximity. Category 1 (no city with 100,000 or more persons
9 and less than 50 persons per square mile within 50 miles). Therefore, according to the
10 sparseness and proximity matrix presented in the GEIS, rankings of sparseness Category 1 and
11 proximity Category 1 result in the conclusion that CNS-1 is located in a low population area.

12 Since Nemaha, Otoe, Richardson, and Atchison counties are not subject to growth control
13 measures that would limit housing development, any changes in employment at CNS-1 would
14 have little noticeable effect on housing availability in these counties. Since NPPD has no plans
15 to add non-outage employees during the license renewal period, employment levels at CNS-1
16 would remain relatively constant with no additional demand for permanent housing during the
17 license renewal term. Based on this information, there would be no additional impact on housing
18 during the license renewal term.

19 **4.9.3 Public Services: Public Utility Impacts**

20 In Section 4.7.4 of the GEIS, the staff defined impacts on public utility services as SMALL if the
21 existing infrastructure could accommodate any plant-related demand without a noticeable effect
22 on the level of service. Impacts are defined as MODERATE if the demand for service or use of
23 the infrastructure is sizeable and would noticeably decrease the level of service or require
24 additional resources to maintain the level of service. Impacts are defined as LARGE when new
25 programs, upgraded or new facilities, or substantial additional staff is needed because of plant-
26 related demand. In the absence of new and significant information to the contrary, the only
27 impacts on public utilities that could be significant would be impacts on public water supplies.

28 Analysis of impacts on the public water systems considered both plant demand and plant-
29 related population growth. Section 2.1.3 describes the permitted withdrawal rate and actual use
30 of water for reactor cooling at CNS-1.

31 Since NPPD has no plans to add non-outage employees during the license renewal period,
32 employment levels at CNS-1 would remain relatively unchanged with no additional demand for
33 public water services. Public water systems in the region would be adequate to meet the
34 demands of residential and industrial customers in the area. Therefore, there would be no
35 additional impact to public water services during the license renewal term.

36 **4.9.4 Offsite Land Use – License Renewal Period**

37 Offsite land use during the license renewal term is a Category 2 issue (10 CFR Part 51, Subpart
38 A, Appendix B, Table B-1). Table B-1 of 10 CFR Part 51, Subpart A, Appendix B notes that
39 “significant changes in land use may be associated with population and tax revenue changes
40 resulting from license renewal.”

1 In Section 4.7.4 of the GEIS, the NRC staff defines the magnitude of land-use changes as a
2 result of plant operation during the license renewal term as SMALL when there will be little new
3 development and minimal changes to an area's land-use pattern, as MODERATE when there
4 will be considerable new development and some changes to the land-use pattern, and LARGE
5 when there will be large-scale new development and major changes in the land-use pattern.

6 Tax revenue can affect land use because it enables local jurisdictions to provide the public
7 services (e.g., transportation and utilities) necessary to support development. Section 4.7.4.1 of
8 the GEIS states that the assessment of tax-driven land-use impacts during the license renewal
9 term should consider (1) the size of the plant's tax payments relative to the community's total
10 revenues, (2) the nature of the community's existing land-use pattern, and (3) the extent to
11 which the community already has public services in place to support and guide development. If
12 the plant's tax payments are projected to be small relative to the community's total revenue, tax
13 driven land-use changes during the plant's license renewal term would be SMALL, especially
14 where the community has pre-established patterns of development and has provided public
15 services to support and guide development. Section 4.7.2.1 of the GEIS states that if new tax
16 payments are less than 10 percent of the taxing jurisdiction's revenue, the significance level
17 would be SMALL. If tax payments are 10 to 20 percent of the community's total revenue, new
18 tax-driven land-use changes would be MODERATE. If tax payments are greater than 20 percent
19 of the community's total revenue, new tax-driven land-use changes would be LARGE. This
20 would be especially true where the community has no pre-established pattern of development or
21 has limited public services available to support and guide development.

22 4.9.4.1 *Population-Related Impacts*

23 Since NPPD has no plans to add non-outage employees during the license renewal period,
24 there would be no plant operations-driven population increase in the vicinity of CNS-1.
25 Therefore, there would be no additional population-related offsite land use impacts during the
26 license renewal term.

27 4.9.4.2 *Tax Revenue-Related Impacts*

28 As previously discussed in Chapter 2, NPPD makes annual payments in lieu of taxes (PILOT) to
29 the municipalities and 91 counties in Nebraska where NPPD sells power. Since NPPD started
30 making payments to local jurisdictions, population levels and land use conditions have not
31 changed significantly, which might indicate that these tax revenues have had little or no affect
32 on land use activities within the county. PILOT payments are based upon the gross revenues
33 NPPD receives from electricity sales in the 91 counties, regardless of where the power is
34 generated. The magnitude of the PILOT payments relative to the county's total revenues is not
35 relevant in assessing tax revenue-related offsite land use impacts since NPPD is responsible for
36 producing and distributing electricity and PILOT payments even if the CNS-1 does not produce
37 electricity or the operating license is not renewed.

38 Since NPPD has no plans to add non-outage employees during the license renewal period,
39 employment levels at the CNS-1 would remain relatively unchanged. Annual PILOT payments
40 would also remain relatively unchanged throughout the license renewal period. Based on this
41 information, there would be no additional tax-revenue-related offsite land use impacts during the
42 license renewal term.

1 **4.9.5 Public Services: Transportation Impacts**

2 Table B-1 of Appendix B to Subpart A of 10 CFR Part 51 states the following:

3 Transportation impacts (level of service) of highway traffic generated...during the
4 term of the renewed license are generally expected to be of SMALL significance.
5 However, the increase in traffic associated with additional workers and the local
6 road and traffic control conditions may lead to impacts of MODERATE or LARGE
7 significance at some sites.

8 All applicants are required by 10 CFR 51.53(c)(3)(ii)(J) to assess the impacts of highway traffic
9 generated by the proposed project on the level of service of local highways during the term of
10 the renewed license and during refurbishment activities.

11 Since NPPD has no plans to add non-outage employees during the license renewal period and
12 does not plan any refurbishment activities, there would be no noticeable change in traffic
13 volume and levels of service on roadways in the vicinity of CNS-1; therefore, there would be no
14 additional transportation impacts during the license renewal term.

15 **4.9.6 Historic and Archaeological Resources**

16 The National Historic Preservation Act (NHPA) requires Federal agencies to consider the effects
17 of their undertakings on historic properties. Historic properties are defined as resources that are
18 eligible for listing on the National Register of Historic Places (NRHP). The criteria for eligibility
19 are listed in 36 CFR 60.4 and include (1) association with significant events in history,(2)
20 association with the lives of persons significant in the past, (3) embodies distinctive
21 characteristics of type, period, or construction, and (4) sites or places that have yielded or are
22 likely to yield important information (ACHP 2009). The historic preservation review process
23 (Section 106 of the NHPA) is outlined in regulations issued by the Advisory Council on Historic
24 Preservation in 36 CFR Part 800.

25 The issuance of a renewed operating license for a nuclear power plant is a Federal action that
26 could affect historic properties on or near the nuclear plant site and transmission lines. In
27 accordance with the provisions of the NHPA, the NRC is required to make a reasonable effort to
28 identify historic properties included in or eligible for inclusion in the NRHP in the area of
29 potential effect. The area of potential effect (APE) for license renewal is the nuclear power plant
30 site, transmission lines, and immediate environs. If historic properties are present, the NRC is
31 required to contact the State Historic Preservation Office (SHPO), assess the potential impact,
32 and resolve any possible adverse effects of the undertaking (license renewal) on historic
33 properties. NRC is also required to notify the SHPO if historic properties would not be affected
34 by license renewal or if no historic properties are present.

35 NPPD contacted the Missouri SHPO and the Nebraska State Historical Society (NSHS) in
36 January 2008, requesting information on historic and archaeological resources in the vicinity of
37 CNS-1 and described the proposed action (license renewal) (NPPD, 2008). The NSHS
38 responded in February 2008 that the proposed action (license renewal) would have no effect on
39 historic structures (NPPD, 2008). The Missouri SHPO requested that an “historic architectural
40 and archaeological survey” be conducted at the CNS-1 (NPPD, 2008). In response to the
41 Missouri SHPO’s request, NPPD conducted a survey and submitted a Phase 1A Literature
42 Review and Archeological Sensitivity Assessment along with NPPD’s “Cultural Resources
43 Protection Plan” in May 2008 (NPPD, 2008). In June 2008, the Missouri SHPO concurred with
44 the conclusions in NPPD’s archaeological assessment (NPPD, 2008).

1 In accordance with 36 CFR 800.8(c), the NRC contacted the Missouri SHPO (NRC, 2008a), the
2 NSHS (NRC, 2008b), the Advisory Council on Historic Preservation (NRC, 2008c), and
3 Federally-recognized American Indian Tribes to initiate Section 106 consultation. These letters
4 are presented in Appendix D.

5 In April 2007 and March 2008, NPPD contracted with Enercon Services, Inc. to conduct an
6 "historic architectural and archaeological survey" of the CNS-1 site. A report, *Phase 1A*
7 *Literature Review and Archeological Sensitivity Assessment of the Cooper Nuclear Station,*
8 *Nemaha County, Nebraska, Atchison County Missouri*, prepared by Enercon Service for NPPD (
9 did not conduct any subsurface testing. The survey determined that 55 acres of the site were
10 heavily disturbed by construction of the CNS-1 facility and some of the lands have and continue
11 to be farmed. The study identified one prehistoric site (Whitten) adjacent to CNS-1 property, two
12 prehistoric lithic scatters, and three former house (farm) sites. All surface structures associated
13 with the earlier house sites have been demolished; however, remnants of these buildings
14 remain as historic archaeological sites and could be eligible for inclusion to the NRHP under
15 Criteria A and D pending further research. Additionally, Lewis and Clark were known to have
16 camped in the vicinity of CNS-1. The exact location of this campsite has never been
17 determined.

18 As discussed in Section 2.2.9, a search of the NSHS site files identified no previously recorded
19 historic properties on CNS-1 property; however, the Enercon report indicates that portions of the
20 Whitten site could extend onto CNS-1 property. A formal archaeological survey of the CNS-1
21 site has not been completed; however, a number of archaeological and historical research
22 studies have been conducted in both Nemaha and Atchison counties. These surveys identified
23 several historic and archaeological sites within a 6-mile radius of CNS-1. The resources found
24 during these surveys tend to occur on the same landforms that occur on the CNS-1 property
25 suggesting that there is a potential for deeply buried undiscovered historic and archaeological
26 resources on the plant property.

27 The Whitten archeological site (25NH4) is a prehistoric mound (Plains Woodland) site
28 excavated in the late 1930s. It is unclear from the archaeological site description if the Whitten
29 site was located entirely on private property north of CNS-1, or if the site extended onto the
30 CNS-1 property. Human remains, grave goods, and other artifacts were recovered from this
31 site. Artifacts recovered from the site suggest an affiliation with the Sterns Creek variant of the
32 Plains Woodland tradition (Gibbon and Ames, 1998). The NSHS site form noted that some of
33 the remains were sent to the U.S. National Museum in accordance with a Works Progress
34 Administration contract (NSHS, 1937). Historic records indicate that the entire bluff was
35 surveyed from CNS-1 property to the city of Nemaha. During Enercon's 2007 and 2008
36 walkovers, no additional burial mounds were identified; however, there remains a potential for
37 additional prehistoric sites (camp sites) to be in the area. During NRC's walkover survey, the
38 staff noted the presence of prehistoric and historic artifacts on CNS-1 property.

39 The William Dawson House (Site # NH00-69), located in the southwest corner of the site near
40 the bluff, was recorded in Nebraska historic archives but not included on the NRHP. The
41 Dawson House was torn down shortly after it was recorded. No visible remnants of the house
42 remain; however, subsurface portions of the house could remain.

Environmental Impacts of Operation

1 During the environmental site visit, the NRC staff discovered that archaeological surveys were
2 not conducted prior to the construction of the firing range. At that time, NPPD did not have
3 corporate procedures (Cultural Resources Protection Plan) in place. In preparation for license
4 renewal, NPPD contracted with Enercon to survey the site and established a Cultural
5 Resources Protection Plan to acknowledge and improve the protection of archaeological
6 resources at CNS-1. In its plan, NPPD calls for surveys to be conducted by a qualified
7 archaeologist in areas deemed sensitive prior to work commencing.

8 In addition, during the construction of the independent spent fuel storage installation (ISFSI)
9 pad, soil was removed from the top of the bluff (with consent of the landowner). Archaeological
10 surveys were not conducted prior to this activity. NPPD has since taken corrective actions to
11 ensure that all aspects of its Cultural Resources Protection Plan are followed.

12 NPPD currently has no planned changes or ground disturbing activities associated with license
13 renewal at CNS-1; however, given the high potential for the discovery of additional historic and
14 archaeological resources at the CNS-1 site, NPPD needs to ensure that these resources are
15 considered during future plant operations and maintenance activities. The CNS-1 is situated in
16 an area where historic and archaeological resources could be located several feet beneath the
17 ground surface. NPPD has instituted a stop work order within its Cultural Resources Protection
18 Plan to ensure that proper notification is taken to protect these resources should they be
19 discovered.

20 Based on review of NSHS files, archaeological surveys, assessments, and other information,
21 the potential impacts of continued operations and maintenance on historic and archaeological
22 resources at CNS-1 would be SMALL. NPPD could further reduce potential impacts to historic
23 and archaeological resources located at the CNS-1 by training NPPD staff in the Section 106
24 consultation process and cultural awareness training to ensure that informed decisions are
25 made prior to any ground disturbing activities. In addition, NPPD could also forward its Cultural
26 Resources Protection Plan to the NSHS and the Missouri SHPO for review and comment. This
27 will ensure that historic and archaeological resources are protected at the CNS-1 site. Any
28 revisions to the Cultural Resources Protection Plan should be developed in consultation with the
29 NRC, NSHS, and Missouri SHPO. In addition, lands not surveyed should be investigated by a
30 qualified archaeologist prior to any ground disturbing activity.

31 **4.9.7 Environmental Justice**

32 Under Executive Order (E.O.) 12898 (59 *Federal Register* (FR) 7629) as amended by 60 FR
33 6381, January 30, 1995, Federal agencies are responsible for identifying and addressing
34 potential disproportionately high and adverse human health and environmental impacts on
35 minority and low-income populations. In 2004, the Commission issued a Policy Statement on
36 the Treatment of Environmental Justice Matters in NRC Regulatory and Licensing Actions (69
37 FR 52040), which states "The Commission is committed to the general goals set forth in E.O.
38 12898, and strives to meet those goals as part of its National Environmental Policy Act of 1969
39 (NEPA) review process."

40 The Council on Environmental Quality (CEQ) provides the following information in
41 Environmental Justice: Guidance under the National Environmental Policy Act (NEPA) (1997):

42 **Disproportionately High and Adverse Human Health Effects.** When
43 determining whether human health effects are disproportionately high and
44 adverse, agencies are to consider the following three factors to the extent

1 practicable: (a) Whether the health effects, which may be measured in risks and
 2 rates, are significant (as employed by NEPA), or above generally accepted
 3 norms. Adverse health effects may include bodily impairment, infirmity, illness, or
 4 death; and (b) Whether the risk or rate of hazard exposure by a minority
 5 population, low-income population, or Indian tribe to an environmental hazard is
 6 significant (as employed by NEPA) and appreciably exceeds or is likely to
 7 appreciably exceed the risk or rate to the general population or other appropriate
 8 comparison group; and (c) Whether health effects occur in a minority population,
 9 low-income population, or Indian tribe affected by cumulative or multiple adverse
 10 exposures from environmental hazards. (CEQ, 1997).

11 **Disproportionately High and Adverse Environmental Effects.** When
 12 determining whether environmental effects are disproportionately high and
 13 adverse, agencies are to consider the following three factors to the extent
 14 practicable: (a) Whether there is or will be an impact on the natural or physical
 15 environment that significantly (as employed by NEPA) and adversely affects a
 16 minority population, low-income population, or Indian tribe. Such effects may
 17 include ecological, cultural, human health, economic, or social impacts on
 18 minority communities, low-income communities, or Indian tribes when those
 19 impacts are interrelated to impacts on the natural or physical environment; and
 20 (b) Whether environmental effects are significant (as employed by NEPA) and
 21 are or may be having an adverse impact on minority populations, low income
 22 populations, or Indian tribes that appreciably exceeds or is likely to appreciably
 23 exceed those on the general population or other appropriate comparison group;
 24 and (c) Whether the environmental effects occur or would occur in a minority
 25 population, low-income population, or Indian tribe affected by cumulative or
 26 multiple adverse exposures from environmental hazards. (CEQ, 1997).

27 The environmental justice analysis assesses the potential for disproportionately high and
 28 adverse human health or environmental effects on minority and low-income populations that
 29 could result from the operation of CNS-1 during the renewal term. In assessing the impacts, the
 30 following CEQ (1997) definitions of minority individuals and populations and low-income
 31 population were used:

32 **Minority.** Individual(s) who are members of the following population groups:
 33 American Indian or Alaskan Native; Asian or Pacific Islander; Black, not of
 34 Hispanic origin; or Hispanic.

35 **Minority populations.** Minority populations should be identified where either: (a)
 36 the minority population of the affected area exceeds 50 percent or (b) the
 37 minority population percentage of the affected area is meaningfully greater than
 38 the minority population percentage in the general population or other appropriate
 39 unit of geographic analysis. In identifying minority communities, agencies may
 40 consider as a community either a group of individuals living in geographic
 41 proximity to one another, or a geographically dispersed/transient set of
 42 individuals (such as migrant workers or Native American), where either type of
 43 group experiences common conditions of environmental exposure or effect. The
 44 selection of the appropriate unit of geographic analysis may be a governing
 45 body's jurisdiction, a neighborhood, census tract, or other similar unit that is to be
 46 chosen so as to not artificially dilute or inflate the affected minority population. A
 47 minority population also exists if there is more than one minority group present

Environmental Impacts of Operation

1 and the minority percentage, as calculated by aggregating all minority persons,
2 meets one of the above-stated thresholds.

3 **Low-income population.** Low-income populations in an affected area are
4 identified with the annual statistical poverty thresholds from the U. S. Census
5 Bureau's (USCB) Current Population Reports, Series PB60, on Income and
6 Poverty.

7 4.9.7.1 *Minority Population in 2000*


8 The 50-mile radius around CNS-1 includes 24 counties with nine in Nebraska, six in Kansas,
9 five in Iowa, and four in Missouri. The geographic area includes any census block with all or part
10 of its area within the 50-mile radius. According to 2000 census data, 4.3 percent of the
11 population (approximately 160,248 individuals) residing within a 50-mile (80 km) radius of CNS-
12 1 identified themselves as minority individuals. The largest minority group was Hispanic or
13 Latino (2,295 persons or 1.4 percent), followed by American Indian (2,366 or about 1.5 percent)
14 (USCB, 2003 – LandView 6). About 2.9 percent of the Nemaha County population identified
15 themselves as minorities, with Hispanic or Latino being the largest minority group (1.0 percent)
16 followed by some other race (0.7 percent) (USCB, 2009) (see Table 2.2.8.5–2).

17 Populations within each state were considered individually and as a
18 four-state geographic area. A combined or aggregate population of the four-state area was
19 calculated based on these state populations.

20 Approximately 370 (individual state method) to 380 (four-state combined method) blocks within
21 50 miles of CNS-1 were determined to have high density minority population percentages that
22 exceeded the state average by 20 percentage points or more. The largest number of high
23 density minority blocks was Hispanic or Latino, with 160 (four-state combined) to 170 (individual
24 state) blocks that exceed the state average by 20 percent or more. The greatest concentrations
25 of high density minority population blocks are located nearly 50 miles south of CNS-1 in Brown
26 County, Kansas, and approximately 30 miles south-southeast of CNS-1 where the Nebraska-
27 Kansas-Missouri state borders come together. The closest high density minority population is
28 located approximately 10 miles west of CNS-1, near Nemaha (NPPD, 2008).


29 The Sac and Fox and Iowa Indian Reservations straddle the border of Nebraska (Richardson
30 County) and Kansas (Brown and Doniphan counties). The Kickapoo Indian Reservation is
31 located south of CNS-1 in Brown County, Kansas.

32 Based on 2000 census data, Figure 4-1 (individual state method) and Figure 4-2
33 (four-state combined method) show the locations of high density minority blocks within a 50-mile
34 radius of CNS-1.



Legend


- ★ Cooper Nuclear Station
- 50-Mile Radius
- Aggregate Minority Plus Hispanic Individual States
- ▭ States
- ▭ Counties



1

2 **Figure 4-1. Minority Blocks in 2000 within a 50-Mile Radius of Cooper Nuclear Station**
 3 **(Individual State)** (Source: USCB, 2008)


Environmental Impacts of Operation



Legend

- ★ Cooper Nuclear Station
- 50-Mile Radius
- Aggregate Minority Plus Hispanic Combined States

- ▭ States
- ▭ Counties



1

2 **Figure 4-2. Minority Blocks in 2000 within a 50-Mile Radius of Cooper Nuclear Station**
 3 **(Combined State)** (Source: USCB, 2008)

4 **4.9.7.2 Low-Income Population in 2000**


5 According to 2000 census data, approximately 3,100 families and 16,000 individuals
 6 (approximately 7.3 and 10.1 percent, respectively) residing within a 50-mile radius of CNS-1
 7 were identified as living below the Federal poverty threshold in 1999 (USCB, 2003-LandView 6).
 8 The 1999 Federal poverty threshold was \$17,029 for a family of four.

9 According to census data estimates, the median household income for Nebraska in 2007 was
 10 \$47,072, with 11.1 percent of the state population living below the Federal poverty threshold.

1 Nemaha County had a lower median household income average (\$41,024) and a higher
2 percentage (13.3 percent) of individuals living below the poverty level when compared to the
3 state average. Richardson County had the lowest median household income of the four
4 counties (\$36,092) and a higher percentage (13.4 percent) of individuals living below the
5 poverty level when compared to the state. Otoe County had the highest median household
6 income (\$45,018) and the lowest percentage (9.4 percent) of individuals living below the poverty
7 level among the four counties (USCB, 2008). Atchinson County, Missouri, had a lower median
8 household income average (\$38,114) than the state and the highest percentage (14.0 percent)
9 of individuals living below the poverty level among the four counties. The median household
10 income for Missouri in 2007 was \$45,012, with 13.3 percent of the state population living below
11 the Federal poverty threshold (USCB, 2009).


12 Census block groups were considered high density low-income block groups if the percentage
13 of households below the Federal poverty threshold exceeded the state average by 20 percent or
14 more. Based on 2000 census data, there were 192 block groups within the 50-mile radius of
15 CNS-1 that exceeded the state average for low income households by 20 percent or more. The
16 majority of census block groups with low-income populations were located in two counties, Page
17 County and Nodaway County in Missouri (NPPD, 2008). Figure 4-3 (individual state method)
18 and Figure 4-4 (four-state combined method) show the location of high density low-income
19 census block groups within a 50-mile radius of CNS-1.

Environmental Impacts of Operation



Legend


- ★ Cooper Nuclear Station
- 50-Mile Radius
- Poverty Individual States
- ▭ States
- ▭ Counties



1

2 **Figure 4-3. Low-Income Block Groups with a 50-Mile Radius of Cooper Nuclear Station**

3 **(Individual States)** (Source: USCB, 2008)



1
2 **Figure 4-4. Low-Income Block with a 50-Mile Radius of Cooper Nuclear Station**
3 **(Combined States)** (Source: USCB, 2008)

Environmental Impacts of Operation

1 4.9.7.3 *Analysis of Impacts*

2 Consistent with the impact analysis for the public and occupational health and safety, the
3 affected populations are defined as minority and low-income populations who reside within a
4 50-mile radius of the CNS-1. Based on the analysis of environmental health and safety impacts
5 presented in Chapter 4 of this SEIS for other resource areas, there would be no
6 disproportionately high and adverse impacts to minority and low-income populations from the
7 continued operation of the CNS-1 during the license renewal period.

8 NRC also analyzed the risk of radiological exposure through the consumption patterns of
9 special pathway receptors, including subsistence consumption of fish, native vegetation, surface
10 waters, sediments, and local produce; absorption of contaminants in sediments through the
11 skin; and inhalation of plant materials. The special pathway receptors analysis is important to
12 the environmental justice analysis because consumption patterns may reflect the traditional or
13 cultural practices of minority and low-income populations in the area. This analysis is presented
14 below.

15 4.9.7.4 *Subsistence Consumption of Fish and Wildlife*

16 Section 4-4 of Exec. Order No. 12898 (1994) directs Federal agencies, whenever practical and
17 appropriate, to collect and analyze information on the consumption patterns of populations that
18 rely principally on fish and wildlife for subsistence and to communicate the risks of these
19 consumption patterns to the public. NRC considered whether or not there were any means for
20 minority or low-income populations to be disproportionately affected by examining impacts to
21 American Indian, Hispanic, and other traditional lifestyle special pathway receptors. Special
22 pathways that took into account the levels of contaminants in native vegetation, crops, soils and
23 sediments, surface water, fish, and game animals in the vicinity of CNS-1 were considered.

24 NPPD has an ongoing comprehensive REMP at CNS-1 that assesses the radiological impact of
25 site operations on the environment. Radiological environmental monitoring began at CNS-1 in
26 1971 before the plant became operational. The REMP program monitors radiation levels in air,
27 terrestrial, and aquatic environments. All samples are collected by NPPD personnel and are
28 shipped to a laboratory for analysis.

29 To assess the radiological impact of the plant on the environment, the monitoring program at
30 CNS-1 uses indicator-control sampling. Samples are collected at nearby indicator locations
31 downwind and downstream from the plant and at distant control locations upwind and upstream
32 from the plant. A plant effect would be indicated if the radiation level at an indicator location was
33 significantly larger than at the control location. The difference would also have to be greater
34 than could be accounted for by typical fluctuations in radiation levels arising from other
35 naturally-occurring sources.

36 Samples are collected from the aquatic and terrestrial pathways in the vicinity of CNS-1. The
37 aquatic pathways include fish, Missouri River surface water, ground water, and shoreline
38 sediment. The terrestrial pathways include airborne particulates, milk and food product garden
39 (leaf) vegetation, and direct radiation. During 2007, analyses performed on collected samples of
40 environmental media showed no significant or measurable radiological impact from CNS-1
41 operations (NPPD, 2008)

42 Aquatic sampling at the CNS-1 consists of semi-annual upstream and downstream collections
43 of fish and shoreline sediments. All samples are analyzed for gamma-emitting isotopes. River
44 water is collected monthly at two locations, one upstream of the plant and one downstream.

1 Quarterly composites are analyzed for tritium. All results were below the required lower limit of
2 detection (NPPD, 2008).

3 Sediment samples collected during June and October 2007 were analyzed by gamma
4 spectrometry. A number of naturally occurring radionuclides were detected in these samples.
5 Naturally occurring potassium-40 and thorium-228 were observed in all samples. All other
6 gamma emitters were below their detection limits (NPPD, 2008).

7 Eight samples of fish were collected during the summer and fall of 2007. A middle-top feeding
8 fish (carp) and a bottom feeding fish (catfish) were collected in June and October. These
9 samples were analyzed by gamma ray spectroscopy. Only naturally occurring potassium-40
10 was detected (NPPD, 2008).

11 According to the 2007 CNS-1 REMP, 17 milk samples from the nearest producers were
12 collected and analyzed by gamma ray spectroscopy and for low-level iodine-131 by
13 radiochemical separation. Naturally occurring potassium-40 was measured in all samples.
14 Thorium-228 was measured in one sample. All other gamma emitters were below their detection
15 levels. Four milk samples were collected from other producers. Naturally occurring potassium-
16 40 was detected in all four samples. All other gamma emitters were below their detection levels
17 (NPPD, 2008).

18 Ground water was collected from two stations quarterly and analyzed for tritium and for gamma
19 emitting radionuclides. One station is located 0.15 miles from the plant and another station 25.8
20 miles from the plant. Naturally occurring potassium-40 was detected in 2 of 24 samples
21 analyzed. Naturally occurring thorium-228 was detected in 2 of 24 samples analyzed. All other
22 gamma emitters were below their detection levels.

23 There were 26 broadleaf vegetation samples were collected June through September from
24 three locations during 2007. The samples were analyzed by gamma ray spectroscopy and for
25 low-level iodine-131 by radiochemical separation. Beryllium-7, which is produced continuously
26 in the upper atmosphere by cosmic radiation, was measured in 24 of 26 samples analyzed.
27 Naturally occurring potassium-40 was measured in all 26 samples analyzed. All other gamma
28 emitters were below their detection levels (NPPD, 2008).

29 The results of the CNS-1 2007 REMP sampling demonstrate that the routine operation at CNS-
30 1 has had no significant or measurable radiological impact on the environment. No elevated
31 radiation levels were detected in the offsite environment as a result of plant operations and the
32 storage of radioactive waste. The results of the REMP continue to demonstrate that the
33 operation of the CNS-1 did not result in a significant measurable dose to a member of the
34 general population or adversely impact the environment as a result of radiological effluents. The
35 REMP continues to demonstrate that the dose to a member of the public from the operation of
36 CNS-1 remains significantly below the Federally required dose limits specified in 10 CFR Part
37 20, 10 CFR Part 72, and 40 CFR Part 190.

38 Based on recent monitoring results, concentrations of contaminants in native leafy vegetation,
39 soils and sediments, surface water, and fish in areas surrounding CNS-1 have been quite low
40 (at or near the threshold of detection) and seldom above background levels. Consequently, no
41 disproportionately high and adverse human health impacts would be expected in special
42 pathway receptor populations in the region as a result of subsistence consumption of fish and
43 wildlife.

1 **4.10 EVALUATION OF NEW AND POTENTIALLY SIGNIFICANT INFORMATION**

2 New and significant information is (1) information that identifies a significant environmental issue
3 not covered in the GEIS and codified in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, or
4 (2) information that was not considered in the analyses summarized in the GEIS and that leads
5 to an impact finding that is different from the finding presented in the GEIS and codified in 10
6 CFR Part 51.

7 In preparing to submit its application to renew the CNS-1 operating license, NPPD developed a
8 process to ensure that information not addressed in or available during the GEIS evaluation
9 regarding the environmental impacts of license renewal for CNS-1 would be properly reviewed
10 before submitting the ER, and to ensure that such new and potentially significant information
11 would be identified, reviewed, and assessed during the NRC review period. NPPD reviewed the
12 Category 1 issues that appear in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, to verify
13 that the conclusions of the GEIS remained valid with respect to CNS-1. This review was
14 performed by personnel from CNS-1 and its support organization that were familiar with NEPA
15 issues and the scientific disciplines involved in the preparation of a license renewal ER. NRC
16 also has a process for identifying new and significant information. That process is described in
17 detail in NUREG-1555, Supplement 1, *Standard Review Plans for Environmental Reviews for*
18 *Nuclear Power Plants, Supplement 1: Operating License Renewal* (NRC, 2000). The search for
19 new information includes (1) review of an applicant's ER and the process for discovering and
20 evaluating the significance of new information; (2) review of records of public comments; (3)
21 review of environmental quality standards and regulations; (4) coordination with Federal, State,
22 and local environmental protection and resource agencies; and (5) review of the technical
23 literature. New information discovered by the NRC staff is evaluated for significance using the
24 criteria set forth in the GEIS. For Category 1 issues where new and significant information is
25 identified, reconsideration of the conclusions for those issues is limited in scope to the
26 assessment of the relevant new and significant information; the scope of the assessment does
27 not include other facets of the issue that are not affected by the new information.

28 The NRC staff has not identified any new and significant information on environmental issues
29 listed in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, related to the operation of CNS-1
30 during the period of license extension. The NRC staff also determined that information provided
31 during the public comment period did not identify any new issues that require site-specific
32 assessment. The NRC staff reviewed the discussion of environmental impacts in the GEIS
33 (NRC, 1996) and conducted its own independent review (including the public scoping meetings
34 held in February 2009) to identify new and significant information.

35 **4.11 CUMULATIVE IMPACTS**

36 The NRC staff considered potential cumulative impacts in the environmental analysis of
37 continued operation of CNS-1. For the purposes of this analysis, past actions are those related
38 to the resources at the time of the power plant licensing and construction. Present actions are
39 those related to the resources at the time of current operation of the power plant, and future
40 actions are considered to be those that are reasonably foreseeable through the end of plant
41 operation including the period of extended operation. Therefore, the analysis considers potential
42 impacts through the end of the current license terms as well as the 20-year renewal license
43 term. The geographic area over which past, present, and future actions would occur is
44 dependent on the type of action considered and is described below for each impact area.

1 The impacts of the proposed action, as described in Sections 4.1–4.9, are combined with other
2 past, present, and reasonably foreseeable future actions regardless of what agency (Federal or
3 non-Federal) or person undertakes such other actions.

4 **4.11.1 Cumulative Impacts on Water Resources**

5 NRC staff divided the description and discussion of water resources in previous sections into
6 ground water and surface water issues in order to follow the regulatory structure presented in
7 10 CFR Part 51 (2009). Hydrologic conditions at CNS-1 and elsewhere within the Missouri River
8 Valley, however, indicate a hydraulic connection between surface and ground water, particularly
9 between the Missouri River and the alluvial aquifer underlying the valley. This connection
10 reveals the possible impact of reduced river flow on ground water levels.

11 NPPD (2008) reviewed well records and identified 1,400 registered wells within the Nemaha
12 River Basin, which includes the Missouri River below its confluence with the Platte River. Of the
13 wells identified, very few are close to CNS-1. The NGPC installed three wells about 1.5 miles
14 (2.4 kilometers) south of CNS-1, and the city of Auburn, NE has a public water supply well about
15 1.9 miles (3 kilometers) south. NPPD (2008) also identified some local shallow farm wells within
16 2 miles (3.2 kilometers) of the plant property. All of the water supply wells in the area are
17 completed either in the Missouri River Valley Aquifer or Glacial Drift Aquifer, which are under
18 unconfined conditions and in hydraulic contact with the Missouri River.

19 Enercon conducted an operations study of the CNS-1 potable wells which showed an
20 equilibrium radius of influence of between 100 to 1,250 feet (46 to 381 meters) from each well.
21 Enercon's analysis of the drawdown data from the study indicated the radius of influence of
22 CNS-1's wells does not extend outside the CNS-1 property boundary. Because all the CNS-1
23 wells are in hydraulic connection with the Missouri River, recharge from the river is likely
24 induced by pumping operations. The total maximum pumping rate at CNS-1 of over 1,500
25 gallons per minute (5,678 liters per minute) is less than one percent of the average flow in the
26 river. Likewise, the influence of offsite pumping should have no measurable effect on ground
27 water levels onsite. Because the cumulative effects of pumping ground water on river flow and
28 vice versa are insignificant, the cumulative impact on water resources in the CNS-1 area is
29 SMALL.

30 **4.11.2 Cumulative Impacts on Electromagnetic Fields and Thermophilic Microbiological** 31 **Organisms**

32 The continued operation of CNS-1 has a low risk of causing outbreaks from thermophilic
33 microbiological organisms associated with thermal discharges. Available data compiled by the
34 CDC into biannual reports for the years 1999 to 2006 (CDC 2000, 2002, 2004, 2006) indicates
35 no occurrence of the waterborne disease outbreaks in the State of Nebraska resulting from
36 exposure to the thermophilic microbiological organisms *Naegleria fowleri* and *Pseudomonas*
37 *aeruginosa* due to the operation of CNS-1.

38 As part of its evaluation of cumulative impacts, the NRC staff also considered the effects of
39 thermal discharges from other facilities on the Missouri River, located within one mile upstream
40 of CNS-1, that are also producing thermal effluents. Such facilities could promote the growth of
41 thermophilic microbiological organisms. The NRC staff did not find any such facilities.

42 Potential cumulative effects of climate change on the Missouri River basin and local climate,
43 whether or not from natural cycles or anthropogenic activities, could result in a variety of

Environmental Impacts of Operation

1 changes to the surface and ground water resources in the Missouri River basin. Nebraska is a
2 part of the Great Plains Region. As projected in the “Global Climate Change Impacts in the
3 United States” report by United States Global Change Research Program (USGCRP) (2009),
4 the temperatures in southeastern Nebraska, where CNS-1 is located, are expected to rise 6 °F
5 (14 °C) by 2080–2099 at minimum and maximum over 10 °F (12 °C), causing more frequent
6 extreme weather events. Increases in average annual temperatures, higher probabilities of
7 extreme heat events, and higher occurrences of extreme rainfall (intense rainfall or drought)
8 could increase Missouri River temperatures and cause degradation of the water supply and its
9 quality. Such conditions could support the proliferation of pathogenic organisms of concern and
10 affect the burden of water-related diseases. The extent and the magnitude of the climate
11 change on human health could be significant (Intergovernmental Panel on Climate Change
12 (IPCC), 2009).

13 The NRC staff concludes that the thermophilic microbiological organisms are not likely to
14 present a public health hazard as a result of CNS-1 discharges to the Missouri River. The NRC
15 staff concludes that the cumulative impacts on public health from thermophilic microbiological
16 organisms from continued operation of CNS-1 during the license renewal period would be
17 SMALL.

18 The NRC staff determined that the CNS-1 transmission lines are operating within original design
19 specifications and meet current NESC clearance standards; therefore, the CNS-1 transmission
20 lines do not detectably affect the overall potential for electric shock from induced currents within
21 the analysis area. With respect to the chronic effects of electromagnetic fields, although the
22 GEIS finding of “not applicable” is appropriate to CNS-1, the transmission lines associated with
23 CNS-1 are not likely to detectably contribute to the regional exposure to extremely low
24 frequency electromagnetic fields. Therefore, the NRC staff has determined that the cumulative
25 impacts of continued operation of the CNS-1 transmission lines would be SMALL.

26 **4.11.3 Cumulative Impacts on Aquatic Resources**

27 This section addresses the direct and indirect effects of license renewal when added to the
28 aggregate effects of past, present, and reasonably foreseeable future actions (CEQ, 2005). The
29 direct effects on aquatic resources from an additional 20 years of CNS-1 operation accrue
30 primarily from impingement, entrainment, and heat shock to natural populations and the
31 populations on which they depend through predator-prey, competitive, and other interactions.
32 The cumulative impact is the total effect on the aquatic resources of all actions taken, no matter
33 who has taken the actions (the second principle of cumulative effects analysis in CEQ, 1997).
34 The geographic boundary for assessing cumulative aquatic impacts is somewhat variable and
35 depends on the specific resource, but is generally the lower biological zone of the Missouri
36 River, which extends from Gavins Point Dam to the confluence with the Mississippi River
37 (Galat et al., 2005a and 2005b).

38 The benchmark for assessing cumulative impacts on aquatic resources takes into account the
39 pre-operational environment as recommended by the EPA (1999) for its review of NEPA
40 documents:

41 Designating existing environmental conditions as a benchmark may focus the
42 environmental impact assessment too narrowly, overlooking cumulative impacts
43 of past and present actions or limiting assessment to the proposed action and
44 future actions. For example, if the current environmental condition were to serve
45 as the condition for assessing the impacts of relicensing a dam, the analysis

1 would only identify the marginal environmental changes between the continued
2 operation of the dam and the existing degraded state of the environment. In this
3 hypothetical case, the affected environment has been seriously degraded for
4 more than 50 years with accompanying declines in flows, reductions in fish
5 stocks, habitat loss, and disruption of hydrologic functions. If the assessment
6 took into account the full extent of continued impacts, the significance of the
7 continued operation would more accurately express the state of the environment
8 and thereby better predict the consequences of relicensing the dam.

9 Section 2.2.5 presents an overview of the condition of the Missouri River ecosystem and the
10 history and factors that led to its condition. At present, the Missouri River is a degraded
11 ecosystem that the National Research Council (NRCC) (2002) has said may be close to or
12 perhaps past the point of irreparable change. To determine and illustrate the environmental
13 changes that affect resources in cumulative impact analysis, CEQ (1997) recommends a
14 conceptual model. We present a simple conceptual model for the Missouri River ecosystem in
15 Figure 2.2.5-1 that shows how some environmental factors affect aquatic resources.

16 The NRCC (2002) identified the following man-induced changes in the Missouri River
17 ecosystem that jeopardize its fundamental natural processes: “the loss of natural flood pulses;
18 the loss of natural low flows; straightening of stream meanders and the elimination of cut-and-fill
19 alluviation; losses of natural riparian vegetation; reductions in water temperature variation;
20 introduction of nonnative species; and extensive bank stabilization and stream channelization.”
21 These changes are due to activities like dam construction that alters flow and water temperature
22 patterns, amplitude and frequency of natural peak flows used by some species as
23 environmental cues for biological processes, and sediment transport and deposition. Land use
24 changes; channelization; and construction of levees and dikes have altered almost three million
25 acres of natural riverine and floodplain habitat. These changes, and more, influence primary
26 productivity and the energy sources for aquatic communities, alter or eliminate natural habitat
27 and habitat diversity required to support some species, and change invertebrate communities
28 and food webs to fish. The NRCC (2002) found that “Of the 67 native fish species living along
29 the mainstem, 51 are now listed as rare, uncommon, or decreasing across all or part of their
30 ranges” and that one of these fish, the pallid sturgeon, is on the Federal Endangered Species
31 List.

32 In addition to these historic impacts, this section focuses on other facilities that withdraw
33 Missouri River water and introduced species. CNS-1 directly affects Missouri River aquatic
34 communities primarily through impingement, entrainment, and heat shock. Other facilities that
35 withdraw water also impact aquatic communities through at least impingement and entrainment,
36 and for some, also heat shock. The impact of introduction and stocking of native and introduced
37 fish species is also somewhat similar to the impact of CNS-1, because the effect of a power
38 plant that impinges and entrains aquatic organisms is somewhat similar to that of a large
39 predator introduced into an aquatic system.

40 The number of water consumptive and non-consumptive water intakes that withdraw water from
41 the Missouri River is relatively large (Table 4-8). The cumulative stress from this large number
42 of intakes, of which CNS-1 is one, spread across the length of the river depends on many
43 factors that NRC staff cannot quantify, but which may be significant when added to all the other
44 stresses on aquatic communities.

Environmental Impacts of Operation

1 The States have stocked and released a number of native and introduced game fish into the
2 Missouri River, primarily for sport fishing. Game fish tend to be predators, which may, through
3 predation, affect aquatic communities in a manner somewhat similar to impingement and
4 entrainment. For example, Nelson-Stastny (2004) compiled a list of selected introduced and
5 native fish species stocked or released into the Missouri River in South Dakota in relation to
6 their potential as predators of pallid sturgeon (Table 4-9). That author notes that:

7 South Dakota made several stocking attempts with other fish species to try to
8 utilize the newly created reservoir habitat in the South Dakota portion of the
9 Missouri River. The fish species that were previously stocked, but for which
10 stocking was eventually discontinued, include lake whitefish (*Coregonus*
11 *clupeaformis*), sockeye salmon/kokanee (*Oncorhynchus nerka*), cutthroat trout
12 (*Oncorhynchus clarki*), lake trout (*Salvelinus namaycush*), Bonneville cisco
13 (*Prosopium gemmiferu*), muskellunge (*Esox masquinongy*), and tiger
14 muskellunge (*Esox lucius x masquinongy*). Of these, only lake whitefish and tiger
15 muskellunge are occasionally sampled either by anglers or in fish population
16 surveys and these fish are believed to be from original stocking events (i.e., large
17 adults).

18 This example is from just one of the states in the Missouri River basin. As with water intakes,
19 the cumulative stress from all these introductions spread across the length of the river depends
20 on many factors, which NRC staff cannot quantify but which may be significant when added to
21 all the other stresses on aquatic communities.

22 While the level of impact due to direct and indirect impacts of CNS-1 on aquatic communities is
23 SMALL, the cumulative impact when combined with all other sources has resulted in the
24 Missouri River aquatic ecosystem being unstable and close to, if not past, the point of reparable
25 change. This condition meets NRC's definition of a LARGE level of impact.

1 **Table 4-8. Intakes.** Number of consumptive and non-consumptive water intakes that withdraw
 2 water from the Missouri River.

Number of intakes by location								
Reach	Lower Boundary (RM)	Intakes					Public	Total Intakes
		Power	Municipal	Industrial	Irrigation	Domestic		
Fort Peck Lake	1,771.60		1		5	101	2	109
Fort Peck	1,547.10		5 (1)	4	283 (94)	162 (14)	1	455 (109)
Lake Sakakawea	1,389.90	1	10 (5)	6 (1)	44 (10)	228 (63)	11	300 (79)
Garrison	1,317.40	6	3	6	77	28	3	123
Lake Oahe	1,072.30		8 (3)	2	179 (12)	21 (6)	8 (2)	218 (23)
Oahe	1,072.20							0
Lake Sharpe	987.40		3 (2)		91 (71)	19 (4)	2	115 (77)
Big Bend	987.30							0
Lake Francis Case	841.80		6		72	4	3	85
Fort Randall	836.10				8 (4)			8 (4)
Lewis and Clark Lake	811.10		2		27 (5)	6	2 (2)	37 (7)
Gavins Point	734.20		1		33	7	1	42
Sioux City	648.00	2	2	1	42 (3)		2	49 (3)
Omaha	597.20	3	2	1	8	2	5	21
Nebraska City	497.40	2			22	1		25
St. Joseph	374.00	3	4				2	9
Kansas City	249.90	5	4				1	10
Boonville	129.90		3				1	4
Hermann	0.00	3	3					6
Total		25	57 (11)	20 (1)	891 (199)	579 (87)	44 (4)	1,616 (302)
Above Gavins Point		7	38 (11)	18 (1)	786 (196)	569 (87)	32 (4)	
Below Gavins Point		18	19	2	105 (3)	10	12	

3 Numbers in parentheses refer to intakes located on reservation land.

4 Source: USACE, 2004a, page 3-112

1 **Table 4-9. Stastny 2004. Native and introduced fish species stocked in South Dakota into the**
 2 **Missouri River system that are to their potential as predators of pallid sturgeon. Species in this**
 3 **table were actively managed via stocking or other means in 2004 or had their status, whether**
 4 **native or nonnative, brought into question by others in litigation.**

Species Name	Common Name	Origin	Stocking Status	Years Stocked in Missouri River in South Dakota
<i>Oncorhynchus mykiss</i>	rainbow trout	I	EFS	1951, 56, 57, 64, 68, 69, 1972-2003
<i>Oncorhynchus tshawytscha</i>	Chinook salmon	I	EFS	1982-2000. 2003
<i>Salmo trutt</i>	brown trout	I	EFS	1964, 68, 79, 1981-2003
<i>Morone chrysops</i>	white bass	I	EPD	1960-62
<i>Coregonus artedi</i>	lake herring	I	EPD	1984, 88, 90-92
<i>Polyodon spathula</i>	paddlefish	N	NSA*	1974, 76-78, 1985-2003
<i>Osmerus mordax</i>	rainbow smelt	I	EPD**	-
<i>Notropis hudsonius</i>	spottail shiner	I	EPD	1973-75, 78, 79
<i>Micropterus dolomieu</i>	smallmouth bass	I	EPD	1972, 74, 80, 83-92, 94-98
<i>Esox lucius</i>	northern pike	PN, N	NSA	1957, 58, 71, 82, 83, 85, 86, 88-97
<i>Perca flavescens</i>	yellow perch	PN, N	NSA	-
<i>Sander vitreum</i>	walleye	N	NSA	1952, 53, 57, 58, 83-98, 2002

5 Table adapted from Nelson-Stastny (2004, Table 1)

6 *Paddlefish stocking in the last decade has only been in Lake Francis Case. An adult population exists in Lake
 7 Francis Case; however, natural reproduction has not been documented.

8 ** Rainbow smelt in the South Dakota portion of the Missouri River originated from fish stocked in Lake Sakakawea in
 9 North Dakota.

10 Origin as a native (N), introduced (I) or probable native (PN).

11 Stocking status refers to one of the following:

12 Established sport fishery – stocking required to maintain (EFS)

13 Established population – stocking discontinued (EPD)

14 Native – if stocked, additive to natural reproduction (NSA)

15 4.11.4 Cumulative Impacts on Terrestrial Resources

16 This section addresses past, present, and future actions that could result in adverse cumulative
 17 impacts to terrestrial resources, including wildlife populations, upland habitats, wetlands,
 18 riparian zones, invasive species, protected species, and land use. For purposes of this analysis,
 19 the geographic area considered in the evaluation includes the CNS-1 site, including the land on
 20 both the Nebraska and the Missouri sides of the Missouri River, the wetlands on and in the
 21 vicinity of the CNS-1 site, and the 145-mile long (233-kilometer) transmission line corridor
 22 identified in Section 2.1.5 of this report.

23 Prior to construction of the CNS-1 facilities and before its conversion to cropland, the region
 24 surrounding the CNS-1 property in Nemaha County, Nebraska, and Atchison County, Missouri,
 25 was historically part of a dynamic Missouri River floodplain system, located within the Missouri
 26 alluvial plain ecoregion (U.S. Geological Survey (USGS), 2001). Historically, the Missouri River
 27 meandered across the width of this relatively flat, 6-mile (10-kilometer) wide alluvial floodplain
 28 along the border of eastern Nebraska and western Missouri. The CNS-1 facilities are located
 29 near the western edge of this floodplain and adjacent to the western bank of the Missouri River.

1 The vegetation within this floodplain and its vicinity was historically dominated by tallgrass
2 prairie and wooded wetlands along the riparian corridors (NGPC, 2005). Before the completion
3 in 1950 of the Federal levee system along the Missouri River, most of the Missouri River
4 floodplain was subjected to frequent overbank flooding and much soil deposition occurred over
5 the entire width of the floodplain (NPPD, 2008; USGS, 2001). Wooded wetlands dominate the
6 239 acres of CNS-1 property on the Missouri side of the property, both today and prior to
7 conversion of approximately 40 acres of the property to agriculture (NPPD, 2008). The Missouri
8 CNS-1 property is also part of the Missouri alluvial plain ecoregion and much of the wooded
9 wetland habitat historically flooded and continues to experience overbank flooding from the
10 Missouri River (USGS, 2001).

11 Historically, over 70 percent of the land encompassing the 145-mile long (233-kilometer)
12 transmission line corridor was comprised primarily of prairie grasses of the tallgrass prairie
13 ecoregion (NPPD, 2008; NGPC, 2005). The remaining 30 percent of the land traversed by the
14 transmission line corridor was historically comprised of numerous narrow stream valleys with
15 woody vegetation and shallow intermittent streams with small pockets of wetlands (NPPD,
16 2008). The western half of the transmission line corridor traverses the Rainwater Basin Plains
17 and historically contained the largest concentrations of natural wetlands found in Nebraska.
18 Most of these wetlands have now been drained and converted to cropland and the historic
19 prairie grass regions in the counties surrounding the transmission line corridor have likewise
20 been converted to cropland (NGPC, 2005; USGS, 2001). Most of the noted stream valleys were
21 too steep or too saturated to allow agriculture and still remain vegetated.

22 Currently, over 97 percent of the land in Nemaha County, Nebraska, is used for agriculture. In
23 the adjacent Richardson County and Otoe County in Nebraska, and Atchison County in
24 Missouri, over 90 percent of the land on average is used for agriculture. Very little residential,
25 commercial, or industrial development has occurred in the counties surrounding the CNS-1 site,
26 and cumulative impacts from such types of development are considered minor.

27 Current land use on the Nebraska CNS-1 property outside of the actual power plant facilities
28 reflects the regional agricultural use. Approximately 900 acres (364 hectares) of the 1,121-acre
29 (454 hectare) CNS-1 site is used for agriculture (NPPD, 2008). Much of the 90-acres (36
30 hectares) of land where the CNS-1 facilities have been constructed was cropland prior to
31 construction of the facility, so disturbance to wildlife habitat had occurred prior to construction of
32 CNS-1. Construction on some of the CNS-1 facility led to the loss of riparian habitat along the
33 shoreline, as well as the loss of some wetlands habitat, which may have impacted wildlife
34 habitat and water quality. NPPD was recently required by the USACE to restore 55 acres (22
35 hectares) of disturbed wetlands habitat onsite as mitigation for NPPD filling in other disturbed
36 wetlands for construction of CNS-1 parking facilities.

37 Surface water drainage patterns have changed on the Nebraska CNS-1 property as a result of
38 construction of the Federal levee system and from construction of the CNS-1 facility. A dike and
39 ditch system was created on the Nebraska side of the CNS-1 site during initial construction of
40 the facilities to protect them from flooding events of the Missouri River (NPPD, 2008). Over 120
41 acres (49 hectares) of the CNS-1 site on the Nebraska side contain wooded, scrub-shrub, and
42 emergent wetlands, riparian habitat along the Missouri River, and several small intermittent
43 streams (NPPD, 2008). Construction of the ditch, dike, and levee systems on the CNS-1 site
44 have in some cases led to additional flooding on portions of the farm fields, forested areas, and
45 these wetland areas. The intermittent streams and some surface water drains south into the
46 adjacent USACE Langdon Bend Wetlands Restoration Project, which may benefit wetlands
47 restoration on the Corps' site (NDNR, 2009; USACE, 2004b).

Environmental Impacts of Operation

1 Approximately 40 acres (16 hectares) of the 239-acre (97 hectare) CNS-1 property on the
2 Missouri side are cropland, and the remaining acres are primarily wooded wetlands. Two
3 transmission line corridors that are not in scope cut through this land and contain emergent
4 vegetation. The Federal levee is located along the eastern border of this land, and reduces the
5 threat of flooding of the farm fields beyond the CNS-1 property while retaining more water on
6 the CNS-1 property. This CNS-1 property is still subject to occasional overbank flooding, as
7 evidenced by water marks located several feet up on the trunks of trees. Thus, some flooding
8 events on this land may be similar in degree of inundation to historic flooding events, helping to
9 maintain this area as a bottomland hardwood, forested wetland. Based upon discussions with
10 NPPD staff during the environmental site audit, NPPD is currently coordinating with Federal and
11 State resource agencies to place this Missouri land into a conservation easement, which may
12 lead to long-term protection of this land from any development as well as removal of the 40
13 acres of cropland from agricultural production. A pair of bald eagles has been actively nesting
14 on this property for the past several years (NPPD, 2008).

15 Several exotic invasive plant species are located along the riverbank or in the vicinity of the
16 CNS-1 site, and include purple loosestrife (*Lythrum salicaria*), reed canary grass (*Phalaris*
17 *arundinacea*), and the common reed (*Phragmites australis*) (Natural Resources Conservation
18 Services (NRCS), 2007; Nebraska Department of Agriculture (NDA), 2008). The NPPD does not
19 manage invasive vegetative species on the CNS-1 site; therefore, a potential exists for these
20 invasive species to increase in population on the CNS-1 site and compete with native vegetation
21 for resources and degrade areas of terrestrial habitat. Invasive species may also be introduced
22 on the associated transmission line ROW, with potentially similar impacts.

23 The land traversed by the transmission line corridor and most of the land in the surrounding
24 counties has been converted primarily from prairie grasses to cropland. There is currently less
25 than two percent remaining of the historic prairie grass habitat in Nebraska (NGPC, 2005;
26 USGS, 2001). Conversion from prairie grassland to cropland will affect wildlife species
27 composition and behavior, and may have a cumulative adverse impact on nutrient discharges
28 into the Missouri River and its tributaries. Farming occurs under the transmission lines and
29 immediately adjacent to the transmission line poles, so little land is lost from agricultural
30 production. Most of the narrow stream valleys now traversed by the transmission line corridor
31 remain as vegetated riparian corridors annually maintained by NPPD, primarily as scrub-shrub
32 wooded areas (NPPD, 2008). ROW maintenance of these riparian corridors has likely had some
33 minor impacts in the past and is likely to have present and future impacts on these areas from
34 their conversion from primarily forested riparian communities to scrub-shrub riparian
35 communities; however, any future maintenance activities are estimated to be minor based on
36 NPPD's plan to conduct only necessary clearing to prevent obstruction of the lines.

37 NPPD has consulted with the USFWS to address the potential risk of bird collisions with NPPD
38 transmission line NPPD TL3502 which crosses the Platte River near the end of the CNS-1
39 transmission line corridor, approximately 4 miles (6 kilometers) east of Grand Island, NE. The
40 Federally-endangered whooping crane (*Grus Americana*) and interior least tern (*Sterna*
41 *antillarum athalassos*), and the Federally-threatened piping plover (*Charadrius melodius*) use
42 the Platte River and associated wetlands around Grand Island for different portions of their
43 lifecycle (e.g., for migration, resting, feeding, and nesting) and risk collisions with the NPPD
44 transmission line. The USFWS has indicated that collisions with transmission lines are the main
45 cause of whooping crane mortality during their migrations (USFWS, 2009a); however, there are
46 no data to indicate that transmission line NPPD TL3502 has caused any injury or mortality to
47 whooping cranes, least terns, piping plovers, or to other species of Federally-protected
48 migratory birds where the transmission line crosses the Platte River. On May 8, 2009, the NPPD

1 informed the USFWS that NPPD had agreed to mark that portion of the NPPD transmission line
 2 that crosses the Platte River with bird flight diverters to increase the visibility of the transmission
 3 line and reduce the risk of collisions (NPPD, 2009). The USFWS replied to NPPD on June 8,
 4 2009, informing them that NPPD had satisfactorily addressed the concerns of the USFWS
 5 regarding bird collisions (USFWS, 2009b). This voluntary mitigation measure by NPPD will help
 6 to reduce current and future potential impacts to whooping cranes, interior least terns, piping
 7 plovers, and other migratory birds that use the Platte River and associated wetlands of the
 8 Rainwater Basin Wetland Management District (USFWS, 2009c).

9 The Missouri River ecosystem has been dramatically transformed since the beginning of the
 10 20th century. Historically, the Missouri River was free-flowing with regular overbank flooding
 11 along its entire length, and the channel meandered across the entire floodplain. The
 12 construction of seven dams upriver from CNS-1, bank stabilization, channelization of the river
 13 for improved navigation by barge traffic, and a levee and dike system constructed along most of
 14 the entire length of the floodplain have led to significant changes to the terrestrial habitat of the
 15 ecosystem. There has also been a reduction of the amount and type of deciduous vegetation,
 16 grasslands, and wetlands present within the floodplain. Within the Missouri River itself, there
 17 has also been a reduction in the number of river islands (89 percent), a reduction in the surface
 18 area of these islands (98 percent), and a reduction in the number of sandbars (97 percent)
 19 along the river (NPPD, 2008). With the implementation of Federal aquatic and terrestrial habitat
 20 restoration projects along the entire Missouri River ecosystem and the adjacent USACE
 21 Langdon Bend Wetlands Restoration Project, restoration of Missouri River terrestrial habitat is
 22 beginning to improve ecological conditions from their current state (USACE, 2004b).

23 Agriculture continues to be the overwhelming dominant land use in the region and with a
 24 declining human population in Nemaha County, additional impacts from new residential,
 25 commercial, or industrial development are not anticipated to increase terrestrial impacts.
 26 Continued runoff of nutrients from agricultural fields and bioaccumulation of pesticides or
 27 herbicides poses a threat to terrestrial and riparian habitats as well as to wildlife species;
 28 however, the Federal wetlands mitigation projects discussed above and in Section 2.2.6 will
 29 help to reduce impacts to both the aquatic and terrestrial environment.

30 The NRC staff concludes that the minimal terrestrial impacts expected from the continued CNS-
 31 1 operations, including the operation and maintenance of the 145-mile (233-kilometer) long
 32 transmission line corridor, would not contribute to the overall decline in the condition of
 33 terrestrial resources; however, the cumulative impacts on terrestrial resources resulting from all
 34 past, present, and reasonably foreseeable future actions, including non-CNS-1 activities, would
 35 be moderate.

36 **4.11.5 Cumulative Air Quality Impacts**

37 CNS-1 is located in Nemaha County, Nebraska, which belongs to the EPA Region 7. There are
 38 no counties designated by the EPA as nonattainment or maintenance counties for any of the
 39 criteria pollutants in the 50-mile (81-kilometer) vicinity of CNS-1. Douglas County, Nebraska,
 40 located approximately 72 miles (116 kilometers) from CNS-1, is the closest maintenance county
 41 for lead.

42 As discussed in Air Quality Impacts Section 2.2.2.2, Nebraska Division of Air Quality of the
 43 NDEQ has primary responsibility for regulating air emission sources within the State of
 44 Nebraska, and, with the assistance from Lincoln-Lancaster County Health Department and
 45 Douglas County Health Department, NDEQ conducts ambient air monitoring in the State,

Environmental Impacts of Operation

1 operating 28 sites throughout the state with the 34 monitors. The EPA and National
2 Atmospheric Deposition Program also monitor air quality in Nebraska, which participates in the
3 EPA's AIRNow Network which continuously monitors some of the criteria pollutants and informs
4 the public of the current environmental conditions.

5 In April 2009, the EPA published the official U.S. inventory of the greenhouse gas (GHG)
6 emissions that identifies and quantifies the primary anthropogenic sources and sinks of GHG.
7 The EPA GHG inventory is an essential tool for addressing climate change and participating
8 with the United Nations Framework Convention on Climate Change to compare the relative
9 global contribution of different emission sources and GHGs to climate change. The EPA
10 estimates that energy-related activities in the United States accounts for three-quarters of
11 human-generated GHG emissions, mostly in the form of carbon dioxide emissions from burning
12 fossil fuels. More than half of the energy-related emissions come from major stationary sources
13 like power plants, and approximately one-third comes from transportation. Industrial processes
14 (production of cement, steel, and aluminum), agriculture, forestry, other land use, and waste
15 management are also important sources of greenhouse gas emissions in the United States
16 (EPA, 2009).

17 Potential cumulative effects of climate change in southeastern Nebraska, where CNS-1 is
18 located, and local climate, whether or not from natural cycles or anthropogenic activities, could
19 result in a variety of changes to the air quality of the area. Nebraska is a part of the Great Plains
20 Region. As projected in the "Global Climate Change Impacts in the United States" report by
21 USGCRP (2009), the temperatures in southeastern Nebraska are expected to rise 6 °F (14 °C)
22 by 2080–2099 at minimum and maximum over 10 °F (12°C), causing more frequent extreme
23 weather events. Increases in average annual temperatures, higher probabilities of extreme heat
24 events, higher occurrences of extreme rainfall (intense rainfall or drought), and changes in the
25 wind patterns could affect concentrations of the air pollutants and their long-range transport
26 because their formation partially depends on the temperature and humidity, and is a result of the
27 interactions between hourly changes in the physical and dynamic properties of the atmosphere,
28 atmospheric circulation features, wind, topography, and energy use (IPCC, 2009).

29 Nebraska is a participant of Western Governors Association (WGA) that encourages the
30 participating regions to utilize its diverse resources for the production of affordable, sustainable,
31 and environmentally responsible energy. Nebraska is also a part of WGA Western Regional Air
32 Partnership which established a multi-state and tribal GHG registry and developed the GHG
33 emissions inventories.

34 As discussed in Nonradioactive Waste Management Section 2.1.3, NPPD is committed to the
35 EPA's Reduce, Reuse, Recycle program at its major and minor facilities, with a growing Green
36 Team, that focuses on pollution prevention, waste minimization, education and training of the
37 personnel, and incorporates EPA recommendations on the national implementation of the
38 climate change energy conservation techniques (EPA, 2009a).

39 In the 2008 Integrated Resource Plan, NPPD outlined the environmental goals of the company
40 with emphasis on lowering GHG emissions and obtaining 10 percent of the energy supply from
41 renewable resources by 2020 (NPPD, 2008).

42 CNS-1 is exempt from the NDEQ operating permit requirements and holds a Low Emitter Status
43 from NDEQ, based on the CNS-1 actual quantities of emissions that meet criteria and do not
44 exceed thresholds, defined in Chapter 5, Title 129 of Nebraska Administrative Code, for the
45 emissions of particulate matter PM₁₀, carbon monoxide volatile organic compounds, oxides of

1 nitrogen (NO_x), SO₂ or SO₃, or any combination of the two (SO_x), single Hazardous Air Pollutant
 2 or HAPs, and lead. As discussed in Air Quality Impacts Section 2.2.2.2, actual total emissions
 3 from all sources at CNS-1 for the period from 2004–2008 were 11.52 tons (10.45 MetricTons)
 4 per year, 10.73 tons (9.73 MetricTons) per year, 13.21 tons (11.98 MetricTons) per year, 11.43
 5 tons (10.37 MetricTons) per year and 9.85 tons (8.94 MetricTons) per year, respectively.
 6 Highest emissions for the period from 2004–2008 were reported in 2006: 0.16 tons (0.15
 7 MetricTons) per year of PM₁₀, 2.41 tons (2.19 MetricTons) per year of CO, 0.22 tons (0.20
 8 MetricTons) per year of VOC, 9.0 tons (8.16 MetricTons) per year of NO_x, 1.41 tons (1.28
 9 MetricTons) per year of SO_x, and 0.01 tons (0.009 MetricTons) per year of single HAP (NPPD,
 10 2009).

11 NPPD stated in the environmental report (NPPD, 2008) and NRC staff confirmed that no
 12 refurbishment is planned at CNS-1 during the license renewal period.

13 Based on all of the above, the staff concludes The Staff concludes that combined with the
 14 emissions from other past, present, and reasonably foreseeable future actions, cumulative
 15 hazardous and criteria air pollutants emissions on air quality from CNS-1 related actions would
 16 be SMALL. When considered with respect to an alternative of building a fossil-fuel powered
 17 plant, continuing the operation of the CNS-1 could constitute a net cumulative beneficial
 18 environmental impact in terms of reducing hazardous, criteria, and GHG air emissions; only the
 19 Combined Alternative (described in Chapter 6) would be equivalent to or would contribute less
 20 cumulative emissions than the option of license renewal.

21 **4.11.6 Cumulative Human Health Impacts**

22 NRC and the EPA developed radiological dose limits for protection of the public and workers to
 23 address the cumulative impact of acute and long-term exposure to radiation and radioactive
 24 material. These dose limits are codified in 10 CFR Part 20 and 40 CFR Part 190. This analysis
 25 includes the area within a 50-mile (80-kilometer) radius of the CNS-1 site. The REMP conducted
 26 by NPPD in the vicinity of the CNS-1 site measures the cumulative impact of radiation and
 27 radioactive materials from all sources.

28 As discussed in Section 4.8.1 of this report, the staff reviewed the radiological environmental
 29 radiation monitoring results for the five-year period from 2003–2007 as part of the cumulative
 30 impacts assessment. Cumulative radiological impacts from all uranium fuel cycle facilities within
 31 a 50-mile (80 km) radius of the CNS-1 site, are limited by the dose limits codified in 10 CFR Part
 32 20 and 40 CFR Part 190. In Section 4.8 of this report, the NRC staff concluded that the impacts
 33 of radiation exposure to the public from the operation of CNS-1 during the renewal term would
 34 be SMALL. NRC and the EPA will regulate any future actions in the vicinity of the CNS-1 site
 35 that could contribute to cumulative radiological impacts; therefore, the NRC concludes that the
 36 cumulative impacts from continued operations of CNS-1 would be SMALL.

37 **4.11.7 Cumulative Socioeconomic Impacts**

38 As discussed in Section 4.4, continued operation of CNS-1 during the license renewal term
 39 would have no impact on socioeconomic conditions in the region beyond those already
 40 experienced. Since NPPD has no plans to hire additional workers during the license renewal
 41 term, overall expenditures and employment levels at CNS-1 would remain relatively constant
 42 with no additional demand for permanent housing and public services. In addition, since
 43 employment levels and tax payments would not change, there would be no population or tax
 44 revenue-related land use impacts. There would also be no disproportionately high and adverse

Environmental Impacts of Operation

1 health and environmental impacts on minority and low-income populations in the region. Based
2 on this and other information presented in this chapter, there would be no cumulative
3 socioeconomic impacts from the continued operation of CNS-1 during the license renewal term
4 beyond what is currently being experienced.

5 Any ground disturbing activities during the license renewal term, however, could result in the
6 cumulative loss of historic and archaeological resources. Historic and archaeological resources
7 are non-renewable; therefore, the loss of archaeological resources is cumulative. The continued
8 operation of CNS-1 during the license renewal term has the potential to impact unknown historic
9 and archaeological resources.

10 As discussed in Section 4.9.6, continued operation of the CNS-1 during the license renewal
11 term would have a SMALL impact on archaeological resources at the CNS-1 site. NPPD has no
12 plans to alter the CNS-1 site for license renewal. Any future land disturbing activities would be
13 carried out under corporate procedures. Should plans change, further consultation would be
14 initiated by NPPD with the NRC and SHPO. Because impacts to historic and archaeological
15 resources from the continued operation of CNS-1 would be SMALL, the cumulative
16 environmental impacts to historic and archaeological resources would be SMALL.

17 **4.11.8 Summary of Cumulative Impacts**

18 We considered the potential impacts resulting from the operation of CNS-1 during the period of
19 extended operation and other past, present, and future actions in the vicinity of CNS-1. The
20 preliminary determination is that the potential cumulative impacts resulting from CNS-1
21 operation during the period of extended operation would be SMALL to MODERATE.

1 **Table 4-10. Summary of Cumulative Impacts on Resources Areas**

Resource Area	Impact	Discussion
Water Resources	SMALL	The total maximum pumping rate at CNS-1 of over 1,500 gallons per minute (5,678 liters per minute) is less than one percent of the average flow in the river. Likewise, the influence of offsite pumping should have no measurable effect on ground water levels onsite. Because the cumulative effects of pumping ground water on river flow and vice versa are insignificant, the cumulative impact on water resources in the CNS-1 area is SMALL.
Aquatic Resources	LARGE	While the level of impact due to direct and indirect impacts of CNS-1 on aquatic communities is SMALL, the cumulative impact when combined with all other sources has resulted in the Missouri River aquatic ecosystem being unstable and close to, if not past, the point of reparable change. This condition meets NRC's definition of a LARGE level of impact.
Terrestrial Resources	MODERATE	Agriculture continues to be the overwhelming dominant land use in the region, and with a declining human population in Nemaha County, additional impacts from new residential, commercial, or industrial development are not anticipated to increase terrestrial impacts. Continued runoff of nutrients from agricultural fields and bioaccumulation of pesticides or herbicides poses a threat to terrestrial and riparian habitats, as well as to wildlife species. However, the Federal wetlands mitigation projects discussed above and in Section 2.2.6 will help to reduce impacts to both the aquatic and terrestrial environment. The NRC staff concludes that the minimal terrestrial impacts expected from the continued CNS-1 operations, including the operation and maintenance of the 145-mile (233 km) long transmission line corridor, would not contribute to the overall decline in the condition of terrestrial resources. The cumulative impacts, however, on terrestrial resources resulting from all past, present, and reasonably foreseeable future actions, including non-CNS-1 activities, would be MODERATE.
Air Quality	SMALL	NPPD is committed to the EPA's Reduce, Reuse, Recycle program at its major and minor facilities, with a growing Green Team, that focuses on pollution prevention, waste minimization, education and training of the personnel, and incorporates EPA recommendations on the national implementation of the climate change energy conservation techniques. CNS- 1 holds a Low Emitter Status from NDEQ, based on the CNS-1 actual quantities of emissions that meet criteria and do not exceed thresholds. The NRC staff concludes that the minimal air quality impacts expected from the continued CNS-1 operation would not destabilize the air quality in the vicinity of CNS-1; therefore, the NRC staff concludes that the cumulative impacts on the air quality from the continued operation of CNS-1 during the license renewal period would be SMALL.
Socioeconomics	SMALL	In Section 4.8 of this report, the NRC staff concluded that the impacts of radiation exposure to the public from the operation of CNS-1 during the renewal term would be SMALL. NRC and the EPA will regulate any future actions in the vicinity of the CNS-1 site that could contribute to cumulative radiological impacts; therefore, the NRC concludes that the cumulative impacts from continued operations of CNS-1 would be SMALL.

Environmental Impacts of Operation

Resource Area	Impact	Discussion
Human Health	SMALL	Cumulative radiological impacts from all uranium fuel cycle facilities within a 50-mile (80-kilometer) radius of the CNS-1 site are limited by the dose limits codified in 10 CFR Part 20 and 40 CFR Part 190. In Section 4.8 of this report, the staff concluded that the impacts of radiation exposure to the public from the operation of CNS-1 during the renewal term would be SMALL. NRC and Nebraska will regulate any future actions in the vicinity of the CNS-1 site that could contribute to cumulative radiological impacts; therefore, the NRC concludes that the cumulative impacts from continued operations of CNS-1 would be SMALL.
Archaeological Resources	SMALL	NPPD has no plans to alter the CNS-1 site for license renewal. Any future land disturbing activities would be carried out under corporate procedures. Archaeological surveys would be conducted in areas identified as archaeologically sensitive prior to any ground disturbing activities. Should plans change, further consultation would be initiated by NPPD with NRC, NSHS, and Missouri SHPO. Because impacts to historic and archaeological resources from the continued operation of CNS-1 would be SMALL, the cumulative environmental impacts to historic and archaeological resources would be SMALL.
Electromagnetic Fields and Thermophilic Microbiological Organisms	SMALL	The NRC staff concludes that the thermophilic microbiological organisms are not likely to present a public health hazard as a result of CNS-1 discharges to the Missouri River. The staff concludes that the cumulative impacts on public health from thermophilic microbiological organisms from continued operation of CNS-1 during the license renewal period would be SMALL. The NRC staff determined that the CNS-1 transmission lines are operating within original design specifications and meet current NESC clearance standards; therefore, the CNS-1 transmission lines do not detectably affect the overall potential for electric shock from induced currents within the analysis area. With respect to the chronic effects of EMFs, although the GEIS finding of “not applicable” is appropriate to CNS-1, the transmission lines associated with CNS-1 are not likely to detectably contribute to the regional exposure of ELF-EMFs; therefore, the NRC staff has determined that the cumulative impacts of the continued operation of the CNS-1 transmission lines would be SMALL.

1 4.12 REFERENCES

- 2 10 CFR Part 20. *Code of Federal Regulations*, Title 10, *Energy*, Part 20, “Standards for
3 Protection Against Radiation.”
- 4 10 CFR Part 50. *Code of Federal Regulations*, Title 10, *Energy*, Part 50, “Domestic Licensing of
5 Production and Utilization Facilities.”
- 6 10 CFR Part 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, “Requirements for
7 Renewal of Operating Licenses for Nuclear Power Plants.”
- 8 36 CFR Part 60. *Code of Federal Regulations*, Title 36, *Parks, Forests, and Public Property*,
9 Part 60, Section 4, “Criteria for Evaluation.”
- 10 36 CFR Part 800. *Code of Federal Regulations*, Title 36, *Parks, Forests, and Public Property*,
11 Part 800, “Protection of Historic Properties.”

- 1 40 CFR Part 190. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 190,
2 “Environmental Radiation Protection Standards for Nuclear Power Operations.”
- 3 Advisory Council on Historic Preservation (ACHP). 2009. “National Register Evaluation Criteria.”
4 Available URL: <http://www.achp.gov/nrcriteria.html> (accessed on May 4, 2009).
- 5 U.S. Atomic Energy Commission (AEC). 1972. *Final Environmental Statement Related to*
6 *Operation of Cooper Nuclear Station*. Nebraska Public Power District. Docket No. 50-298.
7 Directorate of Licensing. Washington, D.C. February 1972.
- 8 U.S. Atomic Energy Commission (AEC). 1973. Final Environmental Statement related to the
9 Cooper Nuclear Station. Northern States Power Company. Facility Operating License DPR-46.
10 Directorate of Licensing. Washington, D.C.
- 11 Advisory Council on Historic Preservation (ACHP). 2009. “National Register Evaluation Criteria.”
12 Available URL: <http://www.achp.gov/nrcriteria.html> (accessed on May 4, 2009).
- 13 Carter, S.R., K.R. Bazata, and D.L. Anderson (Carter). 1982. Chapter 7: Macroinvertebrate
14 communities of the channelized Missouri River near Two Nuclear Power Stations. Pages 146-
15 182 in Hesse, L.W., G.L. Hergenrader, H.S. Lewis, S.D. Reetz, and A.B. Schlesinger (eds.), *The*
16 *Middle Missouri River: A Collection of Papers on the Biology with Special Reference to Power*
17 *Station Effects*. The Missouri River Group, Norfolk, Nebraska.
- 18 Center for Disease Control and Prevention (CDC). 2000. *Surveillance for Waterborne Disease*
19 *and Outbreaks Associated with Recreational Water Use and Other Aquatic Facility-Associated*
20 *Health Events --- United States, 1999–2000*. Available URL:
21 <http://www.cdc.gov/mmwr/preview/mmwrhtml/ss5108a1.htm#tab6> (accessed May 2009).
- 22 Center for Disease Control and Prevention (CDC). 2002. *Surveillance for Waterborne Disease*
23 *and Outbreaks Associated with Recreational Water Use and Other Aquatic Facility-Associated*
24 *Health Events --- United States, 2001–2002*. Available URL:
25 <http://www.cdc.gov/mmwr/preview/mmwrhtml/ss5308a1.htm#tab3> (accessed May 2009).
- 26 Center for Disease Control and Prevention (CDC). 2004. *Surveillance for Waterborne Disease*
27 *and Outbreaks Associated with Recreational Water Use and Other Aquatic Facility-Associated*
28 *Health Events --- United States, 2003–2004*. Available URL:
29 <http://www.cdc.gov/mmwr/preview/mmwrhtml/ss5512a1.htm> (accessed May 2009).
- 30 Center for Disease Control and Prevention (CDC). 2006. *Surveillance for Waterborne Disease*
31 *and Outbreaks Associated with Recreational Water Use and Other Aquatic Facility-Associated*
32 *Health Events --- United States, 2005–2006*. Available URL:
33 <http://www.cdc.gov/mmwr/preview/mmwrhtml/ss5709a1.htm#fig2> (accessed May 2009).
- 34 Conestoga Rover and Associates (CRA). 2007. Hydrogeologic Investigation Work Plan, Ground
35 Water Protection Initiative, Cooper Nuclear Station, Brownsville, Nebraska.
- 36 Council of Environmental Quality (CEQ). 1997. *Considering Cumulative Effects under the*
37 *National Environmental Policy Act*. Executive Office of the President, Washington, D.C.
- 38 Council of Environmental Quality (CEQ). 2005. Memorandum from J. L. Connaughton,
39 Chairman to Heads of Federal Agencies Re: Guidance on the consideration of past actions in
40 cumulative effects analysis. June 24, 2005. Executive Office of the President, Washington, D.C.
41 Available URL: http://www.nepa.gov/nepa/regs/Guidance_on_CE.pdf. (accessed June 2, 2009).
- 42 Environmental Protection Agency (EPA). 1977. Guidance for Evaluating the Adverse Impact of
43 Cooling Water Intake Structures on the Aquatic Environment: Section 316(b) P.L. 92-500. Draft
44 May 1, 1977. Office of Water Enforcement, Permits Division, Washington, D.C.

Environmental Impacts of Operation

- 1 Environmental Protection Agency (EPA). 1998. Guidelines for Ecological Risk Assessment.
2 EPA/630/R-95/002F. Risk Assessment Forum, Washington, D.C.
- 3 Environmental Protection Agency (EPA). 1999. Consideration of Cumulative Impacts in EPA
4 Review of NEPA Documents. EPA-315-R-99-002. Office of Federal Activities (2252A),
5 Washington, D.C.
- 6 Environmental Protection Agency (EPA). 2009. "2009 U.S. Greenhouse Gas Inventory Report.
7 Inventory of U.S. Greenhouse Gas Emissions and Sinks: 1990–2007." Available URL:
8 <http://www.epa.gov/climatechange/emissions/usinventoryreport.html> (accessed June 2009).
- 9 Environmental Protection Agency (EPA). 2009a. "Climate Change – What You Can Do: Actions
10 You Can Take at the Office". Available URL:
11 <http://www.epa.gov/climatechange/wycd/actionsteps.html#office> (accessed June 2009).
- 12 Environmental Protection Agency (EPA). 2009b. E-mail from L. Shepherd, USEPA, Region 7 to
13 USNRC (CooperEIS Resource@nrc.gov). Subject: Scoping Comments for Relicensing of
14 Cooper Nuclear Station, Brownville, NE. March 27, 2009. ADAMS Accession No.
15 ML091070269.
- 16 Farrell, J.R. and M.A. Tesar. 1982. Chapter 5: Periphytic algae in the channelized Missouri
17 River with special emphasis on apparent optimal temperatures. Pages 84-123 in Hesse, L.W.,
18 G.L. Hergenrader, H.S. Lewis, S.D. Reetz, and A.B. Schlesinger (eds.), *The Middle Missouri
19 River: A Collection of Papers on the Biology with Special Reference to Power Station Effects*.
20 The Missouri River Group, Norfolk, Nebraska.
- 21 Galat, D.L., C.R. Berry, Jr., W.M. Gardner, J.C. Hendrickson, G.E. Mestl, G.J. Power, C. Stone,
22 and M.R. Winston (Galat et. al.). 2005a. *Spatiotemporal patterns and changes in Missouri River
23 Fishes*. American Fisheries Society Symposium 45:249–291.
- 24 Galat, D.L., C.R. Berry, Jr., E.J. Peters, and R.G. White (Galat et. al.). 2005b. Missouri River
25 Basin. A.C. Benke, and C.E. Cushing (eds.), *Rivers of North America*. Elsevier Academic Press,
26 New York, pp. 427-480.
- 27 Hazleton Environmental Sciences Corporation (Hazleton). 1979. "Report to Nebraska Public
28 Power District, Columbus, Nebraska: The Evaluation of Thermal Effects in the Missouri River
29 Near Cooper Nuclear Station (Operational Phase), January– December 1978, Project No.
30 8903." Hazleton Environmental Sciences Corporation, Lincoln, Nebraska. ADAMS Accession
31 No. ML092450614.
- 32 Hergenrader, G.L., L.G. Harrow, R.G. King, G.F. Cada, and A.B. Schlesinger (Hergenrader).
33 1982. Chapter 8: Larval fishes in the Missouri River and the effects of entrainment. Hesse, L.W.,
34 G.L. Hergenrader, H.S. Lewis, S.D. Reetz, and A.B. Schlesinger (eds.), *The Middle Missouri
35 River: A Collection of Papers on the Biology with Special Reference to Power Station Effects*.
36 The Missouri River Group, Norfolk, Nebraska, pp. 184-223.
- 37 Institute of Electrical and Electronics Safety Code (IEEE). 2007. *National Electric Safety Code*.
- 38 Intergovernmental Panel on Climate Change (IPCC). 2009. "IPCC Fourth Assessment Report:
39 Working Group II Report "Impacts, Adaptation and Vulnerability." Available URL:
40 <http://www.ipcc.ch/ipccreports/ar4-wg2.htm> (accessed June 2009).
- 41 Joklik, W.K. and D.T. Smith. 1972. *Zinsser Microbiology*. Addleton-Century-Croft, New York.
- 42 Missouri Department of Conservation (MDC). 2009a. Letter from D. Brown, Policy Coordinator,
43 Missouri Department of Conservation, Headquarters, to R. Bulavinetz, Aquatic Ecologist,
44 Division of License Renewal, Nuclear Regulatory Commission. Subject: Cooper Nuclear Plant.
45 March 26, 2009. ADAMS Accession No. ML091030465.

- 1 Missouri Department of Conservation (MDC). 2009b. MDC Heritage Database Results for
2 Atchison County. Available URL: [http://mdc.mo.gov/cgi-](http://mdc.mo.gov/cgi-bin/heritage/search.cgi?county=Atchison)
3 [bin/heritage/search.cgi?county=Atchison](http://mdc.mo.gov/cgi-bin/heritage/search.cgi?county=Atchison) (accessed April 21, 2009).
- 4 National Historic Preservation Act (NHPA) of 1966. 16 U.S.C. 470, et seq.
- 5 Nalco Environmental Sciences (Nalco). 1975. Report to Nebraska Public Power District
6 Columbus, Nebraska: The Evaluation of Thermal Effects in the Missouri River near Cooper
7 Nuclear Station 316 a & b Demonstration, Project No. 64306575. Nalco Environmental
8 Sciences, Lincoln, Nebraska. ADAMS Accession No. ML092450626.
- 9 National Institute of Environmental Health Sciences (NIEHS). 1999. *NIEHS Report on Health*
10 *Effects from Exposure to Power Line Frequency and Electric and Magnetic Fields*. Publication
11 No. 99-4493, Research Triangle Park, NC.
- 12 NatureServe. 2009a. NatureServe Explorer. Version 7.1. Eskimo curlew. Available URL:
13 <http://www.natureserve.org/explorer/servlet/NatureServe> (accessed Jun 4, 2009).
- 14 Nebraska Department of Agriculture (NDA), 2008. Press Release: NDA Adds Phragmites to
15 Noxious Weed List Under Temporary Order. April 15, 2008. Available URL:
16 <http://www.agr.state.ne.us/newsrel/april2008/phragmites.htm> (accessed March 9, 2009).
- 17 Nebraska Department of Environmental Quality (NDEQ). 2008. "Annual Air Quality Report
18 Nebraska Air Quality 2007." Nebraska Department of Environmental Quality, Air Quality
19 Division. ADAMS Accession No. ML091750103
- 20 Nebraska Department of Environmental Quality (NDEQ). 2009. "2009 Ambient Air Monitoring
21 Network Plan." ADAMS Accession No. ML091750088
- 22 National Institute of Environmental Health Sciences (NIEHS). 1999. *NIEHS Report on Health*
23 *Effects from Exposure to Power Line Frequency and Electric and Magnetic Fields*. Publication
24 No. 99-4493, Research Triangle Park, North Carolina.
- 25 Nebraska Public Power District (NPPD). 2004. Cooper Nuclear Station, *Annual Radiological*
26 *Environmental Monitoring Program Report for 2003*. Brownville, Nebraska. ADAMS Accession
27 No. ML041340134.
- 28 Nebraska Public Power District (NPPD). 2004a. Cooper Nuclear Station, *Annual Radioactive*
29 *Effluent Release Report for 2003*. Brownville, Nebraska. ADAMS Accession No. ML041190422.
- 30 Nebraska Public Power District (NPPD). 2005. Cooper Nuclear Station, *Annual Radiological*
31 *Environmental Monitoring Program Report for 2004*. Brownville, Nebraska. ADAMS Accession
32 No. ML051160385.
- 33 Nebraska Public Power District (NPPD). 2005a. Cooper Nuclear Station, *Annual Radioactive*
34 *Effluent Release Report for 2004*. Brownville, Nebraska. ADAMS Accession No. ML051220511.
- 35 Nebraska Public Power District (NPPD). 2006. Cooper Nuclear Station, *Annual Radiological*
36 *Environmental Monitoring Program Report for 2005*. Brownville, Nebraska. ADAMS Accession
37 No. ML061360083.
- 38 Nebraska Public Power District (NPPD). 2006a. Cooper Nuclear Station, *Annual Radioactive*
39 *Effluent Release Report for 2005*. Brownville, Nebraska. ADAMS Accession No. ML061240548.
- 40 Nebraska Public Power District (NPPD). 2007. Cooper Nuclear Station, *Annual Radiological*
41 *Environmental Monitoring Program Report for 2006*. Brownville, Nebraska. ADAMS Accession
42 No. ML071380490.

Environmental Impacts of Operation

- 1 Nebraska Public Power District (NPPD). 2007a. Cooper Nuclear Station, *Annual Radioactive*
2 *Effluent Release Report for 2006*. Brownville, Nebraska. ADAMS Accession No. ML071240393.
- 3 Nebraska Public Power District (NPPD). 2008. *License Renewal Application, Cooper Nuclear*
4 *Station*, Appendix E, Applicant's Environmental Report, Operating License Renewal Stage.
5 ADAMS Accession No. ML083030246
- 6 Nebraska Public Power District (NPPD). 2008a. *Nebraska Public Power District Cooper Nuclear*
7 *Station, Radiological Environmental Monitoring Program, 2007 Annual Report, January 1, 2007*
8 *through December 31, 2007*. Brownville, Nebraska. May 15, 2008. ADAMS Accession No.
9 ML0814105840.
- 10 Nebraska Public Power District (NPPD) 2008b. "2008 Integrated Resource Plan". ADAMS
11 Accession No. ML091750299.
- 12 Nebraska Public Power District (NPPD). 2008c. *Nebraska Public Power District, Cooper*
13 *Nuclear Station, License Renewal Application*. September 24, 2008. ADAMS Accession No.
14 ML083030227.
- 15 Nebraska Public Power District (NPPD). 2008d. Letter from K.M. Krumland, Environmental
16 Protection Supervisor, NPPD to Donna K. Garden, Nebraska Department of Environmental
17 Quality. Subject: Nebraska Public Power District, Cooper Nuclear Station NPDES Permit
18 #NE0001244, Annual 316(b) Compliance Report. February 29, 2008. ADAMS Accession No.
19 ML092450698.
- 20 Nebraska Public Power District (NPPD). 2008e. Cooper Nuclear Station, *Annual Radiological*
21 *Environmental Monitoring Program Report for 2007*. Brownville, Nebraska. ADAMS Accession
22 No. ML081410584.
- 23 Nebraska Public Power District (NPPD). 2008f. Cooper Nuclear Station, *Annual Radioactive*
24 *Effluent Release Report for 2007*. Brownville, Nebraska. ADAMS Accession No. ML081300029.
- 25 Nebraska Public Power District (NPPD). 2009. Response to Request for Additional Information
26 for License Renewal Application Environmental Report Cooper Nuclear Station, Docket No. 50-
27 298, DPR-46. Low Emitter Status for NPPD's Cooper Nuclear Station, NDEQ Facility ID
28 #36750. March 27, 2009. ADAMS Accession No. ML091600712
- 29 Nebraska Public Power District (NPPD). 2009a. Response to Request for Additional Information
30 for License Renewal Application Environmental Report Cooper Nuclear Station, Docket No. 50-
31 298, DPR-46, May 18, 2009. ADAMS Accession No.
- 32 Nebraska Department of Environmental Quality (NDEQ). 2007. Attachment A: Fact Sheet,
33 NPPD Cooper Nuclear Power Station, Brownville, Nebraska, NPDES NE0001244 / PCS 36750-
34 P. January 10, 2007. Wastewater Section. Lincoln, Nebraska. ADAMS Accession No.
35 ML092450693.
- 36 Nebraska Department of Environmental Quality (NDEQ) 1977. Letter from D.T. Drain, Director
37 to L.J. Cooper, Director, Nebraska Public Power District. Subject: 316(b) Demonstration Cooper
38 Nuclear Station, NPDES Permit No. NE 0001244. February 2, 1977. ADAMS Accession No.
39 MLO92450636.

- 1 Nebraska Game and Parks Commission (NGPC). 2008. Estimated Current Ranges of
2 Threatened and Endangered Species: List of Species by County. Available URL:
3 <http://www.ngpc.state.ne.us/wildlife/programs/nongame/TandESpecies.pdf>
4 (accessed April 21, 2009).
- 5 National Research Council, Committee on Missouri River Ecosystem Science (NRCouncil).
6 2002. *The Missouri River Ecosystem: Exploring the Prospects for Recovery*. National Academy
7 Press, Washington, D.C. 188 Pages
- 8 Reetz, S.D. (Reetz). 1982. Chapter 4: Phytoplankton studies in the Missouri River at Fort
9 Calhoun Station and Cooper Nuclear Station. Hesse, L.W., G.L. Hergenrader, H.S. Lewis, S.D.
10 Reetz, and A.B. Schlesinger (eds.), *The Middle Missouri River: A Collection of Papers on the*
11 *Biology with Special Reference to Power Station Effects*. The Missouri River Group, Norfolk,
12 Nebraska. pp. 71-83.
- 13 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement*
14 *for License Renewal of Nuclear Plants*. NUREG-1437, Volumes 1 and 2, Washington, D.C. .
15 ADAMS Accession Nos. ML040690705 and ML040690738.
- 16 U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement*
17 *for License Renewal of Nuclear Plants, Main Report*, "Section 6.3 – Transportation, Table 9.1,
18 Summary of findings on NEPA issues for license renewal of nuclear power plants, Final Report."
19 NUREG-1437, Volume 1, Addendum 1, Washington, D.C. ADAMS Accession No.
20 ML0400690720.
- 21 U.S. Nuclear Regulatory Commission (NRC). 2008a. Letter from D. Pelton, U.S. Nuclear
22 Regulatory Commission, Washington, D.C., to M. Milwa, State Historic Preservation Officer,
23 Missouri Department of Natural Resources, St. Paul, Minnesota. Subject: Cooper Nuclear
24 Station License Renewal Application Review (Log Number 004-AT-08). ADAMS Accession No.
25 ML090210750.
- 26 U.S. Nuclear Regulatory Commission (NRC). 2008b. Letter from D. Pelton, U.S. Nuclear
27 Regulatory Commission, Washington, D.C., to M. Smith, State Historic Preservation
28 Officer, Nebraska State Historical Society, Washington, D.C. Subject: Cooper Nuclear Station
29 License Renewal Application Review (HP Num. 0801-050-01). ADAMS Accession No.
30 ML090080197.
- 31 U.S. Nuclear Regulatory Commission (NRC). 2008c. Letter from D. Pelton, U.S. Nuclear
32 Regulatory Commission, Washington, D.C., to D. Klilma, Director ,Advisory Council on Historic
33 Preservation, Washington, D.C. Subject: Cooper Nuclear Station License Renewal Application
34 Review. ADAMS Accession No. ML090080683.
- 35 Repsys, A.J. and G.D. Rogers. (Repsys) 1982. Chapter 6: Zooplankton studies in the
36 channelized Missouri River. Hesse, L.W., G.L. Hergenrader, H.S. Lewis, S.D. Reetz, and A.B.
37 Schlesinger (eds.), *The Middle Missouri River: A Collection of Papers on the Biology with*
38 *Special Reference to Power Station Effects*. The Missouri River Group, Norfolk, Nebraska. pp.
39 124-145.
- 40 Todar, K. 2007. *Todar's online textbook of bacteriology*. Available URL:
41 <http://www.textbookofbacteriology.net> (accessed June 2009).
- 42 U.S. Army Corps of Engineers (USACE). 2004. *Missouri River Master Water Control Manual,*
43 *Final Environmental impact Statement Review and Update*. Northwestern Division, Omaha,
44 Nebraska. March 2004.

Environmental Impacts of Operation

- 1 U.S. Army Corps of Engineers (USACE). 2004a. *Missouri River Master Water Control Manual*,
2 *Final Environmental Impact Statement Review and Update*. Northwestern Division, Omaha,
3 Nebraska. March 2004.
- 4 U.S. Army Corps of Engineers (USACE). 2004b. Missouri River Mitigation Project. July 2004.
5 Available URL:
6 http://www.nwk.usace.army.mil/projects/mitigation/sites/hamburg_area/lanben.htm (accessed
7 April 15, 2004).
- 8 United States Atomic Energy Commission (USAEC). 1973. *Final Environmental Statement*
9 *related to operation of Cooper Nuclear Station*. Nebraska Public Power District, Docket No. 50-
10 298. February 1973.
- 11 United States Fish and Wildlife Service (USFWS). 2007. Endangered Species, Nebraska,
12 Federally-Listed and Proposed, Endangered, Threatened, Experimental, and Candidate
13 Species Nebraska Counties. Ecological Services, Nebraska Field Office, November 2007.
14 Available URL: <http://www.fws.gov/mountain-prairie/endspp/countylists/nebraska.pdf> (accessed
15 April 17, 2009).
- 16 United States Fish and Wildlife Service (USFWS). 2008. Endangered Species, Missouri, County
17 Distribution of Federally-Listed, Threatened, Endangered, Proposed, and Candidate Species.
18 USFWS, Columbia, Missouri. November 2008. Available URL:
19 <http://www.fws.gov/midwest/endangered/lists/missouri-cty.html> (accessed April 17, 2009).
- 20 USFWS (United States Fish and Wildlife Service). 2009a. Personal e-mail from Robert Harms,
21 Fish and Wildlife Biologist, Grand Island Field Office, to R. Bulavinetz, Aquatic Ecologist,
22 Division of License Renewal, Nuclear Regulatory Commission. Subject: Cooper Nuclear Plant.
23 March 16, 2009. ADAMS No. ML092110590
- 24 United States Fish and Wildlife Service (USFWS). 2009a. Personal e-mail from Robert Harms,
25 Fish and Wildlife Biologist, Grand Island Field Office, to R. Bulavinetz, Aquatic Ecologist,
26 Division of License Renewal, Nuclear Regulatory Commission. Subject: Cooper Nuclear Plant.
27 March 16, 2009. ADAMS Accession No. ML092110590.
- 28 United States Fish and Wildlife Service (USFWS). 2009b. Letter from June M. DeWeese,
29 Nebraska Field Supervisor, U.S. Fish and Wildlife Service, Grand Island, to Joe L. Citta, Jr.,
30 Corporate Environmental Manager, NPPD. Subject: Cooper Nuclear Station. June 8, 2009.
31 ADAMS Accession No. ML091830055.
- 32 United States Fish and Wildlife Service (USFWS). 2009c. Rainwater Basin Wetland
33 Management District. Available URL: <http://www.fws.gov/Refuges/profiles/index.cfm?id=64530>
34 (accessed April 29, 2009).
- 35 U.S. Census Bureau (USCB). 2003. LandView 6 – Census 2000 Profile of General
36 Demographic Characteristics DP-1 (100%) and Census Profile of Selected Economic
37 Characteristics DP-3, Summary of Census Block Groups in a 50-mile radius around the CNS-1
38 (40.361944 Lat., -95.641389 Long). December 2003.
- 39 U.S. Geological Survey (USGS). 2001. Ecoregions of Nebraska and Kansas (color poster with
40 map, descriptive text, summary tables, and photographs). Available URL:
41 http://www.epa.gov/wed/pages/ecoregions/ksne_eco.htm (accessed April 29, 2009).
- 42 World Health Organization (WHO). 2007a. *Extremely Low Frequency Fields Environmental*
43 *Health Criteria Monograph No.238*, World Health Organization, Geneva, Switzerland.
44 http://www.who.int/pehemf/publications/elf_ehc/en/index.html (accessed August, 2008)

1 **5.0 ENVIRONMENTAL IMPACTS OF POSTULATED ACCIDENTS**

2 This chapter describes the environmental impacts from postulated accidents that might
3 occur during the period of extended operation. The term “accident” as defined in the Generic
4 Environmental Impact Statement (GEIS) (NRC, 1996) refers to any unintentional event
5 outside the normal plant operational envelope that results in a release or the potential for
6 release of radioactive materials into the environment. Two classes of postulated accidents
7 are evaluated under the National Environmental Policy Act (NEPA) in the license renewal
8 review: design-basis accidents (DBAs) and severe accidents. In the GEIS, the NRC staff
9 categorized accidents as “design basis” when the plant was designed specifically to
10 accommodate these accidents or as “severe” for those accidents involving multiple failures
11 of equipment or function whose likelihood is generally lower than design-basis accidents but
12 where consequences may be higher” (NRC, 1996). These issues are evaluated in Chapter 5
13 of GEIS, “Environmental Impacts of Postulated Accidents.”

14 **5.1 DESIGN-BASIS ACCIDENTS**

15 As described in 10 CFR 50.34(b), in order to receive NRC approval for an operating license,
16 an applicant for an initial operating license must submit a final safety analysis report (FSAR)
17 as part of its application. The FSAR presents the design criteria and design information for
18 the proposed reactor and comprehensive data on the proposed site. The FSAR also
19 discusses various hypothetical accident situations and the safety features that are provided
20 to prevent and mitigate accidents. The NRC staff reviews the application to determine
21 whether or not the plant design meets the NRC’s regulations and requirements and
22 includes, in part, the nuclear plant design and its anticipated response to an accident.

23 The environmental impacts of postulated accidents were evaluated for the license renewal
24 period in Chapter 5 of the GEIS. Section 5.5.1 states:

25 All plants have had a previous evaluation of the environmental impacts of
26 design-basis accidents. In addition, the licensee will be required to maintain
27 acceptable design and performance criteria throughout the renewal period.
28 Therefore, the calculated releases from design-basis accidents would not be
29 expected to change. Since the consequences of these events are evaluated
30 for the hypothetical maximally exposed individual at the time of licensing,
31 changes in the plant environment will not affect these evaluations. Therefore,
32 the staff concludes that the environmental impacts of design-basis accidents
33 are of small significance for all plants. Because the environmental impacts of
34 design basis accidents are of small significance and because additional
35 measures to reduce such impacts would be costly, the staff concludes that no
36 mitigation measures beyond those implemented during the current term
37 license would be warranted. This is a Category 1 issue.

38 No new and significant information related to DBAs was identified during the review of
39 Nebraska Public Power District’s (NPPD’s) environmental report (ER), site audit, scoping
40 process, or evaluation of other available information. Therefore, there are no impacts related
41 to these issues beyond those discussed in the GEIS.

1 **5.2 SEVERE ACCIDENTS**

2 Severe nuclear accidents are those that are more severe than DBAs because they could
3 result in substantial damage to the reactor core, whether or not there are serious offsite
4 consequences. In the GEIS, the staff assessed the impacts of severe accidents during the
5 license renewal period, using the results of existing analyses and information from various
6 sites to predict the environmental impacts of severe accidents for plants during the renewal
7 period.

8 Severe accidents initiated by external phenomena such as tornadoes, floods, earthquakes,
9 fires, and sabotage have not traditionally been discussed in quantitative terms in the final
10 environmental impact statements and were not specifically considered for the Cooper
11 Nuclear Station, Unit 1 (CNS-1) site in the GEIS (NRC, 1996). The GEIS, however, did
12 evaluate existing impact assessments performed by the NRC staff and by the industry at 44
13 nuclear plants in the United States and segregated all sites into six general categories and
14 then estimated that the risk consequences calculated in existing analyses bound the risks
15 for all other plants within each category. The GEIS further concluded that the risk from
16 beyond design-basis earthquakes at existing nuclear power plants is designated as SMALL.
17 The Commission believes that NEPA does not require the NRC to consider the
18 environmental consequences of hypothetical terrorist attacks on NRC-licensed
19 facilities. However, the NRC staff's GEIS for license renewal contains a discretionary
20 analysis of terrorist acts in connection with license renewal. The conclusion in the GEIS is
21 that the core damage and radiological release from such acts would be no worse than the
22 damage and release to be expected from internally initiated events.

23 In the GEIS, the NRC staff concludes that the risk from sabotage and beyond design-basis
24 earthquakes at existing nuclear power plants is designated as SMALL, and additionally, that
25 the risks from other external events are adequately addressed by a generic consideration of
26 internally initiated severe accidents (NRC, 1996).

27 Based on information in the GEIS, the staff found that:

28 The generic analysis...applies to all plants and that the probability-weighted
29 consequences of atmospheric releases, fallout onto open bodies of water,
30 releases to ground water, and societal and economic impacts of severe
31 accidents are of small significance for all plants. However, not all plants have
32 performed a site-specific analysis of measures that could mitigate severe
33 accidents. Consequently, severe accidents are a Category 2 issue for plants
34 that have not performed a site-specific consideration of severe accident
35 mitigation and submitted that analysis for Commission review.

36 The staff identified no new and significant information related to postulated accidents during
37 the review of NPPD's environmental report, the site audit, the scoping process, or evaluation
38 of other available information. Therefore, there are no impacts related to postulated
39 accidents beyond those discussed in the GEIS. In accordance with 10 CFR
40 51.53(c)(3)(ii)(L), however, the NRC staff has reviewed severe accident mitigation
41 alternatives (SAMAs) for CNS-1. Review results are discussed in Section 5.3.

1 **5.3 SEVERE ACCIDENT MITIGATION ALTERNATIVES**

2 Regulations under Section 51.53(c)(3)(ii)(L) of 10 CFR requires an ER to contain an analysis
3 of alternatives to mitigate severe accidents if the staff has not previously evaluated SAMAs
4 for the applicant's plant in an environmental impact statement (EIS), related supplement, or
5 in an environmental assessment. The Commission's reconsideration of the issue of severe
6 accident mitigation for license renewal is based on the Commission's NEPA regulations that
7 require a consideration of mitigation alternatives in its environmental impact statements
8 (EISs) and supplements to EISs, as well as a previous court decision that required a review
9 of sever mitigation alternatives at the operating license stage.

10 **5.3.1 Introduction**

11 This section presents a summary of the SAMA evaluation for CNS-1 conducted by NPPD
12 Energy Company, LLC (NPPD) and the staff's review of that evaluation. The NRC staff
13 performed its review with contract assistance from Pacific Northwest National Laboratory.
14 Subsequent to the ER, NPPD discovered a problem with the process they used to
15 numerically average the site-specific meteorological data. NPPD performed a sensitivity
16 analysis of the population dose risk and offsite economic cost risk using corrected
17 meteorological data, and found that the population dose and offsite economic cost values for
18 each of the release categories would be slightly less than reported in the ER, and that the
19 conclusions of the SAMA remain valid (NPPD, 2009b). The NRC staff's review is available in
20 Appendix F; the SAMA evaluation is available in NPPD's ER and the supplement submitted
21 in December 2009.

22 The SAMA evaluation for CNS-1 was conducted with a four-step approach. In the first step,
23 NPPD quantified the level of risk associated with potential reactor accidents using the plant
24 specific probabilistic risk assessment (PRA) and other risk models.

25 In the second step, NPPD examined the major risk contributors and identified possible ways
26 (SAMAs) of reducing that risk. Common ways of reducing risk are changes to components,
27 systems, procedures, and training. NPPD identified 33 potential SAMAs for CNS-1. NPPD
28 performed an initial screening to determine if any SAMAs could be eliminated because they
29 are not applicable to CNS-1 due to design differences, or have estimated implementation
30 costs that would exceed the dollar-value associated with completely eliminating all severe
31 accident risk at CNS-1. No SAMAs were eliminated based on this screening, leaving all 33
32 for further evaluation.

33 In the third step, NPPD estimated the benefits and the costs associated with each of the
34 SAMAs. Estimates were made of how much each SAMA could reduce risk. Those estimates
35 were developed in terms of dollars in accordance with NRC guidance for performing
36 regulatory analyses (NRC, 1997). The cost of implementing the proposed SAMAs was also
37 estimated.

38 Finally, in the fourth step, the costs and benefits of each of the remaining SAMAs were
39 compared to determine whether the SAMA was cost beneficial, meaning the benefits of the
40 SAMA were greater than the cost (a positive cost benefit). NPPD concluded in its ER that
41 several of the SAMAs evaluated are potentially cost-beneficial (NPPD, 2008).

42 The potentially cost-beneficial SAMAs do not relate to adequately managing the effects of
43 aging during the period of extended operation (e.g., none of the potentially cost-beneficial

Environmental Impacts of Postulated Accidents

1 SAMAs would reduce the frequency or risk associated with aging-related failures).
2 Therefore, they need not be implemented as part of license renewal pursuant to 10 CFR
3 Part 54. NPPD's SAMA analysis and the NRC staff's review are discussed in more detail
4 below.

5 5.3.2 Estimate of Risk

6 NPPD submitted an assessment of SAMAs for CNS-1 as part of the ER. This assessment
7 was based on the most recent CNS-1 probabilistic safety assessment (PSA) available at
8 that time, a plant-specific offsite consequence analysis performed using the MELCOR
9 Accident Consequence Code System 2 (MACCS2) computer program, and insights from the
10 CNS-1 Individual Plant Examination (IPE) (NPPD, 1993) and Individual Plant Examination of
11 External Events (IPEEE) (NPPD, 1996). As mentioned above, NPPD discovered an error in
12 the method used to average their wind data. NPPD performed a sensitivity analysis using
13 the corrected meteorological data. Their analysis found that the error was conservative
14 relative to the average population dose and economic cost, and that no SAMAs were
15 inappropriately excluded from consideration in the LRA as a result of the error in wind
16 direction. NPPD submitted their analysis and changes to the LRA in a letter dated
17 December 7, 2009 (NPPD, 2009b).

18 The CNS-1 core damage frequency (CDF) is approximately 9.3×10^{-6} per year for internal
19 events as determined from the quantification of the Level 1 PSA model. When determined
20 from the sum of the containment event tree sequences, or Level 2 PSA model, the release
21 frequency is approximately 1.2×10^{-5} per year. The latter value was used as the baseline
22 CDF in the SAMA evaluations. The CDF value is based on the risk assessment for
23 internally-initiated events. NPPD did not include the contributions from external events within
24 the CNS-1 risk estimates; however, it did account for the potential risk reduction benefits
25 associated with external events by increasing the estimated benefits for internal events by a
26 factor of 3. The breakdown of CDF by initiating event is provided in 1.

27 **Table 5-1. Cooper Nuclear Station, Unit 1, Core Damage Frequency for Internal Events**

Initiating Event	CDF (per year)	% Contribution to CDF
Transients	3.0×10^{-6}	32
Loss of DC Power	2.1×10^{-6}	22
Loss of Coolant Accidents (LOCA)	1.4×10^{-6}	15
Loss of Feedwater	1.0×10^{-6}	11
Loss of Offsite Power	6.5×10^{-7}	7
Loss of Service Water	6.0×10^{-7}	7
Loss of AC Buses	2.6×10^{-7}	3
Internal Flood	2.6×10^{-7}	3
Interfacing System LOCA	5.1×10^{-8}	<1
Total CDF (Internal Events)	9.3×10^{-6}	100

28 As shown in this table, events initiated by transients, loss of DC power, LOCA, and loss of
29 feedwater are the dominant contributors to the CDF.

30 NPPD estimated the dose to the population within 50 miles (80 km) of the CNS-1 site to be
31 approximately 0.021 person-sievert (person-Sv) (2.1 person-rem) per year. The breakdown
32 of the total population dose by containment release mode is summarized in Table 5-2.

1 Containment failures within the early time frame (less than 3.7 hours following event
 2 initiation) dominate the population dose risk at CNS-1, with failures in the intermediate time
 3 frame (3.7 to 24 hours following event initiation) contributing most of the remaining
 4 population dose.

5 **Table 5-2. Breakdown of Population Dose by Containment Release Mode**

Containment Release Mode	Population Dose (Person-Rem ¹ Per Year)	% Contribution
Early Containment Failure	1.67	78
Intermediate Containment Failure	0.47	22
Late Containment Failure	<0.1	<1
Intact Containment	Negligible	negligible
Total	2.14	100

¹One person-rem = 0.01 person-Sv

6 The NRC staff has reviewed NPPD's data and evaluation methods and concludes that the
 7 quality of the risk analyses is adequate to support an assessment of the risk reduction
 8 potential for candidate SAMAs. Accordingly, the staff based its assessment of offsite risk on
 9 the CDFs and offsite doses reported by NPPD in their December 2009 letter (NPPD,
 10 2009b).

11 **5.3.3 Potential Plant Improvements**

12 Once the dominant contributors to plant risk were identified, NPPD searched for ways to
 13 reduce that risk. In identifying and evaluating potential SAMAs, NPPD considered insights
 14 from the plant-specific PSA, and SAMA analyses performed for other operating plants that
 15 have submitted license renewal applications. NPPD identified 244 potential risk-reducing
 16 improvements (SAMAs) to plant components, systems, procedures and training.

17 NPPD removed all but 80 of the SAMAs from further consideration because they are not
 18 applicable at CNS-1 due to design differences, have already been implemented at CNS-1,
 19 or are similar in nature and could be combined with another SAMA candidate. A detailed
 20 cost-benefit analysis was performed for each of the remaining SAMAs.

21 The staff concludes that NPPD used a systematic and comprehensive process for
 22 identifying potential plant improvements for CNS-1, and that the set of potential plant
 23 improvements identified by NPPD is reasonably comprehensive and, therefore, acceptable.

24 **5.3.4 Evaluation of Risk Reduction and Costs of Improvements**

25 NPPD evaluated the risk-reduction potential of the remaining 80 SAMAs. The majority of the
 26 SAMA evaluations were performed in a bounding fashion in that the SAMA was assumed to
 27 completely eliminate the risk associated with the proposed enhancement.

28 NPPD estimated the costs of implementing the candidate SAMAs through the application of
 29 engineering judgment and use of other licensee's estimates for similar improvements. The
 30 cost estimates conservatively did not include the cost of replacement power during extended
 31 outages required to implement the modifications, nor did they include maintenance and
 32 surveillance costs of the installed equipment.

Environmental Impacts of Postulated Accidents

1 The staff reviewed NPPD's bases for calculating the risk reduction for the various plant
2 improvements and concludes that the rationale and assumptions for estimating risk
3 reduction are reasonable and generally conservative (i.e., the estimated risk reduction is
4 higher than what would actually be realized). Accordingly, the staff based its estimates of
5 averted risk for the various SAMAs on NPPD's risk reduction estimates.

6 The staff reviewed the bases for the applicant's cost estimates. For certain improvements,
7 the staff also compared the cost estimates to estimates developed elsewhere for similar
8 improvements, including estimates developed as part of other licensee's analyses of SAMAs
9 for operating reactors and advanced light-water reactors. The staff found the cost estimates
10 to be reasonable, and generally consistent with estimates provided in support of other
11 plants' analyses.

12 The staff concludes that the risk reduction and the cost estimates provided by NPPD are
13 sufficient and appropriate for use in the SAMA evaluation.

14 **5.3.5 Cost-Benefit Comparison**

15 The cost-benefit analysis performed by NPPD was based primarily on NUREG/BR-0184
16 (NRC, 1997) and was executed consistent with this guidance. NUREG/BR-0058 has
17 recently been revised to reflect the agency's revised policy on discount rates. Revision 4 of
18 NUREG/BR-0058 states that two sets of estimates should be developed – one at 3 percent
19 and the other at 7 percent (NRC, 2004). NPPD provided both sets of estimates
20 (NPPD, 2008).

21 NPPD identified eight potentially cost-beneficial SAMAs in the baseline analysis contained in
22 the ER. The potentially cost-beneficial SAMAs are:

- 23 • SAMA 25 – Develop procedures to allow bypass of the reactor core
24 isolation cooling (RCIC) turbine exhaust pressure trip, extending the
25 time available for RCIC operation.
- 26 • SAMA 30 – Revise procedures to allow manual alignment of the fire
27 water system to the residual heat removal (RHR) heat exchangers,
28 providing improved ability to cool the RHR heat exchangers in a loss of
29 service water (SW).
- 30 • SAMA 33 – Provide for the ability to establish an emergency connection
31 of existing or new water sources to feedwater and condensate systems,
32 increasing availability of feedwater.
- 33 • SAMA 40 – Revise procedures to provide additional space cooling to
34 the emergency diesel generator (EDG) room via the use of portable
35 equipment, increasing availability of the EDG.
- 36 • SAMA 45 – Provide an alternate means of supplying the instrument air
37 header, increasing availability of instrument air.

- 1 • SAMA 68 – Revise procedures to allow the ability to cross-connect the
2 circulating water pumps and the service water going to the turbine
3 equipment cooling (TEC) heat exchangers, which allow continued use
4 of the power conversion system after service water is lost.

- 5 • SAMA 78 – Improve training on alternate injection via the fire water
6 system, increasing the availability of alternate injection.

- 7 • SAMA 79 – Revise procedures to allow use of the residual heat removal
8 service water (RHRSW) system without a service water booster pump,
9 increasing availability of the RHRSW system.

10 NPPD performed additional analyses to evaluate the impact of parameter choices and
11 uncertainties on the results of the SAMA assessment (NPPD, 2008). If the benefits are
12 increased by an additional factor of 3 to account for uncertainties, three additional SAMA
13 candidates were determined to be potentially cost-beneficial:

- 14 • SAMA 14 – Provide a portable generator to supply DC power to
15 individual panels during a station blackout (SBO), increasing the time
16 available for AC power recovery.

- 17 • SAMA 64 – Revise procedures to allow use of a fire pumper truck to
18 pressurize the fire water system, increasing availability of the fire water
19 system.

- 20 • SAMA 75 – Implement Generation Risk Assessment (trip and shutdown
21 risk modeling) into plant activities, decreasing the probability of
22 trips/shutdown.

23 NPPD indicated that detailed engineering project cost-benefit analyses have been initiated
24 for the 11 potentially cost-beneficial SAMAs (NPPD 2008, 2009).

25 NRC staff reviewed NPPD's re-analysis as submitted by NPPD and agrees that the error
26 was conservative relative to the average population dose and offsite economic cost and that
27 no SAMAs were inappropriately excluded from consideration in the LRA as a result of the
28 error.

29 Based on the staff's review and the supplemental information provided by NPPD, the NRC
30 staff concludes that, with the exception of the potentially cost-beneficial SAMAs discussed
31 above, the costs of the SAMAs evaluated would be higher than the associated benefits.

32 **5.3.6 Conclusions**

33 The staff reviewed NPPD's analysis and concluded that the methods used and the
34 implementation of those methods were sound. The treatment of SAMA benefits and costs
35 support the general conclusion that the SAMA evaluations performed by NPPD are
36 reasonable and sufficient for the license renewal submittal.

37 Based on its review of the SAMA analysis, the staff concurs with NPPD's identification of
38 areas in which risk can be further reduced in a cost-beneficial manner through the
39 implementation of all, or a subset of potentially cost-beneficial SAMAs. Given the potential

1 for cost-beneficial risk reduction, the staff considers that further consideration of these
2 SAMAs by NPPD is warranted. However, none of the potentially cost-beneficial SAMAs
3 relate to adequately managing the effects of aging during the period of extended operation
4 e.g., none of the potentially cost-beneficial SAMAs would reduce the frequency or risk
5 associated with aging-related failures). Therefore, they need not be implemented as part of
6 the license renewal pursuant to 10 CFR Part 54.

7 **5.4 REFERENCES**

- 8 10 CFR Part 50. *Code of Federal Regulations*, Title 10, *Energy*, Part 50, “Domestic
9 Licensing of Production and Utilization Facilities.”
- 10 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, “Environmental
11 Protection Regulations for Domestic Licensing and Related Regulatory Functions.”
- 12 10 CFR Part 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, “Requirements for
13 Renewal of Operating Licenses for Nuclear Power Plants.”
- 14 10 CFR Part 100. *Code of Federal Regulations*, Title 10, *Energy*, Part 100, “Reactor Site
15 Criteria.”
- 16 Nebraska Public Power District (NPPD). 1993. “Generic Letter 88-20, Individual Plant
17 Examination for Severe Accident Vulnerabilities – 10 CFR 50.54(f), IPE Report Submittal,
18 Cooper Nuclear Station, Docket No. 50-298, DPR-46,” March 1993. ADAMS Accession Nos.
19 ML073600192 (Volume 1) and ML073600193 (Volume 2).
- 20 Nebraska Public Power District (NPPD). 1996. “Individual Plant Examination for External
21 Events Report – 10 CFR 50.54(f), Cooper Nuclear Station, NRC Docket No. 50-298, License
22 No. DPR-46,” October 1996. ADAMS Accession No. ML073580487.
- 23 Nebraska Public Power District (NPPD).2008. *Cooper Nuclear Station --- License Renewal*
24 *Application, Appendix E: Applicant’s Environmental Report, Operating License Renewal*
25 *Stage*. Columbus, Nebraska, September 24, 2008 ADAMS Accession Nos.ML083030246
26 (main report) and ML083030252 (attachments).
- 27 Nebraska Public Power District (NPPD).2009. Letter from Stewart B. Minahan, NPPD to
28 NRC Document Control Desk. Subject: Response to Request for Additional Information for
29 License Renewal Application – Severe Accident Mitigation Alternatives, Cooper Nuclear
30 Station, Docket No. 50-298, DPR-46. July 1, 2009. ADAMS Accession No. ML0918803193.
- 31 Nebraska Public Power District (NPPD). 2009b. Letter from Stewart B. Minahan, NPPD to
32 NRC Document Control Desk. Subject: SAMA Meteorological Anomaly Related to the
33 Cooper Nuclear Station License Renewal Application, Cooper Nuclear Station, Docket No.
34 50-298, DPR-46. December 7, 2009. ADAMS Accession No. ML093490997
- 35 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact*
36 *Statement for License Renewal of Nuclear Plants*. NUREG-1437, Vols. 1 and 2,
37 Washington, D.C. ADAMS Accession Nos. ML040690705 and ML040690738
- 38 U.S. Nuclear Regulatory Commission (NRC). 1997. *Regulatory Analysis Technical*
39 *Evaluation Handbook*. NUREG/BR-0184, Washington, D.C.
- 40 U.S. Nuclear Regulatory Commission (NRC). 2004. *Regulatory Analysis Guidelines of the*
41 *U.S. Nuclear Regulatory Commission*. NUREG/BR-0058, Rev. 4, Washington, D.C.

1 **6.0 ENVIRONMENTAL IMPACTS OF THE URANIUM FUEL CYCLE,**
2 **AND SOLID WASTE MANAGEMENT, AND GREENHOUSE GASEOUS**
3 **EMISSIONS**

4 **6.1 THE URANIUM FUEL CYCLE**

5 This section addresses issues related to the uranium fuel cycle and solid waste management
6 during the period of extended operation. The uranium cycle includes uranium mining and
7 milling, the production of uranium hexafluoride, isotopic enrichment, fuel fabrication,
8 reprocessing of irradiated fuel, transportation of radioactive materials, and management of low-
9 level wastes and high-level wastes related to uranium fuel cycle activities. The Generic
10 Environmental Impact Statement (GEIS) (NRC 1996, 1999) details the potential generic impacts
11 of the radiological and nonradiological environmental impacts of the uranium fuel cycle including
12 transportation of nuclear fuel and wastes. The GEIS is based, in part, on the generic impacts
13 provided in Table S-3, "Table of Uranium Fuel Cycle Environmental Data," in Title 10 of the
14 *Code of Federal Regulations* (CFR), Section 51.51(a), and in Table S-4, "Environmental Impact
15 of Transportation of Fuel and Waste to and from One Light-Water-Cooled Nuclear Power
16 Reactor," in 10 CFR 51.52(b). The GEIS also addresses the impacts from radon-222 and
17 technetium-99.

18 For these Category 1 issues, the GEIS concludes that the impacts are designated as SMALL,
19 except for the collective offsite radiological impacts from the fuel cycle and from high-level waste
20 and spent fuel disposal, where no significance level was assigned to these two impacts. For the
21 collective offsite radiological impacts, the Commission concludes that these impacts are
22 acceptable in that these impacts would not be sufficiently large to require the NEPA conclusion,
23 for any plant, that the option of extended operation under 10 CFR Part 54 should be eliminated.
24 The staff of the U.S. Nuclear Regulatory Commission (NRC) did not identify any new and
25 significant information related to the uranium fuel cycle during the review of Nebraska Public
26 Power District's (NPPD) environmental report (ER) (NPPD, 2008), the site audit, and the
27 scoping process. Therefore, there are no impacts related to these issues beyond those
28 discussed in the GEIS.

29 Nine generic issues are related to the fuel cycle and solid waste management. These are shown
30 in Table 6-1. There are no site-specific issues.

1 **Table 6-1. Issues Related to the Uranium Fuel Cycle and Solid Waste Management**

Issues	GEIS Section	Category
Offsite radiological impacts (individual effects from other than the disposal of spent fuel and high-level waste)	6.1, 6.2.1, 6.2.2.1, 6.2.2.3, 6.2.3, 6.2.4, 6.6	1
Offsite radiological impacts (collective effects)	6.1, 6.2.2.1, 6.2.3, 6.2.4, 6.6	1
Offsite radiological impacts (spent fuel and high-level waste disposal)	6.1, 6.2.2.1, 6.2.3, 6.2.4, 6.6	1
Nonradiological impacts of the uranium fuel cycle	6.1, 6.2.2.6, 6.2.2.7, 6.2.2.8, 6.2.2.9, 6.2.3, 6.2.4, 6.6	1
Low-level waste storage and disposal	6.1, 6.2.2.2, 6.4.2, 6.4.3, 6.4.3.1, 6.4.3.2, 6.4.3.3, 6.4.4, 6.4.4.1, 6.4.4.2, 6.4.4.3, 6.4.4.4, 6.4.4.5, 6.4.4.5.1, 6.4.4.5.2, 6.4.4.5.3, 6.4.4.5.4, 6.4.4.6, 6.6	1
Mixed waste storage and disposal	6.4.5.1, 6.4.5.2, 6.4.5.3, 6.4.5.4, 6.4.5.5, 6.4.5.6, 6.4.5.6.1, 6.4.5.6.2, 6.4.5.6.3, 6.4.5.6.4, 6.6	1
Onsite spent fuel	6.1, 6.4.6, 6.4.6.1, 6.4.6.2, 6.4.6.3, 6.4.6.4, 6.4.6.5, 6.4.6.6, 6.4.6.7, 6.6	1
Nonradiological waste	6.1, 6.5, 6.5.1, 6.5.2, 6.5.3, 6.6	1
Transportation	6.1, 6.3.1, 6.3.2.3, 6.3.3, 6.3.4, 6.6, Addendum 1	1

2 **6.2 GREENHOUSE GAS EMISSIONS**

3 This section provides a discussion of potential impacts from greenhouse gases (GHGs) emitted
 4 from the nuclear fuel cycle. The GEIS does not directly address these emissions, and its
 5 discussion is limited to an inference that substantial carbon dioxide (CO₂) emissions may occur
 6 if coal- or oil-fired alternatives to license renewal are implemented.

7 **6.2.1 Existing Studies**

8 Since the development of the GEIS, the relative volumes of GHGs emitted by nuclear and other
 9 electricity generating methods have been widely studied. However, estimates and projections of

1 the carbon footprint of the nuclear power lifecycle vary depending on the type of study
2 conducted. Additionally, considerable debate also exists among researchers regarding the
3 relative impacts of nuclear and other forms of electricity generation on GHG emissions. Existing
4 studies on GHG emissions from nuclear power plants generally take two different forms:

- 5 (1) Qualitative discussions of the potential to use nuclear power to reduce GHG emissions
6 and mitigate global warming; and
- 7 (2) Technical analyses and quantitative estimates of the actual amount of GHGs generated
8 by the nuclear fuel cycle or entire nuclear power plant life cycle and comparisons to the
9 operational or life cycle emissions from other energy generation alternatives.

10 6.2.1.1 *Qualitative Studies*

11 The qualitative studies consist primarily of broad, large-scale public policy or investment
12 evaluations of whether an expansion of nuclear power is likely to be a technically, economically,
13 and/or politically feasible means of achieving global GHG reductions. Studies identified by the
14 NRC staff during the subsequent literature search include:

- 15 • Evaluations to determine whether investments in nuclear power in
16 developing countries should be accepted as a flexibility mechanism to
17 assist industrialized nations in achieving their GHG reduction goals under
18 the Kyoto Protocols (Schneider, 2000; IAEA, 2000; NEA, 2002;
19 NIRS/WISE, 2005). Ultimately, the parties to the Kyoto Protocol did not
20 approve nuclear power as a component under the Clean Development
21 Mechanism (CDM) due to safety and waste disposal concerns (NEA, 2002).
- 22 • Analyses developed to assist governments, including the United States, in
23 making long-term investment and public policy decisions in nuclear power
24 (Keepin, 1988; Hagen et al., 2001; MIT, 2003).

25 Although the qualitative studies sometimes reference and critique the existing quantitative
26 estimates of GHGs produced by the nuclear fuel cycle or life cycle, their conclusions generally
27 rely heavily on discussions of other aspects of nuclear policy decisions and investment such as
28 safety, cost, waste generation, and political acceptability. Therefore, these studies are typically
29 not directly applicable to an evaluation of GHG emissions associated with the proposed license
30 renewal for a given nuclear power plant.

31 6.2.1.2 *Quantitative*

32 A large number of technical studies, including calculations and estimates of the amount of
33 GHGs emitted by nuclear and other power generation options, are available in the literature and
34 were useful to the NRC staff's efforts in addressing relative GHG emission levels. Examples of
35 these studies include – but are not limited to – Mortimer (1990), Andseta et al. (1998), Spadaro
36 (2000), Storm van Leeuwen and Smith (2005), Fritsche (2006), Parliamentary Office of Science
37 and Technology (POST) (2006), Atomic Energy Authority (AEA) (2006), Weisser (2006),
38 Fthenakis and Kim (2007), and Dones (2007).

Environmental Impacts of the Uranium Fuel Cycle

1 Comparing these studies and others like them is difficult because the assumptions and
2 components of the lifecycles the authors evaluate vary widely. Examples of areas in which
3 differing assumptions make comparing the studies difficult include:

- 4 • Energy sources that may be used to mine uranium deposits in the future;
- 5 • Reprocessing or disposal of spent nuclear fuel;
- 6 • Current and potential future processes to enrich uranium and the energy
7 sources that will power them;
- 8 • Estimated grades and quantities of recoverable uranium resources;
- 9 • Estimated grades and quantities of recoverable fossil fuel resources;
- 10 • Estimated GHG emissions other than CO₂, including the conversion to CO₂
11 equivalents per unit of electric energy produced;
- 12 • Performance of future fossil fuel power systems;
- 13 • Projected capacity factors for alternatives means of generation; and
- 14 • Current and potential future reactor technologies.

15 In addition, studies may vary with respect to whether all or parts of a power plant's lifecycle are
16 analyzed, i.e., a full lifecycle analysis will typically address plant construction, operations,
17 resource extraction (for fuel and construction materials), and decommissioning, whereas, a
18 partial lifecycle analysis primarily focus on operational differences.

19 In the case of license renewal a GHG analysis for that portion of the plant's lifecycle (operation
20 for an additional 20 years) would not involve GHG emissions associated with construction
21 because construction activities have already been completed at the time of relicensing. In
22 addition, the proposed action of license renewal would also not involve additional GHG
23 emissions associated with facility decommissioning, because that decommissioning must occur
24 whether the facility is relicensed or not. However, in some of the aforementioned studies, the
25 specific contribution of GHG emissions from construction, decommissioning, or other portions of
26 a plant's lifecycle cannot be clearly separated from one another. In such cases, an analysis of
27 GHG emissions would overestimate the GHG emissions attributed to a specific portion of a
28 plant's lifecycle. Nonetheless, these studies provide some meaningful information with respect
29 to the relative magnitude of the emissions among nuclear power plants and other forms of
30 electric generation, as discussed in the following sections.

31 In Tables 6-2, 6-3, and 6-4 the NRC staff presents the results of the aforementioned quantitative
32 studies to provide a weight-of-evidence evaluation of the relative GHG emissions that may
33 result from the proposed license renewal as compared to the potential alternative use of coal-
34 fired, natural gas-fired, and renewable generation. Most studies from Mortimer (1990) onward
35 suggest that uranium ore grades and uranium enrichment processes are leading determinants
36 in the ultimate GHG emissions attributable to nuclear power generation. These studies indicate
37 that the relatively lower order of magnitude of GHG emissions from nuclear power when
38 compared to fossil-fueled alternatives (especially natural gas) could potentially disappear if

1 available uranium ore grades drop sufficiently while enrichment processes continued to rely on
 2 the same technologies.

3 **6.2.1.3 Summary of Nuclear Greenhouse Gas Emissions Compared to Coal**

4 Considering that coal fuels the largest share of electricity generation in the United States and
 5 that its burning results in the largest emissions of GHGs for any of the likely alternatives to
 6 nuclear power generation, including Cooper Nuclear Station, Unit 1 (CNS-1), most of the
 7 available quantitative studies focused on comparisons of the relative GHG emissions of nuclear
 8 to coal-fired generation. The quantitative estimates of the GHG emissions associated with the
 9 nuclear fuel cycle (and, in some cases, the nuclear lifecycle), as compared to an equivalent
 10 coal-fired plant, are presented in Table 6-2. The following chart does not include all existing
 11 studies, but provides an illustrative range of estimates developed by various sources.

12 **Table 6-2. Nuclear Greenhouse Gas Emissions Compared to Coal**

Source	GHG Emission Results
Mortimer (1990)	Nuclear—230,000 tons CO ₂ Coal—5,912,000 tons CO ₂ Note: Future GHG emissions from nuclear to increase because of declining ore grade.
Andseta et al. (1998)	Nuclear energy produces 1.4 percent of the GHG emissions compared to coal. Note: Future reprocessing and use of nuclear-generated electrical power in the mining and enrichment steps are likely to change the projections of earlier authors, such as Mortimer (1990).
Spadaro (2000)	Nuclear—2.5 to 5.7 g C _{eq} /kWh Coal—264 to 357 g C _{eq} /kWh
Storm van Leeuwen and Smith (2005)	Authors did not evaluate nuclear versus coal.
Fritsche (2006) (Values estimated from graph in Figure 4)	Nuclear—33 g C _{eq} /kWh Coal—950 g C _{eq} /kWh
POST (2006) (Nuclear calculations from AEA, 2006)	Nuclear—5 g C _{eq} /kWh Coal—>1000 g C _{eq} /kWh Note: Decrease of uranium ore grade to 0.03 percent would raise nuclear to 6.8 g C _{eq} /kWh. Future improved technology and carbon capture and storage could reduce coal-fired GHG emissions by 90 percent.
Weisser (2006) (Compilation of results from other studies)	Nuclear—2.8 to 24 g C _{eq} /kWh Coal—950 to 1250 g C _{eq} /kWh
Fthenakis and Kim (2007)	Authors did not evaluate nuclear versus coal.
Dones (2007)	Author did not evaluate nuclear versus coal.

13 **6.2.1.4 Summary of Nuclear Greenhouse Gas Emissions Compared to Natural Gas**

14 The quantitative estimates of the GHG emissions associated with the nuclear fuel cycle (and, in
 15 some cases, the nuclear lifecycle), as compared to an equivalent natural gas-fired plant, are
 16 presented in Table 6-3. The following chart does not include all existing studies, but provides an
 17 illustrative range of estimates developed by various sources.

1 **Table 6-3. Nuclear Greenhouse Gas Emissions Compared to Natural Gas**

Source	GHG Emission Results
Mortimer (1990)	Author did not evaluate nuclear versus natural gas.
Andseta (1998)	Author did not evaluate nuclear versus natural gas.
Spadaro (2000)	Nuclear—2.5 to 5.7 g C _{eq} /kWh Natural Gas—120 to 188 g C _{eq} /kWh
Storm van Leeuwen and Smith (2005)	Nuclear fuel cycle produces 20 to 33 percent of the GHG emissions compared to natural gas (at high ore grades). Note: Future nuclear GHG emissions to increase because of declining ore grade.
Fritsche (2006) (Values estimated from graph in Figure 4)	Nuclear—33 g C _{eq} /kWh Cogeneration Combined Cycle Natural Gas—150 g C _{eq} /kWh
POST (2006) (Nuclear calculations from AEA, 2006)	Nuclear—5 g C _{eq} /kWh Natural Gas—500 g C _{eq} /kWh Note: Decrease of uranium ore grade to 0.03 percent would raise nuclear to 6.8 g C _{eq} /kWh. Future improved technology and carbon capture and storage could reduce natural gas GHG emissions by 90 percent.
Weisser (2006) (Compilation of results from other studies)	Nuclear—2.8 to 24 g C _{eq} /kWh Natural Gas—440 to 780 g C _{eq} /kWh
Fthenakis and Kim (2007)	Authors did not evaluate nuclear versus natural gas.
Dones (2007)	Author critiqued methods and assumptions of Storm van Leeuwen and Smith (2005), and concluded that the nuclear fuel cycle produces 15 to 27 percent of the GHG emissions of natural gas.

2 6.2.1.5 *Summary of Nuclear Greenhouse Gas Emissions Compared to Renewable Energy*
3 *Sources*

4 The quantitative estimates of the GHG emissions associated with the nuclear fuel cycle, as
5 compared to equivalent renewable energy sources, are presented in Table 6-4. Calculation of
6 GHG emissions associated with these sources is more difficult than the calculations for nuclear
7 energy and fossil fuels because of the large variation in efficiencies due to their different
8 sources and locations. For example, the efficiency of solar and wind energy is highly dependent
9 on the location in which the power generation facility is installed. Similarly, the range of GHG
10 emissions estimates for hydropower varies greatly depending on the type of dam or reservoir
11 involved (if used at all). Therefore, the GHG emissions estimates for these energy sources have
12 a greater range of variability than the estimates for nuclear and fossil fuel sources. As noted in
13 Section 6.2.1.2, the following chart does not include all existing studies, but provides an
14 illustrative range of estimates developed by various sources.

1 **Table 6-4. Nuclear Greenhouse Gas Emissions Compared to Renewable Energy Sources**

Source	GHG Emission Results
Mortimer (1990)	Nuclear—230,000 tons CO ₂ Hydropower—78,000 tons CO ₂ Wind power—54,000 tons CO ₂ Tidal power—52,500 tons CO ₂ Note: Future GHG emissions from nuclear to increase because of declining ore grade.
Andseta (1998)	Author did not evaluate nuclear versus renewable energy sources.
Spadaro (2000)	Nuclear—2.5 to 5.7 g C _{eq} /kWh Solar PV—27.3 to 76.4 g C _{eq} /kWh Hydroelectric—1.1 to 64.6 g C _{eq} /kWh Biomass—8.4 to 16.6 g C _{eq} /kWh Wind—2.5 to 13.1 g C _{eq} /kWh
Storm van Leeuwen and Smith (2005)	Author did not evaluate nuclear versus renewable energy sources.
Fritsche (2006) (Values estimated from graph in Figure 4)	Nuclear—33 g C _{eq} /kWh Solar PV—125 g C _{eq} /kWh Hydroelectric—50 g C _{eq} /kWh Wind—20 g C _{eq} /kWh
POST (2006) (Nuclear calculations from AEA, 2006)	Nuclear—5 g C _{eq} /kWh Biomass—25 to 93 g C _{eq} /kWh Solar PV—35 to 58 g C _{eq} /kWh Wave/Tidal—25 to 50 g C _{eq} /kWh Hydroelectric—5 to 30 g C _{eq} /kWh Wind—4.64 to 5.25 g C _{eq} /kWh Note: Decrease of uranium ore grade to 0.03 percent would raise nuclear to 6.8 g C _{eq} /kWh.
Weisser (2006) (Compilation of results from other studies)	Nuclear—2.8 to 24 g C _{eq} /kWh Solar PV—43 to 73 g C _{eq} /kWh Hydroelectric—1 to 34 g C _{eq} /kWh Biomass—35 to 99 g C _{eq} /kWh Wind—8 to 30 g C _{eq} /kWh
Fthenakis and Kim (2007)	Nuclear—16 to 55 g C _{eq} /kWh Solar PV—17 to 49 g C _{eq} /kWh
Dones (2007)	Author did not evaluate nuclear versus renewable energy sources.

2 **6.2.2 Conclusions: Relative GHG Emissions**

3 The sampling of data presented in Tables 6-2, 6-3, and 6-4 above demonstrates the challenges
4 of any attempt to determine the specific amount of GHG emission attributable to nuclear energy
5 production sources, as different assumptions and calculation methodology will yield differing
6 results. The differences and complexities in these assumptions and analyses will further
7 increase when they are used to project future GHG emissions. Nevertheless, several
8 conclusions can be drawn from the information presented.

Environmental Impacts of the Uranium Fuel Cycle

1 First, the various studies indicate a general consensus that nuclear power currently produces
2 fewer GHG emissions than fossil-fuel-based electrical generation, e.g., the GHG emissions from
3 a complete nuclear fuel cycle currently range from 2.5 to 55 g C_{eq}/kWh, as compared to the use
4 of coal plants (264 to 1250 g C_{eq}/kWh) and natural gas plants (120 to 780 g C_{eq}/kWh). The
5 studies also provide estimates of GHG emissions from five renewable energy sources based on
6 current technology. These estimates included solar-photovoltaic (17 to 125 g C_{eq}/kWh),
7 hydroelectric (1 to 64.6 g C_{eq}/kWh), biomass (8.4 to 99 g C_{eq}/kWh), wind (2.5 to 30 g C_{eq}/kWh),
8 and tidal (25 to 50 g C_{eq}/kWh). The range of these estimates is wide, but the general conclusion
9 is that current GHG emissions from the nuclear fuel cycle are of the same order of magnitude as
10 from these renewable energy sources.

11 Second, the studies indicate no consensus on future relative GHG emissions from nuclear
12 power and other sources of electricity. There is substantial disagreement among the various
13 authors regarding the GHG emissions associated with declining uranium ore concentrations,
14 future uranium enrichment methods, and other factors, including changes in technology. Similar
15 disagreement exists regarding future GHG emissions associated with coal and natural gas for
16 electricity generation. Even the most conservative studies conclude that the nuclear fuel cycle
17 currently produces fewer GHG emissions than fossil-fuel-based sources, and is expected to
18 continue to do so in the near future. The primary difference between the authors is the projected
19 cross-over date (the time at which GHG emissions from the nuclear fuel cycle exceed those of
20 fossil-fuel-based sources) or whether cross-over will actually occur.

21 Considering the current estimates and future uncertainties, it appears that GHG emissions
22 associated with the proposed CNS-1 relicensing action are likely to be lower than those
23 associated with fossil-fuel-based energy sources. The NRC staff bases this conclusion on the
24 following rationale:

- 25 (1) As shown in Tables 6-2 and 6-3, the current estimates of GHG emissions from the
26 nuclear fuel cycle are far below those for fossil-fuel-based energy sources;
- 27 (2) CNS-1 license renewal will involve continued GHG emissions due to uranium mining,
28 processing, and enrichment, but will not result in increased GHG emissions associated
29 with plant construction or decommissioning (as the plant will have to be decommissioned
30 at some point whether the license is renewed or not); and
- 31 (3) Few studies predict that nuclear fuel cycle emissions will exceed those of fossil fuels
32 within a timeframe that includes the CNS-1 periods of extended operation. Several
33 studies suggest that future extraction and enrichment methods, the potential for higher
34 grade resource discovery, and technology improvements could extend this timeframe.

35 With respect to comparison of GHG emissions among the proposed CNS-1 license renewal
36 action and renewable energy sources, it appears likely that there will be future technology
37 improvements and changes in the type of energy used for mining, processing, and constructing
38 facilities of all types. Currently, the GHG emissions associated with the nuclear fuel cycle and
39 renewable energy sources are within the same order of magnitude. Because nuclear fuel
40 production is the most significant contributor to possible future increases in GHG emissions
41 from nuclear power, and because most renewable energy sources lack a fuel component, it is
42 likely that GHG emissions from renewable energy sources would be lower than those
43 associated with CNS-1 at some point during the period of extended operation.

1 The NRC staff also provides an additional discussion about the contribution of GHG to
2 cumulative air quality impacts in Section 4.11.5 of this SEIS,

3 **6.3 REFERENCES**

- 4 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, "Environmental
5 Protection Regulations for Domestic Licensing and Related Regulatory Functions."
- 6 10 CFR Part 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, "Requirements for
7 Renewal of Operating Licenses for Nuclear Power Plants."
- 8 10 CFR Part 63. *Code of Federal Regulations*, Title 10, *Energy*, Part 63, "Disposal of High-Level
9 Radioactive Wastes in a Geologic Repository at Yucca Mountain, Nevada."
- 10 40 CFR Part 191. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 191,
11 "Environmental Radiation Protection Standards for Management and Disposal of Spent Nuclear
12 Fuel, High-Level and Transuranic Radioactive Waste."
- 13 AEA Technology (AEA). 2006. "Carbon Footprint of the Nuclear Fuel Cycle, Briefing Note."
14 Prepared for British Energy. March 2006.
- 15 Andseta, S., M.J. Thompson, J.P. Jarrell, and D.R. Pendergast. 1998. "CANDU Reactors and
16 Greenhouse Gas Emissions." Canadian Nuclear Association, 11th Pacific Basin Nuclear
17 Conference, Banff, Alberta, Canada. May 1998.
- 18 Dones, R. 2007. "Critical Note on the Estimation by Storm Van Leeuwen J.W., and Smith P. of
19 the Energy Uses and Corresponding CO₂ Emissions for the Complete Nuclear Energy Chain."
20 Paul Sherer Institute. April 2007.
- 21 Fritsche, U.R. 2006. "Comparison of Greenhouse-Gas Emissions and Abatement Cost of
22 Nuclear and Alternative Energy Options from a Life-Cycle Perspective." Oko-Institut, Darmstadt
23 Office. January 2006.
- 24 Fthenakis, V.M. and H.C. Kim. 2007. Greenhouse-gas emissions from solar-electric and nuclear
25 power: A life cycle study. *Energy Policy*, Volume 35, Number 4.
- 26 International Atomic Energy Agency (IAEA). 2000. "Nuclear Power for Greenhouse Gas
27 Mitigation under the Kyoto Protocol: The Clean Development Mechanism (CDM)." November
28 2000.
- 29 Mortimer, N. 1990. "World Warms to Nuclear Power." *SCRAM Safe Energy Journal*. December
30 1989 and January 1990. Available URL:
31 http://www.no2nuclearpower.org.uk/articles/mortimer_se74.php (accessed February 29, 2007).
- 32 Nebraska Public Power District (NPPD). 2008. *Cooper Nuclear Station License Renewal*
33 *Application*. Environmental Report.
- 34 Organization for Economic Co-Operation and Development, Nuclear Energy Agency (NEA).
35 2002. *Nuclear Energy and the Kyoto Protocol*.
- 36 Parliamentary Office of Science and Technology (POST). 2006. "Carbon Footprint of Electricity
37 Generation." Postnote, Number 268. October 2006.
- 38 Schneider, M. 2000. *Climate Change and Nuclear Power*. World Wildlife Fund for Nature. April
39 2000.
- 40 Spadaro, J.V., L. Langlois and B. Hamilton. 2000. "Greenhouse Gas Emissions of Electricity
41 Generation Chains: Assessing the Difference." IAEA Bulletin 42/2/2000, Vienna, Austria.

Environmental Impacts of the Uranium Fuel Cycle

- 1 Storm van Leeuwen, J.W. and P. Smith 2005. *Nuclear Power—The Energy Balance*. August
2 2005.
- 3 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement*
4 *for License Renewal of Nuclear Plants*. NUREG-1437, Volumes 1 and 2, Washington, D.C,
5 1996. ADAMS Accession Nos. ML040690705 and ML040690738.
- 6 U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement*
7 *for License Renewal of Nuclear Plants, Main Report*, “Section 6.3 – Transportation, Table 9.1,
8 Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants, Final
9 Report.” NUREG-1437, Volume 1, Addendum 1, Washington, D.C.
- 10 Weisser, D. 2006. “A Guide to Life-Cycle Greenhouse Gas (GHG) Emissions from Electric
11 Supply Technologies.” Available URL:
12 [http://www.iaea.org/OurWork/ST/NE/Pess/assets/GHG_manuscript_pre-](http://www.iaea.org/OurWork/ST/NE/Pess/assets/GHG_manuscript_pre-print_versionDanielWeisser.pdf)
13 [print_versionDanielWeisser.pdf](http://www.iaea.org/OurWork/ST/NE/Pess/assets/GHG_manuscript_pre-print_versionDanielWeisser.pdf) (accessed May 19, 2009)

7.0 ENVIRONMENTAL IMPACTS OF DECOMMISSIONING

Environmental impacts from the activities associated with the decommissioning of any reactor before or at the end of an initial or renewed license are evaluated in the *Generic Environmental Impact Statement on Decommissioning of Nuclear Facilities: Supplement 1, Regarding the Decommissioning of Nuclear Power Reactors*, NUREG-0586, Supplement 1 (NRC, 2002). The staff's evaluation of the environmental impacts of decommissioning presented in NUREG-0586, Supplement 1, identifies a range of impacts for each environmental issue.

The incremental environmental impacts associated with decommissioning activities resulting from continued plant operation during the renewal term are discussed in the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437, Volumes 1 and 2 (NRC 1996; 1999).

7.1 DECOMMISSIONING

Category 1 issues in Table B-1 of Title 10 of the Code of Federal Regulations (CFR) Part 51, Subpart A, Appendix B that are applicable to Cooper Nuclear Station, Unit 1 (CNS-1) decommissioning following the renewal term are listed in Table 7-1.

Table 7-1. Category 1 Issues Applicable to the Decommissioning of CNS-1 Following the Renewal Term

ISSUE	GEIS Section
Radiation doses	7.3.1
Waste management	7.3.2
Air quality	7.3.3
Water quality	7.3.4
Ecological resources	7.3.5
Socioeconomic impacts	7.3.7

A brief description of the staff's review and the conclusions, as stated in Table B-1, 10 CFR Part 51, for each of the issues follows:

- Radiation doses. Based on information in the GEIS, the Commission found that:
Doses to the public will be well below applicable regulatory standards regardless of which decommissioning method is used. Occupational doses would increase no more than 1 man-rem caused by buildup of long-lived radionuclides during the license renewal term.
- Waste management. Based on information in the GEIS, the Commission found that:
Decommissioning at the end of a 20-year license renewal period would generate no more solid wastes than at the end of the current license term. No increase in the quantities of Class C or greater than Class C wastes would be expected.
- Air quality. Based on information in the GEIS, the Commission found that:

Environmental Impacts of Decommissioning

1 Air quality impacts of decommissioning are expected to be negligible either at the
2 end of the current operating term or at the end of the license renewal term.

3 • Water quality. Based on information in the GEIS, the Commission found that:

4 The potential for significant water quality impacts from erosion or spills is no
5 greater whether decommissioning occurs after a 20-year license renewal period
6 or after the original 40-year operation period, and measures are readily available
7 to avoid such impacts.

8 • Ecological resources. Based on information in the GEIS, the Commission found that:

9 Decommissioning after either the initial operating period or after a 20-year
10 license renewal period is not expected to have any direct ecological impacts.

11 • Socioeconomic Impacts. Based on information in the GEIS, the Commission found that:

12 Decommissioning would have some short-term socioeconomic impacts. The
13 impacts would not be increased by delaying decommissioning until the end of a
14 20-year relicense period, but they might be decreased by population and
15 economic growth.

16 The NRC staff has not identified any new and significant information during the review of the
17 Nebraska Public Power District (NPPD) environmental report (ER), the site audit, or the scoping
18 process; therefore, there are no impacts related to these issues beyond those discussed in the
19 GEIS (NRC 1996, 1999). For the issues listed in Table 7-1 above, the GEIS concluded that the
20 impacts are SMALL.

21 7.2 REFERENCES

22 10 CFR Part 51. Code of Federal Regulations, Title 10, *Energy*, Part 51, "Environmental
23 Protection Regulations for Domestic Licensing and Related Regulatory Functions

24 Nebraska Public Power District (NPPD). 2008. *Cooper Nuclear Station, Applicant's*
25 *Environmental Report, License Renewal Operating Stage*. ADAMS Accession No.
26 ML08303020246.

27 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement*
28 *for License Renewal of Nuclear Plants*, NUREG-1437, Volumes 1 and 2, Washington, D.C.
29 ADAMS Accession No. ML040690705 and ML040690738.

30 U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement*
31 *for License Renewal of Nuclear Plants, Main Report*, "Section 6.3, Transportation, Table 9.1,
32 Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants, Final
33 Report." NUREG-1437, Volume 1, Addendum 1, Washington, D.C.

34 U.S. Nuclear Regulatory Commission (NRC). 2002. *Generic Environmental Impact Statement*
35 *on Decommissioning of Nuclear Facilities: Supplement 1*, "Regarding the Decommissioning of
36 Nuclear Power Reactors." NUREG-0586, Supplement 1, Volumes 1 and 2, Washington, D.C.

8.0 ENVIRONMENTAL IMPACTS OF ALTERNATIVES

The National Environmental Policy Act (NEPA) mandates that each environmental impact statement (EIS) consider alternatives to any proposed major Federal action. U.S. Nuclear Regulatory Commission (NRC) regulations (Title 10 of the *Code of Federal Regulations* (CFR) Section 51.71(d)) implementing NEPA for license renewal require that a supplemental environmental impact statement (SEIS) do the following:

Consider and weigh the environmental effects of the proposed action; the environmental impacts of alternatives to the proposed action; and alternatives available for reducing or avoiding adverse environmental effects and consideration of the economic, technical, and other benefits and costs of the proposed action.

In this case, the proposed Federal action is issuing a renewed license for Cooper Nuclear Station, Unit 1 (CNS-1), which will allow the plant to operate for 20 years beyond its current license expiration date. In this chapter, the NRC staff examines potential environmental impacts of alternatives to issuing a renewed operating license for CNS-1 as well as alternatives that may reduce or avoid adverse environmental impacts from license renewal, including when and where these alternatives are applicable.

While the *Generic Environmental Impact Statement (GEIS) for License Renewal of Nuclear Plants*, NUREG-1437 (NRC 1996, 1999), reached generic conclusions regarding many environmental issues associated with license renewal, it did not determine which alternatives are reasonable or reach conclusions about site-specific environmental impact levels. As such, the NRC staff must evaluate environmental impacts of alternatives on a site-specific basis.

Alternatives to the proposed action of issuing a renewed CNS-1 operating license must meet the purpose and need for issuing a renewed license; they must “provide an option that allows for power generation capability beyond the term of a current nuclear power plant operating license to meet future system generating needs, as such needs may be determined by State, utility, and, where authorized, Federal (other than NRC) decision makers (NRC, 1996).”

The NRC staff ultimately makes no decision as to which alternative (or the proposed action) to implement, since that decision falls to utility, or State officials. Comparing the environmental effects of these alternatives will assist the NRC in deciding whether or not the adverse environmental impacts of license renewal are so great that preserving the option of license renewal for energy planning decisionmakers would be unreasonable. If the NRC acts to issue a renewed license, all of the alternatives, including the proposed action, will be available to energy-planning decision makers. If NRC decides not to renew the license (or takes no action at all), then energy-planning decision makers may no longer elect to continue operating CNS-1 and will have to resort to another alternative—which may or may not be one of the alternatives the NRC staff considers in this section—to meet their energy needs.

In evaluating alternatives to license renewal, the NRC staff first selects energy technologies or options currently in commercial operation as well as some technologies not currently in commercial operation but likely to be commercially available by the time the current CNS-1 operating license expires.

Environmental Impacts of Alternatives

1 Second, the NRC staff screens the alternatives to remove those that cannot meet future system
2 needs. Then, the staff screens the remaining options to remove those whose costs or benefits
3 do not justify inclusion in the range of reasonable alternatives. Any alternatives remaining, then,
4 constitute alternatives to the proposed action that the staff evaluates in-depth throughout this
5 section. At the end of the section, the staff will briefly address each alternative removed during
6 screening.

7 The NRC staff initially considers 19 discrete alternatives to the proposed action.

8 Once the staff identifies the in-depth alternatives, the staff refers to generic environmental
9 impact evaluations in the GEIS. The GEIS provides overviews of some energy technologies
10 available at the time of its publishing in 1996, though it does not reach any conclusions
11 regarding which alternatives are most appropriate, nor does it precisely categorize impacts for
12 each site. Since 1996, many energy technologies have evolved significantly in capability and
13 cost, while regulatory structures have changed to either promote or impede development of
14 particular alternatives.

15 As a result, our analyses include updated information from sources like the Energy Information
16 Administration (EIA), other organizations within the Department of Energy (DOE), the
17 Environmental Protection Agency (EPA), industry sources and publications, and information
18 submitted by the applicant (Nebraska Public Power District (NPPD)) in the environmental report
19 (ER).

20 For each in-depth analysis, the staff
21 analyzes environmental impacts across
22 seven impact categories: (1) air quality,
23 (2) ground water use and quality, (3)
24 surface water use and quality, (4)
25 ecology, (5) human health, (6)
26 socioeconomics, and (7) waste
27 management. As in earlier chapters of
28 this draft SEIS, the staff uses NRC's
29 three-level standard of significance—
30 SMALL, MODERATE, or LARGE—to
31 indicate the intensity of environmental
32 effects for each alternative that is
33 evaluated in depth. By placing the
34 detailed alternative analyses in this
35 order, the NRC staff does not mean to
36 imply that one alternative would have the
37 least impact, or that an energy-planning
38 decision maker would be most likely to
39 implement one or another alternative.

40 Sections 8.1 through 8.3 contain
41 analyses of environmental impacts of
42 alternatives to license renewal. These
43 include a supercritical coal-fired plant in
44 Section 8.1, a natural gas-fired
45 combined-cycle power plant in 8.2, and a
46 combination of alternatives in 8.3, that

Energy Outlook:

Each year the Energy Information Administration (EIA), part of the U.S. Department of Energy (DOE), issues its updated *Annual Energy Outlook (AEO)*. *AEO, 2009*, indicates that natural gas, coal, and renewables are likely to fuel most new electrical capacity through 2030, with some growth in nuclear capacity (EIA, 2009a), though all projections are subject to future developments in fuel price or electricity demand.

“Natural-gas-fired plants account for 53 percent of capacity additions in the reference case, as compared with 22 percent for renewables, 18 percent for coal-fired plants, and 5 percent for nuclear. Capacity expansion decisions consider capital, operating, and transmission costs. Typically, coal-fired, nuclear, and renewable plants are capital-intensive, whereas operating (fuel) expenditures account for most of the costs associated with natural-gas-fired capacity.” (EIA, 2009c)

1 includes some natural gas-fired capacity, energy conservation, and a wind power component. In
2 Section 8.4, the NRC staff explains why it dismissed many other alternatives from in-depth
3 consideration. Finally, in Section 8.5, the staff considers the environmental effects that may
4 occur if NRC takes no action and does not issue a renewed license for CNS-1.

5 **8.1 SUPERCRITICAL COAL-FIRED GENERATION**

6 Coal-fired generation accounts for a greater share of U.S. electrical power generation than any
7 other fuel (EIA, 2009a). Furthermore, the EIA projects that coal-fired power plants will account
8 for the greatest share of capacity additions through 2030—more than natural gas, nuclear or
9 renewable generation options. While coal-fired power plants are widely used and likely to
10 remain widely used, the staff acknowledges that future additions to coal capacity may be
11 affected by perceived or actual efforts to limit greenhouse gas (GHG) emissions. For now, the
12 staff considers a coal-fired alternative to be a feasible, commercially available option for
13 providing electrical generating capacity beyond CNS-1's current license expiration.

14 Supercritical technologies are increasingly common in new coal-fired plants. Supercritical
15 facilities operate at higher temperatures and pressures than most existing coal-fired plants. At
16 the critical point, there is no change of state when pressure is increased or if heat is added. For
17 states above the critical point the steam is supercritical. Operating at higher temperatures and
18 pressures allows the supercritical coal-fired alternative to operate at a higher thermal efficiency
19 than subcritical coal-fired power plants. While supercritical facilities are more expensive to
20 construct, they consume less fuel for a given output, reducing environmental impacts. Based on
21 technology forecasts from EIA (EIA, 2009), the NRC staff expects that a new, supercritical coal-
22 fired plant that begins operation in 2014 would operate at a heat rate of 9,069 British thermal
23 units/kilowatt hours (Btu/kWh), or approximately 38 percent thermally efficient (EIA, 2009).³

24 In a supercritical coal-fired power plant, burning coal heats pressurized water. As the
25 supercritical steam/water mixture moves through plant pipes to a turbine generator, the
26 pressure drops and the mixture flashes to steam. The heated steam expands across the turbine
27 stages, which then spin and turn the generator to produce electricity. After passing through the
28 turbine, any remaining steam is condensed back to water in the plant's condenser.

29 In most modern U.S. coal facilities, condenser cooling water circulates through cooling towers or
30 a cooling pond system (either of which are closed-cycle cooling systems). Older plants often
31 withdraw cooling water directly from existing rivers or lakes and discharge heated water directly
32 to the same body of water (called open-cycle cooling). Though the NRC staff notes that a new
33 facility could hypothetically continue to use the existing CNS-1 intake structure with a once-
34 through cooling system as long as CNS-1 could continue to receive sufficient water to maintain
35 cooling for those systems necessary for a shutdown plant and provided that no modifications
36 would be necessary to the intake structure and associated pumps. In order to provide cooling
37 water for the new facility, the NRC staff has chosen to evaluate a coal-fired alternative using
38 closed-cycle cooling because it will result in lower impacts—primarily to aquatic ecology—over
39 the life of the alternative. Construction impacts may, however, be slightly greater, and
40 operational impacts to aesthetics may also be slightly more noticeable, depending on whether
41 or not the replacement facility uses natural- or mechanical-draft cooling towers.

³ Thermal efficiency is a measure of the efficiency of converting a fuel to energy and useful work. Thermal efficiency of a nuclear plant is roughly 32 percent.

Environmental Impacts of Alternatives

1 The plant would withdraw makeup water from and discharge blowdown (water containing
2 concentrated dissolved solids and biocides) back to the Missouri River. Cooling towers could be
3 either natural draft (tall towers powered only by the difference in density between heated, humid
4 air, and surrounding cooler and usually drier air) or mechanical draft (shorter towers powered by
5 mechanical fans). For this analysis, the NRC staff assumed that a new supercritical coal-fired
6 power plant would use mechanical draft towers for its closed-cycle cooling system.

7 In order to replace the 816 net MWe that CNS-1 currently supplies, the coal-fired alternative
8 would ideally produce roughly the same amount (NPPD, 2008). Onsite electricity usage includes
9 scrubbers, cooling towers, coal-handling equipment, lights, communication, and other onsite
10 needs. A supercritical coal-fired power plant equivalent in capacity to CNS-1 would require less
11 cooling water than CNS-1 because of the switch from open-cycle to closed-cycle cooling and
12 because the plant operates at a higher thermal efficiency.

13 This 816 net MWe power plant would consume 3.14 million tons (2.84 million metric tons (MT))
14 of coal annually assuming an average heat content of 8,570 British thermal unit/pound (BTU/lb)
15 (EIA, 2006). EIA reported that most coal consumed in Nebraska originates in Wyoming. Given
16 current coal mining operations in Wyoming, the coal used in this alternative would likely be
17 mined in surface mines, then mechanically processed and washed, before being transported—
18 likely by rail—to the power plant site. Limestone for scrubbers would also likely arrive by rail.
19 This coal-fired alternative would then produce roughly 153,000 tons (138,800 MT) of ash, and
20 roughly 49,500 tons (45,000 MT) scrubber sludge. As noted above, much of the coal ash and
21 scrubber sludge (about 38,300 tons (34,800 MT)) could be recycled.

22 Environmental impacts from the coal-fired alternative will be greatest during construction. Site
23 crews will clear the plant site of vegetation, prepare the site surface, and begin excavation
24 before other crews begin actual construction on the plant and any associated infrastructure,
25 including electricity transmission infrastructure connecting the plant to existing transmission
26 lines.

27 **8.1.1 Air Quality**

28 Air quality impacts from coal-fired generation can be substantial because it emits a significant
29 quantity of sulfur oxides (SO_x), nitrogen oxides (NO_x), particulates, carbon monoxide (CO), and
30 hazardous air pollutants (HAPs) such as mercury; however, many of these pollutants can be
31 effectively controlled by various technologies.

32 CNS-1 is located in Nemaha County, Nebraska. There are no areas designated by the EPA as
33 nonattainment or maintenance for any of the criteria pollutants in the 50-mile (81 kilometer)
34 vicinity of CNS-1. (EPA has defined six "criteria pollutants" as indicators of air quality, and has
35 established for each of them a maximum concentration above which adverse effects on human
36 health may occur). A new coal-fired generating plant would qualify as a new major-emitting
37 industrial facility and would be subject to Prevention of Significant Deterioration of Air Quality
38 Review under requirements of the Clean Air Act (CAA) (42 U.S.C. §7401 et seq.), adopted by
39 Nebraska Department of Environmental Quality (NDEQ) in Title 129 of Nebraska Air Quality
40 Regulations (NAQR) (EPA, 2008a). A new coal-fired generating plant would need to comply
41 with the new source performance standards for coal-fired plants set forth in 40 CFR 60 Subpart
42 Da. The standards establish limits for particulate matter (40 CFR 60.42Da), sulfur dioxide (SO₂)
43 (40 CFR 60.43Da), and NO_x (40 CFR 60.44Da). Regulations issued by NDEQ adopt the EPA's
44 CAA rules, with modifications, to limit power plant emissions of SO_x, NO_x, particulate matter,
45 and HAPs, among other matters. The new coal-fired generating plant would qualify as a Class I

1 major source as identified in Chapter 2 of Title 129 of the Nebraska Administrative Code and
 2 would be required to obtain Class I major source permits from NDEQ, (the EPA may also elect
 3 to review this aspect prior to issuance of the permits (NDEQ, 2003)).

4 Section 169A of the CAA (42 U.S.C. § 7491) calls for EPA to establish rules to remedy any
 5 existing visibility impairment and prevent any future impairment in mandatory Class I federal
 6 areas resulting from manmade air pollution. There are no mandatory Class I Federal areas in
 7 the State of Nebraska and the closest mandatory Class I Federal area is Hercules-Glades
 8 Wilderness Area, which is located 295 miles southeast from the CNS-1 in the State of Missouri.
 9 However, the State of Nebraska is among nine states (Nebraska, Kansas, Oklahoma, Texas,
 10 Minnesota, Iowa, Missouri, Arkansas, and Louisiana) that are members of the Central Regional
 11 Air Planning Association (CENRAP), along with tribes, Federal agencies, and other interested
 12 parties that identify regional haze and visibility issues and develop strategies to address them.
 13 The visibility protection regulatory requirements, contained in 40 CFR Part 51, Subpart P,
 14 include the review of the new sources that would be constructed in the attainment or
 15 unclassified areas and may affect visibility in any Federal Class I area (40 CFR § 51.307).

16 The emissions from the coal-fired alternative at the CNS-1 site, projected by the NRC staff
 17 based on published EIA data, EPA emission factors and based on performance characteristics
 18 for this alternative and likely emission controls, would be:

- 19 • Sulfur oxides (SO_x) – 923 tons (838 metric tones) per year
- 20 • Nitrogen oxides (NO_x) – 784 tons (711 metric tones) per year
- 21 • Total suspended particles (TSP) – 80 tons (72 metric tones) per year
- 22 • Particulate matter (PM) PM₁₀ – 18 tons (17 metric tones) per year
- 23 • Particulate matter (PM) PM_{2.5} – 77 tons (69 metric tones) per year
- 24 • Carbon monoxide (CO) – 784 tons (711 metric tones) per year

25 8.1.1.1 *Sulfur Oxides*

26 The coal-fired alternative at the CNS-1 site would likely use wet, limestone-based scrubbers to
 27 remove SO_x. The EPA indicates that this technology can remove more than 95 percent of SO_x
 28 from flue gases. The staff projects total SO_x emissions would be 923 tons (838 MT) per year.
 29 SO_x emissions from a new coal-fired power plant would be subject to the part of the
 30 requirements of the CAA (42 U.S.C. §§7651 et seq.). These regulations were enacted to reduce
 31 emissions of SO₂ and NO_x, the two principal precursors of acid rain, by restricting emissions of
 32 these pollutants from power plants. Title IV caps aggregate annual power plant SO₂ emissions
 33 and imposes controls on SO₂ emissions through a system of marketable allowances. The EPA
 34 issues one allowance for each ton of SO₂ that a unit is allowed to emit. New units do not receive
 35 allowances, but are required to have allowances to cover their SO₂ emissions. Owners of new
 36 units must therefore purchase allowances from owners of other power plants or reduce SO₂
 37 emissions at other power plants they own. Allowances can be banked for use in future years.
 38 Thus, provided a new coal-fired power plant is able to purchase sufficient allowances to
 39 operate, it would not add to net regional SO₂ emissions, although it might do so locally.

1 8.1.1.2 *Nitrogen Oxides*

2 A coal-fired alternative at the CNS-1 site would most likely employ various available NO_x -
3 control technologies, which can be grouped into two main categories: combustion modifications
4 and post-combustion processes. Combustion modifications include low- NO_x burners, overfire
5 air, reburning, flue gas recirculation, and operational modifications. Post-combustion processes
6 include selective catalytic reduction, selective noncatalytic reduction, and hybrid processes.
7 Effective combination of the combustion modifications and post-combustion processes allows
8 reducing NO_x emissions by up to 95 percent (EPA, 1998). NPPD indicated in its ER that it would
9 use a combination of low- NO_x burners, overfire air, and selective noncatalytic reduction
10 technologies in order to reduce NO_x emissions from this alternative. Assuming the use of such
11 technologies at the CNS-1 site, NO_x emissions after scrubbing are estimated to be in the range
12 of 783.77 tons (711.04 MT) annually.

13 Section 407 of the CAA establishes technology-based emission limitations for NO_x emissions. A
14 new coal-fired power plant would be subject to the new source performance standards for such
15 plants as indicated in 40 CFR 60.44Da(1). This regulation, limits the discharge of any gases that
16 contain NO_x to 200 nanograms (ng) of NO_x per joule (J) of gross energy output (equivalent to
17 1.6 pounds per megawatt hours (lb/MWh), based on a 30-day rolling average. Based on the
18 projected emissions and proposed emissions controls, the coal-fired alternative would meet this
19 regulation.

20 8.1.1.3 *Particulates*

21 The new coal-fired power plant would use fabric filters to remove particulates from flue gases.
22 NPPD indicates that fabric filters would remove 99.9 percent of particulate matter (NPPD,
23 2008). The EPA notes that filters are capable of removing in excess of 99 percent of particulate
24 matter, and that SO₂ scrubbers further reduce particulate matter emissions (EPA, 2008);
25 therefore, the NRC staff believes the NPPD removal factor is appropriate. Based on this, the
26 new supercritical coal-fired plant would emit 79.68 tons (72.29 MT) per year of TSP and
27 approximately 18.33 tons (16.63 MT) per year of particulate matter having an aerodynamic
28 diameter less than, or equal to, 10 microns (PM10) annually. In addition, coal burning would
29 also result in approximately 76.50 tons per year (69.40 MT) of particulate emissions with an
30 aerodynamic diameter of 2.5 microns or less (PM2.5) and coal-handling equipment would
31 introduce fugitive dust emissions when fuel is being transferred to onsite storage and then
32 reclaimed from storage for use in the plant. During the construction of a coal-fired plant, onsite
33 activities would also generate fugitive dust. Vehicles and motorized equipment would create
34 exhaust emissions during the construction process. These impacts would be intermittent and
35 short-lived; however, to minimize dust generation, construction crews could use applicable dust-
36 control measures.

37 8.1.1.4 *Carbon Monoxide*

38 Based upon EPA emission factors (EPA, 1998), NRC staff estimates that total CO emissions
39 would be approximately 783.77 tons (711.04 MT) per year.

40 8.1.1.5 *Carbon Dioxide*

41 A coal-fired plant would also have unregulated carbon dioxide (CO₂) emissions during
42 operations, as well as during mining, processing, and transportation. The coal-fired plant would
43 emit between 5,516,000 tons (5,004,000 MT) and 5,715,000 tons (5,184,600 MT) of CO₂ per
44 year from coal combustion, depending on the type and quality of the coal burned.

1 8.1.1.6 *Summary of Air Quality*

2 While the GEIS analysis mentions global warming from unregulated CO₂ emissions and acid
 3 rain from SO_x and NO_x emissions as potential impacts, it does not quantify emissions from coal-
 4 fired power plants; however, the GEIS analysis does imply that air impacts would be substantial
 5 (NRC, 1996). The above analysis shows that emissions of air pollutants, including SO_x, NO_x,
 6 CO, and particulates, exceed those produced by the existing nuclear power plant, as well as
 7 those of the other alternatives considered in this section. Operational emissions of CO₂ are also
 8 much greater under the coal-fired alternative than under other alternatives, as reviewed by the
 9 staff in Section 6.2. Adverse human health effects such as cancer and emphysema have also
 10 been associated with air emissions from coal combustion, and are discussed further in Section
 11 8.1.5.

12 The NRC analysis for a coal-fired alternative at an alternative site indicates that impacts from
 13 the coal-fired alternative would have clearly noticeable effects, but given existing regulatory
 14 regimens, permit requirements, and emissions controls, the coal-fired alternative would not
 15 destabilize air quality. Therefore, the appropriate characterization of air impacts from coal-fired
 16 plant located at CNS-1 site is MODERATE.

17 **8.1.2 Ground Water Use and Quality**

18 If the onsite coal-fired alternative continued to use ground water for drinking water and service
 19 water, the need for ground water at the plant would be minor. Total usage would likely be less
 20 than CNS-1 because fewer workers would be onsite, and the coal-fired unit would have fewer
 21 auxiliary systems requiring service water. No effect on ground water quality would likely be
 22 apparent.

23 Construction of a coal-fired plant could have a localized effect on ground water due to
 24 temporary dewatering and run-off control measures. Because of the temporary nature of
 25 construction and the likelihood of reduced ground water usage during operation, the impact of
 26 the coal-fired alternative would be designated as SMALL.

27 **8.1.3 Surface Water Use and Quality**

28 Because the alternative would draw water from the Missouri River, most of the approximately
 29 12,000 gallons per minute (gpm) needed for maximum withdrawal would be taken from the river
 30 with an average consumptive loss of about 15 million gallons per day (mgd). Since the
 31 consumptive loss is less than 0.1 percent of the average annual flow of the Missouri River, the
 32 NRC staff concludes the impact of surface water use would be designated as SMALL. A new
 33 coal-fired plant would be required to obtain a National Pollutant Discharge and Elimination
 34 System (NPDES) permit from the NDEQ for regulation of industrial discharges such as
 35 wastewater and storm water. Assuming the plant operates within the limits of this permit, the
 36 impact from any cooling tower blowdown, site runoff, and other effluent discharges on surface
 37 water quality would be designated as SMALL.

38 **8.1.4 Aquatic and Terrestrial Ecology**

39 8.1.4.1 *Aquatic Ecology*

40 In Section 8.1, the NRC notes that it may be possible for a coal-fired alternative to rely on the
 41 existing CNS-1 cooling water intake and open cycle cooling, but in order to reduce potential
 42 impacts to aquatic organisms, the NRC staff has determined that the coal-fired alternative would

Environmental Impacts of Alternatives

1 use closed-cycle cooling. The number of fish and other aquatic organisms affected by
2 impingement, entrainment, and thermal impacts will be less than those associated with license
3 renewal because water consumption from, and heat rejected to, the Missouri River would be
4 substantially lower than the current CNS-1 as closed cycle cooling requires less water and has
5 less aquatic effects than once-through cooling. Some temporary impacts to aquatic organisms
6 might occur as a result of construction or effluent discharges to the river. These activities would
7 be monitored by the NDEQ under the project's NPDES permit. Although the number of affected
8 organisms would be substantially less than for license renewal, the level of impact for continued
9 CNS-1 operation is already small, and so NRC expects that the levels of impact for
10 impingement, entrainment, and thermal effects would also be designated as SMALL.

11 8.1.4.2 *Terrestrial Ecology*

12 Coal-mining operation will also affect terrestrial ecology in offsite coal mining areas, although
13 some of the land is most likely already disturbed by mining operations. Onsite and offsite land
14 disturbances form the basis for impacts to terrestrial ecology.

15 Onsite impacts to terrestrial ecology will be minor because most of the site has been previously
16 disturbed and is currently used for agricultural activities, aside from the 234 acres (95 ha) of
17 woodland on the Missouri side of the river. The impact could change if additional railways or
18 roads are constructed through less disturbed areas. It is likely that the coal-fired alternative
19 would continue to use the existing transmission system and right-of-ways (ROWs). The
20 construction of mechanical draft cooling towers for the closed-cycle cooling system may also
21 result in additional land disturbances. These construction activities may fragment (in the case of
22 roads or railways) or destroy habitats and could include a loss of onsite farmland and possibly
23 wetlands. Construction could also affect current drainage patterns of water into and out of the
24 wetlands on the CNS-1 site. These land disturbances could affect food supply and habitat of
25 native wildlife and migratory waterfowl, and changes to the drainage patterns of the wetlands
26 could affect the wetlands vegetation. However, these impacts are not likely to be significant.
27 Cooling tower operation could produce some deposition of dissolved solids on surrounding
28 vegetation and soil from cooling tower drift, even though the GEIS indicates that the impact of
29 cooling towers on agricultural crops is of small significance and most of the land surrounding the
30 CNS-1 site is farmland.

31 Any onsite or offsite waste disposal by land filling will also affect terrestrial ecology at least
32 through the period when the disposal area is reclaimed. Deposition of acid rain resulting from
33 NO_x or SO_x emissions, and the deposition of other pollutants, can also affect terrestrial ecology.
34 Given the emission regulations discussed in Section 8.1.1, air deposition impacts may be
35 noticeable but are not likely to be destabilizing. Because of the potential habitat disturbances
36 and potential pollutant deposition, impacts to terrestrial resources from a coal-fired alternative
37 would be designated as MODERATE and would occur mostly during construction.

38 **8.1.5 Human Health**

39 Coal-fired power plants introduce worker risks from coal and limestone mining, from coal and
40 limestone transportation, from plant operations, and from disposal of coal combustion and
41 scrubber wastes. In addition, there are public risks from inhalation of stack emissions (as
42 addressed in Section 8.1.1) and the secondary effects of eating foods grown in areas subject to
43 deposition from plant stacks.

44 Human health risks of coal-fired power plants are described, in general, in Table 8-2 of the
45 GEIS (NRC, 1996). Cancer and emphysema as a result of the inhalation of toxins and

1 particulates are identified as potential health risks to occupational workers and members of the
 2 public (NRC, 1996). The human health risks of coal-fired power plants, both to occupational
 3 workers and to members of the public, are greater than those of the current CNS-1 due to
 4 exposures to chemicals such as mercury; SO_x; NO_x; radioactive elements such as uranium and
 5 thorium contained in coal and coal ash; and polycyclic aromatic hydrocarbon (PAH) compounds,
 6 including benzo(a)pyrene.

7 Regulations restricting emissions—enforced by the EPA or State agencies—have acted to
 8 significantly reduce potential health effects but do not entirely eliminate them. These agencies
 9 also impose site-specific emission limits as needed to protect human health. Even if the coal-
 10 fired alternative were located in a nonattainment area, emission controls and trading or offset
 11 mechanisms could prevent further regional degradation; however, local effects could be visible.
 12 Many of the byproducts of coal combustion responsible for health effects are largely controlled,
 13 captured, or converted in modern power plants (as described in Section 8.1.1), although some
 14 level of health effects may remain.

15 Aside from emission impacts, the coal-fired alternative introduces the risk of coal pile fires and
 16 for those plants that use coal combustion liquid and sludge waste impoundments, the release of
 17 the waste due to a failure of the impoundment. Although there have been several instances of
 18 this occurring in recent years, these types of events are still relatively rare.

19 Overall, despite the range of potential threats to human health, extensive health-based
 20 regulations exist to mitigate the risks to workers and the public. As a result, the NRC staff
 21 expects human health impacts to be characterized as SMALL.

22 **8.1.6 Socioeconomics**

23 **8.1.6.1 Land Use**

24 The GEIS generically evaluates the impacts of nuclear power plant operations on land use both
 25 on and off each power plant site. The analysis of land use impacts focuses on the amount of
 26 land area that would be affected by the construction and operation of a new supercritical coal-
 27 fired power plant on the CNS-1 site.

28 Based on previous experience and operating coal-fired plants of similar size, the NRC staff
 29 estimates that an 816-MWe plant would require approximately 170 acres (69 ha) of land.
 30 Additional onsite land may be needed to support a rail spur and yard, as well as approximately
 31 140 acres (57 ha) of land area for waste disposal.

32 Offsite land use impacts would occur from coal mining, in addition to land use impacts from the
 33 construction and operation of the new power plant. Scaling from GEIS estimates, approximately
 34 18,260 acres (7,390 ha) of land could be affected by mining coal and waste disposal to support
 35 the coal-fired alternative during its operational life (NRC, 1996); however, most of the land in
 36 existing coal-mining areas has already experienced some level of disturbance. The elimination
 37 of the need for uranium mining to supply fuel for the CNS-1 would partially offset this offsite land
 38 use impact. Scaling from GEIS estimates, approximately 816 acres (330 ha) of land used for
 39 uranium mining and processing would no longer be needed.

40 Based on this information, land use impacts could range from MODERATE to LARGE. Some
 41 portion of this impact could be mitigated by constructing the rail spur in existing ROWs.

Environmental Impacts of Alternatives

1 8.1.6.2 *Socioeconomics*

2 Socioeconomic impacts are defined in terms of changes to the demographic and economic
3 characteristics and social conditions of a region. For example, the number of jobs created by the
4 construction and operation of a new coal-fired power could affect regional employment, income,
5 and expenditures. Job creation is characterized by two types: (1) construction-related jobs, and
6 (2) operation-related jobs in support of power plant operations, which have the greater potential
7 for permanent, long-term socioeconomic impacts. Workforce requirements of power plant
8 construction and operation for the coal-fired alternative were determined in order to measure
9 their possible effects on current socioeconomic conditions.

10 Based on GEIS estimates, NPPD projected a peak construction workforce of 979 to
11 2,040 workers would be required to construct the coal-fired alternative at the CNS-1
12 (NPPD, 2008). During the construction period, the communities surrounding the plant site would
13 experience increased demand for rental housing and public services. The relative economic
14 contributions of these relocating workers to local business and tax revenues would vary over
15 time.

16 After construction, local communities may be temporarily affected by the loss of construction
17 jobs and associated loss in demand for business services. In addition, the rental housing market
18 could experience increased vacancies and decreased prices. As noted in the GEIS, the
19 socioeconomic impacts at a rural construction site could be larger than at an urban site,
20 because the workforce would need to relocate closer to the construction site. Although the CNS-
21 1 site is a rural site, it is located near the city of Omaha, Nebraska (75 miles), meaning that
22 these effects may be somewhat lessened if workers commute to the site instead of relocating
23 closer. Construction impacts could range from MODERATE to LARGE.

24 NPPD estimated an operational workforce of 163 to 204 workers for the 816-MWe CNS-1 based
25 on GEIS estimates (NPPD, 2008). The NPPD estimate appears reasonable and is consistent
26 with trends calling for decreased workforces at power facilities. Even at a rural site like CNS-1,
27 impacts are unlikely to be large. Operations impacts would likely be in the range of SMALL to
28 MODERATE.

29 8.1.6.3 *Transportation*

30 During construction, approximately 2,000 workers would be commuting to the site. In addition to
31 commuting workers, trucks would transport construction materials and equipment to the
32 worksite increasing the amount of traffic on local roads. The increase in vehicular traffic would
33 peak during shift changes resulting in temporary levels of service impacts and delays at
34 intersections. Trains or barges could also be used to deliver large components to the CNS-1
35 site, which could require the construction of a rail spur or a dock, as well as possible dredging in
36 the Missouri River, if barge delivery is chosen. Transportation impacts are likely to be in the
37 range of MODERATE to LARGE during construction.

38 Transportation impacts would be greatly reduced after construction, but would not disappear
39 during plant operations. The maximum number of plant operating personnel commuting to the
40 CNS-1 would be approximately 200 workers. Frequent deliveries of coal and limestone by rail (if
41 rail delivery is used) would add to the overall transportation impact. Onsite coal storage would
42 make it possible to receive several trains per day. Limestone delivered by rail could also add
43 additional traffic (though considerably less traffic than that generated by coal deliveries).

44 The coal-fired alternative would likely create SMALL to MODERATE transportation impacts.

1 8.1.6.4 *Aesthetics*

2 The aesthetics impact analysis focuses on the degree of contrast between the coal-fired
3 alternative and the surrounding landscape and the visibility of the coal plant.

4 The coal-fired alternative would be up to 200 feet (61 m) tall with an exhaust stack up to 500
5 feet (152 m) and may be visible offsite in daylight hours. The coal-fired plant, however, would be
6 shorter than the current CNS-1 reactor building, which stands at 290 feet (88 m), with a release
7 point at 325 feet (99 m). The assumed mechanical draft towers would generate condensate
8 plumes, but these would be shorter than the plumes from the natural-draft tower alternative.
9 Noise and light from plant operations, as well as lighting on plant structures, may be detectable
10 offsite.

11 Impacts could be moderated because the higher elevation ridges along the river valley may
12 make it difficult to see or hear the plant outside of the river valley. Overall, aesthetic impacts
13 associated with the coal-fired alternative would likely be designated as SMALL to MODERATE.

14 8.1.6.5 *Historic and Archaeological Resources*

15 Cultural resources are the indications of human occupation and use of the landscape as defined
16 and protected by a series of Federal laws, regulations, and guidelines. Prehistoric resources are
17 physical remains of human activities that predate written records; they generally consist of
18 artifacts that may alone or collectively yield information about the past. Historic resources
19 consist of physical remains that postdate the emergence of written records; in the United States,
20 they are architectural structures or districts, archaeological objects, and archaeological features
21 dating from 1492 and later. Ordinarily, sites less than 50 years old are not considered historic,
22 but exceptions can be made for such properties if they are of particular importance, such as
23 structures associated with the development of nuclear power or Cold War themes. American
24 Indian resources are sites, areas, and materials important to American Indians for religious or
25 heritage reasons. Such resources may include geographic features, plants, animals,
26 cemeteries, battlefields, trails, and environmental features. The cultural resource analysis
27 encompassed the power plant site and adjacent areas that could potentially be disturbed by the
28 construction and operation of alternative power plants.

29 The potential for historic and archaeological resources can vary greatly depending on the
30 location of the proposed site. To consider a project's effects on historic and archaeological
31 resources, any proposed areas will need to be surveyed to identify and record historic and
32 archaeological resources, identify cultural resources (e.g., traditional cultural properties), and
33 develop possible mitigation measures to address any adverse effects from ground disturbing
34 activities. Studies will be needed for all areas of potential disturbance at the proposed plant site
35 and along associated corridors where new construction will occur (e.g., roads, transmission
36 corridors, rail lines, or other ROWs). In most cases, project proponents should avoid areas with
37 the greatest sensitivity.

38 CNS-1 is situated in an area where historic and archaeological resources could be located
39 several feet beneath the ground surface. As noted in Section 4.9.6, NPPD conducted a Phase
40 1A survey of the CNS-1 site in 2007 and 2008. NPPD has also developed a Cultural Resources
41 Protection Plan which calls for surveys to be conducted by a qualified archaeologist in areas
42 deemed sensitive prior to work commencing. The plan also includes an inadvertent discovery
43 (stop work) provision to ensure that proper notification is taken to protect these resources
44 should they be discovered. Since NPPD conducted a survey and has established a protection
45 plan, the impact for a coal-fired alternative at the CNS-1 site would be designated as SMALL.

1 8.1.6.6 *Environmental Justice*

2 The environmental justice impact analysis evaluates the potential for disproportionately high and
3 adverse human health and environmental effects on minority and low-income populations that
4 could result from the construction and operation of a new coal-fired power plant. Adverse health
5 effects are measured in terms of the risk and rate of fatal or nonfatal adverse impacts on human
6 health. Disproportionately high and adverse human health effects occur when the risk or rate of
7 exposure to an environmental hazard for a minority or low-income population is significant and
8 exceeds the risk or exposure rate for the general population or for another appropriate
9 comparison group. The minority and low-income populations are subsets of the general public
10 residing around the site, and all are exposed to the same hazards generated from various
11 power plant operations.

12 Minority and low-income populations could be affected by the construction and operation of a
13 new coal-fired power plant. For example, increased demand for rental housing during
14 construction could disproportionately affect low-income populations. Nevertheless, impacts on
15 minority and low-income populations from the construction and operation of a coal-fired power
16 plant alternative could range from SMALL to MODERATE.

17 **8.1.7 Waste Management**

18 Coal combustion generates several waste streams including ash (a dry solid) and sludge (a
19 semi-solid by-product of emission control system operation). The NRC staff estimates that an
20 816-MWe power plant would generate annually a total of 326,000 tons (296,000 MT) of dry solid
21 ash and scrubber sludge. Much of this waste would be recycled. Disposal of the remaining
22 waste from the 20-year operation of this alternative would require approximately 141 acres (57
23 ha). Disposal of the remaining waste could noticeably affect land use and ground water quality,
24 but with a proper siting in accordance with the Title 132, Chapter 4 standards of the Nebraska
25 Administrative Code (NAC), implementation of the monitoring and management practices, it
26 would not destabilize resources. After closure of the waste site and revegetation, the land could
27 be available for other uses.

28 The impacts from waste generated during operation of this coal-fired alternative would be
29 designated as MODERATE; the impacts would be clearly visible but would not destabilize
30 important resources.

31 Impacts from waste generated during the construction stage would be short-lived. The amount
32 of the construction waste is small compared to the amount of waste generated during the
33 operational stage, and most could be recycled. Overall, the impacts from waste generated
34 during the construction stage would be designated as SMALL.

35 The NRC staff, therefore, concludes that waste management impacts from construction and
36 operation of this alternative would be MODERATE.

37 Table 8-1 provides a summary of the environmental impacts of the supercritical coal-fired
38 alternative compared to continued operation of CNS-1.

1 **Table 8-1. Summary of Environmental Impacts of the Supercritical Coal-Fired Alternative**
 2 **Compared to Continued Operation of CNS-1**

	Supercritical Coal-Fired Generation	Continued CNS-1 Operation
Air quality	MODERATE	SMALL
Ground water	SMALL	SMALL
Surface water	SMALL	SMALL
Aquatic and terrestrial resources	SMALL to MODERATE	SMALL
Human health	SMALL	SMALL
Socioeconomics	SMALL to LARGE	SMALL
Waste management	MODERATE	SMALL

3 **8.2 NATURAL GAS-FIRED COMBINED-CYCLE GENERATION**

4 In this section, the environmental impacts of natural gas-fired combined-cycle generation are
 5 evaluated at the CNS-1 site.

6 Natural gas fueled 22 percent of electric generation in the United States in 2007 (the most
 7 recent year for which data are available), accounting for the second greatest share of electrical
 8 power after coal (EIA, 2009a). Like coal-fired power plants, natural gas-fired plants may be
 9 affected by perceived or actual action to limit GHG emissions, although they produce markedly
 10 fewer GHGs per unit of electrical output than coal-fired plants. Natural gas-fired power plants
 11 are feasible, commercially available options for providing electrical generating capacity beyond
 12 CNS-1's current license expiration.

13 Combined-cycle power plants differ significantly from coal-fired and existing nuclear power
 14 plants. Combined-cycle power plants derive the majority of their electrical output from a
 15 gas-turbine cycle, and then generate additional power—without burning any additional fuel—
 16 through a second, steam-turbine cycle. The first, gas turbine stage (similar to a large jet engine)
 17 burns natural gas which turns a driveshaft that powers an electric generator. The exhaust gas
 18 from the gas turbine is still hot enough, however, to boil water to steam. Ducts carry the hot
 19 exhaust to a heat recovery steam generator, which produces steam to drive a steam turbine and
 20 produce additional electrical power. The combined-cycle approach is significantly more efficient
 21 than any one cycle on its own; thermal efficiency can exceed 60 percent. Since the natural gas-
 22 fired alternative derives much of its power from a gas turbine cycle, and because it wastes less
 23 heat than either the coal-fired alternative or the existing CNS-1, it requires significantly less
 24 cooling water and smaller cooling towers than the coal-fired alternative discussed in Section 8.1.

25 In order to replace the 816-MWe that CNS-1 currently supplies, the NRC staff selected a gas-
 26 fired alternative that uses two General Electric S107H combined-cycle generating units. While
 27 any number of commercially available combined-cycle units could be installed in a variety of
 28 combinations to replace the power currently produced by CNS-1, the S107H is a highly efficient
 29 model that will help to minimize environmental impacts. Other manufacturers, like Siemens,
 30 offer similarly high efficiency models. This gas-fired alternative produces a net 400 MWe per
 31 unit. Two units produce a total of 800 MWe, or nearly the same net output as the existing CNS-
 32 1.

33 The combined-cycle alternative operates at a heat rate of 5,690 British thermal units per kilowatt
 34 hours (BTU/kWh), or nearly 60 percent thermal efficiency (GE, 2007). As noted above, this gas-

Environmental Impacts of Alternatives

1 fired alternative would require much less cooling water than CNS-1, because it operates at a
2 higher thermal efficiency and because it requires much less water for steam cycle condenser
3 cooling. Cooling towers for this alternative would likely be mechanical draft-type towers
4 approximately 65 feet (20 m) high.

5 In addition to cooling towers, other visible structures onsite include the turbine buildings and
6 heat recovery steam generators (HRSGs) (which may be enclosed in a single building), two
7 exhaust stacks, an electrical switchyard, and, possibly, equipment associated with a natural gas
8 pipeline, like a compressor station. Based on GEIS estimates, NPPD indicated that this 800-
9 MWe plant would require approximately 90 acres (36 ha).

10 This 800-MWe power plant would consume 34 billion ft³ (964 million m³) of natural gas annually
11 assuming an average heat content of 1,029 BTU/ft³ (EIA, 2009b). Natural gas would be
12 extracted from the ground through wells, then treated to remove impurities (like hydrogen
13 sulfide), and blended to meet pipeline gas standards, before being piped through the interstate
14 pipeline system to the power plant site. This gas-fired alternative would produce relatively little
15 waste, primarily in the form of spent catalysts used for emissions controls.

16 Environmental impacts from the gas-fired alternative will be greatest during construction. Site
17 crews will clear vegetation from the site, prepare the site surface, and begin excavation before
18 other crews begin actual construction on the plant and any associated infrastructure, including a
19 pipeline spur to serve the plant and electricity transmission infrastructure connecting the plant to
20 existing transmission lines. Constructing the gas-fired alternative on NPPD property would allow
21 the gas-fired alternative to make use of CNS-1's existing transmission system.

22 8.2.1.1 Air Quality

23 Nemaha County, Nebraska is in EPA Region 7. All counties in the State of Nebraska are in
24 attainment for all criteria pollutants, except Douglas County, which is a maintenance county for
25 lead. A new gas-fired generating plant developed at the CNS-1 site would qualify as a new
26 major-emitting industrial facility and require a New Source Review (NSR)/Prevention of
27 Significant Deterioration of Air Quality review under CAA, adopted by Nebraska Department of
28 Environmental Quality (NDEQ) in Title 129 of NAC (EPA, 2008). The natural gas-fired plant
29 would need to comply with the standards of performance for electric utility steam generating
30 units set forth in 40 CFR Part 60 Subpart Da.

31 Subpart P of 40 CFR Part 51 contains the visibility protection regulatory requirements, including
32 the review of the new sources that would be constructed in the attainment or unclassified areas
33 and may affect visibility in any Federal Class I area. If a gas-fired alternative was located close
34 to a mandatory Class I area, additional air pollution control requirements would imply. There are
35 no mandatory Class I Federal areas in the State of Nebraska and the closest mandatory Class I
36 Federal area is Hercules-Glades Wilderness Area, which is located 295 miles southeast from
37 the CNS-1 in the State of Missouri.

38 The staff projects the following emissions for a gas-fired alternative based on data published by
39 the EIA, EPA, and on performance characteristics for this alternative and its emissions controls:

- 40 • Sulfur oxides (SO_x) – 60 tons (54 MT) per year
- 41 • Nitrogen oxides (NO_x) – 192 tons (177 MT) per year

- 1 • Carbon monoxide (CO) – 40 tons (36 MT) per year
- 2 • Total suspended particles (TSP) – 34 tons (30 MT) per year
- 3 • Particulate matter (PM) PM10 – 34 tons (30 MT) per year
- 4 • Carbon dioxide (CO₂) – 2,050,000 tons (1,860,000 MT) per year

5 A new natural gas-fired plant would have to comply with Title IV of the CAA (42 U.S.C. §7651)
 6 reduction requirements for SO₂ and NO_x, which are main precursors of acid rain and the major
 7 cause of reduced visibility. Title IV establishes maximum SO₂ and NO_x emission rates from the
 8 existing plants and a system of the SO₂ emission allowances that can be used, sold, or saved
 9 for future use by the new plants.

10 *8.2.1.2 Sulfur and Nitrogen Oxides*

11 As stated above, the new natural gas-fired alternative would produce 60.02 tons (54.45 MT) per
 12 year of SO_x and 192.42 tons (176.56 MT) per year of NO_x based on the use of the dry low NO_x
 13 combustion technology and use of the selective catalytic reduction (SCR) in order to
 14 significantly reduce NO_x emissions.

15 The new plant would be subjected to the continuous monitoring requirements of SO_x, NO_x, and
 16 CO₂ specified in 40 CFR Part 75. The natural gas-fired plant would emit approximately 2.1
 17 million tons (approximately 1.9 million MT) per year of unregulated CO₂ emissions. Currently,
 18 there is no required reporting of GHG emissions in Nebraska.

19 *8.2.1.3 Particulates*

20 The new natural gas-fired alternative would produce 33.54 tons (30.43 MT) per year of TSP, all
 21 of which would be emitted as PM₁₀.

22 *8.2.1.4 Hazardous Air Pollutants*

23 The EPA issued in December 2000 regulatory findings (EPA, 2000a) on emissions of HAPs
 24 from electric utility steam-generating units, which identified that natural gas-fired plants emit
 25 HAPs such as arsenic, formaldehyde, and nickel, and stated that:

26 Also in the utility RTC (Report to Congress), the EPA indicated that the impacts
 27 due to HAP emissions from natural gas-fired electric utility steam generating
 28 units were negligible based on the results of the study. The Administrator finds
 29 that regulation of HAP emissions from natural gas-fired electric utility steam
 30 generating units is not appropriate or necessary.

31 The new natural gas-fired alternative would produce 33.25 tons (30.16 MT) per
 32 year of the TSP as PM₁₀ emissions

33 *8.2.1.5 Construction Impacts*

34 Activities associated with the construction of the new natural gas-fired plant onsite or offsite
 35 CNS-1 would cause some additional, temporary air effects as a result of equipment emissions
 36 and fugitive dust from operation of the earth-moving and material handling equipment.
 37 Emissions from workers' vehicles and motorized construction equipment exhaust would be
 38 temporary. The construction crews would employ dust-control practices in order to control and
 39 reduce fugitive dust. The NRC staff concludes that the impact of vehicle exhaust emissions and

Environmental Impacts of Alternatives

1 fugitive dust from operation of the earth-moving and material handling equipment would be
2 SMALL.

3 The overall air-quality impacts of a new natural gas-fired plant located at the CNS-1 site would
4 be designated as SMALL to MODERATE.

5 **8.2.2 Ground Water Use and Quality**

6 The use of ground water for a natural gas-fired combined-cycle plant would likely be limited to
7 supply wells for drinking water and possibly filtered service water. Total usage would likely be
8 much less than CNS-1 because fewer workers would be onsite and because the gas-fired
9 alternative would have fewer auxiliary systems requiring service water.

10 No effects on ground water quality would be apparent except during the construction phase due
11 to temporary dewatering and run-off control measures. Because of the temporary nature of
12 construction and the likelihood of reduced ground water usage during operation, the impact of
13 the coal-fired alternative would be designated as SMALL.

14 **8.2.3 Surface Water Use and Quality**

15 Maximum withdrawals of surface water from the Missouri River would be much less for a gas-
16 fired plant than the 668,000 gpm (2 m³/s)) maximum currently used by CNS-1; however, by
17 switching from the open-cycle cooling system currently used by CNS-1 to a closed-cycle cooling
18 system used by the proposed alternative, consumptive water losses will increase. Since the
19 consumptive loss will remain less than 0.1 percent of the average annual flow of the Missouri
20 River, the NRC staff concludes the impact of surface water use would be designated as SMALL.

21 A new gas-fired plant would be required to obtain an NPDES permit from the NDEQ for
22 regulation of industrial wastewater, stormwater, and other discharges. Assuming the plant
23 operates within the limits of this permit, the impact from any possible runoff cooling tower
24 blowdown, stormwater discharge, and effluent discharges on surface water quality would be
25 designated as SMALL.

26 **8.2.4 Aquatic and Terrestrial Ecology**

27 *8.2.4.1 Aquatic Ecology*

28 Compared to the existing CNS-1 plant, aquatic ecology actually benefits from the onsite gas-
29 fired alternative, as the combined-cycle plant with cooling towers rejects significantly less heat
30 to the environment, thus requiring less water. The number of fish and other aquatic organisms
31 affected by impingement, entrainment, and thermal impacts will be less than those associated
32 with license renewal because water consumption and heat rejected to the Missouri River are
33 substantially lower. Some temporary impacts to aquatic organisms might occur due to any
34 construction or effluent discharge to the river, but NRC assumes that the appropriate agencies
35 would be monitoring and regulating such activities. Although the number of affected organisms
36 would be substantially less than for license renewal, the NRC level of impact for license renewal
37 is already small, and so NRC expects that the levels of impact for impingement, entrainment,
38 and thermal effects would also be designated as SMALL.

1 8.2.4.2 *Terrestrial Ecology*

2 Constructing the natural gas alternative will require 90 acres (36 ha) of land. These land
3 disturbances form the basis for impacts to terrestrial ecology.

4 Impacts to terrestrial ecology will be minor because the selected site has been previously
5 disturbed and is mostly used for agricultural activities. (Gas extraction and collection will also
6 affect terrestrial ecology in offsite gas fields, although, much of this land is likely already
7 disturbed by gas extraction, and the incremental effects of this alternative on gas field terrestrial
8 ecology are difficult to gauge.)

9 Construction of the two natural gas units and mechanical draft cooling towers could result in the
10 loss of farmland and possible changes to drainage patterns of water into and out of the wetlands
11 on the CNS-1 site, which could affect food supply and habitat of native wildlife. Land
12 disturbance could also affect wetland vegetation, but these effects are not expected to be
13 significant. Operation of the cooling towers would produce a visible plume and cause some
14 deposition of dissolved solids on surrounding vegetation (including some wetlands) and soil
15 from cooling tower drift; however, the GEIS indicates that the impact of cooling towers on
16 agricultural crops is of small significance, and most of the land surrounding the cooling towers is
17 farmland.

18 Construction of the 40-mile gas pipeline could lead to a conversion of forested lands used by
19 terrestrial wildlife to a mowed right-of-way (ROW) as well as the possible loss of cropland from
20 agricultural production, which could impact wildlife that use the croplands as a food source
21 (NPPD, 2008). Siting of the pipeline may occur partially in wetlands, which could impact wildlife
22 that utilize wetlands habitat. Pipeline construction may fragment surrounding habitat and may
23 increase edge habitat, which may have adverse impacts on forest interior dwelling species,
24 including migratory songbirds. Threatened and endangered species may also be affected by
25 construction of the gas pipeline. Impacts from construction of the pipeline are expected to be
26 MODERATE.

27 Based on this information, impacts to terrestrial resources could range from SMALL to
28 MODERATE.

29 **8.2.5 Human Health**

30 Like the coal-fired alternative discussed above, a gas-fired plant would emit criteria air
31 pollutants, but generally in smaller quantities (except NO_x, which requires additional controls to
32 reduce emissions). Human health effects of gas-fired generation are generally low, although in
33 Table 8-2 of the GEIS (NRC, 1996), the NRC staff identified cancer and emphysema as
34 potential health risks from gas-fired plants. NO_x emissions contribute to ozone formation, which
35 in turn contributes to human health risks. Emission controls on this gas-fired alternative maintain
36 NO_x emissions well below air quality standards established for the purposes of protecting
37 human health, and emissions trading or offset requirements mean that overall NO_x in the region
38 will not increase. Health risks to workers may also result from handling spent catalysts that may
39 contain heavy metals.

40 Overall, human health risks to occupational workers and to members of the public from
41 gas-fired power plant emissions sited at CNS-1 would be less than the risks described for a
42 coal-fired alternative and therefore, would likely be designated as SMALL.

1 **8.2.6 Socioeconomics**

2 8.2.6.1 *Land Use*

3 As discussed in Section 8.1.6, the GEIS generically evaluates the impacts of nuclear power
4 plant operations on land use, both on and off each power plant site. The analysis of land use
5 impacts focuses on the amount of land area that would be affected by the construction and
6 operation of a two-unit natural gas-fired combined-cycle power plant at the CNS-1 site.

7 Based on GEIS estimates, NPPD indicated that approximately 90 acres (36 ha) of land would
8 be needed to support a natural gas-fired alternative to replace CNS-1 (NPPD, 2008). This
9 amount of land use would include other plant structures and associated infrastructure, and is
10 unlikely to exceed 90 acres (36 ha), excluding land for natural gas wells and collection stations.
11 Land use impacts from construction would be designated as SMALL.

12 In addition to onsite land requirements, land would be required offsite for natural gas wells and
13 collection stations. Scaling from GEIS estimates, approximately 2,988 acres (1,209 ha) would
14 be required for wells, collection stations, and pipelines to bring the gas to the plant. Most of this
15 land requirement would occur on land where gas extraction already occurs. In addition, some
16 natural gas could come from outside the United States and be delivered as liquefied gas.

17 The elimination of uranium fuel for the CNS-1 could partially offset offsite land requirements.
18 Scaling from GEIS estimates, the NRC staff estimated that approximately 816 acres (330 ha)
19 would not be needed for mining and processing uranium during the operating life of the plant.
20 Overall land use impacts from a gas-fired power plant would be in the range of SMALL to
21 MODERATE.

22 8.2.6.2 *Socioeconomics*

23 Socioeconomic impacts are defined in terms of changes to the demographic and economic
24 characteristics and social conditions of a region. For example, the number of jobs created by the
25 construction and operation of a new natural gas-fired power plant could affect regional
26 employment, income, and expenditures. Two types of jobs are created by this alternative: (1)
27 construction-related jobs, which are transient, short in duration, and less likely to have a long-
28 term socioeconomic impact; and (2) operation-related jobs in support of power plant operations,
29 which have the greater potential for permanent, long-term socioeconomic impacts. Workforce
30 requirements of power plant construction and operations for the natural gas-fired power plant
31 alternative were determined in order to measure their possible effect on current socioeconomic
32 conditions.

33 The socioeconomic impacts from constructing and operating a gas-fired plant would have little
34 noticeable effect. Compared to the coal-fired alternative, the small size of the construction and
35 operations workforce would have little or no socioeconomic impact. As discussed in Section
36 8.1.6.2, the socioeconomic impact of operations of the coal-fired alternative would likely be in
37 the range of SMALL to MODERATE.

38 Based on GEIS estimates, NPPD projected a maximum construction workforce of 979 (NPPD,
39 2008). During construction of a gas-fired plant, the communities surrounding the power plant
40 site would experience increased demand for rental housing and public services. The relative
41 economic effect of construction workers on local economy and tax base would vary over time.

1 After construction, local communities may be temporarily affected by the loss of construction
2 jobs and associated loss in demand for business services, and the rental housing market could
3 experience increased vacancies and decreased prices. As noted in the GEIS, the
4 socioeconomic impacts at a rural construction site could be larger than at an urban site,
5 because the workforce may have to move to be closer to the construction site. The impact of
6 construction on socioeconomic conditions could range from SMALL to MODERATE.

7 Based on GEIS estimates, NPPD estimated a power plant operations workforce of
8 approximately 125 (NPPD, 2008). The NPPD estimate appears reasonable and is consistent
9 with trends toward lowering labor costs by reducing the size of power plant operations
10 workforces. The small number of operations workers could have a noticeable effect on
11 socioeconomic conditions in the region, however, socioeconomic impacts associated with the
12 operation of a gas-fired power plant at the CNS-1 site would be designated as SMALL.

13 8.2.6.3 *Transportation*

14 Transportation impacts associated with construction and operation of a two-unit gas-fired power
15 plant would consist of commuting workers and truck deliveries of construction materials to the
16 CNS-1 site. During construction, up to 1,000 workers would be commuting to the site. In
17 addition to commuting workers, trucks would transport construction materials and equipment to
18 the worksite increasing the amount of traffic on local roads. The increase in vehicular traffic
19 would peak during shift changes resulting in temporary levels of service impacts and delays at
20 intersections. Pipeline construction and modification to existing natural gas pipeline systems
21 could also have an impact.

22 During plant operations, transportation impacts would almost disappear. According to NPPD,
23 approximately 125 workers would be needed to operate the gas-fired power plant. Since fuel is
24 transported by pipeline, most transportation infrastructure would experience little increased use
25 from plant operations.

26 The transportation infrastructure would experience little to no increased use from plant
27 operations. Overall, the gas-fired alternative would have a SMALL impact on transportation
28 conditions in the region around the CNS-1.

29 8.2.6.4 *Aesthetics*

30 The aesthetics impact analysis focuses on the degree of contrast between the natural
31 gas-fired alternative and the surrounding landscape and the visibility of the gas-fired plant.

32 The two gas-fired units could be approximately 100 feet (30 m) tall, with two exhaust stacks up
33 to 175 feet (53 m) tall. Some structures may require aircraft warning lights. Aesthetic impacts
34 may be mitigated as higher elevations and vegetation along the river valley could make it
35 difficult to see or hear the plant outside of the river valley. Power plant infrastructure would
36 generally be smaller and less noticeable than the CNS-1, which has a reactor building height of
37 290 feet (88 m). Mechanical draft cooling towers would generate condensate plumes and
38 operational noise. Noise during power plant operations would be limited to industrial processes
39 and communications. Pipelines delivering natural gas fuel could be audible offsite near
40 compressors.

41 In general, aesthetic changes would be limited to the immediate vicinity of the CNS-1. Impacts
42 would likely be designated as SMALL to MODERATE.

Environmental Impacts of Alternatives

1 8.2.6.5 *Historic and Archaeological Resources*

2 The same considerations as discussed in Section 8.1.6.4 for impact of the coal-fired alternative
3 on historic and archaeological resources apply to the gas-fired alternative.

4 The impact for a gas-fired alternative at the CNS-1 site would be SMALL.

5 8.2.6.6 *Environmental Justice*

6 The environmental justice impact analysis evaluates the potential for disproportionately high and
7 adverse human health and environmental effects on minority and low-income populations that
8 could result from the construction and operation of a new natural gas-fired power plant. Adverse
9 health effects are measured in terms of the risk and rate of fatal or nonfatal adverse impacts on
10 human health. Disproportionately high and adverse human health effects occur when the risk or
11 rate of exposure to an environmental hazard for a minority or low-income population is
12 significant and exceeds the risk or exposure rate for the general population or for another
13 appropriate comparison group. The minority and
14 low-income populations are subsets of the general public residing around the site, and all are
15 exposed to the same hazards generated from various power plant operations.

16 Minority and low-income populations could be affected by the construction and operation of a
17 new natural gas-fired power plant. Some of these effects have been identified in resource areas
18 discussed in this section. For example, increased demand for rental housing during construction
19 could disproportionately affect low-income populations. Nevertheless, impacts on minority and
20 low-income populations from the construction and operation of a natural gas-fired power plant
21 alternative could range from SMALL to MODERATE.

22 **8.2.7 Waste Management**

23 During the construction stage of the natural gas-fired combined-cycle generation alternative,
24 land clearing and other construction activities would generate waste that can be recycled,
25 disposed onsite or shipped to the offsite waste disposal facility. Because the alternative would
26 be constructed on the previously disturbed CNS-1 site, the amounts of wastes produced during
27 land clearing would be reduced.

28 During operational stage, spent SCR catalysts, which are used to control NO_x emissions from
29 the natural gas-fired plants, would make up the majority of the waste generated by this
30 alternative.

31 The NRC staff concluded in the GEIS (NRC, 1996), that natural gas-fired plant would generate
32 minimal waste and the waste impacts would be SMALL for a natural gas-fired alternative
33 located at CNS-1 site or offsite.

34 Table 8-2 provides a summary of the environmental impacts of the natural gas-fired alternative
35 compared to continued operation of CNS-1.

1 **Table 8-2. Summary of Environmental Impacts of the Natural Gas-Fired Combined-Cycle**
 2 **Generation Alternative Compared to Continued Operation of CNS-1**

	Natural Gas Combined-Cycle Generation	Continued CNS-1 Operation
Air quality	SMALL to MODERATE	SMALL
Ground water	SMALL	SMALL
Surface water	SMALL	SMALL
Aquatic and terrestrial resources	SMALL to MODERATE	SMALL
Human health	SMALL	SMALL
Socioeconomics	SMALL to MODERATE	SMALL
Waste management	SMALL	SMALL

3 **8.3 COMBINATION ALTERNATIVE**

4 In this section, the environmental impacts of a combination of alternatives are evaluated. This
 5 combination will include a portion of the combined-cycle gas-fired capacity identified in Section
 6 8.2, an energy conservation capacity component, and a wind power component. This alternative
 7 requires new construction of a single gas-fired unit installed at the CNS-1 site and the
 8 construction of roughly 250 wind turbines at an offsite location, or several different offsite
 9 locations.

10 In this alternative, a portion of CNS-1's output—250 MWe—would be replaced by conservation.
 11 Inclusion of this conservation component of the alternative is based on Nebraska's energy
 12 efficiency goals for the year 2012. Wind turbines constructed offsite will account for roughly 150
 13 MWe of capacity and 400 MWe will come from one GE S107H combined-cycle power plant. The
 14 only major construction anticipated is at the current CNS-1 site where the combined-cycle gas-
 15 fired power plant would be constructed and the wind turbine construction at an offsite location
 16 (including the right of way for new transmission lines). No major construction should be
 17 necessary for the conservation portion.

18 The appearance of the gas-fired facility would be similar to that of the full gas-fired alternative
 19 considered in Section 8.2, though only one unit would be constructed. The NRC staff estimates
 20 that it would require about 50 percent of the space necessary for the alternative considered in
 21 Section 8.2, and that all construction effects—as well as operational aesthetic, fuel-cycle, air
 22 quality, socioeconomic, land use, environmental justice, and water consumption effects—will
 23 scale accordingly.

24 **8.3.1 Air Quality**

25 Nemaha County, Nebraska, where CNS-1 is located, is in EPA Region 7. All counties in the
 26 State of Nebraska are in attainment for all criteria pollutants. Douglas County is a maintenance
 27 county for lead. NDEQ is responsible for managing and monitoring air quality in the State of
 28 Nebraska.

29 This alternative is a combination of one 400-MWe natural gas-fired combined-cycle generating
 30 unit, constructed onsite, 250 MWe equivalent of conservation and demand-side management,
 31 and 500 MWe of wind capacity constructed offsite, possibly at several different locations.

Environmental Impacts of Alternatives

1 A new gas-fired generating plant on the CNS-1 site would qualify as a new major-emitting
2 industrial facility and require an NSR under CAA. Nebraska air quality regulations require s that
3 a permit must be obtained before construction of the new major-emitting industrial facility which
4 will be issued only if the new plant includes pollution control measures that reflect the best
5 available control technology (BACT). The natural gas-fired plant must comply with the standards
6 of performance for electric utility steam generating units set forth in 40 CFR Part 60 Subpart Da.

7 Subpart P of 40 CFR Part 51 contains the visibility protection regulatory requirements, including
8 the review of the new sources that would be constructed in the attainment or unclassified areas
9 and may affect visibility in any Federal Class I area (40 CFR §51.307). If a gas-fired unit were
10 located close to a mandatory Class I area, additional air pollution control requirements would
11 imply. There are no mandatory Class I Federal areas in the State of Nebraska. The closest is
12 Hercules-Glades Wilderness Area, which is located 295 miles southeast of CNS-1 in the State
13 of Missouri.

14 According to published EIA data, the EPA emission factors, performance characteristics for this
15 alternative and implemented emission controls, emissions from the one natural gas-fired unit
16 with a capacity of 400 MWe built at CNS-1 site would be:

- 17 • Sulfur oxides (SO_x) – 30 tons (27 MT) per year
- 18 • Nitrogen oxides (NO_x) (with SCR) – 96 tons (87 MT) per year
- 19 • Carbon monoxide (CO) – 20 tons (18 MT) per year
- 20 • Total suspended particles (TSP) – 17 tons (15 MT) per year
- 21 • Particulate matter (PM) PM₁₀ – 17 tons (15 MT) per year
- 22 • Carbon dioxide (CO₂) – 1,030,000 tons (964,000 MT) per year

23 The natural gas-fired component of this alternative would emit 17 tons (15. MT) per year of
24 particulate matter having an aerodynamic diameter less than, or equal to, 10 µm (PM₁₀).

25 In December 2000, the EPA issued regulatory findings (EPA, 2000) on emissions of hazardous
26 air pollutants from electric utility steam-generating units. The findings show that natural gas-fired
27 plants emit HAPs such as arsenic, formaldehyde, and nickel, and state that:

28 Also in the utility RTC (Report to Congress, the impacts due to HAP emissions
29 from natural gas-fired electric utility steam generating units were negligible based
30 on the results of the study. The Administrator finds that regulation of HAP
31 emissions from natural gas-fired electric utility steam generating units is not
32 appropriate or necessary.

33 The new natural gas-fired alternative would produce 16.77 tons (15.21 MT) per year of TSP, all
34 of which would be emitted as PM₁₀ emissions.

35 The natural gas-fired plant would have to comply with CAA reduction requirements for SO₂ and
36 NO_x (42 U.S.C. §7401 et seq.), which are the main precursors of acid rain and major causes of
37 reduced visibility. Title IV establishes maximum SO₂ and NO_x emission rates from the existing

1 plants and a system of the SO₂ emission allowances that can be used, sold, or saved for future
2 use by the new plants.

3 As stated above, the new natural gas-fired unit would produce 30.01 tons (27.23 MT) per year
4 of SO_x and 96.21 tons (87.28 MT) per year of NO_x based on the use of the dry low NO_x
5 combustion technology and use of the SCR in order to significantly reduce NO_x emissions.

6 The natural gas-fired component of this alternative would be subjected to the continuous
7 monitoring requirements of SO₂, NO_x, and CO₂ specified in 40 CFR Part 75. The natural gas-
8 fired plant would emit approximately 1.0 million tons (approximately 0.9 million MT) per year of
9 unregulated CO₂ emissions. In response to the Consolidated Appropriations Act of 2008, the
10 EPA has proposed a rule that requires mandatory reporting of GHG emissions from large
11 sources (applicable to the presented alternative) in the United States that would allow collection
12 of accurate and comprehensive emissions data to inform future policy decisions. EPA proposes
13 that suppliers of fossil fuels or industrial GHGs, manufacturers of vehicles and engines, and
14 facilities that emit 25,000 MT or more per year of GHG emissions submit annual reports to the
15 EPA. The gases covered by the proposed rule are CO₂, CH₄, N₂O, HFC, PFC, SF₆ and other
16 fluorinated gases including NF₃ and HFE. NPPD states in the "Statement on Addressing the
17 Challenge of Global Climate Change" that it is voluntarily engaged in lowering the GHG
18 emissions (NPPD, 2008). In the "2008 Integrated Resource Plan," NPPD outlines the
19 environmental goals of the company with emphasis on lowering GHG emissions and obtaining
20 10 percent of the energy supply from renewable resources by 2020, wind being primarily the
21 source of power (NPPD, 2008).

22 There would be no operating emissions from the wind or conservation components of the
23 combination alternative.

24 Activities associated with the construction of the new natural gas-fired plant onsite at CNS-1 and
25 wind turbines offsite would cause some additional air effects as a result of equipment emissions
26 and fugitive dust from operation of the earth-moving and material handling equipment. Vehicles
27 of workers and construction motorized equipment exhaust emissions would be temporary. The
28 construction crews would employ dust-control practices in order to control and reduce fugitive
29 dust, which would be temporary in nature. The NRC staff concludes that the impact of vehicle
30 exhaust emissions and fugitive dust from operation of earth-moving and material handling
31 equipment would be designated as SMALL. Implementation of the conservation portion of this
32 alternative would have no noticeable effects on air quality, though some weatherization
33 programs may cause existing indoor air quality problems to become worse.

34 The overall air-quality impacts of the combination alternative consisting of a natural gas-fired
35 plant located at CNS-1 site, energy conservation, and an offsite wind component would be in
36 the range of SMALL to MODERATE.

37 **8.3.2 Ground Water Use and Quality**

38 If the onsite gas-fired plant continued to use ground water for drinking water and service water,
39 the total usage would likely be much less than CNS-1 uses, because fewer workers are onsite
40 and because the gas-fired unit would have fewer auxiliary systems requiring service water. The
41 current average withdrawal rate is 250 gpm, and pumping tests indicate this rate would not
42 cause an effect on nearby supply wells. A reduction in this withdrawal rate means that impacts
43 of the combination alternative would remain SMALL.

1 **8.3.3 Surface Water Use and Quality**

2 Using a combined alternative with conservation as a major component will reduce the amount of
3 surface water consumed for cooling purposes from the already low consumption of the wholly
4 gas-fired alternative considered in Section 8.2. The maximum consumptive use would be
5 reduced to a fraction of the surface water withdrawn by the open-cycle cooling system currently
6 in use by CNS-1. This represents less than 0.001 percent of the average annual flow rate in the
7 Missouri River. The impact of this withdrawal would be SMALL.

8 **8.3.4 Aquatic and Terrestrial Ecology**

9 8.3.4.1 *Aquatic Ecology*

10 In order to minimize impacts, NRC assumes that the cooling system for this gas-fired plant
11 would involve closed-cycle cooling. The wind and conservation components would have no
12 associated impingement, entrainment, and thermal impacts. The number of fish and other
13 aquatic resource organisms affected by impingement, entrainment, and other impacts will be
14 less than those associated with license renewal because water consumption and heat injected
15 to the Missouri River would be substantially lower. Some temporary impacts to aquatic
16 organisms might occur due to any construction that might occur or due to any effluent
17 discharges to the river, but these activities would be monitored by the NDEQ under the project's
18 NPDES permit. Although the number of affected organisms would be substantially less than for
19 license renewal, the NRC level of impact for license renewal is already designated as SMALL,
20 and so NRC expects that the impact for impingement, entrainment, and thermal effects would
21 also be SMALL.

22 8.3.4.2 *Terrestrial Ecology*

23 A combination alternative of a single natural gas-fired unit, a system using wind energy, and
24 energy conservation would make use of existing disturbed land and possibly some farmland at
25 the CNS-1 site for the natural gas unit and the mechanical draft cooling tower. This alternative
26 would also require land offsite for the gas pipeline and would require additional land offsite to
27 accommodate the number of turbines necessary in a wind farm to offset the power generated by
28 CNS-1.

29 This alternative would use a portion of the existing plant site land, switchyard, and transmission
30 line system for construction of the gas-fired unit. Approximately 45 ac (18 ha) of land would be
31 required on the CNS-1 site to support a 400 MWe natural gas plant.

32 Impacts to terrestrial ecology from onsite construction of a single gas-fired unit with one
33 mechanical draft cooling tower would be less than the impacts described for the two-unit gas-
34 fired alternative. The impacts to farmland onsite would be approximately one-half of the impacts
35 of the two-unit natural gas plant alternative. The drainage patterns of the wetland areas onsite
36 may also be impacted, though again to a lesser degree than the two-unit gas alternative. These
37 onsite impacts are expected to be minor. Impacts to terrestrial ecology from offsite construction
38 of the 40-mile (64-km) long gas pipeline for a single gas-fired unit would be the same as for the
39 two gas-fired unit alternative previously discussed (NPPD, 2008).

40 Based upon data in the GEIS, the wind farm component of the combination alternative
41 producing 500 MWe of electricity would require approximately 32,000 acres (12,950 ha) spread
42 over several offsite locations, with approximately 125 acres (51 ha) in actual use. The remainder

1 of the land would remain in agriculture. Additional land may be needed for construction of
2 transmission line corridors to connect to existing transmission line corridors.

3 Impacts to terrestrial ecology from construction of the wind farm portion of the combination
4 alternative and any needed transmission lines could include loss of terrestrial habitat, an
5 increase in habitat fragmentation and a corresponding increase in edge habitat, and may impact
6 threatened and endangered species. The GEIS notes that habitat fragmentation may lead to a
7 decline in migrant bird populations. Bird mortality would increase from construction of the wind
8 farm, although proper site selection for the wind farm could help to reduce bird strikes. The
9 GEIS noted that wind farms typically do not cause significant adverse impacts to bird
10 populations, although thousands of acres of wildlife habitat or agricultural land could be
11 impacted, and disruptions could occur to wildlife migratory routes (NRC, 1996).

12 Based on this information, impacts to terrestrial resources could range from MODERATE to
13 LARGE.

14 **8.3.5 Human Health**

15 The human health risks from a combination of alternatives include the effects already discussed
16 in Section 8.2.5 for the combined cycle gas-fired plant. The GEIS (NRC, 1996) notes that the
17 environmental impacts of conservation and a demand-side management alternative are likely to
18 be centered on indoor air quality. This is due to increased weatherization of the home in the
19 form of extra insulation and reduced air turnover rates from the reduction in air leaks; however,
20 the actual impact from the conservation alternative is highly site specific and not yet well-
21 established. For wind capacity, the GEIS notes that, except for a potential small number of
22 occupational injuries, human health would not be affected by routine operations.

23 The human health risks from the combination of alternatives, although uncertain, are considered
24 to be SMALL to MODERATE given that the construction and operation of the facilities are
25 expected to comply with health-based Federal and State safety and emission standards.

26 **8.3.6 Socioeconomics**

27 **8.3.6.1 Land Use**

28 The GEIS generically evaluates the impacts of nuclear power plant operations on land use both
29 on and off each power plant site. The analysis of land use impacts for combination alternative
30 focuses on the amount of land area that would be affected by the construction and operation of
31 a single natural gas-fired unit power plant at the CNS-1 site and at an offsite wind energy
32 generating facility, and demand-side energy conservation.

33 Based on GEIS estimates, approximately 45 acres (18 ha) would be needed to support the
34 single natural gas-fired unit portion of the combination alternative. Land use impacts from
35 construction of the natural gas-fired power plant at CNS-1 would be designated as SMALL.

36 In addition to onsite land requirements, land would be required offsite for natural gas wells and
37 collection stations. Scaling from GEIS estimates, the natural gas-fired power plant at the CNS-1
38 could require 1,469 acres (594 ha) for wells, collection stations, and pipelines to bring the gas to
39 the facility. Most of this land requirement would occur on land where gas extraction already
40 occurs. In addition, some natural gas could come from outside of the United States and be
41 delivered as liquefied gas.

Environmental Impacts of Alternatives

1 The wind farm component of the combination alternative producing 500 MWe of electricity
2 would require approximately a 32,000-acre (12,950-ha) spread over several locations with
3 approximately 125 acres (51 ha) in actual use.

4 Land use impacts of an energy efficiency alternative would be designated as SMALL. Quickly
5 replacing and disposing old inefficient equipment could generate waste material and increase
6 the size of landfills; however, given the time for program development and implementation, the
7 cost of replacements, and the average life of equipment, the replacement process would
8 probably be gradual. Older equipment would simply be replaced by more efficient equipment
9 (especially in the case of frequently replaced items, such as light bulbs). In addition, many items
10 (such as home appliances and industrial equipment) have recycling value and would probably
11 not be disposed of in landfills.

12 The elimination of uranium fuel for CNS-1 could partially offset offsite land requirements.
13 Scaling from GEIS estimates, approximately 816 acres (330 ha) would not be needed for mining
14 and processing uranium during the operating life of the plant. Overall land use impacts from the
15 combination alternative would range from SMALL to MODERATE.

16 8.3.6.2 *Socioeconomics*

17 As previously discussed, socioeconomic impacts are defined in terms of changes to the
18 demographic and economic characteristics and social conditions of a region. For example, the
19 number of jobs created by the construction and operation of a new single natural
20 gas-fired power plant at CNS-1 and the wind farm could affect regional employment, income,
21 and expenditures. Job creation is characterized by two types: (1) construction-related jobs,
22 which are transient, short in duration, and less likely to have a long-term socioeconomic impact;
23 and (2) operation-related jobs in support of power generating operations, which have a greater
24 potential for permanent, long-term socioeconomic impacts. The NRC staff conducted
25 evaluations of construction and operations workforce requirements in order to measure their
26 effect on current socioeconomic conditions.

27 Based on GEIS projections and a workforce of 1,200 for a 1,000-MWe plant, a single 400 MWe
28 unit at CNS-1 requires a peak estimated construction workforce of 490. Additional estimated
29 construction workforce requirements for this combination alternative include 300 construction
30 workers for the wind farm. The number of additional workers would cause a short-term increase
31 in the demand for services and temporary (rental) housing in the region around the construction
32 site.

33 After construction and depending on the size of the community, some local communities may be
34 temporarily affected by the loss of the construction jobs and associated loss in demand for
35 business services. The rental housing market could also experience increased vacancies and
36 decreased prices. The impact of construction on socioeconomic conditions would be designated
37 as SMALL.

38 Following construction, a single-unit gas-fired power plant at CNS-1 could provide up to 63 jobs,
39 based on NPPD estimates, or up to 64 jobs, based on GEIS estimates. Additional estimated
40 operations workforce requirements for this combination alternative include 50 operations
41 workers for the wind farm. Given the small numbers of operations workers at these facilities,
42 socioeconomic impacts associated with the operation of the natural gas-fired power plant at
43 CNS-1 and the wind farm would be designated as SMALL.

1 Socioeconomic effects of an energy efficiency program would be SMALL. As noted in the GEIS,
2 the program would require additional workers. Lower-income families could benefit from
3 weatherization and insulation programs. This effect would be greater than the effect for the
4 general population because low-income households experience home energy burdens more
5 than four times larger than the average household (OMB, 2007).

6 8.3.6.3 *Transportation*

7 Transportation impacts would be SMALL because the number of employees commuting to the
8 CNS-1 site, where the gas-fired portion is located, would be small. Any transportation effects
9 from the energy efficiency alternative would be widely distributed across the state, and would
10 not be noticeable.

11 Construction and operation of a natural gas-fired power plant and wind farm would increase the
12 number of vehicles on the roads in the vicinity of these facilities. During construction, cars and
13 trucks would deliver workers, materials, and equipment to the worksites. The increase in
14 vehicular traffic would peak during shift changes resulting in temporary levels of service impacts
15 and delays at intersections. Pipeline construction and modification to existing natural gas
16 pipeline systems could also have an impact. Highway delivery of large wind farm components
17 may also cause impacts to traffic.

18 During plant operations, transportation impacts would almost disappear. Given the small
19 numbers of operations workers at these facilities, levels of service impacts on local roads from
20 the operation of the natural gas-fired power plant at CNS-1 and at the wind farm, would be
21 SMALL. Transportation impacts at the wind farm site would also depend on current road
22 capacities and average daily traffic volumes.

23 8.3.6.4 *Aesthetics*

24 The aesthetics impact analysis focuses on the degree of contrast between the surrounding
25 landscape and the visibility of the power plant.

26 A single natural gas-fired unit located at CNS-1 would be approximately 100 feet (30 m) tall with
27 an exhaust stack of at least 175 feet (53 m) tall, which is less noticeable than the current CNS-1
28 reactor building at 290 feet (88 m). The impact would be moderated as higher elevations and
29 vegetation along the river valley could make it difficult to see or hear the power plant outside of
30 the river valley. Power plant infrastructure would generally be smaller and less noticeable than
31 the CNS-1 containment and turbine buildings. Mechanical draft cooling towers (if used) would
32 generate condensate plumes and operational noise, which during power plant operations would
33 be limited to noise from industrial processes and communications. In addition to power plant
34 structures, construction of natural gas pipelines would have a short-term impact. Noise from the
35 pipelines could be audible offsite near compressors.

36 Impacts from energy efficiency programs would be SMALL. Some noise impacts could occur in
37 instances of energy efficiency upgrades to major building systems, although this impact would
38 be intermittent and short-lived.

39 In general, aesthetic changes would be limited to the immediate vicinity of the CNS-1 site and
40 the wind farm facilities. The wind farm would have the greatest aesthetic effect. Compared to a
41 fossil-fueled power plant unit on 46 to 1,400 acres, the 250 wind turbines at over 300 feet (100
42 m) tall and spread across multiple sites covering 32,000 acres (13,000 ha) may, in some
43 locations, dominate the view and be a major focus of viewer attention. The overall impact,

Environmental Impacts of Alternatives

1 however, would depend on the sensitivity of the people living around the area of the site;
2 therefore, overall aesthetic impacts from the construction and operation of this combination
3 alternative would be SMALL to MODERATE.

4 8.3.6.5 *Historic and Archaeological Resources*

5 Cultural resources are the indications of human occupation and use of the landscape as defined
6 and protected by a series of Federal laws, regulations, and guidelines. Prehistoric resources are
7 physical remains of human activities that predate written records; they generally consist of
8 artifacts that may alone or collectively yield information about the past. Historic resources
9 consist of physical remains that postdate the emergence of written records; in the United States,
10 they are architectural structures or districts, archaeological objects, and archaeological features
11 dating from 1492 and later. Ordinarily, sites less than 50 years old are not considered historic,
12 but exceptions can be made for such properties if they are of particular importance, such as
13 structures associated with the development of nuclear power or Cold War themes. American
14 Indian resources are sites, areas, and materials important to American Indians for religious or
15 heritage reasons. Such resources may include geographic features, plants, animals, burial
16 grounds, battlefields, trails, and environmental features. The cultural resource analysis
17 encompassed the power plant site and adjacent areas that could potentially be disturbed by the
18 construction and operation of alternative power plants.

19 The potential for historic and archaeological resources can vary greatly depending on the
20 location of the proposed site. To consider a project's effects on historic and archaeological
21 resources, any proposed areas will need to be surveyed to identify and record historic and
22 archaeological resources, identify cultural resources (e.g., traditional cultural properties), and
23 develop possible mitigation measures to address any adverse effects from ground disturbing
24 activities. Studies will be needed for all areas of potential disturbance at the proposed plant site
25 and along associated corridors where new construction will occur (e.g., roads, transmission
26 corridors, rail lines, or other ROWs). In most cases, project proponents should avoid areas with
27 the greatest sensitivity.

28 The impact for a single-unit natural gas-fired alternative at the CNS-1 site would be SMALL. As
29 noted in Section 4.9.6, NPPD conducted a Phase 1A survey of the CNS-1 site in 2007 and
30 2008. NPPD has also developed a Cultural Resources Protection Plan which calls for surveys to
31 be conducted by a qualified archaeologist in areas deemed sensitive prior to work commencing.
32 The plan also includes an inadvertent discovery (stop work) provision to ensure that proper
33 notification is taken to protect these resources should they be discovered. Depending on the
34 resource richness of an alternative site or sites ultimately chosen for the wind farm alternative,
35 impacts could range from SMALL to MODERATE.

36 Impacts to historic and archaeological resources from implementing the energy efficiency
37 programs would be SMALL. A conservation alternative would not affect land use or historical or
38 cultural resources onsite or elsewhere in the state.

39 8.3.6.6 *Environmental Justice*

40 The environmental justice impact analysis evaluates the potential for disproportionately high and
41 adverse human health and environmental effects on minority and low-income populations that
42 could result from the construction and operation of a new natural gas-fired power plant and wind
43 farm. Adverse health effects are measured in terms of the risk and rate of fatal or nonfatal
44 adverse impacts on human health. Disproportionately high and adverse human health effects
45 occur when the risk or rate of exposure to an environmental hazard for a minority or low-income

1 population is significant and exceeds the risk or exposure rate for the general population or for
 2 another appropriate comparison group. The minority and low-income populations are subsets of
 3 the general public residing around the site, and all are exposed to the same hazards generated
 4 from various power plant operations.

5 Minority and low-income populations could be affected by the construction and operation of a
 6 new natural gas-fired power plant and wind farm. Some of these effects have been identified in
 7 resource areas discussed in this section. For example, increased demand for rental housing
 8 during construction could disproportionately affect low-income populations.

9 Weatherization programs could target low-income residents as a cost-effective energy efficiency
 10 option since low-income populations tend to spend a larger proportion of their incomes paying
 11 utility bills (according to the Office of Management and Budget (OMB), low income populations
 12 experience energy burdens more than four times as large as those of average households
 13 (OMB, 2007)). Impacts to minority and low-income populations from energy efficiency programs
 14 would be SMALL, depending on program design and enrollment.

15 Impacts on minority and low-income populations under the combination alternative could range
 16 from SMALL to MODERATE, due to the small number of workers needed to construct and
 17 operate the natural gas-fired power plant and wind farm.

18 **8.3.7 Waste Management**

19 During the construction stage of this combination of alternative, land clearing and other
 20 construction activities would generate wastes that can be recycled, disposed onsite or shipped
 21 to the offsite waste disposal facility. During the operational stage, spent SCR catalysts, which
 22 are used to control NO_x emissions from the natural gas-fired plants, would make up the majority
 23 of the waste generated by this alternative.

24 There will be an increase in wastes generated during installation or implementation of
 25 conservation measures, such as appropriate disposal of old appliances, installation of control
 26 devices and building modifications. New and existing recycling programs would help to minimize
 27 the amount of generated waste.

28 The NRC staff concludes that overall waste impacts from the combination of the natural gas-
 29 fired unit constructed onsite, wind capacity, and conservation are SMALL.

30 Table 8-3 provides a summary of the environmental impacts of the combined alternative
 31 compared to continued operation of CNS-1.

1 **Table 8-3. Summary of Environmental Impacts of the Combination Alternative Compared**
 2 **to Continued Operation of CNS 1**

	Combination Alternative	Continued CNS-1 Operation
Air quality	SMALL to MODERATE	SMALL
Ground water	SMALL	SMALL
Surface water	SMALL	SMALL
Aquatic and terrestrial resources	SMALL to LARGE	SMALL
Human health	SMALL to MODERATE	SMALL
Socioeconomics	SMALL to MODERATE	SMALL
Waste management	SMALL	SMALL

3 **8.4 ALTERNATIVES CONSIDERED BUT DISMISSED**

4 In this section, the NRC staff presents the alternatives it initially considered for analysis as
 5 alternatives to license renewal of CNS-1, but later dismissed due to technical, resource
 6 availability, or commercial limitations that currently exist and that the NRC staff believes are
 7 likely to continue to exist when the existing CNS-1 license expires. Under each of the following
 8 technology headings, the NRC staff indicates why it dismissed each alternative from further
 9 consideration. Offsite coal and gas-fired alternatives were not considered because the NRC
 10 staff determined that a possibly undisturbed offsite location would generally generate larger
 11 impacts than either alternative constructed at the previously disturbed CNS-1 site.

12 **8.4.1 Offsite Coal- and Gas-Fired Capacity**

13 While it is possible that coal- and gas-fired alternatives like those considered in Sections 8.1
 14 and 8.2, respectively, could be constructed at sites other than CNS-1, the NRC staff determined
 15 that they would result in greater impacts than alternatives constructed at the CNS-1 site.
 16 Greater impacts would occur from construction of support infrastructure, like transmission lines,
 17 roads, and railway spurs that are already present on the CNS-1 site. Further, the community
 18 around CNS-1 is already familiar with the appearance of a power facility and it is an established
 19 part of the region's aesthetic character. Workers skilled in power plant operations would also be
 20 available in this area. The availability of these factors is only likely to be available on other
 21 recently-industrial sites. In cases where recently-industrial sites exist, other remediation may
 22 also be necessary in order to make the site ready for redevelopment. In short, an existing power
 23 plant site would present the best location for a new power facility.

24 **8.4.2 Coal-Fired Integrated Gasification Combined-Cycle**

25 While utilities across the United States have considered or are considering plans for integrated
 26 gasification combined-cycle (IGCC) coal-fired power plants, few IGCC facilities have yet been
 27 constructed. All facilities constructed in the United States to date have been smaller than CNS-
 28 1. The technology, however, is commercially available and relies on a gasifier stage and a
 29 combined-cycle stage. Existing combined-cycle facilities (like the ones considered in Section
 30 8.2) could be used as a part of an IGCC alternative.

31 EIA indicates that IGCC and other advanced coal plants may become increasingly common in
 32 coming years, though uncertainties about construction time periods and commercial viability in
 33 the near future lead NRC staff to believe that IGCC is an unlikely alternative to CNS-1 license

1 renewal (EIA, 2009). For plants whose licenses expire at later dates, IGCC (with or without
2 carbon capture and storage) may prove to be a viable alternative.

3 **8.4.3 New Nuclear**

4 In its ER, NPPD indicated that it is unlikely that a nuclear alternative could be sited, constructed,
5 and operational by the time CNS-1's operating license expires in 2014 (NPPD, 2008). Sources
6 in the nuclear industry have recently indicated that reactor projects currently under development
7 are probably eight or nine years from completion (Nucleonics Week, 2008), or possibly online in
8 the 2016–2017 timeframe. A plant currently under development would also require additional
9 time to develop an application. Given the relatively short time remaining on the current CNS-1
10 operating license, NRC staff has not evaluated new nuclear generation as an alternative to
11 license renewal.

12 **8.4.4 Energy Conservation and Energy Efficiency**

13 Though often used interchangeably, energy conservation and energy efficiency are different
14 concepts. Energy efficiency means deriving a similar level of services by using less energy,
15 while energy conservation indicates a reduction in energy consumption. Both fall into a larger
16 category known as demand-side management. Demand-side management measures address
17 energy end uses—unlike energy supply alternatives discussed in previous sections. Demand-
18 side management can include measures that (1) shift energy consumption to different times of
19 the day to reduce peak loads, (2) interrupt certain large customers during periods of high
20 demand, (3) interrupt certain appliances during high demand periods (4) replace older, less
21 efficient appliances, lighting, or control systems (5) encourage customers to switch from gas to
22 electricity for water heating and other similar measures that utilities use to boost sales.

23 Unlike other alternatives to license renewal, the GEIS notes that conservation is not a discrete
24 power generating source; it represents an option that States and utilities may use to reduce their
25 need for power generation capability (NRC, 1996).

26 While NPPD does state that demand-side management is encouraged by the utility, and that in
27 2007 there was over 500 MWe demand reduction (NPPD, 2008), it is unlikely that increased
28 energy efficiency in the State of Nebraska will have grown enough to offset the loss of CNS-1 by
29 the license expiration in 2014. Because of this, the NRC staff has not evaluated energy
30 conservation and efficiency as a discrete alternative to license renewal. It has, however, been
31 considered as a component of the combination alternative.

32 **8.4.5 Purchased Power**

33 In its ER, NPPD indicated that purchased electrical power is, in theory, a potential alternative to
34 CNS-1 license renewal; however, for the 2014 to 2034 time frame of CNS-1's renewal, there are
35 no guaranteed available power sources to replace the 816 MWe that CNS-1 provides. NPPD
36 indicates that most of its purchased power supply is imported from Canada, which is expected
37 to decrease over the next two decades. Within the State of Nebraska, two newly licensed coal-
38 fired plants starting production in 2009 and 2012 combined will barely meet the amount of
39 electricity currently provided by CNS-1. Because of the lack of assured availability of purchased
40 electrical power, the NRC staff has not evaluated purchased power as an alternative to license
41 renewal.

1 **8.4.6 Solar Power**

2 Solar technologies use the sun's energy to produce electricity. Currently, the CNS-1 site
3 receives approximately 3.8 to 4.2 kilowatt hours (kWh) per square meter per day, as does most
4 of the eastern portion of Nebraska (NREL, 2008), for solar collectors oriented at an angle equal
5 to the installation's latitude. Since flat-plate photovoltaics tend to be roughly 25 percent efficient,
6 a solar-powered alternative will require at least 11,620 acres (4,700 ha) of collectors to provide
7 an amount of electricity equivalent to that generated by CNS-1. Space between parcels and
8 associated infrastructure increase this land requirement. This amount of land, while large, is
9 consistent with the land required for coal and natural gas fuel cycles. In the GEIS, the NRC staff
10 noted that, by its nature, solar power is intermittent (i.e., it does not work at night and cannot
11 serve baseload when the sun is not shining), and the efficiency of collectors varies greatly with
12 weather conditions. A solar-powered alternative will require energy storage or backup power
13 supply to provide electric power at night. Given the challenges in meeting baseload
14 requirements, the NRC staff did not evaluate solar power as an alternative to license renewal of
15 CNS-1.

16 **8.4.7 Biomass Waste**

17 In 1999, DOE researchers estimated that Nebraska has biomass fuel resources consisting of
18 forest, mill, agricultural, and urban residues, as well as energy crop potential. Excluding
19 potential energy crops, DOE researchers projected that Nebraska had 16,634,800 tons
20 (15,091,000 MT) of plant-based biomass available at 50 dollars per ton delivered (Walsh, et al.,
21 2000; costs are in 1995 dollars). The Bioenergy Feedstock Development Program at Oak Ridge
22 National Laboratory estimates that each air-dry pound of wood residue produces approximately
23 6,400 BTU of heat (ORNL, 2007). Assuming a 33 percent conversion efficiency, using all
24 biomass available in Nebraska at 50 dollars per ton—the maximum price the researchers
25 considered—would generate roughly 20.6 terawatt hours of electricity.

26 Walsh, et al. (2000), note that these estimates of biomass capacity contain substantial
27 uncertainty, and that potential availability does not mean biomass will actually be available at
28 the prices indicated or that resources will be useably free of contamination. Some of these plant
29 wastes already have reuse value, and would likely be more costly to deliver because of
30 competition. Others, such as forest residues, may prove unsafe and unsustainable to harvest on
31 a regular basis (the vast majority of biomass capacity in Nebraska, however, comes from
32 agricultural residues, with very little potential from forest residues). It is likely that the available
33 resource potential is much less than the estimate totals in Walsh, et al., and the total resource is
34 not likely to be sufficient to substitute for the capacity provided by CNS-1. As a result, the NRC
35 staff has not considered a biomass-fired alternative to CNS-1 license renewal.

36 **8.4.8 Hydroelectric Power**

37 According to researchers at Idaho National Energy and Environmental Laboratory (INEEL),
38 Nebraska has an estimated 345 MWe of technically available, undeveloped hydroelectric
39 resources at 45 sites throughout the State (INEEL, 1997). Most of these sites have a potential
40 capacity of less than 1 MWe, although the largest site in Nebraska is capable of providing 22
41 MWe. Given that the available hydroelectric potential in the State of Nebraska constitutes less
42 than one-half of the generating capacity of CNS-1, the NRC staff did not evaluate hydropower
43 as an alternative to license renewal.

1 **8.4.9 Wave and Ocean Energy**

2 Wave and ocean energy has generated considerable interest in recent years. Ocean waves,
3 currents, and tides are often predictable and reliable. Ocean currents flow consistently, while
4 tides can be predicted months and years in advance with well-known behavior in most coastal
5 areas. Most of these technologies are in relatively early stages of development, and while some
6 results have been promising, they are not likely to be able to replace the capacity of CNS-1 by
7 the time its license expires. While testing of new technologies to produce electricity from the
8 ocean continues, and because the CNS-1 site is located far from any ocean, the NRC did not
9 consider wave and ocean energy as an alternative to CNS-1 license renewal.

10 **8.4.10 Geothermal Power**

11 Although geothermal energy has an average capacity factor of 90 percent and can be used for
12 baseload power where available, geothermal electric generation is limited by the geographical
13 availability of geothermal resources (NRC, 1996). Nebraska has some geothermal potential in a
14 heating and thermal capacity, but it does not have geothermal electricity potential for
15 development (DOE, 2007). The NRC staff concluded that geothermal energy is not a
16 reasonable alternative to license renewal at CNS-1.

17 **8.4.11 Municipal Solid-Waste**

18 Municipal solid-waste combustors use three types of technologies—mass burn, modular, and
19 refuse-derived fuel. Mass burning is used most frequently in the United States and involves little
20 sorting, shredding, or separation. Consequently, toxic or hazardous components present in the
21 waste stream are combusted, and toxic constituents are exhausted to the air or become part of
22 the resulting solid wastes. Currently, approximately 89 waste-to-energy plants operate in the
23 United States. These plants generate approximately 2,700 MWe, or an average of 30 MWe per
24 plant (Integrated Waste Services Association, 2007). More than 27 average-sized plants will be
25 necessary to provide the same level of output as the other alternatives to CNS-1 license
26 renewal.

27 Estimates in the GEIS suggest that the overall level of construction impact from a
28 waste-fired plant will be approximately the same as that for a coal-fired power plant.
29 Additionally, waste-fired plants have the same or greater operational impacts than coal-fired
30 technologies (including impacts on the aquatic environment, air, and waste disposal). The initial
31 capital costs for municipal solid-waste plants are greater than for comparable
32 steam-turbine technology at coal-fired facilities or at wood-waste facilities because of the need
33 for specialized waste separation and handling equipment (NRC, 1996).

34 The decision to burn municipal waste to generate energy is driven by the need for an alternative
35 to landfills rather than energy considerations. The use of landfills as a waste disposal option is
36 likely to increase as energy prices increase; however, it is possible that municipal waste
37 combustion facilities may become attractive again.

38 Regulatory structures that once supported municipal solid-waste incineration no longer exist.
39 The Tax Reform Act of 1986 made capital-intensive projects such as municipal-waste
40 combustion facilities more expensive relative to less expensive waste disposal alternatives such
41 as landfills. Also, the 1994 Supreme Court decision *C&A Carbone, Inc. v. Town of Clarkstown*,
42 New York, struck down local flow control ordinances that required waste to be delivered to
43 specific municipal waste combustion facilities rather than landfills that may have had lower fees.

Environmental Impacts of Alternatives

1 In addition, environmental regulations have increased the cost to construct and maintain
2 municipal waste combustion facilities.

3 Given the small average installed size of municipal solid-waste plants and the unfavorable
4 regulatory environment, the NRC staff does not consider municipal solid-waste combustion to
5 be a feasible alternative to CNS-1 license renewal.

6 **8.4.12 Biofuels**

7 In addition to wood and municipal solid-waste fuels, there are other concepts for
8 biomass-fired electric generators, including conversion to liquid biofuels and biomass
9 gasification. In the GEIS, the NRC staff indicates that none of these technologies progressed to
10 the point of being competitive on a large scale or of being reliable enough to replace a baseload
11 plant such as CNS-1. After reevaluating current technologies, the NRC staff finds other
12 biomass-fired alternatives as still unable to reliably replace the CNS-1 capacity. For this reason,
13 the NRC staff does not consider other biomass-derived fuels to be feasible alternatives to CNS-
14 1 license renewal.

15 **8.4.13 Oil-Fired Power**

16 EIA projects that oil-fired plants will account for very few of new generation capacity constructed
17 in the United States during the 2008 to 2030 time period. Further, EIA does not project that oil-
18 fired power will account for any significant additions to capacity (EIA, 2009a).

19 The variable costs of oil-fired generation are found to be greater than those of nuclear or coal-
20 fired operations, and oil-fired generation has greater environmental impacts than natural gas-
21 fired generation. In addition, future increases in oil prices are expected to make oil-fired
22 generation increasingly more expensive (EIA, 2009a). The high cost of oil has prompted a
23 steady decline in its use for electricity generation. Thus, the NRC staff does not consider oil-
24 fired generation as an alternative to CNS-1 license renewal.

25 **8.4.14 Fuel Cells**

26 Fuel cells oxidize fuels without combustion and its environmental side effects. Power is
27 produced electrochemically by passing a hydrogen-rich fuel over an anode and passing air (or
28 oxygen) over a cathode and then separating the two by an electrolyte. The only byproducts
29 (depending on fuel characteristics) are heat, water, and CO₂. Hydrogen fuel can come from a
30 variety of hydrocarbon resources by subjecting them to steam under pressure. Natural gas is
31 typically used as the source of hydrogen.

32 At the present time, fuel cells are not economically or technologically competitive with other
33 alternatives for large-scale electricity generation. EIA projects that fuel cells may cost \$5,374
34 per installed kW (total overnight costs⁴) (EIA, 2009a), or 3.5 times the construction cost of new
35 coal-fired capacity, and 7.5 times the cost of new, advanced gas-fired, combined-cycle capacity.
36 In addition, fuel cell units are likely to be small (the EIA reference plant is 10 MWe). While it may
37 be possible to use a distributed array of fuel cells to provide an alternative to CNS-1, it would be

⁴ Overnight cost is the cost of a construction project if no interest was incurred during construction.

1 extremely costly to do so. Accordingly, the NRC staff does not consider fuel cells to be an
2 alternative to CNS-1 license renewal.

3 **8.4.15 Delayed Retirement**

4 NPPD has no plans to retire generating capacity in Nebraska prior to 2014 (NPPD, 2008). As a
5 result, delayed retirement is not a feasible alternative to license renewal. Other generation
6 capacity may be retired prior to the expiration of the CNS-1 license, but this capacity is likely to
7 be older, less efficient, and without modern emissions controls.

8 **8.5 NO-ACTION ALTERNATIVE**

9 This section examines environmental effects that occur if NRC takes no action. No action in this
10 case means that NRC does not issue a renewed operating license for CNS-1 and the license
11 expires at the end of the current license term, in 2014. If NRC takes no action, the plant will
12 shutdown at or before the end of the current license. After shutdown, plant operators will initiate
13 decommissioning according to 10 CFR 50.82.

14 The NRC staff notes that no action is the only alternative that is considered in-depth that does
15 not satisfy the purpose and need for this SEIS, because it does not provide power generation
16 capacity nor would it meet the needs currently met by CNS-1 or the alternatives evaluated in
17 Sections 8.1 through 8.3. Assuming that a need currently exists for the power generated by
18 CNS-1, the no-action alternative would require the appropriate energy planning decision makers
19 to rely on an alternative to replace the capacity of CNS-1 or reduce the need for power.

20 This section addresses only those impacts that arise directly as a result of plant shutdown. The
21 environmental impacts from decommissioning and related activities have already been
22 addressed in several other documents, including the *Final Generic Environmental Impact*
23 *Statement on Decommissioning of Nuclear Facilities*, NUREG-0586, Supplement 1
24 (NRC, 2002); the license renewal GEIS (Chapter 7, NRC, 1996); and Chapter 7 of this SEIS.
25 These analyses either directly address or bound the environmental impacts of decommissioning
26 whenever NPPD ceases operating CNS-1.

27 The NRC staff notes that, even with a renewed operating license, CNS-1 will eventually shut
28 down, and the environmental effects addressed in this section will occur at that time. Since
29 these effects have not otherwise been addressed in this SEIS, the impacts will be addressed in
30 this section. As with decommissioning effects, shutdown effects are expected to be similar
31 whether or not they occur at the end of the current license or at the end of a renewed license.

32 **8.5.1 Air Quality**

33 When the plant stops operating, there will be a reduction in emissions from activities related to
34 plant operation, such as use of diesel generators and employee vehicles. In Chapter 4, the NRC
35 staff determined that these emissions would have a SMALL impact on air quality during the
36 renewal term; therefore, if emissions decrease, the impact to air quality would also decrease
37 and would be a SMALL impact.

38 **8.5.2 Ground Water Use and Quality**

39 The use of ground water would diminish as plant personnel are removed from the site and
40 operations cease. Some consumption of ground water may continue as a small staff remains

Environmental Impacts of Alternatives

1 onsite to maintain facilities prior to decommissioning. Overall impacts would be smaller than
2 during operations, but would remain SMALL.

3 **8.5.3 Surface Water Use and Quality**

4 The rate of consumptive use of surface water would decrease as the plant is shut down and the
5 reactor cooling system continues to remove the heat of decay. Wastewater discharges would
6 also be reduced considerably. Shutdown would reduce the already SMALL impact on surface
7 water resources and quality.

8 **8.5.4 Aquatic and Terrestrial Resources**

9 *8.5.4.1 Aquatic Ecology*

10 If the plant were to cease operating, impacts to aquatic ecology would decrease, as the plant
11 would withdraw and discharge less water than it does during operations. Shutdown would
12 reduce the already SMALL impacts to aquatic ecology.

13 *8.5.4.2 Terrestrial Ecology*

14 Terrestrial ecology impacts would be SMALL. No additional land disturbances on or offsite
15 would occur.

16 **8.5.5 Human Health**

17 Human health risks would be smaller following plant shutdown. The plant, which is currently
18 operating within regulatory limits, would emit less gaseous and liquid radioactive material to the
19 environment. In addition, following shutdown, the variety of potential accidents at the plant
20 (radiological or industrial) would be reduced to a limited set associated with shutdown events
21 and fuel handling and storage. In Chapter 4 of this draft supplemental EIS, the NRC staff
22 concluded that the impacts of continued plant operation on human health would be SMALL. In
23 Chapter 5, the NRC staff concluded that the impacts of accidents during operation were SMALL.
24 Therefore, as radioactive emissions to the environment decrease, and as likelihood and variety
25 of accidents decrease following shutdown, the NRC staff concludes that the risk to human
26 health following plant shutdown would be SMALL.

27 **8.5.6 Socioeconomics**

28 *8.5.6.1 Land Use*

29 Plant shutdown would not affect onsite land use. Plant structures and other facilities would
30 remain in place until decommissioning. Most transmission lines connected to CNS-1 would
31 remain in service after the plant stops operating. Maintenance of most existing transmission
32 lines would continue as before. Impacts on land use from plant shutdown would be SMALL.

33 *8.5.6.2 Socioeconomics*

34 Plant shutdown would have an impact on socioeconomic conditions in the region around CNS-
35 1. Plant shutdown would eliminate approximately 750 jobs and would reduce tax revenue in the
36 region. The loss of these contributions, which may not entirely cease until after
37 decommissioning, would have a SMALL to MODERATE impact. See Appendix J to
38 NUREG-0586, Supplement 1 (NRC, 2002), for an additional discussion of the potential
39 socioeconomic impacts of plant decommissioning.

1 8.5.6.3 *Transportation*

2 Traffic volumes on the roads in the vicinity of CNS-1 would be reduced after plant shutdown.
 3 Most of the reduction in traffic volume would be associated with the loss of jobs at the plant.
 4 Deliveries to the plant would be reduced until decommissioning. Transportation impacts would
 5 be SMALL as a result of plant shutdown. Transportation impacts would increase if a new energy
 6 facility were constructed at the CNS-1 site or in the immediate vicinity. These impacts are
 7 addressed in Sections 8.1 to 8.3. Such impacts may be SMALL to MODERATE, but of short
 8 duration.

9 8.5.6.4 *Aesthetics*

10 Plant structures and other facilities would remain in place until decommissioning. Noise caused
 11 by plant operation would cease. Aesthetic impacts of plant closure would be SMALL.

12 8.5.6.5 *Historic and Archaeological Resources*

13 Impacts from the no-action alternative on historic and archaeological resources would be
 14 SMALL, since CNS-1 would be decommissioned. A separate environmental review would be
 15 conducted for decommissioning. That assessment would address the protection of historic and
 16 archaeological resources.

17 8.5.6.6 *Environmental Justice*

18 Termination of power plant operations would not disproportionately affect minority and
 19 low-income populations outside the immediate vicinity of CNS-1. Minority and low-income
 20 populations are generally concentrated in urban areas. Thus, impacts from plant shutdown
 21 would be SMALL. See Appendix J of NUREG-0586, Supplement 1 (NRC, 2002), for additional
 22 discussion of these impacts.

23 **8.5.7 Waste Management**

24 If the no-action alternative were implemented, the generation of high-level waste would stop and
 25 generation of low-level and mixed waste would decrease. Impacts from implementation of no-
 26 action alternative are expected to be SMALL.

27 Table 8-4 provides a summary of the environmental impacts of the no action alternative
 28 compared to continued operation of CNS-1.

29 **Table 8-4. Summary of Environmental Impacts of No Action Compared to Continued**
 30 **Operation of CNS 1**

	No Action	Continued CNS-1 Operation
Air Quality	SMALL	SMALL
Ground water	SMALL	SMALL
Surface water	SMALL	SMALL
Aquatic and terrestrial resources	SMALL	SMALL
Human health	SMALL	SMALL
Socioeconomics	SMALL to MODERATE	SMALL
Waste management	SMALL	SMALL

1 **8.6 ALTERNATIVES SUMMARY**

2 In this chapter, the NRC staff considers the following alternatives to CNS-1 license renewal:
3 supercritical coal-fired generation, natural gas combined-cycle generation, and a combination
4 alternative. No action by NRC and its effects were also considered. The impacts for all
5 alternatives to CNS-1 license renewal are summarized in Table 8-6 on the following page.

6 The environmental impacts of the proposed action (issuing a renewed CNS-1 operating license)
7 would be SMALL for all impact categories, except for the Category 1 issue of collective offsite
8 radiological impacts from the fuel cycle, high level waste (HLW) and from spent fuel disposal.
9 The NRC staff did not add a single significant level to these impacts, but the Commission
10 determined them to be Category 1 issues nonetheless.

11 The coal-fired alternative is not an environmentally favorable alternative due to impacts on air
12 quality from NO_x, SO_x, PM, PAHs, CO, CO₂, and mercury (and their corresponding human
13 health impacts); and due to construction impacts to aquatic, terrestrial, and potential historic and
14 archaeological resources.

15 The gas-fired alternative would have slightly lower air emissions, lower waste management, and
16 lower socioeconomic impacts than the coal-fired alternative. The combination alternative would
17 have lower air emissions and waste management impacts than both the gas-fired and coal-fired
18 alternatives; however, the combination alternative would have relatively high construction
19 impacts to aquatic, terrestrial, and potential historic and archaeological resources due mainly to
20 the wind turbine component.

21 In conclusion, the environmentally preferred alternative in this case is the license renewal of
22 CNS-1. All other alternatives capable of meeting the needs currently served by CNS-1 entail
23 potentially greater impacts than the proposed action of license renewal of CNS-1. The no-action
24 alternative necessitates the implementation of one or a combination of alternatives, all of which
25 have greater impacts than the proposed action, the NRC staff concludes that the no-action
26 alternative will have environmental impacts greater than or equal to the proposed license
27 renewal action.

1 **Table 8-5. Summary of Environmental Impacts of Proposed Action and Alternatives**

Alternative	Impact Area						
	Air Quality	Ground water	Surface Water	Aquatic and Terrestrial Resources	Human Health	Socioeconomics	Waste Management
License renewal	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL	Small
Supercritical coal-fired alternative at CNS-1 site	MODERATE	SMALL	SMALL	SMALL to MODERATE	SMALL	SMALL to LARGE	MODERATE
Gas-fired alternative at the CNS-1 site	SMALL to MODERATE	SMALL	SMALL	SMALL to MODERATE	SMALL	SMALL to MODERATE	SMALL
Combination of alternatives	SMALL to MODERATE	SMALL	SMALL	SMALL to LARGE	SMALL to MODERATE	SMALL to MODERATE	SMALL
No action alternative	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL to MODERATE	SMALL

1 **8.7 REFERENCES**

- 2 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, “Environmental
3 Protection Regulations for Domestic Licensing and Related Regulatory Functions.”
- 4 American Coal Ash Association (ACAA). 2007. “ACAA Releases 2006 CCP Production and Use
5 Survey.” August 24, 2007. Available URL: [http://www.acaa-](http://www.acaa-usa.org/associations/8003/files/2007_ACAA_CCP_Survey_Report_Form%2809-15-08%29.pdf)
6 [usa.org/associations/8003/files/2007_ACAA_CCP_Survey_Report_Form%2809-15-08%29.pdf](http://www.acaa-usa.org/associations/8003/files/2007_ACAA_CCP_Survey_Report_Form%2809-15-08%29.pdf)
7 (accessed April 15, 2008).
- 8 Department of Energy (DOE). 2007. “GeoPowering the West: Nebraska State Profile.” Available
9 URL: http://www1.eere.energy.gov/geothermal/gpw/profile_nebraska.html. (accessed July
10 2009).
- 11 Energy Information Administration (EIA). 2006. “Cost and Quality of Fuel for Electric Plants,
12 2004 and 2005.” DOE/EIA 0191(2006). Washington, D.C. Available URL:
13 <http://www.eia.doe.gov/cneaf/electricity/cq/cqa2005.pdf>. Accessed July 2009. ADAMS No.
14 ML082880730.
- 15 Energy Information Administration (EIA). 2009. *Assumptions to the Annual Energy Outlook 2009*
16 *With Projections to 2030*. DOE/EIA 0383(2009). Washington, D.C. Available URL:
17 [http://www.eia.doe.gov/oiaf/aeo/pdf/0383_\(2009\).pdf](http://www.eia.doe.gov/oiaf/aeo/pdf/0383_(2009).pdf) (accessed July 2009).
- 18 Energy Information Administration (EIA). 2009a. “Summary Statistics for the United States.”
19 Table ES1 from *Electric Power Annual with Data for 2007*. Available URL:
20 <http://www.eia.doe.gov/cneaf/electricity/epa/epates.html>
21 (accessed June 2009).
- 22 Energy Information Administration (EIA). 2009b. Table A4. “Approximate Heat Content of
23 Natural Gas, 1949-2008 (BTU per Cubic Foot).” Available URL:
24 <http://www.eia.doe.gov/emeu/aer/txt/ptb1304.html> (accessed July 2009).
- 25 Energy Information Administration (EIA). 2009c. “Annual Energy Outlook, 2009-Electricity
26 Demand” Available URL: <http://www.eia.doe.gov/oiaf/aeo/electricity.html> (accessed December
27 2009).
- 28 Environmental Protection Agency (EPA). 1998. *Compilation of Air Pollutant Emission Factors*,
29 Volume 1: *Stationary Point and Area Sources*: AP 42, Fifth Edition. “Section 1.1: Bituminous
30 and Subbituminous Coal Combustion: Final Section Supplement E.” Washington, D.C. 2000.
- 31 Environmental Protection Agency (EPA) 2000 “Notice of Regulatory Determination on Wastes
32 from the Combustion of Fossil Fuels.” *Federal Register*, Vol. 65, pp.32214-32237. Washington,
33 D.C.
- 34 Environmental Protection Agency (EPA). 2000a. “Regulatory Finding on the Emissions of
35 Hazardous Air Pollutants from Electric Utility Steam Generating Units.” *Federal Register*, Vol.
36 65, No. 245, pp. 79825–79831. Washington, D.C. December 20, 2000.
- 37 Environmental Protection Agency (EPA). 2008a. *New Resource Review*. Available URL:
38 <http://www.epa.gov/nsr/>. Accessed June 2009. ADAMS No.ML083450073
- 39 Environmental Protection Agency (EPA). 2009a. “Clean Air Mercury Rule.” Available URL:
40 <http://www.epa.gov/mercuryrule/>. Accessed June 2009. ADAMS No. ML091760654

- 1 General Electric (GE). 2007. "Gas Turbine and Combined Cycle Products." May 2007. Available
2 URL:
3 [http://www.gepower.com/prod_serv/products/gas_turbines_cc/en/downloads/gasturbine_cc_pro](http://www.gepower.com/prod_serv/products/gas_turbines_cc/en/downloads/gasturbine_cc_products.pdf)
4 [ducts.pdf](http://www.gepower.com/prod_serv/products/gas_turbines_cc/en/downloads/gasturbine_cc_products.pdf) (accessed June 2009).
- 5 Idaho National Engineering and Environmental Laboratory (INEEL). 1997. "U.S. Hydropower
6 Resource Assessment for Nebraska." DOE/ID-10430(NE). Available URL:
7 <http://hydropower.inl.gov/resourceassessment/pdfs/states/ne.pdf> (accessed July 2009).
- 8 Nebraska Department of Environmental Quality (NDEQ). 2003. Environmental Guidance
9 Document: Air Quality Permit Process. October 2003. Available URL:
10 <http://www.deq.state.ne.us/Publica.nsf/Pages/03-148> (accessed August 2009).
- 11 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement*
12 *for License Renewal of Nuclear Plants*. NUREG-1437, Volumes 1 and 2. Washington, D.C.
- 13 U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement*
14 *for License Renewal of Nuclear Plants, Main Report*, "Section 6.3 – Transportation, Table 9.1,
15 Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants, Final
16 Report." NUREG-1437, Volume 1, Addendum 1. Washington, D.C.
- 17 U.S. Nuclear Regulatory Commission (NRC). 2002. *Generic Environmental Impact Statement*
18 *on Decommissioning of Nuclear Facilities: Supplement 1, Regarding the Decommissioning of*
19 *Nuclear Power Reactors*. NUREG-0586, Supplement 1, Volumes 1 and 2. Washington, D.C.
- 20 U.S. Office of Management and Budget (OMB). 2007. Expectmore.gov. "Detailed Information on
21 the Low Income Home Energy Assistance Program Assessment." Available URL:
22 <http://www.whitehouse.gov/omb/expectmore/detail/10001059.2003.html> (accessed June 2009).
23 ADAMS Accession No. ML082880730.
- 24 Walsh, M.E., R.L. Perlack, A. Turhollow, D. de la Torre Ugarte, D.A. Becker, R.L. Graham, S.A.
25 Slinsky, and D.E. Ray (Walsh et. al.). 2000. "Biomass Feedstock Availability in the United
26 States: 1999 State Level Analysis." Available URL:
27 <http://bioenergy.ornl.gov/resourcedata/index.html> (accessed July 2009). ADAMS Accession No.
28 ML083050223.

9.0 CONCLUSION

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41

This draft supplemental environmental impact statement (SEIS) contains the preliminary environmental review of the Nebraska Public Power District (NPPD) Energy Company, LLC's application for a renewed operating license for Cooper Nuclear Station, Unit 1, (CNS-1) as required by the *Code of Federal Regulations* (CFR), Part 51 of Title 10 (10 CFR Part 51) and the U.S. Nuclear Regulatory Commission's (NRC) regulations that implement the National Environmental Policy Act (NEPA). This chapter presents conclusions and recommendations from the site-specific environmental review of CNS-1 and summarizes site-specific environmental issues of license renewal that were identified during the review. The environmental impacts of license renewal are summarized in Section 9.1; a comparison of the environmental impacts of license renewal and energy alternatives is presented in Section 9.2; unavoidable impacts of license renewal, energy alternatives, and resource commitments are discussed in Section 9.3; and conclusions and NRC staff recommendations are presented in Section 9.4.

9.1 ENVIRONMENTAL IMPACTS OF LICENSE RENEWAL

The staff's review of site-specific environmental issues in this draft SEIS leads to the conclusion that issuing a renewed license would have SMALL impacts for the eight Category 2 issues applicable to license renewal at CNS-1, as well as environmental justice and chronic effects of electromagnetic fields (EMF).

Mitigation measures were considered for each Category 2 issue, as applicable. For ground water, no measures to mitigate the environmental impacts of plant operation were found to be warranted because of the limited radius of influence of CNS-1 wells. NPPD has implemented some impingement and entrainment mitigation measures, such as dual flow screens with modified Ristroph fish buckets and plans to install a fish handling system, which the staff concludes will minimize impacts on aquatic resources. The NRC staff identified a variety of measures that could mitigate potential acute EMF impacts resulting from continued operation of the CNS-1 transmission lines, including erecting barriers along the length of the transmission line to prevent unauthorized access to the ground beneath the conductors and installing road signs at road crossings. These mitigation measures could reduce human health impacts by minimizing public exposures to electric shock hazard.

The staff identified a variety of measures that could mitigate the potential impacts of thermophilic microbiological organisms resulting from continued operation of CNS-1. These mitigation measures include periodically monitoring for thermophilic microbiological organisms in the water and sediments near the discharge, as well as prohibiting recreational use near the discharge plume. These mitigation measures could reduce human health impacts by minimizing public exposures to thermophilic microbiological organisms. NRC staff did not identify any cost-benefit studies applicable to the mitigation measures mentioned above.

The NRC staff also considered cumulative impacts of past, present, and reasonably foreseeable future actions, regardless of what agency (Federal or non-Federal) or person undertakes them. The staff concluded that cumulative impacts of CNS-1's license renewal would be SMALL for potentially affected resources.

1 **9.2 COMPARISON OF ENVIRONMENTAL IMPACTS OF LICENSE RENEWAL AND**
2 **ALTERNATIVES**

3 In the conclusion to Chapter 8, we determined that impacts from license renewal are generally
4 less than the impacts of alternatives to license renewal, with the exception of energy
5 conservation and energy efficiency. In comparing possible environmental impacts from
6 supercritical coal-fired generation, natural gas combined-cycle generation, energy conservation
7 and energy efficiency, and a combination alternative that includes natural gas, conservation and
8 efficiency, upgrades to existing hydroelectric dams, and environmental impacts from license
9 renewal, it was found that the energy conservation and energy efficiency alternative would result
10 in the lowest environmental impact. Based on the NRC staff's analysis, it was found that the
11 impacts of license renewal are reasonable in light of the impacts from alternatives to the license
12 renewal of CNS-1.

13 **9.3 RESOURCE COMMITMENTS**

14 **9.3.1 Unavoidable Adverse Environmental Impacts**

15 Unavoidable adverse environmental impacts are impacts that would occur after implementation
16 of all feasible mitigation measures. Implementing any of the energy alternatives considered in
17 this SEIS, including the proposed action, would result in some unavoidable adverse
18 environmental impacts.

19 Minor unavoidable adverse impacts on air quality would occur due to emission and release of
20 various chemical and radiological constituents from power plant operations. Nonradiological
21 emissions resulting from power plant operations are expected to comply with U.S.
22 Environmental Protection Agency (EPA) emissions standards, though the alternative of
23 operating a fossil-fueled power plant in some areas may worsen existing attainment issues.
24 Chemical and radiological emissions would not exceed the National Emission Standards for
25 Hazardous Air Pollutants.

26 During nuclear power plant operations, workers and members of the public would face
27 unavoidable exposure to radiation and hazardous and toxic chemicals. Workers would be
28 exposed to radiation and chemicals associated with routine plant operations and the handling of
29 nuclear fuel and waste material. Workers would have higher levels of exposure than members
30 of the public, but doses would be administratively controlled and would not exceed standards or
31 administrative control limits. In comparison, the alternatives involving the construction and
32 operation of a non-nuclear power generating facility would also result in unavoidable exposure
33 to hazardous and toxic chemicals to workers and the general public.

34 The generation of spent nuclear fuel and waste material, including low-level radioactive waste,
35 hazardous waste, and nonhazardous waste would also be unavoidable. In comparison,
36 hazardous and nonhazardous wastes would also be generated at non-nuclear power generating
37 facilities. Wastes generated during plant operations would be collected, stored, and shipped for
38 suitable treatment, recycling, or disposal in accordance with applicable Federal and State
39 regulations. Due to the costs of handling these materials, power plant operators would be
40 expected to conduct all activities and optimize all operations in a way that generates the
41 smallest amount of waste possible.

1 **9.3.2 The Relationship between Local Short-Term Uses of the Environment and the** 2 **Maintenance and Enhancement of Long-Term Productivity**

3 The operation of power generating facilities would result in short-term uses of the environment
4 as described in Chapters 4, 5, 6, 7, and 8. "Short-term" is the period of time that continued
5 power generating activities take place.

6 Power plant operations require short-term use of the environment and commitment of
7 resources, and also commit certain resources (e.g., land and energy) indefinitely or
8 permanently. Certain short-term resource commitments are substantially greater under most
9 energy alternatives, including license renewal, than under the No-Action Alternative because of
10 the continued generation of electrical power and the continued use of generating sites and
11 associated infrastructure. During operations, all energy alternatives require similar relationships
12 between local short-term uses of the environment and the maintenance and enhancement of
13 long-term productivity.

14 Air emissions from power plant operations introduce small amounts of radiological and
15 nonradiological constituents to the region around the plant site. Over time, these emissions
16 would result in increased concentrations and exposure, but are not expected to impact air
17 quality or radiation exposure to the extent that public health and long-term productivity of the
18 environment would be impaired.

19 Continued employment, expenditures, and tax revenues generated during power plant
20 operations directly benefit local, regional, and State economies over the short term. Local
21 governments investing project-generated tax revenues into infrastructure and other required
22 services could enhance economic productivity over the long term.

23 The management and disposal of spent nuclear fuel, low-level radioactive waste, hazardous
24 waste, and nonhazardous waste requires an increase in energy and consumes space at
25 treatment, storage, or disposal facilities. Regardless of the location, the use of land to meet
26 waste disposal needs would reduce the long-term productivity of the land.

27 Power plant facilities are committed to electricity production over the short term. After
28 decommissioning these facilities and restoring the area, the land could be available for other
29 future productive uses.

30 **9.3.3 Irreversible and Irretrievable Commitments of Resources**

31 This section describes the irreversible and irretrievable commitment of resources that have
32 been identified in this SEIS. Resources are irreversible when primary or secondary impacts limit
33 the future options for a resource. An irretrievable commitment refers to the use or consumption
34 of resources that are neither renewable nor recoverable for future use. Irreversible and
35 irretrievable commitment of resources for electrical power generation include the commitment of
36 land, water, energy, raw materials, and other natural and man-made resources required for
37 power plant operations. In general, the commitment of capital, energy, labor, and material
38 resources are also irreversible.

39 The implementation of any of the energy alternatives considered in this SEIS would entail the
40 irreversible and irretrievable commitment of energy, water, chemicals, and, in some cases, fossil
41 fuels. These resources would be committed during the license renewal term and over the entire
42 life cycle of the power plant and would be unrecoverable.

Conclusion

1 Energy expended would be in the form of fuel for equipment, vehicles, and power plant
2 operations and electricity for equipment and facility operations. Electricity and fuel would be
3 purchased from offsite commercial sources. Water would be obtained from existing water supply
4 systems. These resources are readily available, and the amounts required are not expected to
5 deplete available supplies or exceed available system capacities.

6 The irreversible and irretrievable commitment of material resources includes materials that
7 cannot be recovered or recycled, materials that are rendered radioactive and cannot be
8 decontaminated, and materials consumed or reduced to unrecoverable forms of waste. None of
9 the resources used by these power generating facilities, however, are in short supply, and for
10 the most part are readily available.

11 Various materials and chemicals derived from chemical vendors, including acids and caustics,
12 are required to support the operation's activities. Their consumption is not expected to affect
13 local, regional, or national supplies.

14 The treatment, storage, and disposal of spent nuclear fuel, low-level radioactive waste,
15 hazardous waste, and nonhazardous waste require the irretrievable commitment of energy and
16 fuel and will result in the irreversible commitment of space in disposal facilities.

17 **9.4 RECOMMENDATIONS**

18 Based on (1) the analysis and findings in the GEIS, (2) information provided in the
19 Environmental Report submitted by NPPD, (3) consultation with Federal, State, and local
20 agencies, (4) a review of pertinent documents and reports, and (5) consideration of public
21 comments received during scoping, the preliminary recommendation of the NRC staff is for the
22 Commission to determine that the above considered adverse environmental impacts of license
23 renewal are not so great that preserving the option of license renewal for energy planning
24 decision makers (i.e., State regulatory agencies and NPPD) would be unreasonable.

10.0 LIST OF PREPARERS

This supplemental environmental impact statement (SEIS) was prepared by members of the Office of Nuclear Reactor Regulation, with assistance from other U. S. Nuclear Regulatory Commission (NRC) organizations and with contract support from Pacific Northwest National Laboratory.

Table 10-1 provides a list of NRC staff that participated in the development of the SEIS. Pacific Northwest National Laboratory provided contract support for the severe accident mitigation alternatives (SAMA) analysis, presented in Chapter 5 and Appendix F.

Table 10-1. List of Preparers.

Name	Affiliation	Function or Expertise
Nuclear Regulatory Commission		
Bo Pham	Nuclear Reactor Regulation	Branch Chief
Dave Pelton	Nuclear Reactor Regulation	Branch Chief
Emmanuel Sayoc	Nuclear Reactor Regulation	Project Manager
Tam Tran	Nuclear Reactor Regulation	Project Manager
Bennett Brady	Nuclear Reactor Regulation	Project Manager
Dennis Beissel	Nuclear Reactor Regulation	Hydrology
Dennis Logan	Nuclear Reactor Regulation	Aquatic Ecology; Terrestrial Ecology
Stephen Klementowicz	Nuclear Reactor Regulation	Radiation Protection; Human Health
Jennifer Davis	Nuclear Reactor Regulation	Historic and Archaeological Resources
Richard Bulavinetz	Nuclear Reactor Regulation	Terrestrial Ecology
Ekaterina Lenning	Nuclear Reactor Regulation	Air Quality
Robert Palla	Nuclear Reactor Regulation	Severe Accident Mitigation Alternatives
Jeffrey Rikhoff	Nuclear Reactor Regulation	Socioeconomics; Land Use; Environmental Justice
Andrew Stuyvenburg	Nuclear Reactor Regulation	Alternatives
Allison Travers	Nuclear Reactor Regulation	Alternatives
SAMA Contractor^(a)		
Steve Short	Pacific Northwest National Laboratory	Severe Accident Mitigation Alternatives
Bruce Schmitt	Pacific Northwest National Laboratory	Severe Accident Mitigation Alternatives
Jon Young	Pacific Northwest National Laboratory	Severe Accident Mitigation Alternatives

^(a)Pacific Northwest National Laboratory is operated by Batelle for the U.S. Department of Energy

11.0 INDEX

1	accidents	xxv, 5-1, 5-2, 5-3, B-8
2	aesthetic	xxiv
3	alternatives	v, xxv, xxvi, 1-6, 5-3, 8-7, 8-27, 9-1, 9-2,9-3, 9-4, 10-1, 12-1, B-8
4	archaeological resources	xxiv, 1-7, B-8, D-1
5	Barnwell	2-7
6	biota	B-2
7	burnup	B-11
8	chronic effects	1-4, 4-15, 4-38, 4-50, 9-1, B-7
9	closed-cycle cooling	B-5
10	cultural resources	C-1
11	decommissioning	3, 11, 12
12	design-basis accidents	xxx, 5-1, 5-2
13	discharges	9-1, B-2, B-3, B-7
14	dose	2-7, 4-16, 4-17, B-6, B-9, B-10
15	education	4-20, 4-21, B-8
16	electromagnetic fields	1-4, 4-12, 4-38, 4-50, 9-1, B-5, B-7
17	entrainment	B-2, B-3
18	environmental justice	1-4, 4-21, 4-27, 9-1, B-12
19	EPA	xxxi, 2-7, 4-16, B-10, C-1
20	GEIS	xx, xxi, xxii, xxiii, xxiv, xxvii, xxxi, 1-3, 1-4, 1-6, 1-10, 4-1, 4-3,4-5, 4-12, 4-15,
21		4-20, 4-21, 4-36, 4-50, 5-1, 5-2, 5-3, 6-1, 6-2, 7-2, 9-4, A-1, B-9
22	ground water	4-2, 4-16, 9-1, B-4, B-5, C-1
23	hazardous waste	2-8, 9-2, 9-3, 9-4
24	high level waste	B-9, B-10
25	impingement	B-2, B-3, B-4
26	low level waste	xxxii
27	mitigation	xxiii, 1-4, 1-6, 4-3, 4-5, 4-12, 4-15, 5-3, 9-1, 9-2, 10-1, 12-1
28	mixed waste	xxxii, B-11
29	NEPA	xx, xxi, xxxiii, 1-1, 1-12, 4-36, 5-1, 7-3, 9-1, B-9, B-10, D-1
30	no-action alternative	v, xxvi
31	nonattainment	B-6
32	NPDES	xxxiv, B-2, C-1
33	Pennsylvania Department of Conservation and Natural Resources	xxx
34	Pennsylvania Department of Environmental Protection	xxxiv
35	Pennsylvania Fish and Boat Commission	xxxiv
36	Pennsylvania Game Commission	xxxv
37	Pennsylvania Historic and Museum Commission	xxxv
38	postulated accidents	5-1, 5-3
39	pressurized water reactor	xxxv
40	radon-222	6-1, B-9
41	reactor	xx, xxi, xxx, xxxii, xxxv, 5-1, 5-2, 5-3, B-4, B-9
42	refurbishment	4-17, B-1, B-2, B-4, B-6, B-7, B-8
43	replacement power	v
44	scoping . xx, xxi, xxiii, xxvii, 1-3, 1-6, 4-3, 4-5, 4-12, 4-15, 4-37, 5-2, 5-3, 6-1, 7-2, 9-4, A-1, E-3	
45	severe accidents (SAMA)	xxxvi, 5-3, 5-4, 10-1, 12-1
46	solid waste	2-7, 2-8, 6-1, B-12, C-1
47	spent fuel	xxxii, 1-4, 6-1, 6-2, B-9, B-10, B-11

Index

1	stormwater.....	4-16
2	surface water.....	xxiv, 4-3, 4-16, B-1, B-4, C-1
3	Susquehanna River Basin Commission.....	xxxvi
4	threatened and endangered species.....	1-7, 4-14, B-2, B-6, C-1, D-1
5	transmission lines.....	4-1, 4-20, 4-21, 4-38, 4-50, 9-1, B-6, B-8
6	tritium.....	4-16
7	uranium.....	6-1, 6-2, B-9, B-11
8	wastewater.....	B-2
9	Yucca.....	B-9, B-10, B-11

1 **12.0 LIST OF AGENCIES, ORGANIZATIONS, AND PERSONS TO**
 2 **WHOM COPIES OF THE SUPPLEMENTAL ENVIRONMENTAL IMPACT**
 3 **STATEMENT ARE SENT**

Name and Title	Company and Address
Mr. Ronald D. Asche President and Chief Executive Officer	Nebraska Public Power District 1414 15th Street Columbus, NE 68601
Mr. Gene Mace Nuclear Asset Manager	Nebraska Public Power District P.O. Box 98 Brownville, NE 68321
Mr. John C. McClure Vice President and General Counsel	Nebraska Public Power District P.O. Box 499 Columbus, NE 68602-0499
Mr. David Van Der Kamp Licensing Manager	Nebraska Public Power District P.O. Box 98 Brownville, NE 68321
Mr. Michael J. Linder, Director Chairman	Nebraska Department of Environmental Quality P.O. Box 98922 Lincoln, NE 68509-8922 Nemaha County Board of Commissioners Nemaha County Courthouse 1824 N Street Auburn, NE 68305
Ms. Julia Schmitt, Manager Radiation Control Program	Nebraska Health & Human Services R & L Public Health Assurance 301 Centennial Mall, South P.O. Box 95007 Lincoln, NE 68509-5007
Mr. H. Floyd Gilzow Deputy Director for Policy Senior Resident Inspector	Missouri Department of Natural Resources P.O. Box 176 Jefferson City, MO 65102-0176 U.S. Nuclear Regulatory Commission P.O. Box 218 Brownville, NE 68321
Regional Administrator, Region IV Director	U.S. Nuclear Regulatory Commission 612 E. Lamar Blvd., Suite 400 Arlington, TX 76011-4125
Chief, Radiation and Asbestos Control Section	Missouri State Emergency Management Agency P.O. Box 116 Jefferson City, MO 65102-0116
	Kansas Department of Health and Environment Bureau of Air and Radiation 1000 SW Jackson Suite 310 Topeka, KS 66612-1366

List of Agencies, Organizations, and Persons

Name and Title	Company and Address
Ms. Melanie Rasmussen Radiation Control Program Director	Bureau of Radiological Health Iowa Department of Public Health Lucas State Office Building, 5th Floor 321 East 12th Street Des Moines, IA 50319
Mr. Keith G. Henke, Planner Division of Community and Public Health	Office of Emergency Coordination 930 Wildwood P.O. Box 570 Jefferson City, MO 65102
Mr. Art Zaremba, Director of Nuclear Safety Assurance	Nebraska Public Power District P.O. Box 98 Brownville, NE 68321
Mr. John F. McCann, Director Licensing, Entergy Nuclear Northeast	Entergy Nuclear Operations, Inc. 440 Hamilton Avenue White Plains, NY 10601-1813
Steward Minahan Vice President Nuclear and Chief Nuclear Officer	Cooper Nuclear Station 72676 – 648A Avenue Brownville, NE 68321
Mike Boyce Cooper Strategic Initiatives Manager	Cooper Nuclear Station 72676 – 648A Avenue Brownville, NE 68321
Dave Bremer License Renewal Project Manager	Cooper Nuclear Station 72676 – 648A Avenue Brownville, NE 68321
Bill Victor License Renewal Project Licensing Lead	Cooper Nuclear Station 72676 – 648A Avenue Brownville, NE 68321
Jim Loynes License Renewal Project Engineer	Cooper Nuclear Station 72676 – 648A Avenue Brownville, NE 68321
Garry Young License Renewal Manager	Entergy Nuclear 1448 S.R. 333, N-GSB-45 Russellville, AK 72802
Alan Cox License Renewal Technical Manager	Entergy Nuclear 1448 S.R. 333, N-GSB-45 Russellville, AK 72802
Jerry Perry	Entergy Nuclear 1448 S.R. 333, N-GSB-45 Russellville, AK 72802
Yolanda Peck	500 S. Main Street Rock Port, MO 64482
Kendall Neiman	1008 Central Ave. Auburn, NE 68305
Annie Thomas	830 Central Ave. Auburn, NE 68305
John Chaney	1522 I Street Auburn, NE 68305
Darrell Kruse	1101 17th Street Auburn, NE 68305

List of Agencies, Organizations, and Persons

Name and Title	Company and Address
Daryl J. Obermeyer	2415 McConnell Ave. Auburn, NE 68305
Sherry Black, Director	64381 727A Road Brownville, NE 68321
Marty Hayes Chairman	Auburn Memorial Library 1810 Courthouse Ave. Auburn, NE 68305
Bob Engles Mayor of Auburn, NE	Board of Brownville, NE P.O. Box 67 223 Main Street Brownville, NE 68321
Jo Stevens Mayor of Rock Port, MO	1101 J Street Auburn, NE 68305
John Cochnar	500 S. Main Street Rock Port, MO 64482
John Askew Regional Administrator	U.S. Fish and Wildlife Service Ecological Services Nebraska Field Office 203 West Second Street Grand Island, NE 68801
Regional Administrator	U.S. Environmental Protection Agency Region 7 901 N. 5th Street Kansas City, KS 66101
Joann Scheafer, Director	U.S. Environmental Protection Agency Region 7 901 N. 5th Street Kansas City, KS 66101
Doyle Childers, Director	Nebraska Department of Health & Human Services 301 Centennial Mall South Lincoln, NE 68509
Mark Miles State Historic Preservation Officer	Missouri Department of Natural Resources P.O. Box 176 Jefferson City, MO 65102
Michael J. Smith State Historic Preservation Officer	Department of Natural Resources P.O. Box 176 Jefferson City, MO 65102
Robert Puschendorf	Nebraska State Historical Society P.O. Box 82554 Lincoln, NE 68501
Carla Mason	ADC Digital Communications 820 Central Ave Auburn, NE 68305
Matthew Leaf	KTNC/KLZA Radio 1602 Stone St. Falls City, NE 68355
Daryl J. Obermeyer	ADC Digital Communications 64381 727A Road Brownville, NE 68321

1
2
3

APPENDIX A.
COMMENTS RECEIVED ON THE COOPER NUCLEAR STATION,
UNIT 1, ENVIRONMENTAL REVIEW

1 **A. COMMENTS RECEIVED ON THE COOPER NUCLEAR STATION,** 2 **UNIT 1, ENVIRONMENTAL REVIEW**

3 **A.1. Comments Received During Scoping**

4 The scoping process began on January 26, 2009 with the publication of the U.S. Nuclear
5 Regulatory Commission's (NRC's) Notice of Intent to conduct scoping in the *Federal Register*
6 (74 FR 4476). The scoping process included two public meetings held in Brownville and Auburn,
7 Nebraska on February 25, 2009. Approximately 120 people attended the meetings. After the
8 NRC's prepared statements pertaining to the license renewal process, the meetings were open
9 for public comments. Attendees provided oral statements that were recorded and transcribed by
10 a certified court reporter. Transcripts of the entire meeting, as well as written statements
11 submitted at the public meetings, were issued as an attachment to the Cooper Public Meeting
12 Summary Report dated April 14, 2009 (NRC, 2009). In addition to the comments received
13 during the public meetings, comments were received through the mail and e-mail.

14 Each commenter was given a unique identifier so every comment could be traced back to its
15 author. Table A-1 identifies the individuals who provided comments applicable to the
16 environmental review and the Commenter ID associated with each person's set of comments.
17 The individuals are listed in the order in which they spoke at the public meeting, and in
18 alphabetical order for the comments received by letter or e-mail. To maintain consistency with
19 the Public Meeting Summary Report, the unique identifier used in that report for each set of
20 comments is retained in this appendix.

21 Specific comments were categorized and consolidated by topic. Comments with similar specific
22 objectives were combined to capture the common essential issues raised by participants.
23 Comments fall into one of the following general groups:

- 24 (1) Specific comments that address environmental issues within the purview of the NRC
25 environmental regulations related to license renewal. These comments address
26 Category 1 (generic) or Category 2 (site-specific) issues or issues not addressed in the
27 *Generic Environmental Impact Statement (GEIS) for License Renewal of Nuclear Power*
28 *Plants*. They also address alternatives to license renewal and related Federal actions.
- 29 (2) General comments (1) in support of, or opposed to, nuclear power or license renewal or
30 (2) on the renewal process, the NRC's regulations, and the regulatory process. These
31 comments may or may not be specifically related to the Cooper Nuclear Station, Unit 1,
32 (CNS-1) license renewal application.
- 33 (3) Comments that do not identify new information for the NRC to analyze as part of its
34 environmental review.
- 35 (4) Comments that address issues that do not fall within, or are specifically excluded from,
36 the purview of NRC environmental regulations related to license renewal. These
37 comments typically address issues such as emergency response and preparedness,
38 security and terrorism, energy costs, energy needs, current operational safety issues,
39 and safety issues related to operation during the renewal period.

Appendix A

1 **Table A-1. Commenters on the Scope of the Environmental Review.** *Each comment is*
 2 *identified along with their affiliation and how their comment was submitted.*

Commenter ID	Commenter	Affiliation	Comment Source	ADAMS Accession Number^a
CNS-1-A	Martin Hansen	Village Board of Brownville	Afternoon Scoping Meeting	ML090840062
CNS-1-B	Glen Krueger	Member of the Public	Afternoon Scoping Meeting	ML090840062
CNS-1-C	Becky Cromer	Falls City Economic Development and Growth Enterprise	Afternoon Scoping Meeting	ML090840062
CNS-1-D	Arnold Ehlers	City Clerk/Treasurer for the City of Nebraska City, Nebraska	Afternoon Scoping Meeting	ML090840062
CNS-1-E	James Gerwick	Emergency Management Director for Richardson County, Nebraska	Afternoon Scoping Meeting	ML090840062
CNS-1-F	Robert Cole	Nemaha County Emergency Management Director	Evening Scoping Meeting	ML090840063
CNS-1-G	Rod Vandenberg	Mayor of Falls City, Nebraska	Evening Scoping Meeting	ML090840063
CNS-1-H	Larry Shepard	U.S. Environmental Protection Agency	Evening Scoping Meeting	ML090840063
CNS-1-I	Bob Engles	Mayor of Auburn, Nebraska	Evening Scoping Meeting	ML090840063
CNS-1-J	Kendall Neiman	Auburn Chamber of Commerce	Evening Scoping Meeting	ML090840063
CNS-1-K	David Sickel	County Commissioner Richardson County	Evening Scoping Meeting	ML090840063
CNS-1-L	Ron Asche,	Nebraska Public Power District	Evening Scoping Meeting	ML090840063
CNS-1-M	Alan Richard	Pawnee City Development Corporation	Letter	ML090720067
CNS-1-N	Ashtin Paris	Deputy Clerk City of Rock Port	Letter	ML090720068
CNS-1-O	James Gerwick	Emergency Management Director for Richardson County, Nebraska	Letter	ML090720066
CNS-1-P	Larry Spepard	U.S. Environmental Protection Agency	Email	ML091070269
CNS-1-Q	Jill Dolberg	Nebraska State Historic Preservation Office	Letter	ML090650061
CNS-1-R	Jean Angell	Nebraska Department of Natural Resources	Letter	ML090860762

^a The accession number for the afternoon transcript is ML090840062
 The accession number for the evening transcript is ML090840063

1 Comments received during scoping applicable to this environmental review are presented in this
2 section along with the NRC response. Comments received during the public meeting have been
3 transcribed; comments received by letter or e-mail have been copied in this document to
4 maintain authenticity. Comments are grouped by category. There were two categories as
5 follows:

6 (1) Comments in support of license renewal at CNS-1, discussed in Section A.2

7 (2) General comments regarding the license renewal review of CNS-1, discussed in A.3

8 **A.2. Comments in Support of License Renewal at Cooper Nuclear Station, Unit, 1**

9 **Comment CNS-1- A:** My name is Martin Hansen, a member of the Village Board of Brownville.
10 I'm filling in for our chairman, Marty Hayes, today. I would like to welcome the members of the
11 Nuclear Regulatory System [sic] to our community for this meeting. Brownville, while being a
12 small community, we see the importance of Cooper Nuclear Station. It is, of course, the largest
13 employer in our community and throughout southeastern Nebraska. But for our community, it is
14 a little more than that. This community was here when the construction on Cooper started nearly
15 40 years ago. We are here on each day of operation which is around the clock. Cooper
16 continues to operate safely and our community of Brownville appreciates that very much.

17 Cooper is a partner with the community. It has lent us support. One of the examples is the
18 Village of Brownville Volunteer Fire Department. The management of Cooper has allowed our
19 group of dedicated fire fighters to utilize their training facilities that has enhanced its firefighting
20 capabilities and has cooperated in an effort and has enabled our department to upgrade its
21 equipment and training capabilities over a number of years. I'm sure that you will hear a lot
22 more from other communities about the economic impact of Cooper on the community and the
23 importance it has on the economy. A 2002 economic study found that there would be
24 detrimental impact to not only Brownville, but to other communities in this area, so Cooper is
25 important to continue operation through the license extension of 20 years.

26 Emergency response is an important part of Cooper operation, and any need for that action to
27 take place would be handled in a manner that is both professional and done for the protection of
28 the public. Cooper Emergency Response organization takes it very seriously and each resident
29 in a 10-mile zone around Cooper always receives the appropriate information about any
30 possible emergency response activity on the site and would have comfort of knowledge that
31 these plans are in place and tested annually.

32 Earlier this month, the Village Board of Brownville unanimously approved a resolution in support
33 of Nebraska Public Power District at Cooper Nuclear Station license renewal for an additional
34 20 years. I would like to read that resolution into the official record at this time.

35 Resolution No. 2-2-09-1

36 WHEREAS, the Nebraska Public Power District Cooper Nuclear Station in Brownville became
37 operational with startup in 1974 and has operated safely and efficiently for more than 30 years
38 and its 828 megawatts of electricity generated; and

39 WHEREAS, the Village of Brownville has had a longstanding history with Cooper Nuclear
40 Station since the plant's construction, through refueling outages, and day-to-day operations; and

Appendix A

1 WHEREAS, the Village of Brownville Volunteer Fire Department has been able to utilize training
2 facilities to enhance the firefighting capabilities and this cooperative effort has allowed the
3 department to upgrade equipment in training firefighters over the years;

4 WHEREAS, Nebraska Public Power District has continually reinvested in the Cooper Nuclear
5 Station facility to access continued safety, clean, reasonable, and affordable production of
6 electricity for Nebraskans across the State; and

7 WHEREAS, the Cooper Nuclear Station is a critical asset as part of Nebraska Public Power
8 District generation resources and the state's unique public power system, continues to assist in
9 keeping state electricity rates among the lowest in the country;

10 WHEREAS, more than 700 permanent jobs at Cooper Nuclear Station and extensive use of
11 contractors in ongoing maintenance and refueling outages are organized and important to the
12 economy of the Village of Brownville, Nemaha County, and surrounding communities in
13 southeastern Nebraska; and

14 WHEREAS, a 2002 economic study of the impact of the loss of Cooper Nuclear Station would
15 be detrimental to the Village of Brownville and other communities in southeast Nebraska; and

16 WHEREAS, the United States Nuclear Regulatory Commission is the federal agency charged
17 with oversight of our nation's vital nuclear facilities and encouraged public input and comment
18 on license renewal and process from the neighborhood and communities; and

19 WHEREAS, the Cooper Nuclear Station has continued to be a good neighbor to Brownville for
20 more than three decades;

21 NOW, THEREFORE, BE IT RESOLVED that the Village of Brownville Council supports the
22 renewal of the license for the nuclear generation facility at Cooper Nuclear Station, and to
23 assure their continued operations of safe, affordable, and important component of Nebraska's
24 public power supply system for another 20 years; but

25 BE IT FURTHER RESOLVED that the Village of Brownville clerk is directed to make available
26 copies of this resolution to the Nuclear Regulatory Commission at its upcoming Environment
27 Scope Public Meeting.

28 Again, I wish to thank the Nuclear Regulatory Commission for hosting this important public
29 meeting, and we'll make ourselves available to you if you have any questions of us, thank you.
30 (End of Comment CNS-1-A)

31 **Comment CNS-1-B:** My name is Glen Krueger and I was the hospital administrator, and I don't
32 think the present one is here at this time. I was the hospital administrator. I came in 1971, so
33 was there when it was started and I retired in 2002. And I would like to say that we have had a
34 full and wonderful cooperation with the Nebraska Public Power District for emergency services.
35 We were able to send an employee down to Tennessee to learn more about radiation. Yes, we
36 were learning more when it first started up, but we finally came that we were very comfortable,
37 that we knew how to take care of if an accident did happen over here. We had full cooperation
38 from them and I would totally support this new license.

39 But, also, as a citizen of Auburn, I would like to restate and I would like to have this new permit
40 be renewed, because of the need that we have in the City of Auburn, if the need -- the people

1 that work there. We have a lot of those employees who work in our church and a lot of those
2 employees, in fact, I have three of those employees in my block where I live. Very appreciative
3 of them. (End of Comment CNS-1 -B)

4 **Comment CNS-1-C:** I also would like to thank you for the opportunity to speak here this
5 afternoon. My name is Beckie Cromer. I'm Executive Director of our Falls City Economic
6 Development and Growth Enterprise. And I'm here this afternoon on behalf of the economic
7 development team from Falls City. We would like to confirm our unwavering support for the 20-
8 year license extension of Cooper Nuclear Station. Falls City EDGE did pass a resolution of
9 support for the 20-year license extension, and we have forwarded that resolution to NPPD
10 officials, although, after reading the materials here today, I think we'll also forward that NRC with
11 the information provided within the packets today. And in addition to that, our mayor will be
12 speaking in support of Nebraska Public Power District this evening, as well.

13 Cooper Nuclear Station is an economic development gem that injects millions into our local
14 economy by providing almost 800 jobs that pay more than double the Nebraska state average.
15 The decommissioning of Cooper Nuclear Station would result in monumental loss of revenue
16 and jobs for our southeast Nebraska area. Additionally, Cooper Nuclear Station runs a very safe
17 operation. It allows Nebraska to offer a diverse portfolio of power to our citizens.

18 I had the opportunity to tour Cooper Nuclear Station this week with many Falls City community
19 leaders. The facility was top notch. The staff was professional and knowledgeable, and the
20 safety measures in place for workers and the surrounding public exceeds benchmarks set by
21 government agencies.

22 Southeast Nebraska is proud to have Cooper Nuclear Station as a partner in economic
23 development and we ask that you grant the licensing request being made by Cooper Nuclear
24 Station. Thank you. (End of Comment CNS-1 -C)

25 **Comment CNS-1-D:** Good afternoon. My name is Arnold Ehlers, City Clerk/Treasurer for the
26 City of Nebraska City, Nebraska. I am here to present a resolution passed unanimously by the
27 City Council and Mayor of Nebraska City, supporting the license renewal of Cooper Nuclear
28 Station. I would also like to make you aware of the economic impact Cooper Nuclear Station
29 has on southeast Nebraska, as well as southwestern Iowa and northwest Missouri, an economic
30 impact that is over \$500 million a year. But the economic impact is just one part of the
31 contribution made by Nebraska Public Power District and its employees. NPPD employees
32 belong to volunteer fire departments, serve on library boards, school boards, and many other
33 boards and committees too numerous to mention. Their spouses and families are also very
34 important contributors to the communities in which they live.

35 Over the years, Cooper has been a good safe partner and good neighbor to all of us. They have
36 attracted employees from around the world, enhancing the multicultural experiences of the area.
37 We've actually become a global community due to this. It is a privilege to live in a public power
38 state and in a city that owns its own utilities. Nebraska City, in fact all of Nebraska, benefits from
39 the low-cost electricity that Cooper Nuclear plays a significant role in providing.

40 I have a resolution that I would like to have entered into the record. I won't bore you with the
41 reading of it, unless it needs to be read. I thank you for this opportunity. (End of Comment CNS-
42 1-D)

Appendix A

1 Comment CNS-1-E: Good afternoon. Many thanks to the Nuclear Regulatory Commission for
2 hosting this public forum. My name is Jim Gerwick, and I'm the Emergency Management
3 Director for Richardson County, Nebraska, the county just south of here.

4 In my position, hardly a month has gone by where some form of interchange has not transpired
5 between Cooper Nuclear Station's Emergency Management Department and other nuclear
6 operations staff and my office in Richardson County. The referenced activities include quarterly
7 emergency communication drills, unannounced communications checks, written
8 correspondence involving improvements in emergency plans and training in many forms, to
9 include FEMA, Federal Emergency Management Agency, evaluated radiological emergency
10 preparedness exercises.

11 Other joint training activities include NPPD staff involvement in annual training of our local
12 radiological emergency response organization, and our joint quarterly off-site training meetings.

13 Cooper Nuclear Station has fully demonstrated its ability to provide safe, reliable electricity for
14 the citizens of the state of Nebraska. Richardson County has supported Cooper Nuclear Station
15 in its off-site responsibilities to protect the public and property for many years, since the plant
16 started, actually, and is glad to be part of the team that supports nuclear power. The bottom line
17 in our realm of experience, the staff at NPPD and Cooper Nuclear Station is thoroughly
18 professional and meticulous in attention to detail concerning their approach to public safety. In
19 short, they are fully integrated and a key member of our public safety team.

20 And in view of their professional performance and contributions to our community, we support
21 NPPD's application to continue to operate Cooper Nuclear Station for another 20 years.

22 In closing, Richardson County is proud to have Cooper Nuclear Station in the Richardson
23 County area. (End of Comment CNS-1-E)

24 **Comment CNS-1-F:** Thank you for the opportunity to speak tonight. I'm Robert Cole. I'm the
25 Nemaha County Emergency Management Director. I wanted to make a few short statements. I've
26 already submitted a letter of support on the relicensing application; however, I wanted to touch on a
27 few of the highlights that I mentioned in the letter.

28 One of the great things about our relationship with Cooper Nuclear Plant is that they have been
29 good partners for the communities that they are neighbors to. One example of that would be the
30 fact that most of my day today was spent taking delivery on sirens that Cooper Nuclear has
31 donated for several local communities in the area, both in Nebraska and Missouri, that lacked
32 operational or modern sirens. These retired sirens from Cooper, although they are dating back to
33 the 1970s, are well maintained and very functional and will certainly be a vital asset to communities
34 that could not otherwise afford replacement of their siren equipment. That's a real benefit to
35 everybody.

36 Also, my relationship with Cooper has been excellent. I correspond or talk to Cooper
37 representatives at least monthly, generally more often, in regard to emergency planning exercises
38 and just day-to-day communications checks. Every time I have talked to somebody from the
39 station, they have always been very professional and very competent, and I have very great
40 confidence in the plant and their operations. It's a joy to be here in Nemaha County, and one of that
41 joys is serving the County in this relationship to Cooper Nuclear. Thanks very much for the
42 opportunity to be here. (End of Comment CNS-1-F)

1 **Comment CNS-1-G:** Good evening. I have prepared comments which I'd be happy to give to you
2 if you would like them at the end of the meeting. I apologize. I maybe have gotten a little bit too
3 lengthy, but I'll try to talk fast.

4 My name is Rod Vandenberg, and I am the mayor of Falls City, Nebraska. Falls City is a community
5 of 4,200, and is located about 20 miles south of Cooper Nuclear Station as you head toward the
6 Nebraska/Kansas border.

7 Interestingly, I personally had the opportunity, along with 18 community members from Falls
8 City, to tour Cooper Nuclear Station last Monday. I can speak for myself and the others who
9 took the tour that we were very impressed by the serious and cordial manner in which NPPD
10 employees were watching out for our personal safety while we were on tour, and also by the
11 extent of the security presence at the site. This opportunity gave us all a little better first-hand
12 look at Cooper Nuclear Station, which many of us had not seen, but have heard so much about
13 over the years. Perhaps properly so, Cooper is a well kept secret. And I would like to take this
14 opportunity to thank everyone who participated with us in that tour. We had the opportunity to
15 hear from the gentleman who heads the management company. And then we had the
16 opportunity to be with several NPPD employees. And it was really an outstanding experience.

17 The impact of going inside such a facility and seeing how well the facility is maintained and how
18 expansive the facility is, how it serves to protect employees, public, and the environment was
19 time well spent. I want to thank NPPD for this opportunity.

20 Several months ago, I sat in a breakfast meeting right here in this building in Auburn and heard
21 from your CEO, Ron Asche, and other NPPD employees about the license renewal process,
22 what the needs for extending of licensing of Cooper for an additional 20 years means, and what
23 does that mean not only for my community, but all of Nebraska. What I learned is that NPPD
24 has put an extensive amount of money into facility improvements for safety and operations of
25 the facility so that it can be an operation that will be able to operate safely and efficiently for an
26 additional 20 years. What I also heard at that time was that replacing Cooper would take several
27 billion dollars to construct another generating facility, probably using coal as fuel to replace the
28 electric generation of Cooper. Just getting a facility sited may be a significant task, and
29 replacing Cooper with that kind of facility may not be the most environmentally friendly one, as
30 Cooper does not generate any greenhouse gases from its nuclear operations.

31 I realize that there are numerous areas that are required to be reviewed by the U.S. Nuclear
32 Regulatory Commission related to the license renewal application, many dealing with the
33 environment, another part on how equipment is expected to last if Cooper Nuclear Station were
34 to operate another 20 years. As I heard at our meeting in the fall, Nebraska Public Power
35 District's Board of Directors has had the foresight to invest millions of dollars into the operation
36 in order to continue that operation in a safe manner, and that is what we expect for the residents
37 of Falls City, Richardson County, and southeast Nebraska.

38 Our community leaders in Falls City also heard from NPPD, at my request, to tell us more about
39 the license renewal in a luncheon session in Falls City two or three months ago. Many in the
40 room that day have had contact with Cooper employees, both personal or for business reasons,
41 for we have a contingent of employees that reside in Falls City and Richardson County, 101
42 employees to be exact.

43 From a socio-economic aspect, that number is important in small communities such as Falls
44 City. Cooper employees do business in our community. They are part of community activities,

Appendix A

1 and they support our schools and services. These individuals operate an important electric
2 generation for Nebraska, and they do it safely in a nuclear operation. On our tour, we were able
3 to get a peek at a control room simulator and what these highly trained employees must train to
4 do. The requirements are rigorous to meet the requirements to become a licensed operator.

5 A loss of Cooper would cause a severe negative impact on Falls City as would it be for all of
6 southeastern Nebraska.

7 NPPD's CEO, Ron Asche, spoke to us last year about several maintenance issues at the plant.
8 He could have easily passed over telling us that information, but he chose to do so, and he
9 expressed confidence to us that NPPD would resolve these issues to the satisfaction of the
10 NRC and return Cooper to the top level of operations for nuclear power plants in the country.
11 And as I have learned, those words have been put into action and those findings have been
12 resolved. Frankly, I believe Cooper is one of the safest nuclear plants in the United States.

13 I, and the members of the City Council of Falls City, recently passed a unanimous resolution of
14 support for Cooper Nuclear Station's license extension for an additional 20 years. We feel that it
15 is an important asset for southeast Nebraska and Nebraska in general, and I would like for this
16 resolution to be included in the official meeting transcript tonight.

17 I want to thank the Nuclear Regulatory Commission for taking the time to hear from
18 communities such as ours on this very important issue, not only locally, but nationally, as we
19 work towards future energy independence. Thank you very much. (End of Comment CNS-1-G)

20 **Comment CNS-1-H:** Good evening. Thank you, Dave. And I'd like to thank the NRC. I'd also
21 like to thank the cities and counties of southeastern Nebraska for the opportunity to attend this
22 scoping meeting. My name is Larry Shepard. I'm an environmental scientist with the U.S.
23 Environmental Protection Agency, in our Kansas City Regional Office. EPA has 10 regional
24 offices around the country. Our regional office is responsible for EPA program activities in
25 Kansas, Iowa, Missouri, and Nebraska.

26 My point in speaking tonight was just to help everyone tonight to understand what EPA's role is
27 in this process, this relicensing process. EPA will be reviewing the Draft Supplemental
28 Environmental Impact Statement and providing comment, but also in actually scoring both the
29 document and the project itself. And we will also, in addition to that, be providing comment --
30 scoping comment to NRC by the March 27th deadline. And that was really my whole purpose. If
31 anyone has any questions after the meeting, I'll be hanging around also. Thank you very much.
32 (End of Comment CNS-1-H)

33 **Comment CNS-1-I:** Good evening. My name is Bob Engles, and I'm the mayor of Auburn,
34 Nebraska. I'd like to thank the NRC for this opportunity and specifically for holding this public
35 forum.

36 As I was watching the NRC presentation, safety review and environmental impact studies were
37 mentioned as key parts of the process. I trust that both NPPD and the NRC will conduct a
38 thorough process to identify issues that must be addressed in these areas so that Cooper
39 Nuclear Station can continue operating for an additional 20 years.

40 That's exactly why I'm here. I'm here in support of extending the license for Nebraska Public
41 Power District's Cooper Nuclear Station. I'll speak just a little bit about the socio-economic
42 impact on my city in particular. From a practical standpoint, I'm not sure it makes sense to

1 discard a proven and effective method of power generation, especially when it has served
2 Auburn, Nemaha County, and the state of Nebraska for so many years as a safe and reliable
3 source of electrical generation for the last 35 years in a manner that has protected the public
4 and the environment.

5 Cooper Nuclear Station is an economic stimulus to Auburn and southeast Nebraska. Their
6 footprint is a stabilizing factor in our community's economy. For example, they employ
7 approximately 720 people, and half of those people live in Nemaha County; 234 of those people
8 live in Auburn.

9 The plant's annual payroll is approximately \$55 million. Over \$17 million of that payroll goes to
10 people that live in Auburn, and with just a little bit of math, that shows that the average income
11 per employee living in Auburn is about \$75,000. These employees are highly educated, highly
12 trained and skilled, and they do a quality job day in and day out with safety as their prime
13 responsibility.

14 Cooper employees have become a part of the fabric of this community over the years. They live
15 here. They're involved in community activities. They're involved in our churches; they frequent
16 the business community; they are involved in youth activities and social events within our
17 community.

18 These people are our friends. They're our neighbors. Their kids attend our schools. They
19 volunteer their time to make Auburn and southeast Nebraska a better place in which to live.

20 Late last year, following NPPD's submittal of a license renewal application, Ron Asche, CEO
21 and President of NPPD, which owns Cooper, held a series of meetings within the community
22 with myself and other elected officials from other communities and the business community. Mr.
23 Asche pointed out that NPPD's Board of Directors has invested over \$300 million in
24 improvements to Cooper in preparation for the license extension. NPPD is serious about making
25 these improvements that will enhance the safety of the operations, as well as continuing to
26 generate low-cost electricity, something that Nebraskans expect and which NPPD is mandated
27 under state law to do.

28 Several years ago, NPPD discussed the possibility of closing Cooper. This community was
29 concerned about that, primarily because of the impact on the economy of Auburn and southeast
30 Nebraska. Closing Cooper would have been unfortunate. But NPPD's Board of Directors saw
31 the value in keeping the facility operating and have done a great job in moving forward with the
32 safe operations of the facility, something that was expected to continue for another 20 years.

33 Indeed, all Nebraskans benefit from the operation of Cooper Nuclear Station. Auburn has
34 benefited from Cooper's operations directly, even though the plant is 10 miles away. Nebraska
35 Public Power District has two facilities in our community that we believe are important for the
36 operations of the site. The former Sheridan Elementary School has been transformed into a
37 training center for Cooper employees and the many contractors who come into the community
38 every 18 months for refueling outages. We believe that the training facility plays a great part of
39 the strong environmental responsibility and safe operations of the facility each day.

40 A second facility was remodeled in our downtown area and houses a state-of-the-art
41 Emergency Operations Center which would operate as needed. Exercises are held on a regular
42 basis from that facility, including ones with local emergency management personnel from
43 southeast Nebraska.

Appendix A

1 As mayor, I'm confident in the ability of NPPD to operate and manage in a safe manner. What
2 we may hear from people that are concerned about safety issues, we can all be concerned
3 about safety issues. But throughout the years, I've come to know that the people at Cooper and
4 NPPD have confidence and that they understand the risks associated with nuclear power
5 generation and that they have been and continue to do everything in their power to ensure my
6 safety and our community's safety, because the same people that are working at NPPD Cooper
7 Nuclear Station live in Auburn. They live in Brownville, Nemaha County, Falls City, and
8 Nebraska City.

9 And at this time, I'd like to introduce into the formal record a resolution that our City Council
10 passed a while back unanimously approving support for the extension of the Cooper Nuclear
11 Station license.

12 And once again, I'd like to thank the NRC for hosting these meetings in our community, and if
13 there's anything our town can do to help you further this process, please do not hesitate to
14 contact us. Thank you. (End of Comment CNS-1-I)

15 **Comment CNS-1-J:** Good evening. My name is Kendall Neiman and I'm President of Auburn
16 Chamber of Commerce, and also the publisher of the Nemaha County Herald, the local weekly
17 newspaper here. On behalf of the Auburn Chamber of Commerce, I'm expressing full support
18 for the Nebraska Public Power District's application to extend the Cooper Nuclear Station for an
19 additional 20 years.

20 We believe that Cooper's safety and performance speaks for NPPD's expertise in nuclear plant
21 operations. Several years ago, it appeared that NPPD might close down the Cooper Nuclear
22 Station. This was something that southeastern Nebraska could not afford to have happen. A
23 community group had an economic study done that gave us a look at what we could see locally
24 if the facility was closed. That was about six years ago, and that picture was not very pretty.
25 Devastating might be a better word. If Cooper Nuclear were not to continue operating after its
26 current license expires, we could see those impacts all over southeastern Nebraska.

27 Over 700 employees live, work, shop, and are involved in the communities in southeastern
28 Nebraska. A majority of these employees live right here in Auburn and Nemaha County. They
29 are contributors to the community, but they are also workers at the nuclear power plant that
30 emphasizes nuclear safety of all as a top priority.

31 I recently attended an open house held by NPPD in the Cooper Nuclear facility and was able to
32 learn more about the license extension, safety, emergency response, and other operations of
33 the facility. It's very complex, but I found that the people that I talked to be very knowledgeable
34 and they were concerned with safety of the operations, but they were very proud of what they
35 do on a daily basis. It is our hope that the Nuclear Regulatory Commission's review of the
36 license application will be thorough in both the environmental review as well as the safety
37 review of the Cooper Nuclear Station as required for license renewal. We believe that NPPD
38 has done an excellent job in the operation of the facility as they have turned out a record
39 generation year in 2007, have maintained a strong safety culture for the safety of the employees
40 and the public, and maintained a high visible emergency response operation with local
41 governments and continue to watch over a reliable generating source of electricity for
42 Nebraskans with a watchful eye.

43 The Auburn Chamber of Commerce supports this license renewal extension and look forward to
44 the Nuclear Regulatory Commission's review of the facility and seeing a 20-year extension

1 added to the existing license of the facility. Again, thank you for coming to Auburn and giving the
2 community an opportunity to be heard. (End of Comment CNS-1-J)

3 **Comment CNS-1-K:** My name is David Sickel. I'm one of the three County Commissioners from
4 Richardson County. I'm pleased to have the opportunity to speak to the Nuclear Regulatory
5 Commission concerning the extension of the Cooper Nuclear Station's license for an additional
6 20 years.

7 While Richardson County may be somewhat outside the influence of Cooper Nuclear Station's
8 operations, it is important to acknowledge that over the years this facility has been able to
9 operate in a safe and effective manner for the residents of Nebraska. It is important that a
10 complete review of the environmental impacts for 20 more years of operation be studied
11 thoroughly by both the Nebraska Public Power District and the Nuclear Regulatory Commission.

12 As I understand another critical phase is a safety review. Again, this is important this type of
13 review be conducted to ensure that equipment at the facility can operate an additional 20 years
14 without having the impact on employee and public safety. The fact that much of this information
15 is available to the public and can have public involvement is an important aspect of the entire
16 process.

17 Cooper Nuclear Station is an important part of our community. It operates safely. The
18 employees at Cooper are highly trained. Cooper generates a reliable source of electricity for the
19 people of the state of Nebraska. Employees reside in communities such as Richardson County.
20 Over the years, the presence of Cooper employees in southeast Nebraska has been an
21 important part of our economy, our schools, or business community, and the community in
22 which these folks live. The impact on this area from the loss of Cooper operations would create
23 an economic hardship when you consider those losses. That loss would impact Richardson
24 County, southeast Nebraska, and the complete state of Nebraska.

25 On behalf of the citizens of Richardson County, we are in support of the extension of the Cooper
26 Nuclear Station's license renewal for an additional 20 years.

27 In a letter that I wrote to NPPD's CEO and President, Ron Asche, I explained that Richardson
28 County was proud to have Cooper Nuclear Station in the Richardson County area. Cooper
29 Nuclear Station clearly demonstrated its ability to provide safe and reliable electricity for citizens
30 of Nebraska. I would like to mention that as the only public power state in the country, we enjoy
31 having the fifth lowest cost electricity rates in the United States. Richardson County, through its
32 Emergency Management has supported the facility in its off-site responsibilities to protect the
33 public for many years, and we are glad to be part of that team that supports Cooper and nuclear
34 power.

35 Thank you for this opportunity to speak to you this evening. (End of Comment CNS-1-K)

36 **Comment CNS-1-L:** I'm Ron Asche, the President and CEO of Nebraska Public Power District,
37 the owner and operator of Cooper Nuclear Station. We began our process of compiling our
38 license renewal application several years ago, and submitted that to the NRC in September of
39 this past year. These public meetings tonight conducted by the NRC are a very important
40 process in that relicensing process. They provide an opportunity for members of the local
41 communities that surround Cooper Station and for other interested stakeholders to provide input
42 directly to the NRC regarding our license application and any issues that they may have
43 regarding the environmental impacts of extending Cooper's license for another 20 years, as well

Appendix A

1 as any public safety issues that they may have. And I'd like to thank all of those that came this
2 evening to express their comments to the Nuclear Regulatory Commission, both in these
3 meetings today and for comments that you might submit via letter or e-mail, et cetera. These
4 are a very important part of that process.

5 I want to close just by saying that NPPD is committed to operating Cooper Station, both now
6 and in the future, in a manner that protects the health and safety of the public and all of our
7 employees and workers at the plant, as well as protecting the environment. We look forward to
8 working together with the NRC over the course of the next several years in addressing issues
9 that may arise, which we hope will ultimately result in an extension of our license for another 20
10 years to operate Cooper Station and continue to provide low cost, reliable, and safe energy to
11 the members of our communities and the state of Nebraska as a whole. Thank you. (End of
12 Comment CNS-1-L)

1 Comment CNS-1-M



PAWNEE CITY DEVELOPMENT CORPORATION

**P.O. Box 85
Pawnee City, NE 68420**

Pawnee City - "Pleasant Past, Progressive Future"

Chief, Rulemaking
Directives and Editing Branch
Division of Administrative Services, Office of Administration
Mailstop T-6D59
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555-0001

12/30/08
73 FR 79921
(2)

To Whom It May Concern:

The Pawnee City Economic Development Corporation is submitting this letter to support the renewal of the license for Cooper Nuclear Station operated by Nebraska Public Power in southeast Nebraska. Our group recognizes the importance of the Station in providing low cost and safe energy to our region. We can assure any potential business, that the Station is committed to safety by their safe operations for the past 40 years and their investment of \$300 million to upgrade the facility. Their trained workforce has a strong economic impact on our area. We do not see any negative environmental impact with this facility but if it were to be replaced by a coal-powered plant, we do not think that would be the case. We urge you to approve the license renewal so we have good, clean, green energy for years to come.

CNS-1-M

Sincerely,

Alan Richard
Alan Richard
President, Pawnee City Development Corporation

RECEIVED

2009 MAR 10 AM 10:06

RULES AND REGULATIONS
BRANCH
12-30-08

SUNSI Review Complete
Template = ADM-013

E-RIDS = ADM-03
Cdd = E. SAYOC (ECS3)

2

3 (CNS-1-M)

Appendix A

1 Comment CNS 1-N



500 South Main
Rock Port, MO 64482
Phone 660-744-2636 • FAX 660-744-5553
rpcityhall@ rpf.coop

February 27, 2009

12/30/08
73 FR 79921

(3)

RECEIVED

2009 MAR 11 AM 10:04

FILES AND DIRECTIVES
BRANCH
19450

Chief, Rules and Directives Branch
Division of Administrative Services
Office of Administration
U.S. Nuclear Regulatory Commission
Mailstop T-6D 59
Washington, D.C. 20555-0001

To whom it may concern:

Please find enclosed a copy of Resolution #2009-1 supporting Nebraska Public Power District's Cooper Nuclear Station License Renewal passed by the City of Rock Port on February 18, 2009.

CNS-1-N

Sincerely,

Ashtin Paris
Deputy Clerk
City of Rock Port

SOVER Review Complete
Template = ADM-013

EL-RDS = ADM-03
Call = E. Soyoo (ECS3)

- 2
- 3 (CNS-1-N)

RESOLUTION # 2009-1

**A RESOLUTION OF THE BOARD OF ALDERMEN
OF THE CITY OF ROCK PORT, MISSOURI
Supporting Nebraska Public Power District's
Cooper Nuclear Station License Renewal**

WHEREAS, Nebraska Public Power District's Cooper Nuclear Station in Brownville became operational with startup in 1974; and

WHEREAS, Cooper Nuclear Station has operated safely and efficiently for more than 30 years, generated a record 6.6 million megawatt hours of electricity in 2007, and its 828 megawatts of electrical generating capacity remains vital to Nebraska's economy; and

WHEREAS, Nebraska Public Power District has continually reinvested in the Cooper Nuclear Station facility to assure continued safe, clean, reliable and affordable production of electricity for Nebraskans across the state; and

WHEREAS, Cooper Nuclear Station is a critical asset as part of Nebraska Public Power District's generation resources and the state's unique public power system, continues to assist in keeping state electric rates among the lowest in the country; and

WHEREAS, more than 700 permanent jobs at Cooper Nuclear Station and the extensive use of contractors for ongoing maintenance and refueling outages are recognized as vitally important to the economies of the City of Rock Port, Atchison County, and surrounding communities of southeastern Nebraska and northwest Missouri; and

WHEREAS, Nebraska Public Power District submitted an application to renew Cooper Nuclear Station's operating license to the United States Nuclear Regulatory Commission on September 29, 2008; and


WHEREAS, the United States Nuclear Regulatory Commission is the federal agency charged with oversight of our nation's vital nuclear facilities and encourages public input and comment on license renewal proceedings from its neighboring communities; and

WHEREAS, Cooper Nuclear Station has been a good neighbor to its communities for more than three decades and its employees are interwoven into the fabric of the community, local schools churches, and community activities;

NOW, THEREFORE, BE IT RESOLVED that the City of Rock Port City Council supports the renewal of the license for the nuclear generating facilities at Cooper Nuclear Station, to assure their continued operation of safe, affordable and integrally important component of Nebraska's public power electric power supply system for another 20 years; and

BE IT FURTHER RESOLVED that the City of Rock Port City Clerk is directed to make available a copy of this resolution to the Nuclear Regulatory Commission at its upcoming Environmental Scoping Public meeting.

Passed and approved this 18th day of February 2009


Helen Jo Stevens, Mayor

ATTEST:


Maureen K. Moore, City Clerk/Admin.

1

CNS-1-N

1 Comment CNS-1-0:

Emergency response- James Gerweck, Richardson County

Good afternoon, many thanks to the NRC for hosting this public forum. I'm James Gerweck. I am the Director of the Richardson County, Nebraska, Emergency Management Agency. In my position, hardly a month has gone by where some form of interchange has not transpired between the Cooper Nuclear Station's Emergency Management Department and other nuclear operations staff and my office in Richardson County.

The referenced activities included quarterly emergency communications drills, unannounced communications checks, written correspondence involving improvements in emergency plans and training in many forms to include FEMA evaluated radiological emergency preparedness exercises. Other joint training activities include NPPD staff involvement and annual training of our radiological emergency response organization and our joint quarterly off-site training meetings.

Cooper Nuclear Station has fully demonstrated its ability to provide safe and reliable electricity for the citizens of the State of Nebraska. Richardson County has supported CNS in its offsite responsibilities to protect the public and property for many years and is glad to be a part of the team that supports nuclear power.

The bottom line in our realm of experience, the staff at the NPPD and Cooper Nuclear Station is thoroughly professional and meticulous in attention to detail concerning their approach to public safety. In short, they are fully integrated and a key member of our

CNS-1-0

1 of 2

public safety team and in view of their professional performance and contributions to our community, and we support the NPPD's application to continue operating at Cooper Nuclear Station for another 20 years.

CNS-1-O

In closing, Richardson County is proud to have CNS in the Richardson County area.

Thank you.

James A. Gerweck, director

P.O. Box 609

Falls City, Nebraska 68355

402-245-2446 office

402-245-5578 Fax

rcema@sentco.net Email

- 1
- 2 (CNS-1-O)
- 3 **NRC Response to Comments CNS-1-A through CNS-1-O:** The comments are supportive of
- 4 license renewal. The comments are general in nature, provide no new information and,
- 5 therefore, will not be evaluated further. No change to the scope of the Cooper Nuclear Station
- 6 Environmental Impact Statement (EIS) will be made as a result of these comments.

1 **A.3. Comments Regarding the license renewal review of Cooper Nuclear Station,**
2 **Unit, 1**

Emmanuel Sayoc

From: CooperEIS Resource
Sent: Thursday, April 16, 2009 1:39 PM
To: Emmanuel Sayoc
Subject: FW: Scoping Comments for Relicensing of Cooper Nuclear Station, Brownvi

-----Original Message-----

From: Shepard.Larry@epamail.epa.gov [mailto:Shepard.Larry@epamail.epa.gov]
Sent: Friday, March 27, 2009 4:59 PM
To: CooperEIS Resource
Cc: Cothorn.Joe@epamail.epa.gov; Hooper.CharlesA@epamail.epa.gov; Dunn.John@epamail.epa.gov; Lancaster.Kris@epamail.epa.gov
Subject: Scoping Comments for Relicensing of Cooper Nuclear Station, Brownville, NE

RE: Notice of Intent to Prepare an Environmental Impact Statement and Conduct Scoping Process for Cooper Nuclear Station; Federal Register Volume 74, No. 15, January 26,2009, page 4476.

Thank you for the opportunity to provide scoping comments on the proposed relicensing of Cooper Nuclear Station (CNS), in support of the U.S. Nuclear Regulatory Commission's (NRC) preparation of an Environmental Impact Statement (EIS). EPA reviewed this project in accordance with the National Environmental Policy Act (NEPA) and Section 309 of the Clean Air Act. We request that, in the future, the NRC provide an adequate period of time after conducting site audits for the submission of scoping comments by state or federal agencies. In this instance, scoping comments are to be submitted prior to the NRC site audit for this project.

Please consider the following comments during the EIS development process.

Radiation - Given the uncertainty involved with licensing the Yucca Mountain Nevada facility and the extremely long time-frames needed to secure Congressional approval and complete site preparation for any possible alternative permanent site for the disposal of spent nuclear fuel, all utilities planning on extending operation of existing nuclear units should consider contingencies for long-term storage of waste on-site.

Water Quality - The current CNS site has an existing infrastructure, which includes intake and discharge structures. The source of water for the plant is the Missouri River. Potential impacts to plant operation associated with available river flow, particularly during periods of sustained low flow, should be thoroughly described in the draft EIS. The draft EIS should articulate the assurance of a long-term water supply (i.e., greater than 20 years) for the operation of the reactor. This analysis should address contingencies created by changing regional climate and potential future changes in the operation of the river by the Army Corps of Engineers (i.e., flow

3

CNS-1-P

releases). The current facility is covered by a National Pollutant Discharge Elimination System (NPDES) permit issued by the Nebraska Department of Environmental Quality (NDEQ). New studies and analyses performed in support of the most recent permit application (e.g., thermal and chemical discharges) should be included in the draft EIS. The draft EIS should also completely discuss issues associated with entrainment and impingement of aquatic organisms (i.e., Section 316b of the Clean Water Act) and include alternatives to the present intake design. From a review of the Environmental Report, it is apparent that there is a great deal of information available regarding the impact of plant operation on the river ecosystem. However, we generally caution that these studies are 30 years old and the draft EIS should clearly articulate whether these data are representative of current river condition and ecological impact. We would expect the NRC to provide both its reasoning and data supporting that additional and more recent research is not required to adequately document current impacts.

The draft EIS should thoroughly characterize past contamination associated with the operation of CNS, particularly source and fate of tritium in the system, and document current condition of surface water and groundwater upstream and downstream from the site.

Environmental Management System - The Council on Environmental Quality (CEQ) published "Aligning NEPA processes with Environmental management Systems-A Guide for NEPA and EMS Practitioners" to improve NEPA implementation and environmental sustainability goals in NEPA and Executive Order 13423. The NEPA document should discuss EMS as appropriate.

CNS-1-P
continued

Larry Shepard
NEPA Team/Interstate Waters
US EPA Region 7
913-551-7441



NEBRASKA STATE HISTORICAL SOCIETY
1500 R STREET, P.O. BOX 82554, LINCOLN, NE 68501-2554
(402) 471-3270 Fax: (402) 471-3100 1-800-833-6747 www.nebraskahistory.org
Michael J. Smith, Director/CEO

February 2, 2009

Mr. David L. Pelton, Chief
Division of License Renewal
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555-0001

RE: Cooper Nuclear Station license renewal HP# 0801-050-001

Dear Mr. Pelton:

Thank you for submitting the referenced project for our review and comment. Our comment on this project and its potential to affect historic properties is required by Section 106 of the National Historic Preservation Act of 1966, as amended, and implementing regulations 36 CFR Part 800. Before we are able to adequately review the proposed Area of Potential Effect (APE) for this project for its potential to affect historic properties, we require the following information:

- A map clearly defining the boundaries of the APE

Please submit this information to: Bob Puschendorf, Nebraska State Historic Preservation Office, P.O. Box 82554, 1420 P Street, Lincoln, NE 68501-2554.

Sincerely,

Jill E. Dolberg
Review and Compliance Coordinator
Nebraska State Historic Preservation Office

Cc: Tam Tran, NRC
Emmanuel Sayoc, NRC
Steward B. Minahan, Chief Nuclear Officer, Cooper Nuclear Station

CNS-1-Q

1

2 (CNS-1-Q)



Dave Heineman
Governor

STATE OF NEBRASKA
DEPARTMENT OF NATURAL RESOURCES
Brian P. Dunnigan, P.E.
Director

March 9, 2009

IN REPLY TO:

David L. Pelton, Branch Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation
United State Regulatory Commission
Washington, DC 20555

Dear Mr. Pelton:

A letter sent by you February 4, 2009, to the Nebraska Department of Natural Resources is being returned. The letter requests a list of protected species. The appropriate Nebraska agency for such request is the Nebraska Game and Parks Commission at the following address:

CNS-1-R

Kristal Stoner
Nebraska Game and Parks Commission
P.O. Box 30370
Lincoln, NE 68303-0370

If we can be of assistance to you in other matters, please feel free to contact us.

Sincerely,

Jean E. Angell
Jean E. Angell

Enclosure

cc: Kristal Stoner, NGPC

legal/angell/2009

301 Centennial Mall South, 4th Floor • PO. Box 94676 • Lincoln, Nebraska 68509-4676 • Phone (402) 471-2363 • Telefax (402) 471-2900

An Equal Opportunity/Affirmative Action Employer

Printed with soy ink on recycled paper

1
2 (CNS-1-R) The NRC subsequently sent correspondence to the Nebraska Game and Parks
3 Commission and received the requested list of protected species by email as shown in
4 Appendix D1. The NPPD also received a letter the U.S. Fish and Wildlife Service that it
5 "concurs with the NPPD and NRC determination that the proposed relicensing action is not
6 likely to adversely affect federally listed species or result in the destruction or adverse

1 modification of federally designated critical habitat.” This letter is also included in Appendix
2 D.

3 **NRC Response to Comments CNS-1-Q through CNS-R-:** With respect to the comments from
4 the Nebraska State Historical Society (CNS-1-Q), and the Nebraska Department of Natural
5 Resources (CNS-1-R), these comments contain matter from consultations with other
6 government agencies, which support the license renewal review process. No change to the
7 scope of the Cooper Nuclear Station Environmental Impact Statement (EIS) will be made as a
8 result of these comments.

9 With respect to the EPA scoping comments (CNS-1-P) regarding the disposal of spent nuclear
10 fuel, all utilities planning on extending operation of existing nuclear units should consider
11 contingencies for long-term storage of waste on-site.

12 The NRC fully evaluated and addressed this issue in our Generic Environmental Impact
13 Statement for License Renewal of Nuclear Plants (NUREG-1437) and in its regulations. The
14 current and potential environmental impacts from spent fuel storage onsite at the current reactor
15 sites have been studied extensively and are well understood. The storage of spent fuel in spent
16 fuel pools was considered for each plant in the safety and environmental reviews at the
17 construction permit and operating license stage. The NRC has studied the safety and
18 environmental effects from the temporary storage of spent fuel after the cessation of reactor
19 operations (which may include the term of a revised or renewed license), and it published a
20 generic determination of no significant environmental impact (the Waste Confidence Rule) in its
21 regulations at 10 CFR 51.23. 10 CFR 51.23 (a) states

22 The Commission has made a generic determination that, if necessary, spent fuel
23 generated in any reactor can be stored safely and without significant
24 environmental impact for at least 30 years beyond the licensed life for operation
25 (which may include the term of a revised or renewed license) of that reactor at its
26 spent-fuel storage basin or at either on-site or off-site independent fuel storage
27 installations.

28 In September 2009, the Commission reviewed this rule and declined to approve an update of
29 the rule. In accordance with this determination, the rule also provides that no discussion is
30 required concerning the environmental impacts of spent fuel storage for the period following the
31 term of the reactor operating license, including a renewed license. Therefore, the SEIS will not
32 include a discussion on the storage of spent nuclear fuel.

33 With respect to the EPA scoping comments (CNS-1-P), regarding past contamination
34 associated with the operation of CNS-1, particularly source and fate of tritium in the system, the
35 draft SEIS will have a discussion on the impacts of radioactive liquid effluents discharged into
36 the Missouri River. The discussion will evaluate the radiological dose impact to members of the
37 public as well the impact to the environment. The SEIS will also discuss the results of Cooper’s
38 radiological environmental monitoring program in which environmental sample media are
39 collected and analyzed in order to evaluate the radiological impacts, if any, of plant operation on
40 the environment.

41 With respect to the EPA scoping comments (CNS-1-P), regarding water quality, the SEIS will
42 discuss NPDES permits and related activities including any updated information, available river
43 flow including low flows, USACE river flow control operations, as well as aquatic and terrestrial
44 ecosystem issues. The NRC staff does recognize that the river ecological studies are generally
45 dated, and will address this issue in the EIS. The NRC staff is doing a search for more recent

1 data. The staffs analysis, findings, as well as references and data used will be outlined in the
2 EIS and referenced for publicly availability. .

3 **A.4. References**

4 74 FR 4476. U.S. Nuclear Regulatory Commission, Washington, D.C, "United States Nuclear
5 Regulatory Commission, Nebraska Public Power District, Cooper Nuclear Station, Notice of
6 Intent to Prepare an Environmental Impact Statement and Conduct Scoping Process, *Federal*
7 *Register*: Vol. 74, No. 15, pp. 4476–4477 January 26, 2009.

8 NRC (U.S. Nuclear Regulatory Commission). "Summary of Public Environmental Scoping
9 Meeting Related to the Review of the Cooper Nuclear Station Unit 1 License Renewal
10 Application," 2009. ADAMS Accession No. ML000910308.

1
2
3

**APPENDIX B.
NATIONAL ENVIRONMENTAL POLICY ACT ISSUES FOR
LICENSE RENEWAL OF NUCLEAR POWER PLANTS**

1 **B. NATIONAL ENVIRONMENTAL POLICY ACT ISSUES FOR LICENSE**
 2 **RENEWAL OF NUCLEAR POWER PLANTS**

3 Table B-1. Summary of Issues and Findings. *This table is taken from Table B-1 in Appendix B,*
 4 *Subpart A, to 10 CFR Part 51. Data supporting this table are contained in NUREG-1437,*
 5 *Generic Environmental Impact Statement for License Renewal of Nuclear Plants. Throughout*
 6 *this report, “Generic” issues are also referred to as Category 1 issues, and “Site-specific” issues*
 7 *are also referred to as Category 2 issues.*

Issue	Type of Issue	Finding
Surface Water Quality, Hydrology, and Use		
Impacts of refurbishment on surface water quality	Generic	SMALL. Impacts are expected to be negligible during refurbishment because best management practices are expected to be employed to control soil erosion and spills.
Impacts of refurbishment on surface water use	Generic	SMALL. Water use during refurbishment will not increase appreciably or will be reduced during plant outage.
Altered current patterns at intake and discharge structures	Generic	SMALL. Altered current patterns have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Altered salinity gradients	Generic	SMALL. Salinity gradients have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Altered thermal stratification of lakes	Generic	SMALL. Generally, lake stratification has not been found to be a problem at operating nuclear power plants and is not expected to be a problem during the license renewal term.
Temperature effects on sediment transport capacity	Generic	SMALL. These effects have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Scouring caused by discharged cooling water	Generic	SMALL. Scouring has not been found to be a problem at most operating nuclear power plants and has caused only localized effects at a few plants. It is not expected to be a problem during the license renewal term.
Eutrophication	Generic	SMALL. Eutrophication has not been found to be a problem at operating nuclear power plants and is not expected to be a problem during the license renewal term.
Discharge of chlorine or other biocides	Generic	SMALL. Effects are not a concern among regulatory and resource agencies, and are not expected to be a problem during the license renewal term.
Discharge of sanitary wastes and minor chemical spills	Generic	SMALL. Effects are readily controlled through National Pollutant Discharge Elimination System (NPDES) permit and periodic modifications, if needed, and are not expected to be a problem during the license renewal term.

Appendix B

Issue	Type of Issue	Finding
Discharge of other metals in wastewater	Generic	SMALL. These discharges have not been found to be a problem at operating nuclear power plants with cooling-tower-based heat dissipation systems and have been satisfactorily mitigated at other plants. They are not expected to be a problem during the license renewal term.
Water use conflicts (plants with once-through cooling systems)	Generic	SMALL. These conflicts have not been found to be a problem at operating nuclear power plants with once-through heat dissipation systems.
Water use conflicts (plants with cooling ponds or cooling towers using makeup water from a small river with low flow)	Site-specific	SMALL OR MODERATE. The issue has been a concern at nuclear power plants with cooling ponds and at plants with cooling towers. Impacts on instream and riparian communities near these plants could be of moderate significance in some situations. See § 51.53(c)(3)(ii)(A).
Aquatic Ecology		
Refurbishment	Generic	SMALL. During plant shutdown and refurbishment, there will be negligible effects on aquatic biota because of a reduction of entrainment and impingement of organisms or a reduced release of chemicals.
Accumulation of contaminants in sediments or biota	Generic	SMALL. Accumulation of contaminants has been a concern at a few nuclear power plants but has been satisfactorily mitigated by replacing copper alloy condenser tubes with those of another metal. It is not expected to be a problem during the license renewal term.
Entrainment of phytoplankton and zooplankton	Generic	SMALL. Entrainment of phytoplankton and zooplankton has not been found to be a problem at operating nuclear power plants and is not expected to be a problem during the license renewal term.
Cold shock	Generic	SMALL. Cold shock has been satisfactorily mitigated at operating nuclear plants with once-through cooling systems, has not endangered fish populations, or been found to be a problem at operating nuclear power plants with cooling towers or cooling ponds, and is not expected to be a problem during the license renewal term.
Thermal plume barrier to migrating fish	Generic	SMALL. Thermal plumes have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Distribution of aquatic organisms	Generic	SMALL. Thermal discharge may have localized effects but is not expected to affect the larger geographical distribution of aquatic organisms.
Premature emergence of aquatic insects	Generic	SMALL. Premature emergence has been found to be a localized effect at some operating nuclear power plants but has not been a problem and is not expected to be a problem during the license renewal term.

Issue	Type of Issue	Finding
Gas supersaturation (gas bubble disease)	Generic	SMALL. Gas supersaturation was a concern at a small number of operating nuclear power plants with once-through cooling systems but has been satisfactorily mitigated. It has not been found to be a problem at operating nuclear power plants with cooling towers or cooling ponds and is not expected to be a problem during the license renewal term.
Low dissolved oxygen in the discharge	Generic	SMALL. Low dissolved oxygen has been a concern at one nuclear power plant with a once-through cooling system but has been effectively mitigated. It has not been found to be a problem at operating nuclear power plants with cooling towers or cooling ponds and is not expected to be a problem during the license renewal term.
Losses from predation, parasitism, and disease among organisms exposed to sublethal stresses	Generic	SMALL. These types of losses have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Stimulation of nuisance organisms (e.g., shipworms)	Generic	SMALL. Stimulation of nuisance organisms has been satisfactorily mitigated at the single nuclear power plant with a once-through cooling system where previously it was a problem. It has not been found to be a problem at operating nuclear power plants with cooling towers or cooling ponds and is not expected to be a problem during the license renewal term.
Aquatic Ecology (for plants with once-through and cooling-pond heat dissipation systems)		
Entrainment of fish and shellfish in early life stages	Site-specific	SMALL, MODERATE, OR LARGE. The impacts of entrainment are small at many plants but may be moderate or even large at a few plants with once-through and cooling-pond cooling systems. Further, ongoing efforts in the vicinity of these plants to restore fish populations may increase the numbers of fish susceptible to intake effects during the license renewal period, such that entrainment studies conducted in support of the original license may no longer be valid. See § 51.53(c)(3)(ii)(B).
Impingement of fish and shellfish	Site-specific	SMALL, MODERATE, OR LARGE. The impacts of impingement are small at many plants but may be moderate or even large at a few plants with once-through and cooling-pond cooling systems. See § 51.53(c)(3)(ii)(B).
Heat shock	Site-specific	SMALL, MODERATE, OR LARGE. Because of continuing concerns about heat shock and the possible need to modify thermal discharges in response to changing environmental conditions, the impacts may be of moderate or large significance at some plants. See § 51.53(c)(3)(ii)(B).
Aquatic Ecology (for plants with cooling-tower-based heat dissipation systems)		
Entrainment of fish and shellfish in early life stages	Generic	SMALL. Entrainment of fish has not been found to be a problem at operating nuclear power plants with this type of cooling system and is not expected to be a problem during the license renewal term.
Impingement of fish and shellfish	Generic	SMALL. The impingement has not been found to be a problem at operating nuclear power plants with this type of cooling system and is not expected to be a problem during the license renewal term.

Appendix B

Issue	Type of Issue	Finding
Heat shock	Generic	SMALL. Heat shock has not been found to be a problem at operating nuclear power plants with this type of cooling system and is not expected to be a problem during the license renewal term.
Ground Water Use and Quality		
Impacts of refurbishment on ground water use and quality	Generic	SMALL. Extensive dewatering during the original construction on some sites will not be repeated during refurbishment on any sites. Any plant wastes produced during refurbishment will be handled in the same manner as in current operating practices and are not expected to be a problem during the license renewal term.
Ground water use conflicts (potable and service water; plants that use <100 gallons per minute (gpm))	Generic	SMALL. Plants using less than 100 gpm are not expected to cause any ground water use conflicts.
Ground water use conflicts (potable and service water, and dewatering plants that use >100 gpm)	Site-specific	SMALL, MODERATE, OR LARGE. Plants that use more than 100 gpm may cause ground water use conflicts with nearby ground water users. See § 51.53(c)(3)(ii)(C).
Ground water use conflicts (plants using cooling towers withdrawing makeup water from a small river)	Site-specific	SMALL, MODERATE, OR LARGE. Water use conflicts may result from surface water withdrawals from small water bodies during low flow conditions which may affect aquifer recharge, especially if other ground water or upstream surface water users come online before the time of license renewal. See § 51.53(c)(3)(ii)(A).
Ground water use conflicts (Ranney wells)	Site-specific	SMALL, MODERATE, OR LARGE. Ranney wells can result in potential ground water depression beyond the site boundary. Impacts of large ground water withdrawal for cooling tower makeup at nuclear power plants using Ranney wells must be evaluated at the time of application for license renewal. See § 51.53(c)(3)(ii)(C).
Ground water quality degradation (Ranney wells)	Generic	SMALL. Ground water quality at river sites may be degraded by induced infiltration of poor-quality river water into an aquifer that supplies large quantities of reactor cooling water. However, the lower quality infiltrating water would not preclude the current uses of ground water and is not expected to be a problem during the license renewal term.
Ground water quality degradation (saltwater intrusion)	Generic	SMALL. Nuclear power plants do not contribute significantly to saltwater intrusion.
Ground water quality degradation (cooling ponds in salt marshes)	Generic	SMALL. Sites with closed-cycle cooling ponds may degrade ground water quality. Because water in salt marshes is brackish, this is not a concern for plants located in salt marshes.
Ground water quality degradation (cooling ponds at inland sites)	Site-specific	SMALL, MODERATE, OR LARGE. Sites with closed-cycle cooling ponds may degrade ground water quality. For plants located inland, the quality of the ground water in the vicinity of the ponds must be shown to be adequate to allow continuation of current uses. See § 51.53(c)(3)(ii)(D).

Issue	Type of Issue	Finding
Terrestrial Ecology		
Refurbishment impacts	Site-specific	SMALL, MODERATE, OR LARGE. Refurbishment impacts are insignificant if no loss of important plant and animal habitat occurs. However, it cannot be known whether important plant and animal communities may be affected until the specific proposal is presented with the license renewal application. See § 51.53(c)(3)(ii)(E).
Cooling tower impacts on crops and ornamental vegetation	Generic	SMALL. Impacts from salt drift, icing, fogging, or increased humidity associated with cooling tower operation have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Cooling tower impacts on native plants	Generic	SMALL. Impacts from salt drift, icing, fogging, or increased humidity associated with cooling tower operation have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Bird collisions with cooling towers	Generic	SMALL. These collisions have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Cooling pond impacts on terrestrial resources	Generic	SMALL. Impacts of cooling ponds on terrestrial ecological resources are considered to be of small significance at all sites.
Power line right of way (ROW) management (cutting and herbicide application)	Generic	SMALL. The impacts of ROW maintenance on wildlife are expected to be of small significance at all sites.
Bird collisions with power lines	Generic	SMALL. Impacts are expected to be of small significance at all sites.
Impacts of electromagnetic fields on flora and fauna	Generic	SMALL. No significant impacts of electromagnetic fields on terrestrial flora and fauna have been identified. Such effects are not expected to be a problem during the license renewal term.
Floodplains and wetland on power line ROW	Generic	SMALL. Periodic vegetation control is necessary in forested wetlands underneath power lines and can be achieved with minimal damage to the wetland. No significant impact is expected at any nuclear power plant during the license renewal term.
Threatened and Endangered Species		
Threatened or endangered species	Site-specific	SMALL, MODERATE, OR LARGE. Generally, plant refurbishment and continued operation are not expected to adversely affect threatened or endangered species. However, consultation with appropriate agencies would be needed at the time of license renewal to determine whether or not threatened or endangered species are present and whether or not they would be adversely affected. See § 51.53(c)(3)(ii)(E).

Appendix B

Issue	Type of Issue	Finding
Air Quality		
Air quality during refurbishment (non-attainment and maintenance areas)	Site-specific	SMALL, MODERATE, OR LARGE. Air quality impacts from plant refurbishment associated with license renewal are expected to be small. However, vehicle exhaust emissions could be cause for concern at locations in or near nonattainment or maintenance areas. The significance of the potential impact cannot be determined without considering the compliance status of each site and the number of workers expected to be employed during the outage. See § 51.53(c)(3)(ii)(F).
Air quality effects of transmission lines	Generic	SMALL. Production of ozone and oxides of nitrogen is insignificant and does not contribute measurably to ambient levels of these gases.
Land Use		
Onsite land use	Generic	SMALL. Projected onsite land use changes required during refurbishment and the renewal period would be a small fraction of any nuclear power plant site and would involve land that is controlled by the applicant.
Power line ROW	Generic	SMALL. Ongoing use of power line ROWs would continue with no change in restrictions. The effects of these restrictions are of small significance.
Human Health		
Radiation exposures to the public during refurbishment	Generic	SMALL. During refurbishment, the gaseous effluents would result in doses that are similar to those from current operation. Applicable regulatory dose limits to the public are not expected to be exceeded.
Occupational radiation exposures during refurbishment	Generic	SMALL. Occupational doses from refurbishment are expected to be within the range of annual average collective doses experienced for pressurized-water reactors and boiling-water reactors. Occupational mortality risk from all causes including radiation is in the mid-range for industrial settings.
Microbiological organisms (occupational health)	Generic	SMALL. Occupational health impacts are expected to be controlled by continued application of accepted industrial hygiene practices to minimize exposure to workers.
Microbiological organisms (public health)(plants using lakes or canals, or cooling towers or cooling ponds that discharge to a small river)	Site-specific	SMALL, MODERATE, OR LARGE. These organisms are not expected to be a problem at most operating plants except possibly at plants using cooling ponds, lakes, or canals that discharge to small rivers. Without site-specific data, it is not possible to predict the effects generically. See § 51.53(c)(3)(ii)(G).
Noise	Generic	SMALL. Noise has not been found to be a problem at operating plants and is not expected to be a problem at any plant during the license renewal term.

Issue	Type of Issue	Finding
Electromagnetic fields – acute effects (electric shock)	Site-specific	SMALL, MODERATE, OR LARGE. Electrical shock resulting from direct access to energized conductors or from induced charges in metallic structures have not been found to be a problem at most operating plants and generally are not expected to be a problem during the license renewal term. However, site-specific review is required to determine the significance of the electric shock potential at the site. See § 51.53(c)(3)(ii)(H).
Electromagnetic fields – chronic effects	Uncategorized	UNCERTAIN. Biological and physical studies of 60-hertz (Hz) electromagnetic fields have not found consistent evidence linking harmful effects with field exposures. However, research is continuing in this area and a consensus scientific view has not been reached.
Radiation exposures to public (license renewal term)	Generic	SMALL. Radiation doses to the public will continue at current levels associated with normal operations.
Occupational radiation exposures (license renewal term)	Generic	SMALL. Projected maximum occupational doses during the license renewal term are within the range of doses experienced during normal operations and normal maintenance outages, and would be well below regulatory limits.
Socioeconomic Impacts		
Housing impacts	Site-specific	SMALL, MODERATE, OR LARGE. Housing impacts are expected to be of small significance at plants located in a medium or high population area and not in an area where growth control measures that limit housing development are in effect. Moderate or large housing impacts of the workforce associated with refurbishment may be associated with plants located in sparsely populated areas or in areas with growth control measures that limit housing development. See § 51.53(c)(3)(ii)(I).
Public services: public safety, social services, and tourism and recreation	Generic	SMALL. Impacts to public safety, social services, and tourism and recreation are expected to be of small significance at all sites.
Public services: public utilities	Site-specific	SMALL OR MODERATE. An increased problem with water shortages at some sites may lead to impacts of moderate significance on public water supply availability. See § 51.53(c)(3)(ii)(I).
Public services: education (refurbishment)	Site-specific	SMALL, MODERATE, OR LARGE. Most sites would experience impacts of small significance but larger impacts are possible depending on site- and project-specific factors. See § 51.53(c)(3)(ii)(I).
Public services: education (license renewal term)	Generic	SMALL. Only impacts of small significance are expected.
Offsite land use (refurbishment)	Site-specific	SMALL OR MODERATE. Impacts may be of moderate significance at plants in low population areas. See § 51.53(c)(3)(ii)(I).
Offsite land use (license renewal term)	Site-specific	SMALL, MODERATE, OR LARGE. Significant changes in land use may be associated with population and tax revenue changes resulting from license renewal. See § 51.53(c)(3)(ii)(I).

Appendix B

Issue	Type of Issue	Finding
Public services: transportation	Site-specific	SMALL, MODERATE, OR LARGE. Transportation impacts (level of service) of highway traffic generated during plant refurbishment and during the term of the renewed license are generally expected to be of small significance. However, the increase in traffic associated with the additional workers and the local road and traffic control conditions may lead to impacts of moderate or large significance at some sites. See § 51.53(c)(3)(ii)(J).
Historic and archaeological resources	Site-specific	SMALL, MODERATE, OR LARGE. Generally, plant refurbishment and continued operation are expected to have no more than small adverse impacts on historic and archaeological resources. However, the National Historic Preservation Act requires the Federal agency to consult with the State Historic Preservation Officer to determine whether or not there are properties present that require protection. See § 51.53(c)(3)(ii)(K).
Aesthetic impacts (refurbishment)	Generic	SMALL. No significant impacts are expected during refurbishment.
Aesthetic impacts (license renewal term)	Generic	SMALL. No significant impacts are expected during the license renewal term.
Aesthetic impacts of transmission lines (license renewal term)	Generic	SMALL. No significant impacts are expected during the license renewal term.
Postulated Accidents		
Design basis accidents	Generic	SMALL. The NRC staff has concluded that the environmental impacts of design-basis accidents are of small significance for all plants.
Severe accidents	Site-specific	SMALL. The probability weighted consequences of atmospheric releases, fallout onto open bodies of water, releases to ground water, and societal and economic impacts from severe accidents are small for all plants. However, alternatives to mitigate severe accidents must be considered for all plants that have not considered such alternatives. See § 51.53(c)(3)(ii)(L).
Uranium Fuel Cycle and Waste Management		
Offsite radiological impacts (individual effects from other than the disposal of spent fuel and high level waste)	Generic	SMALL. Offsite impacts of the uranium fuel cycle have been considered by the Commission in Table S-3 of this part. Based on information in the GEIS, impacts on individuals from radioactive gaseous and liquid releases including radon-222 and technetium-99 are small.

Issue	Type of Issue	Finding
Offsite radiological impacts (collective effects)	Generic	<p>The 100-year environmental dose commitment to the U.S. population from the fuel cycle, high level waste, and spent fuel disposal excepted, is calculated to be about 14,800 person rem, or 12 cancer fatalities, for each additional 20-year power reactor operating term. Much of this, especially the contribution of radon releases from mines and tailing piles, consists of tiny doses summed over large populations. This same dose calculation can theoretically be extended to include many tiny doses over additional thousands of years as well as doses outside the United States. The result of such a calculation would be thousands of cancer fatalities from the fuel cycle, but this result assumes that even tiny doses have some statistical adverse health effect which will not ever be mitigated (for example no cancer cure in the next thousand years), and that these doses projected over thousands of years are meaningful; however, these assumptions are questionable. In particular, science cannot rule out the possibility that there will be no cancer fatalities from these tiny doses. For perspective, the doses are very small fractions of regulatory limits, and even smaller fractions of natural background exposure to the same populations.</p> <p>Nevertheless, despite all the uncertainty, some judgment as to the regulatory NEPA implications of these matters should be made and it makes no sense to repeat the same judgment in every case. Even taking the uncertainties into account, the Commission concludes that these impacts are acceptable in that these impacts would not be sufficiently large to require the NEPA conclusion, for any plant, that the option of extended operation under 10 CFR Part 54 should be eliminated. Accordingly, while the Commission has not assigned a single level of significance for the collective effects of the fuel cycle, this issue is considered Category 1 (Generic).</p>
Offsite radiological impacts (spent fuel and high level waste disposal)	Generic	<p>For the high level waste and spent fuel disposal component of the fuel cycle, there are no current regulatory limits for offsite releases of radionuclides for the current candidate repository site. However, if it is assumed that limits are developed along the lines of the 1995 National Academy of Sciences (NAS) report, "Technical Bases for Yucca Mountain Standards," and that in accordance with the Commission's Waste Confidence Decision, 10 CFR 51.23, a repository can and likely will be developed at some site which will comply with such limits, peak doses to virtually all individuals will be 100 millirem per year or less. However, while the Commission has reasonable confidence that these assumptions will prove correct, there is considerable uncertainty since the limits are yet to be developed, no repository application has been completed or reviewed, and uncertainty is inherent in the models used to evaluate possible pathways to the human environment. The NAS report indicated that 100 millirem per year should be considered as a starting point for limits for individual doses, but notes that some measure of consensus exists among national and international bodies that the limits should be a fraction of the 100 millirem per year. The lifetime individual risk from 100 millirem annual dose limit is about 3×10^{-3}.</p> <p>Estimating cumulative doses to populations over thousands of years is more problematic. The likelihood and consequences of</p>

Appendix B

Issue	Type of Issue	Finding
<p>Nonradiological impacts of the uranium fuel cycle</p>	<p>Generic</p>	<p>events that could seriously compromise the integrity of a deep geologic repository were evaluated by the Department of Energy in the "Final Environmental Impact Statement: Management of Commercially Generated Radioactive Waste," October 1980. The evaluation estimated the 70-year whole-body dose commitment to the maximum individual and to the regional population resulting from several modes of breaching a reference repository in the year of closure, after 1,000 years, after 100,000 years, and after 100,000,000 years. Subsequently, the NRC and other federal agencies have expended considerable effort to develop models for the design and for the licensing of a high level waste repository, especially for the candidate repository at Yucca Mountain. More meaningful estimates of doses to population may be possible in the future as more is understood about the performance of the proposed Yucca Mountain repository. Such estimates would involve very great uncertainty, especially with respect to cumulative population doses over thousands of years. The standard proposed by the NAS is a limit on maximum individual dose. The relationship of potential new regulatory requirements, based on the NAS report, and cumulative population impacts has not been determined, although the report articulates the view that protection of individuals will adequately protect the population for a repository at Yucca Mountain. However, the EPA's generic repository standards in 40 CFR Part 191 generally provide an indication of the order of magnitude of cumulative risk to population that could result from the licensing of a Yucca Mountain repository, assuming the ultimate standards will be within the range of standards now under consideration. The standards in 40 CFR Part 191 protect the population by imposing the amount of radioactive material released over 10,000 years. The cumulative release limits are based on the EPA's population impact goal of 1,000 premature cancer deaths worldwide for a 100,000 metric ton (MT) repository.</p> <p>Nevertheless, despite all the uncertainty, some judgment as to the regulatory NEPA implications of these matters should be made and it makes no sense to repeat the same judgment in every case. Even taking the uncertainties into account, the Commission concludes that these impacts are acceptable in that these impacts would not be sufficiently large to require the NEPA conclusion, for any plant, that the option of extended operation under 10 CFR Part 54 should be eliminated. Accordingly, while the Commission has not assigned a single level of significance for the impacts of spent fuel and high level waste disposal, this issue is considered in Category 1 (Generic).</p> <p>SMALL. The nonradiological impacts of the uranium fuel cycle resulting from the renewal of an operating license for any plant are found to be small.</p>

Issue	Type of Issue	Finding
Low-level waste storage and disposal	Generic	SMALL. The comprehensive regulatory controls that are in place and the low public doses being achieved at reactors ensure that the radiological impacts to the environment will remain small during the term of a renewed license. The maximum additional onsite land that may be required for low-level waste storage during the term of a renewed license and associated impacts will be small.
		Nonradiological impacts on air and water will be negligible. The radiological and nonradiological environmental impacts of long-term disposal of low-level waste from any individual plant at licensed sites are small. In addition, the Commission concludes that there is reasonable assurance that sufficient low-level waste disposal capacity will be made available when needed for facilities to be decommissioned consistent with NRC decommissioning requirements.
Mixed waste storage and disposal	Generic	SMALL. The comprehensive regulatory controls and the facilities and procedures that are in place ensure proper handling and storage, as well as negligible doses and exposure to toxic materials for the public and the environment at all plants. License renewal will not increase the small, continuing risk to human health and the environment posed by mixed waste at all plants. The radiological and nonradiological environmental impacts of long-term disposal of mixed waste from any individual plant at licensed sites are small. In addition, the Commission concludes that there is reasonable assurance that sufficient mixed waste disposal capacity will be made available when needed for facilities to be decommissioned consistent with NRC decommissioning requirements.
Onsite spent fuel	Generic	SMALL. The expected increase in the volume of spent fuel from an additional 20 years of operation can be safely accommodated on site with small environmental effects through dry or pool storage at all plants if a permanent repository or monitored retrievable storage is not available.
Nonradiological waste	Generic	SMALL. No changes to generating systems are anticipated for license renewal. Facilities and procedures are in place to ensure continued proper handling and disposal at all plants.
Transportation	Generic	SMALL. The impacts of transporting spent fuel enriched up to 5 percent uranium-235 with average burnup for the peak rod to current levels approved by NRC up to 62,000 megawatt days per metric-ton uranium (Wd/MTU) and the cumulative impacts of transporting high-level waste to a single repository, such as Yucca Mountain, Nevada are found to be consistent with the impact values contained in 10 CFR 51.52(c), Summary Table S-4 – Environmental Impact of Transportation of Fuel and Waste to and from One Light-Water-Cooled Nuclear Power Reactor. If fuel enrichment or burnup conditions are not met, the applicant must submit an assessment of the implications for the environmental impact values reported in § 51.52.
Decommissioning		
Radiation doses	Generic	SMALL. Doses to the public will be well below applicable regulatory standards regardless of which decommissioning method is used. Occupational doses would increase no more than 1 man-rem caused by buildup of long-lived radionuclides during the license renewal term.

Appendix B

Issue	Type of Issue	Finding
Waste management	Generic	SMALL. Decommissioning at the end of a 20-year license renewal period would generate no more solid wastes than at the end of the current license term. No increase in the quantities of Class C or greater than Class C wastes would be expected.
Air quality	Generic	SMALL. Air quality impacts of decommissioning are expected to be negligible either at the end of the current operating term or at the end of the license renewal term.
Water quality	Generic	SMALL. The potential for significant water quality impacts from erosion or spills is no greater whether decommissioning occurs after a 20-year license renewal period or after the original 40-year operation period, and measures are readily available to avoid such impacts.
Ecological resources	Generic	SMALL. Decommissioning after either the initial operating period or after a 20-year license renewal period is not expected to have any direct ecological impacts.
Socioeconomic impacts	Generic	SMALL. Decommissioning would have some short-term socioeconomic impacts. The impacts would not be increased by delaying decommissioning until the end of a 20-year relicense period, but they might be decreased by population and economic growth.
Environmental Justice		
Environmental justice	Uncategorized	NONE. The need for and the content of an analysis of environmental justice will be addressed in plant-specific reviews.

1
2

APPENDIX C.
APPLICABLE REGULATIONS, LAWS, AND AGREEMENTS

1 C. APPLICABLE REGULATIONS, LAWS, AND AGREEMENTS

2 The Atomic Energy Act (42 USC § 2021) authorizes U.S. Nuclear Regulatory Commission
3 (NRC) to enter into agreement with any State to assume to assume regulatory authority for
4 certain activities. For example, through the Agreement State Program, Nebraska assumed
5 regulatory responsibility over certain byproduct, source, and small quantities of special nuclear
6 material. The Nebraska Agreement State Program is administered by the Radiation Control
7 Program (the program) in the Department of Health. The Program Manager reports to the
8 Section Administrator for Consumer Health Services, who reports to the Division Director for
9 Public Health Assurance, who in turn reports to the Director of Regulation and Licensure.

10 In addition to implementing some Federal programs, State legislatures develop their own laws.
11 State statutes supplement as well as implement Federal laws for protection of air, water quality,
12 and ground water. State legislation may address solid waste management programs, locally
13 rare or endangered species, and historic and cultural resources.

14 The Clean Water Act (CWA) allows for primary enforcement and administration through State
15 agencies, provided the State program is at least as stringent as the Federal program. The State
16 program must conform to the CWA and to the delegation of authority for the Federal National
17 Pollutant Discharge Elimination System (NPDES) program from the EPA to the State. The
18 primary mechanism to control water pollution is the requirement for direct dischargers to obtain
19 an NPDES permit, or in the case of States where the authority has been delegated from the
20 EPA, a State Pollutant Discharge Elimination System (SPDES) permit, pursuant to the CWA. In
21 Nebraska, the Nebraska Department of Environmental Quality (NDEQ) issues and enforces
22 NPDES permits.

23 C.1. Federal Environmental Requirements

24 Cooper Nuclear Station, Unit 1, (CNS-1) is subject to Federal requirements regarding their
25 environmental program. Those requirements are briefly described below. See Section 1.9 for
26 CNS-1's compliance status with these requirements.

27 Table C-1 provides a list of the principal Federal environmental regulations and laws that are
28 applicable to the review of the environmental resources that could be affected by this project
29 that may affect license renewal applications for nuclear power plants.

30 **Table C-1. Federal Environmental Requirements.**

Law/Regulation	Requirements
Current Operating License and License Renewal	
10 CFR Part 51. <i>Code of Federal Regulations</i> (CFR), Title 10, Energy, Part 51	"Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions." This part contains environmental protection regulations applicable to NRC's domestic licensing and related regulatory functions.
10 CFR Part 54.	10 CFR Part 54. "Requirements for Renewal of Operating Licenses for Nuclear Power Plants." Part 54 of 10 CFR focuses on managing adverse effects of aging; rather than identification of all aging mechanisms. The rule is intended to ensure that important systems, structures, and components will continue to perform their intended function in the period of extended operation.
10 CFR Part 50	Regulations promulgated by the NRC pursuant to the Atomic Energy Act of 1954, as amended (68 Stat. 919), and Title II of the Energy Reorganization Act of 1974 (88

Law/Regulation	Requirements
	Stat. 1242), to provide for the licensing of production and utilization facilities. This part also gives notice to all persons who knowingly provide to any licensee, applicant, contractor, or subcontractor, components, equipment, materials, or other goods or services, that relate to a licensee's or applicant's activities subject to this part, that they may be individually subject to NRC enforcement action for violation of § 50.5.

Air Quality Protection

Clean Air Act (CAA) (42 U.S.C. §7401 et seq.)	The Clean Air Act (CAA) is a comprehensive Federal law that regulates air emissions. Under CAA, Federal actions cannot thwart State and local efforts to remedy long-standing air quality problems that threaten public health issues associated with the six criteria air pollutants (i.e., ozone, nitrogen dioxide, sulfur dioxide, particulate matter, carbon monoxide, and lead).
---	---

Water Resources Protection

Section 404 of the Clean Water Act (CWA) (33 U.S.C. § 1344)	Section 404 of the CWA established a program to regulate the discharge of dredged and fill material into waters of the United States, including wetlands. The Army Corps of Engineers (USACE) and the EPA jointly administer this program. Under the 404 program, no discharge of dredged or fill material is allowed if a practicable alternative exists that is less damaging to the aquatic environment or if the nation's waters would be significantly degraded. A Federal permit is required to discharge dredged or fill material into wetlands and waters of the United States.
Comprehensive Environmental Response, Compensation, and Liability Act (CERCLA)(42 U.S.C. §. 9601 et seq)	Section 101 of CERCLA requires a permit to cover consumptive water use over 20,000 gallons per day (over a 30-day average) of surface and ground water.
Wild and Scenic River Act (16 U.S.C. §1271 et seq.)	Created the National Wild and Scenic Rivers System, established to protect the environmental values of free flowing streams from degradation by impacting activities including water resources projects.
Floodplain Executive Order (No. 11988. May 24, 1977, 42 F.R. 26951) and Wetlands Executive Order (No. 11990. May 24, 1977, 42 F.R. 26961)	Both executive orders require Federal agencies to consider the impacts of their actions on floodplains and wetlands through existing review procedures such as National Environmental Policy Act of 1969.

Law/Regulation	Requirements
Waste Management and Pollution Prevention	
Resource Conservation and Recovery Act (RCRA) (42 USC § 6901et seq.)	Before a material can be classified as a hazardous waste, it must first be a solid waste as defined under the RCRA. Hazardous waste is classified under Subtitle C of the RCRA. Parts 261 and 262 of Title 40 CFR contain all applicable generators of hazardous waste regulations. Part 261.5 (a) and (e) contains requirements for Conditionally Exempt Small Quantity Generators (CESQGs). Part 262.34(d) contains requirements for Small Quantity Generators (SQGs). Parts 262 and 261.5(e) contain requirements for Large Quantity Generators (LQGs)
Pollution Prevention Act (42 U.S.C. § 13101 et seq)	Formally established a national policy to prevent or reduce pollution at its source whenever feasible. The Act provides funds for State and local pollution prevention programs through a grant program to promote the use of pollution prevention techniques by business.

Law/Regulation	Requirements
Endangered Species	
Endangered Species Act (ESA) (16 U.S.C. § 1531 et seq.)	Forbids any government agency, corporation, or citizen from taking (harming or killing) endangered animals without an Endangered Species Permit.
Fish and Wildlife Coordination Act (16 U.S.C. § 661 et seq.)	To minimize adverse impacts of proposed actions on fish and wildlife resources and habitat, requires that Federal agencies consult government agencies regarding activities that affect, control, or modify waters of any stream or bodies of water. It also requires that justifiable means and measures be used in modifying plans to protect fish and wildlife in these waters.
Historic Preservation	
National Historic Preservation Act (NHPA) (16 U.S.C. § 470 et seq.)	Directs Federal agencies to consider the impact of their actions on historic properties. NHPA also encourages state and local preservation societies.
Farmland	
Farmland and Protection Policy Act (7 U.S.C. § 4201 et seq.)	Requires that Federal programs, as practicable, shall be administered in a manner compatible with State and local government and private programs and policies to protect farmland.

1
2

**APPENDIX D.
CONSULTATION CORRESPONDENCE**

1 **D. CONSULTATION CORRESPONDENCES**

2 The Endangered Species Act of 1973, as amended, the Magnuson-Stevens Fisheries
 3 Management Act of 1996, as amended; and the National Historic Preservation Act of 1966
 4 require that Federal agencies consult with applicable State and Federal agencies and groups
 5 prior to taking action that may affect threatened and endangered species, essential fish habitat,
 6 or historic and archaeological resources, respectively. This appendix contains consultation
 7 documentation.

8 Table D-1 provides a list of the consultation documents sent between the U.S. Nuclear
 9 Regulatory Commission (NRC) and other agencies. The NRC staff is required to consult with
 10 these agencies based on the National Environmental Policy Act of 1969 (NEPA) requirements.

11 **Table D-1. Consultation Correspondences.**

Author	Recipient	Date of Letter/Email
U.S. Nuclear Regulatory Commission (D. Pelton)	Nebraska State Historic Society (M. Smith)	January 16, 2009 (ML090080197)
U.S. Nuclear Regulatory Commission (D. Pelton)	Advisory Council on Historic Preservation (D. Klima)	January 26, 2009 (ML090080683)
U.S. Nuclear Regulatory Commission (D. Pelton)	Environmental Services Division, Environmental Protection Agency Region 7 (J. Cothorn)	January 27, 2009 (ML090230446)
U.S. Nuclear Regulatory Commission (D. Pelton)	Department of Health and Human Services, Regulation and Licensure, Public Health Assurance (J. Schmitt)	January 28, 2009 (ML090210249)
U.S Nuclear Regulatory Commission (D. Pelton)	U. S. Fish and Wildlife Service, Ecological Services – Nebraska Field Office (J. Cochnar)	January 29, 2009 (ML090070507)
U.S Nuclear Regulatory Commission (D. Pelton)	Missouri State Historic Society (M. Miles)	January 29, 2009 (ML090210750)
Nebraska State Historical Society (J. Dolberg)	U.S. Nuclear Regulatory Commission (D. Pelton)	February 02, 2009 (ML090650061)
U.S Nuclear Regulatory Commission (D. Pelton)	Nebraska Department of Natural Resources (A. Bleed)	February 04, 2009 (ML090260380)
U.S. Nuclear Regulatory Commission (D. Pelton)	U.S. Army Corps of Engineers, Omaha District (D. Press)	February 04, 2009 (ML090160476)
U.S. Nuclear Regulatory Commission (D. Pelton)	Sac and Fox Tribe of the Mississippi in Iowa (A. Pushetonequa) ^a	February 04, 2009 (ML090080045)
Nebraska Department of Natural Resources (J. Angell)	U.S. Nuclear Regulatory Commission (D. Pelton)	March 09, 2009

Appendix D

Author	Recipient	Date of Letter/Email
Environmental Protection Agency Region 7 (L. Shepard)	U.S. Nuclear Regulatory Commission (E. Sayoc)	April 16, 2009 (ML091070269)
Nebraska Games and Parks Commission (R. Simpson)	U.S. Nuclear Regulatory Commission (R. Bulavinetz)	May 08, 2009 (ML091400110)
Fish and Wildlife Service (J. DeWeese)	Nebraska Public Power District (J. Citta)	June 8, 2009 (ML091830055)

1 ^a Similar letters went to 14 other Native American Tribes listed in Section 1.8.

2 **D.1. Consultation Correspondence**

3 The following pages contain copies of the letters listed in Table D-1.

January 16, 2009

Mr. Michael J. Smith
State Historic Preservation Officer
Nebraska State Historical Society
P.O. Box 82554
Lincoln, NE 68501

SUBJECT: COOPER NUCLEAR STATION LICENSE RENEWAL APPLICATION REVIEW
(HP NO. 0801-050-01, DESCRIPTION, NPPD, COOPER NUCLEAR STATION)

Dear Mr. Smith:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application to renew the operating license for Cooper Nuclear Station (CNS), which is located in Nemaha County, Nebraska, on the west bank of the Missouri River at river mile (RM) 532.5. The Village of Brownville, NE is located approximately 2.25 miles northwest of the site. CNS is operated by the Nebraska Public Power District (NPPD). The application for renewal was submitted by NPPD by letter dated September 24, 2008, pursuant to Title 10 of the *Code of Federal Regulations* Part 54 (10 CFR Part 54).

The NRC has established that, as part of the staff's review of any nuclear power plant license renewal action, a Supplemental Environmental Impact Statement (SEIS) to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants", NUREG-1437, will be prepared under the provisions of 10 CFR Part 51, the NRC's regulation that implements the National Environmental Policy Act of 1969 (NEPA). In accordance with 36 CFR 800.8(c), the SEIS will include analyses of potential impacts to historic and cultural resources.

In the context of the National Historic Preservation Act of 1966, as amended, the NRC staff has determined that the area of potential effect (APE) for a license renewal action is the area at the power plant site and its immediate environs that may be impacted by post-license renewal land-disturbing operations or possible refurbishment activities associated with the proposed action. The APE may extend beyond the immediate environs in those instances where post-license renewal land-disturbing operations or projected refurbishment activities specifically related to license renewal may potentially have an effect on known or proposed historic sites. This determination is made irrespective of ownership or control of the lands of interest.


On February 25, 2009, the NRC will conduct two public license renewal and environmental scoping meetings. The first session will be held at the Brownville Concert Hall at 126 Atlantic St., Brownville, NE 68321, telephone (402) 825-3331, and will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second session will be held at the Auburn Senior Center at 1101 J St., Auburn, NE 68305, telephone (402) 274-3420, and will convene at 7:00 p.m., with a repeat of the overview portions of the meeting and will continue until 10:00 p.m., as necessary. You and your staff are invited to attend. Your office will receive a copy of the draft SEIS along with a request for comments. The staff expects to publish the draft SEIS in December 2009.

1



1

Cooper Nuclear Station Site Map - 6 Mile Radius



Cooper Nuclear Station Transmission Lines

Appendix D

January 26, 2009

Mr. Don L. Klima, Director
Advisory Council on Historic Preservation
Office of Federal Agency Programs
1100 Pennsylvania Ave., NW, Suite 803
Washington, DC 20004

SUBJECT: COOPER NUCLEAR STATION LICENSE RENEWAL APPLICATION REVIEW

Dear Mr. Klima:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application to renew the operating license for Cooper Nuclear Station (CNS) which is located near Brownville, Nebraska. It is operated by the Nebraska Public Power District (NPPD). The application for renewal was submitted by NPPD by letter dated September 24, 2008, pursuant to Title 10 of the *Code of Federal Regulations* Part 54 (10 CFR Part 54).

The NRC has established that, as part of the staff's review of any nuclear power plant license renewal action, a site-specific Supplemental Environmental Impact Statement (SEIS) to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants", NUREG-1437, will be prepared under the provisions of 10 CFR Part 51, the NRC's regulation that implements the National Environmental Policy Act of 1969 (NEPA). In accordance with 36 CFR 800.8(c), the SEIS will include analyses of potential impacts to historic and cultural resources.

On February 25, 2009, the NRC will conduct two public license renewal and environmental scoping meetings. The first session will be held at the Brownville Concert Hall at 126 Atlantic St., Brownville, NE 68321, telephone (402) 825-3331, and will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second session will be held at the Auburn Senior Center at 1101 J St., Auburn, NE 68305, telephone (402) 274-3420, and will convene at 7:00 p.m., with a repeat of the overview portions of the meeting and will continue until 10:00 p.m., as necessary. You and your staff are invited to attend. In addition, during the week of March 30, 2009, the NRC staff plans to conduct a site audit at CNS. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is December 2009.

1

D. Klima

- 2 -

If you have any questions or require additional information, please contact the License Renewal Project Managers, Tam Tran telephone, (301) 415-3617, email: tam.tran@nrc.gov or Emmanuel Sayoc, telephone (301) 415-1924, email: emmanuel.sayoc@nrc.gov.

Sincerely,

IRA

David L. Pelton, Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-298

cc w/o encl: See next page

1

January 27, 2009

Mr. Joseph Cothern
Environmental Review Coordinator
Environmental Services Division
USEPA Region 7
901 North 5th Street
Kansas City, KS 66101

SUBJECT: COOPER NUCLEAR STATION LICENSE RENEWAL APPLICATION
REVIEW

Dear Mr. Cothern:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application submitted by Nebraska Public Power District, for the renewal of the operating license for Cooper Nuclear Station (CNS) Unit 1, which is located in Nemaha County, Nebraska, on the west bank of the Missouri River at river mile 532.5. The Village of Brownville, NE is located approximately 2.25 miles northwest of the site, and Lincoln, NE, is located approximately 60 miles west northwest of the site. As part of the review of the license renewal application (LRA), the NRC is preparing a Supplemental Environmental Impact Statement (SEIS) under the provisions of Title 10 of the *Code of Federal Regulations* Part 51 (10 CFR Part 51), the NRC's regulation that implements the National Environmental Policy Act of 1969.

CNS is requesting the renewal of its operating license for a period of 20 years beyond the expiration of the current license term, renewing the license until January 18, 2034. The proposed action would include the use and continued maintenance of existing plant facilities and transmission lines; CNS does not plan to construct or alter any facilities associated with the plant during the period of extended operation.

The NRC staff plans to hold two identical public meetings covering the license renewal and environmental scoping process on February 25, 2009. The first session will be held at the Brownville Concert Hall at 126 Atlantic Street, Brownville, NE 68321, telephone (402) 825-3331, and will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second session will be held at the Auburn Senior Center at 1101 J Street, Auburn, NE 68305, telephone (402) 274 3420, and will convene at 7:00 p.m., with a repeat of the overview portions of the meeting and will continue until 10:00 p.m., as necessary. In addition, during the week of March 30, 2009, the NRC plans to conduct a site audit. You and your staff are invited to attend both the site audit and the public meetings. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is December 2009.

J. Cothorn

- 2 -

If you have any questions concerning the NRC staff's review of this LRA, please contact NRC's Project Managers, Tam Tran, by telephone, 1-800-368-5642, extension 3617, or by e-mail at tam.tran@nrc.gov, or Emmanuel Sayoc, by telephone, 1-800-368-5642, extension 1924, or by e-mail at emmanuel.sayoc@nrc.gov.

Sincerely,

lRAI

David L. Pelton, Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-298

1

cc w/encls: See next page

January 28, 2009

Ms. Julia Schmitt, Manager
Radiation Control Program
Department of Health and Human Services
Regulation and Licensure
Public Health Assurance
301 Centennial Mall, South
P.O. Box 95007
Lincoln, NE 68509-5007

SUBJECT: COOPER NUCLEAR STATION LICENSE RENEWAL APPLICATION
REVIEW

Dear Ms. Schmitt:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application submitted by Nebraska Public Power District (NPPD), for the renewal of the operating license for Cooper Nuclear Station (CNS), which is located in Nemaha County, Nebraska (NE), on the west bank of the Missouri River at river mile (RM) 532.5. The Village of Brownville, NE is located approximately 2.25 miles northwest of the site, and Lincoln, Nebraska, is located approximately 60 miles west northwest of the site. As part of the review of the license renewal application (LRA), the NRC is preparing a Supplemental Environmental Impact Statement (SEIS) under the provisions of Title 10 of the Code of Federal Regulations Part 51 (10 CFR Part 51), the NRC's regulation that implements the National Environmental Policy Act (NEPA) of 1969.

CNS is requesting the renewal of its operating license for a period of 20 years beyond the expiration of the current license term, renewing the license until January 18, 2034. The proposed action would include the use and continued maintenance of existing plant facilities and transmission lines; CNS does not plan to construct or alter any facilities associated with the plant during the period of extended operation.

The NRC staff plans to hold two identical public meetings covering the license renewal and environmental scoping process on February 25, 2009. The first meeting will be held at the Brownville Concert Hall at 126 Atlantic St., Brownville, NE 68321, telephone (402) 825-3331. The meeting will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second meeting will be held at the Auburn Senior Center at 1101 J St., Auburn, NE 68305, telephone (402) 274 3420. The meeting will convene at 7:00 p.m., with a repeat of the overview portions of the meeting and will continue until 10:00 p.m., as necessary. In addition, during the week of March 30, 2009, the NRC plans to conduct a site audit. You and your staff are invited to attend both the site audit and the public meetings. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is December 2009.

1

J. Schmitt

- 2 -

If you have any questions concerning the NRC staff's review of this license renewal application, please contact NRC's Project Managers, Tam Tran, by telephone, 1-800-368-5642, extension 3617, or by email to the NRC at tam.tran@nrc.gov, or Emmanuel Sayoc, by telephone, 1-800-368-5642, extension 1924, or by email to the NRC at emmanuel.sayoc@nrc.gov.

Sincerely,

IRA\

David L. Pelton, Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-298

cc w/o encl: See next page

1

January 29, 2009

Mr. John Cochnar
U. S. Fish and Wildlife Service
Ecological Services - Nebraska Field Office
203 West Second Street
Grand Island, NE 68801

SUBJECT: REQUEST FOR LIST OF PROTECTED SPECIES WITHIN THE AREA UNDER
EVALUATION FOR THE COOPER NUCLEAR STATION, UNIT 1 LICENSE
RENEWAL APPLICATION REVIEW

Dear Mr. Cochnar:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application submitted by the Nebraska Public Power District (NPPD) for the renewal of the operating license for Cooper Nuclear Station (CNS) Unit 1. CNS is located in Nemaha County, Nebraska (NE), on the west bank of the Missouri River at river mile (RM) 532.5. The Village of Brownville, NE is located approximately 2.25 miles northwest of the site and Lincoln, NE, is located approximately 60 miles west northwest of the site. As part of the review of the license renewal application (LRA), the NRC is preparing a Supplemental Environmental Impact Statement (SEIS) under the provisions of Title 10 of the *Code of Federal Regulations* Part 51 (10 CFR Part 51), the NRC's regulation that implements the National Environmental Policy Act (NEPA) of 1969. The SEIS includes an analysis of pertinent environmental issues, including endangered or threatened species and impacts to fish and wildlife. This letter is being submitted under the provisions of the Endangered Species Act of 1973, as amended, and the Fish and Wildlife Coordination Act of 1934, as amended.

The proposed action would include the use and continued maintenance of existing plant facilities and transmission lines. The site surroundings are predominantly agricultural with zero population within a one-half mile radius of the plant. Brownville, NE, is the nearest developed community, at a distance of approximately 2.25 miles from the site, with a 2005 population of approximately 137. The largest town with industry within 10 miles is Auburn, Nebraska, located to the west, with a 2005 population of approximately 3,076. Maryville, Missouri, located approximately 40 miles east of the plant, is the largest community within 50 miles and had a 2005 population of approximately 10,567.

Over 99 percent of the acreage in Nemaha County is used for agriculture and farming. Farming is also the major activity for the rest of the area within a 50-mile radius as well. The site is located on a constructional plain bordering the west bank of the Missouri River. It is situated on the first bottomland of the broad, nearly level, flood plain, which is approximately six miles wide at the site. The U.S. Army Corp of Engineer (USACE) has stabilized the channel by use of pile dikes and bank protection. Earthen levees run parallel with the Missouri River, on both sides of the river.

1

J. Cochnar

- 2 -

The station site grade level of 903 feet above mean sea level (AMSL) has been raised 13 feet above the natural grade level of 890 feet AMSL, in order to bring final grade one foot above the existing 902 feet AMSL levee constructed by the USACE. The site slopes generally east, with surface drainage toward the Missouri River.

The CNS property includes 239 acres on the east side of the Missouri River in Atchison County, Missouri, the most northwestern county in Missouri, bounded on the west by the Missouri River. The eastern bank of the Missouri River is chiefly a densely forested land similar to the un-farmable bluffs that run parallel to the Missouri River. To the west there are bluffs that peak at 1,100 feet, but average 1,000 feet along the stretch of river from Brownville to Nemaha. Beyond the bluffs, the land is a gently rolling flood plain.

There are several Native American lands within a 50-mile radius of CNS. These include the Sac and Fox Reservation, Iowa Reservation, and Kickapoo Reservation. There are also several local and county parks, golf courses, forest lands, wildlife areas, and other public recreation lands within a 50-mile radius of CNS.

Flow of the Missouri River at CNS is largely controlled by the Gavins Point Dam located about 200 miles upstream in Yankton, South Dakota. The flow is highly channelized with swift flows and heavy sediment transport. Wing dams are located on the Missouri side of the river near CNS to force the flow into a central channel.

The USACE constructed and operates six of the seven mainstem dams on the Missouri River; the U.S. Bureau of Reclamation operates the seventh, Canyon Ferry Dam, east of Helena, Montana. When the USACE constructed five of the Missouri River mainstem dams in the 1950s and 1960s after passage of the Pick-Sloan Plan, goals for dam and reservoir operations were to reduce flood damages, enhance navigation, generate hydroelectric power, and store water for irrigation.

Missouri River reservoirs and river segments presently contain populations of exotic fishes, including cisco, several salmon and trout species, and several Asian carp species. Some of these species have contributed to the development of economically important recreational fisheries.

CNS cooling is classified as a circulating water system that uses water taken from the Missouri River. Water passes through trash racks and then through traveling screens. A major portion of the flow is directed to the circulating water pumps, which deliver water to the main condenser. A smaller portion of the Missouri River water is used by the service water pumps. The discharge from the condenser and from the service water system is returned via the discharge channel to the river. The circulating water intake structure (CWIS) is located on the west shoreline. In front of the CWIS is a guide wall and submerged weir constructed of steel sheet

1

piling that runs parallel to and at distance of 14.25 feet (ft) from the face of the intake. The purpose of the guide wall and weir is to reduce the sediment input to the CWIS. It accomplishes this by forcing bed load and other material contained in the river to flow around and past the CWIS.

Four circulating water pumps provide the circulating water for the facility. Each pump can draw 159,000 gpm. The pump design water level is at El. 875.0 ft, with a minimum submergence level at El. 865.0 ft. There are four service water pumps providing a combined flow of 32,000 gpm. Velocities in the intake structure are 1.1 ft/sec under the curtain wall, 0.7 ft/sec at the trash racks, and approximately 2.0 ft/sec at the traveling water screens. These velocities were calculated at low water levels (El. 874.5 ft) and maximum circulating water pump flow (159,000 gpm per pump). The flow is highly channelized with swift flows and heavy sediment transport. Turning vanes and a low sheetpile wall are located in front of the intake bays. Wing dams are located on the Missouri side of the river to force the flow into a central channel. During the winter, ice is very common on the river. To prevent ice damage, ice deflector barges are installed during the winter months. To prevent the formation of frazzle ice, some of the main condenser discharge water (25–30 percent) is re-circulated through the ice control tunnel and released in front of the trash rack within the CWIS while the remaining water is discharged about 1,300 ft downstream of the intake via a discharge canal.

The chlorination system connection is located on the common inlet to Screen Wash Pump A and B from the service water system. Bacteria that occur naturally in the Missouri River may contribute to the growth of biological film fouling of the main condenser tubes. The station is proceeding with a study to determine if routine chemical injection (chlorine, bromine, etc.) will be effective in eliminating the microbiological film on the interior walls of the condenser tubes.

Water leaves the pump house and circulates through the condenser, where it is collected from the condenser section through a large manifold. It then travels through concrete tunnels to the seal well structure and the discharge canal. At the rated circulating water flow of 631,000 gpm through the condenser and at design power on the turbine generator, the temperature rise through the condenser is approximately 17.8°F. From the seal well and gate control structure, the water is directed into a discharge canal that is approximately 1,000 ft long; it then enters the river at a slight angle. The velocity of discharge is about 1 fps during average water levels of 879.4 ft AMSL and 35,000 cfs flow, and increases to about 2.5 fps as the water surface elevation is reduced to 874.5 ft AMSL and flows near 11,000 cfs.

The transmission lines which were constructed to connect CNS to the grid for purposes of power distribution includes (1) NPPD line TL3501 (345 kV energized in August 1969) 63.6 miles in length from CNS to the Mark T. Moore substation near Hallam, Nebraska, (2) NPPD line TL3502 (345 kV energized in July 1970) 82.6 miles in length from the Mark T. Moore substation to the Grand Island substation, and (3) Omaha Public Power District (OPPD) Line "60," which was already planned when CNS was constructed, (4) NPPD line TL3504 was energized as a 345 kV line in July 1970 and is 0.64 miles in length from CNS to the center of the Missouri River.

J. Cochnar

- 4 -

The transmission line "K-Towers" are supported by two wooden poles that are 26 feet apart. Therefore, the farming activity adjacent to and under the towers and lines continues essentially unimpeded with the only land removed from service being that upon which transmission poles physically rest. No cultivated land along the transmission route has been removed from service as a result of rights-of-way, and access for repairs and maintenance is requested on an individual basis from each property owner. For the remainder of the transmission line route, which passes over non-cultivated land, the right-of-way (ROW) is cleared only of woody plants that have a growth pattern that would cause them to grow into or fall onto the line conductors. Thereafter, control of these species is maintained; however, all of the natural grasses and low growing bushy, woody plants are allowed to grow.

There are no densely forested areas on the transmission route, and the land beneath the transmission lines is allowed to return to its natural state. Steel towers are used for the lines crossing the Missouri River and in the immediate vicinity of the station. Based on NPPD clearance practices, the required minimum ground clearance is 29.3 feet.

Provided for your information is the CNS Site Layout (Enclosure 1) and Transmission Line Map (Enclosure 2). To support the SEIS preparation process and to ensure compliance with Section 7 of the Endangered Species Act, the NRC requests information on Federally-listed, proposed, and candidate species and critical habitat that may be in the vicinity of CNS and its associated transmission line rights-of-way. In addition, please provide any information you consider appropriate under the provisions of the Fish and Wildlife Coordination Act.

The NRC staff plans to hold two public license renewal and environmental scoping meetings on February 25, 2009. There will be two sessions, an afternoon and evening session, to accommodate interested parties. The first session will be held at the Brownville Concert Hall at 126 Atlantic St., Brownville, NE 68321, telephone (402) 825-3331, and will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second session will be held at the Auburn Senior Center at 1101 J St., Auburn, NE 68305, telephone (402) 274-3420, and will convene at 7:00 p.m., with a repeat of the overview portions of the meeting and will continue until 10:00 p.m., as necessary. In addition, during the week of March 30, the NRC plans to conduct a site audit. You and your staff are invited to attend both the public meetings and the site audit. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is December 2009.

1

January 29, 2009

Mr. Mark Miles
State Historic Preservation Officer
Department of Natural Resources
P.O. Box 176
Jefferson City, MO 65102

SUBJECT: COOPER NUCLEAR STATION LICENSE RENEWAL APPLICATION REVIEW
(NEBRASKA PUBLIC POWER DISTRICT - COOPER NUCLEAR STATION
SHPO LOG NUMBER 004-AT-08)

Dear Mr. Miles:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application to renew the operating license for Cooper Nuclear Station (CNS), which is located in Nemaha County, Nebraska (NE), on the west bank of the Missouri River at river mile 532.5. The Village of Brownville, NE is located approximately 2.25 miles northwest of the site. CNS is operated by the Nebraska Public Power District (NPPD). The application for renewal was submitted by NPPD by letter dated September 24, 2008, pursuant to Title 10 of the *Code of Federal Regulations* Part 54 (10 CFR Part 54).

The NRC has established that, as part of the staff's review of any nuclear power plant license renewal action, a Supplemental Environmental Impact Statement (SEIS) to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants", NUREG-1437, will be prepared under the provisions of 10 CFR Part 51, the NRC's regulation that implements the National Environmental Policy Act of 1969 (NEPA). In accordance with 36 CFR 800.8(c), the SEIS will include analyses of potential impacts to historic and cultural resources.

In the context of the National Historic Preservation Act of 1966, as amended, the NRC staff has determined that the area of potential effect (APE) for a license renewal action is the area at the power plant site and its immediate environs that may be impacted by post-license renewal land-disturbing operations or projected refurbishment activities associated with the proposed action. The APE may extend beyond the immediate environs in those instances where post-license renewal land-disturbing operations or projected refurbishment activities specifically related to license renewal may potentially have an effect on known or proposed historic sites. This determination is made irrespective of ownership or control of the lands of interest.

On February 25, 2009, the NRC will conduct two public license renewal and environmental scoping meetings. The first session will be held at the Brownville Concert Hall at 126 Atlantic St., Brownville, NE 68321, telephone (402) 825-3331, and will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second session will be held at the Auburn Senior Center at 1101 J St., Auburn, NE 68305, telephone (402) 274-3420, and will convene at 7:00 p.m., with a repeat of the overview portions of the meeting and will continue until 10:00 p.m., as necessary. You and your staff are invited to attend. Your office will receive a copy of the draft SEIS along with a request for comments. The staff expects to publish the draft SEIS in December 2009.

M. Miles

-2-

If you have any questions concerning the NRC staff's review of this license renewal application, please contact NRC's Project Managers, Tam Tran, by telephone, 1-800-368-5642, extension 3617, or by email to the NRC at tam.tran@nrc.gov, or Emmanuel Sayoc, by telephone, 1-800-368-5642, extension 1924, or by email to the NRC at emmanuel.sayoc@nrc.gov.

Sincerely,

/RA/

David Pelton, Branch Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-298

cc: See next page



NEBRASKA STATE HISTORICAL SOCIETY
1500 R STREET, P.O. BOX 82554, LINCOLN, NE 68501-2554
(402) 471-3270 Fax: (402) 471-3100 1-800-833-6747 www.nebraskahistory.org
Michael J. Smith, Director/CEO

February 2, 2009

Mr. David L. Pelton, Chief
Division of License Renewal
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555-0001

RE: Cooper Nuclear Station license renewal HP# 0801-050-001

Dear Mr. Pelton:

Thank you for submitting the referenced project for our review and comment. Our comment on this project and its potential to affect historic properties is required by Section 106 of the National Historic Preservation Act of 1966, as amended, and implementing regulations 36 CFR Part 800. Before we are able to adequately review the proposed Area of Potential Effect (APE) for this project for its potential to affect historic properties, we require the following information:

- A map clearly defining the boundaries of the APE

Please submit this information to: Bob Puschendorf, Nebraska State Historic Preservation Office, P.O. Box 82554, 1420 P Street, Lincoln, NE 68501-2554.

Sincerely,

Jill E. Dolberg
Review and Compliance Coordinator
Nebraska State Historic Preservation Office

Cc: Tam Tran, NRC
Emmanuel Sayoc, NRC
Steward B. Minahan, Chief Nuclear Officer, Cooper Nuclear Station

February 04, 2009

Ms. Ann Salomon Bleed, Director
Nebraska Department of Natural Resources
301 Centennial Mall South
P.O. Box 94676
Lincoln, NE 68509-4676

SUBJECT: REQUEST FOR LIST OF PROTECTED SPECIES WITHIN THE AREA UNDER
EVALUATION FOR THE COOPER NUCLEAR STATION, UNIT 1 LICENSE
RENEWAL APPLICATION REVIEW

Dear Ms. Bleed:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application submitted by the Nebraska Public Power District (NPPD) for the renewal of the operating license for Cooper Nuclear Station (CNS) Unit 1. Cooper Nuclear Station (CNS), located in Nemaha County, Nebraska (NE), on the west bank of the Missouri River at river mile (RM) 532.5. The Village of Brownville, NE is located approximately 2.25 miles northwest of the site, and Lincoln, NE, is located approximately 60 miles west northwest of the site. As part of the review of the license renewal application (LRA), the NRC is preparing a Supplemental Environmental Impact Statement (SEIS) under the provisions of Title 10 of the *Code of Federal Regulations* Part 51 (10 CFR Part 51), the NRC's regulation that implements the National Environmental Policy Act (NEPA) of 1969. The SEIS includes an analysis of pertinent environmental issues, including endangered or threatened species and impacts to fish and wildlife. This letter is being submitted under the provisions of the Endangered Species Act of 1973, as amended, and the Fish and Wildlife Coordination Act of 1934, as amended.

The site surroundings are predominantly agricultural with zero population within a one-half mile radius of the plant. Brownville, NE, is the nearest developed community, at a distance of approximately 2.25 miles from the site, and a 2005 population of approximately 137. The largest town with industry within 10 miles is Auburn, NE, located to the west, with a 2005 population of approximately 3,076. Maryville, Missouri, located approximately 40 miles east of the plant, is the largest community within 50 miles and had a 2005 population of approximately 10,567.

Over 99 percent of the acreage in Nemaha County is used for agriculture and farming. Farming is the major activity for the rest of the area within a 50-mile radius as well. The site is located on a constructional plain bordering the west bank of the Missouri River. It is situated on the first bottomland of the broad, nearly level, flood plain, which is approximately six miles wide at the site. The U.S. Army Corps of Engineers (USACE) has stabilized the channel by use of pile dikes and bank protection. Earthen levees run parallel with the Missouri River, on both sides of the river.

1

The station site grade level of 903 feet above mean sea level (AMSL) has been raised 13 feet above the natural grade level of 890 feet AMSL, in order to bring final grade one foot above the existing 902 feet AMSL levee constructed by the USACE. The site slopes generally east, with surface drainage toward the Missouri River.

The CNS property includes 239 acres on the east side of the Missouri River in Atchison County, Missouri, the most northwestern county in Missouri, bounded on the west by the Missouri River. The eastern bank of the Missouri River is chiefly a densely forested land similar to the unfarmable bluffs that run parallel to the Missouri River. To the west there are bluffs that peak at 1,100 feet, but average 1,000 feet along the stretch of river from Brownville to Nemaha Beyond the bluffs, the land is a gently rolling flood plain.

There are several Native American lands within a 50-mile radius of CNS. These include the Sac and Fox Reservation, Iowa Reservation, and Kickapoo Reservation. There are also several local and county parks, golf courses, forest lands, wildlife areas, and other public recreation lands within a 50-mile radius of CNS.

Flow of the Missouri River at CNS is largely controlled by the Gavins Point Dam located about 200 miles upstream in Yankton, South Dakota. The flow is highly channelized with swift flows and heavy sediment transport. Wing dams are located on the Missouri side of the river near CNS to force the flow into a central channel.

The USACE constructed and operates six of the seven mainstem dams on the Missouri River; the U.S. Bureau of Reclamation operates the seventh, Canyon Ferry Dam, east of Helena, Montana. When the USACE constructed five of the Missouri River mainstem dams in the 1950s and 1960s after passage of the Pick-Sloan Plan, goals for dam and reservoir operations were to reduce flood damages, enhance navigation, generate hydroelectric power, and store water for irrigation.

Missouri River reservoirs and river segments presently contain populations of exotic fishes, including cisco, several salmon and trout species, and several Asian carp species. Some of these species have contributed to the development of economically important recreational fisheries.

CNS cooling is classified as a circulating water system that uses water taken from the Missouri River. Water passes through trash racks and then through traveling screens. A major portion of the flow is directed to the circulating water pumps, which deliver water to the main condenser. A smaller portion of the Missouri River water is used by the service water pumps. The discharge from the condenser and from the service water system is returned via the discharge channel to the river. The circulating water intake structure (CWIS) is located on the west shoreline. In front

1

A. Bleed

- 3 -

of the CWIS is a guide wall and submerged weir constructed of steel sheet piling that runs parallel to and at distance of 14.25 feet (ft) from the face of the intake.

Four circulating water pumps provide the circulating water for the facility. Each pump can draw 159,000 gpm. The pump design water level is at El. 875.0 ft, with a minimum submergence level at El. 865.0 ft. There are four service water pumps providing a combined flow of 32,000 gpm. Velocities in the intake structure are 1.1 ft/sec under the curtain wall, 0.7 ft/sec at the trash racks, and approximately 2.0 ft/sec at the traveling water screens. These velocities were calculated at low water levels (El. 874.5 ft) and maximum circulating water pump flow (159,000 gpm per pump). The flow is highly channelized with swift flows and heavy sediment transport. To minimize the effects of sedimentation on the intake, turning vanes and a low sheetpile wall are located in front of the intake bays. Wing dams are located on the Missouri side of the river to force the flow into a central channel. During the winter, ice is very common on the river. To prevent ice damage, ice deflector barges are installed during the winter months. To prevent the formation of frazzle ice, some of the main condenser discharge water (25–30 percent) is re-circulated through the ice control tunnel and released in front of the trash rack within the CWIS while the remaining water is discharged about 1,300 ft downstream of the intake via a discharge canal.

The chlorination system connection is located on the common inlet to Screen Wash Pump A and B from the service water system. Bacteria that occur naturally in the Missouri River may contribute to the growth of biological film fouling of the main condenser tubes. The station is proceeding with a study to determine if routine chemical injection (chlorine, bromine, etc.) will be effective in eliminating the microbiological film on the interior walls of the condenser tubes.

Water leaves the pump house and circulates through the condenser, where it is collected from the condenser section through a large manifold. It then travels through concrete tunnels to the seal well structure and the discharge canal. At the rated circulating water flow of 631,000 gpm through the condenser and at design power on the turbine generator, the temperature rise through the condenser is approximately 17.8°F. From the seal well and gate control structure, the water is directed into a discharge canal that is approximately 1,000 ft long; it then enters the river at a slight angle. The velocity of discharge is about 1 fps during average water levels of 879.4 ft AMSL and 35,000 cfs flow, and increases to about 2.5 fps as the water surface elevation is reduced to 874.5 ft AMSL and flows near 11,000 cfs.

The transmission lines which were constructed to connect CNS to the grid for purposes of power distribution includes (1) NPPD line TL3501 (345 kV energized in August 1969) 63.6 miles in length from CNS to the Mark T. Moore substation near Hallam, Nebraska, (2) NPPD line TL3502 (345 kV energized in July 1970) 82.6 miles in length from the Mark T. Moore substation to the Grand Island substation, (3) Omaha Public Power District (OPPD) Line "60," which was already planned when CNS was constructed, and (4) NPPD line TL3504 was energized as a 345 kV line in July 1970 and is 0.64 miles in length from CNS to the center of the Missouri River.

1

The transmission line "K-Towers" are supported by two wooden poles that are 26 feet apart. Therefore, the farming activity adjacent to and under the towers and lines continues essentially unimpeded with the only land removed from service being that upon which transmission poles physically rest. No cultivated land along the transmission route has been removed from service as a result of rights-of-way, and access for repairs and maintenance is requested on an individual basis from each property owner. For the remainder of the transmission line route, which passes over non-cultivated land, the right-of-way (ROW) is cleared only of woody plants that have a growth pattern that would cause them to grow into or fall onto the line conductors. Thereafter, control of these species is maintained; however, all of the natural grasses and low growing bushy, woody plants are allowed to grow.

There are no densely forested areas on the transmission route, and the land beneath the transmission lines is allowed to return to its natural state. Steel towers are used for the lines crossing the Missouri River and in the immediate vicinity of the station. Based on NPPD clearance practices, the required minimum ground clearance is 29.3 feet.

Provided for your information is the CNS Site Layout (Enclosure 1) and Transmission Line Map (Enclosure 2). To support the SEIS preparation process and to ensure compliance with Section 7 of the Endangered Species Act, the NRC requests information on State-listed, proposed, and candidate species and critical habitat that may be in the vicinity of CNS and its associated transmission line rights-of-way. In addition, please provide any information you consider appropriate under the provisions of the Fish and Wildlife Coordination Act.

The NRC staff plans to hold two public license renewal and environmental scoping meetings on February 25, 2009. There will be two sessions, an afternoon and evening session, to accommodate interested parties. The first session will be held at the Brownville Concert Hall at 126 Atlantic St., Brownville, NE 68321 telephone (402) 825-3331, and will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second session will be held at the Auburn Senior Center at 1101 J St., Auburn, NE 68305, telephone (402) 274 3420, and will convene at 7:00 p.m., with a repeat of the overview portions of the meeting and will continue until 10:00 p.m., as necessary. In addition, during the week of March 30, 2009, the NRC plans to conduct a site audit. You and your staff are invited to attend both the public meetings and the site audit. Your office will receive a copy of the draft SEIS along with a request for comments.

1

February 04, 2009

Colonel David C. Press, Commander
U.S. Army Corps of Engineers
Omaha District
106 South 15th Street
Omaha, NE 68102-1618

SUBJECT: COOPER NUCLEAR STATION LICENSE RENEWAL APPLICATION
REVIEW

Dear Colonel Press:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application submitted by Nebraska Public Power District (NPPD), for the renewal of the operating license for Cooper Nuclear Station (CNS), which is located in Nemaha County, Nebraska (NE), on the west bank of the Missouri River at river mile 532.5. The Village of Brownville, NE is located approximately 2.25 miles northwest of the site, and Lincoln, NE is located approximately 60 miles west northwest of the site. As part of the review of the license renewal application (LRA), the NRC is preparing a Supplemental Environmental Impact Statement (SEIS) under the provisions of Title 10 of the *Code of Federal Regulations* Part 51 (10 CFR Part 51), the NRC's regulation that implements the National Environmental Policy Act (NEPA) of 1969.

CNS is requesting the renewal of its operating license for a period of 20 years beyond the expiration of the current license term, renewing the license until January 18, 2034. The proposed action would include the use and continued maintenance of existing plant facilities and transmission lines; CNS does not plan to construct or alter any facilities associated with the plant during the period of extended operation.

The NRC staff plans to hold two identical public meetings covering the license renewal and environmental scoping process on February 25, 2009. The first session will be to be held at the Brownville Concert Hall at 126 Atlantic St., Brownville, NE 68321 telephone 402-825-3331, and will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second session will be held at the Auburn Senior Center at 1101 J St., Auburn, NE 68305, telephone 402-274 3420, and will convene at 7:00 p.m., with a repeat of the overview portions of the meeting and will continue until 10:00 p.m., as necessary. In addition, during the week of March 30, 2009 the NRC plans to conduct a site audit. You and your staff are invited to attend both the site audit and the public meetings. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is December 2009.

1

Appendix D

D. Press

- 2 -

If you have any questions concerning the NRC staff's review of this license renewal application, please contact NRC's Project Managers, Tam Tran, by telephone, 1-800-368-5642, extension 3617, or by email to the NRC at tam.tran@nrc.gov, or Emmanuel Sayoc, by telephone, 1-800-368-5642, extension 1924, or by email to the NRC at emmanuel.sayoc@nrc.gov.

Sincerely,

/RA/

David L. Pelton, Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-298

cc w/o encl.: See next page

1

February 04, 2009

Adrian Pushetonequa, Chairman
Sac and Fox Tribe of the Mississippi in Iowa
349 Meskwaki Road
Tama, IA 52339-9629

SUBJECT: REQUEST FOR SCOPING COMMENTS CONCERNING THE COOPER
NUCLEAR STATION, UNIT 1 LICENSE RENEWAL APPLICATION REVIEW

Dear Mr. Pushetonequa:

The U.S. Nuclear Regulatory Commission (NRC or the staff) has recently received an application from Nebraska Public Power District for the renewal of the operating license for the Cooper Nuclear Station (CNS) Unit 1, located in Nemaha County, Nebraska. The NRC is in the initial stages of developing a Supplemental Environmental Impact Statement to the Generic Environmental Impact Statement (GEIS), which will document the impacts associated with the license renewal of the CNS Unit 1. We would like your assistance in our review by providing input to the NRC's environmental review scoping process. The NRC's process includes an opportunity for public and inter-governmental participation in the environmental review. We want to ensure that you are aware of our efforts pursuant to Title 10 of the *Code of Federal Regulations* Part 51, Section 51.28(b). In addition, as outlined in 36 CFR 800.8(c), the NRC plans to coordinate compliance with Section 106 of the National Historic Preservation Act of 1966 through the requirements of the National Environmental Policy Act of 1969.

Under NRC regulations, the original operating license for a nuclear power plant is issued for up to 40 years. The license may be renewed for up to an additional 20 years if NRC requirements are met. The current operating license for CNS Unit 1 will expire in January 18, 2014. Provided for your information is the CNS Unit 1 Site Layout (Enclosure 1) and Transmission Line Map (Enclosure 2). Additionally, attached you will find a compact disk containing copies of the license renewal application and the GEIS.

The GEIS considered the environmental impacts of renewing nuclear power plant operating licenses for a 20-year period on all currently operating sites. In the GEIS the NRC staff identified 92 environmental issues and developed generic conclusions related to environmental impacts for 69 of these issues that apply to all plants or to plants with specific design or site characteristics. For the remaining 23 issues, plant-specific analyses will be documented in a supplement to the GEIS.

A Supplemental Environmental Impact Statement will be prepared for CNS Unit 1 to document the staff's review of environmental impacts related to terrestrial ecology, aquatic ecology, hydrology, cultural resources, and socioeconomic issues (among others), and will contain a recommendation regarding the environmental acceptability of the license renewal action.

1

Please submit any comments that you may have to offer on the scope of the environmental review by March 27, 2009. Written comments should be submitted by mail to the Chief, Rules and Directives Branch, Division of Administrative Services, Mail Stop T-6D59, U.S. Nuclear Regulatory Commission, Washington D.C. 20555-0001. Electronic comments may be submitted to the NRC by e-mail at CooperEIS@nrc.gov. At the conclusion of the scoping process, the NRC staff will prepare a summary of the significant issues identified and the conclusions reached, and mail a copy to you.

To accommodate interested members of the public, the NRC will hold two public scoping meetings for the CNS Unit 1 license renewal supplement to the GEIS on February 25, 2008. The first session will be held in the afternoon at the Brownville Concert Hall at 126 Atlantic Street, Brownville, NE 68321, telephone (402) 825-3331. The second session, covering the same subjects will be held in the evening at the Auburn Senior Center at 1101 J Street, Auburn, NE 68305, telephone (402) 274 3420. Additionally, the NRC staff will host informal discussions one hour before the start of each session. You and your staff are invited to attend the public meetings.

The CNS Unit 1 license renewal application and the GEIS are available on the internet at <http://www.nrc.gov/reactors/operating/licensing/renewal/applications/cooper.html>. In addition, the Auburn Memorial Library, 1810 Courthouse Avenue, Auburn, NE 68305, telephone (402) 274-4023, has agreed to make the license renewal application and the GEIS available for public inspection.

The staff expects to publish the draft Supplemental Environmental Impact Statement in December 2009. A copy of the document will be sent to you for your review and comment. The NRC will hold another set of public meetings in the site vicinity to solicit comments on the draft Supplemental Environmental Impact Statement. After consideration of public comments received, the NRC will prepare a final Supplemental Environmental Impact Statement, which is scheduled to be issued in July 2010.

The NRC is sending this letter to the tribal contacts for the following Federally-recognized tribes: Prairie Band of Potawatomi Indians, Iowa Tribe of Kansas and Nebraska, Iowa Tribe of Oklahoma, Kickapoo Tribe in Kansas, Otoe-Missouria Tribe of Indians, Omaha Tribe of Nebraska, Sac and Fox Nation of Missouri, Sac and Fox Nation of Oklahoma, and the Sac and Fox Tribe of Mississippi in Iowa.

If you need additional information regarding the license renewal review process, please contact Tam Tran, by telephone, 1-800-368-5642, extension 3617, or by e-mail at tam.tran@nrc.gov, or

- 3 -

Emmanuel Sayoc, by telephone, 1-800-368-5642, extension 1924, or by e-mail at emmanuel.sayoc@nrc.gov.

Sincerely,

/RA/

David L. Pelton, Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-298


Enclosures:

1. Site Layout
2. Transmission Line Map

cc w/encls: See next page



Cooper Nuclear Station Site Map – 6 Mile Radius



Cooper Nuclear Station Transmission Lines

ENCLOSURE 2

1
2

Emmanuel Sayoc

From: CooperEIS Resource
Sent: Thursday, April 16, 2009 1:39 PM
To: Emmanuel Sayoc
Subject: FW: Scoping Comments for Relicensing of Cooper Nuclear Station, Brownville, NE

-----Original Message-----

From: Shepard.Larry@epamail.epa.gov [mailto:Shepard.Larry@epamail.epa.gov]
Sent: Friday, March 27, 2009 4:59 PM
To: CooperEIS Resource
Cc: Cothorn.Joe@epamail.epa.gov; Hooper.CharlesA@epamail.epa.gov; Dunn.John@epamail.epa.gov; Lancaster.Kris@epamail.epa.gov
Subject: Scoping Comments for Relicensing of Cooper Nuclear Station, Brownville, NE

RE: Notice of Intent to Prepare an Environmental Impact Statement and Conduct Scoping Process for Cooper Nuclear Station; Federal Register Volume 74, No. 15, January 26,2009, page 4476.

Thank you for the opportunity to provide scoping comments on the proposed relicensing of Cooper Nuclear Station (CNS), in support of the U.S. Nuclear Regulatory Commission's (NRC) preparation of an Environmental Impact Statement (EIS). EPA reviewed this project in accordance with the National Environmental Policy Act (NEPA) and Section 309 of the Clean Air Act. We request that, in the future, the NRC provide an adequate period of time after conducting site audits for the submission of scoping comments by state or federal agencies. In this instance, scoping comments are to be submitted prior to the NRC site audit for this project.

Please consider the following comments during the EIS development process.

Radiation - Given the uncertainty involved with licensing the Yucca Mountain Nevada facility and the extremely long time-frames needed to secure Congressional approval and complete site preparation for any possible alternative permanent site for the disposal of spent nuclear fuel, all utilities planning on extending operation of existing nuclear units should consider contingencies for long-term storage of waste on-site.

Water Quality - The current CNS site has an existing infrastructure, which includes intake and discharge structures. The source of water for the plant is the Missouri River. Potential impacts to plant operation associated with available river flow, particularly during periods of sustained low flow, should be thoroughly described in the draft EIS. The draft EIS should articulate the assurance of a long-term water supply (i.e., greater than 20 years) for the operation of the reactor. This analysis should address contingencies created by changing regional climate and potential future changes in the operation of the river by the Army Corps of Engineers (i.e., flow

releases). The current facility is covered by a National Pollutant Discharge Elimination System (NPDES) permit issued by the Nebraska Department of Environmental Quality (NDEQ). New studies and analyses performed in support of the most recent permit application (e.g., thermal and chemical discharges) should be included in the draft EIS. The draft EIS should also completely discuss issues associated with entrainment and impingement of aquatic organisms (i.e., Section 316b of the Clean Water Act) and include alternatives to the present intake design. From a review of the Environmental Report, it is apparent that there is a great deal of information available regarding the impact of plant operation on the river ecosystem. However, we generally caution that these studies are 30 years old and the draft EIS should clearly articulate whether these data are representative of current river condition and ecological impact. We would expect the NRC to provide both its reasoning and data supporting that additional and more recent research is not required to adequately document current impacts.

The draft EIS should thoroughly characterize past contamination associated with the operation of CNS, particularly source and fate of tritium in the system, and document current condition of surface water and groundwater upstream and downstream from the site.

Environmental Management System - The Council on Environmental Quality (CEQ) published "Aligning NEPA processes with Environmental management Systems-A Guide for NEPA and EMS Practitioners" to improve NEPA implementation and environmental sustainability goals in NEPA and Executive Order 13423. The NEPA document should discuss EMS as appropriate.

Larry Shepard
NEPA Team/Interstate Waters
US EPA Region 7
913-551-7441

1

Appendix D

Richard Bulavinetz

From: Simpson, rachel [rachel.simpson@nebraska.gov]
Sent: Friday, May 08, 2009 4:11 PM
To: Richard Bulavinetz
Subject: RE: Cooper Nuclear Station (CNS) - T & E; & List of Species of Concern
Attachments: NNHP - species by county list for selected Nebraska counties.xls

Dear Mr. Bulavinetz,

Thank you for your inquiry regarding information our program has on species which potentially occur in the following counties: Nemaha County, Johnson County, Gage County, Lancaster County, Saline County, Fillmore County, York County, Hamilton County, and Merrick County.

Attached is the information you requested. Please don't hesitate to contact me if you have any questions about the interpretation of the data or would like additional information.

Sincerely,
Rachel

Rachel Simpson
Data Manager
Nebraska Natural Heritage Program
Nebraska Game and Parks Commission
2200 N. 33rd St.
Lincoln, NE 68503
rachel.simpson@nebraska.gov
402-471-5427

From: Schneider, Rick
Sent: Thursday, April 30, 2009 2:56 PM
To: Simpson, rachel
Cc: Richard.Bulavinetz@nrc.go
Subject: FW: Cooper Nuclear Station (CNS) - T & E; & List of Species of Concern

Rachel,

Could you send Richard a list of species, by county (see list below), for which we have records in the database. For each species, list the federal and state status, Legacy status, and species in need of conservation status. Also, could you include on the list those state or federally listed species which may occur in the county, even though we currently have no records. Richard is with a federal agency so there will be no charge for the data request.

Let me know if you have questions or you could contact Richard.
Thanks.

Rick Schneider
Coordinator/Ecologist
Nebraska Natural Heritage Program
Nebraska Game and Parks Commission
2200 N. 33rd St.
Lincoln, NE 68503

Rick.Schneider@nebraska.gov

402-471-5569

Please note new email address

From: Richard Bulavinetz [Richard.Bulavinetz@nrc.gov]
Sent: Thursday, April 30, 2009 2:40 PM
To: Schneider, Rick
Subject: Cooper Nuclear Station (CNS) - T & E; & List of Species of Concern

Rick:

Per our conversation 2 mins ago - here is my e-mail address.
The counties in question are:

Nemaha County, Johnson County, Gage County, Lancaster County, Saline County, Fillmore County, York County, Hamilton County, and Merrick County

Thanks for your help,

Rich

Richard E. Bulavinetz
Aquatic Ecologist
Nuclear Regulatory Commission
Rockville, MD 20852
301-415-3607
301-415-2002 (fax)
richard.bulavinetz@nrc.gov<mailto:richard.bulavinetz@nrc.gov>

<',) ///>< <',) ///>< <',) ///>< <',) ///>< <',) ///><

Appendix D

Species-by-County List for Selected Nebraska Counties
List produced May 8, 2009 by the Nebraska Natural Heritage Program

Source indicates whether the information came from existing records in the Nebraska Natural Heritage Database (source="Heritage DB") or from the Nebraska Natural Heritage Program's set of range maps for Threatened and Endangered Species (source="Listed Species Range Maps")

Source	COUNTY	SNMNE	SCOMNAME	GNMNE	GCOMNAME	STATE_STAT	FED_STAT	LCGY_STAT	S_RANK	G_RANK	ELEMENT_TY	CATEGORY
Heritage DB	Fillmore	Botaurus lentiginosus	American Bittern	Botaurus lentiginosus	American Bittern			Tier 2	S4	G4	Vertebrate Animal	A
Heritage DB	Fillmore	Circus cyaneus	Northern Harrier	Circus cyaneus	Northern Harrier			Tier 2	S4	G8	Vertebrate Animal	A
Heritage DB	Fillmore	Cistiophorus platensis	Sedge Wren	Cistiophorus platensis	Sedge Wren			Tier 2	S3	G5	Vertebrate Animal	A
Heritage DB	Fillmore	Elanoides forficatus	Wolf Spikewren	Elanoides forficatus	Wolf Spikewren			Tier 1	S2	G3G4	Vascular Plant	P
Listed Species Range Maps	Fillmore	Gus americana	Whooping Crane	Gus americana	Whooping Crane	E	E	Tier 1	S1	G1	Vertebrate Animal	A
Heritage DB	Fillmore	Haliaeetus leucocapillus	Bald Eagle	Haliaeetus leucocapillus	Bald Eagle			Tier 1	S3	G5	Vertebrate Animal	A
Heritage DB	Fillmore	Icthyophaga ciris	Owlhoot	Icthyophaga ciris	Blackfoot Owlhoot			Tier 2	S1	G5	Vascular Plant	P
Heritage DB	Fillmore	Nobolus gymnis	Least Bittern	Nobolus gymnis	Least Bittern			Tier 2	S4	G5	Vertebrate Animal	A
Heritage DB	Fillmore	Nycticorax nycticorax	Tadpole Molebird	Nycticorax nycticorax	Tadpole Molebird			Tier 2	S3	G5	Vertebrate Animal	A
Listed Species Range Maps	Fillmore	Platanthera praecoxa	Black-crowned Night-heron	Nycticorax nycticorax	Black-crowned Night-heron			Tier 2	S3	G5	Vertebrate Animal	A
Heritage DB	Fillmore	Rallus elegans	Western Prairie Fringed Orchid	Platanthera praecoxa	Western Prairie White-fringed CT	T		Tier 1	S2	G2	Vascular Plant	P
Heritage DB	Fillmore	Scopus heterochasus	King Rail	Rallus elegans	King Rail			Tier 1	S1	G4	Vertebrate Animal	A
Heritage DB	Fillmore	Sisyrinchium montanum	Slender Bulrush	Schoenoplectus heterochaetis	Slender Bulrush			Tier 2	S1	G5	Vascular Plant	P
Heritage DB	Fillmore	Sisyrinchium montanum	Rocky Mountain Bulrush	Schoenoplectus saximontanum	Rocky Mountain Bulrush			Tier 1	S1	G5	Vascular Plant	P
Heritage DB	Fillmore	Sisyrinchium montanum	Massasauga	Sisyrinchium calanota	Massasauga	T		Tier 1	S1	G3G4	Vertebrate Animal	A
Heritage DB	Gage	Agelaius phoeniceus	Copperhead	Agelaius phoeniceus	Copperhead		NC	Tier 2	S2	G5	Vertebrate Animal	A
Heritage DB	Gage	Bidens polycephala	Conopsis Beggar-tick	Bidens polycephala	Avenosa Beggar-ticks			Tier 2	S2	G5	Vascular Plant	P
Heritage DB	Gage	Carex burkii	Frank's Sedge	Carex burkii	Bull's Sedge			Tier 2	S1S2	G4	Vascular Plant	P
Heritage DB	Gage	Carex frankii	Frank's Sedge	Carex frankii	Frank's Sedge			Tier 2	S3	G5	Vascular Plant	P
Heritage DB	Gage	Carex leavenworthii	Lewin Sedge	Carex leavenworthii	Leavenworth's Sedge			Tier 2	S3	G5	Vascular Plant	P
Heritage DB	Gage	Crotalus horridus	Timber Rattlesnake	Crotalus horridus	Timber Rattlesnake		NC	Tier 1	S1	G4	Vertebrate Animal	A
Heritage DB	Gage	Crotalus horridus	Woody Croton	Croton capitatus var. capitatus	Hogwort			Tier 2	S3	G5	Vascular Plant	P
Heritage DB	Gage	Etheostoma nigrum	Johnny Darter	Etheostoma nigrum	Johnny Darter			Tier 2	S3	G5	Vertebrate Animal	A
Heritage DB	Gage	Etheostoma spectabile	Orangethroat Darter	Etheostoma spectabile	Orangethroat Darter			Tier 2	S3	G5	Vertebrate Animal	A
Heritage DB	Gage	Eumeces obsoletus	Great Plains Skink	Eumeces obsoletus	Great Plains Skink		NC	Tier 2	S3	G5	Vertebrate Animal	A
Heritage DB	Gage	Gastrophysa olivacea	Crested Plains Narrowmouth Toad	Gastrophysa olivacea	Great Plains Narrowmouth Toad		NC	Tier 2	S2	G5	Vertebrate Animal	A
Heritage DB	Gage	Haliaeetus leucocapillus	Bald Eagle	Haliaeetus leucocapillus	Bald Eagle			Tier 1	S3	G5	Vertebrate Animal	A
Heritage DB	Gage	Hirundo longipennis	Longpoint Hawkweed	Hirundo longipennis	Henry Hawkweed			Tier 2	S4	G4G5	Vascular Plant	P
Heritage DB	Gage	Lampropeltis calligaster	Pine Kingsnake	Lampropeltis calligaster	Yellow-bellied Kingsnake		NC	Tier 2	S2	G5	Vertebrate Animal	A
Heritage DB	Gage	Ligumia substriata	Pondmussel	Ligumia substriata	Pondmussel			Tier 1	S1	G8	Invertebrate Animal	A
Heritage DB	Gage	Neotoma floridana	Eastern Woodrat	Neotoma floridana	Eastern Woodrat			Tier 2	S3	G5	Vertebrate Animal	A
Heritage DB	Gage	Nobolus gymnis	Tadpole Molebird	Nobolus gymnis	Tadpole Molebird			Tier 2	S3	G5	Vertebrate Animal	A
Heritage DB	Gage	Pelusa atropurpurea	Purple Chiff Brake	Pelusa atropurpurea	Purple-blem Cliffbrake			Tier 2	S2	G5	Vascular Plant	P
Heritage DB	Gage	Pentstemon cobaea	Cobaea Pentstemon	Pentstemon cobaea	Cobaea Besardongue			Tier 1	S37	G4	Vascular Plant	P
Listed Species Range Maps	Gage	Platanthera praecoxa	Western Prairie Fringed Orchid	Platanthera praecoxa	Western Prairie White-fringed CT	T		Tier 2	S2	G2	Vascular Plant	P
Heritage DB	Gage	Rhynchospora alba	Graham's Crayfish Snake	Rhynchospora alba	Graham's Crayfish Snake		NC	Tier 1	S1	G3G4	Vertebrate Animal	A
Heritage DB	Gage	Sistrurus catenatus	Massasauga	Sistrurus catenatus	Massasauga			Tier 2	S2	G5	Vertebrate Animal	A
Heritage DB	Gage	Sistrurus catenatus	Simple-stem Bur-reed	Sistrurus catenatus	Greenfruit Bur-reed			Tier 2	S2	G5	Vascular Plant	P
Heritage DB	Gage	Sparganium chlorocarpum	Eastern Spotted Skunk	Sparganium chlorocarpum	Eastern Spotted Skunk			Tier 2	S1	G5	Vertebrate Animal	A
Heritage DB	Gage	Trifolium reflexum	Buffalo Clover	Trifolium reflexum	Buffalo Clover			Tier 2	S1	G3G4	Vascular Plant	P
Heritage DB	Hamilton	Charadrius melodus	Piping Plover	Charadrius melodus	Piping Plover		T	Tier 1	S2	G3	Vertebrate Animal	A
Heritage DB	Hamilton	Cistiophorus platensis	Sedge Wren	Cistiophorus platensis	Sedge Wren			Tier 2	S3	G5	Vertebrate Animal	A
Heritage DB	Hamilton	Culebra inornata	Brook Stickleback	Culebra inornata	Brook Stickleback			Tier 2	S3	G5	Vertebrate Animal	A
Heritage DB	Hamilton	Cyprinodon candidum	Small White Lady's-slipper	Cyprinodon candidum	Small White Lady's-slipper		T	Tier 1	S1	G4	Vascular Plant	P
Heritage DB	Hamilton	Elanoides forficatus	Wolf Spikewren	Elanoides forficatus	Wolf Spikewren			Tier 1	S2	G3G4	Vascular Plant	P
Heritage DB	Hamilton	Etheostoma nigrum	Johnny Darter	Etheostoma nigrum	Johnny Darter			Tier 2	S3	G5	Vertebrate Animal	A
Heritage DB	Hamilton	Etheostoma spectabile	Orangethroat Darter	Etheostoma spectabile	Orangethroat Darter			Tier 2	S3	G5	Vertebrate Animal	A
Heritage DB	Hamilton	Falco peregrinus	Peregrine Falcon	Falco peregrinus	Peregrine Falcon			Tier 2	S3	G5	Vertebrate Animal	A
Heritage DB	Hamilton	Fundulus scardiacus	Plains Topminnow	Fundulus scardiacus	Plains Topminnow			Tier 1	S2	G4	Vertebrate Animal	A
Heritage DB	Hamilton	Gus americana	Whooping Crane	Gus americana	Whooping Crane		E	Tier 1	S1	G1	Vertebrate Animal	A
Heritage DB	Hamilton	Icthyophaga ciris	Owlhoot	Icthyophaga ciris	Blackfoot Owlhoot			Tier 2	S1	G5	Vascular Plant	P
Heritage DB	Hamilton	Lutra canadensis	River Otter	Lutra canadensis	North American River Otter		T	Tier 1	S2	G5	Vertebrate Animal	A
Heritage DB	Hamilton	Macrhybopsis galata	Surgeon Chub	Macrhybopsis galata	Surgeon Chub		E	Tier 1	S1	G3	Vertebrate Animal	A
Heritage DB	Hamilton	Nobolus gymnis	Tadpole Molebird	Nobolus gymnis	Tadpole Molebird			Tier 2	S3	G5	Vertebrate Animal	A
Heritage DB	Hamilton	Nycticorax nycticorax	Black-crowned Night-heron	Nycticorax nycticorax	Black-crowned Night-heron			Tier 2	S3	G5	Vertebrate Animal	A
Listed Species Range Maps	Hamilton	Platanthera praecoxa	Western Prairie Fringed Orchid	Platanthera praecoxa	Western Prairie White-fringed CT	T		Tier 1	S2	G2	Vascular Plant	P
Heritage DB	Hamilton	Spilogale putorius	Eastern Spotted Skunk	Spilogale putorius	Eastern Spotted Skunk			Tier 2	S1	G5	Vertebrate Animal	A
Heritage DB	Hamilton	Stema arthurum atrifasciatus	Interior Least Tern	Stema arthurum atrifasciatus	Interior Least Tern		E	Tier 1	S2	G4T2Q	Vertebrate Animal	A
Heritage DB	Hamilton	Aesculus glabra var. arguta	Western Buckeye	Aesculus glabra var. arguta	Ohio Buckeye			Tier 2	S1S2	G5T4TQ	Vascular Plant	P
Heritage DB	Johnson	Ammodramus henslowi	Herlow's Sparrow	Ammodramus henslowi	Herlow's Sparrow			Tier 1	S2	G4	Vertebrate Animal	A
Heritage DB	Johnson	Ammodramus henslowi	Pale Indian-plantain	Ammodramus henslowi	Pale Indian-plantain			Tier 2	S2	G4G5	Vascular Plant	P

Heritage DB	Johnson	Asclepias amplexicaulis	Climbing Leaf Milkweed	Asclepias amplexicaulis	Climbing Milkweed	S1	C5	Vascular Plant
Heritage DB	Johnson	Asclepias virdis	Spider Milkweed	Asclepias virdis	Spider Milkweed	S5	G4G5	Vascular Plant
Heritage DB	Johnson	Asimina triloba	Pawpaw	Asimina triloba	Pawpaw	S47	G5	Vascular Plant
Heritage DB	Johnson	Cassipouera platensis	Sedge Wren	Cassipouera platensis	Sedge Wren	S3	G4	Vertebrate Animal
Heritage DB	Johnson	Dasyatis macroglypha	Mullen Frogglove	Dasyatis macroglypha	Mullen Frogglove	S1	G4	Vascular Plant
Heritage DB	Johnson	Desmodium cuspidatum	Largerbract Tick-leaf	Desmodium cuspidatum	Tweed Tick-leaf	S27	G5	Vascular Plant
Heritage DB	Johnson	Dracoccephalum parviflorum	American Dragonhead	Dracoccephalum parviflorum	American Dragonhead	S1	G5	Vascular Plant
Heritage DB	Johnson	Etheostoma nigrum	Prime Darter	Etheostoma nigrum	Johnny Darter	S3	G5	Vertebrate Animal
Heritage DB	Johnson	Lampropeltis callisaster	Common Kingsnake	Lampropeltis callisaster	Yellow-bellied Kingsnake	S2	G5	Vertebrate Animal
Heritage DB	Johnson	Liatris squarrosa var. hirsuta	Phlox Gayfeather	Liatris squarrosa var. hirsuta	Common Kingsnake	S17	G5	Vertebrate Animal
Heritage DB	Johnson	Litum michiganense	Tuck's Cap Lily	Litum michiganense	Gladiol Gayfeather	S37	G5	Vascular Plant
Heritage DB	Johnson	Melica nitens	Tall Melic	Melica nitens	Michigan Lily	S1	G5	Vascular Plant
Heritage DB	Johnson	Ophiocoma attenuata	Slender Glass Lizard	Ophiocoma attenuata	Three-flower Milkgrasses	S1	G5	Vertebrate Animal
Heritage DB	Johnson	Penstemon tuberosus	Funnel-form Penstemon	Penstemon tuberosus	White-wand Beardtongue	S1	G5	Vascular Plant
Heritage DB	Johnson	Phenacoccus mirabilis	Suckermouth Minnow	Phenacoccus mirabilis	Suckermouth Minnow	S4	G5	Vertebrate Animal
Heritage DB	Johnson	Platanthera praecoxa	Western Prairie Fringed Orchid	Platanthera praecoxa	Western Prairie White-fringed C.T.	S2	G2	Vascular Plant
Heritage DB	Johnson	Senna mandanica	Wild Senna	Senna mandanica	Maryland Senna	S152	G5	Vascular Plant
Heritage DB	Johnson	Sistruncus catabasis	Massasauga	Sistruncus catabasis	Massasauga	S1	G3G4	Vertebrate Animal
Heritage DB	Johnson	Trochilus biflorus	Small Venus-looking glass	Trochilus perfoliatus var. biflorus	Clastrigial Venus-looking-glass	S1	G5	Vascular Plant
Heritage DB	Johnson	Vernoniastrum virginicum	Cuiver's-root	Vernoniastrum virginicum	Cuiver's-root	S1	G4	Vascular Plant
Heritage DB	Lancaster	Agalinis skinneriana	Pale False Foxglove	Agalinis skinneriana	Pale False Foxglove	SNA	G3G4	Vascular Plant
Heritage DB	Lancaster	Ammodramus henslowi	Henslow's Sparrow	Ammodramus henslowi	Henslow's Sparrow	S2	G4	Vertebrate Animal
Heritage DB	Lancaster	Arabis shortii	Short's Rockcress	Arabis shortii	Short's Rockcress	S2	G5	Vascular Plant
Heritage DB	Lancaster	Ardea herodias	Great Blue Heron	Ardea herodias	Great Blue Heron	S4	G5	Vertebrate Animal
Heritage DB	Lancaster	Arisaema dracontium	Green Dragon	Arisaema dracontium	Green Dragon	S2	G5	Vascular Plant
Heritage DB	Lancaster	Asclepias virdis	Spider Milkweed	Asclepias virdis	Spider Milkweed	S5	G4G5	Vascular Plant
Heritage DB	Lancaster	Aster subulatus var. igneatus	Saltmarsh Aster	Aster subulatus var. igneatus	Saltmarsh Aster	S47	G5	Vascular Plant
Heritage DB	Lancaster	Alypte angulos lowii	Iowa Skipper	Alypte angulos lowii	Iowa Skipper	S1	G37	Invertebrate Animal
Heritage DB	Lancaster	Biophila hirsuta	Wood-snip	Biophila hirsuta	Hairy Woodmint	S1	G37	Vascular Plant
Heritage DB	Lancaster	Botaurus lentiginosus	American Bitern	Botaurus lentiginosus	American Bitern	S4	G4	Vertebrate Animal
Heritage DB	Lancaster	Carex crux-cornii	Raven's Foot Sedge	Carex crux-cornii	Ravenfoot Sedge	S1	G5	Vascular Plant
Heritage DB	Lancaster	Carex squarrosa	Squarestem Sedge	Carex squarrosa	Squarestem Sedge	SNA	G4G5	Vascular Plant
Heritage DB	Lancaster	Cicindela nevadica incolniana	A Tiger Beetle	Cicindela nevadica incolniana	Salt Creek Tiger Beetle	S1	G571	Invertebrate Animal
Heritage DB	Lancaster	Cicindela togata	Tiger Beetle	Cicindela togata	White-donked Tiger Beetle	S1	G5	Invertebrate Animal
Heritage DB	Lancaster	Cistothorus palustris	Sedge Wren	Cistothorus palustris	Sedge Wren	S3	G5	Vertebrate Animal
Heritage DB	Lancaster	Colinus virginianus	Northern Bobwhite	Colinus virginianus	Northern Bobwhite	S1	G5	Vertebrate Animal
Heritage DB	Lancaster	Corydalis aurea	Golden Corydalis	Corydalis aurea	Golden Corydalis	S1	G5	Vascular Plant
Heritage DB	Lancaster	Crabon capitatus var. capitatus	Woolly Crabon	Crabon capitatus var. capitatus	Hogweed	S47	G5757	Vascular Plant
Heritage DB	Lancaster	Culex inornatus	Brook Stickleback	Culex inornatus	Brook Stickleback	S3	G5	Vertebrate Animal
Heritage DB	Lancaster	Cynops buccinator	Trumpeter Swan	Cynops buccinator	Trumpeter Swan	S3	G4	Vertebrate Animal
Heritage DB	Lancaster	Cypripedium candidum	Small White Lady's-slipper	Cypripedium candidum	Small White Lady's-slipper	S1	G4	Vascular Plant
Heritage DB	Lancaster	Dracoccephalum parviflorum	American Dragonhead	Dracoccephalum parviflorum	American Dragonhead	S1	G5	Vascular Plant
Heritage DB	Lancaster	Eragrostis repens	Hairy Creeping Lovegrass	Eragrostis repens	Hairy Creeping Lovegrass	S1	G5	Vascular Plant
Heritage DB	Lancaster	Erythronium inopsiflorum	Small Yellow-flower	Erythronium inopsiflorum	Small-flower Prairie Yellowflower	S2	G5	Vascular Plant
Heritage DB	Lancaster	Erythronium mesocherum	Pringle Dog-tooth-violet	Erythronium mesocherum	Midland Frenally	S2	G5	Vascular Plant
Heritage DB	Lancaster	Eupatorium serotinum	Late Boreact	Eupatorium serotinum	Late-flowering Throughwort	S57	G5	Vascular Plant
Heritage DB	Lancaster	Falco peregrinus	Peregrine Falcon	Falco peregrinus	Peregrine Falcon	S1	G4	Vertebrate Animal
Heritage DB	Lancaster	Gallinago delicata	Wilson's Snipe	Gallinago delicata	Wilson's Snipe	S4	G5	Vertebrate Animal
Heritage DB	Lancaster	Haliaeetus leucocapillus	Bald Eagle	Haliaeetus leucocapillus	Bald Eagle	S3	G5	Vertebrate Animal
Heritage DB	Lancaster	Heliotropium curassavicum var. curassavicum	Sea-rocket	Heliotropium curassavicum var. curassavicum	Sea-rocket	S1	GNR	Vascular Plant
Heritage DB	Lancaster	Heracleum longibulum	Longboard Hawkweed	Heracleum longibulum	Hairy Hawkweed	S4	G4G5	Vascular Plant
Heritage DB	Lancaster	Isobrychus exilis	Least Bittern	Isobrychus exilis	Least Bittern	S4	G5	Vertebrate Animal
Heritage DB	Lancaster	Lampropeltis callisaster	Common Kingsnake	Lampropeltis callisaster	Yellow-bellied Kingsnake	S2	G5	Vertebrate Animal
Heritage DB	Lancaster	Lampropeltis getula	Common Kingsnake	Lampropeltis getula	Common Kingsnake	S1	G5	Vertebrate Animal
Heritage DB	Lancaster	Larus ludovicianus	Loggerhead Shrike	Larus ludovicianus	Loggerhead Shrike	S5	G4	Vertebrate Animal
Heritage DB	Lancaster	Laternaria jamaicensis	Black Rail	Laternaria jamaicensis	Black Rail	S1	G4	Vertebrate Animal
Heritage DB	Lancaster	Ligumia subrostrata	Pondmussel	Ligumia subrostrata	Pondmussel	S1	G5	Invertebrate Animal
Heritage DB	Lancaster	Musala rivialis	Least Wessal	Musala rivialis	Least Wessal	S5	G5	Vertebrate Animal
Heritage DB	Lancaster	Myriophyllum pinnatum	Culleaf Water Milfoil	Myriophyllum pinnatum	Culleaf Water-milfoil	S1	G5	Vascular Plant
Heritage DB	Lancaster	Nyctophorus americanus	American Burying Beetle	Nyctophorus americanus	American Burying Beetle	S1	G2G3	Invertebrate Animal
Heritage DB	Lancaster	Notropis heterolepis	Blacknose Shiner	Notropis heterolepis	Blacknose Shiner	S1	G4	Vertebrate Animal
Heritage DB	Lancaster	Notropis topoka	Topoka Shiner	Notropis topoka	Topoka Shiner	S1	G3	Vertebrate Animal
Heritage DB	Lancaster	Nyctar vauquata	Yellow pond-lily	Nyctar vauquata	Nyctar vauquata	S2	GNR	Vascular Plant
Heritage DB	Lancaster	Nymphalaea odorata	White Water-lily	Nymphalaea odorata	American Water-lily	S27	G5	Vascular Plant
Heritage DB	Lancaster	Obolancha uniflora	One-flower Broomrape	Obolancha uniflora	One-flowered Broomrape	S1	G5	Vascular Plant
Heritage DB	Lancaster	Penstemon cobaea	Cobaea Penstemon	Penstemon cobaea	Cobaea Beardtongue	S37	G4	Vascular Plant
Heritage DB	Lancaster	Pimephales notatus	Bluntnose Minnow	Pimephales notatus	Bluntnose Minnow	S37	G5	Vascular Plant
Heritage DB	Lancaster	Platanthera elongata	Slender Plantain	Platanthera elongata	Slender Plantain	S3	G4	Vascular Plant
Heritage DB	Lancaster	Platanthera praecoxa	Western Prairie Fringed Orchid	Platanthera praecoxa	Western Prairie White-fringed C.T.	S3	G3	Vascular Plant



United States Department of the Interior

FISH AND WILDLIFE SERVICE
Ecological Services
Nebraska Field Office
203 West Second Street
Grand Island, Nebraska 68801

June 8, 2009

Mr. Joe Citta
Corporate Environmental Manager
Nebraska Public Power District
1414 15th Street; PO Box 499
Columbus, NE 68602-0499

Dear Mr. Citta:

Please make reference to your letter dated May 8, 2009, in regards to marking a transmission line that crosses the central Platte River downstream of the Highway 34 Bridge, east of Grand Island, Nebraska. The transmission line is associated with the Cooper Nuclear Station (CNS) and the currently ongoing relicensing process. A site visit of the transmission line was conducted by representatives of the Nebraska Public Power District (NPPD) and the U.S. Fish and Wildlife Service on April 20, 2009.

We have completed a review of the NPPD proposal to mark the power line to address potential collisions by migratory birds and have determined that it is satisfactory. Additionally, we commend NPPD for its willingness to mark an additional transmission line in the immediate vicinity of the aforementioned line that could also pose a risk to migratory birds, but has no relationship to the CNS relicensing process. The proposed actions by NPPD address any concerns we have with the CNS 345kV transmission line.

We remain supportive of the relicensing application. If you have any questions or need additional information please contact Mr. Robert Harms at (308) 382-6468, extension 17.

Sincerely,

June M. DeWeese
Nebraska Field Supervisor

cc: NGPC; Lincoln, NE (Attn: Frank Albrecht)
NGPC; Lincoln, NE (Attn: Gene Zuerlein)
NGPC; Lincoln, NE (Attn: Scott Luedtke)
NGPC; Lincoln, NE (Attn: Michelle Koch)

**APPENDIX D.2 BIOLOGICAL ASSESSMENT
COOPER NUCLEAR STATION LICENSE
RENEWAL DATE 2009 DOCKET NO. 50-298
U.S. NUCLEAR REGULATORY COMMISSION
ROCKVILLE, MARYLAND**

1 **D.2 BIOLOGICAL ASSESSMENT OF THE POTENTIAL EFFECTS ON FEDERALLY**
2 **LISTED ENDANGERED OR THREATENED SPECIES FROM THE PROPOSED**
3 **LICENSE RENEWAL FOR COOPER NUCLEAR STATION**

4 **D.2.1 INTRODUCTION AND PURPOSE**

5 The U.S. Nuclear Regulatory Commission (NRC) prepared this biological assessment (BA) to
6 support the draft supplemental environmental impact statement (SEIS) for the renewal of the
7 operating licenses for Cooper Nuclear Station Unit 1 (CNS-1), located on the western shore of
8 the Missouri River near the Village of Brownville, Nemaha County, Nebraska. The current 40-
9 year license expires in 2014. The proposed license renewal for which this BA has been
10 prepared would extend the operating licenses to 2034.

11 The NRC is required to prepare the draft SEIS as part of its review of a license renewal
12 application. The draft SEIS supplements NUREG-1437, Volumes 1 and 2, *Generic*
13 *Environmental Impact Statement (GEIS) for License Renewal of Nuclear Plants*, (NRC 1996,
14 1999)^a for the license renewal of commercial nuclear power plants. The draft SEIS covers
15 specific issues, such as the potential impact on endangered and threatened species, that are of
16 concern at CNS-1 and that NRC could not address generically in the GEIS.

17 Pursuant to Section 7 of the Endangered Species Act (ESA) of 1973, as amended (16 U.S.C. §
18 1536(a)-(d)), the NRC staff requested, in a letter dated January 29, 2009 (NRC, 2009), that the
19 U.S. Fish and Wildlife Service (USFWS) provide information on Federally listed endangered or
20 threatened species, as well as on proposed or candidate species, and on any designated critical
21 habitats that may occur in the vicinity of CNS-1. Under Section 7, the NRC is responsible for
22 providing information on the potential impact that the continued operation of CNS-1 could have
23 on the Federally listed species, the pallid sturgeon.

24 **D.2.2 PROPOSED ACTION**

25 The proposed action considered in the SEIS is the renewal of the CNS-1 operating license for
26 an additional 20-year term beyond the period of the existing licenses. If the NRC grants the
27 operating license renewal, the applicant can operate and maintain the nuclear unit, the cooling
28 system, and the transmission lines and corridors as they are now until 2034.


29 **D.2.3 SITE DESCRIPTION**

30 CNS-1 is located in Nemaha County, Nebraska 2.25 miles (3.6 km) southeast of Brownville,
31 Nebraska and approximately 60 miles (96 km) southeast of Lincoln, Nebraska. CNS-1 property
32 is bounded on the east by the Missouri River and by non-Nebraska Public Power District
33 (NPPD) owned property on the north, south, and west. Figure 3-1 shows a map of a 50-mile
34 (80-km) radius around CNS-1. Figure 3-2 shows the area within a 6-mile (9.6-km) radius of
35 CNS-1. NPPD owns and operates the site. The structures for CNS-1 span approximately 55
36 acres (22 ha) of the site's total area of approximately 1,359 acres (550 ha), including 239 acres
37 (97 ha) on the opposite bank (east) of the Missouri River in Atchison County, Missouri. Over 99
38 percent of the acreage in Nemaha County is used for agriculture and farming. NPPD currently

^a The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and its Addendum 1.

Appendix D.2

- 1 leases 234 acres (947 ha) of the property in Missouri and 715 acres (289 ha) in Nebraska for
- 2 agricultural activities such as farming and livestock.



3

4 **Figure 3-1. Location of Cooper Nuclear Station Unit 1, 50-mile (80-km) Region**

5 (Source: NPPD, 2008b)




1

2 **Figure 3-2. Location of Cooper Nuclear Station Unit 1, 6-miles (10-km) Region**
 3 (Source: NPPD, 2008b)

Appendix D.2

1 CNS-1 is a single-unit boiling water reactor plant with a nuclear steam supply system supplied
2 by General Electric Company and a turbine generator set supplied by Westinghouse Electric
3 Corporation. CNS-1 achieved commercial operation in 1974 with an initial licensed core thermal
4 power of 2,381 megawatt-thermal (MWt). In 2008, with NRC approval, the applicant performed
5 a measurement uncertainty recapture uprate that increased the core thermal power by 1.62
6 percent to its current level of 2,419 MWt and 830 megawatt-electric (MWe) (NPPD, 2008b).
7 Figure 3-3 shows the general layout of the buildings at CNS-1. The principal structures at CNS-
8 1 consist of the reactor building, turbine building (including service area appendages), control
9 building, controlled corridor, radwaste building, augmented radwaste building, intake structure,
10 off-gas filter building, elevated release point, diesel generator building, multi-purpose facility,
11 railroad airlock, drywell and suppression chamber, miscellaneous circulating water system
12 structures (e.g., circulating water conduits, seal well), optimum water chemistry gas generator
13 building, and office building. Visually dominant features are the 290-foot (88-m) tall reactor
14 building, the 325-foot (99-m) tall elevated release point, and the 328.8-foot (100-m) tall
15 meteorological tower.



1
 2 **Figure 3-3. Cooper Nuclear Station Unit 1, General Site Layout** (Source: NPPD, 2008b)

3 CNS-1 lies on the western shore of the Missouri River, withdraws river water for its once-
 4 through cooling system, and discharges heated water back to the river. Unless otherwise cited,
 5 NRC staff drew information about CNS-1's cooling and auxiliary water systems from NPPD
 6 (2006b) and the applicant's environmental report (ER) (NPPD, 2008b), where more in-depth
 7 information appears. In the vicinity of the plant, the Missouri River has a regulated minimum flow
 8 of 31,000 cubic feet per second (cfs) (878 m³/sec) to the southeast. The circulating water intake
 9 structure is located on the western shore of the river behind a guide wall and submerged weir
 10 meant to reduce the amount of suspended sediment in the cooling water. The weir attaches to
 11 shoreline structures north of the intake and then runs parallel to the face of the intake at a
 12 distance of 14.25 feet (4.3 m). The wall continues past the intake and ends 40 feet (12 m)
 13 downstream of the corner of the intake structure. In a line riverward of the weir wall and

Appendix D.2


1 extending downstream of it, 23 sheet pile vanes (10 feet wide by 6 feet high (3 m wide by 2 m
2 high)), oriented at a 22 degree angle to the weir, redirect sand and gravel outward from the weir
3 and the intake structure. After flowing generally south along the weir and vanes, river water
4 must reverse course and turn northwest to move between the weir and shore and reach the
5 intake bays. Water velocity between the weir wall and the cooling water intake structure is about
6 4 ft/sec (1.2 m/sec).

7 In winter, about 25 to 30 percent of the main condenser discharge water re-circulates through
8 an ice control tunnel at the front of the intake structure and discharges in front of the trash rack
9 to prevent icing. Water flows beneath a curtain wall at about 1.1 ft/sec (0.34 m/sec). Water
10 enters the five intake bays, four of which provide circulating water and are 22 feet (6.7 m) wide
11 and one of which provides service water and is 22.5 feet (6.8 m) wide. The incoming water then
12 flows through trash racks, 3/8 inch (1 cm) vertical bars separated 3 inches (7.6 cm) on center, at
13 up to 0.7 ft/sec (20 cm/sec).

14 The circulating water intake bays each separate into two screen bays and the service water
15 intake bay narrows before water encounters the traveling screens, which are oriented at right
16 angles to the flow. Water filters through 1/8 by 1/2-inch (3.175 by 1.27 cm) smooth-top mesh of
17 nine modified dual-flow traveling screens (eight for circulating water and one for service water)
18 twice: on the upward pass in the front and the downward pass behind as the screens, installed
19 in 2006, rotate continuously at 8.2 ft/min (2.5 m/min). The intake water velocity at the screens is
20 about 2 ft/sec (0.6 m/sec).


21 After the 4.2-foot (1.28-m) wide traveling screen panels rotate over the upper cog and begin
22 moving down, a high pressure (30-60 psig, 200-400 kPa) screen wash of 3,000 gallons per
23 minute (gpm) (0.19 m³/sec) supplied by the service water pumps removes fish and debris, which
24 return together to the river through an 18-inch (0.46-m) diameter steel pipe that discharges
25 downstream from the intake. Although the screens are fitted with fish baskets, the system has
26 neither a low-pressure spray system to more gently remove fish from the screens nor a fish
27 return trough to convey fish and other aquatic organisms back to the river separately from
28 potentially damaging debris. Debris loads are about 10 cubic yards per month (8 m³/month).

29 CNS-1 plans to install "dual-flow conversion screen fish handling systems" during its current
30 operational term. This system would have low pressure (5-10 psi, 35-70 kPa) fish washing
31 sprays on both the ascending and descending screens and a fish return trough that is separate
32 from the debris trough. A recovery basket would collect fish and other aquatic organisms
33 washed from the screens, and the fish trough would return them to the river. Figures 3-4
34 through 3-6 show the CNS-1 intake structures.




1

2 **Figure 3-4. Cooper Nuclear Station Unit 1 Intake Structure Plan** (Source: NPPD, 2008b)



3

4 **Figure 3-5. Cooper Nuclear Station Unit 1 Intake Structure Section** (Source: NPPD, 2008b)



1

2 **Figure 3-6. Cooper Nuclear Station Unit 1 Typical Dual Flow Screen**

3 *(Source: NPPD, 2008b)*

4 After water passes through the traveling screens, the two screen bays of each intake bay rejoin
 5 behind the screens. The four circulating water pumps, one per bay, can draw water from the
 6 bays and can provide up to 159,000 gpm (10 m³/sec) each. The four service water pumps in the
 7 fifth bay can provide a combined flow of 32,000 gpm (2 m³/sec). Water from the circulating
 8 water pumps travels to and circulates through the condenser, where it cools steam from the
 9 turbines. Because of the scouring from the suspended sediment, CNS-1 typically does not need

1 to chlorinate the circulating water to control biological film fouling, although it has the capacity to
2 chlorinate or brominate if needed. NPPD is studying the effectiveness of those options.

3 Water temperature increases about 17.8 °F (10 °C) as it passes through the condenser tubes.
4 From the condenser, circulating cooling water flows through concrete tunnels to a seal well
5 structure and then to the discharge canal, where it travels about 1,000 ft (300 m) to discharge to
6 the river at a slight angle. Water velocity at the discharge is about 1 ft/sec (0.3 m/sec) at
7 average river flow and about 5.6 ft/sec (1.7 m/sec) during low flows. The travel time from the
8 intake structure to the discharge is about 20 minutes at high river flow and 10 to 12 minutes at
9 low flows.

10 Cooling water flow varies with electrical load and ambient river water temperature. At full load
11 during summer, the expected circulating water system flow is highest: about 636,000 gpm
12 (40 m³/sec). Circulating water flow is lower under other conditions. In comparison, the lowest
13 river flow at CNS-1 is about 3,000 cfs. Under these worst conditions, the circulating water
14 system flow would be about 47 percent of the Missouri River flow. Stone rip-rap at the discharge
15 structure prevents the discharge from eroding the river bottom.

16 **D.2.4 STATUS REVIEW OF PALLID STURGEON**

17 D.2.4.1 *Life History*

18 Sturgeons are members of an order of fish (*Acipenseriformes*) that probably evolved in the
19 Devonian age. Living members of this order in North America include the paddlefish and eight
20 sturgeon species. The paddlefish *Polyodon spathula* and three sturgeon species, the lake
21 sturgeon *Acipenser fulvescens*, pallid sturgeon *Scaphirhynchus albus*, and the shovelnose
22 sturgeon *S. platyrhynchus*, live in the Missouri and Mississippi Rivers. In the past, commercial
23 fishermen harvested all three of the sturgeon species in the Missouri and Mississippi rivers.
24 Today pallid sturgeon are a Federally-listed endangered species, and lake sturgeon are listed
25 as endangered by Nebraska. The life history information below is from Dryer and Sandvol
26 (1993) and USFWS (2007) if not otherwise cited.

27 Pallid sturgeon have a flattened snout, a long tail, and rows of bony armor plates. The upper
28 side is convex and the lower side is straight. They have an inferior (bottom-facing) mouth and
29 eat invertebrates, such as the immature stages of insects, and fish. The body shape is well
30 adapted for swimming close to the bottom of relatively fast flowing, large rivers. The diet, inferior
31 mouth, and barbels in front of the mouth are well adapted to feeding on or near the bottom in
32 highly turbid environments.

33 The USFWS listed pallid sturgeon as endangered in 1990. The historic abundance of pallid
34 sturgeon is somewhat vague since biologists did not recognize it as a separate species from
35 shovelnose sturgeon until 1905, but its historical range probably extended from the middle and
36 lower Mississippi River in the south up through the Missouri River and lower reaches of the
37 Platte, Kansas, and Yellowstone rivers in the north and west. The pallid sturgeon is one of the
38 largest fish species in those rivers. Available information suggests that the pallid sturgeon was
39 not a common species since the time of European settlement. Today pallid sturgeon are among
40 the rarest fish of the Missouri and Mississippi River basins, and the present range includes the
41 States of Montana, North and South Dakota, Nebraska, Iowa, Kansas, Missouri, Illinois,
42 Kentucky, Arkansas, Mississippi, and Louisiana. The populations are largely older fish that will
43 die off in the near future.

1 Fisheries biologists know little about pallid sturgeon reproduction or even preferred spawning
2 habitats and conditions. Hurley et al. (2004) tracked sonically-tagged pallid sturgeon in the
3 Mississippi River and found that they exhibited positive selection for the main-channel border,
4 downstream island tips, between-wing-dam, and wing-dam-tip habitats; they showed negative
5 selection for main-channel, downstream of wing dams, and upstream of wing dam habitats. The
6 sturgeon exhibited little habitat selection for temperature or dam discharge. The authors
7 concluded that habitat enhancement and restoration of habitat diversity might be necessary for
8 recovery of pallid sturgeon.

9 Reports of pallid sturgeon reproduction are rare. The U.S. Geological Survey (USGS) (2007),
10 Nebraska Game and Parks Commission (NGPC), and the U.S. Army Corps of Engineers
11 (USACE) confirmed spawning of two female pallid sturgeon in the upstream reaches of the
12 lower Missouri River in May 2007. The capture of young pallid sturgeon that would verify natural
13 reproduction are also rare: none were captured between 1978 and a Mississippi River trawl
14 survey in 1998 through 2000 using equipment designed to capture larval fish in deep, turbulent
15 water (Hrabik et al., 2007). Hrabik et al. (2007) concluded that those latest captures verified
16 reproduction, possibly from the lower Missouri River to the upper and lower Mississippi River,
17 although they also found no evidence of recruitment of pallid sturgeon because they captured
18 no juveniles after 374 trawl hauls that captured over 21,735 fish in that 1998 through 2000
19 survey. Wildhaber et al. (2007) suggest that one or more of the following factors may be
20 responsible for the lack of finding larval pallid sturgeon and of recruitment: lack of successful
21 spawning, low recruitment, high mortality, ineffective sampling methods, inadequate sampling of
22 drift and settling locations, or rapid dispersal and washout of sturgeon larvae in the Missouri and
23 Mississippi rivers. Pallid sturgeon larvae are indistinguishable from those of the congeneric
24 shovelnose sturgeon, which may also help to explain the paucity of reported collections in the
25 past. Also, the construction of dams and other structures with resulting habitat change and the
26 elimination of shallow areas in the river with little or no flow have probably deprived sturgeon of
27 critical nursery areas needed for the survival of immature sturgeon (Missouri Department of
28 Conservation, 2009).

29 Larval pallid and shovelnose sturgeon become strongly photopositive and migrate upwards
30 toward the light starting the first day after hatching. As a result, they remain far above the
31 bottom, even at the water surface, and migrate far downriver (Kynard et al., 2002). Cultured
32 yearling pallid sturgeon in laboratory studies also migrate downstream during summer and fall,
33 which suggests a two-stage (larval, then yearling) downriver migration in the first year of life.
34 Adult sturgeon are also highly migratory and often migrate hundreds of miles in a year.

35 The young of both shovelnose and pallid sturgeon eat invertebrates, but as pallid sturgeon
36 grow, they become more piscivorous. Gerrity and Guy (2006) found that the diet of juvenile
37 pallid sturgeon of age 6 and 7 was mostly fish, compared to the diet of shovelnose sturgeon,
38 which is mainly aquatic insects. Sturgeon chub (*Macrhybopsis gelida*) and sicklefin chub (*M.*
39 *meeki*) together comprised 79 percent of the number of identifiable fish in juvenile pallid
40 sturgeon stomachs. Populations of these two cyprinid minnows have declined throughout much
41 of the Missouri River due to the construction of dams and man's other alterations of river
42 habitat, and the State of Nebraska lists sicklefin chub as threatened and sturgeon chub as
43 endangered. While the population of the piscivorous pallid sturgeon has declined in the Missouri
44 and Mississippi rivers, the population of its similar, insectivorous congener, shovelnose
45 sturgeon, has not declined. Gerrity and Guy (2006) concluded that the prevalence of sicklefin
46 chub and sturgeon chub as a food resource of juvenile pallid sturgeon may help explain the
47 decline of pallid sturgeon populations and that recovery and management of native cyprinids is
48 a potentially important step in the recovery of pallid sturgeon.

1 Male pallid sturgeon are believed to mature at 7 to 9 years after which they spawn at intervals of
 2 2 to 3 years. Females may reach sexual maturity at 7 to 15 years and spawn at intervals up to
 3 10 years. Individuals may reach ages of 60 years or more and reach lengths of 6 feet (2 m).
 4 Like many other fish species, the largest individuals are found farthest north in the species'
 5 range and maximum size decreases with distance south. For example, the maximum weight of
 6 pallid sturgeon in the upper Missouri River in Montana and North Dakota is 86 pounds (39 kg),
 7 in the Missouri River in South Dakota and Nebraska 46 pounds (21 kg), and in the Mississippi
 8 River 26 pounds (12 kg). They become much larger than shovelnose sturgeon, which rarely
 9 weigh more than 8 pounds (3.6 kg).

10 D.2.4.2 *Status of Pallid Sturgeon in the Missouri River*

11 While they were successful in the historical Missouri and Mississippi rivers, with the high flow
 12 and turbidity and diverse habitats of floodplains, backwaters, chutes, sloughs, islands, sand and
 13 gravel bars, and both braided and main channels, they are not so well adapted to the Missouri
 14 and Mississippi rivers today with the construction of dams that isolated subpopulations,
 15 channelization, controlled flow, and elimination of habitat diversity. The USFWS (2007)
 16 concludes that man's activities have adversely affected all of the 3,350 miles (5,390 km) of river
 17 habitat within their range, and habitat alteration and loss may be the biggest threat to their
 18 existence. Other threats may include hybridization with shovelnose sturgeon, commercial
 19 fishing, and exposure to environmental contaminants such as polychlorinated biphenyls (PCBs),
 20 cadmium, mercury, selenium, chlordane, dichlorodiphenyltrichloroethane (DDT),
 21 dichlorodiphenyltrichloroethylene (DDE), and dieldrin, all of which have been found in pallid
 22 sturgeon tissue in the past.

23 During the early 1990s, the Missouri Department of Conservation (MDC) developed "action
 24 plans" for lake and pallid sturgeon a goal of reestablishing self-sustaining populations so they
 25 can be delisted as endangered species and ultimately provide limited sport fisheries. These
 26 plans stress the restoration of both species through habitat improvement, artificial propagation,
 27 protection, research, management, and education (MDC, 2009). As part of this effort, the MDC's
 28 Blind Pony Fish Hatchery has raised and stocked over 13,000 fingerling pallid sturgeon and
 29 200,000 fingerling lake sturgeon into the Missouri and Mississippi rivers (MDC, 2009). In
 30 addition to these efforts, the USGS (Wildhaber et al., 2007) has developed a conceptual life
 31 history to organize the understanding about the complex life history of *Scaphirhynchus*
 32 sturgeons and improve understanding of the effects of management actions on the ecological
 33 requirements of pallid and shovelnose sturgeons. The USFWS's Pallid Sturgeon Recovery Plan
 34 (Dryer and Sandvol, 1993) designated six recovery priority management areas (RPMAs) for
 35 implementation of recovery tasks, and CNS-1 is located within RPMA 4.

36 D.2.4.3 *Impact Assessment of Cooper Nuclear Station on Pallid Sturgeon*

37 NPPD (2008a) summarizes interactions between NPPD and both State and Federal agencies
 38 regarding conservation of pallid sturgeon. That summary is outlined below:

39 In March 2006, before filing a license renewal application with NRC, NPPD voluntarily
 40 participated in meetings with the USFWS, the NGPC, the Nebraska Department of
 41 Environmental Quality (NDEQ), the Nebraska Department of Natural Resources (DNR), the
 42 EPA, and the USACE regarding conservation actions to improve the habitat of pallid sturgeon.
 43 NPPD (2008a) summarizes those meetings. Early in the discussions, the USFWS and NGPC
 44 showed interest in developing existing habitat on a parcel of property south of CNS-1 at
 45 Langdon Bend and later also in CNS-1 property on the Nebraska side of the Missouri River

Appendix D.2

1 adjacent to Langdon Bend. They hoped to enhance pallid sturgeon habitat by building a chute to
2 connect active river channels with the old river area.

3 NPPD had problems with this proposal. Implementing the proposal would reduce CNS-1's
4 mixing zone, which now extends 5,000 feet south of CNS-1 along the Nebraska side of the
5 Missouri River, to less than half, less than 2,500 feet. Reducing the mixing zone would reduce
6 CNS-1's capacity to generate electricity, particularly during summer. The proposal also posed
7 other negative safety and environmental concerns for CNS-1. As an alternative, NPPD then
8 offered to contribute funds toward other new or existing projects on the Missouri River. The
9 USFWS rejected this funding alternative in favor of increasing the amount of land for habitat
10 development.

11 To meet the goal of improving habitat for pallid sturgeon, NPPD offered a conservation
12 easement of about 230 acres (93 ha) of land that it owns on the Missouri side of the Missouri
13 River, opposite CNS-1, for the purposes of habitat development. The USFWS indicated interest
14 in the proposal, and asked NPPD to also acquire an adjacent property of about 150 acres
15 (51 ha) so that the entire bend in the river could be developed into better habitat. When the
16 property owner refused to sell the land, NPPD offered a revised, final proposal to participate in
17 and promote habitat development along the Missouri River. It proposed to revisit the USFWS's
18 and NGPC's interest in a suitable conservation easement and Memorandum of Understanding
19 to enable habitat development on NPPD's approximately 230-acre (93-ha) parcel on the
20 Missouri side of the river. Further, because NPPD recognized that this parcel alone would not
21 meet the USFWS's and NGPC's conservation habitat development goals, NPPD indicated that
22 its willingness to make an additional payment of \$250,000 to be applied toward another
23 conservation habitat development project on the Missouri River at the direction of the USFWS
24 and NGPC. At the time of writing this biological assessment (BA), the involved parties are
25 discussing details of the conservation agreement.

26 Plans for and construction of a chute on the parcel may also involve the owners of the
27 transmission lines and supports that cross the property. NPPD does not own these lines,
28 although CNS-1 provides power to them.

29 The probability that CNS-1 will entrain, impinge, or otherwise affect pallid sturgeon eggs or
30 larvae is low. Hazleton (1979) collected adult and juvenile fish from seven locations in the
31 vicinity of CNS-1 from 1970 through 1978 and reported no pallid sturgeon captured. They also
32 conducted impingement sampling from 1974 through 1978 and reported no pallid sturgeon
33 impinged. Based on 374 trawl hauls that captured over 21,735 fish in a 1998 through 2000
34 survey, Hrabik et al. (2007) concluded pallid sturgeon may reproduce in the lower Missouri
35 River to the upper and lower Mississippi River, although no fish may survive to recruitment.
36 NPPD's involvement in the conservation agreement, however, could have a positive impact on
37 the pallid sturgeon population.

38 **D.2.2 CONCLUSION**

39 Based on this review, the staff concludes that the continued operation of CNS-1 for an
40 additional 20 years may affect, but is not likely to adversely affect, the pallid sturgeon.

1 D.2.3 REFERENCES

- 2 Dryer, M.P., and A.J. Sandvol. 1993. "Recovery plan for the pallid sturgeon *Scaphirhynchus*
3 *albus*." U.S. Fish and Wildlife Service, Bismarck, North Dakota. 55 pp.
- 4 Gerrity, P.C., and C. Guy. 2006. *Juvenile pallid sturgeon are piscivorous: A call for conserving*
5 *native cyprinids*. Transactions of the American Fisheries Society 135:604-609.
- 6 Hazleton Environmental Sciences Corporation (Hazleton). 1979. Report to Nebraska Public
7 Power District, Columbus, Nebraska: The Evaluation of Thermal Effects in the Missouri River
8 Near Cooper Nuclear Station (Operational Phase), January–December 1978, Project No. 8903.
9 Hazleton Environmental Sciences Corporation, Lincoln, Nebraska. ADAMS Accession No.
10 ML092450614.
- 11 Hurleya, K.L., R.J. Sheehan, R.C. Heidinger, P.S. Wills, and B.Clevenstine. 2004. *Habitat Use*
12 *by Middle Mississippi River Pallid Sturgeon*. Transactions of the American Fisheries Society
13 133:1033–1041.
- 14 Hrabik, R. A., Herzog, D. P., Ostendorf, D. E., and Petersen, M. D. 2007. *Larvae provide first*
15 *evidence of successful reproduction by pallid sturgeon, Scaphirhynchus albus, in the Mississippi*
16 *River*. Journal of Applied Ichthyology 23(4):436-443.
- 17 Kynard, B., E. Henyey, and M. Horgan. 2002. *Ontogenetic behavior, migration, and social*
18 *behavior of pallid sturgeon, Scaphirhynchus albus, and shovelnose sturgeon, S. platyrhynchus,*
19 *with notes on the adaptive significance of body color*. Environmental Biology of Fishes 63:389–
20 403.
- 21 Missouri Department of Conservation (MDC). 2009. "The Sturgeon of Missouri: Missouri's
22 Living Dinosaurs." Updated 2009. Available URL: [athttp://mdc.mo.gov/fish/sport/sturgeon/info/](http://mdc.mo.gov/fish/sport/sturgeon/info/)
23 (accessed on May 5, 2009).
- 24 Nebraska Public Power District (NPPD). 2006. Proposal for Information Collection, Cooper
25 Nuclear Station. January 2006. ADAMS Accession No. ML092510103.
- 26 Nebraska Public Power District (NPPD). 2008a. Letter from Joe Citta, NPPD to Robert Harms,
27 USFWS Re: Cooper Nuclear Station License Renewal—Habitat Development Proposal.
28 September 26, 2008. ADAMS Accession No. ML092520156.
- 29 Nebraska Public Power District (NPPD). 2008b. *Nebraska Public Power District, Cooper*
30 *Nuclear Station, License Renewal Application*. September 24, 2008. ADAMS Accession No.
31 ML083030227.
- 32 U.S. Fish and Wildlife Service (USFWS). 2007. Species Profile, Pallid sturgeon,
33 *Scaphirhynchus albus*. Available URL: <http://www.fws.gov/moriver/PSPROFILE.htm> (accessed
34 on March 16, 2007).
- 35 U.S. Geological Service (USGS). 2007. Sturgeon Research Update: Confirmed Pallid Sturgeon
36 Spawning in the Missouri River in 2007. USGS Fact Sheet 2007–3053, July 2007.
- 37 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement*
38 *for License Renewal of Nuclear Power Plants*. NUREG-1437, Volumes 1 and 2,
39 Washington, D.C.
- 40 U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement*
41 *for License Renewal of Nuclear Plants*. Main Report. NUREG-1437, Volume 1, Addendum 1,
42 Washington, D.C.

Appendix D.2

- 1 U.S. Nuclear Regulatory Commission (NRC). 2009. Letter from D. Pelton to Mr. John Cochnar,
- 2 U.S. Fish and Wildlife Service, Grand Island, Nebraska, Re: Request for List of Protected
- 3 Species Dryer, M.P., and A.J. Sandvol. 1993. "Recovery plan for the pallid sturgeon
- 4 *Scaphirhynchus albus*." U.S. Fish and Wildlife Service, Bismarck, North Dakota. 55 pp.
- 5 Wildhaber, M.L., DeLonay, A.J., Papoulias, D.M., Galat, D.L., Jacobson, R.B., Simpkins, D.G.,
- 6 Braaten, P.J., Korschgen, C.E., and Mac, M.J. 2007. *A conceptual life-history model for pallid*
- 7 *and shovelnose sturgeon*. U.S. Geological Survey Circular 1315. U.S. Geological Survey,
- 8 Reston, Virginia. 18 pp.

1
2

**APPENDIX E.
CHRONOLOGY OF ENVIRONMENTAL REVIEW**

1 **E. CHRONOLOGY OF ENVIRONMENTAL REVIEW**
2 **CORRESPONDENCE**

3 This appendix contains a chronological listing of correspondence between the U.S. Nuclear
4 Regulatory Commission (NRC) and external parties as part of its environmental review for
5 Cooper Nuclear Station, Unit 1 (CNS-1). All documents, with the exception of those containing
6 proprietary information, are available electronically from the NRC's Public Electronic Reading
7 Room found on the Internet at the following Web address: <http://www.nrc.gov/reading-rm.html>.

8 From this site, the public can gain access to the NRC's Agencywide Document Access and
9 Management System (ADAMS), which provides text and image files of NRC's public documents
10 in ADAMS. The ADAMS accession number for each document is included below.

11 **E.1. Environmental Review Correspondence**

12 September 24, 2008 Letter from Nebraska Public Power District (NPPD) forwarding the
13 application for renewal of the operating license for CNS-1, requesting an
14 extension of the operating license for an additional 20 years. (ADAMS
15 Accession No. ML0803030227)

16 September 24, 2008 NPPD's environmental report (ER) submitted as Appendix E for the
17 application for renewal of the operating license for CNS- 1, requesting an
18 extension of the operating license for an additional 20 years. (ADAMS
19 Accession No. ML083030246)

20 November 10, 2008 Letter to NPPD, "Receipt and Availability of the License Renewal
21 Application for the Cooper Nuclear Station Unit 1." (ADAMS Accession
22 No. ML082661007)

23 November 17, 2008 *Federal Register* Notice of Receipt and Availability of Application for
24 Renewal of Cooper Nuclear Station Facility Operating License No. DPR-
25 46 for an Additional 20-Year Period (73 FR 67896). (ADAMS Accession
26 No. ML0826608920)

27 December 19, 2008 Letter to NPPD, "Determination of Acceptability and Sufficiency for
28 Docketing and Opportunity for a Hearing Regarding the Application from
29 Nebraska Public Power District, for Renewal of the Operating License for
30 the Cooper Nuclear Station (TAC Nos. MD9763 and Md9737)." (ADAMS
31 Accession No. ML083330066)

32 December 19, 2008 *Federal Register* Notice of Acceptance for Docketing of the Application
33 and Notice of Opportunity for Hearing Regarding Renewal of Facility
34 Operating License No. DPR-46 for an Additional 20-Year Period
35 Nebraska Public Power District Cooper Nuclear Station (73 FR 5877).
36 (ADAMS Accession No. ML083540747)

37 January 15, 2009 *Federal Register* Notice of Intent to Prepare an Environmental Impact
38 Statement and Conduct Scoping Process for Licensee Renewal for
39 Cooper Nuclear Station, Unit 1 (73 FR 13923). (ADAMS Accession No.
40 ML090150526)

Appendix E

- 1 January 16, 2009 Letter to Michael Smith, Nebraska Historic Preservation Society,
2 regarding CNS-1, license renewal application” (ADAMS Accession No.
3 ML090080197)
- 4 January 21, 2009 Letter to NPPD transmitting notice of intent to prepare an environmental
5 impact statement and conduct scoping process for license renewal for
6 CNS-1.” (ADAMS Accession No. ML083640401)
- 7 January 26, 2009 Letter to Sherry Black, Auburn Memorial Library, regarding maintenance
8 of reference materials at the Auburn Memorial Library related to the
9 review of the Cooper Nuclear Station license renewal application.
10 (ADAMS Accession No. ML090230582)
- 11 January 26, 2009 Letter to Don Klima, Director, Advisory Council on Historic Preservation,
12 regarding CNS-1, license renewal application. (ADAMS Accession No.
13 ML090080683)
- 14 January 27, 2009 Letter to Mr. Joseph Cothorn, USEPA Region 7, regarding CNS-1, license
15 renewal application. (ADAMS Accession No. ML090230446)
- 16 January 28, 2009 Letter to Julia Schmitt, Department of Health and Human Services,
17 regarding CNS-1, license renewal application. (ADAMS Accession No.
18 ML090260380)
- 19 January 29, 2009 Notice of forthcoming meeting to discuss the safety review process and
20 environmental scoping process for CNS-1, license renewal application
21 review. (ADAMS Accession No. ML090160280)
- 22 January 29, 2009 Letter to Mark Miles, State Historic Preservation Officer, Department of
23 Natural Resources, MO, regarding CNS-1, license renewal application.
24 (ADAMS Accession No. ML090210750)
- 25 January 29, 2009 Letter to John Cochran, U.S. Fish and Wildlife Service, requesting a list of
26 protected species for the CNS-1, license renewal review. (ADAMS
27 Accession No. ML0901507)
- 28 February 2, 2009 Letter from the Nebraska State Historic Preservation Office requesting a
29 map of the boundaries of the environmental review of the license renewal
30 application for CNS-1. (ADAMS Accession No. ML090650061)
- 31 February 4, 2009 Letter to Adrian Pushetonequa, Sac and Fox Tribe of the Mississippi in
32 Iowa, inviting participation in scoping process related to NRC’s
33 environmental review of the license renewal application for CNS-1.
34 (ADAMS Accession No. ML090080045)
- 35 February 4, 2009 Letter to Ann Bleed, Nebraska Department of Natural Resources,
36 requesting a list of protected species for the CNS-1, license renewal
37 review. (ADAMS Accession No. ML090260380)
- 38 February 25, 2009 Agenda and slides for Cooper Nuclear Station scoping and process public
39 meeting, February 25, 2009. (ADAMS Accession No. ML090750686)

1 February 25, 2009 Transcript of Cooper Nuclear Station license renewal public meeting –
2 afternoon session, February 25, 2009. (ADAMS Accession No.
3 ML090840063)

4 February 25, 2009 Transcript of Cooper Nuclear Station license renewal public meeting –
5 evening session, February 25, 2009. (ADAMS Accession No.
6 ML090840062)

7 February 25, 2009 Comments from the Richardson County, Nebraska, Emergency
8 Management Agency regarding the license renewal of CNS-1. (ADAMS
9 Accession No. ML090720066)

10 February 27, 2009 Letter from the City of Rock Port regarding the license renewal of CNS-1.
11 (ADAMS Accession No. ML090720068)

12 March 9, 2009 Letter from Nebraska Department of Natural Resources regarding the
13 request for a list of protected species for license renewal of CNS-1.
14 (ADAMS Accession No. ML090650061)

15 March 10, 2009 Letter from the Pawnee City Economic Development Corporation
16 regarding the license renewal of CNS-1. (ADAMS Accession No.
17 ML090720067)

18 April 3, 2009 Letter to NPPD regarding the review schedule for the application for the
19 renewal of the operating license for CNS-1. (ADAMS Accession No.
20 ML090220584)

21 April 3, 2008 Letter to Stewart B. Minahan, NPPD, regarding environmental site audit
22 needs for CNS-1 license renewal application from NPPD. (ADAMS
23 Accession No. ML090830248)

24 April 9, 2009 Letter to NPPD, “Regulatory Audit Plan for Aging Management Program
25 Regarding Cooper Nuclear Station Unit 1 License Renewal Application.”
26 (ADAMS Accession No. ML090930256)

27 April 9, 2009 Letter to NPPD, “Request for Additional Information Regarding Balance of
28 Plant Issues for Cooper Nuclear Station Unit 1” (ADAMS Accession No.
29 ML091060150)

30 April 14, 2009 Summary of public meeting for Cooper Nuclear Station Scoping and
31 Process Public Meeting, February 25, 2009 (ADAMS Accession No.
32 ML090910308)

33 April 16, 2009 Email comments from Environmental Protection Agency (EPA) Region 7,
34 regarding the license renewal of CNS-1. (ADAMS Accession
35 No. ML091070269)

36 April 30, 2009 Summary of site audit related to the review of the license renewal
37 application for CNS-1 (TAC NOS. MD9763 and MD9737) (ADAMS
38 Accession No. ML090970414)

Appendix E

1 May 1, 2009 Letter to NPPD, "Request for Additional Information for the Review of the
2 Cooper Nuclear Station License Renewal Application" (TAC No. MD9763
3 and MD9737) (ADAMS Accession No. ML091190597)

4 May 1, 2009 Letter from NPPD to Fish and Wildlife Service regarding the license
5 renewal of the Cooper Nuclear Station. (ADAMS Accession No.
6 ML091830056)

7 May 5, 2009 Email from Fish and Wildlife Service to R. Bulavinez, NRC. (ADAMS
8 Accession No. ML091400116)

9 May 8, 2009 Email and attachment from Nebraska Game and Parks Commission.
10 (ADAMS Accession No. ML091400110)

11 May 18, 2009 Letter from NPPD, "Response to Request for Additional Information for
12 License Renewal Application, Cooper Nuclear Station, Docket No. 50-
13 298, DPR-46. (ADAMS Accession No. ML091600712)

14 May 29, 2009 Summary report of environmental scoping for the license renewal
15 application for CNS-1 (TAC NOS. MD9763 and MD9737) (ADAMS
16 Accession No. ML091200017)

17 June 8, 2009 Letter to NPPD, "Request for Additional Information for the Review of the
18 Cooper Nuclear Station License Renewal application (TAC. No. MD9763
19 and MD9737) (ADAMS Accession No. ML091530316)

20 June 8, 2009 Letter from Fish and Wildlife Service to NPPD regarding the license
21 renewal of Cooper Nuclear Station (ADAMS Accession No.
22 ML091830055)

23 July 1, 2009 Letter from NPPD, "Response to Request for Additional Information for
24 License Renewal Application – Severe Accident Mitigation Alternatives,
25 Cooper Nuclear Station, Docket No. 50-298, DPR-46. (ADAMS Accession
26 No. ML091880319)

27 August 26, 2009 Letter from Fish and Wildlife Service to NPPD concerning the license
28 renewal of the Cooper Nuclear Station.

29 December 17. 2009 Letter from NPPD," SAMA Meteorological Anomaly Related to the Cooper
30 Nuclear Station License Renewal Application," (ADAMS Accession No.
31 ML093490997)

1
2
3
4
5

**APPENDIX F.
U.S. NUCLEAR REGULATORY COMMISSION STAFF
EVALUATION OF SEVERE ACCIDENT MITIGATION
ALTERNATIVES FOR COOPER NUCLEAR STATION, UNIT 1 IN
SUPPORT OF LICENSE RENEWAL APPLICATION REVIEW**

1 **F. U.S. NUCLEAR REGULATORY COMMISSION STAFF EVALUATION**
2 **OF SEVERE ACCIDENT MITIGATION ALTERNATIVES FOR COOPER**
3 **NUCLEAR STATION IN SUPPORT OF LICENSE RENEWAL**
4 **APPLICATION REVIEW**

5 **NOTE:** In December 7, 2009, CNS-1 identified an error in their original SAMA analysis resulting
6 from the wind data used in their code. NPPD discovered a problem with the process they used
7 to numerically average the site-specific meteorological data. NPPD performed a sensitivity
8 analysis of the population dose risk and offsite economic cost risk using corrected
9 meteorological data, and found that the population dose and offsite economic cost values for
10 each of the release categories would be slightly less than reported in the ER, and that the
11 conclusions of the SAMA remain valid (NPPD, 2009c). NRC staff reviewed the revised data as
12 part of the analysis below.

13 **F.1. Introduction**

14 Nebraska Public Power District (NPPD) submitted an assessment of severe accident mitigation
15 alternatives (SAMAs) for the Cooper Nuclear Station, Unit 1 (CNS-1) as part of the
16 environmental report (ER) (NPPD, 2008). This assessment was based on the most recent CNS-
17 1 probabilistic safety assessment (PSA) available at that time, a plant-specific offsite
18 consequence analysis performed using the MELCOR Accident Consequence Code System 2
19 (MACCS2) computer code (NRC, 1998a), and insights from the CNS-1 individual plant
20 examination (IPE) (NPPD, 1993) and individual plant examination of external events (IPEEE)
21 (NPPD, 1996). In identifying and evaluating potential SAMAs, NPPD considered SAMA
22 candidates who addressed the major contributors to core damage frequency (CDF) and large
23 early release frequency (LERF) at CNS-1, as well as, SAMA candidates for other operating
24 plants which have submitted license renewal applications. NPPD identified 244 potential SAMA
25 candidates. This list was reduced to 80 unique SAMA candidates by eliminating SAMAs that are
26 not applicable at CNS-1 due to design differences, have already been implemented at CNS-1,
27 or are similar in nature and could be combined with another SAMA candidate. NPPD assessed
28 the costs and benefits associated with each of the potential SAMAs, and concluded in the ER
29 that several of the candidate SAMAs evaluated are potentially cost-beneficial.

30 Based on a review of the SAMA assessment, the U.S. Nuclear Regulatory Commission (NRC)
31 issued a request for additional information (RAI) to NPPD by letter dated June 8, 2009
32 (NRC, 2009). Key questions concerned: the impact of unresolved Boiling Water Reactor
33 Owner's Group (BWROG) PSA peer review findings on the SAMA analysis results; the process
34 used to develop and group source terms into containment event tree (CET) end states; the
35 rationale for identifying and screening SAMAs, and the costs and benefits of several specific
36 candidate SAMAs and low cost alternatives. NPPD submitted additional information by letter
37 dated July 1, 2009 (NPPD, 2009a) and email dated August 10, 2009 (NPPD, 2009b). In
38 response to the RAIs, NPPD provided information regarding the findings of the BWROG peer
39 review; a discussion and example of the process for assigning severe accident source terms to
40 CET sequences; additional rationale on the process used to identify and screen SAMAs, and
41 additional information regarding several specific SAMAs. NPPD's responses addressed the
42 NRC staff's concerns.

43 An assessment of SAMAs for CNS-1 is presented below.

1 **F.2. Estimate of Risk for Cooper Nuclear Station**

2 NPPD's estimates of offsite risk at CNS-1 are summarized in Section F.2.1. The summary is
3 followed by the NRC staff's review of NPPD's risk estimates in Section F.2.2.

4 **F.2.1. Nebraska Public Power District's Risk Estimates**

5 Two distinct analyses are combined to form the basis for the risk estimates used in the SAMA
6 analysis: (1) the CNS-1 Level 1 and 2 PSA model, which is an updated version of the IPE
7 (NPPD, 1993), and (2) a supplemental analysis of offsite consequences and economic impacts
8 (essentially a Level 3 PSA model) developed specifically for the SAMA analysis. The SAMA
9 analysis is based on the most recent CNS-1 Level 1 and Level 2 PSA models available at the
10 time of the ER, referred to as the CNS-1 2007TM model (2007TM, Rev. 1). The scope of this
11 CNS-1 PSA does not include external events.

12 The CNS-1 CDF is approximately 9.3×10^{-6} per year for internal events as determined from
13 quantification of the Level 1 PSA model. When determined from the sum of the CET sequences,
14 or the Level 2 PSA model, the release frequency is approximately 1.2×10^{-5} per year. The latter
15 value was used as the baseline CDF in the SAMA evaluations (NPPD, 2009a). The CDF is
16 based on the risk assessment for internally-initiated events, which includes internal flooding.
17 NPPD did not include the contribution from external events within the CNS-1 risk estimates,
18 however, it did account for the potential risk reduction benefits associated with external events
19 by multiplying the estimated benefits for internal events by a factor of three. For some fire-
20 related SAMAs, NPPD separately estimated the risk reduction benefits using the fire risk model.
21 This is discussed further in Sections F.2.2 and F.6.2.

22 The breakdown of CDF by initiating event is provided in Table F-1. As shown in this table,
23 events initiated by transients, loss of DC power, loss of coolant accidents (LOCA), and loss of
24 feedwater are the dominant contributors to the CDF. Station blackout (SBO) and anticipated
25 transient without scram (ATWS) sequences may occur following multiple initiators and so their
26 total contributions to CDF were reported separately. Each contributes less than 3 percent to the
27 total internal events CDF.

28 The Level 2 CNS-1 PSA model that forms the basis for the SAMA evaluation represents an
29 updated version of the original IPE Level 2 model. The current Level 2 model utilizes a single
30 CET containing both phenomenological and systemic events. The Level 1 core damage
31 sequences are binned into one of 15 Plant Damage State (PDS) bins which provide the
32 interface between the Level 1 analysis and Level 2 CET analysis. The CET probabilistically
33 evaluates the progression of the damaged core with respect to radiation release into the
34 environment. CET nodes are evaluated using supporting fault trees and logic rules. The CET
35 end states then are examined for considerations of timing and magnitude of release and
36 assigned to release categories.

1 **Table F-1. Cooper Nuclear Station Core Damage Frequency for Internal Events**

Initiating Event	CDF (per year)	% Contribution to CDF
Transients	3.0×10^{-6}	32
Loss of DC Power	2.1×10^{-6}	22
LOCA	1.4×10^{-6}	15
Loss of Feedwater	1.0×10^{-6}	11
Loss of Offsite Power	6.5×10^{-7}	7
Loss of Service Water (SW)	6.0×10^{-7}	7
Loss of AC Buses	2.6×10^{-7}	3
Internal Flood	2.6×10^{-7}	3
Interfacing System LOCA	5.1×10^{-8}	<1
Total CDF (Internal Events)	9.3×10^{-6}	100

2 The result of the Level 2 PSA is a set of 12 release categories, also referred to as source term
3 categories, with their respective frequency and release characteristics. The release categories
4 and their characteristics are provided in Table E.1-10 of the ER (NPPD, 2008). The categories
5 were defined based on the timing, duration, and magnitude of the release and whether or not
6 the containment remains intact or fails. The frequency of each release category was obtained by
7 summing the frequency of the individual accident progression CET endpoints assigned to each
8 release category. Source terms were developed for each of the 12 release categories using the
9 results of Modular Accident Analysis Program (MAAP Version 4.0.5) computer code
10 calculations.

11 The offsite consequences and economic impact analyses use the MACCS2 code to determine
12 the offsite risk impacts on the surrounding environment and general public. Inputs for these
13 analyses include plant-specific and site-specific input values for core radionuclide inventory,
14 source term and release characteristics, site meteorological data, projected population
15 distribution (within a 50-mile (80-km) radius) for the year 2034, emergency response evacuation
16 modeling, and economic data. The magnitude of the onsite impacts (in terms of clean-up and
17 decontamination costs and occupational dose) is based on information provided in
18 NUREG/BR-0184 (NRC, 1997a).

19 In the ER, NPPD estimated the dose to the population within 50 miles (80 km) of the CNS-1 site
20 to be approximately 0.021 person-Sievert (Sv) (2.1 person-roentgen equivalent man (rem)) per
21 year. The breakdown of the total population dose by containment release mode is summarized
22 in Table F-2. Containment failures within the early time frame (less than 3.7 hours following
23 event initiation) dominate the population dose risk at CNS-1, with failures in the intermediate
24 time frame (3.7 to 24 hours following event initiation) contributing most of the remaining
25 population dose risk.

1 **Table F-2. Breakdown of Population Dose by Containment Release Mode**

Containment Release Mode	Population Dose (Person-Rem ¹ Per Year)	% Contribution
Early Containment Failure	1.67	78
Intermediate Containment Failure	0.47	22
Late Containment Failure	<0.1	<1
Intact Containment	Negligible	negligible
Total	2.14	100

¹One person-rem = 0.01 person-Sv

2 **F.2.2. Review of Nebraska Public Power District's Risk Estimates**

3 NPPD's determination of offsite risk at CNS-1 is based on the following three major elements of
4 analysis:

- 5 • The Level 1 and 2 risk models that form the basis for the 1993 IPE
6 submittal (NPPD, 1993) and the external event analyses of the 1996 IPEEE
7 submittal (NPPD, 1996)
- 8 • The major modifications to the IPE model that have been incorporated in
9 the CNS-1 PSA
- 10 • The MACCS2 analyses performed to translate fission product source terms
11 and release frequencies from the Level 2 PSA model into offsite
12 consequence measures.

13 Each of these analyses was reviewed to determine the acceptability of the NPPD risk estimates
14 for the SAMA analysis, as summarized below.

15 The NRC staff's review of the CNS-1 IPE is described in an NRC report dated February 14,
16 1996 (NRC, 1996). Based on a review of the IPE submittal and responses to RAIs, the NRC
17 staff concluded that the IPE submittal met the intent of GL 88-20 (NRC, 1988); that is, the
18 licensee's IPE process is capable of identifying the most likely severe accidents and severe
19 accident vulnerabilities. Although no vulnerabilities were identified in the IPE, several
20 improvements to the plant or procedures were identified. These improvements have been either
21 implemented at the site or addressed in the SAMA evaluation process (NPPD, 2008). These
22 improvements are discussed in Section F.3.2.

23 There have been five revisions to the IPE model since the 1993 IPE submittal. A listing of the
24 major changes in each revision of the PSA was provided by NPPD in the ER and is summarized
25 in Table F-3. A comparison of the internal events CDF between the 1993 IPE and the 2007TM
26 Rev. 1 PSA model used for the SAMA evaluation indicates a decrease of approximately
27 88 percent (from 8.0×10^{-5} per year to 9.3×10^{-6} per year). A description of those changes that
28 resulted in the greatest impact on the internal event CDF is provided in Section E.1.4 of the ER
29 (NPPD, 2008). The decrease is mainly attributed to plant and modeling improvements made
30 between the IPE and the 1996b model update.

1 **Table F-3. Cooper Nuclear Station Probabilistic Safety Assessment Historical Summary**

PSA Version	Summary of Changes from Prior Model	CDF (per year)
1993	IPE Submittal (excluding internal flooding)	8.0×10^{-5}
1996b	<ul style="list-style-type: none"> - Revised the human reliability analysis to incorporate revisions to emergency operating procedures - Added credit for newly installed torus hard pipe vent - Corrected conservative thermal hydraulic analysis of safety relief valve (SRV) flow - Improved loss of offsite power model 	1.3×10^{-5}
2001a	<ul style="list-style-type: none"> - Incorporated minor improvements stemming from the 9/97 peer review - Updated component failure and unavailability database - Developed LERF model 	1.3×10^{-5}
2005TM	Updated initiating event frequencies to reflect information in NUREG/CR-6890	1.1×10^{-5}
2006TM	Updated model to support the Mitigating System Performance Index (MSPI) and maintenance rule update	1.4×10^{-5}
2007TM (Revision 1)	<ul style="list-style-type: none"> - Added internal flooding to the Level 1 model - Incorporated operator action dependencies - Expanded the treatment of common cause failures - Developed a more detailed CET and new Level 2 fault trees - Added new Level 1 system models including severe accident mitigation strategies such as firewater injection - Updated PSA model data - Developed initiator fault trees to calculate some initiating event frequencies, such as loss of turbine equipment cooling (TEC) 	9.3×10^{-6}

2
3 The CDF value from the 1993 CNS-1 IPE (8.9×10^{-5} per year) is near the upper end of the
4 range of the CDF values reported in the IPEs for other boiling water reactor (BWR) 3/4 plants.
5 Figure 11.2 of NUREG-1560 shows that the IPE-based total internal events CDF for BWR 3/4
6 plants, ranges from about 9×10^{-8} per year to 1×10^{-4} per year, with an average CDF for the
7 group of 2×10^{-5} per year (NRC, 1997b). It is recognized that other plants have updated the
8 values for CDF subsequent to the IPE submittals to reflect modeling and hardware changes.
9 The internal events CDF result for CNS-1 used for the SAMA analysis (9.3×10^{-6} per year) is
10 comparable to other plants of similar vintage and characteristics.

11 The NRC staff considered the peer reviews performed for the CNS-1 PSA and the potential
12 impact of the review findings on the SAMA evaluation. In the ER (NPPD, 2008), NPPD
13 described the BWROG peer review of the 2007TM Revision 1 model conducted in May 2008.
14 The peer review was performed using the NEI 05-04 process (NEI, 2007), the ASME PRA
15 Standard (ASME, 2007), and NRC Regulatory Guide 1.200, Rev. 1 (NRC, 2007). The NRC staff
16 asked NPPD to provide a summary of each of the peer review findings and an assessment of
17 the impact of resolving each finding on the SAMA identification and analysis results
18 (NRC, 2009). In response to this request, NPPD provided a table summarizing the peer review
19 findings in relation to the applicable supporting requirements (SR) and an assessment of the
20 impact of the resolution of the findings on the PSA results (NPPD, 2009a). The peer review
21 identified 22 findings against the SR, including 10 classified as not met. The 10 not-met findings
22 included documentation of analysis bases, PSA configuration control, identification of internal
23 flooding mechanisms, and evaluation of human error dependencies. NPPD's review of the 22
24 peer review findings resulted in no changes to the PSA model and no impacts on the SAMA
25 identification and analysis results. The NRC staff considers NPPD's rationale reasonable and

Appendix F

1 that the final resolution of the peer review findings is not likely to impact the results of the SAMA
2 analysis.

3 Because the CNS-1 internal events PSA model has been peer-reviewed and the peer review
4 findings were all addressed, and NPPD has satisfactorily addressed NRC staff questions
5 regarding the PSA, the NRC staff concludes that the internal events Level 1 PSA model is of
6 sufficient quality to support the SAMA evaluation.

7 As indicated above, the current CNS-1 PSA does not include external events. In the absence of
8 such an analysis, NPPD used the CNS-1 IPEEE to identify the highest risk accident sequences
9 and the potential means of reducing the risk posed by those sequences, as discussed below
10 and in Section F.3.2.

11 The CNS-1 IPEEE was submitted in October 1996 (NPPD, 1996), in response to Supplement 4
12 of Generic Letter 88-20 (NRC, 1991). These submittals included a seismic margins analysis, an
13 internal fire PSA, and evaluations of high winds, external flooding, and other hazards. While no
14 fundamental weaknesses or vulnerabilities to severe accident risk in regard to the external
15 events were identified, several opportunities for risk reduction were identified as discussed
16 below. In a letter dated April 27, 2001, the NRC staff concluded that the submittal met the intent
17 of Supplement 4 to Generic Letter 88-20, and that the licensee's IPEEE process is capable of
18 identifying the most likely severe accidents and severe accident vulnerabilities (NRC, 2001).

19 The CNS-1 IPEEE used a focused scope Electric Power Research Institute (EPRI) seismic
20 margins analysis which was completed in conjunction with the Seismic Qualification User's
21 Group (SQUG) program (SQUG, 1992). This method is qualitative and does not provide
22 numerical estimates of the CDF contributions from seismic initiators (EPRI, 1991). For this
23 assessment, the review level earthquake (RLE) value for CNS-1 was specified by NRC to be
24 0.3g. Plant walkdowns were performed in which components and structures were screened for
25 the RLE based on the EPRI guidelines, and specific high confidence low probability of failure
26 (HCLPF) capacities were calculated for components and structures that did not screen out. All
27 structures and all but six components were screened out, of which five were Unresolved Safety
28 Issue (USI) A-46 program outliers. Several improvements were identified to address the six
29 unscreened components and to reduce seismic risk. While some of these improvements have
30 been implemented, all were addressed as SAMA candidates, as discussed in Section F.3.2.
31 The NRC review and closure of USI A-46 for CNS-1 is documented in a letter dated
32 September 30, 1999 (NRC, 1999).

33 To provide additional insight into the appropriate seismic CDF to use for the SAMA evaluation,
34 the NRC staff developed an independent estimate of the seismic CDF for CNS-1 using the
35 simplified-hybrid approximation method described in a paper by Robert P. Kennedy, entitled
36 "Overview of Methods for Seismic PRA and Margin Analysis Including Recent Innovations"
37 (Kennedy, 1999) and using updated 2008 seismic hazard curve data from the U.S. Geologic
38 Survey (USGS, 2008). The NRC staff's independent calculations indicate the seismic CDF for
39 CNS-1 to be approximately 6×10^{-6} per year depending on the seismic hazard curve and plant
40 fragility assumptions. Since NPPD did not provide a seismic CDF contribution in the ER, the
41 NRC staff used this result to assess the appropriateness of the external event multiplier used in
42 the SAMA evaluation.

43 The CNS-1 IPEEE fire analysis employed a combination of PSA with the EPRI's fire-induced
44 vulnerability evaluation (FIVE) methodology (EPRI, 1993). Fire compartments were initially
45 qualitatively screened out if all compartment boundaries screened out according to Fire

1 Compartment Interaction Analysis (FCIA) criteria and if the compartment did not contain
2 Appendix R equipment. Quantitative screening was then performed using fire frequencies based
3 on the FIVE methodology and the assumption that fire failed all of the equipment in the
4 compartment. The sequence was then quantified using the internal events PSA model. If the
5 CDF was greater than 1×10^{-6} per year the compartment was subjected to more detailed
6 analysis. In this analysis, the FIVE fire screening methodology was used in the fire modeling
7 with one exception. The exception involved the partitioning of oil spill fires into large and small
8 spills based on a recommendation in the "EPRI Fire PRA Implementation Guide" (EPRI, 1994).
9 The total fire CDF, found by summing the values for all compartments, is 1.9×10^{-5} per year.
10 The fire compartments having a fire CDF greater than 1×10^{-7} per year and their contributions to
11 the fire CDF are listed in Table F-4.

12 In the ER, NPPD identifies a number of conservatisms in the fire analysis, including:

- 13 • The NRC fire events database indicates a trend toward lower frequency
14 and less severe fires since the IPEEE fire analysis was performed.
- 15 • Because of little industry experience with crew actions following a fire, crew
16 actions were conservatively characterized in the fire model.
- 17 • A fire that damaged a cable was assumed to always induce a conductor
18 failure.
- 19 • Manual fire suppression was only credited in the control room and non-
20 essential switchgear rooms.
- 21 • Hardware repair activities were not credited.

22 The NRC staff inquired about additional measures that NPPD had already taken to reduce fire
23 risk since the IPEEE (NRC, 2009). NPPD provided a description of the measures taken in the
24 four dominant fire compartments (3A-switchgear room 1F, 3B-switchgear room 1G, 10B-control
25 room and security access control corridor, and 20A-SW pump room). These measures
26 consisted primarily of improvements to monitoring and controlling the quantity of combustible
27 materials and pre-staging of outage materials.

1 **Table F-4. Cooper Nuclear Station Fire Compartments and Their Contributions to Fire**
 2 **Core Damage Frequency**

Fire Compartment	Fire Compartment Description	CDF (per year)
10B	Control Room and Security Alarm Station (SAS) Corridor	3.7×10^{-6}
3B	Switchgear Room 1G	2.7×10^{-6}
20A	SW Pump Room	1.7×10^{-6}
3A	Switchgear Room 1F	1.1×10^{-6}
8-1	Condenser Pit Area	9.7×10^{-7}
9A	Cable Spreading Room	8.2×10^{-7}
2A/2C	Reactor Building El. 903'-6" – Control Rod Drive (CRD) Units – North/South	8.2×10^{-7}
8G	DC Switchgear Room 1B	7.9×10^{-7}
8B	Reactor Protection System (RPS) Room 1B	7.3×10^{-7}
8F	Battery Room 1B	6.7×10^{-7}
14A	Emergency Diesel Generator (EDG) Room 1A	6.1×10^{-7}
14B	EDG Room 1B	6.1×10^{-7}
7A	Residual Heat Removal Service Water (RHRSW) Booster and Service Air Compressor	5.6×10^{-7}
4A/4C/4D	Reactor Building El. 958'-3" – Fuel Pool Heat Exchanger/Lube Oil	5.4×10^{-7}
8A	Auxiliary Relay Room	3.7×10^{-7}
9B	Cable Expansion Room	3.4×10^{-7}
8H	DC Switchgear Room 1A	3.4×10^{-7}
13B	Non-Critical Switchgear Room	3.3×10^{-7}
3C/3D/3E	Reactor Building El. 932'-6" - REC	2.7×10^{-7}
8E	Battery Room 1A	1.8×10^{-7}
1F	Suppression Pool Area	1.7×10^{-7}
12D	Turbine Building Floor – North 903'-6" El.	1.4×10^{-7}
1B/1G	Core Spray (CS) and CRD Room	1.0×10^{-7}
	Other Compartments	6.4×10^{-7}
Total Fire CDF		1.9×10^{-5}

3 Based on the conservatisms in the analysis and the actions taken by NPPD to reduce fire risk
 4 since the IPEEE, the NRC staff concludes that the fire CDF of 1.9×10^{-5} per year is reasonable
 5 for the SAMA analysis.

1 The CNS-1 IPEEE analysis of high winds, tornadoes, external floods and other external events
2 followed the screening and evaluation approaches specified in Supplement 4 to GL 88-20
3 (NRC, 1991) and did not identify any sequences or vulnerabilities that exceeded the 1.0×10^{-6}
4 per year criterion except for the design-basis tornado and a lightning strike to the control
5 building (NPPD, 1996). Plant improvements were identified to address each of these issues and
6 included as SAMA candidates, as discussed in Section F.3.2. The NRC staff concluded in the
7 review of the CNS-1 IPEEE that the tornado missiles contribution to CDF is less than the
8 screening criteria and that lightning did not pose a significant hazard to the plant (NRC, 2001).

9 Based on the aforementioned results, including the NRC staff assessment of the CNS-1 seismic
10 CDF, the external events CDF is approximately two times the internal events CDF (based on a
11 seismic CDF of 6×10^{-6} per year, a fire CDF of 1.9×10^{-5} per year, and an internal events CDF
12 of 1.2×10^{-5} per year). Accordingly, the NRC staff concurred with NPPD's conclusion that the
13 total CDF (from internal and external events) would be approximately three times the internal
14 events CDF. In the SAMA analysis submitted in the ER, NPPD tripled the benefit that was
15 derived from the internal events model to account for the combined contribution from internal
16 and external events. The NRC staff agrees with the licensee's overall conclusion concerning the
17 multiplier used to represent the impact of external events and concludes that the licensee's use
18 of a multiplier of three to account for external events is reasonable for the purposes of the
19 SAMA evaluation. This is discussed further in Section F.6.2.

20 The NRC staff reviewed the general process used by NPPD to translate the results of the Level
21 1 PSA into containment releases, as well as the results of the Level 2 analysis, as described in
22 the ER and in response to NRC staff requests for additional information (NPPD 2008, 2009a).
23 This model is an updated version of the model used in the IPE and reflects the CNS-1
24 configuration and design as of December 2007. Major revisions and updates to the Level 2
25 model include equipment performance data for failure rates and system unavailability, plant
26 configuration changes, improved modeling techniques, inclusion of additional PDS bins to
27 improve the Level 1 and Level 2 PSA interface, and updated accident progression and source
28 term analyses using a later version of the MAAP computer code. The Level 1 core damage
29 sequences are binned into one of 15 PDS bins which provide the interface between the Level 1
30 and Level 2 analysis. The PDS, which are described in Table E.1-8 of the ER (NPPD, 2008),
31 are defined by a set of functional characteristics for system operation which are important to
32 accident progression, containment failure and source term definition. The Level 2 models utilize
33 a single CET for each PDS with functional nodes representing both systemic and
34 phenomenological events. The CET is used to determine the appropriate release category for
35 each Level 2 sequence. CET nodes are evaluated using supporting fault trees and logic rules.

36 NPPD characterized the releases for the spectrum of possible radionuclide release scenarios
37 using a set of 12 release categories based on the timing and magnitude of the release and
38 whether or not the containment remained intact. The frequency of each release category was
39 obtained by summing the frequency of the individual accident progression CET endpoints
40 binned into the release category. The release characteristics for each release category were
41 developed by grouping the hundreds of source terms generated for internal initiators into the
42 12 categories based on similar properties. Source term release fractions were developed for
43 each of the 12 release categories using the results of 46 Modular Accident Analysis Program
44 (MAAP 4.0.5) computer code calculations (NPPD, 2009a). In response to an NRC staff RAI,
45 NPPD identified that for each CET sequence, a value for each of the release-to-environment
46 mass fractions was obtained from the representative MAAP calculation (NPPD, 2009a). These
47 mass fractions were then weighted according to the contribution of that sequence to the sum of
48 the sequences in the end state bin. The final mass fraction representing the end state bin was

Appendix F

1 the sum of these individual weighted mass fractions for each species. The release categories,
2 their frequencies, and release characteristics are presented in Tables E.1-6 and E.1-7, E.1-9,
3 and E.1-10 of the ER, respectively (NPPD, 2008).

4 The NRC staff noted that the iodine and cesium mass fractions for the low-low intermediate
5 release category in Table E.1-10 of the ER are substantially less than the corresponding mass
6 fractions for the low-low early and low-low late release categories and requested NPPD to
7 provide an explanation for this apparent anomaly (NRC, 2009). In response, NPPD explained
8 that the dominant sequences for the low-low intermediate release category involve offsite
9 release via containment venting through an intact suppression pool, resulting in effective fission
10 product scrubbing (NPPD, 2009a). In contrast, the dominant sequences for the low-low early
11 and low-low late release categories involve release paths from the primary containment that
12 bypass the suppression pool, resulting in much less fission product scrubbing than for the
13 low-low intermediate release category. Consequently, the cesium and iodine mass fractions for
14 the low-low intermediate release category will be less than that for the low-low early and low-low
15 late release categories.

16 The NRC staff requested NPPD provide an explanation of the reasons for the difference in the
17 total release frequency value of 1.2×10^{-5} derived from the CET and the Level 1 CDF value of
18 9.3×10^{-6} and to provide the rationale for using the total release frequency for the SAMA
19 analysis (NRC, 2009). In response, NPPD indicated that (NPPD, 2009a):

- 20 • The total release frequency derived from the CET is larger than the Level 1
21 CDF because of the methodology used in the CET for deriving the split
22 fraction values. The CET contains numerous paths that do not meet the
23 rare event approximation criterion (e.g., split fractions $> 5 \times 10^{-2}$) in the
24 quantification approach used. For these paths, the sum of the split fractions
25 for the corresponding failure and success branches is greater than 1.0
26 resulting in a conservatively high total CDF.
- 27 • Since the SAMA evaluation requires both Level 1 and 2 PSA results, NPPD
28 chose the higher value from the CET as the basis for quantifying SAMA
29 benefits.

30 NPPD concludes that use of the release frequency, rather than the Level 1 CDF, will have a
31 negligible impact on the results of the SAMA evaluation because the delta risk calculation,
32 performed to assess SAMA benefits, effectively cancels out the impact of the simplified model
33 quantification methodology, and because the external event multiplier and uncertainty multiplier
34 used in the SAMA analysis (discussed in Section F.6.2) have a much greater impact on the
35 SAMA evaluation results than the small error arising from the model quantification approach.
36 The NRC staff agrees with this conclusion.

37 The NRC staff's review of the Level 2 IPE concluded that it addressed the most important
38 severe accident phenomena normally associated with the Mark I containment type, and
39 identified no significant problems or errors (NRC, 1996). The changes to the Level 2 model
40 since the IPE to update the methodology and to address peer review recommendations are
41 described in Section E.1.4 of the ER. The Level 2 PSA model was included in the May 2008
42 BWROG peer review mentioned previously. Of the 22 peer review findings, one finding in the
43 SR not-met category was related to identification of limitations in the LERF analysis that would
44 impact applications. In response to an NRC staff RAI, NPPD reviewed this finding and

1 determined that there were no limitations that would impact projected applications that are not
2 already documented, and concluded that the finding would not impact the results of the SAMA
3 analysis.

4 Based on the NRC staff's review of the Level 2 methodology, the fact that the Level 2 model
5 was reviewed in more detail as part of the BWROG peer review and that the peer review
6 findings do not impact the SAMA analysis, and the responses to the RAIs concerning the
7 analysis and review process, the NRC staff concludes that the Level 2 PSA provides an
8 acceptable basis for evaluating the benefits associated with various SAMAs.

9 As indicated in the ER, the reactor core radionuclide inventory used in the consequence
10 analysis was derived from ORIGEN2 calculations using a bounding core enrichment and burnup
11 for CNS-1. A core power of 2,429 megawatt-thermal (MWt) was assumed to bound the licensed
12 maximum power of 2,419 MWt for the CNS-1 Measurement Uncertainty Recapture power
13 uprate approved by the NRC in 2008. The NRC staff requested additional information about the
14 expected fuel burnup and management for the renewal period (NRC, 2009). NPPD responded
15 that the bounding core inventory assumed an initial enrichment of 3.908 weight percent
16 Uranium-235 and 1300 effective full-power days (EFPD) of continuous operation to achieve an
17 end of cycle core average exposure of 35.8 Gwd/MT (NPPD, 2009a), and that this core
18 inventory reflects the expected fuel management/burnup for the renewal period.

19 The NRC staff reviewed the process used by NPPD to extend the containment performance
20 (Level 2) portion of the PSA to an assessment of offsite consequences (Level 3). This included
21 consideration of the source terms used to characterize fission product releases for the
22 applicable containment release categories and the major input assumptions used in the offsite
23 consequence analyses. Version 1.13.1 of the MACCS2 code was utilized to estimate offsite
24 consequences. Plant-specific input to the code includes the source terms for each release
25 category and the reactor core radionuclide inventory (both discussed above), site-specific
26 meteorological data, projected population distribution within a 50-mile (80-km)) radius for the
27 year 2034, emergency evacuation modeling, and economic data. This information is provided in
28 Attachment E to the ER (NPPD, 2008).

29 NPPD used site-specific meteorological data for the five years, 2002 through 2006, as input into
30 the MACCS2 code. NPPD averaged the data over this interval for this study. The data were
31 collected from the onsite meteorological monitoring system and regional National Weather
32 System (NWS) stations. Regional mixing heights were estimated using ground level and
33 upper-air data collected at National Weather Service Station No. 94980 in Valley, Nebraska
34 (NE) (approximately 76 miles(120 km) north-northwest of CNS-1) and Station No. 72553 in Falls
35 City/Brenner, NE (approximately 19 miles (30 km) south of CNS-1). Missing data were
36 estimated using data substitution methods. These methods include substitution of missing data
37 with valid data from the previous hour, or valid data collected from other elevations on the
38 meteorological tower. The NRC staff notes that previous SAMA analyses results have shown
39 little variation resulting from year-to-year differences in meteorological data and concludes that
40 the approach taken for collecting and applying the meteorological data in the SAMA analysis is
41 reasonable.

42 The population distribution used by the licensee as input to the MACCS2 analysis was
43 estimated for the year 2034 based on county-level projections obtained from the University of
44 Nebraska Bureau of Business Research (UN, 2007), Woods & Poole Economics, Inc. for Iowa
45 (Woods & Poole, 2006), Darrel Eklund, et. al. for Kansas (Eklund, 1999), and the Missouri
46 Census Data Center (Missouri, 2007). Year 2004 tourist information was used to estimate the

1 transient population for year 2005 (Global Insight, 2006; IDED, 2006; Kaylen, 2006;
2 NDED, 2006). These data were used to project county-level populations using a regression
3 method to extrapolate population projections to 2034. For the counties with population in
4 decline, the population value for year 2014 was used, which corresponds to the license
5 expiration date for CNS-1. The NRC staff considers the methods and assumptions for
6 estimating population reasonable and acceptable for purposes of the SAMA evaluation.

7 The emergency evacuation model was modeled as a single evacuation zone extending out
8 10 miles (16 km) from the plant. NPPD assumed that 100 percent of the population would move
9 at an average speed of approximately 19.5 miles per hour (mph) (8.7 meters per second (m/s))
10 with a delayed start time of 2.0 hours (NPPD, 2008). The evacuation speed and time were
11 based on the average values identified in the Missouri and Nebraska time estimate studies.
12 NPPD performed sensitivity analyses in which the evacuation delay time was increased to 4.0
13 hours, and the evacuation speed was decreased to 1.0 m/s. These sensitivity cases resulted in
14 less than 1 percent and 2 percent increases in the total population dose, respectively. The
15 100 percent population evacuation assumption is slightly less conservative than the assumption
16 used in NUREG-1150 study (NRC, 1990), which assumed evacuation of 99.5 percent of the
17 population within the emergency planning zone (EPZ). The NRC staff asked NPPD to address
18 the potential impact on the population dose if 5 percent of the population fails to evacuate the
19 EPZ (NRC, 2009). In response, NPPD performed a sensitivity analysis that showed only a slight
20 increase in population dose (less than 1 percent for the late release) would result
21 (NPPD, 2009a). The NRC staff concludes that the evacuation assumptions and analysis are
22 reasonable and acceptable for the purposes of the SAMA evaluation.

23 Much of the site-specific economic data was obtained from the 2002 Census of Agriculture
24 (USDA, 2002). These included the value of farm and non-farm wealth. Other generic data that
25 applies to the region as a whole, such as the cost of evacuating and relocating people, land
26 decontamination, and property decontamination, were obtained from the code manual for
27 MACCS2 (NRC, 1997c). The data from the MACCS2 code manual were inflation-adjusted
28 using the consumer price index corresponding to the year 2006. Information on regional crops
29 was obtained from the 2002 Census of Agriculture. Crops for each county were mapped into the
30 seven MACCS2 crop categories.

31 The NRC staff concludes that the methodology used by NPPD to estimate the offsite
32 consequences for CNS-1 provides an acceptable basis from which to proceed with an
33 assessment of risk reduction potential for candidate SAMAs. Accordingly, the NRC staff based
34 its assessment of offsite risk on the CDF and offsite doses reported by NPPD.

35 **F.3. Potential Plant Improvements**

36 The process for identifying potential plant improvements, an evaluation of that process, and the
37 improvements evaluated in detail by NPPD are discussed in this section.

1 **F.3.1. Process for Identifying Potential Plant Improvements**

2 NPPD's process for identifying potential plant improvements (SAMAs) consisted of the following
3 elements:

- 4 • Review of the most significant basic events from the current, plant-specific
5 PSA,
- 6 • Review of potential plant improvements identified in the CNS-1 IPE and
7 IPEEE,
- 8 • Review of SAMA candidates identified for license renewal applications for
9 11 other U.S. General Electric (GE) plants, and
- 10 • Review of other NRC and industry documentation discussing potential plant
11 improvements.

12 Based on this process, an initial set of 244 candidate SAMAs, referred to as Phase I SAMAs,
13 was identified. In Phase I of the evaluation, NPPD performed a qualitative screening of the initial
14 list of SAMAs and eliminated SAMAs from further consideration using the following criteria:

- 15 • The SAMA modified features are not applicable to CNS-1,
- 16 • The SAMA has already been implemented at CNS-1, or
- 17 • The SAMA is similar in nature and could be combined with another SAMA
18 candidate.

19 Based on this screening, 164 SAMAs were eliminated leaving 80 for further evaluation. The
20 remaining SAMAs, referred to as Phase II SAMAs, are listed in Table E.2-2 of the ER
21 (NPPD, 2008). In Phase II, a detailed evaluation was performed for each of the 80 remaining
22 SAMA candidates, as discussed in Sections F.4 and F.6 below. To account for the potential
23 impact of external events, the estimated benefits, based on internal events, were multiplied by a
24 factor of three, as previously discussed.

25 **F.3.2. Review of Nebraska Public Power District's Process**

26 NPPD's efforts to identify potential SAMAs focused primarily on areas associated with internal
27 initiating events. The initial list of SAMAs generally addressed the accident sequences
28 considered to be important to CDF from functional, initiating event, and risk reduction worth
29 (RRW) perspectives at CNS-1, and included selected SAMAs from prior SAMA analyses for
30 other plants.

31 NPPD provided a tabular listing of the PSA basic events sorted according to their RRW
32 (NPPD, 2008). SAMAs impacting these basic events would have the greatest potential for
33 reducing risk. NPPD used an RRW cutoff of 1.005, which corresponds to about a 0.5 percent
34 change in CDF given 100-percent reliability of the SAMA. This equates to a benefit of
35 approximately \$5,300 (after the benefits have been multiplied to account for external events).
36 NPPD also provided and reviewed the LERF-based RRW events down to an RRW of 1.005.

Appendix F

- 1 NPPD correlated the top Level 1 and Level 2 events with the SAMAs evaluated in the ER, and
2 showed that all of the significant basic events are addressed by one or more SAMAs
3 (NPPD, 2008).
- 4 The NRC staff asked NPPD to provide the rationale for identifying candidate SAMAs for
5 LERF-based success events (NRC, 2009). In response to the RAI, NPPD replied that, unlike
6 SAMAs identified for the purpose of decreasing the risk of failure events, SAMAs identified for
7 success events are intended to decrease the risk contribution from the cutsets or basic events
8 related to the success event (NPPD, 2009a). NPPD further noted that SAMAs identified for
9 success events are also identified for related failure events, and provided specific examples of
10 this relationship. The staff finds NPPD's treatment of success events acceptable.
- 11 The NRC staff also asked NPPD to clarify how RRW was calculated for complementary events
12 and to provide an assessment of the impact on the SAMA identification and evaluation process
13 if complementary events were not directly coupled in the computation of RRW (NRC, 2009).
14 NPPD responded that complementary events were directly coupled in the calculation of RRW,
15 provided an example of this direct coupling, and concluded that since this coupling was
16 performed correctly there is no impact on the SAMA identification and evaluation process
17 (NPPD, 2009a). The NRC staff agrees that NPPD appropriately accounted for direct coupling of
18 complementary events in the calculation of RRW.
- 19 The NRC staff requested clarification on the screening criteria used for the Phase I SAMAs
20 because the ER was inconsistent in describing this process (NRC, 2009). NPPD responded that
21 the criteria for screening Phase I SAMAs based on SAMA modifying features not applicable to
22 CNS-1 is broader than this description suggests and includes; (1) SAMAs that have already
23 been analyzed for CNS-1 and determined to be of low benefit, and (2) SAMAs that have been
24 previously resolved with NRC based on further evaluation that determined that the modification
25 was not necessary (NPPD, 2009).
- 26 For a number of the Phase II SAMAs listed in the ER, the information provided did not
27 sufficiently describe the proposed modification. Therefore, the NRC staff asked the applicant to
28 provide more detailed descriptions of the modifications for several of the Phase II SAMA
29 candidates (NRC, 2009). In response to the RAI, NPPD provided the requested information on
30 the modifications for SAMAs 20, 44, 45, 63, 70, 72, 73, 76, 77, and 80 (NPPD, 2009a).
- 31 NPPD considered the potential plant improvements described in the IPE and IPEEE in the
32 identification of plant-specific candidate SAMAs for internal and external events. Although the
33 IPE did not identify any vulnerabilities, seven potential enhancements to the plant, procedures,
34 and training at CNS-1 were identified as part of the IPE process. The seven enhancements
35 include (NPPD, 1993):
- 36 • Upgrading the plant-specific emergency operating procedures based on
37 Revision 4 of the BWROG Emergency Procedure Guidelines,
 - 38 • Performing a load study to relax the assumed four-hour battery lifetime and
39 provide a procedure to improve battery loading schemes,
 - 40 • Providing a procedure to bypass the AC solenoid valve on the nitrogen
41 supply line to the SRVs,

- 1 • Providing a diesel-driven fire water pump or other similar source of low
2 pressure water independent of AC power,
- 3 • Improving the reliability of the high pressure coolant injection (HPCI) and
4 reactor core isolation cooling (RCIC) systems,
- 5 • Providing a backup for the SW pumps by modifying the existing system and
6 making procedural changes, and
- 7 • Providing improved drywell spray capability.

8 NPPD noted that the first four of these enhancements have already been implemented at CNS-
9 1 and the remaining three enhancements are addressed by SAMAs. The fifth enhancement, to
10 improve the reliability of the HPCI and RCIC systems, as addressed by Phase II SAMA 35,
11 “provide a redundant train or means of ventilation,” and SAMA 67, “improve the reliability of the
12 HPCI and RCIC systems by upgrading their control systems.” The sixth enhancement, to
13 provide a backup for the SW pumps, as addressed by Phase II SAMA 68, “proceduralize the
14 ability to cross-connect the circulating water pumps and the SW going to the TEC heat
15 exchangers.” The last enhancement, to provide an improved drywell spray capability, was
16 judged to be already implemented at CNS-1 where the fire water system is used as a backup
17 source for the drywell spray system. Nevertheless, NPPD further addressed this enhancement
18 with Phase II SAMA 47, “install a passive drywell spray system to provide a redundant drywell
19 spray method.”

20 Based on this information, the NRC staff concludes that the set of SAMAs evaluated in the ER,
21 together with those identified in response to NRC staff RAIs, addresses the major contributors
22 to internal event CDF.

23 Several seismic-related improvements were identified in the CNS-1 IPEEE. The specific seismic
24 interaction issues are as follows (NPPD, 1996):

- 25 • Potential relay chatter at low seismic levels for ten relays,
- 26 • Potential impact of the 480V critical switchgear 1G with an adjacent
27 concrete beam,
- 28 • Potential seismic interaction of the solatron/accuvolt line conditioners with a
29 stairway supported by a masonry wall,
- 30 • Potential inadequate seismic capacity for the SE and NE quad recirculation
31 fans,
- 32 • Potential impact of the jet pump instrument rack A with an adjacent rack,
- 33 • Inadequate anchorage capacity for loose equipment in the control room and
34 lack of support for the overhead lighting diffusers,
- 35 • Inadequate anchorage for the aux relay room panels,

Appendix F

- 1 • Inadequately braced unistrut trapeze frame in the northeast corner of
2 elevation 903 feet of the reactor building, and
- 3 • Loose bolt securing one corner of an interior panel of the SW pump B & D
4 strainer control panel.

5 All of these were identified as Phase I SAMAs but have already been implemented or previously
6 resolved under the USI A-46 Program (NRC, 2001). As a result, no Phase II SAMAs were
7 identified to address these issues. The CNS-1 IPEEE seismic/fire interaction evaluation did
8 conclude that the CNS-1 water-based fire protection systems were vulnerable to a seismic
9 event. This vulnerability was addressed by Phase II SAMA 69, "upgrade the seismic capacity of
10 the diesel fire pump fuel tank and water supply tank." The NRC staff concludes that the
11 opportunity for seismic-related SAMAs has been adequately explored and that it is unlikely that
12 there are additional potentially cost-beneficial, seismic-related SAMA candidates.

13 The CNS-1 IPEEE fire assessment concluded that the four fire compartments (Control Room
14 and SAS Corridor, Switchgear Rooms 1F and 1G, and SW Pump Room) that did not screen out
15 based on having a fire CDF of less than 1.0×10^{-6} per year represent vulnerabilities
16 (NPPD, 1996). Two plant improvements were identified to address these risk contributors:

- 17 • Addition of a feature to allow remote control of the switchyard breakers from
18 the control room, or to have a pre-planned recovery/repair action for control
19 of the switchyard breakers following a fire, and
- 20 • Provide a diverse water supply for the SW system.

21 Both of these were identified as Phase I SAMAs. As indicated in the ER, an evaluation of
22 improvements for control of the switchyard breakers showed a decrease in CDF of less than
23 0.5 percent, therefore, this change was not implemented or evaluated as a Phase II SAMA. The
24 second improvement was evaluated as Phase II SAMA 68, "proceduralize the ability to
25 cross-connect the circulating water pumps and the SW pumps going to the TEC heat
26 exchangers." NPPD also identified two additional Phase II SAMAs to reduce the fire CDF in
27 dominant fire zones without suppression and in the control room: (1) SAMA 63, "add automatic
28 fire suppression systems to the dominant fire zones," and (2) SAMA 65, "upgrade the ASDS
29 panel to include additional system controls for the opposite division." The NRC staff concludes
30 that the opportunity for fire-related SAMAs has been adequately explored and that it is unlikely
31 that there are additional potentially cost-beneficial, fire-related SAMA candidates.

32 As stated earlier, other external hazards (e.g., high winds, external floods, transportation and
33 nearby facility accidents) are below the threshold screening frequency and are not expected to
34 impact the conclusions of the SAMA analysis. Nevertheless, two plant improvements were
35 identified to address the risk contribution from tornados and lightning:

- 36 • Protect the diesel generator exhaust system from tornado-generated
37 missiles, and
- 38 • Reduce the potential vulnerability of the control building to a
39 lightning-induced loss of offsite power that also affects the station batteries.

1 Both were identified as Phase I SAMAs. The first, Phase I SAMA 232, “protect the diesel
 2 exhaust from tornado missiles,” has already been implemented at CNS-1. The NRC inquired
 3 about this SAMA being described as resolved in 1998, while the IPEEE SER stated that the
 4 issue had yet to be addressed. NPPD responded that the matter was resolved by a letter from
 5 NPPD to NRC in 2001 clarifying that the modification was in fact completed in 1998. The
 6 second improvement was further evaluated and it was determined that the control building was
 7 not vulnerable to a lightning-induced loss of offsite power which might affect the station
 8 batteries.

9 The NRC staff questioned NPPD about lower cost alternatives to some of the SAMAs evaluated
 10 (NRC, 2009), including:

- 11 • Providing additional space cooling to the RHRSW booster pump rooms, CS
 12 pump rooms, residual heat removal (RHR) pump rooms, SW pump rooms,
 13 and HPCI pump room via the use of portable equipment,
- 14 • Improving alternate shutdown training and equipment,
- 15 • Enhancing DC power availability (provide cables from diesel generators or
 16 another source to directly power battery chargers),
- 17 • Developing guidance/procedures for local, manual control of reactor core
 18 isolation cooling following loss of DC power, and
- 19 • Enhancing manual venting of containment using either a local hand wheel
 20 or gas bottle supplies as a possible alternative for containment pressure
 21 control.

22 In response to the RAIs, NPPD addressed the suggested lower cost alternatives
 23 (NPPD, 2009a). This is discussed further in Section F.6.2.

24 The NRC staff notes that the set of SAMAs submitted is not all-inclusive, since additional,
 25 possibly even less expensive, design alternatives can always be postulated. However, the NRC
 26 staff concludes that the benefits of any additional modifications are unlikely to exceed the
 27 benefits of the modifications evaluated and that the alternative improvements would not likely
 28 cost less than the least expensive alternatives evaluated when the subsidiary costs associated
 29 with maintenance, procedures, and training are considered.

30 The NRC staff concludes that NPPD used a systematic and comprehensive process for
 31 identifying potential plant improvements for CNS-1, and that the set of SAMAs evaluated in the
 32 ER, together with those evaluated in response to NRC staff inquiries, is reasonably
 33 comprehensive and, therefore, acceptable. This search included reviewing insights from the
 34 plant-specific risk studies and reviewing plant improvements considered in previous SAMA
 35 analyses. While explicit treatment of external events in the SAMA identification process was
 36 limited, it is recognized that the prior implementation of plant modifications for fire risks and the
 37 absence of external event vulnerabilities reasonably justifies primarily examining the internal
 38 events risk results for this purpose.

1 **F.4. Risk Reduction Potential of Plant Improvements**

2 NPPD evaluated the risk-reduction potential of the 80 remaining SAMAs that were applicable to
3 CNS-1. The majority of the SAMA evaluations were performed in a bounding fashion—the
4 SAMA was assumed to completely eliminate the risk associated with the proposed
5 enhancement. On balance, such calculations overestimate the benefit and are conservative.

6 NPPD used model requantification to determine the potential benefits. The CDF, population
7 dose, and offsite economic cost reductions were estimated using the CNS-1 2007TM model,
8 Rev. 1. The changes made to the model to quantify the impact of SAMAs are detailed in
9 Section E.2.3 of Attachment E to the ER (NPPD, 2008). Table F-5 lists the assumptions
10 considered to estimate the risk reduction for each of the evaluated SAMAs, the estimated risk
11 reduction in terms of percent reduction in CDF and population dose, and the estimated total
12 benefit (present value) of the averted risk. The estimated benefits reported in Table F-5 reflect
13 the combined benefit in both internal and external events. The determination of the benefits for
14 the various SAMAs is further discussed in Section F.6.

15 The NRC staff questioned the assumptions used in evaluating the benefits or risk reduction
16 estimates of certain SAMAs provided in the ER (NRC, 2009). For example, for SAMA 6,
17 “change the time available to recover offsite power to 24 hours,” the NRC staff requested
18 clarification on the modeling assumption provided in ER Table 2-2 for this SAMA, which is
19 inconsistent with the modeling assumption for analysis Case 6, “set failure probability to transfer
20 the RPS panels to their alternate power source to zero” (NRC, 2009). In response to the RAI,
21 NPPD clarified that the modeling assumption for SAMA 6, as provided in Table 2-2 of the ER,
22 was incorrect and should have been the same as described for Case 6. The correct modeling
23 assumption was used in the cost benefit analysis (NPPD, 2009a).

24 For SAMA 14, “portable generator for DC power to supply individual panels,” the NRC staff
25 asked NPPD to clarify the rationale for using the modeling assumption for Case 14, which was
26 to set the CDF contribution due to unavailability of the HPCI system to zero in the Level 1
27 PSA model (NRC, 2009). In response to the RAI, NPPD explained that the benefit of providing
28 an alternate DC power source to HPCI to support emergency core cooling was judged to be
29 larger than the benefit of providing an alternate DC power source to other panels based on: (1)
30 the importance of HPCI in intermediate LOCA sequences, and (2) the fact that the
31 turbine-driven HPCI pump can continue to run in SBO sequences as long as DC control power
32 is available (NPPD, 2009a). The NRC staff further asked NPPD to explain the large CDF
33 reduction for this SAMA (32 percent) when the CDF contribution from HPCI unavailability due to
34 test and maintenance is only 3 percent. In response to the RAI, NPPD responded that the
35 evaluation of this SAMA conservatively assumes HPCI never fails, which eliminates the CDF
36 contribution from all events contributing to HPCI unavailability, not just the test and maintenance
37 event. Other contributing events include loss of DC power, failure of the turbine-driven HPCI
38 pump to start or continue to run, failure of HPCI hydraulic valve HO10, and failure to bypass the
39 HPCI high temperature trip. The NRC staff considers the assumptions, as clarified, to be
40 reasonable and acceptable for purposes of the SAMA evaluation.

41 The NRC staff questioned how the modeling assumption of eliminating failure of the
42 diesel-driven fire pump in the Level 1 PSA model for SAMA 69, “upgrade the seismic capacity of
43 the diesel fire pump fuel tank and water supply tank,” addresses the intent of this SAMA, which
44 is to mitigate seismic risk (NRC, 2009). In response to the RAI, NPPD explained that while the
45 diesel fire pump may be needed to fight a fire following a seismic or fire event, its contribution to
46 preventing core damage is from its dual function of providing an alternate source of water for

1 core cooling. NPPD further argued that the estimated risk reduction benefit for this SAMA is
2 conservative since the analysis credited the benefit from internal events risk reduction, in
3 addition to the benefit from external events risk reduction, through use of the external events
4 multiplier (NPPD, 2009a). The NRC staff agrees that the resulting benefit estimate is
5 conservative since there would be no reduction in internal events risk from implementation of
6 the SAMA.

7 The NRC staff requested clarification on how SAMA 70, “install a curb to prevent debris from
8 spreading across the floor and contacting the shell,” reduces CDF as indicated in the ER
9 (NRC, 2009). In response to the RAI, NPPD explained that SAMA 70 does not impact Level 1
10 CDF and that the CDF reduction value reported in the ER for this SAMA is actually based on the
11 release frequency reduction for this SAMA (NPPD, 2009a). In a follow-up response to the NRC
12 staff RAI, NPPD further clarified that the analysis of this SAMA resulted in about a 12 percent
13 reduction in the frequency for the large early release category, and that this was treated as a
14 12 percent reduction in CDF in assessing the benefits for this SAMA (NPPD, 2009b). NPPD
15 indicated that a more accurate assessment of SAMA 70 would require modifying the CET and
16 that the approach taken results in a conservative estimate of the benefits for this SAMA.
17 Although this approach is not consistent with regulatory analysis methodology, the NRC staff
18 agrees that the resulting benefit estimate would be conservative since a reduction in CDF would
19 result in averted onsite costs that would not be included otherwise for the SAMA. NPPD also
20 noted that this analysis methodology was unique to SAMA 70 and does not impact the
21 evaluation of other SAMAs.

22 For SAMA 75, “Generation Risk Assessment (GRA) implementation into plant activities,” the
23 NRC staff asked for additional clarification of the SAMA and justification for the assumed factor
24 of two reduction in the initiating event frequencies impacted by this SAMA (NRC, 2009). In
25 response to the RAI, NPPD explained that GRA is a new program to identify plant components
26 most likely to result in a plant trip, insights from which are used to identify and reevaluate
27 maintenance and operational practices to reduce the likelihood of future plant trips. NPPD
28 further explained that the GRA program was only recently piloted by CNS-1 for EPRI and that
29 the factor of two is based on recent plant operating history and opinion based on NPPD’s
30 experience in the GRA process. The NRC staff considers the assumptions, as clarified, to be
31 reasonable and acceptable for purposes of the SAMA evaluation.

32 For two of the SAMAs that specifically address fire events (i.e., SAMA 63, “add automatic fire
33 suppression systems to the dominant fire zones,” and SAMA 65, “update the alternate shutdown
34 system (ASDS) panel to include additional system controls for opposite division,” the reduction
35 in fire CDF and population dose was not directly calculated (in Table F-5 these are noted as
36 “Not Estimated”). For these SAMAs, a bounding estimate of the impact was made by assuming
37 the SAMA would eliminate the contribution to fire CDF from fires in the dominant fire zones in
38 SAMA 63 and the control room in SAMA 65. The dominant fire zones in SAMA 63 are those
39 having a fire CDF greater than 1.0×10^{-6} per year. Based on information from the IPEEE, the
40 dominant fire zones are switchgear rooms 1F and 1G, the main control room, and the SW pump
41 room. Based on logic in Section E.2.3 of the ER, only switchgear rooms 1F and 1G would
42 benefit from the addition of automatic fire suppression systems. The benefit or averted cost risk
43 from eliminating the risk in these fire zones is then calculated by multiplying the ratio of the fire
44 zone CDF to the internal events CDF by the total present dollar-value equivalent associated
45 with completely eliminating severe accidents from internal events at CNS-1. These SAMAs were
46 assumed to have no additional benefits in internal events.

1 The NRC staff has reviewed NPPD's bases for calculating the risk reduction for the various
2 plant improvements and concludes that the rationale and assumptions for estimating risk
3 reduction are reasonable and generally conservative (i.e., the estimated risk reduction is higher
4 than what would actually be realized). Accordingly, the NRC staff based its estimates of averted
5 risk for the various SAMAs on NPPD's risk reduction estimates.

6 **F.5. Cost Impacts of Candidate Plant Improvements**

7 NPPD estimated the costs of implementing the 80 candidate SAMAs through the application of
8 engineering judgment and use of other licensees' estimates for similar improvements. The cost
9 estimates conservatively did not include the cost of replacement power during extended
10 outages required to implement the modifications, nor did they include maintenance and
11 surveillance costs of the installed equipment (NPPD 2008, 2009a). The cost estimates provided
12 in the ER did not account for inflation, which is considered another conservatism.

13 The NRC staff reviewed the bases for the applicant's cost estimates (presented in Section E.2
14 of Attachment E to the ER). For certain improvements, the NRC staff also compared the cost
15 estimates to estimates developed elsewhere for similar improvements, including estimates
16 developed as part of other licensees' analyses of SAMAs for operating reactors and advanced
17 light-water reactors. The NRC staff noted that several of the cost estimates provided by the
18 applicant were drawn from previous SAMA analyses for a dual-unit site. For those cost
19 estimates that were taken from a dual-unit SAMA analysis, NPPD reduced the estimated costs
20 by one-half. In response to an RAI requesting a more detailed description of the changes
21 associated with SAMAs 20, 44, 45, 63, 70, 72, 73, 76, 77, and 80, NPPD provided additional
22 information detailing the analysis and plant modifications included in the cost estimate of each
23 improvement (NPPD, 2009a). The staff reviewed the costs and found them to be reasonable,
24 and generally consistent with estimates provided in support of other plants' analyses.

25 The NRC staff requested additional clarification on the estimated cost of \$1,200,000 for
26 implementation of SAMA 41, "provide ability to align diesel power to more air compressors,"
27 which is high for what is described as a procedural modification (NRC, 2009). In response to the
28 RAI, NPPD further described this modification as involving electrical, mechanical, and structural
29 hardware modifications, in addition to the procedural changes (NPPD, 2009a). Based on this
30 additional information, the NRC staff considers this estimated cost to be reasonable and
31 acceptable for purposes of the SAMA evaluation.

32 The NRC staff concludes that the cost estimates provided by NPPD are sufficient and
33 appropriate for use in the SAMA evaluation.

Table F-5. Severe Accident Mitigation Alternatives Cost/Benefit Screening Analysis for Cooper Nuclear Station^(a)

SAMA	Modeling Assumptions	% Risk Reduction		Total Benefit (\$)		Cost (\$)
		CDF	Population Dose	Baseline (Internal + External)	Baseline With Uncertainty	
<p>Increase Availability of DC Power</p> <p>1 – Provide additional DC battery capacity.</p> <p>2 – Replace lead-acid batteries with fuel cells.</p> <p>13 – Portable generator for DC power to supply the battery chargers.</p> <p>21 – Modify plant procedures to allow use of a portable power supply for battery chargers.</p>	<p>Increase time available to recover offsite power (before HPCI and RCIC are lost) to 24 hours during SBO scenarios.</p>	3	3	32K	97K	<p>500K</p> <p>1.0M</p> <p>200K</p> <p>Included in SAMA 13(b)</p>
<p>Improve DC Battery Charging Reliability</p> <p>3 – Add battery charger to existing DC system.</p> <p>15 – Proceduralize battery charger high-voltage shutdown circuit inhibitor.</p>	<p>Eliminate all common cause failures due to loss of DC battery chargers.</p>	<1	0	2.3K	7.0K	<p>90K</p> <p>50K</p>
<p>Improve DC Power Availability and Reliability</p> <p>4 – Provide DC bus cross-ties for the 250V buses.</p> <p>19 – Modify plant procedures to use existing 125V DC bus cross-ties.</p>	<p>Eliminate failure of the 250V DC buses.</p> <p>Eliminate failure of the operator to use the 125V DC bus cross-tie.</p>	0	0	0	0	<p>300K</p> <p>25K</p>
<p>Improve Availability of the 120V Vital AC Bus</p> <p>5 – Provide additional DC power to the 120/240V vital AC system.</p> <p>6 – Add an automatic feature to transfer the 120V vital AC bus from normal to standby power.</p>	<p>Eliminate failure of providing DC power to the no break power panel (NBPP).</p> <p>Eliminate failure to transfer the reactor protection system (RPS) panels to their alternate power source.</p>	~0	0	470	1.4K	<p>>100K</p> <p>500K</p>

Appendix F

SAMA	Modeling Assumptions	% Risk Reduction		Total Benefit (\$)		Cost (\$)
		CDF	Population Dose	Baseline (Internal + External)	Baseline With Uncertainty	
Increase Availability of Onsite AC Power 7 – Provide an additional diesel generator. 10 – Install a gas turbine generator.	Eliminate failure of the EDGs.	13	14	140K	430K	20M 2.0M
Increase Reliability of EDGs 11 – Add a new backup source for diesel cooling. 16 – Provide a portable EDG fuel oil transfer pump.	Eliminate failure of providing SW cooling to the EDGs. Eliminate failure of the EDG fuel oil transfer pumps.	5 <1	3 <1	45K 6.2K	130K 19K	2.0M 100K
Improve Availability of AC Power 8 – Improve 4.16-kV bus cross-tie ability. 17 – Provide alternate feeds to essential loads directly from an alternate emergency bus.	Eliminate failure of the 4.16-kV buses.	3	5	35K	110K	660K 220K
Reduce Probability of Loss of Offsite Power During Severe Weather 9 – Install an additional, buried offsite power source. 12 – Bury offsite power lines.	Eliminate the weather-centered loss of offsite power initiating event.	4	4	43K	130K	2.5M
Reduce Plant-Centered Loss of Offsite Power 18 – Protect transformers from failure.	Eliminate the plant-centered loss of offsite power initiating event.	~0	0	610	1.8K	1.1B 780K
Improve Reliability of the Direct Torus Vent Valves 20 – Provide redundant power to direct torus hard pipe vent valves.	Eliminate failure to power the hard pipe torus vent valves.	4	13	77K	230K	710K

SAMA	Modeling Assumptions	% Risk Reduction		Total Benefit (\$)		Cost (\$)
		CDF	Population Dose	Baseline (Internal + External)	Baseline With Uncertainty	
Increase Availability of High Pressure Injection 14 – Portable generator for DC power to supply the individual panels (using available skid-mounted portable AC generator). 22 – Install an independent active or passive high pressure injection system. 23 – Provide an additional high pressure injection pump with independent diesel.	Eliminate the CDF contribution from unavailability of the HPCI system.	32	22	300K	910K	710K 1.0M 1.0M
Extend RCIC Operation 24 – Raise HPCI/RCIC backpressure trip set points. 25 – Revise procedure to allow bypass of RCIC turbine exhaust pressure trip.	Eliminate failures due to the RCIC backpressure trip.	4	<1	29K	86K	>200K 25K
Improve Reliability of the Automatic Depressurization System (ADS) 26 – Modify ADS components by adding larger accumulators.	Eliminate failure of the ADS accumulators.	0	0	0	0	>100K
Improve Reliability of the SRVs 27 – Add signals to open SRVs automatically in a main steam isolation valve (MSIV) closure transient.	Eliminate failure to open the SRVs when required by reactor pressure vessel overpressure conditions.	19	<1	140K	410K	1.5M
Increase Availability of Low Pressure Injection 28 – Add a diverse low pressure injection system.	Eliminate failure of the low pressure injection system.	55	63	600K	1.8M	8.8M

Appendix F

SAMA	Modeling Assumptions	% Risk Reduction		Total Benefit (\$)		Cost (\$)
		CDF	Population Dose	Baseline (Internal + External)	Baseline With Uncertainty	
Emergency Core Cooling System (ECCS) Low Pressure Interlock 29 – Install a bypass switch to allow operators to bypass the low reactor pressure interlock circuitry.	Eliminate failure of the low pressure interlock circuitry.	24	6	190K	570K	1.0M
Improve Reliability of HPCI and RCIC 67 – Upgrade the HPCI and RCIC control systems.	Eliminate failure of the HPCI and RCIC turbine driven pumps.	6	0	42K	130K	430K
Improve Reliability/Redundancy of Steam Tunnel HVAC 76 – Improve steam tunnel HVAC reliability/redundancy.	Eliminate failure of the steam tunnel HVAC condenser and eliminate the group 1 isolation (closure of the MSIVs) initiating event.	3	1	27K	80K	>100K
Improve Reliability of ECCS Equipment 77 – Improve reliability of auto-start features for the ECCS equipment.	Eliminate failure of the auto-start features for the ECCS equipment.	1	0	9.3K	28K	>100K
Improve Reliability of Alternate Injection 78 – Improve training on providing alternate injection via FPS.	Reduce failure of operator actions to provide alternate injection via the fire water system by a factor of two to 5.0E-02 for events FPS-XHE-FO-DFPAL and FPS-XHE-FO-RPVIN and to 9.5E-03 for event FPS-XHE-FO-DISEL.(c) Eliminate the CDF contribution due to the SW cross-tie valves that are not contained in the maintenance program.	5	4	53K	160K	25K
32 – Include the RHRSW and fire water cross-tie valves in the maintenance program.		~0	0	360	1.1K	50K
33 – Create ability for emergency connection of existing or new water sources to feedwater and condensate systems.	Eliminate the CDF contribution due to loss of feedwater and condensate systems as alternate injection paths.	38	46	430K	1.3M	25K

SAMA	Modeling Assumptions	% Risk Reduction		Total Benefit (\$)		Cost (\$)
		CDF	Population Dose	Baseline (Internal + External)	Baseline With Uncertainty	
Increase Availability of the RHR Heat Exchangers 30 – Revise procedures to allow manual alignment of the fire water system to RHR heat exchangers.	Eliminate failure of SW to provide cooling to the RHR heat exchangers.	21	16	200K	600K	25K
Improve Reliability of Emergency SW System 31 – Add an additional SW pump.	Eliminate all common cause failures due to loss of SW system pumps.	<1	0	3.2K	9.5K	
Increase Availability of the TEC Heat Exchangers 68 – Proceduralize the ability to cross-connect the circulating water pumps and the SW going to the TEC heat exchangers.	Eliminate failure of the SW to provide cooling to the TEC heat exchangers.	15	20	180K	530K	50K
Improve Reliability of Main Feedwater System 34 – Add a motor-driven feedwater pump.	Eliminate failure of feedwater turbine-driven pumps.	~0	0	90	270	1.7M
Increase Availability of the Condensate Storage Tank (CST) 72 – Provide a means of automatically preventing drain-down of CST to hotwell during a SBO.	Eliminate the CDF contribution from operator failure to prevent CST inventory drain-down to the hotwell.	2	2	21K	63K	230K
Increase Availability of Room Cooling 35 – Provide a redundant train or means of ventilation.	Eliminate failure of room cooling to the RHRSW booster pump rooms.	4	3	38K	120K	2.2M

Appendix F

SAMA	Modeling Assumptions	% Risk Reduction		Total Benefit (\$)		Cost (\$)
		CDF	Population Dose	Baseline (Internal + External)	Baseline With Uncertainty	
Increase Availability of EDG System 36 – Add a diesel building high temperature alarm or redundant louver and thermostat. 38 – Install diverse set of EDG HVAC fan actuation logic. 39 – Install additional fan and louver pair for EDG heating, ventilation, and air conditioning. 40 – Revise operator procedures to provide additional space cooling to the EDG room via the use of portable equipment.	Eliminate failure of the EDG HVAC.	3	3	33K	99K	1.3M 100K 6.0M 25K
Improve Diagnosis of a Loss of Switchgear HVAC 37 – Add a switchgear room high temperature alarm.	Eliminate failure of room cooling to the critical switchgear rooms.	0	0	0	0	400K
Increase Reliability of Instrument Air 41 – Provide ability to align diesel power to more air compressors. ^(d) 42 – Replace service and instrument air compressors with more reliable compressors which have self-contained air cooling by shaft driven fans. 45 – Provide an alternate means of supplying the instrument air header.	Eliminate failure of the instrument air compressors.	17	14	170K	500K	1.2M 1.4M 100K
Extend SRV Operation Time 43 – Install nitrogen bottles as backup gas supply for SRVs.	Eliminate failure of loss of nitrogen and air to the SRVs.	0	0	0	0	>100K

SAMA	Modeling Assumptions	% Risk Reduction		Total Benefit (\$)		Cost (\$)
		CDF	Population Dose	Baseline (Internal + External)	Baseline With Uncertainty	
<p>Improve Availability of SRVs and MSIVs</p> <p>44 – Improve SRV and MSIV pneumatic components.</p>	<p>Eliminate failure of nitrogen, air, and accumulators for the SRVs and MSIVs.</p>	17	21	190K	570K	1.5M
<p>Improve Reliability of the Decay Heat Removal System – Torus Cooling</p> <p>46 – Install an independent method of suppression pool cooling.</p> <p>71 – Upgrade existing equipment to transfer water from the torus to the radwaste system.</p> <p>73 – Provide ability to maintain suppression pool temperature lower.</p>	<p>Eliminate loss of torus cooling mode of RHR and RHRSW system events.</p>	35	37	370K	1.1M	5.8M 11M 1.3M
<p>Improve Reliability of the Decay Heat Removal System – Drywell Spray</p> <p>47 – Install a passive drywell spray system to provide a redundant drywell spray method.</p>	<p>Eliminate loss of drywell sprays mode of RHR and RHRSW system events.</p>	17	55	320K	960K	5.8M
<p>Improve Reliability of Fission Product Scrubbing</p> <p>48 – Install a filtered containment vent.</p> <p>49 – Enhance fire protection system and/or standby gas treatment system hardware and procedures.</p>	<p>Reduce accident progression source terms by a factor of two (excluding noble gases).</p>	0	25	89K	270K	1.5M 2.5M
<p>Improve Reliability of Containment Venting</p> <p>50 – Modify containment venting procedure to control containment venting within a narrow band.</p>	<p>Eliminate failure of the operator to control the venting evolution.</p>	~0	0	35K	110K	250K

Appendix F

SAMA	Modeling Assumptions	% Risk Reduction		Total Benefit (\$)		Cost (\$)
		CDF	Population Dose	Baseline (Internal + External)	Baseline With Uncertainty	
<p>Improve Reliability of Vacuum Breakers</p> <p>51 – Install improved vacuum breakers (redundant valves in each line).</p>	<p>Eliminate failure of the vacuum breakers.</p>	1	4	23K	69K	500K
<p>Improve Reliability of Containment Overpressure Relief</p> <p>52 – Provide passive overpressure relief by changing the containment vent valves to “fail open” and improving the strength of the rupture disk.</p> <p>53 – Install an alternate path to the torus hard pipe vent via the wet well using a rupture disk.</p>	<p>Eliminate failure of the hard pipe vent.</p>	7	22	130K	380K	1.0M
<p>Improve Reliability of Debris Barriers</p> <p>70 – Install a curb to prevent debris from spreading across the floor and contacting the shell.</p>	<p>Eliminate the CDF contribution due to failure of the drywall (DW) barriers to prevent debris from contacting the shell.</p>	12	40	230K	680K	840K
<p>Reduce Probability of an Interfacing Systems Loss of Coolant Accident (ISLOCA)</p> <p>54 – Increase frequency of valve leak testing.</p> <p>56 – Revise emergency operating procedures (EOPs) to improve ISLOCA identification.</p> <p>57 – Improve operator training on ISLOCA coping.</p>	<p>Eliminate all ISLOCA initiating events.</p>	<1	1	8.6K	26K	100K 50K 110K
<p>Improve Reliability of MSIVs</p> <p>55 – Improve MSIV design to decrease the likelihood of containment bypass scenarios.</p>	<p>Eliminate failure of the MSIVs to close or remain closed.</p>	<1	0	2.7K	8.2K	1.0M

SAMA	Modeling Assumptions	% Risk Reduction		Total Benefit (\$)		Cost (\$)
		CDF	Population Dose	Baseline (Internal + External)	Baseline With Uncertainty	
Improve Reliability of the Standby Liquid Control (SLC) System	Eliminate the CDF contribution due to failure to initiate SLC and failures due to the boron concentration being too low.	<1	2	12K	37K	>50K
58 – Increase boron concentration in the SLC system.						
Improve Availability of Boron Injection	Eliminate failure of the SLC system.	1	4	22K	67K	>100K
59 – Add an independent boron injection system.						
60 – Provide ability to use the CRD for alternate boron injection.						150K
Improve SRV Rseat Reliability	Eliminate failure of the SRVs to rseat.	1	<1	11K	32K	2.2M
61 – Increase reliability of SRV to rseat after SLC injection.						
Reduce Probability of Internal Flooding						
62 – Improve internal flooding procedures.	Eliminate failure of the operator to implement flood mitigation measures.	2	2	17K	52K	460K
74 – Provide flow diversion to help mitigate the fire water pipe break in the control building ground floor corridor.	Eliminate failure to isolate the large and medium fire water pipe breaks in the control building ground floor corridor.	<1	0	2.0K	6.1K	>100K
Increase Reliability of the Fire Water System	Eliminate failure of the diesel-driven fire pump.	3	2	27K	82K	50K
64 – Proceduralize the use of a fire pumper truck to pressurize the fire water system.						
69 – Upgrade the seismic capacity of the diesel fire pump fuel tank and water supply tank.						>100K
Improve Fire Suppression Capability	Eliminate the fire CDF contribution from critical Switchgear Rooms 1F and 1G.	Not Estimated		120K	350K	375K
63 – Add automatic fire suppression systems to the dominant fire zones.						

Appendix F

SAMA	Modeling Assumptions	% Risk Reduction		Total Benefit (\$)		Cost (\$)
		CDF	Population Dose	Baseline (Internal + External)	Baseline With Uncertainty	
Reduce Risk from Fires that Require Control Room Evacuation 65 – Upgrade the alternate shutdown system (ASDS) panel to include additional system controls for Division 1 equipment.	Eliminate the fire CDF contribution from the main control room.	Not Estimated		110K	340K	790K
Reduce Probability of Large Break LOCA	Eliminate all large break LOCA initiating events.	1	3	19K	58K	
66 – Provide digital large break LOCA protection.						100K
Reduce Frequency of Plant Trips and Shutdowns	Reduce the probability of all initiating events except pipe breaks, floods, and loss of offsite power (LOOP) by a factor of two.	39	35	390K	1.2M	
75 – Include Generation Risk Assessment (trip and shutdown modeling) in plant activities.						500K
Improve Availability of RHRWSW System	Eliminate failure to use the RHRWSW system without a SWBP.	11	10	110K	330K	
79 – Modify procedures to allow use of the RHRWSW system without a service water booster pump (SWBP).						25K
Improve Plant Identification of Reference Leg Leakdowns	Eliminate failure of cognitive recognition of a leakdown of the reference legs.	1	0	5.3K	16K	
80 – Install additional instrumentation to assist in identifying a reference leg leakdown.						>100K

(a) SAMAs in bold are potentially cost-beneficial

(b) In response to an NRC staff RAI, NPPD clarified that SAMA 21 was originally included as a unique SAMA because it was believed that a suitable, existing portable power supply was available to supply the battery chargers (NPPD, 2009a). However, after further investigation, it was determined that the available skid-mounted portable power supply is not sufficient to supply the battery chargers and that a portable power supply would need to be purchased (which is the same as SAMA 13).

(c) Modeling assumption information provided in response to NRC staff RAI 6d (NPPD, 2009a).

(d) SAMA title changed in response to NRC staff RAI 6e (NPPD, 2009a).

1 **F.6. Cost-Benefit Comparison**

2 NPPD's cost-benefit analysis and the NRC staff's review are described in the following sections.

3 **F.6.1. Nebraska Public Power District's Evaluation**

4 The methodology used by NPPD was based primarily on NRC's guidance for performing
5 cost-benefit analysis (i.e., NUREG/BR-0184, *Regulatory Analysis Technical Evaluation*
6 *Handbook*) (NRC, 1997a). The guidance involves determining the net value for each SAMA
7 according to the following formula:

8 Net Value = (APE + AOC + AOE + AOSC) - COE where,

9 APE = present value of averted public exposure (\$)

10 AOC = present value of averted offsite property damage costs (\$)

11 AOE = present value of averted occupational exposure costs (\$)

12 AOSC = present value of averted onsite costs (\$)

13 COE = cost of enhancement (\$)

14 If the net value of a SAMA is negative, the cost of implementing the SAMA is larger than the
15 benefit associated with the SAMA and it is not considered cost-beneficial. NPPD's derivation of
16 each of the associated costs is summarized below.

17 NUREG/BR-0058 has recently been revised to reflect the agency's policy on discount rates.
18 Revision 4 of NUREG/BR-0058 states that two sets of estimates should be developed, one at
19 3 percent and one at 7 percent (NRC, 2004). NPPD provided a base set of results using the
20 7 percent discount rate and a sensitivity study using the 3 percent discount rate (NPPD, 2008).

21 Averted Public Exposure (APE) Costs

22 The APE costs were calculated using the following formula:

23 APE = Annual reduction in public exposure (Δ person-rem per year)

24 x monetary equivalent of unit dose (\$2,000 per person-rem)

25 x present value conversion factor (10.76 based on a 20-year period with a
26 7-percent discount rate)

27 As stated in NUREG/BR-0184 (NRC, 1997a), the monetary value of the public health risk after
28 discounting does not represent the expected reduction in public health risk due to a single
29 accident. Rather, it is the present value of a stream of potential losses extending over the
30 remaining lifetime (in this case, the renewal period) of the facility. Thus, it reflects the expected
31 annual loss due to a single accident, the possibility that such an accident could occur at any
32 time over the renewal period, and the effect of discounting these potential future losses to
33 present value. For the purposes of initial screening, which assumes elimination of all severe
34 accidents caused by internal events, NPPD calculated an APE of approximately \$46,000 for the
35 20-year license renewal period (NPPD, 2008).

1 Averted Offsite Property Damage Costs (AOC)

2 The AOCs were calculated using the following formula:

3 AOC = Annual CDF reduction
4 x offsite economic costs associated with a severe accident (on a
5 per-event basis)
6 x present value conversion factor

7 This term represents the sum of the frequency-weighted offsite economic costs for each release
8 category, as obtained for the Level 3 risk analysis. For the purposes of initial screening, which
9 assumes elimination of all severe accidents caused by internal events, NPPD calculated an
10 annual offsite economic cost of about \$7,000 based on the Level 3 risk analysis. This results in
11 a discounted value of approximately \$75,000 for the 20-year license renewal period
12 (NPPD, 2008).

13 Averted Occupational Exposure (AOE) Costs

14 The AOE costs were calculated using the following formula:

15 AOE = Annual CDF reduction
16 x occupational exposure per core damage event
17 x monetary equivalent of unit dose
18 x present value conversion factor

19 NPPD derived the values for averted occupational exposure from information provided in
20 Section 5.7.3 of the regulatory analysis handbook (NRC, 1997a). Best estimate values provided
21 for immediate occupational dose (3,300 person-rem) and long-term occupational dose
22 (20,000 person-rem over a 10-year cleanup period) were used. The present value of these
23 doses was calculated using the equations provided in the handbook in conjunction with a
24 monetary equivalent of unit dose of \$2,000 per person-rem, a real discount rate of 7 percent,
25 and a time period of 20 years to represent the license renewal period. For the purposes of initial
26 screening, which assumes elimination of all severe accidents caused by internal events, NPPD
27 calculated an AOE of approximately \$4,400 for the 20-year license renewal period
28 (NPPD, 2008).

29 Averted Onsite Costs

30 Averted onsite costs (AOSC) include averted cleanup and decontamination costs and averted
31 power replacement costs. Repair and refurbishment costs are considered for recoverable
32 accidents only and not for severe accidents. NPPD derived the values for AOSC based on
33 information provided in Section 5.7.6 of NUREG/BR-0184, the regulatory analysis handbook
34 (NRC, 1997a).

35 NPPD divided this cost element into two parts – the onsite cleanup and decontamination cost,
36 also commonly referred to as averted cleanup and decontamination costs (ACC), and the
37 replacement power cost.

1 ACC were calculated using the following formula:

$$\begin{aligned}
 &2 \quad \text{ACC} = \text{Annual CDF reduction} \\
 &3 \quad \quad \quad \times \text{present value of cleanup costs per core damage event} \\
 &4 \quad \quad \quad \times \text{present value conversion factor}
 \end{aligned}$$

5 The total cost of cleanup and decontamination subsequent to a severe accident is estimated in
 6 NUREG/BR-0184 to be $\$1.5 \times 10^9$ (undiscounted). This value was converted to present costs
 7 over a 10-year cleanup period and integrated over the term of the proposed license extension.
 8 For the purposes of initial screening, which assumes elimination of all severe accidents caused
 9 by internal events, NPPD calculated an ACC of approximately \$134,000 for the 20-year license
 10 renewal period.

11 Long-term replacement power costs (RPC) were calculated using the following formula:

$$\begin{aligned}
 &12 \quad \text{RPC} = \text{Annual CDF reduction} \\
 &13 \quad \quad \quad \times \text{present value of replacement power for a single event} \\
 &14 \quad \quad \quad \times \text{factor to account for remaining service years for which replacement} \\
 &15 \quad \quad \quad \text{power is required} \\
 &16 \quad \quad \quad \times \text{reactor power scaling factor}
 \end{aligned}$$

17 NPPD based its calculations on the 910 megawatt-electric (MWe) reference plant in
 18 NUREG/BR-0184 (NRC, 1997b), and did not scale down to the 830 MWe rating for CNS-1.
 19 Therefore, NPPD did not apply a power scaling factor to determine the replacement power
 20 costs, which are conservative. For the purposes of initial screening, which assumes elimination
 21 of all severe accidents caused by internal events, NPPD calculated an RPC of approximately
 22 \$91,000 and an AOSC of approximately \$225,000 for the 20-year license renewal period
 23 (NPPD, 2008).

24 Using the above equations, NPPD estimated the total present dollar-value equivalent
 25 associated with completely eliminating severe accidents from internal events at CNS-1 to be
 26 about \$351,000. Use of a multiplier of 3 to account for external events increases the value to
 27 \$1.05M and represents the dollar-value associated with completely eliminating all internal and
 28 external event severe accident risk at CNS-1, also referred to as the Modified Maximum Averted
 29 Cost Risk (MMACR).

30 NPPD's Results

31 If the implementation costs for a candidate SAMA exceeded the calculated benefit, the SAMA
 32 was considered not to be cost-beneficial. In the baseline analysis contained in the ER (using a
 33 7 percent discount rate) NPPD identified eight potentially cost-beneficial SAMAs. The potentially
 34 cost-beneficial SAMAs are:

- 35 • SAMA 25 – Develop procedures to allow bypass of the reactor core
 36 isolation cooling (RCIC) turbine exhaust pressure trip, extending the time
 37 available for RCIC operation.
- 38 • SAMA 30 – Revise procedures to allow manual alignment of the fire water
 39 system to the RHR heat exchangers, providing improved ability to cool the
 40 RHR heat exchangers in a loss of SW.

Appendix F

- 1 • SAMA 33 – Provide for the ability to establish an emergency connection of
2 existing or new water sources to feedwater and condensate systems,
3 increasing availability of feedwater.
- 4 • SAMA 40 – Revise procedures to provide additional space cooling to the
5 EDG room via the use of portable equipment, increasing availability of the
6 EDG.
- 7 • SAMA 45 – Provide an alternate means of supplying the instrument air
8 header, increasing availability of instrument air.
- 9 • SAMA 68 – Revise procedures to allow the ability to cross-connect the
10 circulating water pumps and the SW going to the TEC heat exchangers,
11 allowing continued use of the power conversion system after SW is lost.
- 12 • SAMA 78 – Improve training on alternate injection via the fire water system,
13 increasing the availability of alternate injection.
- 14 • SAMA 79 – Revise procedures to allow use of the RHRSW system without
15 a SW booster pump, increasing availability of the RHRSW system.

16 NPPD performed additional analyses to evaluate the impact of an alternative discount rate
17 (3 percent) and remaining plant life (26 years instead of 20 years) on the results of the SAMA
18 assessment. No additional SAMA candidates were determined to be potentially cost-beneficial
19 (NPPD, 2008).

20 If the benefits are increased by an additional factor of 3 to account for uncertainties, three
21 additional SAMA candidates were determined to be potentially cost-beneficial:

- 22 • SAMA 14 – Provide a portable generator to supply DC power to individual
23 panels during a SBO, increasing the time available for AC power recovery.
- 24 • SAMA 64 – Revise procedures to allow use of a fire pumper truck to
25 pressurize the fire water system, increasing availability of the fire water
26 system.
- 27 • SAMA 75 – Implement GRA (trip and shutdown risk modeling) into plant
28 activities, decreasing the probability of trips/shutdown.

29 The potentially cost-beneficial SAMAs, and NPPD's plans for further evaluation of these SAMAs
30 are discussed in more detail in Section F.6.2.

31 **F.6.2. Review of Nebraska Public Power District's Cost-Benefit Evaluation**

32 The cost-benefit analysis performed by NPPD was based primarily on NUREG/BR-0184
33 (NRC, 1997a) and discount rate guidelines in NUREG/BR-0058 (NRC, 2004) and was executed
34 consistent with this guidance.

35 SAMAs identified primarily on the basis of the internal events analysis could provide benefits in
36 certain external events, in addition to internal events. To account for the additional benefits in

1 external events, NPPD multiplied the internal event benefits by a factor of 3 for each SAMA,
2 except for two SAMAs that specifically address fire risk (SAMAs 63 and 65). Doubling the
3 internal event estimate for SAMAs 63 and 65 would not be appropriate because these SAMAs
4 are specific to fire risks and would not have a corresponding benefit on the risk from internal
5 events. The NRC staff notes that the CNS-1 external events CDF is approximately 200 percent
6 of the internal events CDF from the CNS-1 2007TM PSA model (based on the fire CDF of 1.9×10^{-5}
7 per year, a seismic CDF of 6×10^{-6} per year as estimated by the NRC staff, a negligible
8 HFO contribution, and an internal events CDF of 1.2×10^{-5} per year). Accordingly, the total
9 CDF from internal and external events would be approximately 2.1 times the internal events
10 CDF from the CNS-1 2007 TM PSA model. Because the CDF from internal fires and other
11 external events, as reported by NPPD, is about twice the CDF for internal events, the NRC staff
12 agrees that the factor of 3 multiplier for external events is reasonable.

13 NPPD provided the results of additional sensitivity analyses in the ER, including use of a
14 3 percent discount rate and use of a longer plant life. These analyses did not identify any
15 additional potentially cost-beneficial SAMAs.

16 NPPD considered the impact that possible increases in benefits from analysis uncertainties
17 would have on the results of the SAMA assessment. In the ER, NPPD states that an uncertainty
18 analysis of the internal events CDF resulted in a 95th percentile value that is a factor of
19 1.86 times the mean CDF. The ER further states that an uncertainty factor of 3 was
20 conservatively selected for the uncertainty analysis. The NRC staff asked NPPD to provide the
21 results of the internal events CDF uncertainty analysis and to provide further justification for the
22 use of a factor of 3 for the SAMA uncertainty analysis. In response to the RAI, NPPD provided
23 the results of the internal events CDF, which indicates that the 95th percentile is a factor of
24 $1.86 \times$ the mean CDF as described in the ER. NPPD further clarified that the uncertainty factor
25 of 3 was developed from an earlier version of the uncertainty analysis and that the SAMA
26 analysis was not subsequently updated to avoid rework (NPPD, 2009a). Since the Phase I
27 SAMAs were not screened based on quantitative criteria, a reexamination of the Phase I
28 SAMAs based on the upper bound benefits was not necessary. NPPD considered the impact on
29 the Phase II screening if the estimated benefits were increased by a factor of 3 (in addition to
30 the multiplier of 3 for external events). Three additional SAMAs became cost-beneficial in
31 NPPD's analysis (SAMAs 14, 64, and 75 as described above).

32 The NRC staff noted that SAMA 14, "portable generator for DC power to supply the individual
33 panels," and SAMA 13, "portable generator for DC power to supply the battery chargers," both
34 involve use of a portable generator and requested that NPPD reassess whether or not SAMA 13
35 would be cost-beneficial if it were to use the same portable generator as for SAMA 14, which
36 was determined to be cost beneficial (NRC, 2009). In response, NPPD stated that since the
37 SAMA submittal, SAMA 13 has been implemented at CNS-1 (NPPD, 2009a).

38 The NRC staff also noted that all of the SAMAs considered for basic event
39 PCI-CNT-FF-PREEX, "pre-existing containment failure," involve major hardware modifications.
40 The NRC staff asked NPPD to provide an assessment of lower cost alternatives, such as
41 periodic monitoring of containment integrity during normal operation or procedures to isolate the
42 containment following an event (NRC, 2009). In response to the RAI, NPPD stated that these
43 two specific alternatives have already been implemented at CNS-1 (NPPD, 2009a). NPPD
44 further clarified that basic event PCI-CNT-FF-PREEX represents a preexisting containment
45 failure leading to loss of net positive suction head (NPSH) to the ECCS pumps and that since
46 the CNS-1 containment is inerted during normal operation, a leak large enough to lead to loss of
47 NPSH would require significant nitrogen makeup and would be noticed by the operators.

1 The NRC staff noted that for certain SAMAs considered in the ER, there may be alternatives
2 that could achieve much of the risk reduction at a lower cost. The NRC staff asked the applicant
3 to evaluate several additional lower cost alternatives to the SAMAs considered in the ER,
4 including SAMAs that had been found to be potentially cost-beneficial at other BWR plants.
5 These alternatives were: (1) providing additional space cooling to the RHRSW booster pump
6 rooms, CS pump rooms, RHR pump rooms, SW pump rooms, and HPCI pump room via the use
7 of portable equipment, (2) improving alternate shutdown training and equipment, (3) enhancing
8 DC power availability by providing cables from diesel generators or another source to directly
9 power battery chargers, (4) developing guidance/procedures for local, manual control of reactor
10 core isolation cooling following loss of DC power, and (5) manually venting containment using
11 either a local hand wheel or gas bottle supplies (NRC, 2009). NPPD provided a further
12 evaluation of these alternatives and concluded that each had already been implemented at
13 CNS-1 (NPPD, 2009a).

14 In the ER and in response to an NRC staff RAI, NPPD indicated that detailed engineering
15 project cost-benefit analyses have been initiated for the 11 potentially cost-beneficial SAMAs
16 (NPPD 2008, 2009a).

17 In light of the many potentially cost-beneficial SAMAs identified in the ER, the NRC staff asked
18 NPPD to identify those SAMAs having higher priority for being considered for implementation
19 based on risk reduction potential and implementation cost, and which SAMAs would no longer
20 be cost-beneficial if these higher priority SAMAs were implemented (NRC, 2009). In response to
21 the RAI (NPPD, 2009a), NPPD performed a qualitative assessment to prioritize the
22 cost-beneficial SAMAs. NPPD determined that SAMAs 30, 33, 68, and 79 would have the
23 highest priority based on their potential for significant reduction in risk and relatively low
24 implementation cost. NPPD further identified SAMAs 14, 45, 75, and 78 as a second priority
25 based on their potential for risk reduction and mitigation of plant risk contributors not addressed
26 by SAMAs 30, 33, 68, and 79. The impact of the remaining potentially cost-beneficial SAMAs is
27 expected to be reduced significantly if the higher priority SAMAs are implemented. The NRC
28 considers this approach for prioritizing SAMAs to be reasonable.

29 The NRC staff concludes that, with the exception of the potentially cost-beneficial SAMAs
30 discussed above, the costs of the other SAMAs evaluated would be higher than the associated
31 benefits.

32 **F.7. Conclusions**

33 NPPD compiled a list of 244 SAMAs based on a review of the most significant basic events from
34 the plant-specific PSA, insights from the plant-specific IPE and IPEEE, Phase II SAMAs from
35 license renewal applications for other plants, and review of other NRC and industry
36 documentation. A qualitative screening removed SAMA candidates that (1) modified features
37 not applicable to CNS-1, (2) had already been implemented at CNS-1, or (3) were similar and
38 could be combined with another SAMA. Based on this screening, 164 SAMAs were eliminated
39 leaving 80 candidate SAMAs for evaluation.

40 For the remaining SAMA candidates, a more detailed design and cost estimate were developed
41 as shown in Table F-5. The cost-benefit analyses showed that eight of the SAMA candidates
42 were potentially cost-beneficial in the baseline analysis (Phase II SAMAs 25, 30, 33, 40, 45, 68,
43 78, and 79). NPPD performed additional analyses to evaluate the impact of parameter choices
44 and uncertainties on the results of the SAMA assessment. Three additional SAMAs were
45 identified as potentially cost-beneficial in the ER (Phase II SAMAs 14, 64, and 75). NPPD has

1 indicated that detailed engineering project cost-benefit analyses have been initiated for the 11
2 potentially cost-beneficial SAMAs.

3 The NRC staff reviewed the NPPD analysis and concludes that the methods used and the
4 implementation of those methods were sound. The treatment of SAMA benefits and costs
5 support the general conclusion that the SAMA evaluations performed by NPPD are reasonable
6 and sufficient for the license renewal submittal. Although the treatment of SAMAs for external
7 events was somewhat limited, the likelihood of there being cost-beneficial enhancements in this
8 area was minimized by improvements that have been realized as a result of the IPEEE process,
9 and inclusion of a multiplier to account for external events.

10 The NRC staff concurs with NPPD's identification of areas in which risk can be further reduced
11 in a cost-beneficial manner through the implementation of the identified, potentially
12 cost-beneficial SAMAs. Given the potential for cost-beneficial risk reduction, the NRC staff
13 agrees that further evaluation of these SAMAs by NPPD is warranted. However, these SAMAs
14 do not relate to adequately managing the effects of aging during the period of extended
15 operation. Therefore, they need not be implemented as part of license renewal pursuant to Title
16 10 of the Code of Federal Regulations, Part 54.

17 **F.8. References**

18 American Association of Mechanical Engineers (ASME). 2007. "Standard for Probabilistic Risk
19 Assessment for Nuclear Power Plant Applications." RA-Sc-2007. August 2007.

20 Eklund, Darrel L. et.al. 1999. "Using Water Demand to Determine Population Estimates and
21 Projections for Kansas." June 8, 1999.

22 Electric Power Research Institute (EPRI). 1991. "A Methodology for Assessment of Nuclear
23 Power Plant Seismic Margin." EPRI NP-6041-SL, Revision 1, Palo Alto, CA. August 1991.

24 Electric Power Research Institute (EPRI). 1993. "Fire-Induced Vulnerability Evaluation (FIVE)."
25 EPRI TR-100370, Revision 1, Palo Alto, CA. September 1993.

26 Electric Power Research Institute (EPRI). 1994. "EPRI Fire PRA Implementation Guide."
27 Prepared by Science Applications International Corporation for EPRI, Palo Alto, CA. January
28 1994.

29 Global Insight. 2006. "How Important is Tourism in Kansas? The Tourism Satellite Account
30 Perspective." Kansas Tourism in 2004, prepared by Global Insight. October 3, 2006.

31 Iowa Department of Economic Development (IDED). 2006. "Iowa Tourism Results As of
32 October 1, 2006." Iowa Department of Economic Development Tourism Office.

33 Kaylen, M. 2006. "Economic Impact of Missouri's Tourism and Travel Industry: July 2004–June
34 2005 (FY05)." Executive Summary, MU-Tourism Economics Research Initiative, Columbia,
35 Missouri. May 2006.

36 Kennedy, R. P. (Kennedy). 1999. "Overview of Methods for Seismic PRA and Margin Analysis
37 Including Recent Innovations." Proceedings of the OECD-NEA Workshop of Seismic Risk,
38 Tokyo, Japan. 10–12 August 1999.

39 Missouri. 2007. "Population Projections for Missouri and the U.S." Missouri Census Data
40 Center. Available URL: <http://mcdc2.missouri.edu/trends/projections/shtml> (accessed on June
41 12, 2007).

Appendix F

- 1 Missouri State Emergency Management Agency. 1991. "Evacuation Time Estimate Study
2 Atchison County Missouri." August 1991.
- 3 Nebraska Civil Defense Agency. 1993. "Evacuation Time Estimate Study Nemaha and
4 Richardson Counties Nebraska." January 1993.
- 5 Nebraska Department of Economic Development (NDED). 2006. "2006 Fiscal Year Annual
6 Report, July 1, 2005 - June 30, 2006." Lincoln, Nebraska.
- 7 Nebraska Public Power District (NPPD). 1993. "Generic Letter 88-20, Individual Plant
8 Examination for Severe Accident Vulnerabilities – 10CFR50.54(f), IPE Report Submittal, Cooper
9 Nuclear Station, Docket No. 50-298, DPR-46." March 1993. ADAMS Accession Nos.
10 ML073600192 (Volume 1) and ML073600193 (Volume 2).
- 11 Nebraska Public Power District (NPPD). 1996. "Individual Plant Examination for External Events
12 Report – 10 CFR 50.54(f), Cooper Nuclear Station, NRC Docket No. 50-298, License No.
13 DPR-46." October 1996. ADAMS Accession No. ML073580487.
- 14 Nebraska Public Power District (NPPD). 2008. Cooper Nuclear Station — License Renewal
15 Application, Appendix E: Applicant's Environmental Report, Operating License Renewal Stage.
16 Columbus, Nebraska. September 24, 2008. ADAMS Accession No ML083030246 (main report)
17 and ML083030252 (attachments).
- 18 Nebraska Public Power District (NPPD). 2009a. Letter from Stewart B. Minahan, NPPD to NRC
19 Document Control Desk. Subject: Response to Request for Additional Information for License
20 Renewal Application – Severe Accident Mitigation Alternatives, Cooper Nuclear Station, Docket
21 No. 50-298, DPR-46. July 1, 2009.
- 22 Nebraska Public Power District (NPPD). 2009b. Email from David W. Bremer, NPPD, to Bennett
23 Brady, NRC. Subject: NRC Teleconference to discuss SAMA RAI Follow-up Questions and ER
24 Questions. August 10, 2009.
- 25 Nebraska Public Power District (NPPD). 2009c. Letter from NPPD, SAMA Meteorological
26 Anomaly Related to the Cooper Nuclear Station License Renewal Application, December 7,
27 2009. (ADAMS Accession No. 093490997)
- 28 Nuclear Energy Institute (NEI). 2007. "Process for Performing Follow-on PRA Peer Reviews
29 Using the ASME PRA Standard." NEI 05-04, Rev. 1 (Draft G). November 2007.
- 30 Seismic Qualification Users Group (SQUG). 1992. "Generic Implementation Procedure (GIP) for
31 Seismic Verification of Nuclear Plant Equipment." Revision 2, Corrected. February 14, 1992.
- 32 University of Nebraska (UN). 2007. "Business in Nebraska Population Projection." University of
33 Nebraska Bureau of Business Research. Available URL: <http://www.bbr.unl.edu/PopProjections/>
34 (accessed on June 20, 2007).
- 35 U.S. Department of Agriculture (USDA). 2002. "2002 Census of Agriculture." National
36 Agriculture Statistics Service. Available URL:
37 http://www.nass.usda.gov/Census_of_Agriculture/index.asp (accessed on June 2007).
- 38 U. S. Geologic Survey (USGS). 2008. "2008 NSHM Gridded Data, Peak Ground Acceleration."
39 Available URL: <http://earthquake.usgs.gov/hazards/products/conterminous/2008/data/>
- 40 U.S. Nuclear Regulatory Commission (NRC). 1988. Generic Letter 88-20, "Individual Plant
41 Examination for Severe Accident Vulnerabilities." November 23, 1988.
- 42 U.S. Nuclear Regulatory Commission (NRC). 1990. *Severe Accident Risks: An Assessment for
43 Five U.S. Nuclear Power Plants*. NUREG-1150, Washington, D.C. December 1990.

- 1 U.S. Nuclear Regulatory Commission (NRC). 1991. Generic Letter No. 88-20, Supplement 4,
2 *Individual Plant Examination of External Events for Severe Accident Vulnerabilities*.
3 NUREG-1407, Washington, D.C. June 28, 1991.
- 4 U.S. Nuclear Regulatory Commission (NRC). 1996. Letter from David L. Wigginton, U.S. NRC,
5 to Guy R. Horn, NPPD. Subject: Cooper Nuclear Station – Individual Plant Examination (IPE) for
6 Internal Events (TAC No. M74400), Washington, D.C. February 14, 1996.
- 7 U.S. Nuclear Regulatory Commission (NRC). 1997a. *Regulatory Analysis Technical Evaluation*
8 *Handbook*. NUREG/BR-0184, Washington, D.C. January 1997.
- 9 U.S. Nuclear Regulatory Commission (NRC). 1997b. *Individual Plant Examination Program:*
10 *Perspectives on Reactor Safety and Plant Performance*. NUREG-1560, Washington, D.C.
11 December 1997.
- 12 U.S. Nuclear Regulatory Commission (NRC). 1997c. *Code Manual for MACCS2: Volume 1,*
13 *User's Guide*. NUREG/CR-6613, Washington, D.C. May 1998.
- 14 U.S. Nuclear Regulatory Commission (NRC). 1999. Letter from Lawrence Burkhardt, U.S. NRC,
15 to G.R. Horn, NPPD. Subject: Plant-Specific Safety Evaluation Report for USI A-46 Program
16 Implementation at Cooper Nuclear Station (TAC No. M69439). Washington, D.C. September 30,
17 1999.
- 18 U.S. Nuclear Regulatory Commission (NRC). 2001. “Cooper Nuclear Station – Review of
19 Individual Plant Examination of External Events (TAC No. 83611).” Washington, D.C. April 27,
20 2001.
- 21 U.S. Nuclear Regulatory Commission (NRC). 2002. *Perspectives Gained From the Individual*
22 *Plant Examination of External Events*. NUREG-1742, Vols. 1 & 2, Final Report, Washington
23 D.C. April 2002.
- 24 U.S. Nuclear Regulatory Commission (NRC). 2004. *Regulatory Analysis Guidelines of the U.S.*
25 *Nuclear Regulatory Commission*. NUREG/BR-0058, Rev. 4, Washington, D.C. September 2004.
- 26 U.S. Nuclear Regulatory Commission (NRC). 2007. “An Approach for Determining the Technical
27 Adequacy of Probabilistic Risk Assessment Results for Risk-Informed Activities.” Regulatory
28 Guide 1.200, Rev. 1, Washington, D.C. January 2007.
- 29 U.S. Nuclear Regulatory Commission (NRC). 2009. Letter from Tam Tran, U.S. NRC, to Stewart
30 B. Minahan, NPPD. Subject: Request for Additional Information for the Review of the Cooper
31 Nuclear Station License Renewal Application (TAC Nos. MD9763 and MD9737), Washington,
32 D.C. June 8, 2009. ADAMS Accession No. ML091530316.
- 33 Woods & Poole. 2006. “2006 State Profile: Iowa.” Woods & Poole Economics, Inc.

BIBLIOGRAPHIC DATA SHEET

(See instructions on the reverse)

NUREG-1437, Supplement 41

2. TITLE AND SUBTITLE

Generic Environmental Impact Statement for License Renewal of Nuclear Plants (GEIS)
Supplement 41
Regarding Cooper Nuclear Station, Unit 1
Draft Report

3. DATE REPORT PUBLISHED

MONTH

YEAR

February

2010

4. FIN OR GRANT NUMBER

5. AUTHOR(S)

See Chapter 10 of report

6. TYPE OF REPORT

Technical

7. PERIOD COVERED (Inclusive Dates)

8. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC, provide Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)

Division of License Renewal
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC, type "Same as above"; if contractor, provide NRC Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address.)

Same as 8 above

10. SUPPLEMENTARY NOTES

Docket Number 50-298

11. ABSTRACT (200 words or less)

This supplemental environmental impact statement (SEIS) has been prepared in response to an application submitted by Nebraska Public Power District (NPPD) to the Nuclear Regulatory Commission (NRC) to renew the Operating License for Cooper Nuclear Station, Unit 1 (CNS-1), for an additional 20 years under 10 CFR Part 54. The SEIS includes the NRC staff's analysis that considers and weighs the environmental impacts of the proposed action, the environmental impacts of alternatives to the proposed action, and mitigation measures available for reducing or avoiding adverse impacts. It also includes the staff's recommendation regarding the proposed action.

The NRC staff's preliminary recommendation is that the Commission determine that the adverse environmental impacts of license renewal for CNS-1 are not so great that preserving the option of license renewal for energy-planning decision makers would be unreasonable. The recommendation is based on (1) the analysis and findings in the GEIS; (2) the Environmental Report submitted by NPPD; (3) consultation with Federal, State, and local agencies; (4) the staff's own independent review; and (5) the staff's consideration of public comments.

12. KEY WORDS/DESCRIPTORS (List words or phrases that will assist researchers in locating the report.)

Cooper Nuclear Station, Unit 1
NPPD
Nebraska Public Power District
Supplement to the Generic Environmental Impact Statement
DSEIS
National Environmental Policy Act
NEPA
License Renewal
GEIS
NUREG 1437, Supplement 41

13. AVAILABILITY STATEMENT

unlimited

14. SECURITY CLASSIFICATION

(This Page)

unclassified

(This Report)

unclassified

15. NUMBER OF PAGES

16. PRICE



Federal Recycling Program