

Generic Environmental Impact Statement for License Renewal of Nuclear Plants

Supplement 41

Regarding Cooper Nuclear Station

Final Report

AVAILABILITY OF REFERENCE MATERIALS IN NRC PUBLICATIONS

NRC Reference Material

As of November 1999, you may electronically access NUREG-series publications and other NRC records at NRC's Public Electronic Reading Room at <http://www.nrc.gov/reading-rm.html>.

Publicly released records include, to name a few, NUREG-series publications; *Federal Register* notices; applicant, licensee, and vendor documents and correspondence; NRC correspondence and internal memoranda; bulletins and information notices; inspection and investigative reports; licensee event reports; and Commission papers and their attachments.

NRC publications in the NUREG series, NRC regulations, and *Title 10, Energy*, in the Code of *Federal Regulations* may also be purchased from one of these two sources.

1. The Superintendent of Documents
U.S. Government Printing Office
Mail Stop SSOP
Washington, DC 20402-0001
Internet: bookstore.gpo.gov
Telephone: 202-512-1800
Fax: 202-512-2250
2. The National Technical Information Service
Springfield, VA 22161-0002
www.ntis.gov
1-800-553-6847 or, locally, 703-605-6000

A single copy of each NRC draft report for comment is available free, to the extent of supply, upon written request as follows:

Address: U.S. Nuclear Regulatory Commission
Office of Administration
Reproduction and Mail Services Branch
Washington, DC 20555-0001

E-mail: DISTRIBUTION@nrc.gov

Facsimile: 301-415-2289

Some publications in the NUREG series that are posted at NRC's Web site address <http://www.nrc.gov/reading-rm/doc-collections/nuregs> are updated periodically and may differ from the last printed version. Although references to material found on a Web site bear the date the material was accessed, the material available on the date cited may subsequently be removed from the site.

Non-NRC Reference Material

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, and transactions, *Federal Register* notices, Federal and State legislation, and congressional reports. Such documents as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings may be purchased from their sponsoring organization.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at—

The NRC Technical Library
Two White Flint North
11545 Rockville Pike
Rockville, MD 20852-2738

These standards are available in the library for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from—

American National Standards Institute
11 West 42nd Street
New York, NY 10036-8002
www.ansi.org
212-642-4900

Legally binding regulatory requirements are stated only in laws; NRC regulations; licenses, including technical specifications; or orders, not in NUREG-series publications. The views expressed in contractor-prepared publications in this series are not necessarily those of the NRC.

The NUREG series comprises (1) technical and administrative reports and books prepared by the staff (NUREG-XXXX) or agency contractors (NUREG/CR-XXXX), (2) proceedings of conferences (NUREG/CP-XXXX), (3) reports resulting from international agreements (NUREG/IA-XXXX), (4) brochures (NUREG/BR-XXXX), and (5) compilations of legal decisions and orders of the Commission and Atomic and Safety Licensing Boards and of Directors' decisions under Section 2.206 of NRC's regulations (NUREG-0750).



NUREG-1437
Supplement 41

Generic Environmental Impact Statement for License Renewal of Nuclear Plants

Supplement 41

Regarding Cooper Nuclear Station

Final Report

Manuscript Completed: July 2010
Date Published: July 2010

ABSTRACT

This supplemental environmental impact statement (SEIS) has been prepared in response to an application submitted by Nebraska Public Power District (NPPD) to renew the operating license for Cooper Nuclear Station for an additional 20 years.

This SEIS includes the analysis that evaluates the environmental impacts of the proposed action and alternatives to the proposed action. Alternatives considered include replacement power from new supercritical coal-fired generation; natural gas combined-cycle generation; a combination of alternatives that includes natural gas combined-cycle generation, energy conservation, and wind; and not renewing the license (the no-action alternative).

The recommendation is that the U.S. Nuclear Regulatory Commission (NRC) determines that the adverse environmental impacts of license renewal for Cooper Nuclear Station are not so great that preserving the option of license renewal for energy-planning decision makers would be unreasonable.

TABLE OF CONTENTS

Abstract	iii
Table of Contents.....	v
Figures	xi
Tables	xii
Executive Summary	xv
Abbreviations and Acronyms	xxiii
1.0 Purpose and Need for Action.....	1-1
1.1 Proposed Federal Action.....	1-1
1.2 Purpose and Need for the Proposed Federal Action.....	1-1
1.3 Major Environmental Review Milestones.....	1-1
1.4 Generic Environmental Impact Statement.....	1-4
1.5 Supplemental Environmental Impact Statement	1-6
1.6 Cooperating Agencies	1-6
1.7 Consultations.....	1-6
1.8 Correspondence.....	1-7
1.9 Status of Compliance	1-9
1.10 References	1-11
2.0 Affected Environment.....	2-1
2.1 Facility Description	2-1
2.1.1 Reactor and Containment Systems.....	2-1
2.1.2 Radioactive Waste Management.....	2-5
2.1.2.1 Radioactive Liquid Waste.....	2-6
2.1.2.2 Radioactive Gaseous Waste.....	2-6
2.1.2.3 Radioactive Solid Waste	2-7
2.1.3 Nonradiological Waste Management.....	2-8
2.1.3.1 Nonradioactive Waste Streams.....	2-8
2.1.3.2 Pollution Prevention and Waste Minimization	2-9
2.1.4 Plant Operation and Maintenance	2-10
2.1.5 Power Transmission System	2-10
2.1.6 Cooling and Auxiliary Water Systems.....	2-12
2.1.7 Facility Water Use and Quality	2-17
2.1.7.1 Ground Water Use and Quality	2-17
2.1.7.2 Surface Water Use and Quality.....	2-18
2.1.7.3 National Pollutant Discharge Elimination System	2-19
2.1.7.4 Dredging.....	2-20
2.2 Surrounding Environment.....	2-20
2.2.1 Land Use	2-21
2.2.2 Climate and Meteorology.....	2-23
2.2.2.1 Air Quality Impacts.....	2-24
2.2.3 Ground Water Resources	2-25
2.2.4 Surface Water Resources.....	2-25
2.2.5 Description of Aquatic Resources.....	2-26

Table of Contents

2.2.5.1	Ecosystem Services Provided by Missouri River Aquatic Ecosystems.....	2-26
2.2.5.2	Conceptual Model of Midwestern Rivers.....	2-27
2.2.5.3	Description of the Missouri River Basin	2-28
2.2.5.4	Physical Features of the Missouri River near the Cooper Nuclear Station	2-30
2.2.5.5	Potentially Affected Aquatic Resources	2-31
2.2.5.6	Primary Producers: Phytoplankton, Periphyton, and Aquatic Macrophytes	2-31
2.2.5.7	Invertebrates: Zooplankton and Benthos	2-32
2.2.5.8	Larval Fish.....	2-34
2.2.5.9	Fish	2-35
2.2.6	Terrestrial Resources	2-36
2.2.7	Protected Species.....	2-39
2.2.7.1	Aquatic Species	2-49
2.2.7.2	Terrestrial Species	2-52
2.2.8	Socioeconomic Factors	2-56
2.2.8.1	Housing.....	2-57
2.2.8.2	Public Services.....	2-58
2.2.8.3	Offsite Land Use	2-62
2.2.8.4	Visual Aesthetics and Noise.....	2-63
2.2.8.5	Demography.....	2-64
2.2.8.6	Economy	2-70
2.2.9	Historic and Archaeological Resources	2-73
2.2.9.1	Cultural Background.....	2-73
2.2.9.2	Prehistoric Periods	2-73
2.2.9.3	Historic Period.....	2-74
2.2.10	Historic and Archaeological Resources at the Cooper Nuclear Station Site	2-75
2.3	Related Federal and State Activities	2-76
2.4	References	2-77
3.0	Environmental Impacts of Refurbishment	3-1
3.1	References	3-3
4.0	Environmental Impacts of Operation.....	4-1
4.1	Land Use	4-1
4.2	Air Quality	4-1
4.3	Ground Water	4-2
4.3.1	Generic Ground Water Issues	4-2
4.3.2	Ground Water Use Conflicts	4-2
4.4	Surface Water	4-3
4.4.1	Generic Surface Water Issues.....	4-3
4.4.2	Water Use Conflicts	4-4
4.5	Aquatic Resources	4-4
4.5.1	Generic Aquatic Ecology Issues	4-5
4.5.2	Entrainment and Impingement.....	4-5
4.5.2.1	Introduction	4-5
4.5.2.2	History of Cooper Nuclear Station's 316(b) Compliance.....	4-6
4.5.2.3	Analysis.....	4-7
4.5.3	Thermal Effects.....	4-9
4.5.4	Total Impacts on Aquatic Resources	4-10
4.6	Terrestrial Resources	4-11
4.7	Threatened and Endangered Species.....	4-12

Table of Contents

4.7.1	Aquatic Species	4-12
4.7.2	Terrestrial Species	4-13
4.8	Human Health	4-14
4.8.1	Generic Human Health Issues	4-15
4.8.2	Microbiological Organisms	4-16
4.8.3	Electromagnetic Fields – Acute Shock	4-18
4.8.4	Electromagnetic Fields – Chronic Effects	4-18
4.9	Socioeconomics	4-19
4.9.1	Generic Socioeconomic Issues	4-19
4.9.2	Housing Impacts	4-20
4.9.3	Public Services: Public Utilities	4-20
4.9.4	Offsite Land Use – License Renewal Period	4-21
4.9.4.1	Population-Related Impacts	4-21
4.9.4.2	Tax Revenue-Related Impacts	4-21
4.9.5	Public Services: Transportation Impacts	4-22
4.9.6	Historic and Archaeological Resources	4-22
4.9.7	Environmental Justice	4-24
4.9.7.1	Minority Population in 2000	4-26
4.9.7.2	Low-Income Population in 2000	4-28
4.9.7.3	Analysis of Impacts	4-32
4.9.7.4	Subsistence Consumption of Fish and Wildlife	4-32
4.10	Evaluation of New and Potentially Significant Information	4-34
4.11	Cumulative Impacts	4-35
4.11.1	Cumulative Impacts on Water Resources	4-35
4.11.2	Cumulative Impacts on Electromagnetic Fields and Thermophilic Microbiological Organisms	4-36
4.11.3	Cumulative Impacts on Aquatic Resources	4-37
4.11.4	Cumulative Impacts on Terrestrial Resources	4-40
4.11.5	Cumulative Air Quality Impacts	4-43
4.11.6	Cumulative Human Health Impacts	4-45
4.11.7	Cumulative Socioeconomic Impacts	4-45
4.11.8	Summary of Cumulative Impacts	4-46
4.12	References	4-48
5.0	Environmental Impacts of Postulated Accidents	5-1
5.1	Design-Basis Accidents	5-1
5.2	Severe Accidents	5-2
5.3	Severe Accident Mitigation Alternatives	5-3
5.3.1	Introduction	5-3
5.3.2	Estimate of Risk	5-4
5.3.3	Potential Plant Improvements	5-5
5.3.4	Evaluation of Risk Reduction and Costs of Improvements	5-5
5.3.5	Cost-Benefit Comparison	5-6
5.3.6	Conclusions	5-7
5.4	References	5-8
6.0	Environmental Impacts of the Uranium Fuel Cycle, Solid Waste Management and Greenhouse Gas Emissions	6-1
6.1	The Uranium Fuel Cycle	6-1
6.2	Greenhouse gas emissions	6-2
6.2.1	Existing Studies	6-3

Table of Contents

6.2.1.1 Qualitative Studies6-3

6.2.1.2 Quantitative6-3

6.2.1.3 Summary of Nuclear Greenhouse Gas Emissions Compared to Coal6-5

6.2.1.4 Summary of Nuclear Greenhouse Gas Emissions Compared to
Natural Gas.....6-6

6.2.1.5 Summary of Nuclear Greenhouse Gas Emissions Compared to
Renewable Energy Sources6-6

6.2.2 Conclusions: Relative Greenhouse Gas Emissions6-8

6.3 References6-9

7.0 Environmental Impacts of Decommissioning7-1

7.1 Decommissioning7-1

7.2 References7-2

8.0 Environmental Impacts of Alternatives8-1

8.1 Supercritical Coal-Fired Generation8-3

8.1.1 Air Quality8-4

8.1.1.1 Sulfur Oxides.....8-5

8.1.1.2 Nitrogen Oxides8-6

8.1.1.3 Particulates8-6

8.1.1.4 Carbon Monoxide.....8-6

8.1.1.5 Carbon Dioxide8-7

8.1.1.6 Summary of Air Quality8-7

8.1.2 Ground Water Use and Quality.....8-7

8.1.3 Surface Water Use and Quality8-7

8.1.4 Aquatic and Terrestrial Ecology.....8-8

8.1.4.1 Aquatic Ecology8-8

8.1.4.2 Terrestrial Ecology8-8

8.1.5 Human Health.....8-9

8.1.6 Socioeconomics.....8-9

8.1.6.1 Land Use.....8-9

8.1.6.2 Socioeconomics8-10

8.1.6.3 Transportation8-10

8.1.6.4 Aesthetics.....8-11

8.1.6.5 Historic and Archaeological Resources8-11

8.1.6.6 Environmental Justice8-12

8.1.7 Waste Management.....8-12

8.2 Natural Gas-Fired Combined-Cycle Generation.....8-13

8.2.1.1 Air Quality.....8-14

8.2.1.2 Sulfur and Nitrogen Oxides8-15

8.2.1.3 Particulates8-15

8.2.1.4 Hazardous Air Pollutants.....8-15

8.2.1.5 Construction Impacts8-15

8.2.2 Ground Water Use and Quality.....8-16

8.2.3 Surface Water Use and Quality8-16

8.2.4 Aquatic and Terrestrial Ecology.....8-16

8.2.4.1 Aquatic Ecology8-16

8.2.4.2 Terrestrial Ecology8-16

8.2.5 Human Health.....8-17

8.2.6 Socioeconomics.....8-17

8.2.6.1 Land Use.....8-17

Table of Contents

8.2.6.2	Socioeconomics	8-18
8.2.6.3	Transportation	8-19
8.2.6.4	Aesthetics	8-19
8.2.6.5	Historic and Archaeological Resources	8-19
8.2.6.6	Environmental Justice	8-20
8.2.7	Waste Management.....	8-20
8.3	Combination Alternative	8-21
8.3.1	Air Quality	8-21
8.3.2	Ground Water Use and Quality.....	8-23
8.3.3	Surface Water Use and Quality	8-23
8.3.4	Aquatic and Terrestrial Ecology.....	8-24
8.3.4.1	Aquatic Ecology	8-24
8.3.4.2	Terrestrial Ecology	8-24
8.3.5	Human Health.....	8-25
8.3.6	Socioeconomics.....	8-25
8.3.6.1	Land Use.....	8-25
8.3.6.2	Socioeconomics	8-26
8.3.6.3	Transportation	8-27
8.3.6.4	Aesthetics.....	8-27
8.3.6.5	Historic and Archaeological Resources	8-28
8.3.6.6	Environmental Justice	8-28
8.3.7	Waste Management.....	8-29
8.4	Alternatives Considered but Dismissed.....	8-30
8.4.1	Offsite Coal- and Gas-Fired Capacity.....	8-30
8.4.2	Coal-Fired Integrated Gasification Combined-Cycle	8-30
8.4.3	New Nuclear	8-30
8.4.4	Energy Conservation and Energy Efficiency	8-31
8.4.5	Purchased Power	8-31
8.4.6	Solar Power.....	8-31
8.4.7	Biomass Waste.....	8-32
8.4.8	Hydroelectric Power.....	8-32
8.4.9	Wave and Ocean Energy.....	8-32
8.4.10	Geothermal Power.....	8-33
8.4.11	Municipal Solid-Waste	8-33
8.4.12	Biofuels.....	8-33
8.4.13	Oil-Fired Power.....	8-34
8.4.14	Fuel Cells.....	8-34
8.4.15	Delayed Retirement.....	8-34
8.5	No-Action Alternative.....	8-34
8.5.1	Air Quality	8-35
8.5.2	Ground Water Use and Quality.....	8-35
8.5.3	Surface Water Use and Quality	8-35
8.5.4	Aquatic and Terrestrial Resources	8-36
8.5.4.1	Aquatic Ecology	8-36
8.5.4.2	Terrestrial Ecology	8-36
8.5.5	Human Health.....	8-36
8.5.6	Socioeconomics.....	8-36
8.5.6.1	Land Use.....	8-36
8.5.6.2	Socioeconomics	8-36
8.5.6.3	Transportation	8-36
8.5.6.4	Aesthetics.....	8-37

Table of Contents

8.5.6.5 Historic and Archaeological Resources8-37

8.5.6.6 Environmental Justice8-37

8.5.7 Waste Management.....8-37

8.6 Alternatives Summary8-37

8.7 References8-39

9.0 Conclusion9-1

9.1 Environmental Impacts of License Renewal.....9-1

9.2 Comparison of Environmental Impacts of License Renewal and Alternatives9-2

9.3 Resource Commitments.....9-2

9.1.1 Unavoidable Adverse Environmental Impacts.....9-2

9.1.2 The Relationship between Local Short-Term Uses of the Environment and
the Maintenance and Enhancement of Long-Term Productivity9-3

9.1.3 Irreversible and Irretrievable Commitments of Resources.....9-3

9.4 Recommendations9-4

10.0 List of Preparers.....10-1

11.0 Index11-1

12.0 List of Agencies, Organizations, and Persons to Whom Copies of the
Supplemental Environmental Impact Statement are Sent12-1

Appendix A. Comments Received on the Cooper Nuclear Station Environmental
Review A-1

Appendix B. National Environmental Policy Act Issues for License Renewal of Nuclear
Power Plants B-1

Appendix C. Applicable Regulations, Laws, and Agreements C-1

Appendix D. Consultation Correspondences D-1

Appendix D.2 Biological Assessment Cooper Nuclear Station License Renewal Date
2009 Docket No. 50-298 U.S. Nuclear Regulatory Commission Rockville,
Maryland D.2-1

Appendix E. Chronology of Environmental Review E-1

Appendix F. U.S. Nuclear Regulatory Commission Staff Evaluation of Severe Accident
Mitigation Alternatives for Cooper Nuclear Station In Support of License Renewal
Application Review..... F-1

FIGURES

Figure 1-1. Environmental Review Process	1-3
Figure 1-2. Environmental Issues Evaluated During License Renewal	1-5
Figure 2.1-1. Location of Cooper Nuclear Station, 50-mile (80-kilometer) Region	2-2
Figure 2.1-2. Location of Cooper Nuclear Station, 6-mile (10-kilometer) Region	2-3
Figure 2.1-3. Cooper Nuclear Station, General Site Layout	2-4
Figure 2.1.5-1. Cooper Nuclear Station Transmission Line Corridor	2-12
Figure 2.1.6-1. Cooper Nuclear Station, Intake Structure Plan.....	2-14
Figure 2.1.6-2. Cooper Nuclear Station, Intake Structure Section	2-15
Figure 2.1.6-3. Cooper Nuclear Station, Typical Dual Flow Screen	2-16
Figure 2.2.1-1. Cooper Nuclear Station Facility Location	2-21
Figure 2.2.1-2. Cooper Nuclear Station, Site Boundary Map.....	2-22
Figure 2.2.5-1. Conceptual model showing primary external and internal variables with their interactions that govern the integrity of the aquatic biota of Midwestern streams.....	2-28
Figure 2.2.6-1. Nontidal Wetlands Located on the Cooper Nuclear Station Site	2-37
Figure 4-1. Minority Blocks in 2000 within a 50-Mile Radius of Cooper Nuclear Station (Individual State).....	4-27
Figure 4-2. Minority Blocks in 2000 within a 50-Mile Radius of Cooper Nuclear Station (Combined State).....	4-28
Figure 4-3. Low-Income Block Groups with a 50-Mile Radius of Cooper Nuclear Station (Individual State).....	4-30
Figure 4-4. Low-Income Block with a 50-Mile Radius of Cooper Nuclear Station (Combined State).....	4-31
Figure 3-1. Location of Cooper Nuclear Station, 50-mile (80-kilometer) Region	D.2-2
Figure 3-2. Location of Cooper Nuclear Station, 6-miles (10-kilometer) Region	D.2-3
Figure 3-3. Cooper Nuclear Station, General Site Layout	D.2-5
Figure 3-4. Cooper Nuclear Station, Intake Structure Plan.....	D.2-7
Figure 3-5. Cooper Nuclear Station, Intake Structure Section	D.2-7
Figure 3-6. Cooper Nuclear Station, Typical Dual Flow Screen	D.2-8

TABLES

Summary of Environmental Impacts of Proposed Action and Alternatives	xxi
Table 1-1. Licenses and Permits	1-10
Table 2.1.7-1. Effluent Limitations (mg/L) – National Pollutant Discharge Elimination System Permit for Cooper Nuclear Station	2-19
Table 2.2.7-1. Listed Aquatic and Terrestrial Species	2-40
Table 2.2.8-1. Cooper Nuclear Station Employee Residence by County	2-57
Table 2.2.8.1-1. Housing in Nemaha, Otoe, and Richardson Counties in Nebraska and Atchison County in Missouri	2-58
Table 2.2.8.2-1. Public Water Supply Systems (thousand gallons per day)	2-60
Table 2.2.8.2-2. Major Commuting Routes in the Vicinity of Cooper Nuclear Station in 2006 Average Annual Daily Traffic Count.....	2-62
Table 2.2.8.5-1. Population and Percent Growth in Nemaha, Otoe, and Richardson Counties, Nebraska, and Atchison County, Missouri, from 1970 to 2000 and Projected for 2007 to 2050	2-64
Table 2.2.8.5-2. Demographic Profile of the Population in the Cooper Nuclear Station Four-County Socioeconomic Region of Influence in 2000.....	2-65
Table 2.2.8.5-3. Demographic Profile of the Population in the Cooper Nuclear Station Four-County Socioeconomic Region of Influence in 2007, Estimated.....	2-66
Table 2.2.8.5-4. Seasonal Housing in Counties Located within 50 Miles of the Cooper Nuclear Station	2-67
Table 2.2.8.5-5. Migrant Farm Workers and Temporary Farm Labor in Counties Located within 50 Miles of the Cooper Nuclear Station	2-69
Table 2.2.8.6-1. Major Employers in Nemaha County	2-70
Table 2.2.8.6-2. Estimated Income Information for the Cooper Nuclear Station Region of Influence in 2007	2-71
Table 2.2.8.6-3. Cooper Nuclear Station Estimated Tax Distribution, 2005–2007	2-72
Table 3-1. Category 1 Issues for Refurbishment Evaluation	3-2
Table 3-2. Category 2 Issues for Refurbishment Evaluation	3-2
Table 4-1. Land Use Issues	4-1
Table 4-2. Category 1 Surface Water Issues.....	4-3
Table 4-3. Aquatic Resources Issues	4-5
Table 4-4. Terrestrial Resources Issues	4-12
Table 4-5. Human Health Issues	4-14
Table 4-6. Category 1 Issues Applicable to Socioeconomics during the Renewal Term.....	4-19
Table 4-7. Category 2 Issues Applicable to Socioeconomics and Environmental Justice During the Renewal Term.....	4-20
Table 4-8. Intakes	4-39
Table 4-9. Stastny 2004.....	4-40
Table 4-10. Summary of Cumulative Impacts on Resources Areas	4-46
Table 5-1. Cooper Nuclear Station, Core Damage Frequency for Internal Events.....	5-4
Table 5-2. Breakdown of Population Dose by Containment Release Mode	5-5
Table 6-1. Issues Related to the Uranium Fuel Cycle and Solid Waste Management	6-2
Table 6-2. Nuclear Greenhouse Gas Emissions Compared to Coal	6-5
Table 6-3. Nuclear Greenhouse Gas Emissions Compared to Natural Gas.....	6-6
Table 6-4. Nuclear Greenhouse Gas Emissions Compared to Renewable Energy Sources.....	6-7
Table 7-1. Category 1 Issues Applicable to the Decommissioning of Cooper Nuclear Station Following the Renewal Term	7-1

Table of Contents

Table 8-1. Summary of Environmental Impacts of the Supercritical Coal-Fired Alternative Compared to Continued Operation of Cooper Nuclear Station.....8-13

Table 8-2. Summary of Environmental Impacts of the Natural Gas-Fired, Combined-Cycle Generation Alternative Compared to Continued Operation of Cooper Nuclear Station.....8-21

Table 8-3. Summary of Environmental Impacts of the Combination Alternative Compared to Continued Operation of Cooper Nuclear Station8-29

Table 8-4. Summary of Environmental Impacts of No Action Compared to Continued Operation of Cooper Nuclear Station.....8-37

Table 8-5. Summary of Environmental Impacts of Proposed Action and Alternatives.....8-38

Table 10-1. List of Preparers 10-1

Table A-1. Commenters on the Scope of the Environmental Review A-2

Table A-2. Structures and Operations of Cooper and Fort Calhoun Generating Stations That Affect Aquatic Resources A-50

Table B-1. Summary of Issues and Findings B-1

Table C-1. Federal Environmental Requirements..... C-2

Table D-1. Consultation Correspondences D-1

Table F-1. Cooper Nuclear Station Core Damage Frequency for Internal Events..... F-3

Table F-2. Breakdown of Population Dose by Containment Release Mode..... F-4

Table F-3. Cooper Nuclear Station Probabilistic Safety Assessment Historical Summary F-5

Table F-4. Cooper Nuclear Station Fire Compartments and Their Contributions to Fire Core Damage Frequency F-8

Table F-5. Severe Accident Mitigation Alternatives Cost/Benefit Screening Analysis for Cooper Nuclear Station F-21

EXECUTIVE SUMMARY

BACKGROUND

By letter dated September 24, 2008, Nebraska Public Power District (NPPD) submitted an application to the U.S. Nuclear Regulatory Commission (NRC) to issue a renewed operating license for Cooper Nuclear Station (CNS), for an additional 20-year period.

Pursuant to Title 10, Part 51.20(b)(2) of the *Code of Federal Regulations* (10 CFR 51.20(b)(2)), the Commission indicates that a renewal of a power reactor operating license requires preparation of an environmental impact statement (EIS) or a supplement to an existing EIS. In addition, 10 CFR 51.95(c) states that the Commission shall prepare an EIS, which is a supplement to the Commission's *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437, published in May 1996.

Upon acceptance of NPPD's application, the NRC staff began the environmental review process described in 10 CFR Part 51 by publishing a Notice of Intent to prepare a supplemental environmental impact statement (SEIS) and conduct scoping. In preparation of this SEIS for CNS, the NRC staff performed the following:

- conducted public scoping meetings on February 25, 2009, in Brownville and Auburn, NE
- conducted a site audit at the plant in late March 2009
- reviewed NPPD's environmental report (ER) and compared it to the GEIS
- consulted with other agencies
- conducted a review of the issues following the guidance set forth in NUREG-1555, *Standard Review Plans for Environmental Reviews for Nuclear Power Plants, Supplement 1: Operating License Renewal* (NRC, 2000)
- considered public comments received during the scoping process

PROPOSED ACTION

NPPD initiated the proposed Federal action—issuing a renewed power reactor operating license—by submitting an application for license renewal of CNS, for which the existing license DPR-46 will expire on January 18, 2014. The NRC's Federal action is the decision whether or not to renew the license for an additional 20 years.

PURPOSE AND NEED FOR ACTION

The purpose and need for the proposed action (issuance of a renewed license) is to provide an option that allows for power generation capability beyond the term of the current nuclear power plant operating license, and to meet future system generating needs, as determined by State, utility, and, where authorized, Federal (other than NRC) decision makers. This definition of purpose and need for action reflects the recognition that, unless there are findings in the safety review required by the Atomic Energy Act of 1954 (AEA) or findings in the National Environmental Policy Act (NEPA) environmental analysis that would lead to the rejection of a license renewal application, the NRC does not have a role in the energy-planning decisions of State regulators and utility officials as to whether a particular nuclear power plant should continue to operate.

If the operating license is not renewed, then the facility must be shut down on or before the expiration date of the current operating license, January 18, 2014.

ENVIRONMENTAL IMPACTS OF LICENSE RENEWAL

The SEIS evaluates the potential environmental impacts of the proposed action. The environmental impacts from the proposed action are designated as SMALL, MODERATE, or LARGE. As set forth in the GEIS, Category 1 issues are those that meet all of the following criteria:

- (1) The environmental impacts associated with the issue is determined to apply either to all plants or, for some issues, to plants having a specific type of cooling system or other specified plant or site characteristics.
- (2) A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to the impacts, except for collective offsite radiological impacts from the fuel cycle and from high-level waste and spent fuel disposal.
- (3) Mitigation of adverse impacts associated with the issue is considered in the analysis and it has been determined that additional plant-specific mitigation measures are likely not to be sufficiently beneficial to warrant implementation.

For Category 1 issues, no additional site-specific analysis is required in this SEIS unless new and significant information is identified. Chapter 4 of this report presents the process for identifying new and significant information. Site-specific issues (Category 2) are those that do not meet one or more of the criterion for Category 1 issues; therefore, an additional site-specific review for these nongeneric issues is required, and the results are documented in the SEIS. The NRC staff has reviewed NPPD's established process for identifying and evaluating the significance of any new and significant information on the environmental impacts of license renewal of CNS. Neither NPPD nor the NRC identified information that is both new and significant related to Category 1 issues that would call into question the conclusions in the GEIS. Similarly, neither the scoping process nor the NRC staff has identified any new issue applicable to CNS that has a significant environmental impact. The NRC staff, therefore, relies upon the conclusions of the GEIS for all Category 1 issues applicable to CNS.

LAND USE

SMALL. The NRC staff did not identify any Category 2 issues for land use, nor did the staff identify any new and significant information during the environmental review. Therefore, there would be no impacts beyond those discussed in the GEIS. As stated in the GEIS, the impacts associated with these Category 1 issues were determined to be SMALL, and plant-specific mitigation measures are not sufficiently beneficial to be warranted.

AIR QUALITY

SMALL. The NRC did not identify any Category 2 issues for air quality impacts, nor did the staff identify any new or significant information during the environmental review. Therefore, for plant operation during the license renewal term, there are no impacts beyond those discussed in the GEIS.

GROUND WATER USE AND QUALITY

SMALL. The staff did not identify any new and significant information in regard to Category 1 ground water issues. Ground water use conflicts: potable and service water—plants using greater than 100 gallons per minute is a Category 2 issue related to license renewal at CNS. Because of the limited radius of influence of CNS wells in the unconfined aquifer, no public ground water supplies are close enough to CNS to be impacted by ground water use at the station. There are no well-head protection areas or Environmental Protection Agency (EPA) designated sole source aquifers in the vicinity of CNS. Therefore, the impact of ground water use by CNS is SMALL.

SURFACE WATER USE AND QUALITY

SMALL. The staff did not identify any new information and issues during its review. Therefore, no Category 2 surface water issues were identified for the CNS license renewal term. The surface water issues related to CNS are Category 1. Therefore, no impacts are related to these issues beyond those discussed in the GEIS. For these issues, the NRC staff concludes in the GEIS that the impacts are SMALL.

AQUATIC RESOURCES

SMALL. With regard to operation of CNS during the license renewal term, the NRC staff identified the following Category 2 issues for aquatic resources: entrainment and impingement of fish and shellfish, and heat shock. The NRC staff reviewed the available information and concludes that the weight of evidence indicates a SMALL level of impact on aquatic resources due to impingement and entrainment at CNS. NPPD has implemented some impingement mitigation measures and plans to implement others. After reviewing the available information, the NRC staff concludes that the level of thermal impact on the aquatic community by renewing CNS's operating license is SMALL.

In addition to the impact on aquatic resources due to entrainment and impingement of fish and shellfish and heat shock, the NRC staff reviewed field studies on the total impact of CNS's cooling water system operation on aquatic resources. The NRC staff concludes that the level of impact on aquatic resources due to all aspects of CNS's cooling system operation is SMALL.

TERRESTRIAL RESOURCES

SMALL. The NRC staff identified no Category 2 issues related to terrestrial resources for license renewal. The NRC staff did not identify any additional new and significant information during

Executive Summary

review of the NPPD's ER, the site audit, the scoping process, or the evaluation of other available information. Therefore, the NRC staff concludes that there are no additional impacts related to these issues beyond those discussed in the GEIS. The GEIS further concludes that since the impacts are SMALL, additional site-specific mitigation measures are not likely to be sufficiently beneficial to implement.

THREATENED AND ENDANGERED SPECIES

SMALL. Impact to threatened and endangered species during the period of extended operation includes one Category 2 issue, the conservation of pallid sturgeon. NPPD has been involved with several organizations in a conservation agreement regarding pallid sturgeon, which could have a positive impact on the pallid sturgeon population. Operation of the CNS site and its associated transmission lines has not been known, nor is expected, to adversely affect any threatened or endangered species during the license renewal term. The NRC staff, therefore, concludes that adverse impacts to threatened or endangered species during the license renewal term would be SMALL.

HUMAN HEALTH

SMALL. The NRC staff's review of the historical radioactive releases from CNS and the resultant dose calculation demonstrate that CNS is operating in compliance with Federal radiation protection standards. Continued compliance with regulatory requirements is expected during the license renewal term. Therefore, the impacts from radioactive effluents are not expected to change during the license renewal term.

The NRC staff did not identify any new and significant information during its review. Therefore, there are no impacts related to these issues beyond those discussed in the GEIS. For these issues, the NRC's conclusion in the GEIS was that the impacts are SMALL and additional site-specific mitigation measures are not likely to be sufficiently beneficial to be warranted.

Microbiological organisms (public health) and electromagnetic fields – acute effects (electric shock) are Category 2 human health issues. The NRC staff reviewed all documents applicable to the microbiological organisms issue and concludes that thermophilic microbiological organisms are not likely to present a public health hazard as a result of CNS discharges to the Missouri River. The NRC staff concludes that impacts on public health from thermophilic microbiological organisms from continued operation of CNS in the license renewal period are SMALL.

The NRC staff has reviewed the available information, including the applicant's evaluation and computational results. Based on this information, the NRC staff evaluated the potential impacts for electric shock resulting from operation of CNS and its associated transmission lines. The staff concludes that the potential impacts from electric shock during the renewal period are SMALL.

SOCIOECONOMICS

SMALL. For Category 1 issues (public services and aesthetic impacts), the NRC staff identified no new and significant information during the environmental review. Therefore, there would be no impacts beyond those discussed in the GEIS. Category 2 socioeconomic impacts include housing impacts, public services (public utilities), offsite land use, public services (public transportation), and historic and archaeological resources.

Since NPPD has no plans to add additional employees during the license renewal period except during outages, employment levels at CNS would remain relatively constant with no additional

demand for permanent housing during the license renewal term. Based on this information, there would be no impact on housing during the license renewal term beyond what has already been experienced.

For the same reason, demand for public water services will remain relatively unchanged with no additional demand. Public water systems in the region would be adequate to meet the demands of residential and industrial customers in the area. Therefore, there would be no additional impact to public water services during the license renewal term beyond what is currently being experienced.

Since non-outage employment levels at CNS would remain relatively constant during the license renewal period, there would be no land use impacts related to population or tax revenues, and no transportation impacts. Therefore, offsite land use and transportation issues would remain relatively unchanged.

No impacts to known historic and archaeological resources are expected from the continued operation of CNS during the license renewal term. The CNS site is situated in an area where historic and archaeological resources could be located several feet beneath the ground surface. NPPD has instituted a stop work order within its Cultural Resource Protection Plan to ensure that proper notification is taken to protect these resources should they be discovered. Based on a review of Nebraska State Historical Society (NSHS) files (archaeological surveys, assessments, and other information), the potential impacts of continued operations and maintenance on historic and archaeological resources at CNS would be SMALL.

In reviewing potential social environmental justice impacts (i.e., potential disproportionately high and adverse human health and environmental impacts on minority and low-income populations), an analysis of minority and low-income populations residing within a 50-mile (80-kilometer) radius of CNS indicated there would be no disproportionately high and adverse impacts to these populations from the continued operation of CNS during the license renewal period. Based on recent monitoring results, concentrations of contaminants in native leafy vegetation, soils and sediments, surface water, and fish in areas surrounding CNS have been low (at or near the threshold of detection) and seldom above background levels. Consequently, no disproportionately high and adverse human health impacts are expected in special pathway receptor populations in the region as a result of subsistence consumption of fish and wildlife.

SEVERE ACCIDENT MITIGATION ALTERNATIVES

Since CNS had not previously considered alternatives to reduce the likelihood or potential consequences of a variety of highly uncommon but potentially serious accidents, NRC regulation 10 CFR 51.53(c)(3)(ii)(L) requires that CNS evaluate Severe Accident Mitigation Alternatives (SAMAs) in the course of the license renewal review. SAMAs are potential ways to reduce the risk or potential impacts of uncommon but potentially severe accidents, and may include changes to plant components, systems, procedures, and training.

The NRC staff reviewed the ER's evaluation of potential SAMAs. Subsequent to the ER, a problem with the process used to numerically average the site-specific meteorological data was identified. NPPD performed a re-analysis of the population dose risk and offsite economic cost risk using corrected meteorological data, and found that the population dose and offsite economic cost values for each of the release categories would be slightly less than reported in the ER, and that the conclusions of the SAMA remain valid.

Executive Summary

The NRC staff reviewed NPPD's re-analysis and the methods used by NPPD as submitted by NPPD and agrees that the error was conservative relative to the average population dose and offsite economic cost and that no SAMAs were inappropriately excluded from consideration in the license renewal application as a result of the error.

Based on the staff's review and the supplemental information provided by NPPD, the NRC staff concluded that none of the potentially cost-beneficial SAMAs relate to adequately managing the effects of aging during the period of extended operation. Therefore, they need not be implemented as part of the license renewal pursuant to 10 CFR Part 54.

ALTERNATIVES

The NRC staff considered the environmental impacts associated with alternatives to license renewal. These alternatives include other methods of power generation and not renewing the CNS operating license (the no-action alternative). Replacement power options considered were supercritical coal-fired generation, natural gas combined-cycle generation, and a combination alternative that includes a portion of the combined-cycle gas-fired capacity, a conservation capacity component, and a wind power component. The NRC staff initially considered a number of additional alternatives for analysis as alternatives to license renewal of CNS; these were later dismissed due to technical, resource availability, or commercial limitations that currently exist and that the NRC staff believes are likely to continue to exist when the existing CNS license expires. The no-action alternative by the NRC staff and the effects it would have were also considered.

Where possible, the NRC staff evaluated potential environmental impacts for these alternatives located both at the CNS site and at some other unspecified alternate location. Energy conservation and energy efficiency; purchased power; and a combination alternative, which included natural gas combined-cycle generation, energy conservation, and wind power were also considered. The NRC staff evaluated each alternative using the same impact areas that were used in evaluating impacts from license renewal. The results of this evaluation are summarized in the table on the following page.

COMPARISON OF ALTERNATIVES

The coal-fired alternative is the least environmentally favorable alternative, due to its impacts to air quality from nitrogen oxides (NO_x), sulfur oxides (SO_x), particulate matter (PM), polycyclic aromatic hydrocarbons (PAHs), carbon monoxide (CO), carbon dioxide (CO₂), and mercury (Hg). The corresponding human health impacts and construction impacts to aquatic, terrestrial, and potentially historic and archaeological resources are also factors that make the coal-fired alternative the least environmentally favorable alternative.

The gas-fired alternative would have slightly lower air emissions than the coal-fired alternative, and impacts to aquatic, terrestrial, historic, and archaeological resources would vary depending upon the location of the plant. Purchased power would likely have operational impacts that would include aspects of coal-fired, gas-fired, and existing nuclear generation. The combination alternative would have lower air emissions and waste management impacts than both the gas-fired and coal-fired alternatives; however, the combination alternative would have relatively high construction impacts to aquatic, terrestrial, and potential historic and archaeological resources due mainly to the wind turbine component.

All other alternatives capable of meeting the energy needs currently served by CNS entail potentially greater impacts than the proposed action of license renewal of CNS. The no-action alternative does not meet the needs currently served by CNS. However, if the no-action alternative was selected and this was to trigger the energy conservation and energy efficiency action to replace the capacity currently supplied by CNS, it could result in an overall SMALL impact.

Summary of Environmental Impacts of Proposed Action and Alternatives

Alternative	Impact Area						
	Air Quality	Ground Water	Surface Water	Aquatic and Terrestrial Resources	Human Health	Socioeconomics	Waste Management
License renewal	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL
Supercritical coal-fired alternative at the CNS site	MODERATE	SMALL	SMALL	SMALL to MODERATE	SMALL	SMALL to LARGE	MODERATE
Gas-fired alternative at the CNS site	SMALL TO MODERATE	SMALL	SMALL	SMALL to MODERATE	SMALL	SMALL to MODERATE	SMALL
Combination of alternatives	SMALL TO MODERATE	SMALL	SMALL	SMALL to LARGE	SMALL to MODERATE	SMALL to MODERATE	SMALL
No-action alternative	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL to MODERATE	SMALL

RECOMMENDATION

Our recommendation is that the Commission determines that the adverse environmental impacts of license renewal for CNS are not so great that preserving the option of license renewal for energy planning decision makers would be unreasonable. This recommendation is based on:

- (1) the analysis and findings in the GEIS
- (2) information submitted in the NPPD's ER

Executive Summary

- (3) consultation with other Federal, State, and local agencies
- (4) review of other pertinent studies and reports
- (5) consideration of public comments received during the scoping process

ABBREVIATIONS AND ACRONYMS

AADT	average annual daily traffic
ac	acre
ACC	averted cleanup and decontamination costs
ADAMS	Agencywide Documents Access and Management System
ADS	automatic depressurization system
ADV	atmospheric dump valve
AEA	Atomic Energy Act of 1954
AEC	U.S. Atomic Energy Commission
AEO	Annual Energy Outlook
ALARA	as low as reasonably achievable
AMSL	above mean sea level
ANSI	American National Standards Institute.
APE	area of potential effect
ASDS	alternate shutdown system
ASME	American Association of Mechanical Engineers
BA	biological assessment
BACT	best available control technology
BBR	Bureau of Business Research
Btu	British thermal unit
Btu/ft ³	British thermal unit per cubic feet
Btu/kWh	British thermal unit per kilowatt-hour
Btu/lb	British thermal unit per pound
BWR	boiling-water reactor
BWST	borated water storage tank
CAA	Clean Air Act
CAFTA	cutest and fault tree analysis
CAMR	Clean Air Mercury Rule
CDC	Center for Disease Control
CDF	core damage frequency
CDM	Clean Development Mechanism
CENRAP	Central Regional Air Planning Association

Abbreviations and Acronyms

CEQ	Council on Environmental Quality
CERCLA	Comprehensive Environmental Response, Compensation, and Liability
CESQG	conditionally exempt small quantity generator
CET	containment event tree
CFR	<i>Code of Federal Regulations</i>
cfs	cubic feet per second
CH ₄	methane
cm	centimeter
cm/s	centimeter per second
CNS	Cooper Nuclear Station
CO	carbon monoxide
CO ₂	carbon dioxide
CPPD	Consumers Public Power District
CRA	Conestoga Rover Associates
CRD	control rod drive
CRT	cathode ray tube
CS	core spray
CST	condensate storage tank
CWA	Clean Water Act
dba	decibels adjusted
DBA	design-basis accident
DDE	insecticide, dichlorodiphenyldichloroethylene
DDT	insecticide, dichlorodiphenyltrichloroethane
DHCCW	decay heat closed cooling water
DHHS	Department of Health and Human Services
DHR	decay heat removal
DHRW	decay heat river water system
DNR	Department of Natural Resources
DOE	Department of Energy
DOT	Department of Transportation
DPR	demonstration power reactor
DPS	Department of Public Safety
DSEIS	draft supplemental environmental impact statement

Abbreviations and Acronyms

DSM	demand-side management
E.O.	Executive Order
ECCS	emergency core cooling system
EDG	emergency diesel generator
EFPD	effective full-power day
EFW	emergency feedwater
EIA	Energy Information Administration
EIS	environmental impact statement
ELF-EMF	extremely low frequency-electromagnetic field
EMF	electromagnetic fields
EMS	environmental management system
EOP	emergency operating procedure
EPA	Environmental Protection Agency
EPCRA	Emergency Planning and Community Right-to-Know Act
EPRI	Electric Power Research Institute
EPZ	emergency planning zone
ER	environmental report
ESA	Endangered Species Act
ESAS	engineered safeguards actuation signal
ESRP	Environmental Standard Review Plan
F&O	fact and observation
FCIA	Fire Compartment Interaction Analysis
FCS	Fort Calhoun Station
FES	final environmental statement
FIVE	fire-induced vulnerability evaluation
FR	<i>Federal Register</i>
FSAR	final safety analysis report
ft	foot
ft/min	feet per minute
ft ³	cubic feet
g C _{eq} /kWh	grams of CO ₂ equivalents per kilowatt-hour
GE	General Electric

Abbreviations and Acronyms

GEIS	generic environmental impact statement
GHG	greenhouse gas
gpm	gallons per minute
GRA	Generation Risk Assessment
Gy/d	grays per day
ha	hectare
HAP	hazardous air pollutant
HCLPF	high confidence in low probability of failure
HFC	hydrofluorocarbons
HFE	hydrofluorinated ethers
Hg	mercury
HID	high intensity discharge (light)
HLW	high-level waste
HPCI	high pressure coolant injection
HPI	high-pressure injection
HRA	human reliability analysis
HRSG	heat recovery steam generator
HVAC	heating, ventilation, and air conditioning
IAEA	International Atomic Energy Agency
ICCW	immediate closed cooling water
IEEE	Institute of Electrical and Electronics Engineers
IGCC	integrated gasification combined-cycle
Inc.	incorporated
	Idaho National Energy and Environmental Laboratory
IPCC	Intergovernmental Panel on Climate Change
IPE	individual plant examination
IPEEE	individual plant examination of external events
ISFSI	independent spent fuel storage installation
ISLOCA	interfacing-systems loss-of-coolant accident
J	joule
JHEP	joint human error probability

Abbreviations and Acronyms

kg	kilogram
km	kilometer
km ²	square kilometer
kmh	kilometer per hour
kPa	kilopascal
kV	kilovolt
kWh	kilowatt-hour
lb	pound
lb/MWh	pound per megawatt-hour
LERF	large early release frequency
LLC	limited liability corporation
LLMW	low-level mixed waste
LLNL	Lawrence Livermore National Laboratory
LLW	low-level radioactive waste
LOCA	loss-of-coolant accident
LOOP	loss of offsite power
LPI	low pressure injection
LQG	large quantity generator
m	meter
m/min	meter per minute
m/s	meter per second
m ³	cubic meter
m ³ /month	cubic meter per month
m ³ /s	cubic meter per second
MAAP	modular accident analysis program
MACCS2	MELCOR Accident Consequence Code System 2
MCR	main control room
MDC	Missouri Department of Conservation
MDNR	Missouri Department of Natural Resources
mg/L	milligrams per liter
mgd	million gallons per day
mGy	milligray
mGy/d	milligray per day

Abbreviations and Acronyms

mi	mile
mi ²	square mile
MOU	Memorandum of Understanding
MOV	motor operated valve
mph	mile per hour
mrad	milliradiation absorbed dose
mrem	milliroentgen equivalent man (mrem)
MSA	Magnuson-Stevens Fishery Conservation and Management Act of 1996
MSIV	main steam isolation valve
msl	mean sea level
MSPI	Mitigating System Performance Index
mSv	millisievert
MT	metric tonnes
MW	megawatt
MWd/MTU	megawatt-days per metric ton uranium
MWe	megawatt-electric
MWt	megawatt-thermal
N ₂ O	nitrous oxide
NA	not applicable
NAAQS	National Ambient Air Quality Standards
NAC	Nebraska Administrative Code
NAQR	Nebraska Air Quality Regulations
NAS	National Academy of Sciences
NBPP	no break power panel
NCDC	National Climatic Data Center
NDE	Nebraska Department of Education
NDED	Nebraska Department of Economic Development
NDEQ	Nebraska Department of Environmental Quality
NDNR	Nebraska Department of Natural Resources
NDOR	Nebraska Department of Roads
NEI	Nuclear Energy Institute
NEPA	National Environmental Policy Act of 1969
NESC	National Electric Safety Code

Abbreviations and Acronyms

NF ₃	nitrogen trifluoride
ng	nanograms
NGPC	Nebraska Game and Parks Commission
NHHS	Nebraska Department of Health and Human Services
NHPA	National Historic Preservation Act
NIEHS	National Institute of Environmental Health Sciences
NMFS	National Marine Fisheries Service
NNRD	Nemaha Natural Resources District
NO ₂	nitrogen dioxide
NOAA	National Oceanic and Atmospheric Administration
NO _x	nitrogen oxide(s)
NPDES	National Pollutant Discharge Elimination System
NPPD	Nebraska Public Power District
NPSH	net positive suction head
NRC	U.S. Nuclear Regulatory Commission
NRHP	National Register of Historic Places
NSSCW	nuclear service closed cooling water
NSHS	Nebraska State Historical Society
NSR	New Source Review
NWPCC	Nebraska Water Pollution Control Council
NWS	National Weather Service
ODAM	Offsite Dose Assessment Manual
ODCM	Offsite Dose Calculation Manual
ODNR	Ohio Department of Natural Resources
OMB	Office of Management and Budget
OPPD	Omaha Public Power District
PAH	polycyclic aromatic hydrocarbon
PCB	polychlorinated biphenyl
pCi/L	picocuries per liter
PDS	plant damage state
PFC	perfluorocarbons
PILOT	payments in lieu of taxes
PM	particulate matter

Abbreviations and Acronyms

PM ₁₀	particulate matter, 10 microns or less in diameter
PM _{2.5}	particulate matter, 2.5 microns or less in diameter
PMF	probably maximum flood
PRA	probabilistic risk assessment
psig	pounds per square inch gage
PWR	pressurized water reactor
rad/d	radiation absorbed dose per day
RAI	request for additional information
RBEC	reactor building emergency cooling
RBWMD	Rainwater Basin Wetland Management District
RCIC	reactor core isolation cooling
RCP	reactor coolant pump
RCRA	Resource Conservation and Recovery Act
RCS	reactor coolant system
REMP	radiological environmental monitoring program
RHR	residual heat removal
RHRSW	residual heat removal service water
RKm	river kilometer
RLE	review level earthquake
RM	river mile
rms	root mean square
ROI	region of influence
ROW(s)	right-of-way(s)
RPMA	recovery priority management area
RPO	regional planning organization
RPS	reactor protection system
RPV	reactor pressure vessel
RRW	risk reduction worth
RWD	Rural Water District
SAMA	Severe Accident Mitigation Alternative
SAR	safety analysis report
SAS	security alarm station
SBO	station blackout

Abbreviations and Acronyms

SC	species of concern
SCDHEC	South Carolina Department of Health and Environmental Control
SCR	selective catalytic reduction
SEIS	supplemental environmental impact statement
SER	safety evaluation report
SF ₆	sulfur hexafluoride
SGTR	steam generator tube rupture
SHPO	State Historic Preservation Office
SLC	standby liquid control
SO ₂	sulfur dioxide
SO ₃	sulfur trioxide
SO _x	sulfur oxide(s)
SPDES	State Pollutant Discharge Elimination System
SQG	small quantity generator
SQUG	Seismic Qualification User's Group
SR	supporting requirements
SRV	safety relief valve
Sv	sievert
SWBP	service water booster pump
TDEC	Tennessee Department of Environment and Conservation
TEC	turbine equipment cooling
TSP	total suspended particles
TSS	total suspended solids
U	Uranium
U.S.	United States
U.S.C.	<i>United States Code</i>
UDEQ	Utah Department of Environmental Quality
UNL	University of Nebraska-Lincoln
USACE	United States Army Corps of Engineers
USCB	U.S. Census Bureau
USDA	U.S. Department of Agriculture
USFWS	U.S. Fish and Wildlife Service
USGCRP	United States Global Change Research Program

Abbreviations and Acronyms

USGS	U.S. Geological Survey
USI	unresolved safety issue
V	volt
VOC	volatile organic compound
WGA	Western Governors Association
WHO	World Health Organization
yd ³	cubic yard
yd ³ /month	cubic yard per month

1.0 PURPOSE AND NEED FOR ACTION

Issuance of a renewal of a nuclear power plant operating license requires the preparation of a supplemental environmental impact statement (SEIS) under the U.S. Nuclear Regulatory Commission's (NRC's) environmental protection regulations in Title 10, Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions," of the *Code of Federal Regulations* (10 CFR Part 51.20).

The Atomic Energy Act of 1954 (AEA) specified that licenses for commercial power reactors be granted for up to 40 years, but permitted license renewal. The 40-year licensing period was based on economic and antitrust considerations rather than on technical limitations of the nuclear facility.

The decision to seek a license renewal rests with the nuclear power facility owners and typically is based on the facility's economic viability and the investment necessary to continue to meet NRC safety and environmental requirements. The NRC grants or denies a license renewal application based on whether or not the applicant demonstrates that agency regulations for environmental and safety requirements can be met during the period of extended operation.

1.1 PROPOSED FEDERAL ACTION

Nebraska Public Power District (NPPD) initiated the proposed Federal action by submitting an application for license renewal of the Cooper Nuclear Station (CNS), for which the existing license, DPR-46, expires January 18, 2014 (NPPD, 2008a). The NRC's Federal action is the proposed decision to renew the license for an additional 20 years.

1.2 PURPOSE AND NEED FOR THE PROPOSED FEDERAL ACTION

The purpose and need for the proposed Federal action (i.e., the issuance of a renewed license) is to provide an option that allows for power generation capability, beyond the term of a current nuclear power plant operating license, to meet future system generating needs, as such needs may be determined by State, utility, and, where authorized, Federal decision makers (other than the NRC). This definition of purpose and need for the proposed Federal action reflects the NRC's recognition that, unless there are findings in the safety review required by the AEA or findings in the National Environmental Policy Act (NEPA) environmental analysis that would lead the NRC not to issue a renewal, the NRC does not have a role in the energy-planning decisions of State regulators and utility officials as to whether or not a particular nuclear power plant should continue to operate.

If the NRC renews the operating license, State regulatory agencies and NPPD decide whether or not the plant will continue to operate based on factors such as the need for power within the State's jurisdiction or the purview of the owners. If the NRC does not renew CNS's DPR-46 operating license, the facility must be shut down on or before the expiration date of the current operating license, January 18, 2014.

1.3 MAJOR ENVIRONMENTAL REVIEW MILESTONES

NPPD submitted an environmental report (ER) as part of its license renewal application (NPPD, 2008a) in September 2008. After reviewing the application and the ER for sufficiency, the NRC staff published a Notice of Acceptability and Opportunity for Hearing on December 30,

Purpose and Need for Action

2008, in the *Federal Register* (73 FR 79921). On January 26, 2009, the NRC published another notice in the *Federal Register* (NRC, 2009a) on its intent to conduct scoping, thereby beginning the 60-day scoping period.

The agency held two public scoping meetings on February 25, 2009, in Brownville, NE, and Auburn, NE. The NRC report entitled "Environmental Impact Statement Scoping Process Summary Report for Cooper Nuclear Station," dated May 29, 2009, presents the comments received during the scoping process in their entirety (NRC, 2009b). Appendix A to this SEIS presents the comments considered to be within the scope of the environmental license renewal review and the associated NRC responses.

To independently verify information provided in the ER, the NRC staff conducted a site audit at CNS from March 30 through April 3, 2009. During the site audit, staff met with plant personnel, reviewed specific documentation, toured the facility, and met with interested Federal, State, and local agencies. The agency published a summary of that site audit and a list of the attendees in a report entitled, "Summary of Site Audit Related to the Review of the License Renewal Application for Cooper Nuclear Station," dated April 30, 2009 (NRC, 2009c).

Figure 1-1 shows the major milestones in the public review of the SEIS. Upon completion of the scoping period and site audit, the staff compiled its findings in the draft SEIS, which was made available for public comment for 75 days. During this comment period, the NRC staff hosted public meetings and collected public comments. Based on the information gathered, the staff amended the draft SEIS findings, as necessary, and published this final SEIS.




Figure 1-1. Environmental Review Process. *The environmental review process provides opportunities for public involvement.*

The NRC has established a license renewal process that can be completed in a reasonable period of time with clear requirements to ensure safe plant operations for up to an additional 20 years of plant life. The safety review is conducted simultaneously with the environmental review. The staff documents the findings of the safety review in a safety evaluation report (SER). The Commission considers the findings in both the SEIS and the SER in its decision to either grant or deny the issuance of a new license.

1.4 GENERIC ENVIRONMENTAL IMPACT STATEMENT

The NRC performed a generic assessment of the environmental impacts associated with license renewal to improve the efficiency of the license renewal. NUREG-1437, *Generic Environmental Impact Statement for License Renewal of Nuclear Power Plants (GEIS)*,¹ documents the results of the NRC staff's systematic approach to evaluating the environmental consequences of renewing licenses of individual nuclear power plants and operating them for an additional 20 years (NRC, 1996), (NRC, 1999). The NRC staff analyzed and dispositioned those environmental issues that could be dispositioned generically in the GEIS.

The GEIS includes a determination of whether or not the analysis of the environmental issue could be applied to all plants and if additional mitigation measures are warranted (Figure 1-2). Issues are assigned a designation: a Category 1 (generic to all plants) or a Category 2 (not generic to all plants). As set forth in the GEIS, Category 1 issues are those that meet all of the following criteria:

- (1) The environmental impacts associated with the issue is determined to apply either to all plants or, for some issues, to plants having a specific type of cooling system or other specified plant or site characteristics.
- (2) A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to the impacts, except for collective offsite radiological impacts from the fuel cycle and from high-level waste and spent fuel disposal.
- (3) Mitigation of adverse impacts associated with the issue is considered in the analysis and it has been determined that additional plant-specific mitigation measures are likely not to be sufficiently beneficial to warrant implementation.

For Category 1 issues, no additional site-specific analysis is required in this SEIS unless new and significant information is identified. Chapter 4 of this report presents the process for identifying new and significant information. Site-specific issues (Category 2) are those that do not meet one or more of the criterion for Category 1 issues; therefore, an additional site-specific review for these nongeneric issues is required, and the results are documented in the SEIS.

The GEIS establishes 92 issues for the NRC staff to independently verify. Of these 92, the staff determined that 69 are Category 1, while 21 issues do not lend themselves to generic consideration (Category 2). Two other issues remained uncategorized and must be evaluated on a site-specific basis: environmental justice and the chronic effects of electromagnetic fields. Refer to Appendix B of this SEIS for a list of all 92 issues.

Significance indicates the importance of likely environmental impacts and is determined by considering two variables: **context** and **intensity**.
Context is the geographic, biophysical, and social context in which the effects will occur.
Intensity refers to the severity of the impact, in whatever context it occurs.

¹ NUREG-1437, *Generic Environmental Impact Statement (GEIS) for License Renewal of Nuclear Power Plants*, Volume 1 and 2, May 1996, Washington, D.C.

For each potential environmental issue, the GEIS: (1) describes the activity that affects the environment, (2) identifies the population or resource that is affected, (3) assesses the nature and magnitude of the impact on the affected population or resource, (4) characterizes the significance of the effect for both beneficial and adverse effects, (5) determines whether or not the results of the analysis apply to all plants, and (6) considers whether or not additional mitigation measures are warranted for impacts that would have the same significance level for all plants.

The NRC's standard of significance for impacts was established using the Council on Environmental Quality (CEQ) terminology for "significant." The NRC established three levels of significance for potential impacts—SMALL, MODERATE, and LARGE, as defined below:

SMALL – Environmental effects are not detectable or are so minor that they will neither destabilize nor noticeably alter any important attribute of the resource.

MODERATE – Environmental effects are sufficient to alter noticeably, but not to destabilize, important attributes of the resource.

LARGE – Environmental effects are clearly noticeable and are sufficient to destabilize important attributes of the resource.




Figure 1-2. Environmental Issues Evaluated During License Renewal. *Ninety-two issues were evaluated in the GEIS. A site-specific analysis is required for 23 of those 92 issues.*

1.5 SUPPLEMENTAL ENVIRONMENTAL IMPACT STATEMENT

The SEIS presents an analysis that considers the environmental effects of the continued operation of CNS, alternatives to license renewal, and mitigation measures for minimizing adverse environmental impacts. Chapters 5, 6, and 7 analyze the environmental impact of postulated accidents, the uranium fuel cycle and greenhouse gas emissions, and decommissioning, respectively. Chapter 8 analyzes and compares the potential environmental impacts from alternatives, and Chapter 9 presents the recommendation to the Commission as to whether or not the environmental impacts of license renewal are so great that preserving the option of license renewal would be unreasonable. The recommendation will be made after consideration of the SEIS.

In preparation of this SEIS for CNS, the staff undertook the following activities:

- reviewed information provided in the NPPD ER
- consulted with other Federal, State, and local agencies
- conducted an independent review of the issues during site audit
- considered public comments received during the scoping process

New information can be identified from a number of sources, including the applicant, the NRC, other agencies, or public comments. If a new issue is revealed, then it is first analyzed to determine whether it is within the scope of the license renewal evaluation. If the issue is not addressed in the GEIS, then the NRC determines its significance and documents its analysis in the SEIS.

New and significant information either (1) identifies a significant environmental issue not covered in the GEIS, or (2) was not considered in the analysis in the GEIS and leads to an impact finding that is different from the finding presented in the GEIS.

1.6 COOPERATING AGENCIES

During the scoping process, no Federal, State, or local agencies were identified as cooperating agencies in the preparation of this SEIS.

1.7 CONSULTATIONS

The Endangered Species Act of 1973, as amended; the Magnuson-Stevens Fisheries Conservation and Management Act of 1996, as amended; and the National Historic Preservation Act of 1966, require that Federal agencies consult with applicable State and Federal agencies and groups before taking action that may affect endangered species, fisheries, or historic and archaeological resources, respectively. Below are the agencies and groups with whom the NRC consulted; Appendix D to this report includes copies of consultation documents.

Advisory Council on Historic Preservation
Department of Health and Human Services
Iowa Tribe of Kansas and Nebraska
Iowa Tribe of Oklahoma

Kickapoo Tribe in Kansas
Nebraska Game and Parks Commission
Nebraska Department of Natural Resources
Nebraska State Historic Society
Missouri State Historic Society
Omaha Tribe of Nebraska
Otoe-Missouria Tribe of Indians
Prairie Band of Potawatomi Indians
Sac and Fox Nation of Missouri
Sac and Fox Tribe of the Mississippi in Iowa
Sac and Fox Nation of Oklahoma
U.S. Army Corps of Engineers
U.S. Fish and Wildlife Service, Grand Island, NE Field Office

1.8 CORRESPONDENCE

During the course of the environmental review, the NRC staff contacted the following Federal, State, regional, local, and tribal agencies. Appendix E to this report contains a chronological list of all documents sent and received during the environmental review.

Advisory Council on Historic Preservation
Department of Health and Human Services
Iowa Tribe of Kansas and Nebraska
Iowa Tribe of Oklahoma
Kickapoo Tribe in Kansas
Nebraska Game and Parks Commission
Nebraska Department of Health and Human Services
Nebraska Department of Natural Resources
Nebraska State Historic Preservation Office
Missouri State Historic Preservation Office
Omaha Tribe of Nebraska
Otoe-Missouria Tribe of Indians
Prairie Band of Potawatomi Indians
Sac and Fox Nation of Missouri
Sac and Fox Tribe of the Mississippi in Iowa
Sac and Fox Nation of Oklahoma
U.S. Army Corps of Engineers

Purpose and Need for Action

U.S. Environmental Protection Agency, Kansas City, KS Field Office

U.S. Fish and Wildlife Service, Grand Island, NE Field Office

A list of persons who received a copy of the draft SEIS is provided below:

Mr. Ronald D. Asche President and Chief Executive Officer Nebraska Public Power District 1414 15th Street Columbus, NE 68601	Mr. Gene Mace Nuclear Asset Manager Nebraska Public Power District P.O. Box 98 Brownville, NE 68321	Mr. John C. McClure Vice President and General Counsel Nebraska Public Power District P.O. Box 499 Columbus, NE 68602-0499
Mr. David Van Der Kamp Licensing Manager Nebraska Public Power District P.O. Box 98 Brownville, NE 68321	Mr. Michael J. Linder, Director Nebraska Department of Environmental Quality P.O. Box 98922 Lincoln, NE 68509-8922	Chairman Nemaha County Board of Commissioners Nemaha County Courthouse 1824 N Street Auburn, NE 68305
Mr. Stewart B. Minahan Vice President Nuclear and Chief Nuclear Officer Cooper Nuclear Station 72676 – 648A Avenue Brownville, NE 68321	Ms. Julia Schmitt, Manager Radiation Control Program Nebraska Health & Human Services R&L Public Health Assurance 301 Centennial Mall, South P.O. Box 95007 Lincoln, NE 68509-5007	Deputy Director for Policy Missouri Department of Natural Resources P.O. Box 176 Jefferson City, MO 65102-0176
Senior Resident Inspector U.S. Nuclear Regulatory Commission P.O. Box 218 Brownville, NE 68321	Regional Administrator, Region IV U.S. Nuclear Regulatory Commission 612 E. Lamar Blvd, Suite 400 Arlington, TX 76011-4125	Director, Missouri State Emergency Management Agency P.O. Box 116 Jefferson City, MO 65102-0116
Chief, Radiation and Asbestos Control Section Kansas Department of Health and Environment Bureau of Air and Radiation 1000 SW Jackson, Suite 310 Topeka, KS 66612-1366	Ms. Melanie Rasmussen Radiation Control Program Director Bureau of Radiological Health Iowa Department of Public Health Lucas State Office Building, 5th Floor 321 East 12th Street Des Moines, IA 50319	Mr. Keith G. Henke, Planner Division of Community and Public Health Office of Emergency Coordination 930 Wildwood Drive P.O. Box 570 Jefferson City, MO 65102
Mr. Art Zaremba, Director of Nuclear Safety Assurance Nebraska Public Power District P.O. Box 98 Brownville, NE 68321	Mr. John F. McCann, Director Licensing, Entergy Nuclear Northeast Entergy Nuclear Operations, Inc. 440 Hamilton Avenue White Plains, NY 10601-1813	Mr. Mike Boyce Cooper Strategic Initiatives Manager Cooper Nuclear Station 72676 – 648A Avenue Brownville, NE 68321
Mr. Garry Young License Renewal Manager Entergy Nuclear 1448 S.R. 333, N-GSB-45 Russellville, AR 72802	Mr. Alan Cox License Renewal Technical Manager Entergy Nuclear 1448 S.R. 333, N-GSB-45 Russellville, AR 72802	Mr. Dave Lach LRP Entergy Project Manager Entergy Nuclear 1448 S.R. 333, N-GSB-45 Russellville, AR 72802
Mr. Jerry Perry 500 S. Main Street Rock Port, MO 64482	Ms. Yolanda Peck 1008 Central Avenue Auburn, NE 68305	Ms. Kendall Neiman 830 Central Avenue Auburn, NE 68305
Ms. Annie Thomas 1522 I Street Auburn, NE 8305	Mr. John Chaney 1101 17th Street Auburn, NE 68305	Mr. Darrell Kruse 2415 McConnell Avenue Auburn, NE 68305
Mr. Daryl J. Obermeyer	Ms. Sherry Black, Director	Board of Brownville, NE

Purpose and Need for Action

ADC 64381 727A Road Brownville, NE 68321	Auburn Memorial Library 1810 Courthouse Avenue Auburn, NE 68305	Attn: Chairman Marty Hayes P.O. Box 67 223 Main Street Brownville, NE 68321
Mr. Bob Engles Mayor of Auburn, NE 1101 J Street Auburn, NE 68305	Ms. Jo Stevens Mayor of Rock Port, MO 500 S. Main Street Rock Port, MO 64482	Mr. John Cochnar U.S. Fish and Wildlife Service Ecological Services Nebraska Field Office 203 West Second Street Grand Island, NE 68801
Mr. John Askew Regional Administrator U.S. EPA Region 7 901 N. 5th Street Kansas City, KS 66101	Ms. Joann Scheafer, Director Nebraska Department of Health & Human Services 301 Centennial Mall South Lincoln, NE 68509	Mr. Doyle Childers, Director Missouri Department of Natural Resources P.O. Box 176 Jefferson City, MO 65102
Mr. Mark Miles State Historic Preservation Officer Department of Natural Resources P.O. Box 176 Jefferson City, MO 65102	Mr. Michael J. Smith State Historic Preservation Officer Nebraska State Historical Society P.O. Box 82554 Lincoln, NE 68501	Mr. Robert Puschendorf Nebraska State Historical Society 1500 R Street P.O. Box 82554 Lincoln, NE 68501-2554
Mr. Seth Greenburg Environment, Planning, and Infrastructure Research Assistant ICF International 9300 Lee Highway Fairfax, VA 22031	Mr. Matthew Leaf KTNC/KLZA Radio 1602 Stone St Falls City, NE 68335	Mr. Jim Thomas Enercon 5100 E. Skelton Street, 450 Tulsa, OK 74135
Ms. Carla Mason ADC 820 Central Avenue Auburn, NE 68305		

1.9 STATUS OF COMPLIANCE

NPPD is responsible for complying with all NRC regulations and other applicable Federal, State, and local requirements. Appendix H to the GEIS describes some of the major Federal statutes. Table 1-1 on the following page lists the numerous permits and licenses issued by Federal, State, and local authorities for activities at CNS.

Purpose and Need for Action

Table 1-1. Licenses and Permits. Existing environmental authorizations for CNS operations.

Permit	Number	Dates	Responsible Agency
Operating License	DPR-46	Issued: 1/18/1974 Expires: 1/18/2014	NRC
National Pollutant Discharge Elimination System (NPDES) Permit	NE0001244	Expires: 6/30/2012	Nebraska Department of Environmental Quality (NDEQ)
General NPDES Permit	NER000059	Expires: 9/17/2012	NDEQ
Permit to Construct an Air Contaminant Source	Not Applicable (NA)	NA	NDEQ
Hazardous Waste Generator Identification	NED055071062	NA	NDEQ
Class V Well Underground Injection	NE0208256	Expires: 11/16/2010	NDEQ
Well Registration	G-030088	NA	Nebraska Department of Natural Resources (NDNR)
Well Registration	G-030089	NA	NDNR
Well Registration	G-040718	NA	NDNR
Well Registration	G-100339	NA	NDNR
Well Registration	G-100340	NA	NDNR
Well Registration	G-149001A	NA	NDNR
Well Registration	G-149001B	NA	NDNR
Well Registration	G-149001C	NA	NDNR
Well Registration	G-149001D	NA	NDNR
Well Registration	G-149001E	NA	NDNR
Well Registration	G-149001F	NA	NDNR
Well Registration	G-149001G	NA	NDNR
Well Registration	G-149001H	NA	NDNR
Well Registration	G-149001I	NA	NDNR
Well Registration	G-149001J	NA	NDNR
Well Registration	G-149001K	NA	NDNR
Water withdrawal permit	D-1071	NA	NDNR
Class III Public Water Supply System Permit	NE3150505	NA	Nebraska Health and Human Services (NHHS) System
401 Certification	NA	NA	Nebraska Water Pollution Control Council (NWPPCC)
CNS Radioactive Waste License for Delivery	T-NE002-L08	12/31/2008	Tennessee Department of Environment and Conservation (TDEC), Division of Radiological Health
Generator Site Access Permit	0111000042	1/3/2009	Utah Department of Environmental Quality (UDEQ), Division of Radiological Health
Industrial Storm Water Permit	NER000000	9/18/1997	NPDES
Section 404 Permit for dredging at intake structure and discharge of dredge material			
Section 404 Permit of intake structure ice deflectors			

1.10 REFERENCES

10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions."

Atomic Energy Act of 1954 (AEA). 42 U.S.C. 2011, et seq.

Endangered Species Act of 1973 (ESA). 16 U.S.C. 1531, et seq.

Magnuson-Stevens Fishery Conservation and Management Act, as amended by the Sustainable Fisheries Act of 1996. 16 U.S.C. 1855, et seq.

National Environmental Policy Act of 1969 (NEPA). 42 U.S.C. 4321, et seq.

National Historic Preservation Act (NHPA). 16 U.S.C. 470, et seq.

Nebraska Public Power District (NPPD). 2008. "License Renewal Application, Cooper Nuclear Station, Appendix E – Applicant's Environmental Report, Operating License Renewal Stage," Columbus, NE, September 24, 2008, Agencywide Documents Access and Management System (ADAMS) Accession Nos. ML083030246 (main report) and ML083030252 (attachments).

Nebraska Public Power District (NPPD). 2008a. "Cooper Nuclear Station, License Renewal Application," ADAMS Accession No. ML083030227.

U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*, NUREG-1437, Volumes 1 and 2, Washington, D.C., ADAMS Accession Nos. ML040690705 and ML040690738.

U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Main Report*, "Section 6.3 – Transportation, Table 9.1, Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants, Final Report," NUREG-1437, Volume 1, Addendum 1, Washington, D.C., ADAMS Accession No. ML040690720.

U.S. Nuclear Regulatory Commission (NRC). 2009a. "United States Nuclear Regulatory Commission, Nebraska Public Power District, Cooper Nuclear Station, Notice of Intent to Prepare an Environmental Impact Statement and Conduct Scoping Process," *Federal Register*, Vol. 74, No. 15, pp. 4476–4477, January 26, 2009.

U.S. Nuclear Regulatory Commission (NRC). 2009b. "Environmental Impact Statement, Scoping Process, Summary Report, Cooper Nuclear Station." Brownville, Nebraska, ADAMS Accession No. ML091200017.

U.S. Nuclear Regulatory Commission (NRC). 2009c. "Summary of Site Audit Related to the Review of the License Renewal Application for Cooper Nuclear Station (TAC Nos. MD9763 and MD9737)," ADAMS Accession No. ML090970414.

2.0 AFFECTED ENVIRONMENT

Cooper Nuclear Station (CNS) is located in Nemaha County, Nebraska, 2.25 miles (mi) (3.6 kilometers (km)) southeast of Brownville, Nebraska, approximately 60 mi (96 km) southeast of Lincoln, Nebraska and 65 mi south of Omaha, Nebraska. CNS is bounded on the east by the Missouri River and on the north, south, and west by non-Nebraska Public Power District (NPPD) owned property. Figure 2.1-1 shows a map of a 50-mi (80-km) radius around CNS. Figure 2.2-2 shows the area within a 6-mi (9.6 km) radius of CNS. The site is owned and operated by NPPD. The site structures for CNS span approximately 55 acres (ac) (22 hectares (ha)) of the site's total area of approximately 1,359 ac (550 ha), inclusive of the 239 ac (97 ha) on the opposite bank (east) of the Missouri River in Atchison County, Missouri. Over 99 percent of the total acreage in Nemaha County is used for agriculture and farming. A significant portion of NPPD property at CNS, 234 ac (947 ha) in Missouri and 715 ac (289 ha) in Nebraska, is currently leased for agricultural activities such as farming and raising livestock or conservation purposes.

2.1 FACILITY DESCRIPTION

The principal structures at CNS consist of the reactor building, turbine building (including service area appendages), control building, controlled corridor, radwaste building, augmented radwaste building, intake structure, off-gas filter building, elevated release point, diesel generator building, multi-purpose facility, railroad airlock, drywell and suppression chamber, miscellaneous circulating water system structures (e.g., circulating water conduits, seal well), optimum water chemistry gas generator building, and office building. Predominant features are the 290-foot (ft) (88-meter (m)) tall reactor building, the 325-ft (99-m) tall elevated release point, and the 328.08-ft (100-m) tall meteorological tower.

The reactor and nuclear steam supply systems for the site, along with the mechanical and electrical systems required for the safe operation of CNS, are primarily located in the containment structure. These vital components of the station are located in a protected area that is completely enclosed by a security fence, with access to the station controlled at a security gate. A plant security system monitors the protected area, as well as the buildings within the station. Normal access to the site is by a paved entrance road built across the site from Nemaha County Road 648A Avenue, located on the west side of the property. No residences are permitted within the CNS exclusion area boundary.

2.1.1 Reactor and Containment Systems

CNS is a single-unit boiling-water reactor (BWR) plant with a nuclear steam supply system supplied by General Electric Company and a turbine generator set supplied by Westinghouse Electric Corporation. CNS achieved commercial operation in 1974 with an initial licensed core thermal power of 2,381 megawatts-thermal (MWt). In 2008, with U.S. Nuclear Regulatory Commission (NRC) approval, the applicant performed a measurement uncertainty recapture uprate that increased the core thermal power by 1.62 percent to its current level of 2,419 MWt and 830 megawatts-electric (MWe) (NPPD, 2008a). Figure 2.1-3 shows the general layout of the buildings at CNS.

Affected Environment




Figure 2.1-1. Location of Cooper Nuclear Station, 50-mile (80-kilometer) Region
 (Source: NPPD, 2008a)




Figure 2.1-2. Location of Cooper Nuclear Station, 6-mile (10-kilometer) Region
 (Source: NPPD, 2008a)

Affected Environment




Figure 2.1-3. Cooper Nuclear Station, General Site Layout (Source: NPPD, 2008a)

The reactor fuel is low-enriched high density ceramic uranium dioxide fuel pellets stacked within a Zircaloy-2 cladding tube, which is evacuated, back-filled with helium, and sealed by welding Zircaloy plugs in each end. NPPD currently operates CNS with an individual rod average burnup of not more than 62,000 megawatt-days per metric ton uranium (MWd/MTU) (NPPD, 2008a).

The CNS containment system uses a multibarrier concept consisting of two systems, a primary containment, which is a pressure suppression system, and a secondary containment, which minimizes the release of radioactive materials.

The primary containment houses the reactor pressure vessel, the reactor coolant recirculation system, and other branch connections of the reactor coolant system. Primary containment is a

pressure suppression system consisting of a drywell, a suppression chamber which stores a large volume of water, a connecting vent system between the drywell and suppression pool, isolation valves, portions of the emergency core cooling system, and other service equipment. The drywell is a steel pressure vessel in the shape of an inverted light bulb, and the suppression chamber is a torus-shaped steel pressure vessel, often referred to as the torus, located below and encircling the drywell.

Secondary containment encloses the primary containment system, refueling and reactor servicing areas, new and spent fuel storage facilities, and other reactor auxiliary systems. Secondary containment serves as the primary containment, when required, during reactor refueling and maintenance operations, when primary containment is inoperable and as an additional barrier when primary containment is operable (NPPD, 2008a).

2.1.2 Radioactive Waste Management

The radioactive waste system for CNS collects, treats, and disposes of radioactive and potentially radioactive wastes that are byproducts of plant operations. The byproducts are activation products resulting from the irradiation of reactor water and impurities therein (principally metallic corrosion products) and fission products resulting from defective fuel cladding or uranium contamination within the reactor coolant system. Operating procedures for the radioactive waste system ensure that radioactive wastes are safely processed and discharged from the plant within the limits set forth in Title 10 of the *Code of Federal Regulations* (CFR) Part 20, "Standards for Protection against Radiation," 10 CFR Part 50, "Domestic Licensing of Production and Utilization Facilities," the plant's technical specifications, and the CNS offsite dose assessment manual (ODAM) (NPPD, 2008a).

Radioactive wastes resulting from plant operations are classified as liquid, gaseous, or solid. Radioactive liquid wastes are generated from liquids received directly from portions of the reactor coolant system or were contaminated by contact with liquids from the reactor coolant system. Radioactive gaseous wastes are generated from gases or airborne particulates vented from reactor and turbine equipment containing radioactive material. Radioactive solid wastes are solids from the reactor coolant system, solids that come into contact with reactor coolant system liquids or gases, or solids used in the reactor coolant system or steam and power conversion system operation or maintenance (NPPD, 2008a).

Reactor fuel that has exhausted a certain percentage of its fissile uranium content is referred to as spent fuel. Spent fuel assemblies are removed from the reactor core and replaced with fresh fuel assemblies during routine refueling outages. Spent fuel assemblies are stored in the spent fuel pool in the reactor building. In addition to the spent fuel pool, spent nuclear fuel is expected to be stored in dry casks during the license renewal term.

The CNS ODA contains the methodology and parameters used to calculate offsite doses resulting from radioactive gaseous and liquid effluents, and the gaseous and liquid effluent monitoring alarm and trip setpoints used to verify that the radioactive material being discharged meets regulatory limits. The ODA also contains the radioactive effluent controls and radiological environmental monitoring activities and descriptions of the information that is included in the annual radiological environmental operating report and annual radioactive effluent release report (NPPD, 2008a).

Affected Environment

2.1.2.1 *Radioactive Liquid Waste*

The CNS liquid waste disposal system collects, holds, treats, processes, and monitors all liquid radioactive wastes for reuse or disposal. The function of the radioactive waste system is to reclaim the liquid phase of the wet solid wastes for reuse within the station and to prepare the solid waste for offsite shipment while minimizing radiation exposure to the workers. Prior to offsite shipment to a licensed burial ground, solid wastes may be stored on site in shielded areas. The solid waste processing systems are located in the radioactive waste building and augmented radioactive waste building. Liquid radioactive waste is collected in sumps and drainage tanks and transferred to the appropriate subsystem collection tanks for treatment, disposal, or recycle. The waste processing selectively removes the radioactive material from the liquid. The processing methods used include filtration and/or demineralization. The system can also handle effluent streams that typically do not contain radioactive material, but may on occasion, be radioactive. The applicant limits, to the extent possible, the amount of liquid radioactive wastes discharged to the Missouri River. For example, there were no liquid radioactive discharges from CNS into the Missouri River in 2007. Liquid discharges are made only after the radioactive material has been analyzed and the projected dose to members of the public has been calculated to be within the values specified in the ODAM, 10 CFR Part 20, and Appendix I to 10 CFR Part 50 (NPPD, 2008a).

The NRC staff reviewed the CNS radioactive effluent release reports for 2003 through 2009 for liquid effluents (NPPD, 2004), (NPPD, 2005), (NPPD, 2006a), (NPPD, 2007a), (NPPD, 2008b), (NPPD, 2009a), (NPPD, 2010) to determine if there was an adverse trend (i.e., a steady and consistent annual increase in the amount of liquid effluents discharged) that might result in levels that approach the radiation dose limits for members of the public. The effluent releases are generally consistent from year to year, allowing for variations based on plant operation, the number of refueling outages, and the scope of routine maintenance work performed. No adverse trend was observed.

2.1.2.2 *Radioactive Gaseous Waste*

The CNS gaseous waste disposal system processes and disposes of radioactive gaseous effluent to the atmosphere. The off-gas system (non-augmented) includes subsystems that process and dispose of the gases from the main condenser air ejectors, the startup mechanical vacuum pumps, and the gland steam condensers. The processed gases are routed to the elevated release point for dilution and release to the atmosphere. Radiation monitors monitor the gaseous discharges (NPPD, 2008a).

CNS discharges gaseous waste in accordance with the procedures and methodology described in the ODAM. The radioactive gaseous waste system is used to reduce radioactive materials in gaseous effluents before discharge to meet the dose limits in 10 CFR Part 20 and the dose design objectives in Appendix I to 10 CFR Part 50.

The NRC staff reviewed the CNS radioactive effluent release reports for 2003 through 2009 for gaseous effluents (NPPD, 2004), (NPPD, 2005), (NPPD, 2006a), (NPPD, 2007a), (NPPD, 2008b), (NPPD, 2009a), (NPPD, 2010) to determine if there was an adverse trend (i.e., a steady and consistent annual increase in the amount of gaseous effluents discharged) that might result in levels that approach the radiation dose limits for members of the public. The gaseous effluent releases are generally consistent from year to year, allowing for variations based on plant operation, the number of refueling outages, and the scope of routine maintenance work performed. No adverse trend was observed.

2.1.2.3 Radioactive Solid Waste

The CNS radioactive solid waste disposal system collects, stores, and processes wet and dry solid waste for packaging and shipment offsite. The system consists of a wet process, which collects, processes, dewateres, and solidifies wet solid wastes, and a dry process, which collects and packages dry solid wastes. Wet solid wastes include spent resins, filter cartridges, and filter crud. Dry solid wastes include contaminated rags, clothing, paper, outage equipment, and other radioactively contaminated equipment. CNS uses a combination of onsite processing and an offsite vendor to process radioactive wastes for disposal. Transportation of the radioactive solid waste is conducted in accordance with NRC and U.S. Department of Transportation (DOT) regulations as specified in 10 CFR Part 61, "Licensing Requirements for Land Disposal of Radioactive Wastes," and 10 CFR Part 71, "Packaging and Transportation of Radioactive Material" (NPPD, 2008a).

The State of South Carolina's licensed low-level radioactive waste (LLW) disposal facility, located in Barnwell, has limited the access from radioactive waste generators located in States that are not part of the Atlantic Low-Level Waste Compact. Nebraska is not a member of the Atlantic Low-Level Waste Compact. This has had a minimal affect on CNS's ability to dispose of its solid LLW. It uses the licensed LLW disposal site operated by Envirocare in Clive, Utah, for its Class A waste. The applicant has onsite storage capacity to store its Class B and C radioactive waste during the license renewal term.

In 2007, preparation work began for the construction of an independent spent fuel storage installation (ISFSI) located on the north end of the CNS site in an area that was previously disturbed. The ISFSI will provide storage space for spent fuel storage casks. The ISFSI, in combination with the existing spent fuel pool, will store spent fuel assemblies generated during the license renewal term. Operation of the ISFSI will be in accordance with NRC regulations to ensure the spent fuel is stored safely and that worker and public radiation exposures are controlled in accordance with the dose limits specified in 10 CFR Part 20, as well as the Environmental Protection Agency's (EPA) radiation standards in 40 CFR Part 190, "Environmental Radiation Protection Standards for Nuclear Power Operations" (NPPD, 2008a).

The NRC staff reviewed the CNS LLW reports for 2003 through 2009 (NPPD, 2004), (NPPD, 2005), (NPPD, 2006a), (NPPD, 2007a), (NPPD, 2008b), (NPPD, 2009a), (NPPD, 2010). The solid waste volumes and radioactivity amounts generated in 2009 are typical of previous annual waste shipments made by CNS. Variations in the amount of solid radioactive waste generated and shipped from year to year are expected, based on the overall performance of the plant and the number and scope of outages and maintenance activities. The volume and activity of solid radioactive wastes reported by CNS are reasonable and no unusual trends were noted.

No plant refurbishment activities were identified by the applicant as necessary for the continued operation of CNS through the license renewal term. Routine plant operational and maintenance activities currently performed will continue during the license renewal term. Based on the past performance of the radioactive waste system, and the lack of any planned refurbishment activities, similar amounts of radioactive solid waste are expected to be generated during the license renewal term.

2.1.3 Nonradiological Waste Management

CNS generates nonradioactive wastes as part of routine plant maintenance, cleaning activities, and plant operations. The Resource Conservation and Recovery Act (RCRA) governs the disposal of solid and hazardous waste. RCRA regulations are contained in Title 40, "Protection of the Environment," Parts 239 through 299 (40 CFR 239, et seq.), of the CFR. Parts 239 through 259 of Title 40 contain regulations for solid (nonhazardous) waste, and Parts 260 through 279 contain regulations for hazardous waste. RCRA Subtitle C establishes a system for controlling hazardous waste from "cradle to grave," and RCRA Subtitle D encourages States to develop comprehensive plans to manage nonhazardous solid waste and mandates minimum technological standards for municipal solid waste landfills. Nebraska State RCRA regulations are administered by the Nebraska Department of Environmental Quality (NDEQ) and address the identification, generation, minimization, transportation, and final treatment, storage, or disposal of hazardous and nonhazardous waste.

2.1.3.1 Nonradioactive Waste Streams

CNS generates solid waste, defined by RCRA, as part of routine plant maintenance, cleaning activities, and plant operations. Nebraska is a part of EPA Region 7 and its solid waste program. In 1985, the EPA authorized NDEQ to administer portions of the RCRA program in the State of Nebraska that are incorporated in Title 128 (Nebraska Hazardous Waste Regulations) of the Nebraska Administrative Code (NAC). NAC Title 128 was updated in 2007 to keep current with Federal RCRA regulations.

The EPA classifies certain nonradioactive wastes as hazardous based on characteristics including ignitability, corrosivity, reactivity, or toxicity (identification and listing of hazardous waste is available in 40 CFR Part 261). States authorized to administer the RCRA program may require generators to manage additional wastes, in addition to those hazardous wastes listed by EPA.

The EPA recognizes three main types of the hazardous waste generators (40 CFR Part 262) based on the quantity of the hazardous waste produced: large quantity generators (LQGs), that generate more than 2,200 pounds (lbs) (1,000 kilograms (kg)) per month or more of hazardous waste, more than 2.2 lbs (1 kg) per month of acutely hazardous waste, or more than 220 lbs (100 kg) per month of acute spill residue or soil; small quantity generators (SQGs) that generate more than 220 lbs (100 kg), but less than 2,200 lbs (1,000 kg) of hazardous waste per month; and conditionally exempt small quantity generators (CESQGs) that generate 220 lbs (100 kg) or less per month of hazardous waste, or 2.2 lbs (1 kg) or less per month of acutely hazardous waste, or less than 220 lbs (100 kg) per month of acute spill residue or soil. The State of Nebraska has incorporated the EPA's regulations regarding hazardous wastes and recognizes CNS as a CESQG of hazardous wastes under Title 128, Chapter 8 of the NDEQ Administrative Code. CNS generates small amounts of hazardous wastes including spent and expired chemicals, laboratory chemical wastes, and occasional project-specific wastes. As reported in the NPPD environmental report (ER), CNS produced no hazardous waste in 2003, 1,112 lbs (504 kg) in 2004, 4,285 lbs (1,944 kg) in 2005, 5,317 lbs (2,412 kg) in 2006, and 308 lbs (140 kg) in 2007 (NPPD, 2008a). The increase in quantity of the hazardous waste produced by CNS in 2005–2006 was due to large volumes of paint used during outages, as was confirmed by the NRC staff during the site audit. Used oil, produced during operation of CNS, is sent offsite to the EPA-approved hazardous waste disposal facility (NPPD, 2009c).

The EPA classifies several hazardous wastes as universal wastes; these include batteries, pesticides, mercury-containing items, and fluorescent lamps. NDEQ has incorporated the EPA's

regulations (40 CFR Part 273) regarding universal wastes in Chapter 25 of Title 128 of the NAC. NDEQ defines used batteries, pesticides, mercury-containing items, spent non-Toxic Characteristic Leaching Procedure (TCLP) fluorescent and high intensity discharge (HID) lamps, cathode ray tubes (CRTs), and electronics as universal waste; such wastes make up the majority of the hazardous wastes produced by CNS. The NPPD ER reports that in 2007, CNS produced 20,860 lbs (9,462 kg) of electronic waste, 6,190 lbs (2,808 kg) of lamps, and 25,200 lbs (11,431 kg) of batteries (NPPD, 2008a).

CNS does not routinely chlorinate circulating water systems; however, the periodic use of chlorine/bromine in the circulating water system and cooling water system is allowed in CNS National Pollutant Discharge Elimination System (NPDES) Permit No. NE0001244 (NPPD, 2008a). Radioactive liquid waste is addressed in Section 2.1.2. Section 2.1.7.3 provides more information on the CNS NPDES permit and permitted discharges.

The Emergency Planning and Community Right-to-Know Act (EPCRA) requires applicable facilities to provide information on hazardous and toxic chemicals to local emergency planning authorities and the EPA (Title 42, Section 11001, of the *United States Code* (42 USC 11001)). On October 17, 2008, the EPA finalized several changes to the Emergency Planning (Section 302), Emergency Release Notification (Section 304), and Hazardous Chemical Reporting (Sections 311 and 312) regulations that were proposed on June 8, 1998 (63 FR 31268). CNS is subject to Federal EPCRA reporting requirements and thus, submits an annual Section 312 (Tier II) report on hazardous substances to local emergency agencies.

Low-level mixed wastes (LLMW) are wastes that contain both LLW and RCRA hazardous waste (40 CFR 266.210). The EPA (or any authorized State agency) regulates the hazardous component of the mixed waste through RCRA, and the NRC regulates radioactive waste subject to the Atomic Energy Act (AEA). CNS, as a CESQG under RCRA Subtitle C, periodically produces small amounts of LLMW, mainly from the use of liquid cleaners, and sends it offsite for disposal to an approved disposal facility.

2.1.3.2 *Pollution Prevention and Waste Minimization*

NPPD established company-wide recycling programs at its major and minor facilities, with a growing Green Team, that focuses on pollution prevention, waste minimization, and education of personnel. CNS implements this program and participates in Green Team activities. NPPD compiles an annual recycling report that summarizes recycling efforts at various locations including CNS. As a result of the CNS recycling efforts, 51.2 tons (46 metric tonnes (MT)) of office paper, 6,800 lbs (3.1 MT) of batteries, 8,500 lbs (3.9 MT) of electronic waste, and 2,675 lbs (1.2 MT) of fluorescent lamps were recycled in 2008 as stated in the "Nebraska Public Power District 2008 Recycling Report" (NPPD, 2008a).

In support of nonradiological waste minimization efforts, the EPA's Office of Prevention and Toxics has established a clearinghouse that provides information regarding waste management and technical and operational approaches to pollution prevention (EPA, 2009c). The EPA's clearinghouse can be used as a source for additional opportunities for waste minimization and pollution prevention at CNS, as appropriate.

Affected Environment

The EPA also encourages the use of Environmental Management Systems (EMSs) for organizations to assess and manage the environmental impact associated with their activities, products, and services in an efficient and cost-effective manner. The EPA defines an EMS as “a set of processes and practices that enable an organization to reduce its environmental impacts and increase its operating efficiency.” EMSs help organizations fully integrate a wide range of environmental initiatives, establish environmental goals, and create a continuous monitoring process to help meet those goals. The EPA Office of Solid Waste especially advocates the use of EMSs at RCRA-regulated facilities to improve environmental performance, compliance, and pollution prevention (EPA, 2009c).

2.1.4 Plant Operation and Maintenance

Maintenance activities conducted at CNS include inspection, testing, and surveillance to maintain the current licensing basis of the facility and to ensure compliance with environmental and safety requirements. Various programs and activities currently exist at CNS to maintain, inspect, test, and monitor the performance of facility equipment. These maintenance activities include inspection requirements for reactor vessel materials, boiler and pressure vessel in-service inspection and testing, maintenance structures monitoring program, and maintenance of water chemistry.

Additional programs include those implemented to meet technical specification surveillance requirements, those implemented in response to the NRC generic communications, and various periodic maintenance, testing, and inspection procedures. Certain program activities are performed during the operation of the unit, while others are performed during scheduled refueling outages. Nuclear power plants must periodically discontinue the production of electricity for refueling, periodic in-service inspection, and scheduled maintenance. CNS refuels on an 18-month interval.

2.1.5 Power Transmission System

The NPPD notes in their ER that four transmission lines, three of which are owned and operated by NPPD, are considered in scope for license renewal. Three of these four lines are numbered and connect CNS to the regional grid via 345-kilovolt (kV) transmission lines, and total approximately 148 mi (238 km). Two of these numbered lines, NPPD TL3501 and NPPD TL3502, form a transmission line corridor extending 146 mi (233 km) west-northwest from CNS in Nemaha County and ending within 4 mi (6 km) east of Grand Island in Merrick County. Line NPPD TL3501 originates at CNS and extends approximately 64 mi (103 km) west-northwest to the Mark T. Moore substation, located 1.5 mi (2.4 km) north of Hallam, Nebraska. Line NPPD TL3502 extends approximately 83 mi (134 km) west-northwest from the Moore substation and ends east of Grand Island, crossing the Platte River within 1 mi of the Grand Island substation (Figure 2.1.5-1). This transmission line right-of-way (ROW) originating from the CNS switchyard spans Nemaha County, Johnson County, Gage County, Lancaster County, Saline County, Fillmore County, York County, Hamilton County, and Merrick County, Nebraska. Line NPPD TL3504 originates at CNS and extends 0.6 mi (1 km) east from the plant and midway to the Missouri River, where it connects with a transmission line owned by Mid-America Energy that is not considered in scope. A fourth unnumbered transmission line connects from the plant to the switchyard and is also considered in the scope of license renewal (NPPD, 2008a).

There are several additional transmission lines that connect with the CNS switchyard that are neither owned nor operated by NPPD. These consist of two transmission lines connecting with the CNS switchyard which are owned by Omaha Public Power District (OPPD). Another transmission line connecting with one of the OPPD lines, not connected to the CNS switchyard is owned by Kansas City Power and Light. However, whether a line is in scope for license renewal depends on more than just whether they were constructed for connection to the grid, (i.e., lines originally constructed for connection but no longer necessary are not in scope).

The transmission lines do not cross any Federal, State, or local parks. However, the western half of the only one in scope transmission line corridor traverses counties that are part of the U.S. Fish and Wildlife Service's (USFWS) Rainwater Basin Wetland Management District (RBWMD). The RBWMD contains 61 tracts of wetlands comprising over 21,000 ac scattered over 14 counties in southeastern Nebraska, and are managed to provide resting stops for millions of migratory birds (USFWS, 2009a).

Farming occurs virtually unimpeded under the majority of the transmission lines, and only the footprints of the poles are not used for crops (NPPD, 2008a). On the CNS property, the agricultural land is managed by two farmers under an agreement with NPPD. According to the staff of NPPD, approximately 70 percent of the transmission line corridor beyond the CNS site traverses cropland, and NPPD has easements with the individual property owners to perform maintenance activities along the corridor. Where the remaining 30 percent of the transmission line corridor crosses forested areas, including wetlands and streams, NPPD has vegetative maintenance procedures in place to prevent vegetation from interfering with the lines (NPPD, 2006b).

NPPD uses an integrated management approach to maintain vegetation along the transmission line ROW that includes both mechanical and chemical control methods. Mechanical control methods in the non-cultivated areas include clearing only woody plants with growth habits that may interfere with the transmission lines or the removal of tall trees that may fall onto the transmission line tower poles. Chemical treatment is used to control brush and re-growth of stumps following mechanical cutting (NPPD, 2006b). Native grasses and low growing woody plants are allowed to grow below the power lines within the forested ROWs (NPPD, 2008a). All tree trimming performed by NPPD follows American National Standards Institute (ANSI) guidelines for maintaining safe clearance and operation of the electrical systems. Chemical control methods adhere to the State of Nebraska, Department of Agriculture guidelines for application of restricted-use herbicides. All personnel involved with herbicide applications are trained and certified on the application of restricted-use herbicides by the State of Nebraska or a reciprocating State. For mechanical vegetation management in wetlands or along the shoreline of the Missouri River, NPPD contacts the U.S. Army Corps of Engineers (USACE) to determine if there is a need to obtain a Section 404 permit (NPPD, 2006b). NPPD staff has indicated that no chemical treatment of vegetation is performed in wetlands. Chapter 3 of the NPPD Corporate Environmental Manual (NPPD, 2007b) includes provisions for NPPD personnel and vendors/contractors to follow for any land disturbance activities, including work performed in wetlands or along riverbanks.

ROW aerial inspections occur six times annually, and there is an annual foot patrol inspection; additional patrols are conducted following severe storms. Maintenance activities are performed in compliance with the Endangered Species Act (ESA), the Bald and Golden Eagle Protection Act, and the Migratory Bird Treaty Act. Birds that are nesting are protected except for nests of pigeons, house sparrows, and starlings (NPPD, 2006b).

Affected Environment




Figure 2.1.5-1. Cooper Nuclear Station Transmission Line Corridor
(Modified from NPPD, 2008a)

2.1.6 Cooling and Auxiliary Water Systems

CNS lies on the western shore of the Missouri River, withdraws river water for its once-through cooling system, and discharges heated water back to the river. Unless otherwise cited, the NRC staff drew information about CNS's cooling and auxiliary water systems from NPPD (2006c) and the applicant's ER. In the vicinity of the plant, the Missouri River has a regulated minimum flow of 3,000 cubic feet per second (cfs) (878 cubic meters per second (m³/s)) to the southeast. The circulating water intake structure is located on the western shore of the river behind a guide wall and submerged weir meant to reduce the amount of suspended sediment in the cooling water. The weir attaches to shoreline structures north of the intake and then runs parallel to the face of the intake at a distance of 14.25 ft (4.3 m). The wall continues past the intake and ends 40 ft (12 m) downstream of the downstream corner of the intake structure. In a line riverward of the weir wall and extending downstream of it, 23 sheet pile vanes (10 ft wide by 6 ft high (3 m wide by 2 m high)), oriented at a 22 degree angle to the weir, redirect sand and gravel outward from the weir and the intake structure. After flowing generally south along the weir and vanes, river water must reverse course and turn northwest to move between the weir and shore and reach the intake bays. Water velocity between the weir wall and the cooling water intake structure is about 4 feet per second (ft/s) (1.2 meters per second (m/s)).

In winter, about 25 to 30 percent of main condenser discharge water recirculates through an ice control tunnel at the front of the intake structure and discharges in front of the trash rack to

prevent icing. Water flows beneath a curtain wall at about 1.1 ft/s (0.3 m/s). Water enters the five intake bays, four of which provide circulating water and are 22 ft (6.7 m) wide and one of which provides service water and is 22.5 ft (6.8 m) wide. The incoming water then flows through trash racks, 3/8 inch (1 centimeter (cm)) vertical bars separated 3 inches (7.6 cm) on center, at up to 0.7 ft/s (20 centimeters per second (cm/s)).

The circulating water intake bays each separate into two screen bays and the service water intake bay narrows before water encounters the traveling screens, which are oriented at right angles to the flow. Water filters twice through nine 1/8 by 1/2-inch (.3 cm by 1.3 cm) smooth-top mesh modified dual-flow traveling screens (eight for circulating water and one for service water). The upward pass is in the front and the downward pass is behind the screens that rotate continuously at 8.2 feet per minute (ft/min) (2.5 meters per minute (m/min)). The intake water velocity at the screens is about 2 ft/s (0.6 m/s).

After the 4.2-ft (1.28-m) wide traveling screen panels rotate over the upper cog and begin moving down, a high pressure (30–60 pounds per square inch gage (psig), 200–400 kilopascal (kPa)) screen wash of 3,000 gallons per minute (gpm) (0.19 m³/s) supplied by the service water pumps removes fish and debris, which return together to the river through an 18-inch (0.46-m) diameter steel pipe that discharges downstream from the intake. Although the screens are fitted with fish baskets, the system has neither a low-pressure spray system to more gently remove fish from the screens nor a fish return trough to convey fish and other aquatic organisms back to the river separately from potentially damaging debris. Debris loads are about 10 cubic yards per month (yd³/month) (8 cubic meters per month (m³/month)).

CNS plans to install “dual-flow conversion screen fish handling systems” during its current operational term. This system will have low pressure (5–10 psig, 35–70 kPa) fish washing sprays on both the ascending and descending screens and a fish return trough that is separate from the debris trough. A recovery basket will collect fish and other aquatic organisms washed from the screens, and the fish trough will return them to the river. Figures 2.1.6-1, 2.1.6-2, and 2.1.6-3 show the CNS intake structures.

Affected Environment




Figure 2.1.6-1. Cooper Nuclear Station, Intake Structure Plan (Source: NPPD, 2008a)




Figure 2.1.6-2. Cooper Nuclear Station, Intake Structure Section (Source: NPPD, 2008a)




Figure 2.1.6-3. Cooper Nuclear Station, Typical Dual Flow Screen (Source: NPPD, 2008a)

After water passes through the traveling screens, the two screen bays of each intake bay rejoin behind the screens. The four circulating water pumps, one per bay, draw water from the bays and provide up to 159,000 gpm (10 m³/s) each. The four service water pumps in the fifth bay provide a combined flow of 32,000 gpm (2 m³/s). Water from the circulating water pumps travels to and circulates through the condenser, where it cools steam from the turbines. Because of the scouring from the suspended sediment, CNS typically does not need to chlorinate the circulating water to control biological film fouling, although it has the capacity to chlorinate or brominate if needed. NPPD is studying the effectiveness of these options.

Water temperature increases about 17.8°F (10°C) as it passes through the condenser tubes. From the condenser, circulating cooling water flows through concrete tunnels to a seal well structure and then to the discharge canal, where it travels about 1,000 ft (300 m) to discharge to the river at a slight angle. Water velocity at the discharge is about 1 ft/s (0.3 m/s) at average river flow and about 5.6 ft/s (1.7 m/s) during low flow. The travel time from the intake structure to the discharge is about 20 minutes at high river flow and 10 to 12 minutes at low flow.

Cooling water flow varies with plant power and ambient river water temperature. At full load during the summer, the expected circulating water system flow is highest: about 636,000 gpm (40 m³/s). Circulating water flow is lower under other conditions. In comparison, the lowest river flow at CNS is about 3,000 cfs (85 m³/s). Under the worst conditions, the circulating water system flow would be about 47 percent of Missouri River flow and about 4 percent or less under average annual flow conditions. Stone riprap at the discharge structure prevents the discharge from eroding the river bottom.

2.1.7 Facility Water Use and Quality

CNS has a once-through circulating water system withdrawing cooling water from and discharging to the Missouri River. Each of the four facility circulating water pumps can draw a maximum of 159,000 gpm. The four service water pumps provide a combined flow of 32,000 gpm. In addition, CNS uses two wells to supply potable ground water to the facility, two wells to supply water to pump seals and one well for fire protection training (NPPD, 2008a).

2.1.7.1 Ground Water Use and Quality

The CNS property overlies the Missouri River Stream Valley Aquifer (described in Section 2.2.3) which consists of interbedded alluvial sand, silt, clay, and gravel ranging in thickness between 62 and 71 ft (18.9 and 21.6 m) (NDNR, 2008). Saturated thickness of the aquifer averages approximately 50 ft (15.2 m). In the area of CNS, the alluvial aquifer is in hydraulic contact with the Missouri River with seasonal discharge to the river during lower river stage and recharge from the river during high stage (NPPD, 2008a). Ground water usually flows from west to east toward the river, but will flow east to west when river levels are high in the spring.

The two potable water supply wells completed in the alluvial aquifer are registered with the Nebraska Department of Natural Resources (NDNR) and have a current combined pumping capacity of 250 gpm (0.016 m³/s) (NDNR, 2008). Normal operations require pumping only one well at a time to supply 125 gpm (0.008 m³/s). The wells together operate as a Nebraska Public Water Supply System under Permit No. NE3150505 from the Nebraska Department of Health and Human Services (NHHSS, 2000). The water is chlorinated, distributed onsite, and operated with preventive maintenance and cross connection/backflow prevention programs. NPPD plans to replace the two drinking water wells with two similar new wells in the near future.

Affected Environment

A third alluvial aquifer well registered with the NDNR used for fire protection training has a capacity of 750 gpm (0.047 m³/s). Two additional wells, River Wells A and B, have a capacity of 150 gpm (0.01 m³/s) each and are used to supply water for pump seals.

NPPD CNS also has authorization number NE0208256 from the NDEQ to conduct underground injection of stormwater runoff within the protected area using stormwater drainage wells (dry wells) (NDEQ, 2000). These wells look like storm drains but contain gravel at the bottom that allows the collected stormwater to seep into the fill material above the water table. This water eventually reaches the water table and disperses before likely discharging to the Missouri River.

Ground water monitoring at CNS is conducted by sampling 14 monitoring wells, 11 of which were installed to measure the concentration of tritium in ground water. Three of the wells are piezometers installed as part of the ISFSI Project. NPPD has documented seven instances of liquid radiological releases since the licensing of CNS in 1974, but none of the releases is a current source of ground water contamination (CRA, 2007). In 2008, the Cooper Nuclear Station (CNS) of the Nebraska Public Power District (NPPD) Nebraska Public Power District instituted a comprehensive program to evaluate the impact of station operations on groundwater in the vicinity of CNS. During that time period, 308 analyses were performed on 44 samples from 11 locations. In assessing all the data gathered for this report, it was concluded that the operation of CNS had no adverse radiological impact on the environment, and there are no known active releases into the groundwater or surface water at Nebraska Public Power District. Tritium was not detected in any of the groundwater samples at concentrations greater than the United States Environmental Protection Agency (USEPA) drinking water standard (and the Nuclear Regulatory Commission Reporting Limit) of 20,000 pCi/L. The tritium concentrations ranged from 238 ± 121 pCi/L to 1170 + 181 pCi/L. Strontium-89 and strontium-90 were not detected at concentrations greater than the Lower Limit of Detection in any of the groundwater samples. Iron-55 was not detected in any of the groundwater samples. Nickel-63 was not detected in any of the groundwater samples.

2.1.7.2 Surface Water Use and Quality

CNS employs a once-through cooling system using water from the Missouri River. Wing dams on the Missouri side of the river are designed to force flow into the central channel of the river. Flow in the river is channelized and carries a heavy sediment load. Sedimentation at the CNS intake is minimized by turning vanes and a sheet-pile wall set in the river that direct sediment away from the intake structure.

Surface water quality data in the CNS vicinity are provided by USACE low flow studies in support of the Missouri River Master Water Control Manual. Results show relatively small ranges of values of temperature, pH, and dissolved oxygen, but wider variations of suspended solids (USACE, 2007). None of the samples from downstream of CNS showed effects from operating the CNS once-through cooling system. However, the NDEQ, under the authority of the Clean Water Act, has designated the Missouri River in the reach from the Platte River to the Kansas border as impaired for primary contact recreation and fish consumption due to the presence of fecal coliform and polychlorinated biphenyls (PCBs). Beneficial uses of surface water identified in the CNS area are recreational, aquatic life (Warmwater A), public drinking water supply, agricultural water supply, industrial water supply, and aesthetics (NDEQ, 2004).

2.1.7.3 National Pollutant Discharge Elimination System

The Nebraska Department of Health, Water Pollution Control Council originally authorized CNS to use water from and discharge to the Missouri River. Discharge is regulated by Nebraska NPDES Permit No. NE0001244 which identifies effluent limitations, monitoring requirements, and other conditions to comply with NDEQ Title 117 and Title 119, Chapter 27 (NPDES permits rules and regulations) and 40 CFR Part 423 (NPPD, 2008a). The effluent limitations for each outfall are shown in Table 2.1.7-1.

Table 2.1.7-1. Effluent Limitations (mg/L) – National Pollutant Discharge Elimination System Permit for Cooper Nuclear Station

Outfall No.	Total Suspended Solids		Oil and Grease		Total Residual Chlorine		Temperature-°F
	Avg. Month	Max. Daily	Avg. Month	Max. Daily	Avg. Month	Max. Daily	Max. current
001	NLR	NLR	NLR	NLR	0.01	0.02	109.4
002b	30	100	NLR	10	NLR	NLR	NLR
002c	30	100	NLR	10	NLR	NLR	NLR
004	30	100	NLR	10	NLR	NLR	NLR
008	30	100	NLR	10	NLR	NLR	NLR
009	30	100	NLR	10	NLR	NLR	NLR

NLR = No Limit Required, NPPD NPDES Permit No. NE0001244

Outfall 001, the main discharge canal outfall for the circulating water system, is located approximately 1,000 ft (305 m) downstream of the CNS intake structure and empties to the Missouri River. The once-through service water and equipment non-contact cooling water discharges through Outfall 001, which empties into the discharge canal. Outfall 004 discharges overflow from the reverse osmosis treatment system and boiler blowdown and also empties into the circulating water discharge canal.

Outfalls 002b is the discharge of industrial well ground water bypass, RO reject, and boiler blowdown. Outfall 002c is the discharge of diesel generator, turbine fan heater, boiler room floor drains, and HVAC blowdown. These outfalls discharge to the Missouri River

The only NPDES non-compliance reported in the last 5 years was for total suspended solids (TSS) at Outfall 004 on August 31, 2008. The TSS averaged 37.4 milligrams per liter (mg/L), which exceeds the monthly daily permit limit of 30 mg/L. The cause of this small excess was found to be the presence of fish in the reverse osmosis treatment settling pond. The fish, introduced to the pond by flooding in 2008, stirred up bottom sediment and caused the sample to contain higher than average TSS. The treatment system did not cause the excess.

Affected Environment

In addition to the NDEQ industrial wastewater NPDES permit, CNS has an industrial stormwater discharge Permit No. NER000059 for stormwater discharge outside the power block area. Inside the power block area, stormwater discharge is directed to stormwater drainage wells permitted as Class V underground injection wells by the NDEQ under Permit No. NE0208256. The stormwater enters the storm drains and disperses in the vadose zone (i.e., the portion of the earth between the top of the ground surface and the water table) above the local water table before it likely discharges to the Missouri River.

2.1.7.4 Dredging

CNS has a USACE dredging permit NE 01-10322 to conduct maintenance dredging of the CNS intake structure. A typical dredging event removes approximately 350 cubic yards (yd³) (267.6 cubic meters (m³)) of sediment outside the main channel and discharges the dredged material downstream in the Missouri River (USACE, 2002).

2.2 SURROUNDING ENVIRONMENT

The vicinity of CNS is sparsely populated with zero population within a ½-mile radius of the plant. Brownville, Nebraska, the nearest developed community, had a 2005 population of approximately 137. The largest town within 6 mi (9.6 km), Nemaha, Nebraska, located 2.5 mi (4 km) southwest, had a 2005 population of approximately 177. The largest town with industry within 10 mi (16 km) is Auburn, Nebraska, located to the west, with a 2005 population of approximately 3,076. Nebraska City, located approximately 24 mi (39 km) northwest of the site, is the closest major town with a 2005 population of 7,035. Maryville, Missouri, located approximately 40 mi (64 km) east of the plant, is the largest community within 50 mi (80 km) with a 2005 population of approximately 10,567 (NPPD, 2008a).

CNS is located on the Missouri River at river mile (RM) marker 532.5. In the vicinity of CNS, on average the Missouri River is approximately 800 ft (244 m) wide and 28 ft (8 m) deep. Under the present flow regulation, a minimum Nebraska City flow of 31,000 cfs (878 m³/s) is maintained for navigational purposes beginning in March and extending through November. During the winter months, a minimum flow of 3,000 cfs (85 m³/s) is required for sanitary purposes. The flow is highly channelized with swift flows and heavy sediment transport.

The site is located on a constructional plain bordering the west bank of the Missouri River situated on the first bottomland of the broad, nearly level, flood plain. The USACE has stabilized the channel by use of pile dikes and bank protection. Earthen levees running parallel with the Missouri River, and flood protection levees were constructed in the area to prevent meandering of the river within the alluvial flood plain. The eastern bank of the Missouri River is chiefly a densely forested land similar to the un-farmable bluffs that run parallel to the Missouri River. To the west, there are bluffs that peak at 1,100 ft (335 m), but average 1,000 ft (305 m) along the stretch of river from Brownville to Nemaha. Beyond the bluffs, the land is a gently rolling flood plain.

There are several Native American lands within a 50-mi (80-km) radius of CNS, including the Sac and Fox Reservation, Iowa Reservation, and Kickapoo Reservation. There are also several local and county parks, golf courses, forest lands, wildlife areas, and other public recreation lands within a 50-mi (80-km) radius of CNS (NPPD, 2008a).

2.2.1 Land Use

CNS is located on approximately 1,359 ac (550 ha) of land owned and operated by NPPD, including 239 ac (97 ha) on the opposite bank (east) of the Missouri River in Atchison County, Missouri, see Figure 2.2.1-1. Of the 1,359 ac (550 ha), 949 ac (384 ha) are currently leased for agricultural activities such as farming and livestock: 234 ac (95 ha) in Missouri and 715 ac (289 ha) in Nebraska. The 234 ac (95 ha) on the Missouri side of the river intermittently flood and are mostly wooded wetlands, with 40 of these acres (16 ha) cleared for agricultural activities. The developed portion of the plant site, consisting of the power plant structure and associated buildings, maintenance facilities, parking lots, and roads, occupies approximately 55 ac (22 ha) of the site (NPPD, 2008a).




Figure 2.2.1-1. Cooper Nuclear Station Facility Location (Source: NPPD, 2008a)

Affected Environment

The immediate area around the station is completely enclosed by a security fence, with access to the station controlled at a security gate. The exclusion area, as defined by 10 CFR 100.3, surrounds the plant site as shown in Figure 2.2.1-2. The plant site can be accessed by road on the west side or from the Missouri River on the east. Road access to the plant site is from Nemaha County 648A Avenue. A railroad spur connected to the site during construction was abandoned by the Burlington Northern Railroad. The Steamboat Trace Recreational Trail runs north and south through NPPD property west of the station along the abandoned railroad right-of-way (ROW). The nearest residences lie 0.9 mi beyond the site boundary to the northwest (NPPD, 2008a).




Figure 2.2.1-2. Cooper Nuclear Station, Site Boundary Map (Source: NPPD, 2008a)

2.2.2 Climate and Meteorology

Nebraska is located in the middle portion of the Great Plains. The Great Plains occupy a large region extending from southern Canadian provinces and parts of States such as Montana, North Dakota, and Minnesota and southward to Texas, New Mexico, and Louisiana (Wishart, 2004). Nemaha County, where CNS is located, is a part of the Dissected Till Plains that occupy much of Iowa, eastern Nebraska, northwestern Missouri, and small areas of northwestern Illinois, southern Minnesota, and northeastern Kansas. Moderately dissected, glaciated, flat-to-rolling terrain that slopes gently toward the Missouri and Mississippi River valleys characterizes this area.

Nebraska has a highly variable continental climate, with a large range of both diurnal and annual temperatures and considerable diversity. There are significant precipitation and temperature variations from east to west of Nebraska. The climate of eastern Nebraska is classified as Dfa by the Köppen Climate Classification System: a humid continental climate with hot summers and year round precipitation.

The State of Nebraska belongs to the High Plains National Oceanic and Atmospheric Administration (NOAA) Regional Climate Center, which is a Federal-State cooperative effort. The two closest NOAA National Weather Service (NWS) stations, which provide the most current meteorological data for the area, are in Lincoln and Omaha, Nebraska, and are located 61 mi (98 km) northwest and 62 mi (100 km) north from CNS, respectively.

Strong northwestern winds during winter bring cold Arctic air masses from Canada. Occasional low-pressure systems moving from southwestern States cause high winter winds and severe blizzards. The average annual wind speed for the NWS station located in Lincoln, NEBRASKA, is 10.1 miles per hour (mph) (8.8 knots) and 10.5 mph (9.1 knots) for the Omaha NWS station (NCDC, 2009a). In the summer, winds are predominantly from the south. Annual normals for the 1971–2000 30-year period, provided by the University of Lincoln, indicate that the annual mean temperature was 51.1°F (10.6°C), with a minimum annual temperature of 39.3°F (4°C), and a maximum annual temperature of 62.8°F (17.1°C) (UNL, 2009).

The occurrence of severe weather events in Nebraska is high. During 1950–2009, Nemaha County reported 274 storm events, mostly consisting of tornadoes and high winds with thunderstorms and hail. According to the National Climatic Data Center (NCDC), 17 tornadoes were reported in Nemaha County from January 1950 to February 2009: five at F0, seven at F1, four at F2, and one at F3 strengths (NCDC, 2009b). Occurrence of floods in Nemaha County is less than one per year. Usually they do not cause any significant damage; however, the Auburn flood of 1996 caused \$680,000 in property damage and \$2.1 million in crop damage.

Nebraska has wide ranges of precipitation from year to year with a steady decrease of rainfall from east to west. East and southeast areas of Nebraska receive significantly more precipitation than other areas of the State, where drought is not uncommon. According to the 1971–2000 annual normals for Lincoln, Nebraska, annual precipitation was 28.37 inches (72 cm) (UNL, 2009).

Sections 101(b)(1), 110, 169(a)(2), and 301(a) of the Clean Air Act as amended (42 U.S.C. 7410, 7491(a)(2), 7601(a)) established Mandatory Class I Federal areas where visibility is an important value. There are no Mandatory Class I Federal areas in the State of Nebraska. The closest Mandatory Class I Federal area is Hercules-Glades Wilderness Area, which is located

Affected Environment

295 mi southeast of CNS in the State of Missouri. Due to the significant distance from the site, no adverse impacts on Class I Federal areas are anticipated from CNS operation.

2.2.2.1 Air Quality Impacts.

CNS is located in Nemaha County, Nebraska, in EPA Region 7. There are no counties designated by the EPA as nonattainment or maintenance for any of the criteria pollutants in the 50-mi (81 km) vicinity of CNS. Douglas County, Nebraska, located approximately 72 mi (116 km) from CNS, is the closest maintenance county for lead.

The Nebraska Division of Air Quality of the NDEQ has primary responsibility for regulating air emission sources within the State of Nebraska. The NDEQ, with assistance from Lincoln-Lancaster County Health Department and Douglas County Health Department, conducts ambient air monitoring in Nebraska, operating 28 sites throughout the State with 34 monitors. The EPA and National Atmospheric Deposition Program also monitor air quality in Nebraska, which participates in the EPA's AIRNow Network that allows for continuous monitoring of the criteria pollutants and informs the public of current environmental conditions. NDEQ compiles an annual air quality report (NDEQ, 2008). In compliance with 40 CFR 58.10, NDEQ submitted a Network Plan for EPA review and approval that reflects changes to the ambient air monitoring program in Nebraska (NDEQ, 2009).

CNS has a number of stationary emission sources, such as three standby emergency power supply diesel generators, auxiliaries required for safe starting and continuous operation, and which are tested periodically to ensure their reliability to perform their intended function, and several petroleum fuel storage tanks. Since CNS's actual annual emissions are less than the criteria defined in Title V of the Clean Air Act and in Chapter 5, Title 129 of Nebraska Administrative Code for criteria pollutants and hazardous air pollutants (HAPs), CNS has been granted a low emitter status by the NDEQ Air Quality Section. As reported and submitted to NDEQ, actual total annual emissions at CNS from 2004 to 2008 were 11.52 tons (10.45 MT), 10.73 tons (9.73 MT), 13.21 tons (10.73 MT), 11.43 tons (10.37 MT), and 9.85 tons (8.94 MT), respectively. From 2004 to 2008, maximum reported annual emissions were reported in 2006: 0.16 tons (0.15 MT) of PM₁₀, 2.41 tons (2.19 MT) of CO, 0.22 tons (0.20 MT) of VOC, 9 tons (8.16 MT) of NO_x, 1.41 tons (1.28 MT) of SO_x, and 0.01 tons (0.009 MT) of single HAP (NPPD, 2009c). Used oil is collected for offsite disposal; therefore, no used oil incineration activities occur on the CNS site. Used oil disposal is discussed further in the waste management section. (Section 2.1.3.1)

CNS operates a meteorological system that consists of two monitoring sites at the ground elevation of approximately 889 ft (271 m) above mean sea level (AMSL). These first monitoring sites consist of a 328-ft (100-m) primary meteorological tower and a 32.8-ft (10-m) backup tower. The former is located approximately 1,230 ft (375 m) and the latter is located approximately 1,597 ft (487 m) from the northwest corner of the reactor building, respectively.

A new monitoring site, a 328-ft (100-m) meteorological tower, tower is being planned for 2010. The design details are incomplete, but the new tower will meet or exceed the performance standards of the existing tower and will be fully compliant with NRC. There are two independent but identical dual sensors, system A and system B, mounted onto the 328-ft (100-m) primary meteorological tower measuring temperature, wind speed, and direction at 32.8 ft (10 m), 197 ft (60 m), and 328 ft (100 m). Vertical temperature differential is measured with temperature sensors between all three levels. A relative humidity sensor is positioned at the 32.8 ft (10 m) level. Precipitation is measured at ground level (NPPD, 2008a).

The meteorological data (15-minute and hourly average) is run through meteorological data validation software that checks and flags data discrepancies and inputs it to the CNS plant computer. In the case of a complete system failure, the NWS office, located in Valley, Nebraska provides backup meteorological data by telephone or National Warning System (NPPD, 2008a).

2.2.3 Ground Water Resources

As described by the United States Geological Survey (USGS, 1997), the Western Interior Plains Bedrock Aquifer System is beneath the CNS site but contains no fresh water. The only freshwater aquifer system beneath the site consists of unconsolidated alluvial deposits of the Missouri River Stream Valley Aquifer and glacial deposits of the Glacial Drift Aquifer. These deposits are reworked and difficult to distinguish within the main river valley. All of the onsite wells are completed in these deposits and the aquifer is under unconfined (water-table) conditions (NPPD, 2008a).

As part of a hydrogeologic investigation undertaken by CNS for the study of radioisotopes in ground water, Conestoga Rover Associates (CRA) reviewed water use in the area surrounding the station and searched the NDNR water-well database for all wells in Nemaha County. Three irrigation wells, completed in the shallow unconsolidated aquifer, are located between 2 and 3 mi southwest of CNS. Four farm wells within 1 mi of the station, all only 15 ft deep, produce a limited amount of ground water. None of these wells are impacted by ground water pumping at CNS because the station wells are screened in an unconfined aquifer and have limited area of influence. A search of wells by NPPD in Atchison County, Missouri, across the river from CNS identified no wells within 2 mi of the station. In addition, the Missouri River serves as a ground water recharge/discharge boundary.

Because of the limited radius of influence of CNS wells completed in the unconfined aquifer, no public ground water supplies are close enough to CNS to be impacted by ground water use at the station. There are no well-head protection areas or EPA-designated sole source aquifers in the vicinity of CNS (CRA, 2007).

2.2.4 Surface Water Resources

CNS is within the Nemaha River Basin whose water resources are managed by the Nemaha Natural Resources District (NNRD). The basin is defined as those areas south of the Platte River that drain directly into the Missouri River. The total area of the basin is 2,800 square miles (mi²) (7,252 square kilometers (km²)) (NPPD, 2008a).

Flow of the Missouri River at CNS is partially controlled by the Gavins Point Dam located approximately 200 mi (321 km) upstream near Yankton, South Dakota. The USACE constructed and operates six of the seven mainstem dams on the Missouri River; the U.S. Bureau of Reclamation operates the seventh dam located east of Helena, Montana. The confluence of the Platte and Missouri rivers is located 63 mi (101 km) north of CNS. The Platte River discharges a significant amount of sediment into the Missouri, much of which is carried downriver to CNS and beyond (NPPD, 2008a).

At CNS, the Missouri River is approximately 800 ft (244 m) wide and 28 ft (8.5 m) deep in the main channel. As currently regulated by the USACE, the minimum flow in the river for navigation purposes in March through November at Nebraska City, NE, 30 mi (48.3 km) north of CNS, is 31,000 cfs (878 m³/s). In December through February, the minimum flow permitted is 4,320 cfs (122 m³/s). The lowest flow recorded at Nebraska City was 4,320 cfs (122 m³/s) in 1957. If a

Affected Environment

severe drought occurs, USACE would shorten the navigation season to keep upstream reservoirs high enough to maintain minimum sanitary flows. Water release schedules and priorities for the dams are contained in the USACE Master Manual (USACE, 2004a).

Water level elevations in the river at CNS range from 874.5 to 899 ft (266.5 to 274 m) AMSL with an average level of 880 ft (268 m). The mean annual discharge of the river at Nebraska City is 42,160 cfs (1,194 m³/s) as measured and calculated for the years since 1948 when the upstream impoundments started to control flows. Because the river has been channelized and has a relatively uniform cross-section, flow velocity is up to 3 mph (3.8 kilometers per hour (kmh)), which is significantly higher than historic flows prior to completion of the major impoundments (NAS, 2002).

Significant changes in the Missouri River due to management practices include loss of natural flood and low flow processes, straightening of meanders, bank stabilization, and reduction of temperature variation. These changes, although ecologically significant, result in a more stable water supply for CNS.

2.2.5 Description of Aquatic Resources

2.2.5.1 *Ecosystem Services Provided by Missouri River Aquatic Ecosystems*

The Missouri River has provided and continues to provide many ecological services to people living within its basin. The phrase ecosystem services "refers to a wide range of conditions and processes through which natural ecosystems, and the species that are part of them, help sustain and fulfill human life" (Daily et al., 1997). These services are intrinsic to the river itself and go beyond the obvious constructed economic services of providing a route for transportation or a source of water for irrigation and public consumption.

Daily et al. (1997) provide examples of general ecosystem services, and the NRC staff identified the following ecosystem services specifically provided by the Missouri River. The Missouri River supports birds and other wildlife through fish, insect, and other food webs and also provides recreational and commercial fishing. The river supports populations of mussels that once were a major source of food, tools, and jewelry for Native Americans and later a source of buttons and starting nuclei for cultured pearls. It provides drinking water that supports many forms of domestic animals and wildlife and helps maintain biodiversity from which key ingredients are derived for agricultural, pharmaceutical, and industrial enterprises. The river supports the aquatic phase of insect predators that help control agricultural and other pests.

Within the Missouri River ecosystem, bacteria, algae, fungi, and invertebrates absorb waste nutrients and break down, detoxify, and decompose various wastes and, in doing so, purify water. Living and nonliving components of the aquatic ecosystem participate in the oxygen, carbon, and nitrogen cycles and help mediate concentrations of oxygen and carbon dioxide in the air. Bacteria, fungi, and invertebrates, that break down wastes and organic matter, help make the soil fertile with suspended solids that the river deposits following floods. In doing this, the river helps cycle and move nutrients. The river also helps disperse seeds of some natural vegetation. The Missouri River helps maintain the balance of recharge to the ground water and cycling of water back to air as part of moderating the water cycle. The river also provides aesthetic beauty, intellectual stimulation, and opportunities for education.

2.2.5.2 Conceptual Model of Midwestern Rivers

Karr et al. (1985) summarized the history and sources of degradation of Midwestern rivers. The conclusions, which they illustrate with examples from the Maumee and Illinois rivers, are applicable to understanding the aquatic resources of the Missouri River near CNS today. Karr et al. (1985) found that the human activity with the greatest impact on Midwestern fish communities was agriculture, which lowers the water table and supplies excess nutrients; navigational locks and channels in large rivers; impoundments, levees, and milldams; discharge of wastes that consume oxygen and toxic contaminants; overconsumption of water; and introduction of exotic species. The authors presented a conceptual model to illustrate the links between these activities and those for recovery and restoration of Midwestern river fish communities.

In their conceptual model (Figure 2.2.5-1), five primary variables affect the integrity of aquatic biota:

- (1) The energy source may be primarily allochthonous (not formed in situ, but originating in another place) organic matter or primary production. As well as the amount of energy, the size distribution of organic particles affects aquatic communities.
- (2) Water quality includes such factors as temperature, turbidity, dissolved oxygen concentration, soluble organic and inorganic materials, metals, and toxic substances.
- (3) Habitat structure includes such things as bottom type (e.g., hard substrata, sand); water depth; current velocity; availability of spawning, nursery, and hiding places; and habitat diversity.
- (4) Flow regime indicates water volume, seasonality and temporal distribution of flow and water volume, and frequency of flooding.
- (5) Trophic interactions among biotic components include such factors as competition, predation, disease, and parasitism.

Natural changes and human activities act through these five primary variables affecting the integrity of aquatic biota to cause changes in aquatic communities. The following summary of natural and human history in the Missouri watershed, represented in Figure 2.2.5-1, shows continual changes in the factors that influence the structure and function of aquatic communities in this Missouri River.




Figure 2.2.5-1. Conceptual model showing primary external and internal variables with their interactions that govern the integrity of the aquatic biota of Midwestern streams (After Karr et al., 1985)

2.2.5.3 Description of the Missouri River Basin

The nature of Missouri River aquatic resource communities strongly reflects the formation and history of the prairie region it drains. The Missouri River basin is large, and its present ecology was formed fairly recently on a geological and evolutionary time scale. Because of its size, the basin encompasses many diverse habitats on regional and local levels. Because it is fairly recent, many species that live in the basin are not endemic but have evolved elsewhere and moved into the basin. The present ecology of aquatic communities reflects a history of change both prehistoric and historic and of habitat diversity within seasons and across various geographic scales.

The modern Missouri River basin is the second largest in the United States and drains about a sixth of the conterminous United States as well as part of Canada, including all or parts of 10 U.S. States, 2 Canadian provinces, and 25 Native American lands or tribal reservations. Many of the Missouri River's tributaries drain east to the main stem, which flows roughly southeast. Starting from the west, the river basin drains three physiographic divisions: the Rocky Mountain System, which contributes a little over 10 percent of total flow; the Interior Plains; and the Interior Highlands. Most of the river flows through the highly erodible soils of the Great Plains and Central Lowlands' physiographic provinces of the Interior Plains division, which produces high turbidity and sediment transport (Galat et al., 2005b).

Change and perturbation heavily influence the ecology of the Missouri River, including the aquatic ecology. Glaciers covered much of the basin during the last ice age and helped determine the course of the modern Missouri River and its tributaries, as well as land forms and soils. The modern prairie drained by the Missouri River is relatively young and formed in the last several million years so that much of the flora and fauna have colonized from surrounding ecosystems and few species evolved in and are endemic to the prairie (Benedict et al., 1996). Between the last ice age, which ended about 10,000 years ago, and the beginning of recorded

history of the prairie, invasion and colonization of the basin by plants and animals, and later humans, and extinction of nearly all large mammal species brought further change. Early human settlement probably had limited effects on the ecology of the basin until the 20th century, when the Federal government intervened to encourage further settlement and development (National Research Council, 2002).

Increased settlement occurred through the 1800s, and irrigated agriculture resulted in the early construction of first small and then larger dams in the late 1800s. From the mid-1820s through the 1870s, the Federal government worked to remove large tree snags from the Missouri River to improve navigation. The USACE began stabilizing the river banks in the late 1880s. Construction of hydropower dams began in the late 1800s. Several irrigation projects began in 1904, and by the 1930s, most of the tributaries of the Missouri River had one or more dams. In the late 1920's, the USACE began a program that combined bank stabilization with dike construction and strategic dredging designed to narrow the river and eliminate meandering. Where the USACE eliminated wide bends in the river and narrowed the channel, the river's velocity increased, and in some places the river became self-scouring. The subsequent Federal Pick-Sloan Plan in 1944 led to the construction of six main-stem dams and dedicated upstream storage to three primary uses: hydropower generation, navigation enhancement, and flood control (National Research Council, 2002).

Today the Missouri River is highly regulated, with about 1,200 single-purpose and 100 multipurpose reservoirs, including six reservoirs on the main stem (Galat et al., 2005a), (Galat et al., 2005b). The aquatic community has been highly influenced by damming and channelization. The reservoirs have changed lotic (i.e., pertaining to still or standing water) habitat into lentic (i.e., pertaining to flowing or running water) habitat and impaired the migration of fish and other aquatic organisms. The construction of structures such as dikes, levees, stabilization structures, and dams have added hard substrata, or replaced soft substrata with hard substrata in aquatic habitats. The reservoirs, channels, and structures affect physical habitat, water temperature and quality, flow regimes, suspended sediment loads, and light penetration, and many other attributes of the aquatic ecosystem (Galat et al., 2005a), (Galat et al., 2005b). The prairie is subject to frequent perturbations on time scales that range from shorter than a year to those spanning decades or millennia, such as fire, drought, flooding, grazing, storms, and local events such as digging activities of animals (Benedict et al., 1996). All of these influences affect aquatic habitats and communities.

The climate in the basin is semi-arid, and both direct precipitation and snow melt contribute to the flow, which results in a seasonal succession of low and high flows. Before dam construction and regulation, river flows peaked twice a year: A smaller peak in March through April as snow and ice melted in the middle and upper basins and the prairie, and a second, larger peak in June as the result of melting snows in the Rocky Mountains and precipitation over the prairie. Overbank flooding was common during peak flows. Flows then declined in July and remained low until spring (Galat et al., 2005a).

Before dam construction and regulation of the river, the variation in flow drove changes in the river channel's location, form, and volume of sediment transported. The river carried large amounts of sediment and was known as the "Big Muddy." During high flows, erosion could be severe. As flooding subsided, the river deposited substantial amounts of sediments on flood plains. In a dynamic equilibrium, the river redistributed sediments between its channel and floodplain. The channel was braided to highly sinuous and "characterized by log jams, snags, whirlpools, chutes, bars, cut-off channels, and secondary channels around bars" (National Research Council, 2002). Sand bars shifted frequently. "A typical cross-section of the

Affected Environment

pre-regulation Missouri River contained a deep channel, multiple side channels, oxbow lakes, islands, sand bars and dunes, and backwater habitats interspersed by areas of higher land." The seasonal pattern of flow and temperature cued many natural processes, such as fish spawning, insect emergence, and seed germination. The diverse habitat with frequent disturbance supported high biodiversity and biological productivity (National Research Council, 2002).

In the post-regulation Missouri River, main stem dams dampen the high variation in flows below them, and the extremely high and low flows no longer occur. Dredging and channelization have eliminated much of the temporal and spatial variation. In channelized areas, a typical cross section of the post-regulation Missouri River is trapezoidal rather than varied, and in places, complex. Suspended sediment loads now drop from suspension in the relatively still water of reservoirs behind dams, where clearer water supports greater primary productivity and aquatic species that hunt by vision. Channel degradation occurs below the dams while sedimentation accumulates in reservoirs, and these processes slowly change aquatic habitats. Seasonal cues to biological processes are muted. Fish no longer use floodplains seasonally for spawning and as nursery areas for their young. The water, sediment, and nutrients that once spread across the flood plains are now contained within the channel and reservoirs. In the change from pre- to post-regulation, some aquatic species thrived, and some, such as pallid sturgeon (*Scaphirhynchus albus*) and sauger (*Sander canadense*), experienced sharp reductions. Overall, the less diverse habitat and decreased disturbance of the post-regulation Missouri River support lower biodiversity and lower biological productivity (National Research Council, 2002).

The biological classifications of its terrestrial ecosystems, land uses, and the distribution of fish in the entire basin and in the main stem illustrate the spatial diversity of the Missouri River. The Missouri River flows through and drains six terrestrial ecoregions: North Central Rockies Forests, Montana Valley and Foothill Grasslands, Northwestern Mixed Grasslands, Northern Mixed Grasslands, Central Tall Grasslands, and the Central Forest/Grassland Transition Zone (Galat et al., 2005b). Within 3 mi (5 km) of the river, however, most of the land use is in cropland (33 percent), grassland (26 percent), and developed land (17 percent) (Galat et al., 2005b). Abell et al. (2000, 2008) define three aquatic ecoregions of the Missouri River primarily on the basis of fish distribution: the Upper Missouri, Middle Missouri, and the Central Prairie.

Based on geomorphology and hydrology, Galat et al. (2005a, 2005b) recognize three zones of the Missouri River main stem: (1) the upper zone, from the origin of the Missouri River to Fort Peck Lake, Montana, which is the first major impoundment, is unchannelized and largely flows freely; (2) the middle zone, from the upper end of Fort Peck Lake to the Gavins Point Dam, which forms Lewis and Clark Lake, is not channelized but has impoundments, and can be subdivided into a reservoir zone made up of individual impoundments separated by an inter-reservoir, riverine zone that connects them; and (3) the lower zone, from Gavins Point Dam to the confluence with the Mississippi River, is channelized and has bank stabilization and floodplain levees. CNS lies within the lower, channelized zone.

2.2.5.4 Physical Features of the Missouri River near the Cooper Nuclear Station

CNS is located on the west bank of the Missouri River at RM marker 532.5 (1,960 RM). The bottom contour of the river at CNS is roughly trapezoidal. The Missouri River channel in front of CNS is at an elevation of about 860 to 865 ft (262 to 265 m) AMSL compared to the natural grade level of the flood plain around CNS of 890 ft (271 m) AMSL. On average, the river is about 800 ft (245 m) wide and 28 ft (8.5 m) deep in the vicinity of CNS. Riprap covers some

areas of shoreline near the CNS, and soft sediments are typically composed of medium to coarse sand. Pile dikes and shoreline protection stabilize the channel. Gavins Point Dam, located about 200 RM (322 river kilometers (RKm)) upstream in Yankton, South Dakota, largely controls the flow of the Missouri River at CNS. The flow changes seasonally, but the annual mean river flow from 1930 through 2001 was 38,251 cfs (1,083 m³/s) at the USGS gauging station located about 30 RM (48 RKm) upstream at Nebraska City, Nebraska. NPPD owns the 345 kV transmission line designated as TL3504 that passes over the Missouri River at CNS; at the center of the Missouri River, transmission line ownership changes (NPPD, 2008a).

2.2.5.5 *Potentially Affected Aquatic Resources*

Several publications and reviews provide comprehensive descriptions of the Missouri River aquatic ecosystems, including National Research Council (2002), Galat et al. (2005a, 2005b), and USACE (2004). From the headwater streams to the main stem Missouri River, aquatic communities show the effects of man's activities. Rabeni (1996) summarized the state of the fish and aquatic resources of the prairie ecosystem as follows:

The ecological integrity of most prairie streams has been compromised, because every important relation has been affected: flow conditions by dewatering, altered land-use, and disruption of headwaters; energy source balance by the increase of instream primary production with nutrients and less shading; water quality by modern synthetic compounds and organic wastes; physical habitat by channelization and riparian degradation; and the biotic balance by the introduction of fish predators and competitors and elimination of important food sources.

Comparing this description to Karr et al.'s (1985) conceptual model of Midwestern rivers (Figure 2.2.5-1), one can see that human activities have adversely affected all aspects of the environment that influence the integrity of aquatic communities.

Much of the information summarized below is from a compendium of studies (Hesse et al., 1982) conducted in the late 1960s and early 1970s to provide ecological information for assessing the impacts of Fort Calhoun Station and CNS, both on the Missouri River. Fort Calhoun Station is a nuclear generating unit located at RM marker 646 (1,040 RKm), about 113.5 RM (183 RKm) north of CNS, which is located at RM marker 532.5 (857 RKm); the aquatic communities at the two stations are similar.

2.2.5.6 *Primary Producers: Phytoplankton, Periphyton, and Aquatic Macrophytes*

Before the completion of the dams on the main stem, phytoplankton abundance was low due to the high turbidity and current velocity and the lack of still water habitats. Although dams now replace lotic habitat with lentic habitat where sedimentation increases water clarity, the limiting factor for algal growth in much of the river is still light, not nutrients, due to turbidity (Galat et al., 2005b).

Galat et al. (2005a) summarized the ecology of planktonic algae and cyanobacteria in the Missouri River basin. Most of the information dated from the 1980s or before. Reetz (1982) reported results of phytoplankton studies conducted in the Missouri River in the vicinity of CNS and Fort Calhoun Station, about 113.5 RM (183 RKm) north of CNS, from 1974 through 1977. The composition of the phytoplankton community through the year was largely determined by discharges from Lewis and Clark Lake (RM marker 811, RKm marker 1,305), which is 278.5 RM (448 RKm) upstream, with modifications due to "production in backwater areas of the unchannelized river, production in pools behind the trail dikes in the channelized portion, input

Affected Environment

of phytoplankton from tributaries, and the scouring of periphytic forms" (Reetz, 1982, p. 73). While the species may have changed over the last several decades since Reetz's 1982 studies, the process he describes likely remains unchanged. Although Reetz (1982) could discern no clear trend in phytoplankton abundance at CNS for the 1974–1977 study period, carbon fixation rates were generally lower in winter and highest in mid-summer. Carbon fixation is the photosynthetic process by which plants convert carbon dioxide (and water) to sugar (and oxygen).

Reetz (1982) compared phytoplankton functions at the intake and discharge of both CNS and Fort Calhoun Station. Initial (7-hour) differences in carbon fixation rates at CNS ranged from an average of about 17 percent inhibition during summer to no change during winter. The inhibition in the summer months appeared to depend on absolute discharge temperature and the highest inhibition rates (above 26 percent) occurred when absolute discharge temperatures exceeded 101°F (38.5°C). Recovery from initial inhibition at CNS occurred within 48 hours. While the river would carry phytoplankton far downstream in 48 hours so that a substantial part of the river would be affected, Reetz (1982) concluded that the low rate of water use by CNS compared to river flow combined with the rapid mixing of the thermal plume would make the effects relatively unnoticeable.

Farrall and Tesar (1982) reported results of periphytic algae studies conducted in the Missouri River in the vicinity of CNS from 1972 through 1977, and Fort Calhoun Station from 1974 and 1975. Periphytic algae are those algae attached to solid surfaces under water, such as rocks, logs, pilings, and other structures. Because they remain in one place, periphytic algae colonizing natural and artificial substrata can be used as indicators of environmental effects. Algae fix carbon through photosynthesis and are a base of food webs. In some rivers, such as the Missouri River, organic matter from land and upstream sources is often another base of local aquatic food webs. Farrell and Tesar (1982) did not detect changes in the diversity, density, and biovolume of periphytic algae related to water temperature in the vicinity of CNS, although species composition did reflect water temperature. Although these results may generally be indicative of periphyton responses and processes at CNS today, species composition and magnitude of response, which depends on the species involved, may have changed over the decades since Ferral and Tesar's (1982) studies.

High turbidity, unstable substrates, and variable currents almost exclude aquatic macrophytes from the Missouri River (Galat et al. 2005a), and the NRC staff found no studies of these macrophytes in the vicinity of CNS.

2.2.5.7 *Invertebrates: Zooplankton and Benthos*

Repsys and Rogers (1982) reported results of invertebrate zooplankton studies conducted in the Missouri River in the vicinity of CNS and Fort Calhoun Station from 1972 through 1977. Zooplanktons are animals suspended in the water column and typically contain permanent residents of the water column; temporary members swept up by currents, etc.; and organisms that spend only part of their life cycle in the water column, such as insect and fish eggs and larvae. Zooplankters eat algae and bacteria, protozoans, other zooplankton, detritus, fish eggs and larvae, or a combination of these, and, in turn, are eaten by other invertebrates, fish, and amphibians. In general, zooplanktons are more adapted to the lentic environment of lakes and reservoirs than the lotic environment of streams and rivers. In flowing water environments, currents and suspended sand can buffet zooplankters and cause mechanical damage, while smaller suspended silt and clay particles can adhere to their bodies and interfere with respiration and feeding.

Repsys and Rogers (1982) concluded that the zooplankton community near CNS appears to be largely determined by upstream reservoirs, where the lentic environment encourages their production. The most common groups they collected include copepods and cladocerans (both crustaceans) and rotifers. While the general pattern of abundance in the study indicated relatively high crustacean peaks in late fall to spring and reduced populations during summer and early autumn, the pattern was poorly defined. The authors concluded that the seasonality of zooplankton densities in the limnetic Lake Francis Case, which is more like a natural lake and has high zooplankton production, influenced through releases the pattern of zooplankton downstream in the smaller and less productive Lewis and Clark Lake, which in turn influenced through releases the pattern of zooplankton downstream at CNS.

Decreasing zooplankton densities in the river indicated to them that zooplankton populations originating in the highly productive Lake Francis Case experienced considerable mortality on the downriver journey to CNS. Repsys and Rogers (1982) also investigated the effects of CNS on zooplankton populations in 1974 through 1978. High absolute discharge temperatures greater than or equal to 95°F (35°C) critically affected zooplankton survival, as did duration of exposure. Repsys and Rogers (1982) concluded that entrainment losses were small when compared to the large downstream decreases in zooplankton. Without further studies, the NRC staff concludes that these general patterns and processes most likely still occur, although species composition and magnitude of response, which depends on the species involved, may have changed over the decades since Repsys and Rogers' (1982) studies.

Carter et al. (1982) reported results of benthic infaunal and epifaunal (called aufwuchs on the artificial substrate samples employed by Carter et al.) invertebrate studies conducted in the Missouri River in the vicinity of CNS and Fort Calhoun Station from 1973 through 1977. Benthic infauna refers to the organisms that live in underwater sediments, and benthic epifauna refers to organisms that live on underwater surfaces. Benthic invertebrates form a complex community. Various members may eat algae filtered from the water column, suspended detritus and organisms, sediments, periphytic algae and bacteria, other benthic organisms, and fish eggs and larvae. Carter et al. (1982) report that the channel area of the Missouri River in the vicinity of CNS is largely unsuitable for macroinvertebrates because of continuous shifting and scouring of bottom sediments. In the lee of wing dikes, sedimentation occurs during periods of low flow and supports infaunal communities that may be lost due to scouring during periods of high flow. The seasonal diversity of the benthic community in this area is inversely related to the variability of the flow as measured on a daily basis (Carter et al., 1982): benthic diversity is higher when flows are stable. The most common members of the benthic community are oligochaete worms, primarily tubificids, which live in tubes and may avoid direct contact with the currents, and secondarily naids, which live in the surface layers of sediments and may be subject to low level scouring. Another numerically important group was insect larvae of the family Chironomidae, or non-biting midges (flies). All of these groups are indicative of organically enriched sediments and tolerate low dissolved oxygen levels and so have been designated as indicators of poor water quality (Barbour et al., 1999).

Epifaunal invertebrates in this section of the river are typically found on dikes and riprap. Carter et al. (1982) report that the most common members on dykes and artificial substrate samplers were chironomid, trichopterid (caddisfly), and ephemeropterid (mayfly) larvae. The caddisfly larvae found here are typically net spinners and filter feeders whose survival depends on currents. The chironomid larvae included grazers, predators, and tube-dwellers. The insect larvae are seasonal members of the macroinvertebrate community that become terrestrial after emergence. Carter et al. (1982) were not able to detect consistent changes in the epifaunal invertebrate community due to the operation of CNS.

2.2.5.8 Larval Fish

Hergenrader et al. (1982) report the results of both field and entrainment studies on larval fish in the vicinity of CNS in 1974 through 1976. Several life stages of fish may occur in the plankton, where they are called ichthyoplankton, and may be subject to entrainment at power plants: eggs; larvae, which include both yolk-sac and post yolk-sac larvae and have little or no fin development; post larvae, which have fully developed fins but bodies that have not yet reached the adult form; and juveniles, which have attained the adult form but are still immature. Eggs and juveniles in the collections near CNS were not commonly caught, and made up 2 percent and 1 percent, respectively, of all ichthyoplankton. Larval fish were common in the drift near CNS from May through July, and the numerically dominant fish larvae were freshwater drum, catostomids (e.g., suckers), cyprinids (e.g., minnows), and carp. Larval fish were rare or absent in other months. Although freshwater drum comprised only about 5 percent of adult fish in the vicinity of CNS, since they are pelagic spawners, spawning in the open water column, they contributed 70 to 90 percent of the larvae. Other species commonly found as larvae in the drift, common carp (*Cyprinus carpio*), catostomids, gizzard shad (*Dorosoma cepedianum*), and goldeneye (*Hiodon alosoides*), are also either random or pelagic spawners. The larvae of most of the game fish in the area—white bass (*Morone chrysops*), sunfish (*Lepomis* spp.), crappie (*Pomoxis* spp.), sauger (*Stizostedion canadense*), walleye (*Sander vitreus*), and channel catfish (*Ictalurus punctatus*)—were relatively underrepresented because most of these fish either build nests or spawn randomly, most have adhesive and demersal (sinking) eggs, and some of these species provide parental care of the eggs and larvae.

Depending on the species, the sources of the larvae near CNS included the upstream Lewis and Clark Lake, tributaries, cut-off chutes, and backwaters. Densities of ichthyoplankton also depended on time of year, river flow, horizontal position in the river (cutting bank, mid-channel, or filling bank), depth and patterns of vertical migration, and growth and mortality rates (Hergenrader et al., 1982).

Hergenrader et al. (1982) also report on entrainment mortality. The NRC staff conclude that little can be learned from their direct observations of entrainment mortality because the control mortality measured at the intake was very high, which makes estimation of plant-induced mortality impossible, and because they only observed immediate mortality (typically 20 to 40 minutes after collection), which does not provide an estimate of longer-term or chronic mortality. Injured larvae may not die immediately, and today the standard holding time for fish larvae in short-term chronic toxicity tests with a survival endpoint is typically 7 days (EPA, 2002) in order to account for mortality that is not immediate. In order to determine if entrainment (and impingement) were having an effect on the fish populations in the area, Hergenrader et al. (1982) looked for changes in adult fish populations resulting from impacts to ichthyoplankton but detected none. They concluded that either no significant changes occurred or “[t]oo few resources (financial, technical, equipment, labor) were applied over too small a time frame in too restricted an area to detect the changes which have occurred.”

2.2.5.9 Fish

Galat et al. (2005a, 2005b) report about 183 fish species from the Missouri River, of which about 136 were found in the main channel. No fish species are unique to the main stem (i.e., endemic species), and just two are endemic to the Missouri River basin. About three quarters of Missouri River fish species are native, that is, they live and survive in the river under natural conditions and have not been introduced by human activity. The majority of the species (68 percent) belong to just five families: Cyprinidae (e.g., carp, chub, dace, shiners, minnows), Catostomidae (e.g., suckers, chubsuckers, redhorse, buffalo), Salmonidae (e.g., trout, salmon, whitefish), Centrarchidae (e.g., sunfish; crappies; freshwater basses, but not striped bass and white bass), and Ictaluridae (e.g., catfish, bullhead, madtom). About half of the species are "Big-River species," meaning that they occur primarily in the main channel. Lists of species from the Missouri River can be found in Galat et al. (2005a) and USACE (2003, as reproduced in the ER).

Galat et al. (2005a) present summary data from which the NRC staff made several observations. The study lists 53 species as prevalent or common in the Central Lowlands physiographic province that includes CNS. The species were assigned to mutually exclusive guilds: most (27 spp.) are macrohabitat generalists and the rest distribute evenly between fluvial specialists and fluvial dependents (12 species each). The generalists may inhabit either reservoirs or river segments that connect them, while the other two groups are either specialized for or dependent on flowing river habitat. The high proportion of generalists reflects the variability and history of continued change in the Missouri River system. In terms of habitat, 46 of the prevalent fish species in the Central Lowlands have been found in the channel and channel borders, 9 in floodplains, and 8 in reservoirs, including the species that can be found in more than one of these habitats. The high proportion found in the channel and channel border reflects the history of the river as a flowing water body before regulation and formation of reservoirs. Within the main channel and channel borders, 35 species are associated with the main channel, 9 with channel borders, and 8 are "waifs," that is, removed from their original habitats.

CNS is located below the Gavins Point Dam, the last of the six major dams, in a riverine environment that extends unimpeded to the mouth of the Missouri River at St. Louis. The upper section of this reach is unchannelized north of Sioux City, Iowa with such diverse habitat characteristics as chutes, backwater marshes, sandbars, islands, snags, deep pools, and variable current velocities. The environment is changing due to the downstream effects of Gavins Point Dam and the sedimentation that occurs behind it, as well as some armoring of the riverbed and bank stabilization, which cause channel degradation and siltation of shallow areas, with associated loss of marshes, backwaters, and chute habitats (USACE, 2004a, p.100). Downstream of Sioux City, construction of dikes, revetments, and channelization result in a less diverse environment. Yet, the most common fish species are similar in the unchannelized and channelized portions of the river. These include emerald shiner (*Notropis antheroides*), river carpsucker (*Carpionodes carpio*), channel catfish (*Ictalurus punctatus*), gizzard shad (*Dorosoma cepedianum*), red shiner (*Notropis lutrensis*), shorthead redhorse (*Moxostoma macrolepidotum*), common carp (*Cyprinus carpio*), and goldeye (*Hiodon alosoides*). Big river fish in the lower river and its major tributaries include pallid sturgeon (*Scaphirhynchus albus*), shovelnose sturgeon (*Scaphirhynchus albus*), and paddlefish (*Polyodon spathula*) (USACE, 2004a).

The aquatic community, particularly the fish community, may not be stable and may still be changing in response to historical changes in land use, river regulation, and other human activities. For example, USACE (2004) reports that the benthic fish community appears to be

Affected Environment

changing based on 1996 and 1997 studies. The diversity of species in the unchannelized section appears to be increasing, possibly due to the diverse habitats. Typically more species are found at shallow depth (less than 2 m) and slower water velocities (less than 0.6 m/s), and fish in the unchannelized section are most abundant in the backwater areas. In the channelized segment below Sioux City, most fish are near revetments and dikes. Although surveys have found the most fish in this segment in side channels, few such habitats remain. USACE (2004) reported that ecologists know very little of the mechanisms that control fish production in the channelized segment of the river.

Other investigators have reached similar conclusions. Rabeni (1996) found that “[d]rastic changes in the streams and rivers of the prairie region and their fish fauna have occurred in the last 150 years.” More recently, the NRC (2003) reported that:

The aquatic resources in the vicinity of Fort Calhoun Station are associated with the Missouri River. The species composition of the fish community in this reach of the river has changed significantly (due to channelization) from the 1973 to 1977 fish studies associated with the initial licensing of Fort Calhoun Station and its operations.

2.2.6 Terrestrial Resources

The CNS site is located within the Missouri alluvial plains level IV ecoregion in Nebraska and Missouri, and lies near the western limit of a relatively flat, 6-mi wide (10-km) alluvial floodplain. Natural relief on the CNS site is limited to about 10 ft (3 m). Much of this floodplain has been ditched and drained for farming, with numerous levees constructed for flood protection. Immediately west of the CNS site and running north-south are bluffs rising approximately 170 ft (52 m) above the CNS property and the Missouri River (NPPD, 2008a) that transition into the Nebraska/Kansas loess hills level IV ecoregion (USGS, 2001).

According to the ER, the CNS facilities are located within 55 ac (22 ha) of a 1,120-ac (454-ha) site in Nemaha County, Nebraska, adjacent to the western bank of the Missouri River at RM marker 532.5. There is an additional 239 ac (97 ha) of undeveloped CNS property across the Missouri River and adjacent to its east bank in Atchison County, Missouri. The CNS property in Nebraska is bordered on the west by Nemaha County Road 648A Avenue, the Missouri River on the east, and by agricultural lands on the north and south sides. The CNS property in Missouri is adjacent to the eastern bank of the Missouri River and is bordered by cropland on its east and timberland on its north and south sides (Figure 2.2.1-1) (NPPD, 2008a).

On the Nebraska side of the CNS site, approximately 715 ac (289 ha) are currently used for agricultural activities. There are also more than 120 additional acres (49 ha) of vegetated, nonagricultural land located primarily contiguous with the riverbank but extending inland in some areas into the farm fields on the site. Most of these vegetated areas are classified as palustrine forested, scrub-shrub, and emergent wetlands (USFWS, 2009a) and include two segments of intermittent streams and, according to NPPD staff, a 55-ac (22 ha) wetland area, which includes an approximately 1.5-ac mitigation site. One wetland area is located in the middle of a farm field in the south-central part of the property (Figure 2.2.6-1). The USFWS has identified over 700 wetlands within a 6-mi (10-km) radius of CNS (USFWS, 2007b). The remaining acreage on the Nebraska side includes the riverbank, streams and canals, and transmission line corridors. Several segments of intermittent streams are subject to plowing, which may impact wetland resources (NPPD 2008a). NPPD staff noted that these intermittent streams drain south from the CNS site into the adjacent USACE Langdon Bend Wetlands Restoration Project and into the

Little Nemaha River, and finally into the Missouri River (NDNR, 2009). The Langdon Bend project is one component of the larger Missouri River Mitigation Project (USACE, 2004b). Additional surface water at the CNS site drains from the wetlands and fields directly into the Missouri River by way of man-made drainage ditches and into the Little Nemaha River by way of the intermittent tributary system. However, NPPD staff indicated that the farm fields and wetland areas still flood, primarily from overland drainage, and occasionally because of overbank flow from the Missouri River.




Figure 2.2.6-1. Nontidal Wetlands Located on the Cooper Nuclear Station Site (Source: USFWS, 2009a; National Wetlands Inventory; Nemaha Quad; NPPD, 2008a). (Note that the wetlands polygon is approximate and includes the 55-ac (22-ha) NPPD wetlands mitigation site.)

NPPD staff indicated that a system of levees on the Nebraska side of the CNS site is designed to protect the CNS reactor and support buildings from a 200-year flood event. Additional levees have been constructed along both sides of the Missouri River floodplain through the entire CNS site. Levee construction on the Missouri River was initiated in 1945 as part of a Federal project implemented in 1912 to deepen and widen the Missouri River for navigation purposes. Earthen levees were constructed along the eastern border of the CNS property located in Missouri.

Affected Environment

On the Nebraska side of the river, the alluvial bottomland and rolling floodplains are dominated by cottonwood (*Populus deltoides*), green ash (*Fraxinus pennsylvanica*), boxelder (*Acer negundo*), elm (*Ulmus* spp.), lowland tallgrass prairie, big bluestem (*Andropogon gerardii*), prairie cordgrass (*Spartina pectinata*), switchgrass (*Panicum virgatum*), and several sedges (USGS, 2001).

In Missouri on the CNS property, approximately 200 ac (81 ha) of the 239 ac (97 ha) are classified as palustrine forested wetlands and flood periodically. The NRC staff noted during the site audit evidence of flood water from the Missouri River reaching over 4 ft high on some trees on the Missouri side of the CNS property. The two transmission line corridors running east-west through the Missouri property (not in scope) are primarily emergent wetlands where the transmission lines do not cross cropland. Less than 40 ac (16 ha) of the 239 ac (97 ha) have been cleared and are used for agricultural activities.

The forested riparian areas on the Missouri side of the CNS property are dominated by cottonwood, American sycamore (*Platanus occidentalis*), silver maple (*Acer sacharrinum*), black willow (*Salix nigra*), boxelder, buttonbush (*Cephalanthus occidentalis*), and false indigo (*Amorpha fruticosa*) (NRCS, 2007). The two transmission line corridors located on the Missouri side are dominated primarily by emergent wetlands vegetation, similar to the grasses described on the Nebraska side, as well as some scrub-shrub wetlands vegetation.

Several exotic invasive plant species are located along the riverbank of the CNS site, and include purple loosestrife (*Lythrum salicaria*) and reed canary grass (*Phalaris arundinacea*) (NRCS, 2007). The common reed (*Phragmites australis*) is another exotic invasive species found along the riverbank in the vicinity of the CNS site that was recently added to the list of noxious weeds by the Nebraska Department of Agriculture (NDA, 2008).

While much of the CNS site and vicinity is agricultural land, there are a number of wooded areas and hedgerows that provide habitat for several species of mammals common to this region, including coyote (*Canis latrans*), white-tailed deer (*Odocoileus virginianus*), raccoon (*Procyon lotor*), eastern cottontail rabbit (*Sylvilagus floridanus*), muskrat (*Ondatra zibethicus*), mink (*Mustela vison*), bobcat (*Lynx rufus*), and mice and other small mammals (Bailey, 2007).

The CNS site provides habitat to a variety of game birds and resident and neo-tropical migratory songbirds primarily along the transmission line corridor and within the wooded wetland and scrub-shrub habitat on both sides of the river, some of which were observed by the NRC staff during the site audit. Species of game birds that are commonly found in the vicinity of CNS include the northern bobwhite quail (*Colinus virginianus*), the ring-necked pheasant (*Phasianus colchicus*), and the wild turkey (*Meleagris gallopavo*). Other birds commonly found on CNS property and the transmission line corridor include cliff swallows (*Petrochelidon pyrrhonota*), the American kestrel (*Falco sparverius*), the turkey vulture (*Cathartes aura*), the killdeer (*Charadrius vociferus*), the horned lark (*Eremophila alpestris*), and the American bald eagle (*Haliaeetus leucocephalus*) (Bailey, 2007), (UNSM, 2007a). There is an active bald eagle nest on the Missouri side of the CNS property with a breeding pair of eagles that have produced a number of chicks over the past several years (NPPD, 2008a). Although no longer protected under the ESA, the bald eagle is still protected from any take without a permit under the Bald and Golden Eagle Protection Act (50 CFR Part 22) (NPPD, 2008a).

CNS is located along an overlapping section of the Mississippi and Central Flyways, with 20 waterfowl species following the Missouri River during fall and spring migrations. These waterfowl may use the wetlands located on the CNS site (NPPD, 1971) and its vicinity. The ER contains information on observed bird mortality at CNS from 2003–2006, including a great horned owl (*Bubo virginianus*), a number of additional birds, and the death in 2006 from West Nile Virus of a juvenile bald eagle found near CNS (NPPD, 2008a).

Several amphibians and reptiles are found or are potentially found in the vicinity of CNS and the transmission line corridor. Reptiles include the painted turtle (*Chrysemys picta*), the common snapping turtle (*Chelydra serpentina*), the eastern rat snake (*Elaphe obsoleta*), two species of garter snakes (*Thamnophis* spp.), and the prairie kingsnake (*Lampropeltis calligaster*). Amphibians include the Cope's gray treefrog (*Hyla chrysoscelis*), the northern cricket frog (*Acris crepitans*), the northern leopard frog (*Rana pipiens*), and the bullfrog (*Rana catesbeiana*) (UNSM, 2007b).

2.2.7 Protected Species

The National Marine Fisheries Service (NMFS) and USFWS are responsible for listing aquatic and terrestrial species as threatened and endangered at the Federal level, as delegated by the ESA. The State may list additional species that are regionally threatened or endangered. For the purposes of this SEIS, all Federally- and State-listed species that occur or potentially occur in Nemaha County, Nebraska (the location of CNS) and Johnson, Gage, Lancaster, Saline, Fillmore, York, Hamilton, and Merrick counties, Nebraska, as well as Atchison County, Missouri, have been included (Illinois Wildflowers, 2009), (Kansas Wildflowers and Grasses, 2009), (MOBOT, 2009), (MDC, 2009b), (MDC, 2009c), (Missouri Plants, 2007), (NatureServe, 2009d), (NatureServe, 2009e), (NGPC, 2008), (NGPC, 2009c), (NPPD, 2008a), (NRCS, 2009), (USFWS, 2008a), (USFWS, 2009b), (USGS, 2006), (USGS, 2008), (UWYO, 2002), where transmission line corridors associated with CNS lie (Table 2.2.7-1). On January 15, 2008, the NPPD contacted the USFWS regional offices in Nebraska and Missouri, the Nebraska Game and Parks Commission (NGPC), and the Missouri Department of Conservation (MDC) regarding any concerns these Federal and State natural resources agencies may have as a result of the license renewal action at CNS. The NGPC has not commented upon potential impacts to Federally- or State-listed threatened or endangered species, but has provided an updated list of Nebraska species of concern (NGPC, 2009c).

Table 2.2.7-1. Listed Aquatic and Terrestrial Species

The species listed are Federally-listed, Nebraska-listed, and/or Missouri-listed as threatened, endangered, or State species of concern (SC). State SC may be further classified as S-1, S-2, S, or SX as described at the bottom of this table. The listed species may occur on the CNS site or in its vicinity, within the Missouri River, or within the transmission line corridors.

Scientific Name	Common Name	Federal Status ^(a)	State Status ^{(b)(c)}	Habitat
Fish				
<i>Acipenser fulvescens</i>	Lake sturgeon	-	T (NE)	Large turbid rivers
<i>Cyprinella elongatus</i>	Blue sucker	-	T (NE)	Rivers
<i>Fundulus zebrinus</i>	Plains killifish	-	SC (MO)	Streams and lakes
<i>Hybognathus argyritis</i>	Western silvery minnow	-	SC (MO)	Creeks and backwaters
<i>Hybognathus placitus</i>	Plains minnow	-	SC (MO)	Perennial plains streams
<i>Macrhybopsis meeki</i>	Sicklefin chub	-	T (NE)	Free-flowing rivers with high turbidity
<i>Macrhybopsis gelida</i>	Sturgeon chub	-	E (NE)	Free-flowing rivers with high turbidity
<i>Platygobio gracilis</i>	Flathead chub	-	E (MO)	Main stem Missouri River and small streams
<i>Scaphirhynchus albus</i>	Pallid sturgeon	E	E	Main stem Missouri and Mississippi rivers
Reptiles and Amphibians				
<i>Agkistrodon contortrix</i>	Copperhead	-	S2 (NE)	In or near deciduous forest in hilly situations; vicinity of rock outcrops; floodplains; mesic situations near water in the arid west
<i>Ambystoma texanum</i>	Smallmouth salamander	-	S1 (NE)	Adults migrate from upland, mesic forests to breed in fishless, seasonal, and semipermanent wetlands
<i>Carphophis vermis</i>	Western wormsneak	-	S2 (NE)	Woodlands; forest edge; moist, rocky, hillsides; riparian corridors in prairies; burrowing in or using soil, fallen logs, or debris
<i>Crotalus horridus</i>	Timber rattlesnake	-	S1 (NE)	Riparian; forested and scrub-shrub wetlands; high, dry ridges; hilltop rock outcrops in thick woods
<i>Elaphe vulpina vulpine</i>	Western fox snake	-	E (MO)	Farmlands, prairies, stream valleys, woods, and dune habitats

Affected Environment

Scientific Name	Common Name	Federal Status ^(a)	State Status ^{(b)(c)}	Habitat
<i>Eumeces obsoletus</i>	Great Plains skink	-	S2 (MO)	Open plains, rolling grasslands with few trees and scattered rocks; takes refuge under rocks, logs, or other cover
<i>Gastrophryne olivacea</i>	Great Plains narrowmouth toad		S2 (NE)	Variable: creeks, pools, temporary pools, grasslands, rocky wooded hills, rotten logs; burrows under rocks
<i>Lampropeltis calligaster</i>	Yellow-bellied kingsnake	-	S2 (NE)	Prairies, (including sand prairies), open grassland, forest edge; fields; ditches; woodlands; stream valleys and bluffs
<i>Lampropeltis getula</i>	Common kingsnake	-	S1 (NE)	Open coniferous forest, prairie, desert, woodland, swamps, coastal marshes, river bottoms, farmland, and chaparral.
<i>Liochlorophis vernalis</i>	Smooth green snake	-	S1 (NE) SX (MO)	Meadows, grassy marshes, moist grassy fields at forest edges, stream borders; mountain shrublands, bogs, abandoned farmland; vacant lots; extirpated in Missouri.
<i>Ophisaurus attenuatus</i>	Slender glass lizard	-	S1 (NE)	Open grassland; prairie; open and woodland edge; scrubby areas; fallow fields; near streams and ponds; often in habitats with sandy soil
<i>Rana pipiens</i>	Northern leopard frog	-	S2 (MO)	Springs, slow streams, marshes, bogs, ponds, canals, flood plains, reservoirs, and lakes; permanent water with rooted aquatic vegetation; wet meadows and fields; overwinters usually underwater
<i>Regina grahamii</i>	Graham's crayfish snake	-	S2 (NE)	Sluggish and still waters and their vegetated margins; marshes, swamps; roadside ditches
<i>Sistrurus catenatus</i>	Massasauga rattlesnake	-	T (NE) E (MO)	Wetlands, grassland/herbaceous, old field, savanna, shrubland/chaparral, woodlands
<i>Thamnophis proximus</i>	Western ribbon snake	-	S2 (NE)	Semiaquatic; wide range shrubby habitats near lakes, ponds, sloughs, ditches, swamps, and marshes

Affected Environment

Scientific Name	Common Name	Federal Status ^(a)	State Status ^{(b)(c)}	Habitat
Birds				
<i>Ammodramus henslowii</i>	Henslow's sparrow	-	S2 (NE)	Grassland; open fields and meadows; shrubby vegetation; damp or low-lying areas
<i>Bonasa umbellus</i>	Ruffed grouse	-	SX (NE)	Presumed extirpated; dense forest with some deciduous trees; both wet and relatively dry situations
<i>Charadrius melodus</i>	Piping plover	T	T (NE)	Sandy upper beaches with sparse vegetation, sparsely vegetated shores and islands of shallow lakes, ponds, rivers, and impoundments
<i>Falco peregrinus</i>	Peregrine falcon	-	S1 (NE) S1 (MO)	Various open situations with suitable nesting cliffs and tall buildings with ledges; non-breeding: occurs in farmlands, marshes, lakeshores, river mouths, tidal flats, and urban areas
<i>Grus americana</i>	Whooping crane	E	E (NE)	Wetlands, wet meadows, sandbars, and shallow water in rivers
<i>Lanius ludovicianus</i>	Loggerhead shrike	-	S2 (MO)	Open country with scattered trees and shrubs, savanna, desert scrub, open woodland; often perches on poles, wires, or fence posts
<i>Laterallus jamaicensis</i>	Black rail	-	S1 (NE) S1 (MO)	Breeding and non-breeding: shallow portions of salt, brackish, and freshwater marshes; pond borders; wet meadows; and grassy swamps
<i>Numenius borealis</i>	Eskimo curlew	E	SX (NE)	Possibly extinct; non-breeding: grasslands, pastures, plowed fields, and less frequently, marshes and mudflats; nests in open Arctic tundra
<i>Rallus elegans</i>	King rail	-	S1 (NE) S1 (MO)	Freshwater marshes, upland-wetland marsh edges, flooded farmlands, shrub swamps
<i>Sterna antillarum athalassos</i>	Interior least tern	E	E (NE) S1 (MO)	Bare sand bars and sandy shorelines of large rivers, lakes, and sand pits
<i>Strix varia</i>	Barred owl	-	S2 (NE)	Dense woodland and forest, swamps, wooded river valleys

Scientific Name	Common Name	Federal Status ^(a)	State Status ^{(b)(c)}	Habitat
<i>Thryothorus ludovicianus</i>	Carolina wren	-	S2 (NE)	Open deciduous woodland, thickets, undergrowth, parks, forest edge, pine barrens, and shrubbery of residential areas
<i>Tryngites subruficollis</i>	Buff-breasted sandpiper	-	S1 (NE)	Migratory through Nebraska; short grass plains and dry uplands; man-altered habitats such as fields, golf courses, and runways
Mammals				
<i>Glaucomys volans</i>	Southern flying squirrel	-	T (NE)	Red oak-basswood-ironwood forest
<i>Lontra canadensis</i>	River otter	-	T (NE)	Streams, lakes, ponds, swamps, marshes, estuaries (in some areas), and exposed outer coast
<i>Microtus pinetorum</i>	Woodland vole	-	S1 (NE)	Wide variety of habitats, prefers upland wooded areas with thick layers of loose soil and humus in shallow burrows
<i>Mustela nigripes</i>	Black-footed ferret	E	E (NE)	Limited to open habitat and burrows used by prairie dogs; grasslands and shrub steppe
<i>Perognathus flavescens</i>	Plains pocket mouse	-	S2 (MO)	Tallgrass prairie and sandy-loose soil prairies
<i>Spermophilus franklinii</i>	Franklin's ground squirrel	-	S2 (MO)	Tallgrass and mid-grass prairies; riparian areas; forest-field edges, fields, hedgerows, unmowed strips of railroad ROWs, and roadsides
<i>Spilogale putorius interrupta</i>	Plains spotted skunk	-	S1 (NE) E (MO)	Forested areas, habitats with significant cover, open and brushy areas, rocky canyons and outcrops in woodlands and prairies
<i>Myotis sodalis</i>	Indiana bat	E	E (MO)	Hibernates in caves; foraging habitats include riparian areas, upland forests, ponds, and fields
Insects				
<i>Atrytone arogos iowa</i>	Iowa skipper	-	S1 (NE)	Short grass prairie in Colorado to mesic or dry tall grass prairie.
<i>Cicindela nevadica lincolniana</i>	Salt Creek tiger beetle	E	E (NE)	Eastern Nebraska saline wetlands and their associated streams

Affected Environment

Scientific Name	Common Name	Federal Status ^(a)	State Status ^{(b)(c)}	Habitat
<i>Cicindela togata</i>	White-cloaked tiger beetle	-	S1 (NE)	Very open saline areas far from vegetation; salt flats, salt marshes, and saline lakeshores
<i>Melanoplus packardii</i>	Packard's grasshopper	-	S2 (MO)	Bare, somewhat grassy beaches; sandy woods, always on dry sand and not on vegetation
<i>Nicrophorus americanus</i>	American burying beetle	-	S1 (NE) SH (MO)	Broad vegetational tolerances; mature forest, grassland, and old field shrubland
Plants				
<i>Agalinis purpurea</i>	Large-purple false foxglove	-	S1 (NE)	Moist sand prairies; sandy savannas, paths, and openings in sandy woodlands; boggy areas; occasional disturbance
<i>Anagallis minima</i>	Chaffweed	-	S1 (NE)	Bare damp ground, by roadsides
<i>Anemone cylindrica</i>	Thimbleweed	-	S2 (MO)	Dry open woods, slopes, prairies, and along railroad grades
<i>Arisaema dracontium</i>	Green dragon	-	S2 (NE)	Moist deciduous woodlands, shady seeps, and wooded areas adjacent to springs and vernal pools
<i>Arnoglossum atriplicifolium</i>	Pale Indian-plantain	-	S2 (NE)	Full to partial sun; prairies, woods; in sandy, loamy soil
<i>Asclepias amplexicaulis</i>	Clasping milkweed	-	S1 (NE)	Prairies, glades, rocky open woods, roadsides, and railroads
<i>Asclepias purpurascens</i>	Purple milkweed	-	S1 (NE)	Rocky open woods, glades; prairies; stream banks; wet meadows; valleys; thickets; and roadsides
<i>Astragalus lotiflorus</i>	Low milk vetch	-	S2 (MO)	Dry native prairie in areas where the shortgrasses like blue grama grow
<i>Bidens polylepis</i>	Awnless beggar-ticks	-	S2 (NE)	Wet prairies and meadows, swampy woods, roadsides, and disturbed grounds
<i>Blephilia hirsuta</i>	Hairy woodmint	-	S1 (NE)	Rich, moist, shady woods, slopes, and valleys
<i>Bouteloua gracilis</i>	Blue grama	-	S1 (MO)	Dryish soils on upland short grass prairies and along railroad tracks
<i>Bouteloua hirsute</i> var. <i>hirsuta</i>	Hairy grama	-	S2 (MO)	Shortgrass prairies

Scientific Name	Common Name	Federal Status ^(a)	State Status ^{(b)(c)}	Habitat
<i>Brachyelytrum erectum</i>	Bearded shorthusk	-	S2 (NE)	Mesic upland forests, bottomland forests, and occasional dry upland forest
<i>Buchloe dactyloides</i>	Buffalo grass	-	SH (MO)	Possibly extirpated
<i>Carex bushii</i>	Bush's sedge	-	S1S2 (NE)	Moist prairies, fields, and meadows in full sun (ODNR, 1998).
<i>Carex crus-corvi</i>	Ravenfoot sedge	-	S1 (NE)	Wet meadows and swamps (MSU, 2007)
<i>Carex frankii</i>	Frank's sedge	-	S1S2 (NE)	Edges of wet woods and seasonally wet meadows (USU, 2006)
<i>Carex sprengelii</i>	Longbeak sedge	-	S1 (MO)	Moist soil on bottomlands and streambanks; cliffs and rocky slopes
<i>Castilleja sessiliflora</i>	Downy painted cup	-	S2 (MO)	Dry prairies and rocky hillsides
<i>Coeloglossum viride</i>	Long-bract Green orchis	-	S1 (NE)	Sub-arid soil in damp open woods; mesic to wet woodlands, thickets, and shrub borders; disturbed areas
<i>Corallorhiza wisteriana</i>	Spring coralroot	-	S1 (NE)	Terrestrial in moist hardwood forests and hammocks; Mycorrhizal with fungi
<i>Cornus racemosa</i>	Gray dogwood	-	S1 (NE)	Thickets and moist soil in riparian zones, roadsides, on sandy slopes and limestone ridges
<i>Corydalis aurea</i>	Golden Corydalis	-	S1 (NE)	Rocky or sandy soils along lakes or ponds or in open woods
<i>Cypripedium calceolus</i>	Yellow lady's-slipper	-	S1 (NE)	Rich, humus and decaying leaf litter in wooded areas, often on rocky wooded hillsides
<i>Cypripedium candidum</i>	Small white lady's slipper	-	T (NE) S1 (MO)	Mesic/wet blacksoil prairie; glacial till hill prairie, sedge meadow, glade; calcareous soils; extirpated/possibly extirpated in Missouri
<i>Dalea enneandra</i>	Nine-anther dalea	-	S2 (MO)	Grassland and prairie
<i>Dasistoma macrophylla</i>	Mullein foxglove	-	S1 (NE)	Rich woodlands, often along streams
<i>Desmodium cuspidatum</i>	Toothed tick-trefoil	-	S2? (NE)	Dry or rocky woods, thickets, bluffs, base of slopes, ridges, ravines, and valleys

Affected Environment

Scientific Name	Common Name	Federal Status ^(a)	State Status ^{(b)(c)}	Habitat
<i>Dracocephalum parviflorum</i>	American dragonhead	-	S1 (NE)	Woodland, shrublands, and openings
<i>Eleocharis atropurpurea</i>	Purple spikerush	-	S1 (NE) S1 (MO)	Banks, hammocks, irrigation ditches, and lake and pond margins
<i>Eleocharis wolfii</i>	Wolf's spikerush	-	S2 (NE)	Marshes, wet to wet-mesic prairies, wetland margins; wet ditches, sandy roadsides, and mud flats
<i>Erysimum inconspicuum</i>	Small-flower prairie wallflower	-	S2 (NE)	Dry native prairie; found where grazing is light or moderate
<i>Erythronium mesochoreum</i>	Midland fawnlily	-	S2 (NE)	Prairies and open woods; occasionally found in cut-over woods
<i>Galearis spectabilis</i>	Showy orchis	-	S1 (NE)	Floodplains
<i>Gentiana alba</i>	Yellow gentian	-	S1 (NE)	Mesic black soil prairies, upland forests, and rocky bluffs
<i>Helianthemum bicknellii</i>	Plains frostweed	-	S1S2 (NE)	Sandy soil of open woodlands and prairie areas
<i>Heliotropium curassavicum</i> var. <i>curassavicum</i>	Seaside heliotrope	-	S1 (NE) S1 (MO)	Dry or moist saline and alkaline areas; seasonal flooding
<i>Isoetes melanopoda</i>	Blackfoot quillwort	-	S1 (NE)	Submerged or in wet soil of swales and temporary ponds
<i>Lactuca tatarica</i> var. <i>pulchella</i>	Blue lettuce	-	S1 (MO)	Plains, foothills, montane; meadows and roadside ditches
<i>Lespedeza violacea</i>	Violet bush-clover	-	S1 (NE)	Edges of open upland woods, roadsides; thickets; rocky prairies; dry, rocky soils
<i>Leucospora multifida</i>	Narrowleaf paleseed	-	S1 (NE)	Shores and stream banks, often where sandy
<i>Liatris squarrosa</i> var. <i>hirsuta</i>	Glades gayfeather	-	S1? (NE)	Diverse; including dry, sandy, upland prairies
<i>Melica nitens</i>	Three-flower melicgrass	-	S1 (NE)	Open woods, moist canyon slopes, canyon bottoms, roadsides, rocky grasslands, and streambanks
<i>Monotropa uniflora</i>	Indian-pipe	-	S1 (NE)	Non-green herb parasitic on roots of pines
<i>Neeragrostis reptans</i>	Hairy creeping lovegrass	-	S1 (NE) SH (MO)	Wet sandy or muddy stream banks and alluvial bar (possibly extirpated)

Affected Environment

Scientific Name	Common Name	Federal Status ^(a)	State Status ^{(b)(c)}	Habitat
<i>Nothocalais cuspidate</i>	Prairie false dandelion	-	S2 (MO)	Dry upland areas of prairies, hill prairies, and rocky slopes
<i>Nymphaea odorata</i>	American water-lily	-	S2 (NE)	Lakes, lake margins, ponds, quiet bays in lakes and rivers, slow-moving streams, and ponds
<i>Orobanche uniflora</i>	One-flowered broomrape	-	S1 (NE)	Parasitic; wooded slopes, lowland, and rocky base of bluffs
<i>Oxytropis lambertii</i> var. <i>lambertii</i>	Stemless point vetch	-	S2 (MO)	Extirpated/possibly extirpated
<i>Packera glabella</i>	Grassleaf ragwort	-	S1 (NE)	Moist-to-wet habitat (UT, 2009)
<i>Panax quinquefolius</i>	American ginseng	-	T (NE)	Rich, cool, moist but not extremely wet woods, under a closed canopy; slopes; ravines
<i>Paronychia canadensis</i>	Forked nailwort	-	S1 (NE)	Dry sandy or rocky places
<i>Pedimelum argophyllum</i>	Silvery scurfpea	-	S2 (MO)	Moist prairies, rocky hillsides, lowlands, stream valleys, and open woodlands
<i>Pellaea atropurpurea</i>	Purple-stem cliffbrake	-	S2 (NE)	Crevices of rock outcrops, bluffs and boulders; sinkholes; dry soils adjacent to dolomite glades
<i>Penstemon grandiflorus</i>	Large beard-tongue	-	S1 (MO)	Prairie bluffs in open grassy places
<i>Penstemon tubiflorus</i>	White-wand beardtongue	-	S1 (NE)	Rich loam or sand loam soil from open prairies to deciduous forests; disturbed areas; rocky glades; along railroads
<i>Platanthera praeclara</i>	Western prairie fringed orchid	T	T (NE) E (MO)	Tallgrass prairie; moist, calcareous or subsaline prairies and sedge meadows (many flooded for a period of 1-2 weeks during the year)
<i>Podophyllum peltatum</i>	Mayapple	-	S2 (NE)	Rich cove forests; mesic hardwood forests; low topographic positions
<i>Quercus alba</i>	White oak	-	S1 (NE)	Deciduous forests; mesic; bottomland soil
<i>Ruellia strepens</i>	Limestone wild petunia	-	S2 (NE)	Moist woods, around ponds and lakes, along streams
<i>Salicornia rubra</i>	Western glasswort	-	S1 (NE)	Saline or alkaline soil of flats, shores, seepage areas, and ditches

Affected Environment

Scientific Name	Common Name	Federal Status ^(a)	State Status ^{(b)(c)}	Habitat
<i>Schoenoplectus saximontanus</i>	Rocky Mountain bulrush	-	S1 (NE) S1 (MO)	Damp soils to emergent, freshwater ponds; ditches, often drying; disturbed and sandy areas
<i>Senna marilandica</i>	Maryland senna	-	S1S2 (NE)	Prairie ravines, open woods, thickets, disturbed areas, and bases of slopes and bluffs; dry, gravelly soils
<i>Sparganium chlorocarpum</i>	Greenfruit bur-reed	-	S2 (NE)	Shallow water or mud of marshes, streams, ditches, and ponds, where the water is fairly fresh
<i>Spiranthes vernalis</i>	Twisted ladies'-tresses	-	S2? (NE)	Moist open areas, meadows, swales, and bogs
<i>Symphoricarpos occidentalis</i>	Wolfberry	-	S1 (MO)	Open prairies, and moist, low ground around streams or lakes
<i>Trifolium reflexum</i>	Buffalo clover	-	S1 (NE)	Rocky open woods, glades, old fields, and prairies
<i>Triodanis perfoliata</i> var. <i>biflora</i>	Claspingleaf Venus'-looking-glass	-	S1 (NE)	Dry sandy or gravelly prairies, pastures, waste ground, and occasionally woodlands
<i>Verbena simplex</i>	Narrowleaf vervain	-	S1 (NE)	Dry, open waste areas, rocky prairie hillsides, and roadsides
<i>Veronicastrum virginicum</i>	Culver's-root	-	S1 (NE)	Varied habitats; moist tallgrass prairie and prairie remnants, moist woods, woodland borders, thickets, fields and meadows, stream banks and terraces
<i>Viola palmata</i>	Palmate-leaved violet	-	S2 (NE)	Dry upland woodlands, rocky wooded slopes, and thinly wooded bluffs
<i>Vitis cinerea</i>	Pigeon grape	-	S1 (NE)	Low woods, floodplains, along streams, marshes, bottomlands
<i>Yucca glauca</i>	Small soapweed yucca	-	S2 (MO)	Loess hill prairies

(a) E = Endangered; T = Threatened

(b) NE = Nebraska; MO = Missouri

(c) S = State listing; S1 = critically imperiled; S2 = imperiled; SX = presumed extirpated; SH = possibly extirpated. Note that S3 species ("vulnerable") such as Bald Eagle are not included in this list in order to maintain a less-expansive list.

Sources: NGPC, 2008; NGPC, 2009c; MDC, 2009b; MDC, 2009c; USFWS, 2008a; USFWS, 2009b; UW, 2009

2.2.7.1 Aquatic Species

Table 2.2.7-1 presents aquatic species that are listed as protected by the USFWS, the State of Nebraska, and the State of Missouri that have the potential to occur in counties near CNS or along the transmission corridors. One fish species is listed by the USFWS for Nemaha County, Nebraska: the pallid sturgeon (*Scaphirhynchus albus*) (USFWS, 2007a). Regarding State-listed species, Hesse et al. (1982) report the identification of several fish species then listed as threatened or endangered by Iowa, Missouri, or Nebraska, based on studies from 1971 through 1977 from the channelized Missouri River in the reach from Fort Calhoun Station to CNS. These included skipjack herring (*Alosa chrysochloris*, listed in Iowa), sturgeon chub (*Macrhybopsis gelida*, listed in Iowa and Missouri), blue sucker (*Cycleptus elongateus*, listed in Missouri), plains killifish (*Fundulus kansae*, listed in Missouri), and burbot (*Lota lota*, listed in Missouri). Of these, they collected a single sturgeon chub (in 1977), 3 plains killifish (in 1971), 10 burbot, and consistently low numbers of blue suckers near CNS. MDC (2009) no longer lists sturgeon chub, plains killifish, or burbot, and Iowa no longer lists the sturgeon chub (Iowa Administrative Code, Chapter 77). Fish species that the States of Missouri and Nebraska currently list and that Hesse et al. (1982) collected near CNS or in the reach between CNS and Fort Calhoun Station in the 1971 through 1977 studies include sturgeon chub, blue sucker, and plains killifish. The NRC staff did not find more recent data on fish species living in the Missouri River near CNS, but lack of captures does not necessarily indicate absence of uncommon species in any case.

Life History of Pallid Sturgeon

Sturgeon are members of an order of fish (Acipenseriformes) that probably evolved in the Devonian age. Living members of this order in North America include the paddlefish and eight sturgeon species. The paddlefish (*Polyodon spathula*) and three sturgeon species, the lake sturgeon (*Acipenser fulvescens*), pallid sturgeon (*Scaphirhynchus albus*), and the shovelnose sturgeon (*S. platyrhynchus*), live in the Missouri and Mississippi rivers. In the past, commercial fishermen harvested all three of the sturgeon species in the Missouri and Mississippi rivers. Today pallid sturgeon are a Federally-listed endangered species, and lake sturgeon are listed as endangered by Nebraska. The life history information below is from Dryer and Sandvol (1993) and the USFWS (2007) if not otherwise cited.

Pallid sturgeon have a flattened snout, a long tail, and rows of bony armor plates. The upper side is convex and the lower side is straight. They have an inferior (bottom-facing) mouth and eat invertebrates, such as the immature stages of insects, and fish. The body shape is well adapted for swimming close to the bottom of relatively fast flowing, large rivers. The diet, inferior mouth, and barbels in front of the mouth are well adapted to feeding on or near the bottom in highly turbid environments.

The USFWS listed pallid sturgeon as endangered in 1990. The historic abundance of pallid sturgeon is somewhat vague since biologists did not recognize it as a separate species from shovelnose sturgeon until 1905, but its historical range probably extended from the middle and lower Mississippi River in the south up through the Missouri River and lower reaches of the Platte, Kansas, and Yellowstone rivers in the north and west. The pallid sturgeon is one of the largest fish species in those rivers. Available information suggests that the pallid sturgeon was not a common species since the time of European settlement. Today pallid sturgeon are among the rarest fish of the Missouri and Mississippi River basins, and the present range includes the States of Montana, North and South Dakota, Nebraska, Iowa, Kansas, Missouri, Illinois, Kentucky, Arkansas, Mississippi, and Louisiana. The populations consist mostly of older fish that will likely die off in the near future.

Affected Environment

Fisheries biologists know little about pallid sturgeon reproduction or even preferred spawning habitats and conditions. Hurley et al. (2004) tracked sonically-tagged pallid sturgeon in the Mississippi River and found that they exhibited positive selection for the main-channel border, downstream island tips, between-wing-dam, and wing-dam-tip habitats; they showed negative selection for main-channel, downstream of wing dams, and upstream of wing dam habitats. The sturgeon exhibited little habitat selection for temperature or dam discharge. The authors concluded that habitat enhancement and restoration of habitat diversity might be necessary for the recovery of pallid sturgeon.

Reports of pallid sturgeon reproduction are rare. The USGS (2007), NGPC, and the USACE confirmed spawning of two female pallid sturgeon in the upstream reaches of the lower Missouri River in May 2007. The capture of young pallid sturgeon that would verify natural reproduction are also rare: none were captured between 1978 and a Mississippi River trawl survey in 1998 through 2000 using equipment designed to capture larval fish in deep, turbulent water (Hrabik et al., 2007). Hrabik et al. (2007) concluded that those latest captures verified reproduction, possibly from the lower Missouri River to the upper and lower Mississippi River, although they also found no evidence of recruitment of pallid sturgeon because they captured no juveniles after 374 trawl hauls that captured over 21,735 fish in that 1998 through 2000 survey. Wildhaber et al. (2007) suggest that one or more of the following factors may be responsible for the lack of finding larval pallid sturgeon and of recruitment: lack of successful spawning, low recruitment, high mortality, ineffective sampling methods, inadequate sampling of drift and settling locations, or rapid dispersal and washout of sturgeon larvae in the Missouri and Mississippi rivers. Pallid sturgeon larvae are indistinguishable from those of the congeneric shovelnose sturgeon, which may also help to explain the paucity of reported collections in the past. Also, the construction of dams and other structures with resulting habitat change and the elimination of shallow areas in the river with little or no flow have probably deprived sturgeon of critical nursery areas needed for the survival of immature sturgeon (MDC, 2009c).

Larval pallid and shovelnose sturgeon become strongly photopositive and migrate upwards toward the light starting the first day after hatching. As a result, they remain far above the bottom, even at the water surface, and migrate far downriver (Kynard et al., 2002). Cultured yearling pallid sturgeon in laboratory studies also migrate downstream during summer and fall, which suggests a two-stage (larval, then yearling) downriver migration in the first year of life. Adult sturgeon are also highly migratory and often migrate hundreds of miles in a year.

The young of both shovelnose and pallid sturgeon eat invertebrates, but as pallid sturgeon grow, they become more piscivorous. Gerrity and Guy (2006) found that the diet of juvenile pallid sturgeon of age 6 and 7 was mostly fish, compared to the diet of shovelnose sturgeon, which is mainly aquatic insects. Sturgeon chub (*Macrhybopsis gelida*) and sicklefin chub (*M. meeki*) together comprised 79 percent of the number of identifiable fish in juvenile pallid sturgeon stomachs. Populations of these two cyprinid minnows have declined throughout much of the Missouri River due to the construction of dams and man's other alterations of river habitat. While the population of the piscivorous pallid sturgeon has declined in the Missouri and Mississippi rivers, the population of its similar, insectivorous congener, shovelnose sturgeon, has not declined. Gerrity and Guy (2006) concluded that the prevalence of sicklefin chub and sturgeon chub as a food resource of juvenile pallid sturgeon may help explain the decline of pallid sturgeon populations and that recovery and management of native cyprinids is a potentially important step in the recovery of pallid sturgeon.

Male pallid sturgeon are believed to mature at 7 to 9 years after which they spawn at intervals of 2 to 3 years. Females may reach sexual maturity at 7 to 15 years and spawn at intervals up to

10 years. Individuals may reach ages of 60 years or more and reach lengths of 6 ft (2 m). Like many other fish species, the largest individuals are found farthest north in the species' range and maximum size decreases with distance south. For example, the maximum weight of pallid sturgeon in the upper Missouri River in Montana and North Dakota is 86 lbs (39 kg), in the Missouri River in South Dakota and Nebraska 46 lbs (21 kg), and in the Mississippi River 26 lbs (12 kg). They become much larger than shovelnose sturgeon, which rarely weigh more than 8 lbs (3.6 kg).

While they were successful in the historical Missouri and Mississippi rivers, with the high flow and turbidity and diverse habitats of floodplains, backwaters, chutes, sloughs, islands, sand and gravel bars, and both braided and main channels, they are not so well adapted to the Missouri and Mississippi rivers today with the construction of dams that isolated subpopulations, channelization, controlled flow, and elimination of habitat diversity. The USFWS (2007) concludes that man's activities have adversely affected all of the 3,350 mi (5,390 km) of river habitat within their range, and habitat alteration and loss may be the biggest threat to their existence. Other threats may include hybridization with shovelnose sturgeon, commercial fishing, and exposure to environmental contaminants such as polychlorinated biphenyls, cadmium, mercury, selenium, chlordane, dichlorodiphenyltrichloroethane (DDT), dichlorodiphenyldichloroethylene (DDE), and dieldrin, all of which have been found in pallid sturgeon tissue in the past.

During the early 1990s, the MDC developed "action plans" for lake and pallid sturgeon with a goal of reestablishing self-sustaining populations so they can be delisted as endangered species and ultimately provide limited sport fisheries. These plans stress the restoration of both species through habitat improvement, artificial propagation, protection, research, management, and education (MDC, 2009c). As part of this effort, the MDC's Blind Pony Fish Hatchery has raised and stocked over 13,000 fingerling pallid sturgeon and 200,000 fingerling lake sturgeon into the Missouri and Mississippi rivers (MDC, 2009c). In addition to these efforts, the USGS (Wildhaber et al., 2007) has developed a conceptual life history to organize the understanding about the complex life history of *Scaphirhynchus* sturgeon and improve understanding of the effects of management actions on the ecological requirements of pallid and shovelnose sturgeon. The USFWS's Pallid Sturgeon Recovery Plan (Dryer and Sandvol, 1993) designated six recovery priority management areas (RPMAs) for implementation of recovery tasks, and CNS is located within RPMA 4.

In 2000, the USACE, which provides the primary operation management of the Missouri River, asked the USFWS for formal consultation under the ESA on the operations of the Missouri River Main Stem System, and related operations of the Kansas River Tributary Reservoirs, and the operations and maintenance of the Missouri River Bank Stabilization and Navigation Project (USFWS, 2000b). The USACE prepared biological assessments for these projects and determined that their operations may affect listed species, including the endangered pallid sturgeon. The USFWS found that the proposed actions were likely to jeopardize the continued existence of pallid sturgeon, as well as the endangered least tern and threatened piping plover, though not the then-threatened bald eagle. Working together, the USACE and the USFWS developed Reasonable and Prudent Alternatives under the ESA to help ensure the continued existence of the three species by returning some natural form and function to sections of the Missouri and Kansas rivers. Under the Alternatives, the following five actions are designed for pallid sturgeon: (1) enhance flow by including a spring release from Fort Peck dam and a spring rise and summer drawdown from Gavins Point dam to provide spawning clues and enhance aquatic habitat; (2) restore, create, enhance, acquire, or conserve habitat; (3) unbalance the upper reservoirs, (4) use an adaptive management process combined with monitoring; and

Affected Environment

(5) increase pallid sturgeon propagation and augmentation efforts while the habitat and hydrology improvements are being implemented.

The USFWS (2003a, 2003b) issued a supplemental biological opinion that applied only to operations in 2003 due to a continuing drought. It represented a collaborative effort between the USFWS and the USACE and considered habitat conditions and new information not considered in the November 2000 biological opinion. The USACE changed flow regime in the Missouri River and the USFWS stocked year-old pallid sturgeon, both as interim measures in 2003. The USFWS (2003a, 2003b) reported that the long-term survival of pallid sturgeon will depend on a more natural hydrograph consisting of an increase in spring flows and declining summer flows.

2.2.7.2 Terrestrial Species

Federally Protected Species

Eight animal and plant species Federally-listed as threatened or endangered (Table 2.2.7-1) are known to occur or to potentially occur on terrestrial habitat within the vicinity of CNS or along the associated in-scope transmission line corridor. The ranges of four of these species, the Indiana bat (*Myotis sodalis*), the western prairie fringed orchid (*Platanthera praeclara*), the piping plover (*Charadrius melodus*), and the interior least tern (*Sterna antillarum athalassos*) may include the CNS site. The Indiana bat and interior least tern are listed as endangered, and the western prairie fringed orchid and piping plover are listed as threatened (USFWS, 2008a), (USFWS, 2009b).

Seven Federally-listed species are potentially present along the transmission line corridor, including the western prairie fringed orchid. The endangered species are the Salt Creek tiger beetle (*Cicindela nevadica lincolniiana*), the black-footed ferret (*Mustela nigripes*), the interior least tern, the Eskimo curlew (*Numenius borealis*), and the only known wild population of whooping crane (*Grus americana*). The Eskimo curlew is extirpated from Nebraska and is globally extinct or near-extinct. The piping plover is listed as a threatened species and may be found along the western limit of the transmission line corridor by the Platte River, along with the interior least tern and whooping crane (NatureServe, 2009e), (USFWS, 2008a), (USFWS, 2009b), (USFWS, 2009c).

While threatened piping plovers have not been observed along the CNS shoreline, they have been found along the Missouri River in close proximity to CNS and along the Platte River near the western limit of CNS transmission line NPPD TL3502 (USFWS, 2002), (USFWS, 2009c), (NatureServe, 2009a). The piping plover is a small shorebird with a white underbelly and pale brownish upper parts, with an average length of 6–7 inches (16–18 cm) and a wingspan of about 15 inches (38 cm). The plover has a small black ring around the base of its neck and a black band over its eyes on its forehead (NatureServe, 2009a), (USFWS, 1997). Piping plover habitat includes river channels, their associated sandbars and islands, and their sparsely vegetated shorelines and peninsulas (USFWS, 2002). Even though the shoreline along the Missouri River at CNS does not contain the characteristics required by piping plovers for nesting, they have been reported in the vicinity of CNS. Critical habitat has been designated for the northern Great Plains breeding population of the piping plover along portions of the Platte River in Hamilton County and Merrick County, which is the location of the transmission line crossing of the Platte River near Grand Island, Nebraska. Interior least terns are found along portions of the Missouri River in North Dakota, and also nest along portions of the Platte River and its tributaries in Hamilton County and Merrick County, Nebraska, near the western limit of transmission line NPPD TL3502 (NatureServe, 2009b), (NGPC, 2009b). The interior least tern is a swallow-like bird 8–9 inches (22–24 cm) long with a wingspan of about 20 inches (31 cm). It

has a pale gray and white body with a glossy black crown, and a long, black-tipped, yellow-orange bill. The interior least tern nests in habitat similar to that used by piping plovers. Threats to the interior least tern are also similar to those of the piping plover, with sand and gravel pits now providing some of the only available nesting habitat for least terns (NGPC, 2009b), (USFWS, 2008b).

The current range of the Indiana bat includes Atchison County, Missouri, on the east side of the Missouri River from CNS but does not include Nebraska (USFWS, 2008a), (MDC, 2009b), (MDC, 2009c). The Indiana bat is a medium-sized bat about 2 inches (5 cm) long and weighing about ¼ ounce (7 grams) (NYSDEC, 2009) with a wingspan of about 8 inches (20 cm) and brownish-gray fur (MDC, 2009a). The Indiana bat hibernates in caves during the winter and migrates to streams and rivers in wooded areas in the summer where they roost under loose tree bark (NYSDEC, 2009), (MDC, 2009a). Critical habitat for the Indiana bat has been designated in Missouri, but not in Atchison County (USFWS, 2008a). A number of factors have contributed to population declines for the Indiana bat; a primary cause for their decline has been from humans disturbing bats hibernating in caves during the winter. Stream channelization, deforestation, and agricultural development threaten the habitat of Indiana bats in their summer range (MDC, 2009a).

The western prairie fringed orchid occurs both in Nebraska and Missouri. It is found in Otoe County, located immediately north of Nemaha County, which is the location of CNS. It is also found in Atchison County, Missouri, the location of the Missouri portion of the CNS property (USFWS, 2008a), (USFWS, 2009b). The western prairie fringed orchid produces flower stalks up to about 4 ft (133 cm) tall, with up to 40 one inch (2.5 cm) white flowers, attached to the stalk (USFWS, 2003a), (MNDNR, 1991). It grows in moderately wet to wet prairies and meadows and is occasionally found in old fields and roadside ditches. Habitat loss through conversion to cropland is the greatest threat to populations of the western prairie fringed orchid (USFWS, 2003a).

The only known existing wild population of whooping cranes migrates along the Platte River at the western limit of the CNS transmission line corridor near Grand Island. The whooping crane is a large white crane standing as tall as 5 ft (1.5 m) with a wingspan of 8 ft (2.5 m) and weighing over 17 lbs (8 kg), making it the largest bird in North America and one of the three largest cranes in the world (NGPC, 2009a). Adult whooping cranes have a red crown and black forehead with black primary feathers visible during flight (USFWS, 2009h). Whooping cranes live and breed in wetlands, and feed primarily on crabs, small fish, and other invertebrates (NGPC, 2009a), (NatureServe, 2008a). Whooping cranes declined to the brink of extinction in the first half of the 20th century mainly caused by a loss of habitat to agriculture, human disturbance of nesting areas for eggs, and uncontrolled hunting for meat and plumage. By 1941, only 14 whooping cranes existed (NatureServe, 2008a), (NGPC, 2009a). Current threats to their population include habitat degradation, low productivity associated with drought and/or winter malnutrition, collisions with power lines along their migration routes, and severe weather phenomena during nesting season (NatureServe, 2008a), (USFWS, 2009c).

There are currently two populations of whooping cranes totaling less than 400 adult and juvenile birds, including one wild population and one experimental, nonessential population. The wild population of whooping cranes overwinters in the Aransas National Wildlife Refuge in Texas, and migrates north in the spring to one small breeding area in Canada (USFWS, 2009d). The wild population uses the Platte River and its tributaries and surrounding wetlands along its migratory corridor in the spring and fall. CNS transmission line NPPD TL3502 crosses the Platte River along the whooping crane migratory corridor 1 mile from the endpoint of the transmission

Affected Environment

line near Grand Island, Nebraska. Critical habitat has been designated for whooping cranes on the Platte River, located approximately 25 mi (40 km) southwest of Grand Island (USFWS, 1978). The experimental population breeds in Wisconsin and overwinters in Florida and several other southeastern States (NatureServe, 2008a).

Captive breeding programs over the past several decades have increased whooping crane populations sufficiently to allow creation of the two experimental populations. As of April 2008, however, there were still less than 400 adult and juvenile whooping cranes in existence between these three flocks. Both the wild population and the experimental populations still suffer mortality attributable to severe weather, lack of food, and collisions with power lines. The wild Aransas population lost 57 adult and juvenile whooping cranes between spring 2008 and winter 2009, for a loss of 21 percent of its population in 12 months. The spring 2009 flock of whooping cranes at Arkansas totaled 247 birds (Stehn, 2009).

The NPPD has coordinated efforts with the USFWS to address the potential risk of bird collisions with transmission line NPPD TL3502, which crosses the Platte River near the end of the CNS transmission line corridor, located approximately 4 mi (6 km) east of Grand Island, Nebraska. The Federally-endangered whooping crane (*Grus americana*), the interior least tern (*Sterna antillarum athalassos*), and the Federally-threatened piping plover (*Charadrius melodius*) use the Platte River and associated wetlands around Grand Island for different portions of their life cycle, such as for migration, resting, feeding, and nesting, and risk collisions with the NPPD transmission line. The USFWS has indicated that collisions with transmission lines are the main known cause of whooping crane mortality during their migrations (USFWS, 2009c). On May 8, 2009, NPPD informed the USFWS that NPPD had agreed to mark that portion of the NPPD transmission line that crosses the Platte River with bird flight diverters to increase the visibility of the transmission line and reduce the risk of birds colliding with the line (NPPD, 2009c). The USFWS replied to NPPD on June 8, 2009, informing them that NPPD had satisfactorily addressed the concerns of the USFWS regarding bird collisions (USFWS, 2009i).

The extremely rare Salt Creek tiger beetle is found only in the northern third of Lancaster County, Nebraska (Cornell University, 2008), (USFWS, 2005), (NatureServe, 2008b). The transmission line corridor for CNS traverses the southern portion of Lancaster County (NPPD, 2008a). The Salt Creek tiger beetle is about ½ inch (1.0 cm) long and is metallic brown to dark, olive green above with a metallic, dark green underside (USFWS, 2005), (USFWS, 2009e). The tiger beetle is an active predator, grasping other small invertebrates for prey with its mandibles. The Salt Creek tiger beetle, limited to three populations totaling less than 150 adults, is found only in saline wetlands and along muddy banks of associated streams and tributaries of Little Salt Creek in Lincoln, Nebraska. Threats to the remaining populations of the Salt Creek tiger beetle include habitat loss and degradation caused by development, increased water runoff and sediment runoff from urban areas, eroding banks associated with development, bank stabilization projects, pollution, pesticides, and habitat loss and degradation from grazing and cultivation (Cornell University, 2008), (USFWS, 2005). On December 12, 2007, the USFWS proposed the designation of critical habitat for the Salt Creek tiger beetle (USFWS, 2009f).

The black-footed ferret is considered to be one of the most endangered mammals in the United States, and has the potential to survive in Hamilton County and Merrick County, Nebraska, near the western limit of transmission line NPPD TL3502 (USFWS, 2009b), (NPPD, 2008a). It is a member of the weasel family (*Mustelidae*), and is the only ferret native to North America. The black-footed ferret's distinctive coloration includes a black face mask, black feet, and a black-tipped tail, with a light yellow-buff color on its back and body. It is approximately 6 inches (15 cm) tall, 18–24 inches (50–60 cm) long including a 6-inch (15 cm) tail, and weighs

1.5–2.5 lbs (0.7–1.1 kg) (Defenders of Wildlife, 2009), (NatureServe, 2009c), (USFWS, 2000a), (USFWS, 2009g).

Black-footed ferrets once ranged throughout the Great Plains region of the United States and part of southern Canada. They live primarily on the open prairie and spend most of their time underground in prairie dog burrows, relying on prairie dogs as their prey. Through the first half of the twentieth century, the conversion of open prairie to farmland, the shooting and poisoning of prairie dogs to eliminate them from livestock grazing areas, and sylvatic plague wiped out large numbers of prairie dogs and correspondingly decimated the black-footed ferret population. The black-footed ferret was feared extinct by the mid-1970s, until a small population of 130 was identified in Wyoming in 1981 (Black-footed Ferret Recovery Implementation Team, 2009), (Defenders of Wildlife, 2009), (USFWS, 2000a). A captive breeding program over the last 25 years has increased their population from a low of 18 wild black-footed ferrets to their present number of 750 living in the wild, including an experimental nonessential population and 250 living in captive breeding facilities (USFWS, 2000a), (USFWS, 2009g). Current threats to the black-footed ferret still include their reliance on prairie dogs as their food source, the corresponding prairie dog management practices implemented by agricultural interests competing for land, and the reduction and fragmentation of prairie dog populations to less than 5 percent of their historic range (Defenders of Wildlife, 2009), (NatureServe, 2009c).

State Protected Species

A total of 115 terrestrial species (41 terrestrial animal species and 74 terrestrial plant species) are protected by Nebraska and Missouri, and are listed as endangered, threatened, or species of special concern (S1, S2, SX, SH) (Table 2.2.7-1). Ninety-three of the protected species occur in Nebraska, and 37 of the protected species are in Atchison County, M. These 115 species have the potential to inhabit the counties within the vicinity of CNS and/or the transmission line corridor, including Nemaha County, Johnson County, Gage County, Lancaster County, Saline County, Fillmore County, York County, Hamilton County, and Merrick County, Nebraska, and Atchison County, Missouri. These 41 animal species include 14 bird species, 12 reptile species, 2 amphibian species, 8 mammal species, and 5 insect species (NGPC, 2008), (NGPC, 2009c), (MDC, 2009b), (MDC, 2009c), (USFWS, 2008a), (USFWS, 2009b). NPPD has indicated that no currently Federally- or State-listed terrestrial plant or animal species have been observed on the CNS property (NPPD, 2008a).

Forty-nine of the protected species inhabit Nemaha County, Nebraska, the location of CNS, including 15 species of mammals, birds, reptiles, and amphibians, and 34 species of plants (Table 2.2.7-1). Nebraska lists two mammals, the southern flying squirrel (*Glaucomus volans*) as threatened and the woodland vole (*Microtus pinetorum*) as a species of concern. Both species occur in Nemaha County. Six bird species protected by Nebraska that occur in Nemaha County include the ruffed grouse (*Bonasa umbellus*), the whip-poor-will (*Caprimulgus vociferous*), the peregrine falcon (*Falco peregrinus*), the barred owl (*Strix varia*), the blue-gray gnatcatcher (*Poliophtila caerulea*), and the Carolina wren (*Thryothorus ludovicianus*) (NatureServe, 2009e), (NGPC, 2009c). The peregrine falcon was once a Federally-listed species, but was delisted in 1999. The bald eagle (*Haliaeetus leucocephalus*), an S3 designation, has been observed on both sides of the Missouri River on the CNS property. The bald eagle was likewise a listed species, but was delisted in 2007. Both the peregrine falcon and the bald eagle are protected under the Migratory Bird Treaty Act, and the bald eagle is also protected under the Bald and Golden Eagle Protection Act. There is an active bald eagle nest adjacent to a field on the Missouri side of the CNS property. Six Nebraska State protected reptiles and one amphibian known to inhabit Nemaha County include the western wormsna

Affected Environment

(*Carphophis vermis*), the yellow-bellied kingsnake (*Lampropeltis calligaster*), the common kingsnake (*Lampropeltis getula*), the smooth green snake (*Liochlorophis vernalis*), Graham's crayfish snake (*Regina grahamii*), the Massasauga rattlesnake (*Sistrurus catenatus*), and the smallmouth salamander (*Ambystoma texanum*) (NatureServe, 2009e), (NGPC, 2009c).

Nebraska lists 27 animal species and 39 plant species that are protected and occur or potentially occur in the counties traversed by the transmission line. Species listed as endangered by Nebraska that occur or potentially occur in the counties traversed by the transmission line corridor include the whooping crane, interior least tern, Salt Creek tiger beetle, American burying beetle (*Nicrophorus americanus*), Eskimo curlew, and black-footed ferret. Species listed as threatened by Nebraska that occur or potentially occur in the counties traversed by the transmission line corridor include the Massasauga rattlesnake, the piping plover, and the river otter (*Lontra canadensis*) (NatureServe, 2009e), (NGPC, 2009c).

The 37 protected species in Atchison, County, Missouri (the eastern portion of the CNS site), include 16 species of mammals, birds, reptiles, amphibians, and insects, and 21 species of plants. Two mammals that potentially occur on the CNS site in Missouri include the State endangered Indiana bat (*Myotis sodalis*) and the plains spotted skunk (*Spilogale putorius interrupta*). Other State protected mammals include the plains pocket mouse (*Perognathus flavescens*) and Franklin's ground squirrel (*Spermophilus franklinii*). Five bird species protected by Missouri also are in Atchison County, and include the peregrine falcon, the loggerhead shrike (*Lanius ludovicianus*), the black rail (*Laterallus jamaicensis*), the king rail (*Rallus elegans*), and the interior least tern. Four reptiles protected by Missouri and known to inhabit Atchison County are the western fox snake (*Elaphe vulpine*), the smooth green snake, the Massasauga rattlesnake, listed as State endangered, and the Great Plains skink (*Eumeces obsoletus*). One amphibian protected by Missouri and known to inhabit Atchison County is the northern leopard frog (*Rana pipiens*). Two insect species are protected by Missouri and found in Atchison County, and include Packard's grasshopper (*Melanoplus packardii*) and the American burying beetle. The western prairie-fringed orchid is State listed as endangered (MDC, 2009b), (MDC, 2009c), (NatureServe, 2009d).

2.2.8 Socioeconomic Factors

This section describes current socioeconomic factors that have the potential to be directly or indirectly affected by changes in operations at CNS. CNS and the people and communities surrounding it can be described as a dynamic socioeconomic system. The nuclear power plant requires people, goods, and services from local communities to operate the plant; and the communities, in turn, provide the people, goods, and services to run the plant. CNS employees residing in the community receive income from the plant in the form of wages, salaries, and benefits, and spend this income on goods and services within the community, thereby creating additional opportunities for employment and income. People and businesses in the community also receive income for the goods and services sold to CNS. Payments for these goods and services create additional employment and income opportunities in the community. The measure of a communities' ability to support the operational demands of CNS depends on the ability of the community to respond to changing socioeconomic conditions.

The socioeconomic region of influence (ROI) is defined by the areas where CNS employees and their families reside, spend their income, and use their benefits, thereby affecting the economic conditions of the region. The CNS ROI consists of a four-county area (Nemaha, Otoe, and Richardson counties in Nebraska and Atchison County in Missouri) where approximately 90 percent of CNS employees reside. The following sections describe the housing, public

services, offsite land use, visual aesthetics and noise, population demography, and the economy in the ROI surrounding CNS.

NPPD employs a permanent workforce of approximately 750 employees (NPPD, 2008a). Approximately 90 percent live in Nemaha, Otoe, and Richardson counties, Nebraska, and Atchison County, Missouri (Table 2.2.8-1). Most of the remaining 10 percent of the workforce are divided among 23 counties in Iowa, Kansas, Missouri, and Nebraska with numbers ranging from 1 to 13 employees per county. Given the residential locations of CNS employees, the most significant impacts of plant operations are likely to occur in Nemaha, Otoe, Richardson, and Atchison counties. The focus of the socioeconomic impact analysis in this SEIS is, therefore, on the impacts of CNS on these four counties.

Table 2.2.8-1. Cooper Nuclear Station Employee Residence by County

County	Number of Employees	Percentage of Total
Nemaha, NE	359	48
Otoe, NE	108	14
Atchison, MO	106	14
Richardson, NE	100	13
Fremont, IA	13	2
Holt, MO	12	2
Cass, NE	11	2
Other	41	5
Total	750	100

Source: NPPD, 2008a

Refueling outages at CNS normally occur at 18-month intervals. During refueling outages, site employment increases by as many as 700 to 900 workers for approximately 30 days (NPPD, 2008a). Most of these workers are assumed to be located in the same geographic areas as CNS employees.

2.2.8.1 Housing

Table 2.2.8.1-1 lists the total number of occupied and vacant housing units, vacancy rates, and median value in the four-county ROI. According to the 2000 Census, there were approximately 17,700 housing units in the socioeconomic region, of which approximately 15,800 were occupied. The median value of owner-occupied housing units in the three Nebraska counties ranged from \$38,900 in Richardson County to \$78,000 in Otoe County. The vacancy rate was the lowest in Otoe County (7.7 percent) and highest in Richardson County (12.4 percent). Atchison County, M, has the smallest number of total and vacant housing units among the four counties (USCB, 2009).

By 2007, the estimated number of housing units grew in all three counties by approximately 3 percent of their total inventories. In Nemaha County, the number of housing units grew to an estimated total of 3,540 units in 2007, an increase of more than 100 units. In Otoe County, the number of housing units grew by more than 390 units to an estimated total of 6,955 units or

Affected Environment

approximately 6 percent. The estimated total number of housing units also increased slightly in Atchison County, Missouri (USCB, 2009).

Table 2.2.8.1-1. Housing in Nemaha, Otoe, and Richardson Counties in Nebraska and Atchison County in Missouri

	Nemaha	Otoe	Richardson	Atchison	ROI
2000					
Total	3,439	6,567	4,560	3,103	17,669
Occupied housing units	3,047	6,060	3,993	2,722	15,822
Vacant units	392	507	567	381	1,847
Vacancy rate (percent)	11.4	7.7	12.4	12.3	10.5
Median value (dollars)	58,200	78,000	38,900	49,800	56,225
2007*					
Total	3,540	6,955	4,563	3,129	18,187

* Estimated occupied housing units, vacancy, and median value data is not available for all counties.

Source: USCB, 2009.

2.2.8.2 Public Services

This section presents information regarding public services including water supply, education, and transportation.

Water Supply

Because 90 percent of workers at CNS reside in Nemaha, Otoe, and Richardson counties, Nebraska and Atchison County, Missouri, the discussion of public water supply systems is limited to these counties. In Table 2.2.8.2-1, information about municipal water suppliers in these counties, their permitted capacities and/or maximum design yields, reported annual peak usage, and population served are presented. The primary source of potable water in the vicinity of CNS is ground water. Most of Nemaha, Atchison, and Richardson counties are not served by community water supplies. Private ground water wells supply much of the water to residents in the area.

There are four wellhead protection areas within 10 mi of CNS: Village of Nemaha, Nemaha County Rural Water District (RWD) No. 1, City of Auburn, and Village of Stella. CNS does not use public water systems for cooling or process water systems. NPPD relies on ground water wells and surface water from the Missouri River for all of its water needs at the CNS. Two wells supply potable water to the facility (NPPD, 2008a).

Community water supply systems in Nemaha County include the City of Auburn, the City of Nemaha, Nemaha County RWD No. 1, Nemaha County RWD No. 2, and the City of Peru. The Village of Brownville no longer uses its own supply wells, but is connected to Nemaha County RWD No. 1 (NPPD, 2008a). The Auburn Board of Public Works operates the Auburn Municipal Water System. Eleven wells can provide up to 1,728,000 gallons of water per day. The system provides an average of 700,000 gallons of water per day and can meet a peak demand of 1,181,700 gallons per day. The system has a storage capacity of 1,650,000 gallons (NDED and

NPPD, 2008). The Nemaha municipal water system serves the Village of Nemaha and provides an average of 17,500 gallons of water per day and can meet a peak demand of 30,000 gallons per day. The system has a rated capacity of 216,000 gallons per day (NPPD, 2008a).

Nemaha County RWD No. 1 has a rated capacity of 100,000 gallons per day with a peak demand of 90,000 gallons per day. The Nemaha County RWD No. 1 public water system serves rural Nemaha County including the Village of Brownville. Nemaha County RWD No. 2 has an average service demand of 206,300 gallons per day. The storage capacity is reported to be 230,000 gallons (NPPD, 2008a).

The Peru Municipal Water System serves the municipality of Peru in Nemaha County. The Peru system has a rated capacity of 576,000 gallons per day with an average of 83,000 gallons and a peak demand of 113,500 gallons per day (NPPD, 2008a).

Nebraska City Utilities provides water to the residents of Nebraska City in Otoe County. This water system has a rated capacity of 6,300,000 gallons per day with an average of 2,500,000 gallons and a peak demand of 3,500,000 gallons per day (Great Plains Energy, 2009).

Falls City provides water to approximately 4,800 residents in Richardson County. The water system has a rated capacity of 2,160,000 gallons per day with an average of 690,000 gallons and a peak demand of 1,528,000 gallons per day (Great Plains Energy, 2009).

Richardson County RWD No. 1 and the Village of Shubert have community water systems within 10 mi of CNS. Richardson County RWD No. 1 system has a capacity of 230,000 gallons per day with an average demand of 100,000 gallons per day. The Village of Shubert operates a municipal water system with a capacity of 204,000 gallons per day, with an average daily demand of 22,800 gallons (NPPD, 2008a).

Almost all potable water use within Atchison County is from ground water supplied from wells, with the exception of Westboro, Missouri, which purchases water from a surface water source. The Rock Port Municipal Water System on average supplies approximately 300,000 gallons per day with a system capacity of approximately 720,000 gallons per day (MDNR, 2008).

Table 2.2.8.2-1. Public Water Supply Systems (thousand gallons per day)

Water Supplier^(a)	Water Source^(a)	Average Daily Demand	System Capacity	Population Served^(a)
Nemaha County, Nebraska				
City of Auburn	GW	1,182	1,728	3,217
Village of Nemaha	GW	30	216	188
City of Peru	GW	114	576	923
Nemaha County RWD No. 1	GW	90	100	800
Nemaha County RWD No. 2	GW	206	230	1,315
Otoe County, Nebraska				
City of Nebraska City	GW	2,500	6,300	7,192
Richardson County, Nebraska				
City of Falls City	GW	690	2,160	4,761
Richardson County RWD No. 1	GW	100	230	805
Village of Shubert	GW	23	204	240
Atchison County, Missouri				
Fairfax	GW	185	308	645
Public Water System District No. 1 of Atchison County	GW	171	1,310	831
City of Rock Port	GW	300	720	726
Tarkio Board of Public Works	GW	225	756	1,957
Westboro	SW	20	75	160

GW = ground water; SW = surface water; RWD = rural water district

(a) EPA, 2009b

Source: EPA, 2009b; NDED and NPPD, 2008; NPPD, 2008a; Great Plains Energy, 2009; MDNR, 2008

Education

The CNS is located in the Auburn Public School District, Nemaha County, which has an enrollment of approximately 882 students in the 2008–2009 school year (NDE, 2009). Nemaha County has two public school districts with over 1,100 enrolled students (NDE, 2009). Otoe and Richardson counties have four school districts each (NDE, 2008). Total enrollment in Otoe and Richardson County schools in the 2008–2009 school years was approximately 2,900 and 1,600 students, respectively (NDE, 2009).

Transportation

Several highways serve as transportation corridors within Nemaha and Atchison counties. The primary highways in Nemaha County include U.S. Highways 75 and 136 and Nebraska State Highways 62, 67, and 105. Access to the site is by Nemaha County Road 648A Avenue located on the west side of the CNS property. County Road 648A Avenue intersects U.S. Highway 136

which runs east to west, north of CNS in Brownville, Nebraska. State Highway 67 traverses Nemaha County north to south to the west of CNS. U.S. Highway 75 bisects Nemaha County running north to south. Plant workers living east and west of CNS travel on U.S. Highway 136 to Nemaha County Road 648A Avenue to the site access road, and workers living north and south travel on U.S. Highway 75 and Nebraska State Highway 67 to U.S. Highway 136.

The primary highways in Atchison County, Missouri, on the east side of the Missouri River include Interstate 29 (I-29), U.S. Highways 136, 59, and 275; Missouri State Highways 46 and 111; and County Roads B, M, and T. I-29 runs north to south through Atchison County roughly parallel to the river between Council Bluffs, Iowa northeast of CNS and St. Joseph, Missouri, southeast of CNS. CNS employees who reside in Missouri can access the site by using either U.S. Highways 136 or 159, which cross the Missouri River in Brownville and Rulo, Nebraska (in Richardson County), respectively. U.S. Highway 136 bisects Atchison County east to west in Missouri, similar to Nemaha County on the west side of the river. Atchison County is also bisected by U.S. Highway 59 which runs north to south through the central portion of the county.

Primary highways in Richardson County include U.S. Highways 73, 75, and 159 and State Highways 8, 62, 67, and 105. U.S. Highway 75 runs north and south through both Nemaha and Richardson counties. U.S. Highway 159 crosses the river downstream of CNS in Rulo, Nebraska, from Holt County, Missouri.

The primary highways in Otoe County include U.S. Highways 50 and 75 and Nebraska State Highways 2, 43, 66A, 67, and 128. Otoe County is bisected north to south by U.S. Highway 50 and Nebraska State Highway 2. Access to Otoe County directly from CNS is primarily from Nebraska State Highway 67 and U.S. Highway 75.

Table 2.2.8.2-2 lists commuting routes to CNS and average annual daily traffic (AADT) volume values. The AADT values represent traffic volumes for a 24-hour period factored by both day of the week and month of the year.

Table 2.2.8.2-2. Major Commuting Routes in the Vicinity of Cooper Nuclear Station in 2006 Average Annual Daily Traffic Count

Roadway and Location	AADT ^(a)
U.S. Highway 136 (between State Highway 67 and Brownville, NE)	2,905
U.S. Highway 136 (between Brownville, NE and Missouri River)	2,615
U.S. Highway 136 (between Interstate 29 and the Missouri River in Missouri)	2,487
U.S. Highway 136 at Rock Port, MO	3,194
U.S. Highway 136 (between Auburn, NE and State Highway 67)	3,205
State Highway 67 (between Nemaha, NE and Brownville, NE)	960
State Highway 67 at Nemaha, NE	770
State Highway 67 south of CNS	625
State Highway 67 at Peru, NE	1,025
U.S. Highway 75 (between State Highway 67 and U.S. Highway 136, Auburn, NE)	5,220
U.S. Highway 75 (near Julian, NE)	4,640
U.S. Highway 75 (south of Nebraska City, NE)	5,585
Interstate 29 north of U.S. Highway 136 in Missouri	10,325
Interstate 29 south of U.S. Highway 136 in Missouri	11,832

Source: NDOR, 2007; MOBOT, 2007

(a) All AADTs represent traffic volume during the average 24-hour day during 2006.

U.S. = United States

2.2.8.3 Offsite Land Use

Offsite land use conditions in Nemaha County, Otoe County, Richardson County, and Atchinson County are described in this section. In addition to property taxes, Nemaha and other counties in the vicinity of CNS receive revenue from sales taxes and fees paid by NPPD and its employees residing in the region. Changes in the number of workers at CNS and tax payments to local jurisdictions could affect land use conditions in these counties.

CNS is located in eastern Nemaha County. Otoe, Richardson, and Atchinson counties are located along the Missouri River, north, south, and east of Nemaha County, respectively. The four-county area near CNS is rural and largely unincorporated. Less than half of the population in the four-county area lives in incorporated towns and villages. Most of the land in the four-county area is in agricultural use or is forest or open land. Only a small percentage of the land has been developed for residential, commercial, or industrial purposes. Forested areas are generally limited to narrow strips of land along streams and rivers and steep, hilly areas unsuitable for agriculture.

Nemaha, Richardson, and Atchison counties have seen a steady decline in population over the past 50 years as residents leave farms to seek employment in larger cities and towns. Most towns and villages located within a 50-mi radius of CNS are small and primarily support agricultural communities. The closest communities to CNS are the Village of Brownville, located approximately 2 mi northwest of CNS, and the town of Nemaha to the south. Industrial developments in the four-county area are located in the larger communities of Auburn and Nebraska City, Nebraska, and Marysville, Missouri.

Nemaha County occupies approximately 409 mi² (262,000 ac) (USCB, 2009). Approximately 213,000 ac or 81 percent of the land in Nemaha County was used for agriculturally related activities in 2007. There were 449 farms, with most of the agricultural land devoted to cropland (80 percent) and pasture (12 percent) (USDA, 2009). Nemaha County does not have county-wide zoning regulations, although the city of Auburn has local zoning regulations (NPPD, 2008a).

Otoe County occupies roughly 616 mi² (394,000 ac) (USCB, 2009). The largest category of land use, approximately 322,000 ac or 82 percent, is devoted to agriculture in Otoe County, with 804 farms in 2007. Approximately 80 percent of the agricultural land is in cropland and approximately 11 percent pasture (USDA, 2009). Otoe County has county-wide zoning regulations to manage future growth and development in the county.

Richardson County occupies roughly 553 mi² (354,000 ac) (USCB, 2009). The largest category of land use, approximately 279,000 ac or 79 percent, is devoted to agriculture in Richardson County, with 707 farms in 2007. Approximately 75 percent of the agricultural land is cropland and approximately 14 percent is pasture (USDA, 2009). Richardson County does not have county-wide zoning regulations, although the City of Falls city has local zoning regulations (NPPD, 2008a).

Atchison County, Missouri occupies approximately 545 mi² (349,000 ac) (USCB, 2009). Approximately 87 percent of Atchison County land is used for agricultural purposes. In 2007, the county had 501 farms on approximately 304,000 ac. Major agricultural uses consist of croplands (87 percent) and 6 percent pasture (USDA, 2009). Atchison County currently does not have county-wide zoning regulations to manage future growth and development (NPPD, 2008a).

No significant change in land use is anticipated for the future in these four counties. Land use trends reflect a slow, but steady overall decline in population in the region. Limited potential commercial and urban development occurs in the small urban areas where public services and utilities are available. No significant changes in future agricultural acreage, farm size, and land uses are anticipated for the four-county region near CNS.

2.2.8.4 *Visual Aesthetics and Noise*

CNS can be seen from the river, but is partly shielded by vegetation along the river. Predominant features are the reactor building, which is approximately 290 ft tall, the elevated release point (325 ft), and meteorological tower (328.8 ft). The turbine building and reactor containment structures dominate the landscape of the site. The 239 undeveloped acres of the CNS site on the Missouri (east) side of the river provides a wooded view from the river.

Noise from nuclear plant operations can be detected offsite. Sources of noise at CNS include the turbines and large pump motors. Given the industrial nature of the station, noise emissions from the station are generally nothing more than an intermittent minor nuisance. The EPA uses the 55 decibels adjusted (dBA) level as a threshold level to protect against excess noise during

Affected Environment

outdoor activities (EPA, 1974). However, according to the EPA this threshold does “not constitute a standard, specification, or regulation,” but was intended to provide a basis for State and local governments establishing noise standards.

2.2.8.5 Demography

According to the 2000 Census, approximately 18,318 people lived within 20 mi of CNS, which equates to a population density of 15 persons per mi² (NPPD, 2008a). This density translates to Category 1, most sparse (less than 40 persons per mi² and no community with 25,000 or more persons within 20 mi). Approximately 160,211 people live within 50 mi of CNS (NPPD, 2008a). This equates to a population density of 20 persons per mi². Applying the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437, proximity measures, CNS is classified as proximity Category 1 (no city with 100,000 or more persons and less than 50 persons per mi² within 50 mi). Therefore, according to the sparseness and proximity matrix presented in the GEIS, CNS rankings of sparseness Category 1 and proximity Category 1 result in the conclusion that CNS is located in a low population area.

Table 2.2.8.5-1 shows population projections and growth rates from 1970 to 2050 in Nemaha, Otoe, and Richardson counties, Nebraska, and Atchison County, Missouri. The growth rate in Nemaha County showed a decrease of 5.1 percent for the period of 1990 to 2000. County populations are expected to continue to decline in Nemaha, Richardson, and Atchison counties in the next decades, although Otoe County’s population is expected to increase through 2050.

Table 2.2.8.5-1. Population and Percent Growth in Nemaha, Otoe, and Richardson Counties, Nebraska, and Atchison County, Missouri, from 1970 to 2000 and Projected for 2007 to 2050

Year	Nemaha, NE		Otoe, NE		Richardson, NE		Atchison, MO	
	Population	Percent Growth ^(a)	Population	Percent Growth ^(a)	Population	Percent Growth ^(a)	Population	Percent Growth ^(a)
1970	8,976	—	15,576	—	12,277	—	9,240	—
1980	8,367	-6.8	15,183	-2.5	11,315	-7.8	8,605	-6.9
1990	7,980	-4.6	14,252	-6.1	9,937	-12.2	7,457	-13.3
2000	7,576	-5.1	15,396	8.0	9,531	-4.1	6,430	-13.8
2007	7,039	-7.1	15,647	1.6	8,351	-12.4	6,108	-5.0
2010	6,767	-10.7	15,704	2.0	8,408	-11.8	5,927	-7.8
2020	6,456	-4.6	16,399	4.4	7,892	-6.1	5,559	-6.2
2030	6,033	-6.6	17,414	6.2	7,398	-6.3	5,280	-5.0
2040	5,685	-5.8	18,216	4.6	6,889	-6.9	4,942	-6.4
2050	5,318	-6.5	19,071	4.7	6,384	-7.3	4,618	-6.5

— = No data available.

(a) Percent growth rate is calculated over the previous decade.

Sources: Population data for 1970 through estimated population data for 2006 (USCB, 2009); population projections for 2010–2030 by Bureau of Business Research (BBR) (2008), University of Nebraska-Lincoln, Nebraska Population Projections and Missouri State Demographer, Office of Administration, No Date; population projections for 2040 and 2050 (calculated).

Demographic Profile

The 2000 and 2006 (estimate) demographic profiles of the four-county ROI population are presented in Tables 2.2.8.5-2 and 2.2.8.5-3. In 2000, minorities (race and ethnicity combined) comprised 3.8 percent of the total four-county population. The minority population is composed of Hispanic or Latino and American Indian residents.

Table 2.2.8.5-2. Demographic Profile of the Population in the Cooper Nuclear Station Four-County Socioeconomic Region of Influence in 2000

	Nemaha, NE	Otoe, NE	Richardson, NE	Atchison, MO	ROI
Total Population	7,576	15,396	9,531	6,430	38,933
Race (percent of total population, Not-Hispanic or Latino)					
White	97.1	96.3	95.1	96.6	96.2
Black or African American	0.4	0.2	0.2	2.1	0.5
American Indian and Alaska Native	0.2	0.2	2.1	0.2	0.7
Asian	0.6	0.2	0.1	0.1	0.3
Native Hawaiian and Other Pacific Islander	0.0	0.0	0.0	0.0	0.0
Some other race	0.0	0.0	0.0	0.0	0.0
Two or more races	0.6	0.6	1.4	0.3	0.7
Ethnicity					
Hispanic or Latino	76	377	100	43	596
Percent of total population	1.0	2.4	1.0	0.7	1.5
Minority Population (including Hispanic or Latino ethnicity)					
Total minority population	218	574	469	219	1,480
Percent minority	2.9	3.7	4.9	3.4	3.8

Source: USCB, 2009

According to the USCB's 2007 estimates published in 2009, minority populations in the four-county region were estimated to have increased by over 500 persons and comprised 5.4 percent of the total four county population (see Table 2.2.8.5-3). Most of this increase was due to an estimated influx of Hispanic or Latinos (over 320 persons), an increase in population of over 55 percent from 2000. This was the largest percentage increase of any minority population and a 1 percent increase in Hispanic or Latino population when compared to the total four-county population. The next highest percentage increase in minority population was Asian, an increase of over 51 percent from 2000. However, this resulted in only a very slight increase in population as a percentage of the total four-county population.

Table 2.2.8.5-3. Demographic Profile of the Population in the Cooper Nuclear Station Four-County Socioeconomic Region of Influence in 2007, Estimated

	Nemaha, NE	Otoe, NE	Richardson, NE	Atchison, MO	Region of Influence
Total Population	7,039	15,647	8,351	6,108	37,145
Race (percent of total population, not Hispanic or Latino)					
White	95.9	94.1	93.9	95.6	94.6
Black or African American	0.6	0.5	0.3	2.3	0.7
American Indian and Alaska Native	0.3	0.4	2.6	0.3	0.9
Asian	0.8	0.3	0.5	0.3	0.4
Native Hawaiian and Other Pacific Islander	0.0	0.0	0.0	0.0	0.0
Some other race	*	*	*	*	*
Two or more races	0.6	0.8	1.4	0.3	0.8
Ethnicity					
Hispanic or Latino	126	612	111	73	922
Percent of total population	1.8	3.9	1.3	1.2	2.5
Minority Population (including Hispanic or Latino ethnicity)					
Total minority population	288	930	506	269	1,993
Percent minority	4.1	5.9	6.1	4.4	5.4

* Some other race was eliminated from the Census estimate.

Source: USCB, 2009

Transient Population

Within 50 mi (80 km) of the CNS, colleges and recreational opportunities attract daily and seasonal visitors who create demand for temporary housing and services. In 2009, there were approximately 8,018 students attending colleges and universities within 50 mi (80 km) of the CNS (IES, 2009).

In 2000 in Nemaha County, 1.6 percent of all housing units are considered temporary housing for seasonal, recreational, or occasional use. By comparison, seasonal housing accounted for 0.6 percent, 1.3 percent, and 1.6 percent of total housing units in Otoe and Richardson counties and Nebraska, respectively (USCB, 2009). Seasonal housing accounted for 1.2 percent and 2.7 percent of total housing units in Atchison County and Missouri, respectively (USCB, 2009). Table 2.2.8.5-4 provides information on seasonal housing for the 24 counties located all or partly within 50 mi of the CNS.

Table 2.2.8.5-4. Seasonal Housing in Counties Located within 50 Miles of the Cooper Nuclear Station

County^(a)	Housing Units	Vacant housing units: for seasonal, recreational, or occasional use	Percent
Iowa	1,232,511	16,472	1.3
Fremont	3,514	56	1.6
Mills	5,671	64	1.1
Montgomery	5,399	38	0.7
Page	7,302	47	0.6
Taylor	3,199	19	0.6
County Subtotal	25,085	224	0.9 (avg.)
Kansas	1,131,200	9,639	0.9
Atchison	6,818	47	0.7
Brown	4,815	36	0.7
Doniphan	3,489	28	0.8
Jackson	5,094	42	0.8
Marshall	4,999	46	0.9
Nemaha	4,340	35	0.8
County Subtotal	29,555	234	0.8 (avg.)
Missouri	2,442,017	66,053	2.7
Andrew	6,662	58	0.9
Atchison	3,103	38	1.2
Holt	2,931	391	13.3
Nodaway	8,909	60	0.7
County Subtotal	21,605	547	4.0 (avg.)
Nebraska	722,668	11,912	1.6
Cass	10,179	541	5.3
Gage	10,030	56	0.6
Johnson	2,116	14	0.7
Lancaster	104,217	303	0.3
Nemaha	3,439	56	1.6
Otoe	6,567	37	0.6
Pawnee	1,587	78	4.9
Richardson	4,560	59	1.3
Sarpy	44,981	211	0.5
County Subtotal	187,676	1,355	1.7 (avg.)
County Total	263,921	2,360	1.2 (avg.)

Source: USCB, 2009

(a) Counties within 50 mi of CNS that are totally or partially located within the 50-mi radius
 avg. = percent average for counties within the CNS 50-m radius and excludes State percentage

Affected Environment

Migrant Farm Workers

Migrant farm workers are individuals whose employment requires travel to harvest agricultural crops. These workers may or may not have a permanent residence. Some migrant workers follow the harvesting of crops, particularly fruit, throughout rural areas of the United States. Others may be permanent residents near CNS who travel from farm to farm harvesting crops.

Migrant workers may be members of minority or low-income populations. Because they travel and can spend a significant amount of time in an area without being actual residents, migrant workers may be unavailable for counting by census takers. If uncounted, these workers would be "underrepresented" in USCB minority and low-income population counts.

Information on migrant farm and temporary labor was collected in the 2007 Census of Agriculture. Table 2.2.8.5-5 provides information on migrant farm workers and temporary farm labor (less than 150 days) within 50 mi of CNS. According to the 2007 Census of Agriculture, approximately 7,000 farm workers were hired to work for less than 150 days and were employed on 3,300 farms within 50 mi of CNS. The county with the largest number of temporary farm workers (774 workers on 280 farms) was Lancaster County, Nebraska (USDA, 2009).

In the 2007 Census of Agriculture, farm operators were asked for the first time whether or not any hired migrant workers, defined as a farm worker whose employment required travel that prevented the migrant worker from returning to their permanent place of residence the same day. A total of 87 farms in the 50-mi radius of CNS reported hiring migrant workers in the 2007 Census of Agriculture. Nodaway County, Missouri, and Lancaster County, Nebraska, reported the most farms (18 and 17, respectively) with hired migrant workers, followed by Nemaha County, Nebraska, with 10 farms (USDA, 2009).

According to the 2007 Census of Agriculture estimates, 195 temporary farm laborers (those working fewer than 150 days per year) were employed on 84 farms in Nemaha County, and 311 and 323 temporary farm workers were employed on 145 and 143 farms in Otoe and Richardson counties, respectively (USDA, 2009). Atchison County, Missouri, had 226 temporary farm workers employed on 99 farms (USDA, 2009).

Table 2.2.8.5-5. Migrant Farm Workers and Temporary Farm Labor in Counties Located within 50 Miles of the Cooper Nuclear Station

County^(a)	Number of farms with hired farm labor^(b)	Number of farms hiring workers for less than 150 days^(b)	Number of farm workers working for less than 150 days^(b)	Number of farms reporting migrant farm labor^(b)
Iowa	23,287	19,204	50,266	123
Fremont	126	95	247	2
Mills	91	70	NA	0
Montgomery	118	100	187	0
Page	189	158	276	0
Taylor	134	103	259	1
County Subtotal	658	526	969	3
Kansas	14,437	11,558	30,682	193
Atchison	115	105	231	0
Brown	171	142	333	3
Doniphan	130	108	211	0
Jackson	145	128	319	2
Marshall	246	209	498	3
Nemaha	289	250	584	10
County Subtotal	1,096	942	2,176	18
Missouri	18,263	15,052	33,424	745
Andrew	134	113	258	2
Atchison	134	99	226	2
Holt	136	105	214	1
Nodaway	308	251	472	18
County Subtotal	712	568	1,170	23
Nebraska	14,603	11,261	29,583	468
Cass	148	119	273	4
Gage	322	272	585	7
Johnson	120	105	NA	5
Lancaster	310	280	774	17
Nemaha	107	84	195	3
Otoe	175	145	311	2
Pawnee	91	83	NA	0
Richardson	164	143	323	3
Sarpy	87	69	218	2
County Subtotal	1,524	1,300	2,679	43
County Total	3,990	3,336	6,994	87

Source: 2007 Census of Agriculture - County Data (USDA, 2009)

(a) Counties within 50 mi of CNS that are totally or partially located within the 50-mi radius

(b) Table 7. Hired Farm Labor - Workers and Payroll: 2007

Affected Environment

2.2.8.6 *Economy*

This section contains a discussion of the economy, including employment and income, unemployment, and taxes.

Employment and Income

Between 2000 and 2007, the civilian labor force in Nemaha County decreased 9.4 percent from 3,931 to 3,560. During the same time period, the civilian labor force in Otoe County grew by 13 percent. By 2007, the civilian labor force in Richardson and Atchison counties decreased by 6.3 and 2.4 percent, respectively (USCB, 2009).

In 2000, educational, health, and social services represented the largest sector of employment in the four-county region followed by manufacturing. The educational, health, and social services sector employed the most people in Nemaha County followed by transportation, warehousing, and utilities sectors. A list of some of the major employers in Nemaha County is provided in Table 2.2.8.6-1. As shown in the table, the largest employer in Nemaha County is CNS.

Table 2.2.8.6-1. Major Employers in Nemaha County

Firm	Number of Employees
Cooper Nuclear Station	750
Armstrong Cabinets	162
Peru State College	160
Auburn Public Schools	142
Nemaha County Good Samaritan Home	75
Magnolia Metals, Inc.	65
Nemaha County Hospital	65
Nemaha County Government	48
Johnson-Brock Public Schools	44

Source: NDE, 2009 and NPPD, 2009

Estimated income information for the CNS region of influence is presented in Table 2.2.8.6-2. According to the USCB's 2007 estimates, median household income averages in Nemaha, Otoe, Richardson, and Atchison counties were below their respective State median household income averages. In 1999, per capita income in the four counties was also below both State averages. In 2007, an estimated 13.3 and 13.4 percent of the county populations in Nemaha and Richardson counties were living below the official poverty level, while the percentage for the State of Nebraska as a whole was 11.1 percent. Conversely, Otoe County was estimated to have the smallest percentage of persons living in poverty (9.4 percent). In Atchison County, an estimated 14 percent of the county population was living below the official poverty level, while the percentage for the State of Missouri as a whole was 13.3 percent.

Table 2.2.8.6-2. Estimated Income Information for the Cooper Nuclear Station Region of Influence in 2007

	Nemaha	Otoe	Richardson	Nebraska	Atchison	Missouri
Median household income (dollars)	41,024	45,018	36,092	47,072	38,114	45,012
Per capita income in 1999 (dollars)	17,004	17,752	16,460	19,613	16,956	19,936
Percent of individuals living below the poverty level	13.3	9.4	13.4	11.1	14.0	13.3

Source: USCB 2009

Unemployment

According to the USCB's 2007 estimates, the unemployment rates in Nemaha, Otoe, and Richardson counties were 3.9, 3, and 4 percent, respectively, which was slightly lower than the unemployment rate of 4.8 percent for the State of Nebraska (USCB, 2009). The unemployment rate in Atchison County was 4.3 percent, which was much lower than the 6.5 percent for the State of Missouri (USCB, 2009).

Taxes

As a not-for-profit public corporation and political subdivision of the State of Nebraska, NPPD is exempt from paying income or property taxes. Instead, in lieu of tax, other payments are made to State, county, and local governments in which NPPD provides retail electric power.

According to the Nebraska State Constitution Article VIII, Section 11:

Every public corporation and political subdivision organized primarily to provide electricity or irrigation and electricity shall annually make the same payments in lieu of taxes as it made in 1957, which payments shall be allocated in the same proportion to the same public bodies or their successors as they were in 1957.

The legislature may require each such public corporation to pay to the treasurer of any county in which may be located any incorporated city or village, within the limits of which such public corporation sells electricity at retail, a sum equivalent to five (5) per cent of the annual gross revenue of such public corporation derived from retail sales of electricity within such city or village, less an amount equivalent to the 1957 payments in lieu of taxes made by such public corporation with respect to property or operations in any such city or village. The payments in lieu of taxes as made in 1957, together with any payments made as authorized in this section shall be in lieu of all other taxes, payments in lieu of taxes, franchise payments, occupation and excise taxes, but shall not be in lieu of motor vehicle licenses and wheel taxes, permit fees, gasoline tax and other such excise taxes or general sales taxes levied against the public generally.

So much of such five percent as is in excess of an amount equivalent to the amount paid by such public corporation in lieu of taxes in 1957 shall be distributed in each year to the city or village, the school districts located in such city or village, the county in which such city or village is located, and the State of Nebraska, in the proportion that their respective property tax mill levies in each such year bear to the total of such mill levies (Neb. Const. art. VIII, sec. 11 (1958); Adopted 1958).

Affected Environment

NPPD is Nebraska's largest electric utility, with a chartered territory including all or parts of 91 of Nebraska's 93 counties. NPPD pays monies in lieu of property taxes to the counties in which it provides retail electric power. As part of NPPD's generation capacity, a portion of the in lieu of tax payments and payments to retail communities may be attributed to CNS.

NPPD paid approximately \$6.6 million in 2006 and \$7 million in 2007 in lieu of taxes to the 91 counties in which NPPD is chartered (NPPD, 2008c). Each county receives 5 percent of the total gross revenues NPPD receives from electricity sales within the county. The actual in lieu of tax allocation attributable to CNS is not recorded by NPPD. NPPD's power generation units provide power to the grid, and county retail sales are then from the grid. However, CNS represents approximately 24 percent of NPPD's power generation capacity. Based on 24 percent generation, the payments in lieu of tax that could be attributed to CNS were approximately \$1.6 million in 2006 and \$1.7 million in 2007 (see Table 2.2.8.6-3).

NPPD also pays back 12 percent of the total gross revenues received from retail communities, which amounted to approximately \$17.5 million in 2006 and \$18.3 million in 2007 (NPPD, 2008c). Based on 24 percent of NPPD's total generation capacity, CNS's contribution to retail communities was \$4.2 million in 2006 and \$4.4 million in 2007 (see Table 2.2.8.6-3).

NPPD pays sales/use taxes on purchases made by CNS. As shown in Table 2.2.8.6-3, CNS paid \$943,020 in sales/use taxes in 2007 and \$1,353,435 in 2006. City sales taxes are paid to the town of Auburn, Nebraska. NPPD also pays a special assessment for the Brownville-Nemaha Levee District that is paid to the county treasurer (NPPD, 2008c). As shown in Table 2.2.8.6-3, the total taxes and payments to the State, counties, and retail communities attributable to CNS were approximately \$7.2 million in 2006 and \$7.1 million in 2007.

Table 2.2.8.6-3. Cooper Nuclear Station Estimated Tax Distribution, 2005–2007

Tax	2005	2006	2007
Nebraska State Sales/Use Tax	\$1,082,780	\$1,353,435	\$943,020
City of Auburn, NE Sales/Use Tax	240	455	40
Special Assessment on Brownville-Nemaha Levee Paid to Nemaha County	5,090	5,090	5,090
Nemaha County, NE Real Estate Taxes	10,865	10,980	11,140
Atchison County, MO Real Estate Taxes	145	145	140
Nebraska in Lieu of Taxes to Counties with NPPD Retail Electric Sales Attributed to the CNS	1,607,135	1,595,752	1,687,056
Payments to Retail Communities Attributed to CNS	4,267,771	4,233,381	4,436,089
Total	\$6,976,031	\$7,201,244	\$7,084,582

Source: NPPD, 2008c

2.2.9 Historic and Archaeological Resources

This section discusses the cultural background and the known historic and archaeological resources at the CNS site and in the surrounding area.

2.2.9.1 Cultural Background

CNS is located on a 1,120 ac tract in the floodplain on the west bank of the Missouri River in Nemaha County, Nebraska. To the west of the site are bluffs. CNS also owns an additional 239 ac on the eastern side of the river in Atchison County, Missouri. The eastern bank is a densely forested area that periodically floods, with bluffs that run parallel to the river. The region around the CNS site contains prehistoric and historic Native American and Euro-American cultural resources. Twelve properties in Nemaha County are listed in the *National Register of Historic Places* (NRHP) (NPS, 2009). The nearest NRHP property is the Captain Meriwether Lewis Dredge. Seven NRHP properties are located in Atchison County.

2.2.9.2 Prehistoric Periods

First Arrivals

CNS is situated in the Missouri River Valley on the eastern edge of the Central Great Plains and northwest edge of the Missouri Prairie-Timberlands. The first peoples began emigrating into the region toward the end of the Pleistocene (pre-Clovis circa 11,500 years ago). There is a growing body of evidence indicating that a "First Arrivals" archeological period (circa. 13,000 and 17,000 years ago) preceded the Paleo-Indian Period. A handful of sites in the Central Plains date between about 13,000 and 17,000 years ago, however, most of these sites have limited evidence of human occupation (Hofman, 1996). Acceptance of archeological remains older than the long accepted Clovis Culture remains controversial (Hofman, 1996), (Holen, 1994).

Paleo-Indian Period

The Clovis Culture (circa 11,500 years ago) is the earliest dated and accepted evidence of human habitation during the Paleo-Indian Period in the New World. The climate during the Paleo-Indian Period was much cooler and wetter than today. The eastern edge of the Central Plains was broad open grassland occupied by great herds of now extinct animals. Paleo-Indian populations were highly mobile and left little evidence of their activities. Most Paleo-Indian sites would have been short-term occupations (campsites). Paleo-Indian peoples subsisted on hunted game and gathered plant material. Distinctive point styles and variations in other tool types defined the Clovis, Folsom, Midland, and later Paleo-Indian groups (Hofman, 1996). To date, no early sites have been identified in Nemaha or Atchison counties, but such resources may exist as deeply buried deposits along relic terraces.

Archaic Period

During the Archaic Period, subsistence hunting and gathering underwent changes to adapt to resource availability. As glaciers retreated northward and larger animals disappeared from the region, humans adapted to modern plants and smaller game animals. The Dalton Culture (circa 8,500 to 7,500 years ago) is generally identified as the late Paleo-Indian or Early Archaic Period or as a transition between the two (O'Brien and Wood, 1995). The Archaic Period is subdivided into the following periods: Early Archaic Logan Creek Complex (circa 7,500 to 6,000 years ago), Middle Archaic Jacomo Complex (circa 5,500 to 5,000 years ago) and Late Archaic Nebo Hill Complex (circa 4,500 to 2,500 years ago). Early Archaic people did not appear to establish permanent settlements, though there is evidence that some locations were used

Affected Environment

frequently. Archaic people collected, hunted, and gathered most of what they needed for survival in their home territory with a wider range of tools.

Climatic conditions during the Archaic Period entered a warmer/dryer phase around 5,500 years ago. Late Archaic cultures began to settle in the Missouri River Valley about 3,000 years ago. Archaeological evidence indicates that larger, semi-permanent warm weather settlements were established along the higher terraces, while winter encampments were located in upland areas along small streams. Archaic sites identified in the CNS area typically consist of lithic scatters with various dart points identified as "Archaic."

Woodland Period

The Woodland Period (circa 2,500 to 1,000 years ago) is defined by the introduction of agriculture to augment subsistence hunting and gathering. The reliance on agriculture led to the establishment of permanent settlements during this period. Other characteristics of Woodland culture include increased population, emergence of social hierarchy, expanded interregional trade, elaborate ceremonialism with stone-lined graves and burial mounds, and the introduction of the bow and arrow.

During the middle Woodland Period (circa 2,000 to 1,500 years ago), indigenous groups began increasing in population. Woodland peoples spread along valleys over the entire eastern half of Nebraska, western part of Iowa, and parts of South Dakota and Kansas. These people were forager-gardeners living in small villages along the higher valley terraces. Several Middle Woodland sites have been identified in Nemaha and Atchison counties.

During the late Woodland Period (circa 1,500 to 1,100 years ago), larger middle Woodland villages were abandoned in favor of smaller camps and individual home sites, generally in the uplands away from the river bottoms. The number of burial mounds increased dramatically. Most of the mounds were small and low with distinctive rock structures. Many mounds have been lost to plowing, but rock structures around graves are commonly found on bottom terraces and points on both sides of the river.

Plains Village Period

Around 1,000 years ago, most groups had established permanent villages. The Plains Village peoples were farmers and bison hunters living in larger villages along the river terraces. Smaller hamlets, hunting camps, and kill sites have also been recorded in the uplands. This culture disappeared about 700 years ago for unknown reasons. Climatic conditions during this time were becoming warmer and dryer, and drought may have forced people out of traditional farming areas. Additionally, there was an influx of people coming onto the Plains from the northeast and west that may have made living in the region untenable.

2.2.9.3 *Historic Period*

Historic Tribes and Fur Traders

The 18th and 19th centuries brought the first wave of Europeans to the east Central Plains region. French, and later Spanish land claims inspired trade and exploration of the Missouri River Valley. French fur traders were known to visit the area. Indian populations were subsequently displaced.

Traffic along the Missouri River increased after the Louisiana Purchase in 1803. The Lewis and Clark expedition of 1804 paved the way for subsequent U.S. military expeditions and the

establishment of trading posts and missions. On July 13, 1804, the Lewis and Clark expedition passed the remains of a trading post said to have been where Benet of St. Louis traded with the Otoe and Pawnee for 2 years. Other American Indian groups that passed through the area included the Omaha, Osage, Delaware, Pottawatomie, Sauk and Fox, Winnebago, and Miami.

On July 15, 1804, the Lewis and Clark party camped along a rise on the west side of a bend in the river. There is some dispute about the actual location of the encampment. Nebraska researchers place the camp on the Missouri side of the present river channel and Missouri historians place the camp roughly where the CNS is located.

Historic accounts of the Lewis and Clark expedition describe a beautiful valley filled with grape vines and wild cherries, which first attracted settlers to the area in the 1840s (Plamondon, 2000). Settlement was gradual, but steadily spread along the eastern side of the river (National Historical Company, 1882). The Kansas-Nebraska Act of 1854 created the Nebraska Territory. Nemaha County was established a year later (Heritage, 2004). Settlement along the river increased in the 1850s with Brownville, Nebraska, being established as a major steamboat port and shipping point. The towns of Nemaha, Brownville, and Peru prospered along the bluffs above the Missouri River, and settlement of the interior away from the river remained low until the Nebraska Railway Company reached the area in 1874 (Heritage, 2004). An 1865 Government Land Office plat showed two farmsteads located on or near the area occupied by CNS. By 1911, there were nine homesteads and a school.

The arrival of railroads spurred the development of the interior areas away from the river at the expense of the towns located along the bluff tops. Brownville rapidly declined because of this. The building of the Brownville Bridge in 1939 connected the two sides of the river but did little to alleviate the town's economic downfall.

Construction of CNS began in 1968. Consumers Public Power District (CPPD) planned and financed the construction and became NPPD on January 1, 1970 (NPPD, 2008a).

2.2.10 Historic and Archaeological Resources at the Cooper Nuclear Station Site

No prehistoric or historic sites listed or eligible for listing on the NRHP or the State historic registers are located on the CNS site. Historic archaeological sites have been identified within a 6-mi radius of the site. A great deal of archaeological and historical research has been conducted within both Nemaha County, Nebraska, and Atchison County, Missouri. The bluffs along either side of the Missouri River and the higher terraces along the river valley bottom lands were favored habitation sites for prehistoric and historic people.

Only one previous historical survey has been conducted on the CNS property. This survey evaluated the eligibility of the William Dawson House located in the southwest corner of the CNS site near the bluff for listing on the NRHP. The William Dawson House (Site # NH00-69) was recorded in Nebraska historic archives but was not included on the NRHP. The Dawson House was torn down in 1970, shortly after it was recorded.

A formal survey of the entire CNS property has not been completed, however, a number of archaeological surveys have been conducted in the surrounding area. In the 1930s, A.T. Hill and Paul Cooper walked the bluffs along both sides of the river valley in search of Woodland mound sites. The Whitten Archeological Site, Archeological Survey No. 25NH4, was excavated along the bluffs north of the CNS site. Despite the fact that the mounds were reportedly leveled by cultivation, excavations succeeded in locating two concentrations of human remains along

Affected Environment

with grave goods and other artifacts (Hill and Cooper, 1937). The Nebraska State Historical Society Site Survey Form notes that, "... (two) skeletons were sent to U.S. National Museum in accordance with our WPA (Works Progress Administration) contract." The note is dated June 21, 1944. It is unclear from the archaeological site description if the Whitten site extended onto the CNS property.

In April 2007 and March 2008, NPPD contracted with Enercon Services, Inc. to conduct a Phase 1A Literature Review and Archeological Sensitivity Assessment for the CNS site. The 55 ac occupied by CNS were heavily disturbed. The Enercon study identified two probable prehistoric lithic scatters and three former historic home sites on the CNS site. The report also noted the potential for additional prehistoric and historic resources to be found throughout the area. Enercon also noted the potential for a camp site occupied by the Lewis and Clark Expedition in 1804 being located on the CNS property. The exact location of this campsite remains unknown.

2.3 RELATED FEDERAL AND STATE ACTIVITIES

The NRC staff reviewed the possibility that activities of other Federal agencies might impact the renewal of the operating license for CNS. Any such activity could result in cumulative environmental impacts and the possible need for a Federal agency to become a cooperating agency in the preparation of the CNS SEIS.

The NRC has determined that there are no Federal projects that would make it desirable for another Federal agency to become a cooperating agency in the preparation of the SEIS. Federal lands, facilities, national wildlife refuges, forests, and parks within 50 mi of CNS are listed below:

- Langdon Bend, 1 mi south-southeast (USACE)
- Derion Bend, 8 mi southeast (USACE)
- Nishnabotna, 9 mi north-northwest (USACE)
- Corning, 12 mi southeast (USACE)
- Kansas Bend, 12 mi north-northwest (USACE)
- Thurnau, 15 mi southeast (USACE)
- Lower Hamburg Bend, 15 mi north-northwest (USACE)
- Hamburg Bend, 17 mi north-northwest (USACE)
- Rush Bottom Bend, 22 mi southeast (USACE)
- Sac and Fox Reservation, 23 mi south-southeast (U.S. Department of the Interior, Bureau of Indian Affairs)
- Iowa Reservation, 26 mi south-southeast (U.S. Department of the Interior, Bureau of Indian Affairs)

- Squaw Creek National Wildlife Refuge, 28 mi southeast (USFWS)
- Copeland Bend, 29 mi north-northwest (USACE)
- Auldon Bar, 36 mi north-northwest (USACE)
- Noddleman Island, 39 mi north-northwest (USACE)
- Tobacco Island, 43 mi north-northwest (USACE)

The NRC is required under Section 102(2)(c) of the National Environmental Policy Act of 1969 (NEPA) to consult with and obtain the comments of any Federal agency that has jurisdiction by law or special expertise with respect to any environmental impact involved. Federal Agency consultation correspondence and comments on the SEIS are presented in Appendix E.

2.4 REFERENCES

10 CFR Part 20. *Code of Federal Regulations*, Title 10, *Energy*, Part 20, "Standards for Protection Against Radiation."

10 CFR Part 50. *Code of Federal Regulations*, Title 10, *Energy*, Part 50, "Domestic Licensing of Production and Utilization Facilities."

10 CFR Part 61. *Code of Federal Regulations*, Title 10, *Energy*, Part 61, "Licensing Requirements for Land Disposal of Radioactive Waste."

10 CFR Part 71. *Code of Federal Regulations*, Title 10, *Energy*, Part 71, "Packaging and Transportation of Radioactive Material."

40 CFR PART 190 *Code of Federal Regulations*, Title 40, *Protection of the Environment*, Part 190 Environmental Radiation Protection Requirements for Normal Operations of Activities in the Uranium Fuel Cycle, Final Environmental Statement.

40 C.F.R. PART 239. *Code of Federal Regulations*, Title 40, *Protection of the Environment*, Part 239, Requirements for State Permit Program Determination of Adequacy.

Abell, R., Olson, D., et al. (Abell et al.) 2000. *Freshwater Ecoregions of North America*, Island Press, Washington, D.C.

Abell, R., et al. 2008. "Freshwater Ecoregions of the World: A New Map of Biogeographic Units for Freshwater Biodiversity Conservation," *BioScience* 58(5), pp. 403–414.

Bailey, G. 2007. Personal communication with K. Shannon, Enercon Services, Nebraska Game and Park Commission, January 25, 2007, Lincoln, Nebraska, Agencywide Documents Access and Management System (ADAMS) Accession No. ML092400166.

Barbour, M.T., J. Gerritsen, B.D. Snyder, and J.B. Stribling (Barbour et al.). 1999. *Rapid Bioassessment Protocols for Use in Streams and Wadeable Rivers: Periphyton, Benthic Macroinvertebrates and Fish*, Second Edition, EPA 841-B-99-002, U.S. Environmental Protection Agency, Office of Water, Washington, D.C.

Benedict, R.A., P.W. Freeman, and H.H. Genoways. 1996. "Chapter 11: Prairie Legacies—Mammals," in F.B. Samson and F.L. Knopf (eds.), *Prairie Conservation: Preserving North America's Most Endangered Ecosystem*, Island Press, Washington, D.C, pp. 149–160.

Affected Environment

Black-footed Ferret Recovery Implementation Team. 2009. "Black-Footed Ferret Recovery Program, Ferret Facts," Available URL: <http://www.blackfootedferret.org/ferret-facts.htm> (accessed July 30, 2009).

Bureau of Business Research (BBR). 2008. "Nebraska Population Projections, 2005, 2010, 2015, 2020, 2025, and 2030," University of Nebraska-Lincoln, College of Business Administration. Available URL: <http://www.bbr.unl.edu/PopProjections/> (accessed April 17, 2009).

Carter, S.R., K.R. Bazata, and D.L. Anderson (Carter et al.). 1982. "Chapter 7: Macroinvertebrate communities of the channelized Missouri River near Two Nuclear Power Stations," in Hesse, L.W., G.L. Hergenrader, H.S. Lewis, S.D. Reetz, and A.B. Schlesinger (eds.), *The Middle Missouri River: A Collection of Papers on the Biology with Special Reference to Power Station Effects*, The Missouri River Group, Norfolk, Nebraska, pp. 146–182.

Conestoga Rover and Associates (CRA). 2007. "Hydrogeologic Investigation Work Plan," Ground Water Protection Initiative, Cooper Nuclear Station, Brownsville, Nebraska.

Cornell University. 2008. Insect Conservation Biology. "*Cicindela nevadica lincolniana*, Salt Creek Tiger Beetle." Available URL: <http://courses.cit.cornell.edu/icb344/abstracts/salt-creek-tiger-beetle.htm> (accessed March 9, 2009).

Daily, G.C., S. Alexander, P.R. Ehrlich, L. Goulder, J. Lubchenco, P.A. Matson, H.A. Mooney, S. Postel, S.H. Schneider, D. Tilman, and G.M. Woodwell (Daily et al.). 1997. "Ecosystem services: Benefits supplied to human societies by natural ecosystems," *Issues in Ecology* 2:1–16.

Defenders of Wildlife. 2009. "Black-Footed ferret (*Mustela nigripes*)." Available URL: http://www.defenders.org/wildlife_and_habitat/wildlife/black-footed_ferret.php (accessed March 9, 2009).

Dryer, M.P. and A.J. Sandvol. 1993. "Recovery plan for the pallid sturgeon, *Scaphirhynchus albus*," U.S. Fish and Wildlife Service, Bismarck, ND, 55 pp.

Environmental Protection Agency (EPA). 1974. "Information on Levels of Environmental Noise Requisite to Protect Public Health and Welfare with an Adequate Margin of Safety," Report 550/9-74-004, Washington, D.C., March 1974. Available URL: <http://www.nonoise.org/library/levels74/levels74.htm> (See also "EPA Identifies Noise Levels Affecting Health and Welfare," September 21, 2007. Available URL: <http://www.epa.gov/history/topics/noise/01.htm> (accessed March 2, 2009)).

Environmental Protection Agency (EPA). 2002. "Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms," Fourth Edition, EPA-821-R-02-013, Office of Water, Washington, D.C.

Environmental Protection Agency (EPA). 2009a. "Office of Solid Waste," Available URL: <http://www.epa.gov/osw/> (accessed May 2009).

Environmental Protection Agency (EPA). 2009b. "Safe Drinking Water Information System, County Search – January 29, 2009," Nemaha, Otoe, and Richardson Counties, Nebraska, and Atchison County, MO. Available URL: <http://www.epa.gov/safewater/dwinfo/index.html>. (accessed April 7, 2009).

Federal Register, Vol. 63, No. 109, pp. 31267–31317 (63 FR 31268). "Emergency Planning and Community Right-to-Know Programs; Amendments to Hazardous Chemical Reporting Thresholds, Streamlining Requirements," June 8, 1998.

- Farrell, J.R. and M.A. Tesar. 1982. "Chapter 5: Periphytic algae in the channelized Missouri River with special Emphasis on apparent optimal temperatures," in Hesse, L.W., G.L. Hergenrader, H.S. Lewis, S.D. Reetz, and A.B. Schlesinger (eds.), *The Middle Missouri River: A Collection of Papers on the Biology with Special Reference to Power Station Effects*, The Missouri River Group, Norfolk, Nebraska, pp. 84–123.
- Galat, D.L., C.R. Berry, Jr., E.J. Peters, and R.G. White (Galat et al.). 2005a. "Missouri River Basin," in A.C. Benke and C.E. Cushing (eds.), *Rivers of North America*, Elsevier Academic Press, New York, pp. 84–123.
- Galat, D.L., C.R. Berry, Jr., W.M. Gardner, J.C. Hendrickson, G.E. Mestl, G.J. Power, C. Stone, and M.R. Winston (Galat et al.). 2005b. "Spatiotemporal patterns and changes in Missouri River Fishes," *American Fisheries Society Symposium* 45:249–291.
- Gerrity, P.C. and C. Guy. 2006. "Juvenile pallid sturgeon are piscivorous: A call for conserving native cyprinids," *Transactions of the American Fisheries Society* 135:604–609.
- Great Plains Energy, Inc. 2009. LocationOne® Copyright 2001–2009, Nebraska City, Nebraska and Falls City, Nebraska. Available URL: <http://www.fallscityedge.com/links-library/> Community Quick Facts, IEDC Tables, Printable Brochure (accessed April 10, 2009).
- Heritage Research, Ltd. (Heritage). 2004. "Nemaha County: Nebraska Historic Building Survey," Heritage Research Ltd. Historical/Environmental Consultants, Menomonee Falls, WI, August 2004.
- Hergenrader, G.L., L.G. Harrow, R.G. King, G.F. Cada, and A.B. Schlesinger (Hergenrader et al.). 1982. "Chapter 8: Larval fishes in the Missouri River and the effects of entrainment," in Hesse, L.W., G.L. Hergenrader, H.S. Lewis, S.D. Reetz, and A.B. Schlesinger (eds.), *The Middle Missouri River: A Collection of Papers on the Biology with Special Reference to Power Station Effects*, The Missouri River Group, Norfolk, Nebraska, pp. 184–223.
- Hesse, L.W., G.L. Hergenrader, H.S. Lewis, S.D. Reetz, and A.B. Schlesinger (Hesse et al.). 1982. *The Middle Missouri River: A Collection of Papers on the Biology with Special Reference to Power Station Effects*, The Missouri River Group, Norfolk, Nebraska.
- Hill, A.T. and P. Cooper. 1937. "The Archaeological Campaign of 1937," *Nebraska History Magazine* 18(4):241–359.
- Hofman, J.L. 1996. "Early Hunter-Gatherers of the Central Great Plains: Paleoindian and Mesoindian (Archaic) Cultures," *Archeology and Paleoecology of the Central Great Plains*, Arkansas Archeological Survey Research Series No. 48.
- Holen, S.R. 1994. "Did Someone Eat the La Sena Mammoth? The Cellars of Time: Paleontology and Archaeology in Nebraska," *NEBRASKAland Magazine*, Vol. 72, No. 1, Nebraska Game and Parks Commission.
- Hrabik, R. A., D.P. Herzog, D.E. Ostendorf, and M.D. Petersen (Hrabik et al.). 2007. "Larvae provide first evidence of successful reproduction by pallid sturgeon, *Scaphirhynchus albus*, in the Mississippi River," *Journal of Applied Ichthyology* 23(4):436–443.
- Hurleya, K.L., R.J. Sheehan, R.C. Heidinger, P.S. Wills, and B. Clevensine (Hurleya et al.). 2004. "Habitat Use by Middle Mississippi River Pallid Sturgeon," *Transactions of the American Fisheries Society* 133:1033–1041.
- Illinois Wildflowers. 2009. Available URL: <http://www.illinoiswildflowers.info/index.htm> (accessed May 11, 2009).

Affected Environment

Kansas Wildflowers and Grasses. 2009. Available URL: <http://www.kswildflower.org/index.php> (accessed May 11, 2009).

Karr, J.R., L.A. Toth, and D.R. Dudley (Karr et al.). 1985. "Fish Communities of Midwestern Rivers: A History of Degradation," *BioScience* 15(2):90–95.

Kynard, B., E. Henyey, and M. Horgan (Kynard et al.). 2002. "Ontogenetic behavior, migration, and social behavior of pallid sturgeon, *Scaphirhynchus albus*, and shovelnose sturgeon, *S. platyrhynchus*, with notes on the adaptive significance of body color," *Environmental Biology of Fishes* 63:389–403.

Missouri Department of Natural Resources (MDNR). 2008. "Census of Missouri Public Water Systems 2008," Division of Environmental Quality. Water Protection Program, Public Drinking Water Branch, January 24, 2008. Available URL: <http://www.dnr.mo.gov/pubs/pub2250.pdf> (accessed April 7, 2009).

Missouri Plants. 2007. "Photographs and descriptions of the flowering and non-flowering plants of Missouri, USA," February 2007. Available URL: <http://www.missouriplants.com/> (accessed April 21, 2009).

Missouri State Demographer. Undated. "Missouri Population Projections by County, Age, and Sex: 2000 to 2030." Available URL: <http://oa.mo.gov/bp/projections/totalpop.html> (accessed April 17, 2009).

Missouri Botanical Garden (MOBOT). 2009. "Plant Finder." Available URL: <http://www.mobot.org/gardeninghelp/plantfinder/Alpha.asp> (accessed May 6, 2009).

Missouri Department of Conservation (MDC). 2009a. "Endangered Species Guidesheet, Indiana bat - *Myotis sodalis*." Available URL: <http://mdc.mo.gov/nathis/endangered/endanger/bat/> (accessed March 4, 2009).

Missouri Department of Conservation (MDC). 2009b. "MDC Heritage Database Results for Atchison County." Available URL: <http://mdc.mo.gov/cgi-bin/heritage/search.cgi?county=Atchison> (accessed April 21, 2009).

Missouri Department of Conservation (MDC). 2009c. "Missouri Species and Communities of Conservation Concern, Checklist," January 2009.

Minnesota Department of Natural Resources (MNDNR). 1991. "Western Prairie Fringed Orchid: A Threatened Midwestern Prairie Plant." Available URL: http://files.dnr.state.mn.us/natural_resources/ets/fringed_orchid.pdf?bcsi_scan_B6C3A1920618BACA=0&bcsi_scan_filename=fringed_orchid.pdf (accessed March 4, 2009).

Michigan State University (MSU). 2007. "Rare Species Explorer, *Carex crus-corvi*, Raven's foot sedge," Michigan Natural Features Inventory. Available URL: <http://web4.msue.msu.edu/mnfi/explorer/species.cfm?id=15154> (accessed May 11, 2009).

National Academies of Sciences (NAS). 2002. *The Missouri River Ecosystem*, National Research Council, National Academies Press, Washington, D.C.

National Climatic Data Center (NCDC). 2009a. "Wind - Average Wind Speed - (MPH)." Available URL: <http://wf.ncdc.noaa.gov/oa/climate/online/ccd/avgwind.html> (accessed May, 2009).

National Climatic Data Center (NCDC). 2009b. "Query results: Tornado occurrences in Nemaha County, Nebraska, 1950–2009," ADAMS Accession No. ML091750118.

National Historical Company. 1882. "History of Holt and Atchison Counties, Missouri," National Historical Company, St. Joseph, MO.

National Park Service (NPS). 2009. "National Register of Historic Places Information System, Nemaha County, Nebraska." Available URL: www.nr.nps.gov (accessed July 28, 2009).

National Research Council, Committee on Missouri River Ecosystem Science. 2002. *The Missouri River Ecosystem: Exploring the Prospects for Recovery*, National Academy Press, Washington, D.C., 188 pp. [Note: on CD from Cooper]

Natural Resource Conservation Service (NRCS). 2007. "List of common plants found along the Missouri River in Atchison County, MO."

Natural Resource Conservation Service (NRCS). 2009. "Plants Database, Plants Profile." Available URL: <http://plants.usda.gov/index.html> (accessed May 6, 2009).

NatureServe. 2008a. "*Grus americana*, Whooping Crane," NatureServe Explorer, Version 7.1. Available URL: <http://www.natureserve.org/explorer/servlet/NatureServe?searchSciOrCommonName=whooping+crane> (accessed March 9, 2009).

NatureServe. 2008b. "*Cicindela nevadica lincolniana*, Salt Creek Tiger Beetle," NatureServe Explorer, Version 7.1. Available URL: <http://www.natureserve.org/explorer/servlet/NatureServe?searchSciOrCommonName=salt+creek+tiger+beetle> (accessed March 9, 2009).

NatureServe. 2009a. "*Charadrius melodus*, Piping Plover," NatureServe Explorer, Version 7.1. Available URL: <http://www.natureserve.org/explorer/servlet/NatureServe?searchSciOrCommonName=piping+lover&x=8&y=10> (accessed March 3, 2009).

NatureServe. 2009b. "*Sternula antillarum*, Least Tern," NatureServe Explorer, Version 7.1. Available URL: <http://www.natureserve.org/explorer/servlet/NatureServe?searchName=Sterna+antillarum> (accessed March 3, 2009).

NatureServe. 2009c. "*Mustela nigripes*, Black-footed Ferret," NatureServe Explorer, Version 7.1. Available URL: <http://www.natureserve.org/explorer/servlet/NatureServe?searchSciOrCommonName=black+footed+ferret> (accessed March 9, 2009).

NatureServe. 2009d. "Plant/Animal Records for Atchison County, Missouri," NatureServe Explorer, Version 7.1. Available URL: <http://www.natureserve.org/explorer/servlet/NatureServe> (accessed March 9, 2009).

NatureServe. 2009e. "Plant/Animal Records for Nebraska Counties," NatureServe Explorer, Version 7.1. Available URL: <http://www.natureserve.org/explorer/servlet/NatureServe> (accessed March 9, 2009).

Nebraska Administrative Code (NAC), Title 128, "Nebraska Hazardous Waste Regulations," December 5, 2004.

Nebraska Department of Agriculture (NDA). 2008. Press Release: "NDA Adds Phragmites to Noxious Weed List Under Temporary Order," April 15, 2008. Available URL: <http://www.agr.state.ne.us/newsrel/april2008/phragmites.htm> (accessed March 9, 2009).

Nebraska Department of Economic Development (NDED) and Nebraska Public Power District (NPPD). 2008. "Nebraska Community 'Fast Facts' Profile, Auburn, Nebraska." Available URL: <http://sites.nppd.com/aedc/fastfacts.asp?city=Auburn> (accessed April 10, 2009).

Affected Environment

Nebraska Department of Education (NDE). 2009. "Data and Information, 2008–2009 County Membership by Grade," March 6, 2009. Available URL: http://www.education.ne.gov/DataServices/Data_and_Information.htm (accessed April 15, 2009).

Nebraska Department of Environmental Quality (NDEQ). 2000. Permit No. NE0208256 for Class V Underground Injection Wells.

Nebraska Department of Environmental Quality (NDEQ). 2004. 2004 "Nebraska Surface Water Quality Integrated Report," Lincoln, Nebraska, March 2004.

Nebraska Department of Environmental Quality (NDEQ). 2008. "Annual Air Quality Report Nebraska Air Quality 2007," Nebraska Department of Environmental Quality, Air Quality Division, ADAMS Accession No. ML091750103.

Nebraska Department of Environmental Quality (NDEQ). 2009. "2009 Ambient Air Monitoring Network Plan," ADAMS Accession No. ML091750088.

Nebraska Health and Human Services System (NHHSS). 2000. Permit No. NE3150505 for Non-Community Public Water Supply System.

Nebraska Department of Natural Resources (NDNR). 2008. Registered Ground Water Wells Data Retrieval. Available URL <http://www.dnr.state.ne.us/dnrnews/news2009/April2009.pdf> (accessed February 13, 2009).

Nebraska Department of Natural Resources (NDNR) 2009. Statewide aerial maps. Available URL: <http://dnrmap2.dnr.state.ne.us/website/doqviewer/viewer.htm> (accessed April 16, 2009).

Nebraska Department of Roads (NDOR). 2007. "Traffic Volume Maps & Info." Available URL: <http://www.nebraskatransportation.org/maps/#traffvol> (accessed April 14, 2009).

Nebraska Legislature. 2008. "Nebraska State Constitution Article VIII-11." Available URL: <http://uniweb.legislature.ne.gov/laws/articles.php?article=VIII-11> (accessed April 16, 2009).

Nebraska Public Power District (NPPD). 1971. "Applicant's Environmental Report, Operating License Stage, Cooper Nuclear Station."

Nebraska Public Power District (NPPD). 2004. "Cooper Nuclear Station, Annual Radioactive Effluent Release Report for 2003," Brownville, Nebraska, ADAMS Accession No. ML041190422.

Nebraska Public Power District (NPPD). 2005. "Cooper Nuclear Station, Annual Radioactive Effluent Release Report for 2004," Brownville, Nebraska, ADAMS Accession No. ML051220511.

Nebraska Public Power District (NPPD). 2006a. "Cooper Nuclear Station, Annual Radioactive Effluent Release Report for 2005," Brownville, Nebraska, ADAMS Accession No. ML061240548.

Nebraska Public Power District (NPPD). 2006b. "Nebraska Public Power District Power Line Rights-of-way Vegetation Management Program."

Nebraska Public Power District (NPPD). 2006c. "Proposal for Information Collection, Cooper Nuclear Station," January 2006, ADAMS Accession No. ML092510103

Nebraska Public Power District (NPPD). 2007a. "Cooper Nuclear Station, Annual Radioactive Effluent Release Report for 2006," Brownville, Nebraska, ADAMS Accession No. ML071240393.

Nebraska Public Power District (NPPD). 2007b. "Chapter 3: Land Disturbing Activities," *Corporate Environmental Manual*, December 2007.

Nebraska Public Power District (NPPD). 2007c. "2006 Financial Report." Available URL: http://www.nppd.com/newsroom/annual_report_2006/06financials.pdf (accessed April 16, 2009).

Nebraska Public Power District (NPPD). 2008a. "License Renewal Application, Cooper Nuclear Station, Appendix E – Applicant's Environmental Report, Operating License Renewal Stage," ADAMS Accession No. ML083030246.

Nebraska Public Power District (NPPD). 2008b. "Cooper Nuclear Station, Annual Radioactive Effluent Release Report for 2007," Brownville, Nebraska, ADAMS Accession No. ML081300029.

Nebraska Public Power District (NPPD). 2008c. "2007 Financial Report." Available URL: http://www.nppd.com/newsroom/annual_report_2007/07financials.pdf (accessed April 16, 2009).

Nebraska Public Power District (NPPD). 2009a. "Cooper Nuclear Station, Annual Radioactive Effluent Release Report for 2008," Brownville, Nebraska, ADAMS Accession No. ML091340455.

Nebraska Public Power District (NPPD). 2009b. "About Us." Available URL: <http://www.nppd.com/About%5FU.s/> (accessed April 14, 2009).

Nebraska Public Power District (NPPD). 2009c. Response to Request for Additional Information for License Renewal Application Environmental Report Cooper Nuclear Station, Docket No. 50-298, DPR-46, Attachment 1: "Low Emitter Status for NPPD's Cooper Nuclear Station, NDEQ Facility ID #36750," March 27, 2009, ADAMS Accession No. ML091600712[A1].

Nebraska Public Power District (NPPD). 2010. "Cooper Nuclear Station, Annual Radioactive Effluent Release Report for 2009," Brownville, Nebraska, ADAMS Accession No. ML101270278.

Nebraska Game and Parks Commission (NGPC). 2008. "Estimated Current Ranges of Threatened and Endangered Species: List of Species by County," Nebraska Natural Heritage Program. Available URL: <http://www.ngpc.state.ne.us/wildlife/programs/nongame/TandESpecies.pdf> (accessed April 21, 2009).

Nebraska Game and Parks Commission (NGPC). 2009a. "Spring Migration Guide, About Whooping Cranes." Available URL: <http://www.ngpc.state.ne.us/wildlife/guides/migration/whooping.asp> (accessed March 9, 2009).

Nebraska Game and Parks Commission (NGPC). 2009b. "Wildlife Species Guide, Least Tern - An endangered species." Available URL: <http://www.ngpc.state.ne.us/wildlife/ltern.asp> (accessed March 3, 2009).

Nebraska Game and Parks Commission (NGPC). 2009c. "Species-by-County List for Selected Nebraska Counties," May 8, 2009, ADAMS Accession No. ML092110589.

New York State Department of Environmental Conservation (NYSDEC). 2009. "Indiana Bat, *Myotis sodalis*." Available URL: <http://www.dec.ny.gov/animals/6972.html> (accessed March 4, 2009).

Affected Environment

Ohio Department of Natural Resources (ODNR). 1998. "Carex bushii Mackenzie, Bush's Sedge," March 1998. Available URL:

http://www.dnr.state.oh.us/Portals/3/Abstracts/Abstract_pdf/C/Carex_bushii.pdf (accessed May 11, 2009).

O'Brien, M.J. and R. Wood. 1995. "The Prehistoric Archeological Record. Holocene Human Adaptations in the Missouri Prairie – Timberlands," *Arkansas Archeological Survey Research Series No. 45*.

Plamondon II, M. 2000. *Lewis and Clark Trail Maps: A Cartographic Reconstruction, Vol. 1*, Washington State University Press.

Rabeni, C.F. 1996. "Chapter 8: Prairie Legacies – Fish and Aquatic Resources," in F.B. Samson and F.L. Knopf (eds.), *Prairie Conservation: Preserving North America's Most Endangered Ecosystem*, Island Press, Washington, D.C., pp. 111–124.

Reetz, S.D. 1982. "Chapter 4: Phytoplankton studies in the Missouri River at Fort Calhoun Station and Cooper Nuclear Station," in Hesse, L.W., G.L. Hergenrader, H.S. Lewis, S.D. Reetz, and A.B. Schlesinger (eds.), *The Middle Missouri River: A Collection of Papers on the Biology with Special Reference to Power Station Effects*, The Missouri River Group, Norfolk, Nebraska, pp. 71–83.

Repsys, A.J. and G.D. Rogers. 1982. "Chapter 6: Zooplankton studies in the channelized Missouri River," in Hesse, L.W., G.L. Hergenrader, H.S. Lewis, S.D. Reetz, and A.B. Schlesinger (eds.), *The Middle Missouri River: A Collection of Papers on the Biology with Special Reference to Power Station Effects*, The Missouri River Group, Norfolk, Nebraska, pp. 124–145.

Stehn, T. 2009. "Tom Stehn's Whooping Crane Report," Update: April 20, 2009, from the USFWS Whooping Crane Census Flight. Available URL: http://www.birdrockport.com/tom_stehn_whooping_crane_report.htm (accessed April 20, 2009).

University of Nebraska-Lincoln (UNL). 2009. "Lincoln, Nebraska, 1971–2000, Monthly and Annual Normals." Available URL: <http://www.lincolnweather.org/Lincoln-Monthly-Normals.html> (accessed June, 2009).

University of Nebraska State Museum-Division of Zoology (UNSM). 2007a. "Birds of Nemaha County," database report, T.E. Labeledz.

University of Nebraska State Museum-Division of Zoology (UNSM). 2007b. "Reptiles and Amphibians of Nemaha County," database report, T.E. Labeledz.

U.S. Army Corps of Engineers (USACE). 2002. Permit No. NE01-10322 for Maintenance Dredging of the CNS Water Intake Structure.

U.S. Army Corps of Engineers (USACE). 2004a. "Missouri River Master Water Control Manual," Final Environmental Impact Statement Review and Update, Northwestern Division, Omaha, Nebraska, March 2004.

U.S. Army Corps of Engineers (USACE). 2004b. "Missouri River Mitigation Project," July 2004. Available URL: http://www.nwk.usace.army.mil/projects/mitigation/sites/hamburg_area/lanben.htm (accessed April 15, 2004).

U.S. Army Corps of Engineers (USACE). 2007. "Missouri River Mitigation Project." Available URL: <http://www.nwk.usace.army.mil/projects/mitigation/>

U.S. Department of Agriculture (USDA). 2009. "2007 Census of Agriculture," for Iowa, Kansas, Missouri, Nebraska, February 4, 2009. Available URL: http://www.agcensus.usda.gov/Publications/2007/Online_Highlights/County_Profiles/index.asp. (accessed April 17, 2009).

U.S. Census Bureau (USCB). 2009. "State and County QuickFacts" for Nemaha County, Otoe County, and Richardson County, Nebraska, and Atchison County, MO. Available URL: <http://quickfacts.census.gov> (accessed March 25, 2009).

U.S. Fish and Wildlife Service (USFWS). 1978. 50 CFR Part 17. "Endangered and Threatened Wildlife and Plants, Determination of Critical habitat for the Whooping Crane," Vol. 43, pp. 20938–20942.

U.S. Fish and Wildlife Service (USFWS). 1997. "Piping plover (*Charadrius melodus*), An example of U.S./Canada Cooperation in the protection and recovery of endangered species." Available URL: <http://www.fws.gov/endangered/canada/plover.htm> (accessed March 3, 2009).

U.S. Fish and Wildlife Service (USFWS). 2000a. "Black-footed Ferret (*Mustela nigripes*)." Available URL: <http://www.fws.gov/mountain-prairie/species/mammals/blackfootedferret/revfact.chy.pdf> (accessed March 9, 2009).

U.S. Fish and Wildlife Service (USFWS). 2000b. "Missouri River Final Biological Opinion," November 2000. Available URL: <http://www.nwd-mr.usace.army.mil/mmanual/opinion.html> (accessed June 16, 2009).

U.S. Fish and Wildlife Service (USFWS). 2002. 50 CFR Part 17, "Endangered and Threatened Wildlife and Plants; Designation of Critical Habitat for the Northern Great Plains Breeding Population of the Piping Plover," Final Rule, Vol. 67, pp. 57637–57717.

U.S. Fish and Wildlife Service (USFWS). 2003b. "U.S. Fish and Wildlife Service 2003 Amendment to Biological Opinion on the Operation of the Missouri River Main Stem Reservoir System, Operation and Maintenance of the Missouri River Bank Stabilization and Navigation Project, and Operation of the Kansas River Reservoir System," December 16, 2003. Available URL: <http://www.nwd-mr.usace.army.mil/mmanual/FinalBO2003.pdf> (accessed June 17, 2009).

U.S. Fish and Wildlife Service (USFWS). 2005. News Release October 6, 2005, "Service Lists Salt Creek Tiger Beetle as Endangered." Available URL: <http://www.fws.gov/mountain-prairie/PRESSREL/05-72.htm> (accessed March 4, 2009).

U.S. Fish and Wildlife Service (USFWS). 2007a. "Pallid Sturgeon, *Scaphirhynchus albus*," Available URL: <http://www.fws.gov/moriver/PSPROFILE.htm> (accessed March 16, 2007).

U.S. Fish and Wildlife Service (USFWS). 2007b. "National Wetlands Inventory, Wetlands Mapper." Available URL: <http://www.fws.gov/wetlands/data/Mapper.html> (accessed April 17, 2009).

U.S. Fish and Wildlife Service (USFWS). 2008a. "Endangered Species, Missouri, County Distribution of Federally-Listed, Threatened, Endangered, Proposed, and Candidate Species," Columbia, MO, November 2008. Available URL: <http://www.fws.gov/midwest/endangered/lists/missouri-cty.html> (accessed April 17, 2009).

Affected Environment

U.S. Fish and Wildlife Service (USFWS). 2008b. "Least Tern (*Sterna antillarum*)," North Dakota Field Office, Mountain-Prairie Region, December 2008. Available URL: http://www.fws.gov/northdakotafielddoffice/endspecies/species/least_tern.htm (accessed February 26, 2009).

U.S. Fish and Wildlife Service (USFWS). 2009a. "National Wetlands Inventory, Nemaha Quad." Available URL: <http://www.fws.gov/wetlands/data/> (accessed April 15, 2009).

U.S. Fish and Wildlife Service (USFWS). 2009b. "Endangered, Threatened, Proposed, and Candidate Species in Nebraska Counties," Ecological Services, Nebraska Field Office. Available URL: <http://www.fws.gov/mountain-prairie/endspp/countylists/nebraska.pdf> (accessed April 17, 2009).

U.S. Fish and Wildlife Service (USFWS). 2009c. Personal e-mail from Robert Harms, Fish and Wildlife Biologist, Grand Island Field Office, to R. Bulavinetz, Aquatic Ecologist, Division of License Renewal, U.S. Nuclear Regulatory Commission, Subject: "Cooper Nuclear Plant," March 16, 2009, ADAMS Accession No. ML092110590.

U.S. Fish and Wildlife Service (USFWS). 2009d. "Whooping crane (*Grus americana*)." Available URL: <http://ecos.fws.gov/speciesProfile/SpeciesReport.do?sppcode=B003> (accessed March 9, 2009).

U.S. Fish and Wildlife Service (USFWS). 2009e. "Endangered Species, Salt Creek tiger beetle," February 2009. Available URL: <http://www.fws.gov/mountain-prairie/species/invertebrates/saltcreektiger/> (accessed March 9, 2009).

U.S. Fish and Wildlife Service (USFWS). 2009f. "Designation of Critical Habitat for the Salt Creek tiger beetle (*Cicindela nevadica lincolniiana*)," *Federal Register* Vol. 72, No. 238, pp. 70715–70758.

U.S. Fish and Wildlife Service (USFWS). 2009g. Species Profile, Black-footed ferret (*Mustela nigripes*). Available URL: <http://ecos.fws.gov/speciesProfile/SpeciesReport.do?sppcode=A004> (accessed March 9, 2009).

U.S. Fish and Wildlife Service (USFWS). 2009h. "Rainwater Basin Wetland Management District." Available URL: <http://www.fws.gov/Refuges/profiles/index.cfm?id=64530> (accessed April 29, 2009).

U.S. Fish and Wildlife Service (USFWS). 2009i. Letter from June M. DeWeese, Nebraska Field Supervisor, U.S. Fish and Wildlife Service, Grand Island, to Joe L. Citta, Jr., Corporate Environmental Manager, Nebraska Public Power District, Subject: "Cooper Nuclear Station," June 8, 2009, ADAMS Accession No. ML091830055.

U.S. Geological Survey (USGS). 1997. "Ground Water Atlas of the United States, Kansas, Missouri, and Nebraska, HA 730-D." Available URL: http://pubs.usgs.gov/ha/ha730/ch_d/index.html

U.S. Geological Survey (USGS). 2001. "Ecoregions of Kansas and Nebraska" (color poster with map, descriptive text, summary tables, and photographs). Available URL: http://www.epa.gov/wed/pages/ecoregions/ksne_eco.htm (accessed April 29, 2009).

U.S. Geological Survey (USGS). 2006. "Native Wildflowers of the North Dakota Grasslands," Northern Prairie Wildlife Research Center, August 2006. Available URL: <http://www.npwrc.usgs.gov/resource/plants/wildflwr/> (accessed May 6, 2009).

U.S. Geological Survey (USGS). 2007. "Sturgeon Research Update: Confirmed Pallid Sturgeon Spawning in the Missouri River in 2007," USGS Fact Sheet 2007–3053, July 2007.

- U.S. Geological Survey (USGS). 2008. Search USGS. September 2008. Available URL: <http://search.usgs.gov/> (accessed March 9, 2009).
- U.S. Nuclear Regulatory Commission (NRC). 2003. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants Supplement 12 Regarding Fort Calhoun Station*, NUREG-1437, Supplement 12, ADAMS Accession No. ML032230075.
- Utah State University (USU) 2006. "Fact Sheet, *Carex frankii* Kunth." Available URL: http://utc.usu.edu/factsheets/CarexFSF/Carex_frankii.htm (accessed May 11, 2009).
- University of Texas (UT). 2009. "Native Plant Database," Lady Bird Johnson Wildflower Center, February 2009. Available URL: http://www.wildflower.org/plants/result.php?id_plant=PAGL17 (accessed May 11, 2009).
- University of Wisconsin (UW). 2009. "Robert W. Freckmann Herbarium." Available URL: <http://wisplants.uwsp.edu/scripts/searchphotographer.asp?photographer=Robert%20R.%20Kowal> (accessed April 21, 2009).
- University of Wyoming (UWYO). 2002. "State Species Abstract, Wyoming Natural Diversity Database, *Dalea enneandra*, Nine-Anther Prairie-Clover Fabaceae," January 2002. Available URL: http://www.uwyo.edu/wynddsupport/docs/Reports/SpeciesAbstracts/Dalea_enneandra.pdf (accessed May 6, 2009).
- Wildhaber, M.L., A.J. DeLonay, D.M. Papoulias, D.L. Galat, R.B. Jacobson, D.G. Simpkins, P.J. Braaten, C.E. Korschgen, and M.J. Mac. 2007. "A conceptual life-history model for pallid and shovelnose sturgeon," *U.S. Geological Survey Circular 1315*, U.S. Geological Survey, Reston, VA, 18 pp.
- Wishart, D.J., ed. 2004. *Encyclopedia of the Great Plains*, University of Nebraska Press

3.0 ENVIRONMENTAL IMPACTS OF REFURBISHMENT

Environmental issues associated with refurbishment activities are discussed in the, *Generic Environmental Impact Statement for License Renewal of Nuclear Plants (GEIS)*, NUREG-1437, Volumes 1 and 2 (NRC, 1996). The GEIS includes a determination of whether or not the analysis of the environmental issues can be applied to all plants and whether or not additional mitigation measures are warranted. Issues are then assigned a Category 1 or a Category 2 designation. As set forth in the GEIS, Category 1 issues are those that meet all of the following criteria:

- (1) The environmental impacts associated with the issue have been determined to apply to all plants, or for some issues, apply only to plants having a specific type of cooling system or other specified plant or site characteristics.
- (2) A single significance level (SMALL, MODERATE, or LARGE) has been assigned to the impacts (except for collective offsite radiological impacts from the fuel cycle and from high-level waste and spent fuel disposal).
- (3) Mitigation of adverse impacts associated with the issue has been considered in the analysis. It has been determined that additional plant-specific mitigation measures are likely not to be sufficiently beneficial to warrant implementation.

For issues that meet the three Category 1 criteria, no additional plant-specific analysis is required in this supplemental environmental impact statement (SEIS) unless new and significant information is identified.

Category 2 issues are those that do not meet one or more of the criteria for Category 1, therefore, an additional plant-specific review of these issues is required.

License renewal actions include refurbishment for the extended plant life. These actions may have an impact on the environment that requires evaluation, depending on the type of action and the plant-specific design. Environmental issues associated with refurbishment, which were determined to be Category 1 issues, are listed in Table 3-1.

Environmental Impacts of Refurbishment

Table 3-1. Category 1 Issues for Refurbishment Evaluation

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Section
Surface Water Quality, Hydrology, and Use (for all plants)	
Impacts of refurbishment on surface water quality	3.4.1
Impacts of refurbishment on surface water use	3.4.1
Aquatic Ecology (for all plants)	
Refurbishment	3.5
Ground Water Use and Quality	
Impacts of refurbishment on ground water use and quality	3.4.2
Land Use	
Onsite land use	3.2
Human Health	
Radiation exposures to the public during refurbishment	3.8.1
Occupational radiation exposures during refurbishment	3.8.2
Socioeconomics	
Public services: public safety, social services, and tourism and recreation	3.7.4; 3.7.4.3; 3.7.4.4; 3.7.4.6
Aesthetic impacts (refurbishment)	3.7.8

Environmental issues related to refurbishment considered in the GEIS that are inconclusive for all plants, or for specific classes of plants, are Category 2 issues. These are listed in Table 3-2.

Table 3-2. Category 2 Issues for Refurbishment Evaluation

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Section	10 CFR 51.53 (c)(3)(ii) Subparagraph
Terrestrial Resources		
Refurbishment impacts	3.6	E
Threatened or Endangered Species (for all plants)		
Threatened or endangered species	3.9	E
Air Quality		
Air quality during refurbishment (nonattainment and maintenance areas)	3.3	F
Socioeconomics		
Housing impacts	3.7.2	I
Public services: public utilities	3.7.4.5	I
Public services: education (refurbishment)	3.7.4.1	I
Offsite land use (refurbishment)	3.7.5	I
Public services, transportation	3.7.4.2	J
Historic and archaeological resources	3.7.7	K
Environmental Justice		
Environmental justice ^(a)	Not addressed	Not addressed

(a) Guidance related to environmental justice was not in place at the time the U.S. Nuclear Regulatory Commission (NRC) prepared the GEIS and the associated revision to 10 CFR Part 51. If an applicant plans to undertake refurbishment activities for license renewal, the applicant's environmental report (ER) and the NRC staff's environmental impact statement must address environmental justice.

The potential environmental effects of refurbishment actions are identified, and the analysis will be summarized within this section, if such actions are planned. Nebraska Public Power District (NPPD) indicated that it has performed an evaluation of systems, structures, and components pursuant to Section 54.21 of Title 10 of the *Code of Federal Regulations* (10 CFR 54.21) to identify the need to undertake any major refurbishment activities that are necessary to support continued operation of CNS during the requested 20-year period of extended operation. Items that are subject to aging and might require refurbishment to support continued operation during the renewal period are listed in Table B.2 of the GEIS.

The results of the evaluation of systems, structures, and components for CNS, as required by 10 CFR 54.21, do not identify the need to undertake any major refurbishment or replacement actions associated with license renewal to support the continued operation of CNS beyond the end of the existing operating license.

3.1 REFERENCES

10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions."

10 CFR Part 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, "Requirements for Renewal of Operating Licenses for Nuclear Power Plants."

U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*, NUREG-1437, Volumes 1 and 2, Washington, D.C., Agencywide Documents Access and Management System (ADAMS) Accession Nos. ML040690705 and ML040690738

4.0 ENVIRONMENTAL IMPACTS OF OPERATION

This chapter addresses potential environmental impacts related to the period of extended operation of Cooper Nuclear Station (CNS). These impacts are grouped and presented according to resource. Generic issues (Category 1) rely on the analysis provided in the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437 (May 1996), prepared by the U.S. Nuclear Regulatory Commission (NRC, 1996) and are discussed briefly. The NRC staff analyzed site-specific issues (Category 2) for CNS and assigned them a significance level of SMALL, MODERATE, LARGE or not applicable to CNS because of site characteristics or plant features. Section 1.4 of this report explains the criteria for Category 1 and Category 2 issues and defines the impact designations of SMALL, MODERATE, and LARGE.

4.1 LAND USE

Section 2.2.1 of this report describes the land use around CNS.

Table 4-1, "Land Use Issues," lists Category 1 issues (from Title 10 of the *Code of Federal Regulations* (CFR) Part 51, Subpart A, Appendix B, Table B-1), which are applicable to onsite land use and power line right-of-way impacts during the renewal term. As stated in the GEIS, the impacts associated with the Category 1 issues were determined to be SMALL, and site-specific mitigation measures would not be sufficiently beneficial to be warranted.

The NRC staff reviewed and evaluated the CNS environmental report (ER), scoping comments, other available information, and visited CNS in search of new and significant information that would change the conclusions presented in the GEIS. No new and significant information was identified during this review and evaluation. The staff did not identify any Category 2 issues for land use. Therefore, it is expected that there would be no impacts related to the Category 1 issues during the renewal term beyond those discussed in the GEIS.

Table 4-1. Land Use Issues

Issues	GEIS Section	Category
Onsite land use	4.5.3	1
Power line right-of-way	4.5.3	1

4.2 AIR QUALITY

Section 2.2.2 of this report describes air quality in the vicinity of CNS. One Category 1 air quality issue is applicable to CNS: air quality impacts of transmission lines. No Category 2 issues have been identified for air quality. The NRC staff did not identify any new and significant information during the review of NPPD's ER, the site audit, or during the scoping process. No major facility construction or refurbishments are planned to occur during the license renewal period. Therefore, there are no impacts related to this issue beyond those discussed in the GEIS. For these issues, the GEIS concluded that the impacts are SMALL and site-specific mitigation measures are not warranted.

4.3 GROUND WATER

4.3.1 Generic Ground Water Issues

Section 2.2.3 of this report discusses ground water use and quality at CNS. The staff did not identify any new and significant information in regard to Category 1 or generic ground water issues during the review of the NPPD's ER, the site visit, or the scoping process. Therefore, no impacts are related to these issues beyond those discussed in the GEIS. For these issues, the NRC staff in the GEIS concludes that the impacts are SMALL and additional site-specific mitigation measures are not warranted.

4.3.2 Ground Water Use Conflicts

The Category 2 ground water issue applicable to CNS is ground water use conflicts (potable and service water, plants using greater than 100 gallons per minute (gpm)). CNS has two potable water supply wells completed in the alluvial aquifer that have a combined pumping capacity of 250 gpm. Normal operations require only one well to be pumped at a time, supplying 125 gpm. The water is chlorinated, distributed onsite, and operated with preventive maintenance and cross connection or backflow prevention programs. The two drinking water wells are scheduled to be replaced with two similar new wells in the near future (NPPD, 2008a).

A third alluvial aquifer well at CNS is used for fire protection training and has a capacity of 750 gpm. Two additional wells, River Wells A and B, are used to supply water for facility pump seals. These wells each have a capacity of 150 gpm (NPPD, 2008a).

If all five existing production wells on site pumped at maximum capacity, the total pumping rate would be 1,300 gpm, compared to the 636,000 gpm of total water usage. This scenario does not occur, but represents the maximum impact possible on the alluvial aquifer. The aquifer is in hydraulic contact with the Missouri River and most ground water pumped is induced from surface water. The amount of ground water used is insignificant when compared to surface water use. Ground water not consumed is discharged to the Missouri River or is spread on nearby fields.

The National Pollutant Discharge Elimination System (NPDES) permit only provides one outfall (#001) with a chlorine limit. CNS does not chlorinate/brominate any water used except for the potable water supply system (250 gpm). Chlorine residuals from a potable system are insignificant compared to flow in the river.

As part of a hydrogeologic investigation for the study of radionuclides in ground water and water use in the area surrounding the station, NPPD searched the Nebraska Department of Natural Resources (NDNR) water well database for all wells in Nemaha County. Three irrigation wells, completed in the shallow unconsolidated aquifer, are located between 2 and 3 miles (mi) southwest of CNS. Four farm wells within 1 mi of the station, all only 15 feet (ft) deep, produce a limited amount of ground water. None of these wells are impacted by ground water pumping at CNS because the station wells are screened in an unconfined aquifer and have limited radii of influence. A search of wells by NPPD in Atchison County, MO, across the river from CNS, identified no wells within 2 mi of the station. In addition, the Missouri River serves as a ground water recharge and discharge boundary. Therefore, the NRC staff concludes the effect of pumping the shallow aquifer at CNS would not likely be measurable on the Missouri side of the river.

Because of the limited radii of influence of CNS wells completed in the unconfined aquifer, no public ground water supplies are close enough to CNS to be impacted by ground water use at the station. There are no well-head protection areas or EPA designated sole source aquifers in the vicinity of CNS (CRA, 2007). Therefore, the impact of ground water use by CNS is SMALL and no mitigation measures are warranted.

4.4 SURFACE WATER

4.4.1 Generic Surface Water Issues

The following sections discuss the surface water quality issues applicable to CNS, which are listed in Table 4-2. The staff did not identify any Category 2 issues related to surface water issues in the GEIS. In addition, the staff did not identify any new and significant information with respect to the Category 1 issues below during the review of NPPD's ER, the site audit, or the scoping process. Therefore, no impacts are related to these issues beyond those discussed in the GEIS. For these issues, the NRC staff in the GEIS concludes that the impacts are SMALL, and additional site-specific mitigation measures are not warranted.

Table 4-2. Category 1 Surface Water Issues

Issues	GEIS Section	Category
Altered current patterns at intake and discharge structures	4.2.1.2.1	1
Temperature effects on sediment transport capacity	4.2.1.2.3	1
Scouring caused by discharged cooling water	4.2.1.2.3	1
Discharge of chlorine or other biocides	4.2.1.2.4	1
Discharge of sanitary wastes and minor chemical spills	4.2.1.2.4	1
Discharge of other metals in wastewater	4.2.1.2.4	1
Water use conflicts for plants with once-through cooling systems	4.2.1.3	1

The following briefly describes the GEIS conclusions for these issues:

Altered current patterns at intake and discharge structures. Altered current patterns have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.

Temperature effects on sediment transport capacity. These effects have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.

Scouring caused by discharged cooling water. Scouring has not been found to be a problem at most operating nuclear power plants and has caused only localized effects at a few plants. It is not expected to be a problem during the license renewal term.

Discharge of chlorine or other biocides. The effects are not a concern among regulatory and resource agencies, and are not expected to be a problem during the license renewal term.

Environmental Impacts of Operation

Discharge of sanitary wastes and minor chemical spills. Effects are readily controlled through the NPDES permit. Periodic modifications are granted, if needed, and are not expected to be a problem during the license renewal term.

Discharge of other metals in wastewater. These discharges have not been found to be a problem at operating nuclear power plants and are permitted through the NPDES system. They are not expected to be a problem during the license renewal term.

Water use conflicts for plants with once through cooling systems. Continuing operation of CNS depends on the availability of water from the Missouri River. The volume of water available may be susceptible to droughts and to competing water uses within the basin. In cases of extreme drought, these facilities may be required to curtail operations if the volume of water available is not sufficient (NRC 1996). As described in Section 2.0, the flow in the Missouri River is not expected to decrease to the point cooling water restrictions would be imposed on CNS. This remains a Category 1 issue with small impact.

For all of these Category 1 issues in Table 4-2, the NRC staff has not identified any new and significant information during its review of the NPPD's ER, the staff's site visit, the scoping process, or the evaluation of other available information. Therefore, the NRC staff concludes that there were no other surface water issues.

Because of the complex nature of modeling climate change, current modeling only provides regional-level projections with confidence. The most comprehensive, authoritative report is the Global Climate Change Impacts in the United States (USGCRP, 2009), which discusses the impacts of climate change on the Great Plains region, which includes Cooper and large portions of the Missouri River watershed. The report states that significant trends in regional climate are apparent over the last few decades, including an overall warming and an increase in precipitation.

Projections of future climate change relied upon in the USGCRP report show that the northern Great Plains region is anticipated to become wetter. The United States Global Change Research Program (USGCRP) report expresses serious concerns about water resources in the region, largely driven by increased evaporation and an unsustainable depletion of the Ogallala aquifer. However, anticipated climate change by itself is not expected to reduce Missouri River flows due to the anticipated increases in precipitation for most of the Missouri River watershed. CNS does not use the Ogallala aquifer.

4.4.2 Water Use Conflicts

There were no Category 2 surface water issues identified for the CNS license renewal term.

4.5 AQUATIC RESOURCES

Section 2.1.6 of this report describes the CNS cooling water system and Section 2.2.5 describes the aquatic resources. The Category 1 and Category 2 issues related to aquatic resources applicable to CNS are discussed below and listed in Table 4-3.

Table 4-3. Aquatic Resources Issues

Issues	GEIS Section	Category
For All Plants		
Accumulation of contaminants in sediments or biota	4.2.1.2.4	1
Entrainment of phytoplankton and zooplankton	4.2.2.1.1	1
Cold shock	4.2.2.1.5	1
Thermal plume barrier to migrating fish	4.2.2.1.6	1
Distribution of aquatic organisms	4.2.2.1.6	1
Premature emergence of aquatic insects	4.2.2.1.7	1
Gas supersaturation (gas bubble disease)	4.2.2.1.8	1
Low dissolved oxygen in the discharge	4.2.2.1.9	1
Losses from predation, parasitism, and disease among organisms exposed to sublethal stresses	4.2.2.1.10	1
Stimulation of nuisance organisms	4.2.2.1.11	1
For Plants with Once-Through and Cooling Pond Heat Dissipation Systems		
Entrainment of fish and shellfish in early life stages	4.1.2	2
Impingement of fish and shellfish	4.1.3	2
Heat shock	4.1.4	2

4.5.1 Generic Aquatic Ecology Issues

The NRC staff did not identify any new and significant information related to the Category 1 issues listed above during the review of the NPPD's ER, the site audit, or the scoping process. Therefore, there are no impacts related to these issues beyond those discussed in the GEIS. For these issues, the GEIS concludes that the impacts are SMALL, and additional site-specific mitigation measures are not likely to be sufficiently beneficial to be warranted.

4.5.2 Entrainment and Impingement

4.5.2.1 Introduction

Entrainment and impingement of aquatic organisms are site-specific (Category 2) issues for assessing impacts of license renewal at plants with once-through cooling systems. Entrainment is the taking in of organisms with the cooling water. The organisms involved are generally of small size, dependent on the screen mesh size, and include phyto- and zooplankton, fish eggs and larvae, shellfish larvae, and many other forms of aquatic life. Impingement is the entrapment of organisms against the cooling water intake screens.

A particular life stage of a species can be subject to both entrainment and impingement if some individuals are impinged on screens while others pass through and are entrained (EPA, 1977). Section 316(b) of the Clean Water Act (CWA) (33 *United States Code* (U.S.C.) § 1326(b)) requires that:

Any standard established pursuant to section 1311 of this title or section 1316 of this title and applicable to a point source shall require that the location, design,

Environmental Impacts of Operation

construction, and capacity of cooling water intake structures reflect the best technology available for minimizing adverse environmental impact.

The adverse environmental impacts of cooling water intake occur through both impingement and entrainment. Exhaustion, starvation, asphyxiation, descaling, and physical stresses may kill or injure impinged organisms. Heat, physical stress, or chemicals used to clean the cooling system may kill or injure the entrained organisms.

4.5.2.2 History of Cooper Nuclear Station's 316(b) Compliance

Section 4.2.5 of NPPD's ER provides the history of CNS's compliance with Section 316(a) and 316(b) of the CWA (33 *United States Code* (U.S.C.) § 1326(a) and 1326(b)). The Nebraska Department of Environmental Quality (NDEQ) (1977) found, after reviewing CNS's revised 316(b) documentation on the effects of the intake structure on fish populations, that the structure met the minimum requirements of Section 316(b) of the CWA. The NDEQ (1977) also voiced concerns regarding the fate of fish entrapped in the forebay area, however, and noted that, "should problems develop in this area in the future, more adequate fish protection devices may be warranted." NPPD (2008a, pages 4–25) discontinued entrapment monitoring at CNS about a year later in January 1978.

CNS conducted impingement sampling from 1974 through 1978. NPPD (2008a) lists the annual impingement rates from 1975, 1976, and 1977 as follows: 45,990 fish, 63,245 fish, and 40,296 fish, respectively. NPPD (2008a) does not present the annual impingement rate for 1974, but gives the daytime and nighttime rates as 19.8 and 38.1 fish per hour. Assuming 12-hour day and night sampling periods (Hazleton, 1979) and extrapolating to 365 days per year, the NRC staff calculated a yearly rate of 253,600 fish impinged in 1978. NPPD (2008a) did not present the annual rate for 1978. The total impingement for 27 hours of sampling in 1978 was 266 fish (Hazleton, 1979). Extrapolating to 365 days per year, the NRC staff calculated a yearly rate of about 86,300 fish impinged in 1974. These annual rates can only be rough estimates accompanied by a moderate degree of uncertainty, but they are reasonable for understanding the order of magnitude of impingement.

NPPD (2008a) reports that gizzard shad, freshwater drum, and river carpsucker make up the majority of impinged fish in the 1974 through 1978 studies. Based on data from the ER (NPPD, 2008a, Table 1.3-1), the contribution of these three species to total impingement numbers ranged from 73 to 91 percent for the period of 1974 through 1978. Hazleton (1979, Table 7.1) categorizes the occurrence of gizzard shad, freshwater drum, and river carpsucker in the area around the CNS as "common" based on electroshocking and seining during the pre- and post-operational period, 1970 through 1978. The age class of the majority of fish impinged each year was young of the year, and most impingement occurred at night (NPPD, 2008a, page 4–24).

According to NPPD's (NPPD, 2008c) 316(b) Compliance Strategy Report for 2007, "to help address the 316(b) requirements, NPPD installed Brackett-Green dual flow screens with modified Ristroph fish buckets in 2005 and 2006." CNS has not yet completed the fish protection system. The intention is to install a fish handling and return system to mitigate fish impingement. The CNS implementation date and the final design of the fish handling system are dependent upon the content of the final 316(b) CWA requirements. CNS's original 316(a) and 316(b) demonstration (Nalco, 1975, Tables 4.4-48 through 4.4-50) reported entrainment mortality (intake vs. discharge and after an unspecified holding period) but not the number of fish entrained, both of which are necessary for a full assessment of the effects of entrainment. Nalco (1975, Tables 4.4-50 and 4.4-51) also reported mortality of fish larvae after an

unspecified holding period, after passage through the thermal plume. Following NDEQ's (1977) review of CNS's revised 316(b) documentation, NPDES permits have not required subsequent entrainment monitoring and assessment (NPPD, 2008a, page 4–11). The U.S. Atomic Energy Commission (AEC) (1973, page V–15) found that it could describe the potential loss of fish eggs and larvae only in terms of the fraction of river flow taken by the plant, which in spring and early summer when many of the fish species spawned, was about 4 percent. During unusually low summer flows, this fraction would be greater and the fraction of river flow taken by the plant should be no more than 20 percent (NPPD, 2008a). The AEC (1973) found that the percentage loss of fish eggs and larvae originating upstream of the plant was probably much less than the fractional flow because the sampled fish species were spawning in protected areas.

In its guidelines for ecological risk assessment, the Environmental Protection Agency (EPA) (1998) recommends the use of multiple lines of evidence for characterizing and describing risk. The use of lines of evidence can be quantitative or qualitative. The NRC staff adopted a qualitative approach for the impact analysis here. One line of evidence is the regulatory history itself. Although any final determinations regarding CNS's 316(b) demonstration await the EPA's publication of new Phase II rules. Phase II rules were published in 2004, suspended in 2007, and are awaiting new Phase II rules at the time this supplemental environmental impact statement (SEIS) was developed.

The NRC staff find that the history of regulation reviewed above does not show regulatory concern that the potential effects of impingement and entrainment constitute adverse impacts.

4.5.2.3 Analysis

At NRC's environmental audit at CNS in 2009 and in scoping comments (EPA, 2009c), the EPA voiced concern regarding the age of the data (over three and a half decades) used in the ER to support NPPD's assertion in their ER that CNS's impingement and entrainment produced a SMALL impact level on aquatic populations. To assess whether the Missouri River aquatic resources near CNS are stable (as described in Section 2.2.5 of this SEIS), the NRC staff performed the following analysis.

The NRC staff examined the question of how the age of the data might affect the conclusions regarding entrainment and impingement at CNS. The NRC staff found that the argument used in the NPPD's ER is inconsistent because it assumed at different points that the aquatic resources are both stable and unstable, although in fact they cannot be both. In describing the aquatic resources, the ER stated that fish communities have long been responding to changes in the river brought on by man's activities.

The NRC staff reached the conclusion of resource instability from a review of literature (presented in Chapter 2) on the natural and human history of the watershed. The changes are well documented. The present Missouri River is relatively new in geological terms and was partly formed by the last glaciation. As a result, most species in the region have not evolved in place but have colonized from surrounding environments that may have had somewhat different ecologies. Man has changed the river almost constantly, particularly since European settlement. Particularly influential were the early impoundments and withdrawals for irrigation and later dams built for various purposes (e.g., flood control, hydroelectric power, transportation, irrigation). Numerous diversions now withdraw river water for both consumptive and non-consumptive uses. Dredging, bank stabilization, construction of levees, dikes, revetments, and other structures have changed the course of the river, its hydrological cycles, water current velocity, water levels, patterns of sediment suspension and deposition, suspended sediment levels, substrate types, and other aspects of fish habitat. Agriculture, industrialization, the CWA,

Environmental Impacts of Operation

and other regulations and associated activities have affected levels of contaminants in water and sediments, dissolved oxygen levels, and other water quality parameters that affect aquatic populations. Future changes to the Missouri River, for example, those flowing from the Missouri River Ecosystem Restoration Plan, can be foreseen. Aquatic populations respond to these habitat changes.

The effects of impingement and entrainment on fish populations depend in part on the identity, numbers, and population structure of the affected populations. But the reviews of aquatic resources in the NPPD's ER and Section 2.2.5 in this SEIS show that the aquatic populations are not static or stable.

The observation that the aquatic resources of the Missouri River are not static or stable affects NRC's assignment of its level of impact in two ways. First is the concern voiced by the EPA (2009b): the age of the impingement and entrainment data brings into question "whether these data are representative of current river condition and ecological impact." Second, NRC partially defines its levels of impact in terms of stability: for example, NRC's definition of a small impact level is that "environmental effects are not detectable or are so minor that they will neither destabilize nor noticeably alter any important attribute of the resource" and the definition of large impact is that "environmental effects are clearly noticeable and are sufficient to destabilize important attributes of the resource." In applying its definitions of impact levels to effects of CNS on Missouri River aquatic resources, NRC chose an approach that can accommodate the observations that the aquatic resources are changing constantly in response to many environmental variables and are not stable in the sense of unchanging or static.

Another line of evidence is the ecology of adult and juvenile fish living in the Missouri River. The ER reports that water velocity at CNS's intake screens is about 2 feet per second, whereas "historical river velocities were usually 0.98–2.62 feet per second, but downstream from Gavins Point Dam velocities between 2.62 feet per second and 4.27 feet per second occur more frequently than they did historically (Berry et al., p. 6)." These observations suggest that fish in the Missouri River should be adapted to living in water with velocities well in excess of the current that occurs at the intake screens. So while the identity, numbers, and population structure of the potentially affected fish populations may have changed over the last decades, present fish populations are most likely no less able to escape or avoid adverse impact than those present when the impingement and entrainment studies were performed.

A third line of evidence lies in the general ecology of fish eggs and larvae subject to entrainment. The generalities about the pattern of fish eggs and larvae in the Missouri River drift vulnerable to entrainment at CNS are probably similar to those reported by Hergenrader et al. (1982) in the vicinity of CNS in 1974 through 1976, although the relative and absolute abundances, and perhaps some species, may have changed. Fish eggs and juveniles are probably still a small part of all ichthyoplankton and most common from May through July. The numerically dominant fish larvae are probably still those of pelagic spawners, such as freshwater drum, catostomids (e.g., suckers), cyprinids (e.g., minnows), common carp (*Cyprinus carpio*), gizzard shad (*Dorosoma cepedianum*), and goldeneye (*Hiodon alosoides*). The larvae of fish that build nests or spawn randomly have adhesive and demersal (sinking) eggs, or provide parental care of the eggs and larvae, such as centrarchids (e.g., white bass (*Morone chrysops*), sunfish (*Lepomis* spp.), and crappie (*Pomoxis* spp.), percids (e.g., sauger (*Stizostedion canadense*) and walleye (*Sander vitreus*), and channel catfish (*Ictalurus punctatus*) are probably still relatively underrepresented.

Another line of evidence is the fraction of Missouri River flow withdrawn by CNS. The AEC (1973, page V-15) found that it could describe the potential loss of fish eggs and larvae only in terms of the fraction of river flow taken by the plant, which in spring and early summer when many of the fish species spawned was estimated at 4 percent. During unusually low summer flows, the fraction of river flow taken by the plant should be no more than 20 percent (NPPD, 2008a). The AEC (1973) also found that the percentage loss of fish eggs and larvae originating upstream of the plant was probably much less than this because of the protected areas that these species used for spawning. These are very general ways of analyzing impact, and, within their limitations, these generalities are probably still true today, although once again, the identity of the species affected may have changed over time.

The available lines of evidence for assessing impact level for aquatic resources subject to impingement and entrainment at CNS are as follows: (1) the lack of a history of regulatory action indicates no appreciable adverse impact; (2) while fish populations may have changed over the decades, present fish populations are most likely no less able to escape or avoid adverse impact than those present when the impingement and entrainment studies were performed; (3) the generalities about the pattern of fish eggs and larvae in the Missouri River drift vulnerable to entrainment at CNS are probably similar to those reported in past studies that found little or no adverse effects of plant operation; (4) the relative fraction of river flow withdrawn by the plant remains small, and most fish species still have refugia that protect the populations from adverse effects of impingement and entrainment; (5) CNS now has dual flow screens with modified Ristroph fish buckets and NPPD plans to install a fish handling and return system whose final design is dependent upon the content of the final 316(b) CWA requirements; and (6) the NDEQ conclusion based on monitoring and studies conducted by the Omaha Public Power District near both Fort Calhoun Station and CNS that losses due to entrainment were within the acceptable range.

Although the NRC staff reached the conclusion that aquatic resources are not stable, the NRC staff finds that, although these changes may have occurred, the impact on aquatic resources due to impingement and entrainment at CNS is SMALL. The NRC staff has reviewed the available information, including that provided by the applicant, the staff's site visit, the State of Missouri, the 316(b) demonstration, and other public sources. Although no recent impact studies have been performed, the NRC staff concludes that the weight of evidence from past studies, biological inference, and regulatory history indicates a SMALL level of impact on aquatic resources due to impingement and entrainment at CNS. NPPD has implemented some impingement mitigation measures and plans to implement others.

4.5.3 Thermal Effects

For plants with once-through cooling systems and cooling pond heat dissipation systems, NRC's GEIS (1996) lists the effects of heat shock as an issue requiring plant-specific evaluation before license renewal (Category 2). The NRC (1996) made impacts on fish and shellfish resources resulting from heat shock a site-specific issue because of continuing concerns about thermal discharge effects and the possible need to modify thermal discharges in the future in response to changing environmental conditions.

Information considered includes the type of cooling system (once-through in this case), evidence of a CWA Section 316(a) variance or equivalent State documentation, and other information. To perform this evaluation, the staff reviewed the CNS's ER (NPPD, 2008a); visited the CNS site; reviewed the facility's 316(a) demonstration (Nalco, 1975) dated October 23, 1975, and submitted to the NDEQ; and reviewed the applicant's State of Nebraska NPDES

Environmental Impacts of Operation

Permit No. NE0001244 issued on July 1, 2007, and in force until July 30, 2012 (found in Attachment C of NPPD, 2008a).

The latest fact sheet for the NPDES permit summarizes the thermal limits for the effluent and the bases of the limits. The EPA assisted NDEQ in conducting the assessment of mixing cooling water from CNS with ambient Missouri River water for the permit. The permit limits are based on a modeled limit of a 90°F "heat cap" or maximum at the end of the 5,000-ft mixing zone. According to the fact sheet, "Based on a ΔT of 23.9°F, the permit limit for the Cooper Nuclear power plant is 109.4°F. The maximum instream river temperature where the heat cap is met is 85.54°F (29.7°C)" (NDEQ, 2007).

The NPDES permit limits are set for the protection of aquatic life (NDEQ, 2007). In addition to upper thermal limits, shutdown of the plant in winter could cause sudden decreases of temperature that could cause thermal shock and mortality in fish attracted to or living in the thermal discharge and discharge canal (NPPD, 2008a), although these events would probably be rare.

After reviewing the available information, the NRC concludes that the level of thermal impacts to the aquatic community due to renewing CNS's operating license is designated as SMALL.

4.5.4 Total Impacts on Aquatic Resources

In addition to the information presented for impingement, entrainment, and thermal effects individually, the results of some field studies performed in the past and summarized in Section 2.2.5 provide information on the total impacts of CNS's cooling water system operation on aquatic resources. Field studies comparing aquatic communities at locations upstream and downstream from CNS reflect the total impact of entrainment, impingement, and thermal effects.

Reetz (1982) reported that initial (7-hour) differences in carbon fixation rates of phytoplankton at CNS between intake and discharge sampling locations ranged from an average of about 17 percent inhibition during summer to no change during winter. The inhibition in the summer months appeared to depend on absolute discharge temperature: the highest inhibition rates (above 26 percent) occurred when absolute discharge temperatures exceeded 101°F (38.5°C). Recovery from initial inhibition at CNS occurred within 48 hours. While the river would carry phytoplankton far downstream in 48 hours so that a substantial part of the river would be affected, Reetz (1982) concluded that the low rate of water use by CNS compared to river flow combined with the rapid mixing of the thermal plume would make the effects relatively unnoticeable.

Periphytic algae are those algae that are attached to solid surfaces under water, such as rocks, logs, pilings, and other structures. Farrell and Tesar (1982) reported results of periphytic algae studies conducted in the Missouri River in the vicinity of CNS from 1972 through 1977. Because they remain in one place, periphytic algae colonizing natural and artificial substrata are used as indicators of environmental effects. Farrell and Tesar (1982) did not detect changes in the diversity, density, and biovolume of periphytic algae related to water temperature in the vicinity of CNS, although species composition did reflect water temperature. Although these results may generally be indicative of periphyton responses and processes at CNS today, species composition and magnitude of response, which depends on the species involved, may have changed over the decades since Farrell and Tesar's (1982) studies.

Repsys and Rogers (1982) investigated the effects of CNS on zooplankton populations in 1974 through 1978. High absolute discharge temperatures (at or about equal to 35°C or 95°F) critically affected zooplankton survival, as did the duration of exposure. Repsys and Rogers (1982) concluded that entrainment losses were small when compared to the large downstream decreases in zooplankton. Without further studies, the NRC concludes that these general patterns and processes most likely still occur, although species composition and magnitude of response, which depends on the species involved, may have changed over the decades since Repsys and Rogers' (1982) studies.

Carter et al. (1982) reported results of benthic infaunal and epifaunal invertebrate studies conducted in the Missouri River in the vicinity of CNS and Fort Calhoun Station from 1973 through 1977. Benthic infauna refers to the organisms that live in underwater sediments, and benthic epifauna refers to organisms that live on underwater surfaces. Like periphyton, benthic invertebrates are often used as indicators of impacts because they are relatively immobile and sensitive to local environmental conditions. Carter et al. (1982) were not able to detect consistent changes in the epifaunal invertebrate community due to operation of CNS.

Hergenrader et al. (1982) reported the results of both field and entrainment studies on larval fish in the vicinity of CNS in 1974 through 1976. In order to determine if entrainment (and impingement) were having an effect on the fish populations in the area, Hergenrader et al. (1982) looked for changes in adult fish populations resulting from impacts to larval fish, but detected none. They concluded that either no significant changes occurred or "Too few resources (financial, technical, equipment, labor) were applied over too small a time frame in too restricted an area to detect the changes which had occurred."

The aquatic community, particularly the fish community, may not be stable and may still be changing in response to historical changes in land use, river regulation, and other human activities. For example, the U.S. Army Corps of Engineers (USACE) (2004) reports that the benthic fish community appears to be changing based on 1996 and 1997 studies. Whatever the total effects of CNS on the fish community were in the past, the installation of the modified dual-flow traveling screens in 2006 and future installation of a fish handling and return system (dependent upon the content of the final 316(b) CWA requirements) would mitigate those impacts.

While the species and their numbers would have changed over the last decades, the results summarized above reflect general ecological responses.

The NRC staff concludes that the level of impact on aquatic resources due to all aspects of CNS's cooling system operation is SMALL.

4.6 TERRESTRIAL RESOURCES

Section 2.2.6 of this document provides a description of the terrestrial resources at CNS and in the surrounding area. The issues related to terrestrial resources applicable to CNS are discussed below and listed in Table 4-4. No Category 2 issues are related to terrestrial resources for license renewal. The NRC staff did not identify any additional new and significant information during review of NPPD's ER, the site audit, the scoping process, or the evaluation of other available information. Therefore, the NRC staff concludes that there would be no impacts related to these issues beyond those discussed in the GEIS (NRC, 1996). The GEIS concludes that the impacts are SMALL and additional site-specific mitigation measures are not warranted.

Table 4-4. Terrestrial Resources Issues

Issues	GEIS Section	Category
Power line right-of-way management (cutting herbicide application)	4.5.6.1	1
Bird collisions with power lines	4.5.6.1	1
Impacts of electromagnetic fields on flora and fauna (plants, agricultural crops, honeybees, wildlife, livestock)	4.5.6.3	1
Floodplains and wetlands on power line right-of-way	4.5.7	1

4.7 THREATED AND ENDANGERED SPECIES

4.7.1 Aquatic Species

Section 2.2.7 of this document describes the threatened or endangered species on or near CNS. The impact to threatened and endangered species is a Category 2 issue and is discussed below.

One Federally-listed aquatic species may occur in the Missouri River near CNS: pallid sturgeon. NPPD (2008a) summarizes interactions between NPPD and both State and Federal agencies regarding conservation of pallid sturgeon.

In March 2006, before filing a license renewal application with the NRC, NPPD voluntarily participated in meetings with the U.S. Fish and Wildlife Service (USFWS), the Nebraska Game and Parks Commission (NGPC), the NDEQ, the NDNR, the EPA, and the USACE regarding conservation actions to improve the habitat of pallid sturgeon. NPPD (2008a) summarizes those meetings. Early in the discussions, the USFWS and NGPC showed interest in developing existing habitat on a parcel of property south of CNS at Langdon Bend and later also on CNS property on the Nebraska side of the Missouri River adjacent to Langdon Bend. They hoped to enhance pallid sturgeon habitat by building a chute to connect the active river channel with the old river area.

NPPD had problems with this proposal. Implementing the proposal would reduce CNS's mixing zone, which now extends 5,000 ft south of CNS along the Nebraska side of the Missouri River, to less than 2,500 ft. Reducing the mixing zone would reduce CNS's capacity to generate electricity, particularly during summer. The proposal also posed other negative safety and environmental concerns for CNS. As an alternative, NPPD then offered to contribute funds toward other new or existing projects on the Missouri River. The USFWS rejected this funding alternative in favor of increasing the amount of land for habitat development.

To meet the goal of improving habitat for pallid sturgeon, NPPD offered a conservation easement of about 239 acres (ac) of land that it owns on the Missouri side of the Missouri River, opposite CNS, for the purposes of habitat development. The USFWS indicated interest in the proposal and asked NPPD to also acquire an adjacent property of about 150 ac so that the entire bend in the river could be developed into better habitat. When the property owner refused to sell the land, NPPD offered a revised, final proposal to participate in and promote habitat development along the Missouri River. It proposed to revisit the USFWS's and the NGPC's interest in a suitable conservation easement and Memorandum of Understanding (MOU) to enable habitat development on NPPD's approximately 239 ac parcel on the Missouri side of the river. Furthermore, because NPPD recognized that this parcel alone would not meet the

USFWS's and the NGPC's conservation habitat development goals, NPPD indicated its willingness to make an additional payment of \$250,000 to be applied toward another conservation habitat development project on the Missouri River at the direction of the USFWS and the NGPC. The deed restriction for conservation has been placed upon the 239 ac that NPPD owns on the Missouri side of the river, and the MOU, including conditions regarding the additional payment of \$250,000, has been finalized and signed by the parties.

Plans for and construction of a chute on the parcel may also involve the owners of the transmission lines and supports that cross the property. NPPD does not own these lines, although CNS provides power to them.

The probability that CNS will entrain, impinge, or otherwise affect pallid sturgeon eggs or larvae is low. Hazleton (1979) collected adult and juvenile fish from seven locations in the vicinity of CNS from 1970 through 1978 and reported no pallid sturgeon captured. They also conducted impingement sampling from 1974 through 1978 and reported no pallid sturgeon impinged. Based on 374 trawl hauls that captured over 21,735 fish in a 1998 through 2000 survey, Hrabik et al. (2007) concluded that pallid sturgeon may reproduce in the lower Missouri River and the upper and lower Mississippi River, although no fish may survive to recruitment. NPPD's involvement in the conservation agreement for pallid sturgeon; however, could have a positive impact on the population.

The best information available indicates that the NRC level of impact associated with license renewal is SMALL. Although the NRC also concludes that the continued operation of CNS for an additional 20 years may affect, but is not likely to adversely affect, the pallid sturgeon, the NRC staff prepared a biological assessment, which appears in Appendix D.

4.7.2 Terrestrial Species

An evaluation of impacts to threatened and endangered terrestrial species requires consultation with appropriate agencies to determine whether or not such species are present and whether or not these species would be adversely affected by continued operation of the CNS site during the license renewal term.

NPPD has coordinated efforts with the USFWS to address the potential risk of Federally-listed migratory birds colliding with transmission line NPPD TL3502, as discussed in Section 2.2.7.

Four Federally-listed endangered and threatened species, the Indiana bat (*Myotis sodalis*), the western prairie fringed orchid (*Platanthera praeclara*), the piping plover, and the interior least tern are potentially found in the vicinity of the CNS site (NPPD, 2008a). Seven Federally-listed species are also found or potentially found within the counties spanning the transmission line corridor, including the western prairie fringed orchid, the Salt Creek tiger beetle (*Cicindela nevadica lincolniana*), the black-footed ferret (*Mustela nigripes*), the interior least tern, the piping plover, the Eskimo curlew (*Numenius borealis*), and the only known wild population of whooping cranes (USFWS, 2007), (USFWS, 2008), (USFWS, 2009b). The Eskimo curlew is listed as extirpated from Nebraska and is globally extinct or near-extinct (NatureServe, 2009).

There are 115 State-listed threatened or endangered species that occur or have the potential to occur in the vicinity of CNS in Nemaha County, within the counties spanning the transmission line corridor in Nebraska, and in Atchison County, Missouri (NGPC, 2008), (MDC, 2009b). These 115 species are listed in Table 2.2.7-1 along with information on their habitat

Environmental Impacts of Operation

requirements. No longer included in this list is the American bald eagle (*Haliaeetus leucocephalus*), which was formerly a Federally-listed bird. There is an active bald eagle's nest on the Missouri side of the CNS property with a breeding pair of eagles that have produced a number of chicks over the past several years (NPPD, 2008a). Although no longer protected under the Endangered Species Act (ESA), the bald eagle is still protected under the Migratory Bird Treaty Act, and is also protected under the Bald and Golden Eagle Protection Act from any take of a bald eagle without a permit. According to the ER, NPPD attempts to minimize disturbance to the eagles during the infrequent site activities performed on the Missouri side of the CNS site (NPPD, 2008a).

NPPD is required to promptly report to the appropriate wildlife management agencies and to NRC, any evidence of injury to, or mortality of, migratory birds or threatened or endangered species observed within the transmission line corridor, especially injury to, or mortality of, Federally-listed whooping cranes, interior least terns, and piping plovers along the Platte River near the western limit of CN S transmission line NPPD TL3502, near Grand Island, NE. From the review of the available information, the NRC staff finds that operation of the CNS site and its associated transmission lines has not been known to, nor is it expected to harm any threatened or endangered species during the license renewal term. Mitigation measures currently in place at the CNS site include bird flight diverters on the transmission lines within the CNS facility, minimization of activity near the eagle's nest on the Missouri side of the CNS site, a right-of-way (ROW) vegetation management program, and best management practices.

NPPD has coordinated with the USFWS staff and has installed bird diverters on transmission line NPPD TL3502 where it traverses the Platte River. These bird flight diverters will minimize potential impacts to whooping cranes, interior least terns, piping plovers, and other migratory birds. All of these current and proposed mitigation measures minimize the effects of plant operation on terrestrial species and are found to be adequate. Therefore, the NRC staff concludes that adverse impacts to threatened or endangered species during the license renewal term would be SMALL.

4.8 HUMAN HEALTH

Table B-1 of Appendix B to Subpart A of 10 CFR Part 51 contains more information on these issues. The human health issues applicable to CNS are discussed below and listed in Table 4-5 for Category 1, Category 2, and uncategorized issues.

Table 4-5. Human Health Issues

Issues	GEIS Section	Category
Microbiological organisms (occupational health)	4.3.6	1
Microbiological organisms (public health, for plants using small rivers)	4.3.6	2
Noise	4.3.7	1
Radiation exposures to public (license renewal term)	4.6.1, 4.6.2	1
Occupation radiation exposures (license renewal term)	4.6.3	1
Electromagnetic fields – acute effects (electric shock)	4.5.4.1	2
Electromagnetic fields – chronic effects	4.5.4.2	Uncategorized

4.8.1 Generic Human Health Issues

The staff did not identify any new and significant information during its review of NPPD's ER, the site audit, or the scoping process. Therefore, there are no impacts related to these issues beyond those discussed in the GEIS. For these issues, the NRC staff in the GEIS concluded that the impacts are SMALL, and additional site-specific mitigation measures are not likely to be sufficiently beneficial to be warranted. The following information discusses two specific radiological programs conducted at CNS; the radiological environmental monitoring program (REMP) and the radioactive effluent release program.

CNS conducts an annual REMP in which radiological impacts to the employees, the public, and the environment in the environs around the CNS site are documented. The report contains a discussion of the data relative to pre-plant operation baseline data. The objectives of the REMP include the following:

- measure and evaluate the levels of radiation and radioactive material in the environs around the CNS site to assess the radiological impacts, if any, of plant operation on the environment
- supplement the results of the radiological effluent monitoring program by verifying that the measurable concentrations of radioactive material and levels of radiation are not higher than expected based on the measurement of radioactive effluents and modeling for the applicable exposure pathways
- demonstrate compliance with the requirements of applicable Federal regulatory agencies

Two reports summarize radiological information about the CNS site; the annual radiological environmental operating report and the annual radioactive effluent release report. The media samples are intended to be representative of the radiation exposure pathways to the public from all plant radioactive effluents. The REMP measures the aquatic, terrestrial, and atmospheric environment, as well as the ambient gamma radiation, for radioactivity. Ambient gamma radiation pathways include radiation from buildings and plant structures and airborne material that may be released from the plant. In addition, the REMP also measures background radiation (i.e., cosmic sources, global fallout, and naturally occurring radioactive material, including radon). Thermoluminescent dosimeters (TLDs) are used to measure direct radiation. The atmospheric environmental monitoring consists of sampling the air for particulates and radioiodine. Terrestrial environmental monitoring consists of analyzing samples of milk and food products. The aquatic environmental monitoring consists of analyzing samples of surface water, drinking water, ground water, fish, and sediment from the Missouri River. There is also an onsite ground water protection program designed to monitor the onsite plant environment for indications of leaks from plant systems and pipes carrying radioactive liquid. The NRC staff reviewed the CNS radioactive environmental operating reports for 2003 through 2009 to look for any significant impacts to the environment or any unusual trends in the data (NPPD, 2004a), (NPPD, 2005a), (NPPD, 2006a), (NPPD, 2007a), (NPPD, 2008d), (NPPD, 2009a), (NPPD, 2010). The staff's review of the REMP reports showed no unusual trends in the data and showed no measurable impact from the operations at CNS on the environment.

Historical data on radioactive releases from CNS and the resultant dose calculations demonstrate that the amount of radiation received to a hypothetical maximally exposed

individual in the vicinity of CNS is a small fraction of the dose limits specified in 10 CFR Part 20, the as low as reasonably achievable (ALARA) dose design objectives in Appendix I to 10 CFR Part 50, and the EPA's radiation standards in 40 CFR Part 190, "Environmental Radiation Protection Standards for Nuclear Power Operations." Dose estimates for members of the public are calculated based on liquid and gaseous effluent release data and atmospheric and aquatic transport models. The CNS 2009 annual radioactive effluent release report (NPPD, 2010) contains a detailed presentation of the radioactive discharges and the resultant calculated doses. The following summarizes the calculated hypothetical maximum dose to an individual located at the CNS site boundary from radioactive liquid and gaseous effluents released during 2009:

- The whole-body dose to an offsite member of the general public from liquid effluents was 2.45×10^{-2} millirems (mrem) (2.45×10^{-4} milliSieverts (mSv)) which is below the 3 mrem (0.03 mSv) dose criteria in Appendix I to 10 CFR Part 50.
- The air dose at the site boundary from gamma radiation in gaseous effluents was 1.99×10^{-3} millirads (mrad) (1.99×10^{-5} milligray (mGy)), which is below the 10 mrad (0.10 mGy) dose criteria in Appendix I to 10 CFR Part 50.
- The air dose at the site boundary from beta radiation in gaseous effluents was 3.74×10^{-3} mrad (3.74×10^{-5} mGy), which is below the 20 mrad (0.20 mGy) dose criteria in Appendix I to 10 CFR Part 50.

The NRC staff has reviewed and assessed the CNS radioactive waste system performance in controlling radioactive effluents and the resultant doses to members of the public in conformance with the ALARA criteria. The NRC staff found that the 2009 radiological data for CNS are consistent, with reasonable variation attributable to operating conditions and outages and with the historical radiological effluent releases and resultant doses (NPPD, 2004b), (NPPD, 2005b), (NPPD, 2006b), (NPPD, 2007b), (NPPD, 2008e), (NPPD, 2009a), (NPPD, 2010). These results demonstrate that CNS is operating in compliance with Federal radiation protection standards contained in Appendix I to 10 CFR Part 50, 10 CFR Part 20, and 40 CFR Part 190. The applicant has no plans to conduct refurbishment activities during the term of license renewal. Continued compliance with regulatory requirements is expected during the license renewal term; therefore, the impacts from radioactive effluents are not expected to change during the license renewal term.

4.8.2 Microbiological Organisms

The effects of thermophilic microbiological organisms on human health, listed in Table B-1 of Appendix to Subpart A of 10 CFR Part 51, are categorized as a Category 2 issue and require plant-specific evaluation during the license renewal process for the plants located on a small river. The average annual flow of the Missouri River at the nearest point to a CNS measuring station is approximately 1.2×10^{12} cubic feet per year (ft^3/yr) (3.4×10^{10} cubic meters per year (m^3/yr)), which is less than 3.15×10^{12} ft^3/year (9×10^{10} m^3/year), the rate for which an assessment of the impact of the proposed action on public health from thermophilic organisms in the affected water is required by 10 CFR 51.53(c)(3)(ii)(G). Therefore, the site-specific effects on public health must be addressed.

The Category 2 designation is based on the magnitude of the potential public health impacts associated with thermal enhancement of the enteric pathogens such as *Salmonella* spp. and

Shigella spp., the *Pseudomonas aeruginosa* bacterium, the pathogenic strain of the free-living amoebae *Naegleria* spp., and *Legionella* spp. bacteria (NRC, 1996). Thermophilic microorganisms generally occur at temperatures of 77°F to 176°F (25°C to 80°C) with an optimal growth temperature range of 122°F–150°F (50°C–66°C), minimum and maximum temperature tolerances of 68°F (20°C) and 158°F (70°C), respectively; however, thermal preferences and tolerances vary across bacterial groups. Pathogenic thermophilic microbiological organisms that are of concern during nuclear power reactor operation typically have optimal growing temperatures of approximately 99°F (37°C) (Joklik and Smith, 1972).

Pseudomonas aeruginosa is an opportunistic pathogen that causes serious and sometimes fatal infections in immunocompromised individuals. The organism produces toxins harmful to humans and animals. It has an optimal growth temperature of 99°F (37°C) (Todar, 2007) *Legionella* spp. consists of at least 46 species and 70 serogroups. It is responsible for Legionnaires' disease, with the onset of pneumonia in the first 2 weeks of exposure. Risk groups for *Legionella* spp. include elderly, cigarette smokers, persons with chronic lung or immunocompromising diseases, and persons receiving immunosuppressive drugs.

The ambient temperatures of the Missouri River near CNS vary from freezing (approximately 32°F (0°C)) in the winter to 87°F–89°F (30.5°C–31.6°C) in the summer; therefore, ambient river conditions are not likely to support the proliferation of the pathogenic organisms of concern. According to the data submitted by NPPD to the NDEQ for the period January 2003 to September 2005, the mean monthly average temperature of the thermal discharge at Outfall 001 was 75.7°F (24.3°C). The reported maximum daily temperature, which occurs temporarily for the short time during periodic condenser backwash, was 109.2°F (42.9°C). The highest monthly average discharge temperature was 101.7°F (38.7°C) in August 2003 and 101.3°F (38.5°C) in July 2005, which is consistent with the historical data showing that monthly average discharge temperatures at or above 95°F (35°C) occur only during July and August. Ambient temperatures of the Missouri River stay below 77°F (25°C) from October to April; therefore, ambient river conditions are not likely to support the proliferation of pathogenic organisms of concern.

NPPD consulted the Nebraska Department of Public Health and Human Services (DHHS) and the Missouri Department of Public Safety (DPS) to determine if there was any concern about the potential occurrence of thermophilic microbiological organisms in the Missouri River at the CNS location. The Nebraska DHHS and Missouri DPS stated that no occurrences of infections caused by *Naegleria fowleri* from the Missouri River in the CNS vicinity were documented (NPPD, 2008a).

Available data assembled into biannual reports by the Center for Disease Control (CDC) for the years 1999 to 2006 (CDC, 2000), (CDC, 2002), (CDC, 2004), (CDC, 2006) indicate no occurrence of waterborne disease outbreaks in the State of Nebraska resulting from exposure to the thermophilic microbiological organisms *Naegleria fowleri* and *Pseudomonas aeruginosa* from the operation of CNS.

The NRC staff reviewed all documents, applicable to this Category 2 issue, including NPPD's ER, the NPDES permit, and CDC reports. The NRC staff concludes that thermophilic microbiological organisms are not likely to present a public health hazard as a result of CNS discharges to the Missouri River.

The NRC staff concludes that impacts on public health from thermophilic microbiological organisms from continued operation of CNS in the license renewal period would be SMALL.

4.8.3 Electromagnetic Fields – Acute Shock

Based on the GEIS, the Commission found that electric shock resulting from direct access to energized conductors or from induced charges in metallic structures has not been a problem at most operating plants and generally is not expected to be a problem during the period of extended operation; however, a site-specific review is required to determine the significance of the electric shock potential along the portions of the transmission lines within the scope of the SEIS.

The GEIS states that it is not possible to determine the significance of the electric shock potential without a review of the conformance of each nuclear plant transmission line with National Electric Safety Code (NESC) criteria (IEEE, 2007). Evaluation of individual plant transmission lines is necessary because the issue of electric shock safety was not addressed in the licensing process for some plants. For other plants, land use in the vicinity of transmission lines may have changed, or power distribution companies may have chosen to upgrade line voltage. To comply with 10 CFR 51.53(c)(3)(ii)(H), the applicant must provide an assessment of the potential shock hazard if the transmission lines that were constructed for the specific purpose of connecting the plant to the transmission system do not meet the recommendations of the NESC for preventing electric shock from induced currents.

All transmission lines associated with CNS were constructed in accordance with NESC and industry guidance in effect at the time of their construction (AEC, 1973). The transmission facilities are maintained to ensure continued compliance with current standards. The transmission line assessment program, implemented at CNS, ensures continued monitoring and documenting of current conditions of the transmissions lines, along with maintenance, and compliance with current standards. Bimonthly aerial patrols and additional special patrols after severe storms are performed in order to identify any ground clearance problems and the integrity of the transmission line structures. Ground inspections are conducted by transmission line technicians on an annual basis (NPPD, 2008a).

Since the lines were constructed, a new criterion has been added to the NESC for power lines with voltages exceeding 98 kilovolts (kV). NPPD has reviewed the transmission line clearances and configurations for compliance with this criterion (NPPD, 2008a) and determined that all transmission lines within the scope of this review meet the NESC code. No induced shock hazard to the public should occur, since the lines are operating within original design specifications and meet current NESC clearance standards.

The NRC staff has reviewed the available information, including the applicant's evaluation and computational results. Based on this information, the NRC staff evaluated the potential impacts for electric shock resulting from the operation of CNS and its associated transmission lines. The NRC staff concludes that the potential impacts from electric shock during the renewal period would be SMALL.

4.8.4 Electromagnetic Fields – Chronic Effects

In the GEIS, the chronic effects of 60-hertz (Hz) electromagnetic fields (EMFs) from power lines were not designated as Category 1 or 2, and will not be until a scientific consensus is reached on the health implications of these fields. The Commission rules do not require the license renewal application to include information on this issue.

4.9 SOCIOECONOMICS

Category 1 issues in 10 CFR Part 51, Subpart A, Appendix B, Table B-1 that are applicable to socioeconomic impacts during the renewal term, are listed in Table 4-6. As stated in the GEIS, the impacts associated with these Category 1 issues were determined to be SMALL, and plant-specific mitigation measures would not be sufficiently beneficial to be warranted.

The NRC staff reviewed and evaluated the CNS ER, scoping comments, other available information, and visited CNS in search of new and significant information that would change the conclusions presented in the GEIS. No new and significant information was identified during this review and evaluation. Therefore, it is expected that there would be no impacts related to these Category 1 issues during the renewal term beyond those discussed in the GEIS.

Table 4-6. Category 1 Issues Applicable to Socioeconomics during the Renewal Term

Issues	GEIS Section	Category
Public Services: public safety, social services, and tourism and recreation	4.7.3.3; 4.7.3.4; 4.7.3.6	1
Public Services: education (license renewal)	4.7.3.1	1
Aesthetic Impacts (license renewal term)	4.7.6	1
Aesthetic impacts of transmission lines (license renewal term)	4.5.8	1

4.9.1 Generic Socioeconomic Issues

The following briefly describes the GEIS conclusions, as stated in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, for each of the socioeconomic Category 1 issues:

Public services: public safety, social services, and tourism and recreation. Impacts to public safety, social services, and tourism and recreation are expected to be of small significance at all sites.

Public services: education (license renewal term). Only impacts of small significance are expected.

Aesthetic impacts (license renewal term). No significant impacts are expected during the license renewal term.

Aesthetic impacts of transmission lines (license renewal term). No significant impacts during the license renewal term.

No new and significant information was identified for these issues during the review. Therefore, it is expected that there would be no impacts during the renewal term beyond those discussed in the GEIS.

Table 4-6 lists the Category 1 socioeconomic issues, which require plant-specific analysis, and an environmental justice impact analysis, that was not addressed in the GEIS.

Table 4-7 lists the Category 2 socioeconomic issues, which require plant-specific analysis, and an environmental justice impact analysis, which was not addressed in the GEIS.

Table 4-7. Category 2 Issues Applicable to Socioeconomics and Environmental Justice During the Renewal Term

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Section	10 CFR 51.53(c)(3)(ii) Subparagraph	SEIS Section
Socioeconomics			
Housing impacts	4.7.1	I	4.4.1
Public services: public utilities	4.7.3.5	I	4.4.2
Offsite land use (license renewal term)	4.7.4	I	4.4.3
Public services: transportation	4.7.3.2	J	4.4.4
Historic and archaeological resources	4.7.7	K	4.4.5
Environmental justice	Not addressed ^(a)	Not addressed ^(a)	4.4.6

(a) Guidance related to environmental justice was not in place at the time the GEIS and the associated revision to 10 CFR Part 51 were prepared. Therefore, environmental justice must be addressed in plant-specific reviews.

4.9.2 Housing Impacts

According to the 2000 Census, approximately 18,318 people lived within 20 mi of CNS, which equates to a population density of 15 persons per square mile (mi²) (NPPD, 2008a). The NRC staff defined in the GEIS this density to be most sparse (less than 40 persons per mi² and no community with 25,000 or more persons within 20 mi) and determined it to be Category 1. Approximately 160,211 people live within 50 mi of CNS (NPPD, 2008a). This equates to a population density of 20 persons per mi². Applying the GEIS proximity measures, CNS is classified as proximity Category 1 (no city with 100,000 or more persons and less than 50 persons per mi² within 50 mi). Therefore, according to the sparseness and proximity matrix presented in the GEIS, rankings of sparseness Category 1 and proximity Category 1 result in the conclusion that CNS is located in a low population area.

Since Nemaha, Otoe, Richardson, and Atchison counties are not subject to growth control measures that would limit housing development, any changes in employment at CNS would have little noticeable effect on housing availability in these counties. Since NPPD has no plans to add non-outage employees during the license renewal period, employment levels at CNS would remain relatively constant with no additional demand for permanent housing during the license renewal term. Based on this information, there would be no additional impact on housing during the license renewal term.

4.9.3 Public Services: Public Utilities

In Section 4.7.4 of the GEIS, the staff defined impacts on public utility services as SMALL if the existing infrastructure could accommodate any plant-related demand without a noticeable effect on the level of service. Impacts are defined as MODERATE if the demand for service or use of the infrastructure is sizeable and would noticeably decrease the level of service or require additional resources to maintain the level of service. Impacts are defined as LARGE when new programs, upgraded or new facilities, or substantial additional staff is needed because of plant-related demand. In the absence of new and significant information to the contrary, the only impacts on public utilities that could be significant would be impacts on public water supplies.

Analysis of impacts on the public water systems considered both plant demand and plant-related population growth. Section 2.1.7 describes the permitted withdrawal rate and actual use of water for reactor cooling at CNS.

Since NPPD has no plans to add non-outage employees during the license renewal period, employment levels at CNS would remain relatively unchanged with no additional demand for public water services. Public water systems in the region would be adequate to meet the demands of residential and industrial customers in the area. Therefore, there would be no additional impact to public water services during the license renewal term.

4.9.4 Offsite Land Use – License Renewal Period

Offsite land use during the license renewal term is a Category 2 issue (10 CFR Part 51, Subpart A, Appendix B, Table B-1). Table B-1 of 10 CFR Part 51, Subpart A, Appendix B notes that “significant changes in land use may be associated with population and tax revenue changes resulting from license renewal.”

In Section 4.7.4 of the GEIS, the NRC staff defines the magnitude of land-use changes as a result of plant operation during the license renewal term as SMALL when there will be little new development and minimal changes to an area’s land-use pattern, as MODERATE when there will be considerable new development and some changes to the land-use pattern, and LARGE when there will be large-scale new development and major changes in the land-use pattern.

Tax revenue can affect land use because it enables local jurisdictions to provide the public services (e.g., transportation and utilities) necessary to support development. Section 4.7.4.1 of the GEIS states that the assessment of tax-driven land-use impacts during the license renewal term should consider: (1) the size of the plant’s tax payments relative to the community’s total revenues, (2) the nature of the community’s existing land-use pattern, and (3) the extent to which the community already has public services in place to support and guide development. If the plant’s tax payments are projected to be small relative to the community’s total revenue, tax driven land-use changes during the plant’s license renewal term would be SMALL, especially where the community has pre-established patterns of development and has provided public services to support and guide development. Section 4.7.2.1 of the GEIS states that if new tax payments are less than 10 percent of the taxing jurisdiction’s revenue, the significance level would be SMALL. If tax payments are 10 to 20 percent of the community’s total revenue, new tax-driven land-use changes would be MODERATE. If tax payments are greater than 20 percent of the community’s total revenue, new tax-driven land-use changes would be LARGE. This would be especially true where the community has no pre-established pattern of development or has limited public services available to support and guide development.

4.9.4.1 Population-Related Impacts

Since NPPD has no plans to add non-outage employees during the license renewal period, there would be no plant operations-driven population increase in the vicinity of CNS. Therefore, there would be no additional population-related offsite land use impacts during the license renewal term.

4.9.4.2 Tax Revenue-Related Impacts

As previously discussed in Chapter 2, NPPD makes annual payments in lieu of taxes (PILOT) to the municipalities and 91 counties in Nebraska where NPPD sells power. Since NPPD started making payments to local jurisdictions, population levels and land use conditions have not

Environmental Impacts of Operation

changed significantly, which might indicate that these tax revenues have had little or no effect on land use activities within the county. PILOT payments are based upon the gross revenues NPPD receives from electricity sales in the 91 counties, regardless of where the power is generated. The magnitude of the PILOT payments relative to the county's total revenues is not relevant in assessing tax revenue-related offsite land use impacts since NPPD is responsible for producing and distributing electricity and PILOT payments even if the CNS does not produce electricity or the operating license is not renewed.

Since NPPD has no plans to add non-outage employees during the license renewal period, employment levels at CNS would remain relatively unchanged. Annual PILOT payments would also remain relatively unchanged throughout the license renewal period. Based on this information, there would be no additional tax-revenue-related offsite land use impacts during the license renewal term.

4.9.5 Public Services: Transportation Impacts

Table B-1 of Appendix B to Subpart A of 10 CFR Part 51 states the following:

Transportation impacts (level of service) of highway traffic generated...during the term of the renewed license are generally expected to be of SMALL significance. However, the increase in traffic associated with additional workers and the local road and traffic control conditions may lead to impacts of MODERATE or LARGE significance at some sites.

All applicants are required by 10 CFR 51.53(c)(3)(ii)(J) to assess the impacts of highway traffic generated by the proposed project on the level of service of local highways during the term of the renewed license and during refurbishment activities.

Since NPPD has no plans to add non-outage employees during the license renewal period and does not plan any refurbishment activities, there would be no noticeable change in traffic volume and levels of service on roadways in the vicinity of CNS; therefore, there would be no additional transportation impacts during the license renewal term.

4.9.6 Historic and Archaeological Resources

The National Historic Preservation Act (NHPA) requires Federal agencies to consider the effects of their undertakings on historic properties. Historic properties are defined as resources that are eligible for listing on the National Register of Historic Places (NRHP). The criteria for eligibility are listed in 36 CFR 60.4 and include: (1) association with significant events in history; (2) association with the lives of persons significant in the past; (3) embodies distinctive characteristics of type, period, or construction; and (4) sites or places that have yielded or are likely to yield important information (ACHP, 2009). The historic preservation review process (Section 106 of the NHPA) is outlined in regulations issued by the Advisory Council on Historic Preservation in 36 CFR Part 800.

The issuance of a renewed operating license for a nuclear power plant is a Federal action that could affect historic properties on or near the nuclear plant site and transmission lines. In accordance with the provisions of the NHPA, the NRC is required to make a reasonable effort to identify historic properties included in or eligible for inclusion in the NRHP in the area of potential effect (APE). The APE for license renewal is the nuclear power plant site, transmission lines, and immediate environs. If historic properties are present, the NRC is required to contact the State Historic Preservation Office (SHPO), assess the potential impact, and resolve any

possible adverse effects of the undertaking (license renewal) on historic properties. The NRC is also required to notify the SHPO if historic properties would not be affected by license renewal or if no historic properties are present.

NPPD contacted the Missouri SHPO and the Nebraska State Historical Society (NSHS) in January 2008, requesting information on historic and archaeological resources in the vicinity of CNS and described the proposed action (license renewal) (NPPD, 2008a). The NSHS responded in February 2008 that the proposed action (license renewal) would have no effect on historic structures (NPPD, 2008a). The Missouri SHPO requested that an "historic architectural and archaeological survey" be conducted at CNS (NPPD, 2008a). In response to the Missouri SHPO's request, NPPD conducted a survey and submitted a Phase 1A Literature Review and Archeological Sensitivity Assessment along with NPPD's Cultural Resources Protection Plan in May 2008 (NPPD, 2008a). In June 2008, the Missouri SHPO concurred with the conclusions in NPPD's archaeological assessment (NPPD, 2008a).

In accordance with 36 CFR 800.8(c), the NRC contacted the Missouri SHPO (NRC, 2008a), the NSHS (NRC, 2008b), the Advisory Council on Historic Preservation (NRC, 2008c), and Federally-recognized American Indian Tribes to initiate Section 106 consultation. These letters are presented in Appendix D.

In April 2007 and March 2008, NPPD contracted with Enercon Services, Inc. to conduct an "historic architectural and archaeological survey" of the CNS site. A report, "Phase 1A Literature Review and Archeological Sensitivity Assessment of the Cooper Nuclear Station, Nemaha County, Nebraska, Atchison County Missouri," prepared by Enercon Services for NPPD did not conduct any subsurface testing. The survey determined that 55 ac of the site were heavily disturbed by construction of the CNS facility and some of the lands have and continue to be farmed. The study identified one prehistoric site (Whitten) adjacent to the CNS property, two prehistoric lithic scatters, and three former house (farm) sites. All surface structures associated with the earlier house sites have been demolished; however, remnants of these buildings remain as historic archaeological sites and could be eligible for inclusion to the NRHP under Criteria A. Additionally, Lewis and Clark were known to have camped in the vicinity of CNS. The exact location of this campsite has never been determined.

As discussed in Section 2.2.10, a search of the NSHS site files identified no previously recorded historic properties on the CNS property; however, the Enercon report indicates that portions of the Whitten site could extend onto CNS property. A formal archaeological survey of the CNS site has not been completed; however, a number of archaeological and historical research studies have been conducted in both Nemaha and Atchison counties. These surveys identified several historic and archaeological sites within a 6-mi radius of CNS. The resources found during these surveys tend to occur on the same landforms that occur on the CNS property suggesting that there is a potential for deeply buried undiscovered historic and archaeological resources on the plant property.

The Whitten archeological site (25NH4) is a prehistoric mound (Plains Woodland) site excavated in the late 1930s. It is unclear from the archaeological site description if the Whitten site was located entirely on private property north of CNS, or if the site extended onto the CNS property. Human remains, grave goods, and other artifacts were recovered from this site. Artifacts recovered from the site suggest an affiliation with the Sterns Creek variant of the Plains Woodland tradition (Gibbon and Ames, 1998). The NSHS site form noted that some of the remains were sent to the U.S. National Museum in accordance with a Works Progress Administration contract (NSHS, 1937). Historic records indicate that the entire bluff was

Environmental Impacts of Operation

surveyed from CNS property to the city of Nemaha. During Enercon's 2007 and 2008 walkovers, no additional burial mounds were identified; however, there remains a potential for additional prehistoric sites (camp sites) to be in the area. During NRC's walkover survey, the staff noted the presence of prehistoric and historic artifacts on CNS property.

The William Dawson House (Site # NH00-69), located in the southwest corner of the site near the bluff, was recorded in Nebraska historic archives but not included on the NRHP. The Dawson House was torn down shortly after it was recorded. No visible remnants of the house remain; however, subsurface portions of the house could remain.

During the environmental site visit, the NRC staff discovered that archaeological surveys were not conducted prior to the construction of the firing range. At that time, NPPD did not have corporate procedures (Cultural Resources Protection Plan) in place. In preparation for license renewal, NPPD contracted with Enercon to survey the site and established a Cultural Resources Protection Plan to acknowledge and improve the protection of archaeological resources at CNS. In its plan, NPPD calls for surveys to be conducted by a qualified archaeologist in areas deemed sensitive prior to work commencing.

In addition, during the construction of the independent spent fuel storage installation (ISFSI) pad, soil was removed from the top of the bluff (with consent of the landowner). Archaeological surveys were not conducted prior to this activity. NPPD has since taken corrective actions to ensure that all aspects of its Cultural Resources Protection Plan are followed.

NPPD currently has no planned changes or ground disturbing activities associated with license renewal at CNS; however, given the high potential for the discovery of additional historic and archaeological resources at the CNS site, NPPD needs to ensure that these resources are considered during future plant operations and maintenance activities. CNS is situated in an area where historic and archaeological resources could be located several feet beneath the ground surface. NPPD has instituted a stop work order within its Cultural Resources Protection Plan to ensure that proper notification is taken to protect these resources should they be discovered.

Based on a review of NSHS files, archaeological surveys, assessments, and other information, the potential impacts of continued operations and maintenance on historic and archaeological resources at CNS would be SMALL. NPPD could further reduce potential impacts to historic and archaeological resources located at the CNS by training NPPD staff in the Section 106 consultation process and cultural awareness training to ensure that informed decisions are made prior to any ground disturbing activities. In addition, NPPD could also forward its Cultural Resources Protection Plan to the NSHS and the Missouri SHPO for review and comment. This will ensure that historic and archaeological resources are protected at the CNS site. Any revisions to the Cultural Resources Protection Plan should be developed in consultation with the NRC, NSHS, and Missouri SHPO. In addition, lands not surveyed should be investigated by a qualified archaeologist prior to any ground disturbing activity.

4.9.7 Environmental Justice

Under Executive Order (E.O.) 12898 (59 *Federal Register* (FR) 7629) as amended by 60 FR 6381, January 30, 1995, Federal agencies are responsible for identifying and addressing potential disproportionately high and adverse human health and environmental impacts on minority and low-income populations. In 2004, the Commission issued a Policy Statement on the Treatment of Environmental Justice Matters in NRC Regulatory and Licensing Actions (69 FR 52040), which states, "The Commission is committed to the general goals set forth in

E.O. 12898, and strives to meet those goals as part of its National Environmental Policy Act of 1969 (NEPA) review process.”

The Council on Environmental Quality (CEQ) provides the following information in Environmental Justice: Guidance under the National Environmental Policy Act (NEPA) (1997):

Disproportionately High and Adverse Human Health Effects. When determining whether human health effects are disproportionately high and adverse, agencies are to consider the following three factors to the extent practicable: (a) Whether the health effects, which may be measured in risks and rates, are significant (as employed by NEPA), or above generally accepted norms. Adverse health effects may include bodily impairment, infirmity, illness, or death; (b) Whether the risk or rate of hazard exposure by a minority population, low-income population, or Indian tribe to an environmental hazard is significant (as employed by NEPA) and appreciably exceeds or is likely to appreciably exceed the risk or rate to the general population or other appropriate comparison group; and (c) Whether health effects occur in a minority population, low-income population, or Indian tribe affected by cumulative or multiple adverse exposures from environmental hazards (CEQ, 1997).

Disproportionately High and Adverse Environmental Effects. When determining whether environmental effects are disproportionately high and adverse, agencies are to consider the following three factors to the extent practicable: (a) Whether there is or will be an impact on the natural or physical environment that significantly (as employed by NEPA) and adversely affects a minority population, low-income population, or Indian tribe. Such effects may include ecological, cultural, human health, economic, or social impacts on minority communities, low-income communities, or Indian tribes when those impacts are interrelated to impacts on the natural or physical environment; (b) Whether environmental effects are significant (as employed by NEPA) and are or may be having an adverse impact on minority populations, low-income populations, or Indian tribes that appreciably exceeds or is likely to appreciably exceed those on the general population or other appropriate comparison group; and (c) Whether the environmental effects occur or would occur in a minority population, low-income population, or Indian tribe affected by cumulative or multiple adverse exposures from environmental hazards (CEQ, 1997).

The environmental justice analysis assesses the potential for disproportionately high and adverse human health or environmental effects on minority and low-income populations that could result from the operation of CNS during the renewal term. In assessing the impacts, the following CEQ (1997) definitions of minority individuals and populations and low-income population were used:

Minority. Individual(s) who are members of the following population groups: American Indian or Alaskan Native; Asian or Pacific Islander; Black, not of Hispanic origin; or Hispanic.

Minority populations. Minority populations should be identified where either: (a) the minority population of the affected area exceeds 50 percent or (b) the minority population percentage of the affected area is meaningfully greater than the minority population percentage in the general population or other appropriate unit of geographic analysis. In identifying minority communities, agencies may

Environmental Impacts of Operation

consider as a community either a group of individuals living in geographic proximity to one another, or a geographically dispersed/transient set of individuals (such as migrant workers or Native American), where either type of group experiences common conditions of environmental exposure or effect. The selection of the appropriate unit of geographic analysis may be a governing body's jurisdiction, a neighborhood, census tract, or other similar unit that is to be chosen so as to not artificially dilute or inflate the affected minority population. A minority population also exists if there is more than one minority group present and the minority percentage, as calculated by aggregating all minority persons, meets one of the above-stated thresholds.

Low-income population. Low-income populations in an affected area are identified with the annual statistical poverty thresholds from the U.S. Census Bureau's (USCB) Current Population Reports, Series PB60, on Income and Poverty.

4.9.7.1 *Minority Population in 2000*


The 50-mi radius around CNS includes 24 counties with nine in Nebraska, six in Kansas, five in Iowa, and four in Missouri. The geographic area includes any census block with all or part of its area within the 50-mi radius. According to 2000 census data, 4.3 percent of the population (approximately 160,248 individuals) residing within a 50-mi (80 kilometer (km)) radius of CNS identified themselves as minority individuals. The largest minority group was Hispanic or Latino (2,295 persons or 1.4 percent), followed by American Indian (2,366 or about 1.5 percent) (USCB, 2003). About 2.9 percent of the Nemaha County population identified themselves as minorities, with Hispanic or Latino being the largest minority group (1 percent) followed by some other race (0.7 percent) (USCB, 2009) (see Table 2.2.8.5-2).

Populations within each state were considered individually and as a four-State geographic area. A combined or aggregate population of the four-State area was calculated based on these State populations.

Approximately 370 (individual State method) to 380 (four-State combined method) blocks within 50 mi of CNS were determined to have high density minority population percentages that exceeded the State average by 20 percentage points or more. The largest number of high density minority blocks was Hispanic or Latino, with 160 (four-State combined) to 170 (individual State) blocks that exceed the State average by 20 percent or more. The greatest concentrations of high density minority population blocks are located nearly 50 mi south of CNS in Brown County, KS, and approximately 30 mi south-southeast of CNS where the Nebraska-Kansas-Missouri State borders come together. The closest high density minority population is located approximately 10 mi west of CNS, near Nemaha (NPPD, 2008a).

The Sac and Fox and Iowa Indian Reservations straddle the border of Nebraska (Richardson County) and Kansas (Brown and Doniphan counties). The Kickapoo Indian Reservation is located south of CNS in Brown County, KS.

Based on 2000 census data, Figure 4-1 (individual State method) and Figure 4-2 (four-State combined method) show the locations of high density minority blocks within a 50-mi radius of CNS.



Legend

- ★ Cooper Nuclear Station
- 50-Mile Radius
- Aggregate Minority Plus Hispanic Individual States
- States
- Counties




Figure 4-1. Minority Blocks in 2000 within a 50-Mile Radius of Cooper Nuclear Station (Individual State) (Source: USCB, 2008)

Environmental Impacts of Operation




Figure 4-2. Minority Blocks in 2000 within a 50-Mile Radius of Cooper Nuclear Station (Combined State) (Source: USCB, 2008)

4.9.7.2 Low-Income Population in 2000

According to 2000 census data, approximately 3,100 families and 16,000 individuals (approximately 7.3 and 10.1 percent, respectively) residing within a 50-mi radius of CNS were identified as living below the Federal poverty threshold in 1999 (USCB, 2003). The 1999 Federal poverty threshold was \$17,029 for a family of four.

According to census data estimates, the median household income for Nebraska in 2007 was \$47,072, with 11.1 percent of the State population living below the Federal poverty threshold.

Nemaha County had a lower median household income average (\$41,024) and a higher percentage (13.3 percent) of individuals living below the poverty level when compared to the State average. Richardson County had the lowest median household income of the four counties (\$36,092) and a higher percentage (13.4 percent) of individuals living below the poverty level when compared to the State. Otoe County had the highest median household income (\$45,018) and the lowest percentage (9.4 percent) of individuals living below the poverty level among the four counties (USCB, 2008). Atchinson County, Missouri, had a lower median household income average (\$38,114) than the State and the highest percentage (14 percent) of individuals living below the poverty level among the four counties. The median household income for Missouri in 2007 was \$45,012, with 13.3 percent of the State population living below the Federal poverty threshold (USCB, 2009).

Census block groups were considered high density low-income block groups if the percentage of households below the Federal poverty threshold exceeded the State average by 20 percent or more. Based on 2000 census data, there were 192 block groups within the 50-mi radius of CNS that exceeded the State average for low-income households by 20 percent or more. The majority of census block groups with low-income populations were located in two counties, Page County and Nodaway County in Missouri (NPPD, 2008a). Figure 4-3 (individual State method) and Figure 4-4 (four-State combined method) show the location of high density low-income census block groups within a 50-mi radius of CNS.

Environmental Impacts of Operation




Figure 4-3. Low-Income Block Groups with a 50-Mile Radius of Cooper Nuclear Station (Individual State) (Source: USCB, 2008)




Figure 4-4. Low-Income Block with a 50-Mile Radius of Cooper Nuclear Station (Combined State) (Source: USCB, 2008)

The NRC addresses environmental justice matters for license renewal through: (1) identification of minority and low-income populations that may be affected by the proposed license renewal, and (2) examining any potential human health or environmental effects on these populations to determine if these effects may be disproportionately high and adverse.

The discussion and figures above identify the location of minority and low-income populations residing within a 50-mi (80-km) radius of CNS. This area of impact is consistent with the impact analysis for public and occupational health and safety, which also considers the radiological effects on populations located within a 50-mi (80-km) radius of the plant. As previously

discussed for the other resource areas in Chapter 4, the analyses of impacts for all environmental resource areas indicated that the impact from license renewal would be SMALL.

Socioeconomic conditions at the Sac and Fox and Iowa Reservation would not change as a result of renewing the CNS operating license. Employment levels at CNS would remain relatively unchanged, so direct and indirect employment opportunities caused by CNS would remain unchanged. The Sac and Fox and Iowa Reservations also receive no income from taxes paid by NPPD to the State of Nebraska. Therefore, there would be no additional socioeconomic impact to minority and low-income populations during the license renewal term beyond what is currently being experienced.

Potential impacts to minority and low-income populations would mostly consist of radiological effects; however, radiation doses from continued operations associated with this license renewal are expected to continue at current levels, and would remain within regulatory limits. Chapter 5 discusses the environmental impacts from postulated accidents that might occur during the license renewal term, which include both design basis and severe accidents. In both cases, the Commission has generically determined that impacts associated with such accidents are SMALL because nuclear plants are designed to successfully withstand design basis accidents, and that any risk associated with severe accidents were also SMALL.

Therefore, based on this information and the analysis of human health and environmental impacts presented in Chapters 4 and 5, there would be no disproportionately high and adverse impacts to minority and low-income populations from the continued operation of CNS during the license renewal term.

4.9.7.3 *Analysis of Impacts*

Consistent with the impact analysis for the public and occupational health and safety, the affected populations are defined as minority and low-income populations who reside within a 50-mi radius of CNS. Based on the analysis of environmental health and safety impacts presented in Chapter 4 of this SEIS for other resource areas, there would be no disproportionately high and adverse impacts to minority and low-income populations from the continued operation of CNS during the license renewal period.

The NRC also analyzed the risk of radiological exposure through the consumption patterns of special pathway receptors, including subsistence consumption of fish, native vegetation, surface waters, sediments, and local produce; absorption of contaminants in sediments through the skin; and inhalation of plant materials. The special pathway receptors analysis is important to the environmental justice analysis because consumption patterns may reflect the traditional or cultural practices of minority and low-income populations in the area. This analysis is presented below.

4.9.7.4 *Subsistence Consumption of Fish and Wildlife*

Section 4-4 of E.O. 12898 (1994) directs Federal agencies, whenever practical and appropriate, to collect and analyze information on the consumption patterns of populations that rely principally on fish and wildlife for subsistence and to communicate the risks of these consumption patterns to the public. The NRC considered whether or not there were any means for minority or low-income populations to be disproportionately affected by examining impacts to American Indian, Hispanic, and other traditional lifestyle special pathway receptors. Special pathways that took into account the levels of contaminants in native vegetation, crops, soils and sediments, surface water, fish, and game animals in the vicinity of CNS were considered.

NPPD has an ongoing comprehensive REMP at CNS that assesses the radiological impact of site operations on the environment. Radiological environmental monitoring began at CNS in 1971 before the plant became operational. The REMP program monitors radiation levels in air, terrestrial, and aquatic environments. All samples are collected by NPPD personnel and are shipped to a laboratory for analysis.

To assess the radiological impact of the plant on the environment, the monitoring program at CNS uses indicator-control sampling. Samples are collected at nearby indicator locations downwind and downstream from the plant and at distant control locations upwind and upstream from the plant. A plant effect would be indicated if the radiation level at an indicator location was significantly larger than at the control location. The difference would also have to be greater than could be accounted for by typical fluctuations in radiation levels arising from other naturally-occurring sources.

Samples are collected from the aquatic and terrestrial pathways in the vicinity of CNS. The aquatic pathways include fish, Missouri River surface water, ground water, and shoreline sediment. The terrestrial pathways include airborne particulates, milk and food product garden (leaf) vegetation, and direct radiation. During 2007, analyses performed on collected samples of environmental media showed no significant or measurable radiological impact from CNS operations (NPPD, 2008a)

Aquatic sampling at CNS consists of semi-annual upstream and downstream collections of fish and shoreline sediments. All samples are analyzed for gamma-emitting isotopes. River water is collected monthly at two locations, one upstream of the plant and one downstream. Quarterly composites are analyzed for tritium. All results were below the required lower limit of detection (NPPD, 2008a).

Sediment samples collected during June and October 2007 were analyzed by gamma spectrometry. A number of naturally occurring radionuclides were detected in these samples. Naturally occurring potassium-40 and thorium-228 were observed in all samples. All other gamma emitters were below their detection limits (NPPD, 2008a).

Eight samples of fish were collected during the summer and fall of 2007. A middle-top feeding fish (carp) and a bottom feeding fish (catfish) were collected in June and October. These samples were analyzed by gamma ray spectroscopy. Only naturally occurring potassium-40 was detected (NPPD, 2008a).

According to the 2007 CNS REMP, 17 milk samples from the nearest producers were collected and analyzed by gamma ray spectroscopy and for low-level iodine-131 by radiochemical separation. Naturally occurring potassium-40 was measured in all samples. Naturally occurring thorium-228 was measured in one sample. All other gamma emitters were below their detection levels. Four milk samples were collected from other producers. Naturally occurring potassium-40 was detected in all four samples. All other gamma emitters were below their detection levels (NPPD, 2008a).

Ground water was collected from two stations quarterly and analyzed for tritium and for gamma emitting radionuclides. One station is located 0.15 mi from the plant and another station 25.8 mi from the plant. Naturally occurring potassium-40 was detected in 2 of 24 samples analyzed. Naturally occurring thorium-228 was detected in 2 of 24 samples analyzed. All other gamma emitters were below their detection levels.

Environmental Impacts of Operation

There were 26 broadleaf vegetation samples collected from June through September from three locations during 2007. The samples were analyzed by gamma ray spectroscopy and for low-level iodine-131 by radiochemical separation. Beryllium-7, which is produced continuously in the upper atmosphere by cosmic radiation, was measured in 24 of 26 samples analyzed. Naturally occurring potassium-40 was measured in all 26 samples analyzed. All other gamma emitters were below their detection levels (NPPD, 2008a).

The results of the CNS 2007 REMP sampling demonstrate that the routine operation at CNS has had no significant or measurable radiological impact on the environment. No elevated radiation levels were detected in the offsite environment as a result of plant operations and the storage of radioactive waste. The results of the REMP continue to demonstrate that the operation of CNS did not result in a significant measurable dose to a member of the general population or adversely impact the environment as a result of radiological effluents. The REMP continues to demonstrate that the dose to a member of the public from the operation of CNS remains significantly below the Federally required dose limits specified in 10 CFR Part 20, 10 CFR Part 50, and 40 CFR Part 190.

Based on recent monitoring results, concentrations of contaminants in native leafy vegetation, sediments, surface water, and fish in areas surrounding CNS have been quite low (at or near the threshold of detection) and seldom above background levels. Consequently, no disproportionately high and adverse human health impacts would be expected in special pathway receptor populations in the region as a result of subsistence consumption of fish and wildlife.

4.10 EVALUATION OF NEW AND POTENTIALLY SIGNIFICANT INFORMATION

New and significant information is: (1) information that identifies a significant environmental issue not covered in the GEIS and codified in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, or (2) information that was not considered in the analyses summarized in the GEIS and that leads to an impact finding that is different from the finding presented in the GEIS and codified in 10 CFR Part 51.

In preparing to submit its application to renew the CNS operating license, NPPD developed a process to ensure that information not addressed in or available during the GEIS evaluation regarding the environmental impacts of license renewal for CNS would be properly reviewed before submitting the ER, and to ensure that such new and potentially significant information would be identified, reviewed, and assessed during the NRC review period. NPPD reviewed the Category 1 issues that appear in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, to verify that the conclusions of the GEIS remained valid with respect to CNS. This review was performed by personnel from CNS and its support organization that were familiar with NEPA issues and the scientific disciplines involved in the preparation of a license renewal ER. The NRC also has a process for identifying new and significant information. That process is described in detail in NUREG-1555, Supplement 1, *Standard Review Plans for Environmental Reviews for Nuclear Power Plants, Supplement 1: Operating License Renewal* (NRC, 2000). The search for new information includes: (1) review of an applicant's ER and the process for discovering and evaluating the significance of new information; (2) review of records of public comments; (3) review of environmental quality standards and regulations; (4) coordination with Federal, State, and local environmental protection and resource agencies; and (5) review of the technical literature. New information discovered by the NRC staff is evaluated for significance using the criteria set forth in the GEIS. For Category 1 issues where new and significant information is identified, reconsideration of the conclusions for those issues is limited in scope to

the assessment of the relevant new and significant information; the scope of the assessment does not include other facets of the issue that are not affected by the new information.

The NRC staff has not identified any new and significant information on environmental issues listed in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, related to the operation of CNS during the period of license extension. The NRC staff also determined that information provided during the public comment period did not identify any new issues that require site-specific assessment. The NRC staff reviewed the discussion of environmental impacts in the GEIS (NRC, 1996) and conducted its own independent review (including the public scoping meetings held in February 2009) to identify new and significant information.

4.11 CUMULATIVE IMPACTS

The NRC staff considered potential cumulative impacts in the environmental analysis of continued operation of CNS. For the purposes of this analysis, past actions are those related to the resources at the time of the power plant licensing and construction. Present actions are those related to the resources at the time of current operation of the power plant, and future actions are considered to be those that are reasonably foreseeable through the end of plant operation including the period of extended operation. Therefore, the analysis considers potential impacts through the end of the current license terms as well as the 20-year renewal license term. The geographic area over which past, present, and future actions would occur is dependent on the type of action considered and is described below for each impact area.

The impacts of the proposed action, as described in Sections 4.1–4.9, are combined with other past, present, and reasonably foreseeable future actions regardless of what agency (Federal or non-Federal) or person undertakes such other actions.

4.11.1 Cumulative Impacts on Water Resources

The NRC staff divided the description and discussion of water resources in previous sections into ground water and surface water issues in order to follow the regulatory structure presented in 10 CFR Part 51 (2009). Hydrologic conditions at CNS and elsewhere within the Missouri River Valley, however, indicate a hydraulic connection between surface and ground water, particularly between the Missouri River and the alluvial aquifer underlying the valley. This connection reveals the possible impact of reduced river flow on ground water levels.

NPPD (2008a) reviewed well records and identified 1,400 registered wells within the Nemaha River Basin, which includes the Missouri River below its confluence with the Platte River. Of the wells identified, very few are close to CNS. The NGPC installed three wells about 1.5 mi (2.4 km) south of CNS, and the city of Auburn, Nebraska, has a public water supply well about 1.9 mi (3 km) south. NPPD (2008a) also identified some local shallow farm wells within 2 mi (3.2 km) of the plant property. All of the water supply wells in the area are completed either in the Missouri River Valley Aquifer or Glacial Drift Aquifer, which are under unconfined conditions and in hydraulic contact with the Missouri River.

Enercon conducted an operations study of the CNS potable wells which showed an equilibrium radius of influence of between 100 to 1,250 ft (46 to 381 meters (m)) from each well. Enercon's analysis of the drawdown data from the study indicated the radius of influence of CNS's wells does not extend outside the CNS property boundary. Because all the CNS wells are in hydraulic connection with the Missouri River, recharge from the river is likely induced by pumping operations. The total maximum pumping rate at CNS of over 1,500 gpm (5,678 liters per minute)

Environmental Impacts of Operation

is less than 1 percent of the average flow in the river. Likewise, the influence of offsite pumping should have no measurable effect on ground water levels onsite. Because the cumulative effects of pumping ground water on river flow and vice versa are insignificant, the cumulative impact on water resources in the CNS area is SMALL.

4.11.2 Cumulative Impacts on Electromagnetic Fields and Thermophilic Microbiological Organisms

The continued operation of CNS has a low risk of causing outbreaks from thermophilic microbiological organisms associated with thermal discharges. Available data compiled by the CDC into biannual reports for the years 1999 to 2006 (CDC, 2000), (CDC, 2002), (CDC, 2004), (CDC, 2006) indicates no occurrence of the waterborne disease outbreaks in the State of Nebraska resulting from exposure to the thermophilic microbiological organisms *Naegleria fowleri* and *Pseudomonas aeruginosa* due to the operation of CNS.

As part of its evaluation of cumulative impacts, the NRC staff also considered the effects of thermal discharges from other facilities on the Missouri River, located within 1 mi upstream of CNS, that are also producing thermal effluents. Such facilities could promote the growth of thermophilic microbiological organisms. The NRC staff did not find any such facilities.

Potential cumulative effects of climate change on the Missouri River basin and local climate, whether or not from natural cycles or anthropogenic activities, could result in a variety of changes to the surface and ground water resources in the Missouri River basin. Nebraska is a part of the Great Plains Region. As projected in the "Global Climate Change Impacts in the United States" report by the USGCRP (2009), the temperatures in southeastern Nebraska, where CNS is located, are expected to rise 6°F (-14°C) by 2080–2099 at minimum and maximum over 10°F (5.6°C), causing more frequent extreme weather events. Increases in average annual temperatures, higher probabilities of extreme heat events, and higher occurrences of extreme rainfall (intense rainfall or drought) could increase Missouri River temperatures and cause degradation of the water supply and its quality. Such conditions could support the proliferation of pathogenic organisms of concern and affect the burden of water-related diseases. The extent and the magnitude of the climate change on human health could be significant (IPCC, 2009).

The NRC staff concludes that the thermophilic microbiological organisms are not likely to present a public health hazard as a result of CNS discharges to the Missouri River. The NRC staff concludes that the cumulative impacts on public health from thermophilic microbiological organisms from continued operation of CNS during the license renewal period would be SMALL.

The NRC staff determined that the CNS transmission lines are operating within original design specifications and meet current NESC clearance standards; therefore, the CNS transmission lines do not detectably affect the overall potential for electric shock from induced currents within the analysis area. With respect to the chronic effects of electromagnetic fields, although the GEIS finding of "not applicable" is appropriate to CNS, the transmission lines associated with CNS are not likely to detectably contribute to the regional exposure to extremely low frequency electromagnetic fields. Therefore, the NRC staff has determined that the cumulative impacts of continued operation of the CNS transmission lines would be SMALL.

4.11.3 Cumulative Impacts on Aquatic Resources

This section addresses the direct and indirect effects of license renewal when added to the aggregate effects of past, present, and reasonably foreseeable future actions (CEQ, 2005). The direct effects on aquatic resources from an additional 20 years of CNS operation accrue primarily from impingement, entrainment, and heat shock to natural populations and the populations on which they depend through predator-prey, competitive, and other interactions. The cumulative impact is the total effect on the aquatic resources of all actions taken, no matter who has taken the actions (the second principle of cumulative effects analysis in CEQ, 1997). The geographic boundary for assessing cumulative aquatic impacts is somewhat variable and depends on the specific resource, but is generally the lower biological zone of the Missouri River, which extends from Gavins Point Dam to the confluence with the Mississippi River (Galat et al., 2005a), (Galat et al., 2005b).

The benchmark for assessing cumulative impacts on aquatic resources takes into account the pre-operational environment as recommended by the EPA (1999) for its review of NEPA documents:

Designating existing environmental conditions as a benchmark may focus the environmental impact assessment too narrowly, overlooking cumulative impacts of past and present actions or limiting assessment to the proposed action and future actions. For example, if the current environmental condition were to serve as the condition for assessing the impacts of relicensing a dam, the analysis would only identify the marginal environmental changes between the continued operation of the dam and the existing degraded state of the environment. In this hypothetical case, the affected environment has been seriously degraded for more than 50 years with accompanying declines in flows, reductions in fish stocks, habitat loss, and disruption of hydrologic functions. If the assessment took into account the full extent of continued impacts, the significance of the continued operation would more accurately express the state of the environment and thereby better predict the consequences of relicensing the dam.

Section 2.2.5 presents an overview of the condition of the Missouri River ecosystem and the history and factors that led to its condition. At present, the Missouri River is a degraded ecosystem that the National Research Council (NRCC) (2002) has said may be close to or perhaps past the point of irreparable change. To determine and illustrate the environmental changes that affect resources in cumulative impact analysis, CEQ (1997) recommends a conceptual model. We present a simple conceptual model for the Missouri River ecosystem in Figure 2.2.5-1 that shows how some environmental factors affect aquatic resources.

The NRCC (2002) identified the following man-induced changes in the Missouri River ecosystem that jeopardize its fundamental natural processes, "the loss of natural flood pulses; the loss of natural low flows; straightening of stream meanders and the elimination of cut-and-fill alluviation; losses of natural riparian vegetation; reductions in water temperature variation; introduction of nonnative species; and extensive bank stabilization and stream channelization." These changes are due to activities like dam construction that alter flow and water temperature patterns, amplitude and frequency of natural peak flows used by some species as environmental cues for biological processes, and sediment transport and deposition. Land use changes, channelization, and construction of levees and dikes have altered almost 3 million acres of natural riverine and floodplain habitat. These changes, and more, influence primary productivity and the energy sources for aquatic communities, alter or eliminate natural habitat and habitat diversity required to support some species, and change invertebrate communities

Environmental Impacts of Operation

and food webs to fish. The NRCC (2002) found that, "Of the 67 native fish species living along the mainstream, 51 are now listed as rare, uncommon, or decreasing across all or part of their ranges" and that one of these fish, the pallid sturgeon, is on the Federal Endangered Species List.

In addition to these historic impacts, this section focuses on other facilities that withdraw Missouri River water and introduced species. CNS directly affects Missouri River aquatic communities primarily through impingement, entrainment, and heat shock. Other facilities that withdraw water also impact aquatic communities through at least impingement and entrainment, and for some, also heat shock. The impact of introduction and stocking of native and introduced fish species is also somewhat similar to the impact of CNS, because the effect of a power plant that impinges and entrains aquatic organisms is somewhat similar to that of a large predator introduced into an aquatic system.

The number of consumptive and non-consumptive intakes that withdraw water from the Missouri River is relatively large (Table 4-8). The cumulative stress from this large number of intakes, of which CNS is one, spread across the length of the river depends on many factors that the NRC staff cannot quantify, but which may be significant when added to all the other stresses on aquatic communities.

The States have stocked and released a number of native and introduced game fish into the Missouri River, primarily for sport fishing. Game fish tend to be predators, which may, through predation, affect aquatic communities in a manner somewhat similar to impingement and entrainment. For example, Nelson-Statny (2004) compiled a list of selected introduced and native fish species stocked or released into the Missouri River in South Dakota in relation to their potential as predators of pallid sturgeon (Table 4-9). That author notes that:

South Dakota made several stocking attempts with other fish species to try to utilize the newly created reservoir habitat in the South Dakota portion of the Missouri River. The fish species that were previously stocked, but for which stocking was eventually discontinued, include lake whitefish (*Coregonus clupeaformis*), sockeye salmon/kokanee (*Oncorhynchus nerka*), cutthroat trout (*Oncorhynchus clarki*), lake trout (*Salvelinus namaycush*), Bonneville cisco (*Prosopium gemmiferu*), muskellunge (*Esox masquinongy*), and tiger muskellunge (*Esox lucius x masquinongy*). Of these, only lake whitefish and tiger muskellunge are occasionally sampled either by anglers or in fish population surveys and these fish are believed to be from original stocking events (i.e., large adults).

This example is from just one of the States in the Missouri River basin. As with water intakes, the cumulative stress from all these introductions spread across the length of the river depends on many factors, which the NRC staff cannot quantify but which may be significant when added to all the other stresses on aquatic communities.

While the level of impact due to direct and indirect impacts of CNS on aquatic communities is SMALL, the cumulative impact when combined with all other sources has resulted in the Missouri River aquatic ecosystem being unstable and has resulted in a LARGE level of impact.

Table 4-8. Intakes. Number of consumptive and non-consumptive water intakes that withdraw water from the Missouri River.

Reach	Lower Boundary (RM)	Number of Intakes By Location						Total Intakes
		Intakes						
		Power	Municipal	Industrial	Irrigation	Domestic	Public	
Fort Peck Lake	1,771.60		1		5	101	2	109
Fort Peck	1,547.10		5 (1)	4	283 (94)	162 (14)	1	455 (109)
Lake Sakakawea	1,389.90	1	10 (5)	6 (1)	44 (10)	228 (63)	11	300 (79)
Garrison	1,317.40	6	3	6	77	28	3	123
Lake Oahe	1,072.30		8 (3)	2	179 (12)	21 (6)	8 (2)	218 (23)
Oahe	1,072.20							0
Lake Sharpe	987.40		3 (2)		91 (71)	19 (4)	2	115 (77)
Big Bend	987.30							0
Lake Francis Case	841.80		6		72	4	3	85
Fort Randall	836.10				8 (4)			8 (4)
Lewis and Clark Lake	811.10		2		27 (5)	6	2 (2)	37 (7)
Gavins Point	734.20		1		33	7	1	42
Sioux City	648.00	2	2	1	42 (3)		2	49 (3)
Omaha	597.20	3	2	1	8	2	5	21
Nebraska City	497.40	2			22	1		25
St. Joseph	374.00	3	4				2	9
Kansas City	249.90	5	4				1	10
Boonville	129.90		3				1	4
Hermann	0.00	3	3					6
Total		25	57 (11)	20 (1)	891 (199)	579 (87)	44 (4)	1,616 (302)
Above Gavins Point		7	38 (11)	18 (1)	786 (196)	569 (87)	32 (4)	
Below Gavins Point		18	19	2	105 (3)	10	12	

Numbers in parentheses refer to intakes located on reservation land.

Source: USACE, 2004a, page 3-112

Table 4-9. Stastny 2004. Native and introduced fish species stocked in South Dakota into the Missouri River system that are potential predators of pallid sturgeon. Species in this table were actively managed via stocking or other means in 2004 or had their status, whether native or nonnative, brought into question by others in litigation.

Species Name	Common Name	Origin	Stocking Status	Years Stocked in Missouri River in South Dakota
<i>Oncorhynchus mykiss</i>	rainbow trout	I	EFS	1951, 56, 57, 64, 68, 69, 1972-2003
<i>Oncorhynchus tshawytscha</i>	Chinook salmon	I	EFS	1982-2000, 2003
<i>Salmo trutt</i>	brown trout	I	EFS	1964, 68, 79, 1981-2003
<i>Morone chrysops</i>	white bass	I	EPD	1960-62
<i>Coregonus artedi</i>	lake herring	I	EPD	1984, 88, 90-92
<i>Polyodon spathula</i>	paddlefish	N	NSA*	1974, 76-78, 1985-2003
<i>Osmerus mordax</i>	rainbow smelt	I	EPD**	-
<i>Notropis hudsonius</i>	spottail shiner	I	EPD	1973-75, 78, 79
<i>Micropterus dolomieu</i>	smallmouth bass	I	EPD	1972, 74, 80, 83-92, 94-98
<i>Esox lucius</i>	northern pike	PN, N	NSA	1957, 58, 71, 82, 83, 85, 86, 88-97
<i>Perca flavescens</i>	yellow perch	PN, N	NSA	-
<i>Sander vitreum</i>	walleye	N	NSA	1952, 53, 57, 58, 83-98, 2002

Table adapted from Nelson-Stastny (2004, Table 1)

*Paddlefish stocking in the last decade has only been in the Lake Francis Case. An adult population exists in the Lake Francis Case; however, natural reproduction has not been documented.

** Rainbow smelt in the South Dakota portion of the Missouri River originated from fish stocked in Lake Sakakawea in North Dakota.

Origin as a native (N), introduced (I), or probable native (PN).

Stocking status refers to one of the following:

Established sport fishery – stocking required to maintain (EFS)

Established population – stocking discontinued (EPD)

Native – if stocked, additive to natural reproduction (NSA)

4.11.4 Cumulative Impacts on Terrestrial Resources

This section addresses past, present, and future actions that could result in adverse cumulative impacts to terrestrial resources, including wildlife populations, upland habitats, wetlands, riparian zones, invasive species, protected species, and land use. For purposes of this analysis, the geographic area considered in the evaluation includes the CNS site, including the land on both the Nebraska and the Missouri sides of the Missouri River, the wetlands on and in the vicinity of the CNS site, and the 145-mi long (233-km) transmission line corridor identified in Section 2.1.5 of this report.

Prior to construction of the CNS facilities and before its conversion to cropland, the region surrounding the CNS property in Nemaha County, Nebraska, and Atchison County, Missouri, was historically part of a dynamic Missouri River floodplain system, located within the Missouri alluvial plain ecoregion (USGS, 2001). Historically, the Missouri River meandered across the width of this relatively flat, 6-mi (10-km) wide alluvial floodplain along the border of eastern

Nebraska and western Missouri. The CNS facilities are located near the western edge of this floodplain and adjacent to the western bank of the Missouri River. The vegetation within this floodplain and its vicinity was historically dominated by tallgrass prairie and wooded wetlands along the riparian corridors (NGPC, 2005). Before the completion in 1950 of the Federal levee system along the Missouri River, most of the Missouri River floodplain was subjected to frequent overbank flooding and much soil deposition occurred over the entire width of the floodplain (NPPD, 2008a), (USGS, 2001). Wooded wetlands dominate the 239 ac of CNS property on the Missouri side of the property, both today and prior to conversion of approximately 40 ac of the property to agriculture (NPPD, 2008a). The Missouri CNS property is also part of the Missouri alluvial plain ecoregion and much of the wooded wetland habitat historically flooded and continues to experience overbank flooding from the Missouri River (USGS, 2001).

Historically, over 70 percent of the land encompassing the 145-mi long (233-km) transmission line corridor was comprised primarily of prairie grasses of the tallgrass prairie ecoregion (NPPD, 2008a), (NGPC, 2005). The remaining 30 percent of the land traversed by the transmission line corridor was historically comprised of numerous narrow stream valleys with woody vegetation and shallow intermittent streams with small pockets of wetlands (NPPD, 2008a). The western half of the transmission line corridor traverses the Rainwater Basin Plains and historically contained the largest concentrations of natural wetlands found in Nebraska. Most of these wetlands have now been drained and converted to cropland and the historic prairie grass regions in the counties surrounding the transmission line corridor have likewise been converted to cropland (NGPC, 2005), (USGS, 2001). Most of the noted stream valleys were too steep or too saturated to allow agriculture and still remain vegetated.

Currently, over 97 percent of the land in Nemaha County, Nebraska, is used for agriculture. In the adjacent Richardson County and Otoe County in Nebraska, and Atchison County in Missouri, over 90 percent of the land on average is used for agriculture. Very little residential, commercial, or industrial development has occurred in the counties surrounding the CNS site, and cumulative impacts from such types of development are considered minor.

Current land use on the Nebraska CNS property outside of the actual power plant facilities reflects the regional agricultural use. Approximately 900 ac (364 hectares (ha)) of the 1,120-ac (453-ha) CNS site is used for agriculture (NPPD, 2008a). Much of the 55 ac (22 ha) of land where the CNS facilities have been constructed was cropland prior to construction of the facility, so disturbance to wildlife habitat had occurred prior to construction of CNS. Construction on some of the CNS facility led to the loss of riparian habitat along the shoreline, as well as the loss of some wetlands habitat, which may have impacted wildlife habitat and water quality. NPPD was recently required by the USACE to restore approximately 1.5 ac (0.6 ha) of disturbed wetlands habitat on a 55-ac (22-ha) parcel of ground as mitigation for NPPD filling in other disturbed wetlands for construction of CNS parking facilities.

Surface water drainage patterns have changed on the Nebraska CNS property as a result of construction of the Federal levee system and from construction of the CNS facility. A dike and ditch system was created on the Nebraska side of the CNS site during initial construction of the facilities to protect them from flooding events of the Missouri River (NPPD, 2008a). Over 120 ac (49 ha) of the CNS site on the Nebraska side contain wooded, scrub-shrub, and emergent wetlands, riparian habitat along the Missouri River, and several small intermittent streams (NPPD, 2008a). Construction of the ditch, dike, and levee systems on the CNS site have in some cases led to additional flooding on portions of the farm fields, forested areas, and these wetland areas. The intermittent streams and some surface water drains south into the adjacent

Environmental Impacts of Operation

USACE Langdon Bend Wetlands Restoration Project, which may benefit wetlands restoration on the USACE site (NDNR, 2009) (USACE, 2004b).

Approximately 40 ac (16 ha) of the 239-ac (97-ha) CNS property on the Missouri side are cropland, and the remaining acres are primarily wooded wetlands. Two transmission line corridors that are not in scope cut through this land and contain emergent vegetation. The Federal levee is located along the eastern border of this land, and reduces the threat of flooding of the farm fields beyond the CNS property while retaining more water on the CNS property. This CNS property is still subject to occasional overbank flooding, as evidenced by water marks located several feet up on the trunks of trees. Thus, some flooding events on this land may be similar in degree of inundation to historic flooding events, helping to maintain this area as a bottomland hardwood, forested wetland. A conservation deed restriction has been placed upon the 239 ac of land located on the Missouri side of the river to provide for long-term protection of this land from any development as well as agricultural production. A pair of bald eagles has been actively nesting on this property for the past several years (NPPD, 2008a).

Several exotic invasive plant species are located along the riverbank or in the vicinity of the CNS site, and include purple loosestrife (*Lythrum salicaria*), reed canary grass (*Phalaris arundinacea*), and the common reed (*Phragmites australis*) (NRCS, 2007), (NDA, 2008). NPPD does not manage invasive vegetative species on the CNS site; therefore, a potential exists for these invasive species to increase in population on the CNS site and compete with native vegetation for resources and degrade areas of terrestrial habitat. Invasive species may also be introduced on the associated transmission line ROW, with potentially similar impacts.

The land traversed by the transmission line corridor and most of the land in the surrounding counties has been converted primarily from prairie grasses to cropland. There is currently less than 2 percent remaining of the historic prairie grass habitat in Nebraska (NGPC, 2005), (USGS, 2001). Conversion from prairie grassland to cropland will affect wildlife species composition and behavior, and may have a cumulative adverse impact on nutrient discharges into the Missouri River and its tributaries. Farming occurs under the transmission lines and immediately adjacent to the transmission line poles, so little land is lost from agricultural production. Most of the narrow stream valleys now traversed by the transmission line corridor remain as vegetated riparian corridors annually maintained by NPPD, primarily as scrub-shrub wooded areas (NPPD, 2008a). ROW maintenance of these riparian corridors has likely had some minor impacts in the past and is likely to have present and future impacts on these areas from their conversion from primarily forested riparian communities to scrub-shrub riparian communities; however, any future maintenance activities are estimated to be minor based on NPPD's plan to conduct only necessary clearing to prevent obstruction of the lines.

NPPD has consulted with the USFWS to address the potential risk of bird collisions with NPPD transmission line NPPD TL3502 which crosses the Platte River near the end of the CNS transmission line corridor, approximately 4 mi (6 km) east of Grand Island, Nebraska. The Federally-endangered whooping crane (*Grus americana*) and interior least tern (*Sterna antillarum athalassos*), and the Federally-threatened piping plover (*Charadrius melodus*) use the Platte River and associated wetlands around Grand Island for different portions of their life cycle (e.g., for migration, resting, feeding, and nesting) and risk collisions with the NPPD transmission line. The USFWS has indicated that collisions with transmission lines are the main cause of whooping crane mortality during their migrations (USFWS, 2009a); however, there are no data to indicate that transmission line NPPD TL3502 has caused any injury or mortality to whooping cranes, least terns, piping plovers, or to other species of Federally-protected migratory birds where the transmission line crosses the Platte River. On May 8, 2009, the NPPD informed the

USFWS that NPPD had agreed to mark that portion of the NPPD transmission line that crosses the Platte River with bird flight diverters to increase the visibility of the transmission line and reduce the risk of collisions (NPPD, 2009b). The USFWS replied to NPPD on June 8, 2009, informing them that NPPD had satisfactorily addressed the concerns of the USFWS regarding bird collisions (USFWS, 2009b). This voluntary mitigation measure by NPPD will help to reduce current and future potential impacts to whooping cranes, interior least terns, piping plovers, and other migratory birds that use the Platte River and associated wetlands of the Rainwater Basin Wetland Management District (USFWS, 2009c).

The Missouri River ecosystem has been dramatically transformed since the beginning of the 20th century. Historically, the Missouri River was free-flowing with regular overbank flooding along its entire length, and the channel meandered across the entire floodplain. The construction of seven dams upriver from CNS, bank stabilization, channelization of the river for improved navigation by barge traffic, and a levee and dike system constructed along most of the entire length of the floodplain have led to significant changes to the terrestrial habitat of the ecosystem. There has also been a reduction of the amount and type of deciduous vegetation, grasslands, and wetlands present within the floodplain. Within the Missouri River itself, there has also been a reduction in the number of river islands (89 percent), a reduction in the surface area of these islands (98 percent), and a reduction in the number of sandbars (97 percent) along the river (NPPD, 2008a). With the implementation of Federal aquatic and terrestrial habitat restoration projects along the entire Missouri River ecosystem and the adjacent USACE Langdon Bend Wetlands Restoration Project, restoration of Missouri River terrestrial habitat is beginning to improve ecological conditions from their current state (USACE, 2004b).

Agriculture continues to be the overwhelming dominant land use in the region and with a declining human population in Nemaha County, additional impacts from new residential, commercial, or industrial development are not anticipated to increase terrestrial impacts. Continued runoff of nutrients from agricultural fields and bioaccumulation of pesticides or herbicides poses a threat to terrestrial and riparian habitats as well as to wildlife species; however, the Federal wetlands mitigation projects discussed above and in Section 2.2.6 will help to reduce impacts to both the aquatic and terrestrial environment.

The NRC staff concludes that the minimal terrestrial impacts expected from the continued CNS operations, including the operation and maintenance of the 145-mi (233-km) long transmission line corridor, would not contribute to the overall decline in the condition of terrestrial resources; however, while the level of impact due to direct and indirect impacts of CNS on terrestrial communities is SMALL, the cumulative impact when combined with all other sources, even if CNS was excluded, would be MODERATE.

4.11.5 Cumulative Air Quality Impacts

CNS is located in Nemaha County, Nebraska, which belongs to EPA Region 7. There are no counties designated by the EPA as nonattainment or maintenance counties for any of the criteria pollutants in the 50-mi (81-km) vicinity of CNS. Douglas County, Nebraska, located approximately 72 mi (116 km) from CNS, is the closest maintenance county for lead.

As discussed in Section 2.2.2.1, "Air Quality Impacts," the Nebraska Division of Air Quality of the NDEQ has primary responsibility for regulating air emission sources within the State of Nebraska, and with the assistance from Lincoln-Lancaster County Health Department and Douglas County Health Department, the NDEQ conducts ambient air monitoring in the State, operating 28 sites throughout the State with 34 monitors. The EPA and National Atmospheric

Environmental Impacts of Operation

Deposition Program also monitor air quality in Nebraska, which participates in the EPA's AIRNow Network which continuously monitors some of the criteria pollutants and informs the public of the current environmental conditions.

In April 2009, the EPA published the official U.S. inventory of the greenhouse gas (GHG) emissions that identifies and quantifies the primary anthropogenic sources and sinks of GHG. The EPA GHG inventory is an essential tool for addressing climate change and participating with the United Nations Framework Convention on Climate Change to compare the relative global contribution of different emission sources and GHGs to climate change. The EPA estimates that energy-related activities in the United States account for three-quarters of human-generated GHG emissions, mostly in the form of carbon dioxide emissions from burning fossil fuels. More than half of the energy-related emissions come from major stationary sources like power plants, and approximately one-third comes from transportation. Industrial processes (production of cement, steel, and aluminum), agriculture, forestry, other land use, and waste management are also important sources of GHG emissions in the United States (EPA, 2009a).

Potential cumulative effects of climate change in southeastern Nebraska, where CNS is located, and local climate, whether or not from natural cycles or anthropogenic activities, could result in a variety of changes to the air quality of the area. Nebraska is a part of the Great Plains Region. As projected in the "Global Climate Change Impacts in the United States" report by USGCRP (2009), the temperatures in southeastern Nebraska are expected to rise 6°F (°C) by 2080–2099 at minimum and maximum over 10°F (5°C), causing more frequent extreme weather events. Increases in average annual temperatures, higher probabilities of extreme heat events, higher occurrences of extreme rainfall (intense rainfall or drought), and changes in the wind patterns could affect concentrations of the air pollutants and their long-range transport because their formation partially depends on the temperature and humidity, and is a result of the interactions between hourly changes in the physical and dynamic properties of the atmosphere, atmospheric circulation features, wind, topography, and energy use (IPCC, 2009).

Nebraska is a participant of the Western Governors Association (WGA) that encourages the participating regions to use their diverse resources for the production of affordable, sustainable, and environmentally responsible energy. Nebraska is also a part of the WGA Western Regional Air Partnership which established a multi-State and Tribal GHG registry and developed the GHG emissions inventories.

As discussed in Section 2.1.3, "Nonradiological Waste Management," NPPD is committed to the EPA's Reduce, Reuse, Recycle program at its major and minor facilities, with a growing Green Team, that focuses on pollution prevention, waste minimization, education and training of the personnel, and incorporates EPA recommendations on the national implementation of the climate change energy conservation techniques (EPA, 2009b).

In the 2008 Integrated Resource Plan, NPPD outlined the environmental goals of the company with emphasis on lowering GHG emissions and obtaining 10 percent of the energy supply from renewable resources by 2020 (NPPD, 2008a).

CNS is exempt from the NDEQ operating permit requirements and holds a Low Emitter Status from NDEQ, based on the CNS actual quantities of emissions that meet criteria and do not exceed thresholds, defined in Chapter 5, Title 129 of the Nebraska Administrative Code, for the emissions of particulate matter, 10 microns or less in diameter (PM₁₀); carbon monoxide (CO); volatile organic compounds (VOCs); oxides of nitrogen (NO_x); sulfur dioxide (SO₂), sulfur trioxide (SO₃), or any combination of the two (SO_x); a single Hazardous Air Pollutant (HAP) or

HAPs; and lead. As discussed in Section 2.2.2.1, "Air Quality Impacts," actual total emissions from all sources at CNS for the period from 2004–2008 were 11.52 tons (10.45 metric tonnes (MT)) per year, 10.73 tons (9.73 MT) per year, 13.21 tons (11.98 MT) per year, 11.43 tons (10.37 MT) per year and 9.85 tons (8.94 MT) per year, respectively. Highest emissions for the period from 2004–2008 were reported in 2006: 0.16 tons (0.15 MT) per year of PM₁₀, 2.41 tons (2.19 MT) per year of CO, 0.22 tons (0.20 MT) per year of VOC, 9.0 tons (8.16 MT) per year of NO_x, 1.41 tons (1.28 MT) per year of SO_x, and 0.01 tons (0.009 MT) per year of a single HAP (NPPD, 2009b).

NPPD stated in the ER (NPPD, 2008a), and the NRC staff confirmed, that no refurbishment is planned at CNS during the license renewal period.

Based on all of the above, the staff concludes that combined with the emissions from other past, present, and reasonably foreseeable future actions, cumulative hazardous and criteria air pollutant emissions on air quality from CNS related actions would be SMALL.

4.11.6 Cumulative Human Health Impacts

The NRC and the EPA developed radiological dose limits for protection of the public and workers to address the cumulative impact of acute and long-term exposure to radiation and radioactive material. These dose limits are codified in 10 CFR Part 20 and 40 CFR Part 190. This analysis includes the area within a 50-mi (80-km) radius of the CNS site. The REMP conducted by NPPD in the vicinity of the CNS site measures the cumulative impact of radiation and radioactive materials from all sources.

As discussed in Section 4.8.1 of this report, the staff reviewed the radiological environmental radiation monitoring results for the 5-year period from 2003–2007 as part of the cumulative impacts assessment. Cumulative radiological impacts from all uranium fuel cycle facilities within a 50-mi (80-km) radius of the CNS site are limited by the dose limits codified in 10 CFR Part 20 and 40 CFR Part 190. In Section 4.8 of this report, the NRC staff concluded that the impacts of radiation exposure to the public from the operation of CNS during the renewal term would be SMALL. The NRC and the EPA will regulate any future actions in the vicinity of the CNS site that could contribute to cumulative radiological impacts; therefore, the NRC concludes that the cumulative impacts from continued operations of CNS would be SMALL.

4.11.7 Cumulative Socioeconomic Impacts

As discussed in Section 4.4, continued operation of CNS during the license renewal term would have no impact on socioeconomic conditions in the region beyond those already experienced. Since NPPD has no plans to hire additional workers during the license renewal term, overall expenditures and employment levels at CNS would remain relatively constant with no additional demand for permanent housing and public services. In addition, since employment levels and tax payments would not change, there would be no population or tax revenue-related land use impacts. There would also be no disproportionately high and adverse health and environmental impacts on minority and low-income populations in the region. Based on this and other information presented in this chapter, there would be no cumulative socioeconomic impacts from the continued operation of CNS during the license renewal term beyond what is currently being experienced.

Environmental Impacts of Operation

Any ground disturbing activities during the license renewal term, however, could result in the cumulative loss of historic and archaeological resources. Historic and archaeological resources are non-renewable; therefore, the loss of archaeological resources is cumulative. The continued operation of CNS during the license renewal term has the potential to impact unknown historic and archaeological resources.

As discussed in Section 4.9.6, continued operation of CNS during the license renewal term would have a SMALL impact on archaeological resources at the CNS site. NPPD has no plans to alter the CNS site for license renewal. Any future land disturbing activities would be carried out under corporate procedures. Should plans change, further consultation would be initiated by the NRC with the SHPO to evaluate if existing procedures at NPPD remain adequate to protect historic and archaeological resources. Because impacts to historic and archaeological resources from the continued operation of CNS would be SMALL, the cumulative environmental impacts to historic and archaeological resources would be SMALL.

4.11.8 Summary of Cumulative Impacts

The NRC staff considered the potential impacts resulting from the operation of CNS during the period of extended operation and other past, present, and future actions in the vicinity of CNS. The determination is that the potential cumulative impacts resulting from CNS operation combined with other actions during the period of extended operation would be SMALL to LARGE.

Table 4-10. Summary of Cumulative Impacts on Resources Areas

Resource Area	Impact	Discussion
Water Resources	SMALL	The total maximum pumping rate at CNS of over 1,500 gpm (5,678 liters per minute) is less than 1 percent of the average flow in the river. Likewise, the influence of offsite pumping should have no measurable effect on ground water levels onsite. Because the cumulative effects of pumping ground water on river flow and vice versa are insignificant, the cumulative impact on water resources in the CNS area is SMALL.
Aquatic Resources	LARGE	While the level of impact due to direct and indirect impacts of CNS on aquatic communities is SMALL, the cumulative impact when combined with all other sources has resulted in the Missouri River aquatic ecosystem being unstable and close to, if not past, the point of reparable change. This condition meets the NRC's definition of a LARGE level of impact.

Environmental Impacts of Operation

Resource Area	Impact	Discussion
Terrestrial Resources	MODERATE	Agriculture continues to be the overwhelming dominant land use in the region, and with a declining human population in Nemaha County, additional impacts from new residential, commercial, or industrial development are not anticipated to increase terrestrial impacts. Continued runoff of nutrients from agricultural fields and bioaccumulation of pesticides or herbicides poses a threat to terrestrial and riparian habitats, as well as to wildlife species. However, the Federal wetlands mitigation projects discussed above and in Section 2.2.6 will help to reduce impacts to terrestrial resources. The minimal terrestrial impacts expected from the continued CNS operations, including the operation and maintenance of the transmission line corridor, would not contribute to the overall decline in the condition of terrestrial resources. The cumulative impacts on terrestrial, including non-CNS activities, would be MODERATE.
Air Quality	SMALL	CNS holds a Low Emitter Status from NDEQ, based on the CNS actual quantities of emissions that meet criteria and do not exceed thresholds. The NRC staff concludes that the minimal air quality impacts expected from the continued CNS operation would not destabilize the air quality in the vicinity of CNS; therefore, the NRC staff concludes that the cumulative impacts on the air quality from the continued operation of CNS during the license renewal period would be SMALL.
Socioeconomics	SMALL	In Section 4.8 of this report, the NRC staff concluded that the impacts of radiation exposure to the public from the operation of CNS during the renewal term would be SMALL. The NRC and the EPA will regulate any future actions in the vicinity of the CNS site that could contribute to cumulative radiological impacts; therefore, the NRC concludes that the cumulative impacts from continued operations of CNS would be SMALL.
Human Health	SMALL	Cumulative radiological impacts from all uranium fuel cycle facilities within a 50-mi (80-km) radius of the CNS site are limited by the dose limits codified in 10 CFR Part 20 and 40 CFR Part 190. In Section 4.8 of this report, the staff concluded that the impacts of radiation exposure to the public from the operation of CNS during the renewal term would be SMALL. The NRC and the State of Nebraska will regulate any future actions in the vicinity of the CNS site that could contribute to cumulative radiological impacts; therefore, the NRC concludes that the cumulative impacts from continued operations of CNS would be SMALL.
Archaeological Resources	SMALL	NPPD has no plans to alter the CNS site for license renewal. Any future land disturbing activities would be carried out under corporate procedures. Archaeological surveys would be conducted in areas identified as archaeologically sensitive prior to any ground disturbing activities. Should plans change, further consultation would be initiated by NPPD with the NRC, NSHS, and Missouri SHPO. Because impacts to historic and archaeological resources from the continued operation of CNS would be SMALL, the cumulative environmental impacts to historic and archaeological resources would be SMALL.

Environmental Impacts of Operation

Resource Area	Impact	Discussion
Electromagnetic Fields and Thermophilic Microbiological Organisms	SMALL	The NRC staff concludes that the thermophilic microbiological organisms are not likely to present a public health hazard as a result of CNS discharges to the Missouri River. Therefore, the cumulative impacts on public health from thermophilic microbiological organisms from continued operation of CNS during the license renewal period would be SMALL. The NRC staff determined that the CNS transmission lines are operating within original design specifications and meet current NESC clearance standards; therefore, the CNS transmission lines do not detectably affect the overall potential for electric shock from induced currents within the analysis area. With respect to the chronic effects of EMFs, although the GEIS finding of "not applicable" is appropriate to CNS, the transmission lines associated with CNS are not likely to detectably contribute to the regional exposure of extremely low frequency-electromagnetic fields (ELF-EMFs); therefore, the NRC staff has determined that the cumulative impacts of the continued operation of the CNS transmission lines would be SMALL.

4.12 REFERENCES

10 CFR Part 20. *Code of Federal Regulations*, Title 10, *Energy*, Part 20, "Standards for Protection Against Radiation."

10 CFR Part 50. *Code of Federal Regulations*, Title 10, *Energy*, Part 50, "Domestic Licensing of Production and Utilization Facilities."

10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions."

36 CFR Part 800. *Code of Federal Regulations*, Title 36, *Parks, Forests, and Public Property*, Part 800, "Protection of Historic Properties."

40 CFR Part 190. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 190, "Environmental Radiation Protection Standards for Nuclear Power Operations."

Advisory Council on Historic Preservation (ACHP). 2009. "National Register Evaluation Criteria." Available URL: <http://www.achp.gov/nrcriteria.html> (accessed on May 4, 2009).

Carter, S.R., K.R. Bazata, and D.L. Anderson (Carter et al.). 1982. "Chapter 7: Macroinvertebrate communities of the channelized Missouri River near Two Nuclear Power Stations," in Hesse, L.W., G.L. Hergenrader, H.S. Lewis, S.D. Reetz, and A.B. Schlesinger (eds.), *The Middle Missouri River: A Collection of Papers on the Biology with Special Reference to Power Station Effects*, The Missouri River Group, Norfolk, Nebraska, pp. 146–182.

Center for Disease Control and Prevention (CDC). 2000. "Surveillance for Waterborne Disease and Outbreaks Associated with Recreational Water Use and Other Aquatic Facility-Associated Health Events --- United States, 1999–2000." Available URL: <http://www.cdc.gov/mmwr/preview/mmwrhtml/ss5108a1.htm#tab6> (accessed May 2009).

Center for Disease Control and Prevention (CDC). 2002. "Surveillance for Waterborne Disease and Outbreaks Associated with Recreational Water Use and Other Aquatic Facility-Associated Health Events --- United States, 2001–2002." Available URL: <http://www.cdc.gov/mmwr/preview/mmwrhtml/ss5308a1.htm#tab3> (accessed May 2009).

- Center for Disease Control and Prevention (CDC). 2004. "Surveillance for Waterborne Disease and Outbreaks Associated with Recreational Water Use and Other Aquatic Facility-Associated Health Events --- United States, 2003–2004." Available URL: <http://www.cdc.gov/mmwr/preview/mmwrhtml/ss5512a1.htm> (accessed May 2009).
- Center for Disease Control and Prevention (CDC). 2006. "Surveillance for Waterborne Disease and Outbreaks Associated with Recreational Water Use and Other Aquatic Facility-Associated Health Events --- United States, 2005–2006." Available URL: <http://www.cdc.gov/mmwr/preview/mmwrhtml/ss5709a1.htm#fig2> (accessed May 2009).
- Conestoga Rover and Associates (CRA). 2007. Hydrogeologic Investigation Work Plan, Ground Water Protection Initiative, Cooper Nuclear Station, Brownsville, Nebraska.
- Council of Environmental Quality (CEQ). 1997. "Considering Cumulative Effects under the National Environmental Policy Act," Executive Office of the President, Washington, D.C.
- Council of Environmental Quality (CEQ). 2005. Memorandum from J.L. Connaughton, Chairman to Heads of Federal Agencies, Subject: "Guidance on the consideration of past actions in cumulative effects analysis," June 24, 2005, Executive Office of the President, Washington, D.C. Available URL: http://www.nepa.gov/nepa/regs/Guidance_on_CE.pdf (accessed June 2, 2009).
- Environmental Protection Agency (EPA). 1977. "Guidance for Evaluating the Adverse Impact of Cooling Water Intake Structures on the Aquatic Environment: Section 316(b) P.L. 92-500," Draft May 1, 1977, Office of Water Enforcement, Permits Division, Washington, D.C.
- Environmental Protection Agency (EPA). 1998. "Guidelines for Ecological Risk Assessment," EPA/630/R-95/002F, Risk Assessment Forum, Washington, D.C.
- Environmental Protection Agency (EPA). 1999. "Consideration of Cumulative Impacts in EPA Review of NEPA Documents," EPA-315-R-99-002, Office of Federal Activities (2252A), Washington, D.C.
- Environmental Protection Agency (EPA). 2009a. "2009 U.S. Greenhouse Gas Inventory Report. Inventory of U.S. Greenhouse Gas Emissions and Sinks: 1990–2007." Available URL: <http://www.epa.gov/climatechange/emissions/usinventoryreport.html> (accessed June 2009).
- Environmental Protection Agency (EPA). 2009b. "Climate Change – What You Can Do: Actions You Can Take at the Office". Available URL: <http://www.epa.gov/climatechange/wycd/actionsteps.html#office> (accessed June 2009).
- Environmental Protection Agency (EPA). 2009c. E-mail from L. Shepherd, U.S. Environmental Protection Agency, Region 7, to U.S. Nuclear Regulatory Commission (CooperEIS Resource@nrc.gov), Subject: "Scoping Comments for Relicensing of Cooper Nuclear Station, Brownville, Nebraska," March 27, 2009, Agencywide Documents Access and Management System (ADAMS) Accession No. ML091070269.
- Farrell, J.R. and M.A. Tesar. 1982. "Chapter 5: Periphytic algae in the channelized Missouri River with special emphasis on apparent optimal temperatures," in Hesse, L.W., G.L. Hergenrader, H.S. Lewis, S.D. Reetz, and A.B. Schlesinger (eds.), *The Middle Missouri River: A Collection of Papers on the Biology with Special Reference to Power Station Effects*, The Missouri River Group, Norfolk, Nebraska, pp. 84–123.
- Galat, D.L., C.R. Berry, Jr., W.M. Gardner, J.C. Hendrickson, G.E. Mestl, G.J. Power, C. Stone, and M.R. Winston (Galat et. al.). 2005a. "Spatiotemporal patterns and changes in Missouri River Fishes," *American Fisheries Society Symposium* 45:249–291.

Environmental Impacts of Operation

Galat, D.L., C.R. Berry, Jr., E.J. Peters, and R.G. White (Galat et. al.). 2005b. "Missouri River Basin," in Benke, A.C. and C.E. Cushing (eds.), *Rivers of North America*, Elsevier Academic Press, New York, pp. 427–480.

Hazleton Environmental Sciences Corporation (Hazleton). 1979. "Report to Nebraska Public Power District, Columbus, Nebraska: The Evaluation of Thermal Effects in the Missouri River Near Cooper Nuclear Station (Operational Phase), January–December 1978, Project No. 8903," Hazleton Environmental Sciences Corporation, Lincoln, Nebraska, ADAMS Accession No. ML092450614.

Hergenrader, G.L., L.G. Harrow, R.G. King, G.F. Cada, and A.B. Schlesinger (Hergenrader et al.). 1982. "Chapter 8: Larval fishes in the Missouri River and the effects of entrainment," in Hesse, L.W., G.L. Hergenrader, H.S. Lewis, S.D. Reetz, and A.B. Schlesinger (eds.), *The Middle Missouri River: A Collection of Papers on the Biology with Special Reference to Power Station Effects*, The Missouri River Group, Norfolk, Nebraska, pp. 184–223.

Institute of Electrical and Electronics Safety Code (IEEE). 2007. *National Electric Safety Code*.

Intergovernmental Panel on Climate Change (IPCC). 2009. "IPCC Fourth Assessment Report: Working Group II Report, Impacts, Adaptation and Vulnerability." Available URL: <http://www.ipcc.ch/ipccreports/ar4-wg2.htm> (accessed June 2009).

Joklik, W.K. and D.T. Smith. 1972. *Zinsser Microbiology*. Addleton-Century-Croft, New York.

Missouri Department of Conservation (MDC). 2009b. MDC Heritage Database Results for Atchison County. Available URL: <http://mdc.mo.gov/cgi-bin/heritage/search.cgi?county=Atchison> (accessed April 21, 2009).

National Historic Preservation Act (NHPA) of 1966. 16 U.S.C. 470, et seq.

Nalco Environmental Sciences (Nalco). 1975. "The Evaluation of Thermal Effects in the Missouri River near Cooper Nuclear Station 316(a) & (b) Demonstration, Project No. 64306575," report to Nebraska Public Power District Columbus, Nebraska, Nalco Environmental Sciences, Lincoln, Nebraska, ADAMS Accession No. ML092450626.

National Institute of Environmental Health Sciences (NIEHS). 1999. "NIEHS Report on Health Effects from Exposure to Power Line Frequency and Electric and Magnetic Fields," Publication No. 99-4493, Research Triangle Park, NC.

NatureServe. 2009. NatureServe Explorer. Version 7.1. Eskimo curlew. Available URL: <http://www.natureserve.org/explorer/servlet/NatureServe> (accessed Jun 4, 2009).

Nebraska Department of Agriculture (NDA), 2008. Press Release: "NDA Adds Phragmites to Noxious Weed List Under Temporary Order," April 15, 2008. Available URL: <http://www.agr.state.ne.us/newsrel/april2008/phragmites.htm> (accessed March 9, 2009).

Nebraska Public Power District (NPPD). 2004a. "Cooper Nuclear Station, Annual Radiological Environmental Monitoring Program Report for 2003," Brownville, Nebraska, ADAMS Accession No. ML041340134.

Nebraska Public Power District (NPPD). 2004b. "Cooper Nuclear Station, Annual Radioactive Effluent Release Report for 2003," Brownville, Nebraska, ADAMS Accession No. ML041190422.

Nebraska Public Power District (NPPD). 2005a. "Cooper Nuclear Station, Annual Radiological Environmental Monitoring Program Report for 2004," Brownville, Nebraska, ADAMS Accession No. ML051160385.

Nebraska Public Power District (NPPD). 2005b. "Cooper Nuclear Station, Annual Radioactive Effluent Release Report for 2004," Brownville, Nebraska, ADAMS Accession No. ML051220511.

Nebraska Public Power District (NPPD). 2006a. "Cooper Nuclear Station, Annual Radiological Environmental Monitoring Program Report for 2005," Brownville, Nebraska, ADAMS Accession No. ML061360083.

Nebraska Public Power District (NPPD). 2006b. "Cooper Nuclear Station, Annual Radioactive Effluent Release Report for 2005," Brownville, Nebraska, ADAMS Accession No. ML061240548.

Nebraska Public Power District (NPPD). 2007a. "Cooper Nuclear Station, Annual Radiological Environmental Monitoring Program Report for 2006," Brownville, Nebraska, ADAMS Accession No. ML071380490.

Nebraska Public Power District (NPPD). 2007b. "Cooper Nuclear Station, Annual Radioactive Effluent Release Report for 2006," Brownville, Nebraska, ADAMS Accession No. ML071240393.

Nebraska Public Power District (NPPD). 2008a. "License Renewal Application, Cooper Nuclear Station, Appendix E – Applicant's Environmental Report, Operating License Renewal Stage," ADAMS Accession No. ML083030246.

Nebraska Public Power District (NPPD). 2008b. "2008 Integrated Resource Plan," ADAMS Accession No. ML091750299.

Nebraska Public Power District (NPPD). 2008c. Letter from K.M. Krumland, Environmental Protection Supervisor, Nebraska Public Power District, to Donna K. Garden, Nebraska Department of Environmental Quality, Subject: "Nebraska Public Power District, Cooper Nuclear Station NPDES Permit #NE0001244, Annual 316(b) Compliance Report," February 29, 2008, ADAMS Accession No. ML092450698.

Nebraska Public Power District (NPPD). 2008d. "Cooper Nuclear Station, Annual Radiological Environmental Monitoring Program Report for 2007," Brownville, Nebraska, ADAMS Accession No. ML081410584.

Nebraska Public Power District (NPPD). 2008e. "Cooper Nuclear Station, Annual Radioactive Effluent Release Report for 2007," Brownville, Nebraska, ADAMS Accession No. ML081300029.

Nebraska Public Power District (NPPD). 2009a. "Cooper Nuclear Station, Annual Radiological Environmental Monitoring Program Report for 2008," Brownville, Nebraska, ADAMS Accession No. ML091410170.

Nebraska Public Power District (NPPD). 2009b. Response to Request for Additional Information for License Renewal Application Environmental Report Cooper Nuclear Station, Docket No. 50-298, DPR-46, Low Emitter Status for NPPD's Cooper Nuclear Station, NDEQ Facility ID #36750, March 27, 2009, ADAMS Accession No. ML091600712

Nebraska Public Power District (NPPD). 2009b Cooper Nuclear Station, Annual Radiological Environmental Monitoring Program Report for 2008. Brownville, Nebraska, ADAMS Accession No. ML091410170.

Nebraska Public Power District (NPPD). 2010. "Cooper Nuclear Station, Annual Radiological Environmental Monitoring Program Report for 2009," Brownville, Nebraska, ADAMS Accession No. ML101390493.

Environmental Impacts of Operation

Nebraska Department of Environmental Quality (NDEQ) 1977. Letter from D.T. Drain, Director, to L.J. Cooper, Director, Nebraska Public Power District, Subject: "316(b) Demonstration Cooper Nuclear Station, NPDES Permit No. NE 0001244," February 2, 1977, ADAMS Accession No. MLO92450636.

Nebraska Department of Environmental Quality (NDEQ). 2007. "Attachment A: Fact Sheet, NPPD Cooper Nuclear Power Station, Brownville, Nebraska, NPDES NE0001244 / PCS 36750-P," January 10, 2007, Wastewater Section, Lincoln, Nebraska, ADAMS Accession No. MLO92450693.

Nebraska Game and Parks Commission (NGPC). 2008. "Estimated Current Ranges of Threatened and Endangered Species: List of Species by County." Available URL: <http://www.ngpc.state.ne.us/wildlife/programs/nongame/TandESpecies.pdf> (accessed April 21, 2009).

National Research Council (NRCC). 2002. *The Missouri River Ecosystem: Exploring the Prospects for Recovery*, Committee on Missouri River Ecosystem Science, National Academy Press, Washington, D.C., 188 Pages.

Reetz, S.D. 1982. "Chapter 4: Phytoplankton studies in the Missouri River at Fort Calhoun Station and Cooper Nuclear Station," in Hesse, L.W., G.L. Hergenrader, H.S. Lewis, S.D. Reetz, and A.B. Schlesinger (eds.), *The Middle Missouri River: A Collection of Papers on the Biology with Special Reference to Power Station Effects*, The Missouri River Group, Norfolk, Nebraska, pp. 71–83.

Repsys, A.J. and G.D. Rogers. 1982. "Chapter 6: Zooplankton studies in the channelized Missouri River," in Hesse, L.W., G.L. Hergenrader, H.S. Lewis, S.D. Reetz, and A.B. Schlesinger (eds.), *The Middle Missouri River: A Collection of Papers on the Biology with Special Reference to Power Station Effects*, The Missouri River Group, Norfolk, Nebraska, pp. 124–145.

Todar, K. 2007. "Todard's online textbook of bacteriology." Available URL: <http://www.textbookofbacteriology.net> (accessed June 2009).

U.S. Army Corps of Engineers (USACE). 2004a. *Missouri River Master Water Control Manual, Final Environmental Impact Statement Review and Update*, Northwestern Division, Omaha, Nebraska, March 2004.

U.S. Army Corps of Engineers (USACE). 2004b. "Missouri River Mitigation Project," July 2004. Available URL: http://www.nwk.usace.army.mil/projects/mitigation/sites/hamburg_area/lanben.htm (accessed April 15, 2004).

U.S. Atomic Energy Commission (AEC). 1973. "Final Environmental Statement related to the Cooper Nuclear Station," Northern States Power Company, Facility Operating License DPR-46, Directorate of Licensing, Washington, D.C.

U.S. Census Bureau (USCB). 2003. "LandView 6 – Census 2000 Profile of General Demographic Characteristics DP-1 (100%) and Census Profile of Selected Economic Characteristics DP-3, Summary of Census Block Groups in a 50-mile radius around the CNS (40.361944 Lat., -95.641389 Long)," December 2003.

U.S. Fish and Wildlife Service (USFWS). 2007. "Endangered, Threatened, Proposed, and Candidate Species in Nebraska Counties," Ecological Services, Nebraska Field Office, November 2007. Available URL: <http://www.fws.gov/mountain-prairie/endsp/CountyLists/Nebraska.pdf> (accessed April 17, 2009).

U.S. Fish and Wildlife Service (USFWS). 2008. "Endangered Species, Missouri, County Distribution of Federally-Listed, Threatened, Endangered, Proposed, and Candidate Species," Columbia, Missouri, November 2008. Available URL: <http://www.fws.gov/midwest/endangered/lists/missouri-cty.html> (accessed April 17, 2009).

U.S. Fish and Wildlife Service (USFWS). 2009a. Personal e-mail from Robert Harms, Fish and Wildlife Biologist, Grand Island Field Office, to R. Bulavinetz, Aquatic Ecologist, Division of License Renewal, U.S. Nuclear Regulatory Commission, Subject: "Cooper Nuclear Plant," March 16, 2009, ADAMS Accession No. ML092110590

U.S. Fish and Wildlife Service (USFWS). 2009b. Letter from June M. DeWeese, Nebraska Field Supervisor, U.S. Fish and Wildlife Service, Grand Island, to Joe L. Citta, Jr., Corporate Environmental Manager, Nebraska Public Power District, Subject: "Cooper Nuclear Station," June 8, 2009, ADAMS Accession No. ML091830055.

U.S. Fish and Wildlife Service (USFWS). 2009c. "Rainwater Basin Wetland Management District." Available URL: <http://www.fws.gov/Refuges/profiles/index.cfm?id=64530> (accessed April 29, 2009).

U.S. Geological Survey (USGS). 2001. "Ecoregions of Nebraska and Kansas" (color poster with map, descriptive text, summary tables, and photographs). Available URL: http://www.epa.gov/wed/pages/ecoregions/ksne_eco.htm (accessed April 29, 2009).

U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*, NUREG-1437, Volumes 1 and 2, Washington, D.C., ADAMS Accession Nos. ML040690705 and ML040690738.

U.S. Nuclear Regulatory Commission (NRC). 2008a. Letter from D. Pelton, U.S. Nuclear Regulatory Commission, Washington, D.C., to M. Milwa, State Historic Preservation Officer, Missouri Department of Natural Resources, St. Paul, MN, Subject: "Cooper Nuclear Station License Renewal Application Review (Log Number 004-AT-08)," ADAMS Accession No. ML090210750.

U.S. Nuclear Regulatory Commission (NRC). 2008b. Letter from D. Pelton, U.S. Nuclear Regulatory Commission, Washington, D.C., to M. Smith, State Historic Preservation Officer, Nebraska State Historical Society, Washington, D.C., Subject: "Cooper Nuclear Station License Renewal Application Review (HP Num. 0801-050-01)," ADAMS Accession No. ML090080197.

U.S. Nuclear Regulatory Commission (NRC). 2008c. Letter from D. Pelton, U.S. Nuclear Regulatory Commission, Washington, D.C., to D. Klilma, Director, Advisory Council on Historic Preservation, Washington, D.C., Subject: "Cooper Nuclear Station License Renewal Application Review," ADAMS Accession No. ML090080683.

5.0 ENVIRONMENTAL IMPACTS OF POSTULATED ACCIDENTS

This chapter describes the environmental impacts from postulated accidents that might occur during the period of extended operation. The term "accident" as defined in the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437 (NRC, 1996), refers to any unintentional event outside the normal plant operational envelope that results in a release or the potential for release of radioactive materials into the environment. Two classes of postulated accidents are evaluated under the National Environmental Policy Act (NEPA) in the license renewal review: design-basis accidents (DBAs) and severe accidents. In the GEIS, the U.S. Nuclear Regulatory Commission (NRC) staff categorized accidents as "design basis" when the plant was designed specifically to accommodate these accidents, or as "severe" for those accidents involving multiple failures of equipment or function whose likelihood is generally lower than DBAs but where consequences may be higher (NRC, 1996). These issues are evaluated in Chapter 5 of the GEIS, "Environmental Impacts of Postulated Accidents."

Table 5-1. Issues Related to Postulated Accidents. *Two issues related to postulated accidents are evaluated under the National Environmental Policy Act (NEPA) in the license renewal review: DBAs and severe accidents.*

Issue	GEIS Section	Category
DBAs	5.3.2; 5.5.1	1
Severe accidents	5.3.3; 5.3.3.2; 5.3.3.3; 5.3.3.4; 5.3.3.5; 5.4; 5.5.2	2

5.1 DESIGN-BASIS ACCIDENTS

As described in Section 50.34(b) in Title 10 of the *Code of Federal Regulations* (10 CFR 50.34(b)), in order to receive NRC approval for an operating license, an applicant, for an initial operating license, must submit a final safety analysis report (FSAR) as part of its application. The FSAR presents the design criteria and design information for the proposed reactor and comprehensive data on the proposed site. The FSAR also discusses various hypothetical accident situations and the safety features that are provided to prevent and mitigate accidents. The NRC staff reviews the application to determine whether or not the plant design meets the NRC's regulations and requirements and includes, in part, the nuclear plant design and its anticipated response to an accident.

The environmental impacts of postulated accidents were evaluated for the license renewal period in Chapter 5 of the GEIS. Section 5.5.1 states:

All plants have had a previous evaluation of the environmental impacts of design-basis accidents. In addition, the licensee will be required to maintain acceptable design and performance criteria throughout the renewal period. Therefore, the calculated releases from design-basis accidents would not be expected to change. Since the consequences of these events are evaluated for the hypothetical maximally exposed individual at the time of licensing, changes in the plant environment will not affect these evaluations. Therefore, the staff concludes that the environmental impacts of design-basis accidents are of small significance for all plants. Because the environmental impacts of design basis

Environmental Impacts of Postulated Accidents

accidents are of small significance and because additional measures to reduce such impacts would be costly, the staff concludes that no mitigation measures beyond those implemented during the current term license would be warranted. This is a Category 1 issue.

No new and significant information related to DBAs was identified during the review of Nebraska Public Power District's (NPPD's) environmental report (ER), site audit, scoping process, or evaluation of other available information. Therefore, there are no impacts related to these issues beyond those discussed in the GEIS.

5.2 SEVERE ACCIDENTS

Severe nuclear accidents are those that are more severe than DBAs because they could result in substantial damage to the reactor core, whether or not there are serious offsite consequences. In the GEIS, the staff assessed the impacts of severe accidents during the license renewal period, using the results of existing analyses and information from various sites to predict the environmental impacts of severe accidents for plants during the renewal period.

Severe accidents initiated by external phenomena such as tornadoes, floods, earthquakes, fires, and sabotage have not traditionally been discussed in quantitative terms in the final environmental impact statements and were not specifically considered for the Cooper Nuclear Station (CNS) site in the GEIS (NRC, 1996). The GEIS, however, did evaluate existing impact assessments performed by the NRC staff and by the industry at 44 nuclear plants in the United States and segregated all sites into six general categories and then estimated that the risk consequences calculated in existing analyses bound the risks for all other plants within each category. The GEIS further concluded that the risk from beyond design-basis earthquakes at existing nuclear power plants is designated as SMALL. The Commission believes that NEPA does not require the NRC to consider the environmental consequences of hypothetical terrorist attacks on NRC-licensed facilities. However, the NRC staff's GEIS for license renewal contains a discretionary analysis of terrorist acts in connection with license renewal. The conclusion in the GEIS is that the core damage and radiological release from such acts would be no worse than the damage and release to be expected from internally initiated events.

In the GEIS, the NRC staff concludes that the risk from sabotage and beyond design-basis earthquakes at existing nuclear power plants is designated as SMALL, and additionally, that the risks from other external events are adequately addressed by a generic consideration of internally initiated severe accidents (NRC, 1996).

Based on information in the GEIS, the staff found that:

The generic analysis...applies to all plants and that the probability-weighted consequences of atmospheric releases, fallout onto open bodies of water, releases to ground water, and societal and economic impacts of severe accidents are of small significance for all plants. However, not all plants have performed a site-specific analysis of measures that could mitigate severe accidents. Consequently, severe accidents are a Category 2 issue for plants that have not performed a site-specific consideration of severe accident mitigation and submitted that analysis for Commission review.

The staff identified no new and significant information related to postulated accidents during the review of NPPD's ER, the site audit, the scoping process, or evaluation of other available information. Therefore, there are no impacts related to postulated accidents beyond those

discussed in the GEIS. In accordance with 10 CFR 51.53(c)(3)(ii)(L), however, the NRC staff has reviewed severe accident mitigation alternatives (SAMAs) for CNS. Review results are discussed in Section 5.3.

5.3 SEVERE ACCIDENT MITIGATION ALTERNATIVES

Regulations under Section 51.53(c)(3)(ii)(L) of 10 CFR requires an ER to contain an analysis of alternatives to mitigate severe accidents if the staff has not previously evaluated SAMAs for the applicant's plant in an environmental impact statement (EIS), related supplement, or in an environmental assessment. The Commission's reconsideration of the issue of severe accident mitigation for license renewal is based on the Commission's NEPA regulations that require a consideration of mitigation alternatives in its EISs and supplements to EISs, as well as a previous court decision that required a review of SAMAs at the operating license stage.

5.3.1 Introduction

This section presents a summary of the SAMA evaluation for CNS conducted by NPPD and the staff's review of that evaluation. The NRC staff performed its review with contract assistance from Pacific Northwest National Laboratory. Subsequent to the ER, NPPD discovered a problem with the process they used to numerically average the site-specific meteorological data. NPPD performed a sensitivity analysis of the population dose risk and offsite economic cost risk using corrected meteorological data, and found that the population dose and offsite economic cost values for each of the release categories would be slightly less than reported in the ER, and that the conclusions of the SAMA remain valid (NPPD, 2009b). The NRC staff's review is available in Appendix F; the SAMA evaluation is available in NPPD's ER and the supplement submitted in December 2009.

The SAMA evaluation for CNS was conducted with a four-step approach. In the first step, NPPD quantified the level of risk associated with potential reactor accidents using the plant specific probabilistic risk assessment (PRA) and other risk models.

In the second step, NPPD examined the major risk contributors and identified possible ways (SAMAs) of reducing that risk. Common ways of reducing risk are changes to components, systems, procedures, and training. NPPD identified 244 potential SAMAs for CNS. NPPD performed an initial screening to determine if any SAMAs could be eliminated because they are not applicable to CNS due to design differences, because they have already been implemented at CNS or because they are addressed by another SAMA candidate. One hundred sixty-four SAMAs were eliminated based on this screening, leaving 33 for further evaluation.

In the third step, NPPD estimated the benefits and the costs associated with each of the SAMAs. Estimates were made of how much each SAMA could reduce risk. Those estimates were developed in terms of dollars in accordance with NRC guidance for performing regulatory analyses (NRC, 1997). The cost of implementing the proposed SAMAs was also estimated.

Finally, in the fourth step, the costs and benefits of each of the remaining SAMAs were compared to determine whether the SAMA was cost-beneficial, meaning the benefits of the SAMA were greater than the cost (a positive cost benefit). NPPD concluded in its ER that several of the SAMAs evaluated are potentially cost-beneficial (NPPD, 2008).

The potentially cost-beneficial SAMAs do not relate to adequately managing the effects of aging during the period of extended operation (e.g., none of the potentially cost-beneficial SAMAs

would reduce the frequency or risk associated with aging-related failures). Therefore, they need not be implemented as part of license renewal pursuant to 10 CFR Part 54. NPPD's SAMA analysis and the NRC staff's review are discussed in more detail below.

5.3.2 Estimate of Risk

NPPD submitted an assessment of SAMAs for CNS as part of the ER. This assessment was based on the most recent CNS probabilistic safety assessment (PSA) available at that time, a plant-specific offsite consequence analysis performed using the MELCOR Accident Consequence Code System 2 (MACCS2) computer program, and insights from the CNS individual plant examination (IPE) (NPPD, 1993) and individual plant examination of external events (IPEEE) (NPPD, 1996). As mentioned above, NPPD discovered an error in the method used to average their wind data. NPPD performed a sensitivity analysis using the corrected meteorological data. Their analysis found that the error was conservative relative to the average population dose and economic cost, and that no SAMAs were inappropriately excluded from consideration in the license renewal application (LRA) as a result of the error in wind direction. NPPD submitted their analysis and changes to the LRA in a letter dated December 7, 2009 (NPPD, 2009b).

The NRC staff reviewed NPPD's re-analysis as submitted by NPPD and agrees that the error was conservative relative to the average population dose and offsite economic cost and that no SAMAs were inappropriately excluded from consideration in the LRA as a result of the error.

The CNS core damage frequency (CDF) is approximately 9.3×10^{-6} per year for internal events as determined from the quantification of the Level 1 PSA model. When determined from the sum of the containment event tree sequences, or Level 2 PSA model, the release frequency is approximately 1.2×10^{-5} per year. The latter value was used as the baseline CDF in the SAMA evaluations. The CDF value is based on the risk assessment for internally-initiated events.

NPPD did not include the contributions from external events within the CNS risk estimates; however, it did account for the potential risk reduction benefits associated with external events by increasing the estimated benefits for internal events by a factor of 3. The breakdown of CDF by initiating event is provided in Table 5-1.

Table 5-1. Cooper Nuclear Station, Core Damage Frequency for Internal Events

Initiating Event	CDF (per year)	% Contribution to CDF
Transients	3.0×10^{-6}	32
Loss of DC power	2.1×10^{-6}	22
Loss-of-coolant accidents (LOCAs)	1.4×10^{-6}	15
Loss of feedwater	1.0×10^{-6}	11
Loss of offsite power	6.5×10^{-7}	7
Loss of service water	6.0×10^{-7}	7
Loss of AC buses	2.6×10^{-7}	3
Internal flood	2.6×10^{-7}	3
Interfacing-systems loss-of-coolant accidents (ISLOCAs)	5.1×10^{-8}	<1
Total CDF (Internal Events)	9.3×10^{-6}	100

As shown in this table, events initiated by transients, loss of DC power, LOCA, and loss of feedwater are the dominant contributors to the CDF.

NPPD estimated the dose to the population within 50 miles (mi) (80 kilometers (km)) of the CNS site to be approximately 0.021 person-sievert (person-Sv) (2.1 person-roentgen equivalent man (person-rem)) per year. The breakdown of the total population dose by containment release mode is summarized in Table 5-2. Containment failures within the early time frame (less than 3.7 hours following event initiation) dominate the population dose risk at CNS, with failures in the intermediate time frame (3.7 to 24 hours following event initiation) contributing most of the remaining population dose.

Table 5-2. Breakdown of Population Dose by Containment Release Mode

Containment Release Mode	Population Dose (Person-Rem ^(a) Per Year)	% Contribution
Early containment failure	1.67	78
Intermediate containment failure	0.47	22
Late containment failure	<0.1	<1
Intact containment	Negligible	Negligible
Total	2.14	100

(a) One person-rem = 0.01 person-Sv

The NRC staff has reviewed NPPD's data and evaluation methods and concludes that the quality of the risk analyses is adequate to support an assessment of the risk reduction potential for candidate SAMAs. Accordingly, the staff based its assessment of offsite risk on the CDFs and offsite doses reported by NPPD in their ER (NPPD, 2008).

5.3.3 Potential Plant Improvements

Once the dominant contributors to plant risk were identified, NPPD searched for ways to reduce that risk. In identifying and evaluating potential SAMAs, NPPD considered insights from the plant-specific PSA, and SAMA analyses performed for other operating plants that have submitted license renewal applications. NPPD identified 244 potential risk-reducing improvements (SAMAs) to plant components, systems, procedures, and training.

NPPD removed all but 80 of the SAMAs from further consideration because they are not applicable at CNS due to design differences, have already been implemented at CNS, or are similar in nature and could be combined with another SAMA candidate. A detailed cost-benefit analysis was performed for each of the remaining SAMAs.

The staff concludes that NPPD used a systematic and comprehensive process for identifying potential plant improvements for CNS, and that the set of potential plant improvements identified by NPPD is reasonably comprehensive and, therefore, acceptable.

5.3.4 Evaluation of Risk Reduction and Costs of Improvements

NPPD evaluated the risk-reduction potential of the remaining 80 SAMAs. The majority of the SAMA evaluations were performed in a bounding fashion in that the SAMA was assumed to completely eliminate the risk associated with the proposed enhancement.

NPPD estimated the costs of implementing the candidate SAMAs through the application of engineering judgment and use of other licensee's estimates for similar improvements. The cost estimates conservatively did not include the cost of replacement power during extended

Environmental Impacts of Postulated Accidents

outages required to implement the modifications, nor did they include maintenance and surveillance costs of the installed equipment.

The staff reviewed NPPD's bases for calculating the risk reduction for the various plant improvements and concludes that the rationale and assumptions for estimating risk reduction are reasonable and generally conservative (i.e., the estimated risk reduction is higher than what would actually be realized). Accordingly, the staff based its estimates of averted risk for the various SAMAs on NPPD's risk reduction estimates.

The staff reviewed the bases for the applicant's cost estimates. For certain improvements, the staff also compared the cost estimates to estimates developed elsewhere for similar improvements, including estimates developed as part of other licensee's analyses of SAMAs for operating reactors and advanced light-water reactors. The staff found the cost estimates to be reasonable, and generally consistent with estimates provided in support of other plants' analyses.

The staff concludes that the risk reduction and the cost estimates provided by NPPD are sufficient and appropriate for use in the SAMA evaluation.

5.3.5 Cost-Benefit Comparison

The cost-benefit analysis performed by NPPD was based primarily on NUREG/BR-0184 (NRC, 1997) and was executed consistent with this guidance. NUREG/BR-0058 has recently been revised to reflect the agency's revised policy on discount rates. Revision 4 of NUREG/BR-0058 states that two sets of estimates should be developed – one at 3 percent and the other at 7 percent (NRC, 2004). NPPD provided both sets of estimates (NPPD, 2008).

NPPD identified eight potentially cost-beneficial SAMAs in the baseline analysis contained in the ER. The potentially cost-beneficial SAMAs are:

- SAMA 25 – Develop procedures to allow bypass of the reactor core isolation cooling (RCIC) turbine exhaust pressure trip, extending the time available for RCIC operation.
- SAMA 30 – Revise procedures to allow manual alignment of the fire water system to the residual heat removal (RHR) heat exchangers, providing improved ability to cool the RHR heat exchangers in a loss of service water (SW).
- SAMA 33 – Provide for the ability to establish an emergency connection of existing or new water sources to feedwater and condensate systems, increasing availability of feedwater.
- SAMA 40 – Revise procedures to provide additional space cooling to the emergency diesel generator (EDG) room via the use of portable equipment, increasing availability of the EDG.
- SAMA 45 – Provide an alternate means of supplying the instrument air header, increasing availability of instrument air.

- SAMA 68 – Revise procedures to allow the ability to cross-connect the circulating water pumps and the service water going to the turbine equipment cooling (TEC) heat exchangers, which allow continued use of the power conversion system after service water is lost.
- SAMA 78 – Improve training on alternate injection via the fire water system, increasing the availability of alternate injection.
- SAMA 79 – Revise procedures to allow use of the residual heat removal service water (RHRSW) system without a service water booster pump, increasing availability of the RHRSW system.

NPPD performed additional analyses to evaluate the impact of parameter choices and uncertainties on the results of the SAMA assessment (NPPD, 2008). If the benefits are increased by an additional factor of 3 to account for uncertainties, three additional SAMA candidates were determined to be potentially cost-beneficial:

- SAMA 14 – Provide a portable generator to supply DC power to individual panels during a station blackout (SBO), increasing the time available for AC power recovery.
- SAMA 64 – Revise procedures to allow use of a fire pumper truck to pressurize the fire water system, increasing availability of the fire water system.
- SAMA 75 – Implement Generation Risk Assessment (trip and shutdown risk modeling) into plant activities, decreasing the probability of trips/shutdown.

NPPD indicated that detailed engineering project cost-benefit analyses have been initiated for the 11 potentially cost-beneficial SAMAs (NPPD, 2008), (NPPD, 2009a).

Based on the staff's review and the supplemental information provided by NPPD, the NRC staff concludes that, with the exception of the potentially cost-beneficial SAMAs discussed above, the costs of the SAMAs evaluated would be higher than the associated benefits.

5.3.6 Conclusions

The staff reviewed NPPD's analysis and concluded that the methods used and the implementation of those methods were sound. The treatment of SAMA benefits and costs support the general conclusion that the SAMA evaluations performed by NPPD are reasonable and sufficient for the license renewal submittal.

Based on its review of the SAMA analysis, the staff concurs with NPPD's identification of areas in which risk can be further reduced in a cost-beneficial manner through the implementation of all, or a subset of potentially cost-beneficial SAMAs. Given the potential for cost-beneficial risk reduction, the staff considers that further consideration of these SAMAs by NPPD is warranted. However, none of the potentially cost-beneficial SAMAs relate to adequately managing the effects of aging during the period of extended operation (i.e., none of the potentially cost-beneficial SAMAs would reduce the frequency or risk associated with aging-related failures). Therefore, they need not be implemented as part of the license renewal pursuant to 10 CFR Part 54.

5.4 REFERENCES

10 CFR Part 50. *Code of Federal Regulations*, Title 10, *Energy*, Part 50, "Domestic Licensing of Production and Utilization Facilities."

10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions."

10 CFR Part 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, "Requirements for Renewal of Operating Licenses for Nuclear Power Plants."

Nebraska Public Power District (NPPD). 1993. "Generic Letter 88-20, Individual Plant Examination for Severe Accident Vulnerabilities – 10 CFR 50.54(f), IPE Report Submittal, Cooper Nuclear Station, Docket No. 50-298, DPR-46," March 1993, Agencywide Documents Access and Management System (ADAMS) Accession Nos. ML073600192 (Volume 1) and ML073600193 (Volume 2).

Nebraska Public Power District (NPPD). 1996. "Individual Plant Examination for External Events Report – 10 CFR 50.54(f), Cooper Nuclear Station, NRC Docket No. 50-298, License No. DPR-46," October 1996, ADAMS Accession No. ML073580487.

Nebraska Public Power District (NPPD). 2008. "License Renewal Application, Cooper Nuclear Station, Appendix E – Applicant's Environmental Report, Operating License Renewal Stage," Columbus, Nebraska, September 24, 2008, ADAMS Accession Nos. ML083030246 (main report) and ML083030252 (attachments).

Nebraska Public Power District (NPPD). 2009a. Letter from Stewart B. Minahan, Nebraska Public Power District, to the U.S. Nuclear Regulatory Commission Document Control Desk, Subject: "Response to Request for Additional Information for License Renewal Application – Severe Accident Mitigation Alternatives, Cooper Nuclear Station, Docket No. 50-298, DPR-46," July 1, 2009, ADAMS Accession No. ML091880319.

Nebraska Public Power District (NPPD). 2009b. Letter from Stewart B. Minahan, Nebraska Public Power District, to the U.S. Nuclear Regulatory Commission Document Control Desk, Subject: "SAMA Meteorological Anomaly Related to the Cooper Nuclear Station License Renewal Application, Cooper Nuclear Station, Docket No. 50-298, DPR-46," December 7, 2009, ADAMS Accession No. ML093490997.

U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*, NUREG-1437, Volumes 1 and 2, Washington, D.C., ADAMS Accession Nos. ML040690705 and ML040690738.

U.S. Nuclear Regulatory Commission (NRC). 1997. "Regulatory Analysis Technical Evaluation Handbook," NUREG/BR-0184, Washington, D.C.

U.S. Nuclear Regulatory Commission (NRC). 2004. "Regulatory Analysis Guidelines of the U.S. Nuclear Regulatory Commission," NUREG/BR-0058, Revision 4, Washington, D.C. September 2004.

6.0 ENVIRONMENTAL IMPACTS OF THE URANIUM FUEL CYCLE, SOLID WASTE MANAGEMENT AND GREENHOUSE GAS EMISSIONS

6.1 THE URANIUM FUEL CYCLE

This section addresses issues related to the uranium fuel cycle and solid waste management during the period of extended operation. The uranium cycle includes uranium mining and milling, the production of uranium hexafluoride, isotopic enrichment, fuel fabrication, reprocessing of irradiated fuel, transportation of radioactive materials, and management of low-level wastes and high-level wastes related to uranium fuel cycle activities. The *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437 (NRC, 1996), (NRC, 1999), details the potential generic impacts of the radiological and nonradiological environmental impacts of the uranium fuel cycle, including transportation of nuclear fuel and wastes. The GEIS is based, in part, on the generic impacts provided in Table S-3, "Table of Uranium Fuel Cycle Environmental Data," in Title 10 of the *Code of Federal Regulations* (CFR), Section 51.51(a), and in Table S-4, "Environmental Impact of Transportation of Fuel and Waste to and from One Light-Water-Cooled Nuclear Power Reactor," in 10 CFR 51.52(b). The GEIS also addresses the impacts from radon-222 and technetium-99.

For these Category 1 issues, the GEIS concludes that the impacts are designated as SMALL, except for the collective offsite radiological impacts from the fuel cycle and from high-level waste and spent fuel disposal, where no significance level was assigned to these two impacts. For the collective offsite radiological impacts, the Commission concludes that these impacts are acceptable in that these impacts would not be sufficiently large to require the National Environmental Policy Act (NEPA) conclusion, for any plant, that the option of extended operation under 10 CFR Part 54 should be eliminated. The staff of the U.S. Nuclear Regulatory Commission (NRC) did not identify any new and significant information related to the uranium fuel cycle during the review of Nebraska Public Power District's (NPPD) environmental report (ER) (NPPD, 2008), the site audit, and the scoping process. Therefore, there are no impacts related to these issues beyond those discussed in the GEIS.

Nine generic issues are related to the fuel cycle and solid waste management. These are shown in Table 6-1. There are no site-specific issues.

Environmental Impacts of the Uranium Fuel Cycle

Table 6-1. Issues Related to the Uranium Fuel Cycle and Solid Waste Management

Issues	GEIS Section	Category
Offsite radiological impacts (individual effects from other than the disposal of spent fuel and high-level waste)	6.1, 6.2.1, 6.2.2.1, 6.2.2.3, 6.2.3, 6.2.4, 6.6	1
Offsite radiological impacts (collective effects)	6.1, 6.2.2.1, 6.2.3, 6.2.4, 6.6	1
Offsite radiological impacts (spent fuel and high-level waste disposal)	6.1, 6.2.2.1, 6.2.3, 6.2.4, 6.6	1
Nonradiological impacts of the uranium fuel cycle	6.1, 6.2.2.6, 6.2.2.7, 6.2.2.8, 6.2.2.9, 6.2.3, 6.2.4, 6.6	1
Low-level waste storage and disposal	6.1, 6.2.2.2, 6.4.2, 6.4.3, 6.4.3.1, 6.4.3.2, 6.4.3.3, 6.4.4, 6.4.4.1, 6.4.4.2, 6.4.4.3, 6.4.4.4, 6.4.4.5, 6.4.4.5.1, 6.4.4.5.2, 6.4.4.5.3, 6.4.4.5.4, 6.4.4.6, 6.6	1
Mixed waste storage and disposal	6.4.5.1, 6.4.5.2, 6.4.5.3, 6.4.5.4, 6.4.5.5, 6.4.5.6, 6.4.5.6.1, 6.4.5.6.2, 6.4.5.6.3, 6.4.5.6.4, 6.6	1
Onsite spent fuel	6.1, 6.4.6, 6.4.6.1, 6.4.6.2, 6.4.6.3, 6.4.6.4, 6.4.6.5, 6.4.6.6, 6.4.6.7, 6.6	1
Nonradiological waste	6.1, 6.5, 6.5.1, 6.5.2, 6.5.3, 6.6	1
Transportation	6.1, 6.3.1, 6.3.2.3, 6.3.3, 6.3.4, 6.6, Addendum 1	1

6.2 GREENHOUSE GAS EMISSIONS

This section provides a discussion of potential impacts from greenhouse gases (GHGs) emitted from the nuclear fuel cycle. The GEIS does not directly address these emissions, and its discussion is limited to an inference that substantial carbon dioxide (CO₂) emissions may occur if coal- or oil-fired alternatives to license renewal are implemented.

6.2.1 Existing Studies

Since the development of the GEIS, the relative volumes of GHGs emitted by nuclear and other electricity generating methods have been widely studied. However, estimates and projections of the carbon footprint of the nuclear power life cycle vary depending on the type of study conducted. Additionally, considerable debate also exists among researchers regarding the relative impacts of nuclear and other forms of electricity generation on GHG emissions. Existing studies on GHG emissions from nuclear power plants generally take two different forms:

- (1) qualitative discussions of the potential to use nuclear power to reduce GHG emissions and mitigate global warming
- (2) technical analyses and quantitative estimates of the actual amount of GHGs generated by the nuclear fuel cycle or entire nuclear power plant life cycle and comparisons to the operational or life cycle emissions from other energy generation alternatives

6.2.1.1 Qualitative Studies

The qualitative studies consist primarily of broad, large-scale public policy or investment evaluations of whether an expansion of nuclear power is likely to be a technically, economically, and/or politically feasible means of achieving global GHG reductions. Studies identified by the NRC staff during the subsequent literature search include:

- Evaluations to determine whether investments in nuclear power in developing countries should be accepted as a flexibility mechanism to assist industrialized nations in achieving their GHG reduction goals under the Kyoto Protocols (Schneider, 2000), (IAEA, 2000), (NEA, 2002), (NIRS/WISE, 2005). Ultimately, the parties to the Kyoto Protocol did not approve nuclear power as a component under the Clean Development Mechanism (CDM) due to safety and waste disposal concerns (NEA, 2002).
- Analyses developed to assist governments, including the United States, in making long-term investment and public policy decisions in nuclear power (Keepin, 1988), (Hagen et al., 2001), (MIT, 2003).

Although the qualitative studies sometimes reference and critique the existing quantitative estimates of GHGs produced by the nuclear fuel cycle or life cycle, their conclusions generally rely heavily on discussions of other aspects of nuclear policy decisions and investment such as safety, cost, waste generation, and political acceptability. Therefore, these studies are typically not directly applicable to an evaluation of GHG emissions associated with the proposed license renewal for a given nuclear power plant.

6.2.1.2 Quantitative

A large number of technical studies, including calculations and estimates of the amount of GHGs emitted by nuclear and other power generation options, are available in the literature and were useful to the NRC staff's efforts in addressing relative GHG emission levels. Examples of these studies include – but are not limited to – Mortimer (1990), Andseta et al. (1998), Spadaro et al. (2000), Storm van Leeuwen and Smith (2005), Fritsche (2006), Parliamentary Office of Science and Technology (POST) (2006), AEA Technology (AEA, 2006), Weisser (2006), Fthenakis and Kim (2007), and Dones (2007).

Environmental Impacts of the Uranium Fuel Cycle

Comparing these studies and others like them is difficult because the assumptions and components of the life cycles the authors evaluate vary widely. Examples of areas in which differing assumptions make comparing the studies difficult include:

- energy sources that may be used to mine uranium deposits in the future
- reprocessing or disposal of spent nuclear fuel
- current and potential future processes to enrich uranium and the energy sources that will power them
- estimated grades and quantities of recoverable uranium resources
- estimated grades and quantities of recoverable fossil fuel resources
- estimated GHG emissions other than CO₂, including the conversion to CO₂ equivalents per unit of electric energy produced
- performance of future fossil fuel power systems
- projected capacity factors for alternative means of generation
- current and potential future reactor technologies

In addition, studies may vary with respect to whether all or parts of a power plant's life cycle are analyzed (i.e., a full life cycle analysis will typically address plant construction, operations, resource extraction (for fuel and construction materials), and decommissioning, whereas, a partial life cycle analysis will primarily focus on operational differences).

In the case of license renewal, a GHG analysis for that portion of the plant's life cycle (operation for an additional 20 years) would not involve GHG emissions associated with construction because construction activities have already been completed at the time of relicensing. In addition, the proposed action of license renewal would also not involve additional GHG emissions associated with facility decommissioning, because that decommissioning must occur whether the facility is relicensed or not. However, in some of the aforementioned studies, the specific contribution of GHG emissions from construction, decommissioning, or other portions of a plant's life cycle cannot be clearly separated from one another. In such cases, an analysis of GHG emissions would overestimate the GHG emissions attributed to a specific portion of a plant's life cycle. Nonetheless, these studies provide some meaningful information with respect to the relative magnitude of the emissions among nuclear power plants and other forms of electric generation, as discussed in the following sections.

In Tables 6-2, 6-3, and 6-4, the NRC staff presents the results of the aforementioned quantitative studies to provide a weight-of-evidence evaluation of the relative GHG emissions that may result from the proposed license renewal as compared to the potential alternative use of coal-fired, natural gas-fired, and renewable generation. Most studies from Mortimer (1990) onward suggest that uranium ore grades and uranium enrichment processes are leading determinants in the ultimate GHG emissions attributable to nuclear power generation. These studies indicate that the relatively lower order of magnitude of GHG emissions from nuclear power when compared to fossil-fueled alternatives (especially natural gas) could potentially

disappear if available uranium ore grades drop sufficiently while enrichment processes continued to rely on the same technologies.

6.2.1.3 Summary of Nuclear Greenhouse Gas Emissions Compared to Coal

Considering that coal fuels the largest share of electricity generation in the United States and that its burning results in the largest emissions of GHGs for any of the likely alternatives to nuclear power generation, including Cooper Nuclear Station (CNS), most of the available quantitative studies focused on comparisons of the relative GHG emissions of nuclear to coal-fired generation. The quantitative estimates of the GHG emissions associated with the nuclear fuel cycle (and, in some cases, the nuclear life cycle), as compared to an equivalent coal-fired plant, are presented in Table 6-2. The following chart does not include all existing studies, but provides an illustrative range of estimates developed by various sources.

Table 6-2. Nuclear Greenhouse Gas Emissions Compared to Coal

Source	GHG Emission Results
Mortimer (1990)	Nuclear—230,000 tons CO ₂ Coal—5,912,000 tons CO ₂ Note: Future GHG emissions from nuclear to increase because of declining ore grade.
Andseta et al. (1998)	Nuclear energy produces 1.4 percent of the GHG emissions compared to coal. Note: Future reprocessing and use of nuclear-generated electrical power in the mining and enrichment steps are likely to change the projections of earlier authors, such as Mortimer (1990).
Spadaro et al. (2000)	Nuclear—2.5 to 5.7 g C _{eq} /kWh Coal—264 to 357 g C _{eq} /kWh
Storm van Leeuwen and Smith (2005)	Authors did not evaluate nuclear versus coal.
Fritsche (2006) (Values estimated from graph in Figure 4)	Nuclear—33 g C _{eq} /kWh Coal—950 g C _{eq} /kWh
POST (2006) (Nuclear calculations from AEA, 2006)	Nuclear—5 g C _{eq} /kWh Coal— >1000 g C _{eq} /kWh Note: Decrease of uranium ore grade to 0.03 percent would raise nuclear to 6.8 g C _{eq} /kWh. Future improved technology and carbon capture and storage could reduce coal-fired GHG emissions by 90 percent.
Weisser (2006) (Compilation of results from other studies)	Nuclear—2.8 to 24 g C _{eq} /kWh Coal—950 to 1250 g C _{eq} /kWh
Fthenakis and Kim (2007)	Authors did not evaluate nuclear versus coal.
Dones (2007)	Author did not evaluate nuclear versus coal.

g C_{eq}/kWh = grams of CO₂ equivalents per kilowatt-hour

Environmental Impacts of the Uranium Fuel Cycle

6.2.1.4 Summary of Nuclear Greenhouse Gas Emissions Compared to Natural Gas

The quantitative estimates of the GHG emissions associated with the nuclear fuel cycle (and, in some cases, the nuclear life cycle), as compared to an equivalent natural gas-fired plant, are presented in Table 6-3. The following chart does not include all existing studies, but provides an illustrative range of estimates developed by various sources.

Table 6-3. Nuclear Greenhouse Gas Emissions Compared to Natural Gas

Source	GHG Emission Results
Mortimer (1990)	Author did not evaluate nuclear versus natural gas.
Andseta et al. (1998)	Authors did not evaluate nuclear versus natural gas.
Spadaro et al. (2000)	Nuclear—2.5 to 5.7 g C _{eq} /kWh Natural Gas—120 to 188 g C _{eq} /kWh
Storm van Leeuwen and Smith (2005)	Nuclear fuel cycle produces 20 to 33 percent of the GHG emissions compared to natural gas (at high ore grades). Note: Future nuclear GHG emissions to increase because of declining ore grade.
Fritsche (2006) (Values estimated from graph in Figure 4)	Nuclear—33 g C _{eq} /kWh Cogeneration Combined Cycle Natural Gas—150 g C _{eq} /kWh
POST (2006) (Nuclear calculations from AEA, 2006)	Nuclear—5 g C _{eq} /kWh Natural Gas—500 g C _{eq} /kWh Note: Decrease of uranium ore grade to 0.03 percent would raise nuclear to 6.8 g C _{eq} /kWh. Future improved technology and carbon capture and storage could reduce natural gas GHG emissions by 90 percent.
Weisser (2006) (Compilation of results from other studies)	Nuclear—2.8 to 24 g C _{eq} /kWh Natural Gas—440 to 780 g C _{eq} /kWh
Fthenakis and Kim (2007)	Authors did not evaluate nuclear versus natural gas.
Dones (2007)	Author critiqued methods and assumptions of Storm van Leeuwen and Smith (2005), and concluded that the nuclear fuel cycle produces 15 to 27 percent of the GHG emissions of natural gas.

6.2.1.5 Summary of Nuclear Greenhouse Gas Emissions Compared to Renewable Energy Sources

The quantitative estimates of the GHG emissions associated with the nuclear fuel cycle, as compared to equivalent renewable energy sources, are presented in Table 6-4. Calculation of GHG emissions associated with these sources is more difficult than the calculations for nuclear energy and fossil fuels because of the large variation in efficiencies due to their different sources and locations. For example, the efficiency of solar and wind energy is highly dependent on the location in which the power generation facility is installed. Similarly, the range of GHG emissions estimates for hydropower varies greatly depending on the type of dam or reservoir involved (if used at all). Therefore, the GHG emissions estimates for these energy sources have a greater range of variability than the estimates for nuclear and fossil fuel sources. As noted in Section 6.2.1.2, the following chart does not include all existing studies, but provides an illustrative range of estimates developed by various sources.

Table 6-4. Nuclear Greenhouse Gas Emissions Compared to Renewable Energy Sources

Source	GHG Emission Results
Mortimer (1990)	Nuclear—230,000 tons CO ₂ Hydropower—78,000 tons CO ₂ Wind power—54,000 tons CO ₂ Tidal power—52,500 tons CO ₂ Note: Future GHG emissions from nuclear to increase because of declining ore grade.
Andseta et al. (1998)	Authors did not evaluate nuclear versus renewable energy sources.
Spadaro et al. (2000)	Nuclear—2.5 to 5.7 g C _{eq} /kWh Solar PV—27.3 to 76.4 g C _{eq} /kWh Hydroelectric—1.1 to 64.6 g C _{eq} /kWh Biomass—8.4 to 16.6 g C _{eq} /kWh Wind—2.5 to 13.1 g C _{eq} /kWh
Storm van Leeuwen and Smith (2005)	Authors did not evaluate nuclear versus renewable energy sources.
Fritsche (2006) (Values estimated from graph in Figure 4)	Nuclear—33 g C _{eq} /kWh Solar PV—125 g C _{eq} /kWh Hydroelectric—50 g C _{eq} /kWh Wind—20 g C _{eq} /kWh
POST (2006) (Nuclear calculations from AEA, 2006)	Nuclear—5 g C _{eq} /kWh Biomass—25 to 93 g C _{eq} /kWh Solar PV—35 to 58 g C _{eq} /kWh Wave/Tidal—25 to 50 g C _{eq} /kWh Hydroelectric—5 to 30 g C _{eq} /kWh Wind—4.64 to 5.25 g C _{eq} /kWh Note: Decrease of uranium ore grade to 0.03 percent would raise nuclear to 6.8 g C _{eq} /kWh.
Weisser (2006) (Compilation of results from other studies)	Nuclear—2.8 to 24 g C _{eq} /kWh Solar PV—43 to 73 g C _{eq} /kWh Hydroelectric—1 to 34 g C _{eq} /kWh Biomass—35 to 99 g C _{eq} /kWh Wind—8 to 30 g C _{eq} /kWh
Fthenakis and Kim (2007)	Nuclear—16 to 55 g C _{eq} /kWh Solar PV—17 to 49 g C _{eq} /kWh
Dones (2007)	Author did not evaluate nuclear versus renewable energy sources.

6.2.2 Conclusions: Relative Greenhouse Gas Emissions

The sampling of data presented in Tables 6-2, 6-3, and 6-4 above demonstrates the challenges of any attempt to determine the specific amount of GHG emissions attributable to nuclear energy production sources, as different assumptions and calculation methodology will yield differing results. The differences and complexities in these assumptions and analyses will further increase when they are used to project future GHG emissions. Nevertheless, several conclusions can be drawn from the information presented.

First, the various studies indicate a general consensus that nuclear power currently produces fewer GHG emissions than fossil-fuel-based electrical generation (e.g., the GHG emissions from a complete nuclear fuel cycle currently range from 2.5 to 55 g C_{eq}/kWh, as compared to the use of coal plants (264 to 1250 g C_{eq}/kWh) and natural gas plants (120 to 780 g C_{eq}/kWh)). The studies also provide estimates of GHG emissions from five renewable energy sources based on current technology. These estimates included solar-photovoltaic (17 to 125 g C_{eq}/kWh), hydroelectric (1 to 64.6 g C_{eq}/kWh), biomass (8.4 to 99 g C_{eq}/kWh), wind (2.5 to 30 g C_{eq}/kWh), and tidal (25 to 50 g C_{eq}/kWh). The range of these estimates is wide, but the general conclusion is that current GHG emissions from the nuclear fuel cycle are of the same order of magnitude as from these renewable energy sources.

Second, the studies indicate no consensus on future relative GHG emissions from nuclear power and other sources of electricity. There is substantial disagreement among the various authors regarding the GHG emissions associated with declining uranium ore concentrations, future uranium enrichment methods, and other factors, including changes in technology. Similar disagreement exists regarding future GHG emissions associated with coal and natural gas for electricity generation. Even the most conservative studies conclude that the nuclear fuel cycle currently produces fewer GHG emissions than fossil-fuel-based sources, and is expected to continue to do so in the near future. The primary difference between the authors is the projected cross-over date (the time at which GHG emissions from the nuclear fuel cycle exceed those of fossil-fuel-based sources) or whether cross-over will actually occur.

Considering the current estimates and future uncertainties, it appears that GHG emissions associated with the proposed CNS relicensing action are likely to be lower than those associated with fossil-fuel-based energy sources. The NRC staff bases this conclusion on the following rationale:

- (1) As shown in Tables 6-2 and 6-3, the current estimates of GHG emissions from the nuclear fuel cycle are far below those for fossil-fuel-based energy sources.
- (2) CNS license renewal will involve continued GHG emissions due to uranium mining, processing, and enrichment, but will not result in increased GHG emissions associated with plant construction or decommissioning (as the plant will have to be decommissioned at some point whether the license is renewed or not).
- (3) Few studies predict that nuclear fuel cycle emissions will exceed those of fossil fuels within a time frame that includes the CNS periods of extended operation. Several studies suggest that future extraction and enrichment methods, the potential for higher grade resource discovery, and technology improvements could extend this time frame.

With respect to comparison of GHG emissions among the proposed CNS license renewal action and renewable energy sources, it appears likely that there will be future technology

improvements and changes in the type of energy used for mining, processing, and constructing facilities of all types. Currently, the GHG emissions associated with the nuclear fuel cycle and renewable energy sources are within the same order of magnitude. Because nuclear fuel production is the most significant contributor to possible future increases in GHG emissions from nuclear power, and because most renewable energy sources lack a fuel component, it is likely that GHG emissions from renewable energy sources would be lower than those associated with CNS at some point during the period of extended operation.

The NRC staff also provides an additional discussion about the contribution of GHG to cumulative air quality impacts in Section 4.11.5 of this SEIS,

6.3 REFERENCES

10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions."

10 CFR Part 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, "Requirements for Renewal of Operating Licenses for Nuclear Power Plants."

AEA Technology (AEA). 2006. "Carbon Footprint of the Nuclear Fuel Cycle, Briefing Note," prepared for British Energy, March 2006.

Andseta, S., M.J. Thompson, J.P. Jarrell, and D.R. Pendergast (Andseta et al.). 1998. "CANDU Reactors and Greenhouse Gas Emissions," Canadian Nuclear Association, 11th Pacific Basin Nuclear Conference, Banff, Alberta, Canada, May 1998.

Dones, R. 2007. "Critical Note on the Estimation by Storm Van Leeuwen J.W., and Smith P. of the Energy Uses and Corresponding CO₂ Emissions for the Complete Nuclear Energy Chain," Paul Sherer Institute, April 2007.

Fritsche, U.R. 2006. "Comparison of Greenhouse-Gas Emissions and Abatement Cost of Nuclear and Alternative Energy Options from a Life-Cycle Perspective," Oko-Institut, Darmstadt Office, January 2006.

Fthenakis, V.M. and H.C. Kim. 2007. "Greenhouse-gas emissions from solar-electric and nuclear power: A life cycle study," *Energy Policy*, Volume 35, Number 4.

International Atomic Energy Agency (IAEA). 2000. "Nuclear Power for Greenhouse Gas Mitigation under the Kyoto Protocol: The Clean Development Mechanism (CDM)," November 2000.

Mortimer, N. 1990. "World Warms to Nuclear Power," *SCRAM Safe Energy Journal*, December 1989 and January 1990. Available URL: http://www.no2nuclearpower.org.uk/articles/mortimer_se74.php (accessed February 29, 2007).

Nebraska Public Power District (NPPD). 2008. "License Renewal Application, Cooper Nuclear Station, Appendix E – Applicant's Environmental Report, Operating License Renewal Stage," Columbus, Nebraska, September 24, 2008, Agencywide Documents Access and Management System (ADAMS) Accession Nos. ML083030246 (main report) and ML083030252 (attachments).

Organization for Economic Co-Operation and Development, Nuclear Energy Agency (NEA). 2002. "Nuclear Energy and the Kyoto Protocol."

Parliamentary Office of Science and Technology (POST). 2006. "Carbon Footprint of Electricity Generation," Postnote, Number 268, October 2006.

Environmental Impacts of the Uranium Fuel Cycle

Schneider, M. 2000. "Climate Change and Nuclear Power," World Wildlife Fund for Nature, April 2000.

Spadaro, J.V., L. Langlois and B. Hamilton (Spadaro et al.). 2000. "Greenhouse Gas Emissions of Electricity Generation Chains: Assessing the Difference," *IAEA Bulletin* 42/2/2000, Vienna, Austria.

Storm van Leeuwen, J.W. and P. Smith 2005. "Nuclear Power—The Energy Balance," August 2005.

U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*, NUREG-1437, Volumes 1 and 2, Washington, D.C., ADAMS Accession Nos. ML040690705 and ML040690738.

U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Main Report*, "Section 6.3 – Transportation, Table 9.1, Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants, Final Report," NUREG-1437, Volume 1, Addendum 1, Washington, D.C., ADAMS Accession No. ML040690720.

Weisser, D. 2006. "A Guide to Life-Cycle Greenhouse Gas (GHG) Emissions from Electric Supply Technologies." Available URL: http://www.iaea.org/OurWork/ST/NE/Pess/assets/GHG_manuscript_pre-print_versionDanielWeisser.pdf (accessed May 19, 2009)

7.0 ENVIRONMENTAL IMPACTS OF DECOMMISSIONING

Environmental impacts from the activities associated with the decommissioning of any reactor before or at the end of an initial or renewed license are evaluated in the *Generic Environmental Impact Statement on Decommissioning of Nuclear Facilities: Supplement 1, "Regarding the Decommissioning of Nuclear Power Reactors,"* NUREG-0586, Supplement 1 (NRC, 2002). The staff's evaluation of the environmental impacts of decommissioning presented in NUREG-0586, Supplement 1, identifies a range of impacts for each environmental issue.

The incremental environmental impacts associated with decommissioning activities resulting from continued plant operation during the renewal term are discussed in the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants (GEIS)*, NUREG-1437, Volumes 1 and 2 (NRC, 1996), (NRC, 1999).

7.1 DECOMMISSIONING

Category 1 issues in Table B-1 of Title 10 of the *Code of Federal Regulations (CFR)* Part 51, Subpart A, Appendix B that are applicable to Cooper Nuclear Station (CNS) decommissioning following the renewal term are listed in Table 7-1.

Table 7-1. Category 1 Issues Applicable to the Decommissioning of Cooper Nuclear Station Following the Renewal Term

Issue	GEIS Section
Radiation doses	7.3.1
Waste management	7.3.2
Air quality	7.3.3
Water quality	7.3.4
Ecological resources	7.3.5
Socioeconomic impacts	7.3.7

A brief description of the staff's review and the conclusions, as stated in Table B-1, 10 CFR Part 51, for each of the issues follows:

- Radiation doses. Based on information in the GEIS, the Commission found that:
Doses to the public will be well below applicable regulatory standards regardless of which decommissioning method is used. Occupational doses would increase no more than 1 milliroentgen equivalent man (mrem) caused by buildup of long-lived radionuclides during the license renewal term.
- Waste management. Based on information in the GEIS, the Commission found that:
Decommissioning at the end of a 20-year license renewal period would generate no more solid wastes than at the end of the current license term. No increase in the quantities of Class C or greater than Class C wastes would be expected.

Environmental Impacts of Decommissioning

- Air quality. Based on information in the GEIS, the Commission found that:

Air quality impacts of decommissioning are expected to be negligible either at the end of the current operating term or at the end of the license renewal term.
- Water quality. Based on information in the GEIS, the Commission found that:

The potential for significant water quality impacts from erosion or spills is no greater whether decommissioning occurs after a 20-year license renewal period or after the original 40-year operation period, and measures are readily available to avoid such impacts.
- Ecological resources. Based on information in the GEIS, the Commission found that:

Decommissioning after either the initial operating period or after a 20-year license renewal period is not expected to have any direct ecological impacts.
- Socioeconomic impacts. Based on information in the GEIS, the Commission found that:

Decommissioning would have some short-term socioeconomic impacts. The impacts would not be increased by delaying decommissioning until the end of a 20-year relicense period, but they might be decreased by population and economic growth.

The NRC staff has not identified any new and significant information during the review of the Nebraska Public Power District (NPPD) environmental report (ER), the site audit, or the scoping process; therefore, there are no impacts related to these issues beyond those discussed in the GEIS (NRC, 1996), (NRC, 1999). For the issues listed in Table 7-1 above, the GEIS concluded that the impacts are SMALL.

7.2 REFERENCES

10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions."

U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*, NUREG-1437, Volumes 1 and 2, Washington, D.C., Agencywide Documents Access and Management System (ADAMS) Accession Nos. ML040690705 and ML040690738.

U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Main Report*, "Section 6.3 – Transportation, Table 9.1, Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants, Final Report," NUREG-1437, Volume 1, Addendum 1, Washington, D.C.

U.S. Nuclear Regulatory Commission (NRC). 2002. *Generic Environmental Impact Statement on Decommissioning of Nuclear Facilities: Supplement 1*, "Regarding the Decommissioning of Nuclear Power Reactors," NUREG-0586, Supplement 1, Volumes 1 and 2, Washington, D.C.

8.0 ENVIRONMENTAL IMPACTS OF ALTERNATIVES

The National Environmental Policy Act (NEPA) mandates that each environmental impact statement (EIS) consider alternatives to any proposed major Federal action. U.S. Nuclear Regulatory Commission (NRC) regulations (Title 10 of the *Code of Federal Regulations* (CFR) Section 51.71(d)) implementing NEPA for license renewal require that a supplemental environmental impact statement (SEIS) do the following:

Consider and weigh the environmental effects of the proposed action; the environmental impacts of alternatives to the proposed action; and alternatives available for reducing or avoiding adverse environmental effects and consideration of the economic, technical, and other benefits and costs of the proposed action.

In this case, the proposed Federal action is issuing a renewed license for Cooper Nuclear Station (CNS), which will allow the plant to operate for 20 years beyond its current license expiration date. In this chapter, the NRC staff examines potential environmental impacts of alternatives to issuing a renewed operating license for CNS as well as alternatives that may reduce or avoid adverse environmental impacts from license renewal, including when and where these alternatives are applicable.

While the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437 (NRC, 1996), (NRC, 1999), reached generic conclusions regarding many environmental issues associated with license renewal, it did not determine which alternatives are reasonable or reach conclusions about site-specific environmental impact levels. As such, the NRC staff must evaluate environmental impacts of alternatives on a site-specific basis.

Alternatives to the proposed action of issuing a renewed CNS operating license must meet the purpose and need for issuing a renewed license; they must "provide an option that allows for power generation capability beyond the term of a current nuclear power plant operating license to meet future system generating needs, as such needs may be determined by State, utility, and, where authorized, Federal (other than NRC) decision makers" (NRC, 1996).

The NRC staff ultimately makes no decision as to which alternative (or the proposed action) to implement, since that decision falls to utility, or State officials. Comparing the environmental effects of these alternatives will assist the NRC in deciding whether or not the adverse environmental impacts of license renewal are so great that preserving the option of license renewal for energy planning decision makers would be unreasonable. If the NRC acts to issue a renewed license, all of the alternatives, including the proposed action, will be available to energy-planning decision makers. If the NRC decides not to renew the license (or takes no action at all), then energy-planning decision makers may no longer elect to continue operating CNS and will have to resort to another alternative—which may or may not be one of the alternatives the NRC staff considers in this section—to meet their energy needs.

In evaluating alternatives to license renewal, the NRC staff first selects energy technologies or options currently in commercial operation, as well as some technologies not currently in commercial operation but likely to be commercially available by the time the current CNS operating license expires.

Second, the NRC staff screens the alternatives to remove those that cannot meet future system needs. Then, the staff screens the remaining options to remove those whose costs or benefits do not justify inclusion in the range of reasonable alternatives. Any alternatives remaining, then, constitute alternatives to the proposed action that the staff evaluates in-depth throughout this section. At the end of the section, the staff will briefly address each alternative removed during screening.

The NRC staff initially considers 19 discrete alternatives to the proposed action.

Once the staff identifies the in-depth alternatives, the staff refers to generic environmental impact evaluations in the GEIS. The GEIS provides overviews of some energy technologies available at the time of its publishing in 1996, though it does not reach any conclusions regarding which alternatives are most appropriate, nor does it precisely categorize impacts for each site. Since 1996, many energy technologies have evolved significantly in capability and cost, while regulatory structures have changed to either promote or impede development of particular alternatives.

As a result, our analyses include updated information from sources like the Energy Information Administration (EIA), other organizations within the Department of Energy (DOE), the Environmental Protection Agency (EPA), industry sources and publications, and information submitted by the applicant (Nebraska Public Power District (NPPD)) in the environmental report (ER).

For each in-depth analysis, the staff analyzes environmental impacts across seven impact categories: (1) air quality, (2) ground water use and quality, (3) surface water use and quality, (4) ecology, (5) human health, (6) socioeconomics, and (7) waste management. As in earlier chapters of this SEIS, the staff uses the NRC's three-level standard of significance—SMALL, MODERATE, or LARGE—to indicate the intensity of environmental effects for each alternative that is evaluated in depth. By placing the detailed alternative analyses in this order, the NRC staff does not mean to imply that one alternative would have the least impact, or that an energy-planning decision maker would be most likely to implement one or another alternative.

Sections 8.1 through 8.3 contain analyses of environmental impacts of alternatives to license renewal. These include a supercritical coal-fired plant in Section 8.1, a natural gas-fired combined-cycle power plant in 8.2, and a combination of alternatives in 8.3, that includes some natural gas-fired capacity, energy conservation, and a wind power component. In Section 8.4,

**In-Depth
Alternatives:**

- Coal-fired
- Supercritical
- Natural gas-fired
Combined cycle
- Combination

**Other Alternatives
Considered:**

- Coal-fired integrated
gasification
combined-cycle
(IGCC)
- New nuclear
- Wind power
- Conservation
- Purchased power
- Solar power
(photovoltaic and
concentrating)
- Wood-fired
combustion.
- Conventional
hydroelectric power
- Wave and ocean
energy
- Geothermal power
- Municipal solid waste
- Biofuels
- Methane
- Oil-fired power
- Fuel cells
- Delayed retirement

the NRC staff explains why it dismissed many other alternatives from in-depth consideration. Finally, in Section 8.5, the staff considers the environmental effects that may occur if the NRC takes no action and does not issue a renewed license for CNS.

8.1 SUPERCRITICAL COAL-FIRED GENERATION

Coal-fired generation accounts for a greater share of U.S. electrical power generation than any other fuel (EIA, 2009b). Furthermore, the EIA projects that coal-fired power plants will account for the greatest share of capacity additions through 2030—more than natural gas, nuclear, or renewable generation options. While coal-fired power plants are widely used and likely to remain widely used, the staff acknowledges that future additions to coal capacity may be affected by perceived or actual efforts to limit greenhouse gas (GHG) emissions. For now, the staff considers a coal-fired alternative to be a feasible, commercially available option for providing electrical generating capacity beyond CNS's current license expiration.

Energy Outlook:

Each year the EIA, part of the DOE, issues its updated *Annual Energy Outlook* (AEO). The AEO (2009) indicates that natural gas, coal, and renewables are likely to fuel most new electrical capacity through 2030, with some growth in nuclear capacity (EIA, 2009b), though all projections are subject to future developments in fuel price or electricity demand.

"Natural-gas-fired plants account for 53 percent of capacity additions in the reference case, as compared with 22 percent for renewables, 18 percent for coal-fired plants, and 5 percent for nuclear. Capacity expansion decisions consider capital, operating, and transmission costs. Typically, coal-fired, nuclear, and renewable plants are capital-intensive, whereas operating (fuel) expenditures account for most of the costs associated with natural-gas-fired capacity" (EIA, 2009d).

Supercritical technologies are increasingly common in new coal-fired plants. Supercritical facilities operate at higher temperatures and pressures than most existing coal-fired plants. At the critical point, there is no change of state when pressure is increased or if heat is added. For states above the critical point, the steam is supercritical. Operating at higher temperatures and pressures allows the supercritical coal-fired alternative to operate at a higher thermal efficiency than subcritical coal-fired power plants. While supercritical facilities are more expensive to construct, they consume less fuel for a given output, reducing environmental impacts. Based on technology forecasts from EIA (EIA, 2009a), the NRC staff expects that a new, supercritical coal-fired plant that begins operation in 2014 would operate at a heat rate of 9,069 British thermal units per kilowatt-hours (Btu/kWh), or approximately 38 percent thermally efficient (EIA, 2009a).²

In a supercritical coal-fired power plant, burning coal heats pressurized water. As the supercritical steam/water mixture moves through plant pipes to a turbine generator, the pressure drops and the mixture flashes to steam. The heated steam expands across the turbine stages, which then spin and turn the generator to produce electricity. After passing through the turbine, any remaining steam is condensed back to water in the plant's condenser.

In most modern U.S. coal facilities, condenser cooling water circulates through cooling towers or a cooling pond system (either of which are closed-cycle cooling systems). Older plants often

² Thermal efficiency is a measure of the efficiency of converting a fuel to energy and useful work. Thermal efficiency of a nuclear plant is roughly 32 percent.

Environmental Impacts of Alternatives

withdraw cooling water directly from existing rivers or lakes and discharge heated water directly to the same body of water (called open-cycle cooling). Though the NRC staff notes that a new facility could hypothetically continue to use the existing CNS intake structure with a once-through cooling system, as long as CNS could continue to receive sufficient water to maintain cooling for those systems necessary for a shutdown plant and provided that no modifications would be necessary to the intake structure and associated pumps. In order to provide cooling water for the new facility, the NRC staff has chosen to evaluate a coal-fired alternative using closed-cycle cooling because it will result in lower impacts—primarily to aquatic ecology—over the life of the alternative. Construction impacts may, however, be slightly greater, and operational impacts to aesthetics may also be slightly more noticeable, depending on whether or not the replacement facility uses natural- or mechanical-draft cooling towers.

The plant would withdraw makeup water from and discharge blowdown (water containing concentrated dissolved solids and biocides) back to the Missouri River. Cooling towers could be either natural draft (tall towers powered only by the difference in density between heated, humid air, and surrounding cooler and usually drier air) or mechanical draft (shorter towers powered by mechanical fans). For this analysis, the NRC staff assumed that a new supercritical coal-fired power plant would use mechanical draft towers for its closed-cycle cooling system.

In order to replace the 816 net megawatt-electric (MWe) that CNS currently supplies, the coal-fired alternative would ideally produce roughly the same amount (NPPD, 2008). Onsite electricity usage includes scrubbers, cooling towers, coal-handling equipment, lights, communication, and other onsite needs. A supercritical coal-fired power plant equivalent in capacity to CNS would require less cooling water than CNS because of the switch from open-cycle to closed-cycle cooling and because the plant operates at a higher thermal efficiency.

This 816 net MWe power plant would consume 3.14 million tons (2.84 million metric tonnes (MT)) of coal annually assuming an average heat content of 8,570 British thermal units per pound (Btu/lb) (EIA, 2006). The EIA reported that most coal consumed in Nebraska originates in Wyoming. Given current coal mining operations in Wyoming, the coal used in this alternative would likely be mined in surface mines, then mechanically processed and washed, before being transported—likely by rail—to the power plant site. Limestone for scrubbers would also likely arrive by rail. This coal-fired alternative would then produce roughly 153,000 tons (138,800 MT) of ash, and roughly 49,500 tons (45,000 MT) scrubber sludge. The coal ash and scrubber sludge (about 38,300 tons (34,800 MT)) could be recycled.

Environmental impacts from the coal-fired alternative will be greatest during construction. Site crews will clear the plant site of vegetation, prepare the site surface, and begin excavation before other crews begin actual construction on the plant and any associated infrastructure, including electricity transmission infrastructure connecting the plant to existing transmission lines.

8.1.1 Air Quality

Air quality impacts from coal-fired generation can be substantial because it emits a significant quantity of sulfur oxides (SO_x), nitrogen oxides (NO_x), particulates, carbon monoxide (CO), and hazardous air pollutants (HAPs) such as mercury; however, many of these pollutants can be effectively controlled by various technologies.

CNS is located in Nemaha County, Nebraska. There are no areas designated by the EPA as nonattainment or maintenance for any of the criteria pollutants in the 50-mile (mi) (81-kilometer (km)) vicinity of CNS. (EPA has defined six "criteria pollutants" as indicators of air quality, and has established for each of them a maximum concentration above which adverse effects on human health may occur). A new coal-fired generating plant would qualify as a new major-emitting industrial facility and would be subject to Prevention of Significant Deterioration of Air Quality Review under requirements of the Clean Air Act (CAA) (42 U.S.C. § 7401 et seq.), adopted by the Nebraska Department of Environmental Quality (NDEQ) in Title 129 of Nebraska Air Quality Regulations (NAQR) (EPA, 2008). A new coal-fired generating plant would need to comply with the new source performance standards for coal-fired plants set forth in 40 CFR 60 Subpart Da. The standards establish limits for particulate matter (PM) (40 CFR 60.42Da), sulfur dioxide (SO₂) (40 CFR 60.43Da), and NO_x (40 CFR 60.44Da). Regulations issued by NDEQ adopt the EPA's CAA rules, with modifications, to limit power plant emissions of SO_x, NO_x, PM, and HAPs, among other matters. The new coal-fired generating plant would qualify as a Class I major source as identified in Chapter 2 of Title 129 of the Nebraska Administrative Code (NAC) and would be required to obtain Class I major source permits from NDEQ, (the EPA may also elect to review this aspect prior to issuance of the permits (NDEQ, 2003)).

Section 169A of the CAA (42 U.S.C. § 7491) calls for the EPA to establish rules to remedy any existing visibility impairment and prevent any future impairment in mandatory Class I Federal areas resulting from man-made air pollution. There are no mandatory Class I Federal areas in the State of Nebraska and the closest mandatory Class I Federal area is Hercules-Glades Wilderness Area, which is located 295 mi southeast from CNS in the State of Missouri. However, the State of Nebraska is among nine States (Nebraska, Kansas, Oklahoma, Texas, Minnesota, Iowa, Missouri, Arkansas, and Louisiana) that are members of the Central Regional Air Planning Association (CENRAP), along with tribes, Federal agencies, and other interested parties that identify regional haze and visibility issues and develop strategies to address them. The visibility protection regulatory requirements, contained in 40 CFR Part 51, Subpart P, include the review of the new sources that would be constructed in the attainment or unclassified areas and may affect visibility in any Class I Federal area (40 CFR 51.307).

The emissions from the coal-fired alternative at the CNS site, projected by the NRC staff based on published EIA data, EPA emission factors, and based on performance characteristics for this alternative and likely emission controls, would be:

- Sulfur oxides (SO_x) – 923 tons (838 MT) per year
- Nitrogen oxides (NO_x) – 784 tons (711 MT) per year
- Total suspended particles (TSP) – 80 tons (72 MT) per year
- Particulate matter (PM) PM₁₀ – 18 tons (17 MT) per year
- Particulate matter (PM) PM_{2.5} – 77 tons (69 MT) per year
- Carbon monoxide (CO) – 784 tons (711 MT) per year

8.1.1.1 Sulfur Oxides

The coal-fired alternative at the CNS site would likely use wet, limestone-based scrubbers to remove SO_x. The EPA indicates that this technology can remove more than 95 percent of SO_x from flue gases. The staff projects total SO_x emissions would be 923 tons (838 MT) per year. SO_x emissions from a new coal-fired power plant would be subject to the part of the requirements of the CAA (42 U.S.C. § 7651 et seq.). These regulations were enacted to reduce emissions of SO₂ and NO_x, the two principal precursors of acid rain, by restricting emissions of these pollutants from power plants. Title IV caps aggregate annual power plant SO₂ emissions and imposes controls on SO₂ emissions through a system of marketable allowances. The EPA

Environmental Impacts of Alternatives

issues one allowance for each ton of SO₂ that a unit is allowed to emit. New units do not receive allowances, but are required to have allowances to cover their SO₂ emissions. Owners of new units must, therefore, purchase allowances from owners of other power plants or reduce SO₂ emissions at other power plants they own. Allowances can be banked for use in future years. Thus, provided a new coal-fired power plant is able to purchase sufficient allowances to operate, it would not add to net regional SO₂ emissions, although it might do so locally.

8.1.1.2 Nitrogen Oxides

A coal-fired alternative at the CNS site would most likely employ various available NO_x-control technologies, which can be grouped into two main categories: combustion modifications and post-combustion processes. Combustion modifications include low-NO_x burners, overfire air, reburning, flue gas recirculation, and operational modifications. Post-combustion processes include selective catalytic reduction (SCR), selective noncatalytic reduction, and hybrid processes. Effective combination of the combustion modifications and post-combustion processes allows reducing NO_x emissions by up to 95 percent (EPA, 1998). NPPD indicated in its ER that it would use a combination of low-NO_x burners, overfire air, and selective noncatalytic reduction technologies in order to reduce NO_x emissions from this alternative.

Assuming the use of such technologies at the CNS site, NO_x emissions after scrubbing are estimated to be in the range of 783.77 tons (711.04 MT) annually.

Section 407 of the CAA establishes technology-based emission limitations for NO_x emissions. A new coal-fired power plant would be subject to the new source performance standards for such plants as indicated in 40 CFR 60.44Da(a)(1). This regulation limits the discharge of any gases that contain NO_x to 200 nanograms (ng) of NO_x per joule (J) of gross energy output (equivalent to 1.6 pounds per megawatt-hours (lb/MWh), based on a 30-day rolling average. Based on the projected emissions and proposed emissions controls, the coal-fired alternative would meet this regulation.

8.1.1.3 Particulates

The new coal-fired power plant would use fabric filters to remove particulates from flue gases. NPPD indicates that fabric filters would remove 99.9 percent of PM (NPPD, 2008). The EPA notes that filters are capable of removing in excess of 99 percent of PM, and that SO₂ scrubbers further reduce PM emissions (EPA, 2008); therefore, the NRC staff believes the NPPD removal factor is appropriate. Based on this, the new supercritical coal-fired plant would emit 79.68 tons (72.29 MT) per year of TSP and approximately 18.33 tons (16.63 MT) per year of particulate matter having an aerodynamic diameter less than, or equal to, 10 microns (PM₁₀) annually. In addition, coal burning would also result in approximately 76.50 tons per year (69.40 MT) of particulate matter with an aerodynamic diameter of 2.5 microns or less (PM_{2.5}) and coal-handling equipment would introduce fugitive dust emissions when fuel is being transferred to onsite storage and then reclaimed from storage for use in the plant. During the construction of a coal-fired plant, onsite activities would also generate fugitive dust. Vehicles and motorized equipment would create exhaust emissions during the construction process. These impacts would be intermittent and short-lived; however, to minimize dust generation, construction crews could use applicable dust-control measures.

8.1.1.4 Carbon Monoxide

Based upon EPA emission factors (EPA, 1998), the NRC staff estimates that total CO emissions would be approximately 783.77 tons (711.04 MT) per year.

8.1.1.5 Carbon Dioxide

A coal-fired plant would also have unregulated carbon dioxide (CO₂) emissions during operations, as well as during mining, processing, and transportation. The coal-fired plant would emit between 5,516,000 tons (5,004,000 MT) and 5,715,000 tons (5,184,600 MT) of CO₂ per year from coal combustion, depending on the type and quality of the coal burned.

8.1.1.6 Summary of Air Quality

While the GEIS analysis mentions global warming from unregulated CO₂ emissions and acid rain from SO_x and NO_x emissions as potential impacts, it does not quantify emissions from coal-fired power plants; however, the GEIS analysis does imply that air impacts would be substantial (NRC, 1996). The above analysis shows that emissions of air pollutants, including SO_x, NO_x, CO, and particulates, exceed those produced by the existing nuclear power plant, as well as those of the other alternatives considered in this section. Operational emissions of CO₂ are also much greater under the coal-fired alternative than under other alternatives, as reviewed by the staff in Section 6.2. Adverse human health effects such as cancer and emphysema have also been associated with air emissions from coal combustion, and are discussed further in Section 8.1.5.

The NRC analysis for a coal-fired alternative at an alternative site indicates that impacts from the coal-fired alternative would have clearly noticeable effects, but given existing regulatory regimens, permit requirements, and emissions controls, the coal-fired alternative would not destabilize air quality. Therefore, the appropriate characterization of air impacts from a coal-fired plant located at the CNS site is MODERATE.

8.1.2 Ground Water Use and Quality

If the onsite coal-fired alternative continued to use ground water for drinking water and service water, the need for ground water at the plant would be minor. Total usage would likely be less than CNS because fewer workers would be onsite, and the coal-fired unit would have fewer auxiliary systems requiring service water. No effect on ground water quality would likely be apparent.

Construction of a coal-fired plant could have a localized effect on ground water due to temporary dewatering and runoff control measures. Because of the temporary nature of construction and the likelihood of reduced ground water usage during operation, the impact of the coal-fired alternative would be designated as SMALL.

8.1.3 Surface Water Use and Quality

Because the alternative would draw water from the Missouri River, most of the approximately 12,000 gallons per minute (gpm) needed for maximum withdrawal would be taken from the river with an average consumptive loss of about 15 million gallons per day (mgd). Since the consumptive loss is less than 0.1 percent of the average annual flow of the Missouri River, the NRC staff concludes that the impact of surface water use would be designated as SMALL. A new coal-fired plant would be required to obtain a National Pollutant Discharge and Elimination System (NPDES) permit from the NDEQ for regulation of industrial discharges such as wastewater and stormwater. Assuming the plant operates within the limits of this permit, the impact from any cooling tower blowdown, site runoff, and other effluent discharges on surface water quality would be designated as SMALL.

8.1.4 Aquatic and Terrestrial Ecology

8.1.4.1 Aquatic Ecology

In Section 8.1, the NRC notes that it may be possible for a coal-fired alternative to rely on the existing CNS cooling water intake and open-cycle cooling, but in order to reduce potential impacts to aquatic organisms, the NRC staff has determined that the coal-fired alternative would use closed-cycle cooling. The number of fish and other aquatic organisms affected by impingement, entrainment, and thermal impacts will be less than those associated with license renewal because water consumption from, and heat rejected to, the Missouri River would be substantially lower than the current CNS as closed-cycle cooling requires less water and has less aquatic effects than once-through cooling. Some temporary impacts to aquatic organisms might occur as a result of construction or effluent discharges to the river. These activities would be monitored by the NDEQ under the project's NPDES permit. Although the number of affected organisms would be substantially less than for license renewal, the level of impact for continued CNS operation is already small, and so NRC expects that the levels of impact for impingement, entrainment, and thermal effects would also be designated as SMALL.

8.1.4.2 Terrestrial Ecology

Coal mining operations will also affect terrestrial ecology in offsite coal mining areas, although some of the land is most likely already disturbed by mining operations. Onsite and offsite land disturbances form the basis for impacts to terrestrial ecology.

Onsite impacts to terrestrial ecology will be minor because most of the site has been previously disturbed and is currently used for agricultural activities, aside from the 234 acres (ac) (95 hectares (ha)) of woodland on the Missouri side of the river. The impact could change if additional railways or roads are constructed through less disturbed areas. It is likely that the coal-fired alternative would continue to use the existing transmission system and right-of-ways (ROWs). The construction of mechanical draft cooling towers for the closed-cycle cooling system may also result in additional land disturbances. These construction activities may fragment (in the case of roads or railways) or destroy habitats and could include a loss of onsite farmland and possibly wetlands. Construction could also affect current drainage patterns of water into and out of the wetlands on the CNS site. These land disturbances could affect food supply and habitat of native wildlife and migratory waterfowl, and changes to the drainage patterns of the wetlands could affect the wetlands vegetation. However, these impacts are not likely to be significant. Cooling tower operation could produce some deposition of dissolved solids on surrounding vegetation and soil from cooling tower drift, even though the GEIS indicates that the impact of cooling towers on agricultural crops is of small significance and most of the land surrounding the CNS site is farmland.

Any onsite or offsite waste disposal by land filling will also affect terrestrial ecology at least through the period when the disposal area is reclaimed. Deposition of acid rain resulting from NO_x or SO_x emissions, and the deposition of other pollutants, can also affect terrestrial ecology. Given the emission regulations discussed in Section 8.1.1, air deposition impacts may be noticeable but are not likely to be destabilizing. Because of the potential habitat disturbances and potential pollutant deposition, impacts to terrestrial resources from a coal-fired alternative would be designated as MODERATE and would occur mostly during construction.

8.1.5 Human Health

Coal-fired power plants introduce worker risks from coal and limestone mining, coal and limestone transportation, plant operations, and disposal of coal combustion and scrubber wastes. In addition, there are public risks from the inhalation of stack emissions (as addressed in Section 8.1.1) and the secondary effects of eating foods grown in areas subject to deposition from plant stacks.

Human health risks of coal-fired power plants are described, in general, in Table 8-2 of the GEIS (NRC, 1996). Cancer and emphysema as a result of the inhalation of toxins and particulates are identified as potential health risks to occupational workers and members of the public (NRC, 1996). The human health risks of coal-fired power plants, both to occupational workers and to members of the public, are greater than those of the current CNS due to exposures to chemicals such as mercury; SO_x; NO_x; radioactive elements, such as uranium and thorium contained in coal and coal ash; and polycyclic aromatic hydrocarbon (PAH) compounds, including benzo(a)pyrene.

Regulations restricting emissions—enforced by the EPA or State agencies—have acted to significantly reduce potential health effects but do not entirely eliminate them. These agencies also impose site-specific emission limits as needed to protect human health. Even if the coal-fired alternative were located in a nonattainment area, emission controls and trading or offset mechanisms could prevent further regional degradation; however, local effects could be visible. Many of the byproducts of coal combustion responsible for health effects are largely controlled, captured, or converted in modern power plants (as described in Section 8.1.1), although some level of health effects may remain.

Aside from emission impacts, the coal-fired alternative introduces the risk of coal pile fires, and for those plants that use coal combustion liquid and sludge waste impoundments, the release of the waste due to a failure of the impoundment. Although there have been several instances of this occurring in recent years, these types of events are still relatively rare.

Overall, despite the range of potential threats to human health, extensive health-based regulations exist to mitigate the risks to workers and the public. As a result, the NRC staff expects human health impacts to be characterized as SMALL.

8.1.6 Socioeconomics

8.1.6.1 Land Use

The GEIS generically evaluates the impacts of nuclear power plant operations on land use both on and off each power plant site. The analysis of land use impacts focuses on the amount of land area that would be affected by the construction and operation of a new supercritical coal-fired power plant on the CNS site.

Based on previous experience in operating coal-fired plants of similar size, the NRC staff estimates that an 816-MWe plant would require approximately 170 ac (69 ha) of land. Additional onsite land may be needed to support a rail spur and yard, as well as approximately 140 ac (57 ha) of land area for waste disposal.

Offsite land use impacts would occur from coal mining, in addition to land use impacts from the construction and operation of the new power plant. Scaling from GEIS estimates, approximately 18,260 ac (7,390 ha) of land could be affected by mining coal and waste disposal to support the

Environmental Impacts of Alternatives

coal-fired alternative during its operational life (NRC, 1996); however, most of the land in existing coal mining areas has already experienced some level of disturbance. The elimination of the need for uranium mining to supply fuel for the CNS would partially offset this offsite land use impact. Scaling from GEIS estimates, approximately 816 ac (330 ha) of land used for uranium mining and processing would no longer be needed.

Based on this information, land use impacts could range from MODERATE to LARGE. Some portion of this impact could be mitigated by constructing the rail spur in existing ROWs.

8.1.6.2 *Socioeconomics*

Socioeconomic impacts are defined in terms of changes to the demographic and economic characteristics and social conditions of a region. For example, the number of jobs created by the construction and operation of a new coal-fired power could affect regional employment, income, and expenditures. Job creation is characterized by two types: (1) construction-related jobs, which are transient, short in duration, and less likely to have a long-term socioeconomic impact; and (2) operation-related jobs in support of power plant operations, which have the greater potential for permanent, long-term socioeconomic impacts. Workforce requirements of power plant construction and operation for the coal-fired alternative were determined in order to measure their possible effects on current socioeconomic conditions.

Based on GEIS estimates, NPPD projected a peak construction workforce of 979 to 2,040 workers would be required to construct the coal-fired alternative at CNS (NPPD, 2008). During the construction period, the communities surrounding the plant site would experience increased demand for rental housing and public services. The relative economic contributions of these relocating workers to local business and tax revenues would vary over time.

After construction, local communities may be temporarily affected by the loss of construction jobs and associated loss in demand for business services. In addition, the rental housing market could experience increased vacancies and decreased prices. As noted in the GEIS, the socioeconomic impacts at a rural construction site could be larger than at an urban site, because the workforce would need to relocate closer to the construction site. Although the CNS site is a rural site, it is located near the city of Omaha, Nebraska (75 mi), meaning that these effects may be somewhat lessened if workers commute to the site instead of relocating closer. Construction impacts could range from MODERATE to LARGE.

NPPD estimated an operational workforce of 163 to 204 workers for the 816-MWe CNS based on GEIS estimates (NPPD, 2008). The NPPD estimate appears reasonable and is consistent with trends calling for decreased workforces at power facilities. Even at a rural site like CNS, impacts are unlikely to be large. Operations impacts would likely be in the range of SMALL to MODERATE.

8.1.6.3 *Transportation*

During construction, approximately 2,000 workers would be commuting to the site. In addition to commuting workers, trucks would transport construction materials and equipment to the worksite increasing the amount of traffic on local roads. The increase in vehicular traffic would peak during shift changes resulting in temporary levels of service impacts and delays at intersections. Trains or barges could also be used to deliver large components to the CNS site, which could require the construction of a rail spur or a dock, as well as possible dredging in the Missouri River, if barge delivery is chosen. Transportation impacts are likely to be in the range of MODERATE to LARGE during construction.

Transportation impacts would be greatly reduced after construction, but would not disappear during plant operations. The maximum number of plant operating personnel commuting to CNS would be approximately 200 workers. Frequent deliveries of coal and limestone by rail (if rail delivery is used) would add to the overall transportation impact. Onsite coal storage would make it possible to receive several trains per day. Limestone delivered by rail could also add additional traffic (though considerably less traffic than that generated by coal deliveries).

The coal-fired alternative would likely create SMALL to MODERATE transportation impacts.

8.1.6.4 *Aesthetics*

The aesthetics impact analysis focuses on the degree of contrast between the coal-fired alternative and the surrounding landscape and the visibility of the coal plant.

The coal-fired alternative would be up to 200 feet (ft) (61 meters (m)) tall with an exhaust stack up to 500 ft (152 m) and may be visible offsite in daylight hours. The coal-fired plant, however, would be shorter than the current CNS reactor building, which stands at 290 ft (88 m), with a release point at 325 ft (99 m). The assumed mechanical draft towers would generate condensate plumes, but these would be shorter than the plumes from the natural draft tower alternative. Noise and light from plant operations, as well as lighting on plant structures, may be detectable offsite.

Impacts could be moderated because the higher elevation ridges along the river valley may make it difficult to see or hear the plant outside of the river valley. Overall, aesthetic impacts associated with the coal-fired alternative would likely be designated as SMALL to MODERATE.

8.1.6.5 *Historic and Archaeological Resources*

Cultural resources are the indications of human occupation and use of the landscape as defined and protected by a series of Federal laws, regulations, and guidelines. Prehistoric resources are physical remains of human activities that predate written records; they generally consist of artifacts that may alone or collectively yield information about the past. Historic resources consist of physical remains that postdate the emergence of written records; in the United States, they are architectural structures or districts, archaeological objects, and archaeological features dating from 1492 and later. Ordinarily, sites less than 50 years old are not considered historic, but exceptions can be made for such properties if they are of particular importance, such as structures associated with the development of nuclear power or Cold War themes. American Indian resources are sites, areas, and materials important to American Indians for religious or heritage reasons. Such resources may include geographic features, plants, animals, cemeteries, battlefields, trails, and environmental features. The cultural resource analysis encompassed the power plant site and adjacent areas that could potentially be disturbed by the construction and operation of alternative power plants.

The potential for historic and archaeological resources can vary greatly depending on the location of the proposed site. To consider a project's effects on historic and archaeological resources, any proposed areas will need to be surveyed to identify and record historic and archaeological resources, identify cultural resources (e.g., traditional cultural properties), and develop possible mitigation measures to address any adverse effects from ground disturbing activities. Studies will be needed for all areas of potential disturbance at the proposed plant site and along associated corridors where new construction will occur (e.g., roads, transmission corridors, rail lines, or other ROWs). In most cases, project proponents should avoid areas with the greatest sensitivity.

Environmental Impacts of Alternatives

CNS is situated in an area where historic and archaeological resources could be located several feet beneath the ground surface. As noted in Section 4.9.6, NPPD conducted a Phase 1A survey of the CNS site in 2007 and 2008. NPPD has also developed a Cultural Resources Protection Plan which calls for surveys to be conducted by a qualified archaeologist in areas deemed sensitive prior to work commencing. The plan also includes an inadvertent discovery (stop work) provision to ensure that proper notification is taken to protect these resources should they be discovered. Since NPPD conducted a survey and has established a protection plan, the impact for a coal-fired alternative at the CNS site would be designated as SMALL.

8.1.6.6 *Environmental Justice*

The environmental justice impact analysis evaluates the potential for disproportionately high and adverse human health and environmental effects on minority and low-income populations that could result from the construction and operation of a new coal-fired power plant. Adverse health effects are measured in terms of the risk and rate of fatal or nonfatal adverse impacts on human health. Disproportionately high and adverse human health effects occur when the risk or rate of exposure to an environmental hazard for a minority or low-income population is significant and exceeds the risk or exposure rate for the general population or for another appropriate comparison group. The minority and low-income populations are subsets of the general public residing around the site, and all are exposed to the same hazards generated from various power plant operations.

Minority and low-income populations could be affected by the construction and operation of a new coal-fired power plant. For example, increased demand for rental housing during construction could disproportionately affect low-income populations. Nevertheless, impacts on minority and low-income populations from the construction and operation of a coal-fired power plant alternative could range from SMALL to MODERATE.

8.1.7 **Waste Management**

Coal combustion generates several waste streams including ash (a dry solid) and sludge (a semi-solid by-product of emission control system operation). The NRC staff estimates that an 816-MWe power plant would generate annually a total of 326,000 tons (296,000 MT) of dry solid ash and scrubber sludge. Much of this waste would be recycled. Disposal of the remaining waste from the 20-year operation of this alternative would require approximately 141 ac (57 ha). Disposal of the remaining waste could noticeably affect land use and ground water quality, but with a proper siting in accordance with the Title 132, Chapter 4 standards of the NAC, implementation of the monitoring and management practices, it would not destabilize resources. After closure of the waste site and revegetation, the land could be available for other uses.

The impacts from waste generated during operation of this coal-fired alternative would be designated as MODERATE; the impacts would be clearly visible but would not destabilize important resources.

Impacts from waste generated during the construction stage would be short-lived. The amount of the construction waste is small compared to the amount of waste generated during the operational stage, and most could be recycled. Overall, the impacts from waste generated during the construction stage would be designated as SMALL.

The NRC staff, therefore, concludes that waste management impacts from construction and operation of this alternative would be MODERATE.

Table 8-1 provides a summary of the environmental impacts of the supercritical coal-fired alternative compared to continued operation of CNS.

Table 8-1. Summary of Environmental Impacts of the Supercritical Coal-Fired Alternative Compared to Continued Operation of Cooper Nuclear Station

	Supercritical Coal-Fired Generation	Continued CNS Operation
Air quality	MODERATE	SMALL
Ground water	SMALL	SMALL
Surface water	SMALL	SMALL
Aquatic and terrestrial resources	SMALL to MODERATE	SMALL
Human health	SMALL	SMALL
Socioeconomics	SMALL to LARGE	SMALL
Waste management	MODERATE	SMALL

8.2 NATURAL GAS-FIRED COMBINED-CYCLE GENERATION

In this section, the environmental impacts of natural gas-fired combined-cycle generation are evaluated at the CNS site.

Natural gas fueled 22 percent of electric generation in the United States in 2007 (the most recent year for which data are available), accounting for the second greatest share of electrical power after coal (EIA, 2009b). Like coal-fired power plants, natural gas-fired plants may be affected by perceived or actual action to limit GHG emissions, although they produce markedly fewer GHGs per unit of electrical output than coal-fired plants. Natural gas-fired power plants are feasible, commercially available options for providing electrical generating capacity beyond CNS's current license expiration.

Combined-cycle power plants differ significantly from coal-fired and existing nuclear power plants. Combined-cycle power plants derive the majority of their electrical output from a gas-turbine cycle, and then generate additional power—without burning any additional fuel—through a second, steam-turbine cycle. The first, gas turbine stage (similar to a large jet engine) burns natural gas which turns a drive shaft that powers an electric generator. The exhaust gas from the gas turbine is still hot enough, however, to boil water to steam. Ducts carry the hot exhaust to a heat recovery steam generator, which produces steam to drive a steam turbine and produce additional electrical power. The combined-cycle approach is significantly more efficient than any one cycle on its own; thermal efficiency can exceed 60 percent. Since the natural gas-fired alternative derives much of its power from a gas turbine cycle, and because it wastes less heat than either the coal-fired alternative or the existing CNS, it requires significantly less cooling water and smaller cooling towers than the coal-fired alternative discussed in Section 8.1.

In order to replace the 816-MWe that CNS currently supplies, the NRC staff selected a gas-fired alternative that uses two General Electric S107H combined-cycle generating units. While any number of commercially available combined-cycle units could be installed in a variety of combinations to replace the power currently produced by CNS, the S107H is a highly efficient model that will help to minimize environmental impacts. Other manufacturers, like Siemens,

Environmental Impacts of Alternatives

offer similarly high efficiency models. This gas-fired alternative produces a net 400 MWe per unit. Two units produce a total of 800 MWe, or nearly the same net output as the existing CNS.

The combined-cycle alternative operates at a heat rate of 5,690 Btu/kWh, or nearly 60 percent thermal efficiency (GE, 2007). As noted above, this gas-fired alternative would require much less cooling water than CNS, because it operates at a higher thermal efficiency and because it requires much less water for steam cycle condenser cooling. Cooling towers for this alternative would likely be mechanical draft-type towers approximately 65 ft (20 m) high.

In addition to cooling towers, other visible structures onsite include the turbine buildings and heat recovery steam generators (HRSGs) (which may be enclosed in a single building), two exhaust stacks, an electrical switchyard, and possibly, equipment associated with a natural gas pipeline, like a compressor station. Based on GEIS estimates, NPPD indicated that this 800-MWe plant would require approximately 90 ac (36 ha).

This 800-MWe power plant would consume 34 billion cubic feet (ft³) (964 million cubic meters (m³)) of natural gas annually assuming an average heat content of 1,029 British thermal units per cubic feet (Btu/ft³) (EIA, 2009c). Natural gas would be extracted from the ground through wells, then treated to remove impurities (like hydrogen sulfide) and blended to meet pipeline gas standards, before being piped through the interstate pipeline system to the power plant site. This gas-fired alternative would produce relatively little waste, primarily in the form of spent catalysts used for emissions controls.

Environmental impacts from the gas-fired alternative will be greatest during construction. Site crews will clear vegetation from the site, prepare the site surface, and begin excavation before other crews begin actual construction on the plant and any associated infrastructure, including a pipeline spur to serve the plant and electricity transmission infrastructure connecting the plant to existing transmission lines. Constructing the gas-fired alternative on NPPD property would allow the gas-fired alternative to make use of CNS's existing transmission system.

8.2.1.1 Air Quality

Nemaha County, Nebraska is in EPA Region 7. All counties in the State of Nebraska are in attainment for all criteria pollutants, except Douglas County, which is a maintenance county for lead. A new gas-fired generating plant developed at the CNS site would qualify as a new major-emitting industrial facility and require a New Source Review (NSR)/Prevention of Significant Deterioration of Air Quality review under the CAA, adopted by NDEQ in Title 129 of the NAC (EPA, 2008). The natural gas-fired plant would need to comply with the standards of performance for electric utility steam generating units set forth in 40 CFR Part 60 Subpart Da.

Subpart P of 40 CFR Part 51 contains the visibility protection regulatory requirements, including the review of the new sources that would be constructed in the attainment or unclassified areas and may affect visibility in any Class I Federal area. If a gas-fired alternative was located close to a mandatory Class I Federal area, additional air pollution control requirements would imply. There are no mandatory Class I Federal areas in the State of Nebraska and the closest mandatory Class I Federal area is Hercules-Glades Wilderness Area, which is located 295 mi southeast from CNS in the State of Missouri.

The staff projects the following emissions for a gas-fired alternative based on data published by the EIA, EPA, and on performance characteristics for this alternative and its emissions controls:

- Sulfur oxides (SO_x) – 60 tons (54 MT) per year
- Nitrogen oxides (NO_x) – 192 tons (177 MT) per year
- Carbon monoxide (CO) – 40 tons (36 MT) per year
- Total suspended particles (TSP) – 34 tons (30 MT) per year
- Particulate matter (PM) PM₁₀ – 34 tons (30 MT) per year
- Carbon dioxide (CO₂) – 2,050,000 tons (1,860,000 MT) per year

A new natural gas-fired plant would have to comply with Title IV of the CAA (42 U.S.C. § 7651) reduction requirements for SO₂ and NO_x, which are main precursors of acid rain and the major cause of reduced visibility. Title IV establishes maximum SO₂ and NO_x emission rates from the existing plants and a system of the SO₂ emission allowances that can be used, sold, or saved for future use by the new plants.

8.2.1.2 Sulfur and Nitrogen Oxides

As stated above, the new natural gas-fired alternative would produce 60.02 tons (54.45 MT) per year of SO_x and 192.42 tons (176.56 MT) per year of NO_x based on the use of the dry, low NO_x combustion technology and use of the SCR in order to significantly reduce NO_x emissions.

The new plant would be subjected to the continuous monitoring requirements of SO_x, NO_x, and CO₂ specified in 40 CFR Part 75. The natural gas-fired plant would emit approximately 2.1 million tons (approximately 1.9 million MT) per year of unregulated CO₂ emissions.

8.2.1.3 Particulates

The new natural gas-fired alternative would produce 33.54 tons (30.43 MT) per year of TSP, all of which would be emitted as PM₁₀.

8.2.1.4 Hazardous Air Pollutants

The EPA issued in December 2000 regulatory findings (EPA, 2000b) on emissions of HAPs from electric utility steam-generating units, which identified that natural gas-fired plants emit HAPs such as arsenic, formaldehyde, and nickel, and stated that:

Also in the utility RTC (Report to Congress), the EPA indicated that the impacts due to HAP emissions from natural gas-fired electric utility steam generating units were negligible based on the results of the study. The Administrator finds that regulation of HAP emissions from natural gas-fired electric utility steam generating units is not appropriate or necessary.

The new natural gas-fired alternative would produce 33.25 tons (30.16 MT) per year of the TSP as PM₁₀ emissions

8.2.1.5 Construction Impacts

Activities associated with the construction of the new natural gas-fired plant onsite or offsite CNS would cause some additional, temporary air effects as a result of equipment emissions and fugitive dust from operation of the earth-moving and material handling equipment. Emissions from workers' vehicles and motorized construction equipment exhaust would be temporary. The construction crews would employ dust-control practices in order to control and reduce fugitive dust. The NRC staff concludes that the impact of vehicle exhaust emissions and fugitive dust from operation of the earth-moving and material handling equipment would be SMALL.

The overall air quality impacts of a new natural gas-fired plant located at the CNS site would be designated as SMALL to MODERATE.

8.2.2 Ground Water Use and Quality

The use of ground water for a natural gas-fired combined-cycle plant would likely be limited to supply wells for drinking water and possibly filtered service water. Total usage would likely be much less than CNS because fewer workers would be onsite and because the gas-fired alternative would have fewer auxiliary systems requiring service water.

No effects on ground water quality would be apparent except during the construction phase due to temporary dewatering and runoff control measures. Because of the temporary nature of construction and the likelihood of reduced ground water usage during operation, the impact of the coal-fired alternative would be designated as SMALL.

8.2.3 Surface Water Use and Quality

Maximum withdrawals of surface water from the Missouri River would be much less for a gas-fired plant than the 668,000 gpm (2 cubic meters per second (m^3/s)) maximum currently used by CNS; however, by switching from the open-cycle cooling system currently used by CNS to a closed-cycle cooling system used by the proposed alternative, consumptive water losses will increase. Since the consumptive loss will remain less than 0.1 percent of the average annual flow of the Missouri River, the NRC staff concludes that the impact of surface water use would be designated as SMALL.

A new gas-fired plant would be required to obtain an NPDES permit from the NDEQ for regulation of industrial wastewater, stormwater, and other discharges. Assuming the plant operates within the limits of this permit, the impact from any possible runoff cooling tower blowdown, stormwater discharge, and effluent discharges on surface water quality would be designated as SMALL.

8.2.4 Aquatic and Terrestrial Ecology

8.2.4.1 Aquatic Ecology

Compared to the existing CNS plant, aquatic ecology actually benefits from the onsite gas-fired alternative, as the combined-cycle plant with cooling towers rejects significantly less heat to the environment, thus requiring less water. The number of fish and other aquatic organisms affected by impingement, entrainment, and thermal impacts will be less than those associated with license renewal because water consumption and heat rejected to the Missouri River are substantially lower. Some temporary impacts to aquatic organisms might occur due to any construction or effluent discharge to the river, but the NRC assumes that the appropriate agencies would be monitoring and regulating such activities. Although the number of affected organisms would be substantially less than for license renewal, the NRC level of impact for license renewal is already small, and so the NRC expects that the levels of impact for impingement, entrainment, and thermal effects would also be designated as SMALL.

8.2.4.2 Terrestrial Ecology

Constructing the natural gas alternative will require 90 ac (36 ha) of land. These land disturbances form the basis for impacts to terrestrial ecology.

Impacts to terrestrial ecology will be minor because the selected site has been previously disturbed and is mostly used for agricultural activities. (Gas extraction and collection will also affect terrestrial ecology in offsite gas fields, although much of this land is likely already disturbed by gas extraction, and the incremental effects of this alternative on gas field terrestrial ecology are difficult to gauge.)

Construction of the two natural gas units and mechanical draft cooling towers could result in the loss of farmland and possible changes to drainage patterns of water into and out of the wetlands on the CNS site, which could affect food supply and habitat of native wildlife. Land disturbance could also affect wetland vegetation, but these effects are not expected to be significant. Operation of the cooling towers would produce a visible plume and cause some deposition of dissolved solids on surrounding vegetation (including some wetlands) and soil from cooling tower drift; however, the GEIS indicates that the impact of cooling towers on agricultural crops is of small significance, and most of the land surrounding the cooling towers is farmland.

Construction of the 40-mi gas pipeline could lead to a conversion of forested lands used by terrestrial wildlife to a mowed ROW as well as the possible loss of cropland from agricultural production, which could impact wildlife that use the croplands as a food source (NPPD, 2008). Siting of the pipeline may occur partially in wetlands, which could impact wildlife that use wetlands habitat. Pipeline construction may fragment surrounding habitat and may increase edge habitat, which may have adverse impacts on forest interior dwelling species, including migratory songbirds. Threatened and endangered species may also be affected by construction of the gas pipeline. Impacts from construction of the pipeline are expected to be MODERATE.

Based on this information, impacts to terrestrial resources could range from SMALL to MODERATE.

8.2.5 Human Health

Like the coal-fired alternative discussed above, a gas-fired plant would emit criteria air pollutants, but generally in smaller quantities (except NO_x, which requires additional controls to reduce emissions). Human health effects of gas-fired generation are generally low, although in Table 8-2 of the GEIS (NRC, 1996), the NRC staff identified cancer and emphysema as potential health risks from gas-fired plants. NO_x emissions contribute to ozone formation, which in turn contributes to human health risks. Emission controls on this gas-fired alternative maintain NO_x emissions well below air quality standards established for the purposes of protecting human health, and emissions trading or offset requirements mean that overall NO_x in the region will not increase. Health risks to workers may also result from handling spent catalysts that may contain heavy metals.

Overall, human health risks to occupational workers and to members of the public from gas-fired power plant emissions sited at CNS would be less than the risks described for a coal-fired alternative and, therefore, would likely be designated as SMALL.

8.2.6 Socioeconomics

8.2.6.1 Land Use

As discussed in Section 8.1.6, the GEIS generically evaluates the impacts of nuclear power plant operations on land use, both on and off each power plant site. The analysis of land use impacts focuses on the amount of land area that would be affected by the construction and operation of a two-unit natural gas-fired combined-cycle power plant at the CNS site.

Environmental Impacts of Alternatives

Based on GEIS estimates, NPPD indicated that approximately 90 ac (36 ha) of land would be needed to support a natural gas-fired alternative to replace CNS (NPPD, 2008). This amount of land use would include other plant structures and associated infrastructure, and is unlikely to exceed 90 ac (36 ha), excluding land for natural gas wells and collection stations. Land use impacts from construction would be designated as SMALL.

In addition to onsite land requirements, land would be required offsite for natural gas wells and collection stations. Scaling from GEIS estimates, approximately 2,988 ac (1,209 ha) would be required for wells, collection stations, and pipelines to bring the gas to the plant. Most of this land requirement would occur on land where gas extraction already occurs. In addition, some natural gas could come from outside the United States and be delivered as liquefied gas.

The elimination of uranium fuel for the CNS could partially offset offsite land requirements. Scaling from GEIS estimates, the NRC staff estimated that approximately 816 ac (330 ha) would not be needed for mining and processing uranium during the operating life of the plant. Overall land use impacts from a gas-fired power plant would be in the range of SMALL to MODERATE.

8.2.6.2 Socioeconomics

Socioeconomic impacts are defined in terms of changes to the demographic and economic characteristics and social conditions of a region. For example, the number of jobs created by the construction and operation of a new natural gas-fired power plant could affect regional employment, income, and expenditures. Two types of jobs are created by this alternative: (1) construction-related jobs, which are transient, short in duration, and less likely to have a long-term socioeconomic impact; and (2) operation-related jobs in support of power plant operations, which have the greater potential for permanent, long-term socioeconomic impacts. Workforce requirements of power plant construction and operations for the natural gas-fired power plant alternative were determined in order to measure their possible effect on current socioeconomic conditions.

The socioeconomic impacts from constructing and operating a gas-fired plant would have little noticeable effect. Compared to the coal-fired alternative, the small size of the construction and operations workforce would have little or no socioeconomic impact. As discussed in Section 8.1.6.2, the socioeconomic impact of operations of the coal-fired alternative would likely be in the range of SMALL to MODERATE.

Based on GEIS estimates, NPPD projected a maximum construction workforce of 979 (NPPD, 2008). During construction of a gas-fired plant, the communities surrounding the power plant site would experience increased demand for rental housing and public services. The relative economic effect of construction workers on local economy and tax base would vary over time.

After construction, local communities may be temporarily affected by the loss of construction jobs and associated loss in demand for business services, and the rental housing market could experience increased vacancies and decreased prices. As noted in the GEIS, the socioeconomic impacts at a rural construction site could be larger than at an urban site, because the workforce may have to move to be closer to the construction site. The impact of construction on socioeconomic conditions could range from SMALL to MODERATE.

Based on GEIS estimates, NPPD estimated a power plant operations workforce of approximately 125 (NPPD, 2008). The NPPD estimate appears reasonable and is consistent

with trends toward lowering labor costs by reducing the size of power plant operations workforces. The small number of operations workers could have a noticeable effect on socioeconomic conditions in the region, however, socioeconomic impacts associated with the operation of a gas-fired power plant at the CNS site would be designated as SMALL.

8.2.6.3 *Transportation*

Transportation impacts associated with construction and operation of a two-unit, gas-fired power plant would consist of commuting workers and truck deliveries of construction materials to the CNS site. During construction, up to 1,000 workers would be commuting to the site. In addition to commuting workers, trucks would transport construction materials and equipment to the worksite increasing the amount of traffic on local roads. The increase in vehicular traffic would peak during shift changes resulting in temporary levels of service impacts and delays at intersections. Pipeline construction and modification to existing natural gas pipeline systems could also have an impact.

During plant operations, transportation impacts would almost disappear. According to NPPD, approximately 125 workers would be needed to operate the gas-fired power plant. Since fuel is transported by pipeline, most transportation infrastructure would experience little increased use from plant operations.

The transportation infrastructure would experience little to no increased use from plant operations. Overall, the gas-fired alternative would have a SMALL impact on transportation conditions in the region around the CNS.

8.2.6.4 *Aesthetics*

The aesthetics impact analysis focuses on the degree of contrast between the natural gas-fired alternative and the surrounding landscape and the visibility of the gas-fired plant.

The two gas-fired units could be approximately 100 ft (30 m) tall, with two exhaust stacks up to 175 ft (53 m) tall. Some structures may require aircraft warning lights. Aesthetic impacts may be mitigated as higher elevations and vegetation along the river valley could make it difficult to see or hear the plant outside of the river valley. Power plant infrastructure would generally be smaller and less noticeable than CNS, which has a reactor building height of 290 ft (88 m). Mechanical draft cooling towers would generate condensate plumes and operational noise. Noise during power plant operations would be limited to industrial processes and communications. Pipelines delivering natural gas fuel could be audible offsite near compressors.

In general, aesthetic changes would be limited to the immediate vicinity of the CNS. Impacts would likely be designated as SMALL to MODERATE.

8.2.6.5 *Historic and Archaeological Resources*

The same considerations as discussed in Section 8.1.6.4 for impact of the coal-fired alternative on historic and archaeological resources apply to the gas-fired alternative.

The impact for a gas-fired alternative at the CNS site would be SMALL.

8.2.6.6 *Environmental Justice*

The environmental justice impact analysis evaluates the potential for disproportionately high and adverse human health and environmental effects on minority and low-income populations that could result from the construction and operation of a new natural gas-fired power plant. Adverse health effects are measured in terms of the risk and rate of fatal or nonfatal adverse impacts on human health. Disproportionately high and adverse human health effects occur when the risk or rate of exposure to an environmental hazard for a minority or low-income population is significant and exceeds the risk or exposure rate for the general population or for another appropriate comparison group. The minority and low-income populations are subsets of the general public residing around the site, and all are exposed to the same hazards generated from various power plant operations.

Minority and low-income populations could be affected by the construction and operation of a new natural gas-fired power plant. Some of these effects have been identified in resource areas discussed in this section. For example, increased demand for rental housing during construction could disproportionately affect low-income populations. Nevertheless, impacts on minority and low-income populations from the construction and operation of a natural gas-fired power plant alternative could range from SMALL to MODERATE.

8.2.7 **Waste Management**

During the construction stage of the natural gas-fired, combined-cycle generation alternative, land clearing and other construction activities would generate waste that can be recycled, disposed onsite or shipped to the offsite waste disposal facility. Because the alternative would be constructed on the previously disturbed CNS site, the amounts of wastes produced during land clearing would be reduced.

During the operational stage, spent SCR catalysts, which are used to control NO_x emissions from the natural gas-fired plants, would make up the majority of the waste generated by this alternative.

The NRC staff concluded in the GEIS (NRC, 1996) that a natural gas-fired plant would generate minimal waste and the waste impacts would be SMALL for a natural gas-fired alternative located at the CNS site or offsite.

Table 8-2 provides a summary of the environmental impacts of the natural gas-fired alternative compared to continued operation of CNS.

Table 8-2. Summary of Environmental Impacts of the Natural Gas-Fired, Combined-Cycle Generation Alternative Compared to Continued Operation of Cooper Nuclear Station

	Natural Gas Combined-Cycle Generation	Continued CNS Operation
Air quality	SMALL to MODERATE	SMALL
Ground water	SMALL	SMALL
Surface water	SMALL	SMALL
Aquatic and terrestrial resources	SMALL to MODERATE	SMALL
Human health	SMALL	SMALL
Socioeconomics	SMALL to MODERATE	SMALL
Waste management	SMALL	SMALL

8.3 COMBINATION ALTERNATIVE

In this section, the environmental impacts of a combination of alternatives are evaluated. This combination will include a portion of the combined-cycle gas-fired capacity identified in Section 8.2, an energy conservation capacity component, and a wind power component. This alternative requires new construction of a single gas-fired unit installed at the CNS site and the construction of roughly 250 wind turbines at an offsite location, or several different offsite locations.

In this alternative, a portion of CNS's output—250 MWe—would be replaced by conservation. Inclusion of this conservation component of the alternative is based on Nebraska's energy efficiency goals for the year 2012. Wind turbines constructed offsite will account for roughly 150 MWe of capacity and 400 MWe will come from one GE S107H combined-cycle power plant. The only major construction anticipated would be at the current CNS site where the combined-cycle gas-fired power plant would be constructed and the wind turbine construction at an offsite location (including the ROW for new transmission lines). No major construction should be necessary for the conservation portion.

The appearance of the gas-fired facility would be similar to that of the full gas-fired alternative considered in Section 8.2, though only one unit would be constructed. The NRC staff estimates that it would require about 50 percent of the space necessary for the alternative considered in Section 8.2, and that all construction effects—as well as operational aesthetic, fuel-cycle, air quality, socioeconomic, land use, environmental justice, and water consumption effects—would scale accordingly.

8.3.1 Air Quality

Nemaha County, Nebraska, where CNS is located, is in EPA Region 7. All counties in the State of Nebraska are in attainment for all criteria pollutants. Douglas County is a maintenance county for lead. NDEQ is responsible for managing and monitoring air quality in the State of Nebraska.

This alternative is a combination of one 400-MWe natural gas-fired, combined-cycle generating unit, constructed onsite, 250 MWe equivalent of conservation and demand-side management, and 500 MWe of wind capacity constructed offsite, possibly at several different locations.

Environmental Impacts of Alternatives

A new gas-fired generating plant on the CNS site would qualify as a new major-emitting industrial facility and requires an NSR under the CAA. Nebraska air quality regulations require that a permit must be obtained before construction of the new major-emitting industrial facility, which will be issued only if the new plant includes pollution control measures that reflect the best available control technology (BACT). The natural gas-fired plant must comply with the standards of performance for electric utility steam generating units set forth in 40 CFR Part 60 Subpart Da.

Subpart P of 40 CFR Part 51 contains the visibility protection regulatory requirements, including the review of the new sources that would be constructed in the attainment or unclassified areas and may affect visibility in any Class I Federal area (40 CFR 51.307). If a gas-fired unit were located close to a mandatory Class I Federal area, additional air pollution control requirements would imply. There are no mandatory Class I Federal areas in the State of Nebraska. The closest is Hercules-Glades Wilderness Area, which is located 295 mi southeast of CNS in the State of Missouri.

According to published EIA data, the EPA emission factors, performance characteristics for this alternative, and implemented emission controls, emissions from the one natural gas-fired unit with a capacity of 400 MWe built at the CNS site would be:

- Sulfur oxides (SO_x) – 30 tons (27 MT) per year
- Nitrogen oxides (NO_x) (with SCR) – 96 tons (87 MT) per year
- Carbon monoxide (CO) – 20 tons (18 MT) per year
- Total suspended particles (TSP) – 17 tons (15 MT) per year
- Particulate matter (PM) PM₁₀ – 17 tons (15 MT) per year
- Carbon dioxide (CO₂) – 1,030,000 tons (964,000 MT) per year

The natural gas-fired component of this alternative would emit 17 tons (15 MT) per year of PM₁₀.

In December 2000, the EPA issued regulatory findings (EPA, 2000b) on emissions of HAPs from electric utility steam-generating units. The findings show that natural gas-fired plants emit HAPs such as arsenic, formaldehyde, and nickel, and state that:

Also in the utility RTC (Report to Congress), the impacts due to HAP emissions from natural gas-fired electric utility steam generating units were negligible based on the results of the study. The Administrator finds that regulation of HAP emissions from natural gas-fired electric utility steam generating units is not appropriate or necessary.

The new natural gas-fired alternative would produce 16.77 tons (15.21 MT) per year of TSP, all of which would be emitted as PM₁₀ emissions.

The natural gas-fired plant would have to comply with CAA reduction requirements for SO₂ and NO_x (42 U.S.C. § 7401 et seq.), which are the main precursors of acid rain and major causes of reduced visibility. Title IV establishes maximum SO₂ and NO_x emission rates from the existing plants and a system of the SO₂ emission allowances that can be used, sold, or saved for future use by the new plants.

As stated above, the new natural gas-fired unit would produce 30.01 tons (27.23 MT) per year of SO_x and 96.21 tons (87.28 MT) per year of NO_x based on the use of the dry, low NO_x combustion technology and use of the SCR in order to significantly reduce NO_x emissions.

The natural gas-fired component of this alternative would be subjected to the continuous monitoring requirements of SO₂, NO_x, and CO₂ specified in 40 CFR Part 75. The natural gas-fired plant would emit approximately 1 million tons (0.9 million MT) per year of unregulated CO₂ emissions. In response to the Consolidated Appropriations Act of 2008, the EPA has proposed a rule that requires mandatory reporting of GHG emissions from large sources (applicable to the presented alternative) in the United States that would allow collection of accurate and comprehensive emissions data to inform future policy decisions. The EPA proposes that suppliers of fossil fuels or industrial GHGs, manufacturers of vehicles and engines, and facilities that emit 25,000 MT or more per year of GHG emissions submit annual reports to the EPA. The gases covered by the proposed rule are CO₂, methane (CH₄), nitrous oxide (N₂O), hydrofluorocarbons (HFC), perfluorocarbons (PFC), sulfur hexafluoride (SF₆), and other fluorinated gases including nitrogen trifluoride (NF₃) and hydrofluorinated ethers (HFE). NPPD states in the "Statement on Addressing the Challenge of Global Climate Change" that it is voluntarily engaged in lowering the GHG emissions (NPPD, 2008). In the 2008 Integrated Resource Plan, NPPD outlines the environmental goals of the company with emphasis on lowering GHG emissions and obtaining 10 percent of the energy supply from renewable resources by 2020, wind being primarily the source of power (NPPD, 2008).

There would be no operating emissions from the wind or conservation components of the combination alternative.

Activities associated with the construction of the new natural gas-fired plant onsite at CNS and wind turbines offsite would cause some additional air effects as a result of equipment emissions and fugitive dust from operation of the earth-moving and material handling equipment. Vehicles of workers and construction motorized equipment exhaust emissions would be temporary. The construction crews would employ dust-control practices in order to control and reduce fugitive dust, which would be temporary in nature. The NRC staff concludes that the impact of vehicle exhaust emissions and fugitive dust from operation of earth-moving and material handling equipment would be designated as SMALL. Implementation of the conservation portion of this alternative would have no noticeable effects on air quality, though some weatherization programs may cause existing indoor air quality problems to become worse.

The overall air-quality impacts of the combination alternative consisting of a natural gas-fired plant located at the CNS site, energy conservation, and an offsite wind component would be in the range of SMALL to MODERATE.

8.3.2 Ground Water Use and Quality

If the onsite gas-fired plant continued to use ground water for drinking water and service water, the total usage would likely be much less than CNS uses, because fewer workers are onsite and because the gas-fired unit would have fewer auxiliary systems requiring service water. The current average withdrawal rate is 250 gpm, and pumping tests indicate this rate would not cause an effect on nearby supply wells. A reduction in this withdrawal rate means that impacts of the combination alternative would remain SMALL.

8.3.3 Surface Water Use and Quality

Using a combined alternative with conservation as a major component will reduce the amount of surface water consumed for cooling purposes from the already low consumption of the wholly gas-fired alternative considered in Section 8.2. The maximum consumptive use would be reduced to a fraction of the surface water withdrawn by the open-cycle cooling system currently

in use by CNS. This represents less than 0.001 percent of the average annual flow rate in the Missouri River. The impact of this withdrawal would be SMALL.

8.3.4 Aquatic and Terrestrial Ecology

8.3.4.1 Aquatic Ecology

In order to minimize impacts, NRC assumes that the cooling system for this gas-fired plant would involve closed-cycle cooling. The wind and conservation components would have no associated impingement, entrainment, and thermal impacts. The number of fish and other aquatic resource organisms affected by impingement, entrainment, and other impacts will be less than those associated with license renewal because water consumption and heat injected to the Missouri River would be substantially lower. Some temporary impacts to aquatic organisms might occur due to any construction that might occur or due to any effluent discharges to the river, but these activities would be monitored by the NDEQ under the project's NPDES permit. Although the number of affected organisms would be substantially less than for license renewal, the NRC level of impact for license renewal is already designated as SMALL, and so the NRC expects that the impact for impingement, entrainment, and thermal effects would also be SMALL.

8.3.4.2 Terrestrial Ecology

A combination alternative of a single natural gas-fired unit, a system using wind energy, and energy conservation would make use of existing disturbed land and possibly some farmland at the CNS site for the natural gas unit and the mechanical draft cooling tower. This alternative would also require land offsite for the gas pipeline and would require additional land offsite to accommodate the number of turbines necessary in a wind farm to offset the power generated by CNS.

This alternative would use a portion of the existing plant site land, switchyard, and transmission line system for construction of the gas-fired unit. Approximately 45 ac (18 ha) of land would be required on the CNS site to support a 400 MWe natural gas plant.

Impacts to terrestrial ecology from onsite construction of a single gas-fired unit with one mechanical draft cooling tower would be less than the impacts described for the two-unit gas-fired alternative. The impacts to farmland onsite would be approximately one-half of the impacts of the two-unit natural gas plant alternative. The drainage patterns of the wetland areas onsite may also be impacted, though again to a lesser degree than the two-unit gas alternative. These onsite impacts are expected to be minor. Impacts to terrestrial ecology from offsite construction of the 40-mi (64-km) long gas pipeline for a single gas-fired unit would be the same as for the two gas-fired unit alternative previously discussed (NPPD, 2008).

Based upon data in the GEIS, the wind farm component of the combination alternative producing 500 MWe of electricity would require approximately 32,000 ac (12,950 ha) spread over several offsite locations, with approximately 125 ac (51 ha) in actual use. The remainder of the land would remain in agriculture. Additional land may be needed for construction of transmission line corridors to connect to existing transmission line corridors.

Impacts to terrestrial ecology from construction of the wind farm portion of the combination alternative and any needed transmission lines could include loss of terrestrial habitat, an increase in habitat fragmentation and a corresponding increase in edge habitat, and may impact threatened and endangered species. The GEIS notes that habitat fragmentation may lead to a

decline in migrant bird populations. Bird mortality would increase from construction of the wind farm, although proper site selection for the wind farm could help to reduce bird strikes. The GEIS noted that wind farms typically do not cause significant adverse impacts to bird populations, although thousands of acres of wildlife habitat or agricultural land could be impacted, and disruptions could occur to wildlife migratory routes (NRC, 1996).

Based on this information, impacts to terrestrial resources could range from MODERATE to LARGE.

8.3.5 Human Health

The human health risks from a combination of alternatives include the effects already discussed in Section 8.2.5 for the combined-cycle gas-fired plant. The GEIS (NRC, 1996) notes that the environmental impacts of conservation and a demand-side management alternative are likely to be centered on indoor air quality. This is due to increased weatherization of the home in the form of extra insulation and reduced air turnover rates from the reduction in air leaks; however, the actual impact from the conservation alternative is highly site-specific and not yet well-established. For wind capacity, the GEIS notes that, except for a potential small number of occupational injuries, human health would not be affected by routine operations.

The human health risks from the combination of alternatives, although uncertain, are considered to be SMALL to MODERATE given that the construction and operation of the facilities are expected to comply with health-based Federal and State safety and emission standards.

8.3.6 Socioeconomics

8.3.6.1 Land Use

The GEIS generically evaluates the impacts of nuclear power plant operations on land use both on and off each power plant site. The analysis of land use impacts for a combination alternative focuses on the amount of land area that would be affected by the construction and operation of a single natural gas-fired unit power plant at the CNS site and at an offsite wind energy generating facility, and demand-side energy conservation.

Based on GEIS estimates, approximately 45 ac (18 ha) would be needed to support the single natural gas-fired unit portion of the combination alternative. Land use impacts from construction of the natural gas-fired power plant at CNS would be designated as SMALL.

In addition to onsite land requirements, land would be required offsite for natural gas wells and collection stations. Scaling from GEIS estimates, the natural gas-fired power plant at CNS could require 1,469 ac (594 ha) for wells, collection stations, and pipelines to bring the gas to the facility. Most of this land requirement would occur on land where gas extraction already occurs. In addition, some natural gas could come from outside of the United States and be delivered as liquefied gas.

The wind farm component of the combination alternative producing 500 MWe of electricity would require approximately a 32,000-ac (12,950-ha) spread over several locations with approximately 125 ac (51 ha) in actual use.

Land use impacts of an energy efficiency alternative would be designated as SMALL. Quickly replacing and disposing old inefficient equipment could generate waste material and increase the size of landfills; however, given the time for program development and implementation, the

Environmental Impacts of Alternatives

cost of replacements, and the average life of equipment, the replacement process would probably be gradual. Older equipment would simply be replaced by more efficient equipment (especially in the case of frequently replaced items, such as light bulbs). In addition, many items (such as home appliances and industrial equipment) have recycling value and would probably not be disposed of in landfills.

The elimination of uranium fuel for CNS could partially offset offsite land requirements. Scaling from GEIS estimates, approximately 816 ac (330 ha) would not be needed for mining and processing uranium during the operating life of the plant. Overall land use impacts from the combination alternative would range from SMALL to MODERATE.

8.3.6.2 Socioeconomics

As previously discussed, socioeconomic impacts are defined in terms of changes to the demographic and economic characteristics and social conditions of a region. For example, the number of jobs created by the construction and operation of a new single natural gas-fired power plant at CNS and the wind farm could affect regional employment, income, and expenditures. Job creation is characterized by two types: (1) construction-related jobs, which are transient, short in duration, and less likely to have a long-term socioeconomic impact; and (2) operation-related jobs in support of power generating operations, which have a greater potential for permanent, long-term socioeconomic impacts. The NRC staff conducted evaluations of construction and operations workforce requirements in order to measure their effect on current socioeconomic conditions.

Based on GEIS projections and a workforce of 1,200 for a 1,000-MWe plant, a single 400 MWe unit at CNS requires a peak estimated construction workforce of 490. Additional estimated construction workforce requirements for this combination alternative include 300 construction workers for the wind farm. The number of additional workers would cause a short-term increase in the demand for services and temporary (rental) housing in the region around the construction site.

After construction and depending on the size of the community, some local communities may be temporarily affected by the loss of the construction jobs and associated loss in demand for business services. The rental housing market could also experience increased vacancies and decreased prices. The impact of construction on socioeconomic conditions would be designated as SMALL.

Following construction, a single-unit gas-fired power plant at CNS could provide up to 63 jobs, based on NPPD estimates, or up to 64 jobs, based on GEIS estimates. Additional estimated operations workforce requirements for this combination alternative include 50 operations workers for the wind farm. Given the small numbers of operations workers at these facilities, socioeconomic impacts associated with the operation of the natural gas-fired power plant at CNS and the wind farm would be designated as SMALL.

Socioeconomic effects of an energy efficiency program would be SMALL. As noted in the GEIS, the program would require additional workers. Lower-income families could benefit from weatherization and insulation programs. This effect would be greater than the effect for the general population because low-income households experience home energy burdens more than four times larger than the average household (OMB, 2007).

8.3.6.3 *Transportation*

Transportation impacts would be **SMALL** because the number of employees commuting to the CNS site, where the gas-fired portion is located, would be small. Any transportation effects from the energy efficiency alternative would be widely distributed across the State, and would not be noticeable.

Construction and operation of a natural gas-fired power plant and wind farm would increase the number of vehicles on the roads in the vicinity of these facilities. During construction, cars and trucks would deliver workers, materials, and equipment to the worksites. The increase in vehicular traffic would peak during shift changes resulting in temporary levels of service impacts and delays at intersections. Pipeline construction and modification to existing natural gas pipeline systems could also have an impact. Highway delivery of large wind farm components may also cause impacts to traffic.

During plant operations, transportation impacts would almost disappear. Given the small numbers of operations workers at these facilities, levels of service impacts on local roads from the operation of the natural gas-fired power plant at CNS and at the wind farm, would be **SMALL**. Transportation impacts at the wind farm site would also depend on current road capacities and average daily traffic volumes.

8.3.6.4 *Aesthetics*

The aesthetics impact analysis focuses on the degree of contrast between the surrounding landscape and the visibility of the power plant.

A single natural gas-fired unit located at CNS would be approximately 100 ft (30 m) tall with an exhaust stack of at least 175 ft (53 m) tall, which is less noticeable than the current CNS reactor building at 290 ft (88 m). The impact would be moderated as higher elevations and vegetation along the river valley could make it difficult to see or hear the power plant outside of the river valley. Power plant infrastructure would generally be smaller and less noticeable than the CNS containment and turbine buildings. Mechanical draft cooling towers (if used) would generate condensate plumes and operational noise, which during power plant operations would be limited to noise from industrial processes and communications. In addition to power plant structures, construction of natural gas pipelines would have a short-term impact. Noise from the pipelines could be audible offsite near compressors.

Impacts from energy efficiency programs would be **SMALL**. Some noise impacts could occur in instances of energy efficiency upgrades to major building systems, although this impact would be intermittent and short-lived.

In general, aesthetic changes would be limited to the immediate vicinity of the CNS site and the wind farm facilities. The wind farm would have the greatest aesthetic effect. Compared to a fossil-fueled power plant unit on 46 to 1,400 ac, the 250 wind turbines at over 300 ft (100 m) tall and spread across multiple sites covering 32,000 ac (13,000 ha) may, in some locations, dominate the view and be a major focus of viewer attention. The overall impact, however, would depend on the sensitivity of the people living around the area of the site; therefore, overall aesthetic impacts from the construction and operation of this combination alternative would be **SMALL to MODERATE**.

8.3.6.5 *Historic and Archaeological Resources*

Cultural resources are the indications of human occupation and use of the landscape as defined and protected by a series of Federal laws, regulations, and guidelines. Prehistoric resources are physical remains of human activities that predate written records; they generally consist of artifacts that may alone or collectively yield information about the past. Historic resources consist of physical remains that postdate the emergence of written records; in the United States, they are architectural structures or districts, archaeological objects, and archaeological features dating from 1492 and later. Ordinarily, sites less than 50 years old are not considered historic, but exceptions can be made for such properties if they are of particular importance, such as structures associated with the development of nuclear power or Cold War themes. American Indian resources are sites, areas, and materials important to American Indians for religious or heritage reasons. Such resources may include geographic features, plants, animals, burial grounds, battlefields, trails, and environmental features. The cultural resource analysis encompassed the power plant site and adjacent areas that could potentially be disturbed by the construction and operation of alternative power plants.

The potential for historic and archaeological resources can vary greatly depending on the location of the proposed site. To consider a project's effects on historic and archaeological resources, any proposed areas will need to be surveyed to identify and record historic and archaeological resources, identify cultural resources (e.g., traditional cultural properties), and develop possible mitigation measures to address any adverse effects from ground disturbing activities. Studies will be needed for all areas of potential disturbance at the proposed plant site and along associated corridors where new construction will occur (e.g., roads, transmission corridors, rail lines, or other ROWs). In most cases, project proponents should avoid areas with the greatest sensitivity.

The impact for a single-unit, natural gas-fired alternative at the CNS site would be SMALL. As noted in Section 4.9.6, NPPD conducted a Phase 1A survey of the CNS site in 2007 and 2008. NPPD has also developed a Cultural Resources Protection Plan which calls for surveys to be conducted by a qualified archaeologist in areas deemed sensitive prior to work commencing. The plan also includes an inadvertent discovery (stop work) provision to ensure that proper notification is taken to protect these resources should they be discovered. Depending on the resource richness of an alternative site or sites ultimately chosen for the wind farm alternative, impacts could range from SMALL to MODERATE.

Impacts to historic and archaeological resources from implementing the energy efficiency programs would be SMALL. A conservation alternative would not affect land use or historical or cultural resources onsite or elsewhere in the State.

8.3.6.6 *Environmental Justice*

The environmental justice impact analysis evaluates the potential for disproportionately high and adverse human health and environmental effects on minority and low-income populations that could result from the construction and operation of a new natural gas-fired power plant and wind farm. Adverse health effects are measured in terms of the risk and rate of fatal or nonfatal adverse impacts on human health. Disproportionately high and adverse human health effects occur when the risk or rate of exposure to an environmental hazard for a minority or low-income population is significant and exceeds the risk or exposure rate for the general population or for another appropriate comparison group. The minority and low-income populations are subsets of the general public residing around the site, and all are exposed to the same hazards generated from various power plant operations.

Minority and low-income populations could be affected by the construction and operation of a new natural gas-fired power plant and wind farm. Some of these effects have been identified in resource areas discussed in this section. For example, increased demand for rental housing during construction could disproportionately affect low-income populations.

Weatherization programs could target low-income residents as a cost-effective energy efficiency option since low-income populations tend to spend a larger proportion of their incomes paying utility bills (according to the Office of Management and Budget (OMB), low-income populations experience energy burdens more than four times as large as those of average households (OMB, 2007). Impacts to minority and low-income populations from energy efficiency programs would be SMALL, depending on program design and enrollment.

Impacts on minority and low-income populations under the combination alternative could range from SMALL to MODERATE, due to the small number of workers needed to construct and operate the natural gas-fired power plant and wind farm.

8.3.7 Waste Management

During the construction stage of this combination of alternative, land clearing and other construction activities would generate wastes that can be recycled, disposed onsite, or shipped to the offsite waste disposal facility. During the operational stage, spent SCR catalysts, which are used to control NO_x emissions from the natural gas-fired plants, would make up the majority of the waste generated by this alternative.

There will be an increase in wastes generated during installation or implementation of conservation measures, such as appropriate disposal of old appliances, installation of control devices, and building modifications. New and existing recycling programs would help to minimize the amount of generated waste.

The NRC staff concludes that overall waste impacts from the combination of the natural gas-fired unit constructed onsite, wind capacity, and conservation are SMALL.

Table 8-3 provides a summary of the environmental impacts of the combined alternative compared to continued operation of CNS.

Table 8-3. Summary of Environmental Impacts of the Combination Alternative Compared to Continued Operation of Cooper Nuclear Station

	Combination Alternative	Continued CNS Operation
Air quality	SMALL to MODERATE	SMALL
Ground water	SMALL	SMALL
Surface water	SMALL	SMALL
Aquatic and terrestrial resources	SMALL to LARGE	SMALL
Human health	SMALL to MODERATE	SMALL
Socioeconomics	SMALL to MODERATE	SMALL
Waste management	SMALL	SMALL

8.4 ALTERNATIVES CONSIDERED BUT DISMISSED

In this section, the NRC staff presents the alternatives it initially considered for analysis as alternatives to license renewal of CNS, but later dismissed due to technical, resource availability, or commercial limitations that currently exist and that the NRC staff believes are likely to continue to exist when the existing CNS license expires. Under each of the following technology headings, the NRC staff indicates why it dismissed each alternative from further consideration. Offsite coal and gas-fired alternatives were not considered because the NRC staff determined that a possibly undisturbed offsite location would generally generate larger impacts than either alternative constructed at the previously disturbed CNS site.

8.4.1 Offsite Coal- and Gas-Fired Capacity

While it is possible that coal- and gas-fired alternatives like those considered in Sections 8.1 and 8.2, respectively, could be constructed at sites other than CNS, the NRC staff determined that they would result in greater impacts than alternatives constructed at the CNS site. Greater impacts would occur from construction of support infrastructure, like transmission lines, roads, and railway spurs that are already present on the CNS site. Furthermore, the community around CNS is already familiar with the appearance of a power facility and it is an established part of the region's aesthetic character. Workers skilled in power plant operations would also be available in this area. The availability of these factors is only likely to be available on other recently-industrial sites. In cases where recently-industrial sites exist, other remediation may also be necessary in order to make the site ready for redevelopment. In short, an existing power plant site would present the best location for a new power facility.

8.4.2 Coal-Fired Integrated Gasification Combined-Cycle

While utilities across the United States have considered or are considering plans for integrated gasification combined-cycle (IGCC) coal-fired power plants, few IGCC facilities have yet been constructed. All facilities constructed in the United States to date have been smaller than CNS. The technology, however, is commercially available and relies on a gasifier stage and a combined-cycle stage. Existing combined-cycle facilities (like the ones considered in Section 8.2) could be used as a part of an IGCC alternative.

The EIA indicates that IGCC and other advanced coal plants may become increasingly common in coming years, though uncertainties about construction time periods and commercial viability in the near future lead the NRC staff to believe that IGCC is an unlikely alternative to CNS license renewal (EIA, 2009a). For plants whose licenses expire at later dates, IGCC (with or without carbon capture and storage) may prove to be a viable alternative.

8.4.3 New Nuclear

In its ER, NPPD indicated that it is unlikely that a nuclear alternative could be sited, constructed, and operational by the time CNS's operating license expires in 2014 (NPPD, 2008). Sources in the nuclear industry have recently indicated that reactor projects currently under development are probably 8 or 9 years from completion (Nucleonics Week, 2008), or possibly online in the 2016–2017 time frame. A plant currently under development would also require additional time to develop an application. Given the relatively short time remaining on the current CNS operating license, the NRC staff has not evaluated new nuclear generation as an alternative to license renewal.

8.4.4 Energy Conservation and Energy Efficiency

Though often used interchangeably, energy conservation and energy efficiency are different concepts. Energy efficiency means deriving a similar level of services by using less energy, while energy conservation indicates a reduction in energy consumption. Both fall into a larger category known as demand-side management. Demand-side management measures address energy end uses—unlike energy supply alternatives discussed in previous sections.

Demand-side management can include measures that: (1) shift energy consumption to different times of the day to reduce peak loads; (2) interrupt certain large customers during periods of high demand; (3) interrupt certain appliances during high demand periods; (4) replace older, less efficient appliances, lighting, or control systems; and (5) encourage customers to switch from gas to electricity for water heating and other similar measures that utilities use to boost sales.

Unlike other alternatives to license renewal, the GEIS notes that conservation is not a discrete power generating source; it represents an option that States and utilities may use to reduce their need for power generation capability (NRC, 1996).

While NPPD does state that demand-side management is encouraged by the utility, and that in 2007 there was over a 500 MWe demand reduction (NPPD, 2008), it is unlikely that increased energy efficiency in the State of Nebraska will have grown enough to offset the loss of CNS by the license expiration in 2014. Because of this, the NRC staff has not evaluated energy conservation and efficiency as a discrete alternative to license renewal. It has, however, been considered as a component of the combination alternative.

8.4.5 Purchased Power

In its ER, NPPD indicated that purchased electrical power is, in theory, a potential alternative to CNS license renewal; however, for the 2014 to 2034 time frame of CNS's renewal, there are no guaranteed available power sources to replace the 816 MWe that CNS provides. NPPD indicates that most of its purchased power supply is imported from Canada, which is expected to decrease over the next two decades. Within the State of Nebraska, two newly licensed coal-fired plants starting production in 2009 and 2012 combined will barely meet the amount of electricity currently provided by CNS. Because of the lack of assured availability of purchased electrical power, the NRC staff has not evaluated purchased power as an alternative to license renewal.

8.4.6 Solar Power

Solar technologies use the sun's energy to produce electricity. Currently, the CNS site receives approximately 3.8 to 4.2 kilowatt-hours (kWh) per square meter per day, as does most of the eastern portion of Nebraska (NREL, 2008), for solar collectors oriented at an angle equal to the installation's latitude. Since flat-plate photovoltaics tend to be roughly 25 percent efficient, a solar-powered alternative will require at least 11,620 ac (4,700 ha) of collectors to provide an amount of electricity equivalent to that generated by CNS. Space between parcels and associated infrastructure increase this land requirement. This amount of land, while large, is consistent with the land required for coal and natural gas fuel cycles. In the GEIS, the NRC staff noted that, by its nature, solar power is intermittent (i.e., it does not work at night and cannot serve baseload when the sun is not shining), and the efficiency of collectors varies greatly with weather conditions. A solar-powered alternative will require energy storage or backup power supply to provide electric power at night. Given the challenges in meeting baseload

requirements, the NRC staff did not evaluate solar power as an alternative to license renewal of CNS.

8.4.7 Biomass Waste

In 1999, DOE researchers estimated that Nebraska has biomass fuel resources consisting of forest, mill, agricultural, and urban residues, as well as energy crop potential. Excluding potential energy crops, DOE researchers projected that Nebraska had 16,634,800 tons (15,091,000 MT) of plant-based biomass available at 50 dollars per ton delivered (Walsh et al., 2000) (costs are in 1995 dollars). The Bioenergy Feedstock Development Program at Oak Ridge National Laboratory estimates that each air-dry pound of wood residue produces approximately 6,400 British thermal units (Btu) of heat (ORNL, 2007). Assuming 33 percent conversion efficiency, using all biomass available in Nebraska at 50 dollars per ton—the maximum price the researchers considered—would generate roughly 20.6 terawatt hours of electricity.

Walsh et al. (2000) note that these estimates of biomass capacity contain substantial uncertainty, and that potential availability does not mean biomass will actually be available at the prices indicated or that resources will be useably free of contamination. Some of these plant wastes already have reuse value, and would likely be more costly to deliver because of competition. Others, such as forest residues, may prove unsafe and unsustainable to harvest on a regular basis (the vast majority of biomass capacity in Nebraska, however, comes from agricultural residues, with very little potential from forest residues). It is likely that the available resource potential is much less than the estimate totals in Walsh et al., and the total resource is not likely to be sufficient to substitute for the capacity provided by CNS. As a result, the NRC staff has not considered a biomass-fired alternative to CNS license renewal.

8.4.8 Hydroelectric Power

According to researchers at the Idaho National Energy and Environmental Laboratory (INEEL), Nebraska has an estimated 345 MWe of technically available, undeveloped hydroelectric resources at 45 sites throughout the State (INEEL, 1997). Most of these sites have a potential capacity of less than 1 MWe, although the largest site in Nebraska is capable of providing 22 MWe. Given that the available hydroelectric potential in the State of Nebraska constitutes less than one-half of the generating capacity of CNS, the NRC staff did not evaluate hydropower as an alternative to license renewal.

8.4.9 Wave and Ocean Energy

Wave and ocean energy has generated considerable interest in recent years. Ocean waves, currents, and tides are often predictable and reliable. Ocean currents flow consistently, while tides can be predicted months and years in advance with well-known behavior in most coastal areas. Most of these technologies are in relatively early stages of development, and while some results have been promising, they are not likely to be able to replace the capacity of CNS by the time its license expires. While testing of new technologies to produce electricity from the ocean continues, and because the CNS site is located far from any ocean, the NRC did not consider wave and ocean energy as an alternative to CNS license renewal.

8.4.10 Geothermal Power

Although geothermal energy has an average capacity factor of 90 percent and can be used for baseload power where available, geothermal electric generation is limited by the geographical availability of geothermal resources (NRC, 1996). Nebraska has some geothermal potential in a heating and thermal capacity, but it does not have geothermal electricity potential for development (DOE, 2007). The NRC staff concluded that geothermal energy is not a reasonable alternative to license renewal at CNS.

8.4.11 Municipal Solid-Waste

Municipal solid-waste combustors use three types of technologies: mass burn, modular, and refuse-derived fuel. Mass burning is used most frequently in the United States and involves little sorting, shredding, or separation. Consequently, toxic or hazardous components present in the waste stream are combusted, and toxic constituents are exhausted to the air or become part of the resulting solid wastes. Currently, approximately 89 waste-to-energy plants operate in the United States. These plants generate approximately 2,700 MWe, or an average of 30 MWe per plant (Integrated Waste Services Association, 2007). More than 27 average-sized plants will be necessary to provide the same level of output as the other alternatives to CNS license renewal.

Estimates in the GEIS suggest that the overall level of construction impact from a waste-fired plant will be approximately the same as that for a coal-fired power plant. Additionally, waste-fired plants have the same or greater operational impacts than coal-fired technologies (including impacts on the aquatic environment, air, and waste disposal). The initial capital costs for municipal solid-waste plants are greater than for comparable steam-turbine technology at coal-fired facilities or at wood-waste facilities because of the need for specialized waste separation and handling equipment (NRC, 1996).

The decision to burn municipal waste to generate energy is driven by the need for an alternative to landfills rather than energy considerations. The use of landfills as a waste disposal option is likely to increase as energy prices increase; however, it is possible that municipal waste combustion facilities may become attractive again.

Regulatory structures that once supported municipal solid-waste incineration no longer exist. The Tax Reform Act of 1986 made capital-intensive projects, such as municipal-waste combustion facilities, more expensive relative to less expensive waste disposal alternatives, such as landfills. Also, the 1994 Supreme Court decision *C&A Carbone, Inc. v. Town of Clarkstown, New York*, struck down local flow control ordinances that required waste to be delivered to specific municipal waste combustion facilities rather than landfills that may have had lower fees. In addition, environmental regulations have increased the cost to construct and maintain municipal waste combustion facilities.

Given the small average installed size of municipal solid-waste plants and the unfavorable regulatory environment, the NRC staff does not consider municipal solid-waste combustion to be a feasible alternative to CNS license renewal.

8.4.12 Biofuels

In addition to wood and municipal solid-waste fuels, there are other concepts for biomass-fired electric generators, including conversion to liquid biofuels and biomass gasification. In the GEIS, the NRC staff indicates that none of these technologies progressed to

Environmental Impacts of Alternatives

the point of being competitive on a large scale or of being reliable enough to replace a baseload plant such as CNS. After reevaluating current technologies, the NRC staff finds other biomass-fired alternatives as still unable to reliably replace the CNS capacity. For this reason, the NRC staff does not consider other biomass-derived fuels to be feasible alternatives to CNS license renewal.

8.4.13 Oil-Fired Power

The EIA projects that oil-fired plants will account for very few of new generation capacity constructed in the United States during the 2008 to 2030 time period. Furthermore, EIA does not project that oil-fired power will account for any significant additions to capacity (EIA, 2009b).

The variable costs of oil-fired generation are found to be greater than those of nuclear or coal-fired operations, and oil-fired generation has greater environmental impacts than natural gas-fired generation. In addition, future increases in oil prices are expected to make oil-fired generation increasingly more expensive (EIA, 2009b). The high cost of oil has prompted a steady decline in its use for electricity generation. Thus, the NRC staff does not consider oil-fired generation as an alternative to CNS license renewal.

8.4.14 Fuel Cells

Fuel cells oxidize fuels without combustion and its environmental side effects. Power is produced electrochemically by passing a hydrogen-rich fuel over an anode and passing air (or oxygen) over a cathode and then separating the two by an electrolyte. The only byproducts (depending on fuel characteristics) are heat, water, and CO₂. Hydrogen fuel can come from a variety of hydrocarbon resources by subjecting them to steam under pressure. Natural gas is typically used as the source of hydrogen.

At the present time, fuel cells are not economically or technologically competitive with other alternatives for large-scale electricity generation. The EIA projects that fuel cells may cost \$5,374 per installed kilowatt (total overnight costs³) (EIA, 2009b), or 3.5 times the construction cost of new coal-fired capacity, and 7.5 times the cost of new, advanced gas-fired, combined-cycle capacity. In addition, fuel cell units are likely to be small (the EIA reference plant is 10 MWe). While it may be possible to use a distributed array of fuel cells to provide an alternative to CNS, it would be extremely costly to do so. Accordingly, the NRC staff does not consider fuel cells to be an alternative to CNS license renewal.

8.4.15 Delayed Retirement

NPPD has no plans to retire generating capacity in Nebraska prior to 2014 (NPPD, 2008). As a result, delayed retirement is not a feasible alternative to license renewal. Other generation capacity may be retired prior to the expiration of the CNS license, but this capacity is likely to be older, less efficient, and without modern emissions controls.

8.5 NO-ACTION ALTERNATIVE

This section examines environmental effects that occur if NRC takes no action. No action in this case means that NRC does not issue a renewed operating license for CNS and the license

³ Overnight cost is the cost of a construction project if no interest was incurred during construction.

expires at the end of the current license term, in 2014. If NRC takes no action, the plant will shutdown at or before the end of the current license. After shutdown, plant operators will initiate decommissioning according to 10 CFR 50.82.

The NRC staff notes that no action is the only alternative that is considered in-depth that does not satisfy the purpose and need for this SEIS, because it does not provide power generation capacity nor would it meet the needs currently met by CNS or the alternatives evaluated in Sections 8.1 through 8.3. Assuming that a need currently exists for the power generated by CNS, the no-action alternative would require the appropriate energy planning decision makers to rely on an alternative to replace the capacity of CNS or reduce the need for power.

This section addresses only those impacts that arise directly as a result of plant shutdown. The environmental impacts from decommissioning and related activities have already been addressed in several other documents, including the *Final Generic Environmental Impact Statement on Decommissioning of Nuclear Facilities*, NUREG-0586, Supplement 1 (NRC, 2002); the license renewal GEIS (Chapter 7, NRC, 1996); and Chapter 7 of this SEIS. These analyses either directly address or bound the environmental impacts of decommissioning whenever NPPD ceases operating CNS.

The NRC staff notes that, even with a renewed operating license, CNS will eventually shut down, and the environmental effects addressed in this section will occur at that time. Since these effects have not otherwise been addressed in this SEIS, the impacts will be addressed in this section. As with decommissioning effects, shutdown effects are expected to be similar whether or not they occur at the end of the current license or at the end of a renewed license.

8.5.1 Air Quality

When the plant stops operating, there will be a reduction in emissions from activities related to plant operation, such as use of diesel generators and employee vehicles. In Chapter 4, the NRC staff determined that these emissions would have a SMALL impact on air quality during the renewal term; therefore, if emissions decrease, the impact to air quality would also decrease and would be a SMALL impact.

8.5.2 Ground Water Use and Quality

The use of ground water would diminish as plant personnel are removed from the site and operations cease. Some consumption of ground water may continue as a small staff remains onsite to maintain facilities prior to decommissioning. Overall impacts would be smaller than during operations, but would remain SMALL.

8.5.3 Surface Water Use and Quality

The rate of consumptive use of surface water would decrease as the plant is shut down and the reactor cooling system continues to remove the heat of decay. Wastewater discharges would also be reduced considerably. Shutdown would reduce the already SMALL impact on surface water resources and quality.

8.5.4 Aquatic and Terrestrial Resources

8.5.4.1 Aquatic Ecology

If the plant were to cease operating, impacts to aquatic ecology would decrease, as the plant would withdraw and discharge less water than it does during operations. Shutdown would reduce the already SMALL impacts to aquatic ecology.

8.5.4.2 Terrestrial Ecology

Terrestrial ecology impacts would be SMALL. No additional land disturbances on or offsite would occur.

8.5.5 Human Health

Human health risks would be smaller following plant shutdown. The plant, which is currently operating within regulatory limits, would emit less gaseous and liquid radioactive material to the environment. In addition, following shutdown, the variety of potential accidents at the plant (radiological or industrial) would be reduced to a limited set associated with shutdown events and fuel handling and storage. In Chapter 4 of this SEIS, the NRC staff concluded that the impacts of continued plant operation on human health would be SMALL. In Chapter 5, the NRC staff concluded that the impacts of accidents during operation were SMALL. Therefore, as radioactive emissions to the environment decrease, and as likelihood and variety of accidents decrease following shutdown, the NRC staff concludes that the risk to human health following plant shutdown would be SMALL.

8.5.6 Socioeconomics

8.5.6.1 Land Use

Plant shutdown would not affect onsite land use. Plant structures and other facilities would remain in place until decommissioning. Most transmission lines connected to CNS would remain in service after the plant stops operating. Maintenance of most existing transmission lines would continue as before. Impacts on land use from plant shutdown would be SMALL.

8.5.6.2 Socioeconomics

Plant shutdown would have an impact on socioeconomic conditions in the region around CNS. Plant shutdown would eliminate approximately 750 jobs and would reduce tax revenue in the region. The loss of these contributions, which may not entirely cease until after decommissioning, would have a SMALL to MODERATE impact. See Appendix J to NUREG-0586, Supplement 1 (NRC, 2002), for an additional discussion of the potential socioeconomic impacts of plant decommissioning.

8.5.6.3 Transportation

Traffic volumes on the roads in the vicinity of CNS would be reduced after plant shutdown. Most of the reduction in traffic volume would be associated with the loss of jobs at the plant. Deliveries to the plant would be reduced until decommissioning. Transportation impacts would be SMALL as a result of plant shutdown. Transportation impacts would increase if a new energy facility were constructed at the CNS site or in the immediate vicinity. These impacts are addressed in Sections 8.1 to 8.3. Such impacts may be SMALL to MODERATE, but of short duration.

8.5.6.4 Aesthetics

Plant structures and other facilities would remain in place until decommissioning. Noise caused by plant operation would cease. Aesthetic impacts of plant closure would be SMALL.

8.5.6.5 Historic and Archaeological Resources

Impacts from the no-action alternative on historic and archaeological resources would be SMALL, since CNS would be decommissioned. A separate environmental review would be conducted for decommissioning. That assessment would address the protection of historic and archaeological resources.

8.5.6.6 Environmental Justice

Termination of power plant operations would not disproportionately affect minority and low-income populations outside the immediate vicinity of CNS. Minority and low-income populations are generally concentrated in urban areas. Thus, impacts from plant shutdown would be SMALL. See Appendix J of NUREG-0586, Supplement 1 (NRC, 2002), for additional discussion of these impacts.

8.5.7 Waste Management

If the no-action alternative were implemented, the generation of high-level waste would stop and generation of low-level and mixed waste would decrease. Impacts from implementation of the no-action alternative are expected to be SMALL.

Table 8-4 provides a summary of the environmental impacts of the no-action alternative compared to continued operation of CNS.

Table 8-4. Summary of Environmental Impacts of No Action Compared to Continued Operation of Cooper Nuclear Station

	No Action	Continued CNS Operation
Air quality	SMALL	SMALL
Ground water	SMALL	SMALL
Surface water	SMALL	SMALL
Aquatic and terrestrial resources	SMALL	SMALL
Human health	SMALL	SMALL
Socioeconomics	SMALL to MODERATE	SMALL
Waste management	SMALL	SMALL

8.6 ALTERNATIVES SUMMARY

In this chapter, the NRC staff considers the following alternatives to CNS license renewal: supercritical coal-fired generation, natural gas combined-cycle generation, and a combination alternative. No action by NRC and its effects were also considered. The impacts for all alternatives to CNS license renewal are summarized in Table 8-6 on the following page.

Table 8-5. Summary of Environmental Impacts of Proposed Action and Alternatives

Alternative	Impact Area						
	Air Quality	Ground water	Surface Water	Aquatic and Terrestrial Resources	Human Health	Socioeconomics	Waste Management
License renewal	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL	Small
Supercritical coal-fired alternative at CNS site	MODERATE	SMALL	SMALL	SMALL to MODERATE	SMALL	SMALL to LARGE	MODERATE
Gas-fired alternative at the CNS site	SMALL to MODERATE	SMALL	SMALL	SMALL to MODERATE	SMALL	SMALL to MODERATE	SMALL
Combination of alternatives	SMALL to MODERATE	SMALL	SMALL	SMALL to LARGE	SMALL to MODERATE	SMALL to MODERATE	SMALL
No-action alternative	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL to MODERATE	SMALL

The environmental impacts of the proposed action (issuing a renewed CNS operating license) would be SMALL for all impact categories, except for the Category 1 issue of collective offsite radiological impacts from the fuel cycle, high-level waste, and spent fuel disposal. The NRC staff did not add a single significant level to these impacts, but the Commission determined them to be Category 1 issues nonetheless.

The coal-fired alternative is not an environmentally favorable alternative due to impacts on air quality from NO_x, SO_x, PM, PAHs, CO, CO₂, and mercury (and their corresponding human health impacts); and due to construction impacts to aquatic, terrestrial, and potential historic and archaeological resources.

The gas-fired alternative would have slightly lower air emissions, lower waste management, and lower socioeconomic impacts than the coal-fired alternative. The combination alternative would have lower air emissions and waste management impacts than both the gas-fired and coal-fired alternatives; however, the combination alternative would have relatively high construction impacts to aquatic, terrestrial, and potential historic and archaeological resources due mainly to the wind turbine component.

In conclusion, the environmentally preferred alternative in this case is the license renewal of CNS. All other alternatives capable of meeting the needs currently served by CNS entail potentially greater impacts than the proposed action of license renewal of CNS. The no-action alternative necessitates the implementation of one or a combination of alternatives, all of which have greater impacts than the proposed action, the NRC staff concludes that the no-action alternative will have environmental impacts greater than or equal to the proposed license renewal action.

8.7 REFERENCES

10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions."

Department of Energy (DOE). 2007. "GeoPowering the West: Nebraska State Profile." Available URL: http://www1.eere.energy.gov/geothermal/gpw/profile_nebraska.html (accessed July 2009).

Energy Information Administration (EIA). 2006. "Cost and Quality of Fuel for Electric Plants, 2004 and 2005," DOE/EIA-0191(2005), Washington, D.C., Agencywide Documents Access and Management System (ADAMS) No. ML082880730. Available URL: <http://www.eia.doe.gov/cneaf/electricity/cq/cqa2005.pdf> (accessed July 2009).

Energy Information Administration (EIA). 2009a. "Annual Energy Outlook 2009 With Projections to 2030," DOE/EIA-0383(2009), Washington, D.C. Available URL: [http://www.eia.doe.gov/oiaf/archive/aeo09/pdf/0383\(2009\).pdf](http://www.eia.doe.gov/oiaf/archive/aeo09/pdf/0383(2009).pdf) (accessed July 2009).

Energy Information Administration (EIA). 2009a. "Summary Statistics for the United States." Table ES1 from *Electric Power Annual with Data for 2007*. Available URL: (accessed June 2009).

Energy Information Administration (EIA). 2009c. "Table A4. Approximate Heat Content of Natural Gas, 1949-2008 (Btu per Cubic Foot)." Available URL: <http://www.eia.doe.gov/emeu/aer/txt/ptb1304.html> (accessed July 2009).

Energy Information Administration (EIA). 2009d. "Annual Energy Outlook 2009, Electricity Demand." Available URL: <http://www.eia.doe.gov/oiaf/archive/aeo09/electricity.html> (accessed December 2009).

Environmental Impacts of Alternatives

Environmental Protection Agency (EPA). 1998. *Compilation of Air Pollutant Emission Factors, Volume 1: Stationary Point and Area Sources: AP 42, Fifth Edition. "Section 1.1: Bituminous and Subbituminous Coal Combustion: Final Section Supplement E,"* Washington, D.C.

Environmental Protection Agency (EPA). 2000a. "Notice of Regulatory Determination on Wastes from the Combustion of Fossil Fuels," *Federal Register*, Vol. 65, pp. 32214–32237, Washington, D.C.

Environmental Protection Agency (EPA). 2000b. "Regulatory Finding on the Emissions of Hazardous Air Pollutants from Electric Utility Steam Generating Units," *Federal Register*, Vol. 65, No. 245, pp. 79825–79831, Washington, D.C., December 20, 2000.

Environmental Protection Agency (EPA). 2008. "New Source Review (NSR)," ADAMS No. ML083450073. Available URL: <http://www.epa.gov/nsr/> (accessed June 2009)

General Electric (GE). 2007. "Gas Turbine and Combined Cycle Products," May 2007. Available URL:

http://www.gepower.com/prod_serv/products/gas_turbines_cc/en/downloads/gasturbine_cc_products.pdf (accessed June 2009).

Idaho National Engineering and Environmental Laboratory (INEEL). 1997. "U.S. Hydropower Resource Assessment for Nebraska," DOE/ID-10430(NE). Available URL:

<http://hydropower.inel.gov/resourceassessment/pdfs/states/ne.pdf> (accessed July 2009).

Nebraska Department of Environmental Quality (NDEQ). 2003. "Environmental Guidance Document: Air Quality Permit Process," October 2003. Available URL:

[http://www.deq.state.ne.us/Publications/c4afc76e4e077e11862568770059b73f/c754133ad12af72a06256dc1006371f0/\\$FILE/03-148.pdf](http://www.deq.state.ne.us/Publications/c4afc76e4e077e11862568770059b73f/c754133ad12af72a06256dc1006371f0/$FILE/03-148.pdf) (accessed August 2009).

Nebraska Public Power District (NPPD). 2008. "License Renewal Application, Cooper Nuclear Station, Appendix E – Applicant's Environmental Report, Operating License Renewal Stage," Columbus, Nebraska, September 24, 2008, ADAMS Accession Nos. ML083030246 (main report) and ML083030252 (attachments).

U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*, NUREG-1437, Volumes 1 and 2, Washington, D.C., ADAMS Accession Nos. ML040690705 and ML040690738.

U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Main Report*, "Section 6.3 – Transportation, Table 9.1, Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants, Final Report," NUREG-1437, Volume 1, Addendum 1, Washington, D.C.

U.S. Nuclear Regulatory Commission (NRC). 2002. *Generic Environmental Impact Statement on Decommissioning of Nuclear Facilities: Supplement 1*, "Regarding the Decommissioning of Nuclear Power Reactors," NUREG-0586, Supplement 1, Volumes 1 and 2, Washington, D.C.

U.S. Office of Management and Budget (OMB). 2007. "Detailed Information on the Low Income Home Energy Assistance Program Assessment," ADAMS Accession No. ML082880730.

Available URL: <http://www.whitehouse.gov/omb/expectmore/detail/10001059.2003.html> (accessed June 2009).

Walsh, M.E., R.L. Perlack, A. Turhollow, D. de la Torre Ugarte, D.A. Becker, R.L. Graham, S.A. Slinsky, and D.E. Ray (Walsh et. al.). 2000. "Biomass Feedstock Availability in the United States: 1999 State Level Analysis," ADAMS Accession No. ML083050223. Available URL: <http://bioenergy.ornl.gov/resourcedata/index.html> (accessed July 2009).

9.0 CONCLUSION

This final supplemental environmental impact statement (SEIS) contains the environmental review of the Nebraska Public Power District (NPPD) application for a renewed operating license for Cooper Nuclear Station (CNS), as required by the *Code of Federal Regulations* (CFR), Part 51 of Title 10 (10 CFR Part 51) and the U.S. Nuclear Regulatory Commission's (NRC) regulations that implement the National Environmental Policy Act (NEPA). This chapter presents conclusions and recommendations from the site-specific environmental review of CNS and summarizes site-specific environmental issues of license renewal that were identified during the review. The environmental impacts of license renewal are summarized in Section 9.1; a comparison of the environmental impacts of license renewal and energy alternatives is presented in Section 9.2; unavoidable impacts of license renewal, energy alternatives, and resource commitments are discussed in Section 9.3; and conclusions and NRC staff recommendations are presented in Section 9.4.

9.1 ENVIRONMENTAL IMPACTS OF LICENSE RENEWAL

The staff's review of site-specific environmental issues in this SEIS leads to the conclusion that issuing a renewed license would have SMALL impacts for the eight Category 2 issues applicable to license renewal at CNS, as well as environmental justice and chronic effects of electromagnetic fields (EMF).

Mitigation measures were considered for each Category 2 issue, as applicable. For ground water, no measures to mitigate the environmental impacts of plant operation were found to be warranted because of the limited radius of influence of CNS wells. NPPD has implemented some impingement and entrainment mitigation measures, such as dual flow screens with modified Ristroph fish buckets and plans to install a fish handling system, which the staff concludes will minimize impacts on aquatic resources. The NRC staff identified a variety of measures that could mitigate potential acute EMF impacts resulting from continued operation of the CNS transmission lines, including erecting barriers along the length of the transmission line to prevent unauthorized access to the ground beneath the conductors and installing road signs at road crossings. These mitigation measures could reduce human health impacts by minimizing public exposures to electric shock hazard.

The staff identified a variety of measures that could mitigate the potential impacts of thermophilic microbiological organisms resulting from continued operation of CNS. These mitigation measures include periodically monitoring for thermophilic microbiological organisms in the water and sediments near the discharge, as well as prohibiting recreational use near the discharge plume. These mitigation measures could reduce human health impacts by minimizing public exposures to thermophilic microbiological organisms. The NRC staff did not identify any cost-benefit studies applicable to the mitigation measures mentioned above.

The NRC staff also considered cumulative impacts of past, present, and reasonably foreseeable future actions, regardless of what agency (Federal or non-Federal) or person undertakes them. The staff concluded that cumulative impacts of CNS's license renewal would be SMALL for potentially affected resources.

9.2 COMPARISON OF ENVIRONMENTAL IMPACTS OF LICENSE RENEWAL AND ALTERNATIVES

In the conclusion to Chapter 8, the NRC staff determined that impacts from license renewal are generally less than the impacts of alternatives to license renewal, with the exception of energy conservation and energy efficiency. In comparing possible environmental impacts from supercritical coal-fired generation, natural gas combined-cycle generation, energy conservation and energy efficiency, and a combination alternative that includes natural gas, conservation and efficiency, upgrades to existing hydroelectric dams, and environmental impacts from license renewal, it was found that the energy conservation and energy efficiency alternative would result in the lowest environmental impact. Based on the NRC staff's analysis, it was found that the impacts of license renewal are reasonable in light of the impacts from alternatives to the license renewal of CNS.

9.3 RESOURCE COMMITMENTS

9.1.1 Unavoidable Adverse Environmental Impacts

Unavoidable adverse environmental impacts are impacts that would occur after implementation of all feasible mitigation measures. Implementing any of the energy alternatives considered in this SEIS, including the proposed action, would result in some unavoidable adverse environmental impacts.

Minor unavoidable adverse impacts on air quality would occur due to emission and release of various chemical and radiological constituents from power plant operations. Nonradiological emissions resulting from power plant operations are expected to comply with Environmental Protection Agency (EPA) emissions standards, though the alternative of operating a fossil-fueled power plant in some areas may worsen existing attainment issues. Chemical and radiological emissions would not exceed the National Emission Standards for Hazardous Air Pollutants.

During nuclear power plant operations, workers and members of the public would face unavoidable exposure to radiation and hazardous and toxic chemicals. Workers would be exposed to radiation and chemicals associated with routine plant operations and the handling of nuclear fuel and waste material. Workers would have higher levels of exposure than members of the public, but doses would be administratively controlled and would not exceed standards or administrative control limits. In comparison, the alternatives involving the construction and operation of a non-nuclear power generating facility would also result in unavoidable exposure to hazardous and toxic chemicals to workers and the general public.

The generation of spent nuclear fuel and waste material, including low-level radioactive waste, hazardous waste, and nonhazardous waste would also be unavoidable. In comparison, hazardous and nonhazardous wastes would also be generated at non-nuclear power generating facilities. Wastes generated during plant operations would be collected, stored, and shipped for suitable treatment, recycling, or disposal in accordance with applicable Federal and State regulations. Due to the costs of handling these materials, power plant operators would be expected to conduct all activities and optimize all operations in a way that generates the smallest amount of waste possible.

9.1.2 The Relationship between Local Short-Term Uses of the Environment and the Maintenance and Enhancement of Long-Term Productivity

The operation of power generating facilities would result in short-term uses of the environment as described in Chapters 4, 5, 6, 7, and 8. "Short-term" is the period of time that continued power generating activities take place.

Power plant operations require short-term use of the environment and commitment of resources, and also commit certain resources (e.g., land and energy) indefinitely or permanently. Certain short-term resource commitments are substantially greater under most energy alternatives, including license renewal, than under the No-Action alternative because of the continued generation of electrical power and the continued use of generating sites and associated infrastructure. During operations, all energy alternatives require similar relationships between local short-term uses of the environment and the maintenance and enhancement of long-term productivity.

Air emissions from power plant operations introduce small amounts of radiological and nonradiological constituents to the region around the plant site. Over time, these emissions would result in increased concentrations and exposure, but are not expected to impact air quality or radiation exposure to the extent that public health and long-term productivity of the environment would be impaired.

Continued employment, expenditures, and tax revenues generated during power plant operations directly benefit local, regional, and State economies over the short term. Local governments investing project-generated tax revenues into infrastructure and other required services could enhance economic productivity over the long term.

The management and disposal of spent nuclear fuel, low-level radioactive waste, hazardous waste, and nonhazardous waste requires an increase in energy and consumes space at treatment, storage, or disposal facilities. Regardless of the location, the use of land to meet waste disposal needs would reduce the long-term productivity of the land.

Power plant facilities are committed to electricity production over the short term. After decommissioning these facilities and restoring the area, the land could be available for other future productive uses.

9.1.3 Irreversible and Irrecoverable Commitments of Resources

This section describes the irreversible and irretrievable commitment of resources that have been identified in this SEIS. Resources are irreversible when primary or secondary impacts limit the future options for a resource. An irretrievable commitment refers to the use or consumption of resources that are neither renewable nor recoverable for future use. Irreversible and irretrievable commitment of resources for electrical power generation include the commitment of land, water, energy, raw materials, and other natural and man-made resources required for power plant operations. In general, the commitment of capital, energy, labor, and material resources are also irreversible.

The implementation of any of the energy alternatives considered in this SEIS would entail the irreversible and irretrievable commitment of energy, water, chemicals, and in some cases, fossil fuels. These resources would be committed during the license renewal term and over the entire life cycle of the power plant and would be unrecoverable.

Conclusion

Energy expended would be in the form of fuel for equipment, vehicles, and power plant operations and electricity for equipment and facility operations. Electricity and fuel would be purchased from offsite commercial sources. Water would be obtained from existing water supply systems. These resources are readily available, and the amounts required are not expected to deplete available supplies or exceed available system capacities.

The irreversible and irretrievable commitment of material resources includes materials that cannot be recovered or recycled, materials that are rendered radioactive and cannot be decontaminated, and materials consumed or reduced to unrecoverable forms of waste. None of the resources used by these power generating facilities, however, are in short supply, and for the most part are readily available.

Various materials and chemicals derived from chemical vendors, including acids and caustics, are required to support the operation's activities. Their consumption is not expected to affect local, regional, or national supplies.

The treatment, storage, and disposal of spent nuclear fuel, low-level radioactive waste, hazardous waste, and nonhazardous waste require the irretrievable commitment of energy and fuel and will result in the irreversible commitment of space in disposal facilities.

9.4 RECOMMENDATIONS

Based on: (1) the analysis and findings in the GEIS; (2) information provided in the environmental report submitted by NPPD; (3) consultation with Federal, State, and local agencies; (4) a review of pertinent documents and reports; and (5) consideration of public comments received, the recommendation of the NRC staff is for the Commission to determine that the above considered adverse environmental impacts of license renewal are not so great that preserving the option of license renewal for energy planning decision makers (i.e., State regulatory agencies and NPPD) would be unreasonable.

10.0 LIST OF PREPARERS

This supplemental environmental impact statement (SEIS) was prepared by members of the Office of Nuclear Reactor Regulation, with assistance from other U.S. Nuclear Regulatory Commission (NRC) organizations and with contract support from Pacific Northwest National Laboratory.

Table 10-1 provides a list of NRC staff that participated in the development of the SEIS. Pacific Northwest National Laboratory provided contract support for the severe accident mitigation alternatives (SAMAs) analysis, presented in Chapter 5 and Appendix F.

Table 10-1. List of Preparers

Name	Affiliation	Function or Expertise
Nuclear Regulatory Commission		
Bo Pham	Nuclear Reactor Regulation	Branch Chief
Dave Pelton	Nuclear Reactor Regulation	Branch Chief
Andrew Imboden	Nuclear Reactor Regulation	Branch Chief
Emmanuel Sayoc	Nuclear Reactor Regulation	Project Manager
Tam Tran	Nuclear Reactor Regulation	Project Manager
Bennett Brady	Nuclear Reactor Regulation	Project Manager
Dennis Beissel	Nuclear Reactor Regulation	Hydrology
Dennis Logan	Nuclear Reactor Regulation	Aquatic Ecology; Terrestrial Ecology
Stephen Klementowicz	Nuclear Reactor Regulation	Radiation Protection; Human Health
Jennifer Davis	Nuclear Reactor Regulation	Historic and Archaeological Resources
Richard Bulavinetz	Nuclear Reactor Regulation	Terrestrial Ecology
Ekaterina Lenning	Nuclear Reactor Regulation	Air Quality
Robert Palla	Nuclear Reactor Regulation	Severe Accident Mitigation Alternatives
Jeffrey Rikhoff	Nuclear Reactor Regulation	Socioeconomics; Land Use; Environmental Justice; Historic and Archaeological Resources
Andrew Stuyvenburg	Nuclear Reactor Regulation	Alternatives
Allison Travers	Nuclear Reactor Regulation	Alternatives

List of Preparers

Name	Affiliation	Function or Expertise
Nuclear Regulatory Commission		
SAMA Contractor^(a)		
Steve Short	Pacific Northwest National Laboratory	Severe Accident Mitigation Alternatives
Bruce Schmitt	Pacific Northwest National Laboratory	Severe Accident Mitigation Alternatives
Jon Young	Pacific Northwest National Laboratory	Severe Accident Mitigation Alternatives

(a) Pacific Northwest National Laboratory is operated by Batelle for the U.S. Department of Energy

11.0 INDEX

accidents	xix, 5-1, 5-2, 5-3, B-7
aesthetic	xviii
alternatives	iii, xix, xx, xxi, 1-6, 5-2, 8-6, 8-25, 9-1, 9-2, 9-3, 10-1, 12-1, B-7
archaeological resources	xix, 1-6, B-7, D-1
Barnwell.....	2-7
biota	B-2
burnup	B-10
chronic effects	1-4, 4-14, 4-36, 4-48, 9-1, B-6
closed-cycle cooling	B-4
cultural resources	C-1
decommissioning.....	9-3, B-10, B-11
design-basis accidents	xxiv, 5-1, 5-2
discharges	9-1, B-2, B-7
dose	2-7, 4-16, 4-17, B-6, B-8, B-9
education.....	4-19, 4-21, B-7
electromagnetic fields.....	1-4, 4-12, 4-38, 4-50, 9-1, B-5, B-7
entrainment	B-2, B-3
environmental justice.....	1-4, 4-21, 4-27, 9-1, B-12
EPA	xxxii, 2-7, 4-16, B-10, C-1
GEIS	xx, xxi, xxii, xxiii, xxiv, xxvii, xxxi, 1-3, 1-4, 1-6, 1-10, 4-1, 4-3, 4-5, 4-12, 4-15, 4-20, 4-21, 4-36, 4-50, 5-1, 5-2, 5-3, 6-1, 6-2, 7-2, 9-4, A-1, B-9
ground water	4-2, 4-16, 9-1, B-4, B-5, C-1
hazardous waste	2-8, 9-2, 9-3, 9-4
high level waste.....	B-9, B-10
impingement.....	B-2, B-3, B-4
low level waste	xxxii
mitigation	xxiii, 1-4, 1-6, 4-3, 4-5, 4-12, 4-15, 5-3, 9-1, 9-2, 10-1, 12-1
mixed waste	xxxii, B-11
NEPA	xx, xxi, xxxiii, 1-1, 1-12, 4-36, 5-1, 7-3, 9-1, B-9, B-10, D-1
no-action alternative	v, xxvi
nonattainment.....	B-6
NPDES	xxxiv, B-2, C-1
pressurized water reactor.....	xxxv
radon-222	6-1, B-9
reactor	xx, xxi, xxx, xxxii, xxxv, 5-1, 5-2, 5-3, B-4, B-9
refurbishment	4-17, B-1, B-2, B-4, B-6, B-7, B-8
replacement power	v
scoping . xx, xxi, xxiii, xxvii, 1-3, 1-6, 4-3, 4-5, 4-12, 4-15, 4-37, 5-2, 5-3, 6-1, 7-2, 9-4, A-1, E-3	
severe accidents (SAMA).....	xxxvi, 5-3, 5-4, 10-1, 12-1
solid waste.....	2-7, 2-8, 6-1, B-12, C-1
spent fuel.....	xxxii, 1-4, 6-1, 6-2, B-9, B-10, B-11
stormwater.....	4-16
surface water	xxiv, 4-3, 4-16, B-1, B-4, C-1
Threatened and endangered species	1-7, 4-14, B-2, B-6, C-1, D-1
transmission lines	4-1, 4-20, 4-21, 4-38, 4-50, 9-1, B-6, B-8
tritium	4-16

Index

uranium	6-1, 6-2, B-9, B-11
wastewater	B-2
Yucca	B-9, B-10, B-11

12.0 LIST OF AGENCIES, ORGANIZATIONS, AND PERSONS TO WHOM COPIES OF THE SUPPLEMENTAL ENVIRONMENTAL IMPACT STATEMENT ARE SENT

Name and Title	Company and Address
Mr. Ronald D. Asche President and Chief Executive Officer	Nebraska Public Power District 1414 15th Street Columbus, NE 68601
Mr. Gene Mace Nuclear Asset Manager	Nebraska Public Power District P.O. Box 98 Brownville, NE 68321
Mr. John C. McClure Vice President and General Counsel	Nebraska Public Power District P.O. Box 499 Columbus, NE 68602-0499
Mr. David Van Der Kamp Licensing Manager	Nebraska Public Power District P.O. Box 98 Brownville, NE 68321
Mr. Michael J. Linder Director	Nebraska Department of Environmental Quality P.O. Box 98922 Lincoln, NE 68509-8922
Chairman	Nemaha County Board of Commissioners Nemaha County Courthouse 1824 N Street Auburn, NE 68305
Ms. Julia Schmitt Manager, Radiation Control Program	Nebraska Health & Human Services R & L Public Health Assurance 301 Centennial Mall, South P.O. Box 95007 Lincoln, NE 68509-5007
Mr. H. Floyd Gilzow Deputy Director for Policy	Missouri Department of Natural Resources P.O. Box 176 Jefferson City, MO 65102-0176
Senior Resident Inspector	U.S. Nuclear Regulatory Commission P.O. Box 218 Brownville, NE 68321
Regional Administrator, Region IV	U.S. Nuclear Regulatory Commission 612 E. Lamar Blvd., Suite 400 Arlington, TX 76011-4125
Director	Missouri State Emergency Management Agency P.O. Box 116 Jefferson City, MO 65102-0116

List of Agencies, Organizations, and Persons

Name and Title	Company and Address
Chief, Radiation and Asbestos Control Section	Kansas Department of Health and Environment Bureau of Air and Radiation 1000 SW Jackson, Suite 310 Topeka, KS 66612-1366
Ms. Melanie Rasmussen Radiation Control Program Director	Bureau of Radiological Health Iowa Department of Public Health Lucas State Office Building, 5th Floor 321 East 12th Street Des Moines, IA 50319
Mr. Keith G. Henke Planner, Division of Community and Public Health	Office of Emergency Coordination 930 Wildwood P.O. Box 570 Jefferson City, MO 65102
Mr. Art Zaremba Director of Nuclear Safety Assurance	Nebraska Public Power District P.O. Box 98 Brownville, NE 68321
Mr. John F. McCann Director Licensing, Entergy Nuclear Northeast	Entergy Nuclear Operations, Inc. 440 Hamilton Avenue White Plains, NY 10601-1813
Steward Minahan Vice President Nuclear and Chief Nuclear Officer	Cooper Nuclear Station 72676 – 648A Avenue Brownville, NE 68321
Mike Boyce Cooper Strategic Initiatives Manager	Cooper Nuclear Station 72676 – 648A Avenue Brownville, NE 68321
Dave Bremer License Renewal Project Manager	Cooper Nuclear Station 72676 – 648A Avenue Brownville, NE 68321
Bill Victor License Renewal Project Licensing Lead	Cooper Nuclear Station 72676 – 648A Avenue Brownville, NE 68321
Jim Loynes License Renewal Project Engineer	Cooper Nuclear Station 72676 – 648A Avenue Brownville, NE 68321
Garry Young License Renewal Manager	Entergy Nuclear 1448 S.R. 333, N-GSB-45 Russellville, AK 72802
Alan Cox License Renewal Technical Manager	Entergy Nuclear 1448 S.R. 333, N-GSB-45 Russellville, AK 72802
Jerry Perry	Entergy Nuclear 1448 S.R. 333, N-GSB-45 Russellville, AK 72802

List of Agencies, Organizations, and Persons

Name and Title	Company and Address
Yolanda Peck	500 S. Main Street Rock Port, MO 64482
Kendall Neiman	1008 Central Ave. Auburn, NE 68305
Annie Thomas	830 Central Ave. Auburn, NE 68305
John Chaney	1522 I Street Auburn, NE 68305
Darrell Kruse	1101 17th Street Auburn, NE 68305
Daryl J. Obermeyer	2415 McConnell Ave. Auburn, NE 68305
Sherry Black Director	64381 727A Road Brownville, NE 68321
Marty Hayes Chairman	Auburn Memorial Library 1810 Courthouse Ave. Auburn, NE 68305
Bob Engles Mayor of Auburn, NE	Board of Brownville, NE P.O. Box 67 223 Main Street Brownville, NE 68321
Jo Stevens Mayor of Rock Port, MO	1101 J Street Auburn, NE 68305
John Cochnar	500 S. Main Street Rock Port, MO 64482
John Askew Regional Administrator	U.S. Fish and Wildlife Service Ecological Services Nebraska Field Office 203 West Second Street Grand Island, NE 68801
Regional Administrator	U.S. Environmental Protection Agency Region 7 901 N. 5th Street Kansas City, KS 66101
Joann Scheafer Director	U.S. Environmental Protection Agency Region 7 901 N. 5th Street Kansas City, KS 66101
Doyle Childers Director	Nebraska Department of Health & Human Services 301 Centennial Mall South Lincoln, NE 68509
Mark Miles State Historic Preservation Officer	Missouri Department of Natural Resources P.O. Box 176 Jefferson City, MO 65102

List of Agencies, Organizations, and Persons

Name and Title	Company and Address
Michael J. Smith State Historic Preservation Officer	Department of Natural Resources P.O. Box 176 Jefferson City, MO 65102
Robert Puschendorf	Nebraska State Historical Society P.O. Box 82554 Lincoln, NE 68501
Carla Mason	ADC Digital Communications 820 Central Ave Auburn, NE 68305
Matthew Leaf	KTNC/KLZA Radio 1602 Stone St. Falls City, NE 68355
Daryl J. Oberneyer	ADC Digital Communications 64381 727A Road Brownville, NE 68321

**APPENDIX A.
COMMENTS RECEIVED ON THE COOPER NUCLEAR STATION,
ENVIRONMENTAL REVIEW**

A. COMMENTS RECEIVED ON THE COOPER NUCLEAR STATION ENVIRONMENTAL REVIEW

A.1. Comments Received During Scoping

The scoping process began on January 26, 2009, with the publication of the U.S. Nuclear Regulatory Commission's (NRC's) Notice of Intent to conduct scoping in the *Federal Register* (NRC, 2009a). The scoping process included two public meetings held in Brownville and Auburn, Nebraska, on February 25, 2009. Approximately 120 people attended the meetings. After the NRC's prepared statements pertaining to the license renewal process, the meetings were open for public comments. Attendees provided oral statements that were recorded and transcribed by a certified court reporter. Transcripts of the entire meeting, as well as written statements submitted at the public meetings, were issued as an attachment to the Cooper Public Meeting Summary Report dated April 14, 2009 (NRC, 2009b). In addition to the comments received during the public meetings, comments were received through the mail and e-mail.

Each commenter was given a unique identifier so every comment could be traced back to its author. Table A-1 identifies the individuals who provided comments applicable to the environmental review and the Commenter ID associated with each person's set of comments. The individuals are listed in the order in which they spoke at the public meeting, and in alphabetical order for the comments received by letter or e-mail. To maintain consistency with the Public Meeting Summary Report, the unique identifier used in that report for each set of comments is retained in this appendix.

Specific comments were categorized and consolidated by topic. Comments with similar specific objectives were combined to capture the common essential issues raised by participants. Comments fall into one of the following general groups:

- (1) Specific comments that address environmental issues within the purview of the NRC environmental regulations related to license renewal. These comments address Category 1 (generic) or Category 2 (site-specific) issues or issues not addressed in the *Generic Environmental Impact Statement for License Renewal of Nuclear Power Plants* (GEIS). They also address alternatives to license renewal and related Federal actions.
- (2) General comments: (1) in support of, or opposed to, nuclear power or license renewal; or (2) on the renewal process, the NRC's regulations, and the regulatory process. These comments may or may not be specifically related to the Cooper Nuclear Station (CNS) license renewal application.
- (3) Comments that do not identify new information for the NRC to analyze as part of its environmental review.
- (4) Comments that address issues that do not fall within, or are specifically excluded from, the purview of NRC environmental regulations related to license renewal. These comments typically address issues such as emergency response and preparedness, security and terrorism, energy costs, energy needs, current operational safety issues, and safety issues related to operation during the renewal period.

Appendix A

Table A-1. Commenters on the Scope of the Environmental Review. *Each comment is identified along with their affiliation and how their comment was submitted.*

Commenter ID	Commenter	Affiliation	Comment Source	ADAMS Accession Number^(a)
CNS-A	Martin Hansen	Village Board of Brownville	Afternoon Scoping Meeting	ML090840062
CNS-B	Glen Krueger	Member of the Public	Afternoon Scoping Meeting	ML090840062
CNS-C	Becky Cromer	Falls City Economic Development and Growth Enterprise	Afternoon Scoping Meeting	ML090840062
CNS-D	Arnold Ehlers	City Clerk/Treasurer for the City of Nebraska City, Nebraska	Afternoon Scoping Meeting	ML090840062
CNS-E	James Gerwick	Emergency Management Director for Richardson County, Nebraska	Afternoon Scoping Meeting	ML090840062
CNS-F	Robert Cole	Nemaha County Emergency Management Director	Evening Scoping Meeting	ML090840063
CNS-G	Rod Vandenberg	Mayor of Falls City, Nebraska	Evening Scoping Meeting	ML090840063
CNS-H	Larry Shepard	U.S. Environmental Protection Agency	Evening Scoping Meeting	ML090840063
CNS-I	Bob Engles	Mayor of Auburn, Nebraska	Evening Scoping Meeting	ML090840063
CNS-J	Kendall Neiman	Auburn Chamber of Commerce	Evening Scoping Meeting	ML090840063
CNS-K	David Sickel	County Commissioner Richardson County	Evening Scoping Meeting	ML090840063
CNS-L	Ron Asche,	Nebraska Public Power District	Evening Scoping Meeting	ML090840063
CNS-M	Alan Richard	Pawnee City Development Corporation	Letter	ML090720067
CNS-N	Ashtin Paris	Deputy Clerk City of Rock Port	Letter	ML090720068
CNS-O	James Gerwick	Emergency Management Director for Richardson County, Nebraska	Letter	ML090720066
CNS-P	Larry Spepard	U.S. Environmental Protection Agency	Email	ML091070269
CNS-Q	Jill Dolberg	Nebraska State Historic Preservation Office	Letter	ML090650061
CNS-R	Jean Angell	Nebraska Department of Natural Resources	Letter	ML090860762

(a) The accession number for the afternoon transcript is ML090840062.
The accession number for the evening transcript is ML090840063.

Comments received during scoping applicable to this environmental review are presented in this section along with the NRC response. Comments received during the public meeting have been transcribed; comments received by letter or e-mail have been copied in this document to maintain authenticity. Comments are grouped by category. There were two categories as follows:

- Comments in support of license renewal at CNS, discussed in Section A.2
- General comments regarding the license renewal review of CNS, discussed in Section A.3

A.1.1 Comments in Support of License Renewal at Cooper Nuclear Station

Comment CNS-A: My name is Martin Hansen, a member of the Village Board of Brownville. I'm filling in for our chairman, Marty Hayes, today. I would like to welcome the members of the Nuclear Regulatory System [sic] to our community for this meeting. Brownville, while being a small community, we see the importance of Cooper Nuclear Station. It is, of course, the largest employer in our community and throughout southeastern Nebraska. But for our community, it is a little more than that. This community was here when the construction on Cooper started nearly 40 years ago. We are here on each day of operation which is around the clock. Cooper continues to operate safely and our community of Brownville appreciates that very much.

Cooper is a partner with the community. It has lent us support. One of the examples is the Village of Brownville Volunteer Fire Department. The management of Cooper has allowed our group of dedicated fire fighters to utilize their training facilities that has enhanced its firefighting capabilities and has cooperated in an effort and has enabled our department to upgrade its equipment and training capabilities over a number of years. I'm sure that you will hear a lot more from other communities about the economic impact of Cooper on the community and the importance it has on the economy. A 2002 economic study found that there would be detrimental impact to not only Brownville, but to other communities in this area, so Cooper is important to continue operation through the license extension of 20 years.

Emergency response is an important part of Cooper operation, and any need for that action to take place would be handled in a manner that is both professional and done for the protection of the public. Cooper Emergency Response organization takes it very seriously and each resident in a 10-mile zone around Cooper always receives the appropriate information about any possible emergency response activity on the site and would have comfort of knowledge that these plans are in place and tested annually.

Earlier this month, the Village Board of Brownville unanimously approved a resolution in support of Nebraska Public Power District at Cooper Nuclear Station license renewal for an additional 20 years. I would like to read that resolution into the official record at this time.

Resolution No. 2-2-09-1

WHEREAS, the Nebraska Public Power District Cooper Nuclear Station in Brownville became operational with startup in 1974 and has operated safely and efficiently for more than 30 years and its 828 megawatts of electricity generated; and

WHEREAS, the Village of Brownville has had a longstanding history with Cooper Nuclear Station since the plant's construction, through refueling outages, and day-to-day operations; and

Appendix A

WHEREAS, the Village of Brownville Volunteer Fire Department has been able to utilize training facilities to enhance the firefighting capabilities and this cooperative effort has allowed the department to upgrade equipment in training firefighters over the years;

WHEREAS, Nebraska Public Power District has continually reinvested in the Cooper Nuclear Station facility to access continued safety, clean, reasonable, and affordable production of electricity for Nebraskans across the State; and

WHEREAS, the Cooper Nuclear Station is a critical asset as part of Nebraska Public Power District generation resources and the State's unique public power system, continues to assist in keeping State electricity rates among the lowest in the country;

WHEREAS, more than 700 permanent jobs at Cooper Nuclear Station and extensive use of contractors in ongoing maintenance and refueling outages are organized and important to the economy of the Village of Brownville, Nemaha County, and surrounding communities in southeastern Nebraska; and

WHEREAS, a 2002 economic study of the impact of the loss of Cooper Nuclear Station would be detrimental to the Village of Brownville and other communities in southeast Nebraska; and

WHEREAS, the United States Nuclear Regulatory Commission is the Federal agency charged with oversight of our nation's vital nuclear facilities and encouraged public input and comment on license renewal and process from the neighborhood and communities; and

WHEREAS, the Cooper Nuclear Station has continued to be a good neighbor to Brownville for more than three decades;

NOW, THEREFORE, BE IT RESOLVED that the Village of Brownville Council supports the renewal of the license for the nuclear generation facility at Cooper Nuclear Station and to assure their continued operations of safe, affordable, and important component of Nebraska's public power supply system for another 20 years; but

BE IT FURTHER RESOLVED that the Village of Brownville clerk is directed to make available copies of this resolution to the Nuclear Regulatory Commission at its upcoming Environment Scope Public Meeting.

Again, I wish to thank the Nuclear Regulatory Commission for hosting this important public meeting, and we'll make ourselves available to you if you have any questions of us, thank you.
(End of Comment CNS-A)

Comment CNS-B: My name is Glen Krueger and I was the hospital administrator, and I don't think the present one is here at this time. I was the hospital administrator. I came in 1971, so was there when it was started and I retired in 2002. And I would like to say that we have had a full and wonderful cooperation with the Nebraska Public Power District for emergency services. We were able to send an employee down to Tennessee to learn more about radiation. Yes, we were learning more when it first started up, but we finally came that we were very comfortable, that we knew how to take care of if an accident did happen over here. We had full cooperation from them and I would totally support this new license.

But, also, as a citizen of Auburn, I would like to restate and I would like to have this new permit be renewed, because of the need that we have in the City of Auburn, if the need—the people

that work there. We have a lot of those employees who work in our church and a lot of those employees, in fact, I have three of those employees in my block where I live. Very appreciative of them. (End of Comment CNS-B)

Comment CNS-C: I also would like to thank you for the opportunity to speak here this afternoon. My name is Beckie Cromer. I'm Executive Director of our Falls City Economic Development and Growth Enterprise. And I'm here this afternoon on behalf of the economic development team from Falls City. We would like to confirm our unwavering support for the 20-year license extension of Cooper Nuclear Station. Falls City EDGE did pass a resolution of support for the 20-year license extension, and we have forwarded that resolution to NPPD officials, although, after reading the materials here today, I think we'll also forward that NRC with the information provided within the packets today. And in addition to that, our mayor will be speaking in support of Nebraska Public Power District this evening, as well.

Cooper Nuclear Station is an economic development gem that injects millions into our local economy by providing almost 800 jobs that pay more than double the Nebraska state average. The decommissioning of Cooper Nuclear Station would result in monumental loss of revenue and jobs for our southeast Nebraska area. Additionally, Cooper Nuclear Station runs a very safe operation. It allows Nebraska to offer a diverse portfolio of power to our citizens.

I had the opportunity to tour Cooper Nuclear Station this week with many Falls City community leaders. The facility was top notch. The staff was professional and knowledgeable, and the safety measures in place for workers and the surrounding public exceeds benchmarks set by government agencies.

Southeast Nebraska is proud to have Cooper Nuclear Station as a partner in economic development and we ask that you grant the licensing request being made by Cooper Nuclear Station. Thank you. (End of Comment CNS-C)

Comment CNS-D: Good afternoon. My name is Arnold Ehlers, City Clerk/Treasurer for the City of Nebraska City, Nebraska. I am here to present a resolution passed unanimously by the City Council and Mayor of Nebraska City, supporting the license renewal of Cooper Nuclear Station. I would also like to make you aware of the economic impact Cooper Nuclear Station has on southeast Nebraska, as well as southwestern Iowa and northwest Missouri, an economic impact that is over \$500 million a year. But the economic impact is just one part of the contribution made by Nebraska Public Power District and its employees. NPPD employees belong to volunteer fire departments, serve on library boards, school boards, and many other boards and committees too numerous to mention. Their spouses and families are also very important contributors to the communities in which they live.

Over the years, Cooper has been a good safe partner and good neighbor to all of us. They have attracted employees from around the world, enhancing the multicultural experiences of the area. We've actually become a global community due to this. It is a privilege to live in a public power state and in a city that owns its own utilities. Nebraska City, in fact all of Nebraska, benefits from the low-cost electricity that Cooper Nuclear plays a significant role in providing.

I have a resolution that I would like to have entered into the record. I won't bore you with the reading of it, unless it needs to be read. I thank you for this opportunity. (End of Comment CNS-D)

Comment CNS-E: Good afternoon. Many thanks to the Nuclear Regulatory Commission for hosting this public forum. My name is Jim Gerwick, and I'm the Emergency Management Director for Richardson County, Nebraska, the county just south of here.

In my position, hardly a month has gone by where some form of interchange has not transpired between Cooper Nuclear Station's Emergency Management Department and other nuclear operations staff and my office in Richardson County. The referenced activities include quarterly emergency communication drills, unannounced communications checks, written correspondence involving improvements in emergency plans and training in many forms, to include FEMA, Federal Emergency Management Agency, evaluated radiological emergency preparedness exercises.

Other joint training activities include NPPD staff involvement in annual training of our local radiological emergency response organization, and our joint quarterly off-site training meetings.

Cooper Nuclear Station has fully demonstrated its ability to provide safe, reliable electricity for the citizens of the state of Nebraska. Richardson County has supported Cooper Nuclear Station in its off-site responsibilities to protect the public and property for many years, since the plant started, actually, and is glad to be part of the team that supports nuclear power. The bottom line in our realm of experience, the staff at NPPD and Cooper Nuclear Station is thoroughly professional and meticulous in attention to detail concerning their approach to public safety. In short, they are fully integrated and a key member of our public safety team.

And in view of their professional performance and contributions to our community, we support NPPD's application to continue to operate Cooper Nuclear Station for another 20 years.

In closing, Richardson County is proud to have Cooper Nuclear Station in the Richardson County area. (End of Comment CNS-E)

Comment CNS-F: Thank you for the opportunity to speak tonight. I'm Robert Cole. I'm the Nemaha County Emergency Management Director. I wanted to make a few short statements. I've already submitted a letter of support on the relicensing application; however, I wanted to touch on a few of the highlights that I mentioned in the letter.

One of the great things about our relationship with Cooper Nuclear Plant is that they have been good partners for the communities that they are neighbors to. One example of that would be the fact that most of my day today was spent taking delivery on sirens that Cooper Nuclear has donated for several local communities in the area, both in Nebraska and Missouri, that lacked operational or modern sirens. These retired sirens from Cooper, although they are dating back to the 1970s, are well maintained and very functional and will certainly be a vital asset to communities that could not otherwise afford replacement of their siren equipment. That's a real benefit to everybody.

Also, my relationship with Cooper has been excellent. I correspond or talk to Cooper representatives at least monthly, generally more often, in regard to emergency planning exercises and just day-to-day communications checks. Every time I have talked to somebody from the station, they have always been very professional and very competent, and I have very great confidence in the plant and their operations. It's a joy to be here in Nemaha County, and one of that joys is serving the County in this relationship to Cooper Nuclear. Thanks very much for the opportunity to be here. (End of Comment CNS-F)

Comment CNS-G: Good evening. I have prepared comments which I'd be happy to give to you if you would like them at the end of the meeting. I apologize. I maybe have gotten a little bit too lengthy, but I'll try to talk fast.

My name is Rod Vandenberg, and I am the mayor of Falls City, Nebraska. Falls City is a community of 4,200, and is located about 20 miles south of Cooper Nuclear Station as you head toward the Nebraska/Kansas border.

Interestingly, I personally had the opportunity, along with 18 community members from Falls City, to tour Cooper Nuclear Station last Monday. I can speak for myself and the others who took the tour that we were very impressed by the serious and cordial manner in which NPPD employees were watching out for our personal safety while we were on tour, and also by the extent of the security presence at the site. This opportunity gave us all a little better first-hand look at Cooper Nuclear Station, which many of us had not seen, but have heard so much about over the years. Perhaps properly so, Cooper is a well kept secret. And I would like to take this opportunity to thank everyone who participated with us in that tour. We had the opportunity to hear from the gentleman who heads the management company. And then we had the opportunity to be with several NPPD employees. And it was really an outstanding experience.

The impact of going inside such a facility and seeing how well the facility is maintained and how expansive the facility is, how it serves to protect employees, public, and the environment was time well spent. I want to thank NPPD for this opportunity.

Several months ago, I sat in a breakfast meeting right here in this building in Auburn and heard from your CEO, Ron Asche, and other NPPD employees about the license renewal process, what the needs for extending of licensing of Cooper for an additional 20 years means, and what does that mean not only for my community, but all of Nebraska. What I learned is that NPPD has put an extensive amount of money into facility improvements for safety and operations of the facility so that it can be an operation that will be able to operate safely and efficiently for an additional 20 years. What I also heard at that time was that replacing Cooper would take several billion dollars to construct another generating facility, probably using coal as fuel to replace the electric generation of Cooper. Just getting a facility sited may be a significant task, and replacing Cooper with that kind of facility may not be the most environmentally friendly one, as Cooper does not generate any greenhouse gases from its nuclear operations.

I realize that there are numerous areas that are required to be reviewed by the U.S. Nuclear Regulatory Commission related to the license renewal application, many dealing with the environment, another part on how equipment is expected to last if Cooper Nuclear Station were to operate another 20 years. As I heard at our meeting in the fall, Nebraska Public Power District's Board of Directors has had the foresight to invest millions of dollars into the operation in order to continue that operation in a safe manner, and that is what we expect for the residents of Falls City, Richardson County, and southeast Nebraska.

Our community leaders in Falls City also heard from NPPD, at my request, to tell us more about the license renewal in a luncheon session in Falls City 2 or 3 months ago. Many in the room that day have had contact with Cooper employees, both personal or for business reasons, for we have a contingent of employees that reside in Falls City and Richardson County, 101 employees to be exact.

From a socio-economic aspect, that number is important in small communities such as Falls City. Cooper employees do business in our community. They are part of community activities,

Appendix A

and they support our schools and services. These individuals operate an important electric generation for Nebraska, and they do it safely in a nuclear operation. On our tour, we were able to get a peek at a control room simulator and what these highly trained employees must train to do. The requirements are rigorous to meet the requirements to become a licensed operator.

A loss of Cooper would cause a severe negative impact on Falls City as would it be for all of southeastern Nebraska.

NPPD's CEO, Ron Asche, spoke to us last year about several maintenance issues at the plant. He could have easily passed over telling us that information, but he chose to do so, and he expressed confidence to us that NPPD would resolve these issues to the satisfaction of the NRC and return Cooper to the top level of operations for nuclear power plants in the country. And as I have learned, those words have been put into action and those findings have been resolved. Frankly, I believe Cooper is one of the safest nuclear plants in the United States.

I, and the members of the City Council of Falls City, recently passed a unanimous resolution of support for Cooper Nuclear Station's license extension for an additional 20 years. We feel that it is an important asset for southeast Nebraska and Nebraska in general, and I would like for this resolution to be included in the official meeting transcript tonight.

I want to thank the Nuclear Regulatory Commission for taking the time to hear from communities such as ours on this very important issue, not only locally, but nationally, as we work towards future energy independence. Thank you very much. (End of Comment CNS-G)

Comment CNS-H: Good evening. Thank you, Dave. And I'd like to thank the NRC. I'd also like to thank the cities and counties of southeastern Nebraska for the opportunity to attend this scoping meeting. My name is Larry Shepard. I'm an environmental scientist with the U.S. Environmental Protection Agency, in our Kansas City Regional Office. EPA has 10 regional offices around the country. Our regional office is responsible for EPA program activities in Kansas, Iowa, Missouri, and Nebraska.

My point in speaking tonight was just to help everyone tonight to understand what EPA's role is in this process, this relicensing process. EPA will be reviewing the draft supplemental environmental impact statement and providing comment, but also in actually scoring both the document and the project itself. And we will also, in addition to that, be providing comment—scoping comment to NRC by the March 27th deadline. And that was really my whole purpose. If anyone has any questions after the meeting, I'll be hanging around also. Thank you very much. (End of Comment CNS-H)

Comment CNS-I: Good evening. My name is Bob Engles, and I'm the mayor of Auburn, Nebraska. I'd like to thank the NRC for this opportunity and specifically for holding this public forum.

As I was watching the NRC presentation, safety review and environmental impact studies were mentioned as key parts of the process. I trust that both NPPD and the NRC will conduct a thorough process to identify issues that must be addressed in these areas so that Cooper Nuclear Station can continue operating for an additional 20 years.

That's exactly why I'm here. I'm here in support of extending the license for Nebraska Public Power District's Cooper Nuclear Station. I'll speak just a little bit about the socioeconomic impact on my city in particular. From a practical standpoint, I'm not sure it makes sense to

discard a proven and effective method of power generation, especially when it has served Auburn, Nemaha County, and the State of Nebraska for so many years as a safe and reliable source of electrical generation for the last 35 years in a manner that has protected the public and the environment.

Cooper Nuclear Station is an economic stimulus to Auburn and southeast Nebraska. Their footprint is a stabilizing factor in our community's economy. For example, they employ approximately 720 people, and half of those people live in Nemaha County; 234 of those people live in Auburn.

The plant's annual payroll is approximately \$55 million. Over \$17 million of that payroll goes to people that live in Auburn, and with just a little bit of math, that shows that the average income per employee living in Auburn is about \$75,000. These employees are highly educated, highly trained and skilled, and they do a quality job day in and day out with safety as their prime responsibility.

Cooper employees have become a part of the fabric of this community over the years. They live here. They're involved in community activities. They're involved in our churches; they frequent the business community; they are involved in youth activities and social events within our community.

These people are our friends. They're our neighbors. Their kids attend our schools. They volunteer their time to make Auburn and southeast Nebraska a better place in which to live.

Late last year, following NPPD's submittal of a license renewal application, Ron Asche, CEO and President of NPPD, which owns Cooper, held a series of meetings within the community with myself and other elected officials from other communities and the business community. Mr. Asche pointed out that NPPD's Board of Directors has invested over \$300 million in improvements to Cooper in preparation for the license extension. NPPD is serious about making these improvements that will enhance the safety of the operations, as well as continuing to generate low-cost electricity, something that Nebraskans expect and which NPPD is mandated under State law to do.

Several years ago, NPPD discussed the possibility of closing Cooper. This community was concerned about that, primarily because of the impact on the economy of Auburn and southeast Nebraska. Closing Cooper would have been unfortunate. But NPPD's Board of Directors saw the value in keeping the facility operating and have done a great job in moving forward with the safe operations of the facility, something that was expected to continue for another 20 years.

Indeed, all Nebraskans benefit from the operation of Cooper Nuclear Station. Auburn has benefited from Cooper's operations directly, even though the plant is 10 miles away. Nebraska Public Power District has two facilities in our community that we believe are important for the operations of the site. The former Sheridan Elementary School has been transformed into a training center for Cooper employees and the many contractors who come into the community every 18 months for refueling outages. We believe that the training facility plays a great part of the strong environmental responsibility and safe operations of the facility each day.

A second facility was remodeled in our downtown area and houses a state-of-the-art Emergency Operations Center which would operate as needed. Exercises are held on a regular basis from that facility, including ones with local emergency management personnel from southeast Nebraska.

Appendix A

As mayor, I'm confident in the ability of NPPD to operate and manage in a safe manner. What we may hear from people that are concerned about safety issues, we can all be concerned about safety issues. But throughout the years, I've come to know that the people at Cooper and NPPD have confidence and that they understand the risks associated with nuclear power generation and that they have been and continue to do everything in their power to ensure my safety and our community's safety, because the same people that are working at NPPD Cooper Nuclear Station live in Auburn. They live in Brownville, Nemaha County, Falls City, and Nebraska City.

And at this time, I'd like to introduce into the formal record a resolution that our City Council passed a while back unanimously approving support for the extension of the Cooper Nuclear Station license.

And once again, I'd like to thank the NRC for hosting these meetings in our community, and if there's anything our town can do to help you further this process, please do not hesitate to contact us. Thank you. (End of Comment CNS-I)

Comment CNS-J: Good evening. My name is Kendall Neiman and I'm President of Auburn Chamber of Commerce, and also the publisher of the Nemaha County Herald, the local weekly newspaper here. On behalf of the Auburn Chamber of Commerce, I'm expressing full support for the Nebraska Public Power District's application to extend the Cooper Nuclear Station for an additional 20 years.

We believe that Cooper's safety and performance speaks for NPPD's expertise in nuclear plant operations. Several years ago, it appeared that NPPD might close down the Cooper Nuclear Station. This was something that southeastern Nebraska could not afford to have happen. A community group had an economic study done that gave us a look at what we could see locally if the facility was closed. That was about 6 years ago, and that picture was not very pretty. Devastating might be a better word. If Cooper Nuclear were not to continue operating after its current license expires, we could see those impacts all over southeastern Nebraska.

Over 700 employees live, work, shop, and are involved in the communities in southeastern Nebraska. A majority of these employees live right here in Auburn and Nemaha County. They are contributors to the community, but they are also workers at the nuclear power plant that emphasizes nuclear safety of all as a top priority.

I recently attended an open house held by NPPD in the Cooper Nuclear facility and was able to learn more about the license extension, safety, emergency response, and other operations of the facility. It's very complex, but I found that the people that I talked to be very knowledgeable and they were concerned with safety of the operations, but they were very proud of what they do on a daily basis. It is our hope that the Nuclear Regulatory Commission's review of the license application will be thorough in both the environmental review as well as the safety review of the Cooper Nuclear Station as required for license renewal. We believe that NPPD has done an excellent job in the operation of the facility as they have turned out a record generation year in 2007, have maintained a strong safety culture for the safety of the employees and the public, and maintained a high visible emergency response operation with local governments and continue to watch over a reliable generating source of electricity for Nebraskans with a watchful eye.

The Auburn Chamber of Commerce supports this license renewal extension and look forward to the Nuclear Regulatory Commission's review of the facility and seeing a 20-year extension

added to the existing license of the facility. Again, thank you for coming to Auburn and giving the community an opportunity to be heard. (End of Comment CNS-J)

Comment CNS-K: My name is David Sickel. I'm one of the three County Commissioners from Richardson County. I'm pleased to have the opportunity to speak to the Nuclear Regulatory Commission concerning the extension of the Cooper Nuclear Station's license for an additional 20 years.

While Richardson County may be somewhat outside the influence of Cooper Nuclear Station's operations, it is important to acknowledge that over the years this facility has been able to operate in a safe and effective manner for the residents of Nebraska. It is important that a complete review of the environmental impacts for 20 more years of operation be studied thoroughly by both the Nebraska Public Power District and the Nuclear Regulatory Commission.

As I understand another critical phase is a safety review. Again, this is important this type of review be conducted to ensure that equipment at the facility can operate an additional 20 years without having the impact on employee and public safety. The fact that much of this information is available to the public and can have public involvement is an important aspect of the entire process.

Cooper Nuclear Station is an important part of our community. It operates safely. The employees at Cooper are highly trained. Cooper generates a reliable source of electricity for the people of the State of Nebraska. Employees reside in communities such as Richardson County. Over the years, the presence of Cooper employees in southeast Nebraska has been an important part of our economy, our schools, or business community, and the community in which these folks live. The impact on this area from the loss of Cooper operations would create an economic hardship when you consider those losses. That loss would impact Richardson County, southeast Nebraska, and the complete State of Nebraska.

On behalf of the citizens of Richardson County, we are in support of the extension of the Cooper Nuclear Station's license renewal for an additional 20 years.

In a letter that I wrote to NPPD's CEO and President, Ron Asche, I explained that Richardson County was proud to have Cooper Nuclear Station in the Richardson County area. Cooper Nuclear Station clearly demonstrated its ability to provide safe and reliable electricity for citizens of Nebraska. I would like to mention that as the only public power State in the country, we enjoy having the fifth lowest cost electricity rates in the United States. Richardson County, through its Emergency Management has supported the facility in its offsite responsibilities to protect the public for many years, and we are glad to be part of that team that supports Cooper and nuclear power.

Thank you for this opportunity to speak to you this evening. (End of Comment CNS-K)

Comment CNS-L: I'm Ron Asche, the President and CEO of Nebraska Public Power District, the owner and operator of Cooper Nuclear Station. We began our process of compiling our license renewal application several years ago, and submitted that to the NRC in September of this past year. These public meetings tonight conducted by the NRC are a very important process in that relicensing process. They provide an opportunity for members of the local communities that surround Cooper Station and for other interested stakeholders to provide input directly to the NRC regarding our license application and any issues that they may have regarding the environmental impacts of extending Cooper's license for another 20 years, as well

Appendix A

as any public safety issues that they may have. And I'd like to thank all of those that came this evening to express their comments to the Nuclear Regulatory Commission, both in these meetings today and for comments that you might submit via letter or e-mail, et cetera. These are a very important part of that process.

I want to close just by saying that NPPD is committed to operating Cooper Station, both now and in the future, in a manner that protects the health and safety of the public and all of our employees and workers at the plant, as well as protecting the environment. We look forward to working together with the NRC over the course of the next several years in addressing issues that may arise, which we hope will ultimately result in an extension of our license for another 20 years to operate Cooper Station and continue to provide low cost, reliable, and safe energy to the members of our communities and the State of Nebraska as a whole. Thank you. (End of Comment CNS-L)

Comment CNS-M:



PAWNEE CITY DEVELOPMENT CORPORATION

P.O. Box 65
Pawnee City, NE 68420

Pawnee City - "Pleasant Past, Progressive Future"

Chief, Rulemaking
Directives and Editing Branch
Division of Administrative Services, Office of Administration
Mailstop T-6D59
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555-0001

12/30/08
73 FR 79921
②

To Whom It May Concern:

The Pawnee City Economic Development Corporation is submitting this letter to support the renewal of the license for Cooper Nuclear Station operated by Nebraska Public Power in southeast Nebraska. Our group recognizes the importance of the Station in providing low cost and safe energy to our region. We can assure any potential business, that the Station is committed to safety by their safe operations for the past 40 years and their investment of \$300 million to upgrade the facility. Their trained workforce has a strong economic impact on our area. We do not see any negative environmental impact with this facility but if it were to be replaced by a coal-powered plant, we do not think that would be the case. We urge you to approve the license renewal so we have good, clean, green energy for years to come.

CNS-M

Sincerely,

Alan Richard
Alan Richard
President, Pawnee City Development Corporation

RECEIVED

DEC 10 10:41:06

ADMINISTRATIVE SERVICES

*SUNSE Review Complete
Template = ADM-013*

*E-RIDS = ADM-03
Add. = E. SAYOC (ECS3)*

(End of Comment CNS-M)

Comment CNS-N:



500 South Main
Rock Port, MO 64482

Phone 660-744-2636 • FAX 660-744-5553
rpcityhall@rpl.coop

February 27, 2009

12/30/08
73 FR 79921

③

RECEIVED

NOV 11 AM 10:04

NUREG-1437-41

Chief, Rules and Directives Branch
Division of Administrative Services
Office of Administration
U.S. Nuclear Regulatory Commission
Mailstop T-6D 59
Washington, D.C. 20555-0001

To whom it may concern:

Please find enclosed a copy of Resolution #2009-1 supporting Nebraska Public Power District's Cooper Nuclear Station License Renewal passed by the City of Rock Port on February 18, 2009.

CNS-N

Sincerely,

Ashtin Paris
Deputy Clerk
City of Rock Port

50VSL Review Complete.
Template = ADM-013

E-RTS = ADM-03
Call = E. Soyoc (ECS3)

RESOLUTION # 2009-1

**A RESOLUTION OF THE BOARD OF ALDERMEN
OF THE CITY OF ROCK PORT, MISSOURI
Supporting Nebraska Public Power District's
Cooper Nuclear Station License Renewal**

WHEREAS, Nebraska Public Power District's Cooper Nuclear Station in Brownville became operational with startup in 1974; and

WHEREAS, Cooper Nuclear Station has operated safely and efficiently for more than 30 years, generated a record 6.6 million megawatt hours of electricity in 2007, and its 828 megawatts of electrical generating capacity remains vital to Nebraska's economy; and

WHEREAS, Nebraska Public Power District has continually reinvested in the Cooper Nuclear Station facility to assure continued safe, clean, reliable and affordable production of electricity for Nebraskans across the state; and

WHEREAS, Cooper Nuclear Station is a critical asset as part of Nebraska Public Power District's generation resources and the state's unique public power system, continues to assist in keeping state electric rates among the lowest in the country; and

WHEREAS, more than 700 permanent jobs at Cooper Nuclear Station and the extensive use of contractors for ongoing maintenance and refueling outages are recognized as vitally important to the economies of the City of Rock Port, Atchison County, and surrounding communities of southeastern Nebraska and northwest Missouri; and

WHEREAS, Nebraska Public Power District submitted an application to renew Cooper Nuclear Station's operating license to the United States Nuclear Regulatory Commission on September 29, 2008; and


WHEREAS, the United States Nuclear Regulatory Commission is the federal agency charged with oversight of our nation's vital nuclear facilities and encourages public input and comment on license renewal proceedings from its neighboring communities; and

WHEREAS, Cooper Nuclear Station has been a good neighbor to its communities for more than three decades and its employees are interwoven into the fabric of the community, local schools churches, and community activities;

NOW, THEREFORE, BE IT RESOLVED that the City of Rock Port City Council supports the renewal of the license for the nuclear generating facilities at Cooper Nuclear Station, to assure their continued operation of safe, affordable and integrally important component of Nebraska's public power electric power supply system for another 20 years; and

BE IT FURTHER RESOLVED that the City of Rock Port City Clerk is directed to make available a copy of this resolution to the Nuclear Regulatory Commission at its upcoming Environmental Scoping Public meeting.

Passed and approved this 18th day of February 2009


Helen Jo Stevens, Mayor

ATTEST:


Maureen K. Moore, City Clerk/Admin.

CNS-N,
continued

(End of Comment CNS-N)

Comment CNS-O:

Emergency response- James Gerweck, Richardson County

Good afternoon, many thanks to the NRC for hosting this public forum. I'm James Gerweck. I am the Director of the Richardson County, Nebraska, Emergency Management Agency. In my position, hardly a month has gone by where some form of interchange has not transpired between the Cooper Nuclear Station's Emergency Management Department and other nuclear operations staff and my office in Richardson County.

The referenced activities included quarterly emergency communications drills, unannounced communications checks, written correspondence involving improvements in emergency plans and training in many forms to include FEMA evaluated radiological emergency preparedness exercises. Other joint training activities include NPPD staff involvement and annual training of our radiological emergency response organization and our joint quarterly off-site training meetings.

Cooper Nuclear Station has fully demonstrated its ability to provide safe and reliable electricity for the citizens of the State of Nebraska. Richardson County has supported CNS in its offsite responsibilities to protect the public and property for many years and is glad to be a part of the team that supports nuclear power.

The bottom line in our realm of experience, the staff at the NPPD and Cooper Nuclear Station is thoroughly professional and meticulous in attention to detail concerning their approach to public safety. In short, they are fully integrated and a key member of our

CNS-O

1082

public safety team and in view of their professional performance and contributions to our community, and we support the NPPD's application to continue operating at Cooper Nuclear Station for another 20 years.

CNS-O,
continued

In closing, Richardson County is proud to have CNS in the Richardson County area.

Thank you.

James A. Gerwech, director

PO Box 609

Falls City, Nebraska 68355

402-245-2446 office

402-245-5578 Fax

rcema@sencoco.net Email

(End of Comment CNS-O)

NRC Response to Comments CNS-A through CNS-O: The comments are supportive of license renewal. The comments are general in nature, provide no new information and, therefore, will not be evaluated further. No change to the scope of the CNS supplemental environmental impact statement (SEIS) will be made as a result of these comments.

A.1.2 Comments Regarding the License Renewal Review of Cooper Nuclear Station

Comment CNS-P:

Emmanuel Sayoc

From: CooperEIS Resource
Sent: Thursday, April 16, 2009 1:39 PM
To: Emmanuel Sayoc
Subject: FW: Scoping Comments for Relicensing of Cooper Nuclear Station, Brownvi

-----Original Message-----

From: Shepard.Larry@epamail.epa.gov [mailto:Shepard.Larry@epamail.epa.gov]
Sent: Friday, March 27, 2009 4:59 PM
To: CooperEIS Resource
Cc: Cothorn.Joe@epamail.epa.gov; Hooper.CharlesA@epamail.epa.gov; Dunn.John@epamail.epa.gov; Lancaster.Kris@epamail.epa.gov
Subject: Scoping Comments for Relicensing of Cooper Nuclear Station, Brownville, NE

RE: Notice of Intent to Prepare an Environmental Impact Statement and Conduct Scoping Process for Cooper Nuclear Station; Federal Register Volume 74, No. 15, January 26, 2009, page 4476.

Thank you for the opportunity to provide scoping comments on the proposed relicensing of Cooper Nuclear Station (CNS), in support of the U.S. Nuclear Regulatory Commission's (NRC) preparation of an Environmental Impact Statement (EIS). EPA reviewed this project in accordance with the National Environmental Policy Act (NEPA) and Section 309 of the Clean Air Act. We request that, in the future, the NRC provide an adequate period of time after conducting site audits for the submission of scoping comments by state or federal agencies. In this instance, scoping comments are to be submitted prior to the NRC site audit for this project.

Pleased consider the following comments during the EIS development process.

Radiation - Given the uncertainty involved with licensing the Yucca Mountain Nevada facility and the extremely long time-frames needed to secure Congressional approval and complete site preparation for any possible alternative permanent site for the disposal of spent nuclear fuel, all utilities planning on extending operation of existing nuclear units should consider contingencies for long-term storage of waste on-site.

Water Quality - The current CNS site has an existing infrastructure, which includes intake and discharge structures. The source of water for the plant is the Missouri River. Potential impacts to plant operation associated with available river flow, particularly during periods of sustained low flow, should be thoroughly described in the draft EIS. The draft EIS should articulate the assurance of a long-term water supply (i.e., greater than 20 years) for the operation of the reactor. This analysis should address contingencies created by changing regional climate and potential future changes in the operation of the river by the Army Corps of Engineers (i.e., flow

CNS-P

releases). The current facility is covered by a National Pollutant Discharge Elimination System (NPDES) permit issued by the Nebraska Department of Environmental Quality (NDEQ). New studies and analyses performed in support of the most recent permit application (e.g., thermal and chemical discharges) should be included in the draft EIS. The draft EIS should also completely discuss issues associated with entrainment and impingement of aquatic organisms (i.e., Section 316b of the Clean Water Act) and include alternatives to the present intake design. From a review of the Environmental Report, it is apparent that there is a great deal of information available regarding the impact of plant operation on the river ecosystem. However, we generally caution that these studies are 30 years old and the draft EIS should clearly articulate whether these data are representative of current river condition and ecological impact. We would expect the NRC to provide both its reasoning and data supporting that additional and more recent research is not required to adequately document current impacts.

The draft EIS should thoroughly characterize past contamination associated with the operation of CNS, particularly source and fate of tritium in the system, and document current condition of surface water and groundwater upstream and downstream from the site.

Environmental Management System - The Council on Environmental Quality (CEQ) published "Aligning NEPA processes with Environmental management Systems-A Guide for NEPA and EMS Practitioners" to improve NEPA implementation and environmental sustainability goals in NEPA and Executive Order 13423. The NEPA document should discuss EMS as appropriate.

CNS-P,
continued

Larry Shepard
NEPA Team/Interstate Waters
US EPA Region 7
913-551-7441

(End of Comment CNS-P)

Appendix A

Comment CNS-Q:



NEBRASKA STATE HISTORICAL SOCIETY
1500 R STREET, P.O. BOX 82554, LINCOLN, NE 68501-2554
(402) 471-3270 Fax: (402) 471-3100 1-800-833-6747 www.nebraskahistory.org
Michael J. Smith, Director/CEO

February 2, 2009

Mr. David L. Pelton, Chief
Division of License Renewal
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555-0001

RE: Cooper Nuclear Station license renewal HP# 0801-050-001

Dear Mr. Pelton:

Thank you for submitting the referenced project for our review and comment. Our comment on this project and its potential to affect historic properties is required by Section 106 of the National Historic Preservation Act of 1966, as amended, and implementing regulations 36 CFR Part 800. Before we are able to adequately review the proposed Area of Potential Effect (APE) for this project for its potential to affect historic properties, we require the following information:

- A map clearly defining the boundaries of the APE

Please submit this information to: Bob Puschendorf, Nebraska State Historic Preservation Office, P.O. Box 82554, 1420 P Street, Lincoln, NE 68501-2554.

Sincerely,

Jill E. Dolberg
Review and Compliance Coordinator
Nebraska State Historic Preservation Office

Cc: Tam Tran, NRC
Emmanuel Sayoc, NRC
Steward B. Minahan, Chief Nuclear Officer, Cooper Nuclear Station

(End of Comment CNS-Q)

CNS-Q

Comment CNS-R:



Dave Heineman
Governor

STATE OF NEBRASKA
DEPARTMENT OF NATURAL RESOURCES
Brian P. Dunnigan, P.E.
Director

March 9, 2009

IN REPLY TO:

David L. Pelton, Branch Chief
Projects Branch I
Division of License Renewal
Office of Nuclear Reactor Regulation
United State Regulatory Commission
Washington, DC 20555

Dear Mr. Pelton:

A letter sent by you February 4, 2009, to the Nebraska Department of Natural Resources is being returned. The letter requests a list of protected species. The appropriate Nebraska agency for such request is the Nebraska Game and Parks Commission at the following address:

CNS-R

Kristal Stoner
Nebraska Game and Parks Commission
P.O. Box 30370
Lincoln, NE 68503-0370

If we can be of assistance to you in other matters, please feel free to contact us.

Sincerely,

Jean E. Angell
Jean E. Angell

Enclosure
cc: Kristal Stoner, NGPC

legal/angell/2009
301 Centennial Mall South, 4th Floor • PO. Box 94676 • Lincoln, Nebraska 68509-4676 • Phone (402) 471-2363 • Telefax (402) 471-2900

An Equal Opportunity/Affirmative Action Employer

Printed with soy ink on recycled paper

(End of Comment CNS-R)

Appendix A

The NRC subsequently sent correspondence to the Nebraska Game and Parks Commission and received the requested list of protected species by e-mail as shown in Appendix D1. The NPPD also received a letter from the U.S. Fish and Wildlife Service that it “concur[s] with the NPPD and NRC determination that the proposed relicensing action is not likely to adversely affect Federally-listed species or result in the destruction or adverse modification of federally designated critical habitat.” This letter is also included in Appendix D.

NRC Response to Comments CNS-P through CNS-R: With respect to the comments from the Nebraska State Historical Society (CNS-Q), and the Nebraska Department of Natural Resources (CNS-R), these comments contain matter from consultations with other government agencies, which support the license renewal review process. No change to the scope of the CNS SEIS will be made as a result of these comments.

With respect to the Environmental Protection Agency (EPA) scoping comments (CNS-P) regarding the disposal of spent nuclear fuel, all utilities planning on extending operation of existing nuclear units should consider contingencies for long-term storage of waste onsite.

The NRC fully evaluated and addressed this issue in the GEIS, and in its regulations. The current and potential environmental impacts from spent fuel storage onsite at the current reactor sites have been studied extensively and are well understood. The storage of spent fuel in spent fuel pools was considered for each plant in the safety and environmental reviews at the construction permit and operating license stage. The NRC has studied the safety and environmental effects from the temporary storage of spent fuel after the cessation of reactor operations (which may include the term of a revised or renewed license), and it published a generic determination of no significant environmental impact (the Waste Confidence Rule) in its regulations in Section 51.23 of Title 10 of the *Code of Federal Regulations* (CFR). 10 CFR 51.23(a) states:

The Commission has made a generic determination that, if necessary, spent fuel generated in any reactor can be stored safely and without significant environmental impact for at least 30 years beyond the licensed life for operation (which may include the term of a revised or renewed license) of that reactor at its spent-fuel storage basin or at either on-site or off-site independent fuel storage installations.

In September 2009, the Commission reviewed this rule and declined to approve an update of the rule. In accordance with this determination, the rule also provides that no discussion is required concerning the environmental impacts of spent fuel storage for the period following the term of the reactor operating license, including a renewed license. Therefore, the SEIS will not include a discussion on the storage of spent nuclear fuel.

With respect to the EPA scoping comments (CNS-P), regarding past contamination associated with the operation of CNS, particularly source and fate of tritium in the system, the SEIS has a discussion on the impacts of radioactive liquid effluents discharged into the Missouri River. The discussion evaluates the radiological dose impact to members of the public as well the impact to the environment. The SEIS also discusses the results of CNS’s radiological environmental monitoring program in which environmental sample media are collected and analyzed in order to evaluate the radiological impacts, if any, of plant operation on the environment.

With respect to the EPA scoping comments (CNS-P), regarding water quality, the SEIS will discuss National Pollutant Discharge Elimination System (NPDES) permits and related activities including any updated information, available river flow including low flows, U.S. Army

Corps of Engineers (USACE) river flow control operations, as well as aquatic and terrestrial ecosystem issues. The NRC staff does recognize that the river ecological studies are generally dated, and addresses this issue in the SEIS.

Comments Received on the Draft Supplemental Environmental Impact Statement

Pursuant to 10 CFR Part 51, the staff transmitted the "Generic Environmental Impact Statement for License Renewal of Nuclear Plants Regarding Cooper Nuclear Station," Draft Report for Comment (NUREG-1437, Supplement 41, referred to as the draft supplemental environmental impact statement (SEIS)) to Federal, State, and local government agencies, and interested members of the public. As part of the process to solicit public comments on the draft SEIS, the staff:

- placed a copy of the draft SEIS into the NRC's Public Electronic Reading Room, on its license renewal website, and at the Auburn Memorial Library, Auburn, Nebraska.
- sent copies of the draft SEIS to the applicant, members of the public who requested copies, and certain Federal, State, and local agencies
- published a notice of availability of the draft SEIS in the *Federal Register* on February 18, 2010 (75 FR 8757);
- announced and held two public meetings in Auburn, Nebraska, on April 7, 2010, to describe the results of the environmental review and answer questions on the license renewal process
- placed newspaper ads and issued press releases announcing the issuance of the draft SEIS, the public meetings, and instructions on how to comment on the draft SEIS
- established an e-mail address to receive comments on the draft SEIS through the Internet

During the comment period, the staff received a total of six comment letters and e-mails in addition to the comments received during the public meetings.

The staff has reviewed the public meeting transcripts and the comment letters that are part of the docket file for the application, all of which are available in the NRC's Public Document Room. This section of Appendix A contains a copy of each commenter's submission(s) during the comment period. For those that provided oral comments at the April 7 meetings, comments are taken from the meeting transcripts. Note that only comments from those transcripts are included in this document; however, the complete meeting transcripts can be accessed online or in-person from the Agencywide Documents Access and Management System (ADAMS) at accession numbers ML101320545 and ML101320618.

Comment letters and e-mails are also available online in ADAMS. A cross-reference of the speaker or author of the comment, their affiliation (if stated), the comment source, and the ADAMS accession number of the comment is provided in Table A-2.

Table A-2. Commenters on the Draft Supplemental Environmental Impact Statement.
Each comment is identified along with their affiliation and how their comment was submitted.

Commenter ID	Commenter	Affiliation	Comment Source	ADAMS Accession Number ^(a)
--------------	-----------	-------------	----------------	---------------------------------------

CNS-S	Andrew Smith	No Known Affiliation	Letter	ML101040676
CNS-T	Bob Engles	Mayor of Auburn, Nebraska	Afternoon DSEIS Meeting	ML101440133
CNS-U	Glen Krueger	Former local hospital administrator	Afternoon DSEIS Meeting	Transcript, ML101320545
CNS-V	Robert Harns	U.S. Fish and Wildlife Service	E-mail	ML101440172
CNS-W	Robert Puschendorf	Nebraska State Historic Preservation Office	Concurrence on NRC Letter	ML101440131
CNS-X	Robert Stewart	U.S. Department of Interior	Letter	ML101440132
CNS-Y	R. Hammerschmidt	U.S. Environmental Protection Agency	Letter	ML101270268
CNS-Z	Brian J. O'Grady	Nebraska Public Power District	Letter	ML101250348

- (a) The accession number for the afternoon transcript is ML101320545.
The accession number for the evening transcript is ML101320618.

There was no significant new information provided on Category 1 issues, or information that required further evaluation on Category 2 issues. Therefore, the conclusions in the GEIS and draft SEIS remained valid and bounding, and no further evaluation was performed. Comments without a supporting technical basis or without any new information are discussed in this appendix, and not in other sections of this report. Relevant references that address the issues within the regulatory authority of the NRC are provided where appropriate. Many of these references can be obtained from the NRC Public Document Room. Where the comment or question resulted in a change in the text of the draft report, the corresponding response refers the reader to the appropriate section of this report where the change was made. Revisions to text in the draft report are designated by vertical lines beside the text. Comments were grouped by category. There were four categories as follows:

- (1) Comments in support of license renewal at CNS, discussed in Section A.2.1
- (2) Comments in support of the conclusions of the DSEIS, discussed in Section A.2.2
- (3) Comments on DSEIS by EPA, discussed in Section A.2.3
- (4) Editorial comments on the DSEIS, discussed in Section A.2.4

A.2.1 Comments in Support of License Renewal at Cooper Nuclear Station

Comment CNS-S:

Andrew E. Smith
3300 Huntington Avenue
Apt. Four
Lincoln, Nebraska 68804-2354 USA

April 3, 2010

Chief, Rules and Directives Branch
Division of Administrative Services
Mail Stop T-6D59,
U. S. Nuclear Regulatory Commission
Washington, DC 20555-0001

2/25/2010
75 FR 8757

(1)

RECEIVED

2010 APR 13 AM 9:10

RULES AND DIRECTIVES
BRANCH
USNRC

Re Cooper Nuclear Station License Renewal

Dear Sir:

I was asked by a news item for comment on this, and they gave the above address. I believe the nuclear power industry to be safe and reliable, and attempts to limit it by environmental screaming are politically motivated. The U. S. has an energy crisis which could be solved, as in Europe, by the use of nuclear power if not for the negative influence of environmental hysteria. That hysteria is not only false, but motivated by attempts to keep the United States down and helpless.

I disagree with those environmental idiots and detect the Communism in their efforts to somehow limit the nuclear industry. I therefore disagree with not renewing the license of this power plant. It should be renewed.

Nuclear energy is cheaper than coal, water, solar, wind, or anything else. Not only that, but it is more regulated than any other industry in the country because of political idiocy. I do not agree with their worries; they are farcical. I view nuclear power as cheaper, safer, cleaner, and the best for the country in the long run.

I hope you renew this plant's license. I enjoy cheaper electric utility rates as a result of nuclear power in my area, with some of the lowest rates in America. Let's keep it that way, please! I fear nothing but the Communist idiots who are so concerned.

Sincerely,
Andrew Smith

CNS-S

SI Review Complete
plate = ADM-013

E-RDS = ADM-03
Cell = B. Brady (BMB1)

(End of Comment CNS-S)

Comment CNS-T:

Several years ago NPPD discussed the possibility of closing Cooper. This community was concerned about that, primarily because of the impact on the economy of southeastern Nebraska. Closing Cooper would have been unfortunate. But NPPD's Board of Directors saw value in keeping the facility operating and have done a great job in moving forward with the safe operations of the facility, something that we expect to continue for another 20 years.

Indeed, all Nebraskans benefit from the operation of the Cooper Nuclear Station. Auburn has benefited from Cooper's operations directly, even though the plant is 10 miles away. Nebraska Public Power District has two facilities in the community that we believe are important for the operations of the site. The former Sheridan Elementary School has been transformed into a training center for Cooper employees and the many contractors who come into the community every 18 months for refueling outages. We believe that the training facility plays a great part of the strong environmental responsibility and safe operations of the facility each day.


A second facility was remodeled in our downtown area and houses a state-of-the-art Emergency Operations Center that would operate as needed. Exercises are held on a regular basis from that facility including ones with local emergency management personnel from southeastern Nebraska.

As Mayor, I'm confident in the ability of NPPD to operate and manage Cooper in a safe manner. We'll hear from, I'm sure, people that are concerned about safety issues and so am I. Throughout the years though, I've come to know the people at Cooper and NPPD and I have confidence that they understand the risks associated with nuclear power generation and that they've been and continue to do everything in their power to ensure my safety. You see, at the same time they're ensuring the safety of their families because they live in Auburn, Brownville, Nemaha County, Falls City, and Nebraska City too.

At this time I would like to introduce into the formal record a resolution of support for license extension for Cooper that was approved by the Auburn City Council.

With that, I'd like to thank the Nuclear Regulatory Commission for hosting these meetings in our community.

Thank you.



Robert B. Engles, Mayor
City of Auburn, Nebraska

CNS-T

(End of Comment CNS-T)

Comment CNS-U:

My name is Glen Krueger, G-l-e-n, K-r-u-e-g-e-r.

I was a former hospital administrator here for 31 years, retired in 2002. Totally great cooperation with Cooper. There was some—a couple of small accidents. Went very well, the cooperation between them and us. Cooper did a wonderful job of educating, providing the necessary materials.

At first when, many years ago, '71-'72, when it first started, we was a little concerned. That was alleviated very quickly. Soon as we were educated as to how to handle in case there was a problem and we was very proud to find out that we'd never had any great problems with them. Some small accidents were handled quite well.

I am very much in support of this, though I am not personally the hospital administrator at this time, but those 31 years, we was very proud to have them over there and had no problem at all with them. Thank you. (End of Comment CNS-U)

CNS-U

NRC Response to Comments CNS-S through CNS-U: The comments are supportive of license renewal. The comments are general in nature, provide no new information and, therefore, will not be evaluated further. No change to the draft CNS SEIS will be made as a result of these comments.

A.2.2 Comments in Support of the Conclusions of the Draft Supplemental Environmental Impact Statement

Comment CNS-V:

Brady, Bennett

From: Robert_Harms@fws.gov
Sent: Friday, March 19, 2010 5:19 PM
To: Brady, Bennett; Bulavinetz, Richard
Cc: jlcitta@nppd.com; John_Cochnar@fws.gov
Subject: Concurrence Cooper Nuclear Station
Attachments: CNS concurrence.pdf

Importance: High

Ms. Brady/Mr. Bulavinetz:

Please make reference to your February 18, 2010, letter requesting that the U.S. Fish and Wildlife Service (Service) concur with a determination of affect made by the Nuclear Regulatory Commission that continued operation of the Cooper Nuclear Station for an additional 20 years may affect, but is not likely to adversely affect the federally endangered pallid sturgeon. The Service has completed its review of the Biological Assessment included within the Environmental Impact Statement for the proposed project and has determined that it is satisfactory. The Service previously provided its concurrence in a letter dated August 26, 2009, which would conclude section 7 consultation on this matter. It is attached for your use.

(See attached file: CNS concurrence.pdf)

Bob

Robert R. Harms
 Fish and Wildlife Biologist
 U.S. Fish and Wildlife Service
 203 West Second Street
 Grand Island, Nebraska 68801
 Phone: 308-382-6468, Extension 17
 Fax: 308-384-8835
robert_harms@fws.gov

CNS-V



United States Department of the Interior

FISH AND WILDLIFE SERVICE

Ecological Services
Nebraska Field Office
203 West Second Street
Grand Island, Nebraska 68801

August 26, 2009

Mr. Joe Citta
Corporate Environmental Manager
Nebraska Public Power District
1414 15th Street
Columbus, NE 68801

RE: Cooper Nuclear Station License Renewal, Nebraska Public Power District

Dear Mr. Citta:

This is in response to your August 25, 2009, letter with an enclosed Memorandum of Understanding and Restrictive Covenant for Conservation. Both enclosures have been signed and executed and demonstrate the Nebraska Public Power District (NPPD) and Nuclear Regulatory Commission (NRC) intention to offset adverse affects to federally listed species resulting from the proposed Cooper Nuclear Station License Renewal.


After reviewing your August 25 letter, the U.S. Fish and Wildlife Service (Service) has concluded that it concurs with the NPPD and NRC determination that the proposed relicensing action is not likely to adversely affect federally listed species or result in the destruction or adverse modification of federally designated critical habitat.

Please note that the Service may reinitiate consultation if new species become listed or are proposed to be listed, critical habitat is proposed or designated, or new information about federally listed species becomes available that previously was not considered during this consultation. The NPPD and NRC should reinitiate consultation with the Service if the current relicensing project is modified through a change in scope and/or if new information becomes available about the project that previously was not considered.

CNS-V,
continued

The Service appreciates the opportunity to work cooperatively with the NPPD and NRC in assuming a shared responsibility for protecting federal trust fish and wildlife resources in Nebraska. If you have any questions or require technical assistance, please do not hesitate to contact Mr. Robert Harms within our office at (308)382-6468, extension 17.

Sincerely,



June DeWeese
Nebraska Field Supervisor

cc: NGPC; Lincoln, NE (Attn: Frank Albrecht)
Nebraska Land Trust; Lincoln, NE (Attn: Dave Sands)

CNS-V

(End of Comment CNS-V)


Comment CNS-W:



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

February 18, 2010

MAR 01 2010



Mr. Michael Smith, Director
Nebraska State Historical Society
P.O. Box 82554
1500 R Street
Lincoln, NE 68501

SUBJECT: COOPER NUCLEAR STATION LICENSE RENEWAL APPLICATION REVIEW
(HP NO. 0801-050-01, DESCRIPTION, NPPD, COOPER NUCLEAR STATION)

Dear Mr. Smith:

The U.S. Nuclear Regulatory Commission (NRC) staff is reviewing an application to renew the operating license for Cooper Nuclear Station, Unit 1 (CNS-1), which is located in Nemaha County, Nebraska (NE) on the west side of the Missouri River at river mile 532.5. The Village of Brownville, NE is located about 2.25 miles northwest of the site. CNS-1 is operated by the Nebraska Public Power District (NPPD). As part of its review of the proposed action, the NRC staff has prepared a site-specific Supplemental Environmental Impact Statement (SEIS) to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants," NUREG-1437. The SEIS includes analyses of relevant environmental issues, including potential impacts to historic, archeological and cultural properties from extended operation and possible refurbishment activities associated with license renewal. In accordance with our letter to the Nebraska State and Historical Society (NSHS) dated January 16, 2009, a copy of the draft supplement is enclosed. Pursuant to 36 CFR § 800.8(c), we are requesting your comments on the draft supplement and on our preliminary conclusions regarding historic properties.

CNS-W

As stated in our January 16, 2009 letter, the NRC staff has determined that the area of potential effect (APE) for a license renewal action is the area at the power plant site and its immediate environs that may be impacted by post-license renewal land disturbing operation or projected refurbishment activities associated with the proposed action. The staff views the APE for the Cooper Nuclear Station, Unit 1, license renewal as including the Cooper Nuclear Station site and the immediate environs.

The NRC staff has conducted an environmental audit at the site and has reviewed historic and archaeological records. The NRC staff also contacted 15 federally recognized Native American Tribes identified as having potential interest in the proposed undertaking. To date, no comments have been received.

In the context of the National Environmental Policy Act of 1969, under which the draft supplemental environmental impact statement was prepared, the NRC staff's preliminary determination, based on review of NSHS files, archaeological surveys, assessments, and other information, is that the potential impacts of license renewal on historic and archaeological resources is small. Under the provisions of the National Historic Preservation Act of 1966, the NRC staff's preliminary determination is that no historic properties will be affected by the proposed action. Further, NPPD has instituted a stop work order within its Cultural Resources Protection Plan to ensure that proper notification is taken to protect any historic and archaeological resources should they be discovered.

HP# 0801-050-01
County _____
STR. ARCHEO
Resp. NBS Date 20100307

M. Smith

- 2 -

Please note that the period for public comment expires on May 5, 2010. If your office requires additional time, or if there are any other questions regarding this correspondence, please have your representative contact the Environmental Project Manager, Ms. Bennett Brady, at 301-415-2981.


Sincerely,



Bo Pham, Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No.: 50-298

Enclosures: As stated

CONCUR

DEPUTY STATE HISTORIC PRESERVATION OFFICER
DATE: 3/19/10

CNS-W

(End of Comment CNS-W)



United States Department of the Interior

OFFICE OF THE SECRETARY
Office of Environmental Policy and Compliance
Denver Federal Center, Building 67, Room 118
Post Office Box 25007 (D-108)
Denver, Colorado 80225-0007



April 27, 2010

9043.1
ER 10/174

Chief, Rules and Directive Branch,
Division of Administrative Services, Mail Stop T-6D59
U.S Nuclear Regulatory Commission
Washington, D.C. 20555-0001

Dear Sir or Madam:

The Department of the Interior has reviewed the Draft Generic Environmental Impact Statement (EIS), NUREG-1437, Supplement 41, for License Renewal of Nuclear Plants; Cooper Nuclear Station, Unit 1, Nemaha County, Nebraska and has no comments on the document.

Sincerely,

Robert F. Stewart
Regional Environmental Officer

(End of Comment CNS-X)

CNS-X

NRC Response to Comments CNS-V through CNS-X: The comments provide concurrence on the findings of the draft CNS SEIS. No change to the draft will be made as a result of these comments.

A.2.3 Comments on the Draft Supplemental Environmental Impact Statement by the Environmental Protection Agency

Comment CNS-Y:



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION 7
901 NORTH 5TH STREET
KANSAS CITY, KANSAS 66101

MAY 03 2010

Michael T. Lesar, Chief
Rulemaking and Directives Branch
Division of Administrative Services
Office of Administration TWB-05-B01M
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555-0001

Dear Mr. Lesar:

RE: NRC Docket ID: NRC-2008-0617, Review of the Generic Environmental Impact Statement for License Renewal of Nuclear Plants, NUREG-1437, Supplement 41, Regarding Cooper Nuclear Station, Unit 1, Draft Report for Comment

The U.S. Environmental Protection Agency (EPA) has reviewed the Nuclear Regulatory Commission's (NRC) Generic Environmental Impact Statement (GEIS), Supplement 41, for the Cooper Nuclear Station, Unit 1 (Draft Report). Our review is provided pursuant to the National Environmental Policy Act (NEPA) 42 U.S.C. 4231, Council on Environmental Quality (CEQ) regulations 40 C.F.R. Parts 1500-1508, and Section 309 of the Clean Air Act (CAA). The GEIS, Supplement 41, was assigned the Council on Environmental Quality (CEQ) number 20100053.

The NRC is proposing to renew the license of the Cooper Nuclear Station (CNS) for an additional 20 years beyond the expiration date of the facility's current 40-year license which is January 18, 2014. CNS is owned and operated by Nebraska Public Power District (NPPD). The facility is located in Nemaha County, Nebraska, on the west bank of the Missouri River at River Mile 532.5, approximately 60 miles southeast of the city of Lincoln. The 1,359 acre site includes 239 acres on the opposite bank of the Missouri River in Atchison County, Missouri. CNS structures occupy approximately 55 acres of the total site area. NPPD leases 715 acres in Nebraska and 234 acres in Missouri for agricultural activities such as farming and livestock. The 55 acres of facility structures include a control/reactor/turbine complex serving a General Electric boiling water reactor with a generating capacity of 830 megawatts electric, a low-level radwaste building, off-gas filter building, elevated release point, diesel generator building, miscellaneous circulating water system structures, independent spent fuel storage installation (ISFSI), switchyard and other infrastructure. The facility uses the Missouri River for cooling water in a single-pass cooling water system. CNS utilizes two wells for potable water supply and three additional wells for service purposes. Wells are finished in alluvial aquifer which is under immediate influence of the Missouri River. CNS monitors groundwater through sampling of 14 monitoring wells. CNS does not routinely monitor surface water. CNS discharges process water to the Missouri River through a discharge canal. It is our understanding that the licensee

CNS-Y


does not intend to undertake any facility refurbishment activities as part of its license renewal although NPPD is constructing an ISFSI to serve CNS through the renewal term.

Based on our overall review and the level of our comments, EPA has rated the draft Supplemental Environmental Impact Statement (SEIS) for this project EC-2 (Environmental Concerns-Insufficient Information). EPA's detailed comments on aspects of the draft SEIS and a copy of EPA's rating descriptions are provided as enclosures to this letter. This EC-2 rating is based on the uncertainty of potential impacts to ground and surface waters from radiological contamination, the effects of future changes to the river environment on CNS operation and the evaluation of alternatives to CNS license renewal. Specific to the draft SEIS, the curtailed presentation of radiological data limits the ability of the reader to ascertain its strength. In addition, the presentation of values regarding many parameters lacks any benchmark against which the reader could determine significance or trend information which would allow the reader to understand whether emissions were steady, increasing or decreasing over 36 years of operation. Further, conclusions reached in the GEIS which affect alternative assessment and selection in the SEIS should be brought forward in some more appropriate form in the SEIS.

As reflected in our enclosed issue-specific comments, we request that the NRC include, as part of its license renewal for CNS, a requirement to collect data on the aquatic community of the Missouri River in the vicinity of CNS which would provide contemporary ecological information of the area of the river receiving immediate impact from facility operation, particularly cooling water withdrawals. As stated in our comments during the scoping process and referenced in the draft SEIS, currently available data regarding the immediate aquatic environment of CNS is over 30 years old. With continued operation of CNS to 2034, the conclusions reached by the licensee in its Environmental Report and the NRC in its SEIS regarding "any new and significant information on environmental issues," in the context of the GEIS and 40 CFR 51, Subpart A, Appendix B, treatment of Category 1 issues, relying solely on data collected during initial licensing will become unsupportable. The draft SEIS recognizes the dynamic, unstable nature of the lower Missouri River. As the federal government continues to expend significant resources on the recovery of species and restoration of historic river structure and function, the need for current data on the river in the vicinity of CNS and on possible impacts related to continued CNS operation and its final disposition is critical to the comprehensive review required by NEPA.

We appreciate the opportunity to provide comments regarding this project. If you have any questions or concerns regarding this letter, please contact Mr. Joe Cothorn, NEPA Team Leader, at (913) 551-7148, cothorn.joe@epa.gov, or Larry Shepard, at (913) 551-7441, shepard.larry@epa.gov.

Sincerely yours,



Ronald Hammerschmidt, Ph.D.
Director
Environmental Services Division

CNS-Y,
continued

Issue-specific Comments

Purpose and Need

We recognize that the draft SEIS relies upon the GEIS for its project purpose and need statement and that this statement is generic to all NRC license renewal decisions. However, we believe it is important to comment on this feature of the draft SEIS as it appears to influence the thoroughness of the document's evaluation of alternatives. Both the GEIS and the draft SEIS appear to confuse project 'purpose and need' with the proposed action itself (i.e., issuance of a renewed license) and, thereby, hinders the full consideration of all reasonable alternatives in this draft SEIS. In a NEPA context, the project purpose and need is to "provide an option that allows for power generation capability beyond the term of a current nuclear power plant operating license to meet future system generating needs, which may be determined by State, utility, and, where authorized, Federal decision-makers" (Section 1.2, Chapter 1). The expiration of the CNS' current operating license and existing and future energy demands in the region is the 'need' to which NRC is "responding [to] in proposing the alternatives including the proposed action" (40 CFR 1502.13). The NRC's proposed action is "issuing a renewed license for Cooper Nuclear Station, Unit 1"; however, this is but one alternative to addressing this 'need.' A fuller statement of project purpose and need is, in our estimation, an important distinction to providing a full, open review of all possible alternatives to meeting project purpose and need. This approach to purpose and need fully implements CEQ requirements regarding NRC's responsibility to "rigorously explore and objectively evaluate all reasonable alternatives", "devote substantial treatment to each alternative considered in detail", "include reasonable alternatives not within the jurisdiction of the lead agency" and "include the alternative of no action" (40 CFR 1502.14(a), (b), (c) and (d)).

CNS-Y,
continued

The intent of 40 CFR 1502.14 is difficult to achieve when project purpose and need is so directly linked to the singular decision whether to reissue an operating license. Any alternative which does not meet project purpose and need does not appear to be a reasonable or viable alternative by any measure. Inclusion of a 'no action' alternative within the SEIS is required under CEQ regulations at 40 CFR 1502.14(d). The draft SEIS states that the 'no action' alternative does not meet the project's purpose and need (Section 8.5). Further, if purpose and need are tied to the proposed action, none of the alternatives to license renewal will meet project purpose and need and this contradiction appears to affect the rigor of the evaluation of these alternatives later in the draft SEIS (40 CFR 1502.14(a) and (b)). The draft SEIS links, throughout the document, the broad project purpose and need to the NRC's determination whether safety issues or environmental impacts should preclude license renewal. In simple summation, the NRC will renew the current license, unless its' analysis reveals significant safety or environmental issues that would preclude it. That appears to create the impression that the licensing decision is the project purpose. It would seem that the project purpose and need statement should not preclude selection of any of the alternatives, including the 'no action' alternative, regardless of the outcome of the NRC evaluation of the licensee's application for renewal. Regardless of the outcome of NRC's license renewal decision, the EIS process should inform and support deliberations by other decision-makers (e.g., "State regulators and utility officials," page xviii, Executive Summary) on how to meet this energy demand by any means, including continuing

operation of CNS-1, new generation sources (e.g., supercritical coal-fired, natural gas-fired, a combination), existing sources operating outside this region, conservation measures responding to reduced capacity or a combination of these alternatives. In essence, selection of an alternative other than license renewal as the preferred alternative is not precluded by NRC's regulatory responsibilities and is fully consistent with 40 CFR 1502.14(c) which provides for the inclusion of "reasonable alternatives not within the jurisdiction of the lead agency." The SEIS should clarify whether the purpose of the project is to meet the energy demands of the region currently met by CNS operation or only a license renewal decision.

Affected Environment and Environmental Impacts of Operation

Radiological Environmental Monitoring Program (REMP) Data

The draft SEIS characterizes its conclusions regarding radiation exposures to humans and contamination of the environment from radiation releases on a limited amount of REMP data (e.g., 2003 through 2007) without explanation. Section 2.1.2 characterizes multiple forms of radioactive waste streams from CNS using data from 2003 through 2007 or only data from 2007. In Section 4.8.1., the draft SEIS generally summarizes "the calculated hypothetical maximum dose to an individual located at the CNS-1 site boundary from radioactive liquid and gaseous effluents released during 2007." The draft SEIS offers no explanation why that single year of data was relied upon to make the assessment. Similarly, in Section 4.9.7.4, the draft SEIS qualitatively summarizes REMP environmental data for only 2007 for several media to assess exposures from subsistence consumption of fish and wildlife. Again, there is no explanation offered for why only one year of data is utilized in making these determinations nor does the draft SEIS present a quantitative summary of available data. The SEIS should provide a rationale for relying on this more limited data set after almost 40 years of operation. Regarding both the assessment of radiation exposures to humans and contamination of ground and surface water, the SEIS should characterize REMP data rather than merely reference a data set and the NRC's judgment of their significance (i.e., "reasonable", "no unusual trends"). Recognizing that CNS' REMP has a 'indicator-control' design, a presentation of trend and comparison to control or environmental benchmark, where available, utilizing a more robust data set than just one or several years would provide support to the NRC's determinations of significance in the SEIS. The SEIS would be improved if the document provided some information on 'control' location and the basis for determining these sites were beyond the influence of CNS emissions and discharges. Public review of radiological data within the SEIS would also be strengthened with a more complete and thorough organization of that data for each waste stream, including non-contact cooling water (Outfall 001). Currently, the draft SEIS relies completely on the NRC's qualitative expressions that there are "no unusual trends", "no measurable impact" and "small significance" without the benefit of presenting any characterization of the data supporting these conclusions, their completeness and their representativeness of the larger operational data set.

CNS-Y,
continued

Ground Water

The SEIS does not address the potential for radiological contamination of alluvial groundwater and, therefore, the Missouri River from atmospheric washout in the immediate area of CNS. There is no description of background or historic groundwater contamination or trends in

groundwater radiological contamination during the current license period as would be expected from the facility's REMP which was initiated in 1971. In Section 2.1.7.1, the SEIS makes statements regarding a large number of monitoring wells installed to "measure the concentration of tritium in ground water" and documented "instances of liquid radiological releases." The SEIS also states that "none of the releases is a current source of ground water contamination", but provides no basis for this statement. The document also indicates that sampling and analysis results from the ground water monitoring program will be included in the final SEIS. The absence of this information in the draft SEIS interferes with our ability to evaluate radiological impacts to ground water and, potentially, the Missouri River. The SEIS would be improved if it included: the rationale behind the installation of the monitoring wells on-site and their locations, particularly the 11 installed to measure tritium contamination, the rationale behind the 3 remaining wells installed as part of CNS' INFSI Project, comparisons of the radiological character of site ground water in comparison with off-site reference or background, an explanation of benchmarks for both human health and aquatic life exposures and a characterization of ground water trends with regard to radiological contamination. Further, the SEIS should specify possible sources of radiological contamination and response actions by the licensee based on the presence of radiological contamination in these wells. Public review of these data would be strengthened if there was more information regarding what radiological levels are 'expected' by NRC at this facility, what levels might raise concern for the NRC and what measures CNS intends to take or has taken to address sources of contamination to ground water.

CNS-Y,
continued

Surface Water

Section 4.4 of the draft SEIS does not adequately characterize CNS' use of surface water in comparison to available river flows. The SEIS would be improved if it characterized the percentage of flow utilized by CNS under low and high flow river conditions under 'wet' and drought periods in the basin. Given the direct hydrologic link between ground water and the river, computations of relative facility water consumption should combine ground water and surface water withdrawals. An assessment of comparative volumes of river flow use by CNS during varying conditions (e.g., seasonal, climatic) would better characterize both the potential impact of operation on the river and the facility's dependence upon river flow. Section 2.1.6 mentions that "the circulating water system flow would be about 47 percent of Missouri River flow" under critical low flow conditions. The fact sheet supporting the State of Nebraska's NPDES permit for CNS states that 625 MGD is withdrawn from the river at the intakes. The Missouri River basin appears to be ending a recent long-term drought period during which the navigation season was shortened several times. In the recent past, low winter flows and continuing river bed degradation in some reaches have caused utilities drawing water from the lower river to take extreme engineering measures to ensure a continuing flow of water to their systems. Congress has recently ordered the Army Corps of Engineers to study those purposes for which the current Missouri River system is operated as well as to develop a formal plan to recover native species and the river ecosystem. It is reasonable to consider these actions as they might affect CNS operation during a license renewal period which extends to 2034. In addition, climatic changes to the region could result in changes in the availability and timing of river flows for facility operation. Treatment of these complex relationships in Section 4.4 is not robust enough to aid in the decision-making value of the SEIS.

Given the potential impacts of thermal discharges from any single-pass cooling system, Section 4.5.3 should provide much more information regarding CNS's NPDES compliance record since 1974 with regard to its temperature limits, recent warming trends in ambient river water and tributary flows and the impact of warmer receiving water on facility temperature compliance and a characterization of the relative volume of cooling water discharge to river flow at high and low river flows. Assimilation of heat by receiving waters without adverse effect to aquatic organisms has been a significant issue for any energy production facility and is becoming more problematic for some facilities with recent trends of increasingly warmer receiving waters (i.e., less assimilative capacity for heat). This issue warrants more detailed treatment in the SEIS. NRC should consider adding more detailed information regarding the facility's temperature allocation, modeling and mixing zone calculations as an appendix to the document.

Section 2.1.7.2 states that CNS operations do not affect water quality in the Missouri River based on a cursory description of data from the Army Corps of Engineers' Water Control Manual and listings of impairment by the State of Nebraska. There is no characterization of available monitoring data for the Missouri River in the vicinity of CNS. The draft SEIS states that NPPD does not monitor surface waters as part of its environmental program. In fact, there is limited ambient water quality data for the Missouri River. The SEIS should avoid making statements regarding the impacts of facility operation on the river based on limited and uncharacterized data. Finally, the State of Nebraska has designated the river for more beneficial uses than is stated in this section.

CNS-Y,
continued

Section 2.1.7.3 is incomplete as it does not discuss the two compliance schedules contained within CNS' NPDES permit for its cooling water intake structure (Clean Water Act, Section 316(b)) and water quality-based limits for total residual chlorine. The SEIS should also clarify which outfalls discharge to surface water and which outfalls are chlorinated or brominated.

Aquatic Life

Although we continue to have concerns about the age of the data relied upon to characterize the impacts of entrainment and impingement on river biota (Section 4.5.2.3, page 4-6), we generally agree with the conclusions of the analysis performed by NRC staff in this section. However, Section 4.5.2 would be greatly improved if the analysis included impingement data from other facilities utilizing the same or other technology and source water (i.e., large river) against which to compare CNS data. It is difficult to determine if the amount of fish impinged at CNS constitutes a comparatively large or small amount of biomass. Alternatively, data regarding entrainment at CNS appears to be very limited and inconclusive making the conclusions expressed in Section 4.5.2 regarding entrainment much more speculative and qualitative. As addressed in the cover letter to these comments, the basis for asserting that CNS operation has a small impact on aquatic life in the Missouri River would be better supported if NPPD provided more contemporary data regarding river biota in the immediate environment of the facility in an indicator-control design similar to the REMP and better characterized risks to biota from entrainment.

As with our previous comments regarding the presentation of REMP data, the draft SEIS limits its characterization of radiological contamination in the environment, in many instances, to one

year's worth of data. The document briefly mentions, in Section 4.9.7.4, monitoring milk, vegetation, surface water, drinking water, groundwater, fish and sediment, but characterizes data from only 2007. Relying on conclusions of significance apparently drawn from one year provides little basis for the NRC concluding that "the routine operation at CNS-1 has had no significant or measurable radiological impact on the environment." The SEIS reader has only the assurances of NRC staff that these data are representative of ambient conditions to conclude that a proper evaluation of environmental impact has indeed occurred.

Stormwater and Wastewater Treatment

The draft SEIS does not address possible tritium contamination within the wastewater collection and treatment system. Downwash from facility venting operations and worker sanitary contributions are common sources of radiological contamination of nuclear facility liquid effluent. CNS discharges collected site stormwater into ground water through drainage wells. The draft SEIS does not characterize stormwater radiological contamination which reflects downwash from site structures. The SEIS should summarize REMP data and characterize radiological contamination resulting from air deposition and resulting surface runoff which is discharged into drainage wells. Similarly, sanitary wastewater effluent is land-applied on-site, but there is no characterization of possible radiological ground water contamination associated with this waste stream.

There is no discussion within the draft SEIS regarding potential wastewater lagoon sludge contamination with radionuclides or the means by which the sludge is disposed. The SEIS should characterize this environmental medium and also describe how and where the sludge is disposed.

Spent Fuel Storage and Independent Spent Fuel Storage Installation

Although collective offsite radiological impacts of spent fuel storage are addressed under other NEPA documentation, the SEIS should describe the current status of the CNS's new Independent Spent Fuel Storage Installation (ISFSI) and projected capacity over the term of the license renewal period that extends to 2034. This information does not pertain to radiological risk assessment and would not be adequately addressed in the 1996 GEIS and Addendum. Given the current status of the Department of Energy's application for license for the Yucca Mountain site, this information is germane to a discussion of short-term use and long-term productivity and an irreversible commitment of resources (40 CFR 1502.15). The need for continued storage, on-site, of spent fuel might extend well beyond the operating life of the facility itself. The status of each licensed facility with regard to storage of spent fuel varies and each SEIS should characterize that status and project change to that status over the lifetime of the renewed license.

Environmental Justice

The SEIS should describe socioeconomic factors associated with CNS affecting the Sac and Fox and Iowa Reservation populations which are within the facility's ROI. These factors are noticeably absent from the SEIS' assessment of community-based impacts.

CNS-Y,
continued

The discussion of risks from subsistence consumption of fish and wildlife in Section 4.9.7.4 relies on data from 2007 and concludes that risk is minimal without the benefit of any summary data from the facility's REMP. With regard to multiple pathways of exposure, the draft SEIS concludes that "the routine operation at CNS-1 has had no significant or measurable radiological impact on the environment (page 4-33)." Given that the REMP began in 1971, it is unclear why this analysis is performed on a single year's worth of REMP data. This statement would be better supported with the characterization of more REMP data than from only 2007.

Environmental Impact of Alternatives

The SEIS carries forward, for detailed evaluation, in addition to the proposed action, three alternatives and the 'no action' alternative, although the SEIS states that the 'no action' alternative does not meet project purpose and need. Fifteen other alternatives were considered, but dismissed before detailed evaluation. The three alternatives evaluated are: supercritical coal-fired generation; natural gas combined-cycle generation; and a combination of natural gas combined-cycle generation, conservation capacity increases and wind power.

Super Critical Coal-Fired Generation

The cumulative air impacts of emissions associated with this alternative in combination with those of existing coal-burning facilities in eastern Nebraska, western Iowa and northwestern Missouri should be considered in Section 8.1. The significance of the impacts of this alternative on air quality and total regional carbon emissions should be evaluated in the context of all other carbon sources.

CNS-Y,
continued

Mercury is a significant contaminant of concern associated with coal combustion. Many watersheds downwind of the CNS site have been listed by Iowa and Missouri for mercury contamination. Further, mercury contamination is measured in fish tissue in areas far from their estimated source, primarily from air deposition. Section 8.1 does not provide an assessment of impacts from hazardous air pollutants, specific to this alternative, particularly with regard to mercury emissions. For this alternative, more information is needed in the SEIS regarding projected mercury emissions and the status of surface waters in the depositional path with regard to mercury.

Evaluation of Alternatives

Given the comparatively cursory evaluation of the three alternatives compared to the preferred action, it is not clear how the Alternatives Summary could conclude that "All other alternatives capable of meeting the needs currently served by CNS-1 entail potentially greater impacts than the proposed action of license renewal of CNS-1." This conclusion is not sufficiently supported by the alternatives analysis, consistent with the requirements of 40 CFR 1502.14(a). Notwithstanding the requirements for "rigorous" and "objective" alternatives analysis at 40 CFR 150.14(a), the NRC's expressed view of its responsibilities to determine whether "there are findings in the safety review required by the Atomic Energy Act of 1954 (AEA) or findings in the NEPA environmental analysis that would lead to the rejection of a license application..." (Executive Summary, page xviii) does not appear to necessitate any alternatives analysis.

The summary of impacts contained in Tables 1 and 8-5 does not appear to be a rigorous evaluation of the five alternatives carried forward in the draft SEIS for detailed review as is required in 40 CFR 1502.14(a), (b) and (c). In our view, the power of the evaluation required by NEPA, particularly an evaluation of a reasonable range of alternatives to a proposed action, is in a detailed and well-documented determination of whether it is good public policy to proceed with an action instead of an alternative to the proposed action. The discussion of this evaluation of a range of reasonable alternatives within the Executive Summary and Chapter 9 is not compelling and separation points critical to a decision to select the preferred alternative over an alternative are not evident.

As presently described in the draft SEIS, the impacts of the alternatives are characterized according to rather broad categories, primarily in isolation from each other and the proposed action. Rather than weighing of the impacts of each alternative, none of these alternatives are evaluated in direct comparison to the license renewal of the CNS. In effect, the license renewal of the CNS, or any existing facility, stands separately from all other alternatives and is evaluated on its merit alone. This intent is reflected, initially, in project purpose and need. Additionally, some significant impacts associated with continued operation of any existing facility are not addressed within the SEIS, but are addressed generically in the GEIS or other NEPA documentation, making a complete comparison of several large scale impacts of continued operation to the alternatives impossible. No comprehensive assessment or comparison of the merits of generating power by the existing facility or one of the alternatives is performed in this documentation. Unless the economic costs and environmental impacts of spent fuel transportation and disposal and facility decommissioning are somehow incorporated or summarized in the decision documentation supporting this license renewal decision, an equal comparison of alternatives to license renewal by the reader is not possible. This issue reflects an apparent disconnect between the broad treatment of license renewal for all facilities in the GEIS and facility-specific assessments in the SEIS.

CNS-Y,
continued

(End of Comment CNS-Y)

NRC Response to Comment CNS-Y: In the June 5, 1996, final rule for the Environmental Review for Renewal of Nuclear Power Plant Operating Licenses (61 FR 28467), the NRC addressed the concerns of the Council of Environmental Quality (CEQ) relative to consideration of appropriate alternatives and the narrow definition of purpose and need. The definition of purpose and need in the 1996 GEIS reflects the Commission's recognition that the NRC has no role in the energy planning decisions of State regulators and utility officials, and the NRC will neither perform analyses of the need for power nor draw any conclusions about the need for generating capacity in a license renewal review. The purpose of renewing an operating license is to maintain the availability of the nuclear plant to meet system energy requirements beyond the term of the plant's current license.

The operation of a nuclear power plant beyond its initial license term involves separate regulatory actions, one taken by the utility and the NRC, and the other taken by the utility and the State regulatory authorities. The NRC would determine whether it is reasonable to renew the operating license and allow State and utility decision makers the option of considering a currently operating nuclear power plant as an alternative for meeting future energy needs. The focus of the analysis is whether the environmental impacts anticipated for continued operation during the term of the renewed license reasonably compare with the impacts of alternatives considered for meeting generating requirements. The NRC would reject a license renewal application if the analysis demonstrated that the adverse environmental impacts of license renewal were so great that preserving the option of license renewal for energy planning decision makers would be unreasonable.

Given the uncertainties involved and the lack of control that the NRC has in the choice of energy alternatives in the future, the Commission believes that it is reasonable to exercise its NEPA authority to reject license renewal applications only when it has determined that the impacts of license renewal sufficiently exceed the impacts of all or almost all of the alternatives that preserving the option of license renewal for future decision makers would be unreasonable. The decision will not affect the scope or rigor of NRC's analyses, including the consideration of the environmental impacts relevant to the license renewal decision and associated alternatives.

The staff forwarded this comment to the group currently working on Revision 1 to NUREG-1437, the Draft Revised GEIS. The approach used in the Draft Revised GEIS more-clearly presents all alternatives (proposed action and other energy alternatives that are outside the agency's purview) in a more parallel and directly comparable format. The NRC staff also notes that EPA headquarters staff provided specific comments on the Draft Revised GEIS during the comment period for that document that closed in January of 2010.

Following receipt of the EPA's comment letter, the NRC initiated a followup telephone call with the EPA to better understand their concerns. As discussed on that phone call, the NRC staff requests the EPA's early and continued communication in future projects.

The NRC staff notes that the comments provided by the EPA staff on the draft SEIS for CNS are made in the context of compliance with the EPA's regulations 40 CFR Parts 1500-1508 and Section 309 of the Clean Air Act. The NRC takes its responsibility to perform an environmental impact statement in accordance with NEPA programmatic guidance very seriously.

The NEPA regulations direct Federal agencies on matters related to environmental policy, including the public scoping process, use of lead agencies, and selection of alternatives. The NRC is an independent regulatory agency. As an independent agency, the NRC established its own regulations to implement NEPA. The Commission set policy to take account of the CEQ's

1978 regulations voluntarily. The NRC's requirements for compliance with NEPA are contained in 10 CFR Part 51, Subpart A; National Environmental Policy Act – Regulations Implementing Section 102(2).

The Commission recognizes a continuing obligation to conduct its domestic licensing and related regulatory functions in a manner which is both receptive to environmental concerns and consistent with the Commission's responsibility as an independent regulatory agency for protecting the radiological health and safety of the public.

Response to EPA Comments on Affected Environment and Environmental Impacts of Operation

In order to address the EPA comments in other areas of their document and to better understand the NRC's responses below, it is important to understand the NRC's license renewal process which classifies environmental and human health issues as either Category 1 (generic to all nuclear power plants) or 2 (requires a site-specific evaluation). For license renewal, the NRC performed a comprehensive evaluation of all nuclear power plants in the United States to assess the scope and impact to public health and safety and the environment from radioactive material released from a nuclear power plant for an additional 20 years of operation.

The impact evaluation performed by the staff and presented in the GEIS identified 92 environmental issues that were considered for the license renewal evaluation for power reactors in the United States. The industry, Federal, State, and local governmental agencies, members of the public, and citizen groups commented on and helped identify these 92 issues during the preparation of the GEIS. For each of the identified 92 issues, the staff evaluated existing data from all operating power plants throughout the United States. From this evaluation, the staff determined which issues could be considered generically and which issues do not lend themselves to generic consideration. The GEIS divides the 92 issues that were assessed into two principle categories:

- one for generic issues (which are termed "Category 1 issues")
- the other for site-specific issues (termed "Category 2 issues")

Category 1 issues are termed "generic" issues because the conclusions related to their environmental impacts were found to be common to all plants (or, in some cases, to plants having specific characteristics such as a particular type of cooling system). For Category 1 issues, a single level of significance was common to all plants, mitigation was considered, and the NRC determined that it was not likely to be beneficial. Issues that were resolved generically are not reevaluated in the site-specific supplement to the generic environmental impact statement on license renewal (SEIS) because the conclusions reached would be the same as in the GEIS, unless new and significant information is identified that would lead the NRC staff to reevaluate the GEIS's conclusions. During the environmental reviews of license renewal applications, the NRC staff makes a concerted effort to determine whether any new and significant information exists that would change the generic conclusions for Category 1 issues. The issues of radiological impacts on human health and radiation doses to members of the public from the current operation of nuclear power facilities were examined from a variety of perspectives, and the impacts were found to be well within the NRC's and EPA's radiation protection standards in each instance. As a result, the issues are classified as Category 1 issues.

Category 2 issues are those that require a site-specific review. For each of the Category 2 issues applicable to the site under review, the staff evaluates site-specific data provided by the applicant, other Federal agencies, State agencies, Tribal and local governments, as well as

information from the open literature and members of the public. From this data, the staff makes a site-specific evaluation of the particular issues and presents its analyses and conclusions in the SEIS for the facility.

This does not mean that the NRC takes the generic (Category 1) issues "off the table" for public review. If there is new and significant information that would change the conclusions reached in the GEIS, the issue requires a site-specific analysis.

During the scoping process and the environmental review, the NRC looks for any information that could demonstrate that there are unique characteristics related to the facility or the environment surrounding the facility that would lead to the conclusion that the generic determination for a particular issue is not valid for a specific site. The NRC staff discusses and evaluates potential new and significant information on impacts of operations during the renewal term in the SEIS.

As discussed above, the generic issues of radiological impacts on human health and radiation doses to members of the public from the current operation of nuclear power facilities have been examined from a variety of perspectives, and the impacts were found to be well within regulatory requirements in each instance. The NRC expects its licensees to continue to comply with its radiation protection standards during the period of license renewal; therefore, there is no reason to expect radioactive effluents to increase during the period of the renewal license. However, as with all Category 1 conclusions, the NRC staff review evaluates each license renewal application and the site to determine if there is new and significant information that would change the conclusion in the GEIS. In addition, the staff notes that effective use of radioactive waste treatment systems and practices at nuclear power plants have resulted in public radiation doses being well within NRC's as low as reasonably achievable (ALARA) dose criteria contained in Appendix I to 10 CFR Part 50. The NRC staff concluded in the GEIS that the significance of radiation exposures to the public attributable to operation after license renewal will be small at all sites and that this is a generic (Category 1) issue.

Additionally, in accordance with NRC regulations, a number of issues are not considered in the environmental review for license renewal conducted by the NRC, including but not limited to:

- safety
- operational issues that require a separate NEPA review (such as an independent spent fuel storage installation (ISFSI))
- security and safeguard issues
- emergency preparedness (including distribution of potassium iodide)
- need for power
- spent fuel disposal and storage
- economic feasibility
- cost-benefit analyses

These issues are covered in other NRC regulations, licensing actions, the inspection and enforcement program, and the environmental assessment specific to the issue to ensure adequate protection of the public's health and safety and the environment.

In summary, the comments relating to radiological issues has been evaluated in the GEIS for license renewal and no new and significant information was identified during the scoping process, the review of CNS's environmental report (ER), and the staff's site visit that contradict the GEIS's findings. Therefore, there are no impacts beyond those identified and evaluated in the GEIS.

Response to EPA Comments on Radiological Environmental Monitoring Program Data

The comments relating to radiological issues has been evaluated in the GEIS for license renewal and no new and significant information was identified during the scoping process, the review of the CNS ER, and the staff's site visit that contradict the GEIS's findings. Therefore, there are no impacts beyond those identified and evaluated in the GEIS. No changes will be made to the SEIS based on the comments.

The radiological issues cited in the EPA's comment are Category 1 issues that have been generically resolved in the GEIS for license renewal. The staff previously discussed the NRC's license renewal process for handling Category 1 and 2 issues. In summary, the comments relating to radiological issues has been thoroughly evaluated in the GEIS for license renewal and no new and significant information was identified during the scoping process, the review of the CNS ER, and the staff's site visit that contradict the GEIS's findings. Therefore, there are no impacts beyond those identified and evaluated in the GEIS.

The radiological data in Sections 2.1.2.1, 2.1.2.2, 2.1.2.3, and 4.8.1 of the SEIS were updated to include data from 2003 through 2009 based on the comment and the availability of more recent data since the draft SEIS was published.

Response to EPA Comments on Ground Water

The comment raises a concern regarding radiological contamination of alluvial ground water and the potential for contamination to the Missouri River. While there are no programs at CNS to specifically sample and monitor alluvial ground water, the staff evaluated two specific aspects of CNS's ground water monitoring programs that do provide data for consideration: (1) the analysis of drinking water from an onsite well, as documented in the radiological environmental monitoring program (REMP); and (2) indications of potential leaks of radioactive fluids from plant systems and buried piping through the ground water protection program.

The REMP is an NRC-required program that monitors releases and buildup of radioactive material from the plant to assess the potential impact to man and the environment. The NRC staff reviewed the REMP data over a 7-year period and found no instances where tritium or gamma emitting radionuclides were detected above the lower limit of detection in samples from an onsite drinking water well and surface water from the Missouri River.

In addition, the ground water protection program at CNS is an industry-wide voluntary initiative designed to serve as an early warning indicator of abnormal spills or leaks of radioactive fluid from a plant system, component, or buried piping. As reported by CNS in their annual radiological environmental report, the long-term objectives of the program are as follows:

- (1) Identify suitable locations to monitor and evaluate potential impacts from station operations before significant radiological impact to the environment and potential drinking water sources.
- (2) Understand the local hydrogeologic regime in the vicinity of the station and maintain up-to-date knowledge of flow patterns on the surface and shallow subsurface.
- (3) Perform routine water sampling and radiological analysis of water from selected locations.
- (4) Report new leaks, spills, or other detections with potential radiological significance to stakeholders in a timely manner.
- (5) Regularly assess analytical results to identify adverse trends.
- (6) Take necessary corrective actions to protect ground water resources.

The programs evaluated by the staff above did not indicate any adverse radiological impacts to the ground water at CNS and the Missouri River. Such finding is consistent with the Category 1 generic finding documented in the GEIS for license renewal. The staff previously discussed the NRC's license renewal process for handling Category 1 and 2 issues. In summary, the comment did not provide new and significant information regarding radiological impacts associated with license renewal at CNS.

No changes were made to the SEIS as a result of the comment.

Response to EPA Comments on Surface Water

The comment suggests the inclusion of additional data and analysis in Section 4.4 of the SEIS for surface water issues associated with the CNS site. The NRC staff found that the information contained in the CNS ER and developed in SEIS Sections 4.4 and 4.5.3 was sufficient to assess the surface water issues. Also, as illustrated in Table B-1 to Appendix B to Subpart A of 10 CFR Part 51, the Commission has assessed the environmental impacts associated with surface water quality, hydrology, and use, and determined them to be Category 1 issues that have been discussed and generically resolved in the GEIS for license renewal. The only exception to this generic finding is in the case where there exists water use conflicts for plants with cooling ponds or cooling towers drawing makeup water from a small river with low flow, which is not applicable to the CNS site. In accordance with 10 CFR 51.71(d), this SEIS relies "on conclusions as amplified by the supporting information in the GEIS for issues designated as Category 1." In summary, the comment relating to the surface water issues has been previously addressed in the GEIS for license renewal. While the commenter presents various hypothetical scenarios to consider, no new and significant information was identified to contradict the previous findings in the GEIS.

Therefore, no changes were made to the SEIS as a result of the comment.

Response to EPA Comments on Aquatic Life

Regarding comparison of impingement at CNS to impingement by other facilities using the same or other technology and source water, NRC's regulations define levels of impact in terms of the effects that NRC's Federal action (license renewal or nonrenewal) would have on the resources. NEPA calls for agencies to look at the direct and indirect effects of the proposed action and their consequences (Sec. 1502.16 Environmental consequences), not the relative effect of the proposed action compared to the effects of some other unrelated stressor. Even so, a good comparison for the effects of impingement at CNS is Fort Calhoun Generating Station, which is located about 113.5 river miles (183 river kilometers) north of CNS. Aquatic ecology sections of the CNS and Fort Calhoun Generating Station SEISs summarize studies by Hesse et al. (1982) that monitored the effects of both stations. Although Fort Calhoun Station is smaller (1,500 megawatts-thermal (MWt)) than CNS (2,419 MWt), aspects of the structures and operation that affect aquatic resources are similar (Table A-2). The NRC found the level of impact at both generating stations to be small.

Table A-2. Structures and Operations of Cooper and Fort Calhoun Generating Stations That Affect Aquatic Resources

Structure or Operation	Cooper Nuclear Station	Fort Calhoun Generating Station
Output (MWt)	2,419	1,500
Type of cooling system	Once-through	Once-through
Orientation and location of intake structure	Along the shore of the Missouri River	Along the shore of the Missouri River
Traveling screens	Yes	Yes
Traveling screen mesh	1/8 x 1/2 in. (1.27 x 3.175 cm)	3/8 in. (1 cm) square
Screen approach velocity (ft/s; m/s)	0.7 to 1.1 0.2 to 0.3	2 0.6
Number of cooling water system pumps	4	3
Capacity per pump (gpm; m ³ /s)	159,000 10	120,000 7.6
Fish return system	No	No

Regarding the age and amount of impingement data, the EPA, not the NRC, regulates cooling water intake structures through the Clean Water Act and oversees collection of information on the effects of entrainment and impingement for Section 316(b) demonstrations in NPDES permits.

The NRC does not have a regulatory framework for radiological protection of nonhuman species to use in the SEIS. The NRC believes that if humans are adequately protected, other living things are also likely to be sufficiently protected. Nevertheless, a qualitative assessment of the impact to biota from radioactivity released into the Missouri River was performed using radiation protection standards for biota from recognized scientific organizations.

The International Atomic Energy Agency (IAEA) and the National Council on Radiation Protection and Measurements reported that a chronic dose rate of no greater than 1 radiation absorbed dose per day (rad/d) (10 milligrays per day (mGy/d)) to the maximally exposed individual in a population of aquatic organisms would ensure protection of the population. The IAEA also concluded that chronic dose rates of 0.1 rad/d (1 mGy/d) or less do not appear to

cause observable changes in terrestrial animal populations. The NRC assessed the cumulative effects to aquatic biota from radionuclides, including tritium, released into the Missouri River from CNS in relation to the calculated dose to a member of the public from radioactive liquid effluents. For 2009, the calculated annual whole body dose to a member of the public from radioactive liquid effluents was 2.45 E-2 millirems (mrem) (2.45 E-4 milliseiverts (mSv)). This dose assumes an exposure point at the effluent and pathways appropriate for a human receptor. This dose is well below the 25 mrem (0.25 mSv) EPA radiation protection standard in 40 CFR Part 190 and the NRC's ALARA criteria of 3 mrem (0.03 mSv) in Appendix I to 10 CFR Part 50. In comparison to the dose rate criteria for aquatic and terrestrial biota, a dose of 2.45 E-2 mrem (2.45 E-4 mSv) delivered over the course of a year from periodic radioactive liquid effluent discharges represents a negligible impact.

No changes were made to the SEIS as a result of the comment.

Response to EPA Comments on Stormwater and Wastewater Treatment

The GEIS resolved the human health impacts from the release of radioactive effluents from nuclear power plants as a Category 1 issue that is generic to all plants. The GEIS evaluated the radioactive gaseous and liquid effluents released into the environment and concluded that the impacts are of small significance, provided they are within NRC dose standards. The evaluation was based on the radioactive effluent release reports submitted by licensees to the NRC on an annual basis. These reports contain information on the types and quantities of radioactive material released from the plant from various plant specific release points (i.e., plant vent, liquid discharge line, stormwater drains, and wastewater treatment facility) into the environment and the calculated dose to a member of the public that may be exposed to the material. The GEIS reported that trends for average doses for persons living around nuclear power plants reflect the small radiation dose levels seen in the calculated doses reported by the nuclear power industry. The GEIS further reported that radiation doses to members of the public from the operation of nuclear power plants were found to be well within the NRC's regulatory standards.

The NRC requires that radioactive effluents discharged into the environment be accounted for, regardless of where they originated from (i.e., plant vent, liquid discharge line, stormwater drains, or wastewater treatment facility), and be reported in the annual effluent release report. In addition, the licensee is required to calculate the dose to a member of the public from radioactive gaseous and liquid releases. The calculated doses are required to be within NRC dose limits. Compliance with NRC dose limits is inspected by NRC regional inspectors on a routine basis. In addition to the radioactive effluent monitoring program, the NRC requires the plant to have a REMP that monitors the environment around the site for radioactive contamination. The REMP supplements the radioactive effluent monitoring program by verifying that the measurable concentrations of radioactive materials and levels of radiation in the environment are not higher than those calculated using the radioactive effluent release measurements and transport models. The REMP can also provide an indication that there is an abnormal radioactive release if unusual or unexpected data is observed.

In summary, the comments relating to radiological issues, such as the impacts from radioactive gaseous and liquid effluents released into the environment from the facility, have been evaluated in the GEIS for license renewal and no new and significant information was identified during the scoping process, the review of the CNS ER, and the staff's site visit that contradict the GEIS's findings. Therefore, there are no impacts beyond those identified and evaluated in the GEIS.

No changes will be made to the SEIS based on the comment.

Response to EPA Comments on Spent Fuel Storage and Independent Spent Fuel Storage Installation

The storage of spent nuclear fuel is a Category 1 issue and discussed in Chapter 6 of the SEIS. The safety and environmental effects of spent fuel storage have been evaluated by the NRC and, as set forth in the Waste Confidence Rule (10 CFR 51.23), the Commission has made a generic determination that, if necessary, spent fuel generated in any reactor can be stored safely and without significant environmental impacts for at least 30 years beyond the licensed life of operation (which may include the term of a revised or renewed license) of that reactor at its spent fuel storage basin or at either onsite or offsite ISFSIs.

The GEIS evaluated a variety of spent fuel and waste storage scenarios, including onsite storage of these materials for up to 30 years following expiration of the operating license, transfer of these materials to a different plant, and transfer of these materials to an ISFSI. During dry cask storage and transportation, spent nuclear fuel must be "encased" in NRC-approved casks. An NRC-approved cask is one that has undergone a technical review of its safety aspects and been found to meet all of the NRC's requirements. These requirements are specified in 10 CFR Part 72 for storage casks and 10 CFR Part 71 for transportation casks. For each potential scenario involving spent fuel, the GEIS determined that existing regulatory requirements, operating practices, and radiological monitoring programs were sufficient to ensure that impacts resulting from spent fuel and waste storage practices during the term of a renewed operating license would be small and is a Category 1 issue. This conclusion is contained in NRC regulation; in Table B-1 of Appendix B to Subpart A to Part 51, the Commission concluded that the impacts associated with spent fuel and high level waste disposal are acceptable in that these impacts would not be sufficiently large to require the NEPA conclusion, for any plant, that the option of extended operation under 10 CFR Part 54 should be eliminated. The staff's evaluation of the CNS license renewal application did not find any new and significant information related to the storage of spent nuclear fuel. Thus, there are no impacts related to spent nuclear fuel storage beyond those discussed in the GEIS.

No changes will be made to the SEIS based on the comment.

Response to EPA Comments on Environmental Justice

Socioeconomic conditions at the Sac and Fox and Iowa Reservation would not change as a result of renewing the CNS operating license. Employment levels at CNS would remain relatively unchanged, so direct and indirect employment opportunities caused by CNS would remain unchanged. The Sac and Fox and Iowa Reservations receive no income from tax monies paid by NPPD to the State of Nebraska. Nevertheless, the SEIS has been revised to more fully describe the overall potential human health and environmental effects that could affect minority and low-income populations including the Sac and Fox and Iowa Reservation populations.

The discussion in Section 4.9.7.4 summarizes the results from the CNS 2007 REMP report and incorporates this document by reference. The analysis of impacts was performed on more than a single year's worth of REMP data. While the REMP generates an annual report, each report provides several years of analytical and historic trend information on a number of critical pathways (e.g., airborne iodine, fish, milk, and broadleaf food crop vegetation). For example, the 2007 REMP report provides a trend analysis of cesium-137 in fish samples going back to June 1995. The results of the REMP continues to demonstrate that the operation of CNS does not result in a significant measurable dose to a member of the general population nor adversely impacts the environment as a result of radiological emissions and effluents.

Section 4.9.7.2 of the SEIS was revised to describe the impact on the Sac and Iowa Reservation as a result of renewing the CNS operating license.

Response to EPA Comments on Supercritical Coal-Fired Generation

While there are many coal-burning facilities in the area, any of the proposed alternatives would add to these current emissions. As mentioned in Section 8.1, air quality regulations are currently in place for these facilities, and any new construction would be subject to the Prevention of Significant Deterioration of Air Quality Review by the Nebraska Department of Environmental Quality. The NRC staff is of the opinion that, unless regional carbon regulations and monitoring systems are in place, assessing the air impacts of the coal-fired alternative in addition to the emissions of existing coal-burning facilities in the area does not meaningfully add to the alternatives discussion in Section 8.1.

The NRC staff recognizes that mercury contamination of fish in fresh water streams is an issue in Nebraska. Mercury is brought up as a contaminant of concern in Section 8.1; however, the potential effects are not discussed in further detail because, upon evaluation, the coal-fired alternative is the clearly inferior option. The NRC staff did not think it necessary to go into further detail on the issue of potential mercury contamination because the results would not have affected the impact level determination.

No changes will be made to the SEIS based on the comment.

Response to EPA Comments on Environmental Impact of Alternatives

In the SEIS, the NRC staff concluded that license renewal of CNS would result in smaller impacts than the other considered alternatives. All alternatives were considered in detail, based on the technical review of the potential environmental impacts found in Chapters 4, 5, 6, 7, and 8. The NRC staff found that the alternatives to license renewal of CNS resulted in larger potentially adverse environmental impacts than the proposed action, the impacts of which were evaluated in Chapter 4 of the SEIS.

The staff's SEIS for the proposed CNS license renewal, in addition to evaluating potential alternatives, must satisfy NRC regulations in 10 CFR 51.95(c)(4) which states that, "the NRC staff, adjudicatory officers, and Commission shall determine whether or not the adverse environmental impacts of license renewal are so great that preserving the option of license renewal for energy planning decisionmakers would be unreasonable." Thus, by regulation, the final SEIS must contain the staff's recommendation on whether the impacts of license renewal ought to preclude its availability as a future system generating option.

The NRC staff rigorously explored and devoted sufficient treatment to each considered alternative to determine which alternatives were environmentally preferable. Each of the alternatives considered were evaluated in terms of potential environmental impacts by NRC technical staff in the same resource areas evaluated for the proposed action in Chapter 4 of the SEIS. Potential environmental impacts in each resource area were determined to be SMALL, MODERATE, or LARGE based on these technical evaluations in order to provide a clear basis for choice among the alternatives. These findings are presented in Table 8-5 alongside the impacts of the proposed action in order to present a clear comparison of the overall impact levels.

Each alternative is evaluated separately to obtain a more accurate picture of the potential impacts. Table 8-5 is included at the end of Chapter 8 in order to provide a direct comparison of

Appendix A

the potential impacts of each discussed alternative, including license renewal. From this comparison, the NRC staff determined that these alternatives resulted in larger potentially adverse environmental impacts than the proposed action.

A.2.4 Comments on the Draft Supplemental Environmental Impact Statement from the Applicant

Comment CNS-Z:

NLS2010037
April 29, 2010

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555-0001

Subject: Comments on Draft Generic Environmental Impact Statement Supplement 41
Regarding the Cooper Nuclear Station License Renewal Application

Cooper Nuclear Station, Docket No. 50-298, DPR-46

- References:
1. Letter from Bo Pham, U.S. Nuclear Regulatory Commission, to Stewart B. Minahan, Nebraska Public Power District, dated February 18, 2010, "Notice of Availability of the Draft Plant-Specific Supplement 41 to the Generic Environmental Impact Statement for License Renewal of Nuclear Plants Regarding Cooper Nuclear Station, Unit 1 (TAC Nos. MD9763 and MD9737)."
 2. Letter from Stewart B. Minahan, Nebraska Public Power District, to U.S. Nuclear Regulatory Commission, dated September 24, 2008, "License Renewal Application" (NLS2008071).

Dear Sir or Madam:

The purpose of this letter is for the Nebraska Public Power District (NPPD) to provide comments on the draft Generic Environmental Impact Statement (GEIS) Supplement 41 per Reference 1. This draft GEIS supplement was prepared in response to NPPDs License Renewal Application (LRA) for Cooper Nuclear Station (Reference 2). The NPPD comments are itemized in Attachment 1. Section 2.1.6 of the draft GEIS supplement had significant number of comments, and so a recommended underline/strikeout revision is provided in Attachment 2. Attachment 3 contains certain changes to the LRA Environmental Report resulting from the review of this draft GEIS supplement.

Should you have any questions regarding this submittal, please contact David Bremer, License Renewal Project Manager, at (402) 825-5673.

I declare under penalty of perjury that the foregoing is true and correct.

Executed on _____
(Date)

Sincerely,

Brian J. O'Grady
Vice President-Nuclear and
Chief Nuclear Officer

/wv

Attachments

cc: Regional Administrator w/ attachments

USNRC - Region IV

Cooper Project Manager w/ attachments

USNRC - NRR Project Directorate IV-1

Senior Resident Inspector w/ attachments

USNRC - CNS

Nebraska Health and Human Services w/ attachments

Department of Regulation and Licensure

NPG Distribution w/ attachments

CNS Records w/ attachments

NRC Response to Comments in CNS-Z: NPPD provided comments and corrections to the draft SEIS as shown in the letter dated April 29, 2010, above. The NRC staff response to their comments is as follows:

Comments: #1–9, 11–13, 15–44, 46–85, 87–143, 146, 148–172, 174–199, 201–211, 213–234, 236–286, and 288–327 consisted of editorial comments (e.g., spelling, grammar, word choice) and suggestions for clarifications in the draft SEIS.

Response: The staff made corrections, as appropriate, for editorial comments within the text of this SEIS. Where the commenter requested clarifications, the staff provided additions or deletions of text, as appropriate, to better convey the intended meaning of the discussion.

Comment #10: The statement "...plans to implement others..." regarding impingement mitigation measures should be clarified with a rejoinder to pending changes to Section 316(b) of the Clean Water Act.

Response: The statement of concern is part of the Executive Summary and is not meant to be specific, as details are provided in Chapter 4. No changes to the SEIS were made as a result of this comment.

Comment #14: The discussion of "Comparison of Alternatives" seems to be missing a summary of the Staff's conclusions regarding the combination alternative. Recommend a summary statement in the Executive Summary as it pertains to the "Comparison of Alternatives."

Response: The statement of concern is part of the Executive Summary and is not meant to be specific, as details are provided in Chapter 4. No changes to the SEIS were made as a result of this comment.

Comment #45: The sentence "The EPA's clearinghouse can be used as a source for additional opportunities for waste minimization and pollution prevention at CNS, as appropriate." makes the implication that NPPD does not have an effective waste minimization plan.

Response: The implication regarding NPPD's waste minimization program is inferred by the commenter, not the statement in the SEIS. No changes to the SEIS were made as a result of this comment.

Comment #86: It is not clear what this figure is trying to communicate. Recommend clarification or deletion.

Response: The discussion associated with Figure 2.2.5-1 is in Section 2.2.5.2, "Conceptual Model of Midwestern Rivers." No changes to the SEIS were made as a result of this comment.

Comment #144: The race percentages do not add up to 100%.

Response: The individual percentage values for race in Table 2.2.8.5-2 were rounded off individually during the staff's estimation and thus resulted in a total summation slightly off 100 percent. Nevertheless, the percentages provide a qualitative basis for comparison across the regions. No changes to the SEIS were made as a result of this comment.

Comment #145: If some other race category has been eliminated from the Census estimate, why is it being included in the table? Consider eliminating the category of "Other Race."

Response: The comment is noted. However, such artifact from previously available information provides some context for comparison. No changes to the SEIS were made as a result of this comment.

Comment #147: The numbers provided for "Nebraska in Lieu of Taxes to Counties with NPPD Retail Electric Sales Attributed to the CNS-1," "Payments to Retail Communities Attributed to CNS-1," and the Total values do not match what was provided in ER Table 2.7-1. Recommend revision to conform with ER information.

Response: The staff acknowledges the values provided by NPPD in ER Table 2.7-1. However, the values provided in Table 2.2.8.6-3 represent the staff's independent verification of figures tabulated using NPPD's financial reports for those years. The slightly higher figures in the SEIS are most likely due to the staff's inclusion of smaller generating capacity from NPPD other than CNS. Nevertheless, Table 2.2.8.6-3 provides a comparison basis for such figures over the years, and the difference in accounting when compared with the ER values does not change the staff's findings on the socioeconomic impacts of taxes. No changes to the SEIS were made as a result of this comment.

Comment #173: Recommend the use of the word "reasonable" over "useful."

Response: The recommendation is noted. However, no changes were made to this SEIS based on the comment.

Comment #200: NPPD has procedural administrative controls in place to ensure that cultural resource reviews are conducted prior to engaging in construction or operational activities in previously undisturbed areas that may result in a potential impact to cultural resources at the site [NPPD, 2007c]. Areas depicted in Phase 1A Literature Review and Archeological Sensitivity Assessment were identified as higher probability archeological site areas on the CNS Owner Controlled Area. However, NPPD has developed a Cultural Resources Protection Plan in an effort to meet state and federal expectations and includes measures for archeological investigations (Phase 1B) and consultations with the Nebraska and Missouri State Historic Preservation Offices (SHPO), and the appropriate Native American groups prior to any future ground disturbing activities [CNS, 2008]. These measures provide adequate protection for potential area cultural resources.

Response: The comment reflects a preference and provides no additional basis. In accordance with NEPA, it is appropriate for the staff to document its findings of environmental impacts and State recommendations for further mitigation if such actions are appropriate. No changes were made to the SEIS as a result of this comment.

Comment #212: This section states:

"The impact of introduction and stocking of native and introduced fish species is also somewhat similar to the impact of CNS, because the effect of a power plant that impinges and entrains aquatic organisms is somewhat similar to that of a large predator introduced into an aquatic system."

This appears to be subjective and is not substantiated. Recommend deletion.

Response: The statement of concern in the SEIS is the staff's attempt to provide context for a qualitative comparison and not meant to be proven or substantiated. No changes were made to the SEIS as a result of this comment.

Comment #235: It is not clear why a discussion of alternatives is made in this cumulative impacts assessment. The National Environmental Protection Act requires the cumulative impact conclusions be based on known and foreseeable actions, not hypothetical alternatives. Recommend deletion.

Response: The discussion regarding the fossil-fuel alternative is meant to provide a context for comparison with respect to greenhouse gas (GHG) emissions. No changes were made to the SEIS as a result of this comment.

Comment #287: It does not appear to be reasonable to conclude that 250 MWe of CNS baseload generation can be replaced by conservation. The Staff claims that this is supported by the state's energy efficiency goals, but this does not seem realistic. Request NRC verify and provide reference of the source of the Nebraska energy efficiency goals.

Response: The commenter asserts that 250 megawatts-electric (MWe) is not a realistic assumption for CNS's generation to be replaced by conservation, but does not provide additional information to support. The 250 megawatts-electric (MWe) was taken from the Nebraska and State Goals for Energy Efficiency under the Energy Policy Act of 2005 (http://apps1.eere.energy.gov/states/economic_indicators.cfm/state=NE). Although the 250 MWe estimate does not specify how such conservation will be achieved, the quantity of concern is not a significant amount considering the energy production and consumption throughout the entire State. No changes were made to the SEIS as a result of this comment.

Comment in Attachment 2 of its letter dated April 29, 2010, NPPD suggested revisions to Section 2.1.6 of the draft SEIS to clarify: a) ER changes from NLS2009036, b) the U.S. Army Corps of Engineers Missouri River flow regulation, and c) suggest a different format to present the discussion for the cooling and auxiliary water systems.

Response: The staff reviewed and incorporated, where appropriate, the information provided by NPPD, previously provided in a request for information response. The staff also confirmed that the changes were limited to describing the system and its interaction with the environment, and that such changes did not alter the staff's findings, as documented in Chapters 4 and 9.

Comment in Attachment 3 of its letter dated April 29, 2010, NPPD provided revisions to its ER to reflect changes based on the development of its 316(b) determination under the Clean Water Act requirements.

Response: The staff reviewed changes to NPPD's ER and confirmed that such changes did not alter the staff's findings, as documented in Chapters 4 and 9. As of publishing date of this SEIS, NPPD has not physically installed the fish handling system, whose final design and implementation will be dependent upon the content of the final 316(b) Clean Water Act requirements.

A.2. References

U.S. Nuclear Regulatory Commission (NRC). 2009a. "United States Nuclear Regulatory Commission, Nebraska Public Power District, Cooper Nuclear Station, Notice of Intent to

Prepare an Environmental Impact Statement and Conduct Scoping Process," *Federal Register*, Vol. 74, No. 15, pp. 4476–4477, January 26, 2009.

Hesse, L.W., G.L. Hergenrader, H.S. Lewis, S.D. Reetz, and A.B. Schlesinger (Hesse et al.). 1982. *The Middle Missouri River: A Collection of Papers on the Biology with Special Reference to Power Station Effects*, The Missouri River Group, Norfolk, Nebraska.

U.S. Nuclear Regulatory Commission (NRC). 2009b. "Summary of Public Environmental Scoping Meeting Related to the Review of the Cooper Nuclear Station License Renewal Application," Agencywide Documents Access and Management System (ADAMS) Accession No. ML000910308.

Attachment 1
Comments on Draft Generic Environmental Impact Statement Supplement 41
Regarding the Cooper Nuclear Station License Renewal Application
Cooper Nuclear Station, Docket No. 50-298, DPR-46

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
1	GENERAL	<p>The draft Supplemental Environmental Impact Statement (DSEIS) uses the acronym "CNS-1" when referring to Cooper Nuclear Station. No other nuclear units have ever been contemplated at the site. Consistent with other single unit SEISs (e.g., "KPS" (Kewaunee), "WCGS" (Wolf Creek), and "JAFNPP" (Fitzpatrick) the acronym "CNS" should be used for Cooper Nuclear Station, without "-1."</p>	<p>Change "CNS-1" to "CNS" through draft SEIS. Basis for Change: List of Acronyms in the CNS Environmental Report.</p>
2	GENERAL	<p>Measurement units are inconsistent. Sometimes metric units are provided in the text and U.S. customary units are provided in parentheses. Sometimes the reverse is presented. Both measurements are not always provided.</p> <p>Examples:</p> <p>Page 2-19, lines 19-20: mg/l, but not ppm Page 2-19, line 4: 1000 ft., does not have accompanying meters Page 2-20, line 21: 50 miles, but not kilometers</p>	
3	GENERAL	<p>Punctuation within references in text is inconsistent. Periods, commas, semi-colons, or no punctuation at all are all used for the same purpose/ location within a reference.</p> <p>Examples:</p> <p>Page 2-29, lines 45-46: No punctuation within reference Page 2-29, line 18: Same reference, comma used Page 4-15, line 43: Semi-colon within reference</p>	
4	GENERAL	<p>Inconsistent use of abbreviations/ acronyms, etc.</p> <p>Example: Page 2-31, lines 29-30: River miles, river mile, and RM are all used within the same sentence. RM has been used previously and should be used from that point forward.</p>	

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
5	GENERAL	<p>Inconsistent application of °C and °F. Degree symbol should be immediately after the number. No spaces between number, symbol, or C/F.</p> <p>Example: Page 2-33, line 15</p>	
6	GENERAL	<p>Per the Chicago Manual of Style, whenever there are multiple references in a given year from a single author, the series starts with "a." Example, Reference "(NPPD 2008)" should be "(NPPD 2008a)" on Page 2-82/Line 27; Reference "(NCDC 2009)" should be "(NCDC 2009a)" on Page 2-80/Line 10.</p> <p>It is recommended that all of the DSEIS Reference Sections be reviewed for this writing style inconsistency and renumbered, with corresponding changes made in the text.</p>	
7	iii/2	Brownville is a village, not a city.	<p>Revise to read: "...in the city<u>Village</u> of Brownville..."</p> <p>Basis for Change: CNS License Renewal Application Environmental Report (ER) Section 2.1</p>
8	xvii/11	References "(May 1996), (NRC 1996)" are not defined. They should either be deleted or a reference section added at the end of the Executive Summary.	
9	xix/10 and 11	It is not clear what the Staff means regarding the absence of "generic ground water issues."	<p>Revise to read: "...Category 1-or generic ground water issues."</p> <p>Basis for Change: A finding on "new and significant information" for ground water use and quality is unrelated to generic ground water issues.</p>

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
10	xix/30	The statement "...plans to implement others..." regarding impingement mitigation measures should be clarified with a rejoinder to pending changes to Section 316(b) of the Clean Water Act.	<p>Revise to read: "NPPD has implemented some impingement mitigation measures and plans to implement others, <u>as necessary for compliance with Section 316(b) of the Clean Water Act.</u>"</p> <p>Basis for Change: Clarification. See Attachment 3, Changes 2, 4, 5, 6, 7, 8, 9, 10, and 11.</p>
11	xx/22	Insert space after "fields."	<p>Revise to read: "electromagnetic fields— acute effects..."</p> <p>Basis for Change: Typographical correction.</p>
12	xx/38	Incomplete list of Category 2 socioeconomic impacts.	<p>Revise to include "public services (education – refurbishment)."</p> <p>Basis for Change: NUREG-1555 Supplement 1</p> <p>No change. NPPD has informed NRC that it does not plan</p>
13	xxi/18	There should be a space inserted with "...impacts(...)" Typographical correction.	
14	xxii/24 through 40	The discussion of "Comparison of Alternatives" seems to be missing a summary of the Staff's conclusions regarding the combination alternative. Recommend a summary statement in the Executive Summary as it pertains to the "Comparison of Alternatives."	
15	xxii/27 and 28	Insert symbol of mercury and period after mercury. Delete dash. Delete "and" and capitalize "the" to form a new sentence. Otherwise it is a run-on sentence.	<p>Revise to read: "...and mercury (Hg). The corresponding..."</p> <p>Basis for Change: Grammatical enhancement</p>

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
16	xxii/31	The statement "The gas-fired alternative would have slightly lower air emissions,..." makes it sound like gas-fired alternative would have lower air emissions than a nuclear plant.	Revise to read: "The gas-fired alternative would have slightly lower air emissions <u>than the coal-fired alternative</u> ," Basis for Change: Verbiage enhancement for clarity
17	xxvi/3	"CWERCLA" should be changed to "CERCLA."	Revise to read: "CWERCLA" Basis for Change: Typographical correction
18	xxix/1	"NDED" is defined as the "Nebraska Department of Education" in the Table of Acronyms. However, "NDED" is defined as the "Nebraska Department of Economic Development" on Page 2-81, Line 17. The Nebraska Department of Education is "NDE," as stated on Page 2-81 Line 26. Recommend the Table of Acronyms be revised and include an "NDE" entry.	
19	xxxi/10	Delete "SPDES" and "State Pollutant Discharge Elimination System" since this program is designated as the "NPDES" program in Nebraska.	
20	1-1/7 and 8	The sentence reads awkwardly.	Revise to read: "The Atomic Energy Act of 1954 (AEA) originally specified that licenses for commercial power reactors be granted for up to 40 years, and permits license renewal." Basis for Change: Grammatical enhancement
21	1-1/19	After "2014," a reference should be provided to the CNS License Renewal Application.	Revise to read: "...2014. <u>(NPPD 2008a)</u> " Basis for Change: Referencing enhancement
22	1-2/Figure 1-1	The asterisked statement and block connector lines are difficult to read against the dark background.	

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
23	1-9 /last row of the table first entry	<p>The entry:</p> <p>"Mr. Ron Asche NPPD 1414 15th Street Columbus, NC 68601"</p> <p>is a duplicate entry from Page 1-8, and is also the wrong address, it is Nebraska, not North Carolina. Recommend deleting this entry.</p>	
24	1-10/Table 1-1	General NPDES Permit Expiration Date is incorrect.	<p>Revise to clarify that this is the stormwater permit and to read: "Expires: 9/17/2012 <u>2002</u>." (Add footnote that this has been administratively extended by the Nebraska Department of Environmental Quality (NDEQ)).</p> <p>Basis for Change: NLS2009036 Change 12.</p>
25	1-10/Table 1-1	Hazardous Waste Generator Identification Number is not correct.	<p>Revise to read: "NED1055071064-2 <u>NED055071062</u>."</p> <p>Basis for Change: NLS2009036 Change 12</p>
26	1-10/Table 1-1	Permit Number 0218-26-08-X with the South Carolina Department of Health and Environmental Control is expired and is no longer being used.	<p>Revise to delete the entry for CNS-1 Radioactive Waste Transport Permit.</p> <p>Basis for Change: NPPD is no longer authorized to ship radwaste under this permit. See Attachment 3, Change 12.</p>
27	1-11/Table 1-1	Missing Stormwater NPDES Construction Permit for Independent Spent Fuel Storage Installation construction.	<p>Revise to include a third line item provided in NLS2009036, replacement page 9-5.</p> <p>Basis for Change: NLS2009036 Change 12</p>

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
28	1-11/Table 1-1	The Section 404 Permit for dredging at intake structure and discharge of dredge material to the Missouri River is missing from the table.	Revise to include a fourth line item provided in NLS2009036, replacement page 9-5. Basis for Change: NLS2009036 Change 12
29	1-11/Table 1-1	Missing Section 404 Permit for intake structure ice deflectors.	Revise to include a fifth line item provided in NLS2009036, replacement page 9-5. Basis for Change: NLS2009036 Change 12
30	1-11/Table 1-1	Permit Numbers T-NE002-L08 and 0111000042 need to be updated with latest expiration dates.	Revise to read: [T-NE002-L08] " <u>Expires: 12/31/2008</u> 10 " [0111000042] " <u>Expires: 1/3/2009</u> 11 " Basis for Change: NPPD has received new expiration dates for these permits from the relevant State agencies. See Attachment 3, Changes 13 and 14.
31	Chapter 2 Global	The NAS 2002 and National Research Council 2002 are the same document. Change all references to "National Research Council 2002" throughout the chapter to "NAS 2002," and delete National Research Council reference in Section 2.4.	
32	2-1/9	Change "including" to "inclusive of the." Grammatical enhancement.	
33	2-1/10	This sentence could be read (in light of previous and subsequent sentences) to apply to the Nebraska Public Power District (NPPD) land in Nemaha County.	Revise to read: [Relocate to the end of Line 12] "Over 99 percent of the <u>total</u> acreage in Nemaha County is used for agriculture and farming." Basis for Change: Clarification

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
34	2-1/11-12	These lines mention that 234 acres is leased for agricultural purposes, but that is the land that is now subject to the environmental easement that is mentioned later. For consistency, the text should mention the environmental easement in addition to the use for agricultural purposes.	Revise to read: "A significant portion of NPPD property at CNS-1, 234 acres in Missouri and 715 acres in Nebraska, is currently leased for agricultural activities such as farming and raising livestock <u>or conservation purposes.</u> " Basis for Change: Change for consistency
35	2-1/20	The 100m meteorological tower is 328.08 ft, not 328.8 ft.	Revise to read: "... and the <u>approximately</u> 328.8-foot tall..." Basis for change: Clarification
36	2-7/27	A reference should be provided for "40 CFR Part 190" in the Section 2.4 references for consistency with other CFR references provided.	
37	2-8/19	"NAC Title 128 was updated in 2004..." This is incorrect, it was updated August 18, 2007.	Revise to read: "...was updated in <u>20042007</u> ..." Basis for Change: NAC Title 128 was last updated on August 18, 2007.
38	2-8/23 and 24	The sentence "State-level regulators may add wastes to the EPA's list of hazardous wastes." should be clarified.	Revise to read: "States authorized to administer the RCRA program may require generators to manage additional wastes, in addition to those hazardous wastes listed by EPA." Basis for Change: Clarification
39	2-8/24 and 25	The sentence "RCRA provides the standards for the treatment, storage, and disposal of hazardous wastes for hazardous waste generators (regulations are available in 40 CFR Part 262)." is not correct in that 40 CFR 262 only addresses generators, while 40 CFR 264 and 40 CFR 265 address treatment, storage and disposal facilities.	

Comment No	Page Number/ Line Number	Comment	Suggested Resolution
40	2-8/27	The reference to 40 CFR 260.10 is not correct. It should be "40 CFR Part 262." Additionally, add 40 CFR Part 262 to Section 2.4 references.	Revise to read: "The EPA recognizes three main types of the hazardous waste generators (40 CFR 260.10 <u>Part 262</u>) based on the quantity of the hazardous waste produced:..." Basis for Change: CFR correction
41	2-8/29	Definition of Large Quantity Generators does not match Environmental Protection Agency (EPA) definition.	Revise to read: "...Large Quantity Generators (LQGs), that generate <u>more than</u> 2,200 pounds (1,000 kg) per month or more of hazardous waste..." Basis for Change: EPA website Glossary of Terms
42	2-8/36	The sentence is missing an initial definite article.	Revise to read: Insert "The" before "State..." Basis for Change: Grammatical correction
43	2-9/36	"(NPPD, 2008)" is an incorrect reference.	Revise to read: "(NPPD, 2008 <u>2009c</u>)" Basis for Change: NLS2009036 Enclosure 5.3
44	2-9/39	The "(EPA, 2009a)" reference appears to be incorrect based on Section 2.4, which shows the EPA 2009c reference addressing waste minimization.	Revise to read: "...approaches to pollution prevention (EPA, 2009a <u>2009c</u>)..." Basis for Change: Reference correction
45	2-9/40 and 41	The sentence "The EPA's clearinghouse can be used as a source for additional opportunities for waste minimization and pollution prevention at CNS-1, as appropriate." makes the implication that NPPD does not have an effective waste minimization plan.	Revised to read: "The EPA's clearinghouse can be used for waste minimization and pollution prevention opportunities by RCRA-regulated facilities, as appropriate. <u>Note that Cooper already has an effective waste minimization program in place.</u> " Basis for Change: Clarification

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
46	2-10/26	Statement that ER notes that four transmission lines are owned and operated by NPPD is incorrect.	Revise to read: " The NPPD notes in their ER that four transmission lines, <u>three of which are</u> owned and operated by NPPD, are..." Basis for Change: ER Section 3.2.7.
47	2-10/29	Transmission line "TL301" should be "TL3501."	Revise to read: "Two of these numbered lines, NPPD TL <u>3501</u> and..." Basis for Change: ER Section 3.2.7
48	2-10/30	The 145 mile transmission corridor length should be 146 miles.	Revise to read: "...transmission line corridor extending <u>145.6</u> miles (<u>233.5</u> km) west-northwest..." Basis for Change: ER Section 3.2.7, 63.6 + 82.6 = 146.2
49	2-11/1-3	The paragraph as written does not accurately characterize the Omaha Public Power District lines that connect with the CNS switchyard.	Revise to read: "There are several transmission lines originating at <u>that connect with</u> the CNS-1 switchyard that are neither owned nor operated by CNS-1 NPPD. <u>These consist of</u> Two transmission lines originating at <u>connecting with</u> the CNS-1 switchyard, <u>which are owned by the</u> Omaha Public Power District (OPPD); <u>Another transmission line connecting with one of the</u> OPPD lines, not connected to the CNS switchyard and a third is owned by Aquila <u>Kansas City Power and Light</u> . Basis for Change: ER Section 3.2.7. Also, Aquila became Kansas City Power and Light on 7/14/2008.

Comment No.	Page Number/Line Number	Comment	Suggested Resolution
50	2-11/4 and 5	The discussion regarding the transmission lines that are in the scope of license renewal does not seem to indicate a proper rationale for inclusion; i.e., that the lines originally connected the plant to the grid. Instead, the Staff seems to indicate that the in-scope lines are those owned or under the control of NPPD.	<p>Revise to read: "As these three transmission lines are not owned or under the control of NPPD and were not constructed to connect CNS to the transmission system, they are not within the scope of license renewal for CNS-1 (NPPD, 2008a).</p> <p>Basis for Change: Refer to ER Page 3-20, Section 3.2.7.</p>
51	2-11/6 and 7	A word search was performed of the ER, and no statement could be found that transmission lines do not cross any Federal, State, or local parks. Only one transmission crosses the United States Fish and Wildlife Service (USFWS) rainwater basin area.	<p>Revise to read: "The transmission lines do not cross any Federal, State, or local parks (NPPD, 2008). However, the western half of the <u>only one in-scope</u> transmission line corridor traverses counties that..."</p> <p>Basis for Change: No ER information supports the statement. Clarification on transmission line corridors.</p>
52	2-11/11	The "(USFWS, 2009h)" reference appears to be inaccurate based on the Section 2.4 references, which shows it being associated with the Salt Creek tiger beetle.	
53	2-11/14	There are actually two separate farmers, one on each side of the Missouri River. It is not important to describe the number of farmers.	<p>Revise to read: "On the CNS-1 property the agricultural and is managed by a single farmer under an agreement with NPPD.</p> <p>Basis for Change: The statement appears to be irrelevant.</p>
54	2-11/26-27	Misquote of the ER.	<p>Revise to read: "Native grasses and low-lying growing woody plants..."</p> <p>Basis for Change: "Low-lying woody plants" is not the same as "low growing woody plants."</p>

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
55	2-12/1	Incorrect inspection periodicity.	<p>Revise to read: "ROW aerial inspections occur bi-monthly six times annually, and there is an annual foot patrol inspection."</p> <p>Basis for Change: Inspections do not occur every two months.</p>
56	2-15/Figure 2.1.6-2	NLS2009036 Change 10 has not been incorporated.	<p>Replace: Figure 2.1.6-2 with NLS2009036 Attachment 2, Enclosure Figure 3.2-4.</p> <p>Basis for Change: NLS2009036 Change 10</p>
57	2-17/34	The "(NPPD, 2008c)" appears to be incorrect based on the Section 2.4 references, since it refers to a 2007 NPPD Annual Report, which does not appear to support this information.	
58	2-17/42	"(NHHSS, 2000)" is defined as "Nebraska Department of Health and Human Services" on Line 42. On Page 2-81/Line 39, this reference is defined as "Nebraska Department of Health and Human Services System." Which is correct?	
59	2-18/8	For consistency with Page 2-20 (Line 7), change "This water eventually reaches the water table and disperses." to "This water eventually reaches the water table and disperses before likely discharging to the Missouri River."	
60	2-18/13-15	The DSEIS states: "Preliminary sampling and analysis results from the ground water monitoring program for tritium will be submitted and summarized in the final SEIS." NPPD has not committed to provide this information, and believes it is inappropriate to use the DSEIS as the venue to solicit this action. However, NPPD is willing to provide this information following a request from the NRC staff.	<p>Revise to read: "<u>The NRC staff will request that NPPD submit preliminary sampling and analysis results from the ground water monitoring program for tritium</u> will be submitted and for summarized <u>in the final SEIS.</u>"</p> <p>Basis for Change: No communication has been received requesting this information.</p>

Comment No	Page Number/ Line Number	Comment	Suggested Resolution
61	2-18/29-30	NDEQ Title 117 lists additional beneficial uses for the Missouri River than those provided.	<p>Revise to read: "Beneficial uses of surface water identified in the CNS-1 area are <u>recreational, aquatic life (Warmwater A), public drinking water supply, agricultural water supply, industrial water supply, and aesthetics for agricultural and industrial water supply</u> (NDEQ, 2004)."</p> <p>Basis for Change: Clarification</p>
62	2-18/34	Reference to NPDES Permit NE-0001244 is not the correct designator.	<p>Revise to read: "...Nebraska NPDES permit <u>NE-0001244 NE0001244</u>."</p> <p>Basis for Change: ER Table 9.2-1</p>
63	2-19/Table 2.1.7-1	Table 2.1.7-1 listed NPDES outfalls from an earlier permit. The present NPDES permit for CNS does not have Outfalls 002a, 003, 005, or 006. Also, the present NPDES permit has pH limits for each of the remaining outfalls. Limits are Min. 6.5 SU and Max 9.0 SU.	<p>Revise Table 2.1.7-1 to: a) remove Outfalls 002a, 003, 005 and 006 from this table since there are no such outfalls listed in the current NPDES Permit, and b) for Outfalls 001, 002b, 002c, 004, 008 and 009, the pH effluent limitation of 6.5 (Minimum) and 9.0 (Maximum) should be added.</p> <p>Basis for Change: NPPD NPDES Permit No. NE0001244.</p>
64	2-19/ Table 2.1.7-1	This table should have a reference to NPPD NPDES Permit No. NE0001244.	
65	2-19/Table 2.1.7-1	The "Max. proposed" temperature column should be deleted, as the proposed NPPD NPDES Permit was approved.	
66	2-19/6	"Outfall 006" should be "Outfall 001."	<p>Revise to read: "...through Outfall 00<u>6</u>1..."</p> <p>Basis for Change: NPPD NPDES Permit No. NE0001244.</p>

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
67	2-19/9-17	The outfall description does not match the latest NPPD NPDES Permit as issued on June 26, 2007, by the NDEQ.	<p>Revise to read: <u>Outfalls 002a, 002b is the discharge of industrial well ground water bypass, RO reject, and boiler blowdown, and Outfall 002c is the discharge of diesel generator, turbine fan heater, boiler room floor drains, and HVAC blowdown</u> discharge water from roof drain sumps outside the power block, from clear well discharge, and HVAC blowdown, respectively. Along with the intake screen backwash discharged through Outfall 003, Outfalls 002a, b, and c. These outfalls discharge to the Missouri River. Outfall 005 discharges batch volumes of sanitary waste from the sewage lagoon system. The discharge is sprayed on nearby farm land and is not directly connected to area surface water bodies.</p> <p>Basis for Change: NPPD NPDES Permit NE0001244, Expiration Date June 30, 2012</p>
68	2-19/18	Sentence reads awkwardly.	<p>Revise to read: "The only NPDES non-compliance reported in the last five years was <u>for</u> total suspended solids..."</p> <p>Basis for Change: Grammatical enhancement.</p>
69	2-21/1	Referenced Figure should be 2.2.1-1.	<p>Revise to read: "...Atchison County, Missouri, see Figure 2.2.1-1."</p> <p>Basis for Change: Typographical error</p>
70	2-22/9	The cited source for Figure 2.2.1-2 is "(NPPD, 2008a)." This reference is not provided in Section 2.4.	
71	2-23/4-5	Reference "(David J. Wishart, 2004)" is not consistent with citation in Section 2.4.	<p>Revise to read: "...<u>(David J. Wishart, 2004) (Wishart 2004).</u>"</p> <p>Basis for Change: Citation consistency</p>

Comment No	Page Number/ Line Number	Comment	Suggested Resolution
72	2-23/31-32	Change "@" symbols to "at" (grammatical enhancement).	
73	2-24/18-36	Paragraph should be rewritten to state that CNS's potential to emit is less than the criteria defined in Title V of the United States EPA Clean Air Act and in Chapter 5, Title 129 of Nebraska Administrative Code for criteria pollutants and hazardous air pollutants (HAPs). The presentation of the emissions in tons should be clarified to more clearly identify which pollutant is associated with which value for emissions, and the source for the basis of those emissions should be provided as a reference. Remove the mention of used oil as it is not relevant to air emissions as discussed.	Revise to read: "CNS-1 has a number of stationary emission sources, such as three standby emergency power supply diesel generators, auxiliaries required for safe starting and continuous operation <u>and which are tested periodically to ensure their reliability to perform their intended function</u> , and several petroleum fuel storage tanks, which do not require the facility to secure Title V permit. Since CNS's actual annual emissions are less than the criteria defined in Title V of the Clean Air Act and in Chapter 5, Title 129 of Nebraska Administrative Code for criteria pollutants and hazardous air pollutants (HAPs), CNS-1 is has been granted a low emitter status by the NDEQ Air Quality Section due to the actual quantities of emissions that are required to meet criteria and not to exceed thresholds for the emissions of pollutants defined in Chapter 5, Title 129 of Nebraska Administrative Code: for the emissions of particulate matter PM10, carbon monoxide (CO), volatile organic compounds (VOC), oxides of nitrogen (NOx), SO2 or SO3 or any combination of the two (SOx), single-Hazardous Air Pollutant (HAP) or Hazardous Air Pollutant (HAPs) and lead. As reported and submitted to NDEQ, actual total annual emissions from all sources at CNS-1 from 2004 to 2008 were 11.52 tons (10.45 MT) per year, 10.73 tons (9.73 MT) per year, 13.21 tons (10.73 MT) per year, 11.43 tons (10.37 MT) per year, and 9.85 tons (8.94 MT) per year respectively. Highest emissions from 2004 to 2008, maximum reported annual emissions occurred were reported in 2006 at 13.21 tons (10.73 MT): 0.16 tons (0.15 MT) per year of PM10, 2.41 tons (2.19 MT) per year of CO, 0.22 tons (0.20 MT) per year of VOC, 9.0 tons (8.16 MT) per year of NOx, 1.41 tons (1.28 MT) per year of Sox, and 0.01 tons

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
			<p>(0.009 MT) per year of single HAP (NPPD, 2009c). The generators are tested periodically to ensure their continued ability to perform their intended function; and there are procedures in place to ensure continuous monitoring, sampling, and filtering of the oil. Used oil is collected for offsite disposal; therefore, no used oil incineration activities occur on the CNS site. Used oil disposal is discussed further in the waste management section.</p> <p>Basis for Change: Clarification</p>
74	2-24/24-25	"PM10," "SO2," and "SO3" should all have the numbers as subscript ("PM ₁₀ ," "SO ₂ ," and "SO ₃ "). Grammatical enhancement.	
75	2-24/32	"Sox" should be "SO _x ." Grammatical correction.	
76	2-24/38-39	Text suggests that the two monitoring sites are more than the 100-m tower and the 10-m tower.	<p>Revise to read: "These first monitoring sites <u>consist of</u> accommodates a 328-foot (100-m) primary meteorological tower and a 32.8-foot (10-m) back up tower."</p> <p>Basis for Change: Clarification</p>
77	2-24/40	NLS2009036 Change 2 has not been incorporated.	<p>Revise to read: "The former is located approximately <u>31,230 feet (985375 m)</u> and the latter..."</p> <p>Basis for Change: NLS2009036 Change 2</p>

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
78	2-24/42-44	NLS2009036 Change 3 has not been incorporated. The text suggests, incorrectly, that the second monitoring site is the new 100-m tower erected to support dry cask storage at CNS. See also Comment 76.	<p>Relocate text to Page 2-25 (new paragraph after Line 8) and revise to read: "<u>The second A new monitoring site, a 328-foot (100-m) meteorological tower is being planned for 2010. The design details are incomplete, but the new tower will meet or exceed the performance standards of the existing tower and will be fully compliant with NRC requirements with equipment and monitoring system that is nearly identical to the original- 328-foot (100-m) tower, was recently built approximately 2,000 feet (610 m) northwest of the first site.</u>"</p> <p>Basis for change: NLS2009036 Change 3</p>
79	2-25/11	Change "fresh water" to "freshwater." Grammatical enhancement.	
80	2-25/18	The acronym "CRA" is not defined after its use here (although it is listed in the Table of Acronyms). Some discussion of who "CRA" is would be helpful; e.g., some indication of their expertise.	<p>Revise to read: "As part of a hydrogeologic investigation undertaken by CNS-1 for the study of radioisotopes in ground water, <u>Conestoga Rivers Associates (CRA) (a noted industry vendor in such studies) reviewed...</u>"</p> <p>Basis for Change: Clarification</p>
81	2-25/38 2-29/16	"Main-stem" should be "mainstem."	
82	2-26/4	The metric flow rate for 31,000 cfs is missing.	<p>Revise to read: "... north of CNS-1, is 31,000 cfs (<u>878 m³/s</u>)."</p> <p>Basis for Change: Correction</p>

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
83	2-26/4 and 5	The minimum permitted 3,000 cfs sanitary flow is not correct. The value should be 4,320 cfs per the U.S. Army Corps of Engineers Master Manual.	Revised to read: "In December through February, the minimum flow permitted is 3,000 4,320 cfs (85 122 m ³ /s), primarily for sanitary water quality purposes." Basis for Change: U.S. Army Corps of Engineers Master Manual. See Attachment 3, Change 1.
84	2-26/35	Change "...we derive..." to "...are derived..." Grammatical enhancement.	
85	2-27/12 and 13	Sentence does not read correctly.	Revise to read: "The authors presented a conceptual model to illustrate the links between these activities and those for recovery and restoration and of of Midwestern river fish communities." Basis for Change: Grammatical correction
86	2-28/Figure 2.2.5-1	It is not clear what this figure is trying to communicate. Recommend clarification or deletion.	
87	2-29/22-23	Appears the terms "lentic" and "lotic" are interchanged. The reservoirs would cause lentic flow, not lotic.	Revise to read: "The reservoirs have changed lentic lotic (i.e., pertaining to flowing or running water) habitat into lotic lentic (i.e., pertaining to still or standing water) habitat..." Basis for Change: Merriam-Webster Dictionary.
88	2-29/23	Insert comma after "i.e." Grammatical correction.	
89	2-29/30	"Draught" should be "drought."	Revise to read: "...as fire, draught drought, flooding..." Basis for Change: Spelling correction

Comment No.	Page Number/Line Number	Comment	Suggested Resolution
90	2-33/2	The upstream reservoir produces a lentic environment, not a lotic environment.	Revise to read: "...be largely determined by upstream reservoirs, where the lotic <u>lentic</u> environment ..." Basis for Change: Merriam-Webster Dictionary.
91	2-34/23	"Louis" should be "Lewis."	Revise to read: "...included the upstream <u>Lewis</u> and Clark..." Basis for Change: Grammatical correction
92	2-35/12	"USACE 2003" is not listed in the Section 2.4 references. Add reference to "USACE 2003" to Section 2.4.	
93	2-35/26	Sentence reads awkwardly.	Revise to read: "Within the main channel..." Basis for Change: Grammatical correction
94	2-36/4	Insert "are" between "fish near." Grammatical correction.	
95	2-36/24	The site acreage differs from the number provided on Page 2-1, line 8.	Revise to read: "According to the ER, the CNS-1 facilities are located within 55 acres (22 ha) of a 1,124 <u>0</u> -acre (454 ha) site in Nemaha County..." Basis for Change: Consistency change
96	2-36/31	The statement "...cropland on north, south, and east sides..." is not correct.	Revise to read: "The CNS property in Missouri is adjacent to the eastern bank of the Missouri River and is bordered by cropland on its <u>north, south, and east</u> and timberland on its <u>north and south sides</u> (Figure 2.2.1-1) (NPPD, 2008)." Basis for Change: ER Figure 2.2.1-1

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
97	2-36/32	An incorrect number of acres is devoted to agricultural acres on the Nebraska side of CNS site.	Revise to read: "On the Nebraska side of the CNS-1 site, approximately 900715 <u>364 289</u> acres (364 289 ha) are currently used..." Basis of Change: CNS ER Section 2.1
98	2-36/37	This line states "...a 55-acre (22ha) wetland mitigation site." The site does not have a 55-acre wetland mitigation site. It has an approximately 1.5-acre wetland mitigation site on a 55-acre parcel of ground.	Revise to read: "...and, according to NPPD staff, a 55-acre (22 ha) wetland area, <u>which includes an approximately 1.5-acre mitigation site.</u> " Basis for Change: Letter from L. Peterson (USACE) to B. Shanks (NPPD), July 6, 1995.
99	2-37/24 and 25	There is an improper attribution to the License Renewal Application ER for 40-acre agricultural activity use on the Missouri side of NPPD property. Delete/relocate "NPPD, 2008" reference.	
100	2-38/3	The greater prairie chicken is not commonly found in the vicinity of CNS. Recommend that "greater prairie chicken" be deleted, as it is not indigenous.	
101	2-39/1	"(Bubo virginianus)" should be in italics.	
102	2-39/1	Incorrect number of bird deaths.	Revise to read: "...horned owl (<i>Bubo virginianus</i>), three <u>a number of</u> additional birds, and the death..." Basis of Change: ER Page 2-52 cites more than three bird deaths.
103	2-39/Table 2.2.7-1 2-48/10	Incorrect spelling of Blue sucker scientific name.	Revise Blue sucker entry to read: " <i>Cycleptus elongateus</i> ." Basis of Change: NatureServe- "Blue sucker."

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
104	2-40/Table 2.2.7-1	The scientific name of the pallid sturgeon is listed as "Scaphirhynchus albus." Page 2-48/5 calls the pallid sturgeon "Scaphirhynchus albus" (emphasis added).	Revise Table 2.2.7-1 entry to read: "Scaphirhynchus albus." Basis for Change: NatureServe- "Pallid sturgeon."
105	2-41/Table 2.2.7-1	Incorrect spelling of "Western ribbonsnake" (needs space between "ribbon" and "snake").	Revise entry to read: "Western ribbon_snake." Basis of Change: NatureServe- "Western ribbon snake."
106	2-41/Table 2.2.7-1	Incorrect spelling of Whooping crane scientific name.	Revise Whooping crane entry to read: "Grus Americana." Basis of Change: NatureServe- "Whooping crane."
107	2-41/Table 2.2.7-1	Need to include the "Bald Eagle" since it is listed as threatened in Nebraska and endangered in Missouri.	
108	2-43/Table 2.2.7-1	Incorrect spelling of Salt Creek tiger beetle scientific name.	Revise Salt Creek tiger beetle entry to read: "Cincindela nevadica lingolnaina." Basis of Change: NatureServe- "Salt Creek tiger beetle."
109	2-43/Table 2.2.7-1	Per reference MDC, 2009c, the American burying beetle should be listed as possibly extirpated as other items are also listed as such.	
110	2-43/Table 2.2.7-1	Incorrect spelling of Thimbleweed scientific name.	Revise Thimbleweed entry to read: "Anemone cylindrical." Basis of Change: NatureServe- "Thimbleweed."
111	2-43/Table 2.2.7-1	"Harry Woodmint" should be "Harry woodmint."	Revise entry to read: "Harry <u>W</u> woodmint." Basis of Change: Typographical correction.

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
112	2-44/Table 2.2.7-1	For Buffalo grass, there should be a Habitat description beyond "Possibly extirpated" for consistency with other flora and fauna that are stasured as possibly extirpated.	
113	2-44/Table 2.2.7-1 2-45/Table 2.2.7-1 2-47/Table 2.2.7-1	The State Status for Toothed ticktrefoil, Glades gayfeather, and Twisted ladies'-tresses are "S1?" or "S2?" It is unclear what the "?" signifies.	
114	2-44/Table 2.2.7-1 2-45/Table 2.2.7-1 2-46/Table 2.2.7-1	The State Status for Bush's sedge, Frank's sedge, Plains frostweed, and Maryland senna are "S1S2." It is unclear what this classification signifies.	
115	2-45/Table 2.2.7-1	"Gastrophe olivacea" (Great Plains narrowmouth toad) should in the amphibian section rather than the plant section of the table.	
116	2-45/Table 2.2.7-1	"Seaside Heliotrope" should have a lower case "h."	Revise to read: "Seaside H <h>eliotrope."</h> Basis for Change: NatureServe – "Seaside heliotrope."
117	2-45/Table 2.2.7-1	For hairy creeping lovegrass, it should be noted in the Habitat column that it is possibly extirpated.	
118	2-45/Table 2.2.7-1	The common name for "Nothocalais cuspidate" is "Prairie false dandelion."	Revise to read: "Prairie <u>false</u> dandelion." Basis for Change: NatureServe – "Prairie false dandelion."
119	2-46/Table 2.2.7-1	"Locoweed" is not a single species of plant. "Oxytropis lambertii var. lambertii" corresponds to "Stemless point vetch."	Revise to read: " Locoweed <u>Stemless point vetch.</u> " Basis for Change: NatureServe – "Stemless point vetch."
120	2-46/Table 2.2.7-1	"Panax quinquefolium" should be "Panax quinquefolius."	Revise to read: "Panax quinquefoli <u>us.</u> " Basis for Change: NatureServe - "American ginseng."

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
121	2-46/Table 2.2.7-1	"Pediomelum argophyllum" should be "Silvery scurfpea."	Revise to read: "Silvery peoralea <u>scurfpea</u> ." Basis for Change: NatureServe – "Silvery scurfpea."
122	2-48/15	"(Iowa Administrative Code, Chapter 77)" is not included in the Section 2.4 references.	
123	2-48/46	Regarding the pallid sturgeon, the statement "The populations are largely older fish that will die off in the near future" is too definitive.	Revise to read: "The populations are <u>believed to be mostly</u> largely older fish that <u>may</u> will die off in the <u>foreseeable</u> near -future." Basis for Change: Clarification
124	2-50/17	Insert comma after "chlordane." "Chlordane" and "DDT" are two different chemicals.	
125	2-50/36	Delete "had." Grammatical enhancement.	
126	2-51/8	Change "200b" to "2003b." Referencing correction.	
127	2-51/16	Incorrect scientific name for piping plover.	Revise to read: "...piping plover (Charadrius melodius), and the ..." Basis for Change: NatureServe – "Piping plover."
128	2-51/ 37	Delete "but" following the comma. Grammatical enhancement.	
129	2-51/38-43	These lines should be deleted. The critical habitat for plovers in Nebraska was vacated and remanded for new designation but that has not occurred yet. This discussion is no longer accurate as the USFWS designation of critical habitat has been overturned. Reference: Case: 4:03-cv-03059-LES-DLP Document #: 53 Date Filed: 10/13/2005, Case: 4:03-cv-03059-LES-DLP Document #: 54 Date Filed: 10/13/2005	

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
130	2-52/4 and 9	Change "NGPC 2009a" to "NGCP 2009b" to correlate with the Section 2.4 references.	
131	2-52/13 and 16	Delete the space between "NYS DEC" to be shown as "NYSDEC" for consistency with Section 2.4 references.	
132	2-52/27	Delete the space between "MN DNR" to be shown as "MNDNR."	
133	2-52/46	The whooping crane population discussion is no longer accurate, as the experimental population of whooping cranes in Idaho is extinct.	<p>Revise to read: "There are currently three <u>two</u> populations of whooping cranes totaling less than 400 adult and juvenile birds, including one wild population and two <u>one</u> experimental, nonessential populations.</p> <p>Basis for Change: http://www.whoopingcrane.com/FLOCKSTATUS.HTM</p>
134	2-52/35, 38, 41	Change "(NGPC, 2009b)" to "(NGPC, 2009a)" to correlate with the Section 2.4 reference.	
135	2-53/7-8	The experimental population of whooping cranes in Idaho is extinct.	<p>Revise to read: "One of the two experimental populations breeds in Idaho and overwinters in Utah. The second experimental population breeds in Wisconsin and overwinters in Florida and several other southeastern States (NatureServe, 2008a)."</p> <p>Basis for Change: http://www.whoopingcrane.com/FLOCKSTATUS.HTM</p>
136	2-53/13	Recommend that the word "significant" be deleted since it implies that there are large populations, which is not the case.	

Comment No	Page Number/ Line Number	Comment	Suggested Resolution
137	2-53/26 4-42/44-45	The statement that "...collisions with transmission lines are the main cause of whooping crane mortality during their migrations" should be clarified that these are the main <u>known</u> cause of mortality.	Revise to read: "The USFWS has indicated that collisions with transmission lines are the main <u>known</u> cause of whooping crane mortality during their migrations ..." Basis for Change: It is not known what the main reason is for loss of whooping crane numbers during migratory transit. Therefore, it is appropriate to characterize transmission line collisions as a "known" cause.
138	2-58/1-2 2-59/4	Section 2.4 contains no reference "(NDED and NPPD, 2008a)."	
139	2-59/Table 2.2.8.2-1	"City of Nebraska" should be "City of Nebraska City."	
140	2-59/10	There is no "(NDE, 2008)" listed in the Section 2.4 references.	
141	2-62/44 2-63/1-2	There has been no indication that noise levels at CNS have exceeded the 55 dBA threshold noise level.	Revise to read: " <u>The EPA uses</u> However, noise levels may sometimes exceed the 55 dBA level that the EPA uses as a threshold level to protect against excess noise during outdoor activities (EPA, 1974)." Basis for Change: There is no data that noise levels at CNS have exceeded the 55 dBA noise level.
142	2-63/Table 2.2.8.5-1	In title "2006" should be "2007."	
143	2-63/Table 2.2.8.5-1	Footnote: Reference "(USCB, 2009)" does not exist in Section 2.4. Reference "University of Nebraska-Lincoln, Nebraska Population Projections (2008)" does not exist in Section 2.4.	
144	2-64/Table 2.2.8.5-2 2-65/Table 2.2.8.5-3	The race percentages do not add up to 100%.	

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
145	2-65/Table 2.2.8.5-3	If some other race category has been eliminated from the Census estimate, why is it being included in the table? Consider eliminating the category of "Other Race."	
146	2-71/17-18	It is not clear what the nexus is between NPPD's charter to provide electricity to it's customers in Nebraska, and that payments would continue regardless of the operation of CNS.	Revise to read: "NPPD's would continue charter is to be responsible for provide electricity to customers throughout the State, these payments would continue regardless of whether or not the CNS-1 is operating." Basis for Change: Clarification
147	2-71/25	The numbers provided for "Nebraska in Lieu of Taxes to Counties With NPPD Retail Electric Sales Attributed to the CNS-1," "Payments to Retail Communities Attributed to CNS-1," and the Total values do not match what was provided in ER Table 2.7-1. Recommend revision to conform with ER information.	
148	2-71/26	Reference "NPPD, 2008b" is incorrect. Change "NPPD, 2008b" to "NPPD, 2008" to correlate with the reference in Section 2.4.	
149	2-73/17	Delete random ")" following "population."	
150	2-76/19 and 20	The reference "50 CFR Part 22" is not referenced in the Section 2.0 discussion.	
151	2-78/23-28	Hesse, L.W., [et al]. 1982a is not referenced in the Section 2.0 discussion.	
152	2-79/15-17	Missouri Conservation Department 2009 is not referenced in the Section 2.0 discussion.	
153	2-79/ 38-41	MDC 2009d" is not referenced in the Section 2.0 discussion.	
154	2-80/23-25	NRCS. 2000" is not referenced in the Section 2.0 discussion.	
155	2-82/10	Change "2004a" to "2004" to correlate with the reference listing in the Section 2.0 discussion.	

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
156	2-82/12	Change "2005a" to "2005" to correlate with the reference listing in the Section 2.0 discussion.	
157	2-82/24-26	NPPD 2007c is not referenced in the Section 2.0 discussion.	
158	2-82/35-37	NPPD 2008d is not referenced in the Section 2.0 discussion.	
159	2-82/42-43	NPPD 2009b is not referenced in the Section 2.0 discussion.	
160	2-83/9	Insert "2009a" after "(NGPC)" to correlate with the reference listing in the Section 2.0 discussion.	
161	2-84/27-30	USCB 2009b is not referenced in the Section 2.0 discussion.	
162	2-85/34-37	USFWS 2008c is not referenced in the Section 2.0 discussion.	
163	2-86/5 and 6	USFWS 2009d is not referenced in the Section 2.0 discussion.	
164	2-86/7-11	USFWS 2009e is not referenced in the Section 2.0 discussion.	
165	2-86/12-15	USFWS 2009f is not referenced in the Section 2.0 discussion.	
166	3-4/3-5	Need to separate 10 CFR 54 as a stand alone reference.	
167	3-4/10-12	NRC 1999 is not referenced in the Section 3.0 discussion.	
168	4-1/14	For consistency, "10 CFR Part 51" should be listed in the Section 4.12 references.	
169	4-2/13	Insert a "period" after "(gpm)."	
170	4-5/22	Delete "the" before "Section 316(a)." Grammatical enhancement.	
171	4-5/15 and 16	Delete the duplicated phrase "...for minimizing adverse environmental impact."	
172	4-5/35	On line 35, the NRC appears to be calculating a fish impingement value for the year 1974, not 1978. Please verify.	

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
173	4-5/39	Recommend the use of the word "reasonable" over "useful."	
174	4-6/9	The Staff indicates that NPPD has committed to change out the fish screens during the 2011 refueling outage, as opposed to the more general characterization of during the initial operating term. This should be clarified to be consistent with the discussion suggested in Attachment 2 for Page 2-13/Lines 26-31.	<p>Revise to read: "CNS-1 has not <u>yet</u> completed the fish protection system, and <u>plans to install, during a 2011 refueling outage, The intention is to install a fish handling and return system to mitigate fish impingement consisting of inside and outside sprays to wash fish from the screens and a separate fish return trough (NPPD, 2008, pgs 4-11). The plant's service water system would supply water for the spray wash. The new screens, fish handling system, and fish return trough primarily affect impingement but not entrainment. CNS implementation date and the final design of the fish handling system are dependent upon the content of the final 316(b) Clean Water Act requirements.</u>"</p> <p>Basis for Change: Clarification. See Attachment 3, Changes 2, 4, 5, 6, 7, 8, 9, 10, and 11.</p>
175	4-6/39	The "(EPA, 2009)" reference should be changed to "(EPA, 2009b)" based on the Section 4.12 references.	
176	4-7/1-6	<p>The NRC states the following:</p> <p>"The NRC staff examined the question of how the age of the data might affect the conclusions regarding entrainment and impingement at CNS-1. The NRC staff found that the argument used in the NPPD's ER is inconsistent because it assumed at different points that the aquatic resources are both stable and unstable, although in fact they cannot be both. In describing the aquatic resources, the ER stated that fish communities have long been responding to changes in the river brought on by man's activities."</p> <p>These statements should be deleted. The CNS ER does not present an argument that aquatic species are stable or unstable. NPPD's evaluation of the aquatic resources in the vicinity of CNS did not assume or conclude that the aquatic resources were stable. In fact, the available</p>	

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
		<p>studies of Missouri River communities indicate little historic information is available related to the aquatic communities in the Missouri River prior to its damming and channelization. There have, however, been numerous studies that conclude alterations of the river flows and channel may have had significant impact on the communities that may have once existed. NPPD's ER made several statements that some species may be in decline while others may be aggressively and invasively increasing (e.g., Asian carp). NPPD's ER discusses at length the anthropogenic factors that have and continue to affect the aquatic resources. These anthropogenic factors, however, are unrelated to the operation of CNS or other power plants on the Missouri River.</p>	
177	4-7/30 and 31	<p>The "EPA (2009)" reference should be changed to "EPA (2009b)" based on the Section 4.12 references.</p>	
178	4-7/45	<p>The "(Berry et al.)" reference is not listed in the Section 4.12 references.</p>	
179	4-8/15-16	<p>Delete extra closing parentheses in two locations.</p>	
180	4-8/38-40	<p>NPPD's plans for installing a fish handling system should indicate that the final design is dependent on the content of the final 316(b) regulations.</p>	<p>Revise to read: "...and NPPD plans to install a fish handling <u>and return</u> system consisting of inside and outside sprays to wash fish from the screens and a separate fish return trough to mitigate adverse effects of impingement whose final design is dependent upon the content of the final 316(b) Clean Water Act requirements ..."</p> <p>Basis for Change: Clarification. See Attachment 3, Changes 2, 4, 5, 6, 7, 8, 9, 10, and 11.</p>
181	4-8/40	<p>Replace "NDEC" with "NDEQ."</p>	

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
182	4-10/45-46	The design of the fish handling system is contingent on content of the final <u>316(b)</u> regulations.	<p>Revise to read: "Whatever the total effects of CNS-1 on the fish community were in the past, the installation of the modified dual-flow traveling screens in 2006 and future installation of a <u>fish handling and return system</u>low pressure screen-wash and fish return trough <u>(dependent upon the final design and implementation of the final 316(b) Clean Water Act requirements)</u> would mitigate those impacts...."</p> <p>Basis for Change: Clarification. See Attachment 3, Changes 2, 4, 5, 6, 7, 8, 9, 10, and 11.</p>
183	4-11/Table 4-4	Table 4-4 is not in the Table of Contents.	
184	4-12/10 and 17	As noted in Section 2.0, the number of acres owned by NPPD on the Missouri side of the river is 239 acres, not 230 acres. This entire parcel was offered for a conservation easement. The acreage values should be revised.	
185	4-12/21 and 22	The conservation agreement discussions should be updated.	<p>Revise to read: "At the time of writing this SEIS, <u>The deed restriction for conservation has been placed upon the 239 acres that NPPD owns on the Missouri side of the river, and the MOU including conditions regarding the additional payment of \$250,000, has been finalized and signed by the parties involved parties are discussing details of the conservation agreement.</u>"</p> <p>Basis for Change: Status update</p>
186	4-12/31	The "Hrabik et al. (2007)" reference is not listed in the Section 4.12 references.	
187	4-13/3	Change "section" to "Section." Grammatical correction.	

Comment No	Page Number/ Line Number	Comment	Suggested Resolution
188	4-13/25-33	It is not necessary for the NRC to solicit a commitment for NPPD to report the existence of endangered or threatened species via the draft SEIS. Reporting is conducted in accordance with State and Federal regulations.	<p>Revise to read: "The staff requests that NPPD report the existence of any Federally listed or State listed endangered or threatened species within the CNS-1 site or near the transmission line corridor to NGPC, MDC, and the USFWS, if any such species are identified during the license renewal term. In addition, the NPPD is required to promptly report to the appropriate wildlife management agencies and to NRC, any evidence of injury to, or mortality of, migratory birds or threatened or endangered species observed within the transmission line corridor, especially injury to, or mortality of, Federally listed whooping cranes, interior least terns, and piping plovers along the Platte River near the western limit of CNS-1 transmission line NPPD TL3502, near Grand Island, NE. All of NPPD operations, including those necessary for transmission line maintenance and operation, are conducted in accordance with NPPD policies and procedures that require special precautions related to operations involving threatened and endangered species and avian protection [NPPD 2007a; NPPD 2007b]."</p> <p>Basis for Change: ER Page 4-47, Section 4.10.5</p>
189	4-13/40-41	The status of the bird diverters should be updated.	<p>Revise to read: "The NPPD is also has coordinated with USFWS staff and has to installed bird diverters on transmission line NPPD TL3502 where it traverses the Platte River."</p> <p>Basis for Change: Status update.</p>
190	4-15/32	Insert space after "0.0031."	

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
191	4-16/21-22	The verbiage needs to be revised to more accurately reflect the applicability of the issue since CNS is not a closed-cycle plant.	Revise to read: "The effects of thermophilic microbiological organisms on human health, listed in Table B-1 of Appendix to Subpart A of 10 CFR Part 51, are categorized as a Category 2 issue and require plant-specific evaluation during license renewal process for the plants located on the <u>a small river, that use closed-cycle cooling.</u> " Basis for Change: 10 CFR 51.53(c)(3)(ii)(G)
192	4-16/24	"3.15x10 ¹² ft ³ /year (9x10 ¹⁰ m ³ /year)" should be revised as follows: "3.15x10 ¹² ft ³ /year (9x10 ¹⁰ m ³ /year)"	
193	4-19/Table 4-7	Recommend that NRC confirm the subject matter of Table 4-7, as it appears to be nearly identical to Table 4.6. Should Table 4-7 cover Category 2 socioeconomic issues?	
194	4-20/8	Delete the period following "proximity."	
195	4-22/19	Add a space after the comma as follows "...history, (2)..."	
196	4-23/8	Extra "(" at end of the line.	
197	4-23/15	There is no "pending research" anticipated for historic archeological sites in the vicinity of CNS.	Revise to read: "All surface structures associated with the earlier house sites have been demolished; however, remnants of these buildings remain as historic archaeological sites and could be eligible for inclusion to the NRHP under Criteria A and D pending further research. " Basis for Change: Clarification
198	4-23/32	The "(Gibbon and Ames, 1998)" reference is not listed in the Section 4.12 references.	
199	4-23/34	The "(NSHS, 1937)" reference is not listed in the Section 4.12 references.	

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
200	4-24/22-30	<p>NPPD has procedural administrative controls in place to ensure that cultural resource reviews are conducted prior to engaging in construction or operational activities in previously undisturbed areas that may result in a potential impact to cultural resources at the site [NPPD, 2007c]. Areas depicted in Phase 1A Literature Review and Archeological Sensitivity Assessment were identified as higher probability archeological site areas on the CNS Owner Controlled Area. However, NPPD has developed a Cultural Resources Protection Plan in an effort to meet state and federal expectations and includes measures for archeological investigations (Phase 1B) and consultations with the Nebraska and Missouri State Historic Preservation Offices (SHPO), and the appropriate Native American groups prior to any future ground disturbing activities [CNS, 2008]. These measures provide adequate protection for potential area cultural resources.</p>	<p>Revise to read: <u>"NPPD could further reduce potential impacts to historic and archaeological resources located at the CNS-1 by training NPPD staff in the Section 106 consultation process and cultural awareness training to ensure that informed decisions are made prior to any ground disturbing activities. In addition, NPPD could also forward its Cultural Resources Protection Plan to the NSHS and the Missouri SHPO for review and comment. This will ensure that historic and archaeological resources are protected at the CNS-1 site. Any revisions to the Cultural Resources Protection Plan should be developed in consultation with the NRC, NSHS, and Missouri SHPO. In addition, lands not surveyed should be investigated by a qualified archaeologist prior to any ground disturbing activity. NPPD should continue to fulfill all site, state, federal, and NEPA requirements regarding future land disturbances on-site."</u></p> <p>Basis for Change: It is not necessary for the DSEIS to make recommendations on actions NPPD could take to further reduce the SMALL impacts on historic and archaeological resources at CNS.</p>
201	4-26/16	The "(USCB, 2009)" reference is not listed in the Section 4.12 references.	
202	4-26/17	There is a big space at the end of this line that should be filled with text – check the carriage return.	
203	4-27/3 4-28/3 4-29/7 4-30/3 4-31/3	The "(USCB, 2008)" reference is not listed in the Section 4.12 references.	

Comment No.	Page Number/Line Number	Comment	Suggested Resolution
204	4-29/11	The "(USCB, 2009)" reference is not listed in the Section 4.12 references.	
205	4-33/14	Change "Thorium" to "Naturally occurring thorium" to indicate that it's not plant-related.	Revise to read: " <u>Naturally occurring</u> Thorium-228 was measured in one sample." Basis for Change: Clarification
206	4-33/23	Sentence does not read correctly.	Revise to read: "There were 26 broadleaf vegetation samples <u>were</u> collected <u>from</u> June through September.." Basis for Change: Grammatical correction
207	4-33/37	Change "10 CFR Part 72" to "10 CFR Part 50" since CNS has not yet implemented a General License under Part 72.	Revise to read: "The REMP continues to demonstrate that the dose to a member of the public from the operation of CNS-4 remains significantly below the Federally required dose limits specified in 10 CFR Part 20, 10 CFR Part <u>50</u> 72, and 40 CFR Part 190." Basis for Change: CNS has a Part 50 license, but not a General License under Part 72.
208	4-33/39	"Soils" are not monitored.	Revise to read: "Based on recent monitoring results, concentrations of contaminants in native leafy vegetation, soils and sediments, surface water, and fish in areas surrounding CNS-1 have been quite low (at or near the threshold of detection) and seldom above background levels." Basis for Change: CNS Offsite Dose Assessment Manual
209	4-34/18	The "(NRC, 2000)" reference is not listed in the Section 4.12 references.	
210	4-36/3 4-44/21	The "(USGCRP, 2009)" reference is not listed in the Section 4.12 references.	

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
211	4-36/5	“(14 °C)” should be “(3.3°C).” “(12 °C)” should be “(5.6°C).”	
212	4-37\36-39	This section states: “The impact of introduction and stocking of native and introduced fish species is also somewhat similar to the impact of CNS-1, because the effect of a power plant that impinges and entrains aquatic organisms is somewhat similar to that of a large predator introduced into an aquatic system.” This appears to be subjective and is not substantiated. Recommend deletion.	
213	4-38/1	Recommend clarification as to which states are being referred to.	
214	4-38/4 4-40/Table 4-9	The “Nelson-Stastny (2004)” reference is not listed in the Section 4.12 references.	
215	4-38/22-25 4-47/Table 4-10	The characterization of the Missouri River aquatic ecosystem being potentially past the point of reparable change is not adequately justified.	Revise to read: “While the level of impact due to direct and indirect impacts of CNS-1 on aquatic communities is SMALL, the cumulative impact when combined with of all other sources of impact has resulted in the Missouri River aquatic ecosystem being unstable <u>and has resulted in a large and close to, if not past, the point of reparable change.</u> This condition meets NRC’s definition of a LARGE level of impact. ” Basis for Change: Clarification
216	4-40/Table 4-9	Why is this table titled “Stastny 2004?” No other tables have titles from the reference name.	
217	4-41/2, 13, and 20	The “(NGPC, 2005)” reference is not listed in the Section 4.12 references.	

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
218	4-41/27-29	The acreages listed do not match the values provided in ER Section 2.1.	<p>Revise to read: "Approximately 900 acres (364 hectares) of the 1,120-acre (4534 hectare) CNS-1 site is used for agriculture (NPPD, 2008). Much of the 5590-acres (2236 hectares) of land where the CNS-1 facilities have been constructed was cropland prior to construction of the facility, so disturbance to wildlife habitat had occurred prior to construction of CNS-1."</p> <p>Basis for Change: CNS Environmental Report, Section 2.1.</p>
219	4-41/34-36	The site does not have a 55-acre mitigation site, it has an approximately 1.5-acre mitigation site on 55-acre parcel of ground.	<p>Revised to read: "NPPD was recently required by the USACE to restore <u>approximately 1.5 56-acres (0.622 hectares)</u> of disturbed wetlands habitat <u>onsite on a 55-acre (22-hectacre) parcel of ground</u> as mitigation for NPPD filling in other disturbed wetlands for construction of CNS-1 parking facilities.</p> <p>Basis for Change: Letter from L. Peterson (USACE) to B. Shanks (NPPD), July 6, 1995.</p>
220	4-41/47	The "(NDNR, 2009)" reference is not listed in the Section 4.12 references.	

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
221	4-42/9-13	This discussion should be updated based on the recently reached wetland agreement.	<p>Revised to read: Based upon discussions with NPPD staff during the environmental site audit, NPPD is currently coordinating with Federal and State resource agencies to place this Missouri land into a conservation easement, which may lead to long-term protection of this land from any development as well as removal of the 40 acres of cropland from agricultural production. A conservation deed restriction has been placed upon the 239 acres of land located on the Missouri side of the river to provide for long-term protection of this land from any development as well as agricultural production.</p> <p>Basis for Change: Clarification</p>
222	4-42/18	The "(NCRS), 2007" reference is not listed in the Section 4.12 references.	
223	4-42/25	The "(NGPC, 2005)" reference is not listed in the Section 4.12 references.	
224	4-43/3	"(NPPD, 2009)" appears to be an incorrect reference since it does not correlate with the Section 4.12 NPPD references.	
225	4-43/30-35	The NRC concluded that the cumulative impacts on terrestrial resources would be MODERATE. However, the information presented in Section 4.11.4 makes it unclear how that conclusion was reached. Additional justification should be provided.	

Comment No.	Page Number/Line Number	Comment	Suggested Resolution
226	4-43/33-35	It is recommended that this section be revised for consistency with the language utilized on Page 4-38 of the DSEIS regarding aquatic impacts.	Revise to read: "...however, the cumulative impacts on terrestrial resources resulting from all 34 past, present, and reasonably foreseeable future actions, including non-CNS-1 activities, while the level of impact due to direct and indirect impacts of CNS on terrestrial communities is <u>SMALL</u> , the cumulative impact when combined with all other sources, even if CNS was excluded, <u>would be moderate.</u> " Basis for Change: Clarification
227	4-43/35	Moderate should be in all capital letters.	
228	4-44/1	Delete "the" before 34. Grammatical enhancement.	
229	4-44/21 and 22	"(14 °C)" should be "(3.3°C)" "(12 °C)" should be "(5.6°C)"	
230	4-44/34-38	This sentence appears to be out of place for this air quality discussion: "As discussed in Nonradioactive Waste Management Section 2.1.3, NPPD is committed to the EPA's Reduce, Reuse, Recycle program at its major and minor facilities, with a growing Green Team, that focuses on pollution prevention, waste minimization, education and training of the personnel, and incorporates EPA recommendations on the national implementation of the climate change energy conservation techniques (EPA, 2009a)."	
231	4-44/42-45 4-45/1-10	In Comment 73, a significant rewording was suggested for Section 2.2.2.1. If these changes are accepted by the NRC, conforming changes to Page 4-44/42-45 and Page 4-45/1-10 are necessary.	
232	4-44/45	Insert "(CO)" after carbon monoxide. Grammatical enhancement.	
233	4-45/2	A cross-reference is made to Air Quality Impacts in Section 2.2.2.2. This should be Section 2.2.2.1.	
234	4-45/13.	Delete the second "The staff concludes." It is repeated.	

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
235	Page 4-45/16-20	It is not clear why a discussion of alternatives is made in this cumulative impacts assessment. The National Environmental Protection Act requires the cumulative impact conclusions be based on known and foreseeable actions, not hypothetical alternatives. Recommend deletion.	
236	4-46/13 and 14	NPPD has made no commitments to initiate further consultations with the NRC and SHPO should plans change for future land-disturbing activities. NPPD procedures stipulate when outside agency consultations should be initiated. Accordingly, the statement: "Should plans change, further consultation would be initiated by NPPD with the NRC and SHPO." should be deleted.	
237	4-46/19-21	<p>It is unclear if the NRC is describing the potential cumulative impacts of CNS operation alone, or the cumulative impacts of CNS operation combined with other Federal or non-Federal actions (ref. Council on Environmental Quality implementation of 40 CFR 1508.7).</p> <p>If describing CNS operation alone, the text should be: "...resulting from CNS-1 operation <u>alone</u> during the period of extended operation would be SMALL. to MODERATE" based on the Staff's conclusions in Sections 4.1 through 4.9.</p> <p>If describing CNS operation with other non-CNS actions, the text should read: "... resulting from CNS-1 operation <u>combined with these other actions</u> during the period of extended operation would be SMALL to MODERATE <u>LARGE</u>" due to the previous aquatic determination of a LARGE impact in Section 4.11.3.</p>	
238	4-47/Table 4-10 Air Quality	It is unclear what NPPD's commitment to "the EPA's Reduce, Reuse, Recycle program at its major and minor facilities, with a growing Green Team, that focuses on pollution prevention, waste minimization, education and training of personnel..." relates to air quality. Recommend deletion.	
239	4-48/6 and 7	10 CFR Part 54 is not referenced in the Section 4.0 discussion.	
240	4-48/8 and 9	36 CFR Part 60 is not referenced in the Section 4.0 discussion.	
241	4-49/5-7	AEC 1972 is not referenced in the Section 4.0 discussion.	

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
242	4-50/12-15	EPA 2009b is not referenced in the Section 4.0 discussion.	
243	4-50/42-46	MDC 2009a is not referenced in the Section 4.0 discussion.	
244	4-51/9-11	NEIHS 1999 is not referenced in the Section 4.0 discussion.	
245	4-51/12 and 13	Change "2009a" to "2009" so that the reference will correlate with how it's listed in the Section 4.0 discussion.	
246	4-51/17-19	NDEQ 2008 is not referenced in the Section 4.0 discussion.	
247	4-51/20 and 21	NDEQ 2009 is not referenced in the Section 4.0 discussion.	
248	4-51/22-24	NIEHS 1999 is not referenced in the Section 4.0 discussion.	
249	4-52/6-9	NPPD 2008a is not referenced in the Section 4.0 discussion.	
250	4-52/10 and 11	NPPD 2008b is not referenced in the Section 4.0 discussion.	
251	4-52/12-14	NPPD 2008c is not referenced in the Section 4.0 discussion.	
252	4-53/16-20	NRC 1999 is not referenced in the Section 4.0 discussion.	
253	4-54/8-10	USAEC 1973 is not referenced in the Section 4.0 discussion.	
254	4-54/24-27	Delete the "USFWS 2009a" reference since it is already listed on Lines 20 – 23.	
255	4-54/42-44	WHO 2007a is not referenced in the Section 4.0 discussion.	
256	5-3/2	Replace verb "requires" with "require" to agree with subject, "Regulations."	
257	5-3/9	Incomplete sentence and misspelled word.	Revise to read: "of severe <u>accident</u> mitigation alternatives..." Basis for Change: Grammatical correction

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
258	5-3/11-12	Incorrect corporate name.	<p>Revise to read: "...conducted by the <u>Nebraska Public Power District</u> NPPD Energy Company, LLC, (NPPD)..."</p> <p>Basis for Change: Correction</p>
259	5-3/27-33	<p>Section states, "NPPD identified 33 potential SAMAs for CNS-1. NPPD performed an initial screening to determine if any SAMAs could be eliminated because they are not applicable to CNS-1 due to design differences, or have estimated implementation costs that would exceed the dollar-value associated with completely eliminating all severe accident risk at CNS-1. No SAMAs were eliminated based on this screening, leaving all 33 for further evaluation."</p> <p>This is not consistent with the information provided in Section E.2 of the ER, with the summary in DSEIS Section 5.3.3 (page 5-5), or with DSEIS Appendix F (Section F.3.1, page F-13). In fact, 244 potential Severe Accident Mitigation Alternatives (SAMA) were identified for CNS. The dollar-value of completely eliminating severe accident risk was not used in the screening phase, and 80 SAMAs were left for further evaluation.</p>	<p>Revise to read: "NPPD identified 33 <u>244</u> potential SAMAs for CNS-1. NPPD performed an initial screening to determine if any SAMAs could be eliminated because they are not applicable to CNS-1 due to design differences, or because they have estimated implementation costs that would exceed the dollar-value associated with completely eliminating all severe accident risk <u>already been implemented at CNS-1, or because they are addressed by another SAMA candidate.</u> No 164 SAMAs were eliminated based on this screening, leaving all 33 <u>80</u> for further evaluation."</p> <p>Basis for Change: Clarification</p>
260	5-5/8-10	<p>Section states, "Accordingly, the staff based its assessment of offsite risk on the CDFs and offsite doses reported by NPPD in their December 2009 letter (NPPD, 2009b)."</p> <p>It appears that the Staff actually based its assessment of the offsite risk on the Core Damage Frequencies and offsite doses reported by NPPD in the ER (NPPD, 2008). The December 2009 letter merely indicates that the ER results are conservative compared to the results that would have been obtained using corrected meteorological data.</p>	<p>Revise to read: "Accordingly, the staff based its assessment of offsite risk on the CDFs and offsite doses reported by NPPD in their December 2009 <u>letter LRA Environmental Report (NPPD, 2008b)</u>."</p> <p>Basis for Change: Clarification</p>
261	5-7/25-28	<p>Section states, "NRC staff reviewed NPPD's re-analysis as submitted by NPPD and agrees that the error was conservative relative to the average population dose and offsite economic cost and that no SAMAs were inappropriately excluded from consideration in the LRA as a result of the error."</p> <p>This paragraph is not clear as a stand-alone paragraph. Suggest moving this paragraph to Section 5.3.2, page 5-4, following lines 11-17.</p>	

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
262	5-8/4	Insert an open parenthesis "(" at the beginning of the line, prior to "e.g." Also, recommend changing "e.g." to "i.e." since this statement appears to be paraphrasing for clarity of meaning rather than providing an example of managing the effects of aging.	
263	5-8/14 and 15	10 CFR Part 100 is not referenced in the Section 5.0 discussion.	
264	5-8/16-22	The NPPD 1993 (ML073600192 and ML073600193) references were not found in ADAMS search.	
265	5-8/30	NPPD 2009 reference should be ML091880319 (delete trailing 3).	
266	5-8/40 and 41	Add, "September 2004" at the end of the reference for consistency with same reference on page F-39 (line 25).	
267	6-3/1 6-4/2, 15, 16, 19, 26 and 28 6-5/ 9 and 15	Change "lifecycle" to "life cycle."	
268	6-3/24	"(Keepin, 1988; Hagen et al., 2001; and MIT, 2003)" are not listed in the Section 6.3 references.	
269	6-5/Table 6-2.	The POST (2006) line of data contains an arrow after coal. There is nothing like it elsewhere so it appears it should be deleted.	
270	6-5/Table 6-2 6-6/Table 6-3 6-7/Table 6-4	"POST (2006)" is not listed in the Section 6.3 references.	
271	6-9/8 and 9	10 CFR Part 63 is not referenced in the Section 6.0 discussion.	
272	6-9/10-12	40 CFR Part 191 is not referenced in the Section 6.0 discussion.	
273	7-2/24-26	NPPD 2008 is not referenced in the Section 7.0 discussion.	

Comment No	Page Number/ Line Number	Comment	Suggested Resolution
274	8-2/Box	The "EIA 2009a" reference appears to be inaccurate based on the Section 8.7 references. Based on Section 8.7, it appears that it should be "EIA 2009."	
275	8-4/8 8-6/22 and 23 8-10/12 and 25 8-17/21 8-18/8, 38 and 39 8-19/8 8-23/18 and 21 8-24/39 8-31/5 and 27 8-35/4	There is no "(NPPD, 2008)" in the Section 8.7 references.	
276	8-4/20 and 21	Since the DSEIS had not previously discussed coal ash and scrubber sludge being recycled, the following sentence is incorrect: "As noted above, much of the coal ash and scrubber sludge (about 38,300 tons (34,800 MT)) could be recycled."	Revise to read: " As noted above, much of t The coal ash and scrubber sludge (about 38,300 tons (34,800 MT)) could be recycled." Basis for Change: Correction
277	8-4/40	Change "(EPA, 2008a)" to "(EPA, 2008)" to correlate with the Section 8.7 reference.	
278	8-5/19-24	The Table of Acronyms identify "MT" as "metric tonnes." This section spells it "metric tones." Recommend replacing with "MT." Grammatical correction.	
279	8-5/22-23 8-6/28	The numbers after PM should be subscript in two locations.	
280	8-6/15	The citation "40 CFR 60.44Da(1)" should be "40 CFR 60.44Da(a)(1)."	
281	8-6/24	Insert space after "SO ₂ ."	
282	8-13/17	Change "driveshaft" to "drive shaft."	
283	8-15/3	PM10 should be PM ₁₀ .	

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
284	8-15/17 and 18	The statement that "there is no required reporting of GHG emissions in Nebraska" is inaccurate. EPA finalized the mandatory reporting of greenhouse gases rule which was effective January 1, 2010. This sentence should be deleted.	
285	8-16/16	Delete extra parentheses after "2 m ³ /s."	
286	8-20/13	Large space at the end of line needs to be corrected.	
287	Page 8-21/10-17	It does not appear to be reasonable to conclude that 250 MWe of CNS baseload generation can be replaced by conservation. The Staff claims that this is supported by the state's energy efficiency goals, but this does not seem realistic. Request NRC verify and provide reference of the source of the Nebraska energy efficiency goals.	
288	8-21/14	Change "is" to "would be." Grammatical enhancement.	
289	8-21/22	Change "will" to "would." Grammatical enhancement.	
290	8-22/2	Delete the "s" after "require."	
291	8-22/28	Insert ")" after Congress.	
292	8-31/7	There is no "(Nucleonics Week, 2008)" in the Section 8.7 references.	
293	8-32/4	There is no "(NREL, 2008)" in the Section 8.7 references.	
294	8-32/23	There is no "(ORNL, 2007)" in the Section 8.7 references.	
295	8-33/24	There is no "(Integrated Waste Services Association, 2007)" in the Section 8.7 references.	
296	8-40/4-6	ACAA, 2007 is not referenced in the Section 8.0 discussion.	
297	8-40/34	Change "2000a" to "2000" to correlate with the reference listing in the Section 8.0 discussion.	
298	8-40/37	Change "2008a" to "2008" to correlate with the reference listing in the Section 8.0 discussion.	

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
299	8-40/39 and 40	EPA 2009a is not referenced in the Section 8.0 discussion.	
300	9-1/3	Incorrect corporate name for NPPD.	Revise to read: "...Nebraska Public Power District (NPPD) Energy Company, LLC's..." Basis for Change: Correction
301	9-1/25-30	The discussion states that the NRC staff has identified a variety of measures to mitigate potential acute electromagnetic field (EMF) impacts. The discussion of EMF impacts, however, does not indicate the consideration of any such mitigation alternatives in this case. Recommend deletion.	
302	9-1/31-37	The discussion states that the NRC staff has identified a variety of measures to mitigate potential impacts of thermophilic microbiological organisms resulting from continued operation of CNS. These measures are not enumerated in section 4.8.2 of the document, so it is unclear where the NRC staff identified mitigation measures. Recommend deletion.	
303	11-1/33-37	It is unclear how regulatory agencies in Pennsylvania are related to license renewal at CNS. Recommend deletion.	
304	11-2/3	Unclear how the Susquehanna River Basin Commission is related to license renewal at CNS. Recommend deletion.	
305	F-1/5	Change "In December 7, 2009" to "On December 7, 2009." Grammatical correction.	
306	F-1/19	There is no "(NRC, 1998a)" in the Section F.8 references.	
307	F-1/22	Change "...who addressed..." to "...that addressed..."	
308	F-5/3	The "(8.9 x 10 ⁻⁵ per year)" value does not agree with the CDF value reported in Section E.1.4 of the ER and in DSEIS Table F-3.	Revise to read: "... <u>(8.90)</u> x 10 ⁻⁵ per year..." Basis for Change: Correction
309	F-7/23-27	Recommend providing a reference to "(NPPD 2009a)."	

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
310	F-10/44 through F-11/2	Recommend providing a reference to "(NPPD 2009a)."	
311	F-11/11-13	Recommend providing a reference to Measurement Uncertainty Recapture power uprate approved by the NRC in 2008 (NPPD License Amendment 231 ADAMS Accession Number ML081540280).	
312	F-11/46 through F-12/2	<p>Section states, "Year 2004 tourist information was used to estimate the transient population for year 2005 (Global Insight, 2006; IDED, 2006; Kaylen, 2006; NDED, 2006)."</p> <p>These references were used for the tourist information. Although this information was not provided in the ER or the responses to Requests for Additional Information, it was included in the supporting Engineering Report (CNS-RPT-07-PRA3). This report indicates that year 2004 tourist information was used for Kansas since 2005 data was not available. However, 2005 data was used for the other states (Iowa, Missouri, and Nebraska).</p> <p>Thus, the statement in the DSEIS is not accurate.</p>	<p>Revise to read: "<u>Year 2005 tourist information was used to estimate the transient population in Iowa, Missouri, and Nebraska (IDED, 2006; Kaylen, 2006; NDED, 2006).</u> Year 2004 tourist information was used to estimate the transient population in <u>Kansas</u> for year 2005 (Global Insight, 2006; IDED, 2006; Kaylen, 2006; NDED, 2006)."</p> <p>Basis for Change: Clarification</p>
313	F-12/10 and 11	Add reference to the time estimate studies (listed on Page F-38/Lines 1-4) for the following sentence: "The evacuation speed and time were based on the average values identified in the Missouri and Nebraska time estimate studies."	
314	F-12/2-14	<p>Section states, "NPPD performed sensitivity analyses in which the evacuation delay time was increased to 4.0 hours, and the evacuation speed was decreased to 1.0 m/s. These sensitivity cases resulted in less than 1 percent and 2 percent increases in the total population dose, respectively."</p> <p>Table E.1-15 of the ER provides the results of the sensitivity cases. Comparison of the sums of the third and fourth columns with the sum of the second column shows that both sensitivity cases resulted in less than 1% increase in the total population dose.</p> <p>Thus, the statement in the DSEIS is not accurate.</p>	<p>Revise to read: "NPPD performed sensitivity analyses in which the evacuation delay time was increased to 4.0 hours, and the evacuation speed was decreased to 1.0 m/s. <u>Each of these</u> sensitivity cases resulted in less than <u>a</u> 1 percent and 2 percent increases in the total population dose, respectively."</p> <p>Basis for Change: Correction</p>

Comment No.	Page Number/Line Number	Comment	Suggested Resolution
315	F-12/19-21	<p>Section states, "In response, NPPD performed a sensitivity analysis that showed only a slight increase in population dose (less than 1 percent for the late release) would result (NPPD, 2009a)."</p> <p>The RAI response letter (NPPD, 2009a) states, "If only 95 percent of the population had been assumed to evacuate the EPZ, then the offsite exposure risk would have been 2.15 person-rem/yr for the baseline severe accident consequences."</p> <p>This represents an increase of less than 1% for the total population dose. Since the increase in total population dose, rather than "late release" population dose was reported, suggest deleting "for the late release."</p>	<p>Revise to read: "In response, NPPD performed a sensitivity analysis that showed only a slight increase in population dose (less than 1 percent total for the late release) would result (NPPD, 2009a)."</p> <p>Basis for Change: Correction</p>
316	F-21 through F-30/Table F-5	For consistency with the rest of the table, remove horizontal lines prior to SAMAs 12, 26, 31, and 66.	
317	F-24 and F-30/Table F-5	Details in modeling assumption for SAMA 78 are beyond the level of detail provided for other SAMAs. Suggest deleting, "to 5.0E-02 for events FPS-XHE-FODFPAL and FPS-XHE-FO-RPVIN and to 9.5E-03 for event FPS-XHE-FODISEL.(c)" and note (c).	<p>Revise to read: "Reduce failure of operator actions to provide alternate injection via the fire water system by a factor of two to 5.0E-02 for events FPS-XHE-FO-RPVIN and to 9.5E-03 for event FPS-XHE-FO-DISEL.(e)"</p> <p>Also, delete note (c).</p> <p>Basis for Change: Level of detail consistency</p>
318	F-28/Table F-5	Typo in modeling assumptions for SAMA 70; "drywall" should be "drywell."	

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
319	F-30/Note (a)	<p>Note (a) indicates that SAMAs in bold are potentially cost-beneficial, but no SAMAs are bold. The following SAMAs are potentially cost-beneficial, based on the CNS SAMA analysis:</p> <p>SAMAs 14 and 25 on page F-23 SAMAs 78 and 33 on page F-24 SAMAs 30 and 68 on page F-25 SAMAs 40 and 45 on page F-26 SAMA 64 on page F-29 SAMAs 75 and 79 on page F-30</p>	
320	F-31/33-34 F-32/8-9 and 25-26 F-33/8-9	<p>For each of the averted cost calculations, the text states, "For the purposes of initial screening, which assumes elimination of all severe accidents caused by internal events, NPPD calculated..." However, NPPD did not use the value of eliminating all severe accidents in the initial screening task.</p>	<p>Revise to read: "For the purposes of initial screening, which assumes elimination of all severe accidents caused by internal events, NPPD calculated..."</p> <p>Basis for Change: Correction</p>
321	F-32/31 and 32	<p>Section states, "Repair and refurbishment costs are considered for recoverable accidents only and not for severe accidents." Wording incorrectly suggests that repair and refurbishment costs are considered in the analysis.</p>	<p>Revise to read: "Repair and refurbishment costs are considered for recoverable accidents only not considered for severe accidents."</p> <p>Basis for Change: Clarification</p>
322	F-33/28 and 29	<p>Section states, "...also referred to as the Modified Maximum Averted Cost Risk (MMACR)." This qualifying statement is not necessary since the ER and DSEIS do not use the term MMACR. Recommend deletion.</p>	<p>Revise to read: "...external event severe accident risk at CNS-1, also referred to as the Modified Maximum Averted Cost Risk (MMACR)."</p> <p>Basis for Change: Clarification</p>

Comment No.	Page Number/ Line Number	Comment	Suggested Resolution
323	F-35/36 and 37	<p>Section states that the NRC "requested that NPPD reassess whether or not SAMA 13 would be cost-beneficial if it were to use the same portable generator as for SAMA 14, which was determined to be cost beneficial (NRC, 2009). In response, NPPD stated that since the SAMA submittal, SAMA 13 has been implemented at CNS-1 (NPPD, 2009a)."</p> <p>As stated, it sounds like NPPD did not address the question. However, in the RAI response, NPPD also stated that the available skid mounted portable power supply considered in the cost estimate for SAMA 14 was not sufficient to supply the battery chargers as proposed in SAMA 13. No DSEIS change needed.</p>	
324	F-38/1 and 2	Missouri State Emergency Management Agency (1991) is not referenced in the Section F discussion. It appears to be related to Page F-12/Lines 10 and 11.	
325	F-38/3 and 4	Nebraska Civil Defense Agency (1993) is not referenced in the Section F discussion.	
326	F-38/21	Add "ADAMS Accession No. ML091880319" for consistency with same reference on page 5-8 (line 30).	
327	F-39/21-23	NRC 2002 is not referenced in the Section F discussion.	

Attachment 2
Proposed Revision to Section 2.1.6 of the
Draft Generic Environmental Impact Statement Supplement 41

During the course of reviewing draft Supplement 41 to the Generic Environmental Impact Statement, the Nebraska Public Power District identified an extensive number of comments for Section 2.1.6, "Cooling and Auxiliary Water Systems." These comments included: a) the need to incorporate Environmental Report changes from NLS2009036, b) the need to clarify the U.S. Army Corps of Engineers Missouri River flow regulation, and c) to reorganize the paragraphs in a more topical manner. As this section describes one of the key environmental interfaces of Cooper Nuclear Station, an underline/strikeout version of this section has been generated for the Nuclear Regulatory Commission's consideration.

2.1.6 Cooling and Auxiliary Water Systems

CNS-4 lies on the western shore of the Missouri River, withdraws river water for its once through cooling system, and discharges heated water back to the river. Unless otherwise cited, NRC staff drew information about CNS-4's cooling and auxiliary water systems from NPPD(2006c) and the applicant's ER. Under the present flow regulation, a minimum Nebraska City flow of 31,000 cfs (878 m³/sec) is maintained for navigational purposes beginning in March and extending through November. In the vicinity of the plant, the Missouri River has a regulated minimum flow of 31,000 cubic feet per second (cfs) (878 cubic meters per second (m³/sec)) to the southeast. During the winter months, the winter flow in recent years has routinely been maintained at approximately 6,000 cfs (170 m³/sec) or greater. Since the establishment of present flow regulation, the lowest flow at Nebraska City to date (16 year record) was 4,320 cfs (122 m³/sec) in January 1957, which is also the minimum regulated flow by the U.S. Army Corps of Engineers. [see Attachment 3, Change 1] Should a prolonged drought occur such that water is not available to maintain the above required flows, the navigational season will be shortened so that the minimum sanitary flows can always be maintained, if needed. The annual mean river flow is 38,251 cfs (1,083 m³/sec)(1930-2001) at the United States Geological Survey (USGS) gauging station at Nebraska City, Nebraska, which is located approximately 30 river miles north of CNS (NPPD 2008a).

The circulating water intake structure is located on the western shore of the river behind a guide wall and submerged weir meant to reduce the amount of suspended sediment in the cooling water. The weir attaches to shoreline structures north of the intake and then runs parallel to the face of the intake at a distance of 14.25 feet (4.3 m). The wall continues past the intake and ends approximately 40 feet (12 m) downstream of the downstream corner of the intake structure. In a line riverward of the weir wall and extending downstream of it, 23 sheet pile vanes (10 ft wide by 6 ft high, 3 m wide by 2 m high) oriented at a 22 degree angle to the weir redirect sand and gravel outward from the weir and the intake structure. After flowing generally south along the weir and vanes, river water must reverse course and turn northwest to move between the weir and shore and reach the intake bays. An array of 20 submerged flow turning vanes has been installed east of the guide wall in the river channel. Each vane is constructed of steel sheet piling and driven into the river bed to a top elevation below barge navigation depth. The vane array functions to induce scouring of the river bed adjacent to the guide wall to prevent sediment accumulation. The prevention of sediment accumulations increases the effectiveness of the guide wall. River water flows over the weir wall leaving heavier sediment on the river side of the wall. Water velocity between the weir wall and the cooling water intake structure is approximately about 4 ft/sec (1.2 m/sec).

In winter, about 25 to 30 percent of main condenser discharge water recirculates through an ice control tunnel at the front of the intake structure and discharges in front of the trash rack to prevent icing. Water flows beneath a curtain wall at about 1.1 ft/sec (0.3 m/sec). Water enters the five intake bays, four of which provide circulating water and are 22 feet (6.7 m) wide and one of which provides service water and is 22.5 feet (6.8 m) wide. The incoming water then flows through trash racks, 3/8 inch (1.0 cm) vertical bars separated 3 inches (7.6 cm) on center, at up to 0.7 ft/sec (20 cm/sec). Water for the facility is drawn through five intake bays. Four of these bays provide circulating water to the generating unit while the other is used for service water. Each circulating water intake bay splits into two screen bays, while the service water intake bay narrows to a smaller screen bay. These bays are 9.7 feet (3 m) in length by 5.6 feet (1.7 m) wide, providing space for 4.2 feet (1.3 m) wide dual flow screens. Each bay is fitted with modified dual flow traveling screens designed with fish collection baskets. The modified dual flow screens operate at 90 degrees to the water flow. Four circulating water pumps provide the circulating water for the facility. Each pump can draw 159,000 gpm (10 m³/sec). The pump design water level is at El. 875.0 ft, with a minimum submergence level at El. 865.0 ft. There are four service water pumps providing a combined flow of 32,000 gpm (2 m³/sec). Velocities in the intake structure are 1.1 ft/sec (0.3 m/sec) under the curtain wall, 0.7 ft/sec (20 cm/sec) at the trash racks, and approximately 2.0 ft/sec (0.6 m/sec) at the traveling water screens. These velocities were calculated at low water levels (El. 874.5 ft) and maximum circulating water pump flow (159,000 gpm (10 m³/sec) per pump). Fish and debris are currently collected on both the ascending and descending sides of the dual-flow screen, which allows only filtered water to pass downstream to the pumps. Fish and debris are removed by a high pressure screen wash system and conveyed back to the river. Modified dual-flow traveling screens were installed in 2006 to address debris carry-over problems encountered with the original flow-through traveling screens. (NPPD 2008a)

The circulating water intake bays each separate into two screen bays and the service water intake bay narrows before water encounters the traveling screens, which are oriented at right angles to the flow. Water filters twice through nine 1/8 by 1/2 in. (.3 cm by 1.3 cm) smooth top mesh modified dual flow traveling screens (eight for circulating water and one for service water). The upward pass is in the front and the downward pass is behind the screens, that rotate continuously at 8.2 ft/min (2.5 m/min). The intake water velocity at the screens is about 2 ft/sec (0.6 m/sec).

Each circulating water screen has 1/8 by 1/2 in. (0.3 cm by 1.3 cm) smooth top mesh. The service water screen has 0.2-in. (5 mm) perforated plastic mesh. Each screen has a high and low speed, but is normally rotated continuously at the slow 8.2 ft/min (2.5m/min) speed to prevent excess debris build up. A high pressure screen backwash system providing 3,000 gpm (0.19 m³/sec) at 30-60 psig (207-414 kPa) is used to remove fish and debris from the screens. Water for the screenwash is drawn from the service water pumps. Fish and debris flushed from the screens are returned to the river via an 18 in. (0.46 m) steel pipe. This steel pipe discharges downstream from the intake. The existing screen wash system does not have the capacity to provide the required flow to support both a low pressure fish protection spray system and the high pressure debris removal system nor is there a separate fish return trough and conveyance system to return fish back to the river. (NPPD 2008a) Figure 2.1.6-1, Figure 2.1.6-2, and Figure 2.1.6-3 show the CNS intake structures. After the 4.2-ft (1.28-m) wide traveling screen panels rotate over the upper cog and begin moving down, a high pressure (30-60 psig, 200-400 kPa) screen wash of 3000 gallons per minute (gpm) (0.19 m³/sec) supplied by the service water pumps removes fish and debris, which return together to the river through an 18-in (0.46-m) diameter steel pipe that discharges downstream from the intake. Although the screens are fitted with fish baskets, the system has neither a low pressure spray system to more gently remove

~~fish from the screens nor a fish return trough to convey fish and other aquatic organisms back to the river separately from potentially damaging debris. Debris loads are approximately about 10 cubic yards per month (8 m³/month).~~

In winter, some of the main condenser discharge (about 25 to 30 percent) recirculates through an ice control tunnel at the front of the intake structure and discharges in front of the trash rack to prevent icing.

~~CNS-1NPPD plans to install "dual flow conversion screen a fish handling and return systems to mitigate the effects of impingement." during its current operational term. This system will have low pressure (5 to 10 psi, 35-70 kPa) fish washing sprays on both the ascending and descending screens and a fish return trough that is separate from the debris trough. A recovery basket will collect fish and other aquatic organisms washed from the screens, and the fish trough will return them to the river. The final design and implementation of the fish handling system are dependent upon the requirements of the final Phase II 316(b) Clean Water Act amended regulations. Figure 2.1.6-1, Figure 2.1.6-2, and Figure 2.1.6-3 show the CNS-1 intake structures. [See Attachment 3, Changes 2, 4, 5, 6, 7, 8, 9, 10, and 11]~~

~~After water passes through the traveling screens, the two screen bays of each intake bay rejoin behind the screens. The four circulating water pumps, one per bay, draw water from the bays and provide up to 159,000 gpm (10 m³/sec) each. The four service water pumps in the fifth bay provide a combined flow of 32,000 gpm (2 m³/sec). Water from the circulating water pumps travels to and circulates through the condenser, where it cools steam from the turbines. Because of the scouring from the suspended sediment, CNS-1 typically does is not need required to chlorinate the circulating water to control biological film fouling, although it has the capacity to chlorinate or brominate if needed. NPPD is studying the effectiveness of these options. [See Attachment 3, Change 3] Water temperature increases approximately about 17.8°F (10°C) as it passes through the condenser tubes. From the condenser, circulating cooling water flows through concrete tunnels to a seal well structure and then to the discharge canal, where it travels about 1,000 feet (300 m) to discharge to the river at a slight angle. Water velocity at the discharge is about 1 ft/sec (0.3 m/sec) at average river flow and about 5.6 ft/sec (1.7 m/sec) during low flows. The travel time from the intake structure to the discharge is about 20 minutes at high river flow and 10 to 12 minutes at low flow. From the seal well and gate control structure, the water is directed into a discharge canal that is approximately 1,000 ft (305 m) long; it then enters the river at a slight angle. The velocity of discharge is about 1 fps (0.03 m³/sec) during average water levels of 879.4 ft and 35,000 cfs (991 m³/sec) river flow, and increases to about 2.5 fps as the river water surface elevation is reduced to 874.5 ft and flows near 11,000 cfs (311 m³/sec) which is the nominal control low maintained by the USACE below the confluence of the Platte River. Travel times in the pump house-condenser-canal system will be approximately 20 minutes at high flow and 10 to 12 minutes at lower river flows. Stone rip-rap is used to prevent scours in the vicinity of the discharge structure.~~

~~Cooling water flow demand varies with electrical load plant power and ambient river water temperature. At full load during summer, the expected circulating water system flow is highest: about 636,000 gpm (40 m³/sec). Lower cCirculating water flow is lower required under other lower river temperature conditions. In comparison, the lowest river flow at CNS-1 is about 3,000 cfs. Under the worst conditions, the circulating water system flow would be about 47 percent of Missouri River flow. Stone riprap at the discharge structure prevents the discharge from eroding the river bottom. The annual mean river flow is 38,251 cfs (1,083 m³/sec) (1930-2001) at the United States Geological Survey (USGS) gauging station at Nebraska City, Nebraska, approximately 30 river miles north of CNS (NPPD 2008a). The CNS maximum circulating water~~

withdrawal represents less than 4 percent of the average annual Missouri River flow. While the percentage of river flow withdrawn by CNS may be higher during winter, the withdrawal is significantly less than in summer, and occurs at a time when impacts due to entrainment of fish eggs and larval fish are non-existent or minimal.

Attachment 3 Changes to the License Renewal Application Environmental Report

As a result of reviewing the draft Supplement 41 to the Generic Environmental Impact Statement, the Nebraska Public Power District identified certain corrections/enhancements to the License Renewal Application Environmental Report. They are presented in underline/ strikeout format.

- (1) Page 2-10, 1st paragraph is revised to read:

"During the winter months, a minimum regulated flow of 3,000 4,320 cfs is maintained ~~required~~ at Nebraska City ~~for sanitary purposes~~; however, the actual winter flow in recent years has been maintained at 6,000 cfs or more."

Reference: Correction based on USACE Master Manual.

- (2) Page 3-4, second paragraph is revised to read:

"However, CNS is planning to augment its existing intake structure design with a dual flow conversion screen fish handling and return systems ~~during the current operational term to mitigate the effects of fish impingement~~. The system currently being considered is the Brackett Green USA, Inc. Fish Handling Screen with the Advanced S.I.M.P.L.E. Process. ~~This possible modification to the intake structure would involve the installation of inside and outside fish sprays which operate between 5-10 psi and a separate fish return trough. As raw water would pass through the existing fish baskets, floating and suspended debris larger than the mesh opening of the existing dual flow screens would be retained on the upstream side of the mesh and juvenile marine life would be captured in the hydraulically stabilized fish recovery basket. The recovered fish would then be discharged on the descending side with aid from the inside and outside fish sprays into a fish trough located above the debris trough. [Brackett]~~ The CNS implementation date and the final design of the fish handling system are dependent upon the content of the final 316(b) Clean Water Act requirements."

Reference: Clarification. It is expected that the final design will be at least as robust as currently described.

- (3) Page 3-4, last paragraph, Page 3-5, 1st paragraph is revised to read:

"Chlorination is typically not required because of the inherent scouring action of the sandy river water. However, a connection is provided for such a system in the event should it's be found necessary potentially needed in the future. The chlorination system connection is located on the common inlet to Screen Wash Pump A and B from the service water system. [NPPD 2008, Section XI-6.3]. Bacteria that occur naturally in the Missouri River may contribute to the growth of biological film fouling of the main condenser tubes. ~~The station is proceeding with a study to determine if routine chemical injection (chlorine, bromine, etc.) will be effective in eliminating the microbiological film on the interior walls of the condenser tubes.~~"

Reference: NPPD has completed the chlorination study and has determined that application of up to twice per year can be effective in optimizing thermal performance.

- (4) Page 4-10, 1st paragraph is revised to read:

"However as discussed in Section 3.2.2, CNS has already installed dual flow conversion screens that are equipped with fish baskets and is planning on installing a fish handling and return system to mitigate the effects of fish impingement consisting of inside and outside fish sprays and a separate fish return trough prior to the end of the current operational term. The CNS implementation date and the final design of the fish handling system are dependent upon the content of the final 316(b) Clean Water Act requirements."

Reference: Clarification. It is expected that the final design will be at least as robust as currently described.

- (5) Page 4-11, 4th paragraph is revised to read:

"However, as discussed in Section 3.2.2, CNS is planning to install a fish handling and return system to mitigate the effects of fish impingement consisting of inside and outside fish sprays and separate fish return trough prior to the end of the current operational term. The CNS implementation date and the final design of the fish handling system are dependent upon the content of the final 316(b) Clean Water Act requirements."

Reference: Clarification. It is expected that the final design will be at least as robust as currently described.

- (6) Page 4-21, 1st paragraph is revised to read:

"However as discussed in Section 3.2.2, CNS is planning to install a fish handling and return system to mitigate the effects of fish impingement consisting of inside and outside fish sprays and a separate fish return trough prior to the end of the current operational term. The CNS implementation date and the final design of the fish handling system are dependent upon the content of the final 316(b) Clean Water Act requirements."

Reference: Clarification. It is expected that the final design will be at least as robust as currently described.

- (7) Page 4-23, 1st paragraph is revised to read:

"However as discussed in Section 3.2.2, CNS is planning to install a fish handling and return system consisting of inside and outside fish sprays and a separate fish return trough prior to the end of the current operational term. This change to the CWIS design would most likely be considered Best Technology Available for minimizing impingement impacts. The CNS implementation date and the final design of the fish handling system are dependent upon the content of the final 316(b) Clean Water Act requirements."

Reference: Clarification. It is expected that the final design will be at least as robust as currently described.

- (8) Page 4-28, 4th paragraph is revised to read:

"Although NDEQ had already determined that the cooling water intake impacts were probably minimal at CNS, NPPD is planning to install a fish handling and

~~return system consisting of inside and outside fish sprays and a separate fish return trough during the current operational term. This change to the existing design of the CWIS (Ristroph screens) would most likely be considered Best Technology Available for minimizing impingement impacts. The CNS implementation date and the final design of the fish handling system are dependent upon the content of the final 316(b) Clean Water Act requirements.~~

Reference: Clarification. It is expected that the final design will be at least as robust as currently described.

- (9) Page 4-28, last paragraph, and 4-29, 1st paragraph is revised to read:

"NPPD is planning to install a fish handling and return system at CNS, consisting of inside and outside fish sprays and a separate fish return trough to the existing design of the CWIS (Ristroph screens). This change to the CWIS would most likely be considered Best Technology Available as it relates to minimizing impingement impacts. The CNS implementation date and the final design of the fish handling system are dependent upon the content of the final 316(b) Clean Water Act requirements. In addition, even though current impingement impacts are minimal, impacts during the license renewal period would be even smaller due to this CWIS design change. Therefore In summary, NPPD concludes the impact due to impingement of fish and shellfish in the Missouri River is SMALL and mitigation measures are not warranted."

Reference: Clarification. It is expected that the final design will be at least as robust as currently described.

- (10) Page 4-4-93, 3rd paragraph is revised to read:

"NPPD is planning to install a fish handling and return system consisting of inside and outside fish sprays and a separate fish return trough to the existing design of the CWIS (Ristroph screens). This change to the CWIS would most likely be considered Best Technology Available as it relates to minimizing impingement impacts. The CNS implementation date and the final design of the fish handling system are dependent upon the content of the final 316(b) Clean Water Act requirements. Therefore In summary, NPPD concludes the cumulative impact due to impingement of fish and shellfish in the Missouri River is SMALL and mitigation measures are not warranted."

Reference: Clarification. It is expected that the final design will be at least as robust as currently described.

- (11) Page 6-2, "Impinge of fish and shellfish [10 CFR 51.53(c)(3)(ii)(B)]" is revised to read:

"**SMALL.** Missouri River studies and previous agency determinations identify factors (i.e., river and tributary dams, channelization and other habitat management, invasive aquatic species) other than impingement as being the primary cause of direct and cumulative impacts to the fish populations. CNS is also planning to install a fish handling and return system ~~consisting of inside and outside fish sprays and a separate fish return trough to the existing CWIS design (Ristroph screens)~~ which would most likely be considered Best Technology Available. The CNS implementation date and the final design of the fish handling system are dependent upon the content of the final 316(b) Clean Water Act

~~requirements. Therefore~~ In summary, NPPD concludes the impact from plant operations due to impingement of fish and shellfish in the Missouri River is SMALL. Further consideration of mitigation measures is not warranted."

Reference: Clarification. It is expected that the final design will be at least as robust as currently described.

- (12) Page 9-4, Table 9.2-1, delete entry 7, "CNS Radioactive Waste Transport Permit No. 0218-26-08-X."

Reference: NPPD is no longer authorized to ship radwaste under this permit.

- (13) Page 9-5, Table 9.2-1, revise entry 1, "CNS Radioactive Waste License for Delivery No. T-NE002-L08 expiration date from "December 31, 2008" to "January 3, 2011."

Reference: Letter from M. Singleton (Tennessee Department of Environment and Conservation) to J. Kuttler (NPPD), dated November 24, 2009, "Radioactive Waste License-for-Delivery."

- (14) Page 9-5, Table 9.2-1, revise entry 2, "Generator Site Access Permit No. 0111000042 expiration date from "January 3, 2009" to "January 3, 2011."

Reference: Letter from D. Finerfrock (Utah Department of Environmental Quality) to J. Kuttler (NPPD), dated November 24, 2009, "Generator Site Access Permit Number 0111000042."

**APPENDIX B.
NATIONAL ENVIRONMENTAL POLICY ACT ISSUES FOR
LICENSE RENEWAL OF NUCLEAR POWER PLANTS**

B. NATIONAL ENVIRONMENTAL POLICY ACT ISSUES FOR LICENSE RENEWAL OF NUCLEAR POWER PLANTS

Table B-1. Summary of Issues and Findings. *This table is taken from Table B-1 in Appendix B, Subpart A, to Title 10 of the Code of Federal Regulations (CFR) Part 51. Data supporting this table are contained in NUREG-1437, Generic Environmental Impact Statement for License Renewal of Nuclear Plants. Throughout this report, "Generic" issues are also referred to as Category 1 issues, and "Site-specific" issues are also referred to as Category 2 issues.*

Issue	Type of Issue	Finding
Surface Water Quality, Hydrology, and Use		
Impacts of refurbishment on surface water quality	Generic	SMALL. Impacts are expected to be negligible during refurbishment because best management practices are expected to be employed to control soil erosion and spills.
Impacts of refurbishment on surface water use	Generic	SMALL. Water use during refurbishment will not increase appreciably or will be reduced during plant outage.
Altered current patterns at intake and discharge structures	Generic	SMALL. Altered current patterns have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Altered salinity gradients	Generic	SMALL. Salinity gradients have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Altered thermal stratification of lakes	Generic	SMALL. Generally, lake stratification has not been found to be a problem at operating nuclear power plants and is not expected to be a problem during the license renewal term.
Temperature effects on sediment transport capacity	Generic	SMALL. These effects have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Scouring caused by discharged cooling water	Generic	SMALL. Scouring has not been found to be a problem at most operating nuclear power plants and has caused only localized effects at a few plants. It is not expected to be a problem during the license renewal term.
Eutrophication	Generic	SMALL. Eutrophication has not been found to be a problem at operating nuclear power plants and is not expected to be a problem during the license renewal term.
Discharge of chlorine or other biocides	Generic	SMALL. Effects are not a concern among regulatory and resource agencies, and are not expected to be a problem during the license renewal term.
Discharge of sanitary wastes and minor chemical spills	Generic	SMALL. Effects are readily controlled through National Pollutant Discharge Elimination System (NPDES) permit and periodic modifications, if needed, and are not expected to be a problem during the license renewal term.
Discharge of other metals in wastewater	Generic	SMALL. These discharges have not been found to be a problem at operating nuclear power plants with cooling-tower-based heat dissipation systems and have been satisfactorily mitigated at other plants. They are not expected to be a problem during the license renewal term.

Appendix B

Issue	Type of Issue	Finding
Water use conflicts (plants with once-through cooling systems)	Generic	SMALL. These conflicts have not been found to be a problem at operating nuclear power plants with once-through heat dissipation systems.
Water use conflicts (plants with cooling ponds or cooling towers using makeup water from a small river with low flow)	Site-specific	SMALL OR MODERATE. The issue has been a concern at nuclear power plants with cooling ponds and at plants with cooling towers. Impacts on instream and riparian communities near these plants could be of moderate significance in some situations. See § 51.53(c)(3)(ii)(A).
Aquatic Ecology		
Refurbishment	Generic	SMALL. During plant shutdown and refurbishment, there will be negligible effects on aquatic biota because of a reduction of entrainment and impingement of organisms or a reduced release of chemicals.
Accumulation of contaminants in sediments or biota	Generic	SMALL. Accumulation of contaminants has been a concern at a few nuclear power plants but has been satisfactorily mitigated by replacing copper alloy condenser tubes with those of another metal. It is not expected to be a problem during the license renewal term.
Entrainment of phytoplankton and zooplankton	Generic	SMALL. Entrainment of phytoplankton and zooplankton has not been found to be a problem at operating nuclear power plants and is not expected to be a problem during the license renewal term.
Cold shock	Generic	SMALL. Cold shock has been satisfactorily mitigated at operating nuclear plants with once-through cooling systems, has not endangered fish populations, or been found to be a problem at operating nuclear power plants with cooling towers or cooling ponds, and is not expected to be a problem during the license renewal term.
Thermal plume barrier to migrating fish	Generic	SMALL. Thermal plumes have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Distribution of aquatic organisms	Generic	SMALL. Thermal discharge may have localized effects but is not expected to affect the larger geographical distribution of aquatic organisms.
Premature emergence of aquatic insects	Generic	SMALL. Premature emergence has been found to be a localized effect at some operating nuclear power plants but has not been a problem and is not expected to be a problem during the license renewal term.
Gas supersaturation (gas bubble disease)	Generic	SMALL. Gas supersaturation was a concern at a small number of operating nuclear power plants with once-through cooling systems but has been satisfactorily mitigated. It has not been found to be a problem at operating nuclear power plants with cooling towers or cooling ponds and is not expected to be a problem during the license renewal term.
Low dissolved oxygen in the discharge	Generic	SMALL. Low dissolved oxygen has been a concern at one nuclear power plant with a once-through cooling system but has been effectively mitigated. It has not been found to be a problem at operating nuclear power plants with cooling towers or cooling ponds and is not expected to be a problem during the license renewal term.

Issue	Type of Issue	Finding
Losses from predation, parasitism, and disease among organisms exposed to sublethal stresses	Generic	SMALL. These types of losses have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Stimulation of nuisance organisms (e.g., shipworms)	Generic	SMALL. Stimulation of nuisance organisms has been satisfactorily mitigated at the single nuclear power plant with a once-through cooling system where previously it was a problem. It has not been found to be a problem at operating nuclear power plants with cooling towers or cooling ponds and is not expected to be a problem during the license renewal term.
Aquatic Ecology (for plants with once-through and cooling-pond heat dissipation systems)		
Entrainment of fish and shellfish in early life stages	Site-specific	SMALL, MODERATE, OR LARGE. The impacts of entrainment are small at many plants but may be moderate or even large at a few plants with once-through and cooling-pond cooling systems. Further, ongoing efforts in the vicinity of these plants to restore fish populations may increase the numbers of fish susceptible to intake effects during the license renewal period, such that entrainment studies conducted in support of the original license may no longer be valid. See § 51.53(c)(3)(ii)(B).
Impingement of fish and shellfish	Site-specific	SMALL, MODERATE, OR LARGE. The impacts of impingement are small at many plants but may be moderate or even large at a few plants with once-through and cooling-pond cooling systems. See § 51.53(c)(3)(ii)(B).
Heat shock	Site-specific	SMALL, MODERATE, OR LARGE. Because of continuing concerns about heat shock and the possible need to modify thermal discharges in response to changing environmental conditions, the impacts may be of moderate or large significance at some plants. See § 51.53(c)(3)(ii)(B).
Aquatic Ecology (for plants with cooling-tower-based heat dissipation systems)		
Entrainment of fish and shellfish in early life stages	Generic	SMALL. Entrainment of fish has not been found to be a problem at operating nuclear power plants with this type of cooling system and is not expected to be a problem during the license renewal term.
Impingement of fish and shellfish	Generic	SMALL. The impingement has not been found to be a problem at operating nuclear power plants with this type of cooling system and is not expected to be a problem during the license renewal term.
Heat shock	Generic	SMALL. Heat shock has not been found to be a problem at operating nuclear power plants with this type of cooling system and is not expected to be a problem during the license renewal term.
Ground Water Use and Quality		
Impacts of refurbishment on ground water use and quality	Generic	SMALL. Extensive dewatering during the original construction on some sites will not be repeated during refurbishment on any sites. Any plant wastes produced during refurbishment will be handled in the same manner as in current operating practices and are not expected to be a problem during the license renewal term.

Appendix B

Issue	Type of Issue	Finding
Ground water use conflicts (potable and service water; plants that use <100 gallons per minute (gpm))	Generic	SMALL. Plants using less than 100 gpm are not expected to cause any ground water use conflicts.
Ground water use conflicts (potable and service water, and dewatering plants that use >100 gpm)	Site-specific	SMALL, MODERATE, OR LARGE. Plants that use more than 100 gpm may cause ground water use conflicts with nearby ground water users. See § 51.53(c)(3)(ii)(C).
Ground water use conflicts (plants using cooling towers withdrawing makeup water from a small river)	Site-specific	SMALL, MODERATE, OR LARGE. Water use conflicts may result from surface water withdrawals from small water bodies during low flow conditions which may affect aquifer recharge, especially if other ground water or upstream surface water users come online before the time of license renewal. See § 51.53(c)(3)(ii)(A).
Ground water use conflicts (Ranney wells)	Site-specific	SMALL, MODERATE, OR LARGE. Ranney wells can result in potential ground water depression beyond the site boundary. Impacts of large ground water withdrawal for cooling tower makeup at nuclear power plants using Ranney wells must be evaluated at the time of application for license renewal. See § 51.53(c)(3)(ii)(C).
Ground water quality degradation (Ranney wells)	Generic	SMALL. Ground water quality at river sites may be degraded by induced infiltration of poor-quality river water into an aquifer that supplies large quantities of reactor cooling water. However, the lower quality infiltrating water would not preclude the current uses of ground water and is not expected to be a problem during the license renewal term.
Ground water quality degradation (saltwater intrusion)	Generic	SMALL. Nuclear power plants do not contribute significantly to saltwater intrusion.
Ground water quality degradation (cooling ponds in salt marshes)	Generic	SMALL. Sites with closed-cycle cooling ponds may degrade ground water quality. Because water in salt marshes is brackish, this is not a concern for plants located in salt marshes.
Ground water quality degradation (cooling ponds at inland sites)	Site-specific	SMALL, MODERATE, OR LARGE. Sites with closed-cycle cooling ponds may degrade ground water quality. For plants located inland, the quality of the ground water in the vicinity of the ponds must be shown to be adequate to allow continuation of current uses. See § 51.53(c)(3)(ii)(D).
Terrestrial Ecology		
Refurbishment impacts	Site-specific	SMALL, MODERATE, OR LARGE. Refurbishment impacts are insignificant if no loss of important plant and animal habitat occurs. However, it cannot be known whether important plant and animal communities may be affected until the specific proposal is presented with the license renewal application. See § 51.53(c)(3)(ii)(E).
Cooling tower impacts on crops and ornamental vegetation	Generic	SMALL. Impacts from salt drift, icing, fogging, or increased humidity associated with cooling tower operation have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.

Issue	Type of Issue	Finding
Cooling tower impacts on native plants	Generic	SMALL. Impacts from salt drift, icing, fogging, or increased humidity associated with cooling tower operation have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Bird collisions with cooling towers	Generic	SMALL. These collisions have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Cooling pond impacts on terrestrial resources	Generic	SMALL. Impacts of cooling ponds on terrestrial ecological resources are considered to be of small significance at all sites.
Power line right of way (ROW) management (cutting and herbicide application)	Generic	SMALL. The impacts of ROW maintenance on wildlife are expected to be of small significance at all sites.
Bird collisions with power lines	Generic	SMALL. Impacts are expected to be of small significance at all sites.
Impacts of electromagnetic fields on flora and fauna	Generic	SMALL. No significant impacts of electromagnetic fields on terrestrial flora and fauna have been identified. Such effects are not expected to be a problem during the license renewal term.
Floodplains and wetland on power line ROW	Generic	SMALL. Periodic vegetation control is necessary in forested wetlands underneath power lines and can be achieved with minimal damage to the wetland. No significant impact is expected at any nuclear power plant during the license renewal term.
Threatened and Endangered Species		
Threatened or endangered species	Site-specific	SMALL, MODERATE, OR LARGE. Generally, plant refurbishment and continued operation are not expected to adversely affect threatened or endangered species. However, consultation with appropriate agencies would be needed at the time of license renewal to determine whether or not threatened or endangered species are present and whether or not they would be adversely affected. See § 51.53(c)(3)(ii)(E).
Air Quality		
Air quality during refurbishment (non-attainment and maintenance areas)	Site-specific	SMALL, MODERATE, OR LARGE. Air quality impacts from plant refurbishment associated with license renewal are expected to be small. However, vehicle exhaust emissions could be cause for concern at locations in or near nonattainment or maintenance areas. The significance of the potential impact cannot be determined without considering the compliance status of each site and the number of workers expected to be employed during the outage. See § 51.53(c)(3)(ii)(F).
Air quality effects of transmission lines	Generic	SMALL. Production of ozone and oxides of nitrogen is insignificant and does not contribute measurably to ambient levels of these gases.
Land Use		
Onsite land use	Generic	SMALL. Projected onsite land use changes required during refurbishment and the renewal period would be a small fraction of any nuclear power plant site and would involve land that is controlled by the applicant.
Power line ROW	Generic	SMALL. Ongoing use of power line ROWs would continue with no change in restrictions. The effects of these restrictions are of small significance.

Appendix B

Issue	Type of Issue	Finding
Human Health		
Radiation exposures to the public during refurbishment	Generic	SMALL. During refurbishment, the gaseous effluents would result in doses that are similar to those from current operation. Applicable regulatory dose limits to the public are not expected to be exceeded.
Occupational radiation exposures during refurbishment	Generic	SMALL. Occupational doses from refurbishment are expected to be within the range of annual average collective doses experienced for pressurized-water reactors and boiling-water reactors. Occupational mortality risk from all causes including radiation is in the mid-range for industrial settings.
Microbiological organisms (occupational health)	Generic	SMALL. Occupational health impacts are expected to be controlled by continued application of accepted industrial hygiene practices to minimize exposure to workers.
Microbiological organisms (public health)(plants using lakes or canals, or cooling towers or cooling ponds that discharge to a small river)	Site-specific	SMALL, MODERATE, OR LARGE. These organisms are not expected to be a problem at most operating plants except possibly at plants using cooling ponds, lakes, or canals that discharge to small rivers. Without site-specific data, it is not possible to predict the effects generically. See § 51.53(c)(3)(ii)(G).
Noise	Generic	SMALL. Noise has not been found to be a problem at operating plants and is not expected to be a problem at any plant during the license renewal term.
Electromagnetic fields – acute effects (electric shock)	Site-specific	SMALL, MODERATE, OR LARGE. Electrical shock resulting from direct access to energized conductors or from induced charges in metallic structures have not been found to be a problem at most operating plants and generally are not expected to be a problem during the license renewal term. However, site-specific review is required to determine the significance of the electric shock potential at the site. See § 51.53(c)(3)(ii)(H).
Electromagnetic fields – chronic effects	Uncategorized	UNCERTAIN. Biological and physical studies of 60-hertz (Hz) electromagnetic fields have not found consistent evidence linking harmful effects with field exposures. However, research is continuing in this area and a consensus scientific view has not been reached.
Radiation exposures to public (license renewal term)	Generic	SMALL. Radiation doses to the public will continue at current levels associated with normal operations.
Occupational radiation exposures (license renewal term)	Generic	SMALL. Projected maximum occupational doses during the license renewal term are within the range of doses experienced during normal operations and normal maintenance outages, and would be well below regulatory limits.
Socioeconomic Impacts		
Housing impacts	Site-specific	SMALL, MODERATE, OR LARGE. Housing impacts are expected to be of small significance at plants located in a medium or high population area and not in an area where growth control measures that limit housing development are in effect. Moderate or large housing impacts of the workforce associated with refurbishment may be associated with plants located in sparsely populated areas or in areas with growth control measures that limit housing development. See § 51.53(c)(3)(ii)(I).

Issue	Type of Issue	Finding
Public services: public safety, social services, and tourism and recreation	Generic	SMALL. Impacts to public safety, social services, and tourism and recreation are expected to be of small significance at all sites.
Public services: public utilities	Site-specific	SMALL OR MODERATE. An increased problem with water shortages at some sites may lead to impacts of moderate significance on public water supply availability. See § 51.53(c)(3)(ii)(I).
Public services: education (refurbishment)	Site-specific	SMALL, MODERATE, OR LARGE. Most sites would experience impacts of small significance but larger impacts are possible depending on site- and project-specific factors. See § 51.53(c)(3)(ii)(I).
Public services: education (license renewal term)	Generic	SMALL. Only impacts of small significance are expected.
Offsite land use (refurbishment)	Site-specific	SMALL OR MODERATE. Impacts may be of moderate significance at plants in low population areas. See § 51.53(c)(3)(ii)(I).
Offsite land use (license renewal term)	Site-specific	SMALL, MODERATE, OR LARGE. Significant changes in land use may be associated with population and tax revenue changes resulting from license renewal. See § 51.53(c)(3)(ii)(I).
Public services: transportation	Site-specific	SMALL, MODERATE, OR LARGE. Transportation impacts (level of service) of highway traffic generated during plant refurbishment and during the term of the renewed license are generally expected to be of small significance. However, the increase in traffic associated with the additional workers and the local road and traffic control conditions may lead to impacts of moderate or large significance at some sites. See § 51.53(c)(3)(ii)(J).
Historic and archaeological resources	Site-specific	SMALL, MODERATE, OR LARGE. Generally, plant refurbishment and continued operation are expected to have no more than small adverse impacts on historic and archaeological resources. However, the National Historic Preservation Act requires the Federal agency to consult with the State Historic Preservation Officer to determine whether or not there are properties present that require protection. See § 51.53(c)(3)(ii)(K).
Aesthetic impacts (refurbishment)	Generic	SMALL. No significant impacts are expected during refurbishment.
Aesthetic impacts (license renewal term)	Generic	SMALL. No significant impacts are expected during the license renewal term.
Aesthetic impacts of transmission lines (license renewal term)	Generic	SMALL. No significant impacts are expected during the license renewal term.
Postulated Accidents		
Design basis accidents	Generic	SMALL. The NRC staff has concluded that the environmental impacts of design-basis accidents are of small significance for all plants.
Severe accidents	Site-specific	SMALL. The probability weighted consequences of atmospheric releases, fallout onto open bodies of water, releases to ground water, and societal and economic impacts from severe accidents are small for all plants. However, alternatives to mitigate severe accidents must be considered for all plants that have not considered such alternatives. See § 51.53(c)(3)(ii)(L).

Appendix B

Issue	Type of Issue	Finding
Uranium Fuel Cycle and Waste Management		
Offsite radiological impacts (individual effects from other than the disposal of spent fuel and high level waste)	Generic	SMALL. Offsite impacts of the uranium fuel cycle have been considered by the Commission in Table S-3 of this part. Based on information in the GEIS, impacts on individuals from radioactive gaseous and liquid releases including radon-222 and technetium-99 are small.
Offsite radiological impacts (collective effects)	Generic	<p>The 100-year environmental dose commitment to the U.S. population from the fuel cycle, high level waste, and spent fuel disposal excepted, is calculated to be about 14,800 person rem, or 12 cancer fatalities, for each additional 20-year power reactor operating term. Much of this, especially the contribution of radon releases from mines and tailing piles, consists of tiny doses summed over large populations. This same dose calculation can theoretically be extended to include many tiny doses over additional thousands of years as well as doses outside the United States. The result of such a calculation would be thousands of cancer fatalities from the fuel cycle, but this result assumes that even tiny doses have some statistical adverse health effect which will not ever be mitigated (for example no cancer cure in the next thousand years), and that these doses projected over thousands of years are meaningful; however, these assumptions are questionable. In particular, science cannot rule out the possibility that there will be no cancer fatalities from these tiny doses. For perspective, the doses are very small fractions of regulatory limits, and even smaller fractions of natural background exposure to the same populations.</p> <p>Nevertheless, despite all the uncertainty, some judgment as to the regulatory NEPA implications of these matters should be made and it makes no sense to repeat the same judgment in every case. Even taking the uncertainties into account, the Commission concludes that these impacts are acceptable in that these impacts would not be sufficiently large to require the NEPA conclusion, for any plant, that the option of extended operation under 10 CFR Part 54 should be eliminated. Accordingly, while the Commission has not assigned a single level of significance for the collective effects of the fuel cycle, this issue is considered Category 1 (Generic).</p>

Issue	Type of Issue	Finding
Offsite radiological impacts (spent fuel and high level waste disposal)	Generic	<p>For the high level waste and spent fuel disposal component of the fuel cycle, there are no current regulatory limits for offsite releases of radionuclides for the current candidate repository site. However, if it is assumed that limits are developed along the lines of the 1995 National Academy of Sciences (NAS) report, "Technical Bases for Yucca Mountain Standards," and that in accordance with the Commission's Waste Confidence Decision, 10 CFR 51.23, a repository can and likely will be developed at some site which will comply with such limits, peak doses to virtually all individuals will be 100 millirem per year or less. However, while the Commission has reasonable confidence that these assumptions will prove correct, there is considerable uncertainty since the limits are yet to be developed, no repository application has been completed or reviewed, and uncertainty is inherent in the models used to evaluate possible pathways to the human environment. The NAS report indicated that 100 millirem per year should be considered as a starting point for limits for individual doses, but notes that some measure of consensus exists among national and international bodies that the limits should be a fraction of the 100 millirem per year. The lifetime individual risk from 100 millirem annual dose limit is about 3×10^{-3}.</p> <p>Estimating cumulative doses to populations over thousands of years is more problematic. The likelihood and consequences of events that could seriously compromise the integrity of a deep geologic repository were evaluated by the Department of Energy in the "Final Environmental Impact Statement: Management of Commercially Generated Radioactive Waste," October 1980. The evaluation estimated the 70-year whole-body dose commitment to the maximum individual and to the regional population resulting from several modes of breaching a reference repository in the year of closure, after 1,000 years, after 100,000 years, and after 100,000,000 years. Subsequently, the NRC and other federal agencies have expended considerable effort to develop models for the design and for the licensing of a high level waste repository, especially for the candidate repository at Yucca Mountain. More meaningful estimates of doses to population may be possible in the future as more is understood about the performance of the proposed Yucca Mountain repository. Such estimates would involve very great uncertainty, especially with respect to cumulative population doses over thousands of years. The standard proposed by the NAS is a limit on maximum individual dose. The relationship of potential new regulatory requirements, based on the NAS report, and cumulative population impacts has not been determined, although the report articulates the view that protection of individuals will adequately protect the population for a repository at Yucca Mountain. However, the EPA's generic repository standards in 40 CFR Part 191 generally provide an indication of the order of magnitude of cumulative risk to population that could result from the licensing of a Yucca Mountain repository, assuming the ultimate standards will be within the range of standards now under consideration. The standards in 40 CFR Part 191 protect the population by imposing the amount of radioactive material released over 10,000 years. The cumulative release limits are based on the EPA's population impact goal of 1,000 premature cancer deaths worldwide for a 100,000 metric ton (MT) repository. While the Commission has not assigned a single level of significance for the impacts of spent fuel and high level waste disposal, this issue is considered in Category 1 (Generic).</p>

Appendix B

Issue	Type of Issue	Finding
Nonradiological impacts of the uranium fuel cycle	Generic	SMALL. The nonradiological impacts of the uranium fuel cycle resulting from the renewal of an operating license for any plant are found to be small.
Low-level waste storage and disposal	Generic	SMALL. The comprehensive regulatory controls that are in place and the low public doses being achieved at reactors ensure that the radiological impacts to the environment will remain small during the term of a renewed license. The maximum additional onsite land that may be required for low-level waste storage during the term of a renewed license and associated impacts will be small. Nonradiological impacts on air and water will be negligible. The radiological and nonradiological environmental impacts of long-term disposal of low-level waste from any individual plant at licensed sites are small. In addition, the Commission concludes that there is reasonable assurance that sufficient low-level waste disposal capacity will be made available when needed for facilities to be decommissioned consistent with NRC decommissioning requirements.
Mixed waste storage and disposal	Generic	SMALL. The comprehensive regulatory controls and the facilities and procedures that are in place ensure proper handling and storage, as well as negligible doses and exposure to toxic materials for the public and the environment at all plants. License renewal will not increase the small, continuing risk to human health and the environment posed by mixed waste at all plants. The radiological and nonradiological environmental impacts of long-term disposal of mixed waste from any individual plant at licensed sites are small. In addition, the Commission concludes that there is reasonable assurance that sufficient mixed waste disposal capacity will be made available when needed for facilities to be decommissioned consistent with NRC decommissioning requirements.
Onsite spent fuel	Generic	SMALL. The expected increase in the volume of spent fuel from an additional 20 years of operation can be safely accommodated on site with small environmental effects through dry or pool storage at all plants if a permanent repository or monitored retrievable storage is not available.
Nonradiological waste	Generic	SMALL. No changes to generating systems are anticipated for license renewal. Facilities and procedures are in place to ensure continued proper handling and disposal at all plants.
Transportation	Generic	SMALL. The impacts of transporting spent fuel enriched up to 5 percent uranium-235 with average burnup for the peak rod to current levels approved by NRC up to 62,000 megawatt days per metric-ton uranium Wd/MTU)and the cumulative impacts of transporting high-level waste to a single repository, such as Yucca Mountain, Nevada are found to be consistent with the impact values contained in 10 CFR 51.52(c), Summary Table S-4 – Environmental Impact of Transportation of Fuel and Waste to and from One Light-Water-Cooled Nuclear Power Reactor. If fuel enrichment or burnup conditions are not met, the applicant must submit an assessment of the implications for the environmental impact values reported in § 51.52.

Issue	Type of Issue	Finding
Decommissioning		
Radiation doses	Generic	SMALL. Doses to the public will be well below applicable regulatory standards regardless of which decommissioning method is used. Occupational doses would increase no more than 1 man-rem caused by buildup of long-lived radionuclides during the license renewal term.
Waste management	Generic	SMALL. Decommissioning at the end of a 20-year license renewal period would generate no more solid wastes than at the end of the current license term. No increase in the quantities of Class C or greater than Class C wastes would be expected.
Air quality	Generic	SMALL. Air quality impacts of decommissioning are expected to be negligible either at the end of the current operating term or at the end of the license renewal term.
Water quality	Generic	SMALL. The potential for significant water quality impacts from erosion or spills is no greater whether decommissioning occurs after a 20-year license renewal period or after the original 40-year operation period, and measures are readily available to avoid such impacts.
Ecological resources	Generic	SMALL. Decommissioning after either the initial operating period or after a 20-year license renewal period is not expected to have any direct ecological impacts.
Socioeconomic impacts	Generic	SMALL. Decommissioning would have some short-term socioeconomic impacts. The impacts would not be increased by delaying decommissioning until the end of a 20-year relicensing period, but they might be decreased by population and economic growth.
Environmental Justice		
Environmental justice	Uncategorized	NONE. The need for and the content of an analysis of environmental justice will be addressed in plant-specific reviews.

**APPENDIX C.
APPLICABLE REGULATIONS, LAWS, AND AGREEMENTS**

C. APPLICABLE REGULATIONS, LAWS, AND AGREEMENTS

The Atomic Energy Act (42 USC § 2021) authorizes the U.S. Nuclear Regulatory Commission (NRC) to enter into agreement with any State to assume regulatory authority for certain activities. For example, through the Agreement State Program, Nebraska assumed regulatory responsibility over certain byproduct, source, and small quantities of special nuclear material. The Nebraska Agreement State Program is administered by the Radiation Control Program (the program) in the Department of Health. The Program Manager reports to the Section Administrator for Consumer Health Services, who reports to the Division Director for Public Health Assurance, who in turn reports to the Director of Regulation and Licensure.

In addition to implementing some Federal programs, State legislatures develop their own laws. State statutes supplement as well as implement Federal laws for protection of air, water quality, and ground water. State legislation may address solid waste management programs, locally rare or endangered species, and historic and cultural resources.

The Clean Water Act (CWA) allows for primary enforcement and administration through State agencies, provided the State program is at least as stringent as the Federal program. The State program must conform to the CWA and to the delegation of authority for the Federal National Pollutant Discharge Elimination System (NPDES) program from the Environmental Protection Agency (EPA) to the State. The primary mechanism to control water pollution is the requirement for direct dischargers to obtain an NPDES permit, or in the case of States where the authority has been delegated from the EPA, a State Pollutant Discharge Elimination System (SPDES) permit, pursuant to the CWA. In Nebraska, the Nebraska Department of Environmental Quality (NDEQ) issues and enforces NPDES permits.

C.1. Federal Environmental Requirements

Cooper Nuclear Station (CNS) is subject to Federal requirements regarding their environmental program. Those requirements are briefly described below. See Section 1.9 for CNS's compliance status with these requirements.

Table C-1 provides a list of the principal Federal environmental regulations and laws that are applicable to the review of the environmental resources that could be affected by this project that may affect license renewal applications for nuclear power plants.

Table C-1. Federal Environmental Requirements

Law/Regulation	Requirements
Current Operating License and License Renewal	
10 CFR Part 51. <i>Code of Federal Regulations</i> (CFR), Title 10, <i>Energy</i> , Part 51	"Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions." This part contains environmental protection regulations applicable to the NRC's domestic licensing and related regulatory functions.
10 CFR Part 54	"Requirements for Renewal of Operating Licenses for Nuclear Power Plants." This part focuses on managing adverse effects of aging; rather than identification of all aging mechanisms. The rule is intended to ensure that important systems, structures, and components will continue to perform their intended function in the period of extended operation.
10 CFR Part 50	Regulations promulgated by the NRC pursuant to the Atomic Energy Act of 1954, as amended (68 Stat. 919), and Title II of the Energy Reorganization Act of 1974 (88 Stat. 1242), to provide for the licensing of production and utilization facilities. This part also gives notice to all persons who knowingly provide to any licensee, applicant, contractor, or subcontractor, components, equipment, materials, or other goods or services, that relate to a licensee's or applicant's activities subject to this part, that they may be individually subject to NRC enforcement action for violation of § 50.5.
Air Quality Protection	
Clean Air Act (CAA) (42 U.S.C. § 7401 et seq.)	The CAA is a comprehensive Federal law that regulates air emissions. Under the CAA, Federal actions cannot thwart State and local efforts to remedy long-standing air quality problems that threaten public health issues associated with the six criteria air pollutants (i.e., ozone, nitrogen dioxide, sulfur dioxide, particulate matter, carbon monoxide, and lead).
Water Resources Protection	
Section 404 of the Clean Water Act (CWA) (33 U.S.C. § 1344)	Section 404 of the CWA established a program to regulate the discharge of dredged and fill material into waters of the United States, including wetlands. The U.S. Army Corps of Engineers (USACE) and the EPA jointly administer this program. Under the 404 program, no discharge of dredged or fill material is allowed if a practicable alternative exists that is less damaging to the aquatic environment or if the nation's waters would be significantly degraded. A Federal permit is required to discharge dredged or fill material into wetlands and waters of the United States.
Comprehensive Environmental Response, Compensation, and Liability Act (CERCLA) (42 U.S.C. § 9601 et seq)	Section 101 of CERCLA requires a permit to cover consumptive water use over 20,000 gallons per day (over a 30-day average) of surface and ground water.
Wild and Scenic River Act (16 U.S.C. §1271 et seq.)	Created the National Wild and Scenic Rivers System, established to protect the environmental values of free flowing streams from degradation by impacting activities including water resources projects.
Floodplain Executive Order (No. 11988. May 24, 1977, 42 <i>Federal Register</i> (FR) 26951) and Wetlands Executive Order (No. 11990. May 24, 1977, 42 FR 26961)	Both executive orders require Federal agencies to consider the impacts of their actions on floodplains and wetlands through existing review procedures such as the National Environmental Policy Act of 1969 (NEPA).

Law/Regulation	Requirements
Waste Management and Pollution Prevention	
Resource Conservation and Recovery Act (RCRA) (42 USC § 6901 et seq.)	Before a material can be classified as a hazardous waste, it must first be a solid waste as defined under the RCRA. Hazardous waste is classified under Subtitle C of the RCRA. Parts 261 and 262 of Title 40 CFR contain all applicable generators of hazardous waste regulations. Part 261.5 (a) and (e) contain requirements for conditionally exempt small quantity generators (CESQGs). Part 262.34(d) contains requirements for small quantity generators (SQGs). Parts 262 and 261.5(e) contain requirements for large quantity generators (LQGs)
Pollution Prevention Act (42 U.S.C. § 13101 et seq.)	Formally established a national policy to prevent or reduce pollution at its source whenever feasible. The Act provides funds for State and local pollution prevention programs through a grant program to promote the use of pollution prevention techniques by business.
Endangered Species	
Endangered Species Act (ESA) (16 U.S.C. § 1531 et seq.)	Forbids any government agency, corporation, or citizen from taking (harming or killing) endangered animals without an Endangered Species Permit.
Fish and Wildlife Coordination Act (16 U.S.C. § 661 et seq.)	To minimize adverse impacts of proposed actions on fish and wildlife resources and habitat, requires that Federal agencies consult government agencies regarding activities that affect, control, or modify waters of any stream or bodies of water. It also requires that justifiable means and measures be used in modifying plans to protect fish and wildlife in these waters.
Historic Preservation	
National Historic Preservation Act (NHPA) (16 U.S.C. § 470 et seq.)	Directs Federal agencies to consider the impact of their actions on historic properties. The NHPA also encourages State and local preservation societies.
Farmland	
Farmland and Protection Policy Act (7 U.S.C. § 4201 et seq.)	Requires that Federal programs, as practicable, shall be administered in a manner compatible with State and local government and private programs and policies to protect farmland.

**APPENDIX D.
CONSULTATION CORRESPONDENCE**

D. CONSULTATION CORRESPONDENCES

The Endangered Species Act of 1973, as amended; the Magnuson-Stevens Fisheries Management Act of 1996, as amended; and the National Historic Preservation Act of 1966 require that Federal agencies consult with applicable State and Federal agencies and groups prior to taking action that may affect threatened and endangered species, essential fish habitat, or historic and archaeological resources, respectively. This appendix contains consultation documentation.

Table D-1 provides a list of the consultation documents sent between the U.S. Nuclear Regulatory Commission (NRC) and other agencies. The NRC staff is required to consult with these agencies based on the National Environmental Policy Act of 1969 (NEPA) requirements.

Table D-1. Consultation Correspondences

Author	Recipient	Date of Letter/E-mail
U.S. Nuclear Regulatory Commission (D. Pelton)	Nebraska State Historic Society (M. Smith)	January 16, 2009 (ML090080197)
U.S. Nuclear Regulatory Commission (D. Pelton)	Advisory Council on Historic Preservation (D. Klima)	January 26, 2009 (ML090080683)
U.S. Nuclear Regulatory Commission (D. Pelton)	Environmental Services Division, Environmental Protection Agency Region 7 (J. Cothorn)	January 27, 2009 (ML090230446)
U.S. Nuclear Regulatory Commission (D. Pelton)	Department of Health and Human Services, Regulation and Licensure, Public Health Assurance (J. Schmitt)	January 28, 2009 (ML090210249)
U.S. Nuclear Regulatory Commission (D. Pelton)	U. S. Fish and Wildlife Service, Ecological Services – Nebraska Field Office (J. Cochnar)	January 29, 2009 (ML090070507)
U.S. Nuclear Regulatory Commission (D. Pelton)	Missouri State Historic Society (M. Miles)	January 29, 2009 (ML090210750)
Nebraska State Historical Society (J. Dolberg)	U.S. Nuclear Regulatory Commission (D. Pelton)	February 02, 2009 (ML090650061)
U.S. Nuclear Regulatory Commission (D. Pelton)	Nebraska Department of Natural Resources (A. Bleed)	February 04, 2009 (ML090260380)
U.S. Nuclear Regulatory Commission (D. Pelton)	U.S. Army Corps of Engineers, Omaha District (D. Press)	February 04, 2009 (ML090160476)
U.S. Nuclear Regulatory Commission (D. Pelton)	Sac and Fox Tribe of the Mississippi in Iowa (A. Pushetonequa) ^(a)	February 04, 2009 (ML090080045)
Nebraska Department of Natural Resources (J. Angell)	U.S. Nuclear Regulatory Commission (D. Pelton)	March 09, 2009
Environmental Protection Agency Region 7 (L. Shepard)	U.S. Nuclear Regulatory Commission (E. Sayoc)	April 16, 2009 (ML091070269)
Nebraska Games and Parks Commission (R. Simpson)	U.S. Nuclear Regulatory Commission (R. Bulavinetz)	May 08, 2009 (ML091400110)
Fish and Wildlife Service (J. DeWeese)	Nebraska Public Power District (J. Citta)	June 08, 2009 (ML091830055)

Appendix D

Author	Recipient	Date of Letter/E-mail
U.S. Fish and Wildlife Service (R. Harms)	U.S. Nuclear Regulatory Commission (B. Brady)	March 19, 2010 (ML101440172)
Nebraska State Historic Society (R. Puschendorf)	U.S. Nuclear Regulatory Commission (B. Pham)	March 19, 2010 (ML101440132)
U.S. Department of Interior (R. Stewart)	U.S. Nuclear Regulatory Commission (Chief. Rules and Directives Branch)	April 27, 2010 (ML101440133)
U.S. Environmental Protection Agency (R. Hammerschmidt)	U.S. Nuclear Regulatory Commission (M. Lesar)	May 03, 2010 (ML101270268)

D.1. Consultation Correspondence

The following pages contain copies of the letters listed in Table D-1.

Appendix D

January 16, 2009

Mr. Michael J. Smith
State Historic Preservation Officer
Nebraska State Historical Society
P.O. Box 82554
Lincoln, NE 68501

SUBJECT: COOPER NUCLEAR STATION LICENSE RENEWAL APPLICATION REVIEW
(HP NO. 0801-050-01, DESCRIPTION, NPPD, COOPER NUCLEAR STATION)


Dear Mr. Smith:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application to renew the operating license for Cooper Nuclear Station (CNS), which is located in Nemaha County, Nebraska, on the west bank of the Missouri River at river mile (RM) 532.5. The Village of Brownville, NE is located approximately 2.25 miles northwest of the site. CNS is operated by the Nebraska Public Power District (NPPD). The application for renewal was submitted by NPPD by letter dated September 24, 2008, pursuant to Title 10 of the *Code of Federal Regulations* Part 54 (10 CFR Part 54).

The NRC has established that, as part of the staff's review of any nuclear power plant license renewal action, a Supplemental Environmental Impact Statement (SEIS) to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants", NUREG-1437, will be prepared under the provisions of 10 CFR Part 51, the NRC's regulation that implements the National Environmental Policy Act of 1969 (NEPA). In accordance with 36 CFR 800.8(c), the SEIS will include analyses of potential impacts to historic and cultural resources.


In the context of the National Historic Preservation Act of 1966, as amended, the NRC staff has determined that the area of potential effect (APE) for a license renewal action is the area at the power plant site and its immediate environs that may be impacted by post-license renewal land-disturbing operations or possible refurbishment activities associated with the proposed action. The APE may extend beyond the immediate environs in those instances where post-license renewal land-disturbing operations or projected refurbishment activities specifically related to license renewal may potentially have an effect on known or proposed historic sites. This determination is made irrespective of ownership or control of the lands of interest.

On February 25, 2009, the NRC will conduct two public license renewal and environmental scoping meetings. The first session will be held at the Brownville Concert Hall at 126 Atlantic St., Brownville, NE 68321, telephone (402) 825-3331, and will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second session will be held at the Auburn Senior Center at 1101 J St., Auburn, NE 68305, telephone (402) 274-3420, and will convene at 7:00 p.m., with a repeat of the overview portions of the meeting and will continue until 10:00 p.m., as necessary. You and your staff are invited to attend. Your office will receive a copy of the draft SEIS along with a request for comments. The staff expects to publish the draft SEIS in December 2009.



Cooper Nuclear Station Site Map - 6 Mile Radius

Appendix D



January 26, 2009

Mr. Don L. Klima, Director
Advisory Council on Historic Preservation
Office of Federal Agency Programs
1100 Pennsylvania Ave., NW, Suite 803
Washington, DC 20004

SUBJECT: COOPER NUCLEAR STATION LICENSE RENEWAL APPLICATION REVIEW

Dear Mr. Klima:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application to renew the operating license for Cooper Nuclear Station (CNS) which is located near Brownville, Nebraska. It is operated by the Nebraska Public Power District (NPPD). The application for renewal was submitted by NPPD by letter dated September 24, 2008, pursuant to Title 10 of the *Code of Federal Regulations* Part 54 (10 CFR Part 54).

The NRC has established that, as part of the staff's review of any nuclear power plant license renewal action, a site-specific Supplemental Environmental Impact Statement (SEIS) to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants", NUREG-1437, will be prepared under the provisions of 10 CFR Part 51, the NRC's regulation that implements the National Environmental Policy Act of 1969 (NEPA). In accordance with 36 CFR 800.8(c), the SEIS will include analyses of potential impacts to historic and cultural resources.

On February 25, 2009, the NRC will conduct two public license renewal and environmental scoping meetings. The first session will be held at the Brownville Concert Hall at 126 Atlantic St., Brownville, NE 68321, telephone (402) 825-3331, and will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second session will be held at the Auburn Senior Center at 1101 J St., Auburn, NE 68305, telephone (402) 274-3420, and will convene at 7:00 p.m., with a repeat of the overview portions of the meeting and will continue until 10:00 p.m., as necessary. You and your staff are invited to attend. In addition, during the week of March 30, 2009, the NRC staff plans to conduct a site audit at CNS. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is December 2009.

Appendix D

D. Klima

- 2 -

If you have any questions or require additional information, please contact the License Renewal Project Managers, Tam Tran telephone, (301) 415-3617, email: tam.tran@nrc.gov or Emmanuel Sayoc, telephone (301) 415-1924, email: emmanuel.sayoc@nrc.gov.

Sincerely,

IRA

David L. Pelton, Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-298

cc w/o encl: See next page

January 27, 2009

Mr. Joseph Cothorn
Environmental Review Coordinator
Environmental Services Division
USEPA Region 7
901 North 5th Street
Kansas City, KS 66101

SUBJECT: COOPER NUCLEAR STATION LICENSE RENEWAL APPLICATION
REVIEW

Dear Mr. Cothorn:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application submitted by Nebraska Public Power District, for the renewal of the operating license for Cooper Nuclear Station (CNS) Unit 1, which is located in Nemaha County, Nebraska, on the west bank of the Missouri River at river mile 532.5. The Village of Brownville, NE is located approximately 2.25 miles northwest of the site, and Lincoln, NE, is located approximately 60 miles west northwest of the site. As part of the review of the license renewal application (LRA), the NRC is preparing a Supplemental Environmental Impact Statement (SEIS) under the provisions of Title 10 of the *Code of Federal Regulations* Part 51 (10 CFR Part 51), the NRC's regulation that implements the National Environmental Policy Act of 1969.

CNS is requesting the renewal of its operating license for a period of 20 years beyond the expiration of the current license term, renewing the license until January 18, 2034. The proposed action would include the use and continued maintenance of existing plant facilities and transmission lines; CNS does not plan to construct or alter any facilities associated with the plant during the period of extended operation.

The NRC staff plans to hold two identical public meetings covering the license renewal and environmental scoping process on February 25, 2009. The first session will be held at the Brownville Concert Hall at 126 Atlantic Street, Brownville, NE 68321, telephone (402) 825-3331, and will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second session will be held at the Auburn Senior Center at 1101 J Street, Auburn, NE 68305, telephone (402) 274 3420, and will convene at 7:00 p.m., with a repeat of the overview portions of the meeting and will continue until 10:00 p.m., as necessary. In addition, during the week of March 30, 2009, the NRC plans to conduct a site audit. You and your staff are invited to attend both the site audit and the public meetings. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is December 2009.

Appendix D

J. Cothorn

- 2 -

If you have any questions concerning the NRC staff's review of this LRA, please contact NRC's Project Managers, Tam Tran, by telephone, 1-800-368-5642, extension 3617, or by e-mail at tam.tran@nrc.gov, or Emmanuel Sayoc, by telephone, 1-800-368-5642, extension 1924, or by e-mail at emmanuel.sayoc@nrc.gov.

Sincerely,

!RA!

David L. Pelton, Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-298

cc w/encs: See next page

January 28, 2009

Ms. Julia Schmitt, Manager
Radiation Control Program
Department of Health and Human Services
Regulation and Licensure
Public Health Assurance
301 Centennial Mall, South
P.O. Box 95007
Lincoln, NE 68509-5007

SUBJECT: COOPER NUCLEAR STATION LICENSE RENEWAL APPLICATION
REVIEW

Dear Ms. Schmitt:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application submitted by Nebraska Public Power District (NPPD), for the renewal of the operating license for Cooper Nuclear Station (CNS), which is located in Nemaha County, Nebraska (NE), on the west bank of the Missouri River at river mile (RM) 532.5. The Village of Brownville, NE is located approximately 2.25 miles northwest of the site, and Lincoln, Nebraska, is located approximately 60 miles west northwest of the site. As part of the review of the license renewal application (LRA), the NRC is preparing a Supplemental Environmental Impact Statement (SEIS) under the provisions of Title 10 of the Code of Federal Regulations Part 51 (10 CFR Part 51), the NRC's regulation that implements the National Environmental Policy Act (NEPA) of 1969.

CNS is requesting the renewal of its operating license for a period of 20 years beyond the expiration of the current license term, renewing the license until January 18, 2034. The proposed action would include the use and continued maintenance of existing plant facilities and transmission lines; CNS does not plan to construct or alter any facilities associated with the plant during the period of extended operation.

The NRC staff plans to hold two identical public meetings covering the license renewal and environmental scoping process on February 25, 2009. The first meeting will be held at the Brownville Concert Hall at 126 Atlantic St., Brownville, NE 68321, telephone (402) 825-3331. The meeting will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second meeting will be held at the Auburn Senior Center at 1101 J St., Auburn, NE 68305, telephone (402) 274 3420. The meeting will convene at 7:00 p.m., with a repeat of the overview portions of the meeting and will continue until 10:00 p.m., as necessary. In addition, during the week of March 30, 2009, the NRC plans to conduct a site audit. You and your staff are invited to attend both the site audit and the public meetings. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is December 2009.

Appendix D

J. Schmitt

- 2 -

If you have any questions concerning the NRC staff's review of this license renewal application, please contact NRC's Project Managers, Tam Tran, by telephone, 1-800-368-5642, extension 3617, or by email to the NRC at tam.tran@nrc.gov, or Emmanuel Sayoc, by telephone, 1-800-368-5642, extension 1924, or by email to the NRC at emmanuel.sayoc@nrc.gov.

Sincerely,

!RA!

David L. Pelton, Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-298

cc w/o encl: See next page

January 29, 2009

Mr. John Cochnar
U. S. Fish and Wildlife Service
Ecological Services - Nebraska Field Office
203 West Second Street
Grand Island, NE 68801

SUBJECT: REQUEST FOR LIST OF PROTECTED SPECIES WITHIN THE AREA UNDER
EVALUATION FOR THE COOPER NUCLEAR STATION, UNIT 1 LICENSE
RENEWAL APPLICATION REVIEW

Dear Mr. Cochnar:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application submitted by the Nebraska Public Power District (NPPD) for the renewal of the operating license for Cooper Nuclear Station (CNS) Unit 1. CNS is located in Nemaha County, Nebraska (NE), on the west bank of the Missouri River at river mile (RM) 532.5. The Village of Brownville, NE is located approximately 2.25 miles northwest of the site and Lincoln, NE, is located approximately 60 miles west northwest of the site. As part of the review of the license renewal application (LRA), the NRC is preparing a Supplemental Environmental Impact Statement (SEIS) under the provisions of Title 10 of the *Code of Federal Regulations* Part 51 (10 CFR Part 51), the NRC's regulation that implements the National Environmental Policy Act (NEPA) of 1969. The SEIS includes an analysis of pertinent environmental issues, including endangered or threatened species and impacts to fish and wildlife. This letter is being submitted under the provisions of the Endangered Species Act of 1973, as amended, and the Fish and Wildlife Coordination Act of 1934, as amended.

The proposed action would include the use and continued maintenance of existing plant facilities and transmission lines. The site surroundings are predominantly agricultural with zero population within a one-half mile radius of the plant. Brownville, NE, is the nearest developed community, at a distance of approximately 2.25 miles from the site, with a 2005 population of approximately 137. The largest town with industry within 10 miles is Auburn, Nebraska, located to the west, with a 2005 population of approximately 3,076. Maryville, Missouri, located approximately 40 miles east of the plant, is the largest community within 50 miles and had a 2005 population of approximately 10,567.

Over 99 percent of the acreage in Nemaha County is used for agriculture and farming. Farming is also the major activity for the rest of the area within a 50-mile radius as well. The site is located on a constructional plain bordering the west bank of the Missouri River. It is situated on the first bottomland of the broad, nearly level, flood plain, which is approximately six miles wide at the site. The U.S. Army Corp of Engineer (USACE) has stabilized the channel by use of pile dikes and bank protection. Earthen levees run parallel with the Missouri River, on both sides of the river.

Appendix D

J. Cochnar

- 2 -

The station site grade level of 903 feet above mean sea level (AMSL) has been raised 13 feet above the natural grade level of 890 feet AMSL, in order to bring final grade one foot above the existing 902 feet AMSL levee constructed by the USACE. The site slopes generally east, with surface drainage toward the Missouri River.

The CNS property includes 239 acres on the east side of the Missouri River in Atchison County, Missouri, the most northwestern county in Missouri, bounded on the west by the Missouri River. The eastern bank of the Missouri River is chiefly a densely forested land similar to the unfarmable bluffs that run parallel to the Missouri River. To the west there are bluffs that peak at 1,100 feet, but average 1,000 feet along the stretch of river from Brownville to Nemaha. Beyond the bluffs, the land is a gently rolling flood plain.

There are several Native American lands within a 50-mile radius of CNS. These include the Sac and Fox Reservation, Iowa Reservation, and Kickapoo Reservation. There are also several local and county parks, golf courses, forest lands, wildlife areas, and other public recreation lands within a 50-mile radius of CNS.

Flow of the Missouri River at CNS is largely controlled by the Gavins Point Dam located about 200 miles upstream in Yankton, South Dakota. The flow is highly channelized with swift flows and heavy sediment transport. Wing dams are located on the Missouri side of the river near CNS to force the flow into a central channel.

The USACE constructed and operates six of the seven mainstem dams on the Missouri River; the U.S. Bureau of Reclamation operates the seventh, Canyon Ferry Dam, east of Helena, Montana. When the USACE constructed five of the Missouri River mainstem dams in the 1950s and 1960s after passage of the Pick-Sloan Plan, goals for dam and reservoir operations were to reduce flood damages, enhance navigation, generate hydroelectric power, and store water for irrigation.

Missouri River reservoirs and river segments presently contain populations of exotic fishes, including cisco, several salmon and trout species, and several Asian carp species. Some of these species have contributed to the development of economically important recreational fisheries.

CNS cooling is classified as a circulating water system that uses water taken from the Missouri River. Water passes through trash racks and then through traveling screens. A major portion of the flow is directed to the circulating water pumps, which deliver water to the main condenser. A smaller portion of the Missouri River water is used by the service water pumps. The discharge from the condenser and from the service water system is returned via the discharge channel to the river. The circulating water intake structure (CWIS) is located on the west shoreline. In front of the CWIS is a guide wall and submerged weir constructed of steel sheet

J. Cochnar

- 3 -

piling that runs parallel to and at distance of 14.25 feet (ft) from the face of the intake. The purpose of the guide wall and weir is to reduce the sediment input to the CWIS. It accomplishes this by forcing bed load and other material contained in the river to flow around and past the CWIS.

Four circulating water pumps provide the circulating water for the facility. Each pump can draw 159,000 gpm. The pump design water level is at El. 875.0 ft, with a minimum submergence level at El. 865.0 ft. There are four service water pumps providing a combined flow of 32,000 gpm. Velocities in the intake structure are 1.1 ft/sec under the curtain wall, 0.7 ft/sec at the trash racks, and approximately 2.0 ft/sec at the traveling water screens. These velocities were calculated at low water levels (El. 874.5 ft) and maximum circulating water pump flow (159,000 gpm per pump). The flow is highly channelized with swift flows and heavy sediment transport. Turning vanes and a low sheetpile wall are located in front of the intake bays. Wing dams are located on the Missouri side of the river to force the flow into a central channel. During the winter, ice is very common on the river. To prevent ice damage, ice deflector barges are installed during the winter months. To prevent the formation of frazzle ice, some of the main condenser discharge water (25–30 percent) is re-circulated through the ice control tunnel and released in front of the trash rack within the CWIS while the remaining water is discharged about 1,300 ft downstream of the intake via a discharge canal.

The chlorination system connection is located on the common inlet to Screen Wash Pump A and B from the service water system. Bacteria that occur naturally in the Missouri River may contribute to the growth of biological film fouling of the main condenser tubes. The station is proceeding with a study to determine if routine chemical injection (chlorine, bromine, etc.) will be effective in eliminating the microbiological film on the interior walls of the condenser tubes.

Water leaves the pump house and circulates through the condenser, where it is collected from the condenser section through a large manifold. It then travels through concrete tunnels to the seal well structure and the discharge canal. At the rated circulating water flow of 631,000 gpm through the condenser and at design power on the turbine generator, the temperature rise through the condenser is approximately 17.8°F. From the seal well and gate control structure, the water is directed into a discharge canal that is approximately 1,000 ft long; it then enters the river at a slight angle. The velocity of discharge is about 1 fps during average water levels of 879.4 ft AMSL and 35,000 cfs flow, and increases to about 2.5 fps as the water surface elevation is reduced to 874.5 ft AMSL and flows near 11,000 cfs.

The transmission lines which were constructed to connect CNS to the grid for purposes of power distribution includes (1) NPPD line TL3501 (345 kV energized in August 1969) 63.6 miles in length from CNS to the Mark T. Moore substation near Hallam, Nebraska, (2) NPPD line TL3502 (345 kV energized in July 1970) 82.6 miles in length from the Mark T. Moore substation to the Grand Island substation, and (3) Omaha Public Power District (OPPD) Line "60," which was already planned when CNS was constructed, (4) NPPD line TL3504 was energized as a 345 kV line in July 1970 and is 0.64 miles in length from CNS to the center of the Missouri River.

The transmission line "K-Towers" are supported by two wooden poles that are 26 feet apart. Therefore, the farming activity adjacent to and under the towers and lines continues essentially unimpeded with the only land removed from service being that upon which transmission poles physically rest. No cultivated land along the transmission route has been removed from service as a result of rights-of-way, and access for repairs and maintenance is requested on an individual basis from each property owner. For the remainder of the transmission line route, which passes over non-cultivated land, the right-of-way (ROW) is cleared only of woody plants that have a growth pattern that would cause them to grow into or fall onto the line conductors. Thereafter, control of these species is maintained; however, all of the natural grasses and low growing bushy, woody plants are allowed to grow.

There are no densely forested areas on the transmission route, and the land beneath the transmission lines is allowed to return to its natural state. Steel towers are used for the lines crossing the Missouri River and in the immediate vicinity of the station. Based on NPPD clearance practices, the required minimum ground clearance is 29.3 feet.

Provided for your information is the CNS Site Layout (Enclosure 1) and Transmission Line Map (Enclosure 2). To support the SEIS preparation process and to ensure compliance with Section 7 of the Endangered Species Act, the NRC requests information on Federally-listed, proposed, and candidate species and critical habitat that may be in the vicinity of CNS and its associated transmission line rights-of-way. In addition, please provide any information you consider appropriate under the provisions of the Fish and Wildlife Coordination Act.

The NRC staff plans to hold two public license renewal and environmental scoping meetings on February 25, 2009. There will be two sessions, an afternoon and evening session, to accommodate interested parties. The first session will be held at the Brownville Concert Hall at 126 Atlantic St., Brownville, NE 68321, telephone (402) 825-3331, and will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second session will be held at the Auburn Senior Center at 1101 J St., Auburn, NE 68305, telephone (402) 274-3420, and will convene at 7:00 p.m., with a repeat of the overview portions of the meeting and will continue until 10:00 p.m., as necessary. In addition, during the week of March 30, the NRC plans to conduct a site audit. You and your staff are invited to attend both the public meetings and the site audit. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is December 2009.

January 29, 2009

Mr. Mark Miles
State Historic Preservation Officer
Department of Natural Resources
P.O. Box 176
Jefferson City, MO 65102

SUBJECT: COOPER NUCLEAR STATION LICENSE RENEWAL APPLICATION REVIEW
(NEBRASKA PUBLIC POWER DISTRICT - COOPER NUCLEAR STATION
SHPO LOG NUMBER 004-AT-08)

Dear Mr. Miles:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application to renew the operating license for Cooper Nuclear Station (CNS), which is located in Nemaha County, Nebraska (NE), on the west bank of the Missouri River at river mile 532.5. The Village of Brownville, NE is located approximately 2.25 miles northwest of the site. CNS is operated by the Nebraska Public Power District (NPPD). The application for renewal was submitted by NPPD by letter dated September 24, 2008, pursuant to Title 10 of the *Code of Federal Regulations* Part 54 (10 CFR Part 54).

The NRC has established that, as part of the staff's review of any nuclear power plant license renewal action, a Supplemental Environmental Impact Statement (SEIS) to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants", NUREG-1437, will be prepared under the provisions of 10 CFR Part 51, the NRC's regulation that implements the National Environmental Policy Act of 1969 (NEPA). In accordance with 36 CFR 800.8(c), the SEIS will include analyses of potential impacts to historic and cultural resources.

In the context of the National Historic Preservation Act of 1966, as amended, the NRC staff has determined that the area of potential effect (APE) for a license renewal action is the area at the power plant site and its immediate environs that may be impacted by post-license renewal land-disturbing operations or projected refurbishment activities associated with the proposed action. The APE may extend beyond the immediate environs in those instances where post-license renewal land-disturbing operations or projected refurbishment activities specifically related to license renewal may potentially have an effect on known or proposed historic sites. This determination is made irrespective of ownership or control of the lands of interest.

On February 25, 2009, the NRC will conduct two public license renewal and environmental scoping meetings. The first session will be held at the Brownville Concert Hall at 126 Atlantic St., Brownville, NE 68321, telephone (402) 825-3331, and will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second session will be held at the Auburn Senior Center at 1101 J St., Auburn, NE 68305, telephone (402) 274-3420, and will convene at 7:00 p.m., with a repeat of the overview portions of the meeting and will continue until 10:00 p.m., as necessary. You and your staff are invited to attend. Your office will receive a copy of the draft SEIS along with a request for comments. The staff expects to publish the draft SEIS in December 2009.

Appendix D

M. Miles

-2-

If you have any questions concerning the NRC staff's review of this license renewal application, please contact NRC's Project Managers, Tam Tran, by telephone, 1-800-368-5642, extension 3617, or by email to the NRC at tam.tran@nrc.gov, or Emmanuel Sayoc, by telephone, 1-800-368-5642, extension 1924, or by email to the NRC at emmanuel.sayoc@nrc.gov.

Sincerely,

/RA/

David Pelton, Branch Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No: 50-298

cc: See next page



NEBRASKA STATE HISTORICAL SOCIETY

1500 R STREET, P.O. BOX 82554, LINCOLN, NE 68501-2554
(402) 471-3270 Fax: (402) 471-3100 1-800-833-6747 www.nebraskahistory.org

Michael J. Smith, Director/CEO

February 2, 2009

Mr. David L. Pelton, Chief
Division of License Renewal
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555-0001

RE: Cooper Nuclear Station license renewal HP# 0801-050-001

Dear Mr. Pelton:

Thank you for submitting the referenced project for our review and comment. Our comment on this project and its potential to affect historic properties is required by Section 106 of the National Historic Preservation Act of 1966, as amended, and implementing regulations 36 CFR Part 800. Before we are able to adequately review the proposed Area of Potential Effect (APE) for this project for its potential to affect historic properties, we require the following information:

- A map clearly defining the boundaries of the APE

Please submit this information to: Bob Puschendorf, Nebraska State Historic Preservation Office, P.O. Box 82554, 1420 P Street, Lincoln, NE 68501-2554.

Sincerely,

Jill E. Dolberg
Review and Compliance Coordinator
Nebraska State Historic Preservation Office

Cc: Tam Tran, NRC
Emmanuel Sayoc, NRC
Steward B. Minahan, Chief Nuclear Officer, Cooper Nuclear Station

February 04, 2009

Ms. Ann Salomon Bleed, Director
Nebraska Department of Natural Resources
301 Centennial Mall South
P.O. Box 94676
Lincoln, NE 68509-4676

SUBJECT: REQUEST FOR LIST OF PROTECTED SPECIES WITHIN THE AREA UNDER
EVALUATION FOR THE COOPER NUCLEAR STATION, UNIT 1 LICENSE
RENEWAL APPLICATION REVIEW

Dear Ms. Bleed:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application submitted by the Nebraska Public Power District (NPPD) for the renewal of the operating license for Cooper Nuclear Station (CNS) Unit 1. Cooper Nuclear Station (CNS), located in Nemaha County, Nebraska (NE), on the west bank of the Missouri River at river mile (RM) 532.5. The Village of Brownville, NE is located approximately 2.25 miles northwest of the site, and Lincoln, NE, is located approximately 60 miles west northwest of the site. As part of the review of the license renewal application (LRA), the NRC is preparing a Supplemental Environmental Impact Statement (SEIS) under the provisions of Title 10 of the *Code of Federal Regulations* Part 51 (10 CFR Part 51), the NRC's regulation that implements the National Environmental Policy Act (NEPA) of 1969. The SEIS includes an analysis of pertinent environmental issues, including endangered or threatened species and impacts to fish and wildlife. This letter is being submitted under the provisions of the Endangered Species Act of 1973, as amended, and the Fish and Wildlife Coordination Act of 1934, as amended.

The site surroundings are predominantly agricultural with zero population within a one-half mile radius of the plant. Brownville, NE, is the nearest developed community, at a distance of approximately 2.25 miles from the site, and a 2005 population of approximately 137. The largest town with industry within 10 miles is Auburn, NE, located to the west, with a 2005 population of approximately 3,076. Maryville, Missouri, located approximately 40 miles east of the plant, is the largest community within 50 miles and had a 2005 population of approximately 10,567.

Over 99 percent of the acreage in Nemaha County is used for agriculture and farming. Farming is the major activity for the rest of the area within a 50-mile radius as well. The site is located on a constructional plain bordering the west bank of the Missouri River. It is situated on the first bottomland of the broad, nearly level, flood plain, which is approximately six miles wide at the site. The U.S. Army Corps of Engineers (USACE) has stabilized the channel by use of pile dikes and bank protection. Earthen levees run parallel with the Missouri River, on both sides of the river.

A. Bleed

- 2 -

The station site grade level of 903 feet above mean sea level (AMSL) has been raised 13 feet above the natural grade level of 890 feet AMSL, in order to bring final grade one foot above the existing 902 feet AMSL levee constructed by the USACE. The site slopes generally east, with surface drainage toward the Missouri River.

The CNS property includes 239 acres on the east side of the Missouri River in Atchison County, Missouri, the most northwestern county in Missouri, bounded on the west by the Missouri River. The eastern bank of the Missouri River is chiefly a densely forested land similar to the unfarmable bluffs that run parallel to the Missouri River. To the west there are bluffs that peak at 1,100 feet, but average 1,000 feet along the stretch of river from Brownville to Nemaha. Beyond the bluffs, the land is a gently rolling flood plain.

There are several Native American lands within a 50-mile radius of CNS. These include the Sac and Fox Reservation, Iowa Reservation, and Kickapoo Reservation. There are also several local and county parks, golf courses, forest lands, wildlife areas, and other public recreation lands within a 50-mile radius of CNS.

Flow of the Missouri River at CNS is largely controlled by the Gavins Point Dam located about 200 miles upstream in Yankton, South Dakota. The flow is highly channelized with swift flows and heavy sediment transport. Wing dams are located on the Missouri side of the river near CNS to force the flow into a central channel.

The USACE constructed and operates six of the seven mainstem dams on the Missouri River; the U.S. Bureau of Reclamation operates the seventh, Canyon Ferry Dam, east of Helena, Montana. When the USACE constructed five of the Missouri River mainstem dams in the 1950s and 1960s after passage of the Pick-Sloan Plan, goals for dam and reservoir operations were to reduce flood damages, enhance navigation, generate hydroelectric power, and store water for irrigation.

Missouri River reservoirs and river segments presently contain populations of exotic fishes, including cisco, several salmon and trout species, and several Asian carp species. Some of these species have contributed to the development of economically important recreational fisheries.

CNS cooling is classified as a circulating water system that uses water taken from the Missouri River. Water passes through trash racks and then through traveling screens. A major portion of the flow is directed to the circulating water pumps, which deliver water to the main condenser. A smaller portion of the Missouri River water is used by the service water pumps. The discharge from the condenser and from the service water system is returned via the discharge channel to the river. The circulating water intake structure (CWIS) is located on the west shoreline. In front

Appendix D

A. Bleed

- 3 -

of the CWIS is a guide wall and submerged weir constructed of steel sheet piling that runs parallel to and at distance of 14.25 feet (ft) from the face of the intake.

Four circulating water pumps provide the circulating water for the facility. Each pump can draw 159,000 gpm. The pump design water level is at El. 875.0 ft, with a minimum submergence level at El. 865.0 ft. There are four service water pumps providing a combined flow of 32,000 gpm. Velocities in the intake structure are 1.1 ft/sec under the curtain wall, 0.7 ft/sec at the trash racks, and approximately 2.0 ft/sec at the traveling water screens. These velocities were calculated at low water levels (El. 874.5 ft) and maximum circulating water pump flow (159,000 gpm per pump). The flow is highly channelized with swift flows and heavy sediment transport. To minimize the effects of sedimentation on the intake, turning vanes and a low sheetpile wall are located in front of the intake bays. Wing dams are located on the Missouri side of the river to force the flow into a central channel. During the winter, ice is very common on the river. To prevent ice damage, ice deflector barges are installed during the winter months. To prevent the formation of frazzle ice, some of the main condenser discharge water (25–30 percent) is re-circulated through the ice control tunnel and released in front of the trash rack within the CWIS while the remaining water is discharged about 1,300 ft downstream of the intake via a discharge canal.

The chlorination system connection is located on the common inlet to Screen Wash Pump A and B from the service water system. Bacteria that occur naturally in the Missouri River may contribute to the growth of biological film fouling of the main condenser tubes. The station is proceeding with a study to determine if routine chemical injection (chlorine, bromine, etc.) will be effective in eliminating the microbiological film on the interior walls of the condenser tubes.

Water leaves the pump house and circulates through the condenser, where it is collected from the condenser section through a large manifold. It then travels through concrete tunnels to the seal well structure and the discharge canal. At the rated circulating water flow of 631,000 gpm through the condenser and at design power on the turbine generator, the temperature rise through the condenser is approximately 17.8°F. From the seal well and gate control structure, the water is directed into a discharge canal that is approximately 1,000 ft long; it then enters the river at a slight angle. The velocity of discharge is about 1 fps during average water levels of 879.4 ft AMSL and 35,000 cfs flow, and increases to about 2.5 fps as the water surface elevation is reduced to 874.5 ft AMSL and flows near 11,000 cfs.

The transmission lines which were constructed to connect CNS to the grid for purposes of power distribution includes (1) NPPD line TL3501 (345 kV energized in August 1969) 63.6 miles in length from CNS to the Mark T. Moore substation near Hallam, Nebraska, (2) NPPD line TL3502 (345 kV energized in July 1970) 82.6 miles in length from the Mark T. Moore substation to the Grand Island substation, (3) Omaha Public Power District (OPPD) Line "60," which was already planned when CNS was constructed, and (4) NPPD line TL3504 was energized as a 345 kV line in July 1970 and is 0.64 miles in length from CNS to the center of the Missouri River.

A. Bleed

- 4 -

The transmission line "K-Towers" are supported by two wooden poles that are 26 feet apart. Therefore, the farming activity adjacent to and under the towers and lines continues essentially unimpeded with the only land removed from service being that upon which transmission poles physically rest. No cultivated land along the transmission route has been removed from service as a result of rights-of-way, and access for repairs and maintenance is requested on an individual basis from each property owner. For the remainder of the transmission line route, which passes over non-cultivated land, the right-of-way (ROW) is cleared only of woody plants that have a growth pattern that would cause them to grow into or fall onto the line conductors. Thereafter, control of these species is maintained; however, all of the natural grasses and low growing bushy, woody plants are allowed to grow.

There are no densely forested areas on the transmission route, and the land beneath the transmission lines is allowed to return to its natural state. Steel towers are used for the lines crossing the Missouri River and in the immediate vicinity of the station. Based on NPPD clearance practices, the required minimum ground clearance is 29.3 feet.

Provided for your information is the CNS Site Layout (Enclosure 1) and Transmission Line Map (Enclosure 2). To support the SEIS preparation process and to ensure compliance with Section 7 of the Endangered Species Act, the NRC requests information on State-listed, proposed, and candidate species and critical habitat that may be in the vicinity of CNS and its associated transmission line rights-of-way. In addition, please provide any information you consider appropriate under the provisions of the Fish and Wildlife Coordination Act.

The NRC staff plans to hold two public license renewal and environmental scoping meetings on February 25, 2009. There will be two sessions, an afternoon and evening session, to accommodate interested parties. The first session will be held at the Brownville Concert Hall at 126 Atlantic St., Brownville, NE 68321 telephone (402) 825-3331, and will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second session will be held at the Auburn Senior Center at 1101 J St., Auburn, NE 68305, telephone (402) 274 3420, and will convene at 7:00 p.m., with a repeat of the overview portions of the meeting and will continue until 10:00 p.m., as necessary. In addition, during the week of March 30, 2009, the NRC plans to conduct a site audit. You and your staff are invited to attend both the public meetings and the site audit. Your office will receive a copy of the draft SEIS along with a request for comments.

February 04, 2009

Colonel David C. Press, Commander
U.S. Army Corps of Engineers
Omaha District
106 South 15th Street
Omaha, NE 68102-1618

SUBJECT: COOPER NUCLEAR STATION LICENSE RENEWAL APPLICATION
REVIEW

Dear Colonel Press:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application submitted by Nebraska Public Power District (NPPD), for the renewal of the operating license for Cooper Nuclear Station (CNS), which is located in Nemaha County, Nebraska (NE), on the west bank of the Missouri River at river mile 532.5. The Village of Brownville, NE is located approximately 2.25 miles northwest of the site, and Lincoln, NE is located approximately 60 miles west northwest of the site. As part of the review of the license renewal application (LRA), the NRC is preparing a Supplemental Environmental Impact Statement (SEIS) under the provisions of Title 10 of the *Code of Federal Regulations* Part 51 (10 CFR Part 51), the NRC's regulation that implements the National Environmental Policy Act (NEPA) of 1969.

CNS is requesting the renewal of its operating license for a period of 20 years beyond the expiration of the current license term, renewing the license until January 18, 2034. The proposed action would include the use and continued maintenance of existing plant facilities and transmission lines; CNS does not plan to construct or alter any facilities associated with the plant during the period of extended operation.

The NRC staff plans to hold two identical public meetings covering the license renewal and environmental scoping process on February 25, 2009. The first session will be held at the Brownville Concert Hall at 126 Atlantic St., Brownville, NE 68321 telephone 402-825-3331, and will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second session will be held at the Auburn Senior Center at 1101 J St., Auburn, NE 68305, telephone 402-274 3420, and will convene at 7:00 p.m., with a repeat of the overview portions of the meeting and will continue until 10:00 p.m., as necessary. In addition, during the week of March 30, 2009 the NRC plans to conduct a site audit. You and your staff are invited to attend both the site audit and the public meetings. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is December 2009.

D. Press

- 2 -

If you have any questions concerning the NRC staff's review of this license renewal application, please contact NRC's Project Managers. Tam Tran, by telephone, 1-800-368-5642, extension 3617, or by email to the NRC at tam.tran@nrc.gov, or Emmanuel Sayoc, by telephone, 1-800-368-5642, extension 1924, or by email to the NRC at emmanuel.sayoc@nrc.gov.

Sincerely,

/RA/

David L. Pelton, Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-298

cc w/o encl.: See next page

February 04, 2009

Adrian Pushetonequa, Chairman
Sac and Fox Tribe of the Mississippi in Iowa
349 Meskwaki Road
Tama, IA 52339-9629

SUBJECT: REQUEST FOR SCOPING COMMENTS CONCERNING THE COOPER
NUCLEAR STATION, UNIT 1 LICENSE RENEWAL APPLICATION REVIEW

Dear Mr. Pushetonequa:

The U.S. Nuclear Regulatory Commission (NRC or the staff) has recently received an application from Nebraska Public Power District for the renewal of the operating license for the Cooper Nuclear Station (CNS) Unit 1, located in Nemaha County, Nebraska. The NRC is in the initial stages of developing a Supplemental Environmental Impact Statement to the Generic Environmental Impact Statement (GEIS), which will document the impacts associated with the license renewal of the CNS Unit 1. We would like your assistance in our review by providing input to the NRC's environmental review scoping process. The NRC's process includes an opportunity for public and inter-governmental participation in the environmental review. We want to ensure that you are aware of our efforts pursuant to Title 10 of the *Code of Federal Regulations* Part 51, Section 51.28(b). In addition, as outlined in 36 CFR 800.8(c), the NRC plans to coordinate compliance with Section 106 of the National Historic Preservation Act of 1966 through the requirements of the National Environmental Policy Act of 1969.

Under NRC regulations, the original operating license for a nuclear power plant is issued for up to 40 years. The license may be renewed for up to an additional 20 years if NRC requirements are met. The current operating license for CNS Unit 1 will expire in January 18, 2014. Provided for your information is the CNS Unit 1 Site Layout (Enclosure 1) and Transmission Line Map (Enclosure 2). Additionally, attached you will find a compact disk containing copies of the license renewal application and the GEIS.

The GEIS considered the environmental impacts of renewing nuclear power plant operating licenses for a 20-year period on all currently operating sites. In the GEIS the NRC staff identified 92 environmental issues and developed generic conclusions related to environmental impacts for 69 of these issues that apply to all plants or to plants with specific design or site characteristics. For the remaining 23 issues, plant-specific analyses will be documented in a supplement to the GEIS.

A Supplemental Environmental Impact Statement will be prepared for CNS Unit 1 to document the staff's review of environmental impacts related to terrestrial ecology, aquatic ecology, hydrology, cultural resources, and socioeconomic issues (among others), and will contain a recommendation regarding the environmental acceptability of the license renewal action.

- 2 -

Please submit any comments that you may have to offer on the scope of the environmental review by March 27, 2009. Written comments should be submitted by mail to the Chief, Rules and Directives Branch, Division of Administrative Services, Mail Stop T-6D59, U.S. Nuclear Regulatory Commission, Washington D.C. 20555-0001. Electronic comments may be submitted to the NRC by e-mail at CooperEIS@nrc.gov. At the conclusion of the scoping process, the NRC staff will prepare a summary of the significant issues identified and the conclusions reached, and mail a copy to you.

To accommodate interested members of the public, the NRC will hold two public scoping meetings for the CNS Unit 1 license renewal supplement to the GEIS on February 25, 2008. The first session will be held in the afternoon at the Brownville Concert Hall at 126 Atlantic Street, Brownville, NE 68321, telephone (402) 825-3331. The second session, covering the same subjects will be held in the evening at the Auburn Senior Center at 1101 J Street, Auburn, NE 68305, telephone (402) 274 3420. Additionally, the NRC staff will host informal discussions one hour before the start of each session. You and your staff are invited to attend the public meetings.

The CNS Unit 1 license renewal application and the GEIS are available on the internet at <http://www.nrc.gov/reactors/operating/licensing/renewal/applications/cooper.html>. In addition, the Auburn Memorial Library, 1810 Courthouse Avenue, Auburn, NE 68305, telephone (402) 274-4023, has agreed to make the license renewal application and the GEIS available for public inspection.

The staff expects to publish the draft Supplemental Environmental Impact Statement in December 2009. A copy of the document will be sent to you for your review and comment. The NRC will hold another set of public meetings in the site vicinity to solicit comments on the draft Supplemental Environmental Impact Statement. After consideration of public comments received, the NRC will prepare a final Supplemental Environmental Impact Statement, which is scheduled to be issued in July 2010.

The NRC is sending this letter to the tribal contacts for the following Federally-recognized tribes: Prairie Band of Potawatomi Indians, Iowa Tribe of Kansas and Nebraska, Iowa Tribe of Oklahoma, Kickapoo Tribe in Kansas, Otoe-Missouria Tribe of Indians, Omaha Tribe of Nebraska, Sac and Fox Nation of Missouri, Sac and Fox Nation of Oklahoma, and the Sac and Fox Tribe of Mississippi in Iowa.

If you need additional information regarding the license renewal review process, please contact Tam Tran, by telephone, 1-800-368-5642, extension 3617, or by e-mail at tam.tran@nrc.gov, or

Appendix D

- 3 -

Emmanuel Sayoc, by telephone, 1-800-368-5642, extension 1924, or by e-mail at emmanuel.sayoc@nrc.gov.

Sincerely,

/RA/


David L. Pelton, Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation


Docket No. 50-298

Enclosures:

1. Site Layout
2. Transmission Line Map

cc w/encls: See next page





Emmanuel Sayoc

From: CooperEIS Resource
Sent: Thursday, April 16, 2009 1:39 PM
To: Emmanuel Sayoc
Subject: FW: Scoping Comments for Relicensing of Cooper Nuclear Station, Brownville, NE

-----Original Message-----

From: Shepard.Larry@epamail.epa.gov [mailto:Shepard.Larry@epamail.epa.gov]
Sent: Friday, March 27, 2009 4:59 PM
To: CooperEIS Resource
Cc: Cothem.Joe@epamail.epa.gov; Hooper.CharlesA@epamail.epa.gov; Dunn.John@epamail.epa.gov; Lancaster.Kris@epamail.epa.gov
Subject: Scoping Comments for Relicensing of Cooper Nuclear Station, Brownville, NE

RE: Notice of Intent to Prepare an Environmental Impact Statement and Conduct Scoping Process for Cooper Nuclear Station; Federal Register Volume 74, No. 15, January 26, 2009, page 4476.

Thank you for the opportunity to provide scoping comments on the proposed relicensing of Cooper Nuclear Station (CNS), in support of the U.S. Nuclear Regulatory Commission's (NRC) preparation of an Environmental Impact Statement (EIS). EPA reviewed this project in accordance with the National Environmental Policy Act (NEPA) and Section 309 of the Clean Air Act. We request that, in the future, the NRC provide an adequate period of time after conducting site audits for the submission of scoping comments by state or federal agencies. In this instance, scoping comments are to be submitted prior to the NRC site audit for this project.

Please consider the following comments during the EIS development process.

Radiation - Given the uncertainty involved with licensing the Yucca Mountain Nevada facility and the extremely long time-frames needed to secure Congressional approval and complete site preparation for any possible alternative permanent site for the disposal of spent nuclear fuel, all utilities planning on extending operation of existing nuclear units should consider contingencies for long-term storage of waste on-site.

Water Quality - The current CNS site has an existing infrastructure, which includes intake and discharge structures. The source of water for the plant is the Missouri River. Potential impacts to plant operation associated with available river flow, particularly during periods of sustained low flow, should be thoroughly described in the draft EIS. The draft EIS should articulate the assurance of a long-term water supply (i.e., greater than 20 years) for the operation of the reactor. This analysis should address contingencies created by changing regional climate and potential future changes in the operation of the river by the Army Corps of Engineers (i.e., flow

releases). The current facility is covered by a National Pollutant Discharge Elimination System (NPDES) permit issued by the Nebraska Department of Environmental Quality (NDEQ). New studies and analyses performed in support of the most recent permit application (e.g., thermal and chemical discharges) should be included in the draft EIS. The draft EIS should also completely discuss issues associated with entrainment and impingement of aquatic organisms (i.e., Section 316b of the Clean Water Act) and include alternatives to the present intake design. From a review of the Environmental Report, it is apparent that there is a great deal of information available regarding the impact of plant operation on the river ecosystem. However, we generally caution that these studies are 30 years old and the draft EIS should clearly articulate whether these data are representative of current river condition and ecological impact. We would expect the NRC to provide both its reasoning and data supporting that additional and more recent research is not required to adequately document current impacts.

The draft EIS should thoroughly characterize past contamination associated with the operation of CNS, particularly source and fate of tritium in the system, and document current condition of surface water and groundwater upstream and downstream from the site.

Environmental Management System - The Council on Environmental Quality (CEQ) published "Aligning NEPA processes with Environmental management Systems-A Guide for NEPA and EMS Practitioners" to improve NEPA implementation and environmental sustainability goals in NEPA and Executive Order 13423. The NEPA document should discuss EMS as appropriate.

Larry Shepard
NEPA Team/Interstate Waters
US EPA Region 7
913-551-7441

Richard Bulavinetz

From: Simpson, Rachel [rachel.simpson@nebraska.gov]
Sent: Friday, May 08, 2009 4:11 PM
To: Richard Bulavinetz
Subject: RE: Cooper Nuclear Station (CNS) - T & E: & List of Species of Concern
Attachments: NNHP - species by county list for selected Nebraska counties.xls

Dear Mr. Bulavinetz,

Thank you for your inquiry regarding information our program has on species which potentially occur in the following counties: Nemaha County, Johnson County, Gage County, Lancaster County, Saline County, Fillmore County, York County, Hamilton County, and Merrick County.

Attached is the information you requested. Please don't hesitate to contact me if you have any questions about the interpretation of the data or would like additional information.

Sincerely,
Rachel

Rachel Simpson
 Data Manager
 Nebraska Natural Heritage Program
 Nebraska Game and Parks Commission
 2200 N. 33rd St.
 Lincoln, NE 68503
rachel.simpson@nebraska.gov
 402-471-5427

From: Schneider, Rick
Sent: Thursday, April 30, 2009 2:56 PM
To: Simpson, Rachel
Cc: Richard.Bulavinetz@nrc.gov
Subject: FW: Cooper Nuclear Station (CNS) - T & E: & List of Species of Concern

Rachel,

Could you send Richard a list of species, by county (see list below), for which we have records in the database. For each species, list the federal and state status, Legacy status, and species in need of conservation status. Also, could you include on the list those state or federally listed species which may occur in the county, even though we currently have no records. Richard is with a federal agency so there will be no charge for the data request.

Let me know if you have questions or you could contact Richard.
Thanks.

Rick Schneider
 Coordinator/Ecologist
 Nebraska Natural Heritage Program
 Nebraska Game and Parks Commission
 2200 N. 33rd St.
 Lincoln, NE 68503

Rick.Schneider@nebraska.gov

Appendix D

402-471-5569

Please note new email address

From: Richard Bulavinetz [Richard.Bulavinetz@nrc.gov]
Sent: Thursday, April 30, 2009 2:40 PM
To: Schneider, Rick
Subject: Cooper Nuclear Station (CNS) - T & E; & List of Species of Concern

Rick:

Per our conversation 2 mins ago - here is my e-mail address.
The counties is question are:

Nemaha County, Johnson County, Gage County, Lancaster County, Saline County, Fillmore County, York
County, Hamilton County, and Merrick County

Thanks for your help.

Rich

Richard E. Bulavinetz
Aquatic Ecologist
Nuclear Regulatory Commission
Rockville, MD 20852
301-415-3607
301-415-2002 (fax)
richard.bulavinetz@nrc.gov<mailto:richard.bulavinetz@nrc.gov>

<')|||>< <')|||>< <')|||>< <')|||>< <')|||><

Species-by-County List for Selected Nebraska Counties
List produced May 8, 2009 by the Nebraska Natural Heritage Program

Source indicates whether the information came from existing records in the Nebraska Natural Heritage Database (source="Heritage DB") or from the Nebraska Natural Heritage Program's set of range maps for Threatened and Endangered Species (source="Listed Species Range Maps")

Source	COUNTY	SNAME	SCONNAME	GNANE	GCNAME	STATE_STAT	FED_STAT	LGCY_STAT	S_RANK	G_RANK	ELEMENT_TY	CATEGORY
Heritage DB	Filmore	Belairus lentiginosus	American Blizen	Bolairus lentiginosus	American Blizen			Tier 2	S4	G4	Vertebrate Animal	A
Heritage DB	Filmore	Circus cyaneus	Northam Hamor	Circus cyaneus	Northam Hamor			Tier 2	S4	G5	Vertebrate Animal	A
Heritage DB	Filmore	Cistothorus platensis	Sedge Wren	Cistothorus platensis	Sedge Wren			Tier 2	S3	G5	Vertebrate Animal	A
Heritage DB	Filmore	Elaeothus waffi	Wolf Sp. Kerush	Elaeothus waffi	Wolf's Sp. Kerush			Tier 1	S2	G3G4	Vascular Plant	P
Listed Species Range Maps	Filmore	Grus americana	Whooping Crane	Grus americana	Whooping Crane	E	F	Tier 1	S1	G1	Vertebrate Animal	A
Heritage DB	Filmore	Haliaeetus leucocephalus	Bald Eagle	Haliaeetus leucocephalus	Bald Eagle			Tier 1	S3	G5	Vertebrate Animal	A
Heritage DB	Filmore	Isoties melanocoda	Curlew	Isoties melanocoda	Blackfoot Quiltwren			Tier 2	S1	G5	Vascular Plant	P
Heritage DB	Filmore	Isoties melanocephala	Least Bittern	Isoties melanocephala	Least Bittern			Tier 2	S4	G5	Vertebrate Animal	A
Heritage DB	Filmore	Necturus gyrinus	Tadpole Madtom	Necturus gyrinus	Tadpole Madtom			Tier 2	S3	G5	Vertebrate Animal	A
Heritage DB	Filmore	Nycticorax nycticorax	Black-crowned Night-heron	Nycticorax nycticorax	Black-crowned Night-heron			Tier 2	S3	G5	Vertebrate Animal	A
Listed Species Range Maps	Filmore	Platanthera praecleara	Western Prairie Fringed Orchid	Platanthera praecleara	Western Prairie White-fringed CT		T	Tier 1	S2	G2	Vascular Plant	P
Heritage DB	Filmore	Rallus elegans	King Rat	Rallus elegans	King Rat			Tier 1	S1	G4	Vertebrate Animal	A
Heritage DB	Filmore	Scorpus heterochaetus	Slender Bulrush	Schoenoplectus heterochaetus	Slender Bulrush			Tier 2	S4	G5	Vascular Plant	P
Heritage DB	Filmore	Scorpus saximontanus	Rocky Mountain Bulrush	Schoenoplectus saximontanus	Rocky Mountain Bulrush			Tier 2	S1	G5	Vascular Plant	P
Heritage DB	Filmore	Sagittaria arifolia	Massasauga	Sagittaria arifolia	Massasauga		T	Tier 1	S1	G3G4	Vertebrate Animal	A
Heritage DB	Gage	Agelaius phoeniceus	Copperhead	Agelaius phoeniceus	Copperhead	NC		Tier 2	S2	G5	Vertebrate Animal	A
Heritage DB	Gage	Bidens polylepis	Coneopsis Boggar-tak	Bidens polylepis	Arness Boggar-tak			Tier 2	S2	G5	Vascular Plant	P
Heritage DB	Gage	Carex lasiocarpa	Burns Sedge	Carex lasiocarpa	Burns Sedge			Tier 2	S1S2	G4	Vascular Plant	P
Heritage DB	Gage	Carex frankii	Frank's Sedge	Carex frankii	Frank's Sedge			Tier 2	S1S2	G5	Vascular Plant	P
Heritage DB	Gage	Carex lasiocarpa	Lawn Sedge	Carex lasiocarpa	Leavenworth's Sedge			Tier 2	S3	G5	Vascular Plant	P
Heritage DB	Gage	Crotalus horridus	Timber Rattlesnake	Crotalus horridus	Timber Rattlesnake	NC		Tier 1	S1	G4	Vertebrate Animal	A
Heritage DB	Gage	Crotalus capitatus var. capatus	Woody Croon	Crotalus capitatus var. capatus	Woody Croon				S47	G57	Vascular Plant	P
Heritage DB	Gage	Ethoostema nigrum	Johnny Darter	Ethoostema nigrum	Johnny Darter			Tier 2	S3	G5	Vertebrate Animal	A
Heritage DB	Gage	Ethoostema spectabile	Orangethroat Darter	Ethoostema spectabile	Orangethroat Darter			Tier 2	S3	G5	Vertebrate Animal	A
Heritage DB	Gage	Eumecurus oregonus	Great Plains Skink	Eumecurus oregonus	Great Plains Skink	NC		Tier 2	S2	G5	Vertebrate Animal	A
Heritage DB	Gage	Gastrophysa olivacea	Great Plains Narrow-mouth Toad	Gastrophysa olivacea	Great Plains Narrow-mouth Toad	NC		Tier 2	S2	G5	Vertebrate Animal	A
Heritage DB	Gage	Haliaeetus leucocephalus	Bald Eagle	Haliaeetus leucocephalus	Bald Eagle			Tier 1	S3	G5	Vertebrate Animal	A
Heritage DB	Gage	Hieracium longifolium	Longbeard Hawkweed	Hieracium longifolium	Hairy Hawkweed			Tier 2	S4	G4G5	Vascular Plant	P
Heritage DB	Gage	Lamprolaima caligaster	Primo Keganate	Lamprolaima caligaster	Yellow-bellied Keganate	NC		Tier 2	S2	G5	Vertebrate Animal	A
Heritage DB	Gage	Ligumia sibirica	Perennissal	Ligumia sibirica	Rand Mussel			Tier 1	S1	G5	Vertebrate Animal	A
Heritage DB	Gage	Nycticorax nycticorax	Eastern Woodrat	Nycticorax nycticorax	Eastern Woodrat			Tier 2	S3	G5	Vertebrate Animal	A
Heritage DB	Gage	Necturus gyrinus	Tadpole Madtom	Necturus gyrinus	Tadpole Madtom			Tier 2	S3	G5	Vertebrate Animal	A
Heritage DB	Gage	Pellaea atropurpurea	Purple Cliff Brake	Pellaea atropurpurea	Purple-stem Cliff Brake			Tier 2	S2	G5	Vascular Plant	P
Heritage DB	Gage	Perispermum coccineum	Cobaea Perisperm	Perisperm coccineum	Cobaea Perisperm				S37	G4	Vascular Plant	P
Listed Species Range Maps	Gage	Platanthera praecleara	Western Prairie Fringed Orchid	Platanthera praecleara	Western Prairie White-fringed CT		I	Tier 1	S2	G2	Vascular Plant	P
Heritage DB	Gage	Rhynchospora alba	Graham's Clayfish Snake	Rhynchospora alba	Graham's Clayfish Snake	NC		Tier 2	S2	G5	Vertebrate Animal	A
Heritage DB	Gage	Sagittaria arifolia	Massasauga	Sagittaria arifolia	Massasauga		T	Tier 1	S1	G3G4	Vertebrate Animal	A
Heritage DB	Gage	Spartanum chlorocarpum	Spotted-stem Bur-reed	Spartanum chlorocarpum	Greenfruit Bur-reed			Tier 2	S2	G5	Vascular Plant	P
Heritage DB	Gage	Spizella monticola	Eastern Spotted Skunk	Spizella monticola	Eastern Spotted Skunk			Tier 2	S1	G5	Vertebrate Animal	A
Heritage DB	Gage	Trifolium reflexum	Buffalo Clover	Trifolium reflexum	Buffalo Clover			Tier 1	S1	G3G4	Vascular Plant	P
Heritage DB	Hamilton	Chamaedaphne nuttallii	Piping Plover	Chamaedaphne nuttallii	Piping Plover		T	Tier 1	S2	G3	Vertebrate Animal	A
Heritage DB	Hamilton	Cistothorus platensis	Sedge Wren	Cistothorus platensis	Sedge Wren			Tier 2	S1	G5	Vertebrate Animal	A
Heritage DB	Hamilton	Culebra inconstans	Brook Stickleback	Culebra inconstans	Brook Stickleback			Tier 2	S3	G5	Vertebrate Animal	A
Heritage DB	Hamilton	Cyprinodon candidum	Small White Lady's-slipper	Cyprinodon candidum	Small White Lady's-slipper		T	Tier 1	S1	G4	Vascular Plant	P
Heritage DB	Hamilton	Elaeothus waffi	Wolf Sp. Kerush	Elaeothus waffi	Wolf Sp. Kerush			Tier 1	S2	G3G4	Vascular Plant	P
Heritage DB	Hamilton	Ethoostema nigrum	Johnny Darter	Ethoostema nigrum	Johnny Darter			Tier 2	S3	G5	Vertebrate Animal	A
Heritage DB	Hamilton	Ethoostema spectabile	Orangethroat Darter	Ethoostema spectabile	Orangethroat Darter			Tier 2	S3	G5	Vertebrate Animal	A
Heritage DB	Hamilton	Falco peregrinus	Peregrine Falcon	Falco peregrinus	Peregrine Falcon			Tier 2	S1	G4	Vertebrate Animal	A
Heritage DB	Hamilton	Fundulus scudicus	Plains Topminnow	Fundulus scudicus	Plains Topminnow			Tier 1	S2	G4	Vertebrate Animal	A
Heritage DB	Hamilton	Grus americana	Whooping Crane	Grus americana	Whooping Crane	E	E	Tier 1	S1	G1	Vertebrate Animal	A
Heritage DB	Hamilton	Isoties melanocoda	Curlew	Isoties melanocoda	Blackfoot Quiltwren			Tier 2	S1	G5	Vascular Plant	P
Heritage DB	Hamilton	Lutra canadensis	River Otter	Lutra canadensis	North American River Otter		T	Tier 1	S2	G5	Vertebrate Animal	A
Heritage DB	Hamilton	Macrhybopsis galda	Surgeon Club	Macrhybopsis galda	Surgeon Club		E	Tier 1	S1	G3	Vertebrate Animal	A
Heritage DB	Hamilton	Necturus gyrinus	Tadpole Madtom	Necturus gyrinus	Tadpole Madtom			Tier 2	S3	G5	Vertebrate Animal	A
Heritage DB	Hamilton	Nycticorax nycticorax	Black-crowned Night-heron	Nycticorax nycticorax	Black-crowned Night-heron			Tier 2	S3	G5	Vertebrate Animal	A
Listed Species Range Maps	Hamilton	Platanthera praecleara	Western Prairie Fringed Orchid	Platanthera praecleara	Western Prairie White-fringed CT		T	Tier 1	S2	G2	Vascular Plant	P
Heritage DB	Hamilton	Spizella monticola	Eastern Spotted Skunk	Spizella monticola	Eastern Spotted Skunk			Tier 2	S1	G5	Vertebrate Animal	A
Heritage DB	Hamilton	Sterna antillarum adaltesus	Western Least Tern	Sterna antillarum adaltesus	Western Least Tern		E	Tier 1	S2	G47G5	Vertebrate Animal	A
Heritage DB	Johnson	Aesacus glabra var. arguta	Western Bur-Apple	Aesacus glabra var. arguta	Ohio Bur-Apple		E	Tier 2	S1S2	G577G6	Vascular Plant	P
Heritage DB	Johnson	Ammodramus hemilaevis	Hemilaevis Sparrow	Ammodramus hemilaevis	Hemilaevis Sparrow			Tier 1	S2	G4	Vertebrate Animal	A
Heritage DB	Johnson	Amoglossum stipitatum	Pale Indian plantain	Amoglossum stipitatum	Pale Indian plantain			Tier 2	S2	G4G5	Vascular Plant	P

Appendix D

Heritage DB	Johnson	Asclepias amplexicaulis	Clasping Milkweed	Asclepias amplexicaulis	Clasping Milkweed	Her 2	S1	G5	Vascular Plant	P	
Heritage DB	Johnson	Asclepias viridis	Spider Milkweed	Asclepias viridis	Spider Milkweed		S5	G4G5	Vascular Plant	P	
Heritage DB	Johnson	Asimina triloba	Pawpaw	Asimina triloba	Pawpaw		S4?	G5	Vascular Plant	P	
Heritage DB	Johnson	Clethra alnifolia	Sedge Wren	Clethra alnifolia	Sedge Wren	Tier 2	S3	G5	Vertebrate Animal	A	
Heritage DB	Johnson	Dasycodon macrophylla	Mullen Froglove	Dasycodon macrophylla	Mullen Froglove	Tier 2	S1	G4	Vascular Plant	P	
Heritage DB	Johnson	Desmodium cuspidatum	Tooted Tick-trefoil	Desmodium cuspidatum	Tooted Tick-trefoil		S2?	G5	Vascular Plant	P	
Heritage DB	Johnson	Dracopis parviflorum	American Dragonhead	Dracopis parviflorum	American Dragonhead		S1	G5	Vascular Plant	P	
Heritage DB	Johnson	Ethoecostema agrum	Johnny Darter	Ethoecostema agrum	Johnny Darter	Tier 2	S3	G5	Vertebrate Animal	A	
Heritage DB	Johnson	Lampropeltis calligaster	Prarie Kingsnake	Lampropeltis calligaster	Yellow-bellied Kingsnake	NC	Tier 2	S2	G5	Vertebrate Animal	A
Heritage DB	Johnson	Lampropeltis getula	Common Kingsnake	Lampropeltis getula	Common Kingsnake	NC	Tier 2	S1	G5	Vertebrate Animal	A
Heritage DB	Johnson	Liriodendron tulipifera	Peter's Cap Lily	Liriodendron tulipifera	Golden Gayfeather		Tier 2	S17	G5T47	Vascular Plant	P
Heritage DB	Johnson	Lilium michiganense	Tulip Cap Lily	Lilium michiganense	Michigan Lily		Tier 2	S3?	G3	Vascular Plant	P
Heritage DB	Johnson	Melica nitens	Tall Milk	Melica nitens	Three-flower Milkgrass		Tier 2	S1	G5	Vascular Plant	P
Heritage DB	Johnson	Ophisaurus attenuatus	Slender Glass Lizard	Ophisaurus attenuatus	Slender Glass Lizard	NC	Tier 2	S1	G5	Vertebrate Animal	A
Heritage DB	Johnson	Peristemon tuberosus	Funnel-tom Fenceseemon	Peristemon tuberosus	White-wand Beard-tongue		S1	G5	Vascular Plant	P	
Heritage DB	Johnson	Phlox pilularis	Succowitch Attraction	Phlox pilularis	Suckermouth Minnow		S4	G5	Vertebrate Animal	A	
Heritage DB	Johnson	Piscanthera praecox	Western Prairie Fringed Orchid	Piscanthera praecox	Western Prairie White-fringed CT	T	Tier 1	S2	G2	Vascular Plant	P
Heritage DB	Johnson	Senna maritima	Wild Senna	Senna maritima	Maryland Senna		Tier 2	S1S2	G5	Vascular Plant	P
Heritage DB	Johnson	Sisyrinchium albidum	Massasauga	Sisyrinchium albidum	Massasauga	T	Tier 1	S1	G3G4	Vertebrate Animal	A
Heritage DB	Johnson	Trodanis beccari	Small Venus-looking glass	Trodanis beccari	Elizabeth Venus-looking-glass		Tier 2	S1	G5	Vascular Plant	P
Heritage DB	Johnson	Veronicastrum virginicum	Culver's root	Veronicastrum virginicum	Culver's root		Tier 2	S1	G4	Vascular Plant	P
Heritage DB	Lancaster	Agalinis skinneriana	Pale False Froglove	Agalinis skinneriana	Pale False Froglove		SVA	G3G4	Vascular Plant	P	
Heritage DB	Lancaster	Ammodramus hennipowii	Hennipow's Sparrow	Ammodramus hennipowii	Hennipow's Sparrow		Tier 1	S2	G4	Vertebrate Animal	A
Heritage DB	Lancaster	Arabis shortii	Short's Rockcress	Arabis shortii	Short's Rockcress		Tier 2	S2	G5	Vascular Plant	P
Heritage DB	Lancaster	Ardea herodias	Great Blue Heron	Ardea herodias	Great Blue Heron		S4	G5	Vertebrate Animal	A	
Heritage DB	Lancaster	Ansaema draconium	Green Dragon	Ansaema draconium	Green Dragon		Tier 2	S2	G5	Vascular Plant	P
Heritage DB	Lancaster	Asclepias viridis	Spider Milkweed	Asclepias viridis	Spider Milkweed		S5	G4G5	Vascular Plant	P	
Heritage DB	Lancaster	Aster subulatus var. agulatus	Silvertop Aster	Symphoricarpos divaricatum	Silvertop Aster		Tier 2	S4?	G5	Vascular Plant	P
Heritage DB	Lancaster	Athyrium angustifolium	Low Shupper	Athyrium angustifolium	Low Shupper		Tier 1	S1	G3T3	Invertebrate Animal	A
Heritage DB	Lancaster	Blechnum hirsutum	Wood-nut	Blechnum hirsutum	Hairy Wood-nut		Tier 2	S1	G5?	Vascular Plant	P
Heritage DB	Lancaster	Bolitoglossa lentiginosa	American Blimie	Bolitoglossa lentiginosa	American Blimie		Tier 2	S4	G4	Vertebrate Animal	A
Heritage DB	Lancaster	Carex crux-corni	Haver's Hair Sedge	Carex crux-corni	Haver's Hair Sedge		S1	G5	Vascular Plant	P	
Heritage DB	Lancaster	Carex squarrosa	Squarrose Sedge	Carex squarrosa	Squarrose Sedge		SVA	G4G5	Vascular Plant	P	
Heritage DB	Lancaster	Cicindela rebecca trichiana	A Tiger Beetle	Cicindela rebecca trichiana	Salt Creek Tiger Beetle	E	Tier 1	S1	G5T1	Invertebrate Animal	A
Heritage DB	Lancaster	Cicindela togata	A Tiger Beetle	Cicindela togata	White-backed Tiger Beetle		Tier 2	S1	G5	Invertebrate Animal	A
Heritage DB	Lancaster	Clethra alnifolia	Sedge Wren	Clethra alnifolia	Sedge Wren		Tier 2	S3	G5	Vertebrate Animal	A
Heritage DB	Lancaster	Colinus virginianus	Northern Bobwhite	Colinus virginianus	Northern Bobwhite		Tier 2	S5	G5	Vertebrate Animal	A
Heritage DB	Lancaster	Corydalis aurea	Golden Corydalis	Corydalis aurea	Golden Corydalis		Tier 2	S1	G5	Vascular Plant	P
Heritage DB	Lancaster	Crotalus capitatus var. capitatus	Woody Crotal	Crotalus capitatus var. capitatus	Ringsnake		S5?	G5T5?	Vascular Plant	P	
Heritage DB	Lancaster	Culex inornatus	Bronx Sandpiper	Culex inornatus	Golden Sandpiper		Tier 2	S3	G5	Vertebrate Animal	A
Heritage DB	Lancaster	Cygnus buccinator	Trumpeter Swan	Cygnus buccinator	Trumpeter Swan		Tier 1	S3	G4	Vertebrate Animal	A
Heritage DB	Lancaster	Cypripedium candidum	Small White Lady's-slipper	Cypripedium candidum	Small White Lady's-slipper	T	Tier 1	S1	G4	Vascular Plant	P
Heritage DB	Lancaster	Dracopis parviflorum	American Dragonhead	Dracopis parviflorum	American Dragonhead		S1	G5	Vascular Plant	P	
Heritage DB	Lancaster	Eragrostis reptans	Hairy Creeping Lovegrass	Eragrostis reptans	Hairy Creeping Lovegrass		S1	G5	Vascular Plant	P	
Heritage DB	Lancaster	Erythronium inconspicuum	Small Yellow Flower	Erythronium inconspicuum	Small Yellow Flower		Tier 2	S2	G5	Vascular Plant	P
Heritage DB	Lancaster	Erythronium mesochoreum	Fairie Dog-tooth violet	Erythronium mesochoreum	Mildred Family		Tier 2	S2	G4G5	Vascular Plant	P
Heritage DB	Lancaster	Eupatorium serotinum	Late Boneset	Eupatorium serotinum	Late-flowering Thoroughwort		S5?	G5	Vascular Plant	P	
Heritage DB	Lancaster	Falco peregrinus	Peregrine Falcon	Falco peregrinus	Peregrine Falcon		Tier 2	S1	G4	Vertebrate Animal	A
Heritage DB	Lancaster	Gallinago delicata	Wilson's Snipe	Gallinago delicata	Wilson's Snipe		Tier 2	S4	G5	Vertebrate Animal	A
Heritage DB	Lancaster	Haliaeetus leucocoryphus	Bald Eagle	Haliaeetus leucocoryphus	Bald Eagle		Tier 1	S3	G5	Vertebrate Animal	A
Heritage DB	Lancaster	Hesperis matronalis var. curassavicum	Sea-isle Heliotrope	Hesperis matronalis var. curassavicum	Curassavicum		Tier 2	S1	G4H	Vascular Plant	P
Heritage DB	Lancaster	Hieracium longepetium	Longbeard Fawnwood	Hieracium longepetium	Hairy Hawkweed		S4	G4G5	Vascular Plant	P	
Heritage DB	Lancaster	Ichthyophaga exilis	Least Bittern	Ichthyophaga exilis	Least Bittern		Tier 2	S4	G5	Vertebrate Animal	A
Heritage DB	Lancaster	Lampropeltis calligaster	Prarie Kingsnake	Lampropeltis calligaster	Yellow-bellied Kingsnake	NC	Tier 2	S2	G5	Vertebrate Animal	A
Heritage DB	Lancaster	Lampropeltis getula	Common Kingsnake	Lampropeltis getula	Common Kingsnake	NC	Tier 2	S1	G5	Vertebrate Animal	A
Heritage DB	Lancaster	Larus ludovicianus	Loggerhead Shrike	Larus ludovicianus	Loggerhead Shrike		S3	G4	Vertebrate Animal	A	
Heritage DB	Lancaster	Lateralis jamaicensis	Black Rail	Lateralis jamaicensis	Black Rail		Tier 2	S1	G4	Vertebrate Animal	A
Heritage DB	Lancaster	Ligumia substriata	Pondmussel	Ligumia substriata	Pondmussel		Tier 1	S1	G5	Invertebrate Animal	A
Heritage DB	Lancaster	Mustela nivalis	Least Weasel	Mustela nivalis	Least Weasel		S5	G5	Vertebrate Animal	A	
Heritage DB	Lancaster	Mynophyllum pinnatum	Cutleaf Water Milfoil	Mynophyllum pinnatum	Cutleaf Water Milfoil		S1	G5	Vascular Plant	P	
Heritage DB	Lancaster	Nicrophorus americanus	American Burying Beetle	Nicrophorus americanus	American Burying Beetle	E	Tier 1	S1	G2G3	Invertebrate Animal	A
Heritage DB	Lancaster	Nottus heterolepis	Blacknose Shiner	Nottus heterolepis	Blacknose Shiner	E	Tier 1	S1	G4	Vertebrate Animal	A
Heritage DB	Lancaster	Notropis topaka	Topeka Shiner	Notropis topaka	Topeka Shiner	E	Tier 1	S1	G3	Vertebrate Animal	A
Heritage DB	Lancaster	Nuphar variegata	Yellow pond-lily	Nuphar variegata	Yellow pond-lily		Tier 2	S2	G4R	Vascular Plant	P
Heritage DB	Lancaster	Nymphaea odorata	White Water-lily	Nymphaea odorata	American Water-lily		Tier 2	S2?	G5	Vascular Plant	P
Heritage DB	Lancaster	Ombanicha uniflora	One-flowered Broomrape	Ombanicha uniflora	One-flowered Broomrape		Tier 2	S1	G5	Vascular Plant	P
Heritage DB	Lancaster	Pendemon coccinea	Cobweb Penstemon	Pendemon coccinea	Cobweb Penstemon		S3?	G4	Vascular Plant	P	
Heritage DB	Lancaster	Pimephales notatus	Bluntnose Minnow	Pimephales notatus	Bluntnose Minnow		Tier 2	S3	G5	Vertebrate Animal	A
Heritage DB	Lancaster	Potamogeton elongata	Slender Plantain	Potamogeton elongata	Slender Plantain		S3	G4	Vascular Plant	P	
Heritage DB	Lancaster	Piscanthera praecox	Western Prairie Fringed Orchid	Piscanthera praecox	Western Prairie White-fringed CT	T	Tier 1	S3	G3	Vascular Plant	P

Heritage DB	Lancaster	<i>Portulaca oleraceae</i>	Blue-gray Gravelchick	<i>Follicularia caerulea</i>	Blue-gray Gravelchick	Tier 2	S4	G5	Vascular Animal	A	
Heritage DB	Lancaster	<i>Portulaca oleraceae</i>	Water-Frac Pondweed	<i>Potamogeton diversifolius</i>	Water-Frac Pondweed	Tier 2	S2	G5	Vascular Plant	P	
Heritage DB	Lancaster	<i>Rattus elegans</i>	King Rat	<i>Rattus elegans</i>	King Rat	Tier 1	S1	G4	Vascular Animal	A	
Heritage DB	Lancaster	<i>Regina grahami</i>	Graham's Crayfish Snake	<i>Regina grahami</i>	Graham's Crayfish Snake	NC	Tier 2	S2	G5	Vascular Animal	A
Heritage DB	Lancaster	<i>Sagittaria rigida</i>	Stiff Arrowhead	<i>Sagittaria rigida</i>	Stiff Arrowhead	Tier 2	S3	G5	Vascular Plant	P	
Heritage DB	Lancaster	<i>Salsola vermiculata</i>	Saltwort	<i>Salsola vermiculata</i>	Saltwort	Tier 1	S1	G5	Vascular Plant	P	
Heritage DB	Lancaster	<i>Senna maritima</i>	Wild Senna	<i>Senna maritima</i>	Wild Senna	Tier 2	S1S2	G5	Vascular Plant	P	
Heritage DB	Lancaster	<i>Sisyrinchium albidum</i>	Massachusetts	<i>Sisyrinchium albidum</i>	Massachusetts	T	Tier 1	S1	G3G4	Vascular Animal	A
Heritage DB	Lancaster	<i>Sparganium pectinatum</i>	Eastern Spotted Skunk	<i>Sparganium pectinatum</i>	Eastern Spotted Skunk	Tier 2	S1	G5	Vascular Animal	A	
Heritage DB	Lancaster	<i>Spiranthes veris</i>	Early Lady's-tresses	<i>Spiranthes veris</i>	Early Lady's-tresses	Tier 2	S27	G5	Vascular Plant	P	
Heritage DB	Lancaster	<i>Sporobolus laxus</i>	Texas Dropseed	<i>Sporobolus laxus</i>	Texas Dropseed	Tier 2	S1	G5	Vascular Plant	P	
Heritage DB	Lancaster	<i>Strix varia</i>	Barred Owl	<i>Strix varia</i>	Barred Owl	Tier 2	S2	G5	Vascular Animal	A	
Heritage DB	Lancaster	<i>Sturmia magna</i>	Eastern Meadowlark	<i>Sturmia magna</i>	Eastern Meadowlark	Tier 2	S5	G5	Vascular Animal	A	
Heritage DB	Lancaster	<i>Thamnotropis proximus</i>	Western Ribbon Snake	<i>Thamnotropis proximus</i>	Western Ribbon Snake	NC	Tier 2	S2	G5	Vascular Animal	A
Heritage DB	Lancaster	<i>Trifolium reflexum</i>	Buffalo Clover	<i>Trifolium reflexum</i>	Buffalo Clover	Tier 2	S1	G3G4	Vascular Plant	P	
Heritage DB	Lancaster	<i>Urtica dioica</i>	Southern Stinging Nettle	<i>Urtica dioica</i>	Southern Stinging Nettle	Tier 2	S1	G5	Vascular Plant	P	
Heritage DB	Lancaster	<i>Verbena stricta</i>	Narrowleaf Verbena	<i>Verbena stricta</i>	Narrowleaf Verbena	Tier 1	S5	G5	Vascular Animal	A	
Heritage DB	Lancaster	<i>Vitis rotundifolia</i>	Bell's Vine	<i>Vitis rotundifolia</i>	Bell's Vine	Tier 2	S1	G5	Vascular Plant	P	
Heritage DB	Merrick	<i>Agalinis purpurea</i>	Large Purple False Foxglove	<i>Agalinis purpurea</i>	Large Purple False Foxglove	Tier 2	S17	G5	Vascular Plant	P	
Heritage DB	Merrick	<i>Charadrius melodus</i>	Piping Plover	<i>Charadrius melodus</i>	Piping Plover	T	Tier 1	S7	G5	Vascular Animal	A
Heritage DB	Merrick	<i>Culex inornatus</i>	Brook Stickleback	<i>Culex inornatus</i>	Brook Stickleback	T	Tier 2	S3	G5	Vascular Animal	A
Heritage DB	Merrick	<i>Cypripedium canadense</i>	Small White Lady's-slipper	<i>Cypripedium canadense</i>	Small White Lady's-slipper	T	Tier 1	S1	G4	Vascular Plant	P
Heritage DB	Merrick	<i>Erechtosium atrorubens</i>	Purple Spikeweed	<i>Erechtosium atrorubens</i>	Purple Spikeweed	Tier 2	S1	G4G5	Vascular Plant	P	
Heritage DB	Merrick	<i>Falco peregrinus</i>	Peregrine Falcon	<i>Falco peregrinus</i>	Peregrine Falcon	Tier 2	S1	G4	Vascular Animal	A	
Heritage DB	Merrick	<i>Fundulus sciencii</i>	Plains Topminnow	<i>Fundulus sciencii</i>	Plains Topminnow	Tier 1	S2	G4	Vascular Animal	A	
Heritage DB	Merrick	<i>Grus americana</i>	Whooping Crane	<i>Grus americana</i>	Whooping Crane	E	Tier 1	S1	G1	Vascular Animal	A
Heritage DB	Merrick	<i>Haliaeetus leucocephalus</i>	Bald Eagle	<i>Haliaeetus leucocephalus</i>	Bald Eagle	Tier 1	S3	G5	Vascular Animal	A	
Heritage DB	Merrick	<i>Hesperis matronalis</i>	Frostweed	<i>Hesperis matronalis</i>	Frostweed	Tier 2	S1S2	G5	Vascular Plant	P	
Heritage DB	Merrick	<i>Immunaria pinnatifida</i>	Pinna River Caddisfly	<i>Immunaria pinnatifida</i>	Pinna River Caddisfly	Tier 1	SNR	G1G2	Invertebrate Animal	A	
Heritage DB	Merrick	<i>Leucospiza montana</i>	Narrowwinged Palesnake	<i>Leucospiza montana</i>	Narrowwinged Palesnake	Tier 2	S1	G5	Vascular Plant	P	
Heritage DB	Merrick	<i>Liocichlopsis vermis</i>	Smooth Green Snake	<i>Liocichlopsis vermis</i>	Smooth Green Snake	NC	Tier 2	S1	G5	Vascular Animal	A
Heritage DB	Merrick	<i>Lutra canadensis</i>	River Otter	<i>Lutra canadensis</i>	North American River Otter	T	Tier 1	S2	G5	Vascular Animal	A
Heritage DB	Merrick	<i>Macropygia perspicillata</i>	Surgeon Club	<i>Macropygia perspicillata</i>	Surgeon Club	E	Tier 1	S1	G3	Vascular Animal	A
Heritage DB	Merrick	<i>Margaritana margaritula</i>	Peel Dace	<i>Margaritana margaritula</i>	Peel Dace	Tier 1	S2	G5	Vascular Animal	A	
Heritage DB	Merrick	<i>Melanerpes formicivorus</i>	Esikine Cuckoo	<i>Melanerpes formicivorus</i>	Esikine Cuckoo	E	Tier 1	SX	G5	Vascular Animal	A
Heritage DB	Merrick	<i>Phoxinus phoxinus</i>	Finescale Dace	<i>Phoxinus phoxinus</i>	Finescale Dace	T	Tier 1	S2	G5	Vascular Animal	A
Heritage DB	Merrick	<i>Pimephales notatus</i>	Burrowing Minnow	<i>Pimephales notatus</i>	Burrowing Minnow	Tier 2	S3	G5	Vascular Animal	A	
Heritage DB	Merrick	<i>Plantago elongata</i>	Plantain	<i>Plantago elongata</i>	Plantain	Tier 2	S1	G4	Vascular Plant	P	
Heritage DB	Merrick	<i>Platanthera praecox</i>	Western Prairie Fringed Orchid	<i>Platanthera praecox</i>	Western Prairie White-fringed C	T	Tier 1	S2	G7	Vascular Plant	P
Heritage DB	Merrick	<i>Sperula idaea</i>	Regal Flycatcher	<i>Sperula idaea</i>	Regal Flycatcher	Tier 1	S3	G3	Invertebrate Animal	A	
Heritage DB	Merrick	<i>Sterna antillarum adaeata</i>	Interior Least Tern	<i>Sterna antillarum adaeata</i>	Interior Least Tern	E	Tier 1	S2	G1Z0	Vascular Animal	A
Heritage DB	Nemaha	<i>Actinostemura lutescens</i>	Lake Sturgeon	<i>Actinostemura lutescens</i>	Lake Sturgeon	T	Tier 1	S1	G3G4	Vascular Animal	A
Heritage DB	Nemaha	<i>Amblystoma texanum</i>	Smallmouth Salamander	<i>Amblystoma texanum</i>	Smallmouth Salamander	NC	Tier 2	S1	G5	Vascular Animal	A
Heritage DB	Nemaha	<i>Amelanchier arborea</i>	Juniberry	<i>Amelanchier arborea</i>	Dowry Serviceberry	Tier 2	S37	G5	Vascular Plant	P	
Heritage DB	Nemaha	<i>Ampelopsis cordata</i>	Racoon Grape	<i>Ampelopsis cordata</i>	Heartleaf Peppercorn	Tier 2	S37	G5	Vascular Plant	P	
Heritage DB	Nemaha	<i>Anagallis minima</i>	Chaffweed	<i>Anagallis minima</i>	Chaffweed	Tier 2	S1	G5	Vascular Plant	P	
Heritage DB	Nemaha	<i>Arabis canadensis</i>	Stickpod	<i>Arabis canadensis</i>	Stickpod	Tier 2	S47	G5	Vascular Plant	P	
Heritage DB	Nemaha	<i>Artemisia tridentata</i>	Sprenger	<i>Artemisia tridentata</i>	Artemisia	Tier 2	S1	G4G5	Vascular Plant	P	
Heritage DB	Nemaha	<i>Amoglossum striatellatum</i>	Pale Indian-plantain	<i>Amoglossum striatellatum</i>	Pale Indian-plantain	Tier 2	S2	G4G5	Vascular Plant	P	
Heritage DB	Nemaha	<i>Asclepias tuberosa</i>	Clasping-leaf Milkweed	<i>Asclepias tuberosa</i>	Clasping Milkweed	Tier 2	S1	G5	Vascular Plant	P	
Heritage DB	Nemaha	<i>Asclepias purpurascens</i>	Purple Milkweed	<i>Asclepias purpurascens</i>	Purple Milkweed	Tier 2	S1	G57	Vascular Plant	P	
Heritage DB	Nemaha	<i>Asimina triloba</i>	Pawpaw	<i>Asimina triloba</i>	Pawpaw	Tier 2	S47	G5	Vascular Plant	P	
Heritage DB	Nemaha	<i>Coronopus didymus</i>	Coronopus beggar-lick	<i>Coronopus didymus</i>	American Eggplant	Tier 2	S2	G5	Vascular Plant	P	
Heritage DB	Nemaha	<i>Bursera umbellata</i>	Ruffed Grouse	<i>Bursera umbellata</i>	Ruffed Grouse	Tier 2	SX	G5	Vascular Animal	A	
Heritage DB	Nemaha	<i>Brachyelytrum erectum</i>	Bearded Wood Grass	<i>Brachyelytrum erectum</i>	Bearded Shortspur	Tier 2	S2	G5	Vascular Plant	P	
Heritage DB	Nemaha	<i>Cannabis sativa</i>	Whip-poor-will	<i>Cannabis sativa</i>	Whip-poor-will	Tier 2	S1	G5	Vascular Plant	P	
Heritage DB	Nemaha	<i>Cardamine concatenata</i>	Cutleaf Toothwort	<i>Cardamine concatenata</i>	Cutleaf Toothwort	Tier 2	S1	G5	Vascular Plant	P	
Heritage DB	Nemaha	<i>Carex crux-cornu</i>	Raven's Foot Sedge	<i>Carex crux-cornu</i>	Ravenfoot Sedge	Tier 2	S1	G5	Vascular Plant	P	
Heritage DB	Nemaha	<i>Carex frankii</i>	Frank's Sedge	<i>Carex frankii</i>	Frank's Sedge	Tier 2	S1S2	G5	Vascular Plant	P	
Heritage DB	Nemaha	<i>Carex jamesii</i>	Grass Sedge	<i>Carex jamesii</i>	Nebraska Sedge	Tier 2	S57	G5	Vascular Plant	P	
Heritage DB	Nemaha	<i>Carphoxiphium vermis</i>	Worm Snake	<i>Carphoxiphium vermis</i>	Worm Snake	NC	Tier 2	S2	G5	Vascular Animal	A
Heritage DB	Nemaha	<i>Cistothorus platensis</i>	Sedge Wren	<i>Cistothorus platensis</i>	Sedge Wren	Tier 2	S3	G5	Vascular Animal	A	
Heritage DB	Nemaha	<i>Coccoloba virginica</i>	Long-Bract Green Orchid	<i>Coccoloba virginica</i>	Long-bract Green Orchid	Tier 2	S1	G5	Vascular Plant	P	
Heritage DB	Nemaha	<i>Comarostaphyle wisteriana</i>	Spring Coral-root	<i>Comarostaphyle wisteriana</i>	Spring Coralroot	Tier 2	S1	G5	Vascular Plant	P	
Heritage DB	Nemaha	<i>Cornus racemosa</i>	Gray Dogwood	<i>Cornus racemosa</i>	Gray Dogwood	Tier 2	S1	G57	Vascular Plant	P	
Heritage DB	Nemaha	<i>Croton glandulosus var. septentrionalis</i>	Sand Croton	<i>Croton glandulosus var. septentrionalis</i>	Northern Croton	Tier 2	S47	G57	Vascular Plant	P	
Heritage DB	Nemaha	<i>Cyrtopogon elongatus</i>	Blue Sucker	<i>Cyrtopogon elongatus</i>	Blue Sucker	Tier 1	S1	G3G4	Vascular Animal	A	
Heritage DB	Nemaha	<i>Cypripedium parviflorum</i>	Yellow Lady's-slipper	<i>Cypripedium parviflorum</i>	Yellow Lady's slipper	Tier 2	S1	G5	Vascular Plant	P	
Heritage DB	Nemaha	<i>Dasyloma maculipylis</i>	Mullein Foxglove	<i>Dasyloma maculipylis</i>	Mullein Foxglove	Tier 2	S1	G4	Vascular Plant	P	
Heritage DB	Nemaha	<i>Dracontopogon parviflorum</i>	American Dragonhead	<i>Dracontopogon parviflorum</i>	American Dragonhead	Tier 2	S1	G5	Vascular Plant	P	

Brady, Bennett

From: Robert_Harms@fws.gov
Sent: Friday, March 19, 2010 5:19 PM
To: Brady, Bennett; Bulavinetz, Richard
Cc: jlcitta@nppd.com; John_Cochnar@fws.gov
Subject: Concurrence Cooper Nuclear Station
Attachments: CNS concurrence.pdf

Importance: High

Ms. Brady/Mr. Bulavinetz:

Please make reference to your February 18, 2010, letter requesting that the U.S. Fish and Wildlife Service (Service) concur with a determination of affect made by the Nuclear Regulatory Commission that continued operation of the Cooper Nuclear Station for an additional 20 years may affect, but is not likely to adversely affect the federally endangered pallid sturgeon. The Service has completed its review of the Biological Assessment included within the Environmental Impact Statement for the proposed project and has determined that it is satisfactory. The Service previously provided its concurrence in a letter dated August 26, 2009, which would conclude section 7 consultation on this matter. It is attached for your use.

(See attached file: CNS concurrence.pdf)

Bob

Robert R. Harms
Fish and Wildlife Biologist
U.S. Fish and Wildlife Service
203 West Second Street
Grand Island, Nebraska 68801
Phone: 308-382-6468, Extension 17
Fax: 308-384-8835
robert_harms@fws.gov



United States Department of the Interior

FISH AND WILDLIFE SERVICE

Ecological Services
Nebraska Field Office
203 West Second Street
Grand Island, Nebraska 68801

August 26, 2009

Mr. Joe Citta
Corporate Environmental Manager
Nebraska Public Power District
1414 15th Street
Columbus, NE 68801

RE: Cooper Nuclear Station License Renewal, Nebraska Public Power District

Dear Mr. Citta:


This is in response to your August 25, 2009, letter with an enclosed Memorandum of Understanding and Restrictive Covenant for Conservation. Both enclosures have been signed and executed and demonstrate the Nebraska Public Power District (NPPD) and Nuclear Regulatory Commission (NRC) intention to offset adverse affects to federally listed species resulting from the proposed Cooper Nuclear Station License Renewal.

After reviewing your August 25 letter, the U.S. Fish and Wildlife Service (Service) has concluded that it concurs with the NPPD and NRC determination that the proposed relicensing action is not likely to adversely affect federally listed species or result in the destruction or adverse modification of federally designated critical habitat.

Please note that the Service may reinitiate consultation if new species become listed or are proposed to be listed, critical habitat is proposed or designated, or new information about federally listed species becomes available that previously was not considered during this consultation. The NPPD and NRC should reinitiate consultation with the Service if the current relicensing project is modified through a change in scope and/or if new information becomes available about the project that previously was not considered.

The Service appreciates the opportunity to work cooperatively with the NPPD and NRC in assuming a shared responsibility for protecting federal trust fish and wildlife resources in Nebraska. If you have any questions or require technical assistance, please do not hesitate to contact Mr. Robert Harms within our office at (308)382-6468, extension 17.

Sincerely,

A handwritten signature in black ink, appearing to read 'June DeWeese', with a long horizontal flourish extending to the right.

June DeWeese
Nebraska Field Supervisor


cc: NGPC; Lincoln, NE (Attn: Frank Albrecht)
Nebraska Land Trust; Lincoln, NE (Attn: Dave Sands)



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

February 18, 2010

MAR 01 2010



Mr. Michael Smith, Director
Nebraska State Historical Society
P.O. Box 82554
1500 R Street
Lincoln, NE 68501

SUBJECT: COOPER NUCLEAR STATION LICENSE RENEWAL APPLICATION REVIEW
(HP NO. 0801-050-01, DESCRIPTION, NPPD, COOPER NUCLEAR STATION)

Dear Mr. Smith:

The U.S. Nuclear Regulatory Commission (NRC) staff is reviewing an application to renew the operating license for Cooper Nuclear Station, Unit 1 (CNS-1), which is located in Nemaha County, Nebraska (NE) on the west side of the Missouri River at river mile 532.5. The Village of Brownville, NE is located about 2.25 miles northwest of the site. CNS-1 is operated by the Nebraska Public Power District (NPPD). As part of its review of the proposed action, the NRC staff has prepared a site-specific Supplemental Environmental Impact Statement (SEIS) to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants," NUREG-1437. The SEIS includes analyses of relevant environmental issues, including potential impacts to historic, archeological and cultural properties from extended operation and possible refurbishment activities associated with license renewal. In accordance with our letter to the Nebraska State and Historical Society (NSHS) dated January 16, 2009, a copy of the draft supplement is enclosed. Pursuant to 36 CFR § 800.8(c), we are requesting your comments on the draft supplement and on our preliminary conclusions regarding historic properties.

As stated in our January 16, 2009 letter, the NRC staff has determined that the area of potential effect (APE) for a license renewal action is the area at the power plant site and its immediate environs that may be impacted by post-license renewal land disturbing operation or projected refurbishment activities associated with the proposed action. The staff views the APE for the Cooper Nuclear Station, Unit 1, license renewal as including the Cooper Nuclear Station site and the immediate environs.

The NRC staff has conducted an environmental audit at the site and has reviewed historic and archaeological records. The NRC staff also contacted 15 federally recognized Native American Tribes identified as having potential interest in the proposed undertaking. To date, no comments have been received.

In the context of the National Environmental Policy Act of 1969, under which the draft supplemental environmental impact statement was prepared, the NRC staff's preliminary determination, based on review of NSHS files, archaeological surveys, assessments, and other information, is that the potential impacts of license renewal on historic and archaeological resources is small. Under the provisions of the National Historic Preservation Act of 1966, the NRC staff's preliminary determination is that no historic properties will be affected by the proposed action. Further, NPPD has instituted a stop work order within its Cultural Resources Protection Plan to ensure that proper notification is taken to protect any historic and archaeological resources should they be discovered.

HP# 0801-050-01
County _____
STR. ARCHEO.
Resp. NSHS Date 20100302

M. Smith

- 2 -

Please note that the period for public comment expires on May 5, 2010. If your office requires additional time, or if there are any other questions regarding this correspondence, please have your representative contact the Environmental Project Manager, Ms. Bennett Brady, at 301-415-2981.


Sincerely,



Bo Pham, Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No.: 50-298

Enclosures: As stated

CONCUR

DEPUTY STATE HISTORIC PRESERVATION OFFICER
DATE: 3/19/10



United States Department of the Interior

OFFICE OF THE SECRETARY
Office of Environmental Policy and Compliance
Denver Federal Center, Building 67, Room 118
Post Office Box 25007 (D-108)
Denver, Colorado 80225-0007



April 27, 2010

9043.1
ER 10/174

Chief, Rules and Directive Branch,
Division of Administrative Services, Mail Stop T-6D59
U.S Nuclear Regulatory Commission
Washington, D.C. 20555-0001

Dear Sir or Madam:

The Department of the Interior has reviewed the Draft Generic Environmental Impact Statement (EIS), NUREG-1437, Supplement 41, for License Renewal of Nuclear Plants; Cooper Nuclear Station, Unit 1, Nemaha County, Nebraska and has no comments on the document.

Sincerely,

Robert F. Stewart
Regional Environmental Officer



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION 7
901 NORTH 5TH STREET
KANSAS CITY, KANSAS 66101

MAY 03 2010

Michael T. Lesar, Chief
Rulemaking and Directives Branch
Division of Administrative Services
Office of Administration TWB-05-B01M
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555-0001

Dear Mr. Lesar:

RE: NRC Docket ID: NRC-2008-0617, Review of the Generic Environmental Impact Statement for License Renewal of Nuclear Plants, NUREG-1437, Supplement 41, Regarding Cooper Nuclear Station, Unit 1, Draft Report for Comment

The U.S. Environmental Protection Agency (EPA) has reviewed the Nuclear Regulatory Commission's (NRC) Generic Environmental Impact Statement (GEIS), Supplement 41, for the Cooper Nuclear Station, Unit 1 (Draft Report). Our review is provided pursuant to the National Environmental Policy Act (NEPA) 42 U.S.C. 4231, Council on Environmental Quality (CEQ) regulations 40 C.F.R. Parts 1500-1508, and Section 309 of the Clean Air Act (CAA). The GEIS, Supplement 41, was assigned the Council on Environmental Quality (CEQ) number 20100053.

The NRC is proposing to renew the license of the Cooper Nuclear Station (CNS) for an additional 20 years beyond the expiration date of the facility's current 40-year license which is January 18, 2014. CNS is owned and operated by Nebraska Public Power District (NPPD). The facility is located in Nemaha County, Nebraska, on the west bank of the Missouri River at River Mile 532.5, approximately 60 miles southeast of the city of Lincoln. The 1,359 acre site includes 239 acres on the opposite bank of the Missouri River in Atchison County, Missouri. CNS structures occupy approximately 55 acres of the total site area. NPPD leases 715 acres in Nebraska and 234 acres in Missouri for agricultural activities such as farming and livestock. The 55 acres of facility structures include a control/reactor/turbine complex serving a General Electric boiling water reactor with a generating capacity of 830 megawatts electric, a low-level radwaste building, off-gas filter building, elevated release point, diesel generator building, miscellaneous circulating water system structures, independent spent fuel storage installation (ISFSI), switchyard and other infrastructure. The facility uses the Missouri River for cooling water in a single-pass cooling water system. CNS utilizes two wells for potable water supply and three additional wells for service purposes. Wells are finished in alluvial aquifer which is under immediate influence of the Missouri River. CNS monitors groundwater through sampling of 14 monitoring wells. CNS does not routinely monitor surface water. CNS discharges process water to the Missouri River through a discharge canal. It is our understanding that the licensee


does not intend to undertake any facility refurbishment activities as part of its license renewal although NPPD is constructing an ISFSI to serve CNS through the renewal term.

Based on our overall review and the level of our comments, EPA has rated the draft Supplemental Environmental Impact Statement (SEIS) for this project EC-2 (Environmental Concerns-Insufficient Information). EPA's detailed comments on aspects of the draft SEIS and a copy of EPA's rating descriptions are provided as enclosures to this letter. This EC-2 rating is based on the uncertainty of potential impacts to ground and surface waters from radiological contamination, the effects of future changes to the river environment on CNS operation and the evaluation of alternatives to CNS license renewal. Specific to the draft SEIS, the curtailed presentation of radiological data limits the ability of the reader to ascertain its strength. In addition, the presentation of values regarding many parameters lacks any benchmark against which the reader could determine significance or trend information which would allow the reader to understand whether emissions were steady, increasing or decreasing over 36 years of operation. Further, conclusions reached in the GEIS which affect alternative assessment and selection in the SEIS should be brought forward in some more appropriate form in the SEIS.

As reflected in our enclosed issue-specific comments, we request that the NRC include, as part of its license renewal for CNS, a requirement to collect data on the aquatic community of the Missouri River in the vicinity of CNS which would provide contemporary ecological information of the area of the river receiving immediate impact from facility operation, particularly cooling water withdrawals. As stated in our comments during the scoping process and referenced in the draft SEIS, currently available data regarding the immediate aquatic environment of CNS is over 30 years old. With continued operation of CNS to 2034, the conclusions reached by the licensee in its Environmental Report and the NRC in its SEIS regarding "any new and significant information on environmental issues," in the context of the GEIS and 40 CFR 51, Subpart A, Appendix B, treatment of Category 1 issues, relying solely on data collected during initial licensing will become unsupportable. The draft SEIS recognizes the dynamic, unstable nature of the lower Missouri River. As the federal government continues to expend significant resources on the recovery of species and restoration of historic river structure and function, the need for current data on the river in the vicinity of CNS and on possible impacts related to continued CNS operation and its final disposition is critical to the comprehensive review required by NEPA.

We appreciate the opportunity to provide comments regarding this project. If you have any questions or concerns regarding this letter, please contact Mr. Joe Cothem, NEPA Team Leader, at (913) 551-7148, cothem.joe@epa.gov, or Larry Shepard, at (913) 551-7441, shepard.larry@epa.gov.

Sincerely yours,



Ronald Hammerschmidt, Ph.D.
Director
Environmental Services Division

Issue-specific Comments

Purpose and Need

We recognize that the draft SEIS relies upon the GEIS for its project purpose and need statement and that this statement is generic to all NRC license renewal decisions. However, we believe it is important to comment on this feature of the draft SEIS as it appears to influence the thoroughness of the document's evaluation of alternatives. Both the GEIS and the draft SEIS appear to confuse project 'purpose and need' with the proposed action itself (i.e., issuance of a renewed license) and, thereby, hinders the full consideration of all reasonable alternatives in this draft SEIS. In a NEPA context, the project purpose and need is to "provide an option that allows for power generation capability beyond the term of a current nuclear power plant operating license to meet future system generating needs, which may be determined by State, utility, and, where authorized, Federal decision-makers" (Section 1.2, Chapter 1). The expiration of the CNS' current operating license and existing and future energy demands in the region is the 'need' to which NRC is "responding [to] in proposing the alternatives including the proposed action" (40 CFR 1502.13). The NRC's proposed action is "issuing a renewed license for Cooper Nuclear Station, Unit 1"; however, this is but one alternative to addressing this 'need.' A fuller statement of project purpose and need is, in our estimation, an important distinction to providing a full, open review of all possible alternatives to meeting project purpose and need. This approach to purpose and need fully implements CEQ requirements regarding NRC's responsibility to "rigorously explore and objectively evaluate all reasonable alternatives", "devote substantial treatment to each alternative considered in detail", "include reasonable alternatives not within the jurisdiction of the lead agency" and "include the alternative of no action" (40 CFR 1502.14(a), (b), (c) and (d)).

The intent of 40 CFR 1502.14 is difficult to achieve when project purpose and need is so directly linked to the singular decision whether to reissue an operating license. Any alternative which does not meet project purpose and need does not appear to be a reasonable or viable alternative by any measure. Inclusion of a 'no action' alternative within the SEIS is required under CEQ regulations at 40 CFR 1502.14(d). The draft SEIS states that the 'no action' alternative does not meet the project's purpose and need (Section 8.5). Further, if purpose and need are tied to the proposed action, none of the alternatives to license renewal will meet project purpose and need and this contradiction appears to affect the rigor of the evaluation of these alternatives later in the draft SEIS (40 CFR 1502.14(a) and (b)). The draft SEIS links, throughout the document, the broad project purpose and need to the NRC's determination whether safety issues or environmental impacts should preclude license renewal. In simple summation, the NRC will renew the current license, unless its' analysis reveals significant safety or environmental issues that would preclude it. That appears to create the impression that the licensing decision is the project purpose. It would seem that the project purpose and need statement should not preclude selection of any of the alternatives, including the 'no action' alternative, regardless of the outcome of the NRC evaluation of the licensee's application for renewal. Regardless of the outcome of NRC's license renewal decision, the EIS process should inform and support deliberations by other decision-makers (e.g., "State regulators and utility officials," page xviii, Executive Summary) on how to meet this energy demand by any means, including continuing

operation of CNS-1, new generation sources (e.g., supercritical coal-fired, natural gas-fired, a combination), existing sources operating outside this region, conservation measures responding to reduced capacity or a combination of these alternatives. In essence, selection of an alternative other than license renewal as the preferred alternative is not precluded by NRC's regulatory responsibilities and is fully consistent with 40 CFR 1502.14(c) which provides for the inclusion of "reasonable alternatives not within the jurisdiction of the lead agency." The SEIS should clarify whether the purpose of the project is to meet the energy demands of the region currently met by CNS operation or only a license renewal decision.

Affected Environment and Environmental Impacts of Operation

Radiological Environmental Monitoring Program (REMP) Data

The draft SEIS characterizes its conclusions regarding radiation exposures to humans and contamination of the environment from radiation releases on a limited amount of REMP data (e.g., 2003 through 2007) without explanation. Section 2.1.2 characterizes multiple forms of radioactive waste streams from CNS using data from 2003 through 2007 or only data from 2007. In Section 4.8.1., the draft SEIS generally summarizes "the calculated hypothetical maximum dose to an individual located at the CNS-1 site boundary from radioactive liquid and gaseous effluents released during 2007." The draft SEIS offers no explanation why that single year of data was relied upon to make the assessment. Similarly, in Section 4.9.7.4, the draft SEIS qualitatively summarizes REMP environmental data for only 2007 for several media to assess exposures from subsistence consumption of fish and wildlife. Again, there is no explanation offered for why only one year of data is utilized in making these determinations nor does the draft SEIS present a quantitative summary of available data. The SEIS should provide a rationale for relying on this more limited data set after almost 40 years of operation. Regarding both the assessment of radiation exposures to humans and contamination of ground and surface water, the SEIS should characterize REMP data rather than merely reference a data set and the NRC's judgment of their significance (i.e., "reasonable", "no unusual trends"). Recognizing that CNS' REMP has a 'indicator-control' design, a presentation of trend and comparison to control or environmental benchmark, where available, utilizing a more robust data set than just one or several years would provide support to the NRC's determinations of significance in the SEIS. The SEIS would be improved if the document provided some information on 'control' location and the basis for determining these sites were beyond the influence of CNS emissions and discharges. Public review of radiological data within the SEIS would also be strengthened with a more complete and thorough organization of that data for each waste stream, including non-contact cooling water (Outfall 001). Currently, the draft SEIS relies completely on the NRC's qualitative expressions that there are "no unusual trends", "no measurable impact" and "small significance" without the benefit of presenting any characterization of the data supporting these conclusions, their completeness and their representativeness of the larger operational data set.

Ground Water

The SEIS does not address the potential for radiological contamination of alluvial groundwater and, therefore, the Missouri River from atmospheric washout in the immediate area of CNS. There is no description of background or historic groundwater contamination or trends in

groundwater radiological contamination during the current license period as would be expected from the facility's REMP which was initiated in 1971. In Section 2.1.7.1, the SEIS makes statements regarding a large number of monitoring wells installed to "measure the concentration of tritium in ground water" and documented "instances of liquid radiological releases." The SEIS also states that "none of the releases is a current source of ground water contamination", but provides no basis for this statement. The document also indicates that sampling and analysis results from the ground water monitoring program will be included in the final SEIS. The absence of this information in the draft SEIS interferes with our ability to evaluate radiological impacts to ground water and, potentially, the Missouri River. The SEIS would be improved if it included: the rationale behind the installation of the monitoring wells on-site and their locations, particularly the 11 installed to measure tritium contamination, the rationale behind the 3 remaining wells installed as part of CNS' INFSI Project, comparisons of the radiological character of site ground water in comparison with off-site reference or background, an explanation of benchmarks for both human health and aquatic life exposures and a characterization of ground water trends with regard to radiological contamination. Further, the SEIS should specify possible sources of radiological contamination and response actions by the licensee based on the presence of radiological contamination in these wells. Public review of these data would be strengthened if there was more information regarding what radiological levels are 'expected' by NRC at this facility, what levels might raise concern for the NRC and what measures CNS intends to take or has taken to address sources of contamination to ground water.

Surface Water

Section 4.4 of the draft SEIS does not adequately characterize CNS' use of surface water in comparison to available river flows. The SEIS would be improved if it characterized the percentage of flow utilized by CNS under low and high flow river conditions under 'wet' and drought periods in the basin. Given the direct hydrologic link between ground water and the river, computations of relative facility water consumption should combine ground water and surface water withdrawals. An assessment of comparative volumes of river flow use by CNS during varying conditions (e.g., seasonal, climatic) would better characterize both the potential impact of operation on the river and the facility's dependence upon river flow. Section 2.1.6 mentions that "the circulating water system flow would be about 47 percent of Missouri River flow" under critical low flow conditions. The fact sheet supporting the State of Nebraska's NPDES permit for CNS states that 625 MGD is withdrawn from the river at the intakes. The Missouri River basin appears to be ending a recent long-term drought period during which the navigation season was shortened several times. In the recent past, low winter flows and continuing river bed degradation in some reaches have caused utilities drawing water from the lower river to take extreme engineering measures to ensure a continuing flow of water to their systems. Congress has recently ordered the Army Corps of Engineers to study those purposes for which the current Missouri River system is operated as well as to develop a formal plan to recover native species and the river ecosystem. It is reasonable to consider these actions as they might affect CNS operation during a license renewal period which extends to 2034. In addition, climatic changes to the region could result in changes in the availability and timing of river flows for facility operation. Treatment of these complex relationships in Section 4.4 is not robust enough to aid in the decision-making value of the SEIS.

Given the potential impacts of thermal discharges from any single-pass cooling system, Section 4.5.3 should provide much more information regarding CNS's NPDES compliance record since 1974 with regard to its temperature limits, recent warming trends in ambient river water and tributary flows and the impact of warmer receiving water on facility temperature compliance and a characterization of the relative volume of cooling water discharge to river flow at high and low river flows. Assimilation of heat by receiving waters without adverse effect to aquatic organisms has been a significant issue for any energy production facility and is becoming more problematic for some facilities with recent trends of increasingly warmer receiving waters (i.e., less assimilative capacity for heat). This issue warrants more detailed treatment in the SEIS. NRC should consider adding more detailed information regarding the facility's temperature allocation, modeling and mixing zone calculations as an appendix to the document.

Section 2.1.7.2 states that CNS operations do not affect water quality in the Missouri River based on a cursory description of data from the Army Corps of Engineers' Water Control Manual and listings of impairment by the State of Nebraska. There is no characterization of available monitoring data for the Missouri River in the vicinity of CNS. The draft SEIS states that NPPD does not monitor surface waters as part of its environmental program. In fact, there is limited ambient water quality data for the Missouri River. The SEIS should avoid making statements regarding the impacts of facility operation on the river based on limited and uncharacterized data. Finally, the State of Nebraska has designated the river for more beneficial uses than is stated in this section.

Section 2.1.7.3 is incomplete as it does not discuss the two compliance schedules contained within CNS' NPDES permit for its cooling water intake structure (Clean Water Act, Section 316(b)) and water quality-based limits for total residual chlorine. The SEIS should also clarify which outfalls discharge to surface water and which outfalls are chlorinated or brominated.

Aquatic Life

Although we continue to have concerns about the age of the data relied upon to characterize the impacts of entrainment and impingement on river biota (Section 4.5.2.3, page 4-6), we generally agree with the conclusions of the analysis performed by NRC staff in this section. However, Section 4.5.2 would be greatly improved if the analysis included impingement data from other facilities utilizing the same or other technology and source water (i.e., large river) against which to compare CNS data. It is difficult to determine if the amount of fish impinged at CNS constitutes a comparatively large or small amount of biomass. Alternatively, data regarding entrainment at CNS appears to be very limited and inconclusive making the conclusions expressed in Section 4.5.2 regarding entrainment much more speculative and qualitative. As addressed in the cover letter to these comments, the basis for asserting that CNS operation has a small impact on aquatic life in the Missouri River would be better supported if NPPD provided more contemporary data regarding river biota in the immediate environment of the facility in an indicator-control design similar to the REMP and better characterized risks to biota from entrainment.

As with our previous comments regarding the presentation of REMP data, the draft SEIS limits its characterization of radiological contamination in the environment, in many instances, to one

year's worth of data. The document briefly mentions, in Section 4.9.7.4, monitoring milk, vegetation, surface water, drinking water, groundwater, fish and sediment, but characterizes data from only 2007. Relying on conclusions of significance apparently drawn from one year provides little basis for the NRC concluding that "the routine operation at CNS-1 has had no significant or measurable radiological impact on the environment." The SEIS reader has only the assurances of NRC staff that these data are representative of ambient conditions to conclude that a proper evaluation of environmental impact has indeed occurred.

Stormwater and Wastewater Treatment

The draft SEIS does not address possible tritium contamination within the wastewater collection and treatment system. Downwash from facility venting operations and worker sanitary contributions are common sources of radiological contamination of nuclear facility liquid effluent. CNS discharges collected site stormwater into ground water through drainage wells. The draft SEIS does not characterize stormwater radiological contamination which reflects downwash from site structures. The SEIS should summarize REMP data and characterize radiological contamination resulting from air deposition and resulting surface runoff which is discharged into drainage wells. Similarly, sanitary wastewater effluent is land-applied on-site, but there is no characterization of possible radiological ground water contamination associated with this waste stream.

There is no discussion within the draft SEIS regarding potential wastewater lagoon sludge contamination with radionuclides or the means by which the sludge is disposed. The SEIS should characterize this environmental medium and also describe how and where the sludge is disposed.

Spent Fuel Storage and Independent Spent Fuel Storage Installation

Although collective offsite radiological impacts of spent fuel storage are addressed under other NEPA documentation, the SEIS should describe the current status of the CNS's new Independent Spent Fuel Storage Installation (ISFSI) and projected capacity over the term of the license renewal period that extends to 2034. This information does not pertain to radiological risk assessment and would not be adequately addressed in the 1996 GEIS and Addendum. Given the current status of the Department of Energy's application for license for the Yucca Mountain site, this information is germane to a discussion of short-term use and long-term productivity and an irreversible commitment of resources (40 CFR 1502.15). The need for continued storage, on-site, of spent fuel might extend well beyond the operating life of the facility itself. The status of each licensed facility with regard to storage of spent fuel varies and each SEIS should characterize that status and project change to that status over the lifetime of the renewed license.

Environmental Justice

The SEIS should describe socioeconomic factors associated with CNS affecting the Sac and Fox and Iowa Reservation populations which are within the facility's ROI. These factors are noticeably absent from the SEIS' assessment of community-based impacts.

The discussion of risks from subsistence consumption of fish and wildlife in Section 4.9.7.4 relies on data from 2007 and concludes that risk is minimal without the benefit of any summary data from the facility's REMP. With regard to multiple pathways of exposure, the draft SEIS concludes that "the routine operation at CNS-1 has had no significant or measurable radiological impact on the environment (page 4-33)." Given that the REMP began in 1971, it is unclear why this analysis is performed on a single year's worth of REMP data. This statement would be better supported with the characterization of more REMP data than from only 2007.

Environmental Impact of Alternatives

The SEIS carries forward, for detailed evaluation, in addition to the proposed action, three alternatives and the 'no action' alternative, although the SEIS states that the 'no action' alternative does not meet project purpose and need. Fifteen other alternatives were considered, but dismissed before detailed evaluation. The three alternatives evaluated are: supercritical coal-fired generation; natural gas combined-cycle generation; and a combination of natural gas combined-cycle generation, conservation capacity increases and wind power.

Super Critical Coal-Fired Generation

The cumulative air impacts of emissions associated with this alternative in combination with those of existing coal-burning facilities in eastern Nebraska, western Iowa and northwestern Missouri should be considered in Section 8.1. The significance of the impacts of this alternative on air quality and total regional carbon emissions should be evaluated in the context of all other carbon sources.

Mercury is a significant contaminant of concern associated with coal combustion. Many watersheds downwind of the CNS site have been listed by Iowa and Missouri for mercury contamination. Further, mercury contamination is measured in fish tissue in areas far from their estimated source, primarily from air deposition. Section 8.1 does not provide an assessment of impacts from hazardous air pollutants, specific to this alternative, particularly with regard to mercury emissions. For this alternative, more information is needed in the SEIS regarding projected mercury emissions and the status of surface waters in the depositional path with regard to mercury.


Evaluation of Alternatives

Given the comparatively cursory evaluation of the three alternatives compared to the preferred action, it is not clear how the Alternatives Summary could conclude that "All other alternatives capable of meeting the needs currently served by CNS-1 entail potentially greater impacts than the proposed action of license renewal of CNS-1." This conclusion is not sufficiently supported by the alternatives analysis, consistent with the requirements of 40 CFR 1502.14(a). Notwithstanding the requirements for "rigorous" and "objective" alternatives analysis at 40 CFR 150.14(a), the NRC's expressed view of its responsibilities to determine whether "there are findings in the safety review required by the Atomic Energy Act of 1954 (AEA) or findings in the NEPA environmental analysis that would lead to the rejection of a license application..." (Executive Summary, page xviii) does not appear to necessitate any alternatives analysis.

The summary of impacts contained in Tables 1 and 8-5 does not appear to be a rigorous evaluation of the five alternatives carried forward in the draft SEIS for detailed review as is required in 40 CFR 1502.14(a), (b) and (c). In our view, the power of the evaluation required by NEPA, particularly an evaluation of a reasonable range of alternatives to a proposed action, is in a detailed and well-documented determination of whether it is good public policy to proceed with an action instead of an alternative to the proposed action. The discussion of this evaluation of a range of reasonable alternatives within the Executive Summary and Chapter 9 is not compelling and separation points critical to a decision to select the preferred alternative over an alternative are not evident.

As presently described in the draft SEIS, the impacts of the alternatives are characterized according to rather broad categories, primarily in isolation from each other and the proposed action. Rather than weighing of the impacts of each alternative, none of these alternatives are evaluated in direct comparison to the license renewal of the CNS. In effect, the license renewal of the CNS, or any existing facility, stands separately from all other alternatives and is evaluated on its merit alone. This intent is reflected, initially, in project purpose and need. Additionally, some significant impacts associated with continued operation of any existing facility are not addressed within the SEIS, but are addressed generically in the GEIS or other NEPA documentation, making a complete comparison of several large scale impacts of continued operation to the alternatives impossible. No comprehensive assessment or comparison of the merits of generating power by the existing facility or one of the alternatives is performed in this documentation. Unless the economic costs and environmental impacts of spent fuel transportation and disposal and facility decommissioning are somehow incorporated or summarized in the decision documentation supporting this license renewal decision, an equal comparison of alternatives to license renewal by the reader is not possible. This issue reflects an apparent disconnect between the broad treatment of license renewal for all facilities in the GEIS and facility-specific assessments in the SEIS.

**APPENDIX D.2
BIOLOGICAL ASSESSMENT
COOPER NUCLEAR STATION LICENSE
RENEWAL DATE 2009 DOCKET NO. 50-298
U.S. NUCLEAR REGULATORY COMMISSION
ROCKVILLE, MARYLAND**



D.2 BIOLOGICAL ASSESSMENT OF THE POTENTIAL EFFECTS ON FEDERALLY-LISTED ENDANGERED OR THREATENED SPECIES FROM THE PROPOSED LICENSE RENEWAL FOR COOPER NUCLEAR STATION

D.2.1 INTRODUCTION AND PURPOSE

The U.S. Nuclear Regulatory Commission (NRC) prepared this biological assessment (BA) to support the supplemental environmental impact statement (SEIS) for the renewal of the operating license for Cooper Nuclear Station (CNS), located on the western shore of the Missouri River near the Village of Brownville, Nemaha County, NE. The current 40-year license expires in 2014. The proposed license renewal for which this BA has been prepared would extend the operating license to 2034.

The NRC is required to prepare the SEIS as part of its review of a license renewal application. The SEIS supplements NUREG-1437, Volumes 1 and 2, *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), (NRC, 1996), (NRC, 1999)^a for the license renewal of commercial nuclear power plants. The SEIS covers specific issues, such as the potential impact on endangered and threatened species, that are of concern at CNS and that NRC could not address generically in the GEIS.

Pursuant to Section 7 of the Endangered Species Act (ESA) of 1973, as amended (16 U.S.C. § 1536(a)-(d)), the NRC staff requested, in a letter dated January 29, 2009 (NRC, 2009), that the U.S. Fish and Wildlife Service (USFWS) provide information on Federally-listed endangered or threatened species, as well as on proposed or candidate species, and on any designated critical habitats that may occur in the vicinity of CNS. Under Section 7, the NRC is responsible for providing information on the potential impact that the continued operation of CNS could have on the Federally-listed species, the pallid sturgeon.

D.2.2 PROPOSED ACTION

The proposed action considered in the SEIS is the renewal of the CNS operating license for an additional 20-year term beyond the period of the existing license. If the NRC grants the operating license renewal, the applicant can operate and maintain the nuclear unit, the cooling system, and the transmission lines and corridors as they are now until 2034.

D.2.3 SITE DESCRIPTION

CNS is located in Nemaha County, NE, 2.25 miles (mi) (3.6 kilometers (km)) southeast of Brownville, Nebraska, and approximately 60 mi (96 km) southeast of Lincoln, Nebraska. The CNS property is bounded on the east by the Missouri River and by non-Nebraska Public Power District (NPPD) owned property on the north, south, and west. Figure 3-1 shows a map of a 50-mi (80-km) radius around CNS. Figure 3-2 shows the area within a 6-mi (9.6-km) radius of CNS. NPPD owns and operates the site. The structures for CNS span approximately 55 acres (ac) (22 hectares (ha)) of the site's total area of approximately 1,359 ac (550 ha), including 239 ac (97 ha) on the opposite bank (east) of the Missouri River in Atchison County, MO. Over 99 percent of the acreage in Nemaha County is used for agriculture and farming. NPPD

^a The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and its Addendum 1.

Appendix D.2

currently leases 234 ac (947 ha) of the property in Missouri and 715 ac (289 ha) in Nebraska for agricultural activities, such as farming and livestock.



Figure 3-1. Location of Cooper Nuclear Station, 50-mile (80-kilometer) Region
(Source: NPPD, 2008b)




Figure 3-2. Location of Cooper Nuclear Station, 6-miles (10-kilometer) Region
 (Source: NPPD, 2008b)

Appendix D.2

CNS is a single-unit boiling water reactor plant with a nuclear steam supply system supplied by General Electric Company and a turbine generator set supplied by Westinghouse Electric Corporation. CNS achieved commercial operation in 1974 with an initial licensed core thermal power of 2,381 megawatts-thermal (MWt). In 2008, with NRC approval, the applicant performed a measurement uncertainty recapture uprate that increased the core thermal power by 1.62 percent to its current level of 2,419 MWt and 830 megawatts-electric (MWe) (NPPD, 2008b). Figure 3-3 shows the general layout of the buildings at CNS. The principal structures at CNS consist of the reactor building, turbine building (including service area appendages), control building, controlled corridor, radwaste building, augmented radwaste building, intake structure, off-gas filter building, elevated release point, diesel generator building, multi-purpose facility, railroad airlock, drywell and suppression chamber, miscellaneous circulating water system structures (e.g., circulating water conduits, seal well), optimum water chemistry gas generator building, and office building. Visually dominant features are the 290-foot (ft) (88-meter (m)) tall reactor building, the 325-ft (99-m) tall elevated release point, and the 328.8-ft (100-m) tall meteorological tower.




Figure 3-3. Cooper Nuclear Station, General Site Layout (Source: NPPD, 2008b)

CNS lies on the western shore of the Missouri River, withdraws river water for its once-through cooling system, and discharges heated water back to the river. Unless otherwise cited, the NRC staff drew information about CNS's cooling and auxiliary water systems from NPPD (2006) and the applicant's environmental report (ER) (NPPD, 2008b), where more in-depth information appears. In the vicinity of the plant, the Missouri River has a regulated minimum flow of 3,000 cubic feet per second (cfs) (85 cubic meters per second (m^3/s)) to the southeast. The circulating water intake structure is located on the western shore of the river behind a guide wall and submerged weir meant to reduce the amount of suspended sediment in the cooling water. The weir attaches to shoreline structures north of the intake and then runs parallel to the face of the intake at a distance of 14.25 ft (4.3 m). The wall continues past the intake and ends 40 ft (12 m) downstream of the corner of the intake structure. In a line riverward of the weir wall and

Appendix D.2

extending downstream of it, 23 sheet pile vanes (10 ft wide by 6 ft high (3 m wide by 2 m high)), oriented at a 22 degree angle to the weir, redirect sand and gravel outward from the weir and the intake structure. After flowing generally south along the weir and vanes, river water must reverse course and turn northwest to move between the weir and shore and reach the intake bays. Water velocity between the weir wall and the cooling water intake structure is about 4 feet per second (ft/s) (1.2 meters per second (m/s)).

In winter, about 25 to 30 percent of the main condenser discharge water recirculates through an ice control tunnel at the front of the intake structure and discharges in front of the trash rack to prevent icing. Water flows beneath a curtain wall at about 1.1 ft/s (0.3 m/s). Water enters the five intake bays, four of which provide circulating water and are 22 ft (6.7 m) wide and one of which provides service water and is 22.5 ft (6.8 m) wide. The incoming water then flows through trash racks, 3/8 inch (1 centimeter (cm)) vertical bars separated 3 inches (7.6 cm) on center, at up to 0.7 ft/s (20 cm/s).

The circulating water intake bays each separate into two screen bays and the service water intake bay narrows before water encounters the traveling screens, which are oriented at right angles to the flow. Water filters twice through 1/8 by 1/2-inch (.3 by 1.3 cm) smooth-top mesh of nine modified dual-flow traveling screens (eight for circulating water and one for service water): on the upward pass in the front and the downward pass behind the screens, installed in 2006, rotate continuously at 8.2 feet per minute (ft/min) (2.5 meters per minute (m/min)). The intake water velocity at the screens is about 2 ft/s (0.6 m/s).

After the 4.2-ft (1.28-m) wide traveling screen panels rotate over the upper cog and begin moving down, a high pressure (30–60 pounds per square inch gage (psig), 200–400 kilopascal (kPa)) screen wash of 3,000 gallons per minute (gpm) (0.19 m³/s) supplied by the service water pumps removes fish and debris, which return together to the river through an 18-inch (0.46-m) diameter steel pipe that discharges downstream from the intake. Although the screens are fitted with fish baskets, the system has neither a low-pressure spray system to more gently remove fish from the screens nor a fish return trough to convey fish and other aquatic organisms back to the river separately from potentially damaging debris. Debris loads are about 10 cubic yards per month (yd³/month) (8 cubic meters per month (m³/month)).

CNS plans to install "dual-flow conversion screen fish handling systems" during its current operational term. This system would have low pressure (5–10 psig, 35–70 kPa) fish washing sprays on both the ascending and descending screens and a fish return trough that is separate from the debris trough. A recovery basket would collect fish and other aquatic organisms washed from the screens, and the fish trough would return them to the river. Figures 3-4 through 3-6 show the CNS intake structures.




Figure 3-4. Cooper Nuclear Station, Intake Structure Plan (Source: NPPD, 2008b)




Figure 3-5. Cooper Nuclear Station, Intake Structure Section (Source: NPPD, 2008b)




Figure 3-6. Cooper Nuclear Station, Typical Dual Flow Screen

(Source: NPPD, 2008b)

After water passes through the traveling screens, the two screen bays of each intake bay rejoin behind the screens. The four circulating water pumps, one per bay, can draw water from the bays and can provide up to 159,000 gpm (10 m³/s) each. The four service water pumps in the fifth bay can provide a combined flow of 32,000 gpm (2 m³/s). Water from the circulating water pumps travels to and circulates through the condenser, where it cools steam from the turbines. Because of the scouring from the suspended sediment, CNS typically does not need to

chlorinate the circulating water to control biological film fouling, although it has the capacity to chlorinate or brominate if needed. NPPD is studying the effectiveness of those options.

Water temperature increases about 17.8°F (10°C) as it passes through the condenser tubes. From the condenser, circulating cooling water flows through concrete tunnels to a seal well structure and then to the discharge canal, where it travels about 1,000 ft (300 m) to discharge to the river at a slight angle. Water velocity at the discharge is about 1 ft/s (0.3 m/s) at average river flow and about 5.6 ft/s (1.7 m/s) during low flow. The travel time from the intake structure to the discharge is about 20 minutes at high river flow and 10 to 12 minutes at low flow.

Cooling water flow varies with electrical load and ambient river water temperature. At full load during the summer, the expected circulating water system flow is highest: about 636,000 gpm (40 m³/s). Circulating water flow is lower under other conditions. In comparison, the lowest river flow at CNS is about 3,000 cfs (85 m³/s). Under these worst conditions, the circulating water system flow would be about 47 percent of the Missouri River flow. Stone rip-rap at the discharge structure prevents the discharge from eroding the river bottom.

D.2.4 STATUS REVIEW OF PALLID STURGEON

D.2.4.1 Life History

Sturgeon are members of an order of fish (Acipenseriformes) that probably evolved in the Devonian age. Living members of this order in North America include the paddlefish and eight sturgeon species. The paddlefish (*Polyodon spathula*) and three sturgeon species, the lake sturgeon (*Acipenser fulvescens*), pallid sturgeon (*Scaphirhynchus albus*), and the shovelnose sturgeon (*S. platyrhynchus*), live in the Missouri and Mississippi rivers. In the past, commercial fishermen harvested all three of the sturgeon species in the Missouri and Mississippi rivers. Today pallid sturgeon are a Federally-listed endangered species, and lake sturgeon are listed as endangered by Nebraska. The life history information below is from Dryer and Sandvol (1993) and the USFWS (2007) if not otherwise cited.

Pallid sturgeon have a flattened snout, a long tail, and rows of bony armor plates. The upper side is convex and the lower side is straight. They have an inferior (bottom-facing) mouth and eat invertebrates, such as the immature stages of insects, and fish. The body shape is well adapted for swimming close to the bottom of relatively fast flowing, large rivers. The diet, inferior mouth, and barbels in front of the mouth are well adapted to feeding on or near the bottom in highly turbid environments.

The USFWS listed pallid sturgeon as endangered in 1990. The historic abundance of pallid sturgeon is somewhat vague since biologists did not recognize it as a separate species from shovelnose sturgeon until 1905, but its historical range probably extended from the middle and lower Mississippi River in the south up through the Missouri River and lower reaches of the Platte, Kansas, and Yellowstone rivers in the north and west. The pallid sturgeon is one of the largest fish species in those rivers. Available information suggests that the pallid sturgeon was not a common species since the time of European settlement. Today pallid sturgeon are among the rarest fish of the Missouri and Mississippi River basins, and the present range includes the States of Montana, North and South Dakota, Nebraska, Iowa, Kansas, Missouri, Illinois, Kentucky, Arkansas, Mississippi, and Louisiana. The populations are believed to be mostly older fish that may die off in the foreseeable future.

Fisheries biologists know little about pallid sturgeon reproduction or even preferred spawning habitats and conditions. Hurley et al. (2004) tracked sonically-tagged pallid sturgeon in the

Appendix D.2

Mississippi River and found that they exhibited positive selection for the main-channel border, downstream island tips, between-wing-dam, and wing-dam-tip habitats; they showed negative selection for main-channel, downstream of wing dams, and upstream of wing dam habitats. The sturgeon exhibited little habitat selection for temperature or dam discharge. The authors concluded that habitat enhancement and restoration of habitat diversity might be necessary for the recovery of pallid sturgeon.

Reports of pallid sturgeon reproduction are rare. The U.S. Geological Survey (USGS) (2007), Nebraska Game and Parks Commission (NGPC), and the U.S. Army Corps of Engineers (USACE) confirmed spawning of two female pallid sturgeon in the upstream reaches of the lower Missouri River in May 2007. The capture of young pallid sturgeon that would verify natural reproduction are also rare: none were captured between 1978 and a Mississippi River trawl survey in 1998 through 2000 using equipment designed to capture larval fish in deep, turbulent water (Hrabik et al., 2007). Hrabik et al. (2007) concluded that those latest captures verified reproduction, possibly from the lower Missouri River to the upper and lower Mississippi River, although they also found no evidence of recruitment of pallid sturgeon because they captured no juveniles after 374 trawl hauls that captured over 21,735 fish in that 1998 through 2000 survey. Wildhaber et al. (2007) suggest that one or more of the following factors may be responsible for the lack of finding larval pallid sturgeon and of recruitment: lack of successful spawning, low recruitment, high mortality, ineffective sampling methods, inadequate sampling of drift and settling locations, or rapid dispersal and washout of sturgeon larvae in the Missouri and Mississippi rivers. Pallid sturgeon larvae are indistinguishable from those of the congeneric shovelnose sturgeon, which may also help to explain the paucity of reported collections in the past. Also, the construction of dams and other structures with resulting habitat change and the elimination of shallow areas in the river with little or no flow have probably deprived sturgeon of critical nursery areas needed for the survival of immature sturgeon (MDC, 2009).

Larval pallid and shovelnose sturgeon become strongly photopositive and migrate upwards toward the light starting the first day after hatching. As a result, they remain far above the bottom, even at the water surface, and migrate far downriver (Kynard et al., 2002). Cultured yearling pallid sturgeon in laboratory studies also migrate downstream during summer and fall, which suggests a two-stage (larval, then yearling) downriver migration in the first year of life. Adult sturgeon are also highly migratory and often migrate hundreds of miles in a year.

The young of both shovelnose and pallid sturgeon eat invertebrates, but as pallid sturgeon grow, they become more piscivorous. Gerrity and Guy (2006) found that the diet of juvenile pallid sturgeon of age 6 and 7 was mostly fish, compared to the diet of shovelnose sturgeon, which is mainly aquatic insects. Sturgeon chub (*Macrhybopsis gelida*) and sicklefin chub (*M. meeki*) together comprised 79 percent of the number of identifiable fish in juvenile pallid sturgeon stomachs. Populations of these two cyprinid minnows have declined throughout much of the Missouri River due to the construction of dams and man's other alterations of river habitat, and the State of Nebraska lists sicklefin chub as threatened and sturgeon chub as endangered. While the population of the piscivorous pallid sturgeon has declined in the Missouri and Mississippi rivers, the population of its similar, insectivorous congener, shovelnose sturgeon, has not declined. Gerrity and Guy (2006) concluded that the prevalence of sicklefin chub and sturgeon chub as a food resource of juvenile pallid sturgeon may help explain the decline of pallid sturgeon populations and that recovery and management of native cyprinids is a potentially important step in the recovery of pallid sturgeon.

Male pallid sturgeon are believed to mature at 7 to 9 years after which they spawn at intervals of 2 to 3 years. Females may reach sexual maturity at 7 to 15 years and spawn at intervals up to

10 years. Individuals may reach ages of 60 years or more and reach lengths of 6 ft (2 m). Like many other fish species, the largest individuals are found farthest north in the species' range and maximum size decreases with distance south. For example, the maximum weight of pallid sturgeon in the upper Missouri River in Montana and North Dakota is 86 pounds (lbs) (39 kilograms (kg)), in the Missouri River in South Dakota and Nebraska 46 lbs (21 kg), and in the Mississippi River 26 lbs (12 kg). They become much larger than shovelnose sturgeon, which rarely weigh more than 8 lbs (3.6 kg).

D.2.4.2 *Status of Pallid Sturgeon in the Missouri River*

While they were successful in the historical Missouri and Mississippi rivers, with the high flow and turbidity and diverse habitats of floodplains, backwaters, chutes, sloughs, islands, sand and gravel bars, and both braided and main channels, they are not so well adapted to the Missouri and Mississippi rivers today with the construction of dams that isolated subpopulations, channelization, controlled flow, and elimination of habitat diversity. The USFWS (2007) concludes that man's activities have adversely affected all of the 3,350 mi (5,390 km) of river habitat within their range, and habitat alteration and loss may be the biggest threat to their existence. Other threats may include hybridization with shovelnose sturgeon, commercial fishing, and exposure to environmental contaminants such as polychlorinated biphenyls (PCBs), cadmium, mercury, selenium, chlordane, dichlorodiphenyltrichloroethane (DDT), dichlorodiphenyltrichloroethylene (DDE), and dieldrin, all of which have been found in pallid sturgeon tissue in the past.

During the early 1990s, the Missouri Department of Conservation (MDC) developed "action plans" for lake and pallid sturgeon a goal of reestablishing self-sustaining populations so they can be delisted as endangered species and ultimately provide limited sport fisheries. These plans stress the restoration of both species through habitat improvement, artificial propagation, protection, research, management, and education (MDC, 2009). As part of this effort, the MDC's Blind Pony Fish Hatchery has raised and stocked over 13,000 fingerling pallid sturgeon and 200,000 fingerling lake sturgeon into the Missouri and Mississippi rivers (MDC, 2009). In addition to these efforts, the USGS (Wildhaber et al., 2007) has developed a conceptual life history to organize the understanding about the complex life history of *Scaphirhynchus* sturgeon and improve understanding of the effects of management actions on the ecological requirements of pallid and shovelnose sturgeon. The USFWS's Pallid Sturgeon Recovery Plan (Dryer and Sandvol, 1993) designated six recovery priority management areas (RPMAs) for implementation of recovery tasks, and CNS is located within RPMA 4.

D.2.4.3 *Impact Assessment of Cooper Nuclear Station on Pallid Sturgeon*

NPPD (2008a) summarizes interactions between NPPD and both State and Federal agencies regarding conservation of pallid sturgeon. That summary is outlined below:

In March 2006, before filing a license renewal application with NRC, NPPD voluntarily participated in meetings with the USFWS, the NGPC, the Nebraska Department of Environmental Quality (NDEQ), the Nebraska Department of Natural Resources (NDNR), the Environmental Protection Agency (EPA), and the USACE regarding conservation actions to improve the habitat of pallid sturgeon. NPPD (2008a) summarizes those meetings. Early in the discussions, the USFWS and NGPC showed interest in developing existing habitat on a parcel of property south of CNS at Langdon Bend and later also on CNS property on the Nebraska side of the Missouri River adjacent to Langdon Bend. They hoped to enhance pallid sturgeon habitat by building a chute to connect active river channels with the old river area.

Appendix D.2

NPPD had problems with this proposal. Implementing the proposal would reduce CNS's mixing zone, which now extends 5,000 ft south of CNS along the Nebraska side of the Missouri River, to less than half, less than 2,500 ft. Reducing the mixing zone would reduce CNS's capacity to generate electricity, particularly during the summer. The proposal also posed other negative safety and environmental concerns for CNS. As an alternative, NPPD then offered to contribute funds toward other new or existing projects on the Missouri River. The USFWS rejected this funding alternative in favor of increasing the amount of land for habitat development.

To meet the goal of improving habitat for pallid sturgeon, NPPD offered a conservation easement of about 230 ac (93 ha) of land that it owns on the Missouri side of the Missouri River, opposite CNS, for the purposes of habitat development. The USFWS indicated interest in the proposal, and asked NPPD to also acquire an adjacent property of about 150 ac (51 ha) so that the entire bend in the river could be developed into better habitat. When the property owner refused to sell the land, NPPD offered a revised, final proposal to participate in and promote habitat development along the Missouri River. It proposed to revisit the USFWS's and NGPC's interest in a suitable conservation easement and Memorandum of Understanding to enable habitat development on NPPD's approximately 230-ac (93-ha) parcel on the Missouri side of the river. Furthermore, because NPPD recognized that this parcel alone would not meet the USFWS's and NGPC's conservation habitat development goals, NPPD indicated its willingness to make an additional payment of \$250,000 to be applied toward another conservation habitat development project on the Missouri River at the direction of the USFWS and NGPC. At the time of writing this BA, the involved parties are discussing details of the conservation agreement.

Plans for and construction of a chute on the parcel may also involve the owners of the transmission lines and supports that cross the property. NPPD does not own these lines, although CNS provides power to them.

The probability that CNS will entrain, impinge, or otherwise affect pallid sturgeon eggs or larvae is low. Hazleton (1979) collected adult and juvenile fish from seven locations in the vicinity of CNS from 1970 through 1978 and reported no pallid sturgeon captured. They also conducted impingement sampling from 1974 through 1978 and reported no pallid sturgeon impinged. Based on 374 trawl hauls that captured over 21,735 fish in a 1998 through 2000 survey, Hrabik et al. (2007) concluded pallid sturgeon may reproduce in the lower Missouri River to the upper and lower Mississippi River, although no fish may survive to recruitment. NPPD's involvement in the conservation agreement, however, could have a positive impact on the pallid sturgeon population.

D.2.5 CONCLUSION

Based on this review, the staff concludes that the continued operation of CNS for an additional 20 years may affect, but is not likely to adversely affect, the pallid sturgeon.

D.2.6 REFERENCES

Dryer, M.P. and A.J. Sandvol. 1993. "Recovery plan for the pallid sturgeon *Scaphirhynchus albus*," U.S. Fish and Wildlife Service, Bismarck, ND, 55 pp.

Gerrity, P.C. and C. Guy. 2006. "Juvenile pallid sturgeon are piscivorous: A call for conserving native cyprinids," *Transactions of the American Fisheries Society* 135:604-609.

Hazleton Environmental Sciences Corporation (Hazleton). 1979. "The Evaluation of Thermal Effects in the Missouri River Near Cooper Nuclear Station (Operational Phase), January–December 1978, Project No. 8903," report to Nebraska Public Power District, Columbus, NE, Hazleton Environmental Sciences Corporation, Lincoln, NE, Agencywide Documents Access and Management System (ADAMS) Accession No. ML092450614.

Hurleya, K.L., R.J. Sheehan, R.C. Heidinger, P.S. Wills, and B. Clevensine (Hurleya et al.) 2004. "Habitat Use by Middle Mississippi River Pallid Sturgeon," *Transactions of the American Fisheries Society* 133:1033–1041.

Hrabik, R.A., D.P. Herzog, D.E. Ostendorf, and M.D. Petersen (Hrabik et al.) 2007. "Larvae provide first evidence of successful reproduction by pallid sturgeon, *Scaphirhynchus albus*, in the Mississippi River," *Journal of Applied Ichthyology* 23(4):436–443.

Kynard, B., E. Henyey, and M. Horgan (Kynard et al.). 2002. "Ontogenetic behavior, migration, and social behavior of pallid sturgeon, *Scaphirhynchus albus*, and shovelnose sturgeon, *S. platyrhynchus*, with notes on the adaptive significance of body color," *Environmental Biology of Fishes* 63:389–403.

Missouri Department of Conservation (MDC). 2009. "The Sturgeon of Missouri: Missouri's Aquatic Dinosaurs," Updated 2009. Available URL: <http://mdc.mo.gov/fish/sport/sturgeon/info/> (accessed on May 5, 2009).

Nebraska Public Power District (NPPD). 2006. "Proposal for Information Collection, Cooper Nuclear Station," January 2006, ADAMS Accession No. ML092510103.

Nebraska Public Power District (NPPD). 2008a. Letter from Joe Citta, Nebraska Public Power District, to Robert Harms, U.S. Fish and Wildlife Service, Subject: "Cooper Nuclear Station License Renewal—Habitat Development Proposal," September 26, 2008, ADAMS Accession No. ML092520156.

Nebraska Public Power District (NPPD). 2008b. "Nebraska Public Power District, Cooper Nuclear Station, License Renewal Application," September 24, 2008, ADAMS Accession No. ML083030227.

U.S. Fish and Wildlife Service (USFWS). 2007. "Species Profile, Pallid sturgeon, *Scaphirhynchus albus*." Available URL: <http://www.fws.gov/moriver/PSPROFILE.htm> (accessed on March 16, 2007).

U.S. Geological Service (USGS). 2007. "Sturgeon Research Update: Confirmed Pallid Sturgeon Spawning in the Missouri River in 2007," USGS Fact Sheet 2007–3053, July 2007.

U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement for License Renewal of Nuclear Power Plants*, NUREG-1437, Volumes 1 and 2, Washington, D.C., ADAMS Accession Nos. ML040690705 and ML040690738.

U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Main Report*, NUREG-1437, Volume 1, Addendum 1, Washington, D.C.

U.S. Nuclear Regulatory Commission (NRC). 2009. Letter from D. Pelton to Mr. John Cochnar, U.S. Fish and Wildlife Service, Grand Island, NE, Subject: "Request for List of Protected Species."

Wildhaber, M.L., A.J. DeLonay, D. M. Papoulias, D.L. Galat, R.B. Jacobson, D.G. Simpkins, P.J. Braaten, C.E. Korschgen, and M.J. Mac (Wildhaber et al.). 2007. "A conceptual life-history model for pallid and shovelnose sturgeon," *U.S. Geological Survey Circular 1315*, U.S. Geological Survey, Reston, VA, 18 pp.

**APPENDIX E.
CHRONOLOGY OF ENVIRONMENTAL REVIEW**



E. CHRONOLOGY OF ENVIRONMENTAL REVIEW CORRESPONDENCE

This appendix contains a chronological listing of correspondence between the U.S. Nuclear Regulatory Commission (NRC) and external parties as part of its environmental review for Cooper Nuclear Station (CNS). All documents, with the exception of those containing proprietary information, are available electronically from the NRC's Public Electronic Reading Room found on the Internet at the following Web address: <http://www.nrc.gov/reading-rm.html>.

From this site, the public can gain access to the NRC's Agencywide Document Access and Management System (ADAMS), which provides text and image files of NRC's public documents in ADAMS. The ADAMS accession number for each document is included below.

E.1. Environmental Review Correspondence

- September 24, 2008 Letter from Nebraska Public Power District (NPPD) forwarding the application for renewal of the operating license for CNS, requesting an extension of the operating license for an additional 20 years. (ADAMS Accession No. ML0803030227)
- September 24, 2008 NPPD's environmental report (ER) submitted as Appendix E for the application for renewal of the operating license for CNS, requesting an extension of the operating license for an additional 20 years. (ADAMS Accession No. ML083030246)
- November 10, 2008 Letter to NPPD, "Receipt and Availability of the License Renewal Application for the Cooper Nuclear Station." (ADAMS Accession No. ML082661007)
- November 17, 2008 *Federal Register* Notice of Receipt and Availability of Application for Renewal of Cooper Nuclear Station Facility Operating License No. DPR-46 for an Additional 20-Year Period (73 FR 67896). (ADAMS Accession No. ML0826608920)
- December 19, 2008 Letter to NPPD, "Determination of Acceptability and Sufficiency for Docketing and Opportunity for a Hearing Regarding the Application from Nebraska Public Power District, for Renewal of the Operating License for the Cooper Nuclear Station" (TAC Nos. MD9763 and Md9737). (ADAMS Accession No. ML083330066)
- December 19, 2008 *Federal Register* Notice of Acceptance for Docketing of the Application and Notice of Opportunity for Hearing Regarding Renewal of Facility Operating License No. DPR-46 for an Additional 20-Year Period Nebraska Public Power District Cooper Nuclear Station (73 FR 5877). (ADAMS Accession No. ML083540747)
- January 15, 2009 *Federal Register* Notice of Intent to Prepare an Environmental Impact Statement and Conduct Scoping Process for Licensee Renewal for Cooper Nuclear Station (73 FR 13923). (ADAMS Accession No. ML090150526)

Appendix E

- January 16, 2009 Letter to Michael Smith, Nebraska Historic Preservation Society, regarding the CNS license renewal application. (ADAMS Accession No. ML090080197)
- January 21, 2009 Letter to NPPD transmitting notice of intent to prepare an environmental impact statement and conduct scoping process for license renewal for CNS. (ADAMS Accession No. ML083640401)
- January 26, 2009 Letter to Sherry Black, Auburn Memorial Library, regarding maintenance of reference materials at the Auburn Memorial Library related to the review of the CNS license renewal application. (ADAMS Accession No. ML090230582)
- January 26, 2009 Letter to Don Klima, Director, Advisory Council on Historic Preservation, regarding the CNS license renewal application. (ADAMS Accession No. ML090080683)
- January 27, 2009 Letter to Mr. Joseph Cothorn, U.S. Environmental Protection Agency (EPA) Region 7, regarding the CNS license renewal application. (ADAMS Accession No. ML090230446)
- January 28, 2009 Letter to Julia Schmitt, Department of Health and Human Services, regarding the CNS license renewal application. (ADAMS Accession No. ML090260380)
- January 29, 2009 Notice of forthcoming meeting to discuss the safety review process and environmental scoping process for the CNS license renewal application review. (ADAMS Accession No. ML090160280)
- January 29, 2009 Letter to Mark Miles, State Historic Preservation Officer, Department of Natural Resources, MO, regarding the CNS license renewal application. (ADAMS Accession No. ML090210750)
- January 29, 2009 Letter to John Cochnar, U.S. Fish and Wildlife Service (USFWS), requesting a list of protected species for the CNS license renewal review. (ADAMS Accession No. ML0901507)
- February 2, 2009 Letter from the Nebraska State Historic Preservation Office requesting a map of the boundaries of the environmental review of the license renewal application for CNS. (ADAMS Accession No. ML090650061)
- February 4, 2009 Letter to Adrian Pushetonequa, Sac and Fox Tribe of the Mississippi in Iowa, inviting participation in scoping process related to the NRC's environmental review of the license renewal application for CNS. (ADAMS Accession No. ML090080045)
- February 4, 2009 Letter to Ann Bleed, Nebraska Department of Natural Resources, requesting a list of protected species for the CNS license renewal review. (ADAMS Accession No. ML090260380)

February 25, 2009 Agenda and slides for the CNS scoping and process public meeting, February 25, 2009. (ADAMS Accession No. ML090750686)

February 25, 2009 Transcript of the CNS license renewal public meeting – afternoon session, February 25, 2009. (ADAMS Accession No. ML090840063)

February 25, 2009 Transcript of the CNS license renewal public meeting – evening session, February 25, 2009. (ADAMS Accession No. ML090840062)

February 25, 2009 Comments from the Richardson County, NE, Emergency Management Agency regarding the license renewal of CNS. (ADAMS Accession No. ML090720066)

February 27, 2009 Letter from the City of Rock Port regarding the license renewal of CNS. (ADAMS Accession No. ML090720068)

March 9, 2009 Letter from Nebraska Department of Natural Resources regarding the request for a list of protected species for license renewal of CNS. (ADAMS Accession No. ML090650061)

March 10, 2009 Letter from the Pawnee City Economic Development Corporation regarding the license renewal of CNS. (ADAMS Accession No. ML090720067)

March 26, 2009 Letter from D. F. Brown, State of Missouri, Department of Conservation, to R. Bulavinetz, NRC, regarding the preparation of the environmental impact statement. (ADAMS Accession No. ML091030465).

April 3, 2009 Letter to NPPD regarding the review schedule for the application for the renewal of the operating license for CNS. (ADAMS Accession No. ML090220584)

April 3, 2008 Letter to Stewart B. Minahan, NPPD, regarding environmental site audit needs for the CNS license renewal application from NPPD. (ADAMS Accession No. ML090830248)

April 9, 2009 Letter to NPPD, "Regulatory Audit Plan for Aging Management Program Regarding Cooper Nuclear Station License Renewal Application." (ADAMS Accession No. ML090930256)

April 9, 2009 Letter to NPPD, "Request for Additional Information Regarding Balance of Plant Issues for Cooper Nuclear Station." (ADAMS Accession No. ML091060150)

April 14, 2009 Summary of the CNS Scoping and Process Public Meeting, February 25, 2009. (ADAMS Accession No. ML090910308)

April 16, 2009 E-mail comments from EPA Region 7, regarding the license renewal of CNS. (ADAMS Accession No. ML091070269)

Appendix E

April 30, 2009 Summary of the site audit related to the review of the license renewal application for CNS (TAC Nos. MD9763 and MD9737). (ADAMS Accession No. ML090970414)

May 1, 2009 Letter to NPPD, "Request for Additional Information for the Review of the Cooper Nuclear Station License Renewal Application." (TAC Nos. MD9763 and MD9737). (ADAMS Accession No. ML091190597)

May 1, 2009 Letter from NPPD to the USFWS regarding the license renewal of the CNS. (ADAMS Accession No. ML091830056)

May 5, 2009 E-mail from the USFWS to R. Bulavinetz, NRC. (ADAMS Accession No. ML091400116)

May 8, 2009 E-mail and attachment from the Nebraska Game and Parks Commission. (ADAMS Accession No. ML091400110)

May 18, 2009 Letter from NPPD, "Response to Request for Additional Information for License Renewal Application, Cooper Nuclear Station," Docket No. 50-298, DPR-46. (ADAMS Accession No. ML091600712)

May 29, 2009 Summary report of environmental scoping for the license renewal application for CNS (TAC Nos. MD9763 and MD9737). (ADAMS Accession No. ML091200017)

June 8, 2009 Letter to NPPD, "Request for Additional Information for the Review of the Cooper Nuclear Station License Renewal Application" (TAC Nos. MD9763 and MD9737). (ADAMS Accession No. ML091530316)

June 8, 2009 Letter from the USFWS to NPPD regarding the license renewal of CNS. (ADAMS Accession No. ML091830055)

July 1, 2009 Letter from NPPD, "Response to Request for Additional Information for License Renewal Application – Severe Accident Mitigation Alternatives, Cooper Nuclear Station," Docket No. 50-298, DPR-46. (ADAMS Accession No. ML091880319)

August 26, 2009 Letter from the USFWS to NPPD concerning the license renewal of CNS.

December 17, 2009 Letter from NPPD, "SAMA Meteorological Anomaly Related to the Cooper Nuclear Station License Renewal Application." (ADAMS Accession No. ML093490997)

February 18, 2010 Letter from B. Pham, NRC/NRR/DLR/RPB1, to S. Minahan, NPPD, "Notice of Availability of the Draft Plant-Specific Supplement 41 to the Generic Environmental Impact Statement for License Renewal of Nuclear Plants Regarding Cooper Nuclear Station, Unit 1." (ADAMS Accession No. ML100321621)

February 18, 2010 *Federal Register* Notice from B. Pham, NRC/NRR/DLR/RPB1, "Notice of Availability of the Draft Supplement 41 to the Generic Environmental Impact Statement for License Renewal of Nuclear Plants, The License Renewal of Cooper Nuclear Station, Unit 1." (ADAMS Accession No. ML100330057)

February 18, 2010 Letter from B. Pham, NRC/NRR/DLR/RPB1, to M. Smith, State of Nebraska Historical Society, "Cooper Nuclear Station License Renewal Application Review (HP No. 0801-050-01)." (ADAMS Accession No. ML100351164)

February 18, 2010 Letter from B. Pham, NRC/NRR/DLR/RPB1, to J. Cochnar, U.S. Department of Interior, USFWS, "Notice of Availability of the Draft Plant-Specific Supplement 41 to the Generic Environmental Impact Statement for License Renewal of Nuclear Plants Regarding Cooper Nuclear Station." (ADAMS Accession No. ML100430029)

February 18, 2010 Letter from B. Pham, NRC/NRR/DLR/RPB1, to M. Miles, State of Missouri, Historic Preservation Office, "Cooper, License Renewal Application Review (SHPO Log Number: 004-AT-08)." (ADAMS Accession No. ML100430043)

March 19, 2010 E-mail from R. Harms, USFWS, to B. Brady, NRC, "Concurrence Cooper Nuclear Station." (ADAMS Accession No. ML101440172)

March 19, 2010 Letter from R. Puschendorf, Nebraska State Historic Society, to B. Pham, "Concurrence Cooper Nuclear Station," (ADAMS Accession No. ML101440132)

April 7, 2010 Meeting Briefing Package/Handouts of Slides and Viewgraphs, NRC/NRR, "Preliminary Site-Specific Results of the License Renewal Environmental Review for Cooper Nuclear Station." (ADAMS Accession No. ML101050376)

April 7, 2010 Meeting Transcript, NRC/OCM, "Transcript of Cooper, License Renewal Public Meeting, Afternoon Session, April 07, 2010, Pages 1–20." (ADAMS Accession No. ML101320545)

April 7, 2010 Meeting Transcript, NRC/OCM, "Transcript of Cooper, License Renewal Public Meeting: Evening Session, April 07, 2010, Page 1–20." (ADAMS Accession No. ML101320618)

April 27, 2010 Letter from R. Steward, U.S. Department of Interior, to Chief, Rules and Directives Branch, NRC. (ADAMS Accession No. ML101270268)

May 3, 2010 Letter from R. Hammerschmidt, EPA, to M. T. Lesar, NRC/ADM/DAS, "Comment of Ronald Hammerschmidt on Behalf of US Environmental Protection Agency on Review of Generic Environmental Impact Statement for License Renewal of Cooper Nuclear Plants, Unit 1." (ADAMS Accession No. ML101270268)

APPENDIX F.
U.S. NUCLEAR REGULATORY COMMISSION STAFF
EVALUATION OF SEVERE ACCIDENT MITIGATION
ALTERNATIVES FOR COOPER NUCLEAR STATION IN
SUPPORT OF LICENSE RENEWAL APPLICATION REVIEW

F. U.S. NUCLEAR REGULATORY COMMISSION STAFF EVALUATION OF SEVERE ACCIDENT MITIGATION ALTERNATIVES FOR COOPER NUCLEAR STATION IN SUPPORT OF LICENSE RENEWAL APPLICATION REVIEW

NOTE: On December 7, 2009, Cooper Nuclear Station (CNS) identified an error in their original severe accident mitigation alternative (SAMA) analysis resulting from the wind data used in their code. Nebraska Public Power District (NPPD) discovered a problem with the process they used to numerically average the site-specific meteorological data. NPPD performed a sensitivity analysis of the population dose risk and offsite economic cost risk using corrected meteorological data, and found that the population dose and offsite economic cost values for each of the release categories would be slightly less than reported in the environmental report (ER), and that the conclusions of the SAMA remain valid (NPPD, 2009c). U.S. Nuclear Regulatory Commission (NRC) staff reviewed the revised data as part of the analysis below.

F.1. Introduction

NPPD submitted an assessment of SAMAs for the CNS as part of the ER (NPPD, 2008). This assessment was based on the most recent CNS probabilistic safety assessment (PSA) available at that time, a plant-specific offsite consequence analysis performed using the MELCOR Accident Consequence Code System 2 (MACCS2) computer code (NRC, 1998), and insights from the CNS individual plant examination (IPE) (NPPD, 1993) and individual plant examination of external events (IPEEE) (NPPD, 1996). In identifying and evaluating potential SAMAs, NPPD considered SAMA candidates that addressed the major contributors to core damage frequency (CDF) and large early release frequency (LERF) at CNS, as well as SAMA candidates for other operating plants which have submitted license renewal applications. NPPD identified 244 potential SAMA candidates. This list was reduced to 80 unique SAMA candidates by eliminating SAMAs that are not applicable at CNS due to design differences, have already been implemented at CNS, or are similar in nature and could be combined with another SAMA candidate. NPPD assessed the costs and benefits associated with each of the potential SAMAs and concluded in the ER that several of the candidate SAMAs evaluated are potentially cost-beneficial.

Based on a review of the SAMA assessment, the NRC issued a request for additional information (RAI) to NPPD by letter dated June 8, 2009 (NRC, 2009). Key questions concerned: (1) the impact of unresolved Boiling Water Reactor Owner's Group (BWROG) PSA peer review findings on the SAMA analysis results; (2) the process used to develop and group source terms into containment event tree (CET) end states; (3) the rationale for identifying and screening SAMAs; and (4) the costs and benefits of several specific candidate SAMAs and low cost alternatives. NPPD submitted additional information by letter dated July 1, 2009 (NPPD, 2009a) and e-mail dated August 10, 2009 (NPPD, 2009b). In response to the RAIs, NPPD provided information regarding the findings of the BWROG peer review, a discussion and example of the process for assigning severe accident source terms to CET sequences, additional rationale on the process used to identify and screen SAMAs, and additional information regarding several specific SAMAs. NPPD's responses addressed the NRC staff's concerns.

An assessment of SAMAs for CNS is presented below.

F.2. Estimate of Risk for Cooper Nuclear Station

NPPD's estimates of offsite risk at CNS are summarized in Section F.2.1. The summary is followed by the NRC staff's review of NPPD's risk estimates in Section F.2.2.

F.2.1. Nebraska Public Power District's Risk Estimates

Two distinct analyses are combined to form the basis for the risk estimates used in the SAMA analysis: (1) the CNS Level 1 and 2 PSA model, which is an updated version of the IPE (NPPD, 1993); and (2) a supplemental analysis of offsite consequences and economic impacts (essentially a Level 3 PSA model) developed specifically for the SAMA analysis. The SAMA analysis is based on the most recent CNS Level 1 and Level 2 PSA models available at the time of the ER, referred to as the CNS 2007TM model (2007TM, Revision 1). The scope of this CNS PSA does not include external events.

The CNS CDF is approximately 9.3×10^{-6} per year for internal events as determined from quantification of the Level 1 PSA model. When determined from the sum of the CET sequences, or the Level 2 PSA model, the release frequency is approximately 1.2×10^{-5} per year. The latter value was used as the baseline CDF in the SAMA evaluations (NPPD, 2009a). The CDF is based on the risk assessment for internally-initiated events, which includes internal flooding. NPPD did not include the contribution from external events within the CNS risk estimates, however, it did account for the potential risk reduction benefits associated with external events by multiplying the estimated benefits for internal events by a factor of 3. For some fire-related SAMAs, NPPD separately estimated the risk reduction benefits using the fire risk model. This is discussed further in Sections F.2.2 and F.6.2.

The breakdown of CDF by initiating event is provided in Table F-1. As shown in this table, events initiated by transients, loss of DC power, loss-of-coolant accidents (LOCAs), and loss of feedwater are the dominant contributors to the CDF. Station blackout (SBO) and anticipated transient without scram (ATWS) sequences may occur following multiple initiators and so their total contributions to CDF were reported separately. Each contributes less than 3 percent to the total internal events CDF.

The Level 2 CNS PSA model that forms the basis for the SAMA evaluation represents an updated version of the original IPE Level 2 model. The current Level 2 model uses a single CET containing both phenomenological and systemic events. The Level 1 core damage sequences are binned into one of 15 plant damage state (PDS) bins which provide the interface between the Level 1 analysis and Level 2 CET analysis. The CET probabilistically evaluates the progression of the damaged core with respect to radiation release into the environment. CET nodes are evaluated using supporting fault trees and logic rules. The CET end states then are examined for considerations of timing and magnitude of release and assigned to release categories.

Table F-1. Cooper Nuclear Station Core Damage Frequency for Internal Events

Initiating Event	CDF (per year)	% Contribution to CDF
Transients	3.0×10^{-6}	32
Loss of DC power	2.1×10^{-6}	22
LOCAs	1.4×10^{-6}	15
Loss of feedwater	1.0×10^{-6}	11
Loss of offsite power	6.5×10^{-7}	7
Loss of service water (SW)	6.0×10^{-7}	7
Loss of AC buses	2.6×10^{-7}	3
Internal flood	2.6×10^{-7}	3
Interfacing-systems loss-of-coolant accidents (ISLOCAs)	5.1×10^{-8}	<1
Total CDF (Internal Events)	9.3×10^{-6}	100

The result of the Level 2 PSA is a set of 12 release categories, also referred to as source term categories, with their respective frequency and release characteristics. The release categories and their characteristics are provided in Table E.1-10 of the ER (NPPD, 2008). The categories were defined based on the timing, duration, and magnitude of the release and whether or not the containment remains intact or fails. The frequency of each release category was obtained by summing the frequency of the individual accident progression CET endpoints assigned to each release category. Source terms were developed for each of the 12 release categories using the results of Modular Accident Analysis Program, Version 4.0.5 (MAAP 4.0.5) computer code calculations.

The offsite consequences and economic impact analyses use the MACCS2 code to determine the offsite risk impacts on the surrounding environment and general public. Inputs for these analyses include plant-specific and site-specific input values for core radionuclide inventory, source term and release characteristics, site meteorological data, projected population distribution (within a 50-mile (mi) (80-kilometer (km)) radius) for the year 2034, emergency response evacuation modeling, and economic data. The magnitude of the onsite impacts (in terms of clean-up and decontamination costs and occupational dose) is based on information provided in NUREG/BR-0184 (NRC, 1997a).

In the ER, NPPD estimated the dose to the population within 50 mi (80 km) of the CNS site to be approximately 0.021 person-Sievert (Sv) (2.1 person-roentgen equivalent man (rem)) per year. The breakdown of the total population dose by containment release mode is summarized in Table F-2. Containment failures within the early time frame (less than 3.7 hours following event initiation) dominate the population dose risk at CNS, with failures in the intermediate time frame (3.7 to 24 hours following event initiation) contributing most of the remaining population dose risk.

Table F-2. Breakdown of Population Dose by Containment Release Mode

Containment Release Mode	Population Dose (Person-Rem^(a) Per Year)	% Contribution
Early containment failure	1.67	78
Intermediate containment failure	0.47	22
Late containment failure	<0.1	<1
Intact containment	Negligible	negligible
Total	2.14	100

(a) One person-rem = 0.01 person-Sv

F.2.2. Review of Nebraska Public Power District's Risk Estimates

NPPD's determination of offsite risk at CNS is based on the following three major elements of analysis:

- the Level 1 and 2 risk models that form the basis for the 1993 IPE submittal (NPPD, 1993) and the external event analyses of the 1996 IPEEE submittal (NPPD, 1996)
- the major modifications to the IPE model that have been incorporated in the CNS PSA
- the MACCS2 analyses performed to translate fission product source terms and release frequencies from the Level 2 PSA model into offsite consequence measures

Each of these analyses was reviewed to determine the acceptability of the NPPD risk estimates for the SAMA analysis, as summarized below.

The NRC staff's review of the CNS IPE is described in an NRC report dated February 14, 1996 (NRC, 1996). Based on a review of the IPE submittal and responses to RAIs, the NRC staff concluded that the IPE submittal met the intent of Generic Letter (GL) 88-20 (NRC, 1988); that is, the licensee's IPE process is capable of identifying the most likely severe accidents and severe accident vulnerabilities. Although no vulnerabilities were identified in the IPE, several improvements to the plant or procedures were identified. These improvements have been either implemented at the site or addressed in the SAMA evaluation process (NPPD, 2008). These improvements are discussed in Section F.3.2.

There have been five revisions to the IPE model since the 1993 IPE submittal. A listing of the major changes in each revision of the PSA was provided by NPPD in the ER and is summarized in Table F-3. A comparison of the internal events CDF between the 1993 IPE and the 2007TM Revision 1 PSA model used for the SAMA evaluation indicates a decrease of approximately 88 percent (from 8.0×10^{-5} per year to 9.3×10^{-6} per year). A description of those changes that resulted in the greatest impact on the internal event CDF is provided in Section E.1.4 of the ER (NPPD, 2008). The decrease is mainly attributed to plant and modeling improvements made between the IPE and the 1996b model update.

Table F-3. Cooper Nuclear Station Probabilistic Safety Assessment Historical Summary

PSA Version	Summary of Changes from Prior Model	CDF (per year)
1993	IPE Submittal (excluding internal flooding)	8.0×10^{-5}
1996b	<ul style="list-style-type: none"> - Revised the human reliability analysis to incorporate revisions to emergency operating procedures - Added credit for newly installed torus hard pipe vent - Corrected conservative thermal hydraulic analysis of safety relief valve (SRV) flow - Improved loss of offsite power model 	1.3×10^{-5}
2001a	<ul style="list-style-type: none"> - Incorporated minor improvements stemming from the 9/97 peer review - Updated component failure and unavailability database - Developed LERF model 	1.3×10^{-5}
2005TM	Updated initiating event frequencies to reflect information in NUREG/CR-6890	1.1×10^{-5}
2006TM	Updated model to support the Mitigating System Performance Index (MSPI) and maintenance rule update	1.4×10^{-5}
2007TM (Revision 1)	<ul style="list-style-type: none"> - Added internal flooding to the Level 1 model - Incorporated operator action dependencies - Expanded the treatment of common cause failures - Developed a more detailed CET and new Level 2 fault trees - Added new Level 1 system models including severe accident mitigation strategies such as firewater injection - Updated PSA model data - Developed initiator fault trees to calculate some initiating event frequencies, such as loss of turbine equipment cooling (TEC) 	9.3×10^{-6}

The CDF value from the 1993 CNS IPE (8.0×10^{-5} per year) is near the upper end of the range of the CDF values reported in the IPEs for other boiling-water reactor (BWR) 3/4 plants. Figure 11.2 of NUREG-1560 shows that the IPE-based total internal events CDF for BWR 3/4 plants ranges from about 9×10^{-8} per year to 1×10^{-4} per year, with an average CDF for the group of 2×10^{-5} per year (NRC, 1997b). It is recognized that other plants have updated the values for CDF subsequent to the IPE submittals to reflect modeling and hardware changes. The internal events CDF result for CNS used for the SAMA analysis (9.3×10^{-6} per year) is comparable to other plants of similar vintage and characteristics.

The NRC staff considered the peer reviews performed for the CNS PSA and the potential impact of the review findings on the SAMA evaluation. In the ER (NPPD, 2008), NPPD described the BWROG peer review of the 2007TM Revision 1 model conducted in May 2008. The peer review was performed using the Nuclear Energy Institute (NEI) 05-04 process (NEI, 2007), the American Association of Mechanical Engineers (ASME) PRA Standard (ASME, 2007), and NRC Regulatory Guide 1.200, Revision 1 (NRC, 2007). The NRC staff asked NPPD to provide a summary of each of the peer review findings and an assessment of the impact of resolving each finding on the SAMA identification and analysis results (NRC, 2009). In response to this request, NPPD provided a table summarizing the peer review findings in relation to the applicable supporting requirements (SR) and an assessment of the impact of the resolution of the findings on the PSA results (NPPD, 2009a). The peer review identified 22 findings against the SR, including 10 classified as not met. The 10 not-met findings

Appendix F

included documentation of analysis bases, PSA configuration control, identification of internal flooding mechanisms, and evaluation of human error dependencies. NPPD's review of the 22 peer review findings resulted in no changes to the PSA model and no impacts on the SAMA identification and analysis results. The NRC staff considers NPPD's rationale reasonable and that the final resolution of the peer review findings is not likely to impact the results of the SAMA analysis.

Because the CNS internal events PSA model has been peer-reviewed and the peer review findings were all addressed, and NPPD has satisfactorily addressed NRC staff questions regarding the PSA, the NRC staff concludes that the internal events Level 1 PSA model is of sufficient quality to support the SAMA evaluation.

As indicated above, the current CNS PSA does not include external events. In the absence of such an analysis, NPPD used the CNS IPEEE to identify the highest risk accident sequences and the potential means of reducing the risk posed by those sequences, as discussed below and in Section F.3.2.

The CNS IPEEE was submitted in October 1996 (NPPD, 1996), in response to Supplement 4 of GL 88-20 (NRC, 1991). These submittals included a seismic margins analysis, an internal fire PSA, and evaluations of high winds, external flooding, and other hazards. While no fundamental weaknesses or vulnerabilities to severe accident risk in regard to the external events were identified, several opportunities for risk reduction were identified as discussed below. In a letter dated April 27, 2001, the NRC staff concluded that the submittal met the intent of Supplement 4 to GL 88-20, and that the licensee's IPEEE process is capable of identifying the most likely severe accidents and severe accident vulnerabilities (NRC, 2001).

The CNS IPEEE used a focused scope Electric Power Research Institute (EPRI) seismic margins analysis which was completed in conjunction with the Seismic Qualification User's Group (SQUG) program (SQUG, 1992). This method is qualitative and does not provide numerical estimates of the CDF contributions from seismic initiators (EPRI, 1991). For this assessment, the review level earthquake (RLE) value for CNS was specified by the NRC to be 0.3g. Plant walkdowns were performed in which components and structures were screened for the RLE based on the EPRI guidelines, and specific high confidence in low probability of failure (HCLPF) capacities were calculated for components and structures that did not screen out. All structures and all but six components were screened out, of which five were Unresolved Safety Issue (USI) A-46 program outliers. Several improvements were identified to address the six unscreened components and to reduce seismic risk. While some of these improvements have been implemented, all were addressed as SAMA candidates, as discussed in Section F.3.2.

The NRC review and closure of USI A-46 for CNS is documented in a letter dated September 30, 1999 (NRC, 1999).

To provide additional insight into the appropriate seismic CDF to use for the SAMA evaluation, the NRC staff developed an independent estimate of the seismic CDF for CNS using the simplified-hybrid approximation method described in a paper by Robert P. Kennedy, entitled "Overview of Methods for Seismic PRA and Margin Analysis Including Recent Innovations" (Kennedy, 1999) and using updated 2008 seismic hazard curve data from the U.S. Geological Survey (USGS, 2008). The NRC staff's independent calculations indicate the seismic CDF for CNS to be approximately 6×10^{-6} per year depending on the seismic hazard curve and plant fragility assumptions. Since NPPD did not provide a seismic CDF contribution in the ER, the NRC staff used this result to assess the appropriateness of the external event multiplier used in the SAMA evaluation.

The CNS IPEEE fire analysis employed a combination of PSA with the EPRI's fire-induced vulnerability evaluation (FIVE) methodology (EPRI, 1993). Fire compartments were initially qualitatively screened out if all compartment boundaries screened out according to Fire Compartment Interaction Analysis (FCIA) criteria and if the compartment did not contain Appendix R equipment. Quantitative screening was then performed using fire frequencies based on the FIVE methodology and the assumption that fire failed all of the equipment in the compartment. The sequence was then quantified using the internal events PSA model. If the CDF was greater than 1×10^{-6} per year, the compartment was subjected to more detailed analysis. In this analysis, the FIVE fire screening methodology was used in the fire modeling with one exception. The exception involved the partitioning of oil spill fires into large and small spills based on a recommendation in the "EPRI Fire PRA Implementation Guide" (EPRI, 1994). The total fire CDF, found by summing the values for all compartments, is 1.9×10^{-5} per year. The fire compartments having a fire CDF greater than 1×10^{-7} per year and their contributions to the fire CDF are listed in Table F-4.

In the ER, NPPD identifies a number of conservatisms in the fire analysis, including:

- The NRC fire events database indicates a trend toward lower frequency and less severe fires since the IPEEE fire analysis was performed.
- Because of little industry experience with crew actions following a fire, crew actions were conservatively characterized in the fire model.
- A fire that damaged a cable was assumed to always induce a conductor failure.
- Manual fire suppression was only credited in the control room and non-essential switchgear rooms.
- Hardware repair activities were not credited.

The NRC staff inquired about additional measures that NPPD had already taken to reduce fire risk since the IPEEE (NRC, 2009). NPPD provided a description of the measures taken in the four dominant fire compartments (3A-switchgear room 1F, 3B-switchgear room 1G, 10B-control room and security access control corridor, and 20A-SW pump room). These measures consisted primarily of improvements to monitoring and controlling the quantity of combustible materials and pre-staging of outage materials.

Table F-4. Cooper Nuclear Station Fire Compartments and Their Contributions to Fire Core Damage Frequency

Fire Compartment	Fire Compartment Description	CDF (per year)
10B	Control Room and Security Alarm Station (SAS) Corridor	3.7×10^{-6}
3B	Switchgear Room 1G	2.7×10^{-6}
20A	SW Pump Room	1.7×10^{-6}
3A	Switchgear Room 1F	1.1×10^{-6}
8-1	Condenser Pit Area	9.7×10^{-7}
9A	Cable Spreading Room	8.2×10^{-7}
2A/2C	Reactor Building El. 903'-6" – Control Rod Drive (CRD) Units – North/South	8.2×10^{-7}
8G	DC Switchgear Room 1B	7.9×10^{-7}
8B	Reactor Protection System (RPS) Room 1B	7.3×10^{-7}
8F	Battery Room 1B	6.7×10^{-7}
14A	Emergency Diesel Generator (EDG) Room 1A	6.1×10^{-7}
14B	EDG Room 1B	6.1×10^{-7}
7A	Residual Heat Removal Service Water (RHRSW) Booster and Service Air Compressor	5.6×10^{-7}
4A/4C/4D	Reactor Building El. 958'-3" – Fuel Pool Heat Exchanger/Lube Oil	5.4×10^{-7}
8A	Auxiliary Relay Room	3.7×10^{-7}
9B	Cable Expansion Room	3.4×10^{-7}
8H	DC Switchgear Room 1A	3.4×10^{-7}
13B	Non-Critical Switchgear Room	3.3×10^{-7}
3C/3D/3E	Reactor Building El. 932'-6" – REC	2.7×10^{-7}
8E	Battery Room 1A	1.8×10^{-7}
1F	Suppression Pool Area	1.7×10^{-7}
12D	Turbine Building Floor – North El. 903'-6"	1.4×10^{-7}
1B/1G	Core Spray (CS) and CRD Room	1.0×10^{-7}
	Other Compartments	6.4×10^{-7}
Total Fire CDF		1.9×10^{-5}

Based on the conservatisms in the analysis and the actions taken by NPPD to reduce fire risk since the IPEEE, the NRC staff concludes that the fire CDF of 1.9×10^{-5} per year is reasonable for the SAMA analysis.

The CNS IPEEE analysis of high winds, tornadoes, external floods, and other external events followed the screening and evaluation approaches specified in Supplement 4 to GL 88-20 (NRC, 1991) and did not identify any sequences or vulnerabilities that exceeded the 1.0×10^{-6}

per year criterion except for the design-basis tornado and a lightning strike to the control building (NPPD, 1996). Plant improvements were identified to address each of these issues and included as SAMA candidates, as discussed in Section F.3.2. The NRC staff concluded in the review of the CNS IPEEE that the tornado missiles contribution to CDF is less than the screening criteria and that lightning did not pose a significant hazard to the plant (NRC, 2001).

Based on the aforementioned results, including the NRC staff assessment of the CNS seismic CDF, the external events CDF is approximately two times the internal events CDF (based on a seismic CDF of 6×10^{-6} per year, a fire CDF of 1.9×10^{-5} per year, and an internal events CDF of 1.2×10^{-5} per year). Accordingly, the NRC staff concurred with NPPD's conclusion that the total CDF (from internal and external events) would be approximately three times the internal events CDF. In the SAMA analysis submitted in the ER, NPPD tripled the benefit that was derived from the internal events model to account for the combined contribution from internal and external events. The NRC staff agrees with the licensee's overall conclusion concerning the multiplier used to represent the impact of external events and concludes that the licensee's use of a multiplier of 3 to account for external events is reasonable for the purposes of the SAMA evaluation. This is discussed further in Section F.6.2.

The NRC staff reviewed the general process used by NPPD to translate the results of the Level 1 PSA into containment releases, as well as the results of the Level 2 analysis, as described in the ER and in response to NRC staff requests for additional information (NPPD, 2008), (NPPD, 2009a). This model is an updated version of the model used in the IPE and reflects the CNS configuration and design as of December 2007. Major revisions and updates to the Level 2 model include equipment performance data for failure rates and system unavailability, plant configuration changes, improved modeling techniques, inclusion of additional PDS bins to improve the Level 1 and Level 2 PSA interface, and updated accident progression and source term analyses using a later version of the MAAP computer code. The Level 1 core damage sequences are binned into one of 15 PDS bins which provide the interface between the Level 1 and Level 2 analysis. The PDS, which are described in Table E.1-8 of the ER (NPPD, 2008), are defined by a set of functional characteristics for system operation which are important to accident progression, containment failure, and source term definition. The Level 2 models use a single CET for each PDS with functional nodes representing both systemic and phenomenological events. The CET is used to determine the appropriate release category for each Level 2 sequence. CET nodes are evaluated using supporting fault trees and logic rules.

NPPD characterized the releases for the spectrum of possible radionuclide release scenarios using a set of 12 release categories based on the timing and magnitude of the release and whether or not the containment remained intact. The frequency of each release category was obtained by summing the frequency of the individual accident progression CET endpoints binned into the release category. The release characteristics for each release category were developed by grouping the hundreds of source terms generated for internal initiators into the 12 categories based on similar properties. Source term release fractions were developed for each of the 12 release categories using the results of 46 MAAP 4.0.5 computer code calculations (NPPD, 2009a). In response to an NRC staff RAI, NPPD identified that for each CET sequence, a value for each of the release-to-environment mass fractions was obtained from the representative MAAP calculation (NPPD, 2009a). These mass fractions were then weighted according to the contribution of that sequence to the sum of the sequences in the end state bin. The final mass fraction representing the end state bin was the sum of these individual weighted mass fractions for each species. The release categories, their frequencies, and release characteristics are presented in Tables E.1-6, E.1-7, E.1-9, and E.1-10 of the ER, respectively (NPPD, 2008).

Appendix F

The NRC staff noted that the iodine and cesium mass fractions for the low-low intermediate release category in Table E.1-10 of the ER are substantially less than the corresponding mass fractions for the low-low early and low-low late release categories and requested NPPD to provide an explanation for this apparent anomaly (NRC, 2009). In response, NPPD explained that the dominant sequences for the low-low intermediate release category involve offsite release via containment venting through an intact suppression pool, resulting in effective fission product scrubbing (NPPD, 2009a). In contrast, the dominant sequences for the low-low early and low-low late release categories involve release paths from the primary containment that bypass the suppression pool, resulting in much less fission product scrubbing than for the low-low intermediate release category. Consequently, the cesium and iodine mass fractions for the low-low intermediate release category will be less than that for the low-low early and low-low late release categories.

The NRC staff requested NPPD provide an explanation of the reasons for the difference in the total release frequency value of 1.2×10^{-5} derived from the CET and the Level 1 CDF value of 9.3×10^{-6} and to provide the rationale for using the total release frequency for the SAMA analysis (NRC, 2009). In response, NPPD indicated that (NPPD, 2009a):

- The total release frequency derived from the CET is larger than the Level 1 CDF because of the methodology used in the CET for deriving the split fraction values. The CET contains numerous paths that do not meet the rare event approximation criterion (e.g., split fractions greater than 5×10^{-2}) in the quantification approach used. For these paths, the sum of the split fractions for the corresponding failure and success branches is greater than 1 resulting in a conservatively high total CDF.
- Since the SAMA evaluation requires both Level 1 and 2 PSA results, NPPD chose the higher value from the CET as the basis for quantifying SAMA benefits.

NPPD concludes that use of the release frequency, rather than the Level 1 CDF, will have a negligible impact on the results of the SAMA evaluation because the delta risk calculation, performed to assess SAMA benefits, effectively cancels out the impact of the simplified model quantification methodology, and because the external event multiplier and uncertainty multiplier used in the SAMA analysis (discussed in Section F.6.2) have a much greater impact on the SAMA evaluation results than the small error arising from the model quantification approach. The NRC staff agrees with this conclusion.

The NRC staff's review of the Level 2 IPE concluded that it addressed the most important severe accident phenomena normally associated with the Mark I containment type, and identified no significant problems or errors (NRC, 1996). The changes to the Level 2 model since the IPE to update the methodology and to address peer review recommendations are described in Section E.1.4 of the ER. The Level 2 PSA model was included in the May 2008 BWROG peer review mentioned previously. Of the 22 peer review findings, one finding in the SR not-met category was related to identification of limitations in the LERF analysis that would impact applications. In response to an NRC staff RAI, NPPD reviewed this finding and determined that there were no limitations that would impact projected applications that are not already documented, and concluded that the finding would not impact the results of the SAMA analysis.

Based on the NRC staff's review of the Level 2 methodology, the fact that the Level 2 model was reviewed in more detail as part of the BWROG peer review and that the peer review findings do not impact the SAMA analysis, and the responses to the RAIs concerning the analysis and review process, the NRC staff concludes that the Level 2 PSA provides an acceptable basis for evaluating the benefits associated with various SAMAs.

As indicated in the ER, the reactor core radionuclide inventory used in the consequence analysis was derived from ORIGEN2 calculations using a bounding core enrichment and burnup for CNS. A core power of 2,429 megawatts-thermal (MWt) was assumed to bound the licensed maximum power of 2,419 MWt for the CNS Measurement Uncertainty Recapture power uprate approved by the NRC in 2008. The NRC staff requested additional information about the expected fuel burnup and management for the renewal period (NRC, 2009). NPPD responded that the bounding core inventory assumed an initial enrichment of 3.908 weight percent uranium-235 and 1,300 effective full-power days (EFPD) of continuous operation to achieve an end of cycle core average exposure of 35.8 Gwd/MT (NPPD, 2009a), and that this core inventory reflects the expected fuel management/burnup for the renewal period.

The NRC staff reviewed the process used by NPPD to extend the containment performance (Level 2) portion of the PSA to an assessment of offsite consequences (Level 3). This included consideration of the source terms used to characterize fission product releases for the applicable containment release categories and the major input assumptions used in the offsite consequence analyses. Version 1.13.1 of the MACCS2 code was used to estimate offsite consequences. Plant-specific input to the code includes the source terms for each release category and the reactor core radionuclide inventory (both discussed above), site-specific meteorological data, projected population distribution within a 50-mi (80-km) radius for the year 2034, emergency evacuation modeling, and economic data. This information is provided in Attachment E to the ER (NPPD, 2008).

NPPD used site-specific meteorological data for the 5 years, 2002 through 2006, as input into the MACCS2 code. NPPD averaged the data over this interval for this study. The data were collected from the onsite meteorological monitoring system and regional National Weather System (NWS) stations. Regional mixing heights were estimated using ground level and upper-air data collected at NWS station No. 94980 in Valley, NE (approximately 76 mi (120 km) north-northwest of CNS), and station No. 72553 in Falls City/Brenner, NE (approximately 19 mi (30 km) south of CNS). Missing data were estimated using data substitution methods. These methods include substitution of missing data with valid data from the previous hour, or valid data collected from other elevations on the meteorological tower. The NRC staff notes that previous SAMA analyses results have shown little variation resulting from year-to-year differences in meteorological data and concludes that the approach taken for collecting and applying the meteorological data in the SAMA analysis is reasonable.

The population distribution used by the licensee as input to the MACCS2 analysis was estimated for the year 2034 based on county-level projections obtained from the University of Nebraska Bureau of Business Research (UN, 2007), Woods & Poole Economics, Inc. for Iowa (Woods & Poole, 2006), Eklund et al. for Kansas (Eklund et al., 1999), and the Missouri Census Data Center (Missouri, 2007). Year 2005 tourist information was used to estimate the transient population in Iowa, Missouri, and Nebraska (IDED, 2006), (Kaylen, 2006), (NDED, 2006). Year 2004 tourist information was used to estimate the transient population for year 2005 in Kansas (Global Insight, 2006). These data were used to project county-level populations using a regression method to extrapolate population projections to 2034. For the counties with populations in decline, the population value for year 2014 was used, which corresponds to the

license expiration date for CNS. The NRC staff considers the methods and assumptions for estimating population reasonable and acceptable for purposes of the SAMA evaluation.

The emergency evacuation model was modeled as a single evacuation zone extending out 10 mi (16 km) from the plant. NPPD assumed that 100 percent of the population would move at an average speed of approximately 19.5 miles per hour (mph) (8.7 meters per second (m/s)) with a delayed start time of 2 hours (NPPD, 2008). The evacuation speed and time were based on the average values identified in the Missouri and Nebraska time estimate studies. NPPD performed sensitivity analyses in which the evacuation delay time was increased to 4 hours, and the evacuation speed was decreased to 1 m/s. Each of these sensitivity cases resulted in less than a 1 percent increase in the total population dose. The 100 percent population evacuation assumption is slightly less conservative than the assumption used in NUREG-1150 study (NRC, 1990), which assumed evacuation of 99.5 percent of the population within the emergency planning zone (EPZ). The NRC staff asked NPPD to address the potential impact on the population dose if 5 percent of the population fails to evacuate the EPZ (NRC, 2009). In response, NPPD performed a sensitivity analysis that showed only a slight increase in population dose (less than 1 percent) would result (NPPD, 2009a). The NRC staff concludes that the evacuation assumptions and analysis are reasonable and acceptable for the purposes of the SAMA evaluation.

Much of the site-specific economic data was obtained from the 2002 Census of Agriculture (USDA, 2002). These included the value of farm and non-farm wealth. Other generic data that applies to the region as a whole, such as the cost of evacuating and relocating people, land decontamination, and property decontamination, were obtained from the code manual for MACCS2 (NRC, 1998). The data from the MACCS2 code manual were inflation-adjusted using the consumer price index corresponding to the year 2006. Information on regional crops was obtained from the 2002 Census of Agriculture. Crops for each county were mapped into the seven MACCS2 crop categories.

The NRC staff concludes that the methodology used by NPPD to estimate the offsite consequences for CNS provides an acceptable basis from which to proceed with an assessment of risk reduction potential for candidate SAMAs. Accordingly, the NRC staff based its assessment of offsite risk on the CDF and offsite doses reported by NPPD.

F.3. Potential Plant Improvements

The process for identifying potential plant improvements, an evaluation of that process, and the improvements evaluated in detail by NPPD are discussed in this section.

F.3.1. Process for Identifying Potential Plant Improvements

NPPD's process for identifying potential plant improvements (SAMAs) consisted of the following elements:

- review of the most significant basic events from the current, plant-specific PSA
- review of potential plant improvements identified in the CNS IPE and IPEEE
- review of SAMA candidates identified for license renewal applications for 11 other U.S. General Electric (GE) plants

- review of other NRC and industry documentation discussing potential plant improvements

Based on this process, an initial set of 244 candidate SAMAs, referred to as Phase I SAMAs, was identified. In Phase I of the evaluation, NPPD performed a qualitative screening of the initial list of SAMAs and eliminated SAMAs from further consideration using the following criteria:

- the SAMA modified features are not applicable to CNS
- the SAMA has already been implemented at CNS
- the SAMA is similar in nature and could be combined with another SAMA candidate

Based on this screening, 164 SAMAs were eliminated leaving 80 for further evaluation. The remaining SAMAs, referred to as Phase II SAMAs, are listed in Table E.2-2 of the ER (NPPD, 2008). In Phase II, a detailed evaluation was performed for each of the 80 remaining SAMA candidates, as discussed in Sections F.4 and F.6 below. To account for the potential impact of external events, the estimated benefits, based on internal events, were multiplied by a factor of 3, as previously discussed.

F.3.2. Review of Nebraska Public Power District's Process

NPPD's efforts to identify potential SAMAs focused primarily on areas associated with internal initiating events. The initial list of SAMAs generally addressed the accident sequences considered to be important to CDF from functional, initiating event, and risk reduction worth (RRW) perspectives at CNS, and included selected SAMAs from prior SAMA analyses for other plants.

NPPD provided a tabular listing of the PSA basic events sorted according to their RRW (NPPD, 2008). SAMAs impacting these basic events would have the greatest potential for reducing risk. NPPD used an RRW cutoff of 1.005, which corresponds to about a 0.5 percent change in CDF given 100-percent reliability of the SAMA. This equates to a benefit of approximately \$5,300 (after the benefits have been multiplied to account for external events). NPPD also provided and reviewed the LERF-based RRW events down to an RRW of 1.005. NPPD correlated the top Level 1 and Level 2 events with the SAMAs evaluated in the ER and showed that all of the significant basic events are addressed by one or more SAMAs (NPPD, 2008).

The NRC staff asked NPPD to provide the rationale for identifying candidate SAMAs for LERF-based success events (NRC, 2009). In response to the RAI, NPPD replied that, unlike SAMAs identified for the purpose of decreasing the risk of failure events, SAMAs identified for success events are intended to decrease the risk contribution from the cutsets or basic events related to the success event (NPPD, 2009a). NPPD further noted that SAMAs identified for success events are also identified for related failure events and provided specific examples of this relationship. The staff finds NPPD's treatment of success events acceptable.

The NRC staff also asked NPPD to clarify how RRW was calculated for complementary events and to provide an assessment of the impact on the SAMA identification and evaluation process if complementary events were not directly coupled in the computation of RRW (NRC, 2009).

Appendix F

NPPD responded that complementary events were directly coupled in the calculation of RRW, provided an example of this direct coupling, and concluded that since this coupling was performed correctly there is no impact on the SAMA identification and evaluation process (NPPD, 2009a). The NRC staff agrees that NPPD appropriately accounted for direct coupling of complementary events in the calculation of RRW.

The NRC staff requested clarification on the screening criteria used for the Phase I SAMAs because the ER was inconsistent in describing this process (NRC, 2009). NPPD responded that the criteria for screening Phase I SAMAs based on SAMA modifying features not applicable to CNS is broader than this description suggests and includes: (1) SAMAs that have already been analyzed for CNS and determined to be of low benefit, and (2) SAMAs that have been previously resolved with NRC based on further evaluation that determined that the modification was not necessary (NPPD, 2009).

For a number of the Phase II SAMAs listed in the ER, the information provided did not sufficiently describe the proposed modification. Therefore, the NRC staff asked the applicant to provide more detailed descriptions of the modifications for several of the Phase II SAMA candidates (NRC, 2009). In response to the RAI, NPPD provided the requested information on the modifications for SAMAs 20, 44, 45, 63, 70, 72, 73, 76, 77, and 80 (NPPD, 2009a).

NPPD considered the potential plant improvements described in the IPE and IPEEE in the identification of plant-specific candidate SAMAs for internal and external events. Although the IPE did not identify any vulnerabilities, seven potential enhancements to the plant, procedures, and training at CNS were identified as part of the IPE process. The seven enhancements include (NPPD, 1993):

- upgrading the plant-specific emergency operating procedures based on Revision 4 of the BWROG Emergency Procedure Guidelines
- performing a load study to relax the assumed 4-hour battery lifetime and provide a procedure to improve battery loading schemes
- providing a procedure to bypass the AC solenoid valve on the nitrogen supply line to the SRVs
- providing a diesel-driven fire water pump or other similar source of low pressure water independent of AC power
- improving the reliability of the high pressure coolant injection (HPCI) and reactor core isolation cooling (RCIC) systems
- providing a backup for the SW pumps by modifying the existing system and making procedural changes
- providing improved drywell spray capability

NPPD noted that the first four of these enhancements have already been implemented at CNS and the remaining three enhancements are addressed by SAMAs. The fifth enhancement is to improve the reliability of the HPCI and RCIC systems, as addressed by Phase II SAMA 35, "provide a redundant train or means of ventilation," and SAMA 67, "improve the reliability of the

HPCI and RCIC systems by upgrading their control systems." The sixth enhancement is to provide a backup for the SW pumps, as addressed by Phase II SAMA 68, "proceduralize the ability to cross-connect the circulating water pumps and the SW going to the TEC heat exchangers." The last enhancement, to provide an improved drywell spray capability, was judged to be already implemented at CNS where the fire water system is used as a backup source for the drywell spray system. Nevertheless, NPPD further addressed this enhancement with Phase II SAMA 47, "install a passive drywell spray system to provide a redundant drywell spray method."

Based on this information, the NRC staff concludes that the set of SAMAs evaluated in the ER, together with those identified in response to NRC staff RAIs, addresses the major contributors to internal event CDF.

Several seismic-related improvements were identified in the CNS IPEEE. The specific seismic interaction issues are as follows (NPPD, 1996):

- potential relay chatter at low seismic levels for 10 relays
- potential impact of the 480-volt (V) critical switchgear 1G with an adjacent concrete beam
- potential seismic interaction of the solatron/accuvolt line conditioners with a stairway supported by a masonry wall
- potential inadequate seismic capacity for the SE and NE quad recirculation fans
- potential impact of the jet pump instrument rack A with an adjacent rack
- inadequate anchorage capacity for loose equipment in the control room and lack of support for the overhead lighting diffusers
- inadequate anchorage for the aux relay room panels
- inadequately braced unistrut trapeze frame in the northeast corner of elevation 903 feet of the reactor building
- loose bolt securing on one corner of an interior panel of the SW pump B & D strainer control panel

All of these were identified as Phase I SAMAs but have already been implemented or previously resolved under the USI A-46 Program (NRC, 2001). As a result, no Phase II SAMAs were identified to address these issues. The CNS IPEEE seismic/fire interaction evaluation did conclude that the CNS water-based fire protection systems were vulnerable to a seismic event. This vulnerability was addressed by Phase II SAMA 69, "upgrade the seismic capacity of the diesel fire pump fuel tank and water supply tank." The NRC staff concludes that the opportunity for seismic-related SAMAs has been adequately explored and that it is unlikely that there are additional potentially cost-beneficial, seismic-related SAMA candidates.

Appendix F

The CNS IPEEE fire assessment concluded that the four fire compartments (Control Room and SAS Corridor, Switchgear Rooms 1F and 1G, and SW Pump Room) that did not screen out based on having a fire CDF of less than 1.0×10^{-6} per year represent vulnerabilities (NPPD, 1996). Two plant improvements were identified to address these risk contributors:

- addition of a feature to allow remote control of the switchyard breakers from the control room, or to have a preplanned recovery/repair action for control of the switchyard breakers following a fire, and
- provide a diverse water supply for the SW system

Both of these were identified as Phase I SAMAs. As indicated in the ER, an evaluation of improvements for control of the switchyard breakers showed a decrease in CDF of less than 0.5 percent, therefore, this change was not implemented or evaluated as a Phase II SAMA. The second improvement was evaluated as Phase II SAMA 68, "proceduralize the ability to cross-connect the circulating water pumps and the SW pumps going to the TEC heat exchangers." NPPD also identified two additional Phase II SAMAs to reduce the fire CDF in dominant fire zones without suppression and in the control room: (1) SAMA 63, "add automatic fire suppression systems to the dominant fire zones," and (2) SAMA 65, "upgrade the ASDS panel to include additional system controls for the opposite division." The NRC staff concludes that the opportunity for fire-related SAMAs has been adequately explored and that it is unlikely that there are additional potentially cost-beneficial, fire-related SAMA candidates.

As stated earlier, other external hazards (e.g., high winds, external floods, transportation and nearby facility accidents) are below the threshold screening frequency and are not expected to impact the conclusions of the SAMA analysis. Nevertheless, two plant improvements were identified to address the risk contribution from tornadoes and lightning:

- protect the diesel generator exhaust system from tornado-generated missiles
- reduce the potential vulnerability of the control building to a lightning-induced loss of offsite power that also affects the station batteries

Both were identified as Phase I SAMAs. The first, Phase I SAMA 232, "protect the diesel exhaust from tornado missiles," has already been implemented at CNS. The NRC inquired about this SAMA being described as resolved in 1998, while the IPEEE safety evaluation report (SER) stated that the issue had yet to be addressed. NPPD responded that the matter was resolved by a letter from NPPD to the NRC in 2001 clarifying that the modification was in fact completed in 1998. The second improvement was further evaluated and it was determined that the control building was not vulnerable to a lightning-induced loss of offsite power which might affect the station batteries.

The NRC staff questioned NPPD about lower cost alternatives to some of the SAMAs evaluated (NRC, 2009), including:

- providing additional space cooling to the RHRSW booster pump rooms, CS pump rooms, residual heat removal (RHR) pump rooms, SW pump rooms, and HPCI pump room via the use of portable equipment

- improving alternate shutdown training and equipment
- enhancing DC power availability (provide cables from diesel generators or another source to directly power battery chargers)
- developing guidance/procedures for local, manual control of reactor core isolation cooling following loss of DC power
- enhancing manual venting of containment using either a local hand wheel or gas bottle supplies as a possible alternative for containment pressure control

In response to the RAIs, NPPD addressed the suggested lower cost alternatives (NPPD, 2009a). This is discussed further in Section F.6.2.

The NRC staff notes that the set of SAMAs submitted is not all-inclusive, since additional, possibly even less expensive, design alternatives can always be postulated. However, the NRC staff concludes that the benefits of any additional modifications are unlikely to exceed the benefits of the modifications evaluated and that the alternative improvements would not likely cost less than the least expensive alternatives evaluated when the subsidiary costs associated with maintenance, procedures, and training are considered.

The NRC staff concludes that NPPD used a systematic and comprehensive process for identifying potential plant improvements for CNS, and that the set of SAMAs evaluated in the ER, together with those evaluated in response to NRC staff inquiries, is reasonably comprehensive and, therefore, acceptable. This search included reviewing insights from the plant-specific risk studies and reviewing plant improvements considered in previous SAMA analyses. While explicit treatment of external events in the SAMA identification process was limited, it is recognized that the prior implementation of plant modifications for fire risks and the absence of external event vulnerabilities reasonably justifies primarily examining the internal events risk results for this purpose.

F.4. Risk Reduction Potential of Plant Improvements

NPPD evaluated the risk-reduction potential of the 80 remaining SAMAs that were applicable to CNS. The majority of the SAMA evaluations were performed in a bounding fashion—the SAMA was assumed to completely eliminate the risk associated with the proposed enhancement. On balance, such calculations overestimate the benefit and are conservative.

NPPD used model requantification to determine the potential benefits. The CDF, population dose, and offsite economic cost reductions were estimated using the CNS 2007TM model, Revision 1. The changes made to the model to quantify the impact of SAMAs are detailed in Section E.2.3 of Attachment E to the ER (NPPD, 2008). Table F-5 lists the assumptions considered to estimate the risk reduction for each of the evaluated SAMAs, the estimated risk reduction in terms of percent reduction in CDF and population dose, and the estimated total benefit (present value) of the averted risk. The estimated benefits reported in Table F-5 reflect the combined benefit in both internal and external events. The determination of the benefits for the various SAMAs is further discussed in Section F.6.

The NRC staff questioned the assumptions used in evaluating the benefits or risk reduction estimates of certain SAMAs provided in the ER (NRC, 2009). For example, for SAMA 6, “change the time available to recover offsite power to 24 hours,” the NRC staff requested

clarification on the modeling assumption provided in ER Table 2-2 for this SAMA, which is inconsistent with the modeling assumption for analysis Case 6, "set failure probability to transfer the RPS panels to their alternate power source to zero" (NRC, 2009). In response to the RAI, NPPD clarified that the modeling assumption for SAMA 6, as provided in Table 2-2 of the ER, was incorrect and should have been the same as described for Case 6. The correct modeling assumption was used in the cost benefit analysis (NPPD, 2009a).

For SAMA 14, "portable generator for DC power to supply individual panels," the NRC staff asked NPPD to clarify the rationale for using the modeling assumption for Case 14, which was to set the CDF contribution due to unavailability of the HPCI system to zero in the Level 1 PSA model (NRC, 2009). In response to the RAI, NPPD explained that the benefit of providing an alternate DC power source to HPCI to support emergency core cooling was judged to be larger than the benefit of providing an alternate DC power source to other panels based on: (1) the importance of HPCI in intermediate LOCA sequences, and (2) the fact that the turbine-driven HPCI pump can continue to run in SBO sequences as long as DC control power is available (NPPD, 2009a). The NRC staff further asked NPPD to explain the large CDF reduction for this SAMA (32 percent) when the CDF contribution from HPCI unavailability due to test and maintenance is only 3 percent. In response to the RAI, NPPD responded that the evaluation of this SAMA conservatively assumes HPCI never fails, which eliminates the CDF contribution from all events contributing to HPCI unavailability, not just the test and maintenance event. Other contributing events include loss of DC power, failure of the turbine-driven HPCI pump to start or continue to run, failure of HPCI hydraulic valve HO10, and failure to bypass the HPCI high temperature trip. The NRC staff considers the assumptions, as clarified, to be reasonable and acceptable for purposes of the SAMA evaluation.

The NRC staff questioned how the modeling assumption of eliminating failure of the diesel-driven fire pump in the Level 1 PSA model for SAMA 69, "upgrade the seismic capacity of the diesel fire pump fuel tank and water supply tank," addresses the intent of this SAMA, which is to mitigate seismic risk (NRC, 2009). In response to the RAI, NPPD explained that while the diesel fire pump may be needed to fight a fire following a seismic or fire event, its contribution to preventing core damage is from its dual function of providing an alternate source of water for core cooling. NPPD further argued that the estimated risk reduction benefit for this SAMA is conservative since the analysis credited the benefit from internal events risk reduction, in addition to the benefit from external events risk reduction, through use of the external events multiplier (NPPD, 2009a). The NRC staff agrees that the resulting benefit estimate is conservative since there would be no reduction in internal events risk from implementation of the SAMA.

The NRC staff requested clarification on how SAMA 70, "install a curb to prevent debris from spreading across the floor and contacting the shell," reduces CDF as indicated in the ER (NRC, 2009). In response to the RAI, NPPD explained that SAMA 70 does not impact Level 1 CDF and that the CDF reduction value reported in the ER for this SAMA is actually based on the release frequency reduction for this SAMA (NPPD, 2009a). In a followup response to the NRC staff RAI, NPPD further clarified that the analysis of this SAMA resulted in about a 12 percent reduction in the frequency for the large early release category, and that this was treated as a 12 percent reduction in CDF in assessing the benefits for this SAMA (NPPD, 2009b). NPPD indicated that a more accurate assessment of SAMA 70 would require modifying the CET and that the approach taken results in a conservative estimate of the benefits for this SAMA. Although this approach is not consistent with regulatory analysis methodology, the NRC staff agrees that the resulting benefit estimate would be conservative since a reduction in CDF would result in averted onsite costs that would not be included otherwise for the SAMA. NPPD also

noted that this analysis methodology was unique to SAMA 70 and does not impact the evaluation of other SAMAs.

For SAMA 75, "Generation Risk Assessment (GRA) implementation into plant activities," the NRC staff asked for additional clarification of the SAMA and justification for the assumed factor of two reduction in the initiating event frequencies impacted by this SAMA (NRC, 2009). In response to the RAI, NPPD explained that GRA is a new program to identify plant components most likely to result in a plant trip, insights from which are used to identify and reevaluate maintenance and operational practices to reduce the likelihood of future plant trips. NPPD further explained that the GRA program was only recently piloted by CNS for EPRI and that the factor of 2 is based on recent plant operating history and opinion based on NPPD's experience in the GRA process. The NRC staff considers the assumptions, as clarified, to be reasonable and acceptable for purposes of the SAMA evaluation.

For two of the SAMAs that specifically address fire events (i.e., SAMA 63, "add automatic fire suppression systems to the dominant fire zones," and SAMA 65, "update the alternate shutdown system (ASDS) panel to include additional system controls for opposite division," the reduction in fire CDF and population dose was not directly calculated (in Table F-5 these are noted as "Not Estimated"). For these SAMAs, a bounding estimate of the impact was made by assuming the SAMA would eliminate the contribution to fire CDF from fires in the dominant fire zones in SAMA 63 and the control room in SAMA 65. The dominant fire zones in SAMA 63 are those having a fire CDF greater than 1.0×10^{-6} per year. Based on information from the IPEEE, the dominant fire zones are switchgear rooms 1F and 1G, the main control room, and the SW pump room. Based on logic in Section E.2.3 of the ER, only switchgear rooms 1F and 1G would benefit from the addition of automatic fire suppression systems. The benefit or averted cost risk from eliminating the risk in these fire zones is then calculated by multiplying the ratio of the fire zone CDF to the internal events CDF by the total present dollar-value equivalent associated with completely eliminating severe accidents from internal events at CNS. These SAMAs were assumed to have no additional benefits in internal events.

The NRC staff has reviewed NPPD's bases for calculating the risk reduction for the various plant improvements and concludes that the rationale and assumptions for estimating risk reduction are reasonable and generally conservative (i.e., the estimated risk reduction is higher than what would actually be realized). Accordingly, the NRC staff based its estimates of averted risk for the various SAMAs on NPPD's risk reduction estimates.

F.5. Cost Impacts of Candidate Plant Improvements

NPPD estimated the costs of implementing the 80 candidate SAMAs through the application of engineering judgment and use of other licensees' estimates for similar improvements. The cost estimates conservatively did not include the cost of replacement power during extended outages required to implement the modifications, nor did they include maintenance and surveillance costs of the installed equipment (NPPD, 2008), (NPPD, 2009a). The cost estimates provided in the ER did not account for inflation, which is considered another conservatism.

The NRC staff reviewed the bases for the applicant's cost estimates (presented in Section E.2 of Attachment E to the ER). For certain improvements, the NRC staff also compared the cost estimates to estimates developed elsewhere for similar improvements, including estimates developed as part of other licensees' analyses of SAMAs for operating reactors and advanced light-water reactors. The NRC staff noted that several of the cost estimates provided by the applicant were drawn from previous SAMA analyses for a dual-unit site. For those cost

Appendix F

estimates that were taken from a dual-unit SAMA analysis, NPPD reduced the estimated costs by one-half. In response to an RAI requesting a more detailed description of the changes associated with SAMAs 20, 44, 45, 63, 70, 72, 73, 76, 77, and 80, NPPD provided additional information detailing the analysis and plant modifications included in the cost estimate of each improvement (NPPD, 2009a). The staff reviewed the costs and found them to be reasonable, and generally consistent with estimates provided in support of other plants' analyses.

The NRC staff requested additional clarification on the estimated cost of \$1,200,000 for implementation of SAMA 41, "provide ability to align diesel power to more air compressors," which is high for what is described as a procedural modification (NRC, 2009). In response to the RAI, NPPD further described this modification as involving electrical, mechanical, and structural hardware modifications, in addition to the procedural changes (NPPD, 2009a). Based on this additional information, the NRC staff considers this estimated cost to be reasonable and acceptable for purposes of the SAMA evaluation.

The NRC staff concludes that the cost estimates provided by NPPD are sufficient and appropriate for use in the SAMA evaluation.

Table F-5. Severe Accident Mitigation Alternatives Cost/Benefit Screening Analysis for Cooper Nuclear Station^(a)

SAMA	Modeling Assumptions	% Risk Reduction		Total Benefit (\$)		Cost (\$)
		CDF	Population Dose	Baseline (Internal + External)	Baseline With Uncertainty	
Increase Availability of DC Power 1 – Provide additional DC battery capacity 2 – Replace lead-acid batteries with fuel cells 13 – Portable generator for DC power to supply the battery chargers 21 – Modify plant procedures to allow use of a portable power supply for battery chargers	Increase time available to recover offsite power (before HPCI and RCIC are lost) to 24 hours during SBO scenarios	3	3	32K	97K	500K 1.0M 200K Included in SAMA 13(b)
Improve DC Battery Charging Reliability 3 – Add battery charger to existing DC system 15 – Proceduralize battery charger high-voltage shutdown circuit inhibitor	Eliminate all common cause failures due to loss of DC battery chargers	<1	0	2.3K	7.0K	90K 50K
Improve DC Power Availability and Reliability 4 – Provide DC bus cross-ties for the 250V buses 19 – Modify plant procedures to use existing 125V DC bus cross-ties	Eliminate failure of the 250V DC buses Eliminate failure of the operator to use the 125V DC bus cross-tie	0 <1	0 0	0 2.0K	0 6.0K	300K 25K
Improve Availability of the 120V Vital AC Bus 5 – Provide additional DC power to the 120/240V vital AC system 6 – Add an automatic feature to transfer the 120V vital AC bus from normal to standby power	Eliminate failure of providing DC power to the no break power panel (NBPP) Eliminate failure to transfer the RPS panels to their alternate power source	~0 0	0 0	470 0	1.4K 0	>100K 500K

Appendix F

Increase Availability of Onsite AC Power 7 – Provide an additional diesel generator 10 – Install a gas turbine generator	Eliminate failure of the EDGs	13	14	140K	430K	20M 2.0M
Increase Reliability of EDGs 11 – Add a new backup source for diesel cooling 16 – Provide a portable EDG fuel oil transfer pump	Eliminate failure of providing SW cooling to the EDGs Eliminate failure of the EDG fuel oil transfer pumps	5 <1	3 <1	45K 6.2K	130K 19K	2.0M 100K
Improve Availability of AC Power 8 – Improve 4.16-kV bus cross-tie ability 17 – Provide alternate feeds to essential loads directly from an alternate emergency bus	Eliminate failure of the 4.16-kV buses	3	5	35K	110K	660K 220K
Reduce Probability of Loss of Offsite Power During Severe Weather 9 – Install an additional, buried offsite power source 12 – Bury offsite power lines	Eliminate the weather-centered loss of offsite power initiating event	4	4	43K	130K	2.5M 1.1B
Reduce Plant-Centered Loss of Offsite Power 18 – Protect transformers from failure	Eliminate the plant-centered loss of offsite power initiating event	~0	0	610	1.8K	780K
Improve Reliability of the Direct Torus Vent Valves 20 – Provide redundant power to direct torus hard pipe vent valves	Eliminate failure to power the hard pipe torus vent valves	4	13	77K	230K	710K

Increase Availability of High Pressure Injection 14 – Portable generator for DC power to supply the individual panels (using available skid-mounted portable AC generator) 22 – Install an independent active or passive high pressure injection system 23 – Provide an additional high pressure injection pump with independent diesel	Eliminate the CDF contribution from unavailability of the HPCI system	32	22	300K	910K	710K 1.0M 1.0M
Extend RCIC Operation 24 – Raise HPCI/RCIC backpressure trip set points 25 – Revise procedure to allow bypass of RCIC turbine exhaust pressure trip	Eliminate failures due to the RCIC backpressure trip	4	<1	29K	86K	>200K 25K
Improve Reliability of the Automatic Depressurization System (ADS) 26 – Modify ADS components by adding larger accumulators	Eliminate failure of the ADS accumulators	0	0	0	0	>100K
Improve Reliability of the SRVs 27 – Add signals to open SRVs automatically in a main steam isolation valve (MSIV) closure transient	Eliminate failure to open the SRVs when required by reactor pressure vessel overpressure conditions	19	<1	140K	410K	1.5M
Increase Availability of Low Pressure Injection 28 – Add a diverse low pressure injection system	Eliminate failure of the low pressure injection system	55	63	600K	1.8M	8.8M
Emergency Core Cooling System (ECCS) Low Pressure Interlock 29 – Install a bypass switch to allow operators to bypass the low reactor pressure interlock circuitry	Eliminate failure of the low pressure interlock circuitry	24	6	190K	570K	1.0M

Appendix F

<p>Improve Reliability of HPCI and RCIC</p> <p>67 – Upgrade the HPCI and RCIC control systems</p>	<p>Eliminate failure of the HPCI and RCIC turbine driven pumps</p>	6	0	42K	130K	430K
<p>Improve Reliability/Redundancy of Steam Tunnel Heating, Ventilation, and Air Conditioning (HVAC)</p> <p>76 – Improve steam tunnel HVAC reliability/redundancy</p>	<p>Eliminate failure of the steam tunnel HVAC condenser and eliminate the group 1 isolation (closure of the MSIVs) initiating event</p>	3	1	27K	80K	>100K
<p>Improve Reliability of ECCS Equipment</p> <p>77 – Improve reliability of auto-start features for the ECCS equipment</p>	<p>Eliminate failure of the auto-start features for the ECCS equipment</p>	1	0	9.3K	28K	>100K
<p>Improve Reliability of Alternate Injection</p> <p>78 – Improve training on providing alternate injection via FPS</p> <p>32 – Include the RHRSW and fire water cross-tie valves in the maintenance program</p> <p>33 – Create ability for emergency connection of existing or new water sources to feedwater and condensate systems</p>	<p>Reduce failure of operator actions to provide alternate injection via the fire water system by a factor of 2</p> <p>Eliminate the CDF contribution due to the SW cross-tie valves that are not contained in the maintenance program</p> <p>Eliminate the CDF contribution due to loss of feedwater and condensate systems as alternate injection paths</p>	5	4	53K	160K	25K
<p>Increase Availability of the RHR Heat Exchangers</p> <p>30 – Revise procedures to allow manual alignment of the fire water system to RHR heat exchangers</p>	<p>Eliminate failure of SW to provide cooling to the RHR heat exchangers</p>	~0	0	360	1.1K	50K
<p>Improve Reliability of the Emergency SW System</p> <p>31 – Add an additional SW pump</p>	<p>Eliminate all common cause failures due to loss of SW system pumps</p>	38	46	430K	1.3M	25K
		21	16	200K	600K	25K
		<1	0	3.2K	9.5K	5.9M

Increase Availability of the TEC Heat Exchangers 68 – Proceduralize the ability to cross-connect the circulating water pumps and the SW going to the TEC heat exchangers	Eliminate failure of the SW to provide cooling to the TEC heat exchangers	15	20	180K	530K	50K
Improve Reliability of the Main Feedwater System 34 – Add a motor-driven feedwater pump	Eliminate failure of feedwater turbine-driven pumps	~0	0	90	270	1.7M
Increase Availability of the Condensate Storage Tank (CST) 72 – Provide a means of automatically preventing drain-down of CST to hotwell during an SBO	Eliminate the CDF contribution from operator failure to prevent CST inventory drain-down to the hotwell	2	2	21K	63K	230K
Increase Availability of Room Cooling 35 – Provide a redundant train or means of ventilation	Eliminate failure of room cooling to the RHRSW booster pump rooms	4	3	38K	120K	2.2M
Increase Availability of the EDG System 36 – Add a diesel building high temperature alarm or redundant louver and thermostat 38 – Install diverse set of EDG HVAC fan actuation logic 39 – Install additional fan and louver pair for EDG HVAC 40 – Revise operator procedures to provide additional space cooling to the EDG room via the use of portable equipment	Eliminate failure of the EDG HVAC	3	3	33K	99K	1.3M 100K 6.0M 25K
Improve Diagnosis of a Loss of Switchgear HVAC 37 – Add a switchgear room high temperature alarm	Eliminate failure of room cooling to the critical switchgear rooms	0	0	0	0	400K

Appendix F

<p>Increase Reliability of Instrument Air</p> <p>41 – Provide ability to align diesel power to more air compressors^(c)</p> <p>42 – Replace service and instrument air compressors with more reliable compressors which have self-contained air cooling by shaft driven fans</p> <p>45 – Provide an alternate means of supplying the instrument air header</p>	<p>Eliminate failure of the instrument air compressors</p>	<p>17</p>	<p>14</p>	<p>170K</p>	<p>500K</p>	<p>1.2M</p> <p>1.4M</p> <p>100K</p>
<p>Extend SRV Operation Time</p> <p>43 – Install nitrogen bottles as backup gas supply for SRVs</p>	<p>Eliminate failure of loss of nitrogen and air to the SRVs</p>	<p>0</p>	<p>0</p>	<p>0</p>	<p>0</p>	<p>>100K</p>
<p>Improve Availability of SRVs and MSIVs</p> <p>44 – Improve SRV and MSIV pneumatic components</p>	<p>Eliminate failure of nitrogen, air, and accumulators for the SRVs and MSIVs</p>	<p>17</p>	<p>21</p>	<p>190K</p>	<p>570K</p>	<p>1.5M</p>
<p>Improve Reliability of the Decay Heat Removal System – Torus Cooling</p> <p>46 – Install an independent method of suppression pool cooling</p> <p>71 – Upgrade existing equipment to transfer water from the torus to the radwaste system</p> <p>73 – Provide ability to maintain suppression pool temperature lower</p>	<p>Eliminate loss of torus cooling mode of RHR and RHRSW system events</p>	<p>35</p>	<p>37</p>	<p>370K</p>	<p>1.1M</p>	<p>5.8M</p> <p>11M</p> <p>1.3M</p>
<p>Improve Reliability of the Decay Heat Removal System – Drywell Spray</p> <p>47 – Install a passive drywell spray system to provide a redundant drywell spray method</p>	<p>Eliminate loss of drywell sprays mode of RHR and RHRSW system events</p>	<p>17</p>	<p>55</p>	<p>320K</p>	<p>960K</p>	<p>5.8M</p>

<p>Improve Reliability of Fission Product Scrubbing</p> <p>48 – Install a filtered containment vent</p> <p>49 – Enhance fire protection system and/or standby gas treatment system hardware and procedures</p>	<p>Reduce accident progression source terms by a factor of 2 (excluding noble gases)</p>	0	25	89K	270K	<p>1.5M</p> <p>2.5M</p>
<p>Improve Reliability of Containment Venting</p> <p>50 – Modify containment venting procedure to control containment venting within a narrow band</p>	<p>Eliminate failure of the operator to control the venting evolution</p>	~0	0	35K	110K	250K
<p>Improve Reliability of Vacuum Breakers</p> <p>51 – Install improved vacuum breakers (redundant valves in each line)</p>	<p>Eliminate failure of the vacuum breakers</p>	1	4	23K	69K	500K
<p>Improve Reliability of Containment Overpressure Relief</p> <p>52 – Provide passive overpressure relief by changing the containment vent valves to “fail open” and improving the strength of the rupture disk</p> <p>53 – Install an alternate path to the torus hard pipe vent via the wet well using a rupture disk</p>	<p>Eliminate failure of the hard pipe vent</p>	7	22	130K	380K	<p>1.0M</p> <p>5.7M</p>
<p>Improve Reliability of Debris Barriers</p> <p>70 – Install a curb to prevent debris from spreading across the floor and contacting the shell</p>	<p>Eliminate the CDF contribution due to failure of the drywell barriers to prevent debris from contacting the shell</p>	12	40	230K	680K	840K

Appendix F

<p>Reduce Probability of an ISLOCA</p> <p>54 – Increase frequency of valve leak testing</p> <p>56 – Revise emergency operating procedures (EOPs) to improve ISLOCA identification</p> <p>57 – Improve operator training on ISLOCA coping</p>	<p>Eliminate all ISLOCA initiating events</p>	<p><1</p>	<p>1</p>	<p>8.6K</p>	<p>26K</p>	<p>100K</p> <p>50K</p> <p>110K</p>
<p>Improve Reliability of MSIVs</p> <p>55 – Improve MSIV design to decrease the likelihood of containment bypass scenarios</p>	<p>Eliminate failure of the MSIVs to close or remain closed</p>	<p><1</p>	<p>0</p>	<p>2.7K</p>	<p>8.2K</p>	<p>1.0M</p>
<p>Improve Reliability of the Standby Liquid Control (SLC) System</p> <p>58 – Increase boron concentration in the SLC system</p>	<p>Eliminate the CDF contribution due to failure to initiate SLC and failures due to the boron concentration being too low</p>	<p><1</p>	<p>2</p>	<p>12K</p>	<p>37K</p>	<p>>50K</p>
<p>Improve Availability of Boron Injection</p> <p>59 – Add an independent boron injection system</p> <p>60 – Provide ability to use the CRD for alternate boron injection</p>	<p>Eliminate failure of the SLC system</p>	<p>1</p>	<p>4</p>	<p>22K</p>	<p>67K</p>	<p>>100K</p> <p>150K</p>
<p>Improve SRV Reseat Reliability</p> <p>61 – Increase reliability of SRV to reseat after SLC injection</p>	<p>Eliminate failure of the SRVs to reseat</p>	<p>1</p>	<p><1</p>	<p>11K</p>	<p>32K</p>	<p>2.2M</p>
<p>Reduce Probability of Internal Flooding</p> <p>62 – Improve internal flooding procedures</p> <p>74 – Provide flow diversion to help mitigate the fire water pipe break in the control building ground floor corridor</p>	<p>Eliminate failure of the operator to implement flood mitigation measures</p> <p>Eliminate failure to isolate the large and medium fire water pipe breaks in the control building ground floor corridor</p>	<p>2</p> <p><1</p>	<p>2</p> <p>0</p>	<p>17K</p> <p>2.0K</p>	<p>52K</p> <p>6.1K</p>	<p>460K</p> <p>>100K</p>

Increase Reliability of the Fire Water System 64 – Proceduralize the use of a fire pumper truck to pressurize the fire water system 69 – Upgrade the seismic capacity of the diesel fire pump fuel tank and water supply tank	Eliminate failure of the diesel-driven fire pump	3	2	27K	82K	50K >100K
Improve Fire Suppression Capability 63 – Add automatic fire suppression systems to the dominant fire zones	Eliminate the fire CDF contribution from critical switchgear rooms 1F and 1G	Not Estimated		120K	350K	375K
Reduce Risk from Fires that Require Control Room Evacuation 65 – Upgrade the ASDS panel to include additional system controls for Division 1 equipment	Eliminate the fire CDF contribution from the main control room	Not Estimated		110K	340K	790K
Reduce Probability of a Large Break LOCA 66 – Provide digital large break LOCA protection	Eliminate all large break LOCA initiating events	1	3	19K	58K	100K
Reduce Frequency of Plant Trips and Shutdowns 75 – Include GRA (trip and shutdown modeling) in plant activities	Reduce the probability of all initiating events except pipe breaks, floods, and loss of offsite power (LOOP) by a factor of 2	39	35	390K	1.2M	500K
Improve Availability of the RHRSW System 79 – Modify procedures to allow use of the RHRSW system without a service water booster pump (SWBP)	Eliminate failure to use the RHRSW system without a SWBP	11	10	110K	330K	25K
Improve Plant Identification of Reference Leg Leakdowns 80 – Install additional instrumentation to assist in identifying a reference leg leakdown	Eliminate failure of cognitive recognition of a leakdown of the reference legs	1	0	5.3K	16K	>100K

Appendix F

- (a) SAMAs in bold are potentially cost-beneficial.
- (b) In response to an NRC staff RAI, NPPD clarified that SAMA 21 was originally included as a unique SAMA because it was believed that a suitable, existing portable power supply was available to supply the battery chargers (NPPD, 2009a). However, after further investigation, it was determined that the available skid-mounted portable power supply is not sufficient to supply the battery chargers and that a portable power supply would need to be purchased (which is the same as SAMA 13).
- (c) SAMA title changed in response to NRC staff RAI 6e (NPPD, 2009a).

F.6. Cost-Benefit Comparison

NPPD's cost-benefit analysis and the NRC staff's review are described in the following sections.

F.6.1. Nebraska Public Power District's Evaluation

The methodology used by NPPD was based primarily on the NRC's guidance for performing cost-benefit analysis (i.e., NUREG/BR-0184, "Regulatory Analysis Technical Evaluation Handbook") (NRC, 1997a). The guidance involves determining the net value for each SAMA according to the following formula:

Net Value = (APE + AOC + AOE + AOSC) - COE where,

APE = present value of averted public exposure (\$)
 AOC = present value of averted offsite property damage costs (\$)
 AOE = present value of averted occupational exposure costs (\$)
 AOSC = present value of averted onsite costs (\$)
 COE = cost of enhancement (\$)

If the net value of a SAMA is negative, the cost of implementing the SAMA is larger than the benefit associated with the SAMA and it is not considered cost-beneficial. NPPD's derivation of each of the associated costs is summarized below.

NUREG/BR-0058 has recently been revised to reflect the agency's policy on discount rates. Revision 4 of NUREG/BR-0058 states that two sets of estimates should be developed, one at 3 percent and one at 7 percent (NRC, 2004). NPPD provided a base set of results using the 7 percent discount rate and a sensitivity study using the 3 percent discount rate (NPPD, 2008).

Averted Public Exposure (APE) Costs

The APE costs were calculated using the following formula:

APE = Annual reduction in public exposure (Δ person-rem per year)
 x monetary equivalent of unit dose (\$2,000 per person-rem)
 x present value conversion factor (10.76 based on a 20-year period with a 7-percent discount rate)

As stated in NUREG/BR-0184 (NRC, 1997a), the monetary value of the public health risk after discounting does not represent the expected reduction in public health risk due to a single accident. Rather, it is the present value of a stream of potential losses extending over the remaining lifetime (in this case, the renewal period) of the facility. Thus, it reflects the expected annual loss due to a single accident, the possibility that such an accident could occur at any time over the renewal period, and the effect of discounting these potential future losses to present value. NPPD calculated an APE of approximately \$46,000 for the 20-year license renewal period (NPPD, 2008).

Appendix F

Averted Offsite Property Damage Costs (AOC)

The AOCs were calculated using the following formula:

$$\begin{aligned} \text{AOC} = & \text{Annual CDF reduction} \\ & \times \text{offsite economic costs associated with a severe accident (on a} \\ & \text{per-event basis)} \\ & \times \text{present value conversion factor} \end{aligned}$$

This term represents the sum of the frequency-weighted offsite economic costs for each release category, as obtained for the Level 3 risk analysis. For the purposes of initial screening, which assumes elimination of all severe accidents caused by internal events, NPPD calculated an annual offsite economic cost of about \$7,000 based on the Level 3 risk analysis. This results in a discounted value of approximately \$75,000 for the 20-year license renewal period (NPPD, 2008).

Averted Occupational Exposure (AOE) Costs

The AOE costs were calculated using the following formula:

$$\begin{aligned} \text{AOE} = & \text{Annual CDF reduction} \\ & \times \text{occupational exposure per core damage event} \\ & \times \text{monetary equivalent of unit dose} \\ & \times \text{present value conversion factor} \end{aligned}$$

NPPD derived the values for averted occupational exposure from information provided in Section 5.7.3 of the regulatory analysis handbook (NRC, 1997a). Best estimate values provided for immediate occupational dose (3,300 person-rem) and long-term occupational dose (20,000 person-rem over a 10-year cleanup period) were used. The present value of these doses was calculated using the equations provided in the handbook in conjunction with a monetary equivalent of unit dose of \$2,000 per person-rem, a real discount rate of 7 percent, and a time period of 20 years to represent the license renewal period. For the purposes of initial screening, which assumes elimination of all severe accidents caused by internal events, NPPD calculated an AOE of approximately \$4,400 for the 20-year license renewal period (NPPD, 2008).

Averted Onsite Costs

Averted onsite costs (AOSC) include averted cleanup and decontamination costs and averted power replacement costs. Repair and refurbishment costs are not for severe accidents. NPPD derived the values for AOSC based on information provided in Section 5.7.6 of NUREG/BR-0184, the regulatory analysis handbook (NRC, 1997a).

NPPD divided this cost element into two parts – the onsite cleanup and decontamination cost, also commonly referred to as averted cleanup and decontamination costs (ACC), and the replacement power cost.

ACC were calculated using the following formula:

$$\begin{aligned} \text{ACC} &= \text{Annual CDF reduction} \\ &\quad \times \text{present value of cleanup costs per core damage event} \\ &\quad \times \text{present value conversion factor} \end{aligned}$$

The total cost of cleanup and decontamination subsequent to a severe accident is estimated in NUREG/BR-0184 to be $\$1.5 \times 10^9$ (undiscounted). This value was converted to present costs over a 10-year cleanup period and integrated over the term of the proposed license extension. For the purposes of initial screening, which assumes elimination of all severe accidents caused by internal events, NPPD calculated an ACC of approximately \$134,000 for the 20-year license renewal period.

Long-term replacement power costs (RPC) were calculated using the following formula:

$$\begin{aligned} \text{RPC} &= \text{Annual CDF reduction} \\ &\quad \times \text{present value of replacement power for a single event} \\ &\quad \times \text{factor to account for remaining service years for which replacement} \\ &\quad \quad \text{power is required} \\ &\quad \times \text{reactor power scaling factor} \end{aligned}$$

NPPD based its calculations on the 910 megawatt-electric (MWe) reference plant in NUREG/BR-0184 (NRC, 1997b), and did not scale down to the 830 MWe rating for CNS. Therefore, NPPD did not apply a power scaling factor to determine the replacement power costs, which are conservative. For the purposes of initial screening, which assumes elimination of all severe accidents caused by internal events, NPPD calculated an RPC of approximately \$91,000 and an AOSC of approximately \$225,000 for the 20-year license renewal period (NPPD, 2008).

Using the above equations, NPPD estimated the total present dollar-value equivalent associated with completely eliminating severe accidents from internal events at CNS to be about \$351,000. Use of a multiplier of 3 to account for external events increases the value to \$1.05M and represents the dollar-value associated with completely eliminating all internal and external event severe accident risk at CNS.

NPPD's Results

If the implementation costs for a candidate SAMA exceeded the calculated benefit, the SAMA was considered not to be cost-beneficial. In the baseline analysis contained in the ER (using a 7 percent discount rate) NPPD identified eight potentially cost-beneficial SAMAs. The potentially cost-beneficial SAMAs are:

- SAMA 25 – Develop procedures to allow bypass of the RCIC turbine exhaust pressure trip, extending the time available for RCIC operation.
- SAMA 30 – Revise procedures to allow manual alignment of the fire water system to the RHR heat exchangers, providing improved ability to cool the RHR heat exchangers in a loss of SW.

Appendix F

- SAMA 33 – Provide for the ability to establish an emergency connection of existing or new water sources to feedwater and condensate systems, increasing availability of feedwater.
- SAMA 40 – Revise procedures to provide additional space cooling to the EDG room via the use of portable equipment, increasing availability of the EDG.
- SAMA 45 – Provide an alternate means of supplying the instrument air header, increasing availability of instrument air.
- SAMA 68 – Revise procedures to allow the ability to cross-connect the circulating water pumps and the SW going to the TEC heat exchangers, allowing continued use of the power conversion system after SW is lost.
- SAMA 78 – Improve training on alternate injection via the fire water system, increasing the availability of alternate injection.
- SAMA 79 – Revise procedures to allow use of the RHRSW system without a SW booster pump, increasing availability of the RHRSW system.

NPPD performed additional analyses to evaluate the impact of an alternative discount rate (3 percent) and remaining plant life (26 years instead of 20 years) on the results of the SAMA assessment. No additional SAMA candidates were determined to be potentially cost-beneficial (NPPD, 2008).

If the benefits are increased by an additional factor of 3 to account for uncertainties, three additional SAMA candidates were determined to be potentially cost-beneficial:

- SAMA 14 – Provide a portable generator to supply DC power to individual panels during an SBO, increasing the time available for AC power recovery.
- SAMA 64 – Revise procedures to allow use of a fire pumper truck to pressurize the fire water system, increasing availability of the fire water system.
- SAMA 75 – Implement GRA (trip and shutdown risk modeling) into plant activities, decreasing the probability of trips/shutdown.

The potentially cost-beneficial SAMAs, and NPPD's plans for further evaluation of these SAMAs are discussed in more detail in Section F.6.2.

F.6.2. Review of Nebraska Public Power District's Cost-Benefit Evaluation

The cost-benefit analysis performed by NPPD was based primarily on NUREG/BR-0184 (NRC, 1997a) and discount rate guidelines in NUREG/BR-0058 (NRC, 2004) and was executed consistent with this guidance.

SAMAs identified primarily on the basis of the internal events analysis could provide benefits in certain external events, in addition to internal events. To account for the additional benefits in external events, NPPD multiplied the internal event benefits by a factor of 3 for each SAMA, except for two SAMAs that specifically address fire risk (SAMAs 63 and 65). Doubling the

internal event estimate for SAMAs 63 and 65 would not be appropriate because these SAMAs are specific to fire risks and would not have a corresponding benefit on the risk from internal events. The NRC staff notes that the CNS external events CDF is approximately 200 percent of the internal events CDF from the CNS 2007TM PSA model (based on the fire CDF of 1.9×10^{-5} per year, a seismic CDF of 6×10^{-6} per year as estimated by the NRC staff, a negligible HFO contribution, and an internal events CDF of 1.2×10^{-5} per year). Accordingly, the total CDF from internal and external events would be approximately 2.1 times the internal events CDF from the CNS 2007 TM PSA model. Because the CDF from internal fires and other external events, as reported by NPPD, is about twice the CDF for internal events, the NRC staff agrees that the factor of 3 multiplier for external events is reasonable.

NPPD provided the results of additional sensitivity analyses in the ER, including use of a 3 percent discount rate and use of a longer plant life. These analyses did not identify any additional potentially cost-beneficial SAMAs.

NPPD considered the impact that possible increases in benefits from analysis uncertainties would have on the results of the SAMA assessment. In the ER, NPPD states that an uncertainty analysis of the internal events CDF resulted in a 95th percentile value that is a factor of 1.86 times the mean CDF. The ER further states that an uncertainty factor of 3 was conservatively selected for the uncertainty analysis. The NRC staff asked NPPD to provide the results of the internal events CDF uncertainty analysis and to provide further justification for the use of a factor of 3 for the SAMA uncertainty analysis. In response to the RAI, NPPD provided the results of the internal events CDF, which indicates that the 95th percentile is a factor of $1.86 \times$ the mean CDF as described in the ER. NPPD further clarified that the uncertainty factor of 3 was developed from an earlier version of the uncertainty analysis and that the SAMA analysis was not subsequently updated to avoid rework (NPPD, 2009a). Since the Phase I SAMAs were not screened based on quantitative criteria, a reexamination of the Phase I SAMAs based on the upper bound benefits was not necessary. NPPD considered the impact on the Phase II screening if the estimated benefits were increased by a factor of 3 (in addition to the multiplier of 3 for external events). Three additional SAMAs became cost-beneficial in NPPD's analysis (SAMAs 14, 64, and 75 as described above).

The NRC staff noted that SAMA 14, "portable generator for DC power to supply the individual panels," and SAMA 13, "portable generator for DC power to supply the battery chargers," both involve use of a portable generator and requested that NPPD reassess whether or not SAMA 13 would be cost-beneficial if it were to use the same portable generator as for SAMA 14, which was determined to be cost-beneficial (NRC, 2009). In response, NPPD stated that since the SAMA submittal, SAMA 13 has been implemented at CNS (NPPD, 2009a). NPPD also stated that the available skid mounted portable power supply considered in the cost estimate for SAMA 14 was not sufficient to supply the battery chargers as proposed in SAMA 13. No draft supplemental environmental impact statement (DSEIS) change is needed.

The NRC staff also noted that all of the SAMAs considered for basic event PCI-CNT-FF-PREEX, "pre-existing containment failure," involve major hardware modifications. The NRC staff asked NPPD to provide an assessment of lower cost alternatives, such as periodic monitoring of containment integrity during normal operation or procedures to isolate the containment following an event (NRC, 2009). In response to the RAI, NPPD stated that these two specific alternatives have already been implemented at CNS (NPPD, 2009a). NPPD further clarified that basic event PCI-CNT-FF-PREEX represents a preexisting containment failure leading to loss of net positive suction head (NPSH) to the ECCS pumps and that since the CNS

Appendix F

containment is inerted during normal operation, a leak large enough to lead to loss of NPSH would require significant nitrogen makeup and would be noticed by the operators.

The NRC staff noted that for certain SAMAs considered in the ER, there may be alternatives that could achieve much of the risk reduction at a lower cost. The NRC staff asked the applicant to evaluate several additional lower cost alternatives to the SAMAs considered in the ER, including SAMAs that had been found to be potentially cost-beneficial at other BWR plants. These alternatives were: (1) providing additional space cooling to the RHRSW booster pump rooms, CS pump rooms, RHR pump rooms, SW pump rooms, and HPCI pump room via the use of portable equipment; (2) improving alternate shutdown training and equipment; (3) enhancing DC power availability by providing cables from diesel generators or another source to directly power battery chargers; (4) developing guidance/procedures for local, manual control of reactor core isolation cooling following loss of DC power; and (5) manually venting containment using either a local hand wheel or gas bottle supplies (NRC, 2009). NPPD provided a further evaluation of these alternatives and concluded that each had already been implemented at CNS (NPPD, 2009a).

In the ER and in response to an NRC staff RAI, NPPD indicated that detailed engineering project cost-benefit analyses have been initiated for the 11 potentially cost-beneficial SAMAs (NPPD, 2008), (NPPD, 2009a).

In light of the many potentially cost-beneficial SAMAs identified in the ER, the NRC staff asked NPPD to identify those SAMAs having higher priority for being considered for implementation based on risk reduction potential and implementation cost, and which SAMAs would no longer be cost-beneficial if these higher priority SAMAs were implemented (NRC, 2009). In response to the RAI (NPPD, 2009a), NPPD performed a qualitative assessment to prioritize the cost-beneficial SAMAs. NPPD determined that SAMAs 30, 33, 68, and 79 would have the highest priority based on their potential for significant reduction in risk and relatively low implementation cost. NPPD further identified SAMAs 14, 45, 75, and 78 as a second priority based on their potential for risk reduction and mitigation of plant risk contributors not addressed by SAMAs 30, 33, 68, and 79. The impact of the remaining potentially cost-beneficial SAMAs is expected to be reduced significantly if the higher priority SAMAs are implemented. The NRC considers this approach for prioritizing SAMAs to be reasonable.

The NRC staff concludes that, with the exception of the potentially cost-beneficial SAMAs discussed above, the costs of the other SAMAs evaluated would be higher than the associated benefits.

F.7. Conclusions

NPPD compiled a list of 244 SAMAs based on a review of the most significant basic events from the plant-specific PSA, insights from the plant-specific IPE and IPEEE, Phase II SAMAs from license renewal applications for other plants, and review of other NRC and industry documentation. A qualitative screening removed SAMA candidates that: (1) modified features not applicable to CNS, (2) had already been implemented at CNS, or (3) were similar and could be combined with another SAMA. Based on this screening, 164 SAMAs were eliminated leaving 80 candidate SAMAs for evaluation.

For the remaining SAMA candidates, a more detailed design and cost estimate were developed as shown in Table F-5. The cost-benefit analyses showed that eight of the SAMA candidates were potentially cost-beneficial in the baseline analysis (Phase II SAMAs 25, 30, 33, 40, 45, 68,

78, and 79). NPPD performed additional analyses to evaluate the impact of parameter choices and uncertainties on the results of the SAMA assessment. Three additional SAMAs were identified as potentially cost-beneficial in the ER (Phase II SAMAs 14, 64, and 75). NPPD has indicated that detailed engineering project cost-benefit analyses have been initiated for the 11 potentially cost-beneficial SAMAs.

The NRC staff reviewed the NPPD analysis and concludes that the methods used and the implementation of those methods were sound. The treatment of SAMA benefits and costs support the general conclusion that the SAMA evaluations performed by NPPD are reasonable and sufficient for the license renewal submittal. Although the treatment of SAMAs for external events was somewhat limited, the likelihood of there being cost-beneficial enhancements in this area was minimized by improvements that have been realized as a result of the IPEEE process, and inclusion of a multiplier to account for external events.

The NRC staff concurs with NPPD's identification of areas in which risk can be further reduced in a cost-beneficial manner through the implementation of the identified, potentially cost-beneficial SAMAs. Given the potential for cost-beneficial risk reduction, the NRC staff agrees that further evaluation of these SAMAs by NPPD is warranted. However, these SAMAs do not relate to adequately managing the effects of aging during the period of extended operation. Therefore, they need not be implemented as part of license renewal pursuant to Title 10 of the *Code of Federal Regulations*, Part 54.

F.8. References

- American Association of Mechanical Engineers (ASME). 2007. "Standard for Probabilistic Risk Assessment for Nuclear Power Plant Applications," RA-Sc-2007, August 2007.
- Eklund, D.L. et al. (Eklund et al.) 1999. "Using Water Demand to Determine Population Estimates and Projections for Kansas," June 8, 1999.
- Electric Power Research Institute (EPRI). 1991. "A Methodology for Assessment of Nuclear Power Plant Seismic Margin," EPRI NP-6041-SL, Revision 1, Palo Alto, CA, August 1991.
- Electric Power Research Institute (EPRI). 1993. "Fire-Induced Vulnerability Evaluation (FIVE)," EPRI TR-100370, Revision 1, Palo Alto, CA, September 1993.
- Electric Power Research Institute (EPRI). 1994. "EPRI Fire PRA Implementation Guide," prepared by Science Applications International Corporation for EPRI, Palo Alto, CA, January 1994.
- Global Insight. 2006. "How Important is Tourism in Kansas? The Tourism Satellite Account Perspective," Kansas Tourism in 2004, prepared by Global Insight, October 3, 2006.
- Iowa Department of Economic Development (IDED). 2006. "Iowa Tourism Results as of October 1, 2006," Iowa Department of Economic Development Tourism Office.
- Kaylen, M. 2006. "Economic Impact of Missouri's Tourism and Travel Industry: July 2004–June 2005 (FY05)," Executive Summary, MU-Tourism Economics Research Initiative, Columbia, Missouri, May 2006.
- Kennedy, R.P. 1999. "Overview of Methods for Seismic PRA and Margin Analysis Including Recent Innovations," Proceedings of the OECD-NEA Workshop of Seismic Risk, Tokyo, Japan, August 10–12 1999.

Appendix F

Missouri Census Data Center (Missouri). 2007. "Population Projections for Missouri and the U.S." Available URL: <http://mcdc2.missouri.edu/trends/projections/shtml> (accessed June 12, 2007).

Nebraska Department of Economic Development (NDED). 2006. "2006 Fiscal Year Annual Report, July 1, 2005–June 30, 2006," Lincoln, Nebraska.

Nebraska Public Power District (NPPD). 1993. Generic Letter 88-20, "Individual Plant Examination for Severe Accident Vulnerabilities – 10 CFR 50.54(f), IPE Report Submittal, Cooper Nuclear Station, Docket No. 50-298, DPR-46," March 1993, Agencywide Documents Access and Management System (ADAMS) Accession Nos. ML073600192 (Volume 1) and ML073600193 (Volume 2).

Nebraska Public Power District (NPPD). 1996. "Individual Plant Examination for External Events Report – 10 CFR 50.54(f), Cooper Nuclear Station, NRC Docket No. 50-298, License No. DPR-46," October 1996, ADAMS Accession No. ML073580487.

Nebraska Public Power District (NPPD). 2008. "License Renewal Application, Cooper Nuclear Station, Appendix E – Applicant's Environmental Report, Operating License Renewal Stage," Columbus, Nebraska. September 24, 2008, ADAMS Accession No ML083030246 (main report) and ML083030252 (attachments).

Nebraska Public Power District (NPPD). 2009a. Letter from Stewart B. Minahan, Nebraska Public Power District, to the U.S. Nuclear Regulatory Commission Document Control Desk, Subject: "Response to Request for Additional Information for License Renewal Application – Severe Accident Mitigation Alternatives, Cooper Nuclear Station, Docket No. 50-298, DPR-46," July 1, 2009, ADAMS Accession No. ML091880319.

Nebraska Public Power District (NPPD). 2009b. E-mail from David W. Bremer, Nebraska Public Power District, to Bennett Brady, U.S. Nuclear Regulatory Commission, Subject: "NRC Teleconference to discuss SAMA RAI Followup Questions and ER Questions," August 10, 2009.

Nebraska Public Power District (NPPD). 2009c. Letter from Nebraska Public Power District, Subject: "SAMA Meteorological Anomaly Related to the Cooper Nuclear Station License Renewal Application," December 7, 2009, ADAMS Accession No. 093490997.

Nuclear Energy Institute (NEI). 2007. "Process for Performing Follow-on PRA Peer Reviews Using the ASME PRA Standard," NEI 05-04, Revision 1 (Draft G), November 2007.

Seismic Qualification Users Group (SQUG). 1992. "Generic Implementation Procedure (GIP) for Seismic Verification of Nuclear Plant Equipment," Revision 2, Corrected, February 14, 1992.

University of Nebraska (UN). 2007. "Business in Nebraska Population Projection," University of Nebraska Bureau of Business Research. Available URL: <http://www.bbr.unl.edu/PopProjections/> (accessed June 20, 2007).

U.S. Department of Agriculture (USDA). 2002. "2002 Census of Agriculture," National Agriculture Statistics Service. Available URL: http://www.nass.usda.gov/Census_of_Agriculture/index.asp (accessed June 2007).

U. S. Geological Survey (USGS). 2008. "2008 NSHM Gridded Data, Peak Ground Acceleration." Available URL: <http://earthquake.usgs.gov/hazards/products/conterminous/2008/data/>

U.S. Nuclear Regulatory Commission (NRC). 1988. Generic Letter 88-20, "Individual Plant Examination for Severe Accident Vulnerabilities," November 23, 1988.

U.S. Nuclear Regulatory Commission (NRC). 1990. *Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants*, NUREG-1150, Washington, D.C., December 1990.

U.S. Nuclear Regulatory Commission (NRC). 1991. *Generic Letter No. 88-20, Supplement 4, Individual Plant Examination of External Events for Severe Accident Vulnerabilities*, NUREG-1407, Washington, D.C., June 28, 1991.

U.S. Nuclear Regulatory Commission (NRC). 1996. Letter from David L. Wigginton, U.S. Nuclear Regulatory Commission, to Guy R. Horn, Nebraska Public Power District, Subject: "Cooper Nuclear Station – Individual Plant Examination (IPE) for Internal Events (TAC No. M74400)," Washington, D.C., February 14, 1996.

U.S. Nuclear Regulatory Commission (NRC). 1997a. "Regulatory Analysis Technical Evaluation Handbook," NUREG/BR-0184, Washington, D.C., January 1997.

U.S. Nuclear Regulatory Commission (NRC). 1997b. *Individual Plant Examination Program: Perspectives on Reactor Safety and Plant Performance*, NUREG-1560, Washington, D.C., December 1997.

U.S. Nuclear Regulatory Commission (NRC). 1998. "Code Manual for MACCS2: Volume 1, User's Guide," NUREG/CR-6613, Washington, D.C., May 1998.

U.S. Nuclear Regulatory Commission (NRC). 1999. Letter from Lawrence Burkhardt, U.S. Nuclear Regulatory Commission, to G.R. Horn, Nebraska Public Power District, Subject: "Plant-Specific Safety Evaluation Report for USI A-46 Program Implementation at Cooper Nuclear Station (TAC No. M69439)," Washington, D.C., September 30, 1999.

U.S. Nuclear Regulatory Commission (NRC). 2001. "Cooper Nuclear Station – Review of Individual Plant Examination of External Events (TAC No. 83611)," Washington, D.C., April 27, 2001.

U.S. Nuclear Regulatory Commission (NRC). 2004. "Regulatory Analysis Guidelines of the U.S. Nuclear Regulatory Commission," NUREG/BR-0058, Revision 4, Washington, D.C., September 2004.

U.S. Nuclear Regulatory Commission (NRC). 2007. "An Approach for Determining the Technical Adequacy of Probabilistic Risk Assessment Results for Risk-Informed Activities," Regulatory Guide 1.200, Revision 1, Washington, D.C., January 2007.

U.S. Nuclear Regulatory Commission (NRC). 2009. Letter from Tam Tran, U.S. Nuclear Regulatory Commission, to Stewart B. Minahan, Nebraska Public Power District, Subject: "Request for Additional Information for the Review of the Cooper Nuclear Station License Renewal Application (TAC Nos. MD9763 and MD9737)," Washington, D.C., June 8, 2009, ADAMS Accession No. ML091530316.

Woods & Poole. 2006. "2006 State Profile: Iowa," Woods & Poole Economics, Inc.



NRC FORM 335 (9-2004) NRCMD 3.7	U.S. NUCLEAR REGULATORY COMMISSION	1. REPORT NUMBER (Assigned by NRC, Add Vol., Supp., Rev., and Addendum Numbers, if any.) NUREG-1437, Supplement 41							
BIBLIOGRAPHIC DATA SHEET (See instructions on the reverse)		3. DATE REPORT PUBLISHED <table border="1" style="width: 100%;"> <tr> <td style="width: 50%; text-align: center;">MONTH</td> <td style="width: 50%; text-align: center;">YEAR</td> </tr> <tr> <td style="text-align: center;">July</td> <td style="text-align: center;">2010</td> </tr> </table>	MONTH	YEAR	July	2010			
MONTH	YEAR								
July	2010								
2. TITLE AND SUBTITLE Generic Environmental Impact Statement for License Renewal of Nuclear Plants (GEIS) Supplement 41 Regarding Cooper Nuclear Station Final Report	4. FIN OR GRANT NUMBER 								
5. AUTHOR(S) See Chapter 10 of report	6. TYPE OF REPORT <p style="text-align: center;">Technical</p>								
8. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC, provide Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.) Division of License Renewal Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Washington, D.C. 20555-0001									
9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC, type "Same as above"; if contractor, provide NRC Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address.) Same as 8 above									
10. SUPPLEMENTARY NOTES Docket Number 50-298									
11. ABSTRACT (200 words or less) <p>This supplemental environmental impact statement (SEIS) has been prepared in response to an application submitted by Nebraska Public Power District (NPPD) to the Nuclear Regulatory Commission (NRC) to renew the Operating License for Cooper Nuclear Station (CNS) for an additional 20 years under 10 CFR Part 54. The SEIS includes the NRC staff's analysis that considers and weighs the environmental impacts of the proposed action, the environmental impacts of alternatives to the proposed action, and mitigation measures available for reducing or avoiding adverse impacts. It also includes the staff's recommendation regarding the proposed action.</p> <p>The NRC staff's recommendation is that the Commission determine that the adverse environmental impacts of license renewal for CNS are not so great that preserving the option of license renewal for energy-planning decision makers would be unreasonable. The recommendation is based on (1) the analysis and findings in the GEIS; (2) the Environmental Report submitted by NPPD; (3) consultation with Federal, State, and local agencies; (4) the staff's own independent review; and (5) the staff's consideration of public comments.</p>									
12. KEY WORDS/DESCRIPTORS (List words or phrases that will assist researchers in locating the report.) Cooper Nuclear Station NPPD Nebraska Public Power District Supplement to the Generic Environmental Impact Statement FSEIS National Environmental Policy Act NEPA License Renewal GEIS NUREG 1437, Supplement 41	<table border="1" style="width: 100%;"> <tr> <td>13. AVAILABILITY STATEMENT</td> </tr> <tr> <td style="text-align: center;">unlimited</td> </tr> <tr> <td>14. SECURITY CLASSIFICATION</td> </tr> <tr> <td style="text-align: center;">(This Page) unclassified</td> </tr> <tr> <td style="text-align: center;">(This Report) unclassified</td> </tr> <tr> <td>15. NUMBER OF PAGES</td> </tr> <tr> <td>16. PRICE</td> </tr> </table>		13. AVAILABILITY STATEMENT	unlimited	14. SECURITY CLASSIFICATION	(This Page) unclassified	(This Report) unclassified	15. NUMBER OF PAGES	16. PRICE
13. AVAILABILITY STATEMENT									
unlimited									
14. SECURITY CLASSIFICATION									
(This Page) unclassified									
(This Report) unclassified									
15. NUMBER OF PAGES									
16. PRICE									



Federal Recycling Program



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, DC 20555-0001

OFFICIAL BUSINESS