

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
 Reliability and PRA Subcommittee

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Tuesday, December 14, 2010

Work Order No.: NRC-602

Pages 1-321

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
(ACRS)

RELIABILITY AND PRA SUBCOMMITTEE MEETING

+ + + + +

OPEN SESSION

+ + + + +

TUESDAY

DECEMBER 14, 2010

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Advisory Committee met, at the Nuclear
Regulatory Commission, Two White Flint North, Room
T2B1, 11545 Rockville Pike, at 8:30 a.m., John W.
Stetkar, Chairman, presiding.

COMMITTEE MEMBERS:

JOHN W. STETKAR, Chairman

DENNIS C. BLEY, Member

DANA A. POWERS, Member

WILLIAM J. SHACK, Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

NRC STAFF PRESENT:

HAROLD BARRETT, NRR

RAYMOND H.V. GALLUCCI, NRR

DONALD HARRISON, NRR

ANDREW HOWARD, NRR

STEVE LAUR, NRR

CHRISTIANA LUI, RES/DRA

CHARLES MOULTON, NRR

MARK SALLEY, RES/DRA/FRB

SUNIL WEERAKKODY, NRR

JOHN LAI, Designated Federal Official

ALSO PRESENT:

PATRICK BARANOWSKY, ERIN Engineering

BIFF BRADLEY, NEI

KEN CANAVAN, EPRI

PAUL AMICO, SAIC

MARDY KAZARIANS, Kazarians & Associates, ACRS
Consultant

DAVID MISKIEWICZ, Progress Energy

STEVEN P. NOWLEN, Sandia National Laboratories

DOUG TRUE, ERIN Engineering

RICK WACHOWIAK, EPRI

KIANG ZEE, ERIN Engineering

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

C-O-N-T-E-N-T-S

Call to order and Opening Remarks John Stetkar, Chairman	5
Electrical Cabinet Fire (Frequency, HRR, HRA)	8
Rick Wachowiak, EPRI	46
Doug True, ERIN	8, 63
NRC Perspective on Electrical Cabinet Fires	72
Sunil Weerakkody, Deputy Director Fire Protection	108
Ray Gallucci, NRR	112, 126
Harold Barrett, NRR	109
Steve Nowlen, SNL	72
NRC Perspective on FAQ Process	139
Ray Gallucci, NRR	161
Charles Moulton, NRR	139
EPRI/NRC Research Coordination	171
Ken Canavan, EPRI	171, 213
Rick Wachowiak, EPRI	217

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

C-O-N-T-E-N-T-S (CONTINUED)

NRC Perspective on Research	249
Christiana Lui	249
Mark Salley, RES	251
Miscellaneous Questions, Fire PRAs	281
Sunil Weerakkody	281
Public Comment Opportunity	318

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

CHAIRMAN STETKAR: This is the second day of a meeting of the Reliability and PRA Subcommittee.

I'm John Stetkar, Chairman of this Subcommittee meeting.

ACRS members in attendance are Dennis Bley, Dana Powers, and William Shack.

Our ACRS Consultant, Mardy Kazarians, is also in attendance. John Lai, of the ACRS staff, is the Designated Federal Official for this meeting.

The purpose of the meeting is for the Subcommittee to review the current state of licensee efforts on the fire protection program transition to NFPA 805. We will hear presentations from the nuclear industry and NRC staff.

There will be a phone bridge line. To preclude interruption of the meeting, the phone will be placed in the listen-in mode during the presentations and Committee discussions.

We have received no written comments or requests for time to make oral statements from members of the public regarding today's meeting. The entire meeting will be open to public attendance.

The Subcommittee will gather information,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 analyze relevant issues and facts, and formulate
2 proposed positions and actions as appropriate for
3 deliberation by the full Committee.

4 The rules for participation in today's
5 meeting have been announced as part of the notice of
6 this meeting previously published in The Federal
7 Register.

8 A transcript of the meeting is being kept
9 and will be made available, as stated in The Federal
10 Register notice. Therefore, we request that
11 participants in this meeting use the microphones
12 located throughout the meeting room when addressing
13 the Subcommittee. The participants should first
14 identify themselves and speak with sufficient clarity
15 and volume, so that they may be readily heard.

16 What we are going to do today is we are
17 going to pick up with the agenda as it was published.

18 We skipped one presentation from both EPRI and the
19 staff yesterday on incipient fire detection. We will
20 try to make room for that today. Can't promise.
21 We'll see how the schedule goes.

22 But I think that the topic of electrical
23 cabinet fires is probably of somewhat more interest to
24 the Subcommittee. So, I want to make sure that we
25 actually get to that topic today.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 With that, I guess I will turn it over to
2 Doug True and Rick Wachowiak.

3 And welcome, Rick. I'm really happy that
4 you made it. It's a heroic effort.

5 MR. WACHOWIAK: It's good to see you all
6 again.

7 CHAIRMAN STETKAR: Doug?

8 MR. TRUE: Okay. I'm Doug True from ERIN
9 Engineering.

10 I'm going to cover electrical cabinets
11 kind of in a holistic presentation here. Last time,
12 in November, we kind of jumped around between topics
13 and had a little of bit of electrical cabinets in a
14 bunch of different places. This time we are going to
15 try to put it together in one connected discussion.
16 And I'm sure we'll have a lot of dialog on these
17 topics.

18 Also, at your request, Mr. Chairman, we
19 have the presentation from last time that we will go
20 back to to talk about fire growth --

21 CHAIRMAN STETKAR: Good.

22 MR. TRUE: -- because that wasn't
23 explicitly covered in here, or at least in the level
24 of detail that we did last time.

25 CHAIRMAN STETKAR: Good.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TRUE: So, as we talked about in the
2 last PRA SC presentation, electrical cabinets are a
3 significant contributor to the fire CDFs. There's no
4 surprise there. It was the ridge line sort of on our
5 now infamous skyline graph.

6 And the purpose here I think is to
7 elaborate on the relationship between the methods from
8 non-electrical cabinets and the large risk
9 contribution, and sort of talk through why we see that
10 happening.

11 And then, Rick is going to spend a little
12 bit of time talking about some ongoing research
13 activities that target some of these areas and cover
14 what is actually being done with trying to address
15 this.

16 So, we have our issues framework. I am
17 just going to kind of quickly go through and say that,
18 for electrical cabinet fires, I think there are things
19 to talk about on very large number of our elements of
20 this graphic, beginning with the ignition frequency
21 estimate, talking about the severity, about non-
22 suppression, how that gets handled in non-suppression,
23 about detection and response, and its relationship
24 with non-suppression, about the growth rate, about the
25 heat release rates, about the fire propagation and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 damage, about suppression and control, about recovery
2 actions, safe shutdown, and the operator response.
3 So, it hits on very many elements of our issues
4 framework, and this presentation tries to put that
5 together in some sort of reasonably concise
6 description.

7 So, what we are going to do is focus on a
8 handful of the more important aspects of this. First
9 is the fire ignition frequency, and we'll talk about
10 growth rate a little bit. This is where I will
11 probably jump out to the other presentation because I
12 cut it way down in this version; the peak heat release
13 rates, the non-suppression, propagation and damage,
14 and operator response. And they are interrelated, of
15 course, as all these things are.

16 So, let's start with ignition frequencies.
17 Bin 15, as we know, is the electrical cabinet fires.
18 It was split apart in a FAQ. Sort of the high-energy
19 arcing faults were broken off into Bin 16a and b.

20 In NUREG CR-6850, EPRI 1011989, there were
21 109 events. The bin frequency, plantwide bin
22 frequency, was .5 times 10 to the minus 2 per year.
23 That was allocated across the count of cabinets that
24 each plant had. And talked through about how there's
25 some variation from plant to plant in the number of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 electrical cabinets. But it is the same principle as
2 we talked about with diesel generators. Take that
3 frequency and divide by the number of cabinets that
4 qualify, and that is your cabinet-specific frequency.

5 In an EPRI Interim Report, EPRI came up
6 with some new ignition frequencies, EPRI 1016735, that
7 kind of split the population the pre-1991 and 1991
8 through 2000 bins, did a statistical analysis, and
9 came up with a little bit lower frequency that
10 reflected that trend that Pat Baranowsky showed you
11 yesterday of the drop in events that both the Fire
12 Events Database indicates as well as the NRC's
13 tracking of severe fires. So, it was a little bit
14 lower frequency.

15 In doing that work, EPRI detected that
16 there was plant-to-plant variability in the data that
17 had been involved and went through a hierarchical
18 Bayesian analysis to create a more diffused prior
19 distribution. And the result was a relatively broad
20 uncertainty estimate for Bin 15.

21 The value of that broader estimate is
22 that, when plants go to do their plant-specific data
23 update, the mean value will move more if the plant has
24 evidence. So, it was done in order to give a little
25 more weight to the plant-specific evidence on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 electrical cabinet fires because they occur, and it
2 was done because there was plant-to-plant variability.

3 But the result of it is that it will allow plant-
4 specific data to have more influence on the result.

5 CHAIRMAN STETKAR: Doug, I thought we
6 heard -- nobody has yet done any of these plant-
7 specific updating, is that correct?

8 MR. TRUE: They do it as part of each fire
9 PRA.

10 CHAIRMAN STETKAR: Oh, I thought we heard
11 yesterday that they had not done any of that, that
12 they were only using the generic data.

13 MR. TRUE: I think somebody said, one
14 person said they had only used generic, and, then, I
15 think Kiang got up and said that he uses --

16 CHAIRMAN STETKAR: Okay, okay. Sorry.

17 MR. TRUE: -- the data, and Jim I think
18 also is nodding that, too.

19 CHAIRMAN STETKAR: I misunderstood then.
20 Thank you.

21 MR. TRUE: There is a little bit of a
22 disconnect in the numbers. The 109 became more like
23 99, but it had to do with some screening and data
24 cleanup that occurred in the EPRI work. I don't think
25 there's any point of contention over that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Doug, just out of
2 curiosity, were you involved in that rescreening
3 yourself?

4 MR. TRUE: I was not personally.

5 CHAIRMAN STETKAR: You were not?

6 MR. TRUE: But ERIN was.

7 CHAIRMAN STETKAR: Okay.

8 MR. TRUE: And the person who was is here,
9 if you want to talk to him.

10 CHAIRMAN STETKAR: He is? Well, I'm
11 curious whether -- it's, you know, you can talk about
12 factors of two, but it is a fairly dramatic change if
13 you consider also the change in the population over
14 those two time periods, at least for the '68 through
15 '90 time period.

16 Do you happen to know whether the
17 reduction in events that are retained in the database
18 is due to what I would characterize as a real
19 reduction in the fire frequency or is it only because
20 we have more information in the later events, and
21 therefore, can more easily conclude that a larger
22 number of events were not valid fires?

23 MR. TRUE: I don't know.

24 CHAIRMAN STETKAR: You don't know?

25 MR. TRUE: Pat?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. BARANOWSKY: Pat Baranowsky.

2 For the kinds of events that are counted
3 in the fire ignition frequency, the so-called
4 potentially-challenging ones, they have
5 characteristics that at least I'm pretty confident
6 that we're getting all or almost all of those events
7 identified. It is the ones that were undetermined
8 that were a little problematic where the .5 factor was
9 used that we're not quite sure. Now I guess there's a
10 possibility more than half of them could be real
11 fires, and you would slightly underestimate, but I,
12 frankly, doubt it. Because of the nature of
13 potentially-challenging fire events, everyone would
14 recognize them. But that's my opinion.

15 CHAIRMAN STETKAR: Okay. Thank you.

16 MR. TRUE: Okay. There was a FAQ, FAQ 48,
17 that addressed the new EPRI data and the use of that
18 data in the 6850 application for NFPA-805. That FAQ
19 requires the use of both those frequencies for the
20 baseline risk and delta risk calculations.

21 I pulled the quote right out of the FAQ.
22 It says that "the large uncertainty bin fire frequency
23 is due to the sparsity of data for that bin and,
24 therefore, the potential for significant changes
25 should the post-2000 fire event data differ

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 significantly from the 1991-2000 data."

2 Basically, what they're saying is that any
3 of the bins that had large uncertainty, you should do
4 the sensitivity study using both values. The problem
5 is that this bin has the most data of all, of all the
6 bins, because it has the highest frequency of all the
7 bins. But because of the plant-to-plant variability
8 and the additional uncertainty that was built in in
9 the hierarchical Bayesian analysis, it was interpreted
10 as being sparse data. So, we aren't allowed to
11 actually use that value, the upper value in these
12 analyses.

13 And that is one of the reasons why some
14 plants have been loath to sort of jump on to using all
15 this data, is that there is this caginess about
16 whether that is really good data or not to use. So,
17 that is one of our problems, and it is about a factor
18 of two, a little less than a factor of two, on that
19 original line that we like to show in that graphic.
20 So, that's one concern that we have.

21 Any questions about that?

22 CHAIRMAN STETKAR: No. I think we'll have
23 questions for the staff.

24 MR. TRUE: Okay. Fire severity. Fire
25 growth and peak heat release rates, as we talked about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 in the last meeting, are based on tests investigating
2 large electrical cabinet fires. Many of them used
3 accelerants or some kind of flame source. They were
4 qualified and unqualified data. Data was kind of
5 commingled. There were lots of open cabinets. And
6 there was a relatively small number of sub-bins used
7 to define the peak heat release rates.

8 The distributions that are used were
9 anchored to this 98th and 75th percentile. And
10 according to 6850, the 98th percentile was used to
11 establish the high-confidence fire intensity that was
12 expected to bound the vast majority of fires involving
13 a given fire source.

14 Again, this is kind of where we get stuck
15 in this bounding thing, and we've got this ignition,
16 these events that reflect one thing. Now we're
17 anchoring this to a bounding value to make sure we've
18 got everything, the consequences all bounded.

19 And there's no evidence or little to no
20 evidence that the things that we have in the ignition
21 frequency bin reflect the 98th, much less the 75th --
22 or 75th, much less the 98th percentile. I mean there
23 have been some serious fires, but most of the really
24 exciting fires have been the high-energy arcing fault
25 ones, not the ones that start in a cabinet and evolve.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 So, probably this is the point where it
2 would make sense to go and talk about the 12 minutes.

3 So, I am going to go back to the presentation from
4 November 16th. It was one called "The Roadmap".

5 CHAIRMAN STETKAR: Do we have paper copies
6 of this, John? Can we get it because Dennis and Dana
7 were not here in November.

8 MEMBER SHACK: We have electronic ones
9 that John sent to us.

10 MR. TRUE: So, NUREG/CR-4527 is one of the
11 main sources of data for the fire growth estimates in
12 EPRI 1011989, NUREG-6850. Then, it turns out it is
13 the primary basis for the 12-minute fire growth rate
14 assumptions.

15 The tests were done in a variety of
16 different forms, and Steve Nowlen can provide a lot of
17 background on this. But most of the tests involved an
18 ignition source that was a polyethylene bucket. They
19 had a pound of kimwipes doused with some acetone.
20 They had a pretty substantial flame height and burned
21 for about 35 minutes.

22 And according to the report, when they did
23 the first couple of tests, they had difficulty getting
24 the burn to be sustained. So, they would pull the
25 cables physically apart in order to get it a better

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 chance of igniting and burning.

2 So, this is a graph of a test that is just
3 the heat release rate for the polyethylene bucket with
4 kimwipes and acetone. It shows the heat release rate,
5 and it shows that, after about 35 minutes or so, it
6 starts to tail off, and that it ramps up over a period
7 of just about 12 minutes. And it stays relatively
8 constant. I mean it is pretty impressive how steady-
9 state it actually got to over that 25-or-so-minute
10 period of full burn.

11 So, I have traced that with a red line
12 here that we will use again here as we compare it to
13 some of the other tests.

14 So, this is a graph right out of 4527 also
15 that is another set of tests, a different scale, of
16 course, because some of the tests had substantially
17 larger peak heat release rates. It shows a set of
18 five tests.

19 The first, test 1 and test 2, had no
20 propagation and the bundle didn't burn. So, not
21 surprisingly, if you lay that red line over the top,
22 it looks an awful lot like those first two tests.

23 And if you, then, also look at these other
24 tests, they all ramp up to about the 12-minute mark,
25 where they're hitting their peak and then tail off.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 It appears from this data -- and the
2 report is not particularly clear on this -- but it
3 appears that all of these still include the peak heat
4 release rate from the source. I guess I will be
5 interested to hear if that is the case, but --

6 MEMBER BLEY: I'm sorry. Say that again.
7 I didn't hear what you said.

8 MR. TRUE: It appears that all these peaks
9 include the source because tests 1 and 2 are basically
10 the same trace as the source.

11 MR. NOWLEN: Yes. Steve Nowlen.

12 Just to be clear, that's absolutely
13 correct. These are total heat release rates -- I'm
14 sorry -- total heat release rate versus time for the
15 fire. So, it includes the source. They're all that
16 way.

17 MR. TRUE: Thanks, Steve.

18 Okay. So, if we turn, then, to the data
19 table that represents these tests, ST 1 through ST 5,
20 we will see, for example, ST 5 says the peak heat
21 release rate is 132. Let's see if I can do this this
22 way. And that's ST 5, which is 132. So, it tracks
23 with the data in the report.

24 Another thing about this data was that
25 many of these open, unventilated cabinets, which

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that's not totally representative of our electrical
2 cabinets today in plants. Some have certainly grills,
3 but no doors. And the first couple didn't actually
4 have any significant damage involved with them.

5 So, other tests that were included. These
6 were preliminary cabinet tests. We had one that had
7 15 gallons of heptane used as its source, and then we
8 had some others involving benchboard cabinets that
9 were also included into this, into these results.

10 So, this was the table right out of 1650
11 that has a compilation of all these tests and a
12 handful of others. It shows that the peak heat
13 release rate is all in that relatively short period of
14 time.

15 It is sort of a mixture of qualified and
16 unqualified cables and the different ignition sources.

17 To be fair, there was one electrically-initiated fire
18 in 4527 and another one down here in another test.
19 So, there were a couple of electrically transient.
20 When they talk about ignition source, it is a term
21 that was used to describe the polyethylene bucket and
22 kimwipes as the ignition source.

23 CHAIRMAN STETKAR: Doug, on those
24 electrically-initiated fires -- and Steve will
25 probably jump up here --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. TRUE: He probably should.

2 (Laughter.)

3 CHAIRMAN STETKAR: Just get ready here
4 upfront.

5 How were those ignited? Because the
6 interesting thing I see in this table is that the time
7 to develop the peak heat release rate for those two
8 particular tests are 12 and 17 minutes. One is pretty
9 close to the magic 12 minutes that we're talking
10 about. One is a little bit longer. How were they
11 ignited?

12 MR. NOWLEN: Sure. What was simulated is
13 a poor connection at a terminal block. That
14 connection is simulated with a resistive washer placed
15 between the incoming power line and the back side of
16 the terminal block.

17 The power level for that was 165 watts, so
18 a large lightbulb. The idea was to see if a fault
19 that would not be tripped by a typical circuit breaker
20 would be enough to induce a fire in the wiring. And
21 the answer was, yes, it could be done.

22 Now the growth times that are reported
23 here are actually from the first observation of when
24 there was a flame that would form.

25 CHAIRMAN STETKAR: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. NOWLEN: So, there is a period before
2 that where the heating occurs over a relatively long
3 period of time. About a total from when we first
4 turned it on to when the first flame would appear
5 would be about 30 minutes, typically.

6 During that period, that are actually
7 little wisps of smoke that would come off. And one of
8 the things that we do say is, if you have in-cabinet
9 detectors, those were actually very effective at
10 picking up that early heating behavior. But without
11 the in-cabinet detectors, if there was just a detector
12 on the ceiling, for example, you would not pick that
13 up.

14 CHAIRMAN STETKAR: Sure. Yes.

15 MR. NOWLEN: So, these reflect from the
16 point of open flame to the peak heat release rate of
17 the cabinet. And again, there's guidance that, if you
18 have an in-cabinet detector, you take another 15
19 minutes. So, you know, your detection time, you get
20 to add 15 minutes to it.

21 CHAIRMAN STETKAR: Okay.

22 MR. NOWLEN: Does that make sense?

23 MR. TRUE: Yes. And then, this steady
24 burning, was the electrical source removed at some
25 point or was that --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. NOWLEN: Yes.

2 MR. TRUE: Because they are both zero
3 duration at steady --

4 MR. NOWLEN: Yes. Well, that's because
5 they peak -- these were some of the largest of the
6 fires. These are the ones where the 98 percentile
7 values tend to come from. These were the full mockup
8 cabinets in the control room mockup. And they tended
9 to grow very rapidly and then burn out. So, there
10 wasn't a growth to a steady-state followed by decay.
11 It came up and then started on its way down.

12 But these are the fires that were above a
13 megawatt. You know, some of these, especially the
14 benchboard cabinets, and whatnot, these were 1.5
15 megawatts, 1.8 megawatts. And it's that that tended
16 to drive the 98 percentile.

17 MR. TRUE: But my recollection is in 6850
18 -- sorry, I shouldn't be probably asking questions.

19 CHAIRMAN STETKAR: No, no, go on. Just
20 talk. You're on the record. It doesn't make any
21 difference.

22 MR. TRUE: It was that you take the 12-
23 minute rampup rate, and then there's a 30-minute
24 duration or some duration that you assign to this also
25 for input to your fire modeling?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. NOWLEN: Right. I think the guidance
2 was, if you don't know any better, if you can't
3 examine the internals, you don't know what the total
4 fuel load is, take a 12-minute rampup, 12-minute
5 steady-state, and then let it burn out.

6 If you know what the fuel load is, then
7 you should follow the rampup, hit the steady-state,
8 and whenever you run out of fuel, you burn out.

9 MR. TRUE: Okay.

10 MR. NOWLEN: But there was a generic, if
11 you don't know any better, do this.

12 MR. TRUE: Yes. Okay.

13 CHAIRMAN STETKAR: Thank you.

14 MEMBER BLEY: Thanks.

15 MR. TRUE: This is more about the
16 qualified cables and ability to continue a fire.

17 Let's see, there's probably one other
18 thing. This one is actually in the other
19 presentation. So, it is probably worth just a little
20 bit of discussion. And I'm sure this will be a topic
21 for later.

22 For qualified cable cabinets, there are
23 basically two bins, one with one cable and one with
24 more than one cable. The 98th percentile and the 75th
25 percentile on the two different distributions are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 anchored to the same test -- it's reference 2 -- which
2 is done by VTTC. It's actually an unqualified cable
3 test.

4 And our infinite 702 was qualified cables,
5 but it is benchboard, but it is applied to all
6 vertical cabinets. And that is another problem that
7 we are concerned about, is we've got this kind of all
8 vertical cabinets are the same thing. You know, these
9 drive the distribution. If you anchor it at these two
10 points, then you're going to end up with whatever
11 distribution you have.

12 And I think more refinement to that, and
13 down here in the unqualified cables, there are open
14 -- they have consideration of ventilation, closed
15 doors and open doors. We think there's some of that
16 that could be applied also to the qualified cable
17 cases. That is some of what Rick is going to talk
18 about in terms of the ongoing EPRI research.

19 MEMBER BLEY: Doug?

20 MR. TRUE: Yes?

21 MEMBER BLEY: Would you tell me what it
22 means to anchor it at both of those two points?

23 MR. TRUE: That's just what they said they
24 did.

25 MEMBER BLEY: Oh, okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 (Laughter.)

2 That's enough.

3 MR. WACHOWIAK: What that essentially is
4 is you use those points and you fit the distribution.
5 So, that it's of the 75th and 98th pass through those
6 two points.

7 MEMBER BLEY: Oh, okay. Or you can use
8 the parameters of --

9 MR. WACHOWIAK: That's how they determine
10 the parameters.

11 MR. TRUE: And that's how they even set
12 the parameters.

13 MEMBER BLEY: Oh, that's how they set the
14 parameters.

15 MR. TRUE: They pick these two points, and
16 then they pick the parameters.

17 MEMBER BLEY: Well, any two of the four
18 gives you the distribution.

19 MR. NOWLEN: Yes. This is Steve. That is
20 correct. We used judgment to pick two values, one
21 that we thought was upper-bound for the case and one
22 that was a -- initially, it started out as the 50th
23 percentile. We said, what would be the sort of median
24 value you would expect? And as we looked at the
25 distributions, we said, no, these are just too high.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 So, the 50th percentile got moved out to the 75th
2 percentile. Then, we drew the curves and calculated
3 the alpha beta factors, and it was that simple.

4 MEMBER POWERS: How did you decide it was
5 the 75th? I mean you said it wasn't the 50th.

6 MR. NOWLEN: Well, again, this was an
7 evolving process involving the writing team, both the
8 EPRI and the NRC team, plus our peer reviewers. We
9 wanted to do something better than what had been in
10 the EPRI fire PRA Implementation Guide. And you will
11 actually notice these numbers are mirrored in the EPRI
12 fire PRA Implementation Guide.

13 So, what we did is we looked at the
14 numbers that had come out of that work and said, how
15 are we going to deal with these in our approach? And
16 we started out, the first cut was, well, let's take
17 their upper-bound and call it the 95th and let's take
18 their mean value and call it the 50th.

19 And we looked at how that played out in
20 terms of the distribution, and it was unanimous
21 agreement that that was just too aggressive in terms
22 of the fires, that it didn't reflect the data well
23 because we were looking at the events as well. You
24 know, we were seeing a lot of the cabinet fires that
25 went into the fire frequency were quite small, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 they didn't rise to this level.

2 So, we looked at it, and we said, no, half
3 of the fires that we are counting for frequency are
4 not this big. So we said we want to move these out.
5 So, again, as a team, we worked through and said
6 what's a reasonable representation of the event data
7 that we're seeing. And again, given that we have to
8 consider that, in reality, we put fires out, this is a
9 picture of what happens to a fire if you don't put it
10 out, right? You just stand back and let it burn,
11 because we do the suppression piece separately.

12 And this was our judgment. We decided to
13 move the median value out to the 75th. The 95th we
14 moved out to the 98th. And we looked at the profiles
15 and said that's better; we like that better.

16 MEMBER POWERS: But, I mean, you're saying
17 it's just aesthetics, is the only thing that drove you
18 to do this number? I mean you could have made it the
19 99th percentile, for all I know, or the 97th.

20 MR. NOWLEN: Yes, I wouldn't say it's just
21 aesthetics. I mean it was judgment. We were trying
22 to match what we felt was representative of both the
23 test data and the events that we were counting in fire
24 frequency, and this seemed to be a reasonable match.

25 MR. TRUE: We brought up the 211 and 702.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 We're going to go back to the other, today's
2 presentation for a minute.

3 CHAIRMAN STETKAR: One of the things that
4 I think -- maybe you're going to cover it in this one
5 -- that, also, some of those heat release rates are
6 used for other equipment in NUREG CR-6850, in addition
7 to cabinets. Is that correct?

8 MR. TRUE: Yes. It is not in this
9 presentation because it's a different ignition bin.
10 But pumps and motors use an electrical cabinet value
11 of 69 kW. I mean the report's clear; they didn't have
12 any data. They picked it because it was felt to be
13 conservative.

14 And I think Dan Pace's presentation
15 yesterday. He talked about that it's the big circ
16 water pump as well as a little sump pump. As long as
17 it's greater than 5 horsepower, it gets counted in the
18 same way.

19 CHAIRMAN STETKAR: Okay.

20 MR. TRUE: It looks like Steve wants --

21 MR. NOWLEN: Yes, I'm getting the feeling
22 maybe I ought to join him up there.

23 (Laughter.)

24 But that is correct. I mean, when we went
25 to some of these other sources, we couldn't find any

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 data at all. We couldn't find a single test where
2 anyone had burned a motor.

3 So, we said, well, we need to say
4 something. So, let's go ahead and tie it to the
5 values we already have.

6 And again, there are some expectations
7 built into the way we treated some of this. We really
8 didn't think motors were going to turn out to be a
9 really heavy-hitter on risk. I think the
10 distributions bear that out.

11 So, we felt that if we tie it to these
12 lower-level cabinet fires, that would be conservative.

13 It's likely going to give them the tool they need to
14 screen these out, and that will be the end of the
15 story. That's how it developed.

16 CHAIRMAN STETKAR: Thank you.

17 MR. TRUE: This graphic I think was shown
18 to the ACRS once before a couple of years ago by Ken
19 Canavan. It's a compilation of the qualified vertical
20 cabinet tests, the actual tests involving vertical
21 cabinets, excluding the benchboard test. It shows the
22 actual values versus fuel loading. Basically, all the
23 tests came in less than 100 kilowatts. Our
24 distribution has the 98th percentile up here at 702
25 and the 75th percentile at 211.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 So, we first looked at this, and, then,
2 there is the other sort of tertiary issue. I wouldn't
3 say it's a huge issue, but each of these values all
4 still included that ignition source 30 kilowatts. So,
5 those actually coming down a little bit more for that,
6 if you are talking about just the heat-induced by the
7 fire, the electrical cabinet burning itself.

8 MEMBER BLEY: So, what are you suggesting
9 from this figure?

10 MR. TRUE: I'm suggesting that qualified
11 cable cabinets, vertical cabinets that have qualified
12 cable probably deserve a different distribution of
13 heat release rates. And there's an EPRI activity
14 going on to look specifically at that topic, whether
15 we can discriminate a little bit more on different
16 types of cabinets, from the test and some other
17 analysis that is being done.

18 MEMBER BLEY: Just as a subset of --

19 MR. TRUE: A subset, just subdividing. I
20 know there was some objection yesterday to this
21 consideration, this concern of simplifying and
22 bounding assumptions. Well, this is sort of an
23 example. We have one bin that collects everything
24 into it. Then, it's applied these sorting of bounding
25 cases to it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 We are trying to come up with a technical
2 basis for subdividing, so we can get a little bit more
3 realistic slice put together for that piece of it.

4 MEMBER POWERS: But you want to use a
5 gamma distribution on this?

6 MR. TRUE: I am not involved in that
7 project. So, I don't know what they're going to use.

8 MR. WACHOWIAK: The intent at this point
9 is to stick with the gamma distribution.

10 MEMBER POWERS: Why?

11 MR. WACHOWIAK: It's a good question.

12 (Laughter.)

13 I don't have the answer to that question.

14 MEMBER POWERS: Well, it's the maximum
15 entropy distribution for a specified mean. And I
16 could go through a justification that way.

17 MR. WACHOWIAK: Right. I do know that in
18 the report we're looking, we looked at other types of
19 distributions. And for some of the types of vertical
20 cabinets, especially with the qualified cable, other
21 distributions were suggested. And as I said, that
22 report is still under peer review, and we could look
23 into the cabinet or into the distribution.

24 MEMBER POWERS: No, you simply don't have
25 enough data to empirically define the distribution.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WACHOWIAK: That's part of the
2 problem.

3 MEMBER POWERS: So, you've got to have
4 some other theoretical basis for doing the
5 distribution. Maximum entropy distributions at least
6 have the virtue of being maximum entropy.

7 (Laughter.)

8 That's about all you can say about them.
9 Now parameterizing them based on hypotheses about
10 which data point corresponds to the 98th or the 75th
11 percentile is probably not that unusual, but I think
12 it's difficult to defend.

13 I mean I would tend to say, okay, I've got
14 a mean and I'm blatantly going to take a maximum
15 entropy based on a mean and calculate the distribution
16 based on that. And the numbers fall where they may.
17 And if people don't like that, they could define their
18 distribution. Because you just don't have enough data
19 to go out and empirically define the distribution.

20 MR. WACHOWIAK: That's one of the concerns
21 there, is that there's a few points, and we know that
22 these data points don't necessarily really represent
23 the distribution of what we're trying to model. So,
24 it's a difficult problem.

25 One of the reasons why during the peer

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 review we chose to stick with the distributions that
2 were selected in 6850 goes back to part of what was
3 talked about yesterday in the implementation of 6850.
4 If the distribution in 6850 is there, it's easy to
5 get acceptance that it's okay to use that
6 distribution. If we pick some other distribution, we
7 need mounds and mounds of information justifying the
8 different distribution. So, the burden of proof, if
9 you will, is much greater on choosing something that's
10 other than 6850.

11 CHAIRMAN STETKAR: Rick, are you going to
12 talk about the program at EPRI to address it?

13 MR. WACHOWIAK: Yes.

14 CHAIRMAN STETKAR: Okay.

15 MR. WACHOWIAK: Yes, I've got a couple of
16 slides, and we can elaborate as much as we need. And
17 we've got one of the authors here in the audience with
18 us.

19 CHAIRMAN STETKAR: One question before you
20 move off this slide. It is somewhat relevant to the
21 path forward.

22 You're careful to show that these are
23 cabinets that contain qualified cables.

24 MR. WACHOWIAK: Yes.

25 CHAIRMAN STETKAR: In a typical plant,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 what fraction of the cabinets contain only qualified
2 cables? Do you have any notion of that? I mean, in
3 practice, are we actually restricting this effort to
4 what may be a fairly small fraction of the total
5 number of cabinets? Because some cabinets may have
6 only unqualified cables, depending on their purpose,
7 or some fraction may have a relatively undetermined
8 mix, let's say.

9 MR. TRUE: Yes, I should say, and Rick
10 should say, that the EPRI work is not limited to
11 qualified cables --

12 CHAIRMAN STETKAR: Okay. Okay. Good.

13 MR. TRUE: -- as maybe the poster child
14 sort of this.

15 CHAIRMAN STETKAR: Yes. I mean, whenever
16 I see these things like this, I start to wonder about
17 what fraction of the real problem is this addressing.

18 MR. TRUE: Right. I think they are trying
19 to address the whole spectrum of cabinets. Is that
20 right, Rick?

21 CHAIRMAN STETKAR: We'll get to it later
22 when we talk about the actual program. Thanks.

23 MR. TRUE: So, the growth rate is based on
24 those same tests used for the peaks that use the
25 accelerants and flame sources, the mix and match of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the qualified cables.

2 And it doesn't appear that these fit what
3 we see in the actual operating experience, and this
4 greatly influences the damage magnitude and the
5 timeline for suppression and/or operator response.
6 So, it carries through into not just what's damaged,
7 but, then, how long do you have for operators to take
8 actions in response? And that affects the PRA
9 response model. So, it's one of those things that has
10 more tentacles into the actual calculation than just
11 how fast does this fire get from zero to that big
12 fire.

13 The experience in the databases, as best
14 you can interpret from the data we have, the vast
15 majority of them are manually suppressed. That is,
16 there is no automatic suppression that is putting
17 these fires out.

18 CHAIRMAN STETKAR: Okay. That's a simple
19 -- I'm going to interrupt you a lot.

20 MR. TRUE: That's fine. Great.

21 CHAIRMAN STETKAR: This is normal.

22 MR. TRUE: Yes.

23 CHAIRMAN STETKAR: In my experience,
24 that's mostly because most of the locations that
25 contain these cabinets do not have automatic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 suppression systems, is that correct?

2 MR. TRUE: Right.

3 CHAIRMAN STETKAR: Okay.

4 MR. TRUE: Right.

5 CHAIRMAN STETKAR: I just want to make
6 sure that --

7 MR. TRUE: I wasn't trying to say that --

8 CHAIRMAN STETKAR: -- manually suppressed
9 because that's the only way to put --

10 MR. TRUE: -- people are faster than
11 automatic systems at all.

12 (Laughter.)

13 CHAIRMAN STETKAR: Okay.

14 MR. TRUE: It was mostly the experience as
15 we manually put them out.

16 CHAIRMAN STETKAR: Because you have to put
17 them out manually?

18 MR. TRUE: Right.

19 CHAIRMAN STETKAR: Okay.

20 MR. TRUE: Either by de-energizing or by
21 actually shooting them with one or more fire
22 extinguishers.

23 CHAIRMAN STETKAR: Sometimes, you know,
24 the implications of those bullets might be that people
25 are so good, that these fires are so small, that the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 automatic systems didn't even have a chance to work
2 well.

3 MR. TRUE: Definitely not the way it was
4 intended to be taken.

5 If we set aside the HEAFs, then we have
6 very few electrical cabinet fires that have resulted
7 in damage to nearby equipment, even within their own
8 cabinet or array of cabinets, much less cable trays
9 above.

10 We have a FAQ that provided some improved
11 credit for manual suppression, but this rapid assumed
12 growth rate gets overlaid on that. And so, it affects
13 our ability to suppress.

14 And, then, I have brought this up a couple
15 of times, that part of the longer-term research --
16 and, hopefully, we'll get some of this out of the fire
17 database work -- sometimes they don't actually
18 suppress. They will just take some action to control
19 because the fire doesn't look like it's threatening
20 equipment. And we think there's probably some basis
21 to be able to credit control as a sort of interim step
22 before actually extinguishing the fire.

23 The FAQ 42 talks about propagation outside
24 of well-sealed cabinets. And there was originally in
25 that FAQ the industry has proposed some sort of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 probabilistic treatment of fire propagation within
2 cabinets that didn't meet this well-sealed definition.

3 CHAIRMAN STETKAR: I was just thinking.
4 Back to the last slide, the last bullet there, I guess
5 I don't appreciate the difference between control
6 versus suppression. I mean I understand what you're
7 talking about, but in terms of application of the
8 guidance, are the fire suppression curves, the time
9 curves, in 6850 actual extinguishment of the fire or
10 is it simply a combination of control and
11 extinguishment?

12 MR. TRUE: No, it's just extinguishment.

13 CHAIRMAN STETKAR: It is full
14 extinguishment?

15 MR. TRUE: Yes.

16 CHAIRMAN STETKAR: Okay.

17 MR. TRUE: Yes.

18 CHAIRMAN STETKAR: Thanks. Then, I
19 understand.

20 MR. TRUE: I am actually not convinced the
21 control personally -- this is just me talking now --
22 is as big an issue for electrical cabinets as it is
23 for some of the other fires, where they may just let
24 them burn out, but make sure that no other equipment
25 is being damaged. But it's an issue we have raised

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 and it should be looked at for this. I don't know
2 that probabilistic we're going to get a whole lot
3 of --

4 CHAIRMAN STETKAR: It will make a big
5 difference?

6 MR. TRUE: I wouldn't put it as a high
7 priority for sure.

8 CHAIRMAN STETKAR: Okay. Okay. Thanks.
9 I just wanted to make sure I understood the subtleties
10 there.

11 MR. TRUE: Yes, right now, it is only
12 credit, we anchor the non-suppression recovery curve
13 based on actually being extinguished.

14 CHAIRMAN STETKAR: Extinguished fully,
15 whatever they call it? Extinguished.

16 MR. TRUE: Yes.

17 CHAIRMAN STETKAR: Okay. Thank you.

18 MR. TRUE: So, FAQ 42 talked about
19 propagation outside of well-sealed cabinets. And in
20 the original FAQ, the industry had proposed
21 probabilistic treatment of fire propagation within
22 cabinets that didn't meet this well-sealed definition.

23 As part of bringing the FAQ process to
24 closure, that piece was taken out of the FAQ and sort
25 of set aside, and we'll get to it later. It's one of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 those ones that we need to kind of come back to at
2 some point.

3 The FAQ process, the staff felt they
4 needed to drive it to closure. So, some things got
5 left out. That's one that we think needs to be
6 brought back. Because, right now, we're propagating
7 it everywhere in the cabinets.

8 So, any MCC fire basically damages the
9 entire cabinet.

10 CHAIRMAN STETKAR: When you say "the
11 entire cabinet", do you mean the entire cabinet or the
12 entire MCC?

13 MR. TRUE: Well, this is where it gets a
14 little bit tricky in how you count cabinets and stuff.
15 I probably should have somebody who is an actual --

16 CHAIRMAN STETKAR: But I'm asking from a
17 practical --

18 MR. TRUE: It is basically the whole stack
19 goes.

20 CHAIRMAN STETKAR: I'm asking from a
21 practical implementation how are MCC cabinet fires --
22 because I understand how cabinets are counted.

23 MR. TRUE: Right.

24 CHAIRMAN STETKAR: How are they modeled in
25 a typical fire PRA? Does a fire in any MCC cabinet

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 disable the entire MCC?

2 MR. TRUE: Yes.

3 CHAIRMAN STETKAR: The entire MCC --

4 MR. TRUE: It's assumed to because --

5 CHAIRMAN STETKAR: Okay.

6 MR. TRUE: -- there's no other treatment
7 for that beyond that.

8 CHAIRMAN STETKAR: Okay. And you're
9 saying that there may be some evidence that that
10 actually does not occur in practice?

11 MR. TRUE: Yes. The industry believed
12 they had I think it was like a .2 probability that it
13 could be justified for that --

14 CHAIRMAN STETKAR: Okay.

15 MR. TRUE: -- a .2 probability of
16 propagation, I believe it was. So, 80 percent of the
17 time it doesn't actually get outside of the MCC.

18 CHAIRMAN STETKAR: Oh, outside of the MCC?
19 I'm talking about damage to the --

20 MR. TRUE: The initial --

21 CHAIRMAN STETKAR: I thought you were
22 talking about in-cabinet effects here and refining the
23 level of damage within the MCC. In other words, how
24 many actual motor contacters are disabled by a fire in
25 the cabinet.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TRUE: Kiang, can you help me out here?

2 CHAIRMAN STETKAR: But what I want to
3 understand, though, is a lot of the experience says
4 that, if I have a fire in a motor contactor, I get
5 combustion products and I tend to trip the supply to
6 the entire MCC. And usually, after a fire, if I'm an
7 operator, I'm not going to go reclose that circuit
8 breaker --

9 MR. TRUE: Usually.

10 CHAIRMAN STETKAR: -- unless I'm at
11 certain plants who decide that they like to do that,
12 for example, and the fire is worse.

13 (Laughter.)

14 We won't name a plant name.

15 (Laughter.)

16 MR. TRUE: Yes.

17 CHAIRMAN STETKAR: But a prudent thing
18 would be to not do that. So, it's not clear whether
19 you're doing an internal cabinet propagation, whether
20 or not the overall effects are any different.

21 MR. TRUE: Right.

22 MR. ZEE: This is Kiang Zee, ERIN
23 Engineering.

24 You're correct. What's typically done for
25 all MCC fires is every fire that is postulated in an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MCC at a minimum starts with loss of power at that
2 MCC.

3 CHAIRMAN STETKAR: Okay.

4 MR. ZEE: Either because of the variable
5 you describe or what could likely happen is the fire
6 brigade may require that the unit be de-energized
7 before they apply suppression.

8 The issue I think we are dealing with here
9 is the aggression heat release rates and growth times,
10 and when you apply that in fire modeling space and the
11 FAQ 42 will typically result in most MCCs not being
12 considered well-sealed despite the mechanical --

13 CHAIRMAN STETKAR: Oh, okay. Okay.

14 MR. ZEE: -- interlocks on the door.

15 So, consequently, if you pull through the
16 way the data progresses, you could predict virtually
17 every MCC fire will have propagated beyond the
18 enclosure by the time the fire brigade applies
19 suppression.

20 CHAIRMAN STETKAR: Okay.

21 MR. ZEE: And that's where you get into a
22 little bit of disconnect.

23 CHAIRMAN STETKAR: Okay. Thanks. That
24 helps me because I thought the entire context of this
25 slide was really focused on effects within an MCC,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 trying to focus on how many motor contacters might be
2 damaged, but it is related more to the external
3 effects.

4 MR. ZEE: Yes.

5 CHAIRMAN STETKAR: Thank you.

6 MR. TRUE: I sort of already covered on
7 this, but the rapid growth rate reduces available time
8 for operator actions. So, when we have things like
9 fire damage in a valve that needed to change positions
10 or spuriously operating a valve, because these are
11 growing so rapidly, that response time is shortened,
12 which gives higher human error probabilities, which
13 further exacerbate the quantification.

14 And, then, in a number of cases, we think
15 that it results in unrealistic human error
16 probabilities coming directly out of these
17 assumptions.

18 So, back to one of our themes that I think
19 Dan Pace started with yesterday, it is just
20 compounding. We have got, we think, the frequency of
21 the fires is overstated. We think the growth rates
22 are too large. In certain cases, the peaks are too
23 large, and the damage doesn't really comport with our
24 operating experience such that we end up pushing the
25 fire PRA in a direction that departs from reality.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 In the FAQs, there have been some places
2 where it they have really helped. But we think they
3 are still short of providing realistic methods in a
4 number of areas.

5 I think Rick's up.

6 MR. WACHOWIAK: So, some of the related
7 things that we're doing to alleviate the problems that
8 Doug was talking about are related to the things that
9 are in the research matrix.

10 You heard yesterday about the fire events
11 database. We are looking at confirming the trend in
12 the ignition frequencies and to provide some better
13 distributions for the plants used as the prior.

14 We think we can look into the events that
15 are being counted, and because we're collecting more
16 data on the newer events, that we will be able to get
17 a better handle on what was actually going on with the
18 manual suppression and maybe get some insights on the
19 fire growth and the damage from these events. That is
20 mainly a consequence of the way that we are collecting
21 the data to get more information on these.

22 Another thing that we're looking at is the
23 binning structure for the cabinet fires. And this
24 relates to one of the reports that we are in the
25 middle of reviewing right now that addresses what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 would the peak heat release rate be. How do you
2 subdivide this bin that Doug was talking about?

3 Go ahead.

4 CHAIRMAN STETKAR: I'm kind of intrigued
5 by this because I can hear what you're saying you're
6 planning to do. It's not clear to me how it will
7 actually be accomplished. And yet, we're hearing that
8 the database should be available by the end of next
9 year.

10 I'm thinking about short-term --

11 MR. WACHOWIAK: Right.

12 CHAIRMAN STETKAR: -- not protracted five-
13 year research programs. I'm thinking about what sorts
14 of short-term benefits may be available within the
15 next several months to a year, roughly, timeframe to
16 sort of help at least this hurdle, the cabinet fire
17 hurdle, and perhaps other elements of the process.

18 How much have you thought about how you're
19 going to use the data to address these issues of fire
20 growth rate and consequential peak heat release rate,
21 given what you know from the fire event reports? Will
22 it be a subjective evaluation that somebody said,
23 well, we had a relay ignite and it was extinguished
24 within 27 minutes; therefore, the peak heat release
25 rate must have been, you know, a kilowatt or 6 watts,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 or something like that, without any actual measured
2 evidence of heating? Or have you thought much about
3 that?

4 MR. WACHOWIAK: In terms of what's going
5 on with that particular project, maybe Pat would have
6 a better insight to that piece of it.

7 From the end that I have been involved in
8 and that we have been looking at, I wouldn't expect
9 the binning to go that way. It is like I mentioned
10 earlier. If we have a lot of things that are
11 subjective like that where we would infer a peak heat
12 release rate from a text description of the fire, I
13 would find that that would be difficult to pass
14 through review scrutiny.

15 And so, I wouldn't expect that sort of
16 sub-binning to happen, but if you can talk about
17 physical characteristics of the cabinet, what was in
18 there, and how much was available to burn in there,
19 then maybe we could subdivide these things out to
20 something that can be, then, tied back to the
21 experimental evidence and have a reasonable review of
22 that material.

23 CHAIRMAN STETKAR: Okay. Maybe I'll let
24 you get through your slides here. Because I kind of
25 want to really understand where you're up to. Because

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 you're right, it's not a simple -- I mean, you know,
2 the industry has been very, very critical, at least in
3 the report, of the sort of disjoint nature of some of
4 the tasks in 6850, and the fact that the frequency
5 data are not necessarily coupled to the fire growth
6 rates, coupled to the peak heat release rates, et
7 cetera, et cetera, the things we have been talking
8 about. And therefore, a more integrated focus on
9 understanding the operating experience and the test
10 results is required.

11 And that sounds very reasonable, but I
12 would like to understand how that's going to be
13 implemented. Because, so far, I'm hearing a little
14 bit more of just the disjoint stuff.

15 MR. TRUE: Yes. Let me take a little bit
16 of a run on this because I think I may have slides --

17 CHAIRMAN STETKAR: Go ahead. Because, in
18 particular, that second bullet seems to give me the
19 impression that the fire events database is going to
20 give me information on peak heat release rates for
21 different cabinet types. And I'm curious how it is
22 going to do that.

23 MR. TRUE: No. The second bullet is a
24 different thing. The first bullet and its sub-bullets
25 relate to the FEDB. And the FEDB will, by the end of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 next year, have ignition frequencies. The manual
2 suppression data is collected and could also be
3 equally updated in a similar timeframe.

4 What I meant by the sub-bullets on fire
5 growth and damage is that, because we're getting a lot
6 higher-quality information for these more recent
7 events, and we're going back and collecting data on
8 even the 1991 through 200 data, we should get a better
9 picture of the events that actually occurred than we
10 have right now, looking at those cryptic descriptions
11 in the fire events database.

12 And that will inform us more, I think, on
13 fire growth and the kinds of damage that we saw from
14 those fires. So, we have an electrical cabinet fire
15 of a certain kind. It lasted 10 minutes, and damage
16 was limited to this. It lasted five minutes and it
17 extended to this point.

18 That will help us draw the picture of
19 what's really happening out there, I think, because we
20 have a reasonable number of events that we will be
21 able to draw from, probably on the order of 50 to 100
22 events, I would think.

23 CHAIRMAN STETKAR: Twenty-four and a half,
24 according to your slide No. 5.

25 MR. TRUE: Well, 24.5 in the data that we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 have in hand, plus another 10 years' worth of data.

2 CHAIRMAN STETKAR: Okay. Okay.

3 MR. TRUE: You would expect at least
4 another 24.5.

5 (Laughter.)

6 Although we're getting rid of halves --

7 CHAIRMAN STETKAR: Not a thing is getting
8 better every year?

9 (Laughter.)

10 MR. TRUE: We're getting rid of halves, I
11 think, though. Maybe we'll only have 24.

12 (Laughter.)

13 But I think that the 24.5 is actually more
14 than 24 events, of course.

15 CHAIRMAN STETKAR: That's fine, but --

16 MR. TRUE: So, you know, 50ish or
17 something. There will be information, and having
18 higher-quality data, that gives us more of a picture
19 of what happened, maybe even including more
20 photographs -- I know some of the CRs coming in are
21 now including photographs, which is helpful. I think
22 we will be able to inform that. I don't see that in
23 the timeframe you are looking at necessarily informing
24 heat release rates at all.

25 The second activity is an analytical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 activity.

2 CHAIRMAN STETKAR: Okay.

3 MR. TRUE: And that's what Rick was
4 talking about.

5 CHAIRMAN STETKAR: Okay. Okay.

6 MR. TRUE: So, just to distinguish these
7 two.

8 CHAIRMAN STETKAR: Okay. Thanks.

9 MR. TRUE: Sorry, Pat. I didn't mean to
10 cycle you there.

11 MR. WACHOWIAK: So, I think Doug had this
12 slide earlier, and he was showing some aspects of it.

13 But what we intend to do with the heat release rate
14 report is to provide, if you will, a replacement for
15 this table, so that it could be used in the same
16 methodology as 6850, however, has more discrimination
17 than simply these five rows.

18 And one of the intents here was to provide
19 something in the near-term that can be used by the
20 current fire PRAs that are out there without having to
21 do a revamp of the entire thing. So, more of a plug-
22 in-type module, if you will.

23 So, in order to do that, we needed to
24 limit the scope on this to a few things. One, we have
25 data on vertical cabinets. We are only looking at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 vertical cabinets. We're not trying to expand it
2 outside that.

3 We're not looking at other external
4 factors such as detection or the suppression
5 probabilities or anything like this. It's just
6 addressing what happens to the peak heat release rate
7 in the cabinet, based on the characteristics of the
8 cabinet itself. It would be a drop-in replacement for
9 these distributions that are in 6850. That was the
10 intent of the report.

11 So, a couple of things that we end up
12 doing here is, first, we look to see from the
13 experiments. Once again, we basically use the same
14 experimental base that 6850 used. Looking at the
15 experiments that were done, 6850 was able to
16 discriminate between qualified cable fires and
17 unqualified cable fires. We looked for other things
18 that could maybe separate the different
19 characteristics of the fire, and we really didn't find
20 that. So, we ended up retaining the qualified versus
21 non-qualified cable discriminator.

22 But what we did notice is that, for the
23 qualified cable fires in the experimental basis, we
24 really didn't have anything that propagated outside
25 the cabinet or didn't have anything that propagated

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 outside the cabinet and there really were very few
2 that propagated inside the cabinet.

3 So, I guess I should back up. There was
4 one of the tests that had outside-the-cabinet effects.

5 So, part of what the report does is it makes the
6 distributions for heat release rate for the qualified
7 cables look more like a distribution that's anchored
8 to the peak heat release rate tests that were done in
9 qualified cables. Make sense?

10 So, the distribution that comes out of
11 this for the qualified cable-type cabinets would have
12 the upper bound more around the peak heat release
13 rates that Doug showed on the earlier slide. So, that
14 98th wouldn't be way above the data. It would be
15 closer to where the experimental data was, recognizing
16 that those experiments were done with the intent to
17 try to make the big fire in the qualified cables.
18 Okay?

19 CHAIRMAN STETKAR: So, all you're doing is
20 going back to the 4527, whatever it is, experiment
21 published results and, essentially, refining the
22 binning?

23 MR. WACHOWIAK: Refining the binning to
24 include characteristics that we think that the people
25 performing fire PRAs would have, information that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 people performing fire PRAs would have.

2 CHAIRMAN STETKAR: Is there no effort to
3 go out and try to find additional data for cabinet
4 fires that might provide more recent information or
5 somewhat relevant information? I don't know where
6 that data may be, but --

7 MR. AMICO: Paul Amico.

8 CHAIRMAN STETKAR: Those tests were
9 relatively old and there aren't a lot of them. So,
10 trying to develop more insights from them might be
11 relatively difficult.

12 MR. AMICO: Yes, Paul Amico from SAIC.

13 Yes, we actually have data from tests from
14 IRSN which were more recent. So, we ought to add it
15 to the -- you know, we have the VTTC tests, we have
16 IRSN tests. I think it was Carmello was one of the
17 ones. So, we have more information and we have more
18 that we used.

19 And the key to this is an analytical
20 approach. Quite frankly, we have a model. Okay?
21 It's an analytical model that was actually developed
22 elsewhere.

23 What we have done is we have looked at
24 that analytical model and plugged in, I guess if you
25 will, plugged in the characteristics of the cabinets

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that were tested to see if the model reasonably,
2 accurately predicted the results of those tests. And
3 we've been able to show that.

4 So, now what we are doing is we are
5 saying, okay, what are the important things in the
6 analytical model? And it turns out there's a couple
7 of different things.

8 The focus really, we are doing the open
9 cabinet fire, but the focus is really on the closed
10 cabinet --

11 CHAIRMAN STETKAR: Step back from the
12 microphone a little bit.

13 MR. AMICO: Okay. Sorry. I can't even
14 hear it from here. So, is that working?

15 CHAIRMAN STETKAR: Yes.

16 MR. AMICO: The closed cabinet, primarily
17 closed cabinet fires, in looking at the ventilation,
18 what we found is that primary parameter in these fires
19 is the amount of air, the actual amount of air you can
20 get into the cabinet. And it is a function of the
21 total vent area and the ratio between the inlet vent
22 area and the outlet vent area. And also, it relates
23 to the height of the cabinet.

24 So, what we have been doing is we are
25 looking at the actual test results and what we know

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 about the cabinets, does this model reasonably well
2 predict that? The answer is yes. You do find out,
3 also, that there's really a theoretically upper limit,
4 you know, based on the parameters of the cabinet. No
5 matter how much combustible you have, you can only get
6 so far in heat release rate.

7 The issue we're dealing with now is we
8 have done some work in turning that into
9 distributions. We have got a lot of comments from
10 peer reviewers, and a couple of the peer reviewers are
11 in the room, about how we turned those into reasonable
12 distributions. So, we're still working on that aspect
13 right now.

14 What we're comfortable with is that we can
15 get a point estimate based on these parameters that
16 seems to make sense. So, that's where we are right
17 now with that. We have probably got a few more
18 months' worth of work, but, essentially, that is where
19 we are headed with it.

20 And what we have developed is a series of
21 tables for different cabinet heights, different total
22 ventilation areas, qualified and unqualified cable,
23 whether gap formation occurs or not because that
24 changes the ventilation. So, that's kind of where we
25 are now in this process, and that is the major

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 distinction really that we have been find, is this
2 ventilation.

3 And the ventilation-limited fires is the
4 major bin, I guess. If you're going to say created a
5 mass of bins, these bins are all related to
6 ventilation-limited fires.

7 CHAIRMAN STETKAR: Okay. Let me ask you a
8 little bit. So, what we're doing is developing a
9 model, another fire model, what I tend to call fire
10 physics models, that we're trying to benchmark by a
11 few limited data points. What is this model? I mean,
12 what are you using? I don't know if Paul is here.

13 Where I'm headed is one of the concerns
14 that has been expressed about the entire NFPA-805
15 transition process is that people are using models;
16 people are not too clear about what that phrase means,
17 but people are using models that have neither been
18 validated nor benchmarked against actual performance.

19 And therefore, how can you rely on models?

20 I hear good things about, gee, we want to
21 make the fire PRAs consistent with actual operating
22 experience -- that's really good -- actually real test
23 results. That's really good. Now I'm hearing, well,
24 we're going to use another model to develop analytical
25 results. Has that model been validated? Has it been

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 benchmarked against independent test results? Has it
2 been peer-reviewed or now we are going to have new
3 results that are subject to yet more uncertainty about
4 a different modeling method? Is it one of the CFD
5 models that have been, indeed, validated and verified?

6 MR. AMICO: It's pretty much an equation.

7 When you say, "Is it validated?", I said what we did
8 as best we could is we said, if I take the tests we
9 have, and admittedly, all right, there's not a million
10 tests out there, but if I take the tests we have and
11 look at the information about the cabinets, the
12 description of the tests, and I put in those
13 parameters into this equation, I can show that
14 matches, reasonably well matches the limited test data
15 we have. Okay?

16 The prediction of the model and the test
17 results are reasonably correlated. That's what I can
18 say.

19 Admittedly, how many tests we have, you
20 know, closed door, ventilation-limited fires where no
21 gap was formed, I think we had seven or something like
22 that. So, basically, we have done what can be done, I
23 guess is what I can say.

24 And then, that's the other thing. We are
25 going through a process; EPRI has formed a methodology

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 peer review group for fire PRA methods of very senior
2 experienced people, and we are going through that
3 process right now. It's a new process EPRI has put in
4 place for all the methodology development where we go
5 through an independent peer review, just like a fire
6 PRA would, but this is focused on methodology, and we
7 bring people together and we go through an independent
8 peer review and we address those comments. And that's
9 all documented as part of it.

10 MR. WACHOWIAK: Right. And one of the
11 objectives of the peer review in this case is to come
12 to a conclusion that, in fact, the model is validated
13 by the test, the experimental test, that we had in
14 hand.

15 So, this particular one, Paul says it is
16 an equation. Essentially, it is a limited number of
17 parameters that can be used to determine what is the
18 peak heat release rate from a cabinet that has so much
19 fuel, so much ventilation. It is, by no means, a CFD
20 model or anything like that.

21 CHAIRMAN STETKAR: Okay. You know, when
22 people say all models are equations eventually, but --

23 MR. WACHOWIAK: Right. So, in essence,
24 what we're trying to do is take information that the
25 fire PRA practitioner would have from going and doing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 a walkdown in the plant and relating that to what type
2 of experiment could have been done to generate the
3 upper-bound peak heat release rate and what would that
4 peak heat release rate be.

5 Then, it boils down to a series of tables
6 where you say, what's the cabinet volume? Is it a
7 densely-populated cabinet or a sparsely-populated
8 cabinet? And, then, there are some estimates on what
9 is the fuel loading that are in there, in that
10 cabinet, of that particular volume. That goes into
11 the equation to determine what is the maximum
12 theoretical heat release rate from this cabinet, which
13 relates back into the equation. Then, you look at
14 what is the ventilation on the cabinet, as Paul said,
15 inlet area, outlet area, and the ratio between those.

16 And we think we can fairly accurately represent what
17 the upper-bound peak heat release rate from that type
18 of configured cabinet would be.

19 CHAIRMAN STETKAR: We're running a little
20 long, but this is something everybody points to, and
21 it's worth discussing, I think.

22 I might have missed something, but in all
23 of the parameters I heard you talking about I didn't
24 hear anything about energy content of the equipment
25 inside the cabinet. I recall somebody calling me

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 after the San Onofre fire and saying, "Gee, our EPRI
2 models would have never predicted that level of damage
3 because there wasn't enough combustible material
4 inside there," completely disregarding the fact that,
5 for example, when large high-energy switch gear
6 creates an arc, you're not necessarily combustible-
7 limited.

8 So, for example, I'm not hearing any of
9 that type of thought process. So, how are you
10 accounting for that across the complete spectrum of
11 those elusive cabinets that I have that go anywhere
12 from a little picture of the fire protection cabinet
13 that we had yesterday morning to 6.9-kV switchgear,
14 non-high-energy arcing faults, but still internal
15 flaming?

16 MR. WACHOWIAK: Right. And I wanted to
17 say that this does not address high-energy arcing
18 faults.

19 CHAIRMAN STETKAR: No, no. Okay. I'll
20 discount that, but, I mean, the notion of counting up
21 inventory and combustible loading isn't the whole
22 problem, is it, in terms of rate of growth of fire?

23 MR. WACHOWIAK: You need to have an
24 estimate of what is the combustible load within that
25 cabinet. And the report attempts to make a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 correlation between the volume of the cabinet and
2 essentially it's a judgment base, but how much -- is
3 there a lot of cable in there or is there not a lot of
4 cable in there? Because we are not going to actually
5 go and measure the mass of things inside of a cabinet.

6 You have to rely on judgment to figure out what that
7 is.

8 And there is a section in the report that
9 describes how you relate volume versus your judgment
10 of how densely populated the cabinet is to a parameter
11 that actually specifies what is the heat load that is
12 going to be in the cabinet. So, we attempt to do what
13 you're saying there, but it still requires judgment of
14 the user of the model to do that, and we really don't
15 expect people to be going out and actually physically
16 measuring some of these characteristics that you need
17 to put into the equation to get the peak heat release
18 rate.

19 So, there is an attempt to do that, and
20 that part of it is under peer review right now. The
21 main comments that we have gotten back on that
22 portion, though, is it still looks like it's hard for
23 a PRA, a fire PRA modeler, even to get this type of
24 information. How do we know that it is going to be
25 consistently applied when you go from plant to plant?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 So, that is an important part of all
2 these, is usability of these models and making sure
3 that they can be duplicated from plant to plant.

4 CHAIRMAN STETKAR: Okay.

5 MR. WACHOWIAK: So, I think in a
6 roundabout way we have covered everything that is on
7 this slide.

8 MR. TRUE: Yes. We just tried in this or
9 I just tried in this slide to say, okay, we raised a
10 number of issues in this presentation from the
11 ignition frequency to response. I think that the FEDB
12 is going to help us with a couple of these directly.
13 It will give us some information related to growth and
14 damage.

15 The heat release rate work that Rick and
16 Paul talked about is going to give us some direct
17 information on heat release rates and damage. It may
18 give us some indirect inference on growth rates and
19 indirectly will influence the operator response.

20 So, it is certainly not a comprehensive
21 way to address every one of them, but we've got
22 something going on that will directly address most of
23 this, and it should improve the overall realism of the
24 electrical cabinet work.

25 CHAIRMAN STETKAR: Okay. Any other

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 questions for Rick and Doug? If not --

2 MEMBER POWERS: Let me ask a question. I
3 guess I have two questions. One, is there anything
4 unique about electrical cabinets in nuclear plants
5 relative to electrical cabinets anyplace else? I
6 mean, you can see, essentially, I'm asking the
7 question, is there another database that you can go
8 tap?

9 The other one is you're struggling
10 heroically to scale experiments up to specific
11 applications, and I don't see the kind of detailed,
12 let's call it CFD, but I'm sure CFD is not the type of
13 modeling to do that scaling, is there anybody doing
14 that? I mean, do we have faculty members at
15 prestigious universities in America struggling over
16 how you model heat releases and chemical reactions in
17 cabinets? I mean I know they do it for chemical
18 reactors, but those guys have more money than you do.
19 So, maybe they know what it is.

20 (Laughter.)

21 But is there anyone doing that kind of
22 stuff that would provide some sort of a framework for
23 -- the problem is your data is sparse and you need
24 some way to know how to take data and extend it to
25 situations that will never get tested. I am just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 asking, is there anybody doing that kind of stuff?

2 MR. WACHOWIAK: I'm not aware of that.

3 MEMBER POWERS: I'm not, either. I mean I
4 plow around that literature, but I never run across
5 anybody doing that, but maybe because I don't get out
6 much or something like that.

7 MR. WACHOWIAK: What would be very useful
8 for this would be to have something that tests the
9 low-end fires.

10 MEMBER POWERS: Yes.

11 MR. WACHOWIAK: Because once you get
12 beyond a certain threshold, we're burning up
13 everything in the room in the theoretical array model
14 anyway. And having a lot of detail at that end --

15 MEMBER POWERS: It doesn't help.

16 MR. WACHOWIAK: -- it doesn't help us.
17 But, as we found in the experiments that we have now,
18 those are tricky.

19 MEMBER POWERS: Yes, and worse than that
20 is that in this kind of -- it almost doesn't go kind
21 of regime, you get a test and it gives you a result,
22 but what you want to know is what's the whole possible
23 range of results there.

24 CHAIRMAN STETKAR: Yes, have you thought
25 at all about there's greater or lesser support for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 notion of expert elicitation in different communities.

2 MEMBER POWERS: Oh, you and your expert
3 elicitation.

4 (Laughter.)

5 CHAIRMAN STETKAR: I said there are
6 greater or lesser support for the notion of expert
7 elicitation. It sort of ranges across the table here.

8 MEMBER POWERS: Just what I need, more
9 wrong answers.

10 (Laughter.)

11 CHAIRMAN STETKAR: Well, we've had a lot
12 of wrong answers.

13 (Laughter.)

14 MEMBER POWERS: It's a distribution
15 problem.

16 CHAIRMAN STETKAR: Now you have a better
17 distribution at least.

18 Seriously, people have used expert
19 elicitation for focus topical areas in PRA rather
20 extensively. Reactor coolant pump, seal failures,
21 we're all familiar with that; seismic hazard analysis,
22 and in some sense a seismic fragility analysis.

23 MEMBER POWERS: Don't portray this as a
24 virtue of PRA.

25 CHAIRMAN STETKAR: Hum?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: Don't portray use of
2 expert opinion elicitation as one of the virtues of
3 PRA. It may be a necessity. It sure brings a lot of
4 details of inapplicable calculations.

5 (Laughter.)

6 CHAIRMAN STETKAR: Hold on a second, Ken.
7 Let me just kind of finish the thought here.

8 Have you thought at all about doing that?
9 I mean in the same sense of convening industry, and
10 I'll include staff; I'll include universities, for
11 example, experts to look at something like a -- I
12 don't know what you want to call it. You could call
13 it a fire hazard set of curves or something like that,
14 in lieu of some of these other approaches you're
15 taking, recognizing that would be informed by what
16 limited actual operating experience we have available
17 and the limited test data available. Have you thought
18 about doing that all?

19 As I said, there's varying levels of
20 support for it, but --

21 MR. WACHOWIAK: I'll let Ken answer that,
22 and then I have a little bit to offer there. It won't
23 answer your question, though.

24 MR. CANAVAN: Yes, I'm chiming in because
25 your question is historical, and Rick is a little

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 newer. This is Ken Canavan.

2 We had some very detailed discussions
3 about the possibility of expertly eliciting some
4 information. If you look at what Steve and the 6850
5 crew did in the original study, that is essentially
6 what they did. Their expert elicitation was extremely
7 informal on a smaller group.

8 But I will say that in this current
9 environment we have discussed the possibility of that
10 being considered an acceptable approach. I'll point
11 out that, even now, when Paul and Rick gave their
12 discussion of heat release rates, right away we start
13 questioning, well, you're using a model; how do I know
14 this is not going to be just another question model?
15 We came to the conclusion that stuff where we have a
16 model and some judgment is much better than a process
17 where we had just judgment to extrapolate the data,
18 even if it was replacing other judgment.

19 Because the problem was getting that
20 second judgment accepted universally without
21 significant effort. So, I guess I'm going towards
22 Dana's point where expert elicitation replacing an
23 older judgment would come under even more scrutiny as
24 to why that one is right.

25 So, we were better off where we had models

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 with limited judgment and some experimental data. So,
2 essentially, heat release rates is our first foray
3 into what I would call sort of hybrid, where we are
4 using some judgment, but we have a good model and some
5 points, and that's where we want to use our judgment
6 the best. That was our conclusion of our research
7 dollars spent.

8 CHAIRMAN STETKAR: Okay.

9 MEMBER POWERS: Yes, but I mean it is not
10 bad idea. It is that you can use expert judgment on
11 things like heat transfer coefficients where it can be
12 triggered by experiments; whereas, before you had to
13 ask them what's the possibility you will burn up a
14 cabinet that they have never seen before.

15 MR. CANAVAN: Yes. There's reasonable
16 assurance when there's data points that you can point
17 to that at least you correlate to the existing data,
18 even if it is sparse --

19 MEMBER POWERS: Yes, much better.

20 MR. CANAVAN: -- over just judgment. That
21 is changing, and I will give it back to Rick because
22 Rick's driving the future research here. So, he
23 probably has a few points.

24 MR. WACHOWIAK: Right. One of the things
25 that we are trying to do for things going forward is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to introduce more expert judgment, opinion. It
2 depends on what you're actually doing with it.

3 But when we are reviewing the different
4 methodology reports that are going out or when we are
5 reviewing the newer test data that is out there, we
6 are convening panels of experts. And there's a
7 presentation on this later on, but we should be
8 getting to it.

9 CHAIRMAN STETKAR: Okay.

10 MR. CANAVAN: But we are convening the
11 groups of people that have experience in these areas
12 and can do an informed judgment review of things that
13 are based on a model or based on an experiment. So,
14 we are trying to inject that idea into the things that
15 we are doing now and going into the future. I don't
16 know of anything that we have on the matrix right now
17 where it is we are just going to be -- like Ken said,
18 we will just be replacing an older judgment model or
19 an older judgment with a newer judgment in a sense.
20 But we are trying to use the judgment where it looks
21 like it's reasonable. To me right now, that is in the
22 independent review phase of these things.

23 And for the experiments, I think we can
24 use it some, too. For other experiments, you use it
25 upfront to help design the experiment, to make sure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that the experiment itself matches what it is we are
2 trying to get out of the data in the end.

3 So, there are places where we are trying
4 inject it into there, but not as a wholesale --

5 CHAIRMAN STETKAR: A formal expert
6 elicitation type --

7 MR. WACHOWIAK: Yes.

8 CHAIRMAN STETKAR: Okay. Any other
9 questions? Dana, I think you said two. I don't
10 remember whether you asked --

11 MEMBER POWERS: I covered both.

12 CHAIRMAN STETKAR: Okay.

13 MEMBER POWERS: I got them both out.

14 CHAIRMAN STETKAR: Anything else for Rick
15 and Doug?

16 If not, thank you. That was -- oh.

17 DR. WEERAKKODY: This is clearly now a
18 question for them. Through all the presentation, I
19 know, John, you mentioned at least once that you are
20 going to have some questions for the staff.

21 CHAIRMAN STETKAR: Sure.

22 DR. WEERAKKODY: I just hope we'll get
23 that opportunity whenever you want it.

24 CHAIRMAN STETKAR: Well, according to my
25 agenda here, as soon as the esteemed duo at the front

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 table vacant the process, I have an NRC presentation.
2 And again, I hope this is not just Steve Nowlen as an
3 independent contractor. I really would like to hear
4 from the staff at some time or another. Whenever
5 there's some actual card-carrying staff members
6 upfront, I'm sure we're going to have questions.
7 Anybody at all can sit upfront.

8 MR. NOWLEN: Okay. I think the caucus is
9 that I will go ahead through my prepared presentation,
10 and then you're going to hear from staff. But what I
11 have prepared is directly relevant to what you have
12 just seen. So, it seems reasonable to take that
13 approach.

14 Just for the record, my name is Steve
15 Nowlen. I'm from Sandia National Labs. These are my
16 views as an author of the NUREG CR-6850/EPRI
17 TR-1011989. And in this case, I'm also a coauthor of
18 the Sandia electrical cabinet fire test that they have
19 been talking about here, which dates me because that
20 goes back to 1985. I was pretty young then.

21 CHAIRMAN STETKAR: As we all were.

22 MR. NOWLEN: Yes.

23 Okay. So, I'm going to skip a bit of this
24 because a lot of it has already been covered. I think
25 we have talked about this slide. Why do we care about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 fires? We have talked a lot about that already. I
2 don't need to go into this in detail.

3 But one of the things to point out is that
4 the variables that we are dealing with here are
5 substantial. You know, we have function, control
6 power distribution, switching, junction boxes. It's
7 all there. We have voltage levels, anything from less
8 than 50, which is instrumentation, to over 100 kV,
9 your offsite power stuff. Physical configuration,
10 size, construction, venting, you know, there's such a
11 range here. The fuel loading, what's in there?
12 What's inside of motor control center is very
13 different from what's inside of a main control board.

14 So, we have to deal with that. We understand it is
15 difficult because the range is very broad.

16 The event data, I'm not going to go into
17 this very much, either. We talked a lot about this.
18 I think one of the questions that Dr. Powers raised
19 was relative to other industry data. We made an
20 attempt to do that in the early stages of the methods
21 developing work and basically came up empty.

22 We complain about our data. We should be
23 really grateful that we have the data we have.
24 Because if you go to general data sources, it is much
25 rougher and it is very, very difficult.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 We tried to use it to gain sort of
2 qualitative insights of the nature of these fires.
3 That didn't work at all. We gave up very quickly on
4 getting any statistical frequency-type things because
5 there's absolutely no idea what the population is
6 represented by any database. You go to NFPA. Well,
7 how many sites does that represent? It's the whole
8 country nominally on a voluntary reporting basis. So,
9 anyway, there are some real issues there. I don't
10 want to belabor the data too far.

11 I do want to talk a little bit about this
12 because I think it will give you an idea of what data
13 we do have from the testing. There are really three
14 sources. A lot of focus on the NRC tests. There were
15 more individual tests in that series than any of the
16 others, but there's also testing from VTT in Finland
17 and the IRSN data was mentioned as well.

18 At the time that we did 6850/1011989, we
19 did not have access to the IRSN data. They wouldn't
20 give it to us yet. I believe they have recently made
21 that available. So, that's an improvement.

22 But one of the things you have to be a
23 little cautious of is, and this is a theme I'm going
24 to hit on here, is that you have to bring a
25 perspective of understanding fire phenomena and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 experimentation when you look at these tests. Okay?
2 You can't just -- you know, the slide that shows all
3 the tests down below 100 kilowatts and, also, the 98th
4 percentile, well, there's a reason for that. Okay?
5 And I will try and explain that.

6 But I will give you an example on the
7 IRSN. The IRSN tests were not real control cabinets,
8 not real cabinets of any type. There are basically
9 welded-up steel boxes with a control side vent in the
10 top and a control side vent in the bottom, and inside
11 of that, for most of the tests, are PMMA, polymethyl
12 methacrylate, slabs with a little acetone to get them
13 started.

14 What the French were trying to do is
15 develop this chimney model of fires. So, they wanted
16 rigidly-controlled ventilation conditions, right? So,
17 this box is fully welded. And then, they would vary
18 the inlet size, vary the outlet size.

19 So, when you interpret that and you take
20 that to a real cabinet, what does it mean? Well, it
21 tells you, if you had rigidly-controlled ventilation
22 conditions, this is what would happen, but in real
23 cabinets we don't have rigidly-controlled ventilation
24 conditions. So, when you try to extrapolate from the
25 French data and say, see, my model matches, so, well,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 fine, you match what happens to a welded steel box,
2 but not necessarily a cabinet. And you have to bring
3 that perspective into your assessment.

4 The VTT tests are another one that are
5 interesting, in part, for the same reason. This was
6 Olavi Keski-Rahkonan, and I will provide that to the
7 transcriptionist separately.

8 (Laughter.)

9 Olavi was an incredibly analytical
10 individual, a college professor. I mean he loved
11 equations that just went on for pages.

12 And Olavi tried to do the same sort of
13 thing. He was actually burning more realistic
14 cabinets, and he tried to take the ventilation
15 conditions at the inlet and the outlet and do a very
16 detailed analytical model of the chimney flow and what
17 the maximum heat release rate would be. It didn't
18 work because, again, we don't have this rigidly-
19 controlled configuration.

20 So, again, looking at the data and
21 understanding what you're looking at and how you
22 should interpret it is really, really important.

23 The other thing you have to recognize is
24 that every single one of these tests was aimed at
25 control panels. I don't have a single test of a load

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 center, switchgear, MCC. So, what we have to do is
2 take the information that we have for the cabinets
3 that we have tested, control cabinets, and try and
4 extrapolate to these other conditions because we know
5 that out in the plant chances are you're going to be
6 far more interested in load centers, motor control
7 centers, switchgear, things of that nature.

8 CHAIRMAN STETKAR: Steve, let me ask, and
9 you reminded me of something that I wanted to ask EPRI
10 and the industry and I keep forgetting.

11 We have seen results from, at least in our
12 presentations, from six different fire PRAs --

13 MR. NOWLEN: Yes.

14 CHAIRMAN STETKAR: -- all of which show
15 electrical cabinet fires as a measurable contributor.

16 In practice -- and I'm asking folks who are sitting
17 behind me -- in practice, what locations in the plant
18 are driving those results? Are they switchgear rooms?

19 Are they instrumentation and control cabinet rooms?
20 I'm assuming they are not the main control room
21 because that is a separate fire ignition category.
22 So, it is not main control board fires, but are they
23 cabinet fires in main control rooms, electrical
24 cabinet?

25 So, from the results of those three types

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of areas, which are the more important?

2 MR. NOWLEN: I'm absolutely unable to
3 answer your question.

4 CHAIRMAN STETKAR: That's why I'm asking
5 people sitting behind me.

6 MR. NOWLEN: Yes.

7 MR. MISKIEWICZ: David Miskiewicz.

8 For the early models we have done with
9 Harris, it was pretty much control cabinet-type issues
10 that were driving.

11 CHAIRMAN STETKAR: Okay. So, I&C cabinet
12 rooms?

13 MR. MISKIEWICZ: We had some high-energy
14 arcing faults do something --

15 CHAIRMAN STETKAR: Yes.

16 MR. MISKIEWICZ: -- but those are limited
17 and they are easier to understand.

18 CHAIRMAN STETKAR: Right, right. But
19 we're not talking about motor control center or load
20 center fires or --

21 MR. MISKIEWICZ: In a case-by-case basis,
22 you may, but it is because of the control circuitries
23 associated with some of those, not necessarily -- you
24 know, MCCs may have a lot of wires going to them. If
25 the fire gets out of them, you may have issues.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Well, I guess I'm still
2 trying to struggle. In general, when I look at power
3 plants, there are always some exceptions, but there
4 are rooms that are primarily what I call switchgear
5 rooms that have 4-kV switchgear, 40-volt motor control
6 centers, some load centers in them. Those rooms
7 typically don't have I&C cabinets in them.

8 MR. MISKIEWICZ: Sometimes they have
9 transfer panels.

10 (Laughter.)

11 CHAIRMAN STETKAR: Okay. And that's okay.
12 It's a good point. Back to the plant-specific nature
13 of things here, obviously.

14 (Laughter.)

15 But other rooms are typically I&C cabinet
16 rooms. You know, protection control cabinets. You
17 typically don't see motor control centers in those
18 rooms. And, of course, the control room has control
19 boards and other primarily I&C cabinets.

20 And I was more curious from the actual
21 experience from the PRAs, if I can characterize the
22 rooms that way, where are we seeing these problems?
23 You know, what's driving that ridge line?

24 MR. MISKIEWICZ: It's a mixed bag.

25 CHAIRMAN STETKAR: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MISKIEWICZ: In my most severe cases,
2 we're going to involve the control cabinets and those
3 types of things. However, switchgear rooms, depending
4 on your plant's design, they have a lot more cabinets.

5 When you add up the effects of a lot of more
6 cabinets, then those add up.

7 So, depending on your plant, one plant may
8 have all its switchgear in one room, like Harris.
9 Other plants divide it up with 4160 or -- so, you'll
10 see some variation. But when you have a lot of stuff
11 in one room, that room tends to be a large
12 contributor.

13 CHAIRMAN STETKAR: Yes, but, look, Kiang
14 is standing. So, I'm assuming he's going to give us
15 other insights. Or are you just standing?

16 MR. ZEE: I was going to say I think,
17 because of plant design details, I think it is less so
18 an issue of spatial issues. I think it's more in
19 terms of what the ignition sources are.

20 So, if you think in terms of the I&C
21 cabinets you're describing, I mean what tends to
22 happen is a practical matter of how these plants are
23 all designed because they had to meet the same failure
24 criteria, and they have these logics that are one out
25 of two taken twice. You have a lot of these panels

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that have to have cross-connected wiring between
2 divisions. Just that was the nature of how the plants
3 were designed.

4 Now what that means is -- and this is
5 something we touched on a little bit earlier -- when
6 we take an electrical cabinet fire, it is very
7 difficult to distinguish the nature of how the fire
8 progresses within the cabinet. So, once that fire
9 happens within a cabinet, you oftentimes have cases
10 where you have cross-divisional impacts. And from a
11 practical standpoint, there is no way to get out of
12 that.

13 Now when I get to an MCC, the same issue
14 arises. We talked earlier about, well, we had an MCC
15 fire. Do we take MCC failure? Well, that's correct.

16 But at the same time, what tends to happen is you
17 have a race between valves that are powered from that
18 MCC. Does the fire behave in such a fashion that I
19 cause certain valves on an MCC to spuriously operate
20 before power is lost? And in a lot of instances,
21 single-train divisional upsets create some problems.

22 CHAIRMAN STETKAR: Okay. Thanks. That
23 helps.

24 The reason I asked is I was trying to
25 understand a little bit better -- Steve brought up the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 fact that there is a broad range of cabinet types,
2 different voltages, different applications, for
3 example, and the limited tests that have been
4 performed, their applicability to the broad variety of
5 things that we throw into that generic box that we
6 call an electrical cabinet.

7 Insights from the completed studies: for
8 example, if the primary concern was cabinet fires in
9 I&C rooms, those cabinets look very different than a
10 motor control center. So, for example, where one
11 might focus the effort to refine heat release rates,
12 refine growth times, for example, rather than just
13 saying we need to understand everything about
14 everything before we can do anything, is there a way
15 to better focus the efforts, based on at least the
16 preliminary results from a spectrum of PRAs that we
17 have been seeing?

18 And I guess what I am hearing is not
19 necessarily.

20 MR. MISKIEWICZ: Correct.

21 CHAIRMAN STETKAR: Okay. Thank.

22 MR. NOWLEN: I'm a little disappointed to
23 hear that. I was hoping for the same sort of thing.
24 That as we got more risk insights from the
25 applications, we would know where to focus our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 efforts. It sounds like it's pretty diffused.

2 CHAIRMAN STETKAR: Okay.

3 MR. NOWLEN: But, okay. Other things:
4 I've mentioned this before. The tests make no attempt
5 to suppress the fires. So, whenever you go and try to
6 compare a test to reality, you have to keep that in
7 mind. We don't stand around and wait for fires to
8 burn. We put them out.

9 I think the question came up about control
10 versus suppression. I believe that is a legitimate
11 consideration if you have a fire under control. That,
12 to me, says you have at the least limited subsequent
13 damage. Now, again, you've got to maintain control,
14 and we have fires where we thought we had it under
15 control; we lose that.

16 The main reason we didn't put that into
17 the suppression model now is that the events don't
18 tell you, you know, the fire was under control at this
19 time. They generally tell you we've got a detector
20 signal; it was out by this time. But that's what you
21 have.

22 So, again, maybe the new data will help us
23 there. One thing that was stated is, relative to
24 managed burnout sort of situations, if we saw that, we
25 did treat them differently. We would see it. For

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 example, the most common one was hydrogen tank fires.
2 They would just choose to let the fire burn until the
3 fuel was gone because it wasn't going anywhere. It
4 wasn't hurting anything. It was the safest thing to
5 do.

6 We treated those differently. Those were
7 taken out of the suppression because it is not
8 representative of what happens if you try and
9 aggressively put out a fire. So, they would be
10 removed from the suppression curve, but they would
11 count as fires. It was clearly a fire. So, those are
12 treated differently, but I think the control concept
13 is valid.

14 Basically, what the tests tell you is what
15 can happen if a fire grows unchecked in an electrical
16 cabinet. And how you interpret that data is really
17 important. The caution that I put forward is that
18 slicing of data too thin is going to lead you to
19 invalid conclusions.

20 We performed a lot of tests, okay, but
21 these early-phase tests, like all the ST1, ST2, those
22 were very, very limited tests. Like ST1 was a test to
23 see if the ignition source fuel package that we had
24 would ignite the cables from radiant heating. So, the
25 source was here, and the cables were over here. The

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 answer was no. So, it didn't propagate. It didn't
2 even ignite the bundle.

3 The second one was to take a smaller
4 ignition source and put it under a bundle and see if
5 that would propagate. The answer was we burned a
6 little of the thing, but it didn't propagate at all.

7 So, you know, again, when you look at
8 these tests, you can't just take them and say, okay,
9 this is the group that represents my cabinet, and
10 that's all I'm going to look at. It's just not the
11 right way to look at data.

12 What we did in looking at the events, and
13 what is left off of the plot that the industry folks
14 showed are the tests that drove the 98th percentile.
15 The biggest test that we had in these experiments, as
16 I said, were 1.5 to 1.8 megawatts. They were an order
17 of magnitude larger than these fires.

18 Now they eliminate them from the plot
19 because they are benchboards, right? Oh, I'm
20 interested in vertical cabinets; I'm going to throw
21 away the benchboards.

22 Well, a benchboard is not a vertical
23 cabinet, obviously. But does a benchboard test tell
24 you something about what might happen in a different
25 type of electrical cabinet, a vertical panel? In my

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 judgment, absolutely yes. You cannot ignore the fact
2 that we had 1.5-megawatt fires in unqualified cables
3 and 1.8-megawatt fires in qualified cables. There are
4 insights that have to be factored in.

5 What we saw with these tests is that there
6 is truly a threshold sort of behavior with these
7 things. If you get to a certain point, the thing will
8 spread and grow, and it is basically going to burn out
9 the cabinet. That is what the 98th percentile is
10 intended to represent. It is, if we cross that
11 threshold and we burn out the cabinet, what's it going
12 to look like?

13 Is it real? Absolutely, I think it is
14 real. Did ST1 and ST4 and 7? No, they didn't cross
15 the threshold, for various reasons. Each individual
16 test, there's different reasons. Some of them are
17 just the chaotic nature of fires. You know, that's
18 why we have distributions. I can build the same fire
19 in 10 experiments, and I get 11 data points. It is
20 that sort of a beast.

21 So, when we drew these curves -- and
22 again, what's missing is what drove the 98th
23 percentile, which is actually approximately 2.5 times
24 the 98th percentile value, which was ultimately
25 picked. I have a 1.8-megawatt qualified cable fire.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 I'm not going to use 1.8 megawatts for this case
2 because it was benchboard -- that's a difference --
3 and that particular test was open cabinet, right, no
4 doors, more of a control panel open back.

5 And so, we have to take that and say, what
6 would it mean if I had a different configuration? If
7 I had the vertical cabinet, if I had a closed door,
8 but good ventilation through that cabinet, what would
9 it be?

10 So, again, we extrapolate from the
11 knowledge that we have. We extrapolate from the
12 broader insights that we gain from the experiments,
13 though, as well. You can't just take these one, two,
14 three, eight or nine tests and put a distribution on
15 them because it doesn't reflect the broader insights
16 of the program. It doesn't reflect what might happen
17 if you cross that threshold.

18 So, that's my biggest problem with those
19 plots that you see. And I think if they are going to
20 go this way, you know, I'm all for it. Revisit the
21 distributions. I don't have a problem with that. But
22 they need to bring in a more experimental,
23 phenomenological expertise when they weigh these data
24 and try and gain the broader insights. I think that's
25 really lacking at this point.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 So, I will get off my high horse for a
2 minute. Where I think we could do better, these are
3 important, and I think improvements would be welcome
4 by everyone. A model linking the growth time between
5 the contents of the cabinet and the growth behavior,
6 that would be great.

7 One of the things that you see from the
8 testing, for example, is that it is easier to burn
9 kindling than logs, right? So, if you can see in your
10 cabinet and what you have is a very tightly-wrapped
11 bundle of large cables in the back corner that come in
12 and feed one large load center, for example, that's
13 going to be an incredibly different fire than what
14 these tests would reflect. It's going to be much
15 smaller. That is going to be a far harder one to
16 burn.

17 But the other point that comes in is I
18 have a more energetic ignition source there because it
19 is a load center and I have the power; I have the
20 voltage. I can get a pretty good ignition source,
21 right? So, how do we balance that? I'm not too sure.

22 The other thing that I think is the
23 empiric, and I probably should say semi-empiric model
24 of ventilation effects on peak heat release rate, that
25 was the work that they were referring, Paul Amico

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 referred to.

2 I saw a paper by Shawn Hunt at the NEI
3 Forum two years ago that was headed down this path. I
4 said at the time I thought this was a good path to
5 follow. Because what Shawn was trying to do was get
6 away from this idealized view of cabinets that the
7 French had in executing their tests and that Keski-
8 Rahkonan had in developing his model, and to try to
9 say what really happens for a more reasonable
10 representation of the cabinet, where the doors warp
11 and I open up new ventilation openings, the side will
12 warp away. Those are all issues. And I thought that
13 was a good approach. So, I am hoping to see more of
14 that.

15 And again, the idea is we know that the
16 purely idealistic model of the chimney doesn't work.
17 We need something to make the adjustment to reflect
18 the realities of cabinet. We don't have enough data
19 to do that, based on first order of principles, for
20 example. So, I think we have to make some empirical
21 adjustments to try to reflect the data.

22 But, again, when we match that to the test
23 data, you've got to be real careful about how you do
24 that. If all you can match are these scoping tests,
25 the very first tests in the Sandia matrix, you haven't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 matched the range yet.

2 I think these other approaches, the peak
3 heat release rate, are going to be difficult. Again,
4 you have this issue of you have to develop the broader
5 insights from the testing. And I think that is what
6 we did.

7 I mean I was an author on these reports.
8 I was there when we had this debate. We had other
9 fire experts who understood phenomenology and things.
10 We incorporated that into our judgment of what these
11 heat release rate profiles should be.

12 So, you can revisit that, but anyone comes
13 back to me and says, "I never have a fire that exceeds
14 100 kilowatts, so I'm going to call that one 98
15 percentile," I'm going to have difficulty with that.
16 If my opinion is asked, it is not going to be very
17 favorable. Again, I don't speak for staff, but I
18 don't think that is reasonable. So, I think that
19 particular approach a bit problematic.

20 The weld seal issue is another one that I
21 think actually could go somewhere. The approach that
22 I have advocated is that we can tie what we mean by a
23 weld seal cabinet, and a weld seal cabinet doesn't
24 propagate fires outside the panel, if we can tie that
25 to, for example, NEMA ratings of cabinets, that would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 be helpful.

2 There are certain types of NEMA cabinets
3 that are weatherproof, weather-resistant, weather-
4 tight, waterproof, general panels. Those all have
5 implications for this ventilation issue.

6 When we were doing 6850, we just didn't
7 really have the expertise to do that. So, we didn't
8 attempt it. I'm not an expert on NEMA cabinet
9 ratings, but I think the people in this room probably
10 are. So, I think that would be a good approach.

11 The incipient stage timeline that they
12 have talked about, we talked a little about this
13 yesterday. We resetting time zero. There's strong
14 interactions with the other pieces of the method. We
15 have to be careful that that's done right. Again, I'm
16 open to the concept in theory. In practice, it will
17 be a challenge.

18 And I think the other part, and I
19 emphasized this yesterday, so I won't dwell on it. We
20 have to look at the other potential drivers for risk
21 here. You have to do the cable response part, too.

22 If you fix the whole problem by fixing
23 heat release rates on cabinets, then you have simply
24 broken it in a different way, right? Now we have what
25 I would consider overly-optimistic cabinet profiles

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 because I didn't do the cable response and cable
2 damage part properly. I am doing that with incredible
3 conservatism, and I try to compensate for that in
4 optimism in another place. I think that is a bad
5 strategy going forward.

6 We need to fix both pieces, so that
7 together it matches frequency, the heat release rate
8 distributions, the probability that it gets out of the
9 cabinet, and then the likelihood that it damages the
10 fire and the suppression.

11 I have already mentioned this yesterday.
12 It is this interlocking set of steps, and you can't
13 just pick this one and fix it and make the whole
14 problem right. It is the wrong strategy. All the
15 pieces need to be worked together.

16 CHAIRMAN STETKAR: Well, although if,
17 indeed, there's evidence that one piece is
18 substantially -- I don't like the word "conservative"
19 -- substantially less justified by test or operational
20 experience than the others, you know, one would quite
21 naturally try to address that issue first.

22 MR. NOWLEN: Oh, absolutely.

23 CHAIRMAN STETKAR: You know, in a
24 resource-limited world that we live in --

25 MR. NOWLEN: Absolutely.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: -- we can't make
2 everything perfect.

3 MR. NOWLEN: Absolutely, and I'm not
4 advocating for that. I think risk insights, informed
5 approaches here are appropriate. It is just that we
6 are seeing these comparisons between what the PRA
7 predicts and what reality tells us, and they say it's
8 heat release rate. If that is the approach, then I
9 think that is wrong. You can't fix that problem by
10 attacking heat release rate alone, in my mind. And I
11 think the other piece that is really missing is this
12 cable damage piece.

13 CHAIRMAN STETKAR: You know, quite
14 honestly, I am not hearing that from the industry.
15 I'm hearing that it's problems across the board, as
16 you said. It is an integrated problem. On the other
17 hand, they seem to have some evidence that the heat
18 release rate estimates in NUREG CR-6850 may be high
19 for certain types of chem. I don't know whether they
20 are.

21 MR. NOWLEN: Yes.

22 CHAIRMAN STETKAR: You know, I didn't run
23 the tests. I didn't look at the data. So, it's just
24 a matter of I don't hear them saying they think that
25 the conditional cable damage probabilities, that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 hasn't been raised as a potential issue.

2 MR. NOWLEN: Yes, that's my problem, is
3 they're not looking at that and I'm not hearing about
4 it.

5 CHAIRMAN STETKAR: Well, but, on the other
6 hand --

7 MR. NOWLEN: And I want to know what's
8 going -- I don't know.

9 CHAIRMAN STETKAR: -- as a Subcommittee,
10 we have to take the experience of the people who are
11 doing the analyses. I would assume that if the
12 conditional cable damage probabilities were the
13 practitioners felt that they were driving the results,
14 I would assume we would have heard about that. We've
15 heard about an awful lot. That's not one thing we
16 have heard about.

17 So, therefore, right at the moment, it
18 seems to be less interesting to try to refine that
19 particular issue, recognizing that it, in the sense of
20 trying to estimate --

21 MEMBER SHACK: Well, it would be
22 interesting to know what they do use for conditional
23 cable failure probabilities.

24 CHAIRMAN STETKAR: Yes. Yes.

25 MR. ZEE: Yes, I think we have seen this a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 couple of times. We have explored it. I mean we have
2 looked into what treatment like THIEF would give us.
3 And what we are generally finding is the types of
4 situations that are giving us problems are not
5 situations that are solvable using THIEF.

6 I mean what we are generally finding out
7 is that our targets of concern, if you will, are well
8 within the zone of influences for even some of the
9 smallest of the fires in some of the smallest numbers.

10 When we talk about THIEF, I think Steve
11 made mention of 80 kilowatts. You could potentially
12 withstand that for upwards of an hour. I don't know
13 if that's exactly what THIEF tells you.

14 But what we do know is, when we do the
15 fire modeling code at a particular heat release rate,
16 we calculate, if you will, a so-called zone of
17 influence. If my target is on the fringe of that zone
18 of influence, we know there's time to damage. But we
19 also know that the target is well within that zone of
20 influence, that time the damage goes away very
21 quickly. And when we get into the flame region, all
22 the guidance we have been given is there's no
23 analytical to predict time to damage. Basically, it
24 dies almost instantaneously. And that becomes the
25 coupling, the coupling with a growth rate and a heat

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 release rate. And you're right, they're all
2 intertwined together.

3 CHAIRMAN STETKAR: But what I am hearing
4 you say is that the most difficult plant
5 configurations, you are driven by the fact that people
6 built these plants with cable trays located a foot or
7 less above the tops of cabinets, and that within those
8 cable trays there's a lot of really interesting
9 cables. Short of reconfiguring the plant, you are
10 left with that.

11 MR. ZEE: Well, I mean it makes logical
12 sense. I mean I have a safety-related MCC of lots of
13 very interesting components on it. By its very
14 nature, the cable tray above it is carrying those
15 cables. And once I design a plant that way, that
16 cable tray becomes the route that all the other
17 interesting cables tend to take.

18 MR. MISKIEWICZ: This is Dave Miskiewicz.

19 I have two comments responding to what he
20 said. One is we didn't use THIEF, but we actually did
21 use models of time to damage based upon distance from
22 my source and the heat release rate of the source.
23 And we did get some benefits from that. But, like I
24 said, most cases they're close enough in that it is a
25 matter of minutes, not an extreme thing.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The second piece talked about, is the heat
2 release rate the problem or are other things the
3 problems? And it is a combination, but I'm a
4 practitioner, not a researcher. I take the data that
5 is given and I'm trying to apply it.

6 So, the beginning of my problem is, what's
7 the set of equipment that has failed? That is all
8 driven by the heat release rate of my source and the
9 timing and the growth. So, we have to pick something,
10 whether I pick the first tray or the first two trays,
11 and it's never one tray or very rarely do I get the
12 nicest one tray and another tray. It's trays in
13 different in different directions, curving, bending.

14 So, what is really happening is almost an
15 impossible thing. So, we'll assume when a tray is
16 impacted, all the cables fail in a tray. We know it
17 is really the outside one -- or, actually, I don't
18 know.

19 So, we really struggle with that. So,
20 simple concepts like more cables probably means
21 ultimately bigger heat release rate. More oxygen
22 means -- I understand those concepts. Do we have
23 perfect models? That is for others to decide. But
24 there's got to be a model. The one-size-fits-all
25 doesn't work.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Even a template, you know, looking at
2 insides of cabinets and judging cables, you put five
3 people and have them look at it, and you will get five
4 answers. So, as a practitioner, we need more than a
5 98th percentile. It could be as high as a megawatt or
6 700 kW. If we use those heat release rates, we have
7 had a time selecting a damage set that we believe is
8 real. Then, we just propagate that through the rest
9 of the model.

10 Yesterday Danny Pace talked about the set
11 of dominoes. That's a set of dominoes. We build the
12 whole model, and then a fundamental concept changes
13 like, oh, the heat release rate is different, and
14 maybe a whole set of damage targets that are
15 different. And it is a tremendous amount of effort to
16 do that.

17 So, as a practitioner, we need some tools
18 that can be understood by the PRA people trying to
19 build models, understanding we are not all fire
20 modelers, and even if we were, the uncertainties are
21 huge, based upon what we are hearing.

22 So, I just wanted to relay that, that heat
23 release rate is the starting point. And if we are not
24 comfortable with that, it is just compounding above
25 that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Thank you.

2 MR. NOWLEN: Yes, and I will confirm that,
3 of all the parameters that we use to characterize
4 fires, heat release rate is the most important one.
5 There's absolutely no doubt.

6 And I'm not saying we shouldn't reexamine
7 it, but my caution, again, is I haven't seen what is
8 being done by industry. But when I read the reports,
9 there's such a focus on the heat release rate. I
10 think we have to look at this in an integrated manner
11 and make sure that all the pieces are being done in
12 balance. That is all that I'm saying here.

13 CHAIRMAN STETKAR: Okay. Thanks.

14 MR. NOWLEN: This was just a slide to talk
15 about the simple binning. Our intent here was to
16 cover the cases we thought we would see out in the
17 plants. They're predominantly vertical cabinets, the
18 division between qualified and unqualified cable, and
19 open and closed doors.

20 I believe that the last bin may actually
21 be a typo. I believe that was intended to be either
22 qualified or unqualified cables in an open cabinet.
23 Because what you find is, again, if you can cross the
24 threshold and get the cabinet burning, the qualified
25 and unqualified no longer matters. So, the upper end

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 of the distribution is very similar. In fact, the
2 biggest fires we had were in qualified cables, but
3 you've got to cross the threshold. The threshold is
4 easier to cross for the unqualified. So, I think our
5 intent was to cover qualified/unqualified,
6 open/closed, vertical/others.

7 But, again, we were focused on what is
8 going to be the application out in the plant. Given
9 the data that we have, how fine can we cut this? Can
10 we cut it between load centers and MCCS? No.

11 All that we have is control cabinets. We
12 are going to have to use that to extrapolate to what
13 the other cabinets are going to look like. So, let's
14 try and come up with one set that would represent them
15 all. And I agree, revisiting it is totally
16 appropriate. Also, we talked about the control board.

17 Expert judgment is essentially inscrutable
18 and does not meet the requirements of ASME PRA
19 standard. Well, there was no ASME/PRA standard at the
20 time, but I just tried to go through here and explain
21 a little bit about how we did that particular
22 analysis. And I think the report is pretty clear that
23 the distributions represent the expert judgment of the
24 authors.

25 Yes, it would never pass the standard

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 today. We didn't document all our discussions. We
2 didn't have a structured debate. We were a team
3 working to try to come up with a solution. So, take
4 it for what it's worth. It's our judgment.

5 And again, this is another one that I
6 think we have beat this to death. We were trying to
7 provide sort of generically-applicable methods that
8 you could go around your plant and apply. I see a
9 cabinet and I need to do a model of that. How do I do
10 that? Here's some generic guidance that should bound
11 your cases or reasonably represent your cases. I
12 should be careful about using the "bounding" word. I
13 tend to use bounding a little more liberally than it's
14 being used here.

15 Our intent was to provide something that
16 would be a reasonable representation across a broad
17 spectrum. So, again, the idea of specializing for
18 particular cases, looking at the total heat load,
19 looking at whether you actually have a single log in
20 the corner versus spaghetti running through a control
21 panel, those things we intended to be considered, and
22 I understand that crystal clarity is lacking there.
23 We have talked about that.

24 I guess one other point that I should talk
25 about here is that another insight from the cabinet

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 fire testing is that the effects of the cabinet fire
2 on the broader room were relatively minimal. That
3 would address the question about automatic
4 suppression.

5 In general, the effects of these fires --
6 and this goes across the board, almost all of our
7 fires -- they are very, very localized. I rarely get
8 the temperatures at a 14-foot concrete ceiling hot
9 enough to set off a sprinkler. You know, these are
10 localized effects, and we see that because the vast
11 majority of fires in the database are manually
12 suppressed. We actually rarely see the automatic
13 suppression systems coming into play. They do show
14 up, gaseous suppression on cabinet fires, and things
15 like that. But, again, these are localized effects.

16 I'm hoping that the PRAs are reflecting
17 that. Whenever I see a PRA that tells me they burned
18 out a room, "How did you do that?" is my first
19 question. "How did you do that?" And usually, we can
20 track it to some assumption that has been made in
21 growth and damage that just, wow, let's talk about
22 that.

23 And we had some cases like that that led
24 to FAQs, in fact. The cable fires in the main
25 feedwater pump one were both like that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 This is about the industry experience or
2 the actual experience not matching reality. I think
3 we have talked quite a lot about this. I'm not going
4 to go into it. I'm not sure exactly what is
5 contributing to that, and I think we have to look at
6 all the pieces. I have said that.

7 So, I think that, whatever we do, cabinet
8 fires are going to remain important to fire risk.
9 They are our most common source. I mean nearly half
10 the fires we get are in electrical cabinets. So, I
11 don't expect them to go away.

12 I think we can better focus it. Better
13 methods would absolutely be welcome. I think the
14 consistency issues is definitely one that we have to
15 work. We need consistency applied across the
16 analyses. That's important.

17 I think Mardy mentioned the ideal of going
18 back and reexamining the root data, the event data on
19 your own is dangerous. I would add here that going
20 back and reexamining 20-year-old experimental data on
21 your own is also dangerous. You know, you need the
22 insights from people who understand experimentation,
23 understand fire phenomena. I think that is also a
24 dangerous thing. Again, this over slicing and trying
25 to make too much out of a bin of tests that really

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 aren't representative of what you're trying to cover,
2 and, then, the overlapping issues.

3 I think one other point that came up
4 before was with respect to MCCs and how you assume
5 damage. There was a question -- Dr. Stetkar, I think
6 you asked it -- how do we do that? The guidance
7 that's in 6850 is you assume a cabinet is lost in the
8 same way that you counted it.

9 So, for MCCs, it would be a vertical
10 stack. It's not the entire bank of MCCs. It's a
11 vertical stack. So, if you have a fire in the third
12 down, you would assume that it is lost. The idea
13 there is the smoke gets into the back, and it is
14 likely, because the cables usually run and down in the
15 back of these things, it is probably going to trip at
16 least those.

17 Now what I heard from Kiang is that they
18 will likely assume the upstream breaker is tripped
19 either because of smoke damage or the operators trip
20 it, so they can fight the fire, whatever. That's a
21 little different. 6850 says take the stack out.

22 CHAIRMAN STETKAR: I understand that, yes.

23 MR. NOWLEN: So, just a clarification
24 there.

25 CHAIRMAN STETKAR: On the other hand, not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 taking out the whole MCC, at least for some measurable
2 period of time, would seem to be grossly optimistic.
3 So, I'm kind of glad to hear they're taking out the
4 MCCs.

5 MR. NOWLEN: It is an interesting thing.
6 I mean we didn't do anything different for MCCs from
7 any other cabinet because that just goes --

8 CHAIRMAN STETKAR: I understand. That's
9 where I found the discussion.

10 (Laughter.)

11 MR. NOWLEN: Yes. I like it. I think it
12 is a reasonable thing.

13 I think there was also a statement about
14 propagation out of the cabinets in these tests. None
15 of these tests had fuels outside the cabinets. The
16 only thing that was there is what's in the cabinet.
17 So, you have to be a little careful extrapolating from
18 that.

19 Again, the overall insights from Sandia
20 was that these things have a relatively minimal impact
21 on the overall environment, the room, but directly
22 above there is clearly plenty of temperature.

23 Okay. Oh, one last point. In developing
24 our distribution -- and I meant to cover this before
25 -- one of the issues Dr. Powers raised, how we came

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 about this. One of the issues that came out of the
2 IPEEE analyses is that we weren't seeing analyses that
3 covered that low likelihood, severe fire case. So,
4 everything was being based on the mean fire. We think
5 this is the average fire; that's how we are going to
6 do the analysis.

7 But the thought was that the mean fire may
8 not be what really drives risk. It's the most likely
9 fire, but it could be that low-likelihood, severe fire
10 that actually drives your risk. That's the one that
11 can get you the damage state you need.

12 So, when we were defining these
13 distributions, one of the reasons that we were pushing
14 the 98th percentile as a characteristic of the curve
15 is we were trying to capture that upper limit. We
16 wanted to say, how far do we think they should push in
17 terms of going after that low-likelihood, high-
18 consequence fire? So, we made an effort in developing
19 our distributions to try to put an upper bound on it.

20 So, that's why we ended up with 98th and 75th.

21 And that was the end of my notes. Thank
22 you.

23 CHAIRMAN STETKAR: Thank you.

24 Any other questions for Steve?

25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 If not, we are going to take a recess.

2 MR. NOWLEN: Okay. You guys get a
3 reprieve.

4 CHAIRMAN STETKAR: And, then, Harry and
5 Ray can add, only because we're running a little bit
6 late.

7 MR. NOWLEN: I almost got you back on
8 time.

9 CHAIRMAN STETKAR: And I'm the Chairman,
10 and I need a recess.

11 (Laughter.)

12 So, we'll recess until 11 o'clock.

13 (Whereupon, the foregoing matter went off
14 the record at 10:45 a.m. and went back on the record
15 at 11:03 a.m.)

16 CHAIRMAN STETKAR: Can we come back to
17 session, please?

18 And I guess we're going to hear from the
19 staff on enhancing fire PRA realism.

20 Do we have these handouts, John?

21 MR. LAI: Yes. We have Ray's and
22 Harold's, but I think Harold isn't doing any
23 presentation.

24 CHAIRMAN STETKAR: Okay. You're going to
25 answer questions.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WEERAKKODY: Yes. For the record, I'm
2 Sunil Weerakkody, Deputy Director, Fire Protection.

3 Harry Barrett is here. In fact, I asked
4 Harry whether I should introduce him to the Committee
5 because he was our Project Manager for the Harris SC
6 pilot. And he said to me I don't have to because he
7 is in all these pictures, everyone knows him, and that
8 he's famous. And he is. He's in all these pictures.

9 (Laughter.)

10 But the point I want to make was Harry was
11 the lead for our first pilot, Harris SC. He is very
12 cognizant of how to discuss such a number of issues, PRA
13 or non-PRA, and I understand the Committee had a
14 number of questions that they want to ask with respect
15 to the NRR views with respect to processing these
16 licensing actions.

17 So, that's why Harry is here. He does not
18 have a prepared presentation, but he's got it all up
19 here.

20 (Laughter.)

21 Ray is a fire PRA expert, has been for
22 many, many years. Ray is cognizant with the details
23 of Harris and Oconee. With Oconee, we are a little
24 bit pulling because we have not issued the safety
25 regulation. So, the details that we can give with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 respect to Harris and the details we can discuss in a
2 forum like this, our comments may be somewhat limited.

3 But, within that construct, he has a lot of insight
4 on both pilots.

5 CHAIRMAN STETKAR: Okay.

6 DR. WEERAKKODY: With that, Harry?

7 MR. BARRETT: Yes. One thing I wanted to
8 talk about directly was how some of the issues that
9 were brought up through the Harris review were
10 resolved in the safety evaluation.

11 The Progress Energy team ended up having
12 several departures from 6850 because they found issues
13 that either they didn't think were realistic or
14 appropriate. I will give you an example of that as
15 MCCs being treated as closed cabinets. By 6850 rules,
16 looking at an MCC, you would normally end up
17 considering that that was an open cabinet and that you
18 would end up considering that all fires get out of the
19 cabinet essentially every time.

20 The Progress Energy team looked at the
21 data from the testing and the data from the fire
22 events and basically said, no, I think more than
23 likely you're going to end up having that only happen
24 maybe 20 percent of the time or 10 percent of the
25 time. They came up with a distribution of what the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 impacts would be, and they ended up doing,
2 essentially, a probabilistic analysis of that and
3 said, well, 80 percent of the time it's not going to
4 do that and it's going to stay within the cabinet.

5 We looked at their justification and
6 looked at the way they ended up characterizing that,
7 and we essentially said, yes, we agree with that; we
8 don't see a real problem with that.

9 So, it is in the safety evaluation. It
10 has been recorded that there are several instances
11 where they deviated from 6850 but provided
12 justification. And what I wanted to point out is that
13 I think the staff is pretty reasonable when you give a
14 decent justification. We may end up asking RAIs and
15 ask what impact does that have; maybe you need to do a
16 sensitivity to tell us how important is this.

17 But in many cases, we looked at what they
18 did, and we ended up saying, all right, we find that
19 to be an acceptable justification, and we ended up
20 going with it.

21 They also did that looking at MCCs. They
22 happened to be ones that used the FDS model inside an
23 electrical cabinet, as Mardy ended up talking about.

24 But they did that for a specific reason.
25 They had an issue where they have multiple spurious

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 operations that could happen as a result of the fire
2 in an MCC. What they needed to find out was, they had
3 a proposed resolution, but they wanted to see whether
4 or not that resolution was appropriate. Okay?

5 If you have, let's say, a fire in one of
6 the lower buckets in one of these vertical sections,
7 the things above that would likely get damaged. What
8 they did was they did an FDS model to look at what the
9 gas flow would be to what's really going to end up
10 getting damaged by that fire.

11 And they came to the conclusion that if
12 they ended up using fire-rated Meggitt cable to go
13 from the bottom cubicle all the way up through that
14 wireway, and they ended up having the two valves that
15 they were worried about in a multiple spurious
16 combination, or in the low sections of two different
17 vertical section, then they would resolve their
18 multiple spurious concern.

19 We looked at the FDS model. We looked at
20 the way they justified it. And we said, you know, we
21 agree with that. That's a good use of the tool.
22 They're not calculating a probability of spurious
23 actuation using that. They are using that as a
24 sensitivity to whether or not their modification will
25 really resolve the issue. So, we looked at that and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 we said, okay, we can go with that.

2 So, I just wanted to point out that there
3 are cases where people have deviated from 6850. We
4 have looked at what they have done. They have
5 provided a reasonable engineering justification, and
6 we ended up going with it.

7 So, this idea that the staff is totally
8 rejecting ideas that, when people deviate from 6850, I
9 think is not true. There are instances where you can
10 deviate from 6850, but if you provide a technical
11 basis, you know, the staff would be pretty reasonable
12 with that.

13 DR. GALLUCCI: Let me add that the place
14 where we're very careful is where what appears to be a
15 deviation from 6850 may have generic implications as
16 opposed to implications just for the specific plant.
17 If that's the case, then we're much more careful about
18 trying to make a judgment on that.

19 Basically, what we do is we say, for your
20 particular plant, can you justify this deviation?
21 Accepting it or not, we may require sensitivity
22 analysis, but we're careful to say that we are
23 accepting this for your application, but it does not
24 necessarily imply generic implications.

25 Now just an example of something, early on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 in the pilot phase, Harris proposed a relaxation on
2 the screening human error probabilities that came out
3 of 6850. And we had a meeting. It was before really
4 they were too far into their PRA, before they had
5 actually submitted.

6 And we thought it was a good method.
7 Ultimately, it got superseded by the new NUREG-1931,
8 but that was a case there where we probably would have
9 accepted that not only specifically for Harris, but
10 generically. But, ultimately, it was superseded and
11 the fact that the number of human actions that were
12 ultimately left in the PRA diminished significantly,
13 so it wasn't relevant.

14 But that is an example of the type of
15 thing. But, like I say, where we're careful is where,
16 and just like Mardy said yesterday, is where you have
17 a single entity that has proposed a new method or an
18 alternate method that hasn't really been vetted yet.
19 And the industry recognizes this as well in the peer
20 reviews because the new NEI-0712 has a category called
21 "unreviewed analysis method" where the peer review
22 teams -- and I was an observer on one of the teams
23 where that peer review team didn't feel that it was
24 appropriate to make a decision one way or the other on
25 that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 As Donnie mentioned yesterday, that is
2 being passed on to a task force to resolve, hopefully,
3 in the near-term. So that, if those methods do have
4 generic validity, then they would be used.

5 MEMBER BLEY: Just to help me understand
6 what's a deviation from 6850, one example that has
7 come up a number of times in the discussions is there
8 is a statement in the NUREG that you can or should
9 account for fuel load availability. Now, if somebody
10 does that, is that considered a deviation or is that
11 just part of the analysis that you would review?

12 DR. GALLUCCI: That's part of the
13 analysis. I consider it an enhancement.

14 Or 6850 advocates the use of plant-
15 specific insights, fire modeling, et cetera. What we
16 would consider deviation is where, like the first
17 case, where I have the example is Harris proposed new
18 screening values for the HRA. That could be
19 considered a deviation from 6850. However, they
20 provided a basis, et cetera. And I say, ultimately,
21 this didn't end up in their PRA, and it was superseded
22 by the subsequent work on fire HRA that was done by
23 the industry and NRC together. That would be
24 considered a deviation. That would be something I
25 would consider a deviation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIRMAN STETKAR: Let me ask -- another
2 one, Dennis?

3 MEMBER BLEY: No, go ahead.

4 CHAIRMAN STETKAR: A couple of questions.
5 I'm trying to listen through all of the discussions.

6 One thing that was brought up this
7 morning, only because I have it in front of me, is --
8 maybe I'll save this for the FAQ discussion because I
9 know we're having a different discussion on FAQs. So,
10 let me save that one for the moment.

11 What I want to try to understand, and I
12 know you can't talk too much about the Oconee process.

13 So, our dataset here is limited to a single available
14 staff review of one submittal, which is a --

15 MR. BARRETT: Well, there may be generic
16 ramifications from the Oconee review that we might be
17 able to talk about. It depends on what it is you're
18 asking.

19 CHAIRMAN STETKAR: Well, one thing that I
20 wanted to try to get an understanding, the Harris
21 submittal has been approved. Harris has transitioned.

22 MR. BARRETT: They're still implementing.
23 They're almost done.

24 CHAIRMAN STETKAR: Okay. Fine. It's
25 process-related. They are not going backwards, I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 hope.

2 (Laughter.)

3 However, I think yesterday we heard that
4 there are still a number of, I don't know whether
5 they're license conditions because I didn't go back
6 and do my homework last night to actually develop the
7 words, license conditions or restrictions on the
8 further use of the fire PRA going forward after
9 transition.

10 MR. BARRETT: Yes, there is.

11 CHAIRMAN STETKAR: And I'm curious, and I
12 think what we heard with -- again, we don't know and
13 you probably can't discuss it in detail. There may be
14 a similar process being applied in Oconee. Now
15 yesterday it was characterized as the SER will be
16 issued with open items.

17 MR. BARRETT: I'm not sure that's an
18 accurate statement.

19 CHAIRMAN STETKAR: In the sense of a
20 regulatory SER with open items, is that -- I mean,
21 certainly, the Harris SER did not have open items --

22 DR. WEERAKKODY: Correct.

23 CHAIRMAN STETKAR: -- in the sense that we
24 understand it.

25 DR. WEERAKKODY: I think there's a number

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of things we can speak in general terms when we would
2 do something like that.

3 I am going to invite Donnie to speak to
4 that.

5 CHAIRMAN STETKAR: Okay. And as long as I
6 can be assured that the SERs are not, we're not
7 approving something with an SER with open items. In
8 other words, whenever the Oconee SER is issued,
9 whatever that schedule is, that will be an SER with no
10 open items. Is that correct?

11 MR. HARRISON: Yes, and this is Donnie
12 Harrison of the NRC staff.

13 That's correct. I think in different
14 types of applications there might be a draft SER that
15 is issued with open items as part of our review
16 process.

17 CHAIRMAN STETKAR: Yes.

18 MR. HARRISON: We're at a stage on the
19 Oconee review that, when we issue it, it will be the
20 final SER.

21 CHAIRMAN STETKAR: Okay.

22 MR. HARRISON: There will not be a draft
23 with open items.

24 That being said, I think the confusion is
25 there may be limitations on the ability of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 licensee to do self-approval post-transition based
2 upon the current state of their PRA. And that's where
3 there's the confusion, I think, is even within Harris,
4 we had part of the license condition.

5 There were implementation items related
6 to, and the example would be, incipient detection,
7 where the licensee for the transition application used
8 a model. We developed through a FAQ another type of
9 model. They did a sensitivity study to that other
10 model, but when we said, well, we want to do self-
11 approval in the future post-transition implementation;
12 you need to convert your PRA to the accepted model and
13 not use your model.

14 And again, you have to understand the
15 staff's perspective on that is we're granting them the
16 ability to approve plant changes without coming to us.

17 So, we want to have assurance that they are using is
18 a model that we agree with.

19 And so, that's the limitation we put in on
20 Harris in that respect. That's not an open item. We
21 closed it for the application --

22 CHAIRMAN STETKAR: For the transition?

23 MR. HARRISON: For the transition. But,
24 then, we said, but before you can do it on your own,
25 you have got to convert over to this accepted model.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 And similar thing is happening within the
2 Oconee review as well. It may be broader on Oconee,
3 I'll just admit that.

4 CHAIRMAN STETKAR: Is the incipient fire
5 detection model the only -- as I said, I have to
6 apologize, I didn't have the opportunity last night to
7 go back and do my homework. Is the incipient fire
8 detection model the only -- I have to be careful in
9 terminology -- I'll call it a license condition. What
10 do you call it?

11 MR. HARRISON: There's modifications and,
12 then, there's implementation items.

13 CHAIRMAN STETKAR: Okay.

14 MR. HARRISON: So, modifications are
15 actual physical plant changes.

16 CHAIRMAN STETKAR: Yes.

17 MR. HARRISON: The implementation items
18 may be a list of items, many of which are
19 deterministic, but they need --

20 MR. BARRETT: Yes. I'm not sure the
21 implementation items made it to the license condition.
22 In the Safety Evaluation, it said they had to be done
23 within the implementation window. But the
24 modifications and the modeling in the PRA of the
25 incipient detection are license conditions.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIRMAN STETKAR: Are license conditions.
2 But from a PRA perspective, I understand the
3 modifications.

4 MR. BARRETT: Yes.

5 CHAIRMAN STETKAR: I mean that is they
6 committed to do things; they need to do them. But
7 from a PRA perspective, when we're talking about a
8 risk-informed basis, a risk-informed licensing basis,
9 and the use of that risk-informed licensing basis
10 going forward.

11 At least in Harris' case, it is only the
12 incipient detection model that is the only kind of --

13 MR. BARRETT: And making the modifications
14 so that the plant matches --

15 CHAIRMAN STETKAR: Yes.

16 MR. BARRETT: Those are the only two.

17 CHAIRMAN STETKAR: Obviously, the
18 modifications need to be made. But in terms of
19 methods, and what we are discussing primarily in this
20 forum is methods and data --

21 MR. BARRETT: Yes.

22 CHAIRMAN STETKAR: -- and that sort of
23 input.

24 MR. BARRETT: Yes.

25 CHAIRMAN STETKAR: Input to the PRA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 models, and, then, usability of the PRA models going
2 forward.

3 And I recognize you can't speak about
4 details on Oconee at this time.

5 MR. HARRISON: Yes. And, John, if I can
6 just -- again, to just understand, when we do our
7 review, there's essentially two parts to it. One is
8 within our guidance is the transition application, is
9 it acceptable? A licensee can do a number of things.
10 They can use conservative models. They can do
11 sensitivity studies to address issues where there
12 might be questions on our RAIs. Those get you through
13 transition.

14 There may be issues where we say we want
15 some final disposition on issues to allow you to do
16 self-approval. That is a future thing that is part of
17 the application, and again, depending on how
18 comfortable we feel with the applicant, we may or may
19 not grant self-approval until certain things are done.

20 CHAIRMAN STETKAR: I understand. I
21 understand. Understand.

22 MEMBER SHACK: Just in the Harris SER
23 there is a statement that they adjusted HRR values for
24 a limited number of ignition sources based on fire
25 modeling insights. Was that the MCC or is this a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 different issue?

2 MR. BARRETT: That's a different issue. I
3 think the MCC might be included within that, but there
4 were several different ignition source categories that
5 they adjusted downward slightly that we looked at the
6 way they did it and why they did it, and we agreed
7 with them and didn't have a problem with it, partly
8 because it really didn't make that much difference in
9 the overall result. But we did allow that, and it is
10 clearly stated in the Safety Evaluation that we
11 reviewed that and accepted it.

12 MEMBER SHACK: And that was based on what?
13 The fuel loading or the arrangement? What was the
14 nature of the --

15 MR. BARRETT: If I remember right, one of
16 those was transient combustibles.

17 MEMBER SHACK: Well, yes, transient
18 combustibles is another issue. It said you gave them
19 credit for stricter transient controls.

20 MR. BARRETT: And Dave can probably give a
21 little more.

22 MR. MISKIEWICZ: Yes, I can expand on
23 that.

24 And I don't even know if it's a deviation,
25 based on what we're discussing today. But, yes, we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 did make some adjustment to transient combustibles,
2 and we had no transient combustible storage areas, no
3 transients allowed. We used a smaller-sized
4 transient, not the giant trash bag as our source. So,
5 the frequency is still there using the method, but we
6 used a smaller transient.

7 MEMBER SHACK: How about for the cabinets?

8 MR. MISKIEWICZ: For cabinets, what we did
9 is what we had talked about. You know, we had like a
10 lot of rad monitors, a lot of lighting panels, smaller
11 cabinets. We actually looked at them, what was in
12 them, opened them up. Even some larger cabinets, we
13 opened them and there's nothing in it but some
14 terminations or something.

15 And we had our fire modeling folks look at
16 them. We took pictures, and we said we don't believe
17 this could be a 702 fire; we are going to limit it to
18 200 or 69 kW, depending on what it actually looked
19 like.

20 So, we did that. We justified it with
21 calculations and provided that as part of our
22 packages. So, we used the insights like we had been
23 talking about to try to justify that this is not going
24 to be the megawatt fire.

25 MR. BARRETT: But, in reality, that is not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 a deviation from 6850 because you are supposed to look
2 at the combustible loading in the cabinet.

3 MR. MISKIEWICZ: Right.

4 MR. BARRETT: So, that is not really a
5 deviation.

6 MEMBER SHACK: It doesn't call it a
7 deviation; it just says they adjusted the values.

8 MR. BARRETT: Right.

9 CHAIRMAN STETKAR: Okay. It's a pity we
10 don't have the Oconee stuff done yet, for a variety of
11 reasons.

12 MR. BARRETT: Yes, yes.

13 CHAIRMAN STETKAR: I think that we have
14 seen experience through other types of licensing
15 applications. I think somebody yesterday drew the
16 analogy to the license renewal efforts, where
17 certainly the first two or three --

18 MR. BARRETT: Yes.

19 CHAIRMAN STETKAR: -- license renewals, I
20 wasn't around at that time, but in the three years I
21 have been on the Committee I have seen a tremendous
22 improvement, both in the efficiency and quality of the
23 staff reviews and the industry's understanding of what
24 is expected in the submittals and the industry's
25 coordination of their activities to be sure that we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 don't have repetitive questions raised in every
2 submittal.

3 MR. BARRETT: Right.

4 CHAIRMAN STETKAR: It's kind of a poster
5 child for that type of review process. Right now, I
6 think we are dealing with one example. Hopefully,
7 two coming down the pike.

8 MEMBER SHACK: It is about to double.

9 (Laughter.)

10 CHAIRMAN STETKAR: Well, yes. We're going
11 to double our experience base.

12 Thank you very much.

13 With that, Ray, you have a prepared
14 presentation.

15 DR. GALLUCCI: Yes. Let me just say that
16 this is kind of tangential to the cabinet discussion
17 that was before.

18 CHAIRMAN STETKAR: Okay.

19 DR. GALLUCCI: And it may very well just
20 be preaching to the choir. So, if at some point you
21 don't think you want me to continue with it, I will be
22 glad to stop.

23 (Laughter.)

24 Because, basically, this was my humble
25 attempt as a PRA person, and not a fire modeling

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 person, to --

2 MEMBER SHACK: A PSA person.

3 DR. GALLUCCI: PSA.

4 It's a humble attempt to use pre-FAQ
5 information that's in 6850 to just do some simple
6 enhancements of realism. And like I say, this may be
7 so simplistic to not be of that much interest, but I
8 will go forth and you can let me know.

9 CHAIRMAN STETKAR: Okay. You're one of
10 the few people who comes up there and says, "You can
11 tell me to be quiet."

12 (Laughter.)

13 DR. GALLUCCI: Yes. And to twist the
14 words of Shakespeare from Mark Antony's eulogy of
15 Julius Caesar, I come to praise 6850, not to bury it.

16 (Laughter.)

17 Based on the original guidance, the pre-
18 6850 MOU FAQs, which will probably be discussed in
19 more detail later today, from 6850/1011989, I chose to
20 discuss two simple examples, showing how that guidance
21 enables more realistic fire scenarios to be developed,
22 and going from what I would consider the scoping
23 guidance in 6850 to some very basic pre-fire modeling.

24 I don't think it crosses the threshold to really
25 count as fire modeling in the sense of even fire

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 dynamics tools. It uses material directly in 6850.

2 I don't want to offend the fire protection
3 folks, which I was in that Branch for seven years.
4 So, I don't want to pretend that I am doing any fire
5 modeling here.

6 My example, Table E.1, which I think you
7 probably saw snippets of earlier, those are the
8 characteristic heat release rates for the selected
9 eight cases. I just took one, the very first one,
10 Case 1, which is a vertical cabinet unqualified
11 bundle.

12 The listed parameters there, the 75th and
13 98th percentiles; there's a gamma distribution given.

14 And you can calculate the mean heat release rate from
15 the gamma parameters or by looking at the
16 distribution. And it turns out that the mean heat
17 release rate occurs at the 64th percentile for this
18 distribution. So, even the 75th here is higher than
19 the mean estimate.

20 Now, for the sake of my example, I am
21 someone did some sort of fire modeling to show that
22 damage will occur at a temperature that corresponds to
23 that for the mean heat release rate. So, that's
24 temperature is T64; the mean heat release rate, Q64,
25 with 64 represents the percentile.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 So, basically, I'm saying we're going to
2 have damage at 50 kilowatts. Someone did that
3 calculation.

4 Temperature varies as the heat release
5 rate to the two-thirds. The ratio of the damage
6 temperature to the temperature corresponding to the
7 75th percentile heat release rate can be shown to be,
8 it's about 80 percent. So, at the 75th percentile,
9 heat release rate gave you 200 C. Then, the mean
10 percentile, the 64th would have given you about 160.

11 From the ASME/ANS standard, this is a fire
12 scenario selection, Supporting Requirement C-1. The
13 thing here is that it gives you the three increasing
14 levels of the categories: basically, assigned
15 characteristics at level I that bound potentially
16 risk-contributing fire events, et cetera. At category
17 II, it recommends, well, it requires using the two-
18 point fire intensity model, not necessarily the 75th
19 and 98th percentile, although it is probably in the
20 notes that that's a good choice. And at CC-III, it
21 says talk about a range of fire intensities, which
22 brings in the concept maybe you want to use the gamma
23 distributions.

24 So, what I did here is, if you assume just
25 the point estimate, the 75th and/or the 98th

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 percentile heat release rate, and you want to deal
2 with category I or II, you would come up with saying
3 the damage probability is 1, since the 75th percentile
4 corresponding temperature exceeds the 64th percentile
5 corresponding temperature.

6 However, if you want to apply the
7 distributional approach, knowing that the mean occurs
8 at the 64th percentile, the probability of exceeding
9 the mean is .36. So, if you wanted to go from
10 category II to category III, theoretically -- you
11 could obviously do this in category II -- you could
12 say that by just using the distribution I might be
13 able to reduce the damage factor by three.

14 While this example is only for
15 illustration, it shows how use of more detailed, but
16 straightforward guidance from the 6850/1011989 report
17 can enhance fire PRA realism. So, I really haven't
18 done any fire modeling other than just working with
19 the distribution that's in 6850.

20 And what I'm saying, people are probably
21 doing this. That's why I may be speaking to the
22 choir.

23 CHAIRMAN STETKAR: I think what we heard
24 yesterday is that people are doing that.

25 DR. GALLUCCI: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: The mechanics, I'm not
2 quite sure about, but we had --

3 DR. GALLUCCI: Again, it's an example of
4 what's in 6850.

5 CHAIRMAN STETKAR: -- pretty positive
6 feedback that people, indeed --

7 MEMBER BLEY: Or some people.

8 CHAIRMAN STETKAR: Well, perhaps not all
9 people, but people are doing that. And I would assume
10 that if the people doing it are obtaining reasonable
11 benefits, increased reality, that that would be
12 communicated throughout the industry, and more people
13 would be doing it, I would hope.

14 DR. GALLUCCI: Okay. My second example,
15 here we are going to talk about fire growth in
16 electrical cabinets. We have 6850 that fire grows to
17 a peak heat release rate in an average of about 12
18 minutes. There were 20-30 tests, and they are ranging
19 from 4 to 18 minutes of growth. And it suggests use
20 of a T-squared function to represent growth of this
21 peak.

22 Now let's say someone wanted to be
23 conservative, maybe for bounding, or whatever, and
24 they just wanted to assume the heat release rate
25 peaked at T equal zero, instead of using the T-squared

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 curve. Again, I am not saying people have done this.

2 I am just saying this is one possible bounding
3 approach, and here's how you can relax that from 6850.

4 What I have here is the scaled heat
5 release rates, scaled time to maximums of 1. The blue
6 curve there is an example of the heat release rate
7 over T-squared time. In the red, I did an equivalent
8 area step function. Basically, I delayed the start of
9 the fire and then shot it up so that the area under
10 the blue curve and the red curve would be equal.

11 However, talking to the fire protection
12 people, it has been shown -- I don't have the paper,
13 but, apparently, there was a paper given, and this,
14 apparently, is part of the standard teaching in fire
15 protection. It is that, because of the T-squared
16 growth, maybe because of time lag, et cetera, it will
17 actually impart more heat to the target than the
18 equivalent-area step function. Not knowing what the
19 exact ratio is, but suspecting that if I backed off my
20 step function to, instead of the equal area occurring
21 at two-thirds of the timescale, at half the timescale,
22 that would certainly bound that.

23 So, what I basically did here is saying I
24 don't want to run a fire model for my example. I just
25 want to say, instead of assuming that the heat release

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 rate is instantaneously at its peak the time into
2 zero, I am going to use a surrogate for the T-squared
3 growth where I delay that rise to the peak, as a step
4 function, at the 50th point, the 50th percentile
5 point, or midpoint on the distributions here.

6 Looking back at the standard fire scenario
7 selection C-2, category I, "characterize ignition
8 source intensity at full peak heat release rate". One
9 could say, well, I'm doing that, even if I do that at
10 time equals zero. One might say, well, I'm doing that
11 if I do it at time equals .5, whatever. I am
12 basically doing a full peak heat release rate.

13 The second one, categories II and III,
14 "characterize ignition source intensity using a
15 realistic time-dependent fire growth heat release
16 rate". And this would be more analogous to using
17 something like a T-squared curve or a T-squared
18 development.

19 Now, if you look at CFAST, you will find
20 that there's four categories, slow, average, fast, and
21 very fast, very different rates. And if you use FDS,
22 you can actually input whatever heat release rates you
23 want.

24 But, for the purposes here, let's just say
25 the T-squared growth profile would be analogous to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 what I would do for categories II or III. And as a
2 surrogate, I am going to use my step function because
3 I didn't run a fire model and actually put a T-squared
4 heat release rate in.

5 What might I see as a benefit of this? If
6 I look in Section P.1.3 of 6850, the probability of
7 non-suppression of an electrical cabinet fire before
8 electrical damage occurs, the probability of non-
9 suppression within T minutes is an exponential
10 function. The lambda is minus .12. This has been
11 changed slightly as a result of, I believe it's FAQ 50
12 on manual suppression, but it didn't change that much.

13 Again, I was trying to use all the pre-FAQ
14 information.

15 If I have an additional time delay, as
16 opposed to T_0 , included in this non-suppression
17 probability, I will end up with a reduction by a
18 factor of the exponential of minus lambda times D,
19 this time delay. Thus, if a T-squared heat release
20 rate growth profile -- again, I'm using the surrogate
21 function -- is assumed, instead of an instantaneous,
22 the probability of non-suppression will be reduced by
23 a factor of the exponential of minus 0.12 times half
24 of whatever my actual T development time is. T prime
25 is the unscaled time because what I did in my scale

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 curve is I scaled it to 1.

2 So, here's just some examples. Let's say
3 that I decided to reach peak heat release rates ranged
4 from 3 to 15 minutes. So, my halfway point time
5 there, you can see, is at 1.5, et cetera. I
6 highlighted the 12 because that is the recommendation
7 or the suggestion from 6850.

8 And you can see from the third column that
9 that would be the ratio with the time delay to that
10 without the time delay. So, I'm showing decreases.
11 And the reduction factors range from 1.2 to 2.5 by
12 just putting in that 50 percent time delay.

13 I, then, combine that with what I did from
14 the first example, if I want. And what I end up with
15 is a series of joint reduction factors, if I put the
16 two examples together ranging from 3.4 to 6.9 with an
17 average of around 6, if I was basing it on the 12-
18 minute growth rate.

19 As it says at the bottom, the first
20 reduction factor shows how much the non-suppression
21 probability will be reduced by use of just the
22 surrogate step function at T scale equals to .50, from
23 3 to 15 minutes.

24 The second factor shows the joint effect
25 if distributed heat release rate reduction factor of 3

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 from example is also applied.

2 Conclusion: these examples are
3 illustrative only, limited only to two aspects to
4 contribute to fire CDF, but they show how use of more
5 detailed, but straightforward original guidance from
6 6850 and 1011989 will enable you to enhance realism.

7 And I am basically going from what I would
8 label the scoping approach to pre-fire modeling. I am
9 not saying that this is not being done. Again, this
10 is just a simple PSA/PRA person's attempt to use this
11 material.

12 CHAIRMAN STETKAR: Ray, this is good. And
13 I want to see if I can get us somewhat back on
14 schedule here a little bit.

15 But I wanted to ask you something. The
16 first part of your example, I understand fully. I can
17 derive that completely from the information in NUREG
18 CR-6850 because I know what that distribution looks
19 like, and I can chop that distribution up any way I
20 want to.

21 The second part, to me, was a bit less
22 clear, the basis for your step function delay at the
23 50th percentile of the T-squared distribution.

24 My question is, is that type of approach
25 in NUREG CR-6850 or are you now stepping --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 DR. GALLUCCI: No.

2 CHAIRMAN STETKAR: Okay.

3 DR. GALLUCCI: 6850 says T-squared.

4 CHAIRMAN STETKAR: Okay. Right. Now my
5 question is, then, as a practitioner, if I come in,
6 this display is something that I suspect the staff
7 would consider a deviation from 6850. So, I now need
8 to justify why I used a step at 50 percent versus, it
9 looks like, 65 percent versus some other percent, and
10 dredge up the appropriate literature to try to justify
11 that, is that correct?

12 DR. GALLUCCI: Yes.

13 CHAIRMAN STETKAR: Whereas, the first --

14 DR. GALLUCCI: Like I say, this is
15 accurate. I don't have the reference, but my fire
16 protection people say there was a paper that says --

17 CHAIRMAN STETKAR: Okay.

18 DR. GALLUCCI: The .5 is an estimate. I
19 know that the two-thirds value, which is the equal
20 integral, is the exact point at which the area under
21 the T-squared and the step function are the same.

22 And according to the paper, you will
23 transfer more heat using the T-squared distribution.
24 So, the step actually has to occur earlier than that.

25 Where it is, I don't know because I don't have that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 paper. But, talking to the fire protection people, if
2 I used .5, I would certainly be bounding that.

3 CHAIRMAN STETKAR: But, again, if I'm an
4 applicant, it is incumbent on me to -- certainly I can
5 find the paper.

6 DR. GALLUCCI: Right.

7 CHAIRMAN STETKAR: But I have to defend
8 the paper to staff's scrutiny because that is
9 something that is not in 6850.

10 The first is certainly, you know, well --

11 DR. GALLUCCI: Right, right.

12 CHAIRMAN STETKAR: Those distributions are
13 documented. So, I can at least get that initial
14 factor of, pick a number, 3.

15 DR. GALLUCCI: And if I was a fire
16 modeler, I wouldn't even have bothered with the step
17 function. I would have just run CFAST and use the
18 actual T-squared.

19 CHAIRMAN STETKAR: Which is a lot,
20 certainly --

21 DR. GALLUCCI: Yes.

22 CHAIRMAN STETKAR: -- a lot. Okay.
23 Thanks.

24 Kiang, you had something?

25 MR. ZEE: This is an interesting

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 presentation. I think I just want to get just a
2 little bit of a clarification.

3 This is an NRC staff presentation, and I
4 think the context was things that can be done using
5 the existing guidance in 6850. I think we explored a
6 little bit to what extent this represents a deviation.

7 And I'm a little bit confused what they are trying to
8 tell us here, right now.

9 I mean, is this, but for rationalizing
10 equally, stepping back to half of the time, I mean,
11 are you portraying this as essentially something the
12 staff would accept as meeting capability category II-
13 III for related supporting requirements, simply with
14 respect to the growth rate?

15 CHAIRMAN STETKAR: Let me stop this
16 discussion for the moment because this is a
17 presentation to an ACRS Subcommittee. We are trying
18 to understand technical issues. I don't want to turn
19 it into a debate between the industry and staff of
20 what might or might not be acceptable in a licensing
21 review. So, I just want to stop that part.

22 I understand the concern, but let's bring
23 it back to something that we can learn about.

24 Thank you.

25 And next up, let's see, it's 11:40. Let's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 start on the next topic on the agenda. I do want to
2 hear about the FAQs. I think it would be worthwhile.

3 We are going to lose Dr. Powers sometime around noon,
4 as I understand it. Let's start the discussion on the
5 FAQs. The staff is up first. So, see if we can get
6 through the staff presentation, and, then, probably we
7 will break for lunch and have the industry come back
8 after that, if that works. Let's see how the timing
9 works here.

10 Thank you.

11 MR. MOULTON: My name is Chuck Moulton.
12 I'm the NFPA-805 mass questions process manager. I
13 have been from the inception of the process.

14 I have a relatively brief presentation on
15 process. Then, we can get to the more technical
16 discussion.

17 CHAIRMAN STETKAR: Good. I think we
18 fairly well understand the process. We have had some
19 discussions about it. So, see if you can run through
20 that one pretty quickly and see if we can get to some
21 specifics. Because there have been some discussions
22 about -- I want to learn a little bit more about
23 specific FAQs and why there's discrepancies in terms
24 of --

25 DR. GALLUCCI: I will follow that up. I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 have some material on the specific FAQs.

2 CHAIRMAN STETKAR: Okay. Good, good.

3 Okay, good.

4 MR. MOULTON: Do we even want to have this
5 process discussion?

6 CHAIRMAN STETKAR: My preference is no,
7 but if you think it is important for context --

8 MR. MOULTON: Well, let's run through it
9 then.

10 CHAIRMAN STETKAR: Well, run it quickly.

11 MR. MOULTON: The first slide, you have
12 already seen most of this slide from our presentation
13 in November. It is basically the idea that the FAQ
14 process was to incorporate lessons learned in the
15 pilot process and give them some sort of regulatory
16 weight behind them, get interim staff positions on
17 these issues out to the stakeholders in a timely
18 fashion, with the final regulatory closure of an issue
19 resolution incumbent on a revision of the Reg Guide
20 for 805, just 1.205.

21 In the most recent revision on that Reg
22 Guide, 18 results FAQs were incorporated into the
23 guidance document.

24 The next one.

25 This slide is our bragging slide. It

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 basically shows our success in resolving issues that
2 have come before us. As you can see, we are almost
3 done with everything we have gotten so far, and we
4 don't have any currently open PRA-related --

5 MEMBER BLEY: I guess I've lost the thread
6 on this. I wasn't here in November. So, what are
7 these items that are tabulated here?

8 MR. MOULTON: The top row, the first row
9 is total number of frequently-asked questions --

10 MEMBER BLEY: Ah, okay.

11 MR. MOULTON: -- the process, and it moves
12 across the page from the total to the number that were
13 resolved, the number that were withdrawn from the
14 process without resolution, the number that are
15 apparently open or we're working on, and then the
16 number that are in the fast closure process --

17 MEMBER BLEY: Okay.

18 MR. MOULTON: -- to achieve output of a
19 publicly-available memorandum, including the staff's
20 position.

21 MEMBER BLEY: Okay.

22 MEMBER SHACK: Are you talking about them
23 being incorporated in the NEI, but, I mean, this is
24 also in 6850, Supplement 1, isn't it? Or is that a
25 different set of FAQs?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: Or a subset of these?

2 MR. MOULTON: That's a subset.

3 DR. GALLUCCI: A lot of these FAQs are
4 non-PRA-related.

5 MEMBER SHACK: I just was looking at the
6 15.

7 MR. MOULTON: Right. Those PRA-related
8 one are only in the Supplement, I believe.

9 DR. GALLUCCI: I believe in the last
10 Supplement, they were all in there. Mark Salley may
11 be able to illuminate that, but I think all of those
12 have now been published in the Supplement that came
13 out a couple of months ago.

14 MEMBER BLEY: Yes. Okay. That's the one
15 we have. Yes. Okay. Thanks.

16 MR. MOULTON: The initial process was non-
17 PRA issues. So, PRA FAQs, what came to be known as
18 the MOU FAQs.

19 In mid-2008, a large number of new PRA-
20 related FAQs were introduced into the process. Before
21 then, we had had three or four PRA-related FAQs,
22 counting guidance, binning guidance of miscellaneous
23 things. What if the pump is exactly 5 horsepower,
24 which bin does it go in? Does it go into the less-
25 than-5 horsepower or the greater-than-5 horsepower

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 bin, that sort of detail issue?

2 MEMBER BLEY: And these are things that
3 were in that table you just showed?

4 MR. MOULTON: Yes.

5 MEMBER BLEY: Okay.

6 MR. MOULTON: Many of these new FAQs were
7 only problem statements. They did not include an
8 initial proposed resolution for discussion. And it
9 was primarily these FAQs that became known as the MOU
10 FAQs after the research EPRI MOU process.

11 CHAIRMAN STETKAR: Can you, for the other
12 Subcommittee -- I had forgotten that Dennis and Dana
13 weren't here in November. Can you briefly describe
14 that process or do you have another slide coming up
15 that --

16 MEMBER BLEY: How thing should get added
17 to the list?

18 CHAIRMAN STETKAR: No. How things, the
19 process, once a FAQ has been raised, the process that
20 was implemented to eventually reach closure on it.

21 MR. MOULTON: Okay.

22 CHAIRMAN STETKAR: And who participated in
23 that process and how they participated.

24 MR. MOULTON: Once a FAQ is introduced to
25 the process, it is presented at a public meeting. The

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 FAQ process is based on regularly-scheduled public
2 meetings between the NRC and industry stakeholders and
3 the public.

4 A question is posed, is entered in the
5 process, introduced at a public meeting. It is
6 handout. It is publicly available. The staff, then,
7 considers the proposal. There are substantial
8 comments on it. These comments are provided at
9 another public meeting in writing, and publicly
10 available.

11 Then the authors go back and consider
12 those comments and incorporate them. And, then, a new
13 revision is introduced again at a public meeting. And
14 this iterative process continues until a technical
15 agreement is reached, in which case, then, the staff
16 takes the agreed-upon resolution and produces a
17 publicly-available memorandum documenting what that
18 resolution is, referencing the final agreed-upon
19 version of the FAQ.

20 MEMBER BLEY: And 6850 was a joint product
21 with EPRI and the NRC. The FAQ resolution continued
22 that? I know the Supplement is a joint --

23 MR. MOULTON: The FAQ resolution was
24 separate from that.

25 MEMBER BLEY: But it still was a joint

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 effort?

2 DR. GALLUCCI: The MOU FAQs use an
3 expanded group from both NRC Research and from the
4 industry side and incorporated the original 6850
5 authors, members of what evolved into the 805 and Fire
6 PRA Task Force for NEI, and an expanded group of
7 participants from NRC Research. So, it included an
8 even larger group and, naturally, when you have more
9 people, consensus could be more difficult.

10 MEMBER BLEY: Okay.

11 DR. GALLUCCI: But, specifically for the
12 MOU FAQs, that was the process.

13 MEMBER BLEY: And as I recall, the
14 Supplement is a joint publication, like the original.

15 DR. GALLUCCI: It is, yes.

16 MEMBER BLEY: Okay. That's all.

17 MR. CANAVAN: For the record -- Ken
18 Canavan -- 1019259 is the number.

19 MEMBER BLEY: Thank you, sir.

20 MR. MOULTON: Okay. So, once we had these
21 new type of FAQs in, we continued to have our regular
22 monthly public meetings. Several months, almost a
23 year went by with minimal progress. And NRR
24 management determined that we needed to close out
25 these outstanding PRA-related issues.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 So, letter was sent from our management to
2 NEI describing the process that was going to be used
3 to close out these issues. At the same time, a number
4 of fully-developed PRA-related FAQs that we didn't
5 seem close to closure on got subsumed into this
6 alternate resolution process and were closed using it.

7 That is the process. That is aligned with
8 the FAQ process described in the RIS describing the
9 entire FAQ process.

10 So, quickly, the steps of our alternate
11 resolution process for these FAQs. The first step is
12 NRR and Research developed an Interim Position. Then,
13 Research engages EPRI under the MOU to obtain comments
14 on that Interim Position.

15 Step 3 is NRR and Research resolve the
16 subsequent comments. And, then, NRR prepares a
17 position for public comment that is sent into the FAQ
18 process for a public comment period. NRR and Research
19 jointly resolves any comments, and then NRR issues its
20 final position as a publicly-available memorandum.

21 So, how did this typically go? This is an
22 example timeline from FAQ 46, which is the incipient
23 fire detection question. This was a problem statement
24 FAQ. It was introduced into the FAQ process in April
25 of 2008.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 The balance of 2008, we held our regular
2 meetings. Minimal progress was realized from those
3 meetings.

4 CHAIRMAN STETKAR: Why was that?

5 MR. MOULTON: It was hard to get consensus
6 from such a large group of sometimes conflicting
7 interests.

8 CHAIRMAN STETKAR: Okay.

9 MR. MOULTON: In May of 2009, the NRC
10 Draft Interim Position was sent to the MOU. And on
11 the 19th, we received comments back. This was during
12 the time when the letter to NEI was being developed.
13 So, then, the 1st of June, the alternate resolution
14 process was published. Towards the end of June, we
15 released our Interim Position for public comments, and
16 we received comments at the end of July.

17 MEMBER BLEY: I'm just a little confused.
18 As you go through the process, this sounds like the
19 product is an NRC product that has responded to
20 comments from the industry rather than a joint?

21 MR. MOULTON: It is.

22 MEMBER BLEY: It is?

23 CHAIRMAN STETKAR: These are alternate --

24 MR. MOULTON: This is an alternate
25 resolution.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: Oh, 46 is in the Supplement.

2 MEMBER SHACK: They are all in the
3 Supplement.

4 CHAIRMAN STETKAR: They are all in the
5 Supplement.

6 MEMBER BLEY: So, not everything in the
7 Supplement was agreed to by everyone?

8 MR. CANAVAN: The FAQ 46, incipient
9 detection, was not authored, direct response was not
10 authored by the NRC. That's not accurate. Response
11 46 for incipient detection for authored by Pat
12 Baranowsky under contract with EPRI.

13 The solution that is provided from the NRC
14 Draft Interim Position sent to the MOU was actually
15 sent, is our writeup with NRC/RES comments sent back
16 to us.

17 MEMBER BLEY: So, in fact, you are in
18 agreement?

19 MR. CANAVAN: We are the author.

20 CHAIRMAN STETKAR: Well, that is
21 consistent with this process. It is just perhaps not
22 characterized --

23 MEMBER BLEY: But that was an example that
24 was up here.

25 CHAIRMAN STETKAR: Yes. Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: So, the example wasn't
2 right.

3 CHAIRMAN STETKAR: The example is not
4 quite right.

5 MR. CANAVAN: Just to be clear, FAQ 42,
6 44, 46, 48, 49, 50, and 51 are all authored by
7 industry.

8 CHAIRMAN STETKAR: Okay, and we have those
9 on the record, yes.

10 MR. CANAVAN: All the original authorship
11 is of different people, including Dennis Henneke,
12 Kiang Zee, Pat Baranowsky were the primary authors of
13 those resolutions.

14 CHAIRMAN STETKAR: Doug?

15 MR. TRUE: I just want to add a little bit
16 more context to this timeline. So, the NEI letter
17 went in in January of 2008.

18 Could you go back to the one before?

19 And, then, there was a public meeting in
20 February. The FAQ process would have got engaged in
21 March.

22 So, by early April, we had actually
23 decided there were a handful of things we were going
24 to talk about in the FAQ process. This was one of
25 them.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Handful in the PRA
2 area?

3 MR. TRUE: In the PRA area.

4 CHAIRMAN STETKAR: Okay.

5 MR. TRUE: And we tried to actually pick
6 kind of the easy ones. Like we didn't go after heat
7 release rates, for example, in that. And incipient
8 protection was important because Harris was pursuing
9 that, and it was a logical one to include.

10 What's left off of this timeline is that
11 in late 2008 EPRI had proposed the actual solution,
12 and by the end of 2008, had published an interim
13 report that described the solution.

14 And, then, it was May of the following
15 year before any response to that was given back in a
16 staff resolution.

17 MR. CANAVAN: Yes, in December of `08 --

18 MR. TRUE: December of `08 was when the
19 EPRI report was issued.

20 MR. CANAVAN: Yes, and that's 1016735.

21 MR. TRUE: So, that's just from a timeline
22 and context impact with this particular EPRI FAQ, I
23 think Ken can go through them one by one, if you want.

24 CHAIRMAN STETKAR: No, no.

25 (Laughter.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TRUE: The other thing is that, while
2 this one was an industry-proposed resolution, I think
3 the point that Dennis was going to make is correct,
4 that many of the FAQs represent NRC positions, not a
5 consensus position. They refer to consensus, but I
6 think that is a consensus within the staff. It is
7 certainly not a consensus within the MOU FAQ group, or
8 whatever the terminology is.

9 MEMBER BLEY: So, just to get this
10 straight, even though the Supplement is a joint report
11 from both NRC and EPRI, the NRC and EPRI industry
12 haven't completely agreed on all of the resolutions
13 that are in the report?

14 DR. GALLUCCI: There is agreement on what
15 is in the reports. What there may not have been
16 agreement on is the extent to which some parts of
17 these FAQs were dropped because consensus couldn't be
18 reached.

19 MEMBER BLEY: Okay.

20 DR. GALLUCCI: So, there is a limit.

21 MEMBER BLEY: I didn't understand that.

22 DR. GALLUCCI: Some of the FAQs were cut
23 and were divided. So, what is in there are agreed
24 upon.

25 MEMBER BLEY: So, there are still issues?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 There are still leftover issues here?

2 MR. CANAVAN: My presentation actually
3 goes through the technical issues of those FAQs.

4 MEMBER BLEY: Okay. I was just confused.
5 I'm sorry. That is what we wanted to pursue.

6 DR. GALLUCCI: Let me just point out one
7 thing. The EPRI report that came out in December 2008
8 was separate from the FAQ process itself.

9 MEMBER BLEY: Yes. Okay.

10 MR. MOULTON: I'm only touching on the FAQ
11 process of stuff here.

12 MEMBER BLEY: That's fine. I'm not
13 embedded in it.

14 MR. MOULTON: The MOU thing is opaque
15 to --

16 MEMBER BLEY: Okay.

17 MR. HARRISON: This is Donnie Harrison of
18 the staff, just to add some context.

19 Again, if you go back to what Chuck had a
20 couple of slides before this, it was this was the
21 alternate resolution path because we saw that the PRA
22 FAQs weren't moving towards resolution. So, then, it
23 became an activity of saying what can we do to
24 actually at least get a position out there that says
25 what can you do and let's get that guidance out now.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 "Now" takes a year. But that is better than having
2 them sit for three or four years and just be cycling.

3 So, again, to keep it in context on the
4 PRA FAQs, this was kind of trying to drive towards at
5 least some resolution for an interim bit, so that
6 people could actually move forward, like Harris.

7 DR. GALLUCCI: And recognize that this
8 example was a very important one because it was part
9 of the licensing process for Harris. It was quite
10 controversial, and it did require longer than some of
11 the other FAQs to finally come to some sort of
12 consensus between the two sides.

13 MEMBER BLEY: Okay.

14 MR. MOULTON: And so, the memo for this
15 one went out in December.

16 This slide just breaks down how many PRA-
17 related FAQs were resolved using the regular FAQ
18 process and how many used this alternate resolution
19 path. Basically, it is seven and nine. So, almost
20 half.

21 MEMBER BLEY: And if I'm reading this
22 right, five of them have technical issues still that
23 weren't resolved.

24 MR. MOULTON: No, no.

25 MEMBER BLEY: No?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. MOULTON: Those last two rows are
2 breaking down the alternate resolution path FAQs.

3 MEMBER BLEY: Yes.

4 MR. MOULTON: Four of those were
5 introduced with a proposed resolution. Five were just
6 problem statements. There was no proposed resolution.

7 MEMBER BLEY: Okay.

8 DR. GALLUCCI: Prior to 2008, there was
9 already a handful of 6850-related FAQs, like a
10 definition of the main control board, counting of
11 cabinets. These were basically clarifications. In
12 some cases, 6850 may have had something that appeared
13 contradictory.

14 So, four of these were done, and this
15 included the bus duct high-energy arcing fault FAQ,
16 four of these were done prior to or initiated prior to
17 the 2008, what I would call, accelerated process,
18 which dealt with the remaining five. But, ultimately,
19 all that were 6850 PRA-related, it all got rolled up
20 into the Supplement.

21 MR. MOULTON: This is my last slide I'll
22 go over.

23 A couple of things I learned from this
24 process was, the first thing is that the FAQ process
25 is very successful when it is used as it was intended

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to be used.

2 And the other thing is that an initial
3 proposed resolution is vital for successfully
4 resolving any FAQ in a collaborative or a consensus
5 fashion.

6 Well, that's my process presentation.
7 Questions?

8 MEMBER BLEY: I just have two because I
9 hadn't been involved in any of this along the way.

10 The first one deals with what I thought I
11 finally understood, that what was published in the
12 Supplement are those parts of the FAQs and resolutions
13 that everyone could agree on. So, there's some
14 additional issues that are remaining. Where's the
15 count of those?

16 DR. GALLUCCI: They are no longer part of
17 the FAQ process. They were removed from the FAQ
18 process. I think some of them are being pursued
19 independently.

20 MEMBER BLEY: Okay.

21 DR. GALLUCCI: There was an issue dealing
22 with DC hot short duration. The decision was made,
23 rather than to adopt the proposed industry resolution
24 for FAQ 51, to defer all of that to the completion of
25 the DESIREE cable fire test. And already the expert

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 elicitation, which will provide DC hot short
2 probabilities, durations, and an update to the AC, is
3 ongoing.

4 One is on, I think Ken mentioned, heat
5 release rates in cabinets. It was just decided that
6 that one was not ready for primetime, and that FAQ was
7 just withdrawn altogether.

8 Other ones were split. There was one on
9 the 35-degree vertical fire spread model for cable
10 trays. And there was attempt to -- ultimately, there
11 was disagreement as to what were the bounds on that,
12 what could be used. The FAQ eventually got reduced to
13 the only part where there was consensus was to
14 designate the conditions under which that test was run
15 and under which those assumptions were valid.

16 Trying to expand that to another, to a
17 larger FAQ or a separate FAQ was deferred. And the
18 fact that Research has been running the CHRISTIFIRE
19 cable spreading rate tests, basically, that superseded
20 the reintroduction or continuation of that spinoff
21 FAQ.

22 MEMBER BLEY: Okay. Thanks.

23 My other question was, was there anything
24 contentious about items getting onto the FAQ list
25 originally? Or were all the ones that were brought

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 forward added in?

2 DR. GALLUCCI: The only debate may have
3 been whether the FAQ was the most efficient to deal
4 with this issue or could be handled. It was decided
5 that the FAQ process would be more expeditious than
6 trying to reconvene the MOU expert group on 6850 and
7 doing a complete revision of 6850.

8 MEMBER BLEY: Okay.

9 DR. GALLUCCI: So, the FAQ process was
10 kind of a compromise. What could we do in the interim
11 before -- basically, now a Supplement to 6850 has come
12 out, but that's five years after the original 6850.
13 At least these FAQ solutions were coming out in the
14 2008-2009 period.

15 MR. MOULTON: The FAQ process also allowed
16 both sides to give a public footprint issues.

17 MEMBER BLEY: Yes, sur.

18 MR. MOULTON: This is a public process.
19 MOU is non-public.

20 CHAIRMAN STETKAR: What I think I would
21 like to -- any other questions for Chuck at the
22 moment?

23 Because what I would like to do, only
24 because of members' commitments and things like that,
25 I think what I would like to do is recess for lunch

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 now, come back, and after lunch I think we are still
2 interested in hearing specific items that remain under
3 contention, you know, within the FAQ process to give
4 us an idea of what technical sticking points there are
5 remaining.

6 MR. MOULTON: There are no longer any
7 issues in the FAQ process open.

8 CHAIRMAN STETKAR: Okay. I understand. I
9 mischaracterized the terminology.

10 (Laughter.)

11 I am interested in learning things that
12 were in the FAQ process that have been withdrawn for
13 whatever reason because nobody could reach agreement
14 and what those technical issues are, and why nobody
15 can reach agreement on them. Let me just call them
16 "stuff" instead of calling them "FAQs".

17 (Laughter.)

18 So, if we can, after lunch, reconvene with
19 kind of that in mind?

20 And again, if EPRI has a presentation, we
21 want to go less on process, less on who didn't do what
22 when. I want to understand what it was that wasn't
23 done and why.

24 MEMBER BLEY: What are the technical
25 issues?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Okay? And with that,
2 we will recess until, and I'm only going to give you
3 54 minutes, until one o'clock.

4 (Whereupon, the foregoing matter went off
5 the record for lunch at 12:06 p.m. and went back on
6 the record at 1:07 p.m.)

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

A-F-T-E-R-N-O-O-N S-E-S-S-I-O-N

1:07 p.m.

CHAIRMAN STETKAR: Okay, we're back in session.

As I said, there are some folks who have flight constraints. So, I am going to try to keep us as much as possible on schedule and plan to end as close to five o'clock this afternoon as we can, just to accommodate them.

So, what I would like is the presenters to keep that in mind. We may have to forego perhaps some of the topics that are on the agenda.

I think it is important to hear about the FAQs, only, as I said before lunch, from the perspective of I would really like to hear some examples of where there has not been the ability to reach consensus and what those technical issues are, because those are examples that might help our deliberations over what we have been tasked with the SRM.

I am also interested in hearing about the research program. So, I think we want to cover that.

Whether we get to the topics on additional support for NFPA-805 and whether we cover the incipient fire detection remains to be seen yet.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, I want to make sure we get through the
2 FAQs and EPRI's research program and NRC research
3 activities.

4 With that, Ray, I guess you're up.

5 DR. GALLUCCI: Okay. This was originally
6 prepared for one of the sessions yesterday. However,
7 much of the material that I have in here was already
8 covered by Steve Nowlen. So, I'm just going to skip
9 to the part that deals with the FAQs. It is only
10 about four slides.

11 Okay. With regard to the FAQs and fire
12 PRA, contrary to contentions, the FAQ process, while
13 not originally intended as a means to modify NUREG
14 CR-6850, created some significant, what I term,
15 relaxations to the first order guidance to facilitate
16 use of fire PRA in the short-term for NFPA-805
17 transition.

18 Could more have been done? Maybe, but
19 there was consensus in most cases where limits were
20 applied.

21 Here is some of what I would term the
22 significant relaxations:

23 We find that, as you saw yesterday, in
24 most cases the fire ignition frequencies were reduced
25 for most of the bins. A few selected bins were still

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 subject to sensitivities based on the original `68
2 frequencies. For example, the electrical cabinets
3 bin, which is a key ignition source.

4 Probabilities across the spectrum of spill
5 sizes for oil fires, that FAQ eventually was limited
6 to the main feedwater pumps because there was
7 consensus on that, and that was the immediate need. I
8 think further work is being done by the industry now
9 to extend that to other types of pumps.

10 CHAIRMAN STETKAR: Ray, before you go on,
11 one of the FAQs that was highlighted this morning when
12 we were talking about electrical cabinets --

13 DR. WEERAKKODY: Forty-eight that would
14 be. It was FAQ 48.

15 CHAIRMAN STETKAR: -- was 48.

16 DR. WEERAKKODY: Yes.

17 CHAIRMAN STETKAR: And if I read that, I
18 am curious about the closeout of that because the
19 closeout basically says use the lower frequencies from
20 the EPRI report, but you also have to do parallel
21 calculations using the original frequencies from the
22 6850 report.

23 DR. GALLUCCI: Only on selected bins.

24 CHAIRMAN STETKAR: This is 50. I'm
25 talking only about cabinet fire frequencies right now.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. GALLUCCI: Yes. Well, the original
2 FAQ would have required the sensitivities on all the
3 bins. I was an observer for NRR in the FAQ process,
4 the MOU FAQs, a lot of telecons and things. So, this
5 is coming from my observation.

6 But my understanding was --

7 CHAIRMAN STETKAR: Ray, before you go, was
8 48 an MOU FAQ or --

9 DR. GALLUCCI: Yes.

10 CHAIRMAN STETKAR: Okay. Thanks.

11 DR. GALLUCCI: Yes. My understanding was
12 that, when the 6850 authors originally developed the
13 frequencies from the original fire vent database, they
14 pretty much followed guidance that was in an earlier
15 EPRI report. Steve Nowlen can elaborate on some of
16 this since he was involved, and I bet Mardy could as
17 well.

18 But at that time there was guidance in
19 there that said it would be inappropriate to do a time
20 trend. And so, the 6850 authors did not do any time-
21 trending, but just treated the `68 to 2000 data as a
22 whole.

23 Now this FAQ proposed doing a time trend,
24 and the result of the FAQ was that there seemed to be
25 a difference occurring around 1990, for whatever

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 reasons, whether they were physical reasons or
2 reporting reasons, or whatever.

3 The staff concern was that when the
4 original EPRI recommendation that was adopted by 6850
5 not to time-trend this, and second, that the data from
6 2001 to 2009 was yet to be processed. So, this fact
7 was intended to be an interim solution where, yes,
8 these new frequencies could be used, pending final
9 analysis of a 20-year trend from 1990 onward, to see
10 if those reduced frequencies were still being
11 maintained.

12 So, the sensitivities for the electrical
13 cabinets and a few other bins were retained because
14 this data from 2001 to 2009 was not yet processed, and
15 this was intended as an interim solution.

16 CHAIRMAN STETKAR: Okay. Well, you have
17 been through one review on the Harris study. Did they
18 apply the reduced frequencies?

19 DR. GALLUCCI: I don't believe they did.
20 We could check. Dave can verify that.

21 Do you remember, Harry?

22 MR. BARRETT: No.

23 DR. GALLUCCI: I don't think they used it.

24 CHAIRMAN STETKAR: They just kept the 6850
25 frequencies?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. MISKIEWICZ: This is Dave.

2 This is real easy. Actually, LAR went in
3 before this FAQ was completed.

4 CHAIRMAN STETKAR: Say no more. Thank
5 you.

6 (Laughter.)

7 So, we really don't have -- I mean, what
8 happens for example if they do the sensitivity study
9 and the frequencies that have been accepted in the FAQ
10 result in measurably different results from the 6850
11 frequencies? I mean, you know, now we are in a
12 quandary here. What do we do?

13 DR. GALLUCCI: The purpose for the
14 transition for the frequencies is to show whether any
15 of the variances from deterministic requirements,
16 basically, the delta risks for implementations, et
17 cetera, would cross the Reg Guide 1.174 threshold with
18 the other considerations of defense-in-depth and
19 safety margin.

20 If by applying the sensitivity for the
21 specific bins of one of the original 6850 caused a
22 variance from deterministic requirement to change
23 disposition from being acceptable to questionable,
24 then we would ask additional questions, what types of
25 defense-in-depth do you have in place to address the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 possibility that you may be crossing a threshold?
2 What types of safety margins?

3 I don't believe it happened for Harris.
4 Well, Harris didn't do this --

5 CHAIRMAN STETKAR: Harris didn't do it.

6 DR. GALLUCCI: -- but, basically, we would
7 fall back on some of the other provisions of Reg Guide
8 1.174 for defense-in-depth, safety margins, the other
9 considerations.

10 CHAIRMAN STETKAR: Okay. I still have to
11 think about that. Thanks. Continue.

12 DR. GALLUCCI: Okay. The incipient
13 detection, which is more properly termed by the fire
14 protection world Very Early Warning Fire Detection
15 System credit. Up to two orders of magnitude are now
16 attainable for reducing fire ignition frequencies, and
17 it was limited by consensus to low-voltage electrical
18 cabinets. That was the main interest for Harris, and
19 this was being processed in the expedited manner
20 primarily so that Harris could take the credit for
21 installing the system. And their interest at the time
22 was low-voltage electrical cabinets.

23 Expansion to room-wide, et cetera, was
24 deferred to a later time. And the fact that Research
25 will be conducting experiments to address the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 possibilities of the actual credit that might be
2 available for these types of systems.

3 As far as AC hot short durations, we had
4 experimental results from NEI/EPRI and CAROLFIRE were
5 available. Dennis actually used the paper that I
6 developed to come up with the first approximation for
7 AC hot short durations. It got slightly modified in
8 the consensus process between EPRI and Research.

9 That was pretty much completed and
10 consensed upon. Dennis had proposed an approach for
11 dealing with the DC hot short durations until the
12 DESIREE-FIRE test would be completed and the expert
13 panel. It was decided, basically, to defer that until
14 those tests were completed.

15 So, that is one aspect of the FAQ. that
16 was cut out from the FAQ. And so, the FAQ that was
17 closed excluded the DC hot short duration material.

18 In spite of that, there are some
19 contentious limitations due to disagreement between
20 technical experts. Transient fire growth rates was
21 one.

22 The FAQ clarified, one part of the FAQ was
23 clarifying for the main control room what transient
24 fire frequency curve you should use. Should you use
25 the control room fire frequency or fire non-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 suppression curve or should you use the transient?
2 And that was clarified for the transient.

3 Specifications for what were termed trash
4 fires were used, but I think as Steve explained
5 yesterday, if you're getting into other types of
6 transients, then you may not want to use either the
7 6850, all the 317/142 kilowatts. You may not want to
8 use what was designated for the trash fires. You may
9 want to use something specific, if it is a liquid
10 spill, or whatever.

11 So, basically, the FAQ was not extended to
12 address things other than the trash fires, trash can,
13 trash bag, and the main control room. So, whether
14 work will continue on that, I don't know. But, as
15 Chuck pointed out, there's no more MOU FAQs being
16 processed right now, and none that I expect. None are
17 slated, to my knowledge.

18 Another one was the probability of fire
19 spread beyond sealed cabinets. There was a continued
20 debate over what's exactly the meaning of a sealed
21 cabinet and what was the proper way to quantify this.

22 I know there were some models proposed -- again,
23 Dennis Henneke worked on this -- and numbers something
24 like a 10 percent probability of propagation outside
25 the cabinets was proposed, but, again, consensus

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 couldn't be reached.

2 And one of the reasons was something that
3 Mardy brought up, and I believe Steve brought up. It
4 is because the interface between frequency, non-
5 suppression, propagation, et cetera, had been
6 accounted for to some extent by the original 6850
7 authors.

8 If this addition or change was
9 incorporated in there, it might negatively or
10 adversely affect some of those original assumptions.
11 So, consensus couldn't be reached whether or not a
12 quantitative model could be developed. And so, this,
13 basically, the probability aspect was not pursued.

14 And again, theoretically, the option was
15 discussed whether to split thee into two FAQs. That
16 was an option at some point in time. Eventually, the
17 FAQs disappeared, the split FAQs. So, this one
18 remains unresolved as far as a quantification model.

19 Continuing, cable tray fire propagation,
20 as I mentioned, 6850 has a vertical spread model that
21 shows, basically, a 35-degree cone as you go up among
22 the trays, based on one fire test from the Sandia
23 tests in the eighties. If I'm wrong, Steve can
24 correct it.

25 And there was a desire to say, under what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 conditions do you have to use this? Are there
2 conditions where -- it was hoped to broaden this and
3 apply it to more cases.

4 There was enough disagreement, again,
5 between the experts as to whether this was a
6 conservative model, whether this was a limiting model,
7 whatever. I know that some other models were proposed
8 during some of the pilot processes, et cetera.

9 Ultimately, the only agreement that could
10 be reached was to define the conditions under which
11 this model could be modeled, which was basically
12 reiterating the conditions under which the test was
13 conducted. And as far as expanding this, it has
14 basically been deferred to what are the -- which Mark
15 will talk about -- the CHRISTIFIRE series of tests.

16 And this is my conclusion. Given the
17 accelerated agenda, basically, being driven by 805,
18 for relaxing 6850 guidance and limited test results
19 available at the time, the FAQ process should be
20 viewed as a success.

21 And that is all I had on this for the
22 FAQs.

23 CHAIRMAN STETKAR: Any questions for Ray?

24 We might, you know, depending on what
25 comes up in EPRI's presentation, I'm sure we'll have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 some discussion. But thank you, and we'll see.

2 Ken or Rick, or whoever is going to talk
3 to us about the things that I can't call "FAQs".

4 (Laughter.)

5 MR. CANAVAN: Good afternoon.

6 I brought my laptop in case I get in
7 trouble.

8 CHAIRMAN STETKAR: And again, Ken, if you
9 can, just because of time constraints and sort of our
10 interest, if you can downplay body counts and process
11 and try to emphasize more of the specific issues that
12 remain unresolved that were a fallout of the FAQ
13 process, I think we would appreciate that.

14 MR. CANAVAN: I will present only the
15 process issues when they have relevance to our
16 discussions on the technical, if that's okay.

17 CHAIRMAN STETKAR: That's perfect.

18 MR. CANAVAN: And if I go too far, I am
19 sure that I could be corrected.

20 CHAIRMAN STETKAR: I will just keep you
21 apprised of the fact that I'm not going anywhere
22 tonight.

23 (Laughter.)

24 MR. CANAVAN: That is certainly an
25 encouragement for me to move quickly.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I guess what I will do, I wasn't going to
2 focus on the process at all. Actually, I just have
3 two slides on it. There are some important things
4 that we do need to talk about.

5 Obviously, you already know we have
6 differing opinions on the efficacy of the FAQ process.

7 A couple of items I did want to mention. It has been
8 discussed a few times that the FAQ process -- so these
9 are the exact words of the FAQ process from the letter
10 sent from NRR to industry.

11 And I just wanted to point out one thing.

12 If you look through it, you will see two weeks; you
13 will see may disagree, may agree to disagree, or
14 concur with confirmatory research; five weeks. You
15 will see a lot of times in here. So, you go through
16 all the steps, and every step has time. No later than
17 16 weeks. So, it's finish your research or we'll give
18 you the answer. That's what this says to me, and
19 that's what we did.

20 I will point out that the last step is
21 industry and public stakeholders send comments that
22 are appropriately considered and finalized in the FAQ
23 resolution. So, you have heard several times the word
24 "consensus" used, and I'm going to have to disagree
25 because, when the final word is left to one person,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 and not necessarily -- final counts will be
2 appropriately considered, not incorporated
3 dispositions. So, that leads me to the important
4 part, which is its impact on the research.

5 CHAIRMAN STETKAR: But I think what we saw
6 this morning is that, I don't remember whether it was
7 seven or nine, and which side it was --

8 MR. CANAVAN: Nine.

9 CHAIRMAN STETKAR: Roughly half of the
10 FAQs were closed from the MOU process. So, those,
11 indeed, do have consensus, is that right?

12 MR. CANAVAN: That's what I wanted to
13 clarify. I do not believe they do. I believe that
14 those are the final resolutions as provided by the NRC
15 to the industry which were published in a joint report
16 to provide -- that's the current, it provides a
17 baseline. That is the current thing that everybody
18 has to do. It's the current thing that everybody has
19 do.

20 We are collecting the methods together
21 back for 6850. We didn't necessarily agree with them.
22 They were interim positions. They were not
23 consensus, but they are the way you have to do it to
24 comply with 6850.

25 CHAIRMAN STETKAR: I understand that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 thought process for what was presented as the
2 alternate FAQ closeout.

3 MR. CANAVAN: Yes.

4 CHAIRMAN STETKAR: Again, I don't recall.
5 It doesn't make any difference whether it was seven
6 or nine. Roughly half of what's in that joint report
7 --

8 MR. CANAVAN: Is all of them.

9 CHAIRMAN STETKAR: -- is all of them --

10 MR. CANAVAN: Right.

11 CHAIRMAN STETKAR: -- all remaining 15.

12 MR. CANAVAN: And some of them are
13 consensus.

14 CHAIRMAN STETKAR: But not all that
15 were --

16 MR. CANAVAN: No.

17 CHAIRMAN STETKAR: No, I understand, but
18 were all of them that came out of the EPRI/RES MOU
19 process consensus?

20 MR. CANAVAN: The MOU process was
21 superseded by this process. We were operating under
22 these six steps. Even within the MOU, it says RES
23 will engage EPRI under the MOU to obtain comments on
24 the position within two weeks from the receipt, and
25 the MOU team may agree, disagree, or concur with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 additional confirmatory research. And so, we could
2 agree, disagree, or concur, but the process moved
3 forward.

4 The FAQ was going to be issued within 16
5 weeks of its initial -- and that's step 4, where
6 industry, including EPRI, public stakeholders and
7 comments would be received and appropriately
8 dispositioned. So, those comments were appropriately
9 dispositioned.

10 There are cases where comments were not
11 considered, and the FAQ solution was put out. The
12 reason why we collected the 16 and published them in a
13 joint report is because they are additions to 6850.
14 There are people in Spain who try to use this that are
15 EPRI members. There are people in other countries,
16 and you can't find this stuff in the ML system, the
17 ADAMS system. It is very difficult unless you have
18 the ML numbers. We just collected together.

19 CHAIRMAN STETKAR: That's fine. Yes,
20 perhaps it will become more clear if we get to the
21 specifics.

22 MR. CANAVAN: Well, here's all the FAQs
23 listed similar as before. And I want to be careful.
24 Like I said, the FAQ process is a fine process for a
25 lot of stuff. I agree with the NRC conclusion that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 previously, you know, when used as intended, it worked
2 great.

3 When we tried to do research using it, it
4 got difficult. I agree with what the NRC said. You
5 know, teams were large; it got hard to reach consensus
6 sometimes.

7 Sometimes the issues couldn't be closed in
8 a timely manner. You can't have all that discussion
9 in two weeks. You can't get all the people together;
10 they're not available. What do you do when the key
11 person isn't available for the discussion for the two
12 weeks, he's on vacation?

13 So, some of the more contentious issues
14 were difficult. The early ones that were closed were
15 more simple. They were more FAQs related to
16 clarifications of the content, and clarifications were
17 easy.

18 MEMBER BLEY: When you say "closed" on
19 here, can that be considered as consensus?

20 MR. CANAVAN: Yes.

21 MEMBER BLEY: Okay. So, any that say
22 "closed" really were consensus?

23 MR. CANAVAN: Yes.

24 MEMBER BLEY: Okay. That helps.

25 MR. CANAVAN: Right. And so, the nine MOU

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 FAQs that are referred to in the NRC presentation,
2 eight out of the nine are on the Action Plan for
3 further research. Eight out of nine of those, we in
4 some way, shape, or form either had a comment that
5 wasn't dispositioned or we reached consensus with the
6 staff on the interim position, but had an issue or
7 desire to further extend that research. And we had
8 agreed to that.

9 So, I say non-consensus. There's an awful
10 lot of consensus. You know, it's always tough with
11 this because I really think that some of the issues --
12 there was a time issue. We wanted to move forward.
13 And that provided a lot of the emphasis for -- you
14 don't see any of the early FAQs, for example. None of
15 the early FAQs have issues with spinning off
16 additional research or punting to a later time. The
17 other ones were handled.

18 As we get towards the end and time
19 pressure increases, and we're not getting the
20 solutions, there is a tendency to start splitting off
21 the harder parts of it. There is a tendency to defer
22 some of it to later. And then, lastly, there was the
23 last-ditch efforts of, hey, we need to get this out;
24 there's a clock. We don't agree. We got your
25 comments. We're going to take what we can and we are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 going to move forward.

2 So, that's where we are. So, let's walk
3 through each. Let's talk about some of them.

4 The first one that I have here that I
5 wanted to discuss -- and I have some background, and I
6 may refer to that -- we talked about heat release rate
7 from non-vented cabinets. That is in the Action Plan.

8 The Action Plan ID is 2.2.

9 So, there will be a presentation on the
10 future research plans later this afternoon, and those
11 numbers will correspond. So, we can discuss a lot
12 here or a little bit here.

13 The next one is the high-energy arcing
14 faults for bus ducts. Again, we consider this to be
15 partially closed. Our issue was with the zone of
16 influence. We went back and forth a whole bunch of
17 times. We think it is a little bit smaller. Staff
18 thinks it's a little bit larger. Back and forth, back
19 and forth, and eventually the larger zone got agreed
20 to in the FAQ, and it is fine for interim, but we
21 believe that it needs further resolution. And there's
22 an issue, 2.7, that we will talk about this afternoon
23 on looking at the zone of influence from high-energy
24 arching faults.

25 Forty-two, propagation from electrical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 cabinets, this one is open. Again, Action Items 2.2
2 and 2.9. We discussed this a little bit this morning.

3 Forty-two is the propagation. It is
4 interesting, I always looked at it internally to the
5 cabinet and then outside, but it is also outside. And
6 the real reason is, if you contain it in the -- in the
7 MCC, you're going to de-energize it anyway, as Ken
8 explained this morning, most likely. Most people
9 assume that in their model. Hey, you de-energize.
10 You know, get a fire in an MCC. You de-energize the
11 MCC, then you put it out.

12 So, the MCC is already gone, but the
13 question is, do you do cabinet-to-cabinet and, then,
14 does the fire get out of the cabinet? And the
15 interesting thing is that it becomes, you know, that
16 whole cabinet becomes the location of the fire, right?

17 You put it at the top, anywhere around, to assume
18 your impacts.

19 I may just do this. I wasn't going to do
20 this because this is a little confusing the way this
21 is done. This is in your backup material. I included
22 it. I wasn't going to do this because it is a little
23 bit complex, but I will run through them anyway.

24 So, again, the issue was to allow
25 screening of unvented cabinets that are robustly

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 secured, clarify that fire-sealed doesn't mean fire-
2 rated, and all this other stuff.

3 The problem was that the likelihood of
4 propagation was not pursued. Heat release rates are
5 different. That wasn't reviewed. Experimental data
6 to generate heat release rates, mixes of types, and we
7 talked about that.

8 And so this is addressed. The resolutions
9 of these remaining issues are addressed in Action
10 Items 2.2 and 2.9.

11 Okay, No. 43, location of a fire in an
12 electrical cabinet, this is partially resolved. This
13 is the placement of the cabinet fire for fire modeling
14 purposes. And again, we are going to be very
15 interrelated on a lot of these because this fire
16 modeling is this way. Fire PRA is this way.

17 And we didn't address configurations where
18 no propagation occurs. And actually, if you look at
19 the data, you find an awful lot of that. You won't
20 find any of -- I think there's only two that propagate
21 outside, out of the ones that we could mine out of the
22 existing database. But, again, our information is
23 sparse in the database. So, it was very difficult for
24 us to make the case.

25 This was in the original FAQ, but, again,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 was dropped during the later stages when we were
2 having trouble just in getting agreement. And in a
3 lot of cases, it was better to take it out of the FAQ
4 and see if we could get a resolution with at least
5 partial.

6 Remember, there's pressure from the
7 regulator in getting these resolved, but there's
8 pressure from the pilots to get an answer.

9 CHAIRMAN STETKAR: Ken, let me ask a
10 simplistic, naive question on this one. I'm just
11 selecting this one as an example.

12 As I understand it, why do I care about
13 the location of a fire within an electrical cabinet?
14 I mean, why is this an FAQ? I understand if I'm doing
15 research --

16 MR. CANAVAN: Right.

17 CHAIRMAN STETKAR: -- but why do I care as
18 a PRA practitioner about the location of fire in an
19 electrical cabinet?

20 MR. CANAVAN: Zones of influence, if you
21 have a cable tray right over it, if you have a cable
22 tray and an MCC that are -- you know, all different
23 kinds of geometries. I'm looking at Dave here because
24 he's going to shake his head --

25 CHAIRMAN STETKAR: But we're talking about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the location of fire in the electrical cabinet, not
2 the propagation outside, I don't think, unless, for
3 some reason, that makes a difference. So, I'm asking
4 why I care about the location of the fire inside the
5 electrical cabinet.

6 MR. NOWLEN: If I could, this is Steve
7 Nowlen. I think I can answer this one for you.

8 CHAIRMAN STETKAR: No, Steve, actually, I
9 would like the people who are doing the PRAs to --

10 MR. NOWLEN: Well, but this is an issue of
11 fire modeling and how they interact, and it is a
12 fairly fundamental issue. What we are talking about
13 is, where is the location of the fire origin when I
14 apply a plume correlation? And the plume correlation
15 determines the temperatures above the cabinet, and
16 that temperature above the cabinet determines how far
17 the zone of influence is, and whether I can propagate
18 the fire to the next nearest combustible.

19 So, this is a fairly fundamental fire
20 modeling concept. And the issue was 6850 didn't give
21 real clear guidance. It said look at what's inside
22 your cabinet and put the fire wherever your
23 combustibles are concentrated. And they said, well,
24 but what do I do if I don't know? The question was
25 asked. We said put it a foot below the top of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 cabinet. That's a good generic answer, and then you
2 can fall back on the other.

3 But this is really not an issue of how a
4 particular analyst is applying it in their plant. We
5 all want to do it the same way, and I think they all
6 are doing it the same way. Dave and Kiang can correct
7 me if I'm wrong.

8 This is really about the plume
9 correlation. Where do you define the fire origin for
10 the plume correlation?

11 CHAIRMAN STETKAR: Okay.

12 MR. NOWLEN: That's where it is.

13 CHAIRMAN STETKAR: Okay.

14 MR. WACHOWIAK: This is Rick Wachowiak.

15 I think also in the slides, when you look
16 at those background slides, the section that says
17 "Issue" is the part of the issue that was resolved, is
18 what that means. So, when the question came up, how
19 do you address where the fire is in the cabinet, for
20 the purpose of modeling the impact on the rest of the
21 room, the closed part of the FAQ was that we agreed
22 that for the interim to put it, I think it says, 1
23 foot below the top of the cabinet, as long as the
24 cabinet has certain characteristics. That's okay.

25 CHAIRMAN STETKAR: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WACHOWIAK: But the part of the FAQ
2 that was not addressed was the operating experience
3 was that most of the time there was no effect outside
4 the cabinet. How do you account for this? And that
5 piece was just not addressed.

6 CHAIRMAN STETKAR: Okay. What I'm trying
7 to understand is, and the reason for my original
8 question was, I was trying to understand whether that
9 particular, the remaining concern was for modeling
10 fire damage within the cabinet --

11 MR. WACHOWIAK: No.

12 CHAIRMAN STETKAR: -- or it is still
13 focused strictly on the fraction of fires that
14 propagate outside?

15 MR. WACHOWIAK: For that particular FAQ,
16 it was for the ones that propagate outside.

17 CHAIRMAN STETKAR: Okay. Thank you.
18 Thanks.

19 MR. CANAVAN: And I think we solved the
20 first part, which was it was assumed, even for
21 cabinets that were sealed at the top, it was on top of
22 the fire. So, this FAQ resolved that part of it, the
23 solution.

24 CHAIRMAN STETKAR: Okay.

25 MR. CANAVAN: Okay. Pump oil fires. I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 think you will begin to see a trend, again, into
2 further breaking up of bins and looking into those
3 bins and seeing what enveloping characteristics were
4 applied to a bin, and should we be dividing that bin
5 up in some way, shape, or form?

6 So, you start with this. You know, FAQ 44
7 looked at the main feedwater pump oil fires. And the
8 original question was, okay, we're dealing with all
9 main feedwater pump oil fires are treated as a very
10 large spill-type model. And that was the original
11 treatment.

12 This FAQ was partially resolved in that.
13 The actual question on main feedwater was completely
14 resolved in a consensus fashion by looking at the data
15 and agreeing on a model of how much is spilled and
16 what's the frequency of that spill, and smaller spills
17 have a larger frequency and larger spills ignited
18 having a smaller frequency.

19 The reason why it is partially resolved
20 is, how do we apply this to the others? So, other
21 pumps, standby pumps, diesels, transformers, all that
22 oil that can have these spill-type characteristics,
23 and how do we model those and break up those?

24 CHAIRMAN STETKAR: I'm sorry, this says
25 pump oil fires. It doesn't say diesel. It doesn't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 say transformer.

2 MR. CANAVAN: The pump model is currently
3 being used for the diesels. It is the same spill
4 approach. So, the reason why we call it partial is
5 because of the pumps, and then there is, I guess I
6 would call it, an additional piece of research on
7 other spill-type fires like diesels and transformers.

8 CHAIRMAN STETKAR: Okay. Transformers are
9 kind of like motor control centers. If they catch
10 fire, a lot of times they explode.

11 MR. CANAVAN: Yes.

12 CHAIRMAN STETKAR: A lot of times you de-
13 energize them because nobody wants them to explode.
14 So, it is not at all clear whether, unless specific
15 transformers are located to other very, very risk-
16 sensitive pieces of equipment, I pretty much don't
17 care if I have a transformer out in the yard that
18 blows up.

19 MR. CANAVAN: Yes, if they are out in the
20 yard, it's no big deal.

21 CHAIRMAN STETKAR: So, I'm curious.

22 MR. CANAVAN: There are a few inside,
23 though.

24 CHAIRMAN STETKAR: My initial reaction is,
25 apparently, some plants had problems with the location

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 of their feedwater pumps that were risk-significant.
2 Okay. Well, that is a plant-specific configuration,
3 but that must have been the genesis of this question.

4 MR. CANAVAN: Right.

5 CHAIRMAN STETKAR: Suppose this one is
6 never resolved. Does it affect the overall results of
7 the PRAs?

8 MR. CANAVAN: It is going to be very
9 important for the boiling water reactors because
10 boiling water reactors will have, many electrical
11 lines will pass through the feedwater pump area, and
12 feedwater pumps can provide a significant mitigative
13 capability, which will go away if we model the fires
14 as large pool fires.

15 CHAIRMAN STETKAR: But we have resolution
16 on the feedwater pumps.

17 MR. CANAVAN: We have resolution on the
18 feedwater pumps. Then, we move into the buildings.
19 As you saw Danny Pace's presentation the other day,
20 large and small oil pumps being treated the same.

21 Also, the standby pumps versus the non-
22 standby pumps, that pool oil fire from a standby pump
23 can significantly impact all the cables in that part
24 of the aux building.

25 CHAIRMAN STETKAR: It can, but is it? I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 mean, you know, what I am trying to get to is, if we
2 try to be infinitely precise and infinitely perfect
3 about everything that could possibly be modeled and
4 quantified in a fire PRA, we might as well just stop
5 doing it today because we will never achieve that. We
6 have never achieved that in internal risk assessment.

7 And yet, we are satisfied that we know enough about
8 the important contributors.

9 My question is you're highlighting this as
10 something that is still an issue of contention --

11 MR. CANAVAN: Yes.

12 CHAIRMAN STETKAR: -- that requires
13 research. My question is, where on the priority list
14 ought it to be in my research program? I know we'll
15 get to that later.

16 MR. CANAVAN: Good.

17 CHAIRMAN STETKAR: But just saying that we
18 don't have resolution and we don't know enough yet
19 leaves me really cold.

20 MR. CANAVAN: Well, let me give you some
21 advance on the next presentation.

22 CHAIRMAN STETKAR: Okay.

23 MR. CANAVAN: Priorities aren't strictly
24 selected by what contributes the most. It's a
25 combination of what contributes the most and what can

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you solve easily. So, if something contributes sort
2 of middle, but it is easier to solve, then maybe
3 that's a little bit higher priority than something
4 that is really hard to solve and very important
5 because that might take time.

6 So, this is on the list because it
7 contributes. So, there has been at least one plant
8 that has come to us and said, "What are you doing
9 about the feedwater pumps? It's an issue that I think
10 I need resolution to."

11 CHAIRMAN STETKAR: Feedwater pumps are
12 done, though. I'm not asking about feedwater pumps.

13 MR. CANAVAN: Pumps.

14 CHAIRMAN STETKAR: I'm asking about the
15 other ones.

16 MR. CANAVAN: Standbys was brought up --

17 CHAIRMAN STETKAR: Okay.

18 MR. CANAVAN: -- by two separate utilities
19 to EPRI to be put on the list. So, standby oil pumps
20 and their treatments as pool fires and both for
21 standby pumps was brought up.

22 CHAIRMAN STETKAR: Okay.

23 MR. CANAVAN: All these items are brought
24 by utilities doing PRAs. Not one of the items on this
25 list is not something somebody is struggling --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIRMAN STETKAR: Are those PRAs
2 finished?

3 MR. CANAVAN: No.

4 CHAIRMAN STETKAR: I mean we still have
5 results from several --

6 MR. CANAVAN: No, they are not.

7 CHAIRMAN STETKAR: -- PRAs that didn't
8 show any contribution from pump oil fires.

9 MR. CANAVAN: No, those PRAs aren't
10 complete.

11 CHAIRMAN STETKAR: Okay. So, they don't
12 really know how important they are going to be? They
13 are just concerned?

14 MR. CANAVAN: They ran into it. They
15 thought it was going to be a larger one. So, yes.

16 CHAIRMAN STETKAR: Okay.

17 MR. CANAVAN: Yes. One is closer to
18 finished. So, I think that they have a handle on it
19 that it might contribute. The other one is earlier.

20 CHAIRMAN STETKAR: Okay. Okay.

21 MR. CANAVAN: So, I don't know how to take
22 their concern.

23 CHAIRMAN STETKAR: Okay.

24 MR. CANAVAN: Incipient detection, again,
25 partially resolved because I think the particular

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 resolution for incipient detection systems installed
2 within cabinets, similar to the way Harris has done,
3 there is credit. But there are other installations
4 proposed to lower risk that might be different
5 installations than Harris, and the FAQ would not
6 apply.

7 So, if you are going to look at general
8 area, if you are going to do any significant departure
9 from Harris, the FAQ is pretty clear that it requires
10 you to develop basis. We have had a few utilities
11 come and ask us, "Listen, we would like to take
12 advantage of this technology, but how do we do it?"

13 CHAIRMAN STETKAR: But it's on a broader
14 area.

15 MR. CANAVAN: How would we do it? And our
16 real concern is we start having six people doing it
17 six different ways. And then, the staff has six
18 different ways to review, and we have six different
19 ways to try to figure out who did what right. And
20 that's the real concern, is to develop a model that
21 everybody can apply consistently.

22 So, we are looking for configurations
23 outside the ones specifically described. That is
24 Action Matrix Item No. 1.5. I will point out that
25 during the next presentation we will talk about the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 matrix. Rick will do most of that.

2 Spurious operation 47. I am keeping pace
3 in EPRI 1019259, or I don't deviate.

4 Spurious operation probability, this FAQ
5 is open. This is, obviously, the joint work that is
6 going on in the DESIREE-FIRE program. I think that
7 program is going to be very successful in defining
8 this parameter for us.

9 CHAIRMAN STETKAR: In this, the issue, now
10 you say "extend lessons learned into AC circuits."
11 So, you're still trying to gain better information
12 about -- is it conditional probabilities of, I'll use
13 the old speak, hot shorts or is it, in particular,
14 durations?

15 MR. CANAVAN: It's both.

16 CHAIRMAN STETKAR: It's both?

17 MR. CANAVAN: It's both.

18 CHAIRMAN STETKAR: Okay. Thanks.

19 MR. CANAVAN: And the DC tests, I mean
20 every time you perform a test you learn from how you
21 perform the test. And so, the DC tests were a marked
22 improvement over the way the AC tests were performed,
23 both in protocols, information collected, you know,
24 what phenomena to look for, who is smarter?
25 Specifically, RES and Sandia were smarter, I think.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 We came along for the ride.

2 And we were smart enough to get real
3 equipment, real batteries, all the things needed to
4 perform very realistic testing.

5 Fire ignition frequencies, FAQ No. 48.
6 You know, we were looking at the data for ignition
7 frequencies, and there appeared to be a change in the
8 data trajectory after 1990. Really, depending on how
9 you read it and how willing you are to accept risk,
10 the statement in the FAQ response actually says almost
11 verbatim what was presented just a short while ago by
12 Ray, which is, if you use the sensitivity cases and
13 they don't work, if you use the data and it provides a
14 different answer such that you might perform a
15 different action, in other words, it changed something
16 that you have to act on, then you need to use
17 traditional fire defense-in-depth and deterministic
18 evaluations to justify that change.

19 Most utilities that I am aware of have not
20 used this FAQ. They cite that as being the reason.
21 If it provides a change, they have to go back to
22 defense-in-depth and deterministic ways of analyzing
23 it. At least that's what they are reading into it.
24 Maybe I have the wrong interpretation. That's
25 possible.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 But they are reading it, well, that's more
2 work than just going with the conservatism. So,
3 that's what they do. So, to my knowledge, nobody is
4 -- I think there might be one plant that is going to
5 use the different frequencies that I am aware of right
6 now.

7 And again, this was an interim solution.
8 We couldn't come to consensus on a final solution.
9 So, you know, I would look at this as this is not a
10 consensus solution. We believe that we should be
11 using the EPRI numbers. I strongly believe it. I
12 think they represent more how we operate the design
13 as-built, as-operated facilities.

14 I don't see why we aren't reflecting the
15 good housekeeping practices, the Maintenance Rule, and
16 Appendix R in our current data. And if we were doing
17 internal events, we would never keep this data in the
18 internal events because it doesn't represent what we
19 are looking at today.

20 CHAIRMAN STETKAR: Provided you've
21 adequately -- you know, I will throw the independent
22 -- provided you've adequately accounted for the
23 uncertainties and the limited dataset that you are
24 using. And it's not clear, reading your report, that
25 you have. And we'll just leave it there.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. CANAVAN: Okay. Okay. Yes, I am
2 going a little bit anecdotally from having worked in
3 the nuclear power industry for 25 years at the
4 facilities. And the degree of cleanliness
5 demonstrated by Danny Pace the other day was not
6 apparent 20 years ago.

7 CHAIRMAN STETKAR: That's certainly true.

8 (Laughter.)

9 MR. CANAVAN: I was trying to be very
10 nice.

11 (Laughter.)

12 And I also think that some of the other
13 operational programs provide some assurance.

14 Cable tray propagation, 49, the status of
15 this is open. And again, the current guidance for the
16 two configurations wasn't enough. These open other
17 configurations.

18 This one is not explicitly included in the
19 Action Matrix. Some of the items are expected to be
20 resolved in CHRISTIFIRE.

21 CHRISTIFIRE was recently out for public
22 comment. I don't know how many comments the NRC
23 received other than ones from EPRI. We did provide
24 comments on CHRISTIFIRE.

25 CHRISTIFIRE is very interesting. My

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 personal opinion, I will make a short mention here
2 because it is something that I'm thinking of
3 requesting Rick add to the Action Matrix.

4 CHRISTIFIRE comes up with a lot of very
5 interesting observations and conclusions. One of them
6 was, if you remove the source too soon, the cables
7 don't ignite. Too soon is not short minutes. It is
8 tens of minutes. And so, it turns out it is really
9 hard to get cables to ignite.

10 The other interesting phenomenon in
11 CHRISTIFIRE is the cable trays are separated by about
12 more than a foot and a half. And I think I will be
13 corrected if I get it wrong. I see some of the folks
14 in the room. But about a foot and a half. It's very
15 difficult to get the second tray to ignite. You might
16 damage it over a long period of time, but you can't
17 get it to ignite, even with the pilot in place.

18 And then, the last one is that the cable
19 trays are very packed, which also leads me to conclude
20 that if they have a solid bottom or they have some
21 kind of deflector plate on the bottom, that they may
22 not ignite because any good Boy Scout knows -- and I'm
23 stealing this metaphor -- you need to separate your
24 wood to allow for air currents to circulate to make a
25 fire.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 And the interesting thing I noticed, the
2 future follow-on research might be to look at the
3 efficacy of solid plate cable trays as a modification
4 or deflector plates as a modification that could
5 prevent vertical propagation of fire through cable
6 trays in cases where it is really significant, as
7 opposed to going to wraps or other means. Just a
8 thought that that might be a good follow-on.

9 Manual suppression probability, partial
10 resolution. Addressed suppression by personnel in
11 fires. I recall this one. I recall all of these
12 vividly in the process.

13 As a note, each one of the public meetings
14 was preceded by internal team meetings at EPRI,
15 usually phone calls. Then, it was preceded by MOU
16 phone calls. Then the public meeting happened. Some
17 of these were on several public meetings. So, you can
18 only imagine the number of telephone calls and
19 meetings. We did a lot of work. We moved things very
20 far very fast.

21 I think some of our resolution came down
22 to the data, what values to include and what not to
23 include. It became fairly contentious.

24 Again, with a database that has entries
25 that aren't always as specific as they need to be,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 this is going to happen. I'm not going to argue. I
2 have my own opinions about each data point, and our
3 own team didn't always agree on all the data points.
4 However, moving forward, we hope to clear that up.

5 So, again, a partial resolution. We got
6 what I considered to be part of the way. Action
7 Matrix Item 1.6, again, will take the database, and
8 suppression is one of those things in the new database
9 we think we will get a really good feel for. People
10 accurately track that now. In the seventies and
11 eighties, that really wasn't a priority.

12 MEMBER BLEY: I don't want to get into the
13 fingerprinting thing, but earlier someone went through
14 how big a process this was when you had your public
15 meetings and tried to work to consensus. But I didn't
16 quite catch it all.

17 Kind of how many groups were there? The
18 original authors were pretty much part of it. And
19 then, there were several other groups that were
20 mentioned, and I don't remember what they were. Could
21 you just remind me?

22 MR. CANAVAN: Sure. It really depended on
23 the FAQ.

24 MEMBER BLEY: Okay.

25 MR. CANAVAN: So, some of the FAQs were

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 handled by the NEI. The non-MOU FAQs were handled
2 generally by the NEI Task Force.

3 MEMBER BLEY: Okay.

4 MR. CANAVAN: And so, the NEI Task Force
5 met. If there was easy agreement, it was passed up.
6 The resolution was put in the original question. So,
7 the question came with the answer.

8 MEMBER BLEY: And those we heard worked
9 well. Okay.

10 MR. CANAVAN: That was really cool, the
11 question coming with the answer. And if the NRC
12 agreed, they went through quick, and there's a few of
13 those, which is why I say the process works well when
14 the FAQ is appropriate. When the FAQ, when it was
15 clarifications of the methodology, that was a fairly
16 quick thing.

17 The FAQs started progressively getting
18 what I would call more technically-challenging. And
19 so, as they became more technically-challenging, that
20 process wasn't working. Also, now we needed to have
21 meetings of the MOU group, mostly consisting of the
22 authors, to try to agree on how we were going to do.

23 Now the authors at that particular time
24 consisted of very limited industry participation. Bob
25 Kassawara and Bijon Najafi were the two EPRI personnel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 on that meeting. And Bob didn't attend all the
2 meetings because he is in California and most of the
3 meetings were held in Washington. Bijon made a lot of
4 them.

5 At that particular point in time, the
6 questions were pretty substantial. So, we decided to
7 add a few more EPRI people to the team. There was a
8 few more NRC people added to the team as well.

9 And I don't think that was the source of
10 not being able to consent. I think they are just
11 generally tough issues.

12 MEMBER BLEY: Tough issues. Okay.

13 MR. CANAVAN: You know, I respect John a
14 great deal, but I think if me and John were to sit
15 together and look at some of this data, we might have
16 some issues that we needed to work out.

17 MEMBER BLEY: Yes.

18 MR. CANAVAN: You add to that calendar
19 pressure. You add to that fact that there are six of
20 these going on in parallel. The numbers of meetings
21 and consensus because very difficult.

22 The last part is a large part of this was
23 happening in public. The MOU meetings, the "meetings"
24 meetings, were public.

25 MEMBER BLEY: Were public.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. CANAVAN: And so, as soon as research
2 started to be held in public, that was just a really
3 bad idea from every perspective I can think of.
4 Asking people to give their unabashed opinion in a
5 public environment consisting of 60 people, 35 in a
6 room together and 25 on the phone, that was just not
7 -- we probably could have done better is my conclusion
8 on that.

9 So, I do believe that that process is very
10 difficult. We talked a little bit in the last meeting
11 that I believe that research is best started with a
12 small group of technical experts, gradually expanding
13 out. Once they come to some kernel of, hey, this is
14 the idea we would like to pursue, take that a little
15 broader. And if everybody says, hey, that broader
16 group says this is a good idea to move forward,
17 expanding to the next level, and then continuing that
18 expansion up to socialization among the community.

19 But we sort of had a middle ground, and in
20 the middle there was too many new ideas, opinions.
21 And when you have that many, you can't pursue them
22 all. Then, you add the time pressure in. It's all a
23 part.

24 Hot short duration, partially resolved.
25 We resolved it for some AC circuits. We need to post-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 process all that DC data. I think we will get some
2 more insight on AC as well.

3 But, again, I think the DC circuits will
4 go a long way. It will be very helpful. A lot of
5 PRAs currently assume that DC shorts go on
6 indefinitely. So, a time period around those shorts
7 would be very nice to have.

8 And again, this is one of our best
9 examples of cooperation, and we will talk a little bit
10 more about that. But my experience being involved in
11 the DC hot short testing has been a very positive one.

12 Transient fires, you heard all the issues.
13 I don't think I will go through it again. It is on
14 the Action Matrix.

15 I will note right away, again, this is
16 probably one that, if we had taken offline and talked
17 a little bit about, maybe we could have been quicker.

18 I do think that we could probably accelerate this
19 one, and that is something that we will talk a little
20 bit about, because I think there is a recognized need
21 for a new model among everyone from the authors to
22 those who were trying to apply it.

23 And in those cases, there's the incentive
24 that everybody sees a common problem. There is also
25 we have got to be able to come up with a little bit

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 better of a model here, I think, with the collective
2 group.

3 If I have offended anybody with my
4 rendition of the FAQ process, I apologize, but I was
5 deeply involved. I was on almost all those phone
6 calls. Maybe it is more frustration than anything
7 else and a lack of our collective ability to move
8 these things, these technical issues forward in what I
9 consider to be an expeditious manner.

10 CHAIRMAN STETKAR: It's certainly a
11 difficult process, especially in the format that you
12 described, to try to reach consensus. I mean that's
13 perhaps a different format or a different charter
14 rather than trying to reach consensus, but recognize
15 differences of opinion and try to quantify those as
16 sources of uncertainty, you know, as an expedited way
17 to come to an interim solution, if you will,
18 recognizing that further research might enhance
19 reducing those uncertainties. But, again, that is
20 past experience. We are where we are today.

21 And I think it was a good presentation.
22 You know, you highlighted the issues.

23 As I understand it, and correct me if I'm
24 wrong, I think we spoke about this a bit, and it is
25 highlighted a bit in the NEI report, that the industry

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 has basically abandoned the concept of FAQs sometime
2 in 2009. I don't know precisely when. It probably
3 doesn't make any difference about the precise date,
4 but is that true?

5 MR. CANAVAN: It is interesting, that
6 concept. No one was ever told to stop submitting
7 FAQs.

8 CHAIRMAN STETKAR: Okay.

9 MR. CANAVAN: There was no agreed-upon
10 this is the end of the FAQ process date. I think
11 everybody who participated in the FAQ meetings started
12 realizing, if I put this up, I become the champion of
13 the FAQ, right?

14 (Laughter.)

15 Well, I personally volunteer to get my PRA
16 submittal done and be the sacrificial anode for this
17 topic. I think it was really a disincentive. And if
18 you were on some of those meetings, they were
19 difficult and there were many of them. And you are
20 under pressure from your management to get the PRA
21 done. Do you really want to bring up a FAQ?

22 And I wouldn't let you off the hook
23 because you know the issue, and it is your issue at
24 your plant. We have to work together. So, you're
25 going to be stuck.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 So, it was a natural -- nobody has ever
2 been told not to submit a FAQ -- it was a natural
3 stopping because the process stopped itself.

4 CHAIRMAN STETKAR: And if I can read
5 between the lines and from what we have heard both
6 from the staff and you, it seems as though we, as the
7 PRAs themselves became more developed, the questions,
8 the issues become more difficult from a technical
9 perspective.

10 MR. CANAVAN: Yes. That's clear.

11 CHAIRMAN STETKAR: And therefore, from
12 what I have heard, trying to get consensus on the real
13 difficult issues seemed to have been breaking down --

14 MR. CANAVAN: Yes. Yes.

15 CHAIRMAN STETKAR: -- let's say in the
16 middle range of difficulty, if you will. So,
17 pragmatically, I sort of understand that.

18 MR. CANAVAN: And let me caveat my last
19 answer about the process ending for PRA FAQs from the
20 current people who are doing pilots and are active.

21 CHAIRMAN STETKAR: Yes.

22 MR. CANAVAN: So, the other processes were
23 clarifications came in. That continued and worked
24 fine. It was the more difficult issues.

25 The other thing is, if you are doing your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 study and you come across a question and you are
2 trying to figure out, well, I'm the pilot; how am I
3 going to answer this, maybe I'll just submit a FAQ.
4 And then, you think, well, that process is long and
5 difficult, but I have an answer here that I think I
6 have basis for, which is allowed. Maybe I don't want
7 to be the champion for the world. Maybe I just want
8 to get mine, put it in my study, give my
9 justification, and see how the review goes.

10 So, that was the other. You know, I need
11 to get done and put up a FAQ. And then, the pressure
12 on what is the resolution requirements; what's the
13 amount of technical rigor required for solving it for
14 the industry versus solving it for you? Is there a
15 little bit less? Well, yes, because the FAQs get all
16 the "What if's". What if the configuration is
17 different? What if, you know --

18 CHAIRMAN STETKAR: Yes. Yes.

19 MR. CANAVAN: And so, the scope grows.
20 So, in the interest, I think it was a process that
21 wouldn't, as the pilots matured -- now I don't know;
22 we do have a proposal moving forward about how we
23 think we're going to conduct our research, hopefully,
24 with others. And we will be presenting that in a
25 future trial.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Let me ask you one last
2 thing before we go on to the next topic. I think this
3 is a really good summary of the things that I can't
4 call "FAQs" anymore, but are still issues that merit
5 further examination through research, and they provide
6 a basis, part of the basis, for at least the
7 industry's research program.

8 Are there -- I hate to ask this -- but are
9 there other significant issues that have arisen that,
10 were it not for the difficulty of the FAQ process and
11 the timing, et cetera, that the industry believes
12 still need some level of resolution? And I'm not
13 talking trying to make --

14 MR. CANAVAN: Right.

15 CHAIRMAN STETKAR: -- numbers absolutely
16 perfect, precise, well-known. I'm talking about large
17 issues that have come up over the last year, let's
18 say, that are not, for example, in this list, which
19 are effectively derived from the FAQs.

20 MR. CANAVAN: I think if you look at the
21 next presentation that we give --

22 CHAIRMAN STETKAR: Okay.

23 MR. CANAVAN: -- there are no large issues
24 that aren't encapsulated in that list that we're aware
25 of. And I caveat with the "aware of" because I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 struggle with the lack of BWR PRAs being talked about
2 right now, and I do believe, having worked on both,
3 that there may be some challenges. Now the BWRs, they
4 are a little bit more flexible on the core damage
5 side. So, maybe they will be fine and I'm overstating
6 it, but I think there might be a challenge or two in
7 some of the older BWRs that present themselves in a
8 methodological way, you know, a method that doesn't
9 suit them or needs to be revised to suit them.

10 So, with that caveat, I will say that we
11 think that is a full list.

12 MEMBER BLEY: We have heard from various
13 people and in our discussions that Mardy did for us,
14 people doing PRAs who are very concerned about how
15 much effort they need to put in to justifying, if not
16 deviations, special calculations to support their fire
17 PRAs. Is there any effort -- and I know staff is not
18 locked into one once they approve it -- but is there
19 any effort to try to collect the places where people
20 have made arguments and think about building a manual
21 that might eventually work its way into another 6850
22 revision?

23 MR. CANAVAN: We don't have that yet as a
24 specific task, but we have an internal EPRI group that
25 is a forum for fire PRA. And right now, that forum

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 for fire PRA has donated their resources to methods.
2 So, they are just go use our money, do methods.

3 But I have a feeling that in the near
4 future, as more than just the pilot are complete, that
5 that forum will start up and become one of those
6 things that we can collect the technological ones.

7 I see Biff standing, too.

8 MR. BRADLEY: I just wanted to add one
9 thing. We do have, as Ken mentioned, the unreviewed
10 method, the new fire PRA peer review process that
11 kicks the methods out of the peer review to our
12 industry process. So, I think that is partially an
13 answer to your question.

14 MEMBER BLEY: Okay.

15 MR. CANAVAN: That's the next talk as
16 well.

17 MEMBER BLEY: I haven't seen it.

18 CHAIRMAN STETKAR: What?

19 MEMBER BLEY: Their procedure for looking
20 at these.

21 CHAIRMAN STETKAR: No.

22 MEMBER BLEY: Because I hadn't seen it.

23 CHAIRMAN STETKAR: What fraction of the
24 PRAs -- I hear what you're saying -- what fraction of
25 the PRAs out there today, the end of 2010, have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 actually had industry peer reviews performed that
2 could start generating this process? I'm thinking
3 about timeliness and processing.

4 MR. BRADLEY: Well, obviously, we are
5 having a large number of these done rapidly for 805,
6 and quite a number of these were performed before it
7 became clear that we needed to revise the process to
8 accommodate the unrevised methods. Because it was
9 really putting a huge burden on the peer review team
10 to try to come to grips with these methods.

11 So, since we put that revised guidance
12 into place, there have only been, what, half a dozen
13 or less peer reviews? So, it is sort of just getting
14 going. We have had a handful come out. I wouldn't
15 say we have had a large quantity of methods. We do
16 expect to get methods being fed out of that process
17 once we get this thing up and running.

18 CHAIRMAN STETKAR: Okay.

19 MR. WACHOWIAK: This is Rick Wachowiak at
20 EPRI.

21 I have in my hand one proposal from a
22 vendor that has done multiple PRAs for a set of
23 methods that they would like to have reviewed, and
24 another vendor has contacted me and given me an
25 abstract for a method that he wants to propose for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 this.

2 CHAIRMAN STETKAR: So, this is not coming
3 through the peer review process. This is an
4 independent --

5 MR. WACHOWIAK: I think they were
6 identified through the peer review process.

7 CHAIRMAN STETKAR: Okay.

8 MR. WACHOWIAK: And then we are providing
9 this forum or clearinghouse for getting them peer-
10 reviewed.

11 CHAIRMAN STETKAR: Okay.

12 MR. WACHOWIAK: So, it has started, but it
13 is in the initial stages. We have turned the key, and
14 we are waiting to see if the "check engine" light is
15 on at this point.

16 CHAIRMAN STETKAR: Yes. Okay. Good.

17 Any other questions for Ken, as long as he
18 is sitting up there?

19 If not, I think you might as well just
20 stay seated, and we will transition into the research
21 program. I don't know; I guess Rick will join you.

22 MR. CANAVAN: Yes.

23 CHAIRMAN STETKAR: Actually, let me ask,
24 how long is this presentation realistically, do you
25 think? I'm asking, should we take a break now? If

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 you can get through it in about a half-hour, we'll
2 wait.

3 MR. CANAVAN: Yes, we can do it. We can
4 do it in a half an hour.

5 CHAIRMAN STETKAR: Okay.

6 MR. CANAVAN: Yes, I actually will point
7 out that the original talk was designed to answer your
8 question from the last meeting which was, how are you
9 coordinating? So, I will probably start with slides 1
10 and 2, and this being one, and then Rick will take the
11 rest, the hard lifting.

12 And again, I'm here mostly for historical
13 purposes, which is why I get this, because --

14 CHAIRMAN STETKAR: We don't get to see you
15 much. When do you stop?

16 MR. CANAVAN: I won't say "stop". I will
17 say I love PRAs, so I'll always try and come back and
18 see you.

19 (Laughter.)

20 So, if you extend me an invite, I'll come.
21 But --

22 CHAIRMAN STETKAR: This may be your swan
23 song --

24 MR. CANAVAN: This may be it.

25 CHAIRMAN STETKAR: -- in the PRA field?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. CANAVAN: Well, I fear that my
2 usefulness to you is diminishing. So, I will turn it
3 over to Rick.

4 Our PRA research at EPRI is normally
5 driven through an internal EPRI process where we have
6 advisors at the PRA manager level who help us design a
7 research program that we roll up to -- and this is all
8 risk and safety research -- that we roll up to an
9 executive committee that we then roll up to, I'll say,
10 the C&O-type level. So, we go up to Senior
11 Manager/Director, VP, then to Engineering.

12 Outside of that process, we have decided
13 to work all of our fire research through this
14 particular organizational chart. I think I will sort
15 of start from the bottom and work my way up.

16 So, EPRI has a predefined research
17 activity, but anything that comes from either
18 contractors, the PWR, BWR Owners' Group, or EPRI, as a
19 methodology improvement gets given to the Technical
20 Project Manager at EPRI. It used to be me. It is now
21 Rick.

22 And that is for incorporation into the
23 EPRI research program. That research program already
24 has input from the utilities, which is why they are
25 not listed. They are already putting information into

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that. Rick adds external input into the mix, and I
2 write "others" because it could be anybody.

3 There's actually one or two ideas out of
4 this Committee in the last two days that we will take
5 back and figure out, well, how do we work that into
6 our plan? Is it covered? Is it not? So, these ideas
7 come from all kinds of places.

8 The EPRI Technical Manager works for two
9 different groups. It works with the NEI Fire PRA Task
10 Force, and it works with an oversight and peer review
11 team recently formed. I put the names in because I
12 guess you had asked, is that a real team? So, I went
13 out and got real names. And Donnie Harrison, you're
14 laughing, but you're on the list. Okay?

15 (Laughter.)

16 And I asked you if that was okay, and you
17 said you would play.

18 But what we are trying to do is get the
19 core team together of people who will be technical
20 oversight and overview. Now that group will be
21 supplemented by people who have experience given a
22 different technical area. So, if somebody comes up
23 and we are missing some experience on this, a fire
24 model, we will supplement the group.

25 But the thought would be that that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 technical oversight and peer review helps us get a
2 good, solid review of technical research performed by
3 anybody, whether it is performed by EPRI. As a matter
4 of fact, there are panels being exercised with their
5 first big piece of research. It's the HRR research
6 you heard about earlier today. Paul Amico and SAIC is
7 the primary on that, and along with EPRI.

8 So, we are submitting that to our own
9 panel and asking these group of people, give us honest
10 feedback. We've gotten our first set of feedback. We
11 are working the kinks out of the process, and then we
12 will start sort of more of a sort of production type
13 of environment.

14 The purpose of that group is to give
15 feedback to the methods. We will then put them out as
16 interim methods for use. Again, as they are being
17 used, anybody can comment. Anybody can participate in
18 the use, and we will sort of broaden it out, try to
19 get opinions from more folks. Then, anywhere from 60
20 to 90 days to six months, we will make a final --
21 maybe it is a year -- we will make a final report, now
22 that we have evidence that it worked or that the
23 method solved what it needed to solve.

24 We will report up to the Task Force, and
25 we will report up to the NEI Program Manager, which is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 Biff Bradley.

2 I do want to point out there is an
3 executive oversight group. That's why Danny Pace was
4 here. You'll see him. He's on the list.

5 This is by no means, and nobody should
6 interpret this as a rubberstamp-type group. They're
7 looking at what we're doing. They're asking us, how
8 does it help? They're asking very similar questions
9 to you sometimes. You know, are you working on the
10 important issues? How did you decide importance? How
11 much do you want again? That is a question that comes
12 up a lot.

13 When are you going to get finished, and
14 can you get that done sooner? Exactly what you would
15 expect. But there is significant pressure to continue
16 to move these methods. Danny says it very nicely:
17 how much have you spent? To me, it's I spent this
18 much and you need to help me, a little bit different
19 of a statement.

20 So, we are trying to move those methods
21 forward to help these folks who are all in the
22 business of developing PRAs. You notice that Exelon
23 is on there. And Exelon isn't developing PRAs for
24 NFPA-805, the relevant PRAs. And so, their approach
25 is help me get the PRAs get done.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 Last is that executive oversight group
2 goes up to the NSIAC. The NSIAC is the Nuclear
3 Strategic Initiatives Advisory Council, and they're
4 all the CNOs from all the plants. This is executive
5 group reports up to them, and they drag formerly me,
6 soon-to-be Rick, to discuss the status, progress,
7 spending, and when they will see the fruits of their
8 money. I didn't say "labor".

9 So, just so everybody is aware, the Task
10 Force actually does report directly up to the
11 oversight. The dashline is there is actually a
12 separate meeting of the executive oversight group.
13 Every time the Task Force meets, we are required to
14 report up, and we get asked often by that executive
15 group, how can we help?

16 And that's how Danny got here. He said,
17 how can I help? And I said you can come.

18 That was all I had. The rest of this is
19 EPRI fire research in the area of fire PRA moving
20 forward.

21 And I'm going to turn it over to Rick, and
22 he is going to do the rest.

23 MR. WACHOWIAK: So, let me start out with
24 saying that on the original agenda, the topic here was
25 to address the question, how are we going to do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 collaboration? I think it eventually morphed into
2 what is the plan? We will try to address both things.

3 So, the last hour or so we talked about
4 things that happened in the past. And what we want to
5 talk about now is, what do we need to do to move
6 forward with this in an effective, efficient way?

7 So, when we are going to do fire PRA
8 research, and probably any research, not just fire
9 PRA, but we are looking for ways to come up with our
10 more realistic methods. We have talked about that for
11 three days of meetings now. But we still want to
12 maintain the consistency, which is what 6850 and
13 EPRI -- and I don't have the stamp on my brain yet for
14 that yet.

15 CHAIRMAN STETKAR: You've got learn that
16 number, Rick.

17 MR. WACHOWIAK: I know. It looks like
18 everybody else did, and I just didn't quite get with
19 the program.

20 Anyway, so it brought a consistency of how
21 these are done. We want to maintain the consistency.

22 So, we want to try to bring it into some sort of a
23 central clearinghouse-type process, so that it's
24 available for everyone and you maintain consistence.

25 When I was looking at this, I'm looking at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it in terms of, what have we done for internal events?

2 Now I know internal events evolved over several tens
3 of years to get to where we are now, but there are
4 some lessons that we learned from that process to how
5 to solve a difficult problem. So, I want to draw on
6 that experience.

7 As Ken said on the last slide, we are
8 going to rely on peer reviews. We will talk about the
9 expert peer reviews for this, different pieces of
10 this.

11 We would like to participate with the NRC
12 as much as possible in this. One, it allows them to
13 understand what it is we're doing and which ways we're
14 going, understand how we intend to use the methods and
15 how we intend to limit the methods. Because I think
16 some of the contentions in the past, a lot of times
17 around, what's the limitation on this model? And with
18 the participation, you can see what it is we have
19 discussed, and we will get a good understanding of
20 that.

21 Now if the NRC understands what we are
22 doing, and we understand their positions, I think that
23 fosters a stable regulatory environment for using
24 these methods.

25 So, in looking at this, I can see three

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 distinct categories of things we will call research
2 here. The way that we need to collaborate needs to be
3 different based on which one of these you are in.

4 The first one that we have talked a lot
5 about here is the development of methods or models.
6 They all kind of say, how do you do this fire PRA
7 problem?

8 Then, there is testing that has to go on.

9 For this, it's testing to support the methods and the
10 models that we want to use. Then there's also tools
11 that come in. What computer codes can you use that
12 propagate the uncertainty of the distributions that
13 are put into the method, and things like that? So,
14 that is a separate sort of area, the development of
15 those tools.

16 I want to be clear that the methods and
17 models are what we intend to have drive the testing
18 and the tools. You need to have a use for these
19 things before we go off and do a lot of extra testing
20 or start building expensive computer models and things
21 like that. They should be done to solve some problem
22 in this forum here, solve the problem with getting
23 these fire PRAs.

24 And we want to have coordination between
25 all the different groups, including the owners'

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 groups, the NRC, industry, and all sorts of things we
2 have talked about.

3 So, let me start with the easy one, the
4 tools research. The way we have done this for
5 internal events is the industry identifies the tools
6 it needs to do its work. Mainly, it is to address how
7 you efficiently do your work, and we go off and we
8 develop our own tools independent of the NRC. And as
9 a matter of fact, the NRC goes off and develops its
10 own tools independent of the industry.

11 And that's probably a good thing. It
12 helps with independent verification and things like
13 that. We're not looking at a lot of collaboration on
14 this type, but recognize that it's out there.

15 Go to the next one.

16 In the experimental area, really it's
17 based on looking at what methods and models we want to
18 implement, but anybody really can identify this. The
19 industry would identify testing for things where it
20 wants to use a method and maybe not enough data is
21 there. The NRC identifies, okay, industry is using
22 this method; we don't know if we can accept it because
23 there might not be enough data there.

24 So, in that vein, it is to address
25 uncertainties, things where there's large

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 uncertainties in the methods or in the data that
2 supports the methods.

3 These tend to have a long timeframe for
4 getting done. They are a long timeframe. They are
5 expensive. They are very involved.

6 But I think here is where we really need
7 to have the highest level of coordination between the
8 industry and the NRC so that we all make sure that we
9 get what we need. So, like I said, we are trying to
10 use methods for making the submittal. The NRC is
11 trying to use methods for approving a submittal. It
12 is a slightly different look at this, and the testing
13 that needs to be needs to be able to suit both needs.

14 Go to the next slide.

15 So, the conceptual model that we have
16 here, and I think this is what we're using in the
17 DESIREE-FIRE test, is that we've got a defined scope
18 of what it is we are going to do the testing on, okay,
19 and what parts of the models that we're using are we
20 going to address? What's the applicability going to
21 be? Do we need to use real equipment from plants?
22 You know, all those sorts of things need to be
23 factored in ahead of time.

24 We want to identify the phenomena that is
25 going to be investigated. We are not just out testing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 because we like to watch things burn, even though that
2 may be part of it. But we do have a specific thing
3 that we want to look at or that we want to get out of
4 this.

5 We need to identify what the parameters
6 for the experiments are upfront, so that in the end
7 they can be used in the methods that we think that we
8 want to use.

9 Then, when we're done, we need to have an
10 expert panel-type review of the results. In the one
11 that is going on right now, there are actually two
12 panels because it is a combination of the application
13 of the testing is for fire modeling and for fire PRA.

14 So, we have two sets of expert panels that cover both
15 of those technical fields that are looking at these
16 experimental results.

17 One of the things that I think we have
18 learned from the past is that we get the test in; we
19 probably ought to have the experts look at it and
20 provide the interpretation before we start going out
21 and publishing a lot of reports and things like that,
22 so that the results, as interpreted by the experts,
23 are actually the results that are out on the street
24 and are being used. This process works great for the
25 expert panel sort of process.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Then, we get into the methods and model
2 research. The way that the fire PRA Action Matrix is
3 set up, and the new Methods Review Panel is set up, is
4 really that somebody identifies a method, a model that
5 is needed, address realism, address efficiency,
6 address anything that we think we need to have; there
7 needs to be a justification or a reason for why we
8 want to do it.

9 Typically, they are going to come in as
10 generic, application-specific, plant-specific. We
11 like to move things toward the generic or application-
12 specific because plant-specific it's hard to get a
13 team really interested in resolving just plant-
14 specific issues. And maybe that is better done in the
15 license applications. But if we can make it into a
16 generic or application-specific but industry-generic
17 issue, that would be the type of thing that would be
18 in there.

19 And the need for coordination on this with
20 the NRC really depends on the topic. If it is
21 something that is really critical in license
22 applications, maybe there needs to be more
23 collaboration. If it is things that are for more how
24 you address how to do a model more efficiently or how
25 to get a PRA done more efficiently, no, maybe not so

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 much in that area.

2 Go to the next one.

3 So, basically, what we're trying to do
4 here is anybody proposes something. Our model is that
5 they propose it to EPRI. We have already shown that a
6 couple of things have happened there. We pre-proposed
7 some things that are in the Action Matrix to go
8 through this.

9 Ken said, you know, one of the downsides
10 for having somebody propose these is that they get to
11 be the champion. They have to be the champion. As
12 much difficulty as that brings or disincentives is
13 that is for people bringing things out, it is the only
14 way for it to work.

15 They need to define why they need the
16 method. Okay? What is the problem that they are
17 going to solve? We need to have examples of how it is
18 resolved.

19 Eventually, we would think they would be
20 the one to draft a report in collaboration with EPRI,
21 and there's the expectation that anything that comes
22 through this is going to be public.

23 I did leave one thing off that list that I
24 realized here in this set of meetings. They really
25 also need to define how they think this method or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 tool, or this method that they want to use, how it
2 impacts the other areas in 6850, because they are the
3 ones that would best know that from trying to
4 implement it first.

5 And second, it gives the reviewers, which
6 will come into this later, a little guidance as to
7 where to go and look to see, is it really affecting
8 it? Is it affecting something else? Did we miss
9 something? So, that's important there, too.

10 My intent is to, when we get these things
11 in, make the abstract, if you will, the description of
12 what we're trying to solve publicly available, mainly
13 because I want to get a sense from the industry out
14 there how generically-applicable is this, who are the
15 right team members to bring in, and if there's a lot
16 of interest or very little interest. So, to help set
17 the priorities for these. It will also help us
18 determine what are the right qualifications for the
19 expert panel that follows up.

20 Go ahead.

21 We have an expert review panel. We would
22 upfront define the qualifications needed for the
23 members, the expertise, and knowledge, subject matter
24 knowledge. I really think in that, for these types of
25 things, a small handful of people, six to ten members,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 is probably the right size to look at these things and
2 make sure that we are on the right track for it.

3 Once again, NRC would participate. But we
4 still want to make sure that the participation is
5 subject to the qualifications, just like we're going
6 to subject ourselves to the same qualifications.

7 The intent is to have the deliberation of
8 these expert panels published as part of a method.
9 The exact form of that we're still working on.

10 CHAIRMAN STETKAR: But that would include
11 some documentation of the arguments?

12 MR. WACHOWIAK: Documentation of the
13 arguments, absolutely. That's really what I'm looking
14 for there.

15 MR. CANAVAN: It might be meeting minutes.

16 MR. WACHOWIAK: Yes.

17 MR. CANAVAN: It might be meeting minutes.

18 It might be summaries of meeting minutes.

19 MR. WACHOWIAK: Probably summaries of
20 meeting minutes, but the intent, though, is for the
21 major issues to come out, and especially the things
22 that define the boundaries and limitations of the
23 models we want to have on the record to say, okay,
24 this is what was deliberated; we say it's okay to use
25 it in this area. It's maybe not so okay to use it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 here. We didn't even consider it over here. And the
2 people who are using these methods and the people who
3 are reviewing models that use these methods need to
4 know that information.

5 There's probably going to be iterations on
6 these things. I would be extremely surprised if all
7 but the simplest one don't involve some sort of
8 iteration.

9 I think I talked about boundaries enough.

10 In the end, we'll publish the method or
11 the model to be used. Joint publication under the MOU
12 is always an option for these things, but I don't know
13 that it's a requirement. In the internal events area,
14 it's almost never done that way. So, you know, it's
15 an option, but I don't think it's a requirement,
16 though.

17 Go ahead.

18 So, in doing this, we think we can provide
19 a structured, understandable, and scrutable framework
20 for these methods and to distribute it out for people
21 to use the most latest information.

22 I think that came up earlier. Where do we
23 get these things? It's got to be informed by the
24 needs of the users. And there is limited research
25 money on everyone's side. We want to make sure that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 we target it on the things that are going to affect
2 the PRAs the most.

3 The last thing or the two last bullets on
4 there, we think that this method, this framework is
5 consistent with what's being done now with internal
6 events and where we've gotten to in the end, where the
7 industry develops the methods and models, and in the
8 review phase, so we bring in the NRC.

9 And finally, the Action Matrix today is
10 actually being run under this at least a reasonable
11 approximation of this framework. As we tighten things
12 up here and try to go faster, we are going to need to
13 have a structured process, so that we can consistently
14 track and make sure we're getting the products that we
15 need.

16 So, the next part I have on here is the
17 list of the things that we are working on, and I --

18 MEMBER BLEY: Rick?

19 MR. WACHOWIAK: Yes, go ahead.

20 MEMBER BLEY: Because you get to these,
21 and you just said -- I guess we started going faster.

22 On each of the next few slides, because each one is
23 on a topic, could you give us your best thoughts about
24 when some of these will reach fruition?

25 MR. CANAVAN: There are dates associated

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 with every activity as well as a budget.

2 MEMBER BLEY: Okay. I didn't see that in
3 the package.

4 MR. CANAVAN: We didn't provide you the
5 full matrix.

6 MEMBER BLEY: Okay.

7 MR. CANAVAN: We sent it to the staff, I
8 believe, well, RES.

9 CHAIRMAN STETKAR: It's actually in
10 Appendix B of the NEI report.

11 MEMBER BLEY: Oh, is it? Oh, I've got
12 that right here.

13 MR. CANAVAN: It's totally printed out,
14 right?

15 CHAIRMAN STETKAR: It's actually got
16 color-coded bars on it, color only for --

17 MEMBER BLEY: I forgot. I've got this
18 sitting right here. Thank you.

19 MR. WACHOWIAK: So, if you're looking for
20 the approximate timeframes for these, you know, that's
21 listed by quarter. So, you can see today -- this is
22 why the Action Plan is difficult to put into a report
23 like that. That's a snapshot of where we are today
24 with this.

25 If, for some reason, something has to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 change in priority because there is new information,
2 we will have to change it. You know, that's just the
3 nature of these things. But you do have that list,
4 and each of these are number-coded. So, you should be
5 able to see.

6 On these particular slides, these are the
7 X/Y-level headings. I think on the bar chart it is in
8 the X/Y/Z-level headings. So, there are subtopics to
9 each of these.

10 MR. CANAVAN: Sorry about the size of the
11 matrix.

12 MEMBER BLEY: It's all right.

13 CHAIRMAN STETKAR: That's okay.

14 MR. CANAVAN: Excellent.

15 MR. WACHOWIAK: The first part of this is
16 the initiation, detection, suppression focus. We
17 talked a lot this week about the fire events database
18 and how that is really the glue for this first part.
19 We are going to look at fire ignition frequencies,
20 take a look at incipient fire in cabinets, and how
21 well incipient detection can be used for the various
22 fire categories.

23 We are looking at oil fires. A second
24 topic on incipient detection is, where can it be
25 credited? I think I mentioned that when I did the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 first bullet.

2 And also, getting a better
3 characterization of the fire suppression curves that
4 are used to generate the probabilities in the PRAs.

5 The second area, a lot of things here in
6 terms of damage assessment. We've got the growth,
7 fire growth, and comparing that with the data that is
8 out there.

9 MEMBER SHACK: Just out of curiosity,
10 Rick --

11 MR. WACHOWIAK: Yes?

12 MEMBER SHACK: -- just looking at these
13 priorities, I assume you've got so many highs here
14 that the lows and the mediums are going to be dropping
15 off the chart.

16 MR. WACHOWIAK: Well, let me say something
17 about the priorities that you have on the list there.

18 The priorities were what we thought we could get done
19 that was substantial work that we had ahead of us in
20 the timeframe one or so years out there. Okay?

21 But one thing we knew for sure was the
22 database needed to be done. That's the highest
23 priority of everything because it really is the driver
24 for all the rest of these things So, we knew that.

25 Then, the other ones, we looked at, what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 can we accomplish in the timeframe coming up right
2 away? Those were marked as high. And, then, we tried
3 to apportion out the mediums and lows to the other
4 things that were there, and the approximate timeframes
5 that are shown on there. And for those that don't
6 have the report in hand, it's about a three-and-a-half
7 year plan.

8 We don't intend to drop anything off that
9 plan --

10 MEMBER SHACK: It stretches out?

11 MR. WACHOWIAK: It stretches out. And we
12 may be adding things to the plan. So, something might
13 come off if other things get added.

14 MR. CANAVAN: And it might stretch. You
15 know, budget concerns moving into 2011 were our
16 biggest concern. However, we received -- they have
17 been informally approved. I don't know what that
18 actually means, but that's what I was told.

19 (Laughter.)

20 And informally approved for our funding
21 for 2011, which was a substantial increase from 2010.

22 MR. WACHOWIAK: To cover the things that
23 are on that chart that you have in front of you that
24 show in 2011.

25 MR. CANAVAN: But there's no guarantee for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 2012. And informally approved actually doesn't appear
2 to be a guarantee, either.

3 (Laughter.)

4 MEMBER BLEY: It doesn't quite sound like
5 it.

6 MR. WACHOWIAK: I'm going to take it as
7 approved. I'm going to let Ken worry about the
8 informally part.

9 MR. CANAVAN: Yes, that's my job.

10 MR. WACHOWIAK: I think we have talked
11 about most of these things here at some point in time
12 today. So, I don't know that I need to go through the
13 complete list, unless somebody wants to stop me on one
14 of them.

15 CHAIRMAN STETKAR: Yes, I will.

16 MR. WACHOWIAK: Okay.

17 CHAIRMAN STETKAR: Only because I'm trying
18 to understand. You know, you address sort of our
19 questions from November about the concepts of
20 coordinated research or collaboration between the
21 industry and NRC in some of these areas. I'm going to
22 pick up on the poster child that we have been
23 discussing, the cabinet peak heat release rates, which
24 is an example, but, again, it's an example that is
25 driven by what we are seeing at least from those

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 nearly-completed PRAs.

2 We heard this morning that the approach
3 apparently under this program from industry is to have
4 an industry contractor develop a model for estimating
5 heat release rates based on parameter characterization
6 of cabinets. I noticed on the timescale that, for
7 some reason, there's only one of the three subtasks.
8 Review of available data, I'm assuming that is done
9 or, for some reason, we don't look at it for five
10 years.

11 The second one is treatment for
12 ventilation-limited cabinets. That one shows through
13 the end of about mid-year next year. And, then,
14 there's a gap of about two years, and it picks up
15 again in the mid-2013 to end of the first quarter
16 2014. And, then, there's something that says testing
17 plan as needed that's blank over the next four years.

18 My question is that a lot of what we heard
19 this morning was the fact that we are using old test
20 data that may or may not -- the tests may not have
21 been developed specifically for the purposes that the
22 limited data are being used now. There is some other
23 limited test data that may or may not be applicable
24 from VTT and IRSN.

25 I have heard, and I think we are going to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 hear from the staff a little bit about the staff's
2 research program, which I know does include some
3 amount of cabinet heat release rate testing.

4 My question is, do I now, as a third-party
5 interested observer, have confidence that the efforts
6 that are being undertaken by the industry and the
7 staff are the most efficient and productive use of the
8 available collective resources to answer this
9 question?

10 And basically, in a sense, you're headed
11 in somewhat different directions.

12 MR. WACHOWIAK: I'm not sure that that is
13 really the case.

14 CHAIRMAN STETKAR: Okay.

15 MR. WACHOWIAK: Let me try, and you picked
16 a great example of one to look at here because we will
17 be able to touch on a lot of different things with
18 this one.

19 CHAIRMAN STETKAR: Okay.

20 MR. WACHOWIAK: Now the first topic, it
21 doesn't have a bar here because it's done.

22 CHAIRMAN STETKAR: Okay.

23 MR. WACHOWIAK: We're done with that piece
24 of this.

25 CHAIRMAN STETKAR: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WACHOWIAK: It fell off before this
2 snapshot was taken. Okay. So, maybe that's something
3 for me to say, how do I identify on these summaries
4 when things are done?

5 CHAIRMAN STETKAR: No, that's fine. It
6 starts December -- no, it's fine.

7 MR. WACHOWIAK: So, the next piece is the
8 report that we're generating now, and in all these
9 cases we have the intent of generating the report,
10 getting it out into the field, and being used in pilot
11 manner, if we need to. In the initial phase, maybe we
12 put a pilot as part of the initial report, maybe not.

13 This has aspects of a pilot based on who the
14 contractor was.

15 But we want to pilot these things. We
16 want to get them out in use. We want to get the
17 feedback back into how it was used, what are the
18 problems with it, what else needs to be done with it.

19 And, then, our intent is about every year and a half
20 to go back and look at these things, at least in the
21 foreseeable future. Maybe we have to do it again or
22 do an update.

23 CHAIRMAN STETKAR: That's why it's
24 pickup --

25 MR. WACHOWIAK: That's the other one. So,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you will see in a lot of these reports there is a
2 year-and-a-half-or-so gap, and, then, there's another
3 phase to it.

4 CHAIRMAN STETKAR: Okay.

5 MR. WACHOWIAK: Now the testing as needed
6 part, we touched on something in here. We recognize
7 that there are limited tests that are out there, and
8 we are basing this report on the tests that were
9 already done.

10 CHAIRMAN STETKAR: Right.

11 MR. WACHOWIAK: Okay?

12 CHAIRMAN STETKAR: Yes.

13 MR. WACHOWIAK: To get something out now,
14 that is what we can do. But we have in the matrix
15 identified that, if we realize during either the peer
16 review process that we put too many constraints on the
17 use of this method because of the sparseness of test
18 data or the uncertainty is much too large because of
19 the sparseness of test data, then it is our intent to
20 identify what further testing needs to be done to
21 address that. Then, we will factor that in as we go
22 forward.

23 But, once again, I think you said it. We
24 don't want to solve the world here. We want to solve
25 things in pieces that can get out and be used and have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 trial periods now, so we can get the feedback in a
2 timely manner, and recognizing where those things
3 might come in.

4 So, this is one where we recognized that
5 there is this additional testing task. We don't have
6 the testing identified today, but we know that there's
7 probably going to be something in that line
8 eventually.

9 CHAIRMAN STETKAR: It's your program, but
10 I'm mostly concerned about timeliness and collective
11 resources.

12 MR. WACHOWIAK: Right.

13 CHAIRMAN STETKAR: And, for example,
14 obviously, there's a lot of thought that goes into
15 this. You have selected the modeling approach.
16 Perhaps if the resources required to develop that are
17 relatively small, and you can generate something and
18 get it out for comments, that's fine. I sort of
19 understand that.

20 MR. WACHOWIAK: Yes.

21 CHAIRMAN STETKAR: If it's a reasonable
22 amount of resources, I don't know how long the program
23 -- and I don't care because it's your resources. But,
24 for example, if there's a high risk that when the
25 report is published, that there will be so many

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 questions by either the staff or your own internal
2 review committees, the question is, are those
3 resources well-spent? Is it the most productive way
4 to get to eventual resolution on some of these issues,
5 such that the people doing the PRAs can have some
6 confidence that over the next period --

7 MR. WACHOWIAK: And you're bringing up
8 excellent questions.

9 CHAIRMAN STETKAR: -- there will be a
10 staff and industry perspective.

11 MR. WACHOWIAK: Right. Now I think the
12 way that we are trying to address this is, at first,
13 when we got into this, it didn't look like that we
14 were going to have difficulty with the sparseness of
15 data here. It looked like, at least in the initial
16 way through it, it looked like it was a pretty, I
17 wouldn't say easy, but a doable thing.

18 And we got through the first round with
19 it, through the initial development of the paper, and
20 it was reviewed internally with the contractor. And
21 it looked like everything was going to work out okay.

22 We got it to the industry portion of the
23 peer review group first, and I think we have mentioned
24 this before. I wanted to work the bugs out of the
25 peer review before we started bringing in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 additional people.

2 We did find something that, granted, if we
3 had given this presentation last October, this line
4 would be done now -- but it's extended -- or at least
5 close to done now. But it is extended out there
6 because it's not quite as easy as what we thought.

7 Okay, that doesn't mean that it is not
8 correct. It just means it wasn't as straightforward
9 as we thought. So, we will get through that part of
10 the process.

11 And as we get to the revision of the
12 report that incorporates the first peer review
13 comments, this is where we will bring in Donnie and
14 his group to identify who are the right experts that
15 they have to look at this. And I'm sure they will
16 have someone that wants to look at, are you
17 interpreting the data right?

18 CHAIRMAN STETKAR: And this one, in
19 particular, though, that would occur, if I look at
20 this timeline, roughly, soon or six months from now?

21 MR. WACHOWIAK: No, soon.

22 CHAIRMAN STETKAR: Soon? Okay.

23 MR. CANAVAN: Soon, very soon.

24 CHAIRMAN STETKAR: Okay.

25 MR. CANAVAN: Just another comment, taking

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it one level up, back to what you asked, which was you
2 started off with the confidence part. And I think we
3 will provide the schedule on a regular basis to
4 anybody who wants it. So, we are providing the plan
5 to anybody to add to it and to be aware of when they
6 can participate. We are going to update on a regular
7 basis and make it available.

8 The other part is you see this method in a
9 lot of your other questions related to resources.
10 Your questions are great because we did the exact same
11 exercise. So, we could go back through suppression
12 curves again. It's partial, right? It's a partial
13 response. If we go back to the FAQ, we could say
14 these are the data points we don't like. What happens
15 when we take them out? Try and convince the staff
16 again. There's a whole bunch of things we could do
17 now, or we can wait for the database, where we think
18 we will have much better evidence.

19 So, the question is, if it could be done
20 really quick, and it would benefit people right now,
21 then we might put it on the list. But if it is going
22 to bring up more questions, if it is not going to get
23 a resolution, if it is going to be wasted time and
24 effort, we ask ourselves those questions very early in
25 the process. And, then, we say it's not worth doing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 it early; we're just going to do it late. We're just
2 going to wait for the database. We are going to do it
3 right after the database.

4 So, I think we make those decisions in
5 this on a regular basis. You will see a few loops in
6 here where we choose to do early and late as well.
7 And you will see ones, like in this case, or you will
8 see ones where we chose not to do anything early --

9 CHAIRMAN STETKAR: Okay.

10 MR. CANAVAN: -- and we just stuck with
11 what we had.

12 CHAIRMAN STETKAR: Okay. Thanks.

13 MR. WACHOWIAK: Okay. In the area of the
14 fire impact scenarios, we talked about the AC and DC
15 hot short probability and duration. That is being
16 addressed probably as we speak.

17 The human reliability; there's some issues
18 on control room modeling, and what I titled in the
19 matrix as unrealistic model simplifications, but these
20 are those things that are out there that we have
21 talked about before, like always assuming there's a
22 plant trip if you have a fire and always assuming that
23 things like ventilation fail at time zero, when it may
24 take a long time for the fire to develop to where the
25 ventilation ultimately fails and, then, the things

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 supported by the ventilation fail down the road. So,
2 there are a handful of those things that are out there
3 that are kind of grouped into this one bin.

4 CHAIRMAN STETKAR: Okay.

5 MR. WACHOWIAK: And, then, finally, we
6 have our support of other activities. So, you can see
7 what we are doing with those, but there's a lot of
8 ongoing things that we intend to continue doing.

9 CHAIRMAN STETKAR: Good. Any other
10 questions?

11 Good. Thanks.

12 MR. WACHOWIAK: So, one of the things that
13 I think maybe in terms of time we had later is, what
14 is it that we have high priority now and what is it
15 that we are doing right now? What are the interim
16 things that we are trying to get out? It might be
17 just easiest for me to go through those right here.

18 CHAIRMAN STETKAR: Yes, if --

19 MR. WACHOWIAK: It will only take a few
20 minutes. I don't have slides for these things, but
21 all the activities you have just seen. They are all
22 listed there already. So, it is a subset of those
23 activities.

24 The high-priority things that we are doing
25 in 2011, obviously, is the fire events database and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 getting the plant-level frequencies out of the fire
2 events database with the new batch of data. That's a
3 high priority.

4 Also, addressing the non-suppression
5 curves based on the information that we get from
6 gathering all that data from the plants for the
7 database.

8 The heat release rate report that we just
9 talked about a minute ago, that is a high priority,
10 mainly because we think we are close to doing that and
11 we think we can get something out this year that
12 people could actually use in the fire PRAs that they
13 have developed now because it's a drop-in piece for a
14 part of 6850.

15 The transients, including hot work, to
16 really identify what's the right heat release rate to
17 match what the experience of the transient fires that
18 we have seen, that has got to be done. There is just
19 a disconnect there that I think we all agree that that
20 can probably be cleared up, once we have the
21 information from the database.

22 Also, something in terms of the likelihood
23 of the different type of fires that we have out there,
24 that's all tied into that.

25 On the oil fires, we think that we can get

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that, the heat release rate on the oil fires resolved
2 for the pumps, as an extension, diesel generators, and
3 the indoor oil-fueled transformers, the big ones in
4 the yard that's not part of this. It is the things
5 that have a potential to impact other equipment in the
6 room located next to them.

7 That's actually one that the PWR Owners'
8 Group is working on, and they are getting to a state
9 where it is ready to be reviewed here soon.

10 And, then, finally, another owners' group
11 activity that is going on that is tied into the matrix
12 is the propagation of fires within the electrical
13 cabinets, not the one we talked about before as to how
14 does it get out, but what actually is going on inside
15 the cabinets for different industry standard cabinet
16 types?

17 They want to look at, what's the potential
18 for propagation within the cabinet of something like a
19 relay cabinet versus MCC versus a switchgear, and
20 things like that.

21 CHAIRMAN STETKAR: Okay. I understand
22 that. But, as a practitioner, it is not at all clear
23 to me, if I plant with 1330 cabinets, that that's
24 going to be awfully useful to me, or even if I have 50
25 different cabinets, because I have never seen a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 generic cabinet in my life, except in the new standard
2 plant designs they tend to look a little more
3 standard.

4 MR. WACHOWIAK: Yes.

5 CHAIRMAN STETKAR: I'm assuming --

6 MR. WACHOWIAK: They have the luxury that
7 they don't have to worry about other people's
8 decisions.

9 I haven't seen the report yet. So, I
10 can't tell you specifically how that's going to be
11 addressed, but the intent here is to identify things
12 that the PRA practitioners can use. We don't want to
13 put out a method that is out there that somebody
14 goes --

15 CHAIRMAN STETKAR: That's good. I
16 certainly hope so.

17 MR. WACHOWIAK: -- you know, "I can't do
18 this." It's intended to be used by people who can
19 identify that their cabinet is configured like this
20 thing that we have analyzed.

21 CHAIRMAN STETKAR: Okay.

22 MR. WACHOWIAK: So, those are our interim
23 priorities.

24 CHAIRMAN STETKAR: Good. Questions?

25 If not, thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And I think it is time for a recess. So,
2 we will recess now until 3:10. We are doing okay on
3 time. We had time built in at the end for open
4 discussion. So, I think we are doing fine.

5 We will recess until 3:10.

6 (Whereupon, the foregoing matter went off
7 the record at 2:54 p.m. and went back on the record at
8 3:15 p.m.)

9 CHAIRMAN STETKAR: Okay, we're back on the
10 record.

11 I guess we'll hear about the NRC fire
12 research. For the benefit of the members who weren't
13 here in November who are not here now, we heard quite
14 a bit about the research plan. So, I don't think we
15 need to go over what we have heard before. Let's see
16 if we can focus a little bit more on some of the
17 topics that came up in the November meeting.

18 And with that, I will turn it over to,
19 Christiana, I guess you or Mark, one or the other.

20 MS. LUI: Yes, thank you.

21 Good afternoon.

22 Well, in my own interest, I will keep this
23 short, too, because I am about to lose my voice. So,
24 five to ten minutes.

25 MR. SALLEY: Yes, it won't be so much.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. LUI: These are the results I've
2 gotten so far, anyway.

3 Before we go into the different activities
4 the Office of Nuclear Regulatory Research is doing to
5 support NRR, just a few very quick remarks about how
6 we focus our work and the ways that we actually get a
7 job done.

8 So, what we do is that we really focus on
9 NRC's regulatory needs. We establish a technical
10 basis, defensible technical basis, to support the
11 regulatory product development. And in particular, we
12 are aiming for clarity in the guidance documents.

13 And although everybody likes to go into as
14 much detail as possible, our first order of business
15 is really to focus on safety-significant and
16 generally-applicable situations.

17 Although we do have different roles and
18 responsibilities compared to our licensing offices, we
19 work very, very closely to establish the regulatory
20 research priority in terms of shaping our programs.
21 So, the three noticeable criteria that we use is the
22 agency one, the agency-mandated program, any short-
23 term needs, and also longer-term outlook.

24 And how do we actually get there?
25 Clearly, we have in-house analyses. We also have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 contractual support. We clearly leverage on our
2 domestic and international collaborative efforts. And
3 in terms of how do we pursue that, we identify common
4 development interests, and we also build on strength
5 offered by different participants.

6 Some of the programs that you have heard
7 about that I didn't talk about in these two days is
8 the DC circuit testing. That is one particular
9 success example that we can really cite where the
10 industry comes up with the actual operational
11 equipment that we can use while our strength is in the
12 test protocols. And our goal is to continue to be
13 transparent, traceable, and be open.

14 One slight clarification, I really want to
15 offer that some of the statements that we have heard
16 in these two days referring to the MOU process, some
17 people say that it is too public; some people say that
18 it is not public enough.

19 What we do is that, in general, whenever
20 we develop joint products with the industry, we do put
21 our product out for public comments. And very often,
22 if we are jointly conducting a test program, where
23 should we put all the test protocol for public comment
24 once that we have a technical team work together to
25 actually build our strawman?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So, we continue to look for opportunities
2 to get all stakeholder involvements. That's in the
3 past; we are not doing that now, and in the future we
4 will continue to do that.

5 In terms of priority, we do meet with NRR
6 on a quarterly basis to go over the status and also
7 the priority of the program. As needed, we do adjust
8 the priority.

9 So, what Mark is going to talk about in
10 the next couple of slides are our current research
11 program and how these activities stack up in terms of
12 priority.

13 MR. SALLEY: Okay. Thanks, Chris.

14 Last time we met, John, I gave you a
15 pretty detailed presentation about a lot of the
16 different programs. I will be happy to answer any
17 questions on that, but, again, I don't want to repeat
18 the presentation we gave you.

19 What Chris and I discussed when we put
20 this together for you this time was the message we got
21 was priorities. What are our priorities? So, I
22 focused, quite simply, on our priorities.

23 And these priorities, again, as Chris
24 stated, are worked out with NRR. Of course, we will
25 start out with the high-priority items, and they are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 in no particular order. Okay? Once they fall into
2 the high-priority bin, they're in the high-priority
3 bin. So, this is just a random ordering.

4 One of the first key things is the PRA
5 training. Again, this is something we work with EPRI
6 in the partnership of training the methods on CR-6850.

7 We hold two sessions a year. We are now up to four
8 sessions. We have added the HRA piece. Next year we
9 are looking at adding a fire modeling class. So, that
10 continues to grow. It continues to get very good
11 turnout.

12 We take turns holding it. So, it is truly
13 collaborative. This year it was the NRC. So, they
14 were both held in the Washington area. And next year
15 EPRI will sponsor it, and it will be, again, free to
16 the public. It is held as a public meeting forum.

17 Updating CR-6850, that continues to be a
18 challenge. We did issue Supplement 1. So, the FAQs
19 that affected it have all been collected, catalogued,
20 and that is issued as Supplement 1.

21 As I discussed to you last time, the big
22 challenge is going to be, how do we advance the state-
23 of-the-art, and I would really appreciate your
24 feedback. You know, if you think a modular approach
25 would be something that we could go for or do we need

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to try to do a whole full revision of the document?

2 Again, part of our mission is the long-
3 term support. As the new challenges come up with
4 50.48(c) for NRR, we are there to support them in any
5 way we can, answer questions, find things for them.
6 Whatever support they need, that is one that is a high
7 priority for us.

8 The fire modeling applications guide, as I
9 discussed last time, the joint project with EPRI and
10 NIST, the V&V was a challenge to do. That was a hard
11 project. And I thought the fun part, being an old
12 fire modeler, was going to be to write the
13 applications guide. But, boy, I'll tell you what.
14 You get about half a dozen good fire modelers in a
15 room, and I think they can rival the PRA on this.

16 But that program, it's moving along. A
17 lot of good ideas. It was done last January, went out
18 for public comment. It got a lot of comments. The
19 team is back reworking through the comments. They are
20 close to having it completed again, and discussions
21 with Ken was that, because there was so much industry
22 interest in it, that when this draft is completed, we
23 will put it out again for 30 days public comment
24 again, to let the commenters see how we resolve their
25 comments and make sure that everyone is happy with it,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 and we have a good applications guide.

2 So, I am really expecting next month to be
3 getting that real close to being on the street; if
4 not, for sure in January. But that program should
5 finish up this summer as a completed document.

6 As a note, too, I would like to keep that
7 team together, and we've got a lot more for the V&V as
8 we progress. So, I think we can actually roll into
9 the fire model V&V, which is NUREG-1824, and start
10 expanding that a little bit. That is something Rick
11 and I will talk about as we do our future planning.

12 DC circuit testing, the DC circuit testing
13 is complete. The draft report has been written. We
14 have moved around a little on our priorities. We are
15 not in a hurry to get that draft report out. The
16 testing is done; the data is there. It is really now
17 fed into the expert panel.

18 We have the two panels that you have heard
19 mentioned. The first panel was a PIRT panel that we
20 are running. It is a nice group. We've got eight
21 members on it, four from the regulatory side, four
22 that EPRI has supplied from the industry side.
23 Brookhaven is running the PIRT.

24 They have had their first meeting. So,
25 they are started off. I sat in on the meeting, and it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 was a very good meeting. You could feel the interest
2 of the people in there and the expertise. So, Rick, I
3 think you would say the same thing. You say in on the
4 first meeting, too.

5 So, that program is started. When that
6 completes, which will be in the spring with the
7 electrical portion, we will go into the PRA
8 applications, and that will answer the questions about
9 the DC circuits, as well as any updating to the
10 spurious actuations for the AC.

11 And again, this program, it's in play
12 right now. We're really looking at the final two
13 reports being issued by Brookhaven, which will
14 probably be in the summer or early fall of next year.

15 So, that program is working away. And that covers
16 the next one.

17 The fire events database, again, that is
18 really an EPRI program. They hold the data. So, we
19 are there to support them. I believe talking with
20 Steve and J.S. that, while they are here, they are
21 actually going to do a little audit, I guess, and work
22 with the folks from EPRI and see how the data is
23 coming together and to make sure that we are all in
24 alignment with that. So, that program, it's EPRI-
25 controlled, and it's moving along.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 One that we had from NRR directed by the
2 Commission is the fire protection metrics. John, I
3 think I sent you an email with that one.

4 CHAIRMAN STETKAR: Probably.

5 MR. SALLEY: Yes, and this is the one
6 where we capture three things. We capture the fire
7 vents that were sent in versus via the LER program.

8 CHAIRMAN STETKAR: Yes.

9 MR. SALLEY: And the second thing we would
10 look at is the inspection findings, where we will
11 catalog the inspection findings.

12 And the third is the long-term comp
13 measures. So, that is one, again, we work with EPRI
14 and NEI to get especially the long-term comp measure
15 information. And every six months, we update that and
16 we send it over to NRR. That is one that the
17 Commission asked us, so that they could kind of see a
18 tracking of how fire protection is for them. Again,
19 there will be another update of that, and it will be
20 on a rolling six months.

21 We are also trying to go back in time. I
22 think we are back currently to 1990. We want to go
23 back and see if we can find the LERs, the 5072s and
24 73s, to try to get it. Ideally, I would love to go
25 back to the '75 timeframe.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And I heard comments earlier about the
2 reporting requirements. And, yes, the reporting
3 requirements are different, and they have evolved. It
4 is actually interesting. The report, if you read it,
5 we spent some time laying out how those reporting
6 requirements are. But, you know, the key was that,
7 whether you have to report an LER fire, whether it is
8 10 minutes or 15 minutes, there doesn't seem to be a
9 whole bunch of 13-minute fires. They either tend to
10 be longer or very short. So, even though, yes, there
11 are different requirements, I think they are close
12 enough that we are not seeing that 13-minute fire that
13 one reports and the other doesn't.

14 Next slide.

15 Coming along with the high-priority items,
16 the cable tray testing, you heard mention of
17 CHRISTIFIRE. This is where we are looking at the heat
18 release rate and the flame spread.

19 The first report is drafted. It has been
20 out for public comment. We've got the public
21 comments. Dr. McGratten from NIST is working on that
22 with us. That testing is being performed at NIST. He
23 is working with our staff, David Stroup, right now.
24 They are resolving comments. And we expect that first
25 volume to be issued in the spring.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 We will, then, look on to the second
2 phase. We will consider this successful, and we will
3 look on to the second phase, where we will start
4 introducing some more of the variables, vertical
5 trays, covers, fire retardant coating, and we will
6 start that second phase.

7 I know talking with Kevin that we have got
8 the contracts in place. Procurement is started, and
9 they are procuring the cable.

10 An interesting side note, maybe because
11 I'm a fire protection engineer, not an electrical
12 engineer, but it was interesting the amount of lead
13 that was in the jackets of those cables. It surprised
14 me, but I know one of the challenges with NIST is,
15 when they have gone and cleaned their hoods and their
16 filters, is, yes, oops. So, I find ways to stick NIST
17 all the time, but unintentionally.

18 (Laughter.)

19 So, anyhow, part of the procurement is
20 that the cable manufacturers are moving to, I guess,
21 lead-free cables, not that I ever knew there was that
22 much lead in there in the first place. So, that is an
23 interesting little side note that we had as we procure
24 new cable.

25 One of the FAQs that fell out was the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 kerite testing. Again --

2 MEMBER BLEY: I didn't hear the word.

3 MR. SALLEY: Kerite.

4 MEMBER BLEY: Oh, okay.

5 MR. SALLEY: Kerite is an odd cable.
6 Dennis, you know, I want the whole world to be
7 hammered into two nice camps, thermoset and
8 thermoplastic, and from there, we can bin them, and
9 once you are in that family, you tend to be close
10 enough that you are splitting hairs, whether you are
11 cross-linked polyethylene or polypropylene, or
12 whatever specific chemical type.

13 The one cable that does want to be a bit
14 of an outlier, it is supposed to be a thermoset that
15 wants to play like a thermoplastic, is the kerite
16 cable. And again, this is one where you can see the
17 benefit. You will notice I put a lot of parentheses
18 with EPRI here, where you can't buy this kerite table
19 anymore, but EPRI was able to, you know, with the
20 contacts through the industry, to marshal some cables
21 that had been left over from construction or people
22 had spares in the warehouses. And we were able to get
23 enough samples and get them out to Steve.

24 And again, an economy of testing, because
25 we had just figured, completed, the DC testing, Sandia

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 was still geared up. What I am saying is the Penlight
2 facility was still hooked up. The technicians were
3 there. The instrumentation was there.

4 So, it was all in timing that we could get
5 the cables from industry through EPRI and we could run
6 those cables through the testing, and we will come up
7 with an answer for kerite.

8 MEMBER BLEY: Is there a lot of kerite out
9 there? I'm not familiar with it.

10 MR. SALLEY: Well, yes, see, that is the
11 whole thing of this. When we started out, there was a
12 couple of plants. But, as we started talking more and
13 more, all of a sudden, kerite started popping up all
14 over the place. So, there is a fair amount.

15 Now, in fairness, you know, kerite was a
16 big player in medium-voltage power, which is something
17 we are not too interested in. We are interested more
18 in the instrument and control circuits, which is a
19 smaller population.

20 But, again, I think one of the things you
21 saw from the presentations, that if I'm a licensee, I
22 mean, what is my problem that is slowing me down?
23 That is what I am interested in, and everybody has
24 their problem.

25 Duke, for example, it was the armored

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 cable. You know, they had to use so much armored
2 cable that they really needed armored cable. And, of
3 course, when they did their first testing, nobody else
4 used it. So, basically, Duke had to go it alone.

5 Kerite, there is a handful out there. The
6 interest to them is, hey, do I treat this as a
7 thermoset or a thermoplastic; what's my temperature;
8 what's my threshold? So, to them, that was probably
9 one of their most important things.

10 Again, just the fact that we want to close
11 the issue, too. And it was an FAQ. We have had the
12 opportunity. Testing is done. Sandia is writing a
13 report. This spring we will issue the report. We
14 will feed it to the expert panel, which is where I
15 really need to get it, and, hopefully, we will close
16 that. So, that will close up this spring.

17 The effects of the fire-retardant coatings
18 and cable tray covers, I had mentioned that. That is
19 on the plate, and that looks to be about next year at
20 this time completing up there, and that will be the
21 effects of the covers and the coatings.

22 And the last one of the high priorities,
23 and again, these were not in any particular order, is
24 the incipient fire detection. This one we have
25 scheduled to complete in the summer of this year,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 hopefully. We just got the contract in place. We had
2 some contractual stuff. You know, nothing is ever
3 simple, you think, between the government agencies.
4 But the lawyers looked at everything and we had to go
5 through the clauses in our contracts.

6 We awarded the contract to NIST. We have
7 just gotten it in place, and we will be working with
8 NIST on this. And again, we hope to, when we lay the
9 program, I have started laying the program out with my
10 project manager. Again, we will talk to EPRI through
11 Rick and say, "Here's what our plan looks like. If
12 you are interested in joining it, here's how we intend
13 to proceed with the incipient detection."

14 CHAIRMAN STETKAR: Right now, Mark, on the
15 incipient detection, is that only in cabinet with
16 different types of cabinets or are you looking, also,
17 at ex-cabinet area?

18 MR. SALLEY: My project manager Gabriel
19 Taylor, he's been here before, and I have discussed
20 this. We are basically looking at four steps in this
21 process.

22 The first thing we want to look at is,
23 just what is incipient detection? You know, what are
24 the systems out there that are listed, rated, that
25 have some quality, some pedigree? And what is the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 family of them? So, we need to establish that.

2 The second thing we need to look at is,
3 what is the technology that they are using? This is
4 how these systems are designed. This is how
5 underwriters' laboratories test them. These are how
6 they are calibrated.

7 And to a point, you know, educate everyone
8 onto what we are calling incipient detection and how
9 the technology is regulated, how it basically works.
10 So, that phase will come in.

11 The next thing we look at, of course, is
12 the third phase, would be the literature survey. I
13 had known that in the past with the Candu reactors, I
14 can remember years ago going to a conference when I
15 really wasn't interested in this, but I can remember a
16 female engineer from Canada coming down and really
17 singing the praises of incipient detection that they
18 installed post-shutdown on the Candu reactors, I
19 guess, about 10 years ago. So, we need to go back and
20 see what people have done to this point.

21 The fourth phase of that will, then, be to
22 look at it. And believe it or not, these are in use
23 in quite a few places. As I mentioned before, NASA
24 loves the stuff. DOE did not have that good of
25 experience. The Candu reactors is one definitely that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 we talked about, you know, that I want to get the
2 folks to look at.

3 But I think we really need to do the
4 research to go to talk to these people, to see how
5 well they are working, how many years of experience
6 they've got, and look at it that way. And, then, if
7 the next phase is needed, then we will move into a
8 testing phase.

9 CHAIRMAN STETKAR: Okay, but this initial
10 is no testing? It's simply --

11 MR. SALLEY: We need to establish a
12 baseline before we just blindly go out and test.

13 CHAIRMAN STETKAR: Okay.

14 MR. SALLEY: And I think one of the
15 things, you know, beyond testing is going to be how
16 reliable in that are these systems, and what kind of
17 operating experience? Operating experience, as Chris
18 mentioned, is usually valuable. So, we need to get
19 that from other industries. And there is a bit out
20 there that we can pull from. Like I said, NASA, DOE,
21 the Candu's. So, we have a lot of communications to
22 make, a lot of meetings to happen with the folks to
23 get that, and we have started that.

24 CHAIRMAN STETKAR: Have you looked at
25 others? You mentioned Candu's. Have you looked at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 other international experience. I have seen cabinets.
2 I've been up close and personal with cabinets in
3 nuclear power plants in other countries that have
4 them.

5 MR. SALLEY: That have used the incipient?
6 So, that would be international? Where would I be
7 looking, John?

8 CHAIRMAN STETKAR: You would be looking --
9 I don't know how prevalent -- I'm familiar with the
10 Swiss plant, but it's a German plant design. So, I
11 would contact Siemens, you know, or people in Germany.
12 I mean I actually don't know if they use them in
13 France.

14 MR. SALLEY: Okay. I appreciate that, and
15 we'll take that --

16 CHAIRMAN STETKAR: They may have some
17 operating experience.

18 MR. SALLEY: Yes, we will take that with
19 our OECD work. That is something that, as a matter of
20 fact, the OECD is here next year. I'll go to that
21 meeting and I'll ask for the people we can get. Then
22 you can send me over to Switzerland for a month or so,
23 boss; what do you think?

24 CHAIRMAN STETKAR: Well, it is one plant.
25 You know, it is a Siemens plant and they come in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Siemens sort of supplied cabinets. I don't know
2 whether it's a Siemens product. I don't actually
3 recall. It is several years ago that I ran into
4 these.

5 MR. SALLEY: Okay, but that's a place I'll
6 look. And we have got a number of other different
7 leads --

8 CHAIRMAN STETKAR: Okay.

9 MR. SALLEY: -- that we will also run
10 down. And again, we want that operating experience.

11 So, those are all our high-priority items.
12 The next thing we would move into would be a medium
13 priority.

14 This one, the human reliability analysis,
15 you have separate meetings coming up on this. And the
16 only reason this one is down to medium now is because
17 the main product is pretty much complete. The team
18 has completed the NUREG. The NUREG has gone out for
19 comments. The comments are in. The team is walking
20 through and resolving the comments. They hope to have
21 this published this summer.

22 So, again, this one has kind of gotten off
23 the high-radar screen. It's gotten down to medium
24 because now they are just in a closeout portion.

25 It is interesting, too, that we do have a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 full track in the training, that is, a whole class
2 that is dedicated to the fire HRA that looks to be a
3 continual part of the training.

4 Electrical cabinet heat release rate,
5 again, this was one that we did have at a higher
6 priority, but with discussions with NRR, when we
7 learned industry's plans and that they were out there
8 doing the work on the cabinet heat release rate,
9 discussions then are we kind of backed that down to
10 medium because we don't really want to reproduce work
11 that other people are doing.

12 MEMBER BLEY: When you say "medium" here,
13 this means you are not going to do anything until you
14 see what goes on out there or are you doing something
15 at a low level?

16 MR. SALLEY: We have something at a low
17 level. I mean we are doing our versions of literature
18 surveys. Where we were at with this, and you have
19 heard mention, was we looked at what testing had been
20 done, primarily by Sandia, and we were looking at,
21 okay, where is there holes in the data; what's
22 missing?

23 And we were saying, okay, if we were going
24 to go and start filling these data parts that are
25 missing, how would we start setting it up. And that's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 where we were in the project when we learned through
2 conversations with EPRI that they had a project
3 ongoing based on some work that come out of some
4 earlier research about two years ago.

5 So, in essence, we were going to let them
6 run through their course. I believe, Rick, the
7 agreement is that when you guys get the report
8 drafted, you will send it over to us for comment on
9 the heat release rate?

10 MR. WACHOWIAK: Yes. Actually, what we
11 had talked about with Donnie was that, when we have
12 the initial set of review comments done, then we will
13 bring you guys in to be part of the review team,
14 official review team.

15 MR. SALLEY: So, that's how we moved it
16 from a high to a medium, to allow industry to do their
17 portion before we go and pick it up.

18 CHAIRMAN STETKAR: Okay. And we know
19 industry is approaching it, trying to develop
20 parametric models based on the same set of limited
21 test data that you're looking at. So, we are not
22 creating anything new here. We are just simply
23 looking at the same old stuff differently perhaps.

24 The question is, again, the reason we are
25 here is NFPA 805 transition. If it is identified as a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 key issue, and we have a sparsity of test information
2 or in some cases perhaps questionable test information
3 because the tests weren't designed to produce the
4 information that we are trying to glean from those
5 tests.

6 Is this an area where additional testing
7 should be done? Now the industry has decided
8 apparently no. You've decided apparently no. I
9 understand tests are expensive. It is hard to find
10 cabinets. The last I checked, there's a nuclear power
11 plant that I used to work at being dismantled right
12 now on the northern shore of Lake Michigan that I
13 guarantee didn't have many solid-state cabinets in it,
14 but it had a heck of a lot of switchgear and
15 electrical cabinets with relays and wire bundles and
16 things like that that probably shouldn't be
17 contaminated. You know, there might be stuff
18 available.

19 MR. SALLEY: I wouldn't rule out testing,
20 John, but, like any research project, before you just
21 run out there and test, there's steps we like to take.

22 One of the things is we like to do a really good,
23 solid literature survey to see who has done what and
24 to try to learn from their experience. And from that,
25 we, then, go and frame our testing. I fully expect a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 test. It's just when.

2 The other thing is with this that I did
3 have money budgeted, and we were starting to move
4 forward, but there's always more research projects
5 than there are funds and resources, okay? And Chris
6 has six different branches, and we sit down and the
7 six branches basically compete where she has to
8 balance out that all the areas we have covered.

9 Again, this was one where we were getting
10 ready to start it, but we knew that industry had an
11 effort. I didn't want to duplicate theirs or go out
12 and test things and find out that they had data that I
13 had missed.

14 So, we had diverted funds to other high-
15 priority work and decided to be patient here and let
16 industry take the first bite at the apple, if you
17 will, and then we'll pick it up, look at where they
18 are at, where we were going, and see where we need to
19 go.

20 And again, this may well develop into
21 discussions with industry where we say, hey, we need
22 to run "X" number of tests and here's what we're
23 thinking of doing. And do you want to come up with
24 some equipment; you want to come up with some
25 expertise, and we will work with you? We will have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 those discussions under the MOU. And that's how we
2 try to do business.

3 MR. WACHOWIAK: This is Rick from EPRI.

4 The other thing that, as I mentioned
5 earlier, we want to make sure we do is we are trying
6 to come up with a tool, a model, or an equation, like
7 we said before. Then, if that turns out to be a
8 useful model, then we can tailor the test to fill in
9 the gaps for addressing that model.

10 So, I think the way this is being
11 sequenced right now is probably the right way for
12 this.

13 CHAIRMAN STETKAR: Okay.

14 MR. WACHOWIAK: We need to figure out
15 where the gaps are and target the test to fill the
16 gaps.

17 CHAIRMAN STETKAR: Rick, in practice, this
18 is just information. I know Mark in our November
19 meeting was very, very appreciative of the batteries
20 that, I will use the term "scrounged", that EPRI
21 scrounged up from a plant that was replacing their
22 batteries because that allowed them to use a
23 legitimate power source to support the DESIREE tests.

24 If there's any indication that prior
25 testing of electrical cabinets -- and, you know, I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 will run the spectrum of electrical cabinets -- may be
2 done, has there been any thought? I was not
3 necessarily facetious about scrounging equipment from
4 Zion. You know, if you wait too long, it's going to
5 be in a dump out in Utah someplace, I think.

6 (Laughter.)

7 MR. WACHOWIAK: That's something to
8 consider.

9 CHAIRMAN STETKAR: Warehouse space is
10 cheap if, indeed, there is an indication that tests
11 might be performed. You know, granted, the test
12 program isn't designed yet. But if you want to use
13 prototypical equipment, that might be hard to come by.

14 MR. WACHOWIAK: Right.

15 MR. SALLEY: And there's one facet that is
16 not on the priority list that we are dealing with the
17 international. And again, we will get it with EPRI
18 for the U.S. utilities. And that is the high-energy
19 arcing faults one that we have been working for about
20 three or four years now in discussions with an OECD
21 project.

22 And it's interesting that Korea, I
23 believe, emailed me and sent me some nice pictures
24 that they have already started getting surplus
25 switchgear, that they are ready to commit to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 project.

2 So, hopefully, yes, it was really
3 surprising that the guy basically emailed me. I love
4 these emails.

5 CHAIRMAN STETKAR: Those are the tests I
6 want to see.

7 MR. SALLEY: Right. Where I got the email
8 and it said, "See attached photos." I looked at it.
9 It was a bunch of switchgear and says, "Give me an
10 address where I can send this." And I was slow down a
11 minute; we're getting this together. This spring we
12 will get the agreements in place.

13 But some people were interested. And
14 again, that's one where we will look to EPRI, if they
15 can contribute also.

16 And the last in the medium priorities is
17 in the meeting support. Again, anytime NRR would like
18 our assistance at an ACRS meeting, NEI fire protection
19 forum, any public meetings, any of that, then we are
20 there to assist them. That's a smaller activity.

21 Moving from that is into the low-priority
22 items. Sometimes low priority is just because there's
23 nothing much going on or there's very little.

24 The first one, for example, observing
25 industry fire tests, there's nothing going on right

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 now. There was some aluminum conduit penetration seal
2 testing that was done by VEPCO, and we went and
3 witnessed that, and we will write an internal report
4 for NRR and for the Regions. So, that is kind of when
5 something is going on.

6 Low-power shutdown, I talked about that
7 last time. As a matter of fact, my PM and Steve have
8 completed that. Again, Ken said it wasn't a peer
9 review, but EPRI did give it a read and give us some
10 comments.

11 We have incorporated those and that draft
12 NUREG CR we looked to have out the first of the year.

13 So, we will give NRR the two-week look-ahead on that.

14 That will be coming over and we will get this thing
15 straight.

16 A longer-term research project -- so the
17 low-power shutdown we would hope to complete this
18 summer, the summer of '11. Again, it is a low
19 priority, but it has been going for a long time. It
20 has almost been a little fill-in-the-blank-type kind
21 of project.

22 A long-term research project for us is the
23 smoke damage on the I&C circuits. That is one that we
24 have thought about long-term. And it gets more into
25 digital I&C systems. Again, we are still in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 planning stages, but this is something right now that
2 we would be looking at for, say, June of 2012. So, it
3 is a year or two out in the distance.

4 Another one that is in the June 2012
5 timeframe is the gaseous fire extinguishing agents.
6 We need to go back. It has been a while since we have
7 looked at that. And also, there's some newer
8 technologies with things like the water mist systems
9 and that which didn't exist when Sandia did the
10 original work that we need to take a look at.

11 CHAIRMAN STETKAR: Do you actually see
12 those being installed in -- I'm thinking of new plant
13 designs. I haven't seen any of the new plants that
14 have talked about those types of systems.

15 MR. SALLEY: I haven't seen anything. I
16 would defer to industry if there is anything going on.
17 But there's also the things like the halon
18 replacements. Halon is outrageously expensive if you
19 had a system that you have those clean agents in that
20 now.

21 And again, part of it is you know with the
22 deep-seated fires that we see in cables, you know,
23 what concentrations and soak times would you need with
24 these newer agents. That may be an area where some
25 research needs to be performed. And again, this is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 something that we are looking at in two years out
2 getting into.

3 The documentation of the circuits and
4 manual operator action closure, again, these programs
5 have pretty much run their course, I think, and they
6 are being implemented now, but we still need to
7 establish a regulatory footprint and capture that.
8 So, this is a project that we are looking at in about
9 2014, actually, where we can really bring things to
10 closure.

11 I think a funny story, just a side
12 anecdote on this, is we had the whole issue of thermal
13 lag and HEMAC and 3M and the whole fire barrier issue.

14 We wrote a NUREG where we captured the whole history.

15 I believe this was one that we did for you guys when
16 we had the GAO audit where they couldn't follow the
17 full closure of it. So, we packaged it all, and we
18 put the whole regulatory history and the full final
19 closure. It's got it all there.

20 And we figured, okay, that's nice, and the
21 next time GAO comes in and says, "What did you do
22 about this?", the NRC has a real nice response.

23 But, as a side byproduct, as people were
24 looking at multiple spurious, I ran into a contractor
25 and he called me up and said, "You know, that's really

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 coming in handy now because we are going to go install
2 fire barriers again, and you've cataloged all the
3 testing; you've got everything cataloged."

4 So, we had meant it as a historical
5 closure thing. And as people may want to add some
6 fire barriers to resolve their multiple spurious, we
7 now have this nice handbook, if you will, where it has
8 changed its mission and they can say, okay, here's all
9 the tests you've got; here's the configurations;
10 here's where you need to go. And it has become a nice
11 source document. So, I thought that was quite
12 interesting.

13 In follow-on to that project, actually, it
14 wasn't as big an issue, but the radiant energy shields
15 that are used in containment. Typically, you have a
16 thermal lag, get people doing a lot of different
17 things.

18 And the unique qualifications on things
19 like the fire-resistant cables, those were done under
20 50.12 in the exemptions. Again, we want to capture a
21 footprint in the essence of future questions from the
22 GAO that, okay, you did fire barriers; what about in
23 containment? And again, this is one that we are
24 looking at scheduled for the summer of 2013. So,
25 those are our low priority.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 And with that, that is pretty much the
2 matrix of where we are working in research as of
3 today. And again, with this, as Chris mentioned, is
4 the big user here for us right now is NRR. We do have
5 quarterly meetings. So, in those quarterly meetings,
6 it is not uncommon -- for example, you saw the HRA go
7 from a high to a medium. That is because so much
8 progress had been made. It is ahead of all the other
9 HRA projects. So, it lowered that down for
10 completion.

11 And new projects will come in, and
12 projects will close. We keep this pretty much as an
13 active running dialog quarterly with NRR.

14 And also, when we talk to EPRI, one of the
15 things we will do, typically, in the spring is we will
16 exchange our notes. Okay, here's what we are looking
17 at; here's what you're looking. Where do we see
18 possible fits to work together? Or, in the case of
19 the heat release rate on cabinets, where don't we want
20 to duplicate efforts because there's just so much?

21 So, those discussions, like I said,
22 typically happen at least once a year, if not more.
23 There's always talk at things like meetings like this,
24 NEI fire forums, and that, where we discuss this.

25 That's all we had prepared. And again,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 like I said, we wanted to focus on priorities.

2 CHAIRMAN STETKAR: Anything else?

3 Thank you very much.

4 Now the process, looking at the time, it
5 has been a long two days also. On our agenda, I think
6 what we will do, as much as some people probably would
7 really like to talk about incipient fire detection, I
8 think we will probably forego those presentations. I
9 think we have heard a lot about it.

10 I think we are sort of familiar with some
11 of the concerns. Going into the details of the two
12 different approaches, I don't think would necessarily
13 add anything to sort of our understanding of what at a
14 higher level some of the issues are.

15 There are two presentations, one by NEI
16 and EPRI that is entitled "Interim improvement to
17 support NFPA-805 and other important risk
18 applications". I am not sure what --

19 MR. WACHOWIAK: I covered that in this
20 last presentation.

21 MR. SALLEY: Rick covered that at the end
22 of the last one.

23 CHAIRMAN STETKAR: Thank you.

24 And, then, there is kind of a closeout
25 from the staff that says, "NRC perspective on fire

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 PRA". Have we covered that or is that something that,
2 Sunil, you would like to kind of get some closeout?

3 DR. WEERAKKODY: You had a couple of
4 questions yesterday, John. One was with respect to
5 the fire PRA results and, then, the lack of
6 compatibility --

7 CHAIRMAN STETKAR: Okay.

8 DR. WEERAKKODY: So, I would like to
9 speak, comment on that.

10 CHAIRMAN STETKAR: Okay. Good.

11 DR. WEERAKKODY: And, then, you had a
12 question, also, with respect to the implications of
13 these issues on the other PRA applications.

14 CHAIRMAN STETKAR: Yes.

15 DR. WEERAKKODY: And I'm prepared to speak
16 to that.

17 CHAIRMAN STETKAR: Okay. Good. Good.
18 Let's do that because those are relevant. I didn't
19 want to put you on the spot necessarily and make you
20 say, no, you didn't have anything. So, I'm glad you
21 did some homework.

22 MEMBER SHACK: He's born ready. He
23 doesn't need to do homework.

24 (Laughter.)

25 DR. WEERAKKODY: I want to find my

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 presentation.

2 CHAIRMAN STETKAR: Go ahead.

3 Harold said he just arrived at Dulles.
4 That's probably from Germany.

5 MEMBER SHACK: No, no, that's true; he
6 always flies into Dulles.

7 CHAIRMAN STETKAR: He flies into Dulles
8 nonstop LAX-Dulles.

9 DR. WEERAKKODY: I'm Sunil Weerakkody.
10 I'm the Deputy Director, Fire Protection, NRR.

11 The purpose of this presentation is to try
12 to answer one of the questions based on the
13 information that industry presented with respect to
14 some of the insights that they got from some fire PRAs
15 and how they don't really comport with what we see in
16 the experience.

17 I recall very well in November I made a
18 commitment to John to come back and address it at this
19 meeting. Then, we tried to do that yesterday, but I
20 don't think we did really try. I went home and I
21 didn't feel comfortable that we answered your
22 question.

23 So, I kept challenging the staff, and when
24 I kept challenging the staff, they basically said to
25 me that one of the hardest things they have is without

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 just having the results, without knowing the degree of
2 use of the plant-specific insights that went into the
3 six or seven plants, they had the hardest time trying
4 to address that specific question.

5 And, then, I understood, when I listened
6 to Danny Pace yesterday, where he had some information
7 which was how this initial fire PRA was 70 minus 3 for
8 the compartment, and then he applied the detailed fire
9 modeling, it dropped down like almost three orders of
10 magnitude.

11 Even though we have access to the
12 licensee's PRAs when we need to, we can't tell with
13 those seven plants where on the spectrum these are.
14 But, still, the question that you ask is a very
15 legitimate one and we have to try to come up with some
16 kind perspective.

17 Go to the next slide.

18 So, what I said was, you know, let's try
19 to answer these questions with the knowledge we have,
20 the facts we have, and try to shed some light.

21 Go to the next slide.

22 So, basically, I had to rely on a paper
23 that my colleague, Ray Gallucci, put together to
24 present at a forum many years ago. Was it like a
25 couple of years ago, Ray?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 DR. GALLUCCI: 2006.

2 DR. WEERAKKODY: Yes, 2006. He had done
3 some analysis using some of the precursor data, the
4 Browns Ferry, and some of the analyses he has done.

5 And I wanted to be careful in terms of how
6 I presented that information. And when I looked at
7 that, the results that he produced, and then he has to
8 presentation to the staff, if the ACRS is interested.

9 If I include Browns Ferry and the other
10 accident sequence precursors and some of the other key
11 events, I'm getting a number. Use that as a
12 prediction like $6E^{-5}$ per year.

13 But we all know that, since Browns Ferry
14 in 1975, you know, we have made many changes to the
15 plans. Okay?

16 And so, if I, then, go to the other
17 extreme and say the industry has fixed anything and
18 everything, the lessons learned from Browns Ferry, and
19 as a result, if I just throw away the precursor, the
20 conditional, or the contributions from Browns Ferry,
21 what is the order of magnitude I get? I get like
22 $1E^{-7}$ per year.

23 What is interesting about the lower number
24 is, when I look at these new plants where they have
25 complete separation, the new generation of plants

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 where the only place where the two things come
2 together is in the cable control room and the
3 containment, that's the order of magnitude you get.

4 So, with these two bounds, then, I said,
5 okay, you know, we know that a large number of plants
6 have made a lot of modifications to the plants out
7 there. The number is like something that may be
8 lower, $6E^{-5}$, I mean minus 7, but that is the average
9 number. I may have a plant out there today that's
10 higher than $6E^{-5}$ even. It all depends on the risk
11 reductions associated with the post-Browns Ferry
12 actions, and that varies among the plants.

13 For example, if I take one of the plants
14 that I am very familiar with now, say Shearon Harris,
15 not only did they do a number of modifications with
16 respect to the lessons learned from Browns Ferry, they
17 did more modifications such as rerouting cables,
18 putting in incipient detection systems. That has to
19 be towards the lower end.

20 However, I want to be very candid about
21 this. When they submitted their pilot Harris SC,
22 their core damage frequency was, I recall, 3 minus 5
23 per year. I can't remember the exact number.

24 And if you recall what Progress Energy
25 said, what they did was in their analysis they did

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 enough sharpening the pencil to a point where they
2 could just get the staff to approve to complete the
3 transition. So, I wouldn't be surprised if they are
4 today at 3 minus 5, and, then, when they sharpen the
5 pencil some more, they fall into much lower values.
6 Okay? That wouldn't surprise me.

7 Now I do want to make a comment with
8 respect to what I have there. Risk reductions
9 associated with post-Browns Ferry actions vary among
10 plants. One example is Browns Ferry, okay? That I
11 know.

12 And, then, there is another plant that I
13 know about is Browns Ferry, okay? Just last year, we
14 issued them for each of their plants a yellow finding.

15 And as you know, a yellow finding is their CCDP is
16 greater than $1E-5$ per year. That is going to be in
17 the ASP program.

18 And one of the things when I spoke to Gary
19 DeMoss, who is the Branch Chief of the ASP program,
20 and I should have known this yesterday because I used
21 to be an ASP analyst, that in the ASP program, even if
22 a performance deficiency lasted for 20 or 30 years,
23 you truncate it at one year. Okay?

24 So, that yellow finding, it is a yellow
25 only if you assume that the condition that we found at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 Browns Ferry lasted, stayed only one year. And to
2 give you some context, what they had was they had
3 about over 100 operator manual actions. And when the
4 inspectors went in, and I'm sharing this and these are
5 all publicly available. You know, there is an
6 inspection finding. Everything is well-documented.

7 But what is interesting there was that
8 they had about over 100 operator manual actions. And
9 some of the operator manual actions, the time required
10 was like 20 minutes. And when they did the walkdown,
11 they already closed three.

12 So, when you put all this information
13 together and did the quantification, you had this one
14 plant. You know, Browns Ferry, actually, they had
15 three units. Each of those units we had yellows.

16 So, to me, I am very comfortable in
17 sharing in this forum, and I give you the 6E -5. That
18 may be an upper bound. And, then, you have the E -7,
19 which is more like the new plants where they have
20 totally separated.

21 And we know in the operating fleet they
22 have just a lot of barrier issues. They have
23 addressed a lot of issues. But, still, some of the
24 fundamental separation issues are still there. And
25 that's okay. They do provide adequate protection, but

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I cannot say that they have just separated everything
2 and gotten to that other point.

3 So, that is the perspective I wanted to
4 leave with. And with that kind of perspective,
5 depending on the plant, and depending on the
6 conservatism that plant has used in their fire PRA, I
7 am not surprised with some of the results that NEI and
8 EPRI presented with respect to the operating
9 experience that was actual.

10 My main point is each plant is different.
11 Depending on how much separation they have, how much
12 modifications they have, how much lessons learned from
13 Browns Ferry they have internalized in their plant, I
14 might be at a different part of the spectrum.

15 And I just put Oconee there as another
16 example. With Oconee, the staff told me the number is
17 around $6E^{-5}$. Now Oconee has a very unique
18 configuration. They have their switchgear in the
19 turbine building and a lot of stuff. And they are $6E^{-5}$
20 after crediting a very expensive system they will
21 install at the plant over the next couple of years.
22 So, I'm not surprised by that number, too.

23 I just want to share that perspective and
24 answer any questions the staff or the industry has on
25 that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: I guess I'm not quite
2 sure what to say. I'm not sure this has answered the
3 questions that I had. I will come back to it is
4 certainly true that there is variability in plant to
5 plant on the plant configuration, the locations of
6 hazards versus potentially risk-significant cables or
7 equipment. So, you expect to see variability plant to
8 plant.

9 Also, because certainly I haven't had the
10 opportunity to look at any of the fire PRA studies
11 that were referenced in the presentation yesterday and
12 as a continuation of the presentation that we saw in
13 November. But I'm not sure the level of maturity, for
14 example, of those analyses, what refinements have been
15 made to the particular studies that were used as a
16 basis for comparison with operating experience, how
17 much of the pencil-sharpening has been done, has much
18 credit has been taken for, whether credit has been
19 taken for newly-installed detection systems, et
20 cetera. I just don't know that.

21 And that's why I'm not too interested in
22 numerical precision. I'm interested in sort of
23 ballpark accuracy, and the ballpark accuracy that was
24 presented by the industry was that we should be seeing
25 something on the order of a fire that induces some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 sort of spurious operation roughly once every couple
2 of years.

3 And I will be as accurate as "a couple
4 of". That might be every five or so-ish. It is
5 probably not once every 100,000. It is probably not
6 10 times a year. But it should be across the industry
7 somewhere in that ballpark of once every two to five
8 to eight years. We are apparently not seeing that.

9 We should be seeing the frequency of fires
10 that are estimated just looking at the damage of
11 having a condition core damage probability on the
12 order of 10 to the minus 4, and I will probably get
13 these numbers wrong because I didn't look them up, but
14 I'm not trying to be precise anyway. Sort of around
15 kind of one a year or so maybe. It might be once
16 every three or four years. It might be a couple of
17 times a year, but in that sort of range.

18 In other words, if I look back over the
19 industry operating experience over 20 years, for
20 example, I would expect to see countable numbers of
21 these events. I don't care whether it's one or three
22 or eight. I ought to be seeing some numbers, not
23 zero.

24 And the fact that we don't seem to have
25 that operating experience, either countable numbers of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 events or, in the case of the ROP and ASP processes,
2 events that are coming up above the regulatory radar
3 to say, gee, here was a fire, and if I look at the
4 damage from that fire, it is a potentially-challenging
5 fire from a risk perspective because the conditional
6 core damage probability for this particular plant is
7 10 to the minus 4 or perhaps higher. And again, 10 to
8 the minus 4 ballpark, you know. We're not seeing
9 that.

10 So, that was the genesis of the question
11 of why aren't we seeing that. And it is a sense of,
12 are we all in agreement now -- and this is something
13 we are trying to get our hands on. It is, given the
14 results of the fire PRAs -- and, granted, you have
15 seen two now; ACRS has seen zero -- that are being
16 developed to support the NFPA-805 transition, is there
17 general agreement among the staff and the industry
18 that the results of those fire PRAs are numerically
19 conservative compared to the available operating
20 experience that we have? Or is there a contention
21 that, indeed, they are numerically-realistic? And
22 what evidence do we have to support that?

23 I'm not trying to be very, very precise.
24 And obviously, we can't use core damage frequency as a
25 metric because I'm not going to hang around for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 another million years to wait for one or two of these
2 things.

3 MR. WACHOWIAK: Well, John, if I may,
4 you're the Chairman, and I'm just presenting facts.
5 But if I go, you know, after the level of discussion
6 on this topic, if I have tomorrow an event where the
7 CCDP is .05 or .005, I hope it doesn't happen, but it
8 can happen. With Browns Ferry, it has happened.

9 I think if you seem to look at the last 10
10 years, and say just because I didn't have these
11 precursors operating over the last 10 years,
12 therefore, my number just can't be anywhere near
13 realistic, then I'm kind of saying I'm confident that
14 it is in that $1E^{-7}$ per year.

15 I think what I am conveying to the
16 Committee is that, if I look at the new generation
17 where I have perfect separation, you may be there.
18 And based on the last 10 years of experience that I
19 have seen, and I am not limiting to the CCDPs or the
20 ASPs, I'm using my personal knowledge of the licensing
21 actions that come forward, the other events that get
22 reported. There may be these numbers like, for
23 example, Harry's. I think the number they reported is
24 conservative, but I can't make a general statement and
25 say everything out there is conservative.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 I think when we get amendments after
2 looking at how much they have sharpened the pencil, we
3 can make a judgment. But I, sitting here, using my
4 academic hat, I will not agree that just because we
5 didn't see any events that are like Browns Ferry over
6 the last 10 years, the number has to be in the -- you
7 know, that's over-conservatism.

8 So, as a regulator, I am in a quagmire. I
9 hear the industry's pleas that they are conservatisms
10 and all that, but when I make that regulatory decision
11 where I tell the plant, okay, you can use your fire
12 PRA to self-approve changes, I am inclined to be a
13 little bit more conservative than otherwise.

14 So, again, I apologize for being
15 argumentative --

16 CHAIRMAN STETKAR: No, no, no.

17 DR. WEERAKKODY: -- but I think there's a
18 flaw in that fundamental thinking where we jump in and
19 look at a few concepts and say, hey, you know, this
20 just can't be that high. That is all I am trying to
21 convey.

22 MR. HARRISON: And I think, if I can step
23 in and just say, back up to again the information that
24 was presented in regards to Beaver Valley, the staff
25 has not looked at all the seven plants that were used

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to derive the estimated frequency of events. I would
2 say, if they are using the initial fire PRA screening
3 model that Browns Ferry or Beaver Valley used to come
4 up with 7.7 to the minus 3 for an area, I would expect
5 the number to be higher.

6 If I do refine modeling and I drop it by
7 nearly three orders of magnitude, then I would expect
8 those numbers to be lower. So, it is somewhere in
9 between those.

10 CHAIRMAN STETKAR: That is why I prefaced
11 mine --

12 MR. HARRISON: Yes.

13 CHAIRMAN STETKAR: -- because I don't
14 know. I only know what I hear orally in these
15 meetings because we don't see and we haven't been
16 presented with very many details from either the staff
17 or the industry, quite honestly.

18 MEMBER BLEY: On actual PRAs.

19 CHAIRMAN STETKAR: On actual PRAs with
20 actual contributors. Every time we ask people, we get
21 genericized. And that's fine. If that's the
22 available information that we have for us to write our
23 report, that is the available information that we
24 have. I hate to say that, but --

25 DR. WEERAKKODY: Well, we could speak to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 this adding on, with Harris and Ocone we could be
2 specific. We don't have any more data.

3 MR. HARRISON: Yes. And again, the
4 variability is also within the licensee's modeling of
5 their plant because, if it is a high-risk area, they
6 are going to do more refined modeling. That will
7 bring those down.

8 There's variability across how the
9 analysis is done. I guess from our perspective, we
10 can't really give you an answer, but we believe the
11 numbers are not --

12 CHAIRMAN STETKAR: But again, talking --
13 and Doug is standing up; he will get his chance -- the
14 industry I think, as I understand the information that
15 was presented to us, tried in a sense to normalize out
16 a bit of that. Certainly took away the notion of core
17 damage frequency because that is obviously something
18 that you can't measure from operating experience yet.

19 It was my understanding -- and I think
20 Doug probably wants to add some information -- that
21 the results that we were seeing were probably not the
22 initial fire screening model. They may be, it's my
23 impression they are probably a mixed bag of some
24 fairly detailed in some locations and less detailed in
25 other locations, but they led to some amount of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 refinement.

2 But we don't know how much that is. We
3 certainly don't. You do on Harris and Ocone.

4 DR. WEERAKKODY: We do not have --

5 CHAIRMAN STETKAR: We don't know that on
6 Harris and Ocone because we haven't seen, either from
7 the industry or from the staff, Harris or Ocone.

8 MEMBER BLEY: Have you seen any of the
9 other PRAs yet or just those two?

10 MR. HARRISON: Just those two.

11 MEMBER BLEY: Okay.

12 CHAIRMAN STETKAR: So, we are going to
13 have to leave it there, I think.

14 Doug, now it's your turn.

15 MR. TRUE: Okay. I just wanted to add a
16 few things for clarity's sake.

17 One was we stay away from talking about
18 total CDFs entirely in the report.

19 CHAIRMAN STETKAR: Yes. Sure.

20 MR. TRUE: We made some general references
21 to the fact that risks were higher than we expected,
22 but we tried to get to things we could actually look
23 at that were traceable to operating experience.
24 Because it is very difficult to make extrapolations --

25 CHAIRMAN STETKAR: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TRUE: -- at the CDF level.

2 And the second thing is that I used, in
3 one figure I used plant 1 through 7. In one table, I
4 used plant A, B, C, D. And in other plants I used X
5 and Y. That was intentional, so there wasn't any
6 trackability between those.

7 CHAIRMAN STETKAR: Sure. Sure.

8 MR. TRUE: In terms of relevance to
9 operating experience, all of the five CCDP examples we
10 provided were PRAs that were very well along the path,
11 basically done.

12 And both of the pilots were included in
13 that table. I didn't identify them, but they were
14 both included in the table.

15 CHAIRMAN STETKAR: That is important
16 Okay.

17 MR. TRUE: The second thing is, or maybe I
18 don't know, the end thing is, that they were done by
19 different vendors. We had some input from ScienTech.
20 We had some interim studies. We had the pilot
21 studies. So, we were trying to make sure we were
22 getting a reasonable sampling of these reasonably-
23 complete PRAs.

24 The one place where I have somewhat of a
25 regret is that there is a little bit of a mixture in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that list that some of the plants, like the pilot
2 results, were all based on post-mod CDFs. So, they
3 reflect the post-transition CDFs, not pre-transition.

4 And if you are going to compare it to the operating
5 experience, you really have to be looking at pre-
6 transition.

7 So, if anything, by taking credit for
8 those mods in those models -- and it wasn't only the
9 pilots in the list of five; there was one other plant
10 that had the mods incorporated in the model -- those
11 CCDPs would be expected to be lower. The frequency of
12 the high CCDPs would be expected to be lower because
13 they have made modifications.

14 So, I think we tried to be really, really
15 fair in what we provided in that operating experience
16 comparison and, if anything, err on the side of giving
17 the benefit of the doubt to the post-mods and well-
18 developed PRAs.

19 Probably I didn't articulate, I certainly
20 didn't articulate all that in the model or in the
21 report, but just for the record, it is worth knowing
22 those facts because it does maybe flavor the way you
23 look at those.

24 CHAIRMAN STETKAR: Yes, and I appreciate
25 that, those insights. Also, my own personal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 observation is I think we have heard -- I don't
2 remember whether it was Dave or Dan yesterday who made
3 the statement that, well, you do enough analysis
4 refinement in your PRA for your particular purpose.

5 Certainly, for the Harris and Oconee
6 purpose right now, that is to justify transition to
7 the new licensing basis. That may not be to develop a
8 perfect estimate of core damage frequency for every
9 location. So, therefore, you know, there may be
10 residual conservatisms even in those analyses and the
11 analyses that include credit for the incipient
12 detection system, at least at Harris. That is the
13 only one I know about.

14 But other parts of the plant may have not
15 refined the analyses that far. So, you know, there's
16 pluses and minuses in any case. And I think, until
17 you actually look at some of the details of the
18 studies objectively, it is difficult to be very, very
19 precise about those numbers. You certainly cannot be
20 very precise about the numbers without a lot of work.

21 That being said, the numbers that are
22 being presented, at least in this forum, are not in
23 the 10 to the minus 2 event per year kind of range
24 where you could argue that, well, we certainly
25 shouldn't have seen any, or in the last 10 years we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 wouldn't expect to see one. They are in the couple of
2 events per year, depending on how you cut that data.

3 And even within 10 years, you would expect
4 to see a few of them, maybe a couple of them. And I
5 guess we will just leave it at that.

6 MR. TRUE: Yes.

7 CHAIRMAN STETKAR: I don't see us coming
8 to any -- I think the discussion has helped. I don't
9 think we have a clear-cut answer from our perspective.

10 MEMBER SHACK: Which you're not
11 particularly shocked to find that the fire PRA, the
12 current state-of-the-art, when you are not explicitly
13 considering uncertainties, you come up with somewhat
14 conservative answers.

15 CHAIRMAN STETKAR: No. I mean I am
16 personally not shocked to hear that. I actually
17 personally are more concerned about what the
18 implication, if that's true, if everyone agrees that
19 the results are conservative, I am more concerned
20 about what the implications of that conservatism are
21 going forward.

22 I mean recognizing that people who have
23 committed or announced their intention to transition
24 to NFPA-805 have done that for a variety of reasons
25 that we don't need to go into as an ACRS Subcommittee,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 they will probably do enough analyses to justify
2 acceptability of the PRA for that transition.

3 A lot of the concerns that I hear about
4 conservatism seem to be based on what's done with that
5 PRA going forward after that fact. So, I am not quite
6 sure yet how to think about this snapshot that we have
7 of the PRAs and what might be numerical conservatism
8 in those results.

9 Dennis?

10 MEMBER BLEY: Is this our final one?

11 CHAIRMAN STETKAR: No, no, no. No, it
12 isn't.

13 MEMBER BLEY: Nothing especially
14 convincing has crossed my way here.

15 CHAIRMAN STETKAR: I think this
16 transitions a bit into, I think, probably --

17 DR. WEERAKKODY: The next topic?

18 CHAIRMAN STETKAR: Yes.

19 DR. WEERAKKODY: This was your request
20 because I stated in my opening remark that, I made the
21 statement that, with respect to the Commission SRM, I
22 geared my opening or the management remarks to say
23 that the current state of five PRAs are adequate for
24 NRR to do its job, which is to receive and issue the
25 SCs with respect to the 805.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 And, then, John mentioned, hey, you know,
2 let's talk about some of the other implications. So,
3 I kind of did a little bit of different setup because
4 this is kind of like more, I suppose, some of the
5 presentations we give where we think a lot, prepare a
6 lot.

7 I said to Donnie here, "Let's create a
8 slide that has all these other implications." And I
9 said to Donnie, "Let's have in the audience his staff
10 who are most cognizant of these different
11 implications." And I told the staff members, "Let's
12 not argue whether or not five PRAs are conservative.
13 Let's agree that they are conservative by a factor of
14 two or three, and then let's tell John and this
15 Committee what is the implication of that kind of
16 conservatism on other applications."

17 So, it is basically let's go to the next
18 slide.

19 I listed some of the applications or use
20 of PRA here. We may have a case here where -- you
21 know, hopefully, all the staff is here, but the 50.65
22 Maintenance Rule, Donnie, did you want to say
23 anything? Or I can follow that. Or do you want to
24 have one of your staff?

25 MR. HARRISON: Yes. Under the Maintenance

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Rule, right now, to do the A-4 analysis for the
2 Maintenance Rule, that can be done qualitatively. So,
3 you can look at the configuration of your plant and
4 address it using either the onsite tools, the licensee
5 can do that, and make qualitative considerations.

6 I know there's ongoing discussions on the
7 use of fire risk in the Maintenance Rule. And that is
8 an ongoing activity, ongoing discussion topic.

9 But, again, with the Maintenance Rule, you
10 can make those assessments qualitatively. So,
11 conservatism in your fire PRA may inform a licensee.
12 It may result in them potentially taking additional
13 compensatory measures in response to a maintenance
14 activity. I don't see that as something driving them
15 to drastic changes as far as addressing the fire risk
16 associated with 50.65 Maintenance Rule.

17 DR. WEERAKKODY: Yes, if I may add, Biff
18 has a lot of knowledge in this area of where the NRC,
19 the Commission, and the industry had deliberation over
20 several years with respect to what is the regulatory
21 requirement with respect to fire risk and in the
22 Maintenance Rule. We came to a place where we said
23 the regulatory requirement, well, we basically said --
24 Biff, why don't you? You are as knowledgeable as I am
25 on the resolution.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. BRADLEY: We are about to submit a
2 revision to NUMARC-9301 that will include fire risk
3 consideration into A4. It is explicitly qualitative.
4 It does give you the option to use PRA, but it is
5 qualitative guidance.

6 Our initial indications are the staff
7 accepts that concept. As always, these things are
8 more complicated than they sound, and we could spend
9 all day just discussing how this could impact 50.65,
10 and we are running out of time.

11 But I would just note that the NRC's
12 inspection procedure does quantify the delta, and I
13 suspect having a fire PRA lurking at your plant would
14 certainly beg the question. Whether you have done
15 this quantitatively or not, if there is an inspection
16 issue, someone is going to ask the question, run the
17 number, and let's use that to inform the outcome of
18 the inspection.

19 So, it is more of an ROP issue, I think,
20 to me than a 60.65 issue. We have gone to great
21 lengths to make that qualitative because of the very
22 things we have been talking about here. And this is a
23 comparative evaluation where you are looking at
24 internal events versus fire. You have a finite number
25 of risk management actions, and if your fire number

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 dwarfs out internal events, you are not going to be
2 doing internal events risk management actions anymore.

3 That is the concern we have there and why we went to
4 lengths to make it qualitative.

5 MR. HARRISON: Yes, and addressing that
6 particular one, and that applies also to 10 CFR, like
7 what's done on 10 CFR 50.69, which is lower on this
8 list. Instead of looking at it as an "either/or", if
9 fire risk gets too big, and I don't do anything for my
10 internal events hazards because the fire risk is so
11 big, that is an "either/or" approach. It is really a
12 "both/and".

13 You look at what's driving the risk in a
14 certain area. You address it if it is a fire risk.
15 If it has still got internal event impacts, you
16 address those, too.

17 So, you may end up with, again, additional
18 fire compensatory measures on top of what you do
19 already right now for the internal events
20 considerations. So, a slightly different perspective,
21 but, again, that plays out also in how we approach
22 50.69, where it explicitly addresses it that way. You
23 have an integrated assessment of the importance, and,
24 then, you have the individual hazard assessments of
25 importance.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 DR. WEERAKKODY: Let me just introduce
2 Steve Dinsmore, and, then, let's ask him to talk about
3 the next topic. Steve Dinsmore has been the champion
4 or the key staff member in NRR on the risk-informed
5 ISI.

6 One of the things I do want to say is
7 that, when I look at these applications, John, I ask
8 the question, if the five PRAs are conservative, am I
9 causing the licensees to take actions adverse to
10 safety? That's my threshold.

11 With that, Steve, can you speak about
12 whatever you know about fire PRA implications?

13 MR. DINSMORE: Yes, this is Steve Dinsmore
14 from the NRR staff.

15 Well, the short answer is risk ISI looks
16 at weld failures, and weld failures don't cause fires.
17 They cause floods. Fires don't usually cause weld
18 failures.

19 There's some transients that could be
20 induced by fire, which could indirectly cause loads on
21 welds, which could cause the weld to fail, but those
22 are not any specific differences between the internal
23 events and the external events.

24 As long as you are doing an absolute
25 change in risk estimate, I think the conservative fire

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 calculations will never push you in the wrong
2 direction. They might not give you as much relief as
3 you would like, but they won't give you an unsafe
4 answer.

5 It is only when you do relative types of
6 calculations that the fire thing could really perturb.

7 So, ISIs, it doesn't have any effect on the ISI.

8 DR. WEERAKKODY: Is Andy Howard in the
9 audience?

10 MR. HOWARD: Yes.

11 DR. WEERAKKODY: All right. Andy, could
12 you come up here and speak to tech spec 5(b)
13 initiative and tech spec 4(b) initiative, and share
14 your --

15 MR. HOWARD: Yes.

16 DR. WEERAKKODY: Okay. I'm taking a risk
17 here by asking Andy to come and speak here, but --

18 (Laughter.)

19 MR. HOWARD: I guess you're ignoring
20 NOEDs? That was next on your list.

21 Risk-informed tech spec initiative 5(b) is
22 the surveillance frequency extension licensee control.

23 It specifically provides for the use of a high-
24 quality internal events PRA, but fire, seismic, other
25 external events, shutdown risk, other hazard groups,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 can be handled by IPEEE-level analyses and insights or
2 even qualitative insights. So, that has been
3 specifically carved that.

4 You can use a fire PRA for surveillance
5 frequency extensions under this program. If you have
6 one and you so choose, that is perfectly acceptable,
7 but it is not a mandate. So, conservative fire PRAs
8 would have no impact on 5(b), as far as I can tell.

9 DR. WEERAKKODY: And how many are under
10 review or have we issued on 5(b), Andy?

11 MR. HOWARD: How many have we issued?

12 DR. WEERAKKODY: Issued or under review
13 right now?

14 MR. HOWARD: About 33 plants, so about a
15 third of the industry is submitted or it is in the
16 pipeline. We expect pretty close to 100 percent
17 within a decade or so.

18 Tech spec initiative 4(b) is the flexible
19 AOT program. There a fire, a quantitative treatment
20 of fire is required since the standard has now been
21 issued and is in effect, a PRA has been assessed
22 against the standard and meets category II as
23 required.

24 So, a conservative fire PRA will impact
25 the allowed outage times. And I have given this a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 little thought since I was told I might be asked to
2 speak about this.

3 And I don't want to seem hesitant, but I
4 think I have to be a little careful what I say here.
5 In the limiting case of a conservative fire PRA, where
6 I say I'll assume, if I have a fire in the plant, it
7 goes straight to core damage, it would be very non-
8 conservative because the AOT would not be affected.
9 The baseline and any delta would not be affected by
10 out-of-service equipment.

11 Obviously, we don't have fire PRAs that
12 are quite that conservative. I am sure even Biff
13 Bradley would agree that we're not quite that bad, I
14 think.

15 (Laughter.)

16 On the other hand, if you have a perfect
17 fire PRA, whatever "perfect" means, then you get an
18 accurate AOT calculation. We are somewhere in
19 between.

20 I really don't have any knowledge to know
21 whether the shape of that, if you go to the level of
22 conservatism on one axes and what my delta CDF would
23 be on the other, I don't know if initially
24 conservatism is good because it makes things more
25 conservative, and, then, right at the very end it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 becomes, you know, non-conservative or what it does.
2 So, I really don't know.

3 That will be part when and if 4(b)
4 applications come in prior to us correcting this
5 problem that we are dealing with today. That will be
6 the subject of a licensing action. We will explore
7 that. We will look at it. And if it is non-
8 conservative, we will make appropriate adjustments
9 before we approve the amendment. So, it will be a
10 challenge.

11 MR. BRADLEY: I just wanted to add a quick
12 note on that, since Andy invoked my name.

13 I think for the calculation of the
14 completion time, you know, conservatism is just going
15 to limit the duration. So, where you might have a 30-
16 day, it might be less.

17 Again, 4(b) is like 50.65 in that there's
18 a risk management action component. It is not just in
19 the AOT. It is also establish actions to compensate
20 for the risk. So, again, that is where I would have a
21 little more concern with the use of a conservative
22 fire PRA. I think you would have to temper that
23 judgment that, well, I can't really have 95 percent of
24 all my risk management is fire-related. It is sort of
25 like what Danny said yesterday, you know. So, you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 have to take that into consideration.

2 I do believe that I am a big 4(b) fan, and
3 I think we can make this work. This is one that would
4 greatly benefit from our interim improvements in our
5 next year's worth of work to start closing the gap
6 toward realism.

7 Plants, other than STP, which has minimal
8 fire risk to start with, aren't going to be
9 implementing this for another couple of years. We
10 have one pilot in the pipeline. So, we have some time
11 to try to address this.

12 This is an issue for 4(b). It is a real
13 issue for 4(b) that I don't want to downplay that.

14 CHAIRMAN STETKAR: Yes, yes. Okay.

15 MR. HOWARD: Just in closing, though, I
16 should identify myself. I'm Andrew Howard with the
17 NRR staff, just for the transcript.

18 CHAIRMAN STETKAR: Thank you.

19 MR. HOWARD: But, in the event we do get
20 licensing actions on 4(b) again before the fire PRAs
21 are considered accurate, that will be part of the
22 consideration that we make as far as the licensing
23 review. We are not going to license it and say, you
24 know, the fire risk swamps it all. We are going to do
25 something to make sure those insights can come through

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 for the internal events there. I feel like we can
2 handle it.

3 DR. WEERAKKODY: Can one of your staff
4 speak to NOEDs? I can't think of --

5 MR. HARRISON: Yes. You want to speak to
6 NOEDs?

7 DR. WEERAKKODY: Yes, yes.

8 MR. HARRISON: Well, you volunteered when
9 you walked up. Actually, the staff is not here that
10 typically does NOEDs, but go ahead.

11 CHAIRMAN STETKAR: That's okay. We can
12 probably skip that.

13 MR. HARRISON: Okay.

14 CHAIRMAN STETKAR: You can explain to me
15 what it is.

16 (Laughter.)

17 MR. HARRISON: Notice of Enforcement
18 Discretion. So, a licensee finds itself in a place
19 where it's going to violate the tech spec --

20 CHAIRMAN STETKAR: Okay. Yes, we know.

21 DR. WEERAKKODY: Again, I don't want to go
22 through the whole list.

23 CHAIRMAN STETKAR: No, no, no, no.

24 DR. WEERAKKODY: If you have any
25 questions, we can speak to them. Now, with respect to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 ROP, Biff --

2 MR. BRADLEY: You are going to get to the
3 same thing I was. I would say, by far and away, my
4 biggest concern with that list is ROP.

5 CHAIRMAN STETKAR: Okay.

6 MR. BRADLEY: You are not dealing -- you
7 know, you have SRAs; you've got some great PRA people
8 in the Regions, but you are dealing with a lot of
9 inspectors out there. This is going to be viewed as a
10 target-rich area to color your findings.

11 And let's not kid ourselves. I mean we do
12 need -- that is one that is really a concern for me.

13 CHAIRMAN STETKAR: Okay.

14 MR. HARRISON: And I would agree, if you
15 have an overly-conservative fire PRA and you have a
16 finding, you could exaggerate the finding to make it
17 bigger than it really was. So, realism is needed
18 there. I think if we stepped back and went to the
19 actual purpose of the ROP and the SEP process, it
20 would lessen the effect of that. But the intent of
21 that program and its actual impact are two different
22 things. So, it is worth consideration.

23 CHAIRMAN STETKAR: Okay.

24 DR. WEERAKKODY: Yes, the one note there I
25 would add is based on what I have seen in the ROP

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 experience. When a licensee is about to get a yellow
2 or a red, at that time a lot of resources are applied
3 to address that plant-specific -- you know, here we
4 are discussing, what is the plant-specific concern?
5 And the resources do flow into address the plant-
6 specific concerns in that area.

7 But I do agree with Biff and Donnie; that
8 is an area that you need to watch if we have highly-
9 conservative fire PRAs.

10 MR. HARRISON: And I would say it is even
11 important for white findings. So, the resources to
12 start to go exponentially.

13 CHAIRMAN STETKAR: Yes, I think the
14 message is pretty clear there, yes.

15 MR. WACHOWIAK: And just to amplify, this
16 is Rick Wachowiak from EPRI.

17 There are also some things in the
18 guidance, like in the FAQs, that sometimes it was the
19 right thing to do for the FAQ. Because I am writing
20 this interim position to get transition to 805. So,
21 for the frequencies, the staff wasn't quite sure about
22 the trend in frequencies. So, for transition, they
23 said let's go ahead and look at other fire
24 compensatory measures, if they make a difference.

25 I have heard at least one piece of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 anecdotal evidence where in the field it is being
2 said, if you do that sensitivity on an STP, then that
3 FAQ says you have to bump it to the next color.

4 MR. HARRISON: And that's where maybe the
5 staff needs to provide additional guidance, where the
6 FAQ process was an NFPA-805 FAQ process. It was not a
7 generic fire PRA methodology piece.

8 So, some things were done in the context
9 of enabling 805 applications.

10 CHAIRMAN STETKAR: Yes, I think that came
11 across relatively clear in the discussion earlier this
12 afternoon.

13 MR. HARRISON: And it may have been clear
14 here. It is just I think the point you are making is,
15 if you get into an STP or an ROP process, that may not
16 be clear to everyone that is involved in that process.

17 So, we need to make that clear.

18 CHAIRMAN STETKAR: Sure.

19 MR. HARRISON: Steve Laur?

20 MR. LAUR: Steve Laur, NRC staff.

21 I just want to make one observation. I am
22 not an ROP expert in any sense of the word. But if
23 you had a performance deficiency involving, for
24 instance, a barrier or separation, a variance from the
25 deterministic requirements that you somehow missed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 during your transition, those are likely from the fire
2 PRA, even the potentially conservative fire PRAs, to
3 be felt to be negligible delta risk.

4 And I say that based on two pilots that
5 identified a number of variances from deterministic
6 requirements that they wanted to keep by using the
7 performance-based methods, and they were able to show
8 delta risk numbers that were well within the Reg Guide
9 1.174 numbers and allow the staff to approve the
10 Harris one and still review the Oconee one.

11 CHAIRMAN STETKAR: Okay. Thank you.

12 DR. WEERAKKODY: I put that bullet on the
13 last bullet there because it is an issue that is of
14 interest. I'm not going to speak to that. I'm not a
15 licensee. But to the extent the licensee's senior
16 executives are driven by PRAs with respect to resource
17 allocation, that can have an implication. I do
18 acknowledge that.

19 So, it is just an acknowledgment, and I
20 don't know what the plants do today. I know what they
21 did 20 years ago.

22 MR. HARRISON: Well, and in the context of
23 the two pilots, modifications were proposed and are
24 being implemented as a result of having fire risk
25 numbers that were too high for certain areas. So, to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 offset that fire risk, they have implemented
2 modifications.

3 So, I mean, at least from the two pilots,
4 that comes into play as the resources for making
5 safety improvements. From a regulator's standpoint,
6 the plant got safer. It is hard for us to argue
7 against that.

8 But it is an issue that the industry --
9 and we have heard this a number of times from the
10 industry -- of allocating resources and making the
11 right fixes. An overly-conservative fire PRA would
12 potentially drive you to make modifications that make
13 the plant better, but maybe not be the best
14 modifications you could make.

15 CHAIRMAN STETKAR: Yes, the most optimal
16 mix.

17 MR. DINSMORE: This is Steve Dinsmore from
18 the staff.

19 Could I just add that we have discussed,
20 when we were looking at Oconee, we discussed whether
21 these conservatisms could inappropriately perturb the
22 results, the conclusions. We went through and we were
23 looking at, well, conservatisms don't affect the
24 change in risk calculations, and those that do, we
25 came to the conclusion that any conservatisms that are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 in there would be conservative in the change of risk
2 calculation.

3 I guess if industry doesn't think that is
4 the case, we would be very interested in knowing that
5 because we would need that information to go further
6 on the upcoming submittal.

7 CHAIRMAN STETKAR: Okay.

8 DR. WEERAKKODY: Okay?

9 CHAIRMAN STETKAR: Good.

10 It is 4:42, and I think we have just about
11 run our course on the presentations.

12 First of all, I would like to thank
13 everybody. This has been a rather grueling two-day
14 session. I think everyone has been very, very
15 responsive, both to the issues that were raised from
16 the November Subcommittee meeting. I think we
17 understand much more about some of the topics that
18 were raised at that.

19 I really thank all the effort that was put
20 in, both from the industry, everybody involved, and
21 the staff, to be responsive, and, also, the work that
22 you have done over the last couple of days to kind of
23 respond to questions on the fly. We really, really
24 appreciate that because, as you understand, we also
25 are under some time pressure.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So, again, thanks to everyone for your
2 presentations and your responsiveness.

3 I don't know if we have any members of the
4 public here. I don't see any, but I always have to
5 ask whether anyone --

6 MEMBER SHACK: There are members of the
7 public.

8 CHAIRMAN STETKAR: -- wants to add any
9 comments.

10 John, I don't know if there is anyone on
11 the phone. If we can open up the bridge line just in
12 case there is someone listening who would like to make
13 a comment?

14 This is always a somewhat curious activity
15 because we don't really know whether there's anyone
16 out there.

17 (Laughter.)

18 Okay. Are there any members of the public
19 who would like to make a comment or have anything to
20 add to the proceedings here?

21 Hearing nothing, I'm assuming the answer
22 is no. So, thank you.

23 And as a last item, what I would like to
24 do is, for the remaining Members who are here, is
25 there anything else that you need, questions you would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 like to add?

2 No? Okay, thank you.

3 Just for the record, before we close out
4 the meeting, the process going forward here is that we
5 are a Subcommittee. We are not the ACRS. The
6 Subcommittee will write a report sometime during the
7 next three weeks or so, submit that report to the full
8 Committee, basically, summarizing the process that we
9 have gone through, perhaps some draft conclusions and
10 recommendations.

11 The full Committee will have somewhere on
12 the order of three or four weeks to consider that
13 report. We will have a full Committee meeting in
14 February, where we are expecting to have some input
15 from both the industry and staff on highlights of some
16 of the most important issues. Because, again, we are
17 limited in time in the full Committee meetings to
18 probably an hour and a half or two hours. I don't
19 know whether we have the agenda yet.

20 But what I would like to hear is a
21 synopsis of only the most important issues from both
22 the staff and the industry at that full Committee
23 meeting. I don't want to presuppose what those are.
24 I think we have had adequate discussion over the last
25 couple of days. Perhaps we might have more dialog

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 through John over the next two months or month and a
2 half to identify those.

3 And, then, in the February full Committee
4 meeting, the Committee will, then, draft a letter
5 report to the full Commission in response to the SRM
6 that will have the full Committee's conclusions and
7 any recommendations that we might make to the
8 Commission.

9 So, that is sort of the process and the
10 time schedule. The SRM calls for our report to be
11 submitted by the end of February. That's why we need
12 to close out that process in our full Committee
13 meeting in February.

14 MR. BRADLEY: Is there a date set for
15 that? A date set?

16 CHAIRMAN STETKAR: For our submittal of --

17 MR. BRADLEY: The full Committee?

18 CHAIRMAN STETKAR: Yes, it is.

19 MEMBER SHACK: The agenda -- I mean we
20 know the dates of the meeting.

21 CHAIRMAN STETKAR: We know the dates of
22 the meeting. We don't know the specific -- we don't
23 have the agenda for a specific day, but it is, most
24 probably, the first day of the meeting, which would be
25 Wednesday of what looks like the second week in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 February. I can't remember. It would be about the --

2 MEMBER BLEY: The 10th.

3 CHAIRMAN STETKAR: The 10th or so? Yes.

4 MEMBER BLEY: The 10th is a Thursday. So,
5 it would be either Thursday or Friday.

6 CHAIRMAN STETKAR: It would be either
7 Thursday or Friday of that week. And typically, we
8 like to get the important things in on the first day.
9 So, I would guess it will be on the 10th.

10 Anyway, with that, unless there are other
11 comments by anyone?

12 MEMBER BLEY: I would just like to
13 reiterate what you said and thank everybody. The
14 presentations were exceptionally good and I learned a
15 lot. My questions have narrowed a lot.

16 CHAIRMAN STETKAR: Good.

17 MEMBER SHACK: I'll echo that. I mean it
18 was a tremendous presentation from everybody.

19 CHAIRMAN STETKAR: And again, thank you
20 all.

21 And we are adjourned.

22 (Whereupon, at 4:48 p.m., the proceedings
23 in the above-entitled matter were adjourned.)

24

25

NEAL R. GROSS


COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com



EPRI

ELECTRIC POWER
RESEARCH INSTITUTE



Electrical Cabinet Fires



Rick Wachowiak, EPRI
Doug True, ERIN Engineering & Research




ACRS PRASC
December 14, 2010

Background

- As described in Nov. 16, 2011 ACRS PRASC presentation, electrical cabinet fires are a significant contributor to fire CDFs computed using NUREG/CR-6850/EPRI 1011989
- Purpose:
 - Elaborate on the relationship of the prescribed methods for modeling electrical cabinet fires to large risk contribution
 - Describe how EPRI's near term research activities target some of these areas

FPRA Issues Framework



Technical Areas to be Discussed

- Fire Ignition Frequency Estimation
- Fire Growth Rate
- Peak Heat Release Rate
- Fire Non-Suppression Probability
- Fire Propagation & Damage Assessment
- Operator Response Actions

Fire Ignition Frequency Estimation

- Ignition Source Bin 15 addresses electrical cabinet fires
 - Excludes high energy arcing faults (Bin 16a & 16b)

Source	Number of Events	Bin 15 Plant-wide Ignition Frequency
NUREG/CR-6850	109	4.5E-2/yr
EPRI 1016735	1968-1990: 74 ¹ 1991-2000: 24.5	2.4E-2/yr

- EPRI detected plant-to-plant variability in Bin 15
- A more diffuse prior distribution consistent with those from NUREG/CR-6850 was used and a hierarchical Bayesian analysis was performed. The result was a more broad uncertainty in the Bin 15 estimate.

1 - Excluded some pre-operational events and other data cleanup

Fire Ignition Frequency Estimation (Cont.)

- FAQ 08-0048 requires use of both frequencies for baseline risk and delta risk calculations because of:
“...the large uncertainty in the bin fire frequency due to the sparsity of data for that bin and, therefore, the potential for significant changes should the post-2000 fire event data differ significantly from the 1991-2000 data.”
(See note 1, pg 2 of FAQ 08-0048; note 10, page 10-2 of NUREG/CR-6850, Supplement 1)
- Bin 15 actually has the most data of any ignition source bin
- The larger uncertainty exists to support a more appropriate plant-specific Bayesian update of the frequency


A factor of 2 increase in CDF for Bin 15

Severity Characterization

- Fire growth and peak heat release rate (HRR) based on tests investigating large electrical cabinet fires
 - Many used accelerants or flame sources
 - Qualified and unqualified cable data comingled
 - Open cabinets
- A small number of “sub-bins” used to define peak HRR
- HRR distribution anchored to two key percentiles to characterize HRR distributions: 75th and 98th percentile
 - 98% selected to “*establish an anticipated “high-confidence” fire intensity value expected to bound the vast majority of fires involving a given fire source.*”
- No evidence that these postulated fires, even at the 75th percentile, are consistent with operating experience

Vertical Cabinet Test Results (NUREG/CR-4527)

(Qualified Cable)



Severity Characterization (Cont.)

- Fire growth rate based on same tests and are influenced by the same factors:
 - Use of accelerants or flame sources
 - Qualified and unqualified cable data comingled
 - Open cabinets
- No evidence that these growth rates fires are consistent with operating experience
- Greatly influences damage magnitude and the timeline for damage/operator response

Result is faster and greater damage due to inability to suppress fire and exaggerated zone of influence

Fire Non-Suppression Probability

- The vast majority of electrical cabinet fires in the FEDB are manually suppressed, i.e., no automatic suppression occurs
- Very few (non-HEAF) electrical cabinet fires result in damage to nearby SSCs
- FAQ 08-0050 provided improved credit for manual suppression
- Combination of assumed rapid fire growth rate (12 min) and limited suppression credit leads to higher probability of damage
- No consideration of control vs. suppression

Fire Propagation & Damage Assessment

- FAQ 08-0042 addressed fire propagation outside of “well sealed” cabinets
- Probabilistic treatment of fire propagation within cabinets, e.g., MCCs, removed from originally submitted FAQ 08-0042 in order to expedite closure
- Thus, all MCC fires are treated as damaging entire cabinet
- This increases the level of damage and adds to the fires causing spurious operations

Operator Response Actions

- Rapid growth of large fires propagating within and outside of electrical cabinets reduces the available time for operator response actions
- Examples include response to failure to operate due to assume fire damage (e.g., valves fail to open/close) and spuriously operated valves
- These damage timelines can result in unrealistic human error probabilities driven by the unrealistic fire damage assumptions

The Bottom Line

- Compounding of conservatisms leads to unrealistic estimates of risk from electrical cabinet fires
 - Frequency of fires artificially overstated by continued reliance on original values
 - Assumed fire growth rates do not comport with operating experience
 - Damage does not comport with operating experience
- FAQs helped in some areas, but fell short in providing realistic methods and inputs

Related Near-term EPRI Research

- Update of FEDB will provide improved basis for:
 - Ignition frequencies
 - Manual suppression
 - Fire growth
 - Fire damage
- Refined binning structure for electrical cabinet peak HRRs will provide improved basis for:
 - Peak HRRs for different cabinet types
 - Allow more realistic fire damage zones

Vertical Electrical Cabinet Heat Release Rate

- Purpose of study: Re-evaluate the heat release rates (HRRs) of cabinet fires recommended for use in NUREG/CR-6850 (Table G-1)

Ignition Source	HRR kW (Btu/s)		Gamma Distribution	
	75th	98 th	α	β
Vertical cabinets with qualified cable, fire limited to one cable bundle	69 (65)	211 (200)	0.84 (0.83)	59.3 (56.6)
Vertical cabinets with qualified cable, fire in more than one cable bundle	211 (200)	702 (665)	0.7 (0.7)	216 (204)
Vertical cabinets with unqualified cable, fire limited to one cable bundle	90 (85)	211 (200)	1.6 (1.6)	41.5 (39.5)
Vertical cabinets with unqualified cable, fire in more than one cable bundle closed doors	232 (220)	464 (440)	2.6 (2.6)	67.8 (64.3)
Vertical cabinets with unqualified cable, fire in more than one cable bundle open doors	232 (220)	1002 (950)	0.46 (0.45)	386 (366)

- Scope limited to:
 - Vertical cabinets
 - No consideration of external influences, or of fire propagation to other cabinets
 - No consideration of fire duration


Vertical Electrical Cabinet Heat Release rate Comparison with NUREG/CR-6850

- Model maintains distinction between qualified-initiated fires and other fires: Qualified-initiated fires account for probability that fire may stay localized
- Model adds refinements and thus more inputs needed than in NUREG/CR-6850:
 - If not ventilation-limited: HRR dependent on combustible loading. Combustible loading estimated based on:
 - Cabinet volume
 - Estimate of cabinet fullness (low/high loading).
 - If ventilation-limited: HRR controlled by amount of air available for combustion.
 - Determination on whether cabinet is cooled by forced or natural ventilation
 - Assessment of robustness regarding gap potential
 - Need to know vent area and position of vents (top, bottom, or vents at intermediate level)
 - EPRI model uses a flowchart to guide fire analyst to proper ventilation model
 - Open-door cabinet fires are not ventilation-limited
 - Closed-door cabinet fires may or not be ventilation-limited based on air flow within cabinet

Summary: Near-term EPRI Work to Address Electrical Cabinet Issues

Technical Area	FEDB	HRR
Fire Ignition Frequency Estimation	Directly	---
Fire Growth Rate	Indirectly	Indirectly
Peak Heat Release Rates	---	Directly
Fire Non-Suppression Probability	Directly	---
Fire Propagation & Damage Assessment	Indirectly	Directly
Operator Response Actions	---	Indirectly

Together...Shaping the Future of Electricity



EPRI

ELECTRIC POWER
RESEARCH INSTITUTE

Roadmap For Attaining Realism In Fire PRAs

Doug True, ERIN Engineering & Research


ACRS PRASC

November 16, 2010

Purpose

- Develop a report that uses insights from industry fire PRAs to identify the important areas of EPRI 1019189/ NUREG/CR-6850 where bounding assumptions/ simplifications are unduly influencing FPRA results
- Report Objectives:
 - Identify key areas needing additional realism
 - Illuminate causes
 - Identify and organize a set of reasonable near-term research activities (next ~3 years)
 - Inform & update the EPRI FPRA Action Matrix

FPRA Issues Framework



Category 1: Fire Initiation, Detection, Suppression

Areas In Need of Additional Realism:

- Fire Event Data Characterization
 - Fire Events Database
 - Fire Ignition Frequency
- Fire Severity Characterization
 - Incipient Fire Growth in Electrical Cabinets
 - Oil Fire Severity
- Incipient Detection
 - Credit for Incipient Detection
- Fire Suppression & Control
 - Credit for Fire Suppression & Control

Fire Event Data Characterization


- Fire Events Database
 - The events in the current FEDB do not align well with the manner in which they are used.
 - Assumptions are used to make links that could be supported by data
 - The current FEDB only includes data through 2000
 - The current FEDB relies on weak event descriptions and a less than traceable categorization scheme
 - Risk-informed, Performance-based Fire Protection will require a long-term fire event data collection & analysis program

Fire Event Data Characterization

- Fire Ignition Frequency
 - Current approach to component-based ignition frequencies relies upon an allocation technique rather than component-specific ignition frequencies
 - Current approach to the calculation of ignition frequencies is simplistic, does not comport with current data analysis techniques, and does not account well for plant-to-plant variability
 - Treatment of transient ignition frequencies does not address administrative controls
 - No credit for control of transient combustibles

Inventory of Electrical Cabinets (Bin 15)

Relative Frequency
Per Cabinet




* Draft information (unverified)

© 2010 Electric Power Research Institute, Inc. All rights reserved.

Inventory of HEAF Sources > 1000V (Bin 16b)

Relative Frequency
Per Source




* Draft information (unverified)

© 2010 Electric Power Research Institute, Inc. All rights reserved.

Plant-wide Inventory of Pumps (Bin 21)


Relative Frequency
Per Pump



* Draft information (unverified)

© 2010 Electric Power Research Institute, Inc. All rights reserved.

Plant-wide Inventory of Air Compressors (Bin 9)



* Draft information (unverified)

© 2010 Electric Power Research Institute, Inc. All rights reserved.

Database & Ignition Frequencies

- Implications for FPRA
 - Current FAQ requires reliance on old data
 - Current database has non-negligible frequency contribution from “indeterminate” events
 - All fire events treated as entering the t^2 growth phase
 - Experience does not support this


Could easily overstate likelihood of true fires by a factor of 2-5 for key bins

Insights from enhanced database will provide valuable input to other tasks

Fire Severity Characterization

- Incipient Fire Growth in Electrical Cabinets
 - Events from Fire Events Database (FEDB) are treated as in the t^2 growth phase even though vast majority are suppressed or controlled before external damage occurs
- Oil Fire Severity
 - Treatment of oil fires severity is simplistic and over-predicts fire severity vs. events in current FEDB
 - FAQ-44 adjusted treatment for MFW pump oil fires, but other components need a similar update:
 - Pumps
 - Transformers
 - Diesel generators

FPRA Issues Framework



Category 2: Fire Damage Assessment

Areas In Need of Additional Realism :

- Fire Growth Assumptions
 - Fire growth and comparison with data
- Peak Heat Release Rates
 - Electrical cabinet peak heat release rate (HRR)
 - Transient Ignition Source HRR
 - Hot Work HRR
 - Other HRRs
- Damage Assessment
 - Switchgear High Energy Arcing Faults
 - Bus Duct High Energy Arcing Faults
 - Damage to Sensitive Electronic Equipment
- Fire Propagation
 - Electrical cabinet propagation
- Fire Modeling
 - Fire Modeling Guidance

Fire Growth Assumptions

- Fire growth and comparison with data
 - The treatment of electrical fire growth rates is very coarse and does not address condition-specific factors
 - Ventilation-limited conditions
- Fires in the database do not appear to evolve in the t^2 development phase for some time
- Current assumptions has artificially assigned fire growth rates
 - e.g., 12 minute fire growth timing for electrical cabinets
- Artificially limits benefit of intervention actions
- Improved database should provide better basis for fire growth assumptions

NUREG/CR-4527

- Primary basis for 12 minute fire growth rate assumption
- To ignite cables, utilized ignition source comprised of a polyethylene bucket containing:
 - 1 quart of acetone
 - 1 lb of kimwipes
- Flame height of ~3ft
- Duration of source burn ~35 min

- Source insufficient to sustain burn unless cable bundles were physically separated

NUREG/CR-4527 – HRR of ignition source only




Figure 6. Heat Release Rate for the Transient Ignition Source; Screening Test #5

NUREG/CR-4527 – Screening Test Results




Figure 8. Heat Release Rate Plots for Scoping Tests #1 through 5

NUREG/CR-4527 Scoping Test Results

Test # ^a	Cable Type	Amount of In Situ Fuels (KJ) ^{b,c}	Cabinet ^d Ventilation Method	Peak HRR (KW)	Intense Burn Duration (min)	Test Result
ST1	Q	117,000	No doors	24	15	Bundle did not burn
ST2	Q	117,000	No doors	27	17	No propagation
ST3	Q	117,000	No doors	77	18	Entire bundle consumed
ST4	Q	117,000	No doors	82	17	Almost entire bundle consumed
ST5	UQ	117,000	No doors	132	17	Entire bundle consumed
ST6	Q	348,500	No doors	82	25	No propagation
ST7	Q	348,500	Doors closed	95	25	No propagation
ST8	Q	582,875	Doors closed	93	30	No propagation
ST9 barriers	Q	234,990	Doors open	74	20	No propagation
ST10	UQ	611,530	Doors closed	280	30	Propagated All burned
ST11	UQ	611,530	Door open	506	20	Propagated All burned

No significant damage

NUREG/CR-4527 – “Preliminary Cabinet Tests”

Table 4

Matrix of Preliminary Cabinet Tests

TEST #	IGNITION FUEL	CABINET		IN SITU FUEL	
		TYPE	VENTILATION	TYPE	AMOUNT (KJ) [BTU]
PCT 1	Transient	Vertical	Vent Grills on Doors	UQ	7.283 x 10 ⁵ [6.90 x 10 ⁵]
PCT 2	Transient	Vertical	Doors Open	UQ	1.051 x 10 ⁶ [1 x 10 ⁶]
PCT 3	Transient	Vertical	Doors Open	Q	1.055 x 10 ⁶ [1 x 10 ⁶]
PCT 4	Heptane	Vertical	Doors Open	Heptane	56.78 l (.929 m ² pan) [15 gal (10 ft ² pan)]
PCT 5	Electrical	Benchboard	Door Open Front Grill	UQ	1.519 x 10 ⁶ [1.44 x 10 ⁶]
PCT 6	Transient	Benchboard	Door Open Front Grill	Q	1.551 x 10 ⁶ [1.47 x 10 ⁶]

Fire Growth Rate Data – Electrical Cabinets

Test	Time to Peak	Steady Burning	Time to Decay	Ignition Source	Cable	Ventilation
ST1	7	8	15	Transient	Qualified	Open
ST2	6	11	17	Transient	Qualified	Open
ST3	10	8	18	Transient	Qualified	Open
ST4	14	3	17	Transient	Qualified	Open
ST5	8	9	17	Transient	Unqualified	Open
ST6	8	17	25	Transient	Qualified	Open
ST7	18	7	25	Transient	Qualified	Closed
ST8	10	20	30	Transient	Qualified	Closed
ST9	10	10	20	Transient	Qualified	Open
ST10	10	20	30	Transient	Unqualified	Closed
ST11	18	2	20	Transient	Unqualified	Open
PCT1	11	10	21	Transient	Unqualified	Closed
PCT2	12	2	14	Transient	Unqualified	Open
PCT3	13	14	27	Transient	Qualified	Open
PCT4a	16	0	16	Heptane Pool	Unqualified	Open
PCT4c	16	0	16	Heptane Pool	Unqualified	Open
PCT5	17	0	17	Electrical	Unqualified	Open
PCT6	11	0	11	Transient	Qualified	Open
Test 21	4	14	18	Gas Burner	Unqualified	Open
Test 22	9	2	11	Gas Burner	Unqualified	Open
Test 23	10	0	10	Transient	Qualified	Open
Test 24	12	0	12	Electrical	Qualified	Open
Average	11.4	7.1	19			

NUREG/CR-4527 – Scoping Test Conclusions

- “A number of conclusions can be made as a result of the Scoping Tasks that give insight into cabinet fire development and input into the Preliminary Cabinet Tests. The conclusions are as follows:
 - There is a “critical” amount of “ignition source fuel” that is necessary to ignite a cable bundle, particularly qualified cable.
 - Qualified cable fires (with the selected cable and ignition source) in vertical cabinets do not spread throughout the cabinet.
 - Unqualified cable in vertical cabinets will easily ignite (with the selected ignition source) and propagate a fire in a single cabinet.
 - Burning rate (as measured by the HRR) is affected by the ventilation method (i.e., closed or open cabinet door) in tests using unqualified cable. Closed cabinet doors appear to result in higher cabinet temperature but also cause oxygen deprivation that appears to limit the burning rate.
 - Smoke obscuration in the test enclosure occurs within eight minutes in unqualified cable cabinet fires in the configurations tested.
 - The thermal environment in the enclosure does not become severe enough to cause melting of components or result in flashover.
- Furthermore, an important observation made during the tests was that when comparing the test cabinets loaded with in situ fuel (loadings are based on survey information) to pictures of actual nuclear power plant cabinets, the fuel load appears to be small. As a result of the Scoping Tests, it appears that cabinet fires with qualified cable do not propagate significantly. However, cabinet fires with unqualified cable may be a real threat to the safety of a nuclear power plant, from the standpoint of fire spread, and control room habitability, given the “critical” conditions and configurations.”

Ramifications for FPRA

- Simplification in NUREG/CR-6850 leads to potential overstatement of fire growth rate and heat release rate (HRR):
 - Tests designed to cause damage
 - All fires treated as if propagation is possible
 - Fire growth rate set by “transient” ignition source (acetone & kimwipes)
 - Included tests with 10-15 gal of heptane as ignition source
 - Most tests were with open or no doors
 - Many tests were with unqualified cables
 - Benchboard and vertical cabinets treated the same

Ramifications for FPRA (Cont.)

- Damage rate and damage potential appears overstated
- Short time reduces potential for intervention by plant personnel, e.g., operations or brigade
- Needs to be informed by better experience data & more mechanistic treatment of cabinet parameters, e.g., ventilation limited fires

Could easily overstate likelihood of fully involved fire by a factor of 2-5

Peak Heat Release Rates – Electrical Cabinets

- Electrical cabinet peak heat release rate (HRR)
 - HRRs for electrical cabinets are binned very simply
 - Mix and match of test results to assign peak HRRs
 - Assignment of distribution appears to have little connection to experience
 - Expert judgment inscrutable – does not meet PRA Standard requirements
- Simplified scheme for designating peak HRR
 - Qualified/unqualified & number of bundles
 - Ignores ventilation limited cases
 - Applies test results that may not be applicable

Peak Heat Release Rates – Electrical Cabinets (Cont.)

- Major contributor to all current FPRAs
- Not aligned with actual operating experience
- Overstates effects of fires
- Has potential to confound risk-informed decision-making:
 - Assumption of damage that may not occur is not always “conservative”
 - Could mask risk increases from plant changes/ conditions, out-of-service equipment, etc.

Could lead to identification of wrong dominant contributors and misguided decision-making

Fixed Ignition Source HRRs

Tests of Cabinets
with Unqualified Cables

Average of Benchboard
Tests with Open Doors

Table G-1
Recommended HRR Values for Electrical Fires

Ignition Source	HRR kW (Btu/s)		Gamma Distribution	
	75th	98th	α	β
Vertical cabinets with <u>qualified cable</u> , fire limited to one cable bundle	69 ¹ (65)	211 (200)	0.84 (0.83)	59.3 (56.6)
Vertical cabinets with <u>qualified cable</u> , fire in more than one cable bundle	211 (200)	702 (665)	0.7 (0.7)	216 (204)
Vertical cabinets with unqualified cable, fire limited to one cable bundle	90 ⁴ (85)	211 ² (200)	1.6 (1.6)	41.5 (39.5)
Vertical cabinets with unqualified cable, fire in more than one cable bundle closed doors	232 ⁵ (220)	464 ⁶ (440)	2.6 (2.6)	67.8 (64.3)
Vertical cabinets with unqualified cable, fire in more than one cable bundle open doors	232 ⁵ (220)	1002 ⁷ (950)	0.46 (0.45)	386 (366)

Peak Heat Release Rates - Transient Ignition Sources

- Transient ignition sources, e.g., Bins 7, 25, 37
- Source peak HRR data from tests performed on trash bags
- FEDB events are primarily events involving transient ignition sources:
 - Space heaters, extension cords, scaffolding, etc.
 - Only one FEDB event involved a trash receptacle

Overstatement of threat from transient combustibles could skew results and mask important contributors

Quantitative impact on PRA is very plant/scenario-specific, but could be significant

Peak Heat Release Rates – Hot Work

- Majority of events in FEDB are pre-Appendix R
- New FEDB needs to inform with the type of events that actually occur
- HRR should be tied to the types of hot work that has involved fires, rather than an arbitrary HRR from a transient source

Peak Heat Release Rates – Other Sources

- As other refinements are made to FPRA methods, it is expected that additional simplifications/assumptions on peak HRRs will be identified for improvement
- One example involves electrical fires from pumps and fans
- NUREG/CR-6850, Table G-1 says that the data used is from electrical cabinet fire tests and it is “considered conservative”

Fixed Ignition Source HRRs

Table G-1
Recommended HRR Values for Electrical Fires

Ignition Source	HRR kW (Btu/s)		Gamma Distribution	
	75th	98th	α	β
Vertical cabinets with qualified cable, fire limited to one cable bundle	69 ¹ (65)	211 ² (200)	0.84 (0.83)	59.3 (56.6)
Vertical cabinets with qualified cable, fire in more than one cable bundle	211 ² (200)	702 ³ (665)	0.7 (0.7)	216 (204)
Vertical cabinets with unqualified cable, fire limited to one cable bundle	90 ⁴ (85)	211 ² (200)	1.6 (1.6)	41.5 (39.5)
Vertical cabinets with unqualified cable, fire in more than one cable bundle closed doors	232 ⁵ (220)	464 ⁶ (440)	2.6 (2.6)	67.8 (64.3)
Vertical cabinets with unqualified cable, fire in more than one cable bundle open doors	232 ⁵ (220)	1002 ⁷ (950)	0.46 (0.45)	386 (366)
Pumps (electrical fires) ⁸	69 (65)	211 ² (200)	0.84 (0.83)	59.3 (56.6)
Motors ⁸	32 (30)	69 (65)	2.0 (2.0)	11.7 (11.1)
Transient Combustibles ⁹	142 (135)	317 (300)	1.8 (1.9)	57.4 (53.7)

See Note 8: No basis


Note 2: Vertical Cabinet Test

Fixed Ignition Source HRRs (Cont.)

Notes for Table G-2

1. Ref. G.2: Sandia experiments, average of vertical cabinet fire intensities with qualified cable.
2. Ref. G.3: VTT experiments with control cabinets.
3. Ref. G.2: Sandia experiments, average of two bench-board cabinet experiments with qualified cable.
4. The value is based on expert judgment. The expert panel assumes that the type of cable will only affect the ability of the cable to ignite. Therefore, once ignited, a single cable bundle is assumed to burn with similar intensity regardless of the cable qualification. A value of 85 BTU/s was selected as a conservative estimate for unqualified cables to represent a higher intensity at the 75th percentile when compared to qualified cable.
5. Ref. G.2: Sandia experiments, average of two vertical cabinet experiments with unqualified cable and closed doors.
6. Twice the intensity selected for the 75th percentile.
7. Ref. G.2: Sandia experiments, the highest heat release rate observed in cabinets with open door and unqualified cable.
8. No experimental evidence is available for assessing fire intensities for electrical fires in equipment other than electrical cabinets (or panels). Recommended values are considered conservative and are based on electrical cabinet (panel) fires experiments.
9. Distribution estimated based on the range of the tested transient fuel packages summarized in table G-7.

FPRA Issues Framework



Category 3: Plant Impact, Fire PRA Scenarios & Quantification

Areas In Need of Additional Realism:

- Treatment of Hot Shorts
 - AC Circuits Hot Short Probability and Duration
 - DC Circuits Hot Short Probability and Duration
- Human Reliability
 - Human Reliability Methods (HRA) methods and performance shaping factors for fire PRAs
- Modeling of Control Room Fires
 - Control Room Modeling and Treatment in the Fire PRA
- PRA Model Advancement
 - Address unrealistic model simplifications

Summary of Roadmap Conclusions

Conclusion	Primary Bases
Fire characterization does not appear to conform with operating experience	<ul style="list-style-type: none"> • Over-prediction of number of severe fires • Assumed rate of fire growth & severity, e.g., 12 mins in electrical cabinets, oil fire severity • No credit for control of fires
The level of quantified risk appears to be overstated	<ul style="list-style-type: none"> • FPRAs predict high frequency of fires with high CCDPs, but NRC's ASP &ROP have not observed • Predicted frequency of spurious operations not consistent with operating experience
Uneven level of conservatism may mask key risk insights and lead to inappropriate decision-making	<ul style="list-style-type: none"> • Simplifications result in bounding treatment of "bin" • Overstated fire damage can lead to underestimation of risk increases from plant changes • Assumes plant challenge for all fires, e.g., plant trip • No credit for administrative controls

Many areas of expedited research needed to provide enhanced methods

Together...Shaping the Future of Electricity



Perspectives on the Treatment of Cabinet Fires

Steven P. Nowlen
Sandia National Laboratories

ACRS Reliability and PRA Subcommittee
December 13-14, 2010



Cabinet fires are likely to remain important risk contributors

- **The electrical cabinet fire ignition source bin (15) contains more risk-relevant fire events than to any other bin**
 - Cabinets are the single most common source of plant fires
- **One substantial challenge is the wide range of cabinets that exist in plants – variables include:**
 - Function – control, power distribution, switching, junction boxes...)
 - Voltage levels – can range from <50 to >100kV
 - Physical characteristics – including size, construction and venting
 - Fuel loading – type, distribution, and quantities
- **Reflecting the range of potential configurations is difficult**



Limitations to the event data

- **While there are a relatively large number of cabinet fire events in the database, the information on each is rather sparse**
- **Very difficult to parse events into groups**
 - Many events are explicit as to cabinet type based on function
 - Many events are not
- **Attempts to parse the data consistently run into the same problem – what do you do with the large number of ‘unknown’ cases?**
 - ‘6850’ did attempt to parse cabinet fire events
 - Too many were left as unknown
 - The set was eventually collapsed back into a single frequency bin
- **Hopefully the FEDB update effort will provide better data on this important ignition source**



What we know from test data (1 of 2)

- **Three major sources of cabinet fire test data**
 - **NRC/SNL – NUREG/CR-5546**
 - **VTT Finland**
 - **IRSN France**
- **All have focused on control cabinets**
 - **No known investigation of other cabinet types (e.g., power distribution and switching equipment)**
- **Tests have covered a relatively narrow range of fuel loading**
 - **IRSN used surrogate fuel packages (not cables/components)**
 - **NRC used qualified and unqualified cables in various loading arrangements and densities**
 - **VTT did both cables and some tests with components (e.g., circuit cards)**



What we know from test data (2of2)

- **The tests make no attempt to suppress these fires**
 - In reality, plant personnel put most fires out quickly
 - Comparisons between what happens in testing and what happens in an actual event rarely consider what might have happened if the fire had not been suppressed...
 - But that is what fire PRA asks – what might have happened?
- **The tests tell us what can happen if a fire grows unchecked in an electrical cabinet**
- **One caution: slicing the data ‘too thin’ will likely lead to invalid conclusions**
 - SNL performed many tests but early phase tests involved limited fuel loads, were designed to explore fundamental fire spread behaviors, and probably don’t match in-plant conditions
 - Parsing of the data set into small bins is risky at best



Cabinet fires – areas for improvement (1 of 2)

- **Given the importance of cabinet fires any improvements to method would be welcomed by all**
- **A model linking growth time to cabinet contents would be desirable**
 - Challenge will be application – rarely allowed to inspect cabinets
- **Empirical model of ventilation effects on peak HRR is desirable**
 - Prior efforts to model deterministically (e.g., VTT) were not successful
 - Validation should be reasonable achieve given available data
 - Readily implemented because you may only need external inspection
- **Other approaches to peak HRR will be difficult given available data**
 - Again we need inspection of internals to really do better
 - Data will be problematic



Cabinet fires – areas for improvement (2of2)

- **The “well-sealed” issue (non-propagating cabinets)**
 - If we can tie to cabinet rating that would help (e.g., NEMA)
- **Incipient stage timeline implies resetting “time-0”- a real challenge**
 - Strong interaction with how we do fire frequency
 - Would require re-examination of fire events relevant to risk
- **Need to look at other potential drivers for risk results, e.g.:**
 - PRAs do not appear to be taking advantage of THIEF cable damage model
 - Use of conservative cable damage assumptions could overwhelm other issues
 - Need to ensure balance is maintained – Not appropriate to ‘fix’ conservatism driven by cable damage assumptions by making optimistic assumptions about cabinet fire characteristics



Assessing cabinet fire heat release rates (1 of 3)

- **From §3.2.2:**
 - “The peak HRRs assumed for electrical cabinets are binned very simply. As shown in Figure 3-10, there are only 5 bins for electrical cabinets and these do not align well with the test conditions.”
- **‘6850’ parsed the data in an attempt to cover a range of in-plant cabinet configurations and within limits of the available data**
 - e.g., “single bundle” versus “multiple bundles”; qualified versus unqualified...
- **The values cited by NEI only cover vertical cabinets - closed doors**
 - This is the predominate case in general plant areas
 - Very few open-door cabinets outside the main control room and control room annex areas
 - There is a separate treatment provided for the Main Control Board (Appendix L)



Assessing cabinet fire heat release rates (2of3)

- **From §3.2.2:**
 - “The expert judgment applied is essentially inscrutable and does not meet the requirements of the ASME/ANS PRA Standard.”
- **‘6850’ approach may not meet ASME/ANS standard for an expert panel, but it was never meant to**
 - In fact, the standard didn’t exist when this work was done (2002)
- **The approach was pretty simple:**
 - HRR profiles represent the potential peak intensity of a cabinet fire *given no efforts to suppress the fire*
 - The tests were generally assumed to reflect worst case conditions
 - Worst case peak HRRs were generally taken as 98th percentile
 - Average values were generally taken as the 75th percentile
- **The distributions represent the expert judgment of the authors**



Assessing cabinet fire heat release rates (3of3)

- **As in other areas, the intent of the cabinet peak HRR distributions was to provide a generically applicable approach for application to the initial analysis of general plant applications**
- **‘6850’ recommends that analysts review their specific cases and incorporate insights**
 - **Cabinet internals for representative cabinets should be examined**
 - **Fire duration should reflect total fuel load within the cabinet**
 - **Fires don’t burn forever even if there is no intervention**
 - **Fire location within the cabinet should reflect where fuels within the cabinet are actually concentrated**
 - **Fire exposure to external targets should reflect venting conditions and locations**



Comparisons between PRA models and events

- **From §3.2.2:**
 - “The observed damage from operating experience does not align with the damage computed using fire models based on the assumed peak HRR inputs and the damage does not align with actual operating experience.”
- **Many possible explanations – root of this problem is not clear**
 - **Timing is certainly an issue, but we have to be careful**
 - If we incorporate the concept of incipient growth stages, we have to re-think fire frequencies as well
 - ‘6850’ generally called incipient stage fires “non-challenging”
 - The FEDB update effort may not capture incipient events either
 - **Analysts still appear to be applying very conservative cable damage time assumptions**
 - e.g., The THIEF model can add many minutes to the damage time but industry does not seem to be using that tool (NUREG/CR-6931V3)



In Summary...

- **Cabinet fires will likely remain important to plant risk no matter what we do**
- **Better methods would be welcome but we need to maintain consistency between analysis elements**
- **Efforts need to consider other overlapping modeling issues that could drive results – e.g., cable damage assumptions**



U.S. NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

Enhancing Fire PRA Realism Using Original Guidance from NUREG/CR- 6850 (EPRI 1011989)

Dr. Raymond H.V. Gallucci, P.E.

Senior Fire PSA Engineer

NRC Office of Nuclear Reactor Regulation

Purpose

- To twist the words of Shakespeare from Marc Antony's eulogy of Julius Caesar:

**“I come to praise
6850, not to bury it.”**

Outline

- Based on the original guidance (i.e., pre-6850 MOU FAQs) in NUREG/CR-6850 (EPRI 1011989), discuss two simple examples showing how that guidance enables more realistic fire scenarios to be developed when going from scoping to very basic (pre-)fire modeling

Example 1

- Table E.1 Characteristic HRR (Case 1 - Vertical Cabinet, One Qualified Bundle):
 - 69 kW (75th %ile) and 211 kW (98th %ile)
 - Gamma distribution with $\alpha = 0.84$ and $\beta = 59.3$
 - Mean HRR = $\alpha \cdot \beta = 50$ kW (64th %ile)
- Assume damage occurs at temperature (T_{64}) corresponding to mean HRR ($Q_{64} = 50$ kW)
 - Since $T \leftrightarrow Q^{2/3}$, ratio of damage temperature to temperature corresponding to 75th %ile HRR is $T_{64}/T_{75} = (Q_{64}/Q_{75})^{2/3} = (50 \text{ kW}/69 \text{ kW})^{2/3} = 0.81$

ASME/ANS RA-Sa-2009, Part 4 (“Fire”)

- Supporting Requirement FSS-C1
 - CC-I: “... ASSIGN characteristics ... that **bound** potentially risk contributing fire events in the context of both fire intensity and duration ...”
 - CC-II: “... ASSIGN characteristics ... using a **two-point fire intensity** model that encompass low likelihood, but potentially risk contributing, fire events in the context of both fire intensity and duration ...”
 - CC-III: “... ASSIGN characteristics ... that reflect a **range of fire intensities** and durations and that encompass low likelihood, but potentially risk contributing fire events ...”

ASME/ANS RA-Sa-2009, Part 4 (cont.)

- Assuming point-estimate(s) 75th (and/or 98th) %ile HRRs for CC-I or CC-II yields damage probability = 1 since actual threshold is at the 64th %ile HRR
- Assuming a distributed HRR for CC-III yields damage probability = $1 - 0.64 = 0.36$
 - This corresponds to a reduction by a factor of $1/0.36 \approx 3$
- While this example is illustrative only, it shows how use of more detailed, but straightforward, guidance from 6850/1011989 can enhance fire PRA realism


Example 2

- Section G.3.1 on Fire Growth in Electrical Cabinets
 - Fire grows to peak HRR in ~12 minutes
 - Experiments show range from 4 to 18 min
 - A t^2 function can be used to represent growth to this peak
- Compare conservative “instantaneous” HRR peaking ($t = 0$) to t^2 peaking

Simplified HRR Growth Profiles

Blue curve shows t^2 growth
 Red shows equivalent-area step function $[\int_0^1 (t^2) dt = \int_t^1 dt \rightarrow t = 2/3 (0.67)]$

Green shows step function allowing for phenomenology that accounts for more heat being transferred to target by t^2 curve than equivalent-area step function



ASME/ANS RA-Sa-2009, Part 4 (“Fire”)

- Supporting Requirement FSS-C2
 - CC-I: “CHARACTERIZE ignition source intensity ... **at full peak ... HRR ...**”
 - E.g., “instantaneous” ($t = 0$) peak
 - CC-II/III: “CHARACTERIZE ignition source intensity using a **realistic time-dependent fire growth ... HRR** for significant contributors ...”
 - E.g., t^2 growth profile (for illustrative purposes, assume surrogate step function including delay)

Non-Suppression Probability

- Section P.1.3 on Fire Detection-Suppression
 - Probability of non-suppression of an electrical cabinet fire before electrical damage occurs (P_{NS}) within t minutes = $\exp(-0.12t)$, where t includes time from ignition to damage
 - If there is any additional delay (d) included in this time, P_{NS} will be reduced by a factor of $\frac{\{\exp(-0.12[t + d])\}}{\{\exp(-0.12t)\}} = \exp(-0.12d)$
 - Thus, if a t^2 HRR growth profile (using the surrogate step function at t [scaled] = 0.50) is assumed instead of an “instantaneous” peak HRR ($t = 0$), the P_{NS} will be reduced by a factor of $\exp(-0.12[0.50t'])$, where t' is the unscaled time

Reduction in P_{NS}

Time (min)		$\exp(-0.12 [0.50t'])$	P_{NS} Reduction Factor	$\exp(-0.12[0.50t'])$ * 0.36 (from Ex. 1)	Joint Reduction Factor
t'	$0.50t'$				
3	1.5	0.84	1.2	0.30	3.4
6	3	0.70	1.4	0.25	4.0
9	4.5	0.58	1.7	0.21	4.8
12	6	0.49	2.0	0.17	5.8
15	7.5	0.41	2.5	0.15	6.9

The first reduction factor shows how much P_{NS} will be reduced by use of just the surrogate step function at t (scaled) = 0.50 for t^2 growth profiles ranging from 3 to 15 min (with the 12-min profile being the average estimated in 6850/1011989).

The second reduction factor shows the joint effect if the distributed HRR reduction factor of ~3 from Example 1 is also applied.

Conclusion

- While these examples are illustrative only and limited to only two aspects that contribute to fire CDF, they show how use of more detailed, but straightforward, original guidance (i.e., pre-6850 MOU FAQs) from NUREG/CR-6850 (EPRI 1011989) enables more realistic fire scenarios to be developed when going from scoping to very basic (pre-) fire modeling



NRC Review of NEI “Roadmap for Attaining Realism in Fire PRAs”

Dr. Raymond HV Gallucci, PE
Senior Fire PSA Engineer
US NRC

Outline

- NRC Review Comments on NEI
“Roadmap” Report
 - Fire PRA History
 - Scope and Role of NUREG/CR-6850
 - NFPA-805 FAQ Process and Fire PRA
 - NRC “Expectations”

Comments on NEI “Roadmap” Report

- The report appears to misrepresent, or at least try to present in a negative light, aspects of fire PRA history and the more recent activities related to the role of NUREG/CR-6850 and the NFPA-805 FAQ process, particularly in light of their roles in NFPA-805 transition

Fire PRA History

- Plant-specific Fire PRAs originated after WASH-1400's assessment of the Browns Ferry fire in 1975, e.g.,
 - Studies at universities (e.g., UCLA, RPI) ~ 1980
 - General Atomic Fire PRA for an HTGR ~ 1980
 - Early to mid-1980s plant-specific Fire PRAs by PLG

Scope and Role of NUREG/CR-6850

- Specific “first-order” guidance intended for refinement/supplementation by plant-specific analysis, especially for fire modeling
 - Plant-specific guidance necessarily “high level” due to unique aspects at each plant

Scope and Role of NUREG/CR-6850

- Individual tasks (analytic modules) intended to be worked as concurrently as possible with as much integration and iteration among analysts as appropriate
 - No “requirement” that each task create standalone work products to be passed from one task to the next

Scope and Role of NUREG/CR-6850

- Contrary to contentions, 6850 provides guidance for treatment of
 - Sensitive electronics (Attachments H and S)
 - Significant “back-and-forth” between NRC reviewers and Oconee pilot based on 6850
 - “Incipient detection systems” (Attachment P)
 - “Prompt detection” may be credited for “high-sensitivity smoke detection system”
 - Could there be more? Yes (FAQ 08-0046)

NFPA-805 FAQ Process and Fire PRA

- Contrary to contentions, the FAQ process, while not originally intended as a means to modify NUREG/CR-6850, granted some significant “relaxations” to the first-order guidance to facilitate use of Fire PRA in the short-term for NFPA-805 transition
 - Could more have been done? Maybe, but there was consensus in most cases where limits were applied

NFPA-805 FAQ Process and Fire PRA

- Significant “relaxations:”
 - Refined (mostly reduced) fire ignition frequencies
 - A few selected “bins” still subject to sensitivities based on original 6850 frequencies (e.g., electrical cabinets, a key ignition source)
 - Probabilities across spectrum of spill sizes for oil fires
 - Limited by consensus to MFWPs for now

NFPA-805 FAQ Process and Fire PRA

- Significant “relaxations:”
 - “Incipient detection” (Very Early Warning Fire Detection System) credit
 - Up to two orders of magnitude attainable for reducing fire ignition frequencies
 - Limited by consensus to low-V electrical cabinets for now
 - AC “Hot short” durations
 - Experimental results (NEI/EPRI and CAROLFIRE) available; DC deferred by consensus pending completion of DESIREE-FIRE tests

NFPA-805 FAQ Process and Fire PRA

- Some “contentious” limitations due to disagreement between technical experts
 - Transient fire growth rates – clarified for MCR and “trash” fires, but not extended to “other” types of transients
 - Probability of fire spread beyond “sealed” cabinets – continued debate over meaning and proper quantification

NFPA-805 FAQ Process and Fire PRA

- Some “contentious” limitations due to disagreement between technical experts
 - Cable tray fire propagation – defined limits for use of 6850 approach, but expansion deferred pending completion of CHRISTI-FIRE tests
- Given the accelerated agenda (805) for “relaxing” 6850 guidance and limited test results available at the time, the FAQ process should be viewed as a success

NRC “Expectations”

- NRC has “very high” expectations to justify treatment beyond the methods in 6850?
 - NRC “expectations” are set forth in RG 1.200
 - NRC “requires” a high quality fire PRA, whether based in whole, in part, or not at all on 6850
 - E.g., Oconee cited 6850 for their fire PRA. NRC reviews revealed deviations or exceptions, prompting the obvious RAIs: where and why?
 - NEI 07-12 Fire PRA Peer Review guidance itself recognizes need to justify “Unreviewed Analysis Methods” beyond the 6850 methods

Summary

- The report appears to misrepresent, or at least negatively reflect, fire PRA history and the more recent activities related to the role of NUREG/CR-6850 and the NFPA-805 FAQ process
 - Fire PRA History
 - Scope and Role of NUREG/CR-6850
 - NFPA-805 FAQ Process and Fire PRA
 - NRC “Expectations”

Total Fire CDFs (Backup Slide)

- Five plant-specific Fire PRA results presented to show misalignment between prediction and experience can be extrapolated to estimate total Fire CDFs ranging from $\sim 1\text{E-}5/\text{yr}$ to $\sim 1\text{E-}4/\text{yr}$
 - Compatible with historic fire CDF estimates (e.g., IPEEEs, early plant-specific studies)
 - Extent to which plant-specific insights (e.g., fire modeling) are included is unknown

Total Fire CDFs (Backup Calculation)

CCDP		Frequency (1/yr)		CDF (1/yr)	
Threshold	Assumed*	Cumulative	Per Decade**	Per Decade	Sum
≥1E-2	3.2E-2	9.9E-4	9.9E-4	3.2E-5	3.2E-5
≥1E-3	3.2E-3	3.2E-3	2.2E-3	7.1E-6	3.9E-5
≥1E-4	3.2E-4	1.4E-2	1.1E-2	3.5E-6	4.2E-5
≥1E-5	3.2E-5	6.3E-2	4.9E-2	1.6E-6	4.4E-5
≥1E-6	3.2E-6	1.7E-1	1.1E-1	3.4E-7	4.4E-5
*Geometric mean of decade (e.g., $[0.1 \times 0.01]^{1/2} = 0.032$)		**Difference between cumulative frequencies for consecutive decades (e.g, $3.2E-3 - 9.9E-4 = 2.2E-3$)			



NRC Perspective on the NFPA 805 Frequently Asked Question Process

Charles Moulton

Fire Protection Engineer

Division of Risk Assessment

Office of Nuclear Reactor Regulation

December 14, 2010

Frequently Asked Question (FAQ) Process History

- As lessons were learned through the pilot process, licensees asked for a semi-formal process to address guidance document changes
- FAQ process established to provide interim staff approval of changes to NEI 04-02 guidance
- Final closure of a FAQ comes with the approval of a new revision of Regulatory Guide 1.205 incorporating the changes
 - Approximately 18 FAQs were incorporated in NEI 04-02 Revision 2, which was endorsed by RG 1.205, Revision 1

FAQ Status Overview

	Total	Res- olved	With- drawn	Open	In Closure Process
Total	49	35	9	2	3
Non-PRA	33	20	8	2	3
PRA	16	15	1	0	0

“MOU” FAQs

- In mid 2008, a large number of new PRA-related FAQs were introduced into the process
- Many of these FAQs were only problem statements. That is, they were incomplete and did not contain proposed resolutions.
- These FAQs became known as the “MOU” FAQs after the RES/EPRI Memorandum of Understanding.

Alternate FAQ Resolution

- After several months of minimal progress, NRR management determined the need to close the outstanding PRA-related FAQs
- A description of the process that was to be used to close these FAQs is described in a 6/1/2009 letter to NEI
- A number of open PRA-related FAQs (with proposed resolutions) were also closed
- Aligns with regular FAQ process described in RIS 2007-019

Alternate Resolution Process Steps

- Step 1: NRR and RES develop interim position
- Step 2: RES engages EPRI under MOU to obtain comments [non-public]
- Step 3: NRR and RES resolve comments
- Step 4: NRR releases position for public comment
- Step 5: NRR and RES resolve public comments
- Step 6: NRR issues final position

Example Timeline: FAQ 08-0046

TOPIC: Incipient fire detection

- 4/08: Problem statement introduced into FAQ process – no proposed resolution
- Balance of 2008: Several monthly FAQ public meetings are held; minimal progress realized
- 5/1/09: NRC draft interim position sent to MOU

Example Timeline Continued

- 5/19/09: Comments received
- 6/1/09: Alternate resolution process published
- 6/26/09: NRC interim position released for public comment
- 7/31/09: Comments received
- 12/1/09: NRC closure memo issued

PRA FAQ Resolution Breakdown

Total PRA FAQs	16
Standard resolution path	7
Alternate resolution path	9
With initial proposed resolution	4
Without initial proposed resolution	5

Key Lessons

- When used as intended, the FAQ process is very successful.
- An initial proposed resolution is vital to the successful collaborative resolution of any FAQ

PRA FAQ Details (Backup)

FAQ	Topic	Resolution Proposed?	Alternate Resolution?
06-0016	Ignition source counting guidance for electrical cabinets	Yes	No
06-0017	Ignition source counting guidance for high energy arcing faults	Yes	No
06-0018	Ignition source counting guidance for main control board	Yes	No

PRA FAQ Details Continued (Backup)


FAQ	Topic	Resolution Proposed?	Alternate Resolution?
07-0031	Miscellaneous fire ignition frequency binning issues	Yes	No
07-0035	Bus duct counting guidance for high energy arcing faults	Yes	No
08-0042	Fire propagation from electrical cabinets	Yes	Yes
08-0043	Cabinet fire location	Yes	Yes

PRA FAQ Details Continued (Backup)

FAQ	Topic	Resolution Proposed?	Alternate Resolution?
08-0044	Large spill oil fire size	No	Yes
08-0045	Fire Growth in Electrical Cabinets	No	Withdrawn
08-0046	Incipient Fire Detection Systems	No	Yes
08-0047	Spurious Operation Probabilities	Yes	No

PRA FAQ Details Continued (Backup)

FAQ	Topic	Resolution Proposed?	Alternate Resolution?
08-0048	Fire Ignition Frequency Update	No	Yes
08-0049	Cable Tray Fire Propagation	No	Yes
08-0050	Manual Fire Non Suppression Probability	No	Yes
08-0051	Hot short duration	Yes	Yes
08-0052	Transient Fires	Yes	Yes



EPRI

ELECTRIC POWER
RESEARCH INSTITUTE

Fire PRA FAQ Process

Ken Canavan
EPRI

ACRS PRASC
December 14, 2010

FAQ Process – NUREG/CR-6850 Supplement 1

1. NRR staff, in consultation with RES staff, will develop an Interim Position for each FAQ.
2. NRR will transmit the draft Interim Position to RES within two weeks.
3. RES will engage EPRI under the MOU to obtain comments on the FAQ Interim Position within two weeks from receipt of the NRR draft. The MOU Team (RES and EPRI) may agree, disagree, or concur on additional confirmatory research.
4. RES will return the FAQ Interim Position to NRR with recommendations, as appropriate, within five weeks after the start of the process.

FAQ Process – NUREG/CR-6850 Supplement 1

5. NRR will appropriately incorporate recommendations generated through review under the RES/EPRI MOU and provide a proposed resolution of the FAQ for industry and other public stakeholder consideration within seven weeks after the start of the process.
6. Industry and other public stakeholder comments will be received and appropriately considered in finalizing the FAQ resolution and issuing the final FAQ closure documentation within sixteen weeks of the start of the process.

Status of Topic Resolution

FAQ #	Topic	Status	Fire Action Matrix ID
06-0016	Counting cabinets	Closed	
06-0017	Counting cabinet HEAF sources	Closed	
06-0018	Counting Main Control Board	Closed	
07-0031	Misc. frequency binning issues	Closed	
07-0034	Determination of HRR from non-vented cabinets	Withdrawn	2.2
07-0035	HEAF for bus ducts	Partial	2.7
08-0042	Propagation from electrical cabinets	Open	2.2, 2.9
08-0043	Location of fire in electrical cabinet	Partial	2.9

Status of Topic Resolution (continued)

FAQ #	Topic	Status	Fire Action Matrix ID
08-0044	Pump Oil Fires	Partial	1.4
08-0045	Incipient growth phase in electrical panel fires	Open	1.3
08-0046	Incipient fire detection systems	Partial	1.5
08-0047	Spurious operation probability	Open	3.1, 3.2
08-0048	Fire ignition frequency trend	Open	1.1, 1.2
08-0049	Cable tray propagation	Open	
08-0050	Manual non-suppression probability	Partial	1.6
08-0051	Hot short duration	Partial	3.2
08-0052	Transient fire growth rate	Partial	3.2

BACKGROUND

High Energy Arc Faults for Bus Ducts

FAQ: HEAF for bus ducts (07-0035)

Status: Partially Resolved

Issue: Addressed counting and fault placement for: Segmented, Iso-phase, Non-segmented and Cable

Problem: Guidance for zone of influence is conservative

Resolution: Action matrix item 2.7

Review of data from bus duct events and formulation of revised treatment

Propagation from Electrical Cabinets

FAQ: Propagation from electrical cabinets (08-0042)

Status: Open

Issue: Allowed screening of unvented cabinets that are robustly secured

Clarified that fire-sealed does not mean fire-rated

Problem: Likelihood of propagation outside the cabinet was not pursued to get the screening question resolved

Heat release rates different cabinet configurations left unresolved

Experimental data used to generate the HRR values mixes experiment types and does not take into account actual configurations

Resolution: Action matrix items 2.2 and 2.9

Address HRR and propagation as a function of cabinet characteristics and configuration

Location of Fire in an Electrical Cabinet

FAQ: Location of fire in an electrical cabinet (08-0043)

Status: Partially Resolved

Issue: Addressed placement of the cabinet fire for fire modeling purposes

Problem: Does not address configurations where no propagation occurs

- More likely case for many configurations

In original FAQ, but dropped during final stages of resolution

Resolution: Action matrix item 2.9

Review of database and development of revised treatment based on cabinet-specific factors

Pump Oil Fires

FAQ: Pump oil fires (08-0044)

Status: Partially Resolved

Issue: Main Feedwater Pump oil fire treatment addressed

Problem: Original question dealt with all pump oil fires
Resolution left all but MFP unresolved

Resolution: Action matrix item 1.4
Extend the MFW pump fire size argument to other pump types
Investigate ways to model both leaks (small, med, large) and spills (small, med, large)

Incipient Detection Systems

FAQ: Incipient detection systems (08-0046)

Status: Partially Resolved

Issue: Credit for aspirating smoke detectors installed in a specific configuration

Problem: Difficult to apply for configurations outside the one explicitly described in the interim resolution

Resolution Action matrix item 1.5
Refine FAQ 08-0046 to address different configurations on a more generic basis

Spurious Operation Probability

FAQ: Spurious operation probability (08-0047)

Status: Open

Issue: Provided an interim interpretation for use of the existing data

Problem: Behavior of hot shorts remains unresolved
Joint NRC/Industry panel is reviewing the AC and DC test data to provide long term resolution

Resolution: Action matrix item 3.1 and 3.2
DC circuit testing completed. Need to post-process data into DC circuit hot short probability and duration curves
Extend the lessons learned into AC circuit hot short recommendations

Fire Ignition Frequencies

FAQ: Fire ignition frequencies (08-0048)

Status: Open

Issue: Acknowledged that there appears to be a change in the data trajectory post 1990

Problem: Does not allow plants to use the newer data pool if the change in data (from new to total pool) would be significant, eliminating any benefit from using the newer pool

Resolution: Action matrix items 1.1 and 1.2
Revise the FEDB and include data through 2009
Develop revised fire ignition frequencies

Cable Tray Propagation

FAQ: Cable tray propagation (08-0049)

Status: Open

Issue: Provides guidance for two configurations

Problem: Leaves all other configurations (e.g., in a cable spreading room where cable trays may run the entire upper half of the room in close proximity and in all directions)
unresolved

Resolution: Not explicitly included in action matrix
Items expected following publication of CHRISTIFIRE report

Manual Non-Suppression Probability

FAQ: Manual non-suppression probability (08-0050)

Status: Partial Resolution

Issue: Addressed suppression by personnel that detected the fire

Problem: Non-suppression curves used in the response are conservative

Resolution: Action matrix item 1.6
Develop recommended approach for non-suppression curves

Hot Short Duration

FAQ: Hot short duration (08-0051)

Status: Partially Resolved

Issue: Provided duration for some AC control circuits

Problem: DC circuits not addressed

Joint NRC/Industry panel is reviewing the AC and DC test data to provide long term resolution

Resolution: Action matrix item 3.2

DC circuit testing completed

Need to post-process data into DC circuit hot short probability and duration curves

Transient Fires

FAQ: Transient fires (08-0052)


Status: Partially Resolved

Issue: Addressed non-suppression curve to be used in MCR
Provided fire growth times for certain types of transient fire sources

Problem: Left open other types of transient combustibles
Did not address the disconnect between the types of combustibles modeled and the transient fires in the operating experience

Resolution: Action matrix item 2.3
Analysis may be needed to develop a more accurate HRR estimate for transient fires
Address generic 320 kW HRR used for 98 percentile
Ensure accurate reflection of the plant control procedures

Together...Shaping the Future of Electricity



EPRI

ELECTRIC POWER
RESEARCH INSTITUTE



Fire PRA Research Coordination




Rick Wachowiak, EPRI
Ken Canavan, EPRI



ACRS PRASC
December 14, 2010

Fire PRA Industry Organization



Characteristics of Fire PRA Research

- Foster development of more realistic and consistent methods
- Modeled after internal events processes
- Relies on expert peer reviews
- NRC participation is desirable
 - Cognizant of process used for each item
 - Understand the limitations of the models
 - Stable regulatory environment

Categories of Fire PRA Research

- Three categories
 - Development of methods and models
 - Testing to support the methods and models
 - Tools to implement methods and models
- Methods and models drive the testing and tools
- Coordination with industry groups (e.g., owners groups and NRC) is different between the categories

Tools Research

- Industry identifies needs for tools to implement methods and models
- Addresses efficiency
- Typically independent of the NRC

Experimental Research

- Industry or NRC identifies testing that is needed to support methods and models
- Address large uncertainties
- Tends to have long timeframe
- Highest level of coordination needed

Experimental Research – Conceptual Coordination Model

- Defined a scope of experimental research based on nature of model, application of results, etc.
- Identifies the phenomena to be investigated
- Specify the parameters for the experiments
- Reviews the results
 - Determine adequacy
 - Determine applicability
- Results published / presented after wider review

Process given to an “expert panel” type approach

Methods and Models Research

- Industry or NRC identifies methods of models needed
 - Address realism
 - Address efficiency
- These can be generic, application specific, or plant specific
- Need for coordination depends on the topic

Methods and Models Research – Coordination Model

- Anyone can propose a method or model to EPRI
 - Must champion the method
 - Define the need for the method
 - Provide specific application examples
 - Drafts the report (EPRI coordination)
 - Expectation that the method will be public
- EPRI makes “abstracts” available
 - Gauge applicability / priority
 - Panel qualifications

Methods and Models Research – Coordination Model (cont.)

- Expert panel review
 - Defined qualification of members
 - Six to ten members ideal
 - NRC participates subject to qualification requirements
- Deliberations published as part of the method report
- Iteration may be required
- Intent is to determine the boundaries within which the method / model is applicable
- EPRI publishes final method / model
 - Joint publication under MOU is an option

Research Framework Summary

- This framework provides a structured, scrutable way to introduce the latest information
- Informed by the needs of the users
- Efficient way to distribute information to the industry
- Consistent with internal events PRAs
- Fire PRA action plan activities being worked under this framework today

Fire PRA Action Plan – Category 1: Fire Initiation, Detection, Suppression

- 1.1 Fire events database
- 1.2 Fire ignition frequency
- 1.3 Incipient fire growth in electrical cabinets
- 1.4 Oil fire severity
- 1.5 Credit for incipient detection
- 1.6 Fire suppression probabilities

Fire PRA Action Plan – Category 2: Fire Damage Assessment

- 2.1 Fire growth and comparison with data
- 2.2 Electrical cabinet peak heat release rate (HRR)
- 2.3 Transient ignition source HRR
- 2.4 Hot work HRR
- 2.5 Other HRRs
- 2.6 Switchgear HEAF zone of influence (ZOI)
- 2.7 Bus duct HEAF ZOI
- 2.8 Damage to sensitive electronic equipment
- 2.9 Electrical cabinet propagation
- 2.10 Fire modeling guidance

Fire PRA Action Plan – Category 3: Plant Impact, Fire PRA Scenarios & Quantification

- 3.1 AC circuits hot short probability and duration
- 3.2 DC circuits hot short probability and duration
- 3.3 Human reliability Analysis (HRA) methods and performance shaping factors for fire PRAs
- 3.4 Control room modeling and treatment in the fire PRA
- 3.5 Address unrealistic model simplifications

PRA Action Plan – Category 4: Other Fire PRA Items

- 4.1 Update of the fire PRA section of the standard, given lessons learned from the initial peer reviews
- 4.2 Additional peer review guidance.
- 4.3 Results comparison
- 4.4 Fire PRA and NFPA 805 training
- 4.5 Support for peer review of new methods

Summary

- This framework provides a structured, scrutable way to introduce the latest information
- Informed by the needs of the users
- Efficient way to distribute information to the industry
- Fire PRA action matrix activities being worked under this framework today
- Consistent with internal events PRAs

Together...Shaping the Future of Electricity



NRC Perspective on Fire PRA Research

Christiana Lui, Director, RES/DRA
Mark Salley, Chief, RES/DRA/FRB

December 14, 2010

ACRS Reliability and PRA Subcommittee Meeting

Framework

- Focus on NRC regulatory needs
 - Technical basis for regulatory products (Regulations, Regulatory Guides, etc.)
 - Develop tools, models, methods, and data for safety evaluations
- Work closely with the licensing offices in shaping the research program
 - Agency-mandated programs
 - Short-term needs
 - Long-term outlook

Mechanisms

- In-house analyses
- Contractual support
- Domestic and international collaborative efforts
 - Identifying common development needs
 - Building on strengths offered by the participants
- Transparency, traceability, and openness

Current Activities – High Priority

- Fire PRA Training (EPRI)
- Update NUREG/CR-6850 (EPRI)
- Long-Term 10 CFR 50.48(C) Support
- Fire Model Application Guide (EPRI, NIST)
- DC Circuit Testing (EPRI)
- Requantify Spurious Actuation (EPRI)
- Fire Events Database (EPRI)
- Fire Protection Metrics Updating (EPRI/NEI)

Current Activities – High Priority (cont.)

- HRR & Flame Spread Testing
- Kerite Cable Performance (EPRI)
- Effects of Cable Fire Retardant Coatings & Cable Tray Covers
- Incipient Detection System Performance (EPRI)

Current Activities – Medium Priority

- HRA for Post-Fire Human Actions (EPRI)
- Electrical Cabinet HRR
- Compensatory Measures Evaluation
- Fire Protection Meeting Support

Current Activities – Low Priority

- Observe Industry Fire Testing
- Low-Power Shutdown Fire PRA (EPRI)
- Smoke Damage to Instrument & Control Circuits
- Gaseous Fire Extinguishing Agents
- Documentation of Circuit and Manual Operator Action Closure
- Documenting Regulatory History of Radiant Energy Shields & Fire Resistant Cables



Fire PRA Results and Operating Experience

Sunil D. Weerakkody, Ph. D.
Deputy Director-Fire Protection
NRR\DRA

Without knowing the degree of use of plant specific insights (e.g., detailed fire modeling tools used by plants X and Y) staff cannot meaningfully address the difference between industry statements w.r.t. inconsistency between op. experience and fire PRAs.

Example from Beaver Valley (Compartment 1-NS-1)

- *Initial fire PRA screening model CDF = 7.7E-03/Yr*
- *Latest detailed fire modeling CDF = 8.6E-06/Yr*

NRC staff will address the ACRS question using data that is readily available to the staff.

Results of staff analysis of OE

- Browns Ferry is included in the estimations ~ order of 1 E-5/yr
- Browns Ferry fire is excluded in the estimation ~ order of 1 E-7/Yr

Risk reductions associated with post Browns Ferry actions (App. R) vary among operating plants.

- Pilot plants ~ 1 E-5/yr
 - Harris analysis
 - Oconee analysis



Impact of Fire PRA Uncertainties on Other PRA Applications

Sunil D. Weerakkody, Ph. D.
Deputy Director-Fire Protection
NRR\DRA

OTHER APPLICATIONS

- *10 CFR 50.65*
- *RI-ISI*
- *NOEDs*
- *Risk-Informed Licensing Actions*
- *Tech Spec 5B Initiative*
- *Tech Spec 4B Initiative*
- *Reactor Oversight Process*
- *10 CFR 50.69*
- *10 CFR 50.46(a)*
- *Prioritization of licensees' resources for safety improvements*
- *.....*