

May 12, 2011

MEMORANDUM TO: Alexander R. Klein, Chief
Fire Protection Branch
Division of Risk Assessment
Office of Nuclear Reactor Regulation

FROM: Charles E. Moulton, Fire Protection Engineer */RA/*
Fire Protection Branch
Division of Risk Assessment
Office of Nuclear Reactor Regulation

SUBJECT: SUMMARY OF THE APRIL 21, 2011, CATEGORY 2 MEETING
REGARDING THE NATIONAL FIRE PROTECTION ASSOCIATION
STANDARD 805 FREQUENTLY ASKED QUESTION PROCESS

On April 21, 2011, the U.S. Nuclear Regulatory Commission (NRC) staff held a meeting with stakeholders and the public to discuss Frequently Asked Questions (FAQs) at plants that are adopting National Fire Protection Association (NFPA) Standard 805. Licensees and the NRC staff discussed the list of currently open FAQs. The participants determined that both industry stakeholders and the NRC staff needed to continue to work on the remaining open FAQs.

The NRC staff discussed the status of FAQ 08-0053, which deals with Kerite cable categorization. The staff stated that they were finalizing the final test report for publication, and that they planned to issue it to the public in June.

Licensees introduced and discussed a new revision of FAQ 10-0059, which deals with the NFPA 805 Monitoring Program. The discussion focused on the resolution of comments the NRC provided on the previous revision.

Participants agreed that the next FAQ meeting would take place on April 21, 2011, via teleconferencing. A future meeting was scheduled, as a teleconference, for May 26, 2011.

The meeting handouts are available in the Agencywide Documents Access and Management System. The accession number for the revision to FAQ 10-0059 is ML111180481. The comments on FAQ 10-0059 are available at ML110910504 and ML110910508. The March NEI NFPA 805 Task Force FAQ Log is available at ML110910511. The NRC NFPA 805 FAQ status and history document is available at ML111180485.

A list of meeting attendees is enclosed with this memorandum.

Enclosure:
As stated

CONTACT: Charles Moulton, NRR/DRA
(301) 415-2751

MEMORANDUM TO: Alexander R. Klein, Chief
Fire Protection Branch
Division of Risk Assessment
Office of Nuclear Reactor Regulation

FROM: Charles E. Moulton, Fire Protection Engineer
Fire Protection Branch
Division of Risk Assessment
Office of Nuclear Reactor Regulation

SUBJECT: SUMMARY OF THE APRIL 21, 2011, CATEGORY 2 MEETING
REGARDING THE NATIONAL FIRE PROTECTION ASSOCIATION
STANDARD 805 FREQUENTLY ASKED QUESTION PROCESS

On April 21, 2011, the U.S. Nuclear Regulatory Commission (NRC) staff held a meeting with stakeholders and the public to discuss Frequently Asked Questions (FAQs) at plants that are adopting National Fire Protection Association (NFPA) Standard 805. Licensees and the NRC staff discussed the list of currently open FAQs. The participants determined that both industry stakeholders and the NRC staff needed to continue to work on the remaining open FAQs.

The NRC staff discussed the status of FAQ 08-0053, which deals with Kerite cable categorization. The staff stated that they were finalizing the final test report for publication, and that they planned to issue it to the public in June.

Licensees introduced and discussed a new revision of FAQ 10-0059, which deals with the NFPA 805 Monitoring Program. The discussion focused on the resolution of comments the NRC provided on the previous revision.

Participants agreed that the next FAQ meeting would take place on April 21, 2011, via teleconferencing. A future meeting was scheduled, as a teleconference, for May 26, 2011.

The meeting handouts are available in the Agencywide Documents Access and Management System. The accession number for the revision to FAQ 10-0059 is ML111180481. The comments on FAQ 10-0059 are available at ML110910504 and ML110910508. The March NEI NFPA 805 Task Force FAQ Log is available at ML110910511. The NRC NFPA 805 FAQ status and history document is available at ML111180485.

A list of meeting attendees is enclosed with this memorandum.

Enclosure:
As stated

CONTACT: Charles Moulton, NRR/DRA
(301) 415-2751

DISTRIBUTION:

DRA R/F AKlein PLain DOudinot RDaley, RIII RNease, RII
CMoulton HBarrett NOKeefe, RIV JRogge, RI DHarrison

ADAMS Accession No.: ML111320312

Office	NRR/DRA/AFP	NRR/DRA/AFP
Name	CMoulton	AKlein
Date	05 / 12 /11	05 / 12 /11

Official Record Copy

**NATIONAL FIRE PROTECTION ASSOCIATION STANDARD 805
FREQUENTLY ASKED QUESTIONS PROCESS
LIST OF ATTENDEES**

April 21, 2011

U. S. Nuclear Regulatory Commission Staff

D. Frumkin
G. Taylor*
H. Barrett
N. Iqbal
S. Dinsmore

Others

A. Ratchford (Kleinsorg Group)*
B. Waggener (PG&E)*
E. Kleinsorg (Kleinsorg Group)*
G. Chung (SCE&G)*
G. Harris (AmerenUE)*
J. Ertman (Progress)*
K. Lavin (Progress)*
K. Taylor (Appendix R Solutions)*
L. Parker (STARS)*
L. Young (Entergy)*
M. Crompton (EPM)*
M. Fletcher (AmerenUE)*
M. Kammer (SCE&G)*
P. Barbadoro (SCE&G)*
P. Bemis (PG&E)*
P. Boulden (Appendix R Solutions)*
P. Bradley (Dominion)*
P. Ouellette (EPM)*
R. Hendrix (Entergy)*
R. Layton (PNNL)*
R. Oates (Appendix R Solutions)*
R. Richter (SONGS)*
S. Dolcemascolo (SCE)*
S. Short (PNNL)*
T. Basso (NEI)*
T. Jutras (EPM)*
T. Matthews (TVA)*
T. Stafford (TVA)*
V. Rubano (FPL)*
W. Hill (Entergy)*

*participated via phone

ENCLOSURE