

Generic Environmental Impact Statement for License Renewal of Nuclear Plants

Supplement 47

Regarding Columbia Generating Station

Draft Report for Comment

AVAILABILITY OF REFERENCE MATERIALS IN NRC PUBLICATIONS

NRC Reference Material

As of November 1999, you may electronically access NUREG-series publications and other NRC records at NRC's Public Electronic Reading Room at <http://www.nrc.gov/reading-rm.html>.

Publicly released records include, to name a few, NUREG-series publications; *Federal Register* notices; applicant, licensee, and vendor documents and correspondence; NRC correspondence and internal memoranda; bulletins and information notices; inspection and investigative reports; licensee event reports; and Commission papers and their attachments.

NRC publications in the NUREG series, NRC regulations, and *Title 10, Energy*, in the Code of *Federal Regulations* may also be purchased from one of these two sources.

1. The Superintendent of Documents
U.S. Government Printing Office
Mail Stop SSOP
Washington, DC 20402-0001
Internet: bookstore.gpo.gov
Telephone: 202-512-1800
Fax: 202-512-2250
2. The National Technical Information Service
Springfield, VA 22161-0002
www.ntis.gov
1-800-553-6847 or, locally, 703-605-6000

A single copy of each NRC draft report for comment is available free, to the extent of supply, upon written request as follows:

Address: U.S. Nuclear Regulatory Commission
Office of Administration
Publications Branch
Washington, DC 20555-0001

E-mail: DISTRIBUTION.SERVICES@NRC.GOV
Facsimile: 301-415-2289

Some publications in the NUREG series that are posted at NRC's Web site address <http://www.nrc.gov/reading-rm/doc-collections/nuregs> are updated periodically and may differ from the last printed version. Although references to material found on a Web site bear the date the material was accessed, the material available on the date cited may subsequently be removed from the site.

Non-NRC Reference Material

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, and transactions, *Federal Register* notices, Federal and State legislation, and congressional reports. Such documents as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings may be purchased from their sponsoring organization.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at—

The NRC Technical Library
Two White Flint North
11545 Rockville Pike
Rockville, MD 20852-2738

These standards are available in the library for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from—

American National Standards Institute
11 West 42nd Street
New York, NY 10036-8002
www.ansi.org
212-642-4900

Legally binding regulatory requirements are stated only in laws; NRC regulations; licenses, including technical specifications; or orders, not in NUREG-series publications. The views expressed in contractor-prepared publications in this series are not necessarily those of the NRC.

The NUREG series comprises (1) technical and administrative reports and books prepared by the staff (NUREG-XXXX) or agency contractors (NUREG/CR-XXXX), (2) proceedings of conferences (NUREG/CP-XXXX), (3) reports resulting from international agreements (NUREG/IA-XXXX), (4) brochures (NUREG/BR-XXXX), and (5) compilations of legal decisions and orders of the Commission and Atomic and Safety Licensing Boards and of Directors' decisions under Section 2.206 of NRC's regulations (NUREG-0750).

Generic Environmental Impact Statement for License Renewal of Nuclear Plants

Supplement 47

Regarding Columbia Generating Station

Draft Report for Comment

Manuscript Completed: August 2011
Date Published: August 2011

Proposed Action Issuance of a renewed operating license, NPF-21, for Columbia Generating Station in the city of Richland, Benton County, WA.

Type of Statement Draft Supplemental Environmental Impact Statement

Agency Contact Daniel Doyle
U.S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Mail Stop O-11F1
Washington, D.C. 20555-0001
Phone: 301-415-3748
Email: Daniel.Doyle@nrc.gov

Comments Any interested party may submit comments on this supplemental environmental impact statement. Please specify NUREG-1437, Supplement 47, draft, in your comments. Comments must be received by November 16, 2011. Comments received after the expiration of the comment period will be considered if it is practical to do so, but assurance of consideration of late comments will not be given. Comments may be submitted electronically by searching for docket ID NRC-2010-0029 at the federal rulemaking website, <http://www.regulations.gov>. Comments may also be mailed to:

Cindy Bladey, Chief
Rules, Announcements, and Directives Branch
Office of Administration
Mail Stop: TWB-05-B01M
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555-0001

Please be aware that any comments that you submit to the NRC will be considered a public record and entered into the Agencywide Documents Access and Management System (ADAMS). Do not provide information you would not want to be publicly available.

ABSTRACT

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20

This draft supplemental environmental impact statement (SEIS) has been prepared in response to an application submitted by Energy Northwest to renew the operating license for Columbia Generating Station (CGS) for an additional 20 years.

This draft SEIS includes the preliminary analysis that evaluates the environmental impacts of the proposed action and alternatives to the proposed action. Alternatives considered include replacement power from new natural gas-fired combined-cycle generation; new nuclear generation; a combination alternative that includes some natural gas-fired capacity, energy conservation, a hydropower component, and a wind-power component; and not renewing the license (the no-action alternative).

The U.S. Nuclear Regulatory Commission's (NRC's) preliminary recommendation is that the adverse environmental impacts of license renewal for CGS are not great enough to deny the option of license renewal for energy-planning decisionmakers. This recommendation is based on the following:

- the analysis and findings in NUREG-1437, Volumes 1 and 2, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (GEIS)
- the environmental report submitted by Energy Northwest
- consultation with Federal, State, and local agencies
- the NRC's environmental review
- consideration of public comments received during the scoping process

TABLE OF CONTENTS

| | | | |
|----|---|--|------|
| 1 | | | |
| 2 | ABSTRACT | | v |
| 3 | EXECUTIVE SUMMARY | | xv |
| 4 | ABBREVIATIONS AND ACRONYMS..... | | xix |
| 5 | 1.0 PURPOSE AND NEED FOR ACTION..... | | 1-1 |
| 6 | 1.1 Proposed Federal Action | | 1-1 |
| 7 | 1.2 Purpose and Need for the Proposed Federal Action..... | | 1-1 |
| 8 | 1.3 Major Environmental Review Milestones..... | | 1-1 |
| 9 | 1.4 Generic Environmental Impact Statement..... | | 1-3 |
| 10 | 1.5 Supplemental Environmental Impact Statement | | 1-5 |
| 11 | 1.6 Cooperating Agencies | | 1-6 |
| 12 | 1.7 Consultations..... | | 1-6 |
| 13 | 1.8 Correspondence | | 1-6 |
| 14 | 1.9 Status of Compliance | | 1-7 |
| 15 | 1.10 References | | 1-7 |
| 16 | 2.0 AFFECTED ENVIRONMENT | | 2-1 |
| 17 | 2.1 Facility Description | | 2-1 |
| 18 | 2.1.1 Reactor and Containment Systems..... | | 2-1 |
| 19 | 2.1.2 Radioactive Waste Management..... | | 2-6 |
| 20 | 2.1.3 Nonradiological Waste Management..... | | 2-8 |
| 21 | 2.1.4 Plant Operation and Maintenance | | 2-10 |
| 22 | 2.1.5 Power Transmission System | | 2-10 |
| 23 | 2.1.6 Cooling and Auxiliary Water Systems | | 2-11 |
| 24 | 2.1.7 Facility Water Use and Quality | | 2-17 |
| 25 | 2.2 Surrounding Environment..... | | 2-22 |
| 26 | 2.2.1 Land Use | | 2-23 |
| 27 | 2.2.2 Air Quality and Meteorology | | 2-23 |
| 28 | 2.2.3 Groundwater Resources..... | | 2-25 |
| 29 | 2.2.4 Surface Water Resources | | 2-26 |
| 30 | 2.2.5 Description of Aquatic Resources | | 2-27 |
| 31 | 2.2.6 Terrestrial Resources | | 2-39 |
| 32 | 2.2.7 Important Species and Habitats | | 2-42 |
| 33 | 2.2.8 Socioeconomic Factors | | 2-50 |
| 34 | 2.2.9 Historic and Archaeological Resources | | 2-63 |
| 35 | 2.2.10 Historic and Archaeological Resources at the Columbia Generating | | |
| 36 | Station Site | | 2-67 |
| 37 | 2.2.11 Geologic Environment | | 2-69 |
| 38 | 2.3 Related Federal and State Activities | | 2-71 |
| 39 | 2.4 References | | 2-71 |
| 40 | 3.0 ENVIRONMENTAL IMPACTS OF REFURBISHMENT | | 3-1 |
| 41 | 3.1 References | | 3-2 |
| 42 | 4.0 ENVIRONMENTAL IMPACTS OF OPERATION..... | | 4-1 |
| 43 | 4.1 Land Use | | 4-1 |
| 44 | 4.2 Air Quality | | 4-1 |

Table of Contents

| | | | |
|----|--------|---|------|
| 1 | 4.3 | Groundwater..... | 4-2 |
| 2 | 4.3.1 | Generic Groundwater Issues..... | 4-2 |
| 3 | 4.3.2 | Groundwater Use Conflicts..... | 4-2 |
| 4 | 4.3.3 | Groundwater Quality..... | 4-2 |
| 5 | 4.4 | Surface Water | 4-3 |
| 6 | 4.4.1 | Generic Surface-Water Issues | 4-3 |
| 7 | 4.4.2 | Surface-Water Use Conflicts | 4-3 |
| 8 | 4.5 | Aquatic Resources | 4-3 |
| 9 | 4.5.1 | Generic Aquatic Ecology Issues..... | 4-4 |
| 10 | 4.5.2 | Entrainment | 4-5 |
| 11 | 4.5.3 | Impingement..... | 4-6 |
| 12 | 4.5.4 | Heat Shock | 4-6 |
| 13 | 4.5.5 | Total Impacts on Aquatic Resources..... | 4-7 |
| 14 | 4.6 | Terrestrial Resources | 4-7 |
| 15 | 4.7 | Special Status Species and Habitats | 4-8 |
| 16 | 4.7.1 | Aquatic Species..... | 4-8 |
| 17 | 4.7.2 | Terrestrial Species..... | 4-10 |
| 18 | 4.8 | Human Health | 4-11 |
| 19 | 4.8.1 | Generic Human Health Issues..... | 4-11 |
| 20 | 4.8.2 | Radiological Impacts of Normal Operations | 4-11 |
| 21 | 4.8.3 | Microbiological Organisms | 4-21 |
| 22 | 4.8.4 | Electromagnetic Fields—Acute Effects | 4-21 |
| 23 | 4.8.5 | Electromagnetic Fields—Chronic Effects | 4-22 |
| 24 | 4.9 | Socioeconomics | 4-22 |
| 25 | 4.9.1 | Generic Socioeconomic Issues | 4-23 |
| 26 | 4.9.2 | Housing Impacts..... | 4-23 |
| 27 | 4.9.3 | Public Services: Public Utility Impacts..... | 4-24 |
| 28 | 4.9.4 | Offsite Land Use—License Renewal Period | 4-24 |
| 29 | 4.9.5 | Public Services: Transportation Impacts | 4-25 |
| 30 | 4.9.6 | Historic and Archaeological Resources..... | 4-25 |
| 31 | 4.9.7 | Environmental Justice | 4-28 |
| 32 | 4.10 | Evaluation of New and Potentially Significant Information | 4-37 |
| 33 | 4.11 | Cumulative Impacts..... | 4-39 |
| 34 | 4.11.1 | Cumulative Impacts on Water Resources | 4-40 |
| 35 | 4.11.2 | Cumulative Impacts on Aquatic Resources..... | 4-43 |
| 36 | 4.11.3 | Cumulative Impacts on Terrestrial Resources..... | 4-46 |
| 37 | 4.11.4 | Cumulative Impacts on Human Health | 4-48 |
| 38 | 4.11.5 | Cumulative Socioeconomic Impacts..... | 4-51 |
| 39 | 4.11.6 | Cumulative Impacts on Cultural Resources | 4-53 |
| 40 | 4.11.7 | Cumulative Impacts on Air Quality | 4-54 |
| 41 | 4.11.8 | Summary of Cumulative Impacts..... | 4-56 |
| 42 | 4.12 | References | 4-57 |
| 43 | 5.0 | ENVIRONMENTAL IMPACTS OF POSTULATED ACCIDENTS | 5-1 |
| 44 | 5.1 | DBAs | 5-1 |
| 45 | 5.2 | Severe Accidents | 5-2 |
| 46 | 5.2.1 | Severe Accidents Initiated by Sabotage and Terrorism..... | 5-3 |
| 47 | 5.3 | SAMAs | 5-11 |
| 48 | 5.3.1 | Risk Estimates for CGS..... | 5-11 |
| 49 | 5.3.2 | Adequacy of CGS PSA for SAMA Evaluation..... | 5-17 |
| 50 | 5.3.3 | Potential Plant Improvements..... | 5-23 |

| | | | |
|----|--------|--|------|
| 1 | 5.3.4 | Cost-Beneficial SAMAs | 5-26 |
| 2 | 5.3.5 | Conclusions | 5-31 |
| 3 | 5.4 | References | 5-32 |
| 4 | 6.0 | ENVIRONMENTAL IMPACTS OF THE URANIUM FUEL CYCLE, WASTE MANAGEMENT, AND GREENHOUSE GAS | 6-1 |
| 5 | | | |
| 6 | 6.1 | The Uranium Fuel Cycle..... | 6-1 |
| 7 | 6.2 | Greenhouse Gas Emissions..... | 6-2 |
| 8 | 6.2.1 | Existing Studies | 6-2 |
| 9 | 6.2.2 | Conclusions: Relative Greenhouse Gas Emissions | 6-6 |
| 10 | 6.3 | References | 6-7 |
| 11 | 7.0 | ENVIRONMENTAL IMPACTS OF DECOMMISSIONING | 7-1 |
| 12 | 7.1 | Decommissioning | 7-1 |
| 13 | 7.2 | References | 7-2 |
| 14 | 8.0 | ENVIRONMENTAL IMPACTS OF ALTERNATIVES | 8-1 |
| 15 | 8.1 | Natural Gas-Fired Combined-Cycle Generation..... | 8-3 |
| 16 | 8.1.1 | Air Quality | 8-4 |
| 17 | 8.1.2 | Groundwater Use and Quality | 8-6 |
| 18 | 8.1.3 | Surface-Water Use and Quality | 8-6 |
| 19 | 8.1.4 | Aquatic Ecology | 8-6 |
| 20 | 8.1.5 | Terrestrial Ecology..... | 8-7 |
| 21 | 8.1.6 | Human Health..... | 8-7 |
| 22 | 8.1.7 | Land Use | 8-8 |
| 23 | 8.1.8 | Socioeconomics | 8-8 |
| 24 | 8.1.9 | Transportation | 8-9 |
| 25 | 8.1.10 | Aesthetics | 8-9 |
| 26 | 8.1.11 | Historic and Archaeological Resources | 8-10 |
| 27 | 8.1.12 | Environmental Justice | 8-10 |
| 28 | 8.1.13 | Waste Management | 8-11 |
| 29 | 8.1.14 | Summary of Natural Gas-Fired Impacts | 8-11 |
| 30 | 8.2 | New Nuclear Generation | 8-12 |
| 31 | 8.2.1 | Air Quality | 8-13 |
| 32 | 8.2.2 | Groundwater Use and Quality | 8-14 |
| 33 | 8.2.3 | Surface-Water Use and Quality | 8-14 |
| 34 | 8.2.4 | Aquatic Ecology | 8-14 |
| 35 | 8.2.5 | Terrestrial Ecology..... | 8-15 |
| 36 | 8.2.6 | Human Health..... | 8-15 |
| 37 | 8.2.7 | Land Use | 8-15 |
| 38 | 8.2.8 | Socioeconomics | 8-16 |
| 39 | 8.2.9 | Transportation | 8-16 |
| 40 | 8.2.10 | Aesthetics | 8-17 |
| 41 | 8.2.11 | Historic and Archaeological Resources | 8-17 |
| 42 | 8.2.12 | Environmental Justice | 8-17 |
| 43 | 8.2.13 | Waste Management | 8-18 |
| 44 | 8.2.14 | Summary of Impacts of New Nuclear Generation | 8-18 |
| 45 | 8.3 | Combination Alternative | 8-19 |
| 46 | 8.3.1 | Air Quality | 8-19 |
| 47 | 8.3.2 | Groundwater Use and Quality | 8-21 |
| 48 | 8.3.3 | Surface-Water Use and Quality..... | 8-22 |

Table of Contents

| | | | |
|----|--------|---|------|
| 1 | 8.3.4 | Aquatic Ecology | 8-22 |
| 2 | 8.3.5 | Terrestrial Ecology..... | 8-22 |
| 3 | 8.3.6 | Human Health..... | 8-23 |
| 4 | 8.3.7 | Land Use | 8-23 |
| 5 | 8.3.8 | Socioeconomics | 8-24 |
| 6 | 8.3.9 | Transportation | 8-25 |
| 7 | 8.3.10 | Aesthetics | 8-25 |
| 8 | 8.3.11 | Historic and Archaeological Resources | 8-26 |
| 9 | 8.3.12 | Environmental Justice | 8-26 |
| 10 | 8.3.13 | Waste Management | 8-27 |
| 11 | 8.3.14 | Summary of Impacts of the Combination Alternative..... | 8-28 |
| 12 | 8.4 | Alternatives Considered but Dismissed..... | 8-28 |
| 13 | 8.4.1 | Offsite New Nuclear and Natural Gas-Fired Capacity | 8-28 |
| 14 | 8.4.2 | New Coal-Fired Capacity..... | 8-28 |
| 15 | 8.4.3 | Energy Conservation and Energy Efficiency | 8-29 |
| 16 | 8.4.4 | Purchased Power | 8-30 |
| 17 | 8.4.5 | Solar Power | 8-30 |
| 18 | 8.4.6 | Wind Power | 8-31 |
| 19 | 8.4.7 | Biomass Waste..... | 8-32 |
| 20 | 8.4.8 | Hydroelectric Power | 8-32 |
| 21 | 8.4.9 | Wave and Ocean Energy | 8-33 |
| 22 | 8.4.10 | Geothermal Power..... | 8-33 |
| 23 | 8.4.11 | Municipal Solid-Waste | 8-33 |
| 24 | 8.4.12 | Biofuels..... | 8-34 |
| 25 | 8.4.13 | Oil-Fired Power..... | 8-34 |
| 26 | 8.4.14 | Fuel Cells..... | 8-34 |
| 27 | 8.4.15 | Delayed Retirement..... | 8-35 |
| 28 | 8.5 | No-Action Alternative..... | 8-35 |
| 29 | 8.5.1 | Air Quality | 8-35 |
| 30 | 8.5.2 | Groundwater Use and Quality | 8-35 |
| 31 | 8.5.3 | Surface-Water Use and Quality..... | 8-35 |
| 32 | 8.5.4 | Aquatic Ecology | 8-36 |
| 33 | 8.5.5 | Terrestrial Ecology..... | 8-36 |
| 34 | 8.5.6 | Human Health..... | 8-36 |
| 35 | 8.5.7 | Land Use | 8-36 |
| 36 | 8.5.8 | Socioeconomics | 8-36 |
| 37 | 8.5.9 | Transportation | 8-37 |
| 38 | 8.5.10 | Aesthetics | 8-37 |
| 39 | 8.5.11 | Historic and Archaeological Resources | 8-37 |
| 40 | 8.5.12 | Environmental Justice | 8-37 |
| 41 | 8.5.13 | Waste Management | 8-37 |
| 42 | 8.5.14 | Summary of the Impacts of No Action | 8-37 |
| 43 | 8.6 | Alternatives Summary | 8-38 |
| 44 | 8.7 | References | 8-39 |
| 45 | 9.0 | CONCLUSION | 9-1 |
| 46 | 9.1 | Environmental Impacts of License Renewal..... | 9-1 |
| 47 | 9.2 | Comparison of Environmental Impacts of License Renewal and Alternatives ... | 9-1 |
| 48 | 9.3 | Resource Commitments | 9-2 |
| 49 | 9.3.1 | Unavoidable Adverse Environmental Impacts..... | 9-2 |

Table of Contents

| | | |
|----|---|------|
| 1 | Figure 2.2-4. Distribution of shrub-steppe (shaded area) ecosystem in Washington | 2-40 |
| 2 | Figure 4.9-1. Census 2000 minority block groups within a 50-mi radius of CGS..... | 4-30 |
| 3 | Figure 4.9-2. Census 2000 low-income block groups within a 50-mi radius of CGS | 4-32 |
| 4 | Tables | |
| 5 | Table 2.2-1. Annual fuel use and calculated air emission estimates for significant sources at | |
| 6 | CGS..... | 2-24 |
| 7 | Table 2.2-2. Fish species in the Hanford Reach of the Columbia River in Washington State | 2-31 |
| 8 | Table 2.2-3. Recreationally and commercially important fish species in or near the Hanford | |
| 9 | Reach and the CGS site..... | 2-33 |
| 10 | Table 2.2-4. Relative abundance of fish species collected near the CGS site, September 1974 | |
| 11 | through March 1980 | 2-37 |
| 12 | Table 2.2-5. Listed aquatic and terrestrial species | 2-43 |
| 13 | Table 2.2-6. CGS, employee residence by county | 2-51 |
| 14 | Table 2.2-7. Housing in Benton and Franklin County in Washington | 2-51 |
| 15 | Table 2.2-8. Benton and Franklin Counties public water supply systems (in million gallons per | |
| 16 | day (mgd))..... | 2-52 |
| 17 | Table 2.2-9. Major commuting routes in the vicinity of Columbia Generating Station 2009 | |
| 18 | average annual daily traffic count..... | 2-53 |
| 19 | Table 2.2-10. Population and percent growth in Benton and Franklin counties from 1970–2000 | |
| 20 | and projected for 2010–2050 | 2-55 |
| 21 | Table 2.2-11. Demographic profile of the population in the Columbia Generating Station two- | |
| 22 | county socioeconomic region of influence in 2000 | 2-56 |
| 23 | Table 2.2-12. Demographic profile of the population in the Columbia Generating Station two- | |
| 24 | county socioeconomic region of influence, 2006–2008 3-year estimate | 2-57 |
| 25 | Table 2.2-13. Seasonal housing in counties located within 50 miles of Columbia Generating | |
| 26 | Station | 2-57 |
| 27 | Table 2.2-14. Migrant farm workers and temporary farm labor in counties located within 50 | |
| 28 | miles of Columbia Generating Station..... | 2-58 |
| 29 | Table 2.2-15. Major employers of the Tri-City area in 2007..... | 2-60 |
| 30 | Table 2.2-16. Estimated income information for the Columbia Generating Station region of | |
| 31 | influence in 2008 | 2-60 |
| 32 | Table 2.2-17. Columbia Generating Station privilege tax distribution, 2004–2008 | 2-61 |
| 33 | Table 2.2-18. Columbia Generating Station Sales and Use and Leasehold Taxes, | |
| 34 | FY 2004–2008..... | 2-62 |
| 35 | Table 2.2-19. Estimated relative contribution of Columbia Generating Station to revenue of | |
| 36 | selected jurisdictions, 2007 | 2-62 |
| 37 | Table 3-1. Category 1 issues for refurbishment evaluation | 3-1 |
| 38 | Table 3-2. Category 2 issues for refurbishment evaluation | 3-2 |
| 39 | Table 4.1-1. Land use issues..... | 4-1 |
| 40 | Table 4.2-1. Air quality issues..... | 4-2 |
| 41 | Table 4.3-1. Groundwater use and quality issues..... | 4-2 |
| 42 | Table 4.4-1. Surface water quality issues | 4-3 |
| 43 | Table 4.5-1. Aquatic resources issues | 4-4 |
| 44 | Table 4.6-1. Terrestrial resources issues..... | 4-8 |
| 45 | Table 4.7-1. Threatened or endangered species..... | 4-8 |
| 46 | Table 4.8-1. Human health issues | 4-11 |
| 47 | Table 4.9-1. Socioeconomics issues during the renewal term..... | 4-22 |
| 48 | Table 4.11-1. Summary of cumulative impacts on resources areas | 4-56 |
| 49 | Table 5.1-1. Issues related to postulated accidents..... | 5-1 |

| | | |
|----|--|------|
| 1 | Table 5.3-1. CGS CDF for internal events | 5-12 |
| 2 | Table 5.3-2. Important CGS fire compartments and their contribution to fire CDF | 5-13 |
| 3 | Table 5.3-3. Important SDSs and their contribution to seismic CDF..... | 5-14 |
| 4 | Table 5.3-4. Breakdown of population dose by containment release mode for | |
| 5 | PSA Revision 6.2 | 5-16 |
| 6 | Table 5.3-5. Breakdown of population dose by containment release mode for | |
| 7 | PSA Revision 7.1 | 5-17 |
| 8 | Table 5.3-6. Summary of cost-benefit analyses for CGS..... | 5-27 |
| 9 | Table 6.1-1. Issues related to the uranium fuel cycle and waste management | 6-1 |
| 10 | Table 6.2-1. Nuclear greenhouse gas emissions compared to coal | 6-4 |
| 11 | Table 6.2-2. Nuclear greenhouse gas emissions compared to natural gas | 6-5 |
| 12 | Table 6.2-3. Nuclear greenhouse gas emissions compared to renewable energy sources..... | 6-6 |
| 13 | Table 7.1-1. Issues related to decommissioning..... | 7-1 |
| 14 | Table 8.1-1. Summary of environmental impacts of the natural gas-fired combined-cycle | |
| 15 | generation alternative compared to continued operation of CGS..... | 8-12 |
| 16 | Table 8.2-1. Summary of environmental impacts of the new nuclear alternative compared to | |
| 17 | continued operation of the CGS | 8-18 |
| 18 | Table 8.3-1. Summary of environmental impacts of the combination alternative compared to | |
| 19 | continued operation of CGS | 8-28 |
| 20 | Table 8.5-1. Summary of environmental impacts of no action compared to continued operation | |
| 21 | of CGS..... | 8-38 |
| 22 | Table 8.6-1. Summary of environmental impacts of proposed action and alternatives..... | 8-38 |
| 23 | Table 10-1. List of preparers..... | 10-1 |

EXECUTIVE SUMMARY

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38

Background

By letter dated January 19, 2010, Energy Northwest submitted an application to the U.S. Nuclear Regulatory Commission (NRC) to issue a renewed operating license for Columbia Generating Station (CGS) for an additional 20-year period.

Pursuant to Title 10 of the *Code of Federal Regulations* (10 CFR) 51.20(b)(2), the NRC notes that a renewal of a nuclear power reactor operating license requires preparation of an environmental impact statement (EIS) or a supplement to an existing EIS. In addition, 10 CFR 51.95(c) states that the NRC shall prepare an environmental impact statement, which is a supplement to NUREG-1437, “Generic Environmental Impact Statement for License Renewal of Nuclear Plants” (GEIS).

Upon acceptance of Energy Northwest’s application, the NRC staff (staff) began the environmental review process, described in 10 CFR Part 51, by publishing a Notice of Intent to prepare a supplemental EIS (SEIS) and conduct scoping. In preparation of this SEIS for CGS, the staff performed the following actions:

- conducted public scoping meetings on April 6, 2010, in Richland, WA
- conducted a tribal outreach meeting on April 27, 2010, in Richland, WA
- conducted a site visit at the plant in June 2010
- reviewed Energy Northwest’s environmental report (ER) and compared it to the GEIS
- consulted with other agencies
- conducted a review of the issues following the guidance set forth in NUREG-1555, “Standard Review Plans for Environmental Reviews for Nuclear Power Plants, Supplement 1: Operating License Renewal”
- considered public comments received during the scoping process

Proposed Action

Energy Northwest initiated the proposed Federal action—issuing a renewed power reactor operating license—by submitting an application for license renewal of CGS, for which the existing license, NPF-21, will expire on December 20, 2023. The NRC’s Federal action is the decision whether to renew the license for an additional 20 years.

Purpose and Need for Action

The purpose and need for the proposed action (issuance of a renewed license) is to provide an option that allows for power generation capability beyond the term of the current nuclear power plant operating license to meet future system generating needs. Such needs may be determined by other energy-planning decisionmakers, such as State, utility, and, where authorized, Federal agencies (other than NRC). This definition of purpose and need reflects the NRC’s recognition that, unless there are findings in the safety review required by the Atomic Energy Act or findings in the National Environmental Policy Act (NEPA) environmental analysis that would lead the NRC to reject a license renewal application, the NRC does not have a role in

Executive Summary

1 the energy-planning decisions of whether a particular nuclear power plant should continue to
2 operate.

3 If the renewed license is issued, the appropriate energy-planning decisionmakers, along with
4 Energy Northwest will ultimately decide if the plant will continue to operate based on factors
5 such as the need for power. If the operating license is not renewed, then the facility must be
6 shut down on or before the expiration date of the current operating license—
7 December 20, 2023.

8 **Environmental Impacts of License Renewal**

9 The SEIS evaluates the potential environmental impacts of the proposed action. The
10 environmental impacts from the proposed action are designated as SMALL, MODERATE, or
11 LARGE. As set forth in the GEIS, Category 1 issues are those
12 that meet all of the following criteria:

- 13 • The environmental impacts associated with the issue is
14 determined to apply either to all plants or, for some issues,
15 to plants having a specific type of cooling system or other
16 specified plant or site characteristics.
- 17 • A single significance level (i.e., SMALL, MODERATE, or
18 LARGE) has been assigned to the impacts, except for
19 collective offsite radiological impacts from the fuel cycle
20 and from high-level waste and spent fuel disposal.
- 21 • Mitigation of adverse impacts associated with the issue is
22 considered in the analysis, and it has been determined
23 that additional plant-specific mitigation measures are likely
24 not to be sufficiently beneficial to warrant implementation.

SMALL: Environmental effects are not detectable or are so minor that they will neither destabilize nor noticeably alter any important attribute of the resource.

MODERATE: Environmental effects are sufficient to alter noticeably, but not to destabilize, important attributes of the resource.

LARGE: Environmental effects are clearly noticeable and are sufficient to destabilize important attributes of the resource.

25 For Category 1 issues, no additional site-specific analysis is required in this draft SEIS unless
26 new and significant information is found. Chapter 4 of this report presents the process for
27 finding new and significant information. Site-specific issues (Category 2 issues) are those that
28 do not meet one or more of the criteria for Category 1 issues; therefore, an additional
29 site-specific review for these nongeneric issues is required, and the results are documented in
30 the SEIS. The staff has reviewed Energy Northwest's established process for identifying and
31 evaluating the significance of any new and significant information on the environmental impacts
32 of license renewal of CGS. Neither Energy Northwest nor the NRC identified information that is
33 both new and significant related to Category 1 issues that would call into question the
34 conclusions in the GEIS. This conclusion is supported by the NRC's review of the applicant's
35 ER, other documentation relevant to the applicant's activities, the public scoping process and
36 substantive comments raised, consultations with Federal and State agencies and Native
37 American tribes, and the findings from the environmental site visit conducted by the staff.
38 Further, the staff did not identify any new issues applicable to CGS that have a significant
39 environmental impact. The staff, therefore, relies upon the conclusions of the GEIS for all
40 Category 1 issues applicable to CGS.

41 Table ES-1 summarizes the Category 2 issues applicable to CGS, as well as the staff's findings
42 related to those issues. If the staff determined that there were no Category 2 issues applicable
43 for a particular resource area, the findings of the GEIS, as documented in Appendix B to
44 Subpart A of 10 CFR Part 51, stand.

1 **Table ES-1. NRC conclusions relating to site-specific impact of license renewal**

| Resource area | Relevant Category 2 issues | Impacts |
|-----------------------------------|---|---------|
| Land use | None | SMALL |
| Air quality | None | SMALL |
| Surface water resources | None | SMALL |
| Groundwater resources | None | SMALL |
| Aquatic resources | None | SMALL |
| Terrestrial resources | None | SMALL |
| Special status species & habitats | Threatened or endangered species | SMALL |
| Human health | Electromagnetic fields-acute effects (electric shock) | SMALL |
| Socioeconomics | Housing Impacts Public services (public utilities) Offsite land use Public services (public transportation) Historic & archaeological resources | SMALL |

2 With respect to environmental justice, the staff determined that there would be no
 3 disproportionately high and adverse impacts to these populations from the continued operation
 4 of CGS during the license renewal period. Additionally, the staff determined that no
 5 disproportionately high and adverse human health impacts would be expected in special
 6 pathway receptor populations in the region as a result of subsistence consumption of water,
 7 local food, fish, and wildlife.

8 The staff considered groundwater contamination as potentially new and significant information.
 9 Elevated concentrations of tritium have been observed in groundwater adjacent to the CGS site.
 10 However, the highest concentrations, up to 17,400 picocuries per liter (pCi/L), have been found
 11 in an upgradient well, MW-5, and have been attributed to Department of Energy Hanford Site
 12 operations. Elevated conductivity and concentrations of chloride and sulfate have also been
 13 detected adjacent to the CGS site and have been attributed to the infiltration of circulating
 14 cooling water that entered the soil through drywells. However, these elevated concentrations
 15 have not affected the groundwater used for drinking water; therefore, the staff concludes that
 16 there are no significant impacts associated with groundwater contamination at CGS.

17 **Severe Accident Mitigation Alternatives**

18 Since Energy Northwest had not previously considered alternatives to reduce the likelihood or
 19 potential consequences of a variety of highly uncommon but potentially serious accidents at
 20 CGS, NRC regulation 10 CFR 51.53(c)(3)(ii)(L) requires that Energy Northwest evaluate severe
 21 accident mitigation alternatives (SAMAs) in the course of the license renewal review. SAMAs
 22 are potential ways to reduce the risk or potential impacts of uncommon but potentially severe
 23 accidents and may include changes to plant components, systems, procedures, and training.

24 The NRC reviewed Energy Northwest's evaluation of potential SAMAs. Based on the review, the
 25 NRC concurs with Energy Northwest's identification of 16 potentially cost-beneficial SAMAs.
 26 One of them appears to be aging-related. The staff will document the resolution of this SAMA in
 27 the final SEIS. For the other 15 potentially cost-beneficial SAMAs, the staff concludes that they
 28 do not involve aging management of passive, long-lived systems, structures, and components

Executive Summary

1 during the period of extended operation. Therefore, they need not be implemented as part of
2 license renewal pursuant to 10 CFR Part 54.

3 **Alternatives**

4 The NRC considered the environmental impacts associated with alternatives to renewing the
5 CGS operating license. These alternatives include other methods of power generation and not
6 renewing the CGS operating license (the no-action alternative). Replacement power
7 alternatives considered were natural gas combined-cycle generation; new nuclear generation;
8 and a combination alternative that includes a portion of the natural gas combined-cycle
9 capacity, a conservation component, a purchased power component, a hydropower component,
10 and a wind power component. The no-action alternative and the effects it would have were also
11 considered by the NRC. The NRC evaluated each alternative using the same impact areas that
12 were used in evaluating impacts from license renewal. Where possible, the NRC considered
13 the existing infrastructure at the CGS site (e.g., transmission facilities, water intakes, and
14 discharges) and whether it could be used by new alternative power plants.

15 The NRC also considered many other replacement power alternatives to renewing the CGS
16 operating license; these were later eliminated from detailed study due to technical, resource
17 availability, or commercial limitations that currently exist and are likely to continue to exist when
18 the existing CGS license expires. Replacement power alternatives considered but eliminated
19 from detailed study include the following:

- 20 • offsite new nuclear and natural gas-fired capacity
- 21 • coal-fired capacity
- 22 • energy conservation and energy efficiency as full replacement for current capacity
- 23 • purchased power
- 24 • solar power
- 25 • wind power
- 26 • biomass waste
- 27 • hydroelectric power
- 28 • wave and ocean energy
- 29 • geothermal power
- 30 • municipal solid-waste
- 31 • biofuels
- 32 • oil-fired capacity
- 33 • fuel cells
- 34 • delayed retirement of currently operating generating plants in the region

35 **Recommendation**

36 The NRC's preliminary recommendation is that the adverse environmental impacts of license
37 renewal for CGS are not great enough to deny the option of license renewal for energy-planning
38 decisionmakers. This recommendation is based on the following:

- 39 • the analysis and findings in the GEIS
- 40 • the ER submitted by Energy Northwest
- 41 • consultation with Federal, State, and local agencies
- 42 • the NRC's environmental review
- 43 • consideration of public comments received during the scoping process

ABBREVIATIONS AND ACRONYMS

| | |
|---------|---|
| AADT | annual average daily traffic |
| ac | acre |
| AC | alternating current |
| ACC | averted cleanup and decontamination costs |
| ACHP | Advisory Council on Historic Preservation |
| ADAMS | Agencywide Document Access and Management System |
| AEA | Atomic Energy Act of 1954 |
| AEO | annual energy outlook |
| ALARA | as low as is reasonably achievable |
| ANS | American Nuclear Society |
| ANSI | American National Standards Institute |
| AOC | averted offsite property damage costs costs |
| AOE | averted occupational exposure |
| AOSC | averted onsite costs |
| AP1000 | Advanced Passive 1000 |
| APE | averted public exposure |
| AQCR | air quality control region |
| ASME | American Society of Mechanical Engineers |
| ATWS | anticipated transient without scram |
| AWEA | American Wind Energy Association |
| | |
| BOP | balance of plant |
| BPA | Bonneville Power Administration |
| BRAC | Base Realignment and Closure |
| BTU/kWh | British thermal units per kilowatt hour |
| BWR | boiling-water reactor |
| BWROG | BWR Owners' Group |
| | |
| C | Celsius |
| C-14 | carbon-14 |
| CAA | Clean Air Act |
| CCF | common cause failure |
| CDF | core damage frequency |
| CDM | clean development mechanism |
| CEQ | Council of Environmental Quality |
| CERCLA | Comprehensive Environmental Resource, Compensation, and Liability Act of 1980 |
| CETs | containment event tree |
| CFR | Code of Federal Regulations |

Abbreviations and Acronyms

| | |
|-----------------|--|
| cfs | cubic feet per second |
| CGS | Columbia Generating Station |
| CLB | current licensing basis |
| cm | centimeter |
| CO | carbon monoxide |
| CO ₂ | carbon dioxide |
| COE | cost of enhancement |
| COK | containment intact |
| COL | combined operating license |
| Cs-137 | cesium-137 |
| CsI | cesium iodide |
| CST | condensate storage tank |
| CTUIR | Confederated Tribes of the Umatilla Indian Reservation |
| CWA | Clean Water Act |
| DBA | design basis accident |
| DG | diesel generator |
| DHR | decay heat removal |
| DOE | Department of Energy |
| DPS | distinct population segment |
| DWS | drinking water standard |
| ECCS | emergency core cooling system |
| EDG | emergency diesel generator |
| EFH | essential fish habitat |
| EFSEC | Energy Facility Site Evaluation Council |
| EIA | Energy Information Administration |
| EIS | environmental impact statement |
| EJ | environmental justice |
| ELF-EMF | extremely low frequency-electromagnetic field |
| EMS | environmental management system |
| EN | Energy Northwest |
| EO | Executive Order |
| EOPs | emergency operating procedure |
| EPA | Environmental Protection Agency |
| EPCRA | Emergency Planning and Community Right-to-Know Act |
| EPRI | Electric Power Research Institute |
| EPZ | emergency planning zone |
| ER | environmental report |
| ESA | Endangered Species Act of 1973 |
| ESU | evolutionary significant unit |

| | |
|-----------------|--|
| Eu-152 | europium-152 |
| F | Fahrenheit |
| F&Os | facts and observations |
| FCRPS | Federal Columbia River Power System |
| FERC | Federal Energy Regulatory Commission |
| FES | final environmental statement |
| FFTF | fast flux test facility |
| FIVE | fire-induced vulnerability evaluation |
| FP | fire protection |
| fps | feet per second |
| FR | Federal Register |
| FSAR | final safety analysis report |
| ft | foot |
| ft ² | square foot |
| ft ³ | cubic foot |
| FW | feedwater |
| gal | gallon |
| gCeq/kWh | grams of carbon equivalent per kilowatt hour |
| GEIS | generic environmental impact statement |
| GHG | greenhouse gas |
| gpm | gallons per minute |
| GWh | gigawatt hour |
| H/E | high/early |
| H/I | high/intermediate |
| ha | hectare |
| HAP | hazardous air pollutant |
| HEPA | high efficiency particulate air |
| HEPs | human error probability |
| HFO | high wind, external flood, and other external events |
| HPCS | high-pressure core spray |
| HRA | human reliability analysis |
| HVAC | heating, ventilation, and air conditioning |
| I-129 | iodine-129 |
| I-131 | iodine-131 |
| IAEA | International Atomic Energy Agency |
| ICM | interim compensatory measure |
| IDC | industrial development complex |

Abbreviations and Acronyms

| | |
|-----------------|---|
| in. | inch |
| IPE | internal plant examination |
| IPEEE | internal plant examination of external events |
| ISFSI | independent spent fuel storage installation |
| ISLOCA | interfacing systems loss-of-coolant accident |
| | |
| K | thousand |
| K-40 | potassium-40 |
| kg | kilogram |
| km | kilometer |
| km ² | square kilometer |
| kV | kilovolt |
| | |
| L | liter |
| L/E | low/early |
| L/I | low/intermediate |
| lb | pound |
| LEN | large, early, not scrubbed |
| LERF | large early release frequency |
| LES | large, early, scrubbed |
| LL/E | low-low/early |
| LL/I | low-low/intermediate |
| LLD | lower limit of detection |
| LLMW | low-level mixed waste |
| LLN | large, late, not-scrubbed |
| LLS | large, late, scrubbed |
| LLW | low-level radioactive waste |
| LOCA | loss-of-coolant accident |
| LOOP | loss of offsite power |
| LOSP | loss of offsite power |
| LPCI | low-pressure coolant injection |
| LPCS | low-pressure core spray |
| LRA | license renewal application |
| | |
| m | meter |
| M | million |
| M/E | moderate/early |
| M/I | moderate/intermediate |
| m ² | square meter |
| m ³ | cubic meter |
| mA | milliampere |

Abbreviations and Acronyms

| | |
|-----------------|--|
| MAAP | Modular Accident Analysis Program |
| MACCS2 | MELCOR Accident Consequence Code System 2 |
| MCC | motor control center |
| mg | milligram |
| mgd | million gallons per day |
| mGy | milligray |
| mi | mile |
| mi ² | square mile |
| MIT | Massachusetts Institute of Technology |
| MLLW | mixed low-level radioactive waste |
| mm | millimeter |
| MMI | Modified Mercalli Intensity |
| MOX | mixed oxide |
| mph | miles per hour |
| mrad | millirad |
| mrem | millirem |
| MS | main steam |
| MSA | Magnuson-Stevens Fishery Conservation and Management Act |
| MSIV | main steam isolation valve |
| MSL | mean sea level |
| MSOs | multiple spurious operations |
| MSPI | mitigating system performance indicator |
| mSV | millisievert |
| MT | metric ton |
| MW | megawatt |
| MWe | megawatt-electric |
| MWt | megawatt-thermal |
| | |
| N ₂ | nitrogen |
| NAAQS | National Ambient Air Quality Standards |
| NAS | National Academy of Sciences |
| NDE | non-destructive evaluation |
| NEI | Nuclear Energy Institute |
| NEPA | National Environmental Policy Act |
| NESC | National Electrical Safety Code |
| NHPA | National Historic Preservation Act |
| NIEHS | National Institute of Environmental Health Sciences |
| NMFS | National Marine Fisheries Service |
| NO _x | nitrogen oxides |
| NPDES | National Pollutant Discharge Elimination System |
| NRC | U.S. Nuclear Regulatory Commission |

Abbreviations and Acronyms

| | |
|------------------|--|
| NRHP | National Register of Historic Places |
| NWPCC | Northwest Power and Conservation Council |
| ODCM | offsite dose calculation manual |
| OL | operating license |
| OMB | Office of Management and Budget |
| pCi | picocurie |
| PDS | plant damage state |
| PGA | peak ground acceleration |
| PILOT | payments in lieu of taxes |
| PM ₁₀ | particulate matter with a diameter of 10 micrometers or less |
| PNNL | Pacific Northwest National Library |
| POST | Parliamentary Office of Science and Technology |
| PRA | probabilistic risk assessment |
| PSA | probabilistic safety assessment |
| PSD | prevention of significant deterioration |
| Pu-239/240 | plutonium-239/240 |
| PUD | public utility district |
| PWR | pressurized water reactor |
| RAI | request for additional information |
| RCIC | reactor core isolation cooling |
| RCRA | Resource Conservation and Recovery Act of 1976 |
| RCW | Revised Code of Washington |
| rem | roentgen equivalent man |
| REMP | Radiological Environmental Monitoring Program |
| RFW | reactor feedwater |
| RG | Regulatory Guide |
| RHR | residual heat removal |
| RM | river mile |
| ROI | region of influence |
| ROW | right-of-way |
| RPC | replacement power cost |
| RPV | reactor pressure vessel |
| RRW | risk reduction worth |
| RTC | Report to Congress |
| SAMA | severe accident mitigation alternative |
| SAR | safety analysis report |
| SBO | station blackout |

| | |
|-----------------|--|
| SCE&G | South Carolina Electric and Gas |
| SCR | selective catalytic reduction |
| SDS | seismic damage sequence |
| sec | second |
| SEIS | supplemental environmental impact statement |
| SER | safety evaluation report |
| SFPs | spent fuel pool |
| SHPO | State Historic Preservation Officer |
| SLC | standby liquid control |
| SLOCA | small loss-of-coolant accident |
| SO _x | sulfur oxides |
| SR | supporting requirement |
| Sr-90 | strontium-90 |
| SRV | safety relief valve |
| SSEL | safe shutdown equipment list |
| SSW | standby service water |
| Sv | sievert |
| SW | service water |
| SWTF | sanitary waste treatment facility |
| | |
| T | ton |
| Tc-99 | technetium-99 |
| TCP | traditional cultural property |
| TLD | thermoluminescent dosimeter |
| TSP | total suspended particles |
| TSW | plant service water |
| | |
| USC | U.S. Code |
| USCB | U.S. Census Bureau |
| USFWS | U.S. Fish and Wildlife Service |
| USGS | U.S. Geological Survey |
| | |
| VCSNS | Virgil C. Summer Nuclear Station |
| | |
| WAC | Washington Administration Code |
| WCH | Washington Closure Hanford |
| WDFW | Washington State Department of Fish and Wildlife |
| WDNR | Washington State Department of Natural Resources |
| WDOE | Washington State Department of Ecology |
| WDOH | Washington State Department of Health |
| WDOR | Washington Department of Revenue |

Abbreviations and Acronyms

| | |
|-------|---------------------------------------|
| WISC | Washington Invasive Species Council |
| WNP | WPPSS Nuclear Project |
| WNP-2 | Washington Nuclear Plant 2 |
| WPPSS | Washington Public Power Supply System |
| WSDOH | Washington State Department of Health |
| WTP | waste treatment plant |
| YTC | Yakima Training Center |

1.0 PURPOSE AND NEED FOR ACTION

Under the U.S. Nuclear Regulatory Commission's (NRC's) environmental protection regulations in Title 10, Part 51, of the *Code of Federal Regulations* (10 CFR 51)—which carry out the National Environmental Policy Act (NEPA)—issuance of a new nuclear power plant operating license requires the preparation of an environmental impact statement (EIS).

The Atomic Energy Act of 1954 (AEA) originally specified that licenses for commercial power reactors be granted for up to 40 years with an option to renew for another 20 years. The 40-year licensing period was based on economic and antitrust considerations rather than on technical limitations of the nuclear facility.

The decision to seek a license renewal rests entirely with nuclear power facility owners and, typically, is based on the facility's economic viability and the investment necessary to continue to meet NRC safety and environmental requirements. The NRC makes the decision to grant or deny license renewal based on whether the applicant has demonstrated that the environmental and safety requirements in the agency's regulations can be met during the period of extended operation.

1.1 Proposed Federal Action

Energy Northwest initiated the proposed Federal action by submitting an application for license renewal of Columbia Generating Station (CGS), for which the existing license, NPF-21, expires on December 20, 2023. The NRC's proposed Federal action is the decision whether to renew the license for an additional 20 years.

1.2 Purpose and Need for the Proposed Federal Action

The purpose and need for the proposed action (issuance of a renewed license) is to provide an option that allows for power generation capability beyond the term of the current nuclear power plant operating license to meet future system generating needs. Such needs may be determined by other energy-planning decisionmakers, such as State, utility, and, where authorized, Federal agencies (other than NRC). This definition of purpose and need reflects the NRC's recognition that, unless there are findings in the safety review required by the AEA or findings in the NEPA environmental analysis that would lead the NRC to reject a license renewal application, the NRC does not have a role in the energy-planning decisions of State regulators and utility officials as to whether a particular nuclear power plant should continue to operate.

If the renewed license is issued, State regulatory agencies and Energy Northwest will ultimately decide whether the plant will continue to operate based on factors such as the need for power or other matters within the State's jurisdiction or the purview of the owners. If the operating license is not renewed, then the facility must be shut down on or before the expiration date of the current operating license, December 20, 2023.

1.3 Major Environmental Review Milestones

Energy Northwest submitted an environmental report (ER) (EN, 2010b) as part of its license renewal application (EN, 2010a) in January 2010. After reviewing the application and the ER for sufficiency, the NRC published a Notice of Acceptance and Opportunity for Hearing in the

Purpose and Need for Action

1 *Federal Register* (NRC, 2010a) on March 11, 2010. The NRC published another notice in the
2 *Federal Register*, also on March 11, 2010, on its intent to conduct scoping, thus beginning the
3 60-day scoping period (NRC, 2010b).

4 The agency held two public scoping meetings on April 6, 2010, in Richland, WA (NRC, 2010c).
5 The NRC report entitled, "Environmental Impact Statement Scoping Process Summary Report
6 for Columbia Generating Station," dated December 2010, presents the comments received
7 during the scoping process (NRC, 2010d). Appendix A to this draft supplemental environmental
8 impact statement (SEIS) presents the comments considered to be within the scope of the
9 environmental license renewal review and the associated NRC responses.

10 In order to verify information given in the ER, NRC staff (staff) visited the CGS site in
11 June 2010. During the site visit, the staff met with plant personnel; reviewed specific
12 documentation; toured the facility; and met with interested Federal, State, and local agencies
13 (NRC, 2010e).

14 Figure 1.3-1 shows the major milestones in the public review of the SEIS. Upon completion of
15 the scoping period and site visit, the NRC prepared and issued this draft SEIS. This document
16 is made available for public comment for 75 days. During this time, the NRC will host public
17 meetings and collect public comments. Based on the information gathered, the NRC will amend
18 the draft SEIS findings as necessary and then publish the final SEIS.




Figure 1.3-1. Environmental review process

The process gives opportunities for public involvement.

19 The NRC has established a license renewal process that can be completed in a reasonable
20 period of time with clear requirements to assure safe plant operation for up to an additional
21 20 years of plant life. The safety review is done simultaneously with the environmental review.
22 The findings of the safety review are documented in a safety evaluation report (SER). The NRC

1 considers the findings in both the SEIS and the SER in its decision to either grant or deny the
 2 issuance of a renewed license.

3 **1.4 Generic Environmental Impact Statement**

4 To help in the preparation of individual operating license renewal EISs, the NRC prepared the
 5 “Generic Environmental Impact Statement for License Renewal of Nuclear Power Plants
 6 (GEIS),” NUREG-1437. In preparing the GEIS, the NRC determined that certain environmental
 7 impacts associated with the renewal of a nuclear power plant operating license were the same
 8 or similar for all plants and, as such, could be treated on a generic basis. In this way, repetitive
 9 reviews of these environmental impacts could be avoided. The generic assessment of the
 10 environmental impacts associated with license renewal was used to improve the efficiency of
 11 the license renewal process. The GEIS documents the findings of a systematic inquiry into the
 12 environmental impacts of continued operations and refurbishment activities associated with
 13 license renewal.

14 During the preparation of the GEIS, the NRC identified 92 environmental impact issues
 15 associated with license renewal. Of the 92 environmental issues analyzed, 69 issues were
 16 resolved generically (i.e., Category 1), 21 would require plant-specific analysis assessments by
 17 license renewal applicants and review by the NRC (i.e., Category 2), and 2 issues, chronic
 18 effects of electromagnetic fields and environmental justice were not categorized. The NRC
 19 performs a plant-specific environmental justice impact analysis for each license renewal.
 20 Appendix B of this SEIS lists all 92 issues.

21 For each potential environmental issue, the GEIS
 22 provides the following information:

- 23 • describes the activity that affects the
 24 environment
- 25 • notes the population or resource that is
 26 affected
- 27 • assesses the nature and magnitude of the impact on the affected population or resource
- 28 • characterizes the significance of the effect for both beneficial and adverse effects
- 29 • determines if the results of the analysis apply to all plants
- 30 • considers if additional mitigation measures would be warranted for impacts that would
 31 have the same significance level for all plants

Significance shows the importance of likely environmental impacts and is determined by considering two variables: **context** and **intensity**.
Context is the geographic, biophysical, and social context in which the effects will occur.
Intensity refers to the severity of the impact, in whatever context it occurs.

32 The NRC’s standard of significance for impacts was established using the Council on
 33 Environmental Quality (CEQ) terminology for “significantly” as used in NEPA, which requires
 34 considerations of both context and intensity (see 40 CFR 1508.27). The NRC established three
 35 levels of significance for potential impacts—SMALL, MODERATE, and LARGE—as defined
 36 below.

- 37 • **SMALL**—Environmental effects are not detectable or are so minor that they will neither
 38 destabilize nor noticeably alter any important attribute of the resource.
- 39 • **MODERATE**—Environmental effects are sufficient to alter noticeably, but not to
 40 destabilize, important attributes of the resource.

Purpose and Need for Action

- 1 • **LARGE**—Environmental effects are clearly noticeable and are sufficient to destabilize
2 important attributes of the resource.

3 The GEIS includes a determination of whether the analysis of the environmental issue could be
4 applied to all plants and whether additional mitigation measures would be warranted (Figure
5 1.4-1). Issues are assigned a Category 1 or a Category 2 designation. As presented in the
6 GEIS, Category 1 issues are those that meet of the following criteria:

- 7 • The environmental impacts associated with the issue have been determined to apply
8 either to all plants or, for some issues, to plants having a specific type of cooling system
9 or other specified plant or site characteristics.
- 10 • A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to
11 the impacts (except for collective offsite radiological impacts from the fuel cycle and from
12 high-level waste and spent fuel disposal).
- 13 • Mitigation of adverse impacts associated with the issue has been considered in the
14 analysis, and it has been determined that additional plant-specific mitigation measures
15 are likely not to be sufficiently beneficial to warrant implementation.




Figure 1.4-1. Environmental issues evaluated during license renewal

*As previously discussed, the GEIS evaluated 92 issues.
Of those 92 issues, 23 require a site-specific analysis.*

1 For generic issues (Category 1), a site-specific analysis is not required in this SEIS unless new
 2 and significant information is found. Chapter 4 of this SEIS presents the process for finding new
 3 and significant information. Site-specific issues (Category 2) are those that do not meet one or
 4 more of the criteria of Category 1 issues, and, therefore, site-specific review for these issues is
 5 required. The SEIS presents the results of the site-specific review.

6 **1.5 Supplemental Environmental Impact Statement**

7 The SEIS presents an analysis that considers the environmental effects of the continued
 8 operation of CGS, alternatives to license renewal, and mitigation measures for minimizing
 9 adverse environmental impacts. Chapter 8 contains analysis and comparison of the potential
 10 environmental impacts from alternatives, and Chapter 9 presents the preliminary
 11 recommendation to the Commission as to whether or not the environmental impacts of license

Purpose and Need for Action

1 renewal are so great that preserving the option of license renewal would be unreasonable. The
2 final recommendation will be made after consideration of comments received on the draft SEIS.

3 In the preparation of this SEIS for CGS, the NRC carried out the following activities:

- 4 • reviewed the information given in the Energy Northwest ER
- 5 • consulted with other Federal, State, and local agencies
- 6 • carried out an independent review of the issues during the site visit
- 7 • considered the public comments received during the scoping process

8 New information can be found from many
9 sources, including the applicant, the NRC, other
10 agencies, or public comments. If a new issue is
11 revealed, then it is first analyzed to determine if it
12 is within the scope of the license renewal
13 evaluation. If it is not addressed in the GEIS, the
14 NRC determines its significance and documents its analysis in the SEIS.

New and significant information either notes a significant environmental issue that was not covered in the GEIS or was not considered in the analysis in the GEIS and leads to an impact finding that is different from the finding presented in the GEIS.

15 **1.6 Cooperating Agencies**

16 During the scoping process, no Federal, State, or local agencies were identified as cooperating
17 agencies in the preparation of this SEIS.

18 **1.7 Consultations**

19 The Endangered Species Act of 1973, as amended; the Magnuson-Stevens Fisheries
20 Conservation and Management Act of 1996, as amended; and the National Historic
21 Preservation Act of 1966 require that Federal agencies consult with applicable State and
22 Federal agencies and groups before taking action that may affect endangered species,
23 fisheries, or historic and archaeological resources, respectively. Below are the agencies and
24 groups with whom the NRC consulted; Appendix D to this report includes copies of consultation
25 documents.

- 26 • Advisory Council on Historic Preservation
- 27 • Confederated Tribes and Bands of the Yakama Nation
- 28 • Confederated Tribes of the Umatilla Indian Reservation
- 29 • National Marine Fisheries Service
- 30 • Nez Perce Tribe
- 31 • State of Washington Department of Archaeology and Historic Preservation
- 32 • U.S. Environmental Protection Agency, Region 10
- 33 • U.S. Fish and Wildlife Service, Pacific Region Office, Portland, OR

34 **1.8 Correspondence**

35 During the course of the environmental review, the NRC contacted the following Federal, State,
36 regional, local, and Tribal agencies listed in Section 1.7.

37 Appendix E contains a chronological list of all documents sent and received during the
38 environmental review.

1 A list of persons who received a copy of this draft SEIS is provided in Chapter 11.

2 **1.9 Status of Compliance**

3 Energy Northwest is responsible for complying with all NRC regulations and other applicable
4 Federal, State, and local requirements. Appendix H to the GEIS describes some of the major
5 Federal statutes. Appendix C to this SEIS includes a list of the permits and licenses issued by
6 Federal, State, and local authorities for activities at CGS.

7 **1.10 References**

8 Atomic Energy Act of 1954 (AEA), § 42 U.S.C § 2011, et seq.

9 Endangered Species Act of 1973 (ESA), § 16 U.S.C. § 1531, et seq.

10 Magnuson-Stevens Fishery Conservation and Management Act, as amended by the
11 Sustainable Fisheries Act of 1996, § 16 U.S.C. § 1855, et seq.

12 National Environmental Policy Act of 1969 (NEPA), § 42 U.S.C. § 4321, et seq.

13 National Historic Preservation Act (NHPA), § 16 U.S.C. § 470, et seq.

14 Energy Northwest (EN), "License Renewal Application, Columbia Generating Station," 2010a,
15 Agencywide Document Access and Management System (ADAMS) Accession
16 No. ML100250668.

17 EN, "License Renewal Application, Columbia Generating Station, Appendix E, Applicant's
18 Environmental Report" 2010b, ADAMS Accession No. ML100250666

19 EN, "Columbia Generating Station, Docket No. 50-397, Environmental Authorizations for CGS
20 Operation," April 20, 2011, ADAMS Accession No. ML11112A130.

21 *U.S. Code of Federal Regulations* (CFR), "Environmental Protection Regulations for Domestic
22 Licensing and Related Regulatory Functions," Part 51, Chapter 1, Title 10, "Energy."

23 U.S. Nuclear Regulatory Commission (NRC), "Generic Environmental Impact Statement for
24 License Renewal of Nuclear Plants," NUREG-1437, Washington, D.C., Volumes 1 and 2, 1996,
25 ADAMS Accession Nos. ML040690705 and ML040690738.

26 NRC, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Main
27 Report—Final Report," NUREG-1437, Washington, D.C., Section 6.3, Table 9.1, 1999, ADAMS
28 Accession No. ML040690720.

29 NRC, "Notice of Acceptance for Docketing of the Application, Notice of Opportunity for Hearing
30 Regarding Renewal of Facility Operating License No. NPF-21 for an Additional 20-Year Period;
31 Energy Northwest; Columbia Generating Station," *Federal Register*, Volume 75, No. 47,
32 March 11, 2010 (2010a), pp. 11572–11574.

33 NRC, "Energy Northwest; Notice of Intent to Prepare an Environmental Impact Statement and
34 Conduct the Scoping Process for Columbia Generating Station," *Federal Register*, Volume 75,
35 No. 47, March 11, 2010 (2010b), pp. 11576–11578.

Purpose and Need for Action

- 1 NRC, "Summary of Public License Renewal Overview and Environmental Scoping Meetings
- 2 Related to the Review of the Columbia Generating Station License Renewal Application (TAC
- 3 Nos. ME3058 and ME3121)," 2010c, ADAMS Accession No. ML101250540.

- 4 NRC, "Environmental Impact Statement, Scoping Process, Summary Report, Columbia
- 5 Generating Station," Richland, WA, 2010d, ADAMS Accession No. ML102770232.

- 6 NRC, "Summary of Site Visit in Support of the Environmental Review of the License Renewal
- 7 Application for Columbia Generating Station (TAC No. ME3121)," 2010e, ADAMS Accession
- 8 No. ML103400163.

2.0 AFFECTED ENVIRONMENT

Columbia Generating Station (CGS) is located in Benton County, WA, 12 miles (mi) (19 kilometers (km)) northwest of Richland and approximately 160 mi (257 km) southeast of Seattle. The CGS site is located on land leased from the U.S. Department of Energy (DOE) within the Hanford Site. The leased area is bounded on the east by the Columbia River. Figure 2.1-1 and Figure 2.1-2 present the 50-mi (80-km) and 6-mi (10-km) vicinity maps, respectively. For purposes of the evaluation in this supplemental environmental impact statement (SEIS), the “affected environment” is the environment that currently exists at and around CGS. Because existing conditions are at least partially the result of past construction and operation at the plant, the impacts of these past and ongoing actions and how they have shaped the environment are presented here. Section 2.1 of this SEIS describes the facility and its operation, and Section 2.2 discusses the affected environment.

Energy Northwest, formerly known as the Washington Public Power Supply System (WPPSS), is the owner and licensee of CGS. CGS was formerly known as Hanford No. 2 and WPPSS Nuclear Project No. 2 (WNP-2). Energy Northwest is a municipal corporation and joint operating agency of the State of Washington. It is comprised of 27 public member utilities from across the state. All electrical energy produced at CGS is delivered to electrical distribution facilities owned and operated by Bonneville Power Administration (BPA) as part of the Federal Columbia River Power System (FCRPS) (EN, 2010b).

2.1 Facility Description

CGS is a single unit nuclear power plant that began commercial operation in December 1984. The CGS site boundary encloses approximately 1,089 acres (ac) (441 hectares (ha)) leased to Energy Northwest by the DOE. The most conspicuous structures on the CGS site include the reactor containment building, the turbine building, six cooling towers, and various buildings auxiliary to the reactor (EN, 2010b). Figure 2.1-3 provides a general layout of the CGS site.

2.1.1 Reactor and Containment Systems

CGS is a single unit nuclear power plant with a boiling water reactor (BWR). General Electric Company supplied the nuclear steam supply system, and Westinghouse Electric Company supplied the turbine generator. The nuclear steam supply system uses a single-cycle, forced-circulation system and is designated a BWR/5 reactor. The reactor core produces heat that boils water, producing steam for direct use in a turbine-generator to produce electricity.

The containment consists of primary and secondary containment systems. The primary containment structure is a free-standing steel pressure vessel containing a drywell and a suppression chamber. The secondary containment structure consists of the reactor building, which completely encloses the primary containment. The reactor building has reinforced-concrete exterior walls up to the refueling floor. Above this level, the reactor building is a steel framed structure with insulated metal siding with sealed joints.

CGS fuel for the reactor core consists of enriched (less than 5 percent by weight) uranium dioxide pellets sealed in Zircaloy-2 tubes. Fuel design is such that individual rod average burnup (burnup averaged over the length of the fuel rod) will not exceed 62,000 megawatt-days per metric ton uranium. The maximum rated power level limit of the reactor planned for the

Affected Environment

1 extended period of operation is 3,486 megawatts-thermal (MWt). The net and gross electrical
2 power outputs are 1,190 and 1,230 megawatts-electric (MWe), respectively (EN, 2010).

3 In February 2011, the NRC staff (staff), through newspaper articles, became aware that Energy
4 Northwest is considering the potential use of mixed oxide (MOX) fuel at CGS. MOX fuel is
5 produced by taking nuclear weapons plutonium oxide at about 10–15 percent concentration
6 levels and blending it with uranium oxide to enrichment levels suitable for commercial nuclear
7 reactors.

8 Energy Northwest is interested in advanced fuel technologies, including MOX fuel, said a
9 spokesperson for Energy Northwest. The spokesperson also stated that Energy Northwest has
10 no plans to use MOX fuel without more research and cannot predict the viability of the fuel for
11 use at CGS. Energy Northwest is talking with Pacific Northwest National Laboratory about a
12 study to evaluate the feasibility of using the fuel at CGS (Cary, 2011).

13 At this time, the NRC has not received notification from Energy Northwest on its plans to use
14 MOX fuel in the future. The staff notes that a change in the type of fuel used at CGS will require
15 a thorough evaluation by the NRC on the safety and environmental impacts associated with the
16 new fuel prior to receiving approval for its use.



Figure 2.1-1. Location of CGS, 50-mi (80-km) Region

(Source: EN, 2010)




Figure 2.1-2. Location of CGS, 6-mi (10-km) Region

(Source: EN, 2010)




Figure 2.1-3. CGS, general site layout

(Source: EN, 2010)

1 **2.1.2 Radioactive Waste Management**

2 The radioactive waste systems collect, treat, and dispose of radioactive and potentially
3 radioactive wastes that are byproducts of CGS operations. The byproducts are activation
4 products resulting from the irradiation of reactor water and impurities within the reactor water
5 (principally metallic corrosion products) and fission products resulting from defective fuel
6 cladding or uranium contamination within the reactor coolant system. Operating procedures for
7 the radioactive waste system ensure that radioactive wastes are safely processed and
8 discharged from CGS. The systems are designed and operated to assure that the quantities of
9 radioactive materials released from CGS are as low as is reasonably achievable (ALARA) and
10 within the dose standards set forth in 10 CFR Part 20, "Standards for Protection against
11 Radiation," and Appendix I to 10 CFR Part 50, "Domestic Licensing of Production and Utilization
12 Facilities." The CGS Offsite Dose Calculation Manual (ODCM) contains the methods and
13 parameters used to calculate offsite doses resulting from radioactive effluents. These methods
14 are used to ensure that radioactive material discharged from CGS meets regulatory dose
15 standards.

16 Radioactive wastes resulting from CGS operations are classified as liquid, gaseous, and solid.
17 Radioactive wastes generated by CGS operations are collected and processed to meet
18 applicable regulations. The design and operational objectives of the radioactive waste
19 management systems are to limit the release of radioactive effluents from CGS during normal
20 operation and anticipated operational occurrences (EN, 2010).

21 Reactor fuel that has exhausted a certain percentage of its fissile uranium content is referred to
22 as spent fuel. Spent fuel assemblies are removed from the reactor core and replaced with fresh
23 fuel assemblies during routine refueling outages. Spent nuclear fuel from the reactor is stored
24 onsite in a spent fuel pool and an independent spent fuel storage installation (ISFSI) located
25 about 1,200 feet (ft) northwest of the reactor building. The ISFSI is comprised of dry casks on
26 concrete pads surrounded by a security fence. The ISFSI is licensed in accordance with
27 10 CFR Part 72 (EN, 2010).

28 **2.1.2.1 Radioactive Liquid Waste**

29 The liquid waste management system collects, segregates, stores, and disposes of radioactive
30 liquid waste. The system is designed to reduce radioactive materials in liquid effluents to levels
31 that are ALARA and reduce the volume of waste through recycling. Liquid wastes that
32 accumulate in radwaste tanks or in sumps throughout CGS are transferred to collection tanks in
33 the radwaste building and segregated into three categories: high purity waste, low purity waste,
34 and chemical waste. High purity wastes collect in the waste collector tank and are treated in the
35 equipment drain subsystem. Radioactive material is removed from high purity liquid wastes
36 using filtration and ion exchange. Low purity wastes collect in the floor drain collector tank and
37 are treated in the floor drain subsystem. Similar to high purity wastes, treatment of low purity
38 wastes consists of filtration and ion exchange. The chemical waste subsystem is used to treat
39 liquid chemical wastes that collect in the chemical waste tank. Chemical wastes may be treated
40 using a neutralizing agent, and they are processed by routing to a backwash tank or phase
41 separator and then to the floor drain subsystem for further processing.

42 All liquid radwaste process streams end in either a sample or distillate tank. Liquid wastes are
43 processed on a batch basis so that each treated batch can be sampled. Depending on sample
44 results, the waste is either reprocessed or returned to the condensate storage tanks for reuse in
45 CGS. Excess processed water, within 10 CFR Part 20 release limits and 10 CFR Part 50 dose
46 criteria, is discharged—per the procedures and methods described in the ODCM—to the

1 circulating water system blowdown and into the Columbia River. CGS limits, to the extent
 2 possible, the amount of liquid radioactive wastes discharged to the Columbia River. Although
 3 allowed by U.S. Nuclear Regulatory Commission (NRC) regulation, CGS water management
 4 practices are such that no discharge of liquid radwaste has occurred in over 10 years.
 5 Protection against accidental discharge of liquid radioactive waste is supplied by design
 6 redundancy, detection instrumentation and alarms for abnormal conditions, and procedural
 7 control (EN, 2010b).

8 **2.1.2.2 Radioactive Gaseous Waste**

9 Gaseous waste management systems process and control the release of gaseous radioactive
 10 effluents to the atmosphere. Offgases from the main condenser are the major source of
 11 gaseous radioactive waste. Other radioactive gas sources collected by the system include
 12 leakage from steam piping and equipment in the reactor building, turbine generator building,
 13 and radwaste building.

14 Before release into the environment through the reactor building elevated release duct,
 15 treatment of the gases includes the following:

- 16 • volume reduction through a catalytic recombiner to recombine hydrogen and oxygen
- 17 • water vapor removal through a condenser
- 18 • decay of short-lived radioisotopes through a holdup line
- 19 • high efficiency particulate air (HEPA) filtration
- 20 • adsorption of isotopes on activated charcoal beds
- 21 • further HEPA filtration

22 CGS discharges gaseous waste in accordance with the procedures and methods described in
 23 the ODCM so that exposure to persons offsite are ALARA and do not exceed limits specified in
 24 10 CFR Part 20 and Appendix I to 10 CFR Part 50 (EN, 2010).

25 **2.1.2.3 Radioactive Solid Waste**

26 The solid waste management system collects, processes, and packages solid radioactive
 27 wastes for storage and offsite shipment and burial. The system is located in the radwaste
 28 building. The system is designed to process waste while maintaining occupational exposure
 29 ALARA. To ensure compliance with applicable regulations in 10 CFR Parts 20, 61, and 71,
 30 characterization, classification, processing, waste storage, handling and transportation of solid
 31 wastes are controlled by the process control program.

32 CGS uses a portable dewatering and drying system to remove freestanding liquids from wet
 33 solid wastes (e.g., filter residue, concentrated wastes, and spent resins). Dry solid wastes (e.g.,
 34 rags, paper, and air filters) are also processed in the radwaste building. Dry solid wastes are
 35 segregated and monitored to reduce volumes where practicable and may be compressed and
 36 packaged into steel containers. Non-compressible solid wastes are packaged in container vans
 37 or other containers suitable for shipment. Mixed (radioactive and hazardous) wastes generated
 38 at CGS are shipped to permitted offsite facilities.

39 Periodic cleaning of the cooling tower basins and the standby service water ponds results in
 40 sediment that contains low levels of radioactivity. The sediment is disposed of onsite in a
 41 dedicated area south of the cooling towers. The State of Washington Energy Facility Site
 42 Evaluation Council allows the onsite disposal of the contaminated sediment as long as the
 43 material meets specific concentration limits and monitoring requirements.

1 Solid radioactive wastes are packaged and shipped from CGS in containers that meet the
2 requirements established by the U.S. Department of Transportation and by the NRC.
3 Radioactive waste is transported to a commercial low-level radioactive waste disposal facility
4 located near the center of the Hanford Site, approximately 12 mi west-northwest of CGS. Low
5 activity waste may also be transported from CGS to a vendor for volume reduction before
6 disposal (EN, 2010).

7 **2.1.3 Nonradiological Waste Management**

8 CGS generates nonradioactive wastes as part of routine plant maintenance, cleaning activities,
9 and plant operations. The Resource Conservation and Recovery Act (RCRA) governs the
10 disposal of solid and hazardous waste. RCRA waste regulations are contained in
11 40 CFR Parts 239–299. In addition, 40 CFR Parts 239–259 contain regulations for solid
12 (nonhazardous) waste, and 40 CFR Parts 260–279 contain regulations for hazardous waste.
13 RCRA Subtitle C establishes a system for controlling hazardous waste from “cradle to grave,”
14 and RCRA Subtitle D encourages States to develop comprehensive plans to manage
15 nonhazardous solid waste and mandates minimum technological standards for municipal solid
16 waste landfills. Washington State RCRA regulations are administered by the Washington State
17 Department of Ecology (WDOE) and address the identification, generation, minimization,
18 transportation, and final treatment, storage, or disposal of hazardous and nonhazardous waste.

19 **2.1.3.1 Nonradioactive Waste Streams**

20 CGS generates solid waste, defined by RCRA, as part of routine plant maintenance, cleaning
21 activities, and plant operations. Washington is a part of Environmental Protection Agency (EPA)
22 Region 10 and its solid waste program. In 1986, the EPA authorized WDOE to administer
23 portions of the RCRA program in the State of Washington that are incorporated in
24 Chapter 173-303 (Dangerous Waste Regulations) of the Washington Administrative Code
25 (WAC).

26 The EPA classifies certain nonradioactive wastes as hazardous based on characteristics
27 including ignitability, corrosivity, reactivity, or toxicity (hazardous wastes are listed in
28 40 CFR Part 261). State-level regulators may add wastes to the EPA’s list of hazardous
29 wastes. RCRA supplies standards for the treatment, storage, and disposal of hazardous waste
30 for hazardous waste generators (regulations are available in 40 CFR Part 262).

31 The EPA recognizes the following main types of the hazardous waste generators
32 (40 CFR 260.10) based on the quantity of the hazardous waste produced:

- 33 • large quantity generators that generate 2,200 pounds (lb) (1,000 kilograms (kg)) per
34 month or more of hazardous waste, more than 2.2 lb (1 kg) per month of acutely
35 hazardous waste, or more than 220 lb (100 kg) per month of acute spill residue or soil
- 36 • small quantity generators that generate more than 220 lb (100 kg) but less than 2,200 lb
37 (1,000 kg) of hazardous waste per month
- 38 • conditionally exempt small quantity generators that generate 220 lb (100 kg) or less per
39 month of hazardous waste, 2.2 lb (1 kg) or less per month of acutely hazardous waste,
40 or less than 220 lb (100 kg) per month of acute spill residue or soil

41 The State of Washington has incorporated the EPA’s regulations regarding hazardous wastes
42 and recognizes CGS as a large quantity generator of hazardous wastes under WAC Chapter
43 173-303-070. CGS hazardous wastes include spent and expired chemicals, laboratory

1 chemical wastes, and occasional project-specific wastes. CGS produced 9,614 lb (4,361 kg)
 2 waste in 2005; 2,598 lb (1,178 kg) in 2006; 6,797 lb (3,083 kg) in 2007; 23,946 lb (10,862 kg) in
 3 2008; and 12,638 lb (5,733 kg) in 2009 (Gambhir, 2010b).

4 The EPA classifies several hazardous wastes as universal wastes; these include batteries,
 5 pesticides, mercury-containing items, and fluorescent lamps. WDOE has incorporated the
 6 EPA's regulations (40 CFR Part 273) regarding universal wastes in WAC Chapter 173-303-573.
 7 WDOE defines mercury-containing equipment, used batteries, and lamps (e.g., fluorescent,
 8 mercury vapor, metal halide, high-pressure sodium, and neon) as universal waste; these items
 9 make up the majority of the hazardous wastes produced by the CGS and are disposed of or
 10 recycled in accordance with WDOE regulations.

11 Conditions and limitations for wastewater discharge by the CGS are specified in National
 12 Pollutant Discharge Elimination System (NPDES) Permit No. WA-002515-1 (EN, 2010b).
 13 Radioactive liquid waste is addressed in Section 2.1.2 of this SEIS. Section 2.1.7.3 gives more
 14 information about the CGS NPDES permit and permitted discharges.

15 The Emergency Planning and Community Right-to-Know Act (EPCRA) requires applicable
 16 facilities to supply information about hazardous and toxic chemicals to local emergency planning
 17 authorities and the EPA (42 USC 11001). On October 17, 2008, the EPA finalized several
 18 changes to the Emergency Planning (Section 302), Emergency Release Notification
 19 (Section 304), and Hazardous Chemical Reporting (Sections 311 and 312) regulations that were
 20 proposed on June 8, 1998 (63 FR 31268). The CGS is subject to Federal EPCRA reporting
 21 requirements; thus, CGS submits an annual Section 312 (Tier II) report on hazardous
 22 substances to local emergency agencies.

23 Low-level mixed wastes (LLMW) are wastes that contain both low-level waste and RCRA
 24 hazardous waste (40 CFR 266.210). The State of Washington regulates the hazardous
 25 component of the mixed waste through RCRA, and the NRC regulates radioactive waste subject
 26 to the Atomic Energy Act (AEA). CGS periodically produces small amounts of LLMW, mainly
 27 from the use of wiping cloths and liquid cleaners, and sends it offsite for disposal in an approved
 28 disposal facility.

29 **2.1.3.2 Pollution Prevention and Waste Minimization**

30 Pollution-prevention and waste-minimization opportunities carried out by CGS are summarized
 31 in annual reports submitted to WDOE. CGS performs pollution prevention assessments, which
 32 are used to identify and carry out programs that reduce waste. These assessments have
 33 resulted in a several waste-minimization programs, including a comprehensive recycling
 34 program and a program that replaces the use of hazardous materials with non-hazardous
 35 substitutes.

36 In support of nonradiological waste-minimization efforts, the EPA's Office of Prevention and
 37 Toxics has established a clearinghouse that supplies information about waste management and
 38 technical and operational approaches to pollution prevention (EPA, 2010b). The EPA
 39 clearinghouse can be used as a source for additional opportunities for waste minimization and
 40 pollution prevention at CGS, as appropriate.

41 The EPA also encourages the use of environmental management systems (EMSs) for
 42 organizations to assess and manage the environmental impacts associated with their activities,
 43 products, and services in an efficient and cost-effective manner. The EPA defines an EMS as
 44 "a set of processes and practices that enable an organization to reduce its environmental

1 impacts and increase its operating efficiency.” EMSs help organizations fully integrate a wide
2 range of environmental initiatives, establish environmental goals, and create a continuous
3 monitoring process to help meet those goals. The EPA Office of Solid Waste especially
4 advocates the use of EMSs at RCRA-regulated facilities to improve environmental performance,
5 compliance, and pollution prevention (EPA, 2010d).

6 **2.1.4 Plant Operation and Maintenance**

7 Maintenance activities carried out at CGS include inspection, testing, and surveillance to
8 maintain the current licensing basis of the facility and to ensure compliance with environmental
9 and safety requirements. Various programs and activities currently exist at CGS to maintain,
10 inspect, test, and monitor the performance of facility equipment. These maintenance activities
11 include inspection requirements for reactor vessel materials, boiler and pressure vessel
12 inservice inspection and testing, maintenance structures monitoring program, and maintenance
13 of water chemistry.

14 Additional programs include those carried out to meet technical specification surveillance
15 requirements; those carried out in response to the NRC generic communications; and various
16 periodic maintenance, testing, and inspection procedures (EN, 2010). Certain program
17 activities are carried out during the operation of the unit, while others are carried out during
18 scheduled refueling outages. Nuclear power plants must periodically discontinue the production
19 of electricity for refueling, periodic inservice inspection, and scheduled maintenance. CGS
20 refuels on a 24-month interval (EN, 2010).

21 **2.1.5 Power Transmission System**

22 CGS is connected to the BPA transmission grid via the H.J. Ashe Substation, which is located
23 0.5 mi (0.8 km) north of CGS. Electricity output is transmitted from the plant to the Ashe
24 Substation via a 500-kilovolt (kV) transmission line, which extends 2,900 ft (884 meters (m))
25 from CGS. CGS has four main power transformers, with one as a backup, which increase the
26 generator output from 25 kV to 500 kV. An additional 230-kV line connects the plant start-up
27 transformer to the Ashe Substation. This transformer is able to supply power for plant start-up,
28 normal operating auxiliary loads, and engineered safety feature shutdown loads. The 230-kV
29 transmission line and the 500-kV transmission line run parallel in a 280-ft wide (85 m)
30 transmission corridor (Figure 2.1-3) (EN, 2010).

31 Originally, CGS was intended to connect to the BPA transmission grid via an 18-mi (29 km) long
32 500-kV transmission line running from CGS to the existing Hanford Substation (AEC, 1972).
33 Instead, BPA constructed the nearby Ashe Substation, which then tied into the transmission
34 network via four 500-kV lines to the Hanford (18 mi (29 km)), Lower Monumental (41 mi
35 (66 km)), Slatt (72 mi (116 km)), and Marion (224 mi (360 km)) Substations. These
36 transmission lines are operated and maintained by BPA and will remain in service past CGS
37 decommissioning (EN, 2010). These lines connecting the Ashe Substation to the four
38 previously discussed substations are not considered in-scope for this review.

39 A third transmission line supported CGS operations as a power source during construction and
40 is now used as back-up power for safe shutdown under accident conditions. This 115-kV line
41 has a right-of-way (ROW)-width of about 90 ft (27 m), and it connects the CGS switchyard to the
42 115-kV line at the Benton switchyard, about 1.8 mi (2.9 km) southeast of CGS.

43 The transmission lines considered in-scope for license renewal are those that connect the
44 facility to the transmission system; therefore, the 500-kV and 230-kV lines connecting CGS to

1 the Ashe Substation, and the 115-kV back-up power line, are the only transmission lines
2 considered in-scope for this review. All ROW maintenance of the in-scope transmission lines is
3 performed by BPA; however, because the vegetation underneath the overhead lines are mainly
4 low-lying plants and shrubs, very little maintenance is necessary (EN, 2010).

5 **2.1.6 Cooling and Auxiliary Water Systems**

6 The circulating-water system supplies cooling water for the condenser at CGS. The plant
7 service-water system removes the rejected heat from the auxiliary equipment during normal
8 operation. The standby service-water system is a separate cooling water system that removes
9 heat during a loss-of-coolant accident and removes residual reactor heat during a normal
10 shutdown. Unless otherwise cited, the staff drew information about CGS's cooling and auxiliary
11 water systems from Energy Northwest's ER (EN, 2010).

12 Circulating-Water System. The CGS circulating-water system is a single-cycle,
13 forced-circulation cooling water system (EN, 2010). This closed-cycle cooling system removes
14 heat from the condenser and transfers it to the atmosphere through evaporation using six
15 mechanical draft cooling towers (EN, 2010). The circulating-water pumphouse circulates the
16 water from the condenser through the cooling towers and back again at a rate of about
17 550,000 gallons per minute (gpm) (35 cubic meters (m³ per second (sec))). The temperature of
18 the cooling water in the circulating-water system increases about 30 degrees Fahrenheit (F)
19 (17 degrees Celsius (C)) as the water flows through the condenser. The cooling towers rise
20 60 ft (18 m) above the basin and are approximately 200 ft (61 m) in diameter at the base of the
21 towers.

22 The circulating-water system uses water from the Columbia River to replenish the water lost
23 from evaporation, drift, and blowdown. The makeup water pumphouse is located 3 mi (5 km)
24 east of the plant and houses three 800-horsepower makeup water pumps (Figure 2.1-3). The
25 pumps are designed to each supply 12,500 gpm (0.79 m³/sec), or half the system capacity, at
26 the design head. Two pumps normally supply makeup water to the plant with a withdrawal
27 capacity of 25,000 gpm (1.58 m³/sec).

28 The intake system for the makeup water pumps consists of two 36-inch (in.) (91-centimeter
29 (cm)) diameter buried pipes that extend 900 ft (274 m) from the pumphouse into the river, about
30 300 ft (91 m) from the shoreline at Columbia River Mile (RM) 352 (Figure 2.1-4 and Figure
31 2.1-5) (WPPSS, 1980). An intake structure is located at the end of each of the pipes. The
32 pipes make a 90-degree bend and extend slightly above the surface of the riverbed. Each of
33 the pipes ends with an intake structure (20 ft (6 m) in length) mounted above the riverbed and
34 approximately parallel to the river flow, as shown in Figure 2.1-6. Each intake structure is
35 composed of two intake screens that are each 6.5 ft (2 m) in length (Figure 2.1-7) and mounted
36 end to end. The remaining length of the intake structure consists of two solid cones at either
37 end of the structure. The intake screens consist of an outer and inner perforated pipe sleeve
38 (WPPSS, 1986). The outer sleeve has a 42-in. (107-cm) diameter sleeve with 3/8-in.
39 (9.5 millimeter (mm)) diameter holes (composing 40 percent of the surface area). The inner
40 sleeve has a 36-in. (91-cm) diameter sleeve with 3/4-in. (19-mm) diameter holes (composing
41 7 percent of the surface area). The intake screens are designed to distribute the water flow
42 evenly along its surface. During normal operating periods, the average makeup water
43 withdrawal is about 17,000 gpm (1.1 m³/sec).

44




Figure 2.1-4. Intake system plan and profile

(WPPSS, 1980)




Figure 2.1-5. Location of pumphouse, pipelines, intakes, and outfalls

(Gambhir, 2010a), (Poston, et al., 2008)




Figure 2.1-6. Perforated intake plan and section

(WPPSS, 1980)




Figure 2.1-7. Spare perforated pipe for the intake screen at CGS.

“A” side view; “B” close up of outer sleeve; and “C” end view showing inner sleeve of perforated pipe

- 2 The water in the circulating-water system is supplemented with a biocide (e.g., chlorine) to
- 3 retard biological growth and other chemical additives to control corrosion and scale (e.g.,
- 4 sulfuric acid) and fouling on the heat-transfer surfaces (NRC, 1981). The circulating-water
- 5 system discharges a portion of the cooled water back into the river as blowdown. On an annual
- 6 basis, blowdown into the river averages about 2,000 gpm (0.1 m³/sec).

- 7 Blowdown water returns to the river from the cooling towers through a line that extends out
- 8 the river next to the makeup water pumphouse. The 18-in. (46-cm) diameter, buried blowdown
- 9 pipe extends about 175 ft (53 m) from the shoreline at low river stage. The pipe ends above the

Affected Environment

- 1 riverbed at a 15-degree angle in a rectangular slot outfall port that measures 8-in. by 32-in.
- 2 (20-cm by 81-cm) and is perpendicular to the river flow (Figure 2.1-8).




Figure 2.1-8. Rectangular slot discharge

(WPPSS, 1980)

1 The flow of the Columbia River below Priest Rapids Dam for water years 1960–2009 has an
2 average mean annual discharge of 117,823 cubic feet per second (cfs) (3,336 m³/sec) and a
3 minimum mean annual discharge of 80,650 cfs (2,283 m³/sec) (USGS, 2010). Thus, the
4 makeup water withdrawal of 17,000 gpm (1.1 m³/sec) is about 0.03 percent of the average
5 mean annual discharge and 0.05 percent of the minimum mean annual discharge of the river.
6 The annual average blowdown of 2,000 gpm (0.1 m³/sec) is about 0.004 percent of the
7 averaged mean annual discharge and 0.006 percent of the minimum mean annual discharge of
8 the river.

9 Plant Service-Water System. The plant service-water system functions continuously to supply
10 cooling water for removal of heat rejected from auxiliary (nonessential) equipment, including the
11 turbine generator (EN, 2003a). Two 100-percent capacity pumps draw water from the
12 circulating-water system to supply cooling water to equipment located throughout the plant. The
13 circulating water in the system mechanical draft cooling towers also cools the service-water
14 return. In addition to the biocide-treated circulating-water supply used by the plant
15 service-water system, the plant service-water system is equipped with systems to add biocides
16 and other chemicals. The biocide retards biological growth, and the chemicals are added to
17 minimize silt deposition, scale formation, corrosion, and consequent fouling of heat-transfer
18 surfaces (EN, 2003a).

19 Standby Service-Water System. In the event of a loss-of-coolant accident, the standby
20 service-water system supplies emergency cooling water. The standby service-water system
21 functions as the ultimate heat sink. The system has two concrete spray ponds. Each spray
22 pond measures 250 ft (76 m) by 250 ft (76 m) and 15 ft (4.6 m) deep, consisting of 14 ft (4.2 m)
23 of water and 1 ft (0.3 m) of free board (WPPSS, 1980). The combined water inventory of the
24 ponds can supply cooling water for 30 days without makeup. The circulating-water system or
25 the potable water system can supply water to the standby service-water system lost through
26 evaporation, drift, and occasional blowdown (needed to maintain the water chemistry of the
27 system). The spray ponds supply suction and discharge points for the redundant pumping and
28 spray facilities of the service-water system. Two independent, 100-percent capacity
29 service-water pumps supply water to the emergency core cooling system, essential plant
30 equipment, and reactor shutdown cooling equipment. Separate pumphouses accommodate
31 each pump. In one of the pumphouses, a third pump provides supply water to high-pressure
32 core spray system cooling equipment. Chemicals are added to the water in the standby
33 service-water system to control biological growth (e.g., sulfuric acid) and to minimize corrosion
34 (e.g., chlorine).

35 **2.1.7 Facility Water Use and Quality**

36 A portion of the cooling water is lost through evaporation and drift. The evaporative losses lead
37 to concentration of dissolved solids in the cooling water. Thus, a portion of the cooling water,
38 so-called blowdown water, is routinely discharged back to the Columbia River and replenished
39 with freshwater, thus controlling the buildup of dissolved solids.

40 In addition to the normal water supply from the Columbia River, CGS maintains one
41 groundwater-supply well (Well 699-13-1C) as a backup source of water for plant operations.
42 Two other water-supply wells are maintained to support ongoing activities on the Industrial
43 Development Complex (IDC) site. The IDC water system is cross-tied to the CGS site potable
44 water system and can be used to supply water to the CGS site during infrequent maintenance
45 and repair activities that make the CGS river water supply unavailable (EN, 2010).

1 **2.1.7.1 Groundwater Use and Quality**

2 Where undisturbed, the CGS site is underlain by a thin (less than 15 ft thick) sequence of
 3 Holocene-age eolian sand and loess (EN, 2005), (HGI, 2008) overlying an approximate 45–
 4 50-ft-thick sequence of Pleistocene-age glaciofluvial sands and gravels (EN, 2005). These
 5 glaciofluvial sediments, informally referred to as the Hanford formation, were deposited by
 6 numerous cycles of cataclysmic Ice Age flooding (DOE, 2002a). Sediments of the Cold Creek
 7 Unit (DOE, 2002a) are not believed to be present beneath the CGS site (Thorne, 2007).
 8 However, the Cold Creek gravels are often difficult to differentiate from Hanford formation
 9 gravels and the underlying Ringold Formation. They have been noted approximately 1 mi (1.6
 10 km) northwest of the site and may exist in the area immediately north of the site (Vermeul, et
 11 al., 2005).

12 Beneath the Hanford formation lies a thick (approximately 480 ft thick) sequence of dense silt,
 13 sand, and gravel conglomerates of the Ringold Formation—member of Wooded Island
 14 (EN, 2005), (EN, 2010), (Lindsey, 1996). The upper 200 ft of the Ringold Formation, beneath
 15 the CGS site, consists of very dense sandy gravel (EN, 2005) equivalent to Units E and C
 16 (HGI, 2008), (Lindsey, 1996). The lower portion of the Ringold Formation consists of very
 17 compact, interbedded gravel, sand, silt, and clay extending to a depth of about 500–525 ft
 18 (EN, 2005). Finer-grained overbank deposits separate gravel and sand dominated sediments of
 19 the combine Units B/D from the overlying Units E/C, while the lower mud unit separates Units
 20 B/D from unit A, directly overlying the basalt bedrock (HGI, 2008). Bedrock beneath the site
 21 consists of Miocene age tholeiitic basalt of the Columbia River Basalt Group, at a depth of
 22 approximately 550 ft (EN, 2005).

23 The uppermost aquifer is located within the Ringold Formation, at a depth of about 60 ft beneath
 24 the ground surface (EN, 2005), (EN, 2010). The upper portion of this aquifer is unconfined,
 25 while deeper portions of the Ringold Formation may be locally confined (semi-confined) by
 26 lower permeability silts and clays. The effective bottom of the unconfined aquifer is assumed to
 27 be at about 220–260 ft above mean sea level (MSL) at the top of the finer-grain overbank
 28 deposits separating Units E/C from Units B/D. Groundwater potentials from the lower portion of
 29 the Ringold Formation (Units B/D and A) and from the basalt aquifers are about 25 ft higher
 30 than those of the unconfined aquifer (EN, 2005).

31 The groundwater in the unconfined aquifer generally moves in an easterly direction towards its
 32 primary points of discharge to the Columbia River approximately 3 mi away. This aquifer is in
 33 direct hydraulic communication with the Columbia River. However, because of the distance
 34 from the river, and the permeability characteristics and enormous volume of the Ringold
 35 Formation, the water table beneath the site fluctuates very little (EN, 2005), (EN, 2010).

36 Three water-supply wells were installed during construction of the CGS plant to supply
 37 construction support (EN, 2010) (Figure 2.1-9). Two of the wells, 699-13-1A and 699-13-1B,
 38 were constructed in the unconfined aquifer to depths of about 244 and 234 ft, respectively
 39 (EN, 2005), but they were removed from service in 1979 when the pumps were removed
 40 (EN, 2010). The third well, Well 699-13-1C, was completed at a depth of approximately 695 ft
 41 (EN, 2005) in a confined aquifer within the basalt bedrock. This well has a pumping capacity of
 42 about 250 gpm and is maintained in the standby mode to supply supplemental makeup water
 43 for the potable and demineralized water system as needed (EN, 2005). It is typically only
 44 pumped to support quarterly sample collections, with an estimated run time per year of 2 hours
 45 or less at an approximate rate of 200 gpm (EN, 2010).




Figure 2.1-9. Well location map

(After ER Figure 2.3-1 (EN, 2010))

Affected Environment

1 Two other water-supply wells were constructed in 1975 to support construction of Nuclear
2 Projects Nos. 1 and 4 (WNP-1/4), about 1 mi east of the CGS site. These wells, ENW-31
3 (C3080) and ENW-32 (C3081), are screened from 247–341.5 ft and 244.25–366 ft, respectively
4 (Dresel, et al., 2000). These wells are used to fill a water-storage tank to supply water for
5 ongoing activities on the IDC site. The IDC water supply system is cross-tied to the CGS site
6 potable water system to supply the CGS site during infrequent maintenance and repair activities
7 that make the CGS river water supply unavailable. The estimated pumping capacity of each of
8 these wells is estimated at 250–270 gpm (Gambhir, 2010b). Typically, the crosstie is open less
9 than 50 hours per year, although in 2008 it was used for 1,655 hours to supply water to portions
10 of the CGS site (EN, 2010). The water is not metered, but the average annual usage rate for
11 2005–2008 was estimated at about 1 gpm (EN, 2010). From October 2009–April 2010, these
12 water-supply wells each operated for an estimated 120 hours, at pumping rates of
13 approximately 270 gpm, for a total average pumping rate estimated at about 30 gpm, or 15 gpm
14 per well (Gambhir, 2010b).

15 Recharge to the unconfined aquifer is primarily from precipitation and runoff in elevated areas
16 along the western margin of the Pasco Basin (i.e., Rattlesnake Hills, Yakima Ridge, and
17 Umtanum Ridge), leakage from the underlying basalt-confined aquifers, influx from the Yakima
18 River, and recharge from precipitation across the Hanford Site (EN, 2005), (HGI, 2008).
19 Artificial recharge from large wastewater discharges during Hanford Site operations created
20 groundwater mounds that affected groundwater characteristics across the Hanford Site.
21 Significant reduction in wastewater discharges in the 1990s has allowed these groundwater
22 mounds to dissipate over most of the Hanford Site (Duncan, et al., 2007), (DOE, 2008).

23 Some artificial recharge from wastewater and stormwater discharges also occurs locally on the
24 CGS site. One of these recharge sources is an unlined pond located 1,500 ft northeast of the
25 CGS reactor building. This pond receives stormwater from plant roofs, backwashes of the
26 potable water-treatment filter, and a reject stream from a process water reverse osmosis unit. It
27 also receives infrequent batch-type discharges from flushes of emergency diesel engine cooling
28 water and flushes of the fire-protection system. The outfall to this pond is designated as Outfall
29 002 in the CGS NPDES permit. Annual discharges are estimated at about 15 million gallons
30 (gal.) (EN, 2010).

31 The percolation beds at the site sanitary waste-treatment facility supply another point of artificial
32 recharge. This site is located 2,500 ft southeast of the reactor building where, once or twice per
33 year, 1–2 million gal. of treated effluent are released to the soil over a 3–5 day period
34 (EN, 2010).

35 A third point of artificial recharge is an old soil borrow pit, or swale, located about 1,500 ft
36 south-southeast of the reactor building. This pit is designated as Outfall 003 in the NPDES
37 permit (EN, 2010). This site was used for the disposal of about 500,000 gal. per year of
38 backwash water from a sidestream sand filter on the standby service-water system from 1997–
39 2003. Regular discharges to this site ceased in October 2003 when the filter was removed from
40 service. However, the outfall is still available for discharge of water if the spray ponds need to
41 be drawn down for cleaning or maintenance.

42 The CGS site also has numerous drywells for the collection of stormwater. These wells also
43 supply a groundwater recharge pathway (EN, 2010). Drywells around the cooling towers also
44 catch the drift and spray of condenser cooling water from the towers during windy conditions.

45 Groundwater monitoring on the CGS site is done by sampling 14 monitoring wells (MWs). Five
46 of these MWs (MW-1–MW-5, Figure 2.1-9) were installed in 1995 as part of an investigation of a

1 construction debris landfill in use from 1976–1993, located just southwest of the cooling towers.
2 Sampling showed low-level concentrations of contaminants in the groundwater (EN, 2010),
3 (Golder, 1995) and, subsequently, led to capping of the landfill with a synthetic membrane and
4 soil cover in 1999. Groundwater sampling specific to the landfill continued until April 2002,
5 when the data showed that the landfill contaminants were not causing degradation of the
6 groundwater (EN, 2010). Instead, the elevated conductivity and concentrations of chloride and
7 sulfate were attributed to the infiltration of circulating cooling water that entered the soil through
8 drywells (EN, 2002), (EN, 2010).

9 Four more wells (MW-6–MW-9, Figure 2.1-9) were installed in 1997 to support groundwater
10 monitoring of Outfalls 002 and 003 (EN, 2010). MW-6 was installed downgradient of the borrow
11 pit receiving backwash from the service-water filter (Outfall 003), with well MW-3 serving as the
12 upgradient and background well for this site. Wells MW-7, MW-8, and MW-9 were installed at
13 the unlined stormwater pond (Outfall 002). One year (four quarters) of monitoring data showed
14 no adverse effect on groundwater quality at the two points of discharge (WPPSS, 1999).
15 Groundwater monitoring is being carried out under the terms of the current NPDES permit
16 (EN, 2010).

17 In response to the Nuclear Energy Institute Groundwater Protection Initiative (NEI, 2007), the
18 CGS carried out a groundwater monitoring program to routinely sample the unconfined aquifer.
19 As part of this program, five additional MWs (MW-10–MW-14) were installed in late 2008
20 (EN, 2009). Wells MW-10, MW-11, and MW-12 were installed close to the CGS turbine building
21 to help detect potential leakage from the condensate storage tanks and underground piping.
22 Wells MW-13 and MW-14 were installed at the onsite Sanitary Waste Treatment Facility
23 (SWTF) to help assess the effect of discharges to the facility.

24 Groundwater monitoring in 2008 failed to note any gamma-emitting radionuclides of interest
25 (EN, 2009). Tritium concentrations ranged from less than detectable limits to 17,400 picocuries
26 (pCi) per liter (L). However, the highest concentrations were from an upgradient well, MW-5,
27 and have been attributed to DOE Hanford Site operations (EN, 2009), (EN, 2010).

28 **2.1.7.2 Surface-Water Use and Quality**

29 The primary water supply for the CGS is the Columbia River. Water-quality parameters
30 measured by the U.S. Geological Survey (USGS) from 1996–2003 at Vernita Bridge (USGS
31 Station No. 12472900 at RM 388), 35 mi upstream of the CGS site, showed that water
32 temperature ranged between 3–20.5 degrees C with a median of 12 degrees C (EN, 2010),
33 (USGS, 2006). Dissolved oxygen ranged between 9.2–14.0 milligrams (mg) per L with a
34 median of 12.4 mg/L. The pH fluctuated between 7.4–8.2 standard units (EN, 2010),
35 (USGS, 2006).

36 As part of its operational monitoring programs, Energy Northwest collected river water samples
37 at four or more stations near the plant discharge at RM 352. This water-quality component of
38 the environmental monitoring program was discontinued after 1995, when years of data showed
39 no discernable changes in river water quality at monitoring locations 150–1,900 ft downstream
40 of the outfall (EN, 2010).

41 Comparison of water-quality parameters measured 36 mi upstream of CGS, near Vernita
42 Bridge, and 12 mi downstream of CGS, near Richland (USGS Station No. 12473520 at RM
43 340), found no indication of any deterioration of Columbia River water quality along the Hanford
44 Reach (Poston, et al., 2009). Poston, et al., did report that small amounts of radioactive
45 materials were detected downriver from the Hanford Site. However, the amounts were far

Affected Environment

1 below Federal and State limits. Further, there was no indication of any deterioration of
2 Columbia River water or sediment quality resulting from operations at the Hanford Site (Poston,
3 et al., 2009).

4 The 2008 assessment of water quality by the State of Washington found no quality impairments
5 based on water samples in the river reach below Vernita Bridge. However, it did find organic
6 elements in fish tissue and pH and temperature in irrigation return flows as an indicator of
7 water-quality impairment at upstream locations (EN, 2010), (WDOE, 2008).

8 **2.1.7.3 National Pollutant Discharge Elimination System**

9 The State of Washington authorizes discharge of treated wastewater via three outfalls at the
10 CGS, in accordance with the special and general conditions of NPDES Permit
11 No. WA-002515-1 under authority delegated by EPA.

12 Outfall 001—the main discharge outfall for condenser cleaning effluent, radioactive
13 waste-treatment system effluent, cooling water blowdown from the circulating water system, and
14 discharge from the standby service-water system—is located in the Columbia River
15 (RM 351.75). The discharge pipe is buried in the riverbed and ends in an outfall port, about
16 175 ft from the shoreline at low river flow (EN, 2010). This outfall consists of an 8-in. by 32-in.
17 rectangular orifice oriented at a 15-degree angle to the riverbed and perpendicular to the river
18 flow (EN, 2010).

19 Outfall 002 discharges stormwater from plant roofs, backwashes of the potable water-treatment
20 filter, and a reject stream from a process water reverse osmosis unit to an unlined pond located
21 1,500 ft northeast of the CGS reactor building. In addition, infrequent batch-type discharges
22 include flushes of emergency diesel engine cooling water and flushes of the fire-protection
23 system.

24 Outfall 003 is available for water discharges from the spray ponds if they need to be drawn
25 down for cleaning or maintenance. This outfall discharges to an old soil borrow pit or swale
26 located about 1,500 ft south-southeast of the reactor building (EN, 2010). The location was
27 used for the disposal of about 500,000 gal. per year of backwash water from a sidestream sand
28 filter on the standby service-water system from 1997–2003. Regular discharges at this location
29 ended in October 2003 when the filter was removed from service (EN, 2010).

30 **2.2 Surrounding Environment**

31 CGS is in south-central Washington State along the Columbia River on the Hanford Site on land
32 leased from DOE. The nearest population center is the Tri-Cities of Richland, Kennewick, and
33 Pasco, approximately 15 mi southeast of the site. The estimated population within 20 mi
34 (32 km) of CGS in 2000 was 171,371.

35 The topography around CGS is generally flat with gentle hills and an elevation ranging from
36 about 350 ft above MSL near the river to about 460 ft MSL on the hills.

37 There is one Native American reservation within a 50-mi (80-km) radius of CGS—the Yakama
38 Reservation, located approximately 45 mi (72 km) to the west.

1 **2.2.1 Land Use**

2 CGS is located 3 mi (4.8 km) west of the Columbia River in Benton County, WA. The site is
3 comprised of 1,089 ac (441 ha) leased to Energy Northwest by DOE. The leased land is in two
4 parcels—a nearly square section containing the power block and associated structures and an
5 elongated area running east from the station to the river. In addition, the lease from DOE grants
6 Energy Northwest authority to control activities within a 1.2 mi (1.9 km) exclusion area (per
7 10 CFR 100.3) including land outside of the lease boundary (see Figure 2.1-3).

8 The immediate area surrounding CGS is enclosed by a security barrier shown in Figure 2.1-3.
9 Access to CGS is through a security gate via a three lane road off DOE-owned Route 4S, west
10 of the plant. A DOE-owned railroad track runs through the CGS site and passes within about
11 500 ft (152 m) east of the plant. The track is used infrequently by DOE, and it is blocked by
12 security barriers located north and south of the plant.

13 Notable manmade features within a 6-mi (10-km) radius of CGS (see Figure 2.1-2) include two
14 abandoned power plant constructions project (WNP-1 and WNP-4), located about 1 mi (1.6 km)
15 east-southeast and east-northeast of the plant. BPA's H.J. Ashe Substation is 0.5 mi (0.8 km)
16 north of the plant, while the Laser Interferometer Gravitational-Wave Observatory is 3.5 mi (5.6
17 km) from the plant. The following DOE facilities are also within a 3.5 mi (5.6 km) radius of CGS:

- 18 • Fast Flux Test Facility (FFTF), located 2.75 mi (4.4 km) south-southwest in the Hanford
19 400 Area
- 20 • two radioactive waste burial grounds—618-10 located 3.5 mi (5.6 km) south and 618-11
21 immediately west of CGS

22 Nearby communities include Richland, approximately 10 mi (17 km) south; Pasco, 18 mi (29
23 km) southeast; and Kennewick, 21 mi (34 km) southeast. The nearest residence is 4.25 mi (6.8
24 km) from CGS in an east-southeasterly direction across the Columbia River. Prominent
25 features of the surrounding area, out to 50 mi (80 km), are shown in Figure 2.1-1.

26 **2.2.2 Air Quality and Meteorology**

27 The CGS site is located within the Pasco Basin of the Columbia Plateau in southeastern
28 Washington State. The climate for this region is classified as semi-arid shrub-steppe, which is
29 characteristic of areas that receive little—but consistent—annual precipitation to support
30 perennial grass and shrub vegetation (Hoitink, et al., 2005). The region's temperature and
31 precipitation are greatly influenced by the presence of large mountain barriers. The Cascade
32 Mountains to the west form a barrier to the easterly movement of moist air from the Pacific,
33 resulting in a sharp west-to-east gradient in precipitation. The Rocky Mountains in southern
34 British Columbia generally block polar air masses moving south during the winter months.

35 Regionally, the prevailing wind direction is from the southwest or west during most of the year
36 (WRCC, 2010). However, the predominate wind direction near the CGS site is modified by
37 nearby terrain features, such as Rattlesnake Mountain to the southwest and Saddle Mountains
38 to the north, as well as cold-air drainage flows forming along the Columbia River, which is just
39 east of the site. Historical wind observations for a 60-year period (1945–2004), from the primary
40 meteorological tower at the DOE's Hanford Site, show that the prevailing wind direction is
41 generally from the west-northwest or northwest for every month of the year, with an annual
42 average windspeed of 7.6 miles per hour (mph) (Hoitink, et al., 2005). Peak wind gusts,

Affected Environment

1 however, generally have a southwesterly component and average around 80 mph (69.5 knots)
2 (Hoitink, et al., 2005).

3 Monthly mean temperatures near CGS range from a low of 31.8 degrees F (-0.1 degrees C) in
4 January to a high of 76.3 degrees F (24.6 degrees C) in July. Extreme temperatures range from
5 a low of -23.0 degrees F (-30.6 degrees C) on January 3, 1950, to a high of 113.0 degrees F
6 (45.0 degrees C) on July 13, 2002 (Hoitink, et al., 2005).

7 Approximately 7 in. (17.78 cm) of liquid precipitation fall throughout the year, with December
8 being the wettest month (1.11 in. (2.82 cm)) and July and August being the driest months (0.27
9 in. (0.69 cm)). The driest and wettest years on record are 1978 (2.99 in. (7.59 cm)) and 1996
10 (12.31 in. (31.27 cm)), respectively. Annual snowfall for the area is normally 15.4 in. (39.12
11 cm). Severe weather is not common to the area; thunderstorms are observed normally 10 days
12 throughout the year. Dense fog, with visibility less or equal to 0.25 mi (0.40 km), occurs 24 days
13 during a normal year, with the majority of these days occurring during the winter months of
14 December–February (Hoitink, et al., 2005).

15 **2.2.2.1 Air Quality**

16 The CGS site is located in Benton County, WA, which is part of the South Central Washington
17 Intrastate Air Quality Control Region (AQCR) (40 CFR 81.189). Additional counties in this
18 AQCR include Franklin, Kittitas, Klickitat, Walla Walla, and Yakima Counties.

19 The EPA regulates six criteria pollutants under the National Ambient Air Quality Standards
20 (NAAQS)—carbon monoxide, lead, nitrogen dioxide, ozone, sulfur dioxide, and particulate
21 matter. Benton County is designated as unclassified or in attainment for all NAAQS criteria
22 pollutants; a small portion of Benton County, which does not include the CGS site, became a
23 maintenance area for PM₁₀ (particles with a diameter of 10 micrometers or less) on September
24 26, 2005 (40 CFR 81.348). Portions of Yakima County, which are also part of this AQCR, are
25 also maintenance areas for PM₁₀ and carbon monoxide (40 CFR 81.348). All other counties in
26 this AQCR are designated as unclassified or in attainment with respect to the NAAQS criteria
27 pollutants.

28 Regulated air pollutants—including sulfur dioxide, nitrogen oxide, and particulates—are emitted
29 from three standby diesel generators and an auxiliary boiler at the CGS site (EN, 2010). These
30 sources conform to Washington State Regulatory Order 672, which limits air emissions to levels
31 below regulatory thresholds (EFSEC, 1996). A separate State regulation, WAC 463-78-100,
32 requires annual registration of air pollution sources. Table 2.2-1 lists the total diesel fuel usage
33 and associated air emissions from these regulated sources (Gambhir, 2010a). There are no
34 plans for refurbishment of structures or components at the CGS for license renewal. Therefore,
35 there are no changes to expected air emissions associated with license renewal (EN, 2010).

36 **Table 2.2-1. Annual fuel use and calculated air emission estimates**
37 **for significant sources at CGS**

| Year | Fuel usage (gal) ^(a) | NO _x (T) ^(b) | CO (T) ^(b) | SO ₂ (T) ^(b) | PM (T) ^(b) | PM ₁₀ (T) ^(b) | VOC (T) ^(b) | Pb (T) ^(b) | CO ₂ (T) ^{(b),(c)} |
|------|------------------------------------|------------------------------------|-----------------------|------------------------------------|-----------------------|-------------------------------------|------------------------|-----------------------|--|
| 2006 | 56,582 | 10.5 | 2.8 | 0.13 | 0.24 | 0.20 | 0.29 | 0.0002 | 650 |
| 2007 | 60,896 | 11.9 | 3.2 | 0.10 | 0.27 | 0.23 | 0.33 | 0.0003 | 699 |
| 2008 | 59,030 | 8.6 | 2.3 | 0.17 | 0.20 | 0.17 | 0.24 | 0.0002 | 678 |
| 2009 | 74,608 | 8.3 | 2.2 | 0.18 | 0.21 | 0.17 | 0.22 | 0.0002 | 856 |

| Year | Fuel usage (gal) ^(a) | NO _x (T) ^(b) | CO (T) ^(b) | SO ₂ (T) ^(b) | PM (T) ^(b) | PM ₁₀ (T) ^(b) | VOC (T) ^(b) | Pb (T) ^(b) | CO ₂ (T) ^{(b),(c)} |
|------|------------------------------------|------------------------------------|-----------------------|------------------------------------|-----------------------|-------------------------------------|------------------------|-----------------------|--|
|------|------------------------------------|------------------------------------|-----------------------|------------------------------------|-----------------------|-------------------------------------|------------------------|-----------------------|--|

^(a) To convert gallons to liters, multiply by 3.8.

^(b) To convert T to MT, multiply by 0.91.

^(c) Estimated by staff using EPA emission factors for uncontrolled gasoline and industrial engines (EPA, 2010a).

NO_x = nitrogen oxides; CO = carbon monoxide; SO₂ = sulfur dioxide; PM = particulate matter; PM₁₀ = particulate matter with an aerodynamic diameter of 10 microns or less; VOC = volatile organic compounds; Pb = lead; CO₂ = carbon dioxide.

(Gambhir, 2010a)

1 Mandatory Class I Federal Areas, where visibility is an important value, are listed in 40 CFR 81
 2 Subpart D. There are no mandatory Class I Federal areas within 50 mi (81 km) of the CGS site.
 3 The closest mandatory Class I Federal area is Goat Rocks Wilderness Area, which is
 4 approximately 100 mi (161 km) west of the CGS site (40 CFR 81.434). Due to the significant
 5 distance from the site and prevailing wind direction, no adverse impacts on Class I areas are
 6 anticipated from CGS operation. Furthermore, there are no expected air emissions associated
 7 with license renewal (EN, 2010).

8 CGS maintains a 245-ft (75-m) meteorological tower that is approximately 450 ft (137 m) above
 9 sea level. The tower is instrumented at two levels—33 ft (10 m) and 245 ft (75 m)—to measure
 10 wind and temperature (EN, 2010). Redundant measurements are made at both levels by
 11 backup instrumentation (EN, 2010). Relative humidity is also measured at the 33-ft (10-m)
 12 level. Precipitation and pressure are measured at ground level near the tower (EN, 2010).
 13 Observations are averaged to 15-minute and hourly values and are made available to the CGS
 14 plant computer. Separately, the DOE’s Hanford Site, which surrounds the CGS site, maintains
 15 a comprehensive network of meteorological stations and towers that can be used to further
 16 categorize the area (Hoitink, et al., 2005). Meteorological station 14, the closest DOE
 17 meteorological station to the CGS plant, is a 33-ft (10-m) tower that measures both wind and
 18 temperature. The National Weather Service office in Pendleton, OR, provides backup
 19 meteorological support for the CGS site.

20 **2.2.3 Groundwater Resources**

21 CGS is situated within the Hanford Site, in the east-central part of the semi-arid Pasco Basin,
 22 one of several structural and topographical depressions within the Columbia Plateau in
 23 southeastern Washington (EN, 2005), (DOE, 2005). Exploitable groundwater resources are
 24 available in the unconsolidated glaciofluvial sands and gravels of the Hanford formation, the
 25 semi-consolidated sand and gravel conglomerates of the Ringold Formation, and in the basaltic
 26 lava flows of the Columbia River Basalt Group and sedimentary interbeds of the Ellensburg
 27 Formation. Groundwater in the unconsolidated to semi-consolidated sediments above the
 28 basalt bedrock typically occurs in unconfined conditions, whereas groundwater in the basalt
 29 occurs mainly under confined conditions.

30 The uppermost aquifer beneath the CGS site occurs within the semi-consolidated Ringold
 31 Formation. This unconfined to semi-confined aquifer lies at a depth of about 60 ft. Two
 32 water-supply wells, Wells 699-13-1A and 699-13-1B, were constructed in the mid-1970s to tap
 33 into this aquifer, extending to depth of about 240 ft. Use of these wells was discontinued in
 34 1979 (EN, 2010). A third well, Well 699-13-1C, was drilled to a depth of 695 ft and draws water
 35 from a confined aquifer in the basalt.

Affected Environment

1 Nearby points of groundwater use include two water-supply wells located about 1 mi east for the
2 CGS plant, at the IDC. These wells were constructed in the mid-1970s to support construction
3 of Nuclear Projects Nos. 1 and 4 (WNP-1/4). The wells are 372 and 465 ft deep and draw from
4 a semi-confined portion of the lower Ringold Formation and from the upper portion of the
5 Columbia River Basalt Group, respectively (EN, 2010), (Dresel, et al., 2000).

6 Groundwater use on the Hanford Site is generally restricted, except for the purposes of
7 monitoring and treatment, as approved by the EPA or the WDOE (DOE, 2003). However, a
8 limited number of groundwater-supply wells provide drinking water at the FFTF in the 400 Area
9 (one main and two backup wells), the Hanford Patrol Training Center (one well), and the Yakima
10 Barricade (one well) (DOE, 2002a). Other wells supply emergency cooling water at B-Plant
11 (two wells) and water for aquatic studies in the 300 Area (one well) (DOE, 2002a).

12 Hanford Site operations have disposed of large volumes of operational wastewater. This has
13 supplied significant artificial recharge to the unconfined aquifer and led to many changes in the
14 groundwater characteristics. Operational discharges have decreased since 1984 and were
15 nearly eliminated by 1996. As a result of the past Hanford Site operations, the groundwater
16 beneath the Hanford Site has become contaminated by radiological and chemical constituents
17 unrelated to CGS operation. The most extensive contaminant plumes are those of tritium and
18 nitrate, emanating from the 200 Areas and moving east and southeast towards the river and
19 CGS site (DOE, 2008). In 2007, the area of groundwater with contaminants exceeding drinking
20 water standards was about 71 square miles (mi²) (Poston, et al., 2008).

21 In 1999, the DOE discovered high concentrations of tritium emanating from Burial Ground
22 618-11, located adjacent to the northwest corner of the CGS site (EN, 2010), (Figure 2.1-9).
23 This burial ground (dry waste landfill) was used between 1962–1967 for the disposal of fission
24 products and plutonium from Hanford Site operations (FH, 2003), (Dresel, et al., 2000). Tritium
25 concentrations as high as 8 million pCi/L were found in 2000 in Well 699-13-3A next to the
26 burial ground. Measured concentrations have been decreasing but still remain above the
27 drinking-water threshold of 20,000 pCi/L (DOE, 2008), (Vermeul, et al., 2005). In addition,
28 elevated nitrate, gross beta, technetium-99, and iodine-129 were detected in wells near Burial
29 Ground 618-11 (DOE, 2008). DOE continues to monitor the groundwater around Burial Ground
30 618-11 and is focused on the remediation of this burial ground.

31 **2.2.4 Surface Water Resources**

32 The Columbia River is the fourth largest North American river flowing to the sea. It is a
33 high-volume, high-gradient river fed by snowmelt in vast headwater mountain ranges (Benke
34 and Cushing, 2005). The river originates at Columbia Lake in the Canadian Rockies of British
35 Columbia and travels over 1,200 mi (1,900 km), draining a watershed covering approximately
36 262,480 mi² (USFWS, 2008). River flow is regulated by 10 mainstream dams above the CGS
37 site (including three in British Columbia) and 4 below the site. The nearest upstream dam is
38 Priest Rapids, located at RM 397, 45 mi upstream of the CGS site. The nearest downstream
39 dam is McNary, located at RM 292, 60 mi downstream (EN, 2010). The reservoir (Lake
40 Wallula), created by the McNary Dam, extends to about 6 mi below the CGS site. The 51-mi
41 river reach, extending from the Priest Rapids Dam to the Lake Wallula (RM 346), is free flowing
42 following the flow released from Priest Rapids Dam. The elevation drop through this reach is
43 approximately 70 ft. Flow typically peaks from April–July during spring runoff and is lowest from
44 September–October. The monthly flows recorded by the USGS below Priest Rapids Dam
45 during water years 1960–2009 range from a mean of 79,300 cfs during September to a mean of
46 202,000 cfs during June. Mean annual flows for the same period ranged from 80,650 cfs in

1 2001 to 165,600 cfs in 1997 and averaged 117,823 cfs. For water years 1984–2008, coincident
2 with the period of CGS operation, measured flows averaged 113,712 cfs (USGS, 2010). Flow is
3 regulated to meet electrical demands and limit the impact on spawning salmon (EN, 2010).
4 Flows vary daily and hourly as water is released from Priest Rapids Dam, causing the river
5 stage to fluctuate in excess of 10 ft on a daily basis. The river channel near the CGS site varies
6 between 1200–1800 ft wide for low water and normal high water stage, respectively. River
7 depth varies from about 25–45 ft for normal high water and flood high water levels, and
8 velocities vary from 3 feet per second (fps) to over 11 fps depending on the section and flow
9 (EN, 2005a).

10 The only other significant hydrological feature in the site area is the Yakima River, which flows
11 generally west to east and enters the Columbia River at RM 335 (EN, 2010). At its closest
12 approach, the Yakima is about 8 mi southwest of the CGS site.

13 **2.2.5 Description of Aquatic Resources**

14 The Columbia River crosses the west of the CGS site, and the intake and discharge structures
15 are located at approximately RM 352. The Columbia River and associated riparian zones
16 supply habitat for many wildlife and plant species. The portion of the Columbia River known as
17 the Hanford Reach is the segment from Priest Rapids Dam (RM 397) to McNary Pool (RM 346)
18 (Duncan, et al., 2007). The Hanford Reach is the last non-impounded, non-tidal segment of the
19 Columbia River in the U.S. People have been using the aquatic resources of the river for at
20 least 10,000 years (Duncan, et al., 2007). For a vast majority of this time, the aquatic resources
21 were the way of life for the people in the area, and the Hanford Reach still supports subsistence
22 lifestyles. The aquatic ecosystem today is very different than it was 200 years ago when people
23 started making significant changes to the Columbia River. Evidence of gold mining along the
24 shoreline is still apparent today (Duncan, et al., 2007). Intensive commercial fishing during the
25 late 19th century led to significant declines in several migratory salmon species that used the
26 Hanford Reach for spawning, rearing, and passage. The greatest effect on the aquatic
27 resources of the Columbia River has been the result of hydropower development that began in
28 the 1930s (Dauble, 2009). This section describes the aquatic resources near the CGS site with
29 emphasis on those resources present since the proposed construction of the plant.

30 The Hanford Reach of the Columbia River supports a large and diverse population of plankton,
31 benthic, and lotic invertebrates, fish, and other communities. Large rivers contain significant
32 populations of primary energy producers (e.g., algae and plants) that contribute to the
33 ecosystem's basic energy requirements (Duncan, et al., 2007). Figure 2.2-1 (Miley, et al., 2007)
34 illustrates the interdependencies and biomass flow of the aquatic resources in the Hanford
35 Reach.

36 The food web of the Hanford Reach resembles that found in large, flowing northwest rivers.
37 The energy sources for the food web are many and diverse (Cushing and Allan, 2001). Primary
38 production comes from organisms that create organic carbon compounds from inorganic
39 precursors through photosynthesis, using energy from sunlight. Secondary production comes
40 from growing populations of organisms that are unable to synthesize energy from inorganic
41 matter and obtain energy by consuming the organic matter formed by primary producers. The
42 plants and animals in Figure 2.2-1 are loosely organized into trophic or feeding groups. These
43 include the herbivores (plant eaters), carnivores (organisms that feed on other animals), and
44 detritivores (detritus, or nonliving organic matter, feeders). Omnivores are animals that eat
45 more than one trophic level. Ecologists often further categorize taxa within a trophic level by
46 function (e.g., shredders, grazers or scrapers, gatherers and filters and predators).

Affected Environment

- 1 The river supplies habitat for the organisms of the different trophic levels in the water column as
- 2 well as on the bottom of the river (Cushing and Allan, 2001), (Miley, et al., 2007).




Figure 2.2-1. The aquatic and riparian food web for the Hanford Reach of the Columbia River

(Miley, et al., 2007)

3 **2.2.5.1 Aquatic Communities in the Vicinity of the Columbia Generating Station Site**

- 4 The aquatic organisms include planktonic and benthic species, macrophytes, aquatic insects,
- 5 and fish. These organisms represent primary producers, herbivores, carnivores, and
- 6 omnivores. Phytoplankton and zooplankton populations in the Columbia River at the CGS site
- 7 are largely transient, flowing from one reservoir to another. With the relatively rapid flow of the
- 8 Columbia River, there is generally insufficient time for phytoplankton and zooplankton
- 9 populations to develop in the Hanford Reach compared to populations observed in
- 10 impoundments and reservoirs (Duncan, et al., 2007).

1 The organisms in the benthic habitat represent all trophic levels. Macrophytes support grazing
 2 organisms, and when they die, their biomass becomes detritus supporting other organisms.
 3 Aquatic invertebrates and fish represent all of the trophic levels of consumers. Their function in
 4 their habitat often shapes their appearance. For example, snails and fish that feed on
 5 periphyton have mouths that point downward and “teeth” that scrape the algae off the rocks
 6 (Cushing and Allan, 2001).

7 Several communities or trophic levels are discussed separately below.

8 Phytoplankton. Phytoplankton (free-floating algae) are abundant in the Columbia River and are
 9 the basic food for organisms such as filter-feeding aquatic insects. The reservoirs upstream of
 10 Priest Rapids Dam influence the phytoplankton populations in the Hanford Reach. Major
 11 phytoplankton groups identified from the Hanford Reach include diatoms, golden or
 12 yellow-brown algae, green algae, blue-green algae, red algae, and dinoflagellates. Diatoms are
 13 the dominant algae in the Columbia River phytoplankton, usually representing more than
 14 90 percent of the phytoplankton community (based on density and number of species). The
 15 main genera include *Asterionella*, *Cyclotella*, *Fragilaria*, *Melosira*, *Stephanodiscus*, and *Synedra*
 16 (Neitzel, et al., 1982a). These genera of diatoms are typical of diatom communities in lakes and
 17 ponds and originate in upstream reservoirs. Many algae found as free-floating species in the
 18 Hanford Reach of the Columbia River are the same as those in the attached periphyton
 19 community on the river’s substrate. The currents and frequent fluctuations of the water levels in
 20 the Hanford Reach shear and detach the periphyton and suspend the algae in the water
 21 column. Cushing (1967) found peak concentrations of phytoplankton occurred in April and May.
 22 A secondary peak in phytoplankton occurred in late summer and early autumn. Cushing
 23 hypothesized that the increased biomass in phytoplankton later in the year was likely a
 24 response to increased light and rising water temperatures, rather than to the availability of
 25 nutrients, because phosphate and nitrate nutrient concentrations are never limiting in the region.
 26 The lowest densities of phytoplankton were in December and January. Green algae
 27 (*Chlorophyta*) and blue-green algae (*Cyanophyta*) occur in phytoplankton communities during
 28 warmer weather (Duncan, et al., 2007), (Neitzel, et al., 1982a), (Wolf, 1976). These patterns
 29 are typical of large rivers and probably occur in the Columbia River today.

30 Zooplankton. The zooplankton populations in the Hanford Reach of the Columbia River are
 31 generally sparse. Studies by Neitzel, et al., (1982b) show crustacean species of zooplankton
 32 were numerically dominant in the open-water regions. The cladocern genus *Bosmina*, and the
 33 copepods genera *Diatomus* and *Cyclops*, were dominant. Densities were lowest in winter and
 34 highest in the summer, with summer peaks numerically dominated by *Bosmina*, ranging up to
 35 4,500 organisms per cubic foot (ft³) (160,650 organisms/m³). Winter densities were generally
 36 less than 50 organisms/ft³ (1,785 organisms/m³). *Diatomus* dominated in the winter months,
 37 and *Cyclops* dominated spring months (Duncan, et al., 2007), (Neitzel, et al., 1982b).

38 Periphyton. Periphyton is the attached, sessile, algal community in the river, often referred to as
 39 “slime on the rocks” (Biggs, 2000). Periphyton communities develop on solid substrate
 40 wherever there is “sufficient light for photosynthesis and adequate currents to prevent sediment
 41 from covering the colonies” (Duncan, et al., 2007). Periphyton substrates include rocks,
 42 sediments, macrophytes, and even rather sedentary animals, like clams. As mentioned above,
 43 the algal community in the water column includes many periphyton species. The most common
 44 taxa in the periphyton community include diatoms (*Achnanthes*, *Asterionella*, *Cyclotella*,
 45 *Cybella*, *Cocconeis*, *Gomphonema*, *Fragilaria*, *Melosira*, *Nitzschia*, *Navicula*, and *Synedra*) and
 46 blue-green algae (*Schizothrix* and *Plectonema*) (Duncan, et al., 2007), (EN, 2010), (WPPSS,
 47 1982), (WPPSS, 1987). Frequent river-level fluctuations in the Hanford Reach, from the

Affected Environment

1 operation of Priest Rapids Dam, expose the shoreline and inhibit the development of persistent
2 periphyton communities (Duncan, et al., 2007). The periphyton community supports the
3 scraping and grazing insects and mollusks as well as bottom-dwelling fish in the river (Cushing
4 and Allan, 2001).

5 Energy Northwest did periphyton studies as part of the preoperational and operating monitoring
6 programs (EN, 2010), (WPPSS, 1982), (WPPSS, 1987). The periphyton biomass was two–four
7 times higher in winter than in spring and summer. This trend is similar to the biomass trend for
8 the free-floating phytoplankton densities, which were highest in the spring and late summer and
9 fall. Decreases in periphyton biomass are probably associated with the increased foraging and
10 grazing on the attached primary producers by numerous species that are most active when the
11 water temperature rises (Dauble, 2009).

12 Aquatic Macrophytes. Due to the strong currents, rocky bottom, and frequently fluctuating water
13 levels in the Columbia River, aquatic plants—or macrophytes—are sparse compared to
14 shorelines in slower-moving rivers. Upstream of CGS, rushes (*Juncus* spp.) and sedges (*Carex*
15 spp.) occur along shorelines of the slack-water areas. Reed canary grass (*Phalaris*
16 *arundinacea*) is a common non-native species found along the CGS shoreline. Macrophytes
17 are also present along gently sloping shorelines that are subject to flooding during the spring
18 freshet and daily fluctuating river levels. Commonly found plants include duckweed (*Lemna* sp.)
19 and the native rooted pond weeds (*Potamogeton* sp. and *Elodea canadensis*). Macrophytes
20 supply food and shelter for juvenile fish and spawning areas for some species of warm-water
21 game fish (Duncan, et al., 2007).

22 Benthic Macroinvertebrates. Bottom-dwelling epifaunal organisms live either attached to or
23 closely associated with the river substrate, and infaunal organisms live within the soft substrate.
24 The Columbia River supports all major freshwater benthic animal taxa representing several
25 trophic consumer levels. Studies in the Hanford Reach have noted 151 aquatic invertebrate
26 taxa (Duncan, et al., 2007). Insect larvae such as caddisflies (Trichoptera), midge flies
27 (Chironomidae), and black flies (Simuliidae) are dominant in the river. The most common
28 caddisfly species include *Hydropsyche cockerelli*, *Cheumatopsyche campyla*, and *C. enonis*.
29 Other benthic macroinvertebrates include clams (*Corbicula* sp., *Anodonta* spp.), limpets
30 (*Fisherola* spp.), snails (*Physa* spp.), sponges (*Spongilla* spp.), and crayfish (identified as
31 *Astacus trowbridgii*, renamed as *Pacifastacus leniusculus trowbridgii* (Hobbs, 1974)). Suitable
32 habitat for most benthic macroinvertebrates is at depths where they are not affected by river
33 water-level fluctuations from the operation of Priest Rapids Dam (Duncan, et al., 2007).

34 Past studies have characterized the abundance and importance of benthic macroinvertebrates.
35 Duncan et al. (2007) summarized the early Hanford studies and presented the following results.
36 Crayfish numbers in shallow water areas ranged from 0.2–1.1 individuals per square foot (ft²)
37 (0.02–0.10 individuals per square meter (m²)) of river bottom. The diet of crayfish in the
38 Hanford Reach is primarily of vegetation, particularly periphyton. Duncan reported from a
39 different study that insect larvae numbers were as high as 2,000/ft² (185.8/m²). Peak larval
40 insect densities are found in late fall and winter, with major emergence in spring and summer,
41 which corresponds with the decrease of periphyton biomass. An additional study examined the
42 stomach contents of fish collected in the Hanford Reach from 1973–1980, and it revealed that
43 benthic invertebrates were important food items for nearly all juvenile and adult fish.

44 Newell (2003) summarized studies of the macroinvertebrate fauna of the Hanford Reach over
45 the last 50 years. The major trends observed were that “mayfly diversity has increased;
46 stoneflies have disappeared; caddisfly diversity and abundance remain high; Odonata,

1 Hemiptera, Lepidoptera, and Coleoptera are rare; and Diptera diversity remains relatively
 2 constant.” In 2002, visual surveys for western pearlshell mussel (*Margaritifera falcata*) and
 3 crayfish (*P. leniusculus towbridgii*) showed that the mussel has all but disappeared from the
 4 Reach while the crayfish densities remain high.

5 The mollusks of the Hanford Reach also give insight into how people have used the river over
 6 time. Ames et al. (1998) reported investigations of pit houses, dated from the period
 7 5000/4000-1900 BC, from locations upstream of the Hanford Reach (Wells Reservoir and Chief
 8 Joseph Reservoir) in the South-central Plateau. Faunal remains identified in these locations
 9 include freshwater mussels. Nedeau, et al., (2009) mentions the presence of western
 10 pearlshells and other freshwater species in Native American middens found in rivers in eastern
 11 Oregon, dating back more than 1,000 years. The western pearlshells are no longer found in the
 12 river today, showing that the river’s conditions (e.g., water quality or loss of fish host species)
 13 have somehow changed, and the pearlshells are extirpated today from that range.

14 Fish. Studies of fish in the Hanford Reach of the Columbia River date back to the 1840s. Table
 15 2.2-2 lists the 45 species of fish documented in the Hanford Reach of the Columbia River from
 16 surveys using a variety of sampling gear starting in 1973 and continuing to the present. Since
 17 Gray and Dauble (1977) first published a list of fish species collected in the Hanford Reach,
 18 three additional fish species have been collected. These include bull trout (*Salvelinus*
 19 *confluentus*, which had been identified in Gray and Dauble (1977) as the Dolly Varden (*S.*
 20 *malma*)), brown bullhead (*Ameiurus nebulosus*), and western mosquitofish (*Gambusia affinis*)
 21 (Duncan, et al., 2007). Most of the fish species are native to the Hanford Reach. Six native
 22 species are anadromous and use the river either for spawning or as a migration route to and
 23 from upstream spawning areas—upper Columbia River spring/summer/fall-run Chinook salmon
 24 (*Oncorhynchus tshawytscha*), upper Columbia River steelhead (*O. mykiss*), coho salmon (*O.*
 25 *kisutch*), sockeye salmon (*O. nerka*), Pacific lamprey (*Lampetra tridentata*), and American shad
 26 (*Alosa sapidissima*) (FERC, 2006). The river lamprey (*L. ayresii*) may also be present in the
 27 Hanford Reach, although detailed distribution records are not available (Wydoski and
 28 Whitney, 2003), and it is uncertain whether it spawns in this area (Dauble, 2009), (Meeuwig, et
 29 al., 2002).

30 **Table 2.2-2. Fish species in the Hanford Reach of the Columbia River**
 31 **in Washington State**

| Common name | Scientific name |
|--|---------------------------------|
| Family Acipenseridae (paddlefishes, spoonfishes, sturgeons) | |
| white sturgeon | <i>Acipenser transmontanus</i> |
| Family Clupeidae (anchovies, herrings) | |
| American shad | <i>Alosa sapidissima</i> |
| Family Catostomidae (cyprins, minnows, suckers) | |
| chiselmouth | <i>Acrocheilus alutaceus</i> |
| bridgelp sucker | <i>Catostomus columbianus</i> |
| largescale sucker | <i>Catostomus macrocheilus</i> |
| mountain sucker | <i>Catostomus platyrhynchus</i> |
| common carp | <i>Cyprinus carpio</i> |
| peamouth | <i>Mylocheilus caurinus</i> |

Affected Environment

| Common name | Scientific name |
|---|----------------------------------|
| northern pikeminnow | <i>Ptychocheilus oregonensis</i> |
| longnose dace | <i>Rhinichthys cataractae</i> |
| leopard dace | <i>Rhinichthys falcatus</i> |
| speckled dace | <i>Rhinichthys osculus</i> |
| reeside shiner | <i>Richardsonius balteatus</i> |
| tench | <i>Tinca tinca</i> |
| Family Poeciliidae (livebearers) | |
| western mosquitofish | <i>Gambusia affinis</i> |
| Family Gadidae (cods) | |
| burbot | <i>Lota lota</i> |
| Family Gasterosteidae (pipefishes, sticklebacks) | |
| threespine stickleback | <i>Gasterosteus aculeatus</i> |
| Family Centrarchidae (perch-like fishes) | |
| pumpkinseed | <i>Lepomis gibbosus</i> |
| bluegill | <i>Lepomis macrochirus</i> |
| smallmouth bass | <i>Micropterus dolomieu</i> |
| largemouth bass | <i>Micropterus salmoides</i> |
| yellow perch | <i>Perca flavescens</i> |
| white crappie | <i>Pomoxis annularis</i> |
| black crappie | <i>Pomoxis nigromaculatus</i> |
| walleye | <i>Sander vitreus</i> |
| Family Percopsidae (trout perches) | |
| sand roller | <i>Percopsis transmontana</i> |
| Family Petromyzontidae (lampreys) | |
| river lamprey | <i>Lampetra ayresii</i> |
| Pacific lamprey | <i>Lampetra tridentata</i> |
| Family Salmonidae (salmonids, salmon, trout) | |
| lake whitefish | <i>Coregonus clupeaformis</i> |
| bull trout | <i>Salvelinus confluentus</i> |
| cutthroat trout | <i>Oncorhynchus clarkii</i> |
| coho salmon | <i>Oncorhynchus kisutch</i> |
| rainbow trout (steelhead) | <i>Oncorhynchus mykiss</i> |
| sockeye salmon | <i>Oncorhynchus nerka</i> |
| Chinook salmon | <i>Oncorhynchus tshawytscha</i> |
| mountain whitefish | <i>Prosopium williamsoni</i> |
| Family Cottidae (chabots, sculpins) | |
| prickley sculpin | <i>Cottus asper</i> |

| Common name | Scientific name |
|--|----------------------------|
| mottled sculpin | <i>Cottus bairdii</i> |
| Paiute sculpin | <i>Cottus beldingii</i> |
| reticulate sculpin | <i>Cottus perplexus</i> |
| torrent sculpin | <i>Cottus rhotheus</i> |
| Family Ictaluridae (bullhead catfishes, North American freshwater catfishes) | |
| yellow bullhead | <i>Ameiurus natalis</i> |
| brown bullhead | <i>Ameiurus nebulosus</i> |
| black bullhead | <i>Ameiurus melas</i> |
| channel catfish | <i>Ictalurus punctatus</i> |

(Duncan, et al., 2007)

1 American shad is an introduced, anadromous fish species (Duncan, et al., 2007). The other
 2 introduced fish include common carp (*Cyprinus carpio*), tench (*Tinca tinca*), western
 3 mosquitofish (*Gambusia affinis*), pumpkinseed (*Lepomis gibbosus*), bluegill (*L. macrochirus*),
 4 smallmouth bass (*Micropterus dolomieu*), largemouth bass (*M. salmoides*), yellow perch (*Perca*
 5 *flavescens*), white crappie (*Pomoxis annularis*), black crappie (*P. nigromaculatus*), walleye
 6 (*Sander vitreus*), lake whitefish (*Coregonus clupeaformis*), yellow bullhead (*A. natalis*), brown
 7 bullhead (*A. nebulosus*), black bullhead (*A. melas*), and channel catfish (*Ictalurus punctatus*)
 8 (Dauble, 2009), (Gray and Dauble, 1977).

9 The pre-operational monitoring program for CGS included fish sampling by beach seine, hoop
 10 nets, gill net, and electroshocking. From September 1974–March 1980 a total of 35,939 fish
 11 were collected at the CGS site, comprising of 37 species representing 12 families. Chinook
 12 salmon composed approximately 44 percent of all fish caught by all collecting methods. Table
 13 2.2-3 lists the species caught with a relative abundance greater than 0.1 percent (all other
 14 species individually comprised less than 5 percent of the total catch) (EN, 2010), (WPPSS,
 15 1982).

16 **Table 2.2-3. Recreationally and commercially important fish species in or**
 17 **near the Hanford Reach and the CGS site**

| Scientific name | Common name | Distribution |
|---------------------------------|-------------------------|--|
| <i>Acipenser transmontanus</i> | white sturgeon | Abundant year-round |
| <i>Ictalurus punctatus</i> | channel catfish | Common in spring and summer |
| <i>Oncorhynchus tshawytscha</i> | Chinook salmon | Abundant |
| <i>Oncorhynchus kisutch</i> | coho salmon | Uncommon |
| <i>Oncorhynchus mykiss</i> | rainbow trout/steelhead | Abundant spring through fall |
| <i>Oncorhynchus nerka</i> | sockeye salmon | Juveniles common spring & adults common summer |
| <i>Micropterus salmoides</i> | largemouth bass | Common |
| <i>Micropterus dolomieu</i> | smallmouth bass | Abundant |
| <i>Sander vitreus</i> | walleye | Common |

(EN, 2010)

Affected Environment

1 The fish species with the greatest economic importance in the area are anadromous species
2 (Duncan, et al., 2007). Fall-run Chinook salmon and steelhead spawn in the Hanford Reach.
3 The importance of the Hanford Reach to the overall population of the fall-run Chinook salmon
4 has increased with the inundation of other mainstem Columbia River spawning grounds by
5 dams (Dauble and Watson, 1997), (Watson, 1970), (Watson, 1973). Daily and seasonal
6 river-level fluctuations from the operation of Priest Rapids Dam can expose the shoreline and
7 cobble bars during low-flow periods. In recent years, the operation of Priest Rapids Dam has
8 changed, and the more stable water levels during the fall months discourage salmon from
9 spawning in areas that are exposed at low river flow during the winter. This strategy of water
10 release protects salmon redds (nests) from desiccation and temperature extremes.

11 The river bottom supplies habitat for spawning, rearing, foraging, and shelter. Fall-run Chinook
12 salmon select their spawning areas based on water depth, substrate, current velocity, and
13 groundwater upwelling. Even with all these factors, Dauble and Watson (1990) stated that
14 predicting spawning areas was difficult. Once the young salmon begin to migrate, they remain
15 close to the bottom as they pass through the Hanford Reach (Dauble, 2009).

16 Aerial counts of fall-run Chinook salmon redds have been done in the Hanford Reach since
17 1948 (Dauble and Watson, 1997). The count of redds in the Hanford Reach has been trending
18 upwards over time (Figure 2.2-2), and the redds have been observed throughout the Hanford
19 Reach (Figure 2.2-3). The results of these surveys give an index of relative abundance among
20 spawning areas and years. From 1948–1961, redd counts during peak spawning were less
21 than 1,000 annually. The number of redds increased to as high as 9,400 in 2003 after
22 construction of several mainstem dams both the Columbia and Snake rivers. From 1964–1982,
23 escapement of adult fall Chinook salmon to the Hanford Reach (the number of adults that
24 survive natural mortality and harvest to reach the spawning grounds) averaged about
25 25,000 fish annually. In 1987, the number of adult Chinook increased to a peak estimate of
26 89,000 spawning. In addition to the loss of spawning areas due to inundation by dam
27 construction in other areas, other factors for the upward trend of Chinook salmon in the Reach
28 are the increase in hatchery production, improved juvenile and adult passage at hydroelectric
29 dams, changes in harvest management practices, and favorable ocean conditions (Dauble and
30 Watson, 1990), (Poston, et al., 2009). There are presently 10 areas noted in the Hanford Reach
31 that support salmon spawning (Dauble and Watson, 1997), (Duncan, et al., 2007), (Poston, et
32 al., 2004).




Figure 2.2-2. Number of fall-run Chinook Salmon Redds in the Hanford Reach

(Poston, et al., 2009)

Affected Environment




Figure 2.2-3. Fall Chinook and Steelhead spawning areas in the Hanford Reach and vicinity of the CGS site

(DOE, 2000), (Gambhir, 2010b), (Poston, et al., 2009)

1 The steelhead fishery in the Hanford Reach extends from Highway 395 Bridge past CGS to
 2 Priest Rapids Dam. The fishery consists almost exclusively of summer-run fish. The
 3 Washington State Department of Fish and Wildlife (WDFW) estimated steelhead sport catch for
 4 the 2003 season (the last season statistics were tabulated) to be 3,600—up from 1,100 fish in
 5 2002. The majority of these fish were marked hatchery fish (only 12 were unmarked). In recent
 6 years the return of fall Chinook salmon has been high—with 8,550 harvested during 2002 and
 7 16,868 harvested in 2003 (Duncan, et al., 2007), (WDFW, 2010b).

8 American shad may also spawn in the Hanford Reach. The upstream range of the shad has
 9 been increasing since 1956 when the construction of The Dalles Dam inundated Celilo Falls and
 10 opened passage for the shad to migrate. In 2005, 5.2 million adult shad were estimated to
 11 migrate up the Columbia River. More than 350,000 shad per day passed through Bonneville
 12 Dam (Dauble, 2009). The number of shad returning to Priest Rapids Dam increased
 13 dramatically in the 1970s and 1980s and peaked at 121,806 fish in 1992. The number of shad
 14 returning over recent years has dropped to fewer than 10,000. The species does not pass
 15 upstream of Priest Rapids dam because “they do not use or are unable to negotiate the
 16 submerged orifices of the upper sections of Priest Rapids fishways,” and this prevents them
 17 from reaching the upstream reservoir (FERC, 2006). Shad are broadcast spawners compared
 18 to salmon, which restrict their spawning to areas specific for building their redds (Dauble, 2009),
 19 (Duncan, et al., 2007), (FERC, 2006).

20 Near the CGS site, nine fish species are of commercial or recreational importance (Table 2.2-4)
 21 (EN, 2010). There is no commercial fishery established today in the Hanford Reach of the
 22 Columbia River, but several of the fish that occur in the Reach spend part of their life in the
 23 upper Columbia River or the ocean where a commercial fishery exists (e.g., Chinook salmon).
 24 The Hanford Reach supports a very popular recreational fishery. For example, the WDFW
 25 recommended that the Grant Public Utility District develop and carry out a Resident Fish Plan
 26 with a goal of producing 137,000 lb of fish to support recreational fisheries, including the
 27 Hanford Reach, as part of its relicensing efforts for Priest Rapids Dam (FERC, 2006). Because
 28 half of the nine recreationally important fish are introduced species, the list of species is likely to
 29 grow and change in the future (EN, 2010).

30 **Table 2.2-4. Relative abundance of fish species collected near the CGS site,**
 31 **September 1974 through March 1980**

| Scientific name | Common name | Relative abundance (%) |
|----------------------------------|--------------------------|------------------------|
| <i>Oncorhynchus tshawytscha</i> | Chinook salmon | 44.1 |
| <i>Richardsonius balteatus</i> | reidside shiner | 11.3 |
| <i>Catostomus macrocheilus</i> | largescale sucker | 8.8 |
| <i>Ptychocheilus oregonensis</i> | northern pikeminnow | 6.9 |
| <i>Mylocheilus caurinus</i> | peamouth | 6.7 |
| <i>Prosopium williamsoni</i> | mountain whitefish | 3.7 |
| <i>Acrocheilus alutaceus</i> | chiselmouth | 3.5 |
| <i>Catostomus spp.</i> | sucker (miscellaneous) | 3.4 |
| <i>Catostomus columbianus</i> | bridgelip sucker | 3.3 |
| <i>Cottus spp.</i> | sculpin (miscellaneous) | 0.9 |
| <i>Perca flavescens</i> | yellow perch | 0.7 |
| <i>Oncorhynchus mykiss</i> | rainbow trout/ steelhead | 0.6 |

Affected Environment

| Scientific name | Common name | Relative abundance (%) |
|--|------------------------------|------------------------|
| <i>Cyprinidae</i> | carps | 0.6 |
| <i>Cottus asper</i> | prickly sculpin | 0.5 |
| <i>Rhinichthys cataractae</i> | longnose dace | 0.3 |
| <i>Acipenser transmontanus</i> | white sturgeon | 0.2 |
| <i>Pomoxis nigromaculatus</i> | black crappie | 0.2 |
| <i>Lepomis macrochirus</i> | bluegill | 0.2 |
| <i>Micropterus dolomieu</i> | smallmouth bass | 0.2 |
| <i>Cyprinidae and Catostomidae fry</i> | carp, minnow, and sucker fry | 3.1 |

(EN, 2010)

1 An uncommon type of fishery—known as a sport-reward program—exists in the Columbia
 2 River, including the Hanford Reach. The WDFW, in an effort to reduce predation by northern
 3 pikeminnow (*Ptychocheilus oregonensis*) of juvenile salmonids during their emigration from
 4 natal streams to the ocean, established a bounty program that pays recreational fisherman to
 5 harvest the adult pikeminnow. WDFW studies before the bounty program suggest that 10–
 6 20 percent of the juvenile salmonid mortality in eight Columbia and Snake River reservoirs was
 7 due to predation by northern pikeminnow (Porter, 2009). Columbia Point in Richland and the
 8 Vernita Bridge rest stop are the closest locations to the Hanford Reach where recreational
 9 fisherman can turn in their catch (Duncan, et al., 2007). In 2009, the catch-per-unit effort was
 10 4.68 at Columbia Point and 7.37 at Vernita Bridge rest stop, the second highest within the
 11 Columbia River (Porter, 2009).

12 In addition to commercially and recreationally important species, the lamprey—and specifically
 13 the Pacific lamprey—have cultural, ceremonial, medicinal, subsistence, and ecological
 14 importance to Native American tribes of the region (Nez Perce, Umatilla, Yakama, and Warm
 15 Springs Tribes, 2008). Pacific lampreys are found from Hokkaido Island, Japan, along the
 16 Pacific Rim to Baja California. They are the most widely distributed lamprey species on the U.S.
 17 west coast (69 FR 77158). Adult Pacific lampreys parasitize a wide variety of fish, including the
 18 Pacific salmon. In turn, they are preyed upon by sharks, sea lions, and other marine animals.
 19 Pacific lampreys return to freshwater, and spawning occurs the following March or April after a
 20 holdover of almost a year (Dauble, 2009). Eggs are fertilized and deposited in nests, and the
 21 embryos hatch in approximately 19 days at 59 degrees F (15 degrees C) (69 FR 77158). The
 22 larvae, or “ammocoetes,” remain burrowed in the sand and gravel for 5–7 years. They feed
 23 primarily on microscopic algae and become parasitic after they have reached their adult stage
 24 (Dauble, 2009).

25 **2.2.5.2 Invasive or Introduced Aquatic Species**

26 Washington State has an active monitoring and education program for addressing invasive
 27 species, and the program is carried out by the Washington Invasive Species Council (WISC).
 28 The top 50 priority species noted by WISC include aquatic plants and animals. The invasive
 29 aquatic plants include Eurasian watermilfoil (*Myriophyllum spicatum*), hydrilla (*Hydrilla*
 30 *verticillata*), parrotfeather (*M. aquaticum*), common reed (*Phragmites australis*), purple
 31 loosestrife (*Lythrum salicaria*), smooth cordgrass (*Spartina alterniflora*), water chestnut (*Trapa*
 32 *natans*), and Brazilian elodea (*Egeria densa*). Other invasive aquatic animals include Asian
 33 carps (*Hypophthalmichthys nobilis*, *Mylopharyngodon piceus*, *Ctenopharyngodon idella*, and *H.*
 34 *molitrix*), American bullfrog (*Rana catesbeiana*), New Zealand mud snail (*Potamopyrgus*

1 *antipodarum*), northern snakehead (*Channa argus*), red swamp crayfish (*Procambarus clarkii*),
2 and rusty crayfish (*Orconectes rusticus*) (WISC, 2009).

3 Several aquatic invasive species are found near CGS. Eurasian watermilfoil, an introduced
4 macrophyte, has increased to nuisance levels since the late 1980s and may encourage
5 increased sedimentation of fine particulate matter (Duncan, et al., 2007). Purple loosestrife
6 inhabits many islands in the Hanford Reach and along the east bank of the river. Biological
7 controls have not been successful due to effects from the operation of Priest Rapids Dam and
8 water-level fluctuations. Currently, Hanford Site personnel are working with landowners along
9 the Columbia River to find and control purple loosestrife. While zebra (*Dreissena polymorpha*)
10 and quagga mussels (*D. bugensis*) have not been found in Washington State waters, including
11 the Hanford Reach, education and inspection programs are intensifying to deter these mussels
12 from taking hold in the area (WDFW, 2010a).

13 Asian clams (*Corbicula fluminea*) are an invasive species of concern for many nuclear facilities
14 because they have the potential to cause biofouling in the intake and circulating-water systems
15 (NRC, 1996). Operational monitoring studies in 1985 and 1986 included observations of
16 several water systems (e.g., the tower makeup pump pit) to determine if Asian clams were
17 colonizing the systems (WPPSS, 1986), (WPPSS, 1987). Live clams were found around the
18 intake screen supports in the river and in some parts of the circulating-water system. They
19 found few living clams and shells in the circulating-water system and attributed the biofouling
20 treatment program to controlling the clams. Newell (2003) speculated that the rise of Asian
21 clams might have contributed to the decline in population of western pearlshell mussels. The
22 State of Washington is not currently documenting the occurrence of the species in the State
23 (WISC, 2009).

24 As mentioned in Section 2.2.5.1, 17 of the 48 species of fish collected in the Hanford Reach are
25 considered introduced to the area. The reasons for these introductions vary from people's
26 desire for a particular recreational fishery to accidental releases. Western mosquitofish are
27 used for biological control of mosquitos and likely were transplanted to the river unintentionally.
28 This species consumes zooplankton and algae and has some value as a forage fish
29 (Dauble, 2009). Dauble (2009) estimated that more than 60 percent of resident game fish in the
30 Columbia River Basin are warmwater-introduced species such as bass, bluegill, crappie, and
31 perch. Many of these introduced species consume juvenile, listed species, like Chinook
32 (Dauble, 2009). Other negative effects of introduced species include competition food and
33 habitat with native species (Cushing and Allan, 2001).

34 **2.2.6 Terrestrial Resources**

35 The CGS site and its associated transmission lines are located approximately 3.25 mi (5 km)
36 west of the Columbia River at RM 352, within the Columbia River watershed and drainage
37 basin, a broad area lying between the Cascade Range and the Blue Mountains in Oregon and
38 Washington (EN, 2010). The CGS site is located in Benton County, WA, on 1,089 ac (441 ha)
39 of land leased from the southeastern portion of the DOE's Hanford Site (Figure 2.1-2). The site
40 terrain is generally flat with gentle hills and an elevation ranging from about 350 ft above the
41 MSL near the river to about 460 ft MSL on the hills. Plant grade onsite is 441 ft MSL.

42 The 586 mi² Hanford Site, on which CGS is located, is within the Columbia Plateau ecoregion.
43 This ecoregion covers approximately one-third of the State of Washington—including the area
44 bordered by the Cascade Mountains, Okanogan Highlands, the Blue Mountains, and the Rocky
45 Mountains—and is the driest and hottest ecoregion in Washington because it lies within the rain
46 shadow of the Cascade Mountains (WDNR, 2007). The habitat found on the Hanford Site is

Affected Environment

1 typical of a shrub-steppe ecosystem found in the Columbia Plateau ecoregion, consisting of
2 layers of perennial grasses overlain by a discontinuous layer of shrubs (EN, 2003b). More than
3 50 percent of the Columbia Plateau ecoregion has been developed for agricultural or urban use,
4 including much of the native shrub-steppe and grassland habitat (Figure 2.2-4) (WDFW, 2005),
5 (WDNR, 2007). Conversion of land for dryland wheat and other crops has resulted in the
6 isolation and fragmentation of shrub-steppe habitat, as well as the decline of many shrub-steppe
7 dependant species, including the greater sage-grouse (*Centrocercus urophasianus*)
8 (WDFW, 2005), (WDNR, 2007), (WDNR, 2009). The State of Washington currently considers
9 shrub-steppe habitat a Priority 1 ecosystem for conservation. A Priority 1 ecosystem is defined
10 as an ecosystem with few known occurrences in the natural areas system, the extent of which
11 has been greatly reduced (WDNR, 2007), (WDNR, 2009). These ecosystems are considered to
12 be at the highest risk of being destroyed or degraded (WDNR, 2007). Because of the Hanford
13 Site's protected status following the establishment of the Manhattan Project in 1943, its resident
14 plant and animal populations are largely made up of native species and retain shrub-steppe
15 characteristics that have mostly disappeared in other areas of the ecoregion. Undisturbed
16 portions of the Hanford Site are dominated by shrubland, with widely dispersed sagebrush
17 communities (*Artemisia tridentata*) and an understory of grasses. Of the 727 vascular plant
18 species noted on the Hanford Site, approximately 25 percent (179) were found to be non-native
19 (EN, 2003b).




Figure 2.2-4. Distribution of shrub-steppe (shaded area) ecosystem in Washington

(Johnson and O'Neil, 2001)

1 A narrow portion of the CGS riparian area lies within the 305 mi² (79,000 ha) Hanford Reach
 2 National Monument (Figure 2.1-2). The Hanford Reach National Monument is a national wildlife
 3 refuge that was created in 2000 by a Presidential proclamation and is managed by the U.S. Fish
 4 and Wildlife Service (USFWS) (Clinton, 2000), (USFWS, 2008). Because Hanford Reach
 5 National Monument was created from buffer lands on the protected Hanford Site, the
 6 shrub-steppe habitat has remained undisturbed for 60 years, preserving important biological,
 7 historic, and cultural resources (USFWS, 2008), (USFWS, 2010a).

8 The habitat found on the CGS property is generally similar to that of the Hanford Site, with
 9 undisturbed areas of the site supporting a similar mix of grasses, forbs, and shrubs. The
 10 uplands area of the CGS site is also dominated by dune formations that consist of sand and
 11 gravel soils (Link, 2008). Studies done on the CGS site found 66 vascular plant species on the
 12 property and found that herbaceous cover by all grasses and forbs onsite was about 66 percent
 13 (EN, 2010). Annual grasses dominate the herbaceous ground cover at about 35 percent, with
 14 cheatgrass (*Bromus tectorum*) being the dominant annual grass. Cheatgrass is non-native and
 15 typically found on disturbed areas. Perennial grasses comprised about 17 percent of the
 16 herbaceous cover, with Sandberg bluegrass (*Poa secunda*) as the dominant grass. Commonly
 17 occurring plant cover associations on the property include Sandberg bluegrass/snow buckwheat
 18 (*P. secunda/Eriogonum niveum*) and Sandberg bluegrass/needle-and-thread grass (*P.*
 19 *secunda/Hesperostipa comata*) (EN, 2003b).

20 The dominant shrubs on the CGS site are big sagebrush (*Artemisia tridentata*) and bitterbrush
 21 (*Purshia tridentata*). Shrub cover on both the Hanford and CGS sites has been greatly affected
 22 by range fires. An August 1984 range fire covered about 310 mi² and burned much of the
 23 sagebrush and bitterbrush cover on the CGS property, causing the amount of shrub cover found
 24 at the study plots to drop from 15 percent to 2 percent (EN, 2003b), (EN, 2010).

25 Generally, soil moisture levels in this habitat are insufficient to support most tree species except
 26 along the stream banks, so most of the tree species found on the Hanford Site are found in the
 27 riparian zone along the bank of the Columbia River (EN, 2003b). The Hanford Site supports 23
 28 species of trees including cottonwood (*Populus* spp.), willow (*Salix* spp.), white mulberry (*Morus*
 29 *alba*), black locust (*Robinia pseudoacacia*), Russian olive (*Elaeagnus angustifolia*), and Siberian
 30 elm (*Ulmus pumila*). The tree species found specifically on the CGS site were found within a
 31 narrow 1.2 mi (2 km) stretch of the riparian zone along the bank of the Columbia River and
 32 include black cottonwood (*Populus balsamifera*), narrowleaf willow (*Salix exigua*), Siberian elm
 33 (*Ulmus pumila*), and Rocky Mountain juniper (*Juniperus scopulorum*) (Link, 2008).

34 Shrub-steppe ecosystems are threatened by invasive species that can survive disturbances
 35 such as agriculture, grazing, and wildfires. One of the most problematic species in this
 36 ecoregion is cheatgrass, which has little value for wildlife populations and can pose an
 37 additional fire hazard that could be damaging to native vegetation (WDFW, 2005). Cheatgrass
 38 is the dominant annual grass found on the CGS site. Plant surveys found six additional invasive
 39 weed species, the most abundant of which were diffuse knapweed (*Centaurea diffusa*), rush
 40 skeletonweed (*Chondrilla juncea*), and Dalmation toadflax (*Linaria dalmatica*). CGS has
 41 developed a noxious weed control program with the primary goal of containment to prevent the
 42 spread of these invasive weeds to uninfested areas (EN, 2010), (Link, 2009). In addition to
 43 these, the Hanford riparian area has many noxious weeds common to dryland habitat, including
 44 purple loosestrife (*Lythrum salicaria*), smallflower tamarisk (*Tamarix parviflora*), and yellow
 45 star-thistle (*Centaurea solstitialis*). Range fires occurring in 1984 and 2000 created favorable
 46 conditions for the growth of invasive species such as Russian thistle (*Salsola tragus*) and tall
 47 tumbled mustard (*Sisymbrium altissimum*) (EN, 2003b), (WDFW, 2005).

Affected Environment

1 The USFWS National Wetlands Inventory database shows no wetlands areas on the CGS site
2 (USFWS, 2010c).

3 More than 300 terrestrial vertebrate species have been found on the Hanford Site. This number
4 includes 145 bird species, 46 mammal species, 5 amphibian species, and 10 reptile species
5 (EN, 2010). The Hanford Reach is also within the Pacific Flyway, serving as a resting area for
6 species of migrant birds, migratory waterfowl, and shorebirds. According to CGS site studies
7 done from 1981–1987, the most-sighted birds (out of the 25 species sighted), in descending
8 order, were the western meadowlark (*Sturnella neglecta*), red-winged blackbird (*Agelaius*
9 *phoeniceus*), bank swallow (*Riparia riparia*), brown-headed cowbird (*Molothrus ater*), eastern
10 kingbird (*Tyrannus tyrannus*), California gull (*Larus californicus*), Bullock's oriole (*Icterus*
11 *bullockii*), killdeer (*Charadrius vociferus*), western kingbird (*Tyrannus verticalis*), and barn
12 swallow (*Hirundo rustica*) (EN, 2009), (EN, 2010). Most of the shorebirds and waterfowl that
13 have been sighted on CGS property during the past decade have been seen at the sanitary
14 waste treatment plant, where the sanitary waste ponds supply resting and feeding habitat as
15 well as limited breeding habitat for some species. Typical sightings include broods of mallard
16 ducks (*Anas platyrhynchos*), Brewer's blackbird (*Euphagus cyanocephalus*), killdeer, American
17 avocet (*Recurvirostra americana*), black-necked stilt (*Himantopus mexicanus*), and other
18 waterbirds. There are 19 islands along the Columbia River within the Hanford Site. A
19 1.25 mi-long island located opposite the CGS makeup water pumphouse, named Homestead
20 Island, has been used as a roosting area by sandhill cranes (*Grus canadensis*) (EN, 2010).

21 Generally, there are few reported bird strikes on CGS property, with no bird strikes observed at
22 the meteorological tower, transmission line ROWs, or at the cooling towers. Most reported bird
23 strikes have occurred near the reactor building, where cliff swallows tend to nest under the
24 overhang (EN, 2010). CGS does have procedures in place for staff members who encounter
25 displaced or distressed birds on the property, with most incidents being recorded through the
26 corrective action program. Any bird injuries or deaths are also reported by the Environmental
27 Services staff to the USFWS or to the Washington Department of Wildlife (EN, 2010).

28 Mammals common to the CGS property include mule deer (*Odocoileus hemionus*), coyote
29 (*Canis latrans*), cottontail rabbit (*Sylvilagus nuttalli*), and black-tailed jackrabbit (*Lepus*
30 *californicus*) (EN, 2010), (WPPSS, 1988). The American badger (*Taxidea taxus*) and porcupine
31 (*Erethizon dorsatum*) have been found onsite but are rarely seen. The most common reptile
32 seen on the property is the Pacific gophersnake (*Pituophis catenifer*) (WPPSS, 1988). Hanford
33 Reach management plans also protect the sand dune habitat dominated by antelope bitterbrush
34 (*Purshia tridentate*) and Indian ricegrass (*Oryzopsis hymenoides*), which provide habitat for
35 mule deer, burrowing owls, and coyotes (USFWS, 2008).

36 CGS has several procedures for protecting the environment, including environmental review
37 checklists and environmental evaluation forms. If the environmental review checklist reveals
38 that a planned activity could disturb vegetation or wildlife habitat, then an environmental
39 evaluation must also be completed. Environmental evaluation forms require a qualified subject
40 matter expert to describe and assess the potential for adverse impacts on endangered or
41 threatened species or critical habitat and to discuss potential avoidance or mitigation options.

42 **2.2.7 Important Species and Habitats**

43 As delegated by the Endangered Species Act (ESA) (16 USC 1531), the National Marine
44 Fisheries Service (NMFS) and the USFWS are responsible for listing aquatic and terrestrial
45 species as threatened and endangered at the Federal level. The State may list additional
46 species that are regionally threatened or endangered. For the purposes of this SEIS, all

1 Federally and State-listed species that occur, or potentially occur, in Benton County, WA (the
 2 location of CGS site) are included in Table 2.2-5.

3 **Table 2.2-5. Listed aquatic and terrestrial species**

| Scientific name | Common name | Federal status ^(a) | State status ^(b) | Habitat |
|----------------------------------|---|-------------------------------|-----------------------------|--|
| Mammals | | | | |
| <i>Brachylagus idahoensis</i> | pygmy rabbit | FE | SE | Columbia Basin DPS |
| Birds | | | | |
| <i>Centrocercus urophasianus</i> | greater sage grouse | FC | ST | Columbia Basin DPS ^(c) |
| <i>Coccyzus americanus</i> | yellow-billed cuckoo | FC | SC | Deciduous woodlands |
| Plants | | | | |
| <i>Spiranthes diluvialis</i> | Ute ladies'-tresses | FT | - | River floodplains |
| <i>Eriogonum codium</i> | Umtanum desert buckwheat | FC | - | Basalt cliffs |
| Fish | | | | |
| <i>Oncorhynchus tshawytscha</i> | upper Columbia River spring Chinook salmon | FE | SC | Anadromous; spawn in small tributaries; migrate through major rivers |
| <i>Oncorhynchus mykiss</i> | upper Columbia River steelhead | FE | SC | Anadromous; mainstem Columbia River |
| <i>Salvelinus confluentus</i> | bull trout | FT | SC | Anadromous; rivers |
| <i>Catostomus platyrhynchus</i> | mountain sucker | - | SC | Tributaries of the Columbia River |
| <i>Lampetra ayresii</i> | river lamprey | - | SC | Anadromous; spawn in small tributaries; migrate through major rivers |
| <i>Rhinichthys flacatus</i> | leopard dace | - | SC | Rivers |
| <i>Rhinichthys umatilla</i> | Umatilla dace | - | SC | Rivers |
| Mollusks | | | | |
| <i>Anodonta californiensis</i> | California floater | - | SC | Shallow, muddy or sandy substrate in rivers |
| <i>Fluminicola columbiana</i> | great Columbia River spire snail (Columbia pebblesnail) | - | SC | River substrate |

Sources: Poston, et al., 2009; Suzumoto, 2010; USFWS, 2010a; USFWS, 2010b; WDFW, 2010a.

^(a) Federal status listings: FE = Federally Endangered; FT = Federally Threatened; FC= Federal Candidate.

^(b) State of Washington status listings: SE = State Endangered; ST = State Threatened; SC = State Candidate.

^(c) DPS—Distinct Population Segment.

4 In addition, NMFS is responsible for protection, management, and enhancement of the nation's
 5 marine fishery resources as designated by the Magnuson-Stevens Fishery Conservation and
 6 Management Act of 1976, as amended (16 USC 1801 et seq.). The Hanford Reach of the
 7 Columbia River supplies habitat for designated species that are associated with essential fish
 8 habitat (EFH) (73 FR 60987), (Suzumoto, 2010).

1 Further information about the consultation between NMFS, USFWS, and NRC is found in the
2 integrated biological assessment and EFH assessment given in Appendix D-1 to this SEIS.

3 **2.2.7.1 Federally and State-Listed Threatened and Endangered Terrestrial Species**

4 There is no designated critical habitat for Federally-listed threatened and endangered terrestrial
5 species near the CGS site, including the transmission corridor, and there are no Federally-listed
6 or State-listed endangered or threatened mammals, reptiles, amphibians, or invertebrates on
7 the Hanford or CGS site. The State of Washington, however, has designated shrub-steppe
8 environments of the Columbia Plateau ecoregion as priority habitats for preservation
9 (WDNR, 2007).

10 The pygmy rabbit (*Brachylagus idahoensis*) in the Columbia Basin is Federally-listed and
11 State-listed as endangered but has never been observed on the Hanford Site. The Columbia
12 Basin pygmy rabbit population has been extirpated from the wild (WDNR, 2009).

13 There are no Federally-listed threatened or endangered bird species found on the Hanford Site
14 or the CGS site. The yellow-billed cuckoo (*Coccyzus americanus*) is a candidate species for
15 Federal listing and has been noted by the USFWS as occurring in Benton County. However,
16 there have been no known sightings of the yellow-billed cuckoo at CGS (USFWS, 2010d). The
17 greater sage grouse (*Centrocercus urophasianus*) is also a candidate species for Federal listing
18 and could be observed on the Hanford Site. Federal species of concern include the northern
19 goshawk (*Accipiter gentilis*), burrowing owl (*Athene cunicularia*), ferruginous hawk (*Buteo*
20 *regalis*), olive-sided flycatcher (*Contopus cooperi*), peregrine falcon (*Falco peregrinus*), and
21 loggerhead shrike (*Lanius ludovicianus*). The loggerhead shrike and the burrowing owl have
22 been sighted on, or near, the CGS site (EN, 2009).

23 There are no Federally-listed endangered or threatened plants on the Hanford Site or the CGS
24 property. While the Federally-listed threatened species Ute ladies'-tresses (*Spiranthes*
25 *diluvialis*) is known to occur in the Columbia Plateau ecoregion, it has never been observed as
26 far south as the CGS site (Fertig, et al., 2005). The Federal candidate species Umtanum desert
27 buckwheat (*Eriogonum codium*) is not known to occur on the CGS site, and its only known
28 population is found along approximately 1 mi of bluffs within the Hanford Reach National
29 Monument (USFWS, 2010e). The State-listed threatened species lowland toothcup (*Rotala*
30 *ramosior*) and the watch list species shining flatsedge (*Cyperus bipartitus*) were found during
31 surveys of the Columbia shoreline, about 0.5 mi (0.8 km) downstream of the CGS property. The
32 survey also found the State watch list species Columbia River mugwort (*Artemisia lindleyana*)
33 (Link, 2008).

34 There are two State-listed endangered birds that migrate through the area—the American white
35 pelican (*Pelecanus erythrorhynchos*) and the sandhill crane (*Grus canadensis*). Both species
36 have been seen on Homestead Island (EN, 2010b). Threatened bird species that may occur on
37 the Hanford Site include the ferruginous hawk (*Buteo regalis*) and the greater sage grouse
38 (*Centrocercus urophasianus*). Bird species considered sensitive by Washington State are the
39 common loon (*Gavia immer*), peregrine falcon (*Falco peregrinus*), and bald eagle (*Haliaeetus*
40 *leucocephalus*). Both the ferruginous hawk and common loon have been observed on, or near,
41 the CGS site (EN, 2009). The peregrine falcon was once a Federally-listed species, but it was
42 delisted in 1999. The bald eagle was likewise a listed species, but it was delisted in 2007. Both
43 the peregrine falcon and the bald eagle are protected under the Migratory Bird Treaty Act, and
44 the bald eagle is also protected under the Bald and Golden Eagle Protection Act. A location on
45 the river shore about 1.25 mi (2 km) south of the plant makeup water pumphouse has been

1 noted in surveys as a site occupied by bald eagles (EN, 2010b). This site, however, is outside
2 of the CGS leased land.

3 Upland area vegetation surveys of the CGS property found a small population of the State
4 watch list species woodypod milkvetch (*Astragalus sclerocarpus*) and two plants of the State
5 sensitive species Piper's daisy (*Erigeron piperianus*) (Link, 2009).

6 **2.2.7.2 Federally and State-Listed Threatened and Endangered Aquatic Species**

7 Table 2.2-5 presents aquatic species that are listed as protected by the USFWS, NMFS, and
8 the State of Washington and have the potential to occur in the counties near the CGS site.
9 Federally-listed species include the endangered upper Columbia River spring-run Chinook
10 salmon, the endangered upper Columbia River steelhead, and the threatened bull trout. The
11 State of Washington lists these three species, and four additional fish species, as candidate
12 species. Mountain sucker (*Catostomus platyrhynchus*), river lamprey (*Lampetra ayresii*),
13 leopard dace (*Rhinichthys flacatus*), and Umatilla dace (*R. umatilla*) are the additional State
14 candidate species. Two species of mollusks are listed by the State as candidate species,
15 including the California floater (*Anodonta californiensis*) and the great Columbia River spire snail
16 (also known as the Columbia pebblesnail; *Fluminicola columbiana*).

17 Federally-Listed Species. The following sections discuss the Federally-listed threatened and
18 endangered aquatic species.

19 Upper Columbia River Spring-Run Chinook Salmon. NMFS listed the upper Columbia River
20 spring-run Chinook salmon as an endangered species in 1999 and reaffirmed this status in
21 2005. NMFS designated all naturally spawned populations of Chinook salmon in all river
22 reaches accessible to Chinook salmon in Columbia River tributaries upstream of the Rock
23 Island Dam and downstream of Chief Joseph Dam, excluding the Okanogan River, as being
24 within the Evolutionary Significant Unit (ESU) for the species (64 FR 14308; 70 FR 37160). This
25 ESU contains the only remaining genetic resources of those spring-run Chinook salmon that
26 migrate into the upper Columbia River Basin, and those salmon are distinct from other
27 stream-type Chinook salmon ESUs (64 FR 14308). That is, the spring-run populations are
28 genetically and ecologically separate from the summer- and fall-run populations of Chinook. In
29 addition, the upper Columbia River spring-run Chinook have different spawning and rearing
30 habitat preferences from the spring-run Chinook in the Snake and John Day River Basins
31 (NMFS, 2004). Critical habitat for the spring-run Chinook took effect in 2006 and includes the
32 habitat areas within the lower Methow River, Lake Entiat, Icicle/Chumstick, and Lower
33 Wenatchee Rivers (70 FR 52630).

34 As discussed in Section 2.2.5, Chinook salmon have characteristics specific to the location of
35 their spawning areas and the time they spend in the river. It is an important ecological species
36 because their lifecycle integrates across the aquatic ecosystem of the Columbia River Basin.
37 Adults return to spawning areas where they were born and build redds in the river substrate. A
38 female may deposit up to 5,000 eggs. Many of these eggs become food to other fish and
39 invertebrates. Spawned-out adults become easy prey for bald eagles and other predators.
40 Dead salmon that decompose in the river return essential nutrients to the aquatic ecosystem. In
41 addition, predation on the live fish by birds and mammals also transfers nutrients to the
42 terrestrial ecosystem. Juveniles forage on zooplankton and macroinvertebrates as they migrate
43 through the Columbia River Basin, and other fish—as well as birds and mammals—prey upon
44 them (Dauble, 2009).

Affected Environment

1 Chinook salmon has been an important species for the Native Americans as well as other
2 people in the Columbia River Basin. Commercial canning of salmon in the lower Columbia
3 River came to a peak in the 1880s when the catch was more than 40 million lb. By the 1890s,
4 hatcheries were releasing salmon to replenish the declining spring-runs (Dauble, 2009). The
5 construction of Grand Coulee Dam, which started in 1938, blocked the spring-run salmon from
6 fish habitat above Columbia RM 596.6. The Grand Coulee Fish Maintenance Project from
7 1939–1943 homogenized the stocks of Chinook across the currently designated ESU for the
8 spring-run and influenced the present-day loss of genetic diversity. Subsequent construction of
9 numerous dams and other projects on the mainstem Columbia River also contributed to the
10 obstacles for recovery of the upper Columbia River spring-run Chinook salmon (NMFS, 2004).

11 Upper Columbia River spring-run Chinook salmon have a stream-type life history where the
12 juveniles spend 1–2 years in freshwater before migrating to the Pacific Ocean. The adults are
13 the first of the Chinook salmon to enter the estuary in a new year, travel through the mainstem
14 Columbia River past the Hanford Reach, and arrive in the higher elevation tributaries by
15 mid-June. The female spring-run Chinook select a nesting area in gravels similar to that
16 discussed previously for fall-run Chinook. Peak spawning for all populations of upper Columbia
17 River spring-run Chinook occurs from August–September. The juveniles use the Hanford
18 Reach as a nursery area while they migrate downstream toward the ocean (Duncan, et
19 al., 2007). At first, the diet of juveniles consists of midge larvae and zooplankton, then the
20 juveniles switch eating to adult caddisflies and terrestrial insects. The movement of a juvenile
21 through the Hanford Reach lasts no more than 1 week; outmigration of the juvenile spring-run
22 Chinook extends from April to the end of August (DOE, 2000). As the young-of-year migrate to
23 the mainstem Columbia, they are surface-oriented; however, they may migrate at deeper depths
24 in the Hanford Reach (Dauble, 2009), (NMFS, 2004). Adult Chinook salmon returning from the
25 ocean to spawn in the rivers stop feeding entirely after they pass through the estuaries (Higgs,
26 et al., 1995).

27 The main consideration for NMFS when listing the upper Columbia River spring-run Chinook
28 salmon as an endangered species is the concern that the species was at risk of becoming
29 extinct in the foreseeable future (64 FR 14308). NMFS has been developing a series of
30 Biological Opinions to address the restoration of the species from the operation of the FCRPS.
31 FCRPS consists of 31 Federally owned and operated (U.S. Army Corps of Engineers and the
32 Bureau of Reclamation) hydro projects in the Columbia and Snake Rivers. BPA markets and
33 distributes the power generated by these dams and the CGS (BPA, 2010). In addition, NMFS
34 has prepared Biological Opinions for the relicensing of the five dams on the Columbia River that
35 are owned and operated by public utilities including Priest Rapids Dam, which is owned and
36 operated by Public Utility District of Grant County (NMFS, 2004).

37 The actions covered by the NMFS' Biological Opinions for the upper Columbia River spring-run
38 Chinook salmon range from modification of the dams to habitat improvements in areas away
39 from the dams. NMFS characterizes the program that is responsible for carrying out the
40 Biological Opinion as being a "large and complicated program that is commensurate with the
41 scale of the FCRPS and its impact on the listed species and critical habitat." The program calls
42 for "increasing survival rates of fish passing through the dams; managing water to improve fish
43 survival, reducing the numbers of juvenile and adult fish consumed by fish, avian, and marine
44 mammal predators; improving juvenile and adult fish survival by protecting and enhancing
45 tributary and estuary habitat; implementing safety net and conservation hatchery programs to
46 assist recovery; and ensuring that hatchery operations do not impede recovery" (NMFS, 2010).

1 A recent review of the NMFS 2008 Biological Opinion for the FCRPS included evaluation of the
2 status of the upper Columbia River spring-run Chinook salmon and additional actions to build on
3 the 2008 Biological Opinion. The evaluation of new information collected across the critical
4 habitat for spring-run Chinook salmon shows that the aggregate populations of the species have
5 been stable or increasing over the last decade. These results suggest that the actions noted in
6 the Reasonable and Prudent Alternative may be working and are encouraging for the new
7 Adaptive Management Implementation Plan.

8 Upper Columbia River Steelhead. The listing of the upper Columbia River steelhead has
9 changed many times since 1997, and NMFS presently lists the upper Columbia River steelhead
10 as endangered (August 24, 2009; 74 FR 42605). The listing is now defined as the “Distinct
11 Population Segment (DPS) including all naturally spawned anadromous steelhead populations
12 below natural and manmade impassable barriers in streams in the Columbia River Basin,
13 upstream from the Yakima River, WA, to the U.S.-Canada border” (74 FR 42605). The
14 steelhead associated with six artificial propagation programs are also part of the listing,
15 including the Wenatchee River, Wells Hatchery (in the Methow and Okanogan rivers), Winthrop
16 National Fish Hatchery, Omak Creek, and the Ringold steelhead hatchery programs (74 FR
17 42605). Critical habitat for the upper Columbia River steelhead was designated on September
18 2, 2005 (70 FR 52630).

19 Steelhead are the anadromous form of rainbow trout, and both forms can coexist in the same
20 river system. The species has long been important to the people of the region for food,
21 recreation, and commercial activities—similar to Chinook salmon. In addition, like the Chinook,
22 the steelhead in the Columbia River Basin have experienced the same pressures on their
23 habitat, resulting in a decline of the species (Dauble, 2009), (NMFS, 2004).

24 Adult steelhead return to migrate up the Columbia River during most months of the year, with
25 peak runs occurring during the late summer months. The length and weight of steelhead varies
26 with the distinct runs upstream, and the larger, later runs include steelhead that have remained
27 in the ocean for 2 years. Although adult steelhead begin to move into the spawning streams
28 September–February, they do not spawn until the following spring (Dauble, 2009). Spawning in
29 the Hanford Reach appears to occur between February and early June, with a peak in mid-May
30 (Mueller and Geist, 1999). They construct their redds in gravel substrate in moderate velocity
31 waters. The construction of the redds is later in the season than other salmon (e.g., fall-run
32 Chinook), and scientists can distinguish the steelhead redds with aerial surveys. The eggs
33 incubate in the gravel for 2–3 months before hatching. Eggs that do not settle in the redds
34 prepared by the adults are often consumed by other fish waiting downstream during spawning.
35 As steelhead fry emerge from the river substrate and start to feed, they are about 1-in (2.5-cm)
36 long and vulnerable to predation, so they seek cover. Juveniles rear in tributary streams for
37 usually 2 years before migrating to the ocean. If they remain in freshwater for their entire life,
38 they are considered rainbow trout (Dauble, 2009).

39 Juvenile steelhead behave differently in the Hanford Reach than they do in the slower moving
40 reservoirs of the Columbia River. They move through the area near the CGS site in the deepest
41 part of the river, although they tend to stay towards the surface when they are migrating through
42 areas behind a dam. Most of the migration is at night, and the juvenile steelhead rest and feed
43 near the shore during the day (Dauble, 2009). Hatchery programs, including the Ringold Facility
44 upstream of the CGS site, augment the natural spawning efforts in the mainstem Columbia
45 River (NMFS, 2004).

Affected Environment

1 Identification of steelhead redds is difficult because of high, turbid spring runoff that obscures
2 visibility (DOE, 2000). Aerial surveys, boat-deployed video, and digging in the gravels are
3 methods used to confirm the existence of steelhead redds in the Hanford Reach. However,
4 known areas where steelhead have prepared redds are shown in Figure 2.2-3. Some of the
5 identified redds are near the intake and discharge structures for the CGS plant. The redds
6 found near the CGS site include the area upstream of the CGS intake structure between Islands
7 12 and 13 (Columbia RM 352), and another downstream near Island 15 (Columbia RM 349).
8 Two steelhead redds were discovered in 2003 below CGS, prompting the establishment of a
9 monitoring effort by the DOE to locate any steelhead redds in the Hanford Reach. Aerial
10 surveys found 2 regions having characteristics associated with steelhead redds, including the
11 area upstream of the CGS intake structure between Islands 12 and 13 (Columbia RM 352), and
12 another downstream near Island 15 (Columbia RM 349). Using a boat-deployed video camera,
13 4 redds were observed in 2005 near Island 15, but there was no indication of spawning activity;
14 no redds were found around Islands 12 and 13 (Hanf, et al., 2006). From 2006–2008, the aerial
15 surveys have not found any evidence of steelhead spawning near the CGS intake and
16 discharge structure (Duncan, et al., 2008), (Hanf, et al., 2006), (Hanf, et al., 2007), (Poston, et
17 al., 2009).

18 Upper Columbia River steelhead are included in the Biological Opinions for the recovery of the
19 species associated with the operation of the dams on the Columbia and Snake Rivers, as
20 discussed above for upper Columbia River spring-run Chinook salmon. Steelhead recovery in
21 the upper Columbia River ESU is included in the same plans and programs for the spring-run
22 Chinook (NMFS, 2010).

23 *Bull Trout*. USFWS listed the coterminous population of bull trout as a threatened species in
24 1999 (64 FR 58910). On October 6, 2004, the USFWS finalized the critical habitat designation
25 for the Columbia River bull trout population (69 FR 59995). On January 14, 2010, the USFWS
26 published a proposed revised critical habitat rule (75 FR 2270) that included the entire Columbia
27 River as critical habitat for the bull trout. The revised designation became effective on
28 November 17, 2010 (75 FR 63898). The CGS site occurs in the Mid-Columbia recovery unit.
29 The decline of bull trout has been characterized as being primarily due to habitat degradation
30 and fragmentation, blockage of migratory corridors, poor water quality, past fisheries
31 management practices, impoundments, dams, water diversions, and the introduction of
32 non-native species (64 FR 58910; 75 FR 2270). Recovery plans for the species across the
33 critical habitat include reducing threats to bull trout and their habitat, ensuring corridors for
34 interaction of populations of bull trout, and increasing habitat improvements for all life stages of
35 the trout (75 FR 2270).

36 The species needs cold water to survive, and they prefer water temperatures that do not exceed
37 59–64 degrees F (15–18 degrees C). Bull trout “require stable stream channels, clean
38 spawning and rearing gravel, complex and diverse cover, and unblocked migratory corridors”
39 (USFWS, 2010f). They have more specific habitat requirements than most other salmonids
40 (75 FR 2270). Bull trout can be resident or anadromous, and both forms can coexist and
41 reproduce with each other. Unlike Chinook salmon, bull trout can spawn multiple times over
42 their lifetime. They typically spawn from August–November during periods of declining water
43 temperature. The diet of resident and juvenile bull trout consists of invertebrates and small fish.
44 Anadromous bull trout primarily consume fish. Resident bull trout are smaller, up to 10-in.
45 (25-cm) long, than migratory trout, which are up to 35-in. (89-cm) long and up to 32 lb (14 kg)
46 (USFWS, 2010f).

1 Water temperature affects the life stages of bull trout more than other species. They seek
2 colder water for their redds, often in areas with groundwater inflow that have an optimum
3 incubation temperature from 35–39 degrees F (1.7–3.9 degrees C). The water temperature for
4 rearing young is a little warmer, with an optimum temperature of 46–49 degrees F (7.8–9.4
5 degrees C). Bull trout preferences for varying water temperatures over their life cycle affects
6 their distribution and their potential for recovery in the Columbia River Basin (USFWS, 2007).

7 Gray and Dauble (1977) reported bull trout in the Hanford Reach, but the location of the
8 collection was unclear. The water temperatures and habitat in the Hanford Reach are not ideal
9 for spawning, and there are no reports of spawning activity by bull trout near CGS
10 (Dauble, 2009), (USFWS, 2007). Resource scientists at DOE's Hanford Site have
11 characterized the use of the Hanford Reach by bull trout as transient (Poston, et al., 2009).

12 State Protected Aquatic Species. Near the CGS site, the State of Washington lists as candidate
13 species the three Federally-listed species mentioned above. It also lists four additional fish
14 species—the mountain sucker, river lamprey, leopard dace, and Umatilla dace. The State of
15 Washington includes two mollusks—the California floater and the great Columbia River spire
16 snail.

17 From 1973–1975, surveys in the Hanford Reach collected mountain suckers 3–9 mi (5–14 km)
18 above the CGS intake (Gray and Dauble, 1977). This species is smaller than, and not as
19 common as, other sucker species within the Hanford Reach. Typically, they are restricted to
20 tributaries of the Columbia River at higher elevations than the CGS site. They are broadcast
21 spawners with adhesive eggs that settle on the substrate in their preferred riffles of swift running
22 streams. Mountain suckers are listed as a species of concern because their status in
23 Washington State is unknown (Dauble, 2009).

24 Documentation of the distribution and status of the river lamprey near the CGS site and the
25 Columbia River Basin is poor (Dauble, 2009). Historic fish collections in the Hanford Reach
26 include the river lamprey, but the location where the fish were observed is unknown (Gray and
27 Dauble, 1977). Adult river lamprey have an elongated body, 5–11 in. (12–29 cm) long; eel-like
28 fins; and a sucker with teeth (McCloy, 2005). Little is known about the life history of river
29 lamprey (69 FR 77158); however, they are anadromous spending approximately 10 weeks at
30 sea. It has been suggested that the adults return to the Columbia River Basin from the ocean
31 likely in early autumn to hold over and spawn in April and May (Bond, et al., 1983). The larvae,
32 or ammocoetes, burrow into the sediment and filter feed on algae and microscopic organisms.
33 Before migrating back to the ocean, the larvae metamorphose into adults (McClory and
34 Gotthardt, 2005). Because river lamprey remove portions of flesh from their prey, it has been
35 suggested that this species should be considered predatory rather than parasitic (Dauble,
36 2009), (Wydoski and Whitney, 2003).

37 Leopard dace are also listed as species of concern because their status in the Washington
38 State is unknown. From 1973–1975, surveys in the Hanford Reach collected leopard dace
39 more than 30 mi (48 km) above the CGS intake (Gray and Dauble, 1977), but the species is
40 probably only an occasional visitor in the Mid-Columbia region (Dauble, 2009). Adults are
41 small, around 4 in. (10 cm) long, and they are mostly bottom-dwelling fish that consume aquatic
42 insect larvae, zooplankton, and algae. They are broadcast spawners with adhesive eggs.
43 Other, larger fish often consume leopard dace (Dauble, 2009).

44 The Umatilla dace had previously been considered to be a variant of the leopard dace because
45 of the morphological similarity in the two species (Wydoski and Whitney, 2003). The first
46 specimens described were from the Columbia River channel below McNary dam (first dam

Affected Environment

1 downstream of the Columbia Reach) near Umatilla, OR. They have a “spotty distribution” within
2 the Columbia River Basin. They have been reported from tributaries of the Columbia up into
3 British Columbia. They are similar to the leopard dace in their habitat choices and, likely, their
4 food selection. They are considered a bottom-dwelling fish that prefers clean substrate of rock,
5 boulders, and cobble and are located in areas where the water velocity is strong enough to
6 prevent siltation. They are thought to spawn in early to mid-July in Washington State. (Wydoski
7 and Whitney, 2003).

8 The California floater has been collected in the Hanford Reach in the 1970s, 1980s, and as
9 recently as 2003–2004 (Hanf, et al., 2005), (TNC, 2003), (WPPSS, 1986). This mussel has a
10 long—up to 5 in. (13 cm)—elliptical shell with a dark exterior and white interior. They prefer
11 shallow muddy, silty, or sandy habitats in large rivers, reservoirs, and lakes. Like other mussel
12 species, the larval form, called glochidia, develop as parasites in fish hosts. Native minnow
13 species and introduced western mosquito fish are thought to be the host fish for these mussels.
14 The main reasons cited for the decline of California floaters include severe water fluctuations
15 due to hydroelectric dam operation and competition with introduced mollusks (e.g., Asian clams)
16 and other species that may compete with their host fish or eat young mussels (e.g., common
17 carp) (Nedeau, et al., 2009).

18 The great Columbia River spire snail was collected in the Hanford Reach during surveys from
19 the 1970s–1990s, but no snails were collected during the most recent surveys in 2003 and 2004
20 (Hanf, et al., 2005), (TNC, 2003), (WPPSS, 1986), (WPPSS, 1987). The snails have relatively
21 small shells (0.28–0.44 in. (7.0–11.2 mm)) that are opaque and pinkish with 4–4.5 whorls
22 (Hershler and Frest, 1996). The snails are bottom dwellers and scrape periphyton off the rock
23 substrate. The decline of the great Columbia River spire snail may be associated with
24 groundwater contaminants entering the river substrate where they live, increased competition
25 with introduced species, and predation pressures (Hanf, et al., 2005).

26 **2.2.7.3 Essential Fish Habitat**

27 The NMFS noted upper Columbia River Chinook salmon (spring-, summer-, and fall-runs) and
28 coho salmon as species that have EFH (Suzumoto, 2010). A separate EFH Assessment,
29 enclosed as Appendix D-1 in this SEIS, addresses additional consultation between the NMFS
30 and the NRC concerning essential habitat near the CGS site.

31 **2.2.8 Socioeconomic Factors**

32 This section describes current socioeconomic factors that have the potential to be directly or
33 indirectly affected by changes in operations at CGS. CGS, and the communities that support it,
34 can be described as a dynamic socioeconomic system. The communities supply the people,
35 goods, and services required to operate the nuclear power plant. Power plant operations, in
36 turn, supply wages and benefits for people and dollar expenditures for goods and services. The
37 measure of a communities’ ability to support CGS operations depends on their ability of the
38 community to respond to changing environmental, social, economic, and demographic
39 conditions.

40 The socioeconomic region of influence (ROI) is defined by the areas where CGS employees
41 and their families reside, spend their income, and use their benefits, thus affecting the economic
42 conditions of the region. The CGS ROI consists of a two-county area (Benton and Franklin
43 counties) and the Tri-Cities area, where approximately 95 percent of CGS employees reside.

1 CGS employs a permanent workforce of approximately 1,145 employees (EN, 2010b).
 2 Approximately 97 percent live in Benton and Franklin County (Table 2.2-6). Most of the
 3 remaining 3 percent of the workforce are divided among 6 counties in Washington and Oregon,
 4 with numbers ranging from 1–9 employees per county. Given the residential locations of CGS
 5 employees, the most significant effects of plant operations are likely to occur in Benton and
 6 Franklin County. The focus of the socioeconomic impact analysis in this SEIS is, therefore, on
 7 the impacts of continued CGS operations on these two counties.

8 **Table 2.2-6. CGS, employee residence by county**

| County | Number of employees | Percentage of total |
|--------------|---------------------|---------------------|
| Benton | 942 | 83 |
| Franklin | 165 | 14 |
| Other | 38 | 3 |
| Total | 1,145 | 100 |

Source: EN, 2010b.

9 Refueling outages at the CGS normally occur at 24-month intervals. During refueling outages,
 10 site employment increases by as many as 1,100–1,500 temporary workers for approximately
 11 35–45 days (EN, 2010b). Most of these workers are assumed to be located in the same
 12 geographic areas as CGS employees. The following sections describe the housing, public
 13 services, offsite land use, visual aesthetics and noise, population demography, and the
 14 economy in the ROI surrounding CGS.

15 **2.2.8.1 Housing**

16 Table 2.2-7 lists the total number of occupied and vacant housing units, vacancy rates, and
 17 median value in the two-county ROI. According to the 2000 Census, there were approximately
 18 72,000 housing units in the socioeconomic region, of which approximately 67,700 were
 19 occupied. The median values of owner-occupied housing units in Benton and Franklin counties
 20 were \$119,900 and \$102,000, respectively. The vacancy rate was the lower in Benton County
 21 (5.5 percent). The vacancy rate in Franklin County was 7.7 percent (USCB, 2010).

22 **Table 2.2-7. Housing in Benton and Franklin County in Washington**

| | Benton | Franklin | ROI |
|-----------------------------------|---------|----------|---------|
| 2000 | | | |
| Total | 55,963 | 16,084 | 72,047 |
| Occupied housing units | 52,866 | 14,840 | 67,706 |
| Vacant units | 3,097 | 1,244 | 4,341 |
| Vacancy rate (percent) | 5.5 | 7.7 | 6.0 |
| Median value (dollars) | 119,900 | 102,000 | 110,950 |
| 2006-2008, 3-year estimate | | | |
| Total | 63,307 | 22,239 | 85,546 |
| Occupied housing units | 58,013 | 20,332 | 78,345 |
| Vacant units | 5,294 | 1,907 | 7,201 |

Affected Environment

| | Benton | Franklin | ROI |
|------------------------|---------|----------|---------|
| Vacancy rate (percent) | 8.4 | 8.6 | 8.4 |
| Median value (dollars) | 162,600 | 141,100 | 151,850 |

Source: USCB, 2010.

1 By 2008, the estimated number of housing units grew in both counties. In Benton County, the
 2 number of housing units grew by more than 7,000 units to an estimated total of approximately
 3 63,000 units, or approximately 13 percent. The estimated total number of housing units
 4 increased by 38.3 percent in Franklin County (USCB, 2010).

5 **2.2.8.2 Public Services**

6 This section presents information regarding public services to include water supply, education,
 7 and transportation.

8 Water Supply. Kennewick and Richland (Benton County) and Pasco (Franklin County)
 9 comprise the Tri-Cities area, which is where 95 percent of workers at CGS reside. The
 10 discussion of public water supply systems is limited to major municipal water systems in these
 11 counties and cities. Information about municipal water suppliers in these counties, their
 12 permitted capacities and maximum design yields, reported annual peak usage, and population
 13 served are presented in Table 2.2-8. The source of potable water at the CGS is not tied into
 14 any Tri-Cities municipal water systems. Water from the Columbia River is treated onsite to
 15 supply the potable water needs at CGS.

16 **Table 2.2-8. Benton and Franklin Counties public water supply systems**
 17 **(in million gallons per day (mgd))**

| Water Supplier | Primary Water Source | Average Daily Demand (mgd) | System Capacity (mgd) | Population Served |
|------------------------|----------------------|----------------------------|-----------------------|-------------------|
| Benton County | | | | |
| Kennewick City | SW | 11 | 30.0 | 68,128 |
| Richland City | SW | 14.7 | 36.0 | 47,410 |
| Franklin County | | | | |
| City of Pasco | SW | 12 | 30.0 | 48,685 |

Surface Water = SW

Source: EPA, 2010c and TRIDEC, 2010.

18 The City of Kennewick draws its water from the Columbia River and two Ranney Collector wells,
 19 depending upon the time of the year. The water is treated at the Kennewick Water Treatment
 20 Plant before distribution in the water system. In 2009, about 59 percent of the annual water use
 21 was drawn from the Columbia River, and 41 percent of the annual water use was drawn from
 22 the Ranney wells (City of Kennewick, 2010). The Kennewick water system has excess capacity
 23 to meet its average daily water needs, with 36.7 percent use of its capacity. But, during peak
 24 use periods, it uses a significant portion of its capacity (80.7 percent) (TRIDEC, 2010).

25 The City of Pasco obtains all of their water from the Columbia River. The water is then
 26 processed in its treatment plant before distribution (City of Pasco, 2010). The Pasco water

1 system has excess capacity to meet its average daily use (40.0 percent) and peak use
 2 (73.3 percent) water needs (TRIDEC, 2010).

3 The City of Richland draws its water from the Columbia River and three groundwater wells (City
 4 of Richland, 2010). As with the City of Kennewick, withdrawals from each source vary
 5 depending upon the time of the year. The Richland water system has excess capacity to meet
 6 its average daily water needs, with 40.8 percent use of its capacity. But, during peak periods, it
 7 uses almost all of its capacity (94.4 percent) (TRIDEC, 2010).

8 Education. The Kennewick School District has 13 elementary schools, 4 middle schools, 3 high
 9 schools, 1 skills center, and 1 alternative school. During the 2009–2010 school year, enrollment
 10 was 15,234 students (Kennewick School District, 2010).

11 Pasco School District has 11 elementary schools, 3 middle schools, 2 high schools, and 1
 12 alternative middle and high school. The enrollment in 2009 was over 14,400 students (Pasco
 13 Public School District, 2010).

14 The Richland School District serves the cities of Richland and West Richland. The district has 8
 15 elementary schools, 3 middle schools, 2 high schools, 1 alternative middle school, and 1
 16 alternative high school. The enrollment in 2010 was 11,033 students (OSPI, 2010).

17 Transportation. The Tri-Cities area is located at the intersection of several major highways,
 18 including Interstate (I) 182/U.S. Highway (US) 12 and US-395. I-182/US-12 is a four-lane-
 19 divided highway that lies to the south of the Hanford Site and runs east and west. US-395 is
 20 also a four-lane-divided highway that lies 15 mi to the east of the Hanford Site, on the other side
 21 of the Columbia River, and runs north-south. State Route (SR) 240 runs southeast (from its
 22 junction with US-395) to the northwest. The northern part of SR-240 is a 2-lane highway, while
 23 the southern portion (Stevens Drive to Columbia Center Boulevard) is a 6-lane highway. SR-24
 24 also is a two-lane highway that lies on the northern part of the Hanford Site and traverses east
 25 and west.

26 Table 2.2-9 lists commuting routes to CGS and average annual daily traffic (AADT) volume
 27 values. The AADT values represent traffic volumes for a 24-hour period factored by both day of
 28 week and month of year.

29 **Table 2.2-9. Major commuting routes in the vicinity of Columbia Generating Station 2009**
 30 **average annual daily traffic count**

| Roadway and location | Average annual daily traffic (AADT) ^(a) |
|--|--|
| US-395 (south of Vineyard Drive in Pasco) | 14,597 |
| US-395 (at the Columbia River Bridge) | 55,742 ^(b) |
| I-182 (at the Columbia River Bridge in Pasco) | 53,828 |
| SR-240 (west of the Columbia Park Trail interchange in Richland) | 64,399 |
| SR-24 (at the Columbia River Bridge at Vernita) | 3,666 |

Source: WDOT, 2010.

^(a) All AADTs represent traffic volume during the average 24-hour day during 2009.

^(b) No data available for 2009 and 2008, 2007 AADT data is provided.

1 **2.2.8.3 Offsite Land Use**

2 Offsite land use conditions in Benton and Franklin County are described in this section. Of the
3 CGS permanent workforce, 95 percent of lives in these two counties. Land use in Benton and
4 Franklin County primarily consists of agriculture lands, with small urban areas. In addition, three
5 other counties (Grant, Walla Walla, and Yakima) receive tax payment revenue attributable to
6 CGS, although the estimated revenue is less than 1 percent of their general fund.

7 Benton County occupies approximately 1,700 mi² (4,400 square kilometers (km²))
8 (USCB, 2010). Agricultural land and the Hanford Site make up the majority of the land used,
9 with urban lands making up about 6 percent of the total county land area. The Hanford Site
10 contains large undisturbed areas of semi-arid shrub and grassland and localized industrial areas
11 that are principally supported by DOE funding. The principal agriculture land use outside of the
12 Hanford Site is commercial dry land and irrigated crop produce and livestock products, with the
13 market value of crops (mostly wheat for grain) being about nine times that of livestock, poultry,
14 and their products. The number of farms in Benton County increased about 4 percent from
15 1997–2007. Farmland acreage in the county decreased less than 1 percent during the same
16 period, and the average size of a farm decreased 4 percent to 388 ac (157 ha) (USDA
17 NASS, 2008), (USDA NASS, 2009).

18 Franklin County occupies approximately 1,240 mi² (3,200 km²) (USCB, 2010). Like Benton
19 County, Franklin County is primarily agricultural land; 85 percent of the county land area is
20 rangeland, with the largest urban area being Pasco at about 5 percent of the county land area.
21 A small portion of the Hanford Reach National Monument (approximately 40 mi² (64.4 km²) of
22 the Wahluke Unit) extends into northwest Franklin County. The principal crop is livestock forage
23 (i.e., hay and grass silage), followed by wheat for grain, potatoes, vegetables, and sweet corn.
24 Livestock (mostly cattle and calves) is about one-sixth the market value for all agriculture
25 products. The number of farms in Franklin County decreased from 1997–2007 by 17 percent.
26 The number of farmland acres and average size of a farm (in acres), however, increased during
27 the same period by 5 percent and 26 percent, respectively (USDA NASS, 2009).

28 Both Benton and Franklin County have experienced significant population growth in recent
29 years and, from 2000–2009, were ranked by the Washington Department of Financial
30 Management fifth and first, respectively, in population growth among the 39 Washington
31 counties (WOFM, 2009).

32 Even though population growth is projected to continue, there is ample urban and rural land to
33 accommodate the anticipated growth over the next 20 years. However, agricultural will continue
34 to be the major land use outside urban areas.

35 **2.2.8.4 Visual Aesthetics and Noise**

36 CGS is situated on a relatively flat plain, which is shrub-steppe with sagebrush interspersed with
37 perennial native and introduced annual grasses. The makeup water pumphouse is the closest
38 structure to the Columbia River, and with little obstruction from vegetation, the power plant can
39 be seen from the river.

40 Predominate features are the reactor building, which is approximately 230 ft (70 m) tall; the
41 turbine generator building (139 ft (42 m)); six cooling towers each standing 60 ft (18 m) tall; and
42 a 245 ft (75 m) meteorological tower, located west of the Reactor Building. Two abandoned
43 power plant construction projects (WNP-1 and WNP-4) also located on the leased Energy

1 Northwest land—now referred to as the IDC—which is comprised of several IDC facilities (e.g.,
 2 shops, warehouses, office space) (EN, 2010b).

3 Noise from nuclear plant operations can be detected offsite. Sources of noise at CGS include
 4 the turbines and large pump motors. Given the industrial nature of the station, noise emissions
 5 from the station are generally nothing more than an intermittent minor nuisance. However,
 6 noise levels may sometimes exceed the 55 decibels adjusted level that the EPA uses as a
 7 threshold level to protect against excess noise during outdoor activities (EPA, 1974). However,
 8 according to the EPA this threshold does “not constitute a standard, specification, or regulation,”
 9 but was intended to give a basis for State and local governments establishing noise standards.

10 **2.2.8.5 Demography**

11 According to the 2000 Census, an estimated 171,371 people lived within 20 mi (32 km) of CGS,
 12 which equates to a population density of 136 persons per mi² (EN, 2010b). This translates to a
 13 Category 4, “least sparse” population density using the generic environmental impact statement
 14 (GEIS) measure of sparseness (greater than or equal to 120 persons per mi² within 20 mi). An
 15 estimated 387,512 people live within 50 mi (80 km) of CGS with a population density of
 16 49.4 persons per mi² (EN, 2010b). Since the Tri-Cities has a combined population of over
 17 200,000 persons within 50 mi of CGS, this translates to a Category 3 density using the GEIS
 18 measure of proximity (one or more cities with 100,000 or more persons and less than
 19 190 persons per mi² within 50 mi). Therefore, CGS is located in a high population area based
 20 on the GEIS sparseness and proximity matrix.

21 Table 2.2-10 shows population projections and growth rates from 1970–2050 in Benton and
 22 Franklin counties in Washington. The growth rate in Benton County showed an increase of
 23 26.5 percent for the period of 1990–2000. Franklin County population also shows an increase
 24 from 1990–2000 (31.7 percent). Both counties' populations are expected to continue to
 25 increase in the next decades and through 2050.

26 **Table 2.2-10. Population and percent growth in Benton and Franklin counties**
 27 **from 1970–2000 and projected for 2010–2050**

| Year | Benton | | Franklin | |
|-------------|----------------|-------------------------------|---------------|-------------------------------|
| | Population | Percent growth ^(a) | Population | Percent growth ^(a) |
| 1970 | 67,540 | ---- | 25,816 | ---- |
| 1980 | 109,444 | 62.0 | 35,025 | 35.7 |
| 1990 | 112,560 | 2.8 | 37,473 | 7.0 |
| 2000 | 142,475 | 26.6 | 49,347 | 31.7 |
| 2009 | 168,294 | 18.1 | 77,355 | 56.8 |
| 2010 | 168,839 | 18.5 | 70,038 | 41.9 |
| 2020 | 184,704 | 9.4 | 90,654 | 29.4 |
| 2030 | 198,528 | 7.5 | 109,861 | 21.2 |
| 2040 | 213,713 | 7.6 | 130,007 | 18.3 |
| 2050 | 228,557 | 6.9 | 149,919 | 15.3 |

Affected Environment

| Year | Benton | | Franklin | |
|------|------------|-------------------------------|------------|-------------------------------|
| | Population | Percent growth ^(a) | Population | Percent growth ^(a) |

---- = No data available.

^(a) Percent growth rate is calculated over the previous decade.

Sources: Population data for 1970 through estimated population data for 2009 (USCB, 2010); population projections for 2010–2030 by Washington Office of Financial Management (WOFM), *Final Projections of the Total Resident Population for Growth Management, Medium Series: 2000 to 2030*, October 2007; 2040–2050 calculated.

1 Demographic Profile. The 2000 (estimate) demographic profiles of the two-county ROI
 2 population are presented in Table 2.2-11 and Table 2.2-12. In 2000, minorities (race and
 3 ethnicity combined) comprised 27.1 percent of the total two-county population. The minority
 4 population is largely Hispanic or Latino with a small percentage of Asian residents.

5 **Table 2.2-11. Demographic profile of the population in the Columbia Generating Station**
 6 **two-county socioeconomic region of influence in 2000**

| | Benton | Franklin | ROI |
|---|---------|----------|---------|
| Total Population | 142,475 | 49,347 | 191,822 |
| Race (percent of total population, Not-Hispanic or Latino) | | | |
| White | 81.7 | 47.6 | 72.9 |
| Black or African American | 0.9 | 2.3 | 1.2 |
| American Indian & Alaska Native | 0.7 | 0.5 | 0.6 |
| Asian | 2.2 | 1.6 | 2.0 |
| Native Hawaiian Other Pacific Islander | 0.1 | 0.1 | 0.1 |
| Some other race | 0.1 | 0.1 | 0.1 |
| Two or more races | 1.8 | 1.3 | 1.7 |
| Ethnicity | | | |
| Hispanic or Latino | 17,806 | 23,032 | 40,838 |
| Percent of total population | 12.5 | 46.7 | 21.3 |
| Minority population (including Hispanic or Latino ethnicity) | | | |
| Total minority population | 26,018 | 25,877 | 51,895 |
| Percent minority | 18.3 | 52.4 | 27.1 |

Source: USCB, 2010.

7 According to the U.S. Census Bureau’s (USCB) 2006–2008 American Community Survey
 8 3-Year Estimates, minority populations were estimated to have increased by approximately
 9 20,600 persons and comprised 31.7 percent of the county population (see Table 2.2-12). Most
 10 of this increase was due to an estimated influx of Hispanic or Latinos (over 18,300 persons), an
 11 increase of over 45 percent from 2000. The next largest increase in minority population was
 12 Asian, an increase of approximately 1,000 persons, or 26 percent, from 2000.

1 **Table 2.2-12. Demographic profile of the population in the Columbia Generating Station**
 2 **two-county socioeconomic region of influence, 2006–2008 3-year estimate**

| | Benton | Franklin | ROI |
|---|---------|----------|---------|
| Population | 159,629 | 69,241 | 228,870 |
| Race (percent of total population, not-Hispanic or Latino) | | | |
| White | 78.0 | 45.9 | 68.3 |
| Black or African American | 1.3 | 1.6 | 1.4 |
| American Indian & Alaska Native | 0.6 | 0.6 | 0.6 |
| Asian | 2.3 | 1.7 | 2.1 |
| Native Hawaiian Other Pacific Islander | 0.0 | 0.1 | 0.0 |
| Some other race | 0.2 | 0.1 | 0.2 |
| Two or more races | 1.5 | 1.3 | 1.5 |
| Ethnicity | | | |
| Hispanic or Latino | 25,404 | 33,737 | 59,141 |
| Percent of total population | 15.9 | 48.7 | 25.8 |
| Minority population (including Hispanic or Latino ethnicity) | | | |
| Total minority population | 35,049 | 37,431 | 72,480 |
| Percent minority | 22.0 | 54.1 | 31.7 |

Source: USCB, 2010.

3 Transient Population. Within 50 mi (80 km) of CGS, colleges and recreational opportunities
 4 attract daily and seasonal visitors who create demand for temporary housing and services. In
 5 2010, there were approximately 19,189 students attending colleges and universities within 50 mi
 6 (80 km) of CGS (IES, 2010).

7 In 2000, 0.3 percent of all housing units are considered temporary housing for seasonal,
 8 recreational, or occasional use in Benton County. By comparison, seasonal housing accounted
 9 for 1.0 percent, 5.4 percent, 10.9 percent, 5.5 percent, 0.8 percent, and 1.1 percent of total
 10 housing units in Adams, Grant, Kittitas, Klickitat, Walla Walla, and Yakima counties in
 11 Washington, respectively (USCB, 2010). Two counties in the state of Oregon are within 50 mi
 12 of CGS, Morrow and Umatilla, which make up 4.7 percent and 2.5 percent of the total seasonal
 13 housing units. Seasonal housing accounted for 0.5 percent of total housing units in Franklin
 14 County, respectively (USCB, 2010). Table 2.2-13 supplies information on seasonal housing for
 15 the 10 counties located all or partly within 50 mi of CGS.

16 **Table 2.2-13. Seasonal housing in counties located within 50 miles**
 17 **of Columbia Generating Station**

| County ^(a) | Housing units | Vacant housing units: for seasonal, recreational, or occasional use | Percent |
|-----------------------|---------------|---|---------|
| Washington | | | |
| Adams | 5,773 | 59 | 1.0 |
| Benton | 55,963 | 184 | 0.3 |
| Franklin | 16,084 | 76 | 0.5 |

Affected Environment

| County ^(a) | Housing units | Vacant housing units: for seasonal, recreational, or occasional use | Percent |
|------------------------|----------------|---|------------|
| Grant | 29,081 | 1,576 | 5.4 |
| Kittitas | 16,475 | 1,791 | 10.9 |
| Klickitat | 8,633 | 475 | 5.5 |
| Walla Walla | 21,147 | 178 | 0.8 |
| Yakima | 79,174 | 850 | 1.1 |
| County Subtotal | 232,330 | 5,189 | 2.2 |
| Oregon | | | |
| Morrow | 4,276 | 202 | 4.7 |
| Umatilla | 25,195 | 705 | 2.5 |
| County Subtotal | 31,952 | 907 | 2.8 |
| Total | 264,282 | 6,096 | 2.3 |

Source: USCB, 2010.

^(a) Counties within 50 mi (80 km) of CGS with at least one block group located within the 50-mi (80-km) radius.

1 **Migrant Farm Workers.** Migrant farm workers are individuals whose employment requires travel
 2 to harvest agricultural crops. These workers may or may not have a permanent residence.
 3 Some migrant workers follow the harvesting of crops, particularly fruit, throughout rural areas of
 4 the U.S. Others may be permanent residents near CGS and travel from farm to farm harvesting
 5 crops.

6 Migrant workers may be members of minority or low-income populations. Because they travel
 7 and can spend a significant amount of time in an area without being actual residents, migrant
 8 workers may be unavailable for counting by census takers. If uncounted, these workers would
 9 be “underrepresented” in USCB minority and low-income population counts.

10 Information on migrant farm and temporary labor was collected in the 2007 Census of
 11 Agriculture. Table 2.2-14 supplies information on migrant farm workers and temporary farm
 12 labor (less than 150 days) within 50 mi of CGS. According to the 2007 Census of Agriculture,
 13 approximately 123,879 farm workers were hired to work for less than 150 days and were
 14 employed on 3,958 farms within 50 mi of CGS. The county with the largest number of
 15 temporary farm workers (52,428) on 1,350 farms was Yakima County, WA (USDA
 16 NASS, 2009).

17 **Table 2.2-14. Migrant farm workers and temporary farm labor in counties located within**
 18 **50 miles of Columbia Generating Station**

| County ^(a) | Number of farms with hired farm labor ^(b) | Number of farms hiring workers for less than 150 days ^(b) | Number of farm workers working for less than 150 days ^(b) | Number of farms reporting migrant farm labor ^(b) |
|-----------------------|--|--|--|---|
| Washington | | | | |
| Adams | 251 | 197 | 4,637 | 40 |
| Benton | 466 | 412 | 15,347 | 132 |
| Franklin | 427 | 334 | 10,787 | 151 |
| Grant | 745 | 598 | 27,032 | 281 |

| County ^(a) | Number of farms with hired farm labor ^(b) | Number of farms hiring workers for less than 150 days ^(b) | Number of farm workers working for less than 150 days ^(b) | Number of farms reporting migrant farm labor ^(b) |
|------------------------|--|--|--|---|
| Kittitas | 222 | 187 | 1,032 | 22 |
| Klickitat | 185 | 139 | 1,804 | 31 |
| Walla Walla | 284 | 240 | 6,217 | 40 |
| Yakima | 1,483 | 1,350 | 52,428 | 465 |
| County Subtotal | 4,063 | 3,457 | 119,284 | 1,162 |
| Oregon | | | | |
| Morrow | 127 | 109 | 772 | 10 |
| Umatilla | 454 | 392 | 3,823 | 66 |
| County Subtotal | 581 | 501 | 4,595 | 76 |
| Total | 4,644 | 3,958 | 123,879 | 1,238 |

Source: 2007 Census of Agriculture

—County Data (NASS, 2009).

^(a) Counties within 50 miles of CGS with at least one block group located within the 50-mi radius.

^(b) Table 7. Hired farm Labor—Workers and Payroll: 2007.

1 In the 2002 Census of Agriculture, farm operators were asked for the first time whether or not
 2 they hired migrant workers—defined as a farm worker whose employment required travel—to
 3 do work that prevented the migrant worker from returning to their permanent place of residence
 4 the same day. A total of 1,238 farms, in the 50-mi radius of the CGS, reported hiring migrant
 5 workers in the 2007 Census of Agriculture. Yakima and Grant County reported the most farms
 6 (465 and 281, respectively) with hired migrant workers, followed by Franklin and Benton County,
 7 with 151 and 132 farms, respectively (USDA NASS, 2009).

8 According to the 2007 Census of Agriculture estimates, 15,347 temporary farm workers (those
 9 working fewer than 150 days per year) were employed on 412 farms in Benton County, and
 10 10,787 temporary farm workers were employed on 334 farms in Franklin County (USDA
 11 NASS, 2009).

12 **2.2.8.6 Economy**

13 This section contains a discussion of the economy, including employment and income,
 14 unemployment, and taxes.

15 Employment and Income. From 2000–2009, the civilian labor force in Benton County increased
 16 13.9 percent from 70,520 to an estimated 80,305. Franklin County also increased during that
 17 time period, 48.0 percent, from 21,875 to an estimated 32,372 (USCB, 2010).

18 In 2008, educational, health, and social services represented the largest sector of employment
 19 (19.3 percent) in Benton County followed by professional, scientific, management,
 20 administration, and waste management (18.0 percent). In Franklin County, educational, health,
 21 and social services represented the largest sector of employment (16.7 percent) followed by
 22 agriculture, forestry, fishing, and hunting and mining (16.5 percent). A list of some of the major
 23 employers in the Tri-City area is given in Table 2.2-15. As shown in the table, the largest

Affected Environment

1 employer in the Tri-City area is the Pacific Northwest National Laboratory. Energy Northwest is
 2 the seventh largest employer.

3 **Table 2.2-15. Major employers of the Tri-City area in 2007**

| Employer | Number of employees |
|--------------------------------|---------------------|
| Battelle/PNNL | 4,188 |
| Fluor | 3,597 |
| Bechtel National, Inc. | 2,400 |
| ConAgra/Lamb Weston | 1,685 |
| Kadlec Medical Center | 1,486 |
| Tyson Fresh Meats | 1,235 |
| Energy Northwest | 1,072 |
| CH2M Hill Handford Group, Inc. | 1,060 |
| Broetje Orchards (seasonal) | 988 |
| Kennewick General Hospital | 805 |
| Tri-Cities Airport | 703 |
| Benton County | 664 |
| Lockheed Martin Services, Inc. | 650 |
| Lourdes Health Network | 640 |
| AREVA, Inc. | 625 |
| Apollo, Inc. | 490 |
| DOE Richland Operations | 231 |
| AgriNorthwest | 200 |
| DOE Office of River Protection | 102 |

Source: EN, 2010b.

4 Estimated income information for the CGS ROI is presented in Table 2.2-16. According to the
 5 USCB's 2006–2008 American Community Survey 3-Year Estimates, people living in Benton and
 6 Franklin counties had median household and per capita incomes below the state average.
 7 Benton County had a higher median household and per capita income between the two
 8 counties. An estimated 12.7 and 20.9 percent of the population in Benton and Franklin counties
 9 were living below the official poverty level, respectively. The State of Washington, as a whole,
 10 had a lower percentage of persons living below the poverty level (11.6 percent). The
 11 percentage of families living below the poverty level in Benton and Franklin County (9.9 and
 12 17.2 percent, respectively) was higher than the percentage of families in the State of
 13 Washington as a whole (7.9 percent) (USCB, 2010).

14 **Table 2.2-16. Estimated income information for the Columbia Generating Station**
 15 **region of influence in 2008**

| | Benton | Franklin | Washington |
|--|--------|----------|------------|
| Median household income (dollars) ^(a) | 54,544 | 44,744 | 57,234 |
| Per capita income (dollars) ^(a) | 26,542 | 18,220 | 29,927 |

| | Benton | Franklin | Washington |
|--|--------|----------|------------|
| Individuals living below the poverty level (percent) | 12.7 | 20.9 | 11.6 |
| Families living below the poverty level (percent) | 9.9 | 17.2 | 7.9 |

Source: USCB, 2010.

^(a) In 2008 inflation-adjusted dollars.

1 Unemployment. According to the USCB’s 2006–2008 American Community Survey 3-Year
 2 Estimates, the unemployment rates in Benton and Franklin counties were 6.2 and 7.9 percent,
 3 respectively, which was higher than the unemployment rate of 6.0 percent for the State of
 4 Washington (USCB, 2010).

5 Taxes. Energy Northwest, a municipal corporation and joint operating agency of the State of
 6 Washington, is exempt from paying local property taxes but is required to pay a public utility
 7 district (PUD) privilege tax (state excise tax) for the privilege of operating. The tax is authorized
 8 by State law (Revised Code of Washington, Chapter 54.28). The tax is “measured by gross
 9 income derived from the sale of electric energy, the number of kilowatt hours of self-generated
 10 energy which is either distributed to consumers or resold to other utilities, and the wholesale
 11 value of energy produced in thermal plants.” (WDOR 2010).

12 The PUD privilege tax on thermal generating facilities, including CGS, is assessed on the
 13 wholesale value of energy produced for sale or use. The basic rate portion of the tax is
 14 distributed by the Washington Department of Revenue (WDOR) in accordance with specified
 15 formulas. About 4 percent is deposited in the state general fund, with the remaining 96 percent
 16 split evenly (50-50) between the state general fund for public schools and local taxing districts
 17 within a defined “impacted area.” The surtax portion of the PUD privilege tax goes directly to
 18 the state general fund (WDOR 2010).

19 The CGS “impacted area” (also defined by state law) is as an area within 35 mi of the southern
 20 entrance to the DOE Hanford Site (WDOR 2010). The local taxing districts in the “impacted
 21 area” include 5 counties (Benton, Franklin, Grant, Walla Walla, and Yakima), 10 cities
 22 (Richland, Kennewick, Pasco, Benton City, Prosser, West Richland, Connell, Mesa, Grandview,
 23 Sunnyside), 17 fire districts, and 4 library districts. Distribution is based on the population in
 24 each area. Counties receive 22 percent of the local taxing districts portion of the tax payment,
 25 cities receive 23 percent, fire districts receive 3 percent, and library districts receive 2 percent
 26 (WDOR 2010). Privilege taxes paid by Energy Northwest for CGS energy generation over a
 27 5-year period are presented in Table 2.2-17.

28 **Table 2.2-17. Columbia Generating Station privilege tax distribution, 2004–2008**

| | Calendar Year ^(a) | | | | |
|-----------------------|------------------------------|---------|-----------|-----------|-----------|
| | 2004 | 2005 | 2006 | 2007 | 2008 |
| State General Fund | 261,217 | 291,650 | 266,691 | 303,216 | 330,598 |
| Public Schools | 1,139,855 | 127,654 | 1,163,743 | 1,323,123 | 1,442,610 |
| Countries (5) | 501,536 | 559,968 | 512,047 | 582,174 | 634,748 |
| Cities (10) | 524,333 | 585,421 | 535,322 | 608,636 | 663,601 |
| Fire Districts (17) | 68,391 | 76,359 | 69,825 | 79,387 | 86,557 |
| Library Districts (4) | 45,594 | 50,906 | 46,550 | 52,925 | 57,704 |

Affected Environment

| | Calendar Year ^(a) | | | | |
|--------------|------------------------------|------------------|------------------|------------------|------------------|
| | 2004 | 2005 | 2006 | 2007 | 2008 |
| Total | 2,540,927 | 2,836,959 | 2,594,178 | 2,949,461 | 3,215,818 |

Source: EN, 2010b.

^(a) Taxes, payable in June of each year, are based on the generation during the preceding calendar year.

1 The retail sales and use tax is an important revenue source for State and local government in
 2 Washington State. This excise tax is levied on retail transactions and supplied about 55 percent
 3 of state revenues supporting the State general fund and 47.5 percent of total State and local tax
 4 receipts (WDOR 2010).

5 The leasehold excise tax is another tax that applies to leases of public property to private
 6 lessees. All receipts are deposited in the State general fund, and about half is returned to the
 7 cities and counties in which the property is located (WDOR 2010). Energy Northwest owns and
 8 leases office buildings in Benton County that are underwritten, in part, by bonds financing CGS.
 9 Accordingly, a leasehold tax is collected and paid to the state. The sales and use and leasehold
 10 taxes attributable to CGS for fiscal years 2004–2008 are presented in Table 2.2-18.

11 **Table 2.2-18. Columbia Generating Station Sales and Use and Leasehold Taxes,**
 12 **FY 2004–2008**

| | Fiscal Year (July 1–June 30) | | | | |
|---------------------------|------------------------------|-----------|-----------|------------|-----------|
| | 2004 | 2005 | 2006 | 2007 | 2008 |
| Sales & Use Tax (dollars) | 2,799,321 | 7,767,808 | 2,570,866 | 11,489,074 | 4,602,412 |
| Leasehold Tax (dollars) | 41,587 | 43,032 | 39,499 | 45,654 | 59,818 |

Source: EN, 2010b.

13 The sales and use tax fluctuates year-to-year, largely because of the cyclical nature of
 14 procurement activities and refueling and maintenance outages at CGS every 2 years. Nuclear
 15 fuel purchases comprise a significant component of the use tax. However, taxes do not
 16 represent significant percentage of the revenue of the local taxing jurisdictions. In addition,
 17 there is no direct correlation between the amount of taxes paid to the State of Washington and
 18 the distribution of funds to local taxing jurisdictions. The allocation of tax revenue attributable to
 19 CGS to local taxing districts is not recorded. To give a sense of the relative support provided by
 20 CGS, estimates for several taxing districts are listed in Table 2.2-19 for 2007. The listed
 21 jurisdictions are representative of the many that could derive some revenue from sales taxes or
 22 privilege taxes paid by CGS. For most jurisdictions, the estimated revenue attributable to CGS
 23 is less than 1 percent of their general fund revenues.

24 **Table 2.2-19. Estimated relative contribution of Columbia Generating Station to revenue**
 25 **of selected jurisdictions, 2007**

| Jurisdiction | General fund revenue (1,000 dollars) | Estimated tax revenue from CGS | Percent of general fund revenue from CGS taxes |
|-----------------|---|-----------------------------------|---|
| Counties | | | |
| Benton | 51,493 | 393.9 | 0.77 |
| Franklin | 20,760 | 146.2 | 0.70 |

| Jurisdiction | General fund revenue (1,000 dollars) | Estimated tax revenue from CGS | Percent of general fund revenue from CGS taxes |
|--------------------------------|---|---|---|
| Yakima | 51,055 | 74.9 | 0.15 |
| Cities | | | |
| Richland | 37,920 | 276.5 | 0.73 |
| Kennewick | 34,122 | 306.4 | 0.90 |
| Pasco | 29,967 | 315.1 | 1.05 |
| West Richland | 4,943 | 45.6 | 0.92 |
| Prosser | 3,929 | 15.9 | 0.41 |
| Connell | 2,683 | 10.1 | 0.38 |
| Grandview | 4,400 | 27.9 | 0.63 |
| Fire districts | | | |
| Benton County No. 1 | 2,487 | 21.6 | 0.87 |
| Benton County No. 4 | 1,343 | 14.9 | 1.11 |
| Yakima County No. 5 | 3,626 | 8.6 | 0.24 |
| Walla Walla County No. 5 | 729 | 4.6 | 0.63 |
| Library district | | | |
| Mid-Columbia | 5,599 | 41.3 | 0.74 |
| Yakima Valley Regional | 5,946 | 6.8 | 0.11 |
| School district | | | |
| Kennewick | 84,830 | 39.0 | 0.05 |
| Richland | 126,905 | 59.3 | 0.05 |
| Pasco | 97,605 | 52.2 | 0.05 |
| Other | | | |
| Ben Franklin Transit Authority | 26,414 | 290.8 | 1.10 |

Source: EN, 2010b.

Notes:

(1) General fund revenue is normally for the operation and maintenance of the respective governmental function. Sources include taxes, license and permit fees, fines and forfeits, leases and rents, and charges for services. The Washington State Auditor's Office is the source of the revenue numbers.

(2) The calendar year 2007 sale and use tax is assumed to be the average of the fiscal year 2007 and fiscal year 2008 tax in Table 2.2-18. Thus, calendar year 2007 sales and use taxes from Table 2.2-18 are estimated to be \$8,046,000. Similarly, the calendar year 2007 leasehold taxes are estimated to be \$52,700.

(3) For estimation, it is assumed that 50 percent of the procurement subject to sales and use tax occurs locally with 30 percent in Benton County and 20 percent in Franklin County. Additional assumptions are made regarding the distribution of sales and use tax revenue among the cities. Benton County and the City of Richland are assumed to share half of the leasehold taxes that are paid.

(4) Estimated distribution of privilege taxes to school districts is based on fractional share of the total basic program support received by the district. Distribution also assumes 33.4 percent of state general fund revenue supports K-12 education.

(5) Intergovernmental transfers of tax revenues are not considered.

1 2.2.9 Historic and Archaeological Resources

2 This section discusses the cultural background and the known historic and archaeological
3 resources found on and near CGS. The discussion is based on a review of recent historic and

Affected Environment

1 archaeological resource studies and other background information on Hanford and the region
2 surrounding CGS. The National Environmental Policy Act (NEPA) Characterization Report and
3 the Hanford Cultural Resources Management Plan describe in detail most of the cultural
4 resources in the Hanford region, including CGS (Duncan, et al., 2007), (Gambhir, 2010b).
5 Additional historic resource overviews are summarized in the Comprehensive Conservation
6 Plan EIS for the Hanford Reach National Monument (USFWS, 2008). Regional context for the
7 pre-contact and ethnohistoric Native American land use in the Columbia River Basin is available
8 in the Handbook of North American Indians and the Hanford Cultural Resources Management
9 Plan (Walker and Sprague, 1998). In addition, a records search was performed at the DOE
10 Cultural and Historic Resources Program archives for the Hanford Site and the Washington
11 State Department of Archaeology and Historic Preservation to obtain the most updated
12 information about historic and archaeological resources in the region.

13 **2.2.9.1 Cultural Background**

14 Historic and archaeological resources at the Hanford Site are highly significant given the
15 extensive number of archaeological sites that have been found along the Columbia River.
16 These archaeological sites have helped define thousands of years of human occupation in the
17 region, and the Hanford Site has served to protect these resources. Hydroelectric development,
18 agricultural activities, and commercial and industrial development elsewhere in the Columbia
19 River Basin have damaged, destroyed, or covered over many other archeological sites
20 (Duncan, et al., 2007).

21 American Indian tribes with historical ties to the Hanford Site include four Federally recognized
22 tribes—the Yakama Nation, the Nez Perce Tribe, the Confederated Tribes of the Umatilla Indian
23 Reservation (CTUIR), and the Confederated Tribes of the Colville Reservation. Another
24 American Indian tribe, the Wanapum, historically carried out most of their seasonal rounds on
25 the Hanford Site. Today the Wanapum reside just upstream from the Hanford Site at Priest
26 Rapids. Access and protection of these resources is an integral part of their cultural heritage
27 and perpetuates their cultural practices, beliefs, and values (Duncan, et al., 2007),
28 (USFWS, 2008).

29 There are 49 historic and archaeological sites listed on the National Register of Historic Places
30 (NRHP) on the Hanford Site. Most of these sites are associated with the Native American
31 cultural landscape and are part of six archaeological districts situated on the banks and islands
32 of the Columbia River. None of the listed sites is on the CGS site. The Wooded Island
33 Archaeological District is the closest archaeological district to CGS. This district is comprised of
34 several archaeological sites connected with the location of a prehistoric and historic Wanapum
35 fishing village (Fuller, 1974).

36 Over 30 other archaeological sites at Hanford, including one archaeological district and several
37 places of traditional cultural value have also been determined to be eligible for listing on the
38 NRHP. The Manhattan Project and Cold War Era Historic District on the Hanford Site, with over
39 500 buildings and structures as well as several archaeological sites, has been determined
40 eligible for listing on the NRHP. The nearest NRHP-eligible property to CGS in this district
41 consists of several buildings associated with the FFTF, the Midway Benton Line operated by the
42 BPA, and the Hanford Site Plant Railroad operated and maintained by the DOE.

43 NRHP-eligible traditional cultural properties (TCPs) nearest to CGS include Gable
44 Mountain/Gable Butte and *Laliik*. CGS can be seen from both TCPs. These TCPs are highly
45 revered by the tribes and are considered to be sacred sites. Although Gable Mountain/Gable

1 Butte is closer, *Laliik* is located 3,000 ft (914 m) on top of Rattlesnake Mountain and is visible
2 from CGS (Gambhir, 2010b).

3 In addition, 47 of Hanford's historic and archaeological sites are listed on the State of
4 Washington's Heritage Register. These sites are associated with the Native American cultural
5 landscape and are located mostly along the Columbia River (Duncan, et al., 2007).

6 **2.2.9.2 Native American History**

7 Archaeological evidence suggests that Native American people existed in the Columbia Plateau
8 for more than 10,000 years. The following major periods of presence and culture have been
9 documented for the Columbia River Basin (Ames, et al., 1988), (Gambhir, 2010b):

- 10 • Period 1a/b (Paleo-Indian/Windhurst) (13,500–7000/6400 before present (BP))
- 11 • Period II (7000/6400–3900 BP)
- 12 • Period III (3900 BP–1720 AD)
- 13 • Ethnohistoric Period (1720 AD–present)

14 Period 1a/b (Paleo-Indian/Windhurst) (13,500–7000/6400 BP). The prehistory of the lower
15 Columbia River Basin spans approximately 13,000 years. Archaeological evidence associated
16 with the Clovis culture, which is represented by Period 1a, are rare throughout the Columbia
17 Plateau region (Ames, et al., 1988), (Gambhir, 2010b). Period 1b is characterized by
18 Paleo-Indian cultures that were highly mobile relying on a foraging subsistence strategy
19 consisting mostly of large mammals supplemented by some fish and small mammals. Artifact
20 assemblages from this time period include Clovis, Windhurst, and Cascade style projectile
21 points, cobble tools, hammerstones, scrapers, and used lithic flakes (Ames, et al., 1988),
22 (Gambhir, 2010b).

23 Period II (7000/6400–3900 BP). During Period II, bands of people traveled throughout the
24 region to exploit a wide range of seasonally or locally available food sources with increased
25 reliance on fish and exploitation of plants and roots (Ames, et al., 1988), (Gambhir, 2010b).
26 Pithouses appear for the first time during this period around 5000 BP, suggesting evidence of a
27 semi-sedentary lifestyle. Characteristic artifact assemblages include stemmed projectile points,
28 leaf-shaped Cascade projectile points, milling stones, hammerstones, scrapers, core tools, and
29 microblades (Ames, et al., 1988), (Gambhir, 2010b).

30 Period III (3900 BP–1720 AD). The most significant change during this time period is the
31 prevalence of pithouses and the long-term storage of foods. Although bands of people were still
32 highly mobile at this time, they adapted to a mostly riverine environment and began to rely
33 increasingly on fish rather than game, but increased diversification with reliance also on plants
34 and roots. Bermed pithouses and more specialized camps for hunting, root collection, and plant
35 processing also appeared at this time. Inhabitants built more permanent winter villages along
36 the river consisting of long, tule mat community lodges surrounded by family pithouses
37 (USFWS, 2008). The longhouse was used for council meetings, religious ceremonies, dances,
38 and funerals. Sweathouses also were constructed along streams and rivers and were used for
39 physical and spiritual purification, socializing, and physical curing. Diagnostic artifacts from this
40 period include projectile points that become smaller and more variable. Netweights are more
41 prominent; the bow and arrow was introduced; and basketry, wood, and fiber appear in the
42 archeological record (Ames, et al., 1988), (Gambhir, 2010b). The Columbia River provided an
43 important fishery—particularly at Priest Rapids, Coyote Rapids, and Locke Island. Fishing

Affected Environment

1 techniques included spears, nets, traps, and weirs. This period ends with the appearance of the
2 horse and Euro-Americans on the Plateau (Ames, et al., 1998).

3 Ethnohistoric Period (1720–1943 AD). The ethnohistoric period covers the period of time and
4 the changes that occurred since the arrival of Euro-American settlers in the region. The arrival
5 of Euro-American settlers brought fatal epidemic diseases serving to reduce Native American
6 populations and, in some instances, eradicate whole groups (Walker and Sprague, 1998).
7 Historically, the Wanapum people—from the village of Priest Rapids located upstream from the
8 Hanford Site—conducted seasonal rounds of hunting and fishing throughout the Hanford Site
9 and established several village sites along the Columbia River. Over 30 other Native American
10 groups also lived and relied on resources in the Hanford area. These include the Columbia,
11 Sanpoil, Southern Okanaogan, Umatilla, Yakama, Nespelem, Nez Perce, Palus, Cayuse, and
12 the Colville to name a few (Gambhir, 2010b). These groups engaged in intermarriage, trade,
13 resource-gathering, and ceremonial activities on the Hanford Site. The Wanapum continued to
14 fish, camp, and winter on the Hanford Site until 1943.

15 Negotiations with the U.S. Government in 1855 resulted in three treaties with the Nez Perce
16 Tribe, the CTUIR, and the Yakama Nation. Each tribe ceded large amounts of land to the U.S.
17 Government but retained the right to continue traditional activities, including the right to fish,
18 pasture horses and cattle, hunt, and gather traditional foods (Gambhir, 2010b). A Presidential
19 Executive Order, passed in 1872, established The Confederated Tribes of the Colville
20 Reservation (Gambhir, 2010b).

21 **2.2.9.3 European American History**

22 European Americans began to arrive in the Columbia River Basin in the early 1800s. This
23 period overlaps with the ethnohistoric period associated with the Native American history and
24 land use in the region.

25 Explorers, Trappers, Military Units, and Miners. European American presence in the
26 Mid-Columbia region began when the Lewis and Clark Expedition passed through the area
27 during its 1803–1806 exploration of the Louisiana Territory. David Thompson was the first
28 European explorer to cross the Hanford area, traveling through in 1811 as part of his exploration
29 of the Columbia River. He was followed by fur trappers, military units, and miners who traveled
30 through the Hanford Site on their way to lands up and down the Columbia River and across the
31 Columbia River Basin (Duncan, et al., 2007).

32 Early Settlers and Farmers. During the 1860s, merchants began to set up stores, a freight
33 depot, and the White Bluffs Ferry on the Hanford Reach of the Columbia River. Chinese miners
34 worked the gravel bars for gold. Cattle ranches were built in the 1880s, followed by the
35 establishment of farms over the next two decades. In the early 20th century, agricultural
36 development, irrigation districts, and roads were established in the area, and several small
37 towns—Hanford, White Bluffs, Richland, and Ringold—grew up along the riverbanks. Additional
38 ferries became available at Richland, Hanford, Wahluke, and Vernita. In 1913, the Chicago,
39 Milwaukee, St. Paul, and Pacific railroad branch line arrived from Beverly, WA, providing access
40 to outside markets. The towns, and nearly all other structures on the Hanford Site, were razed
41 in 1943 when the U.S. Government acquired the land for the Manhattan Project (Duncan, et
42 al., 2007).

43 The Manhattan Project and Cold War. The Manhattan Project was established during World
44 War II to construct a secret plutonium production plant. Fuel elements were irradiated in up to
45 nine reactors located along the Columbia River. The fuel was then processed and separated in

1 the central part of the Hanford Site. Production activities at Hanford also included research and
 2 development, environmental monitoring, and waste management. The FFTF, constructed in the
 3 early 1970s, was used to test nuclear fuel types (Gambhir, 2010b).

4 Since 1990, DOE has focused its efforts on the environmental cleanup of radioactive and
 5 chemical waste from nuclear material production activities. Many of the buildings and structures
 6 associated with these activities have since been demolished and removed. Before demolition,
 7 historic building surveys were completed to record history and significant engineering attributes
 8 (DOE, 2002b). Over 500 buildings and structures were determined to be eligible for listing on
 9 the NRHP and are now considered part of the Hanford Site Manhattan Project and Cold War
 10 Era District (Gambhir, 2010b).

11 **2.2.10 Historic and Archaeological Resources at the Columbia Generating Station Site**

12 Although there are no known ethnohistoric references to the CGS site, archaeological site
 13 45BN257, located along the Columbia River on CGS (suggesting Wanapum land use), shows
 14 ethnohistoric and pre-contact land use of the CGS site. In addition, the presence of several
 15 fishing stations and a village site (45BN113 and 45BN114 and Wooded Island Archaeological
 16 District) located near CGS confirms extensive and long-term, pre-historic and historic land use
 17 in the area.

18 According to a review of historic maps, very little historic development occurred on or near CGS
 19 from 1880–1943, with the exception of roads south of CGS, the Midway Benton transmission
 20 line, and the Hanford-Richland Railroad. Between 1943 and the construction of CGS in 1983,
 21 the power line and railroad were both used to support Hanford Site operations (DOE, 2002b).

22 Several historic and archaeological resource surveys and investigations were carried out on
 23 CGS land leased from DOE from 1972–2005. This section will summarize each of the
 24 investigations and describe cultural resources located by these investigations.

25 Before the construction of CGS, several archaeological investigations and surveys were carried
 26 out from 1972–1978, resulting in a 100-percent surface survey of CGS leased lands. The
 27 surveys covered both WPPSS Nuclear Projects Nos. 1 and 4 (WNP-1/4) and CGS, previously
 28 referred to as WNP-2 (EN, 2010), (NRC, 1981), (Rice, 1983), (WPPSS, 1980). Archaeological
 29 materials were found along the river near the intake and pumphouse structures for WNP-1/4
 30 and WNP-2. Observations at WNP-2 included a scattering of fire-cracked rock, a few lithic
 31 flakes, and one cobble tool. Observations at WNP-1/4 included cobble implements, fire-cracked
 32 rock, and a few lithic flakes. None of the material was formally recorded as an archaeological
 33 site at that time. Archaeological monitoring was recommended during construction of the intake
 34 and pumphouse structures. Archaeological monitoring at WNP-2 resulted in the additional
 35 discovery of fire-cracked rock, but no discrete archaeological features or substantive
 36 archaeological material was found. In addition, monitoring during the construction of WNP-2
 37 intake and pumphouse structure ensured that effects on nearby fishing station archaeological
 38 sites (45BN113 and 45BN114), located outside of the leased boundary, were avoided (Rice,
 39 1983). Archaeological materials during construction are stored in the DOE Hanford Site Cultural
 40 and Historical Resources Program curation and storage facility.

41 Archaeological monitoring during the construction of WNP-1/4 resulted in the recording of a
 42 multi-component site (45BN257) containing both pre-contact and historic era material. Surface
 43 investigations revealed a ceramic Chinese rice bowl fragment, assumed to be linked to Chinese
 44 placer mining in the 1860s (EN, 2010). During excavation for the makeup water intake pipes,
 45 archaeologists also discovered pre-contact materials consisting of a fire hearth, cobble tools,

Affected Environment

1 and stone flakes. Radiocarbon dating of a piece of sagebrush charcoal found with the materials
2 suggested the location was a late pre-contact fishing camp dating to around 1600 AD (Rice,
3 1983). Additional surveys done before the construction of support facilities near the reactors
4 found no archaeological material (Rice, 1983).

5 Construction of WNP-1/4 and WNP-2 resulted in significant disturbance to large portions of
6 lands leased by Energy Northwest (Gambhir, 2010c). Since construction, from 1987–2008,
7 several additional archaeological surveys were conducted of undisturbed areas within CGS. In
8 1987, a small survey partially overlapping the southern boundary of CGS leased lands was
9 done for a proposed container test facility (Chatters and Hoover, 1988). One isolated find
10 (45BN687), consisting of a prehistoric projectile point dating to 200–1200 AD, was found just
11 south of the leased lands. In 1989, a short linear area on the southeast side of CGS leased
12 lands was surveyed for a proposed project to upgrade the Hanford Site 400 area sewage
13 treatment facility, resulting in no cultural resources findings (Cadoret and Chatters, 1989). In
14 1990, another linear archaeological survey was done through the southern portion of CGS
15 leased lands for the installation of fiber optic lines between the then WPPSS (now Energy
16 Northwest) headquarters in north Richland, WA, and the WNP-2. Again, no significant cultural
17 resources were located on CGS leased lands (Minthorn and Chatters, 1990). In 1998, no
18 archaeological resources were found during surveys of two 150 ac (61 ha) undisturbed areas on
19 lands leased for CGS Units 1 and 4 (Hale, 1998).

20 Several archaeological surveys were carried out near CGS for BPA-proposed transmission-line
21 corridors originating at the Ashe Substation and spanning to the east, west, and north (Rice,
22 1983), (WPPSS, 1980). The surveys found no significant cultural resources located close to
23 CGS (Gambhir, 2010b), (Jackson and Hartmann, 1977), (Smith, et al., 1977), (WPPSS, 1980).

24 In 1999, an archaeological survey was carried out through the eastern edge of CGS along the
25 Columbia River inland approximately 2,300 ft (700 m) (Hale, 1999). Four isolated finds,
26 consisting of two historic cans (HI-99-039 and HT-99-041) and two prehistoric artifacts
27 consisting of a lithic core and an anvil stone (45BN706 and 45BN700), were recorded. Two
28 sites of questionable age and function were also found, including industrial debris of
29 indeterminate age associated with a bulldozed mound (45BN689) and a small pile of cobbles
30 also of indeterminate age (45BN688). Archaeological site 45BN257 was also revisited during
31 this survey. However, the original site surveyed in 1983 could not be located, possibly because
32 of the construction of the intake structure. Nevertheless, two lithic flakes were recorded and
33 added to the site description. With the exception of archaeological site HI-99-039, all of the
34 finds were recorded within 300 m of the river corridor. The two new prehistoric isolates could be
35 part of 45BN257 given their proximity.

36 No cultural resources were found during a 2002 survey done for the installation security barriers
37 around CGS (Prendergast-Kennedy, 2002). Also in 2002, a survey done for the CTUIR, of the
38 eastern 1.2 mi (2 km) of CGS, located four historic isolated finds (three cans and one glass
39 fragment) (HI-2002-021–HI-2002-024) along the power line road (Steinmetz, 2005). No cultural
40 resources were located during two more surveys that crossed over onto CGS along the
41 Midway-Benton transmission and the 1.8 mi long transmission line that supplies offsite power to
42 CGS in 2003 and 2005 (Prendergast-Kennedy, 2003), (Prendergast-Kennedy, 2005). A
43 reconnaissance field inspection in 2008, along the main CGS access ROW as part of a
44 road-widening project, found no archaeological resources (Prendergast-Kennedy, 2008).

45 During 2008, Energy Northwest needed to upgrade its communication facility on Rattlesnake
46 Mountain, which is located on lands Energy Northwest leases from DOE. As part of this action,

1 DOE did a National Historic Preservation Act Section 106 cultural resources review and
 2 concluded that the upgrades and ongoing maintenance and operations would result in an
 3 adverse effect to *Laliik*, a National Register-eligible TCP (DOE, 2009). A Memorandum of
 4 Agreement was developed, and is currently in place, that resolves these adverse effects
 5 (DOE, 2009).

6 In summary, six historic and two prehistoric isolated archaeological finds have been recorded on
 7 CGS land. Three archaeological sites, consisting of two historic sites of undetermined affiliation
 8 or age and one multi-component site, have been recorded. Although the integrity and
 9 significance of these resources have not been determined, it is evident that a cultural sensitivity
 10 zone exists along the Columbia River shore. Two National Register-eligible Manhattan Project
 11 and Cold War Era Historic District properties traverse CGS (the Hanford Site Plant Railroad and
 12 the Midway Benton transmission line operated by the BPA). CGS is also within view of two
 13 National Register-eligible TCPs. With the exception of three historic isolated finds
 14 (HI-2002-021, HI-2002-022, and HI-2002-023), all cultural resources are located within the area
 15 of potential effect (APE) for CGS.

16 **2.2.10.1 Consultation**

17 In March 2010, the NRC initiated consultations on the proposed action by writing to the Advisory
 18 Council on Historic Preservation (ACHP) and the State Historic Preservation Office (SHPO).
 19 Also in March 2010, the NRC initiated consultation with three of the potentially affected
 20 Federally recognized tribes—the CTUIR, Yakama Nation, and the Nez Perce (see Appendix D
 21 for copies of these letters). The NRC supplied information about the proposed action, the
 22 definition of APE, and noted that the NHPA review would be integrated with the NEPA process,
 23 according to 36 CFR 800.8. The NRC invited the potentially affected tribes to participate in the
 24 identification of historic properties, the discussion of cultural concerns, and the scoping process.
 25 The NRC held a meeting with the tribes on April 27, 2010, to explain the license renewal
 26 process and to listen to any expressions of concern with the proposed action. Representatives
 27 from two Federally-recognized tribes (Yakama Nation and the CTUIR) and one non-Federally-
 28 recognized tribe (Wanapum) attended this meeting. An overview of consultation activities that
 29 occurred during the preparation of the SEIS with the SHPO and tribes is given in Section 4.9.6.
 30 The consultation process is ongoing.

31 **2.2.11 Geologic Environment**

32 This section describes the current geologic environment of the CGS site and vicinity including
 33 landforms, geology, soils, and seismic conditions.

34 Physiography. CGS is situated in the Pasco Basin, a structural and topographic depression
 35 within the Columbia Plateau physiographic province (EN, 2005b). The topography of the site is
 36 relatively flat and of low relief. The land surface reflects the accumulation of sediment within the
 37 basin and the effects of Pleistocene cataclysmic flooding between 15,000 and 1.8 million years
 38 ago and more recent eolian activity. Elevations across the plant site range from about 350 ft
 39 (107 m) above MSL at the Columbia River to about 460 ft (140 m) above MSL on the hills
 40 southwest of the plant in the vicinity of the Plant Support Facility. The finished ground elevation
 41 in the vicinity of the power block is approximately 421 ft (134 m) (EN, 2010).

42 Geology. The plant is sited on a shallow erosional channel incised into a relatively flat alluvial
 43 plain underlain by Pleistocene flood deposits of the Hanford formation. These glaciofluvial
 44 sands and gravels are approximately 45–50 ft (14–15 m) thick and are underlain by a thick
 45 (approximately 480 ft [146 m] thick) sequence of dense silt, sand, and gravel conglomerate of

Affected Environment

1 the Miocene-Pliocene age Ringold Formation (EN, 2010). Bedrock beneath the site consists of
2 Miocene age basalt of the Columbia River Basalt Group, at a depth of approximately 168 m
3 (550 ft) (EN, 2005b). The flood basalts erupted between about 6 and 17 million years ago and
4 are interbedded in places with sedimentary rocks of the Ellensburg Formation (EN, 2005b),
5 (Duncan, et al., 2007). CGS is founded on the Ringold Formation, which is further described in
6 Section 2.1.7.1.

7 All safety-related site structures are founded on structural backfill. No subsurface geologic
8 structures, including geologic faults, have been identified which might pose a hazard to plant
9 facilities. No geologic faults were encountered in excavations during plant construction, and no
10 active or capable faults are known to occur within 5 mi (8 km) of the CGS site (EN, 2005b).

11 Soils. A total of 15 different soil types have been categorized for the Hanford Site, varying from
12 sand to silty and sandy loam. Note that while these soil classifications have not been updated
13 to reflect current reinterpretations of soil classifications, they are useful in providing a
14 generalized description of the soils. The predominant soil type in the vicinity of CGS is Rupert
15 Sand, described as brown to grayish-brown coarse sand grading to dark grayish-brown at a
16 depth of 90 cm (35 in.). This soil developed under grass, sagebrush, and hopsage in coarse
17 sandy alluvial deposits that were mantled by wind-blown sand and formed hummocky terraces
18 and dune-like ridges (Duncan, et al., 2007).

19 Seismology. The recent (since 1973) seismicity of the region is characterized by occasional
20 minor (magnitude 4.3 or weaker) earthquake activity. Most seismic activity is situated near the
21 eastern margin of the Cascade Range, west of Yakima, Washington (60+mi [100 km] west of
22 the site); two events in the area near Walla Walla, Washington (59 mi [95 km] east of the site—
23 magnitude 4.1 and 4.3); and one event near the Saddle Mountains (32 mi [52 km] north of the
24 site—magnitude 4.1) (USGS, 2011a). A total of 118 small earthquakes (ranging in magnitude
25 from 2.5–4.3) have been recorded within a radius of 62 mi (100 km) of the CGS location. The
26 largest was the magnitude 4.3 event near Walla Walla in 1991, centered 58 mi (94 km) east-
27 southeast of the site. The closest events were from a cluster or “earthquake swarm” of about 20
28 recurring events, mostly in February–May 2009. The largest events in this cluster area included
29 two magnitude 3.3 events and one magnitude 3.0 event that were located approximately 4–6 mi
30 (7–9 km) south-southeast of the site at shallow depths (0–1.2 mi [0–2 km]) (USGS, 2011a).

31 However, larger, more distant earthquakes have affected the plant region in the past. Most
32 notably, the Lake Chelan (formerly named North Cascades) earthquake of 1872 was centered
33 about 108 mi (174 km) to the north-northwest of the CGS site (USGS, 2011b), (USGS, 2011c).
34 This event produced Modified Mercalli Intensity (MMI) VIII–IX shaking at its epicenter and is
35 estimated to have produced MMI VI shaking near the CGS site (USGS, 2011b). Its estimated
36 magnitude was 6.8–7.0 (USGS 2011b), (USGS, 2011c).

37 The 1936 Milton-Freewater earthquake occurred 64 mi (103 km) east-southeast of the CGS site
38 and had an estimated magnitude of 5.7 (USGS, 2011c), (Duncan, et al., 2007). An epicenter
39 intensity MMI VII event was established as the maximum earthquake for CGS. An earthquake
40 with a MMI VII epicenter intensity would be expected to cause slight damage to well-built
41 ordinary structures and negligible damage to buildings of good design and construction
42 (USGS, 2011d). The horizontal peak ground acceleration associated with this maximum
43 earthquake potential is 0.18–0.34 g (i.e., acceleration relative to that of Earth’s gravity, “g”)
44 (USGS, 2011e). The CGS FSAR (EN, 2005b) documents the use of a Safe Shutdown
45 Earthquake of 0.25 g for the plant based on a combination of deterministic and probabilistic
46 assessments.

1 NRC staff compared current peak ground acceleration data from the USGS National Seismic
 2 Hazard Mapping Project to the Safe Shutdown Earthquake. The peak ground acceleration
 3 value cited is based on a 2 percent probability of exceedance in 50 years. This corresponds to
 4 an annual frequency (chance) of occurrence of about 1 in 2,500 or 4×10^{-4} per year. For CGS,
 5 the calculated peak ground acceleration is approximately 0.17 g (USGS, 2011f).

6 **2.3 Related Federal and State Activities**

7 The staff reviewed the possibility that activities of other Federal agencies might affect the
 8 renewal of the operating license for CGS. Any such activity could result in cumulative
 9 environmental impacts and the possible need for a Federal agency to become a cooperating
 10 agency in the preparation of the CGS SEIS. However, no Federal agency has expressed the
 11 desire to become a cooperating agency in the preparation of the SEIS.

12 Given that CGS is located on DOE's Hanford Site, any significant long-term projects in the
 13 vicinity of CGS will likely have some Federal sponsorship. In addition, there are American
 14 Indian lands within 50 mi of CGS. The Yakama Indian Nation reservation is located
 15 approximately 40 mi west of the CGS site. Other Federal lands, facilities, national wildlife
 16 refuges, wilderness, and reclamation land within 50 mi of CGS are listed below:

- 17 • U.S. Department of Defense land
 - 18 – Boardman Naval Bombing Range
 - 19 – Desert Survival Training Site
 - 20 – McCord Training Annex
 - 21 – Yakama Firing Center
- 22 • U.S. Department of Energy land
 - 23 – Hanford Site
- 24 • U.S. Department of the Interior, Bureau of Indian Affairs land
 - 25 – Yakama Indian Reservation
- 26 • U.S. Department of the Interior, Bureau of Land Management land
 - 27 – Juniper Dunes Wilderness
- 28 • U.S. Department of the Interior, Bureau of Reclamation land
 - 29 – Potholes Reservoir
- 30 • U.S. Fish and Wildlife Service land
 - 31 – Cold Springs National Wildlife Refuge
 - 32 – Columbia National Wildlife Refuge
 - 33 – Hanford Reach National Monument
 - 34 – McNary National Wildlife Refuge
 - 35 – Saddle Mountain National Wildlife Refuge
 - 36 – Toppenish National Wildlife Refuge
 - 37 – Umatilla National Wildlife Refuge

38 The NRC is required, under Section 102(2)(c) of NEPA, to consult with and obtain the
 39 comments of any Federal agency that has jurisdiction by law or special expertise with respect to
 40 any environmental impact involved. The NRC has consulted with the USFWS and the NMFS.
 41 Federal Agency consultation correspondence is presented in Appendix D.

42 **2.4 References**

43 Ames, K.A., et al., "Prehistory of the Southern Plateau," *Handbook of the North American*
 44 *Indians*, Smithsonian Institute, Washington, D.C., Volume 12, 1998.

Affected Environment

- 1 *Atomic Energy Act*, § 2 U.S.C. § 2011, et seq. (1954, as amended).
- 2 Benke, A.C., and C.E. Cushings, eds, *Rivers of North America*, Elsevier Academic Press,
3 London, 2005.
- 4 Benton County Planning/Building Department (BCPD), "Benton County Comprehensive Land
5 Use Plan," adopted January 2006, Available URL: <http://www.co.benton.wa.us> (accessed
6 September 22, 2008).
- 7 Biggs, B.J., *New Zealand Periphyton Guideline: Detecting, Monitoring and Managing*
8 *Enrichment of Streams*, Ministry for the Environment, Wellington, New Zealand, 2000.
- 9 Bond, C.E., et al., "Notes on the Marine Life of the River Lamprey, *Lampetra ayresi*, in Yaquina
10 Bay, OR, and the Columbia River Estuary," *Fishery Bulletin*, 81:165–167, 1983.
- 11 Bonneville Power Administration (BPA), "Federal Columbia River Power System (FCRPS),"
12 2010, Available URL: <http://www.bpa.gov/power/pgf/hydrpnw.shtml> (accessed
13 September 13, 2010).
- 14 Cadoret, N.A., and J.C. Chatters, "*Cultural Resources Review of Project 89L-GFV-791A,*
15 *400 Area Sewage Treatment System Upgrades, HCRC #89-600-007*," Pacific Northwest
16 Laboratory, Richland, WA, 1989.
- 17 Cary, A., "Energy Northwest Considers Mixed Plutonium Fuel," *Tri-City Herald*, Kennewick, WA,
18 February 4, 2011, Available URL: [http://www.tri-cityherald.com/2011/02/04/1354173/energy-](http://www.tri-cityherald.com/2011/02/04/1354173/energy-northwest-considering-mixed.html)
19 [northwest-considering-mixed.html](http://www.tri-cityherald.com/2011/02/04/1354173/energy-northwest-considering-mixed.html) (accessed February 15, 2011).
- 20 Chatters, J.C., and K.A. Hoover, "*Office of Hanford Environment—Cultural Resources Project:*
21 *Report on Cultural Resources Site Review #87-400-003, The Proposed 400-Area Container*
22 *Test Facility*," Pacific Northwest Laboratory, Richland, WA, 1988.
- 23 City of Kennewick, Utility Services Division of Public Works, "Annual Drinking Water Quality
24 Report (Data from 2009)," Kennewick, WA, 2010, Available URL:
25 [http://go2kennewick.com/index.php?option=com_flexicontent&view=items&cid=306&id=684&Ite](http://go2kennewick.com/index.php?option=com_flexicontent&view=items&cid=306&id=684&Itemid=700)
26 [mid=700](http://go2kennewick.com/index.php?option=com_flexicontent&view=items&cid=306&id=684&Itemid=700) (accessed September 20, 2010).
- 27 City of Pasco, "*Annual Water Quality Report 2009*," *City of Pasco, WA*, 2010, Available URL:
28 www.pasco-wa.gov/generalinfo/pwwaterplant (accessed September 2010).
- 29 City of Richland, "*Water Quality Report 2009*," *City of Richland, WA*, 2010, Available URL:
30 <http://www.ci.richland.wa.us/DocumentView.aspx?DID=306> (accessed September 2010).
- 31 Clinton, William J., "Establishment of the Hanford Reach National Monument, Presidential
32 Proclamation 7319," *Federal Register*, Volume 65, No. 37253, June 9, 2000.
- 33 Cushing, C.E., Jr., "Concentration and Transport of ³²P and ⁶⁵Z by Columbia River Plankton,"
34 *Limnology and Oceanography*, 12:330–332, 1967.
- 35 Cushing, C.E., and J.D. Allan, *Streams: Their Ecology and Life*, Academic Press, San Diego,
36 CA, 2001.
- 37 Dauble, D.D., *Fishes of the Columbia Basin: A Guide to Their Natural History and Identification*,
38 Keokee Books, Sandpoint, ID, 2009.

- 1 Dauble, D.D., and D.G. Watson, *Spawning and Abundance of Fall Chinook Salmon*
 2 *(Oncorhynchus tshawytscha) in the Hanford Reach of the Columbia River, 1948–1988*, Pacific
 3 Northwest Laboratory, Richland, WA, PNL-7289, 1990.
- 4 Dauble, D.D., and D.G. Watson, “Status of Fall Chinook Salmon Populations in the Mid
 5 Columbia River, 1948–1992,” *North American Journal of Fisheries Management*, 17:283–300,
 6 1997.
- 7 Department of Commerce (DOC), “Endangered and Threatened Species; Threatened Status for
 8 Three Chinook Salmon Evolutionarily Significant Units (ESUs) in Washington and Oregon, and
 9 Endangered Status for One Chinook Salmon ESU in Washington,” Federal Register, Volume
 10 64, No. 14308, March 24, 1999.
- 11 DOC, “Endangered and Threatened Species: Final Listing Determinations for 16 ESUs of West
 12 Coast Salmon, and Final 4(d) Protective Regulations for Threatened Salmonid ESUs,” Federal
 13 Register, Volume 70, No. 37160, June 28, 2005 (2005a).
- 14 DOC, “Endangered and Threatened Species; Designation of Critical Habitat for 12 Evolutionarily
 15 Significant Units of West Coast Salmon and Steelhead in Washington, Oregon, and Idaho,”
 16 Federal Register, Volume 70, No. 52630, September 2, 2005 (2005b).
- 17 DOC, “Listing Endangered and Threatened Species: Change in Status for the Upper Columbia
 18 River Steelhead Distinct Population Segment,” Federal Register, Volume 74, No. 42605, August
 19 24, 2009.
- 20 Department of the Interior (DOI), “Endangered and Threatened Wildlife and Plants;
 21 Determination of Threatened Status for Bull Trout in the Coterminous United States,” Federal
 22 Register, Volume 64, No. 58910, November 1, 1999.
- 23 DOI, “Endangered and Threatened Wildlife and Plants; 90-Day Finding on a Petition to List
 24 Three Species of Lampreys as Threatened or Endangered,” Federal Register, Volume 69, No.
 25 77158, December 27, 2004.
- 26 DOI, “Listing Endangered and Threatened Species: Change in Status for the Upper Columbia
 27 River Steelhead Distinct Population Segment,” Federal Register, Volume 75, No. 2270, January
 28 14, 2010.
- 29 Dresel, P.E., et al., *Evaluation of Elevated Tritium Levels in Groundwater Downgradient from*
 30 *the 618-11 Burial Ground Phase I Investigations*, Pacific Northwest National Laboratory,
 31 Richland, PNNL-13228, WA, 2000.
- 32 Duncan J.P., et al., “Hanford Site National Environmental Policy Act (NEPA) Characterization,”
 33 Pacific Northwest National Laboratory, Richland, WA, PNNL-6415 Revision 18, 2007.
- 34 Duncan, J.P., et al., “Hanford Site Environmental Report for Calendar Year 2007,” Pacific
 35 Northwest National Laboratory, Richland, WA, PNNL-17603, 2008.
- 36 *Emergency Planning and Community Right-to-Know Act of 1986*, § 42 U.S.C. § 11001 (1986, as
 37 amended).
- 38 Energy Northwest (EN), “*Columbia Generating Station Landfill; Groundwater Monitoring Data*
 39 *Summary August 1995–April 2002*,” Richland, WA, 2002.

Affected Environment

- 1 EN, "Auxiliary Systems," *Columbia Generating Station Final Safety Analysis Report*, Chapter 9,
2 Amendment 57, Richland, WA, 2003 (2003a).
- 3 EN, "Ecological Monitoring Program for Columbia Generating Station, Summary Report for 1975
4 to 2002," CGS, Columbia, WA, 2003 (2003b), ADAMS Accession No. ML102380288.
- 5 EN, *Columbia Generating Station Final Safety Analysis Report*, Amendment 58, Richland, WA,
6 2005
- 7 EN, "Radiological Environmental Monitoring Program, 2008 Annual Radiological Operating
8 Report," Richland, WA, 2009.
- 9 EN, "Columbia Generating Station, License Renewal Application, Appendix E, Applicant's
10 Environmental Report, Operating License Renewal Stage," Richland, WA, Docket No. 50-391,
11 License No. NPF-21, 2010, ADAMS Accession No. ML100250666.
- 12 *Endangered Species Act*, § 16 U.S.C. § 1531, et seq. (1973, as amended).
- 13 Energy Facility Site Evaluation Council (EFSEC), "Regulatory Order No. 672 Limiting WNP-2 Air
14 Emissions," Olympia, WA, 1996.
- 15 Environmental Protection Agency (EPA), "Information on Levels of Environmental Noise
16 Requisite to Protect Public Health and Welfare with an Adequate Margin of Safety,"
17 Washington, D.C., Report 550/9-74-004, 1974, Available URL:
18 <http://www.nonoise.org/library/levels74/levels74.htm> (accessed March 2009). (See also "*EPA*
19 *Identifies Noise Levels Affecting Health and Welfare*," September 21, 2007, Available URL:
20 <http://www.epa.gov/history/topics/noise/01.htm>.)
- 21 EPA, "Emergency Planning and Community Right-to-Know Programs; Amendments to the
22 Hazardous Chemical Reporting Thresholds, Streamlining Requirements," Federal Register,
23 Volume 63, No. 31268, June 8, 1998.
- 24 EPA, "Fifth Addition, Compilation of Air Pollutant Emission Factors, Volume 1: Stationary Point
25 and Area Sources," AP 42, 2010 (2010a), Available URL: <http://www.epa.gov/ttnchie1/ap42/>,
26 (Accessed October 13, 2010).
- 27 EPA, "Office of Solid Waste," 2010 (2010b), Available URL: <http://www.epa.gov/osw/> (accessed
28 August 2010).
- 29 EPA, "Safe Drinking Water Information System (SDWIS)," County Search, Benton and Franklin
30 Counties, WA, 2010 (2010c), Available URL: <http://www.epa.gov/safewater/dwinfo/index.html>,
31 <http://water.epa.gov/drink/local/wa.cfm>, (accessed September 2010).
- 32 EPA, "Waste Environmental Management Systems," 2010 (2010d), Available URL:
33 <http://www.epa.gov/osw/inforesources/ems/index.htm> (accessed August 2010).
- 34 Federal Energy Regulatory Commission (FERC), "Final Environmental Impact Statement, Priest
35 Rapids Hydroelectric Project, Washington," Office of Energy Projects, Washington, D.C.,
36 FERC/FEIS-0190F, 2006.
- 37 Fertig, W., et al., "Rangewide Status Review of Ute Ladies'-Tresses (*Spiranthes diluvialis*),"
38 2005, Available URL:

- 1 http://www.fws.gov/mountain-prairie/species/plants/uteladiestress/SPDI_Status%20review_Fertig2005.pdf (accessed November 12, 2010).
2
- 3 Fluor Hanford (FH), "618-10 and 618-11 Burial Ground Remedial Design Technical Workshop
4 Summary Report," Richland, WA, WMP-17684, 2003.
- 5 Fuller, N.G., *National Register of Historic Places Inventory-Nomination Form for Federal
6 Properties*, United States Department of the Interior National Park Service, Benton County, WA,
7 1974.
- 8 Gambhir, S.K., Vice President, Technical Services, EN, letter to NRC in response to letters from
9 W.S. Oxenford dated January 19, 2010 and D. Doyle dated July 2, 2010, "Subject: Columbia
10 Generating Station, Docket No. 50-397 Response to Request for Additional Information License
11 Renewal Application," G02-10-105, August 5, 2010 (2010a), ADAMS Accession
12 No. ML102300503.
- 13 Gambhir, S.K., Vice President, Technical Services, EN, letter to NRC in response to letters from
14 W.S. Oxenford dated January 19, 2010 and D. Doyle dated July 8, 2010, "Subject: Columbia
15 Generating Station, Docket No. 50-397 Response to Request for Additional Information License
16 Renewal Application," G02-10-108, August 9, 2010 (2010b), ADAMS Accession
17 No. ML102380285.
- 18 Golder Associates (Golder), "RCRA Facility Investigation Report Supply System Nuclear Power
19 Plant No. 2 Landfill Hanford Site, Washington," Richland, WA, 1995.
- 20 Gray, R.H., and D.D. Dauble, "Checklist and Relative Abundance of Fish Species from the
21 Hanford Reach of the Columbia River," *Northwest Science*, 51:208–215, 1977.
- 22 Hale, L.L., "Cultural Resources Report Narrative #98-0600-024, WPPSS Industrial Sites,"
23 Hanford Cultural Resources Laboratory, Richland, WA, 1998.
- 24 Hale, L.L., "Draft Cultural Resources Report Narrative—The Dunes Archaeological Block
25 Survey (HCRC #99-0600-009)," Pacific Northwest National Laboratory, Richland, WA, 1999.
- 26 Hanf, R.W., et al., "*Hanford Site Environmental Report for Calendar Year 2004*," Pacific
27 Northwest National Laboratory, Richland, WA, PNNL-15222, 2005.
- 28 Hanf, R.W., et al., "*Hanford Site Environmental Report for Calendar Year 2005*," Pacific
29 Northwest National Laboratory, Richland, WA, PNNL-15892, 2006.
- 30 Hanf, R.W., et al., "*Hanford Site Environmental Report for Calendar Year 2006*," Pacific
31 Northwest National Laboratory, Richland, WA, PNNL-16623, 2007.
- 32 Hershler, R., and T.J. Frest, "A Review of the North American Freshwater Snail Genus
33 *Fluminicola* (*Hydrobiidae*)," Smithsonian Contributions to Zoology, No. 583, Smithsonian
34 Institution Press, Washington, D.C., 1996.
- 35 Higgs, D.A., et al., "Nutrition and Feeding Habits in Relation to Life History Stage," *Physiological
36 Ecology of Pacific Salmon*, Eds. C. Groot, L. Margolis, and W.C. Clarke, UBC Press,
37 Vancouver, 1995.

Affected Environment

- 1 Hobbs, H.H., Jr., *A Checklist of the North and Middle American Crayfishes (Decapoda:*
2 *Astacidae and Cambaridae)*, Smithsonian Contributions to Zoology, No. 166, Smithsonian
3 Institution Press, Washington, D.C., 1974.
- 4 Hoitink, D.J., et al., "Hanford Site Climatological Summary 2004 with Historical Data," Pacific
5 Northwest National Laboratory, Richland, WA, PNNL-15160, 2005.
- 6 HydroGEOPHYSICS Inc. (HGI), "Site Hydrogeologic Conceptual Model Columbia Generating
7 Station Richland, Washington," Richland, WA, 2008.
- 8 Institute of Educational Science (IES), U.S. Department of Education, National Center for
9 Educational Statistics, "College Opportunities Online Locator," Zip Code 99352 and 99354,
10 August 4, 2010, Available URL: <http://nces.ed.gov/ipeds/cool/RefineSearch.aspx> (accessed
11 October 2010).
- 12 Jackson, J.B., and G.D. Hartmann, *Archaeological Survey from Lower Monumental Substation*
13 *to Ashe Substation*, Archaeological Research Center, Pullman, WA, 1977.
- 14 Johnson, D.A. and T. O'Neil, *Wildlife-Habitat Relationships in Oregon and Washington*, Oregon
15 State University Press, Corvallis, OR, 2001.
- 16 Kennewick School District, "Kennewick School District, 2010/2011 Budget," Kennewick, WA,
17 June 23, 2010, Available URL:
18 [http://www.ksd.org/departments/business/Financial%20Information/KSD%20Adopted%20Budge](http://www.ksd.org/departments/business/Financial%20Information/KSD%20Adopted%20Budget%202010-2011.pdf)
19 [t%202010-2011.pdf](http://www.ksd.org/departments/business/Financial%20Information/KSD%20Adopted%20Budget%202010-2011.pdf) (accessed October 2010).
- 20 Lindsey, K.A., *The Miocene to Pliocene Ringold Formation and Associated Deposits of the*
21 *Ancestral Columbia River System, South-Central Washington and North-Central Oregon*,
22 Washington State Department of Natural Resources, Olympia, WA, 1996.
- 23 Link, S.O., "Rare Plant and Vegetation Survey of the Columbia River Riparian Zone at the
24 Columbia Generating Station," Environmental Solutions, Richland, WA, 2008, ADAMS
25 Accession No. ML102380288.
- 26 Link, S.O., "Rare Plant and Vegetation Survey of the Uplands at Columbia Generating Station,"
27 Environmental Solutions, Richland, WA, 2009, ADAMS Accession No. ML102380288.
- 28 McClory, J.G., and T.A. Gotthardt, "State Conservation Status, Element Ecology & Life History,"
29 Alaska Natural Heritage Program, Environment and Natural Resources Institute, University of
30 Alaska Anchorage, Anchorage, AK, 2005, Available URL:
31 http://aknhp.uaa.alaska.edu/zoology/pdfs/fishes/River_lamprey.pdf (accessed
32 September 11, 2010).
- 33 Meeuwig, M.H., et al., "Identification of Larval Pacific Lampreys (*Lampetra tridentata*), River
34 Lampreys (*L. ayresi*), and Western Brook Lampreys (*L. richardsoni*) and Thermal Requirements
35 of Early Life History Stages of Lampreys," Project No. 2000-02900, BPA Report
36 DOE/BP-00004695-2, 2002.
- 37 Miley, T.B., et al., "Current Conditions Risk Assessment for the 300-FF-5 Groundwater
38 Operable Unit," Pacific Northwest National Laboratory, Richland, WA, PNNL-16454 Revision 0,
39 2007.

- 1 Minthorn, P.E., and J.C. Chatters, "WPPSS Fiberoptic Telecommunications Cable, (HCRC
2 #90-600-012)," Pacific Northwest Laboratories, Richland, WA, 1990.
- 3 Mueller, R.P. and D.R. Geist, "Steelhead Spawning Surveys near Locke Island, Hanford Reach
4 of the Columbia River," Pacific Northwest National Laboratory (PNNL-13055), Richland, WA,
5 1999.
- 6 National Marine Fisheries Service (NMFS), "Biological Opinion and Magnuson-Steven Fishery
7 Conservation and Management Act, New License for the Priest Rapids Hydroelectric Project,"
8 Northwest Division, Seattle, WA, 2004.
- 9 NMFS, "Endangered Species Act, Section 7(a)(2) Consultation, Supplemental Biological
10 Opinion: Supplemental Consultation on Remand for Operation of the Federal Columbia River
11 Power System, 11 Bureau of Reclamation Projects in the Columbia Basin and ESA
12 Section 10(a)(1)(A) Permit for Juvenile Fish Transportation Program," Northwest Region,
13 Seattle, WA, F/NWR/2010/02096, 2010.
- 14 Nedeau, E., et al., *Freshwater Mussels of the Pacific Northwest*, 2nd Edition, The Xerces
15 Society, Portland, OR, 2009, Available URL:
16 http://www.xerces.org/wp-content/uploads/2009/06/pnw_mussel_guide_2nd_edition.pdf
17 (accessed September 12, 2010).
- 18 Neitzel, D.A., et al., "Mid-Columbia River Microflora," *Journal of Freshwater Ecology*, 1(5):495–
19 505, 1982a.
- 20 Neitzel, D.A., et al., "Mid-Columbia River Zooplankton," *Northwest Science*, 57:112–118, 1982b.
- 21 Newell, R.L., "Aquatic Macroinvertebrates," *Biodiversity Studies of the Hanford Site, Final*
22 *Report: 2002–2003*, Eds. J.R. Evans, M.P. Lih, and P.W. Dunwiddie, The Nature Conservancy
23 of Washington, Seattle, WA, 2003.
- 24 Nez Perce, Umatilla, Yakama, and Warm Springs Tribes, "Tribal Pacific Lamprey Restoration
25 Plan for the Columbia River Basin," Formal Draft, May 15, 2008.
- 26 Nuclear Energy Institute (NEI), "Process for Performing Follow-on PRA Peer Reviews Using the
27 ASME PRA Standard," Washington, D.C., NEI 05-04, Revision 1 (Draft G), 2007.
- 28 Office of Superintendent of Public Instruction (OSPI), State of Washington, "Washington State
29 Report Card, Richland School District," Richland, WA, 2010, Available URL:
30 <http://reportcard.ospi.k12.wa.us/summary.aspx?schoold=23&reportLevel=District&o&year=2009-10>
31 (accessed October 2010).
- 32 Pasco Public School District, "Your Pasco Schools Annual Community Report, Pasco School
33 District #1," Pasco, WA, 2010, Available URL:
34 [http://www.psd1.org/18881012912951510/lib/18881012912951510/Annual_Comm_Report_Half](http://www.psd1.org/18881012912951510/lib/18881012912951510/Annual_Comm_Report_Half-Letter2_ENGLISH.pdf)
35 [-Letter2_ENGLISH.pdf](http://www.psd1.org/18881012912951510/lib/18881012912951510/Annual_Comm_Report_Half-Letter2_ENGLISH.pdf) (accessed October 2010).
- 36 Porter, R., "Report on the Predation Index, Predator Control Fisheries, and Program Evaluation
37 for the Columbia River Basin Experimental Northern Pikeminnow Management Program,"
38 Pacific States Marine Fisheries Commission, Portland, OR, 2009.

Affected Environment

- 1 Poston, T.M., et al., "Hanford Site Environmental Report for Calendar Year 2003," Pacific
2 Northwest National Laboratory, Richland, WA, PNNL-14687, 2004.
- 3 Poston, T.M., et al., "Hanford Site Environmental Report for Calendar Year 2007," Pacific
4 Northwest National Laboratory, Richland, WA, PNNL-17603, 2008.
- 5 Poston, T.M., et al., "Hanford Site Environmental Report for Calendar Year 2008," Pacific
6 Northwest National Laboratory, Richland, WA, PNNL-18427, 2009.
- 7 Prendergast-Kennedy, E., "Cultural Resources Review for Security Upgrades/Easement to
8 Energy Northwest (HCRC# 2002-600-021)," Pacific Northwest National Laboratory,
9 Richland, WA, May, 13, 2002, ADAMS Accession No. ML102380296.
- 10 Prendergast-Kennedy, E., "Cultural Resources Review of Restoration and Maintenance of
11 Bonneville Power Association (BPA) Access Roads Lower Monumental Ashe Powerline
12 (HCHR# 2003-600-013)," Pacific Northwest National Laboratory, Richland, WA, 2003.
- 13 Prendergast-Kennedy, E., "Cultural Resources Review and Inventory of Bonneville Power
14 Administration (BPA) Road Maintenance and Improvement Project: Benton Switch Access Road
15 Improvement (2005-600-034)," Pacific Northwest National Laboratory, Richland, WA, 2005.
- 16 Prendergast-Kennedy, E., "Notice to Proceed: Columbia Generating Station access road
17 improvements along existing disturbed road shoulder and fire-break at Energy Northwest
18 (NPCE#2008-600-026)," Pacific Northwest National Laboratory, Richland, WA, July 16, 2008,
19 ADAMS Accession No. ML102380296.
- 20 *Resource Conservation and Recovery Act (RCRA)*, § 42 U.S.C. § 6901, et seq. (1976, as
21 amended).
- 22 Rice, D.G., "Archaeological Investigations at Washington Public Power Supply System Nuclear
23 Plants on the Hanford Reservation, Washington," Richland, WA, 1983.
- 24 Smith, W.C., et al., "An Archaeological-Historical Survey of the Proposed Transmission Power
25 Line Corridor from Ashe Substation, Washington, to Pebble Springs Substation, Oregon,"
26 Archaeological Research Center, Pullman, WA, 1977.
- 27 Steinmetz, S., "A Cultural Resource Inventory of the Hanford Dune Area North of 300 Area,
28 Benton County, Washington," Pendleton, OR, 2005.
- 29 Suzumoto, Bruce, Assistant Regional Administrator, Hydropower Division, NMFS, letter to Bo
30 Pham, NRC, "Columbia Generating Station license renewal, request for species list for
31 consultation," June 23, 2010, ADAMS Accession No. ML101830405.
- 32 The Nature Conservancy (TNC), "Biodiversity Studies of the Hanford Site, Final Report: 2002–
33 2003," The Nature Conservancy, Seattle, WA, 2003.
- 34 Thorne, P.D., "Summary of Hydrogeology and Evaluation of Existing Groundwater Monitoring
35 Wells for Outfalls 002 and 003 at the Columbia Generating Station," Pacific Northwest Division,
36 Richland, WA, PNWD-3845, 2007.
- 37 Tri-City Industrial Development Council (TRIDEC), "Tri-Cities Washington Factsheet.
38 Kennewick, Washington," 2010, Available URL: http://www.tridec.org/about_tri_cities/fact_sheet/
39 (accessed September 2010).

- 1 U.S. Atomic Energy Commission (AEC), “Final Environmental Statement Related to the
2 Proposed Hanford Number Two Nuclear Power Plant,” Docket No. 50-397, 1972, ADAMS
3 Accession No. ML101870543.
- 4 U.S. Census Bureau (USCB), “American FactFinder, Census 2000 and 2006–2008, 3-Year
5 Estimate, American Community Survey, State and County QuickFacts on Benton and Franklin
6 Counties,” 2010, Available URLs: <http://factfinder.census.gov> and <http://quickfacts.census.gov>
7 (accessed September 2010).
- 8 *U.S. Code of Federal Regulations* (CFR), “Environmental Protection Agency”, Part 1, Title 40,
9 “Protection of the Environment,” Subchapter I, “Solid Wastes.”
- 10 *CFR*, “Standards for Protection Against Radiation,” Part 20, Title 10, “Energy.”
- 11 *CFR*, “Domestic Licensing of Production and Utilization Facilities,” Part 50, Title 10, “Energy.”
- 12 *CFR*, “Licensing Requirements for Land Disposal of Radioactive Waste,” Part 60, Chapter 1,
13 Title 10, “Energy.”
- 14 *CFR*, “Packaging and Transportation of Radioactive Material,” Part 70, Chapter 1, Title 10,
15 “Energy.”
- 16 *CFR*, “Designation of Areas for Air Quality Planning Purposes,” Part 80, Chapter 1, Title 40,
17 “Protection of the Environment.”
- 18 *CFR*, “Hazardous Waste Management System: General,” Part 260, Title 40, “Protection of the
19 Environment.”
- 20 *CFR*, “Identification and Listing of Hazardous Waste,” Part 261, Title 40, “Protection of the
21 Environment.”
- 22 *CFR*, “Standard Applicable to Transporters of Hazardous Waste,” Part 262, Title 40, “Protection
23 of the Environment.”
- 24 *CFR*, “Standards Management of Specific Hazardous Wastes and Specific Types of Hazardous
25 Waste Management Facilities,” Part 266, Title 40, “Protection of the Environment.”
- 26 *CFR*, “Standard for Universal Waste Management,” Part 273, Title 40, “Protection of the
27 Environment.”
- 28 *CFR*, “Protection of Historic Properties,” Part 800, Title 36, “Parks, Forests and Public Property.”
- 29 U.S. Department of Agriculture (USDA), National Agricultural Statistics Service (NASS), “2002
30 Census of Agriculture,” Volume 1, Chapter 2, “County Level Data for Washington,” Table 1:
31 “County Highlights: 2002” and Table 7: “Hired Farm Labor--Workers and Payroll: 2002,” Last
32 modified November 24, 2008, Available URL:
33 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
34 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
35 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
36 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
37 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
38 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
39 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
40 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
41 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
42 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
43 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
44 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
45 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
46 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
47 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
48 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
49 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
50 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
51 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
52 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
53 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
54 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
55 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
56 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
57 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
58 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
59 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
60 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
61 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
62 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
63 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
64 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
65 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
66 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
67 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
68 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
69 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
70 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
71 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
72 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
73 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
74 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
75 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
76 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
77 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
78 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
79 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
80 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
81 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
82 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
83 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
84 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
85 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
86 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
87 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
88 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
89 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
90 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
91 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
92 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
93 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
94 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
95 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
96 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
97 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
98 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
99 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
100 http://www.agcensus.usda.gov/Publications/2002/Volume_1,_Chapter_2_County_Level/Washin
- 35 USDA, NASS, “2007 Census of Agriculture,” Volume 1 Chapter 2, “County Level Data for
36 Washington,” Table 1: “County Summary Highlights: 2007” and Table 7: “Hired Farm Labor—
37 Workers and Payroll: 2007,” Released February 4, 2009, and updated December 2009,
38 Available URL:

Affected Environment

- 1 http://www.agcensus.usda.gov/Publications/2007/Full_Report/Volume_1,_Chapter_2_County_Level/Washington/index.asp (accessed September 2010).
- 2
- 3 U.S. Department of Energy (DOE), "Threatened and Endangered Species Management Plan:
4 Salmon and Steelhead," Richland Operations Office, Richland, WA, DOE/RL-2000-27,
5 Revision 0, 2000.
- 6 DOE, "Sitewide Institutional Controls Plan for Hanford CERCLA Response Actions," Fluor
7 Hanford, Inc., United States Department of Energy, Richland, WA, DOE/RL-2001-41, 2002
8 (2002a).
- 9 DOE, The Hanford Site Historic District, Manhattan Project 1943-1946, Cold War Era
10 1947-1990, Hanford Cultural and Historic Resources Program, Richland, WA, 2002 (2002b).
- 11 DOE, "Hanford Site Risk-Based End State Vision," Richland, WA, DOE/RL-2003-59, DRAFT,
12 2003.
- 13 DOE, "Initial Single-Shell Tank System Performance Assessment for the Hanford Site,"
14 Richland, WA, DOE/ORP-2005-01, Revision 0, 2005.
- 15 DOE, "Hanford Site Groundwater Monitory for Fiscal Year 2007," Richland, WA,
16 DOE/RL-2008-01, Revision 0, 2008.
- 17 DOE, "Memorandum of Agreement (MOA) for the Rattlesnake Mountain Combined Community
18 Communication Facility and Infrastructure Cleanup on the Fitzner/Eberhardt Arid Lands Ecology
19 Reserve Hanford Site, Richland, WA Between the U.S. Department of Energy and The
20 Washington State Historic Preservation Office with the Participation of Consulting Parties:
21 Confederated Tribes and Bands of the Yakama Nation, Confederated Tribes of the Umatilla
22 Indian Reservation, the Nez Perce Tribe, and the Wanapum. Richland, Washington."
23 Appendix B in *Environmental Assessment: Combined Community Communications Facility and
24 Infrastructure Cleanup on the Fitzner/Eberhardt Arid Lands Ecology Reserve, Hanford Site,
25 Richland Washington*, Richland Operations Office, Richland, WA, DOE/EA-1660F, 2009,
26 Available URL: http://nepa.energy.gov/documents/EA-1660_Final.pdf.
- 27 U.S. Fish and Wildlife Service (USFWS), "Biological Opinion for the Priest Rapids Project
28 License Renewal, Federal Energy Regulatory Commission," Central Washington Field Office,
29 Wenatchee, WA, 13260-2007-F-0062 and 13260-2006-P-0008, 2007.
- 30 USFWS, "Hanford Reach National Monument Final Comprehensive Conservation Plan and
31 Environmental Impact Statement Adams, Benton, Grant and Franklin Counties, Washington,"
32 2008, Available URL:
33 <http://astro.berkeley.edu/~kalas/ethics/documents/environment/final-ccp-no-maps.pdf>.
- 34 USFWS, "Hanford Reach National Monument," 2010 (2010a), Available URL:
35 <http://www.fws.gov/hanfordreach/index.html> (accessed October 27, 2010).
- 36 USFWS, "Listed and Proposed Endangered and Threatened Species and Critical Habitat;
37 Candidate Species; and Species of Concern in Benton County," USFWS Central Washington
38 Field Office, Revised September 29, 2010 (2010b), Available URL:
39 <http://www.fws.gov/wafwo/pdf/BentonCounty092910.pdf> (accessed November 5, 2010).

- 1 USFWS, "National Wetlands Inventory," 2010 (2010c), Available URL:
2 <http://www.fws.gov/wetlands> (accessed October 27, 2010).
- 3 USFWS, "Species Assessment and Listing Priority Assignment Form: *Coccyzus americanus*,
4 Yellow-billed Cuckoo, Western United States Distinct Population Segment," 2010 (2010d),
5 Available URL: http://ecos.fws.gov/docs/candforms_pdf/r8/B06R_V01.pdf, (accessed
6 November 12, 2010).
- 7 USFWS, "Species Assessment and Listing Priority Assignment Form: *Eriogonum codium*,
8 Umtanum Desert Buckwheat," 2010 (2010e), Available URL:
9 http://ecos.fws.gov/docs/candforms_pdf/r1/Q3HN_P01.pdf, (accessed November 12, 2010).
- 10 USFWS, "Species Profile: Bull Trout (*Salvelinus confluentus*)," 2010 (2010f), Available URL:
11 <http://ecos.fws.gov/speciesProfile/profile/speciesProfile.action?spcode=E065> (accessed
12 September 12, 2010).
- 13 USFWS, "Species Reports: Listings and Occurrences for Washington," 2010 (2010g), Available
14 URL:
15 [http://ecos.fws.gov/tess_public/pub/stateListingAndOccurrenceIndividual.jsp?state=WA&s8fid=1](http://ecos.fws.gov/tess_public/pub/stateListingAndOccurrenceIndividual.jsp?state=WA&s8fid=12761032792&s8fid=112762573902&s8fid=24012843018782)
16 [12761032792&s8fid=112762573902&s8fid=24012843018782](http://ecos.fws.gov/tess_public/pub/stateListingAndOccurrenceIndividual.jsp?state=WA&s8fid=12761032792&s8fid=112762573902&s8fid=24012843018782) (accessed September 12, 2010).
- 17 U.S. Geological Survey (USGS), "Summary Statistics for NASQAN Data—Columbia Basin
18 1996–2003, Columbia River at Vernita Bridge, Near Priest Rapids Dam, Washington
19 (12472900)," 2006, Available URL: <http://water.usgs.gov/nasqan/data/statsum/vernita.html>
20 (accessed September 3, 2008).
- 21 USGS, "Online Report—USGS Surface-Water Monthly Statistics for Washington. USGS
22 12472800 Columbia River Below Priest Rapids Dam, WA," 2010, Available URL:
23 [http://waterdata.usgs.gov/wa/nwis/monthly?referred_module=sw&site_no=12472800&](http://waterdata.usgs.gov/wa/nwis/monthly?referred_module=sw&site_no=12472800&por_12472800_22=1180614,00060,22,1917-10,2009-09&start_dt=1960-01&end_dt=2008-12&format=html_table&date_format=YYYY-MM-DD&rdb_compression=file&submitted_form=parameter_selection_list)
24 [por_12472800_22=1180614,00060,22,1917-10,2009-09&](http://waterdata.usgs.gov/wa/nwis/monthly?referred_module=sw&site_no=12472800&por_12472800_22=1180614,00060,22,1917-10,2009-09&start_dt=1960-01&end_dt=2008-12&format=html_table&date_format=YYYY-MM-DD&rdb_compression=file&submitted_form=parameter_selection_list)
25 [start_dt=1960-01&end_dt=2](http://waterdata.usgs.gov/wa/nwis/monthly?referred_module=sw&site_no=12472800&por_12472800_22=1180614,00060,22,1917-10,2009-09&start_dt=1960-01&end_dt=2008-12&format=html_table&date_format=YYYY-MM-DD&rdb_compression=file&submitted_form=parameter_selection_list)
26 [008-12&format=html_table&date_format=YYYY-MM-DD&rdb_compression=file&](http://waterdata.usgs.gov/wa/nwis/monthly?referred_module=sw&site_no=12472800&por_12472800_22=1180614,00060,22,1917-10,2009-09&start_dt=1960-01&end_dt=2008-12&format=html_table&date_format=YYYY-MM-DD&rdb_compression=file&submitted_form=parameter_selection_list)
[submitted_form=parameter_selection_list](http://waterdata.usgs.gov/wa/nwis/monthly?referred_module=sw&site_no=12472800&por_12472800_22=1180614,00060,22,1917-10,2009-09&start_dt=1960-01&end_dt=2008-12&format=html_table&date_format=YYYY-MM-DD&rdb_compression=file&submitted_form=parameter_selection_list) (accessed July 27, 2010).
- 27 USGS, "Circular Area Earthquake Search," NEIC: Earthquake Search Results, USGS
28 Earthquake Database (search parameters: USGS/NEIC (PDE) 1973 Database, Latitude 46.472
29 N, Longitude 119.333 W), Earthquake Hazards Program, National Earthquake Information,
30 2011 (2011a), Available URL:
31 http://earthquake.usgs.gov/earthquakes/eqarchives/epic/epic_circ.php (accessed
32 June 14, 2011).
- 33 USGS, "Historic US Earthquakes," "1872 Lake Chelan Earthquake," Earthquake Hazards
34 Program, National Earthquake Information, 2011 (2011b), Available URL:
35 http://earthquake.usgs.gov/earthquakes/states/events/1872_12_15.php (accessed
36 June 14, 2011).
- 37 USGS, "Circular Area Earthquake Search," USHIS: Earthquake Search Results, USGS
38 Earthquake Database (search parameters: USGS/Significant U.S. Earthquakes (USHIS),
39 Latitude 46.472 N, Longitude 119.333 W), Earthquake Hazards Program, National Earthquake
40 Information, 2011 (2011c), Available URL:
41 http://earthquake.usgs.gov/earthquakes/eqarchives/epic/epic_circ.php (accessed
42 June 14, 2011).

Affected Environment

- 1 USGS, "Magnitude/Intensity Comparison," Earthquake Hazards Program, 2011 (2011d),
2 Available URL: http://earthquake.usgs.gov/learning/topics/mag_vs_int.php (accessed
3 June 14, 2011).
- 4 USGS, "Shakemap Scientific Background," Earthquake Hazards Program, National Earthquake
5 Information, 2011 (2011e), Available URL:
6 <http://earthquake.usgs.gov/earthquakes/shakemap/background.php> (accessed June 14, 2011).
- 7 USGS, "Geologic Hazards Team Interactive Map Server, National Seismic Hazard Maps—
8 2008," 2011 (2011f), Available URL: <http://gldims.cr.usgs.gov/> (accessed June 14, 2011).
- 9 U.S. Nuclear Regulatory Commission (NRC), "Final Environmental Statement Related to the
10 Operation of WPPSS Nuclear Project No. 2," Office of Nuclear Reactor Regulation, Washington,
11 D.C., NUREG-0812, 1981, ADAMS Accession No. ML100570374.
- 12 NRC, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants,"
13 Washington, D.C., NUREG-1437, Volumes 1 and 2, 1996, ADAMS Accession
14 Nos. ML040690705 and ML040690738.
- 15 Vermeul, V.R., et al., "Evaluation of the Fate and Transport of Tritium Contaminated
16 Groundwater from the 618-11 Burial Ground," Pacific Northwest National Laboratory,
17 Richland, WA, PNNL-15293, 2005.
- 18 Walker D.E., and R. Sprague, "History Until 1846," *Handbook of the North American Indians*,
19 *Volume 12*, Ed. D.E. Walker, Smithsonian Institute, Washington, D.C., 1998.
- 20 *Washington Administrative Code (WAC)*, "Dangerous Waste Regulations," Title 173, Chapter
21 303, "Department of Ecology."
- 22 *WAC*, "General and Operating Permit Regulations for Air Pollution Sources," Title 436, Chapter
23 78, "Energy Facility Site Evaluation."
- 24 Washington Department of Fish and Wildlife (WDFW), "Washington's Comprehensive Wildlife
25 Conservation Strategy, Final Draft," 2005, Available URL:
26 http://wdfw.wa.gov/publications/00727/volumeone_chaptersi-iii.pdf (accessed
27 October 27, 2010).
- 28 WDFW, "Priority Habitats and Species List," 2010 (2010a), Available URL:
29 <http://wdfw.wa.gov/conservation/phs/list/> (accessed September 12, 2010).
- 30 WDFW, "Washington State Sport Catch Report 2003," Olympia, WA, 2010 (2010b).
- 31 WDFW, "WDFW Conducting Boat Checks to Stop Aquatic Invasive Species," Olympia, WA,
32 2010 (2010c), Available URL: <http://wdfw.wa.gov/news/release.php?id=jun1510a> (accessed
33 September 14, 2010).
- 34 Washington Department of Natural Resources (WDNR), "State of Washington Natural Heritage
35 Plan 2007," 2007, Available URL: http://www.dnr.wa.gov/Publications/amp_nh_plan_2007.pdf
36 (accessed October 27, 2010).
- 37 WDNR, "State of Washington Natural Heritage Plan 2009 Update," 2009, Available URL:
38 http://www.dnr.wa.gov/Publications/amp_nh_plan_2009.pdf (accessed October 27, 2010).

- 1 Washington Department of Revenue (WDOR), Research Division, "Tax Reference Manual,
2 Information on State and Local Taxes In Washington State," 2010, Available URL:
3 [http://dor.wa.gov/docs/reports/2010/Tax_Reference_2010/TRM%202010%20-%20Entire%20Do](http://dor.wa.gov/docs/reports/2010/Tax_Reference_2010/TRM%202010%20-%20Entire%20Document.pdf)
4 [cument.pdf](http://dor.wa.gov/docs/reports/2010/Tax_Reference_2010/TRM%202010%20-%20Entire%20Document.pdf), January
- 5 Washington Invasive Species Council (WISC), "Washington Invasive Species Council Annual
6 Report—2009," Olympia, WA, 2009, Available URL:
7 http://www.invasivespecies.wa.gov/documents/2009annual_report.pdf.
- 8 Washington Office of Financial Management (WOFM), "2009 Population Trends,"
9 September 2009, Available URL: <http://www.ofm.wa.gov/pop/april1/poptrends.pdf> (accessed
10 October 2010).
- 11 Washington Public Power Supply System (WPPSS), "Environmental Report, Operating License
12 Stage Docket No. 50-397, WPPSS Nuclear Project No. 2," Richland, WA, 1980, Accession
13 No. ML102180050.
- 14 WPPSS, "Technical Review of the Aquatic Monitoring Program of WNP-2," Richland, WA, 1982.
- 15 WPPSS, "Ecological Monitoring Program for Nuclear Plant 2—1985 Annual Report,"
16 Richland, WA, 1986.
- 17 WPPSS, "Operational Ecological Monitoring Program for Nuclear Plant 2—1986 Annual
18 Report," Richland, WA, 1987.
- 19 WPPSS, "Operational Ecological Monitoring Program for Nuclear Plant 2—1987 Annual
20 Report," 1988, ADAMS Accession No. ML102380289.
- 21 WPPSS, "Supply System Nuclear Plant No. 2 (WNP-2) Final Report on Groundwater Monitoring
22 Program," Richland, WA, 1999.
- 23 Washington State Department of Ecology (WDOE), "2008 303(d) Impaired and Threatened
24 Water Body Maps," 2008, Available URL:
25 <http://www.ecy.wa.gov/services/gis/maps/wria/303d/303d.htm> (accessed May 19, 2009).
- 26 Washington State Department of Transportation (WDOT), "2009 Annual Traffic Report," 2010,
27 Available URL:
28 http://www.wsdot.wa.gov/mapsdata/tto/PDF_and_ZIP_Files/Annual_Traffic_Report_2009.pdf
29 (accessed October 2010).
- 30 Watson, D.G., *Fall Chinook Salmon Spawning in the Columbia River Near Hanford 1947–1969*,
31 Pacific Northwest Laboratory, Richland, WA, BNWL-1515, 1970.
- 32 Watson, D.G., *Fall Chinook Salmon Population Census*, Pacific Northwest Laboratory,
33 Richland, WA, BNWL-1750, 1973.
- 34 Western Regional Climate Center (WRCC), "Climate of Washington," 2010, Available URL:
35 <http://www.wrcc.dri.edu/narratives/WASHINGTON.htm> (accessed July 16, 2010).

Affected Environment

- 1 Wolf, E.G., "Characterization of the Benthos Community," *Final Report on Aquatic Ecological*
- 2 *Studies Conducted at the Hanford Generating Project*, Battelle, Pacific Northwest Laboratories
- 3 for United Engineers and Constructors, Inc. for WPPSS, Richland, WA, 1976.

- 4 Wydoski, R.S., and R.L. Whitney, *Inland Fishes of Washington*, American Fisheries Society and
- 5 University of Washington Press, Second Edition, 2003.

3.0 ENVIRONMENTAL IMPACTS OF REFURBISHMENT

License renewal actions include refurbishment for the extended plant life. These actions may have an impact on the environment that requires evaluation, depending on the type of action and the plant-specific design. Environmental issues associated with refurbishment, which were determined to be Category 1 issues, are listed in Table 3-1.

The U.S. Nuclear Regulatory Commission (NRC) staff analyzed site-specific issues (Category 2) for Columbia Generating Station (CGS) and assigned them a significance level of SMALL, MODERATE, or LARGE, or not applicable to CGS because of site characteristics or plant features. Section 1.4 in Chapter 1 explains the criteria for Category 1 and Category 2 issues and defines the impact designations of SMALL, MODERATE, and LARGE.

Table 3-1. Category 1 issues for refurbishment evaluation

| ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B | GEIS sections |
|---|----------------------------------|
| Surface water quality, hydrology, and use (for all plants) | |
| Impacts of refurbishment on surface water quality | 3.4.1 |
| Impacts of refurbishment on surface water use | 3.4.1 |
| Aquatic ecology (for all plants) | |
| Refurbishment | 3.5 |
| Groundwater use and quality | |
| Impacts of refurbishment on groundwater use and quality | 3.4.2 |
| Land use | |
| Onsite land use | 3.2 |
| Human health | |
| Radiation exposures to the public during refurbishment | 3.8.1 |
| Occupational radiation exposures during refurbishment | 3.8.2 |
| Socioeconomics | |
| Public services: public safety, social services, and tourism and recreation | 3.7.4; 3.7.4.3; 3.7.4.4; 3.7.4.6 |
| Aesthetic impacts (refurbishment) | 3.7.8 |

Environmental issues related to refurbishment considered in NUREG-1437, "Generic Environmental Impact Statement (GEIS) for License Renewal of Nuclear Plants," Volumes 1 and 2 (NRC 1996) that are inconclusive for all plants, or for specific classes of plants, are Category 2 issues. Table 3-2 lists these issues.

1

Table 3-2. Category 2 issues for refurbishment evaluation

| ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1 | GEIS sections | 10 CFR 51.53 (c)(3)(ii) Subparagraph |
|--|----------------------|---|
| Terrestrial resources | | |
| Refurbishment impacts | 3.6 | E |
| Threatened or endangered species (for all plants) | | |
| Threatened or endangered species | 3.9 | E |
| Air quality | | |
| Air quality during refurbishment (nonattainment and maintenance areas) | 3.3 | F |
| Socioeconomics | | |
| Housing impacts | 3.7.2 | I |
| Public services: public utilities | 3.7.4.5 | I |
| Public services: education (refurbishment) | 3.7.4.1 | I |
| Offsite land use (refurbishment) | 3.7.5 | I |
| Public services, transportation | 3.7.4.2 | J |
| Historic and archaeological resources | 3.7.7 | K |
| Environmental justice | | |
| Environmental justice ^(a) | Not addressed | Not addressed |

^(a) Guidance related to environmental justice was not in place at the time the U.S. Nuclear Regulatory Commission (NRC) prepared the GEIS and the associated revision to 10 CFR Part 51. If an applicant plans to undertake refurbishment activities for license renewal, the applicant's environmental report (ER) and the staff's environmental impact statement must address environmental justice.

2 The potential environmental effects of refurbishment actions are noted, and the analysis will be
 3 summarized within this section, if such actions are planned. Energy Northwest stated that it has
 4 performed an evaluation of systems, structures, and components under Section 54.21 of
 5 Title 10 of the *Code of Federal Regulations* (10 CFR 54.21) to note the need to undertake any
 6 major refurbishment activities that are necessary to support continued operation of Columbia
 7 Generating Station (CGS) during the requested 20-year period of extended operation.
 8 Table B.2 of the GEIS lists items that are subject to aging and might require refurbishment to
 9 support continued operation during the renewal period.

10 The results of the evaluation of systems, structures, and components for CGS, as required by
 11 10 CFR 54.21, do not currently note the need to undertake any major refurbishment or
 12 replacement actions associated with license renewal to support the continued operation of CGS
 13 beyond the end of the existing operating license.

14 **3.1 References**

15 *U.S. Code of Federal Regulations* (CFR), "Environmental Protection Regulations for Domestic
 16 Licensing and Related Regulatory Functions," Part 51, Chapter 1, Title 10, "Energy."

17 *CFR*, "Requirements for Renewal of Operating Licenses for Nuclear Power Plants," Part 54,
 18 Chapter 1, Title 10, "Energy."

- 1 U.S. Nuclear Regulatory Commission (NRC), "Generic Environmental Impact Statement for
- 2 License Renewal of Nuclear Plants," NUREG-1437, Office of Nuclear Regulatory Research,
- 3 Washington, D.C., Volumes 1 and 2, 1996, Agencywide Document Access and Management
- 4 System (ADAMS) Accession Nos. ML040690705 and ML040690738.

- 5 NRC, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants,"
- 6 NUREG-1437, Office of Nuclear Reactor Regulation, Washington, D.C., Volume 1,
- 7 Addendum 1, 1999, ADAMS Accession No. ML040690720.

4.0 ENVIRONMENTAL IMPACTS OF OPERATION

This chapter addresses potential environmental impacts related to the period of extended operation of Columbia Generating Station (CGS). These impacts are grouped and presented according to resource. Generic issues (Category 1) rely on the analysis given in the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437, prepared by the U.S. Nuclear Regulatory Commission (NRC) and are discussed briefly (NRC, 1996), (NRC, 1999). Site-specific issues (Category 2) have been analyzed for CGS and assigned a significance level of SMALL, MODERATE, or LARGE, accordingly. Some issues are not applicable to CGS because of site characteristics or plant features. For an explanation of the criteria for Category 1 and Category 2 issues, as well as the definitions of SMALL, MODERATE, and LARGE, refer to Section 1.4.

4.1 Land Use

Section 2.2.1 of this supplemental environmental impact statement (SEIS) describes the land use around CGS.

Table 4.1-1, "Land Use Issues" lists Category 1 issues (from Title 10 Part 51 of the *Code of Federal Regulations* (CFR), Subpart A, Appendix B, Table B-1), which are applicable to onsite land use and power line right-of-way (ROW) impacts during the renewal term. As stated in the GEIS, the impacts associated with the Category 1 issues were determined to be SMALL, and plant-specific mitigation measures would not be sufficiently beneficial to be warranted.

Table 4.1-1. Land use issues

| Issues | GEIS section | Category |
|-----------------|--------------|----------|
| Onsite land use | 4.5.3 | 1 |
| Power line ROW | 4.5.3 | 1 |

The NRC staff (staff) reviewed and evaluated the Energy Northwest environmental report (ER) (EN, 2010), scoping comments, other available information, and visited CGS in search of new and significant information that would change the conclusions presented in the GEIS. No new and significant information was found during this review and evaluation. Therefore, it is expected that there would be no impacts related to these Category 1 issues during the renewal term beyond those discussed in the GEIS.

4.2 Air Quality

Section 2.2.2 of this SEIS describes the meteorology and air quality in the vicinity of the CGS site. Title 10 CFR Part 51, Subpart A, Appendix B, Table B-1 summarizes findings on NEPA issues for license renewal of nuclear power plants. One Category 1 air quality issue is applicable to CGS—air quality effects of transmission lines (Table 4.2-1). No Category 2 issues apply for air quality because there is no planned refurbishment associated with license renewal. The staff did not find any new and significant information during the review of Energy Northwest's ER, the site visit, or during the scoping process. No major facility construction or refurbishment is planned to occur during the license renewal period. Therefore, there are no impacts related to this issue beyond those discussed in the GEIS. For these issues, the staff concludes in the GEIS that the impacts are SMALL.

1 **Table 4.2-1. Air quality issues**

| Issue | GEIS section | Category |
|---|--------------|----------|
| Air quality effects of transmission lines | 4.5.2 | 1 |

2 **4.3 Groundwater**

3 The Category 1 groundwater issues applicable to CGS are listed in Table 4.3-1 and discussed
 4 below. An overview of groundwater use and quality at the CGS site is provided in
 5 Sections 2.1.7 and 2.2.3.

6 **Table 4.3-1. Groundwater use and quality issues**

| Issue | GEIS section | Category |
|---|--------------|----------|
| Impacts of refurbishment on groundwater use & quality | 3.4.2 | 1 |
| Groundwater quality degradation (saltwater intrusion) | 4.8.2 | 1 |

7 **4.3.1 Generic Groundwater Issues**

8 The staff did not find any new and significant information about Category 1 or generic
 9 groundwater issues during the review of the ER, the site visit, or the scoping process.
 10 Therefore, no impacts are related to these issues beyond those discussed in the GEIS. For
 11 these issues, the staff concludes that the impacts are SMALL, and additional site-specific
 12 mitigation measures are not warranted.

13 **4.3.2 Groundwater Use Conflicts**

14 Groundwater onsite at CGS is pumped at a rate of 200 gallons per minute (gpm) from a single
 15 well quarterly for about one-half hour (2 hours total per year) (EN, 2010) for an annual average
 16 of less than 0.05 gpm. An occasional supply of groundwater for the CGS potable water system
 17 is also provided from a crosstie with two offsite wells supporting the industrial development
 18 complex (IDC). Typically, the crosstie is open less than 50 hours per year, and, although the
 19 water is not metered, the estimated annual average usage rate is estimated to be about 1 gpm
 20 (EN, 2010).

21 Because the annual average withdrawal rate from these sources is much less than 100 gpm, no
 22 Category 2 groundwater-use issues were noted for the CGS license renewal term (NRC, 1996),
 23 (NRC, 1999).

24 **4.3.3 Groundwater Quality**

25 Groundwater monitoring has not found any gamma-emitting radionuclides of interest
 26 (EN, 2009a). Elevated concentrations of tritium have been observed in groundwater adjacent to
 27 the CGS site. However, the highest concentrations, up to 17,400 pCi/L, have been found in an
 28 upgradient well, MW-5, and have been attributed to Department of Energy (DOE) Hanford Site
 29 operations (EN, 2009a), (EN, 2010). Elevated conductivity and concentrations of chloride and
 30 sulfate have also been detected adjacent to the CGS site and have been attributed to the
 31 infiltration of circulating cooling water that entered the soil through drywells (EN, 2002),
 32 (EN, 2010). However, these elevated concentrations have not affected the groundwater used
 33 for drinking water; thus, groundwater quality impacts are SMALL, and additional site-specific
 34 mitigation measures are not warranted.

1 **4.4 Surface Water**

2 The Category 1 surface water quality issues applicable to CGS are listed in Table 4.4-1 and are
 3 discussed below. An overview of surface water use and quality at the CGS site is provided in
 4 Sections 2.1.7 and 2.2.4. None of the Category 2 surface water issues set forth in the GEIS
 5 apply to CGS.

6 **Table 4.4-1. Surface water quality issues**

| Issues | GEIS Section | Category |
|---|--------------|----------|
| Impacts of refurbishment on surface water quality | 3.4.1 | 1 |
| Impacts of refurbishment on surface water use | 3.4.1 | 1 |
| Altered current patterns at intake & discharge structures | 4.2.1.2.1 | 1 |
| Altered salinity gradients | 4.2.1.2.2 | 1 |
| Temperature effects on sediment transport capacity | 4.2.1.2.3 | 1 |
| Scouring caused by discharged cooling water | 4.2.1.2.3 | 1 |
| Eutrophication | 4.2.1.2.3 | 1 |
| Discharge of chlorine or other biocides | 4.2.1.2.4 | 1 |
| Discharge of other metals in waste water | 4.2.1.2.4 | 1 |

7 **4.4.1 Generic Surface-Water Issues**

8 CGS has a closed-cycle heat-dissipation system that uses mechanical draft cooling towers with
 9 makeup water pumped from a large river—the Columbia River (with an average mean annual
 10 flow rate greater than the threshold of 3.15×10^{12} cubic feet (ft³) per year (100,000 cubic feet per
 11 second (cfs)) (10 CFR 51.53(c)(3)(ii)(A)). The staff did not find any new and significant
 12 information with respect to the Category 1 issues below during the review of the ER, the site
 13 visit, or the scoping process. In addition, the staff did not find any Category 2 issues related to
 14 surface-water issues in the GEIS. Therefore, no impacts are related to these issues beyond
 15 those discussed in the GEIS. For these issues, the staff concludes that the impacts are SMALL,
 16 and additional site-specific mitigation measures are not warranted.

17 **4.4.2 Surface-Water Use Conflicts**

18 CGS has a closed-cycle heat-dissipation system that uses mechanical-draft cooling towers with
 19 makeup water pumped from the Columbia River (see Section 2.1.7). As noted in Section 2.2.4,
 20 the Columbia River at the CGS site has an average mean annual flow rate greater than the
 21 threshold of 3.15×10^{12} ft³/year (100,000 cfs) (10 CFR 51.53(c)(3)(ii)(A)). Therefore, this issue
 22 does not apply to CGS, and no further analysis is required. No Category 2 surface-water issues
 23 were noted for the CGS license renewal term.

24 **4.5 Aquatic Resources**

25 Section 2.1.6 of this supplemental environmental impact statement (SEIS) describes the CGS
 26 cooling-water system; Section 2.2.5 describes the aquatic resources. Category 1 issues in
 27 10 CFR Part 51, Subpart A, Appendix B, Table B-1 that are applicable to the operation of the
 28 CGS cooling-water system during the renewal term are listed in Table 4.5-1. These issues are
 29 considered generic (Category 1) for facilities with cooling-tower-based heat-dissipation systems.

1

Table 4.5-1. Aquatic resources issues

| Issues | GEIS section | Category |
|--|---------------------|-----------------|
| For all plants | | |
| Accumulation of contaminants in sediments or biota | 4.1.1.2.4 | 1 |
| Entrainment of phytoplankton & zooplankton | 4.2.2.1.1 | 1 |
| Cold shock | 4.2.2.1.5 | 1 |
| Thermal plume barrier to migrating fish | 4.2.2.1.6 | 1 |
| Distribution of aquatic organisms | 4.2.2.1.6 | 1 |
| Premature emergence of aquatic insects | 4.2.2.1.7 | 1 |
| Gas supersaturation (gas bubble disease) | 4.2.2.1.8 | 1 |
| Low dissolved oxygen in the discharge | 4.2.2.1.9 | 1 |
| Losses from predation, parasitism, and disease among organisms exposed to sublethal stresses | 4.2.2.1.10 | 1 |
| Stimulation of nuisance organisms | 4.2.2.1.11 | 1 |
| For plants with cooling tower-based heat dissipation systems | | |
| Entrainment of fish & shellfish in early life stages | 4.3.3 | 1 |
| Impingement of fish & shellfish | 4.3.3 | 1 |
| Heat shock | 4.3.3 | 1 |

2 **4.5.1 Generic Aquatic Ecology Issues**

3 The generic (Category 1) issues related to aquatic resources applicable to CGS are discussed
 4 below and listed in Table 4.5-1. There are no site-specific (Category 2) issues related to aquatic
 5 resources for CGS. The staff did not find any new and significant information during the review
 6 of the Energy Northwest ER (EN, 2010), the site visit, the scoping process, or the evaluation of
 7 other available information. However, the staff does note that the GEIS (NRC 1996) states the
 8 following:

9 However, even low rates of entrainment and impingement at a closed-cycle
 10 cooling system can be a concern when an unusually important resource is
 11 affected. Such aquatic resources would include threatened or endangered
 12 species or anadromous fish that are undergoing restoration. For example,
 13 concern about potential impacts of the Washington Nuclear Project (WNP-2) on
 14 Chinook salmon has been raised by the Washington Department of Fisheries
 15 (Cynthia A. Wilson, Washington Department of Fisheries, letter to G.F. Cada,
 16 ORNL, Oak Ridge, Tennessee, July 5, 1990). Although entrainment,
 17 impingement, and thermal discharges are not believed to be a problem at
 18 WNP-2, the importance of the Columbia River salmon stocks are such that the
 19 resource agency feels that monitoring should continue.

20 As a result, further examination of the normally generic impacts of entrainment, impingement,
 21 and heat shock (thermal plume barriers) from the operation of CGS are considered for
 22 anadromous fish in the Columbia River.

1 4.5.2 Entrainment

2 Entrainment occurs when small aquatic organisms are carried into the intake system and
3 through the cooling system, and it primarily affects organisms with limited swimming ability that
4 can pass through the screens on the intake system. As described in Section 2.1.6, the CGS
5 intake system is a perforated pipe with an outside sleeve that has 3/8-inch (in.) (9.5-millimeter
6 (mm))-diameter holes and an inside sleeve that has 3/4-in. (19-mm)-diameter holes (Figure 2-5)
7 (EN, 2010). Organisms typically entrained by intake systems include phytoplankton,
8 zooplankton, and the eggs, larvae, and juvenile forms of many of the fish and invertebrates. As
9 entrained organisms pass through the intake, they may be injured by abrasion or compression.
10 Once entrained, organisms pass through the makeup-water pumps and are carried with the
11 water flow to the mechanical draft cooling towers. Within the cooling system, they encounter
12 physical and chemical stressors that likely lead to 100-percent mortality (WPPSS, 1982).

13 In the GEIS (NRC, 1996), the NRC reviewed entrainment for once-through cooling systems for
14 nuclear facilities and determined that the relatively small volumes of makeup water needed for
15 those facilities result in low entrainment effects. However, the effect of the withdrawal of
16 Columbia River water by CGS should be considered separately for the anadromous fish species
17 in the area. The anadromous fish that might spawn near the site include American shad (*Alosa*
18 *sapidissima*), upper Columbia River fall-run Chinook salmon (*Oncorhynchus tshawytscha*),
19 steelhead (*Oncorhynchus mykiss*), coho salmon (*O. kisutch*), sockeye salmon (*O. nerka*), and
20 Pacific lamprey (*Lampetra tridentata*). Entrainment could affect these species directly
21 (capturing eggs or juveniles) or indirectly (removing their food source) (WPPSS, 1982).

22 Entrainment studies were done in 1979–1980 and 1985, and no fish, fish eggs, or larvae were
23 collected during the studies. In 1985, during the entrainment studies, beach seine samples
24 collected juvenile Chinook salmon (averaging 43 mm in length), confirming their presence in the
25 area (EN, 2010), (WPPSS, 1986). As discussed in Chapter 2, the fall-run Chinook salmon and
26 steelhead redds are upstream of the intake system (Figure 2-3). The location of the intake
27 screens is in the deepest part of the channel, and the river bottom varies around the intake
28 structure from exposed Ringold conglomerate to boulders, cobble, gravel, and sand
29 (WPPSS, 1987). The type of substrate in this area is not ideal spawning habitat for the fall-run
30 Chinook salmon or for the steelhead (Dauble, 2009).

31 Most fish species in the Hanford Reach of the Columbia River are dependent on food sources
32 that are attached to the substrate (e.g., periphyton) rather than food in the water column (e.g.,
33 phytoplankton and zooplankton) (Dauble, 2009). The phytoplankton and zooplankton
34 populations are sparser in the Hanford Reach of the Columbia River than in the reservoirs
35 because of the river's high flow rate. The Washington Public Power Supply System (WPPSS)
36 estimated that the maximum river water withdrawal through the intake structures is less than
37 0.15 percent of the river volume at the lowest regulated flow in the river of 36,000 cfs
38 (WPPSS, 1982). Periodically, the CGS staff has examined the intake screens and has not
39 observed growth of periphyton or other debris that could attract anadromous fish (EN, 2010),
40 (WPPSS, 1987).

41 The staff concludes that past entrainment studies support the overall conclusions of the staff in
42 the GEIS that entrainment is minimal at facilities with closed-cycle cooling systems and will
43 neither destabilize nor noticeably alter the population of anadromous fish including their early
44 life stages. The staff concludes that the level of impact from the cooling-water intake system
45 from entrainment on anadromous fish in early life stages is SMALL.

1 4.5.3 Impingement

2 Impingement occurs when organisms are trapped against cooling-water intake screens by the
3 force of moving water. Impingement can kill organisms immediately or contribute to a slower
4 death resulting from exhaustion, suffocation, or injury. The amount of time an organism is
5 impinged, its susceptibility to injury, and the physical characteristics of the intake screen are
6 factors that can lead to injury or death. Section 2.1.6 described the intake screens for the CGS
7 plant.

8 In the GEIS (NRC, 1996), the NRC reviewed impingement for once-through cooling systems for
9 nuclear facilities and determined that the relatively small volumes of makeup water needed for
10 those facilities result in low entrainment effects. However, the effect of the withdrawal of
11 Columbia River water by CGS should be considered separately for the anadromous fish species
12 in the area.

13 The CGS intake screens in the Columbia River consist of perforated pipes on supports over the
14 river substrate. The intake system is small in comparison to the width of the river. The area of
15 the 2 intake screens and the support system is approximately 30 feet (ft) by 46 ft (9.1 meters
16 (m) by 14 m), and the width of the river is approximately 1,200 ft (370 m) at a river elevation of
17 345 ft (105 m) (WPPSS, 1987). The inlet velocities are within acceptable limits for best
18 available technology for minimizing impacts (69 FR 41576). The velocity through the external
19 screen openings is approximately 0.5 feet per second (fps) under normal operating conditions
20 where 12,500 gpm is removed through both intake structures. The approach velocity to the
21 intake screens under the same conditions is less than 0.2 fps (WPPSS, 1980). This compares
22 to river velocities measured near the perforated pipes ranging from 4–5 fps (1.2–1.5 m/s
23 (meters per second)) (WPPSS, 1986). Impingement of aquatic organisms is unlikely because
24 the velocity of the water across the face of the intake system is several times faster than the
25 intake velocity (WPPSS, 1982). Studies conducted in 1978, 1979, and 1985 looked for—but did
26 not find—any fish or debris impinged on the screens (EN, 2010), (WPPSS, 1986). However, the
27 1985 study did find that fish were using the intake support system for cover and resting,
28 including largescale suckers (*Catostomus macrocheilus*), mountain whitefish (*Prosopium*
29 *williamsoni*), sculpins (*Cottus* spp.), Northern pikeminnow (*Ptychocheilus oregonensis*), bass
30 (*Micropterus* spp.), redbelt shiner (*Richardsonius balteatus*), and American shad (*Alosa*
31 *sapidissima*) (WPPSS, 1986). During one of the observation periods for impingement in 1985,
32 samples of juvenile Chinook were collected, showing that anadromous species were in the area
33 of the intake screens but were not being affected by the water withdrawal (WPPSS, 1986).

34 The staff concludes that past impingement studies and the design and operation of the intake
35 screen supports the overall conclusions of the staff in the GEIS that impingement is minimal at
36 facilities with closed-cycle cooling systems and will neither destabilize or noticeably alter the
37 population of anadromous fish. The staff concludes that the level of impact from the
38 cooling-water intake system from impingement on anadromous fish is SMALL.

39 4.5.4 Heat Shock

40 Thermal discharges can kill or harm fish and aquatic organisms that migrate or pass through the
41 blowdown at operating nuclear facilities. The CGS has a closed-cycle cooling system that uses
42 mechanical draft cooling towers with blowdown discharged to the Columbia River. The GEIS
43 assessed the effect of heated water from the blowdown at closed-cycle cooling systems on
44 aquatic resources and determined that heat shock has not been found to be a problem with this
45 type of cooling system. However, the temperature of the Columbia River water discharged from
46 CGS should be considered separately for the anadromous fish in the area.

1 The anadromous fish resources in the Columbia River are influenced directly or indirectly by
2 water temperature changes. A review of tolerance and thermal requirements of aquatic species
3 found near the CGS site showed that salmonids are the species most sensitive to, and directly
4 affected by, thermal discharges (WPPSS, 1982).

5 Studies in 1985 evaluated the thermal plume in summer and winter months at above normal
6 operating conditions for the CGS (EN, 2010). These studies reported that the water
7 temperature was not elevated at distances beyond 10 ft (3 m) from the discharge structure and
8 was imperceptible at the surface of the river in the summer. In the winter months, the maximum
9 plume length detected had a temperature rise of 0.7 degrees Fahrenheit (F) (0.4 degrees
10 Celsius (C)) at 500 ft (152 m), and a temperature rise of 0.2 degrees F (0.1 degrees C) isotherm
11 was approximately 40 ft (12 m) wide. The width of the river is about 1,200 ft (370 m) wide near
12 the blowdown discharge; thus, the size of the plume would not likely block fish passage through
13 the area. While the plant discharge created a long, narrow, low incremental thermal plume, the
14 increase in temperature did not exceed Washington State regulations and the limits of the CGS
15 NPDES permit (EN, 2010), (WPPSS, 1986).

16 The staff considered the possible effects of temperature on salmonid species in the Hanford
17 Reach and determined that the relatively small plume that could occur in the winter months
18 would likely have a minimal affect on the fish species. No major facility construction or
19 refurbishments are planned to occur during the license renewal period. Therefore, the staff
20 concludes that the overall conclusions of the staff in the GEIS that heat shock from facilities with
21 closed-cycle cooling systems will neither destabilize or noticeably alter the population of
22 anadromous fish including their early life stages. Therefore, the staff concludes that the impacts
23 from heat shock on anadromous fish is SMALL.

24 **4.5.5 Total Impacts on Aquatic Resources**

25 Closed-cycle cooling systems generally have minor effects resulting from entrainment,
26 impingement, and heat shock on aquatic resources. The staff evaluated the ER and past
27 studies of entrainment and impingement at the CGS site specifically for anadromous fish, as
28 recommended by the GEIS (NRC, 1996), and it determined the intake structure design and
29 operation had minimal impact on these aquatic resources in the Hanford Reach of the Columbia
30 River. In addition, thermal plumes from the blowdown discharge in the river are likely to have
31 minimal impact on aquatic organisms (e.g., heat shock). The staff concludes that the impacts
32 from entrainment, impingement, and heat shock on anadromous fish would be SMALL from the
33 continued operation of CGS.

34 **4.6 Terrestrial Resources**

35 The issues related to terrestrial resources applicable to CGS site are discussed below and listed
36 in Table 4.6-1. There are no Category 2 issues related to terrestrial resources for license
37 renewal. The staff did not find any new and significant information during the review of the
38 (EN, 2010a), the site visit, the scoping process, or the evaluation of other available information.
39 Therefore, the staff concludes that there would be no impacts related to these issues beyond
40 those discussed in the GEIS (NRC, 1996). The GEIS concludes that the impacts are SMALL,
41 and additional site-specific mitigation measures are not likely to be sufficiently beneficial to carry
42 out.

1 **Table 4.6-1. Terrestrial resources issues**
 2 *Section 2.2.6 of this SEIS provides a description of the terrestrial resources*
 3 *at CGS and in the surrounding area.*

| Issues | GEIS section | Category |
|---|--------------|----------|
| Power line ROW management (cutting, herbicide application) | 4.5.6.1 | 1 |
| Bird collisions with power lines | 4.5.6.1 | 1 |
| Impacts of electromagnetic fields on flora & fauna (plants, agricultural crops, honeybees, wildlife, livestock) | 4.5.6.3 | 1 |
| Floodplains & wetlands on power line ROW | 4.5.7 | 1 |

4 **4.7 Special Status Species and Habitats**

5 The impact to threatened or endangered species is a Category 2 issue. It requires consultation
 6 with the appropriate agencies to determine whether threatened or endangered species are
 7 present and whether they would be adversely affected by continued operation of CGS during
 8 the license renewal term. Section 2.2.7 describes the characteristics of threatened or
 9 endangered species and critical habitats near CGS. The staff is in consultation with the U.S.
 10 Fish and Wildlife Service (USFWS) and the National Marine Fisheries Service (NMFS) to
 11 evaluate the potential impacts on Federally-listed aquatic species and critical habitats near
 12 CGS.

13 **Table 4.7-1. Threatened or endangered species**

| Issues | GEIS section | Category |
|----------------------------------|--------------|----------|
| Threatened or endangered species | 4.1 | 2 |

14 **4.7.1 Aquatic Species**

15 Section 2.2.7 of this SEIS describes the Federally listed, threatened, or endangered species
 16 and critical habitats on or near the CGS site. The species include the threatened bull trout, the
 17 endangered upper Columbia River steelhead, and the threatened upper Columbia River
 18 spring-run Chinook salmon (Suzumoto, 2010), (USFWS, 2010). In addition, the Columbia River
 19 near the CGS site is essential fish habitat (EFH) for upper Columbia River Chinook salmon
 20 (spring-, summer-, and fall-runs) and coho salmon. Critical habitat for the threatened bull trout
 21 includes the entire Columbia River Basin (75 FR 2270). The USFWS published, in its recent
 22 ruling on bull trout, that the mainstem of the Columbia River is more important for providing
 23 foraging, migration, and overwintering habitat than was previously understood. Bull trout have
 24 only rarely been found in the Hanford Reach of the Columbia River (Gray and Dauble, 1977).
 25 Observations of the bull trout have usually been in association with the spring freshet (Duncan,
 26 et al., 2007), leading some scientists to believe that the species is transient near the CGS site
 27 (Dauble, 2009), (Poston, et al., 2009).

28 As mentioned in Section 4.5, the design and operation of the intake and discharge structures for
 29 the CGS in the Columbia River will likely have minimal effects on adult fish (e.g., transient bull
 30 trout and their food sources (small fish)). Entrainment studies done in 1979–1980 and 1985 did
 31 not collect any life stage of fish (EN, 2010), (WPPSS, 1986). Impingement studies done over
 32 the same period did not observe any fish impinged on the intake screens (EN, 2010),
 33 (WPPSS, 1986). Juvenile bull trout consume aquatic insects (Dauble, 2009). The operation of
 34 the intake structure would remove from the river any aquatic insect in life stages that are up in

1 the water column and are the food source for the insects and small fish (e.g., phytoplankton and
2 zooplankton). However, the fraction of the river flow withdrawn from the plant (0.03–
3 0.05 percent of the annual discharge of the river) is small. Thus, withdrawals by the intake
4 system will not significantly reduce the amount of food available to the juvenile bull trout. The
5 thermal effluent from the blowdown discharge during the spring is a long, narrow plume,
6 approximately 1 percent of the width of the river, and likely will not affect the migration or
7 foraging of the bull trout (WPPSS, 1986).

8 The endangered upper Columbia River spring-run Chinook salmon and threatened upper
9 Columbia River steelhead are found near the intake and discharge systems for the CGS and
10 were evaluated to determine if they have the potential to be adversely affected by continued
11 operation of the CGS plant during the renewal period. Critical habitat for the spring Chinook is
12 located upstream of the CGS site. Historically, steelhead redds were observed near the intake
13 structure.

14 Upper Columbia River spring Chinook salmon do not spawn in the Hanford Reach. The adults
15 start returning from the ocean in early spring and then pass through the Hanford Reach while
16 migrating to upstream spawning grounds in the Wenatchee, Entiat, Methow, and Okanogan
17 river basins (NMFS, 2007). As discussed in Section 2.2.7, the adult Chinook do not eat while
18 ascending the river. The juveniles use the Hanford Reach as a nursery area while they migrate
19 downstream toward the ocean (Duncan, et al., 2007), foraging on aquatic insects
20 (Dauble, 2009). The movement of a juvenile through the Hanford Reach lasts no more than one
21 week; outmigration of the juvenile spring Chinook extends from April to the end of August
22 (DOE, 2000). The design and operation of the intake and discharge structures are likely to have
23 a similar effect on the juvenile and adult spring Chinook as discussed for the bull trout.

24 Upper Columbia River steelhead have been observed spawning in the Hanford Reach and near
25 the intake and discharge structures for the CGS plant in the past. The most recent confirmed
26 observations of active steelhead redds were in 2003, below the CGS intake. From 2006–2008,
27 the aerial surveys did not find any evidence of steelhead spawning near the CGS intake and
28 discharge structure or in the Hanford Reach (Hanf, et al., 2007), (Poston, et al., 2008),
29 (Poston, et al., 2009).

30 The concern for the steelhead near the intake and discharge structures is the possible
31 entrainment of eggs and larval steelhead from the upstream redds. Adults and juveniles can
32 avoid the influence of the intake and discharge structures during operation activities. Juvenile
33 steelhead migrate through the Hanford Reach in the deepest part of the river and stay near the
34 river bottom (Dauble, 2009). Eggs that do not settle in the redds prepared by the adults are
35 often consumed by other fish waiting downstream during spawning. Considering the distance
36 upstream of previously observed redds, it is unlikely that steelhead eggs would travel to the
37 intake structure and be removed from the environment.

38 As steelhead fry emerge from the river substrate and start to feed, they are about 1 in. (2.5
39 centimeters (cm)) long and vulnerable to predation, so they seek cover. If steelhead fry were
40 upstream of the intake structure, their tendency to stay close to the river substrate would keep
41 them away from the pull of the operating intake structure and minimize the direct affects of
42 entrainment and impingement. However, as observed by divers in 1985, the support and riprap
43 around the intake structure provides shelter for fish species that consume other fish
44 (WPPSS, 1986); thus, indirectly, the intake structure might affect the survival of the fry. During
45 thermal drift studies in 1985, juvenile fall Chinook and steelhead floated in cages through the

Environmental Impacts of Operation

1 thermal and chemical effluent of the blowdown discharge were not measurably affected by
2 exposure to the heated water and blowdown chemicals (WPPSS, 1986).

3 Based on the occurrence of the life stages of bull trout, upper Columbia River spring-run
4 Chinook salmon and upper Columbia River steelhead in the Hanford Reach and the design and
5 operation of the CGS intake and discharge structure, the staff concludes that the impacts of an
6 additional 20 years of operation of CGS on aquatic species that are Federally listed as
7 threatened or endangered species would be SMALL as defined by the NRC for the purposes of
8 NEPA rather than the Endangered Species Act. The staff has prepared an integrated biological
9 assessment and EFH assessment, which are supplied as Appendix D-1 to this SEIS.

10 **4.7.2 Terrestrial Species**

11 Sections 2.2.6 and 2.2.7 of this SEIS discuss the characteristics and habitat of threatened and
12 endangered species near the CGS site.

13 The staff contacted the USFWS to request information that could help in assessing the
14 environmental impacts associated with license renewal. On November 8, 2010, the USFWS
15 noted that the Federally-listed species the Columbia Basin pygmy rabbit (*Brachylagus*
16 *idahoensis*) and the Ute ladies'-tresses (*Spiranthes diluvialis*) could potentially occur within
17 Benton County where the project area and the adjacent, 2,900 ft-long (880 m) transmission line
18 corridor are located (Kurz, 2010). As discussed previously, in Section 2.2.7.1, both species are
19 not known to occur on the CGS site or the surrounding Hanford Site. The Columbia Basin
20 pygmy rabbit has never been documented on the site, has been extirpated from the wild, and is
21 presumed extinct (EN, 2010a), (WDNR, 2009). The Ute ladies'-tresses is known to occur within
22 the Columbia Plateau ecoregion, but it has not been observed as far south as the CGS site
23 (Fertig, et al., 2005).

24 The bald eagle (*Haliaeetus leucocephalus*) and the peregrine falcon (*Falco peregrinus*) were
25 both previously Federally-listed as threatened and may be found near the CGS site
26 (Welch, 2009). The bald eagle is still protected under the Bald and Golden Eagle Protection
27 Act. Both the bald eagle and peregrine falcon are protected under the Migratory Bird Treaty
28 Act. Four State-listed threatened or endangered species that could potentially occur on the
29 CGS site include the sandhill crane (*Grus canadensis*), the American white pelican (*Pelecanus*
30 *erythrorhynchos*), the ferruginous hawk (*Buteo regalis*), and the lowland toothcup (*Rotala*
31 *ramosior*) (EN, 2010).

32 There are no Federally-listed threatened or endangered terrestrial species that occur along the
33 in-scope transmission line ROWs. The staff encourages Energy Northwest to report the
34 existence of any Federally-listed or State-listed endangered or threatened species within or near
35 the CGS site or the transmission line ROWs to the Washington Department of Natural
36 Resources (WDNR) and USFWS, or both, if any such species are identified during the license
37 renewal term. In particular, if any evidence of injury to or mortality of, migratory birds, or any
38 other threatened or endangered species is observed at the CGS site or within the transmission
39 line corridor during the license renewal period, the staff encourages Energy Northwest to
40 promptly report this to the appropriate wildlife management agencies.

41 Because no threatened or endangered species are known to occur on or near the CGS site or
42 within the transmission line corridors, operation of the site and its associated transmission lines
43 are not expected to adversely affect any threatened or endangered terrestrial species during the
44 license renewal term. Therefore, the staff concludes that adverse impacts to threatened or
45 endangered terrestrial species during the period of extend operation would be SMALL. The

1 staff finds several mitigation measures currently in place at the CGS site and along the
 2 associated transmission lines to be adequate. They include environmental review checklists,
 3 environmental evaluation forms, and best management practices for reporting species sightings
 4 and dealing with distressed species.

5 **4.8 Human Health**

6 The human health issues applicable to CGS are discussed below and listed in Table 4.8-1 for
 7 Category 1, Category 2, and uncategorized issues.

8 **Table 4.8-1. Human health issues**

9 *Table B-1 of Appendix B to Subpart A of 10 CFR Part 51*
 10 *contains more information on these issues.*

| Issues | GEIS section | Category |
|---|----------------------|---------------|
| Radiation exposures to the public during refurbishment | 3.8.1 ^(a) | 1 |
| Occupational radiation exposures during refurbishment | 3.8.2 ^(a) | 1 |
| Microbiological organisms (occupational health) | 4.3.6 | 1 |
| Microbiological organisms (public health, for plants using lakes or canals, or cooling towers or cooling ponds that discharge to a small river) | 4.3.6 ^(b) | 2 |
| Noise | 4.3.7 | 1 |
| Radiation exposures to public (license renewal term) | 4.6.2 | 1 |
| Occupational radiation exposures (license renewal term) | 4.6.3 | 1 |
| Electromagnetic fields—acute effects (electric shock) | 4.5.4.1 | 2 |
| Electromagnetic fields—chronic effects | 4.5.4.2 | Uncategorized |

^(a) Issues apply to refurbishment, an activity that CGS does not plan to undertake.

^(b) Issue applies to plants with features such as cooling lakes or cooling towers that discharge to a small river. The issue does not apply to CGS.

11 **4.8.1 Generic Human Health Issues**

12 The staff did not find any new and significant information related to human health issues or
 13 radiation exposures during its review of the Energy Northwest ER, the site visit, or the scoping
 14 process. Energy Northwest found and evaluated a potentially new and significant issue related
 15 to groundwater contamination. Energy Northwest’s evaluation concluded that the issue is not
 16 new and significant. The staff agrees with that conclusion. Section 4.10 of this chapter contains
 17 the discussion of this issue. Therefore, there are no impacts related to these issues beyond
 18 those discussed in the GEIS. For these issues, the GEIS concluded that the impacts are
 19 SMALL, and additional site-specific mitigation measures are not likely to be sufficiently
 20 beneficial to be warranted (Category 1 issues). These impacts are expected to remain SMALL
 21 through the license renewal term.

22 **4.8.2 Radiological Impacts of Normal Operations**

23 Category 1 issues in 10 CFR Part 51, Subpart A, Appendix B, Table B-1—applicable to CGS in
 24 regard to radiological impacts—are listed in Table 4.8-1. The staff has not found any new and
 25 significant information during its independent review of Energy Northwest’s ER, the site visit, the
 26 scoping process, or its evaluation of other available information. Therefore, the staff concludes

Environmental Impacts of Operation

1 that there would be no impact from radiation exposures to the public or to workers during the
2 renewal term beyond those discussed in the GEIS.

3 • Radiation exposures to public (license renewal term). Based on information in the GEIS,
4 the staff found the following:

5 Radiation doses to the public will continue at current levels associated with normal
6 operations.

7 • Occupational exposures (license renewal term). Based on information in the GEIS, the
8 staff found the following:

9 Projected maximum occupational doses during the license renewal term are within the
10 range of doses experienced during normal operations and normal maintenance outages
11 and would be well below regulatory limits.

12 According to the GEIS, the impacts to human health are SMALL, and additional plant-specific
13 mitigation measures are not likely to be sufficiently beneficial to be warranted.

14 There are no Category 2 issues related to radiological impacts of routine operations.

15 The information presented below is a discussion of selected radiological programs carried out at
16 CGS.

17 CGS Radiological Environmental Monitoring Program. CGS conducts a radiological
18 environmental monitoring program (REMP) to assess the radiological impact, if any, to its
19 employees, the public, and the environment around the plant site. The preoperational phase of
20 the program, which lasted from March 1978 until initial criticality in January 1984, gave a
21 baseline of background, including any contribution from the Hanford Site, radiological
22 environmental data. The REMP supplies measurements of radiation and of radioactive
23 materials for the exposure pathways and the radionuclides, which lead to the highest potential
24 radiation exposures to the public. The REMP supplements the radioactive effluent monitoring
25 program by verifying that any measurable concentrations of radioactive materials and levels of
26 radiation in the environment are not higher than those calculated using the radioactive effluent
27 release measurements and transport models.

28 The REMP gives an independent mechanism for determining the levels of radioactivity in the
29 environment to ensure that any accumulation of radionuclides released into the environment will
30 not become significant as a result of station operations. While in-plant radiation monitoring
31 programs are used to ensure that the dose to members of the public from radioactive effluents
32 are within the dose limits in 10 CFR Part 20 and the as low as is reasonably achievable
33 (ALARA) design criteria in Appendix I to 10 CFR Part 50, the REMP directly verifies any
34 environmental impact that may result from plant effluents.

35 An annual radiological environmental operating report is issued, which contains numerical data
36 and a discussion of the results of the monitoring program for the past year. The REMP collects
37 samples of environmental media in order to measure the radioactivity levels that may be
38 present. The locations of most monitoring stations have been selected based on an exposure
39 pathway analysis. The exposure pathway analysis considers factors such as weather patterns,
40 anticipated radioactive emissions, likely receptors, and land use in the surrounding areas.
41 Samples collected from monitoring stations located in areas that potentially could be influenced
42 by CGS operation are used as indicators. Samples collected from locations that are not likely to
43 be influenced by CGS operation serve as controls. Results from indicator monitoring stations

1 are compared to the results from control monitoring stations and results obtained during the
2 previous operational and preoperational years of the program in order to assess the impact
3 CGS operation may be having on the environment. The media samples are representative of
4 the radiation exposure pathways that may affect the public. The REMP measures the aquatic,
5 terrestrial, and atmospheric environment for radioactivity, as well as the ambient radiation.
6 Ambient radiation pathways include radiation from radioactive material inside buildings and
7 plant structures and airborne material that may be released from CGS. In addition, the REMP
8 measures background radiation (i.e., cosmic sources, global fallout, and naturally occurring
9 radioactive material, including radon). Thermoluminescent dosimeters (TLDs) are used to
10 measure ambient radiation. The atmospheric environmental monitoring consists of sampling
11 and analyzing the air for particulates and radioiodine. Terrestrial environmental monitoring
12 consists of analyzing samples of local garden produce, groundwater, plant discharge water,
13 storm drain water, sanitary waste water, soil, and milk. The aquatic environmental monitoring
14 consists of analyzing samples of river water, river sediment, and fish. An annual land use
15 census is done to determine if the REMP needs to be revised to reflect changes in the
16 environment or population that might alter the radiation exposure pathways. CGS has an onsite
17 groundwater protection program designed to monitor the onsite plant environment near the
18 reactor building for early detection of leaks from plant systems and pipes containing radioactive
19 liquid. CGS is located in an area where the unconfined aquifer under the site is known to be
20 contaminated with tritium as a result of past DOE activities on the Hanford Site. The CGS
21 groundwater program is intended to assess any additional contribution CGS may be making to
22 the known groundwater contamination levels (EN, 2010b). The CGS groundwater program is
23 not designed to monitor and assess radioactive contamination originating from past nuclear
24 activities at the Hanford Site. The DOE has its own environmental monitoring program, which is
25 presented later in this section, to assess radioactive contamination levels on the Hanford Site
26 and outside the boundary of the Hanford Site.

27 Due to the location of CGS on the Hanford Site, there are other sources of radioactive material
28 in close proximity to the plant. CGS is unique in the U.S. commercial nuclear power industry in
29 this respect. Radionuclides related to past DOE activities on the Hanford Site, most notably
30 tritium, are found in some CGS REMP samples. Though the presence of these radionuclides
31 near CGS is not necessarily reflective of CGS activity, changes in the levels of these
32 radionuclides are monitored to assess any contribution that CGS may be making to the local
33 background radiation levels.

34 The staff reviewed the CGS annual radiological environmental operating reports for 2005–2009,
35 to look for any significant impacts to the environment or any unusual trends in the data
36 (EN, 2006a), (EN, 2007a), (EN, 2008a), (EN, 2009X4), (EN, 2010b). A 5-year period gives a
37 representative data set that covers a broad range of activities that occur at a nuclear power
38 plant such as refueling outages, non-refueling outage years, routine operation, and years where
39 there may be significant maintenance activities. In addition, the staff reviewed recent DOE
40 Hanford ERs (DOE, 2010d) and Washington State's Hanford Environmental Radiation
41 Oversight Program reports (WDOH, 2011).

42 Below is a summary of the results reported by Energy Northwest in CGS's 2009 annual
43 radiological environmental operating report:

44 Direct Radiation. Offsite direct radiation monitoring results are consistent with previous years.
45 The 2009 results show no measurable dose contribution due to plant operations at locations
46 outside the CGS controlled area.

Environmental Impacts of Operation

1 Airborne Particulate and Iodine. Results for these locations are within the range observed in
2 previous years and closely follow the trend observed for the control location. Based on these
3 results, there is no evidence of any measurable environmental radiological air quality impact
4 that can be attributed to CGS operation during 2009.

5 Surface Water. Tritium results for all plant intakes, plant discharge, and river or drinking
6 samples were so low as to be below the detection capability of the analysis method (i.e., less
7 than the lower limit of detection (LLD)). This is consistent with results seen in previous years.
8 The analysis for gamma radiation emitting material in samples from all plant intake, plant
9 discharge, and river or drinking water showed no indication of any gamma-emitting
10 radionuclides related to CGS operation. There is no evidence of significant impact to the
11 environment due to CGS operation in the plant intake, plant discharge, or river or drinking water
12 results analyzed in 2009.

13 Groundwater. The CGS groundwater monitoring program is carried out to meet the Nuclear
14 Energy Institute (NEI) Groundwater Protection Initiative (NEI 07-07) guidelines and to support
15 Washington State environmental permit requirements. The 11 shallow wells allow water to be
16 sampled from the unconfined aquifer around the CGS site. None of these monitoring wells is
17 used as a source of drinking water. As previously noted, CGS is unique in the commercial
18 nuclear power industry in that it is located in an area where the unconfined aquifer under the
19 site is known to be contaminated with tritium and other radionuclides as a result of past DOE
20 activities on the Hanford Site. The CGS groundwater program is intended to assess any
21 contribution CGS may be making to the known groundwater contamination levels associated
22 with Hanford Site operations.

23 Results of the strontium-90 (Sr-90), iron-55, and nickel-63 analyses conducted during the 1st
24 and 2nd quarters were all below the minimum detectable concentration for the analysis. Results
25 from the gross alpha and beta analysis carried out during the first and second quarters showed
26 the presence of small quantities of gross alpha and beta present in most of these samples.

27 Tritium concentrations in these samples ranged from less than the LLD to 17,400 picocuries
28 (pCi) per liter (L). Tritium results from each well were consistent during the year with the
29 exception of well number 7 in the second quarter and well number 8 during the third quarter,
30 which was noticeably above the trend. The tritium levels were below the NRC's reporting level
31 of 20,000 pCi/L. For samples that have tritium concentrations greater than 20,000 pCi/L,
32 Energy Northwest would have to submit a special report to the NRC documenting the
33 occurrence and noting any corrective actions plans to prevent a reoccurrence.

34 Soil. Analysis of soil samples for gamma emitting radionuclides showed the presence of
35 naturally occurring radionuclides and Cesium-137 (Cs-137) in only two of five samples, one
36 being a sample from the control location. The level of Cs-137 found was similar to that seen in
37 the past and was within the concentration range that is considered normal background levels for
38 Hanford Site soils. The soil sample results do not show any measurable impact from CGS
39 operation.

40 River Sediment. Analysis of river sediment noted naturally occurring radionuclides and Cs-137.
41 Cs-137 was detected in one upstream station and both downstream stations (relative to the
42 cooling tower discharge point). As observed in previous years, Cs-137 downstream activity was
43 slightly higher than the activity identified upstream. Both the upstream and downstream Cs-137
44 activity levels are within the range quantified in previous years and consistent with known
45 Cs-137 background levels in Hanford area sediment and soil. The sediment sample results do

1 not show any measurable impact from CGS operation. It is noted that CGS has not made a
2 radioactive liquid effluent discharge to the Columbia River since 1998.

3 Fish. Analysis of fish samples collected at both the indicator location (Columbia River) and the
4 control location (Snake River) noted the presence of only naturally occurring radionuclides.
5 These results are consistent with results seen from past years.

6 Milk. There was no iodine-131 (I-131) activity identified in any of the milk samples collected in
7 2009. Analysis of milk samples did not find any gamma emitting radionuclides of interest above
8 the detection limits of the analysis method. Naturally occurring potassium-40 (K-40) was found
9 in all milk samples.

10 Garden Produce. Analysis for gamma emitting radionuclides was done on 12 different fruit and
11 vegetable crops in 2009. No radionuclides of interest were found in any of the samples.
12 Naturally occurring K-40 was found in all samples.

13 Special Interest Monitoring Stations. Additional sampling and analysis beyond the requirements
14 of the REMP is done to comply with Washington State's Energy Facility Site Evaluation Council
15 resolutions. The locations and monitoring results are presented below.

16 Storm Drain Pond. The storm drain pond is located approximately 1,500 ft northeast of CGS.
17 The storm drain pond area is fenced, and access is restricted. Water samples were analyzed
18 for gamma emitting radionuclides, tritium, and gross beta. Gamma analysis did not find the
19 presence of any gamma emitting radionuclides of interest. Gross beta was positively noted in
20 only 1 of the 12 samples; the level noted was just above the analysis method's detection limit
21 and within the range observed in previous years. Tritium was detected in 6 of the 12 samples.
22 The samples with the highest tritium activity were from colder, wetter months and are consistent
23 with results seen in previous years. The source of the tritium in these samples is believed to be
24 from tritium contained in CGS routine radioactive gaseous effluents, which "rain out" of the
25 atmosphere during the cooler, rainier periods of the year.

26 Sanitary Waste Treatment Facility. The Sanitary Waste Treatment Facility (SWTF) is located
27 approximately 0.5 miles (mi) south-southeast of the CGS. The facility processes sanitary waste
28 water from CGS, the Energy Northwest IDC (formerly referred to as WNP-1 and WNP-4), the
29 Kootenai Building, and the DOE 400 Area. The sample results were consistent with results
30 seen in previous years. Low level gross beta was noted in all samples; gross alpha was not
31 noted above the LLD in any of the samples. Gamma analysis results of the SWTF water
32 samples found I-131 in the January 2009 composite sample. Since the radioiodine was not
33 expected, Energy Northwest documented the results and carried out an investigation to
34 determine its source. Since no other CGS radionuclides were found in the sample, Energy
35 Northwest determined that the source of the radioiodine was from a medically administered
36 treatment. No other gamma emitting radionuclides of interest were detected in any of the other
37 samples analyzed in 2009. Tritium activity was found in most all of the SWTF samples. The
38 tritium levels found are consistent with levels noted in previous years. The results of one
39 location remain elevated as the source of this sample is partly from an unconfined aquifer that is
40 known to be contaminated with tritium, as a result of past DOE activities on the Hanford Site.
41 Tritium activity coming from the DOE 400 area is the main source of the tritium found in some of
42 the water samples.

43 Cooling Tower Sediment Disposal Area. Washington State authorizes the onsite disposal of
44 sediments from CGS's cooling systems containing low levels of radionuclides. The disposal
45 area for these sediments is located just south of the cooling towers. The State requires direct

Environmental Impacts of Operation

1 radiation monitoring using quarterly and annual TLDs near the disposal cells and the collection
2 and analysis of a dry composite sediment sample from the disposal cell within thirty days
3 following each disposal to confirm that the disposal criteria outlined in the State's criteria have
4 not been exceeded. All results of disposed sediment were well below the State's disposal
5 concentration limits. Cs-137 is routinely noted in the sediment disposal samples, and the
6 Cs-137 level noted in the 2009 samples was within the range seen in previous years and only
7 slightly higher than the Cs-137 levels found in Columbia River sediment. Co-60 was not
8 positively identified in any 2009 sample. Measurements of direct radiation at the disposal basin
9 were taken using TLDs. Two locations were used, an indicator location next to the collection
10 area and a control location approximately 100 yards to the east. The mean quarterly and
11 annual TLD results agree well with results from previous operational years. The negligible
12 difference between the indicator and the control TLDs show that there was no measurable
13 dose contribution above background due to material in the disposal cells.

14 Spray Pond Drain Field. There were no discharges to the spray pond drain field in 2009. The
15 TLD results are in agreement with those seen in previous operational years.

16 Independent Spent Fuel Storage Installation. The independent spent fuel storage installation
17 (ISFSI) is a fenced, secured area north northwest of CGS. There are 10 TLD stations located
18 on the outer security fence surrounding the ISFSI. Other TLD stations are located just north of
19 the ISFSI between the ISFSI and the plant access road, and one is approximately 0.1 mi north
20 of CGS between the transformer yard and the ISFSI. Radiological exposure rates at the ISFSI
21 security fence are elevated, and access to the area directly outside the fence requires
22 notification and approval by CGS's radiation protection personnel and security to enter. In
23 addition to the TLD monitoring program, quarterly radiological surveys of the ISFSI are carried
24 out by the CGS Radiation Protection Department.

25 No spent fuel storage casks were added to the ISFSI during 2009. The TLD results showed a
26 lowering trend for the ISFSI. The TLDs near the turbine building showed a marked drop in the
27 second and third quarters reflecting plant operational status.

28 Additional Air Sample and TLD Locations. Four additional air sample locations and five TLD
29 stations were established in 2008–2009 in order to monitor air quality and direct radiation during
30 remediation work at the DOE 618-11 burial ground located just west of CGS. Air samples were
31 collected, and TLDs were exchanged at these locations in 2009—though no remediation work
32 took place at the burial ground during the year. Air particulate data from the four locations show
33 no indication of any effects from CGS effluents. Three of the TLD stations had results slightly
34 higher than background due to the station's close proximity to the turbine building and the
35 ISFSI.

36 Summary. Based on the review of the radiological environmental monitoring data, the staff
37 found that there were no unusual and adverse trends, and there was no measurable impact to
38 the offsite environment from operations at CGS.

39 Hanford Site Radiological Environmental Monitoring Program. Federal, State, and local
40 government agencies monitor and enforce compliance with applicable environmental
41 regulations at the Hanford Site. Major agencies include the U.S. Environmental Protection
42 Agency (EPA), Washington State Department of Ecology, Washington State Department of
43 Health (WDOH), and Benton Clean Air Agency. These agencies issue permits, review
44 compliance reports, participate in joint monitoring programs, inspect facilities and operations,
45 and oversee compliance with regulations. A key feature in the Hanford Site compliance
46 program is the *Hanford Federal Facility Agreement and Consent Order* (also known as the

1 Tri-Party Agreement). The Tri-Party Agreement is an agreement between DOE, EPA, and the
 2 Washington State Department of Ecology delineating specific requirements, actions, plans, and
 3 schedules required to achieve compliance with the *Comprehensive Environmental Resource,*
 4 *Compensation, and Liability Act of 1980* (CERCLA) and *Resource Conservation and Recovery*
 5 *Act of 1976* (RCRA) regulations and provisions.

6 The staff reviewed the Hanford Site ERs for the years 2005–2008 (the latest report available at
 7 the time of this review) (DOE, 2010d). The staff’s focus is on the monitoring data that assesses
 8 the potential impact to areas and members of the public beyond the Hanford Site boundary.
 9 The following is a summary of the Hanford Site radiological environmental monitoring data for
 10 2008.

11 Air. Radioactive emissions were monitored at Hanford Site facilities. Air particles and gases
 12 were monitored for radioactivity onsite near facilities and offsite. Air samples were collected at
 13 92 locations near Hanford Site facilities, at 23 locations around the site away from facilities, at
 14 11 site perimeter locations, and at 8 community locations.

15 All measurements of radioactive materials in air were below recommended regulatory
 16 guidelines. In general, radionuclide concentrations near facilities were at or near Hanford Site
 17 background levels and were much less than DOE-derived concentration guides. Some Hanford
 18 Site values were greater than concentrations measured offsite. The data also show that
 19 concentrations of certain radionuclides were higher and widely variable within different onsite
 20 operational areas. All offsite air sample results showed very low radiological concentrations in
 21 2008 and were below the EPA *Clean Air Act* dose standard of 10 millirem (mrem) per year.

22 Columbia River Water and Sediment. Columbia River water and sediment samples were
 23 collected from multiple Hanford Reach sampling points and from locations upstream and
 24 downstream of the Hanford Site. The samples were analyzed for radioactive contaminants. As
 25 in past years, small amounts of radioactive materials were detected downriver from the Hanford
 26 Site. However, the amounts were far below Federal and State limits. During 2008, there was
 27 no indication of any deterioration of Columbia River water or sediment quality resulting from
 28 operations at the Hanford Site.

29 Columbia River, Shoreline, Spring Water, Hanford Site Drinking Water, and Sediment.
 30 Groundwater beneath the Hanford Site discharges to the Columbia River along the Hanford Site
 31 shoreline. Discharges above the water level of the river are identified as shoreline springs.
 32 Samples of spring water and sediment were collected at locations along the Hanford Reach.
 33 Measurements of radiological contaminants in samples collected at the shoreline springs were
 34 less than applicable DOE concentration guides. During 2008, annual average concentrations of
 35 all monitored radionuclides in Hanford Site drinking water were below Federal and State
 36 maximum allowable contaminant levels. Radionuclide concentrations measured in shoreline
 37 sediment samples were similar to concentrations measured in Columbia River sediment, with
 38 the exception of the 300 Area where uranium concentrations were above the background
 39 concentration measured in the sediments from the reservoir behind Priest Rapids Dam.

40 Hanford Site Drinking Water. During 2008, annual average concentrations of all monitored
 41 radionuclides in Hanford Site drinking water were below Federal and State maximum allowable
 42 contaminant levels.

43 Hanford Groundwater. Liquid waste released to the ground at the Hanford Site during many
 44 years of nuclear materials production has reached the onsite groundwater. Radioactive
 45 contaminants include tritium, Sr-90, Tc-99, I-129, and uranium. Currently, groundwater

Environmental Impacts of Operation

1 contaminant levels are greater than drinking water standards (DWSs) beneath 12 percent
2 (approximately 70 square miles (mi²)) of the area of the Hanford Site. The report states that the
3 levels are decreasing with time due to radioactive decay and dispersion. Tritium is a significant
4 contaminant of the Hanford onsite groundwater. For example, in 2008 the concentrations of
5 tritium in groundwater near onsite facilities and waste sites range from 5,000–1,200,000 pCi/L.
6 This is well above the EPA's DWS of 20,000 pCi/L. However, site groundwater is not a source
7 of public drinking water and, as reported in the drinking water monitoring section above, does
8 not significantly affect offsite drinking water sources such as the Columbia River and city wells.

9 Food and Farm Products. Samples of milk, potatoes, tomatoes, and cherries were collected
10 from locations upwind and downwind of the Hanford Site. Radionuclide concentrations in
11 samples of food and farm products were at normal environmental levels.

12 Fish and Wildlife. Game animals and other animals of interest on the Hanford Site, and fish
13 from the Hanford Reach of the Columbia River, were monitored. Carcass, liver, and muscle
14 samples were analyzed to evaluate radionuclide concentrations. Populations of selected fish
15 and wildlife species were also surveyed or monitored. Samples of carp, suckers, smallmouth
16 bass, mule deer, and clams were collected and analyzed. Radionuclide levels in wildlife
17 samples were well below levels that are estimated to cause adverse health effects to animals or
18 to the people who may consume them.

19 Soil. To verify known radiological conditions, 95 routine soil samples were collected onsite near
20 facilities and operations in 2008. There were also 41 soil samples collected site-wide and at
21 offsite locations to investigate potential contamination. In general, radionuclide concentrations
22 in routine samples collected from or adjacent to waste disposal facilities in 2008 were higher
23 than concentrations measured in distant communities in previous years. There were 16
24 instances of radiological contamination in soil samples investigated in 2008. Of the 16, 9 were
25 cleaned up. The contamination levels at the other locations did not exceed the radiological
26 control limits for the sites, and the soil was left in place.

27 Vegetation. Vegetation samples were collected on, or adjacent to, former waste disposal sites
28 and from locations downwind and near, or within, the boundaries of operating facilities and
29 remedial action sites to monitor for radioactive contaminants. In general, radionuclide
30 concentrations in vegetation samples collected from, or adjacent to, waste disposal facilities in
31 2008 were higher than concentrations in samples collected farther away, including
32 concentrations measured offsite. During 2008, radiological contamination was found in
33 127 vegetation samples collected around areas of known or suspected contamination, or
34 around specific project regions, on the Hanford Site. All the samples were disposed of at a
35 licensed facility.

36 Potential Radiological Doses from 2008 Hanford Site Operations. During 2008, potential
37 radiological doses to the public and biota from Hanford Site operations were evaluated to
38 determine compliance with pertinent regulations and limits. Doses were assessed in the
39 following terms:

- 40 • total dose (multiple pathways) to the hypothetical, maximally exposed individual at an
41 offsite location
- 42 • average dose to the collective population living within 50 mi of Hanford Site operating
43 areas
- 44 • dose for air pathways using EPA methods

- 1 • dose to workers on the site consuming drinking water
- 2 • doses from non-DOE industrial sources on and near the Hanford Site
- 3 • absorbed dose received by animals exposed to contaminants released to the Columbia
- 4 River and in onsite surface water bodies

5 All doses from Hanford Site activities in 2008 were lower than EPA and DOE standards.

6 Summary. The DOE ERs state that the levels of radioactivity in the offsite environment had no
7 measurable impact to the offsite environment from the Hanford Site. The measured offsite
8 radioactivity levels are generally trending downward to levels approaching background. This is
9 due to a combination of DOE's clean-up work and radioactive decay of the residual radioactivity.

10 Washington State Department of Health's Hanford Environmental Radiation Oversight Program.
11 Since 1985, the WDOH's Hanford Environmental Radiation oversight program has participated
12 with the DOE in the collection of environmental samples on or near the Hanford Site. The
13 purpose of the program is to independently verify the quality of DOE environmental monitoring
14 programs at the Hanford Site and to assess the potential for public health impacts
15 (WDOH, 2011).

16 The oversight program's objectives are met through collection and analysis of environmental
17 samples and interpretation of results. WDOH's environmental samples are either split or
18 collocated with DOE contractors, and the results are compared to verify the quality of the DOE
19 monitoring programs at Hanford. Samples of air, groundwater, surface water, riverbank seep
20 water, drinking water, discharge water, sediment, food and farm products, fish and wildlife, and
21 vegetation are collected. In addition, ambient external radiation levels are measured using
22 radiation dosimeters.

23 For 2008, most environmental samples analyzed by WDOH have radioactivity concentrations
24 that are either below detection limits or consistent with background. A few samples have
25 concentrations elevated above background; however, in most cases the concentrations are
26 consistent with historical trends. For example, carbon-14 (C-14), tritium, I-129, Sr-90,
27 technetium-99 (Tc-99), and isotopes of uranium were detected above background levels in
28 some Hanford Site and Hanford boundary water samples. A variety of radionuclides, including
29 Cs-137, europium-152 (Eu-152), plutonium-239/240 (Pu-239/240), Sr-90, and isotopes of
30 uranium, were found above background levels in some Columbia River sediment samples.
31 Most of the elevated concentrations are consistent with historical trends. Anomalously elevated
32 radionuclide concentrations were found in selected samples—air samples from onsite locations
33 near the 100K Area, groundwater samples from the 200 West and 200 East Areas, Columbia
34 River surface water samples from the 100N Area, and TLD results at the 100KE Area.

35 In summary, the 2008 report states that while Hanford operations have resulted in radionuclides
36 entering the environment, the data from the WDOH oversight program show that public
37 exposure to radioactivity from Hanford is far below regulatory limits (WDOH 2011).

38 Columbia Generating Station Radioactive Effluent Release Program. All nuclear plants were
39 licensed with the expectation that they would release radioactive material to both the air and
40 water during normal operation. However, NRC regulations require that radioactive gaseous and
41 liquid releases from nuclear power plants must meet radiation dose-based limits, specified in
42 10 CFR Part 20, and ALARA criteria in Appendix I to 10 CFR Part 50. Regulatory limits are
43 placed on the radiation dose that members of the public can receive from radioactive material
44 released by a nuclear power plant. In addition, nuclear power plants are required to file an

Environmental Impacts of Operation

1 annual report to the NRC, which lists the types and quantities of radioactive effluents released
2 into the environment. The radioactive effluent release reports are available for review by the
3 public through the Agencywide Documents Access and Management System (ADAMS)
4 electronic reading room, available through the NRC website.

5 The staff reviewed the annual radioactive effluent release reports for 2005–2009 (EN, 2006b),
6 (EN, 2007b), (EN, 2008b), (EN, 2009b), (EN, 2010c). The review focused on the calculated
7 doses to a member of the public from radioactive effluents released from CGS. The doses were
8 compared to the radiation protection standards in 10 CFR 20.1301 and the ALARA dose design
9 objectives in Appendix I to 10 CFR Part 50.

10 Dose estimates for members of the public are calculated based on radioactive gaseous and
11 liquid effluent release data and atmospheric and aquatic transport models. The 2009 annual
12 radioactive material release report (EN, 2010c) contains a detailed presentation of the
13 radioactive discharges and the resultant calculated doses. CGS water management practices
14 are carried out so that there is no need to discharge radioactive liquid effluents into the
15 Columbia River. No radioactive liquid effluents have been discharged in 10 years. The liquid
16 waste is processed into solid waste and disposed of in a low-level radioactive waste disposal
17 facility.

18 The following summarizes the calculated hypothetical maximum dose to a member of the public
19 located outside the CGS site boundary from radioactive gaseous and liquid effluents released
20 during 2009:

- 21 • The maximum whole-body dose to an offsite member of the public from radioactive liquid
22 effluents was 0 mrem (0 mSv) because there were no radioactive liquid discharges
23 during 2009.
- 24 • The maximum organ dose to an offsite member of the public from radioactive liquid
25 effluents was 0 mrem (0 mSv) because there were no radioactive liquid discharges to
26 the Columbia River during 2009.
- 27 • The maximum air dose at the site boundary from gamma radiation in gaseous effluents
28 was 1.54 E-02 mrad (1.54 E-04 mGy), which is well below the 10 mrad (0.1 mGy) dose
29 criterion in Appendix I to 10 CFR Part 50.
- 30 • The maximum air dose at the site boundary from beta radiation in gaseous effluents was
31 5.83 E-03 mrad (5.83 E-05 mGy), which is well below the 20 mrad (0.2 mGy) dose
32 criterion in Appendix I to 10 CFR Part 50.
- 33 • The maximum organ (skin) dose to an offsite member of the public at the site boundary
34 from radioactive iodine and radioactive material in particulate form was 1.84 E-02 mrem
35 (1.84 E-04 mSv), which is well below the 15 mrem (0.15 mSv) dose criterion in
36 Appendix I to 10 CFR Part 50.

37 The staff's review of CGS's radioactive waste system performance in controlling radioactive
38 effluents found that the radiological doses to members of the public for the years 2005–2009
39 comply with Federal radiation protection standards contained in Appendix I to 10 CFR Part 50,
40 10 CFR Part 20, and 40 CFR Part 190.

41 Routine plant operational and maintenance activities currently carried out will continue during
42 the license renewal term. Based on the past performance of the radioactive waste system to

1 maintain the dose from radioactive effluents to be ALARA, similar performance is expected
2 during the license renewal term.

3 The radiological impacts from the current operation of CGS are not expected to change
4 significantly. Continued compliance with regulatory requirements is expected during the license
5 renewal term; therefore, the impacts from radioactive effluents would be SMALL.

6 **4.8.3 Microbiological Organisms**

7 Table B-1 of Appendix B to Subpart A of 10 CFR Part 51 lists the effects of thermophilic
8 microbiological organisms on public health as a Category 2 issue that applies to nuclear plants
9 that discharge to small rivers (those with an annual average flow rate of less than
10 3.15×10^{12} ft³/year). As discussed in section 2.1.6, CGS has a closed-cycle heat dissipation
11 system that uses mechanical draft cooling towers for which make-up water is pumped from the
12 Columbia River. From 1960–2009, the average mean annual discharge of the Columbia River
13 below Priest Rapids Dam was 117,823 cfs (USGS, 2010), which is approximately
14 3.72×10^{12} ft³/year. Since this flow rate is greater than 3.15×10^{12} ft³/year, the Columbia River
15 does not meet the definition of a small river. Therefore, this issue does not apply to CGS.

16 **4.8.4 Electromagnetic Fields—Acute Effects**

17 Based on the GEIS, the NRC found that electric shock resulting from direct access to energized
18 conductors or from induced charges in metallic structures has not been found to be a problem at
19 most operating plants and, generally, is not expected to be a problem during the license renewal
20 term. However, site-specific review is required to determine the significance of the electric
21 shock potential along the portions of the transmission lines that are within the scope of this
22 SEIS.

23 In the GEIS (NRC, 1996), the staff found that without a review of the conformance of each
24 nuclear plant transmission line with National Electrical Safety Code (NESC) criteria, it was not
25 possible to determine the significance of the electric shock potential (IEEE, 2002). Evaluation of
26 individual plant transmission lines is necessary because the issue of electric shock safety was
27 not addressed in the licensing process for some plants. For other plants, land use near
28 transmission lines may have changed or power distribution companies may have chosen to
29 upgrade line voltage. To comply with 10 CFR 51.53(c)(3)(ii)(H), Energy Northwest must supply
30 an assessment of the impact of the proposed action on the potential shock hazard from the
31 transmission lines if the transmission lines that were constructed for the specific purpose of
32 connecting the plant to the transmission system do not meet the recommendations of the NESC
33 for preventing electric shock from induced currents.

34 CGS electrical output is delivered to the Bonneville Power Administration (BPA) at the H.J.
35 Ashe Substation located 0.5 mi north of the plant via an elevated 500-kilovolt (kV) line. CGS
36 startup power comes from the Ashe Substation to the CGS transformer yard on a 230-kV
37 parallel line. A third line supporting CGS serves as a backup power source. This line runs
38 between the CGS transformer yard and a tap off the 115-kV line running between the Benton
39 Switchyard and the Fast Flux Test Facility. These are the lines that are within the scope of
40 license renewal. BPA developed an electric field strength policy for the design and operation of
41 its transmission system. The policy is intended to minimize shock hazards consistent with the
42 NESC criteria. Energy Northwest's analysis determined that there are no locations within the
43 ROW under the transmission lines that have the capacity to induce more than 5 milliamperes
44 (mA) in a vehicle parked beneath the lines. Therefore, the lines meet the NESC 5 mA criterion.

Environmental Impacts of Operation

1 The maximum induced current calculated for the power lines was 4.4 mA (EN, 2010),
2 (Gambhir, 2010c).

3 The CGS transmission line corridor crosses developed portions of the CGS site and open range
4 type space. No land use changes are anticipated near the corridor. Energy Northwest and BPA
5 periodic surveillance of the transmission system assures that ground clearances remain in
6 compliance with NESC criteria (EN, 2010).

7 The staff reviewed the available information, including Energy Northwest's evaluation and
8 results. Based on this information, the staff concludes that the potential impacts from electric
9 shock during the renewal period would be SMALL.

10 **4.8.5 Electromagnetic Fields–Chronic Effects**

11 In the GEIS, the effects of chronic exposure to 60-Hertz electromagnetic fields from power lines
12 were not designated as Category 1 or 2 and will not be until a scientific consensus is reached
13 on the health implications of these fields.

14 The potential effects of chronic exposure from these fields continue to be studied and are not
15 known at this time. The National Institute of Environmental Health Sciences (NIEHS) directs
16 related research through the DOE.

17 The report by NIEHS (NIEHS, 1999) contains the following conclusion:

18 The NIEHS concludes that ELF-EMF (extremely low frequency-electromagnetic
19 field) exposure cannot be recognized as entirely safe because of weak scientific
20 evidence that exposure may pose a leukemia hazard. In our opinion, this finding
21 is insufficient to warrant aggressive regulatory concern. However, because
22 virtually everyone in the United States uses electricity and therefore is routinely
23 exposed to ELF-EMF, passive regulatory action is warranted such as continued
24 emphasis on educating both the public and the regulated community on means
25 aimed at reducing exposures. The NIEHS does not believe that other cancers or
26 non-cancer health outcomes provide sufficient evidence of a risk to currently
27 warrant concern.

28 This statement is not sufficient to cause the staff to change its position with respect to the
29 chronic effects of electromagnetic fields. The staff considers the GEIS finding of "UNCERTAIN"
30 still appropriate and will continue to follow developments on this issue.

31 **4.9 Socioeconomics**

32 The socioeconomic issues applicable to CGS are shown in Table 4.9-1 for Category 1,
33 Category 2, and one uncategorized issue (environmental justice). Section 2.2.9 of this SEIS
34 describes the socioeconomic conditions near CGS.

35 **Table 4.9-1. Socioeconomics issues during the renewal term**

| Issues | GEIS section | Category |
|---|-------------------------------------|----------|
| Housing Impacts | 4.7.1 | 2 |
| Public Services: public safety, social services, & tourism & recreation | 4.7.3; 4.7.3.3; 4.7.3.4; 4.7.3.6 | 1 |

| Issues | GEIS section | Category |
|--|------------------------------|------------------------------|
| Public Services: public utilities | 4.7.3.5 | 2 |
| Public Services: education (license renewal term) | 4.7.3.1 | 1 |
| Offsite Land Use (license renewal term) | 4.7.4 | 2 |
| Public Services: transportation | 4.7.3.2 | 2 |
| Historic and Archaeological Resources | 4.7.7 | 2 |
| Aesthetic Impacts (license renewal term) | 4.7.6 | 1 |
| Aesthetic impacts of transmission lines (license renewal term) | 4.5.8 | 1 |
| Environmental Justice | Not addressed ^(a) | Uncategorized ^(a) |

^(a) Guidance for implementing EO 12898 and conducting an environmental justice impact analysis was not available before completion of the GEIS. This issue must be addressed in plant-specific reviews.

1 4.9.1 Generic Socioeconomic Issues

2 The staff reviewed and evaluated the CGS ER, scoping comments, other available information,
 3 and visited CGS and did not find any new and significant information that would change the
 4 conclusions presented in the GEIS. Therefore, it is expected that there would be no impacts
 5 related to these Category 1 issues during the renewal term beyond those discussed in the
 6 GEIS. For CGS, the NRC incorporates the GEIS conclusions by reference. Impacts for
 7 Category 2 and the uncategorized issue (environmental justice) are discussed in
 8 Sections 4.9.2–4.9.7.

9 4.9.2 Housing Impacts

10 Appendix C of the GEIS presents a population characterization method based on two factors—
 11 sparseness and proximity (GEIS, Section C.1.4). Sparseness measures population density
 12 within 20 mi (32 kilometers (km)) of the site, and proximity measures population density and city
 13 size within 50 mi (80 km). Each factor has categories of density and size (GEIS, Table C.1). A
 14 matrix is used to rank the population category as low, medium, or high (GEIS, Figure C.1).

15 According to the 2000 Census, an estimated 171,371 people lived within 20 mi (32 km) of CGS,
 16 which equates to a population density of 136 persons per mi² (EN, 2010). This translates to a
 17 Category 4, “least sparse” population density using the GEIS measure of sparseness (greater
 18 than or equal to 120 persons per mi² within 20 mi). An estimated 387,512 people live within
 19 50 mi (80 km) of CGS with a population density of 49.4 persons per mi² (EN, 2010a). Since the
 20 Richland-Kennewick-Pasco Metropolitan Statistical Area (Tri-Cities MSA) has a combined
 21 population of over 200,000 persons and is located within 50 mi of CGS, this translates to a
 22 Category 3 density using the GEIS measure of proximity (one or more cities with 100,000 or
 23 more persons and less than 190 persons per mi² within 50 mi). Therefore, CGS is located in a
 24 high population area based on the GEIS sparseness and proximity matrix.

25 Table B-1 of 10 CFR Part 51, Subpart A, Appendix B states that impacts on housing availability
 26 are expected to be of small significance in a medium or high-density population area where
 27 growth-control measures are not in effect. Since CGS is located in a medium to high population
 28 area, and Benton and Franklin Counties are not subject to growth-control measures that would
 29 limit housing development, any changes in employment at CGS would have little noticeable
 30 effect on housing availability in these counties. Since Energy Northwest has no plans to add
 31 additional outage and non-outage employees during the license renewal period, employment
 32 levels at CGS would remain relatively constant with no additional demand for permanent

Environmental Impacts of Operation

1 housing during the license renewal term. Based on this information, there would be no impact
2 on housing during the license renewal term beyond what has already been experienced.

3 **4.9.3 Public Services: Public Utility Impacts**

4 Impacts on public utility services (e.g., water, sewer) are considered SMALL if the public utility
5 has the ability to respond to changes in demand and would have no need to add or modify
6 facilities. Impacts are considered MODERATE if service capabilities are overtaxed during
7 periods of peak demand. Impacts are considered LARGE if additional system capacity is
8 needed to meet ongoing demand.

9 Analysis of impacts on the public water systems considered both plant demand and
10 plant-related population growth. Section 2.1.3 describes the permitted withdrawal rate and
11 actual use of water for reactor cooling at CGS.

12 Since Energy Northwest has no plans to add non-outage employees during the license renewal
13 period, employment levels at CGS would remain relatively unchanged with no additional
14 demand for public water services. Public water systems in the region are adequate to meet the
15 demands of residential and industrial customers in the area. Therefore, there would be no
16 additional impact to public water services during the license renewal term beyond what is
17 currently being experienced.

18 **4.9.4 Offsite Land Use—License Renewal Period**

19 Offsite land use during the license renewal term is a Category 2 issue (10 CFR Part 51,
20 Subpart A, Appendix B, Table B-1). Table B-1 notes that “significant changes in land use may
21 be associated with population and tax revenue changes resulting from license renewal.”
22 Section 4.7.4 of the GEIS defines the magnitude of land-use changes as a result of plant
23 operation during the license renewal term as SMALL when there will be little new development
24 and minimal changes to an area's land-use pattern, as MODERATE when there will be
25 considerable new development and some changes to the land-use pattern, and as LARGE
26 when there will be large-scale new development and major changes in the land-use pattern.

27 Tax revenue can affect land use because it enables local jurisdictions to supply the public
28 services (e.g., transportation and utilities) necessary to support development. Section 4.7.4.1 of
29 the GEIS states that the assessment of tax-driven land-use impacts during the license renewal
30 term should consider the following:

- 31 • the size of the plant's tax payments relative to the community's total revenues
- 32 • the nature of the community's existing land-use pattern
- 33 • the extent to which the community already has public services in place to support and
34 guide development

35 If the plant's tax payments are projected to be small relative to the community's total revenue,
36 tax driven land-use changes during the plant's license renewal term would be SMALL,
37 especially where the community has pre-established patterns of development and has supplied
38 public services to support and guide development. Section 4.7.2.1 of the GEIS states that if tax
39 payments by the plant owner are less than 10 percent of the taxing jurisdiction's revenue, the
40 significance level would be SMALL. If tax payments are 10–20 percent of the community's total
41 revenue, new tax-driven land-use changes would be MODERATE. If tax payments are greater
42 than 20 percent of the community's total revenue, new tax-driven land-use changes would be

1 LARGE. This would be especially true where the community has no pre-established pattern of
 2 development or has not supplied adequate public services to support and guide development.

3 **4.9.4.1 Population-Related Impacts**

4 Since Energy Northwest has no plans to add non-outage employees during the license renewal
 5 period, there would be no plant operations-driven population increase near CGS. Therefore,
 6 there would be no additional population-related offsite land use impacts during the license
 7 renewal term beyond those already being experienced.

8 **4.9.4.2 Tax Revenue-Related Impacts**

9 As previously discussed in Chapter 2, Energy Northwest makes annual payments in lieu of
 10 taxes (PILOT) to 5 counties (Benton, Franklin, Grant, Walla Walla, and Yakima), 10 cities
 11 (Richland, Kennewick, Pasco, Benton City, Prosser, West Richland, Connell, Mesa, Grandview,
 12 Sunnyside), 17 fire districts, and 4 library districts where Energy Northwest sells power. Since
 13 Energy Northwest started making payments to local jurisdictions, population levels and land use
 14 conditions have not changed significantly, which might show that these tax revenues have had
 15 little or no affect on land use activities within the county. PILOT payments are based upon the
 16 gross revenues Energy Northwest receives from electricity sales in the five counties, regardless
 17 of where the power is generated. The magnitude of the PILOT payments relative to the
 18 county's total revenues is not relevant in assessing tax revenue-related offsite land use impacts
 19 since Energy Northwest is responsible for producing and distributing electricity and PILOT
 20 payments even if the CGS does not produce electricity or the operating license is not renewed.

21 Since Energy Northwest has no plans to add non-outage employees during the license renewal
 22 period, employment levels at CGS would remain relatively unchanged. Annual PILOT
 23 payments would also remain relatively unchanged throughout the license renewal period.
 24 Based on this information, there would be no additional tax-revenue-related offsite land use
 25 impacts during the license renewal term beyond those already being experienced.

26 **4.9.5 Public Services: Transportation Impacts**

27 Table B-1 of Appendix B to Subpart A of 10 CFR Part 51 states the following:

28 Transportation impacts (level of service) of highway traffic generated...during the
 29 term of the renewed license are generally expected to be of SMALL significance.
 30 However, the increase in traffic associated with additional workers and the local
 31 road and traffic control conditions may lead to impacts of MODERATE or LARGE
 32 significance at some sites.

33 The regulation in 10 CFR 51.53(c)(3)(ii)(J) requires all applicants to assess the impacts of
 34 highway traffic generated by the proposed project on the level of service of local highways
 35 during the term of the renewed license. Since Energy Northwest has no plans to add
 36 non-outage employees during the license renewal period, traffic volume and levels of service on
 37 roadways near CGS would not change. Therefore, there would be no transportation impacts
 38 during the license renewal term beyond those already being experienced.

39 **4.9.6 Historic and Archaeological Resources**

40 The National Historic Preservation Act (NHPA) requires Federal agencies to consider the effects
 41 of their undertakings on historic properties, and renewing the operating license of a nuclear

Environmental Impacts of Operation

1 power plant is an undertaking that could potentially affect historic properties. Historic properties
2 are defined as resources that are eligible for listing in the National Register of Historic Places
3 (NRHP). The criteria for eligibility are listed in 36 CFR 60.4 and include the following
4 (ACHP, 2008):

- 5 • association with significant events in history
- 6 • association with the lives of persons significant in the past
- 7 • embodiment of distinctive characteristics of type, period, or construction
- 8 • sites or places that have yielded or are likely to yield important information

9 The historic preservation review process (Section 106 of the NHPA) is outlined in regulations
10 issued by the Advisory Council on Historic Preservation (ACHP) in 36 CFR Part 800.

11 In accordance with the provisions of the NHPA, the NRC is required to make a reasonable effort
12 to note historic properties included in or eligible for inclusion on the NRHP in the area of
13 potential effect (APE). The APE for license renewal generally consists of the nuclear power
14 plant site, transmission lines connected to the power plant, and the immediate environs. If
15 historic properties are present, the NRC is required to contact the State Historic Preservation
16 Office (SHPO), assess the potential impact, and resolve any possible adverse effects of the
17 undertaking (license renewal) on historic properties. The NRC is also required to notify the
18 SHPO if historic properties would not be affected by license renewal or if no historic properties
19 are present. This section assesses the potential effects of license renewal on historic properties
20 on or near the CGS site. Section 2.2.9 describes potentially affected historic properties near
21 CGS.

22 Before submitting an operating license renewal application for CGS, Energy Northwest
23 contacted the Washington SHPO in April 2008, requesting information about historic and
24 archaeological resources near CGS (EN, 2010). The Washington SHPO responded in
25 April 2008, requesting information about the proposed APE (EN, 2010). In May 2008, Energy
26 Northwest submitted a detailed map to the Washington SHPO showing the leased boundaries
27 of CGS overlaid on a USGS topographic map. A third letter from Energy Northwest was sent in
28 July 2008, which proposed expanding the CGS APE to include three transmission lines that
29 were part of the original CGS construction and operation licenses (EN, 2010). These
30 transmission lines were constructed by BPA before the construction of CGS and are currently
31 maintained by BPA. In August 2008, SHPO concurred with this APE designation (EN, 2010).

32 In accordance with 36 CFR 800.8(c), the NRC initiated Section 106 consultation with the ACHP
33 and the Washington SHPO in March 2010, by notifying them of the agency's intent to conduct a
34 review of a request from Energy Northwest to renew the CGS operating license. On March
35 29, 2010, the SHPO responded to the NRC's letter by requesting a map depicting the proposed
36 APE (Whitlam, 2010b). In April, via letter to the Washington SHPO, the NRC reiterated the
37 proposed APE information presented in Energy Northwest's ER, Appendix D (EN, 2010). At the
38 time, the proposed APE included CGS leased lands, as well as the three BPA-operated
39 transmission lines. In April 2010, the Washington SHPO concurred with this APE designation
40 (Whitlam, 2010c). No comments were received from the ACHP as a result of these consultation
41 letters.

42 The issue of whether to include the BPA-operated transmission lines in the CGS APE was
43 revisited during a meeting between the staff and the Washington SHPO in June 2010. During
44 the meeting, the staff explained that although the transmission lines were part of the CGS
45 operating license, the lines were constructed by BPA before the construction of CGS and are

1 currently maintained by BPA. On July 22, 2010, Energy Northwest sent a revised CGS APE to
2 the Washington SHPO, which proposed reverting back to the original CGS APE without the
3 BPA-operated transmission lines (Coleman, 2010). The Washington SHPO concurred with this
4 revised CGS APE on July 29, 2010 (Whitlam, 2010a). The three BPA-operated transmission
5 lines are not part of the CGS APE because BPA adheres to its own NHPA and NEPA
6 requirements for the operation and maintenance of these lines (Coleman, 2010). In late
7 November, 2010, the APE was expanded to include an additional 1.8 miles of CGS-supported
8 transmission line to the southeast of CGS that provides backup power to CGS during plant
9 shutdowns (Pham, 2010e). The SHPO concurred with this final APE (Whitlam, 2010d).

10 The NRC also initiated consultation on the proposed CGS license renewal with three Federally
11 recognized tribes: the Confederated Tribes of the Umatilla Indian Reservation (CTUIR), Yakama
12 Nation, and the Nez Perce (Pham, 2010a), (Pham, 2010b), (Pham, 2010c). In letters to the
13 tribes, the NRC supplied information about the proposed action (license renewal) and the
14 definition of the APE and stated that the NHPA review would be integrated with the NEPA
15 process, according to 36 CFR 800.8. The NRC invited the tribes to participate in the
16 identification of potentially affected historic properties near CGS and the scoping process.

17 The NRC held a meeting with the tribes on April 27, 2010, to explain the license renewal
18 process and to listen to any expressions of concern with the proposed action. Representatives
19 from two Federally recognized tribes (Yakama Nation and the CTUIR) and one non-Federally
20 recognized tribe (Wanapum) attended this meeting. Discussions focused on environmental
21 justice concerns and human health and environmental risk scenarios (NRC, 2010).

22 In June 2010, several Tribal members from the Wanapum, Nez Perce Tribe, and CTUIR
23 participated in a tour of the culturally sensitive area along the Columbia River and review of
24 Energy Northwest's cultural resources protection procedure. A brief overview of historic and
25 archaeological resource surveys and sites recorded on CGS was also supplied. After the tour
26 and review, Tribal representatives recommended that Energy Northwest work with Tribal
27 representatives to develop cultural resources sensitivity and awareness training for CGS
28 (NRC, 2011).

29 Energy Northwest currently has no planned changes or ground disturbing activities associated
30 with license renewal at CGS. However, given the potential for the discovery of additional
31 historic and archaeological resources at the CGS site, Energy Northwest developed a cultural
32 resources protection procedure. The procedure ensures resources are considered before any
33 ground disturbance during future plant operations and maintenance activities (Gambhir, 2010a),
34 (Gambhir, 2010b). The procedure is overseen by Energy Northwest personnel who have
35 received cultural resources compliance training (Gambhir, 2010a). The procedure identifies
36 situations requiring coordination with archaeological professionals and the SHPO. In addition,
37 certain restrictions apply for performing work in the culturally sensitive zone. The procedure
38 further shows that because CGS is located on lands leased from DOE, discoveries of human
39 remains and other items of cultural patrimony covered under the *Native American Graves*
40 *Protection and Repatriation Act* would follow DOE procedures outlined in the Hanford Cultural
41 Resources Management Plan. Energy Northwest sent its cultural resources protection
42 procedure to the Washington SHPO on November 2009 (Gambhir, 2010b). No comments were
43 given by the SHPO at that time. Because there are no planned changes to CGS, no additional
44 visual impacts would occur, which means there will be no indirect impacts to the TCPs on *Laliik*
45 and Gable Mountain and Gable Butte. A signed Memorandum of Agreement is in place
46 between DOE, Energy Northwest, and SHPO to resolve any adverse effects related to the

Environmental Impacts of Operation

1 ongoing operation of the Energy Northwest communication facility located on top of *Laliik*
2 (DOE, 2009a).

3 Based on review of archaeological surveys, assessments, and other information, the potential
4 impacts of continued operations and maintenance on historic and archaeological resources at
5 CGS would be SMALL, and there would be no adverse effect on historic properties
6 (36 CFR Section 800.4(d)(1)). Energy Northwest could reduce the risk of potential impacts to
7 historic and archaeological resources located on or near CGS by following their Cultural
8 Resources Protection Plan and by providing staff training on the NHPA Section 106 consultation
9 process as well as on cultural awareness to ensure that informed decisions are made before
10 any ground disturbing activities. Any revisions to the Cultural Resources Protection Plan should
11 be developed in consultation with the NRC and the Washington SHPO and consulting tribes. In
12 addition, lands not surveyed should be investigated by a qualified archaeologist before any
13 ground disturbing activity. Given the potential for discovery of subsurface archaeological
14 material within the culturally sensitivity zone, Energy Northwest needs to ensure that these
15 areas are considered during future plant operations and maintenance activities.

16 **4.9.7 Environmental Justice**

17 Under Executive Order (EO) 12898 (59 FR 7629), Federal agencies are responsible for
18 identifying and addressing, as appropriate, potential disproportionately high and adverse human
19 health and environmental impacts on minority and low-income populations. In 2004, the NRC
20 issued a *Policy Statement on the Treatment of Environmental Justice Matters in NRC*
21 *Regulatory and Licensing Actions* (69 FR 52040), which states that “[t]he Commission is
22 committed to the general goals set forth in EO 12898, and strives to meet those goals as part of
23 its NEPA review process.”

24 The Council of Environmental Quality (CEQ) provides the following information in *Environmental*
25 *Justice: Guidance Under the National Environmental Policy Act* (CEQ, 1997):

26 **Disproportionately High and Adverse Human Health Effects.** Adverse health
27 effects are measured in risks and rates that could result in latent cancer fatalities,
28 as well as other fatal or nonfatal adverse impacts on human health. Adverse
29 health effects may include bodily impairment, infirmity, illness, or death.
30 Disproportionately high and adverse human health effects occur when the risk or
31 rate of exposure to an environmental hazard for a minority or low-income
32 population is significant (as employed by NEPA) and appreciably exceeds the
33 risk or exposure rate for the general population or for another appropriate
34 comparison group (CEQ 1997).

35 **Disproportionately High and Adverse Environmental Effects.** A
36 disproportionately high environmental impact that is significant (as defined by
37 NEPA) refers to an impact or risk of an impact on the natural or physical
38 environment in a low-income or minority community that appreciably exceeds the
39 environmental impact on the larger community. Such effects may include
40 ecological, cultural, human health, economic, or social impacts. An adverse
41 environmental impact is an impact that is determined to be both harmful and
42 significant (as employed by NEPA). In assessing cultural and aesthetic
43 environmental impacts, impacts that uniquely affect geographically dislocated or
44 dispersed minority or low-income populations or American Indian tribes are
45 considered (CEQ 1997).

1 The environmental justice analysis assesses the potential for disproportionately high and
 2 adverse human health or environmental effects on minority and low-income populations that
 3 could result from the operation of CGS during the renewal term. In assessing the impacts, the
 4 following definitions of minority individuals and populations and low-income population were
 5 used (CEQ, 1997):

- 6 • **Minority individuals.** Individuals who identify themselves as members of the following
 7 population groups: Hispanic or Latino, American Indian or Alaska Native, Asian, Black or
 8 African American, Native Hawaiian or Other Pacific Islander, or two or more races—
 9 meaning individuals who identified themselves on a Census form as being a member of
 10 two or more races (e.g., Hispanic and Asian).
- 11 • **Minority populations.** Minority populations are identified when the minority population
 12 of an affected area exceeds 50 percent or the minority population percentage of the
 13 affected area is meaningfully greater than the minority population percentage in the
 14 general population or other appropriate unit of geographic analysis.
- 15 • **Low-income population.** Low-income populations in an affected area are identified
 16 with the annual statistical poverty thresholds from the Census Bureau's Current
 17 Population Reports, Series P60, on Income and Poverty.

18 **4.9.7.1 Minority Population**

19 There are a total of 10 counties in the 50-mi (80-km) radius surrounding CGS. Of these, eight
 20 are in Washington (Adams, Benton, Franklin, Grant, Kittitas, Klickitat, Walla Walla, and Yakima),
 21 and two are in Oregon (Morrow and Umatilla).

22 According to 2000 Census data, 36.9 percent of the population (356,404 persons) residing
 23 within a 80-km (50-mi) radius of CGS identified themselves as minority individuals. The largest
 24 minority group was Hispanic or Latino (113,000 persons or 31.7 percent), followed by persons
 25 identifying themselves as “Some other race” (80,000 persons or 22.5 percent) (USCB, 2003).

26 Of the approximately 300 census block groups located within the 50-mi radius of CGS, 54 block
 27 groups were determined to have minority race population percentages that exceeded the
 28 comparison area average by 20 percent or more. Persons identifying themselves as “Some
 29 other race” comprised the largest minority race population with 49 block groups. These block
 30 groups are concentrated primarily in the Tri-Cities area and Yakima. There were 5 American
 31 Indian or Alaska Native block groups that exceeded the comparison area average by 20 percent
 32 or more. An additional 61 block groups exceeded the comparison area average by 20 percent
 33 or more for Hispanic or Latino ethnicity. The minority population nearest to CGS is located in
 34 the Tri-Cities.

35 According to American Community Survey 3-Year Census data estimates, minority populations
 36 in the two county region (Benton and Franklin) increased by approximately 34,000 persons and
 37 comprised 42.9 percent of the total two county population (see Table 2.2.8.5-3). Most of this
 38 increase was due to an estimated influx of Hispanic or Latinos (over 18,000 persons), an
 39 increase in population of 44.8 percent from 2000. The highest percentage increase in minority
 40 population was “Some other race,” an increase of 54.3 percent from 2000. The next highest
 41 percentage increase in minority population was American Indian and Alaska Natives, an
 42 increase of 53.3 percent from 2000 (USCB, 2010).

43 Based on 2000 Census data, Figure 4.9-1 shows minority block groups within an 50-mi (80-km)
 44 radius of CGS.

Environmental Impacts of Operation




Figure 4.9-1. Census 2000 minority block groups within a 50-mi radius of CGS

(Source: EN, 2010)

1 **4.9.7.2 Low-Income Population**

2 According to 2000 Census data, approximately 11,000 families (12.2 percent) and 56,000
3 individuals (15.8 percent) residing within a 50-mi (80 km) radius of CGS were identified as living
4 below the Federal poverty threshold in 1999 (USCB, 2003). The 1999 Federal poverty
5 threshold was \$17,029 for a family of four. According to the 2000 Census, 7.3 percent of
6 families and 10.6 percent of individuals in Washington—and 7.9 percent of families and
7 11.6 percent of individuals in Oregon—were living below the Federal poverty threshold in 1999
8 (USCB, 2010).

9 Census block groups were considered low-income block groups if the percentage of families
10 and individuals living below the Federal poverty threshold exceeded the comparison area
11 average by 20 percent or more. Based on 2000 Census data, there were 13 block groups
12 within a 50-mi (80 km) radius of CGS that could be considered low-income block groups. The
13 majority of low-income population census block groups were located in the Tri-Cities area.

14 According to American Community Survey 3-Year Census data estimates, the median
15 household income for Washington for the years 2006–2008 was \$57,234, with 11.6 percent of
16 the state population and 7.9 percent of families living below the Federal poverty threshold.
17 Benton County had a slightly lower median household income average (\$54,544) and higher
18 percentages of individuals (12.7 percent) and families (9.9 percent) living below the poverty
19 level when compared to the state average. Franklin County had the lowest median household
20 income between the two counties (\$44,744) and higher percentages of individuals
21 (20.9 percent) and families (17.2 percent) living below the poverty level when compared to
22 Benton County and the state (USCB, 2010).

23 Figure 4.9-2 shows low-income census block groups within a 50-mi (80 km) radius of CGS.

Environmental Impacts of Operation




Figure 4.9-2. Census 2000 low-income block groups within a 50-mi radius of CGS

(Source: EN, 2010)

1 **4.9.7.3 Analysis of Impacts**

2 The NRC addresses environmental justice matters for license renewal by identifying minority
3 and low-income populations that may be affected by the proposed license renewal and
4 examining any potential human health or environmental effects on these populations to
5 determine if these effects may be disproportionately high and adverse.

6 The discussion and figures above identify the minority and low-income populations residing
7 within a 50-mi (80-km) radius of CGS. This area of impact is consistent with the impact analysis
8 for public and occupational health and safety, which also focuses on populations within a 50-mi
9 (80-km) radius of the plant. As previously discussed for the other resource areas in Chapter 4,
10 the analyses of impacts for all environmental resource areas showed that the impact from
11 license renewal would be SMALL.

12 Potential impacts to minority and low-income populations (such as migrant workers or Native
13 Americans) would mostly consist of radiological effects; however, radiation doses from
14 continued operations associated with this license renewal are expected to continue at current
15 levels and would remain within regulatory limits. Chapter 5 of this SEIS discusses the
16 environmental impacts from postulated accidents that might occur during the license renewal
17 term, which include design basis accidents. The NRC has generically determined that impacts
18 associated with such accidents are SMALL because the plant was designed to successfully
19 withstand design basis accidents.

20 Socioeconomic conditions at the Yakima Indian Reservation would not change as a result of
21 renewing the CGS operating license. Employment levels at CGS would remain relatively
22 unchanged, so employment opportunities at CGS would remain unchanged. In addition, the
23 Yakima Indian Reservation does not receive income from public utility tax monies paid by
24 Energy Northwest. Therefore, there would be no additional socioeconomic impact to minority
25 and low-income populations on the Yakima Indian Reservation during the license renewal term
26 beyond what is currently being experienced locally.

27 Therefore, based on this information and the analysis of human health and environmental
28 impacts presented in Chapters 4 and 5, it is not likely there would be any disproportionately high
29 and adverse impacts to minority and low-income populations from the continued operation of
30 CGS during the license renewal term.

31 As part of addressing environmental justice concerns associated with license renewal, the NRC
32 also assessed the potential radiological risk to special population groups (such as migrant
33 workers or Native Americans) from exposure to radioactive material received through their
34 unique consumption and interaction with the environment patterns including subsistence
35 consumption of fish, native vegetation, surface waters, sediments, and local produce;
36 absorption of contaminants in sediments through the skin; and inhalation of airborne radioactive
37 material released from the plant during routine operation. This analysis is presented in
38 Section 4.9.7.4.

39 The NRC also considered information supplied by American Indian Tribal representatives during
40 this review. The following is a brief summary of the reports submitted to the NRC for
41 consideration in conjunction with its evaluation of the environmental justice impacts from the
42 continued operation of CGS.

43 Human Scenarios for the Screening Assessment, Columbia River Comprehensive Impact
44 Assessment—March 1996. Because of past nuclear production operations along the Columbia

Environmental Impacts of Operation

1 River, there is intense public and Tribal interest in assessing any residual Hartford Site related
2 contamination along the river from the Hanford Reach to the Pacific Ocean. The Columbia
3 River Comprehensive Impact Assessment was proposed to address these concerns. The
4 assessment of the Columbia River is being carried out in phases. The initial phase is a
5 screening assessment of risk, which addresses current environmental conditions for a range of
6 potential uses.

7 One component of the screening assessment estimates the risk from contaminants in the
8 Columbia River to humans. Because humans affected by the Columbia River are involved in a
9 wide range of activities, various scenarios have been developed on which to base risk
10 assessments. The scenarios illustrate the range of activities possible by members of the public
11 coming in contact with the Columbia River so that the impact of contaminants in the river on
12 human health can be assessed. Each scenario illustrates particular activity patterns by a
13 specific rate. Risk will be assessed at the screening level for each scenario. This report defines
14 the scenarios and the exposure factors that will be the basis for estimating the potential range of
15 risk to human health from Hanford-derived radioactive as well as non radioactive contaminants
16 associated with the Columbia River. The potential range of risk will be assessed and published
17 in a separate report on the screening assessment of risk. In line with the scope of the screening
18 assessment, the scenarios are Hanford Site-specific (PNNL, 1996).

19 Yakama Nation Exposure Scenario for Hanford Site Risk Assessment, Richland, WA, prepared
20 for the Yakama Nation ERWM Program—September, 2007. An exposure scenario for risk
21 assessment was developed for the Confederated Tribes and Bands of the Yakama Nation to
22 describe their traditional subsistence lifestyle, including dietary patterns and seasonal activities.
23 This lifestyle may result in exposure to radioactive and hazardous chemical contamination, now
24 and in the future, from the nearby Hanford Nuclear Reservation in southeastern Washington.
25 The Hanford Site is located within the Yakama Nation ceded territory.

26 This scenario describes the maximum exposure reasonably expected to occur in the Yakama
27 population, who currently subsist on natural resources near Hanford. Upon adequate cleanup,
28 the Yakama hope to regain access to the Hanford Site, which is part of their usual and
29 accustomed use areas. Without compromising confidential information, details of this scenario
30 will be used by the DOE to complete an exposure assessment to evaluate potential risks to the
31 Yakama Nation from Hanford-associated contamination.

32 Using ethnographic interview methods, adult Yakama members described fishing, hunting, and
33 gathering practices, sweathouse use, feasts, and ceremonies—all of which remain critical
34 aspects of their subsistence lifestyle and unique culture. These data were compiled to give a
35 qualitative description of the current and anticipated future Yakama lifestyle and develop
36 quantitative exposure parameters.

37 This project resulted in a conceptual site model that was developed to illustrate potential
38 exposure pathways from Hanford Site contaminant releases to soil, water, plants, fish and other
39 animals, which may ultimately impact the Yakama people. Surveys found that the Yakama
40 depend heavily on the harvest and consumption of fish from local rivers, including the Columbia
41 River, which passes through the Hanford Site. They also depend upon wild game and an
42 abundance of local native plants, including shoots, roots, leafy material, and berries. These
43 resources provide not only foods and medicines, but also material for tools, shelter, and
44 accessories.

45 Federal guidance documents currently do not include adequate exposure information pertinent
46 to a Native American subsistence lifestyle. This scenario compiles information specific to the

1 Yakama Nation to be considered in evaluating potential risk from Hanford Site contamination
 2 and to support appropriate cleanup decisions. Exposure parameters were estimated for
 3 inhalation, dermal contact, and ingestion of air, soil, water, fish, meat, vegetables, fruit, and milk,
 4 and these parameters reflect the current and anticipated subsistence lifestyle. The Yakama
 5 expect that this scenario will be used to evaluate risk in a comprehensive manner for the entire
 6 Hanford Site—incorporating all sources, radiological and chemical contaminants, exposure
 7 pathways, and natural resource uses appropriately (RIDOLFI Inc., 2007).

8 Exposure Scenario for CTUIR Traditional Subsistence Lifeways. Confederated Tribes of the
 9 Umatilla Indian Reservation—September, 2004. This report presents updated exposure factors
 10 for the CTUIR exposure scenario. Tribal exposure scenarios pose a unique problem in that
 11 much of the specific cultural information about the uses of plants and animals for food,
 12 medicine, ceremonial, and religious purposes is proprietary. Therefore, the challenge to the
 13 scenario developer is to ensure that all human exposures received during the procurement and
 14 use of every natural resource are accounted for, without revealing confidential information. Risk
 15 assessment methods are fairly qualitative and high-level. Risk assessment exposure equations
 16 require simple summary input parameters. For example, the dietary portion of most risk
 17 assessments is quite general (fish, meat, above-ground and below-ground vegetation, or
 18 root-fruit-leafy plants—sometimes with a little more detail), and typically uses generic
 19 soil-to-plant transfer factors that are not species specific.

20 The report discusses a wide range of factors, directly tied to the traditional Native Americans of
 21 the CTUIR, for a risk assessment that is designed and scaled appropriately (Harris and
 22 Harper, 2004).

23 The above reports provided by the CTUIR and Yakama Nation contain information and
 24 guidance to be used in the development of a dose assessment model that takes the cultural
 25 lifestyle of Native Americans into consideration. The staff did not use the reports to develop a
 26 new dose assessment model specific to the Native American community for this SEIS. The
 27 staff used the radiological assessment data and conclusions from the radiological environmental
 28 monitoring programs conducted by Energy Northwest, DOE, and the State of Washington.
 29 These data include monitoring of local vegetation, milk, fish, and game animals that could
 30 potentially impact all members of the public in the vicinity of CGS.

31 **4.9.7.4 Subsistence Consumption of Fish and Wildlife**

32 The special pathway receptors analysis is important to the environmental justice analysis
 33 because consumption patterns may reflect the traditional or cultural practices of minority and
 34 low-income populations in the area, such as migrant workers or Native Americans.

35 Section 4-4 of EO 12898 (1994) directs Federal agencies, whenever practical and appropriate,
 36 to collect and analyze information on the consumption patterns of populations that rely
 37 principally on fish and wildlife for subsistence and to communicate the risks of these
 38 consumption patterns to the public. In this SEIS, NRC considered if there were any means for
 39 minority or low-income populations to be disproportionately affected by examining impacts to
 40 Native Americans, migrant workers, and other traditional lifestyle special pathway receptors.
 41 Special pathways that took into account the levels of contaminants in native vegetation, crops,
 42 soils and sediments, surface water, fish, and game animals on or near CGS were considered.

43 The following is a summary discussion of the NRC's evaluation (from Section 4.8.2) of the
 44 REMP's that assess the potential impacts for subsistence consumption of fish and wildlife near
 45 the CGS site.

Environmental Impacts of Operation

1 Columbia Generating Station. Energy Northwest has an ongoing comprehensive REMP at CGS
2 to assess the impact of site operations on the environment. To assess the impact of the plant
3 on the environment, samples of environmental media are collected and analyzed for
4 radioactivity. A plant effect would be noted if the radioactive material detected in a sample was
5 significantly larger than the background level.

6 Samples of environmental media are collected from the aquatic and terrestrial pathways near
7 CGS. The aquatic pathways include fish, Columbia River surface water, sediment, fish, and
8 groundwater. The terrestrial pathways include airborne particulates, milk, local garden produce,
9 and direct radiation. During 2009, analyses performed on samples of environmental media
10 showed no significant or measurable radiological impact above background levels from CGS
11 site operations (EN, 2010a).

12 Washington State Department of Health. The WDOH is responsible for protecting human health
13 and the environment from the effects of nuclear radiation. The Office of Radiation Protection,
14 Environmental Radiation Monitoring and Assessment Section carries out a REMP. The purpose
15 of the program is to collect samples from the environment, analyze them for trace amounts of
16 radioactive contaminants, and use the results to ultimately determine if the public and the
17 environment are safe from hazards associated with exposure to radioactivity. The surveillance
18 emphasizes major nuclear facilities with known or potential environmental radioactive
19 contamination associated with each facility's operation, decommissioning, or cleanup. Most of
20 the assessment effort relates to radiological surveillance in southeast Washington State at the
21 DOE's Hanford Site and at other nearby nuclear facilities including Energy Northwest's CGS.

22 Each year, WDOH's Radiation Control Unit typically collects samples of air, Columbia river
23 water, well water, milk, game animals and birds (i.e., deer, rabbit, and pheasant), fish, food
24 crops (i.e., grapes, leafy vegetables, and potatoes), soil, and sediment near CGS and Hanford.
25 In addition to the environmental samples, ambient radiation levels are measured using TLDs.

26 For 2008, most environmental samples analyzed by WDOH have radioactivity concentrations
27 that are either below detection limits or consistent with background. A few samples have
28 concentrations elevated above background; however, in most cases the concentrations are
29 consistent with historical trends. For example, C-14, tritium, iodine-129 (I-129), Sr-90, Tc-99,
30 and isotopes of uranium were detected above background levels in some Hanford Site and
31 Hanford boundary water samples. A variety of radionuclides—including Cs-137, Eu-152,
32 Pu-239/240, Sr-90, and isotopes of uranium—were found above background levels in some
33 Columbia River sediment samples. Most of the elevated concentrations are consistent with
34 historical trends.

35 In summary, the 2008 report states that while Hanford operations have resulted in radionuclides
36 entering the environment, the data from the WDOH Oversight Program show that public
37 exposure to radioactivity from Hanford is far below regulatory limits (WDOH, 2011).

38 U.S. Department of Energy. DOE conducts a REMP at the Hanford Site that includes
39 monitoring of the onsite and offsite environment. During 2008, potential radiological doses to
40 the public and biota from Hanford Site operations were evaluated to determine compliance with
41 pertinent regulations and limits. Doses were assessed in terms of the following:

- 42 • total dose (multiple pathways) to the hypothetical, maximally exposed individual at an
43 offsite location

- 1 • average dose to the collective population living within 50 mi of Hanford Site operating
- 2 areas
- 3 • dose for air pathways using EPA methods
- 4 • dose to workers on the site consuming drinking water
- 5 • doses from non-DOE industrial sources on and near the Hanford Site
- 6 • absorbed dose received by animals exposed to contaminants released to the Columbia
- 7 River and in onsite surface water bodies

8 The DOE's 2008 Hanford ER states that DOE also maintains an awareness of the other sources
 9 of radiation on the Hanford Site (i.e., AREVA NP, Perma-Fix Northwest, and CGS, etc.),
 10 which—if combined with the DOE sources—might have the potential to cause an annual dose
 11 exceeding 10 mrem (0.10 mSv) to any member of the public. With information gathered from
 12 the companies via personal communication and annual reports, the DOE estimated that the
 13 total 2008 annual dose to a member of the public from the combined activities was less than 3.0
 14 E-03 mrem (3.0 E-05 mSv). Therefore, the combined annual dose from non-DOE and DOE
 15 sources on and near the Hanford Site to a member of the public for 2008 was well below any
 16 EPA and DOE regulatory dose limits. Additionally, the levels of radioactivity in the offsite
 17 environment had no measurable impact to the offsite environment from the Hanford Site
 18 (DOE, 2010d).

19 Conclusion. Based on the radiological environmental monitoring data from CGS, Washington
 20 State, and the DOE, the NRC finds that no disproportionately high and adverse human health
 21 impacts would be expected in special pathway receptor populations in the region as a result of
 22 subsistence consumption of water, local food, fish, and wildlife.

23 **4.10 Evaluation of New and Potentially Significant Information**

24 New and significant information is: (1) information that identifies a significant environmental
 25 issue not covered in the GEIS and codified in Table B-1 of 10 CFR Part 51, Subpart A,
 26 Appendix B, or (2) information that was not considered in the analyses summarized in the GEIS
 27 and that leads to an impact finding that is different from the finding presented in the GEIS and
 28 codified in 10 CFR Part 51.

29 The new and significant assessment that Energy Northwest conducted during preparation of this
 30 license renewal application included: (1) review of documents related to environmental issues
 31 at CGS and the site environs, (2) review of current site activities and interview of site personnel,
 32 (3) review of internal procedures for reporting to the NRC events that could have environmental
 33 impacts, (4) credit for the oversight provided by inspections of plant facilities by state and
 34 federal regulatory agencies, (5) participation in review of other licensees' environmental reports,
 35 audits, and industry initiatives, and (6) review of SEISs that the NRC has prepared for other
 36 license renewal applications.

37 The NRC also has a process for identifying new and significant information. That process is
 38 described in NUREG-1555, Supplement 1, *Standard Review Plans for Environmental Reviews*
 39 *for Nuclear Power Plants, Supplement 1: Operating License Renewal* (NRC, 1999b). The
 40 search for new information includes: (1) review of an applicant's ER and the process for
 41 discovering and evaluating the significance of new information; (2) review of records of public
 42 comments; (3) review of environmental quality standards and regulations; (4) coordination with
 43 Federal, State, and local environmental protection and resource agencies, and (5) review of the

Environmental Impacts of Operation

1 technical literature. New information discovered by the staff is evaluated for significance using
2 the criteria set forth in the GEIS. For Category 1 issues where new and significant information
3 is identified, reconsideration of the conclusions for those issues is limited in scope to the
4 assessment of the relevant new and significant information; the scope of the assessment does
5 not include other facets of an issue that are not affected by the new information.

6 Energy Northwest reported in its ER that it is aware of one potentially new and significant issue
7 related to its license renewal application—groundwater contamination. The CGS site is unique
8 among commercial nuclear power reactor sites because the groundwater under the site is
9 contaminated due to nuclear activities largely unrelated to the operation of its nuclear power
10 plant. CGS occupies a small portion of the much larger DOE Hanford Site. The Hanford Site
11 was used for the production of nuclear materials, waste storage, and waste disposal. As a
12 result of historical DOE Hanford Site operations, the groundwater is known to be contaminated
13 with residual radioactive and hazardous materials released into the ground from past nuclear
14 operations that occurred before the construction and operation of CGS. The DOE is currently
15 performing a clean-up of the onsite groundwater and the removal or stabilization of residual
16 contamination. Information on the scope and type of remediation work being done on the
17 Hanford Site is presented in Appendix G of this SEIS.

18 CGS discharges non-radioactive liquid system effluents from its circulating water blowdown,
19 equipment and floor drains, storm water run-off from plant roofs, treated raw water, and sanitary
20 wastes. Discharges to the Columbia River, and most discharges to the soil, are controlled
21 through operational and administrative procedures to ensure compliance with the limits of its
22 NPDES permit. Water is collected by the storm water drainage system and is piped to an
23 unlined evaporation and percolation pond. While this pond is designed to receive liquids from
24 non-radioactive sources, CGS is aware that the pond contains tritium that is washed off of plant
25 roofs and walls. The source of the tritium is believed to be from tritium contained in CGS routine
26 radioactive gaseous effluents which “rain out” of the atmosphere during the cooler, rainier
27 periods of the year. However, it is not part of CGS’s radioactive liquid effluent release pathway
28 that is designed to discharge into the Columbia River. As previously noted in Section 4.8.2 of
29 this SEIS, there have not been any radioactive liquid effluent discharges into the Columbia River
30 in 10 years.

31 Energy Northwest performs groundwater monitoring near CGS to characterize the effects of
32 their liquid discharges and to detect unanticipated leakage from plant systems. Energy
33 Northwest reports that the water monitored at the nearest down-gradient water supply wells
34 from CGS located on the IDC have not been impacted with radioactive effluents from the plant.
35 Energy Northwest plans to continue monitoring the wells for contamination. Additionally, DOE
36 plans to continue monitoring the quality of the area-wide aquifer. Energy Northwest does not
37 believe this issue is a new and significant issue in the context of NRC requirements contained in
38 10 CFR 51.53(c)(3)(iv).

39 The staff’s evaluation of the radiological environmental monitoring data in Section 4.8.2 of this
40 chapter shows that CGS’s REMP monitors the onsite and offsite environment for radioactivity.
41 The REMP data supports Energy Northwest’s position that the groundwater contamination issue
42 has not had a significant impact on members of the public and environment. In addition, the
43 NRC periodically inspects CGS’s radioactive effluent, radiological environmental monitoring,
44 and groundwater protection programs for compliance with regulatory standards. The staff
45 reviewed the most recent NRC inspection report covering the scope of these programs
46 (NRC, 2009). The inspection report stated that there were no findings of significance. The staff
47 will continue to periodically inspect Energy Northwest’s compliance with NRC requirements in

1 these areas. Therefore, the staff agrees with Energy Northwest's position that the groundwater
2 contamination issue is not a new and significant issue.

3 The staff concludes that there is no new and significant information on environmental issues
4 listed in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, related to the operation of CGS
5 during the period of license renewal.

6 **4.11 Cumulative Impacts**

7 The staff considered potential cumulative impacts in the environmental analysis of continued
8 operation of CGS nuclear plant during the 20-year license renewal period. Cumulative impacts
9 may result when the environmental effects associated with the proposed action are overlaid or
10 added to temporary or permanent effects associated with other past, present, and reasonably
11 foreseeable actions. Cumulative impacts can result from individually minor, but collectively
12 significant, actions taking place over a period of time. It is possible that an impact that may be
13 SMALL by itself could result in a MODERATE or LARGE cumulative impact when considered in
14 combination with the impacts of other actions on the affected resource. Likewise, if a resource
15 is regionally declining or imperiled, even a SMALL individual impact could be important if it
16 contributes to or accelerates the overall resource decline.

17 For the purposes of this cumulative analysis, past actions are those before the receipt of the
18 license renewal application. Present actions are those related to the resources at the time of
19 current operation of the power plant, and future actions are those that are reasonably
20 foreseeable through the end of plant operation including the period of extended operation.
21 Therefore, the analysis considers potential impacts through the end of the current license terms
22 as well as the 20-year renewal license term. The geographic area over which past, present,
23 and reasonably foreseeable actions would occur is dependent on the type of action considered
24 and is described below for each resource area.

25 To evaluate cumulative impacts, the incremental impacts of the proposed action, as described
26 in Sections 4.1–4.9, are combined with other past, present, and reasonably foreseeable future
27 actions regardless of what agency (Federal or non-Federal) or person undertakes such actions.
28 The staff used the information provided in the ER; responses to requests for additional
29 information; information from other Federal, State, and local agencies; scoping comments; and
30 information gathered during the visits to the CGS site to identify other past, present, and
31 reasonably foreseeable actions. To be considered in the cumulative analysis, the staff
32 determined if the project would occur within the noted geographic areas of interest and within
33 the period of extended operation, was reasonably foreseeable, and if there would be potential
34 overlapping effect with the proposed project. For past actions, consideration within the
35 cumulative impacts assessment is resource and project-specific. In general, the effects of past
36 actions are included in the description of the affected environment in Chapter 2, which serves as
37 the baseline for the cumulative impacts analysis. However, past actions that continue to have
38 an overlapping effect on a resource potentially affected by the proposed action are considered
39 in the cumulative analysis.

40 Other actions and projects that were identified during this review and considered in the staff's
41 independent analysis of the potential cumulative effects are described in Appendix G.
42 Examples of other actions that were considered in this analysis include the following:

Environmental Impacts of Operation

- 1 • proposed reduction of the Hanford Site footprint, including consolidation and
2 acceleration of clean up and restoration activities, such as clean up of the 618-11 and
3 618-10 Burial Grounds
- 4 • waste disposal and tank waste stabilization and closure at Hanford, including operation
5 of the Waste Treatment Plant
- 6 • decommissioning, deactivation, and closure of various facilities at Hanford, including the
7 Fast Fuel Test Facility (FFTF)
- 8 • transportation of radioactive and chemical waste throughout Hanford
- 9 • proposed conversion of a portion of the Hanford Site to an energy park
- 10 • proposed construction of new energy projects, such as the Desert Claim Wind Project
11 and the McNary-John Day Transmission Line
- 12 • operation of dams along the Columbia River, such as Priest Rapids and Wanapum
13 Dams
- 14 • Columbia River and Yakima River water management activities
- 15 • future urbanization

16 **4.11.1 Cumulative Impacts on Water Resources**

17 The staff conducted an assessment of other projects and actions for consideration in
18 determining their cumulative affects on water resources (Appendix G). This section addresses
19 the direct and indirect effects of license renewal on water resources when added to the
20 aggregate effects of other past, present, and reasonably foreseeable future actions. The
21 geographic area considered in the cumulative water resources analysis covers the unconfined
22 aquifer beneath the Hanford Site and the Hanford Reach portion of the Columbia River from
23 Priest Rapids Dam to Lake Wallula (the McNary Pool) including portions of Benton and Franklin
24 Counties. The Columbia River and unconfined aquifer beneath CGS are hydraulically
25 connected. This review focused on those projects and activities that would use groundwater or
26 could affect the unconfined aquifer beneath the CGS site and/or would withdraw from or
27 discharge water to the Columbia River within this geographic area.

28 **4.11.1.1 Groundwater Resources**

29 Groundwater use by the CGS and in the surrounding area is very small (approximately 1 gpm
30 annual average; Section 4.3), thus groundwater issues are related to quality, not quantity.
31 There are few users of the unconfined aquifer and no new project with a substantial demand for
32 groundwater is anticipated (EN, 2010). Reviews of other existing or planned projects in the
33 surrounding area show that some minor use of groundwater will continue. For example, two
34 water-supply wells are being installed to supply water for dust suppression during the
35 decommissioning of the 618-10 Burial Ground. These wells, located approximately 5 km
36 southeast of the CGS site, are planned to produce a combined pumping rate of 250 gpm for
37 5 days per week, 10 hours per day, for a period of 3–5 years (Nichols, 2010). Other
38 decommissioning activities associated with the 618-11 Burial Ground and FFTF are not
39 expected to use groundwater resources over and above existing uses. Groundwater could be
40 used if future energy projects are developed at the IDC or other areas within Hanford.

41 As discussed in Section 2.1, groundwater quality at the CGS site is predominately influenced by
42 historical and ongoing activities on the DOE Hanford Site (see Section 2.1.7). Wastewater

1 disposal from Hanford Site activities led to widespread contamination of the unconfined aquifer.
2 Elevated concentrations of tritium, Tc-99, I-129, and nitrate underlie the CGS site, coming from
3 both large dilute plumes emanating from the Hanford Site's 200-East Area and from a small
4 concentrated plume from the 618-11 Burial Ground (DOE, 2010a).

5 High concentrations of tritium in groundwater from DOE activities were detected in early 1999 at
6 well 699-13-3A, located next to the eastern fence line of the 618-11 Burial Ground, northwest of
7 the CGS site (DOE, 2010a). The contamination was unexpected, and concentrations greatly
8 exceeded the 20,000 pCi/L DWS, with peak concentrations reaching 8 million pCi/L
9 (DOE, 2010a). Subsequent investigations revealed a narrow plume that extends eastward
10 beneath the CGS site with concentrations that are much higher than the surrounding site-wide
11 plume from the 200-East Area (DOE, 2010a). Concentrations near the burial ground have
12 declined, while concentrations at wells farther away from the burial ground reflect migration of
13 the plume (i.e., constant or gradually increasing concentrations trends) (DOE, 2010a).
14 Groundwater monitoring at the CGS site in 2008 found tritium concentrations ranged from less
15 than detectable to 17,400 pCi/L (EN, 2009a).

16 Tc-99 has also been detected near Burial Ground 618-11 at several hundred pCi/L—still well
17 below the 900 pCi/L DWS (DOE, 2010a). At least some of the Tc-99 contamination observed
18 near this burial ground is associated with the site-wide plume emanating from the 200-East
19 Area. However, historical concentration trends for Tc-99 and tritium at well 699-13-3A are
20 similar, showing that small amounts of Tc-99 may have been associated with the release that
21 created the local tritium plume in 1999 (DOE, 2010a). Nitrate concentrations near the 618-11
22 Burial Ground and the CGS site have remained elevated above the DWS for many years, with
23 concentrations as high as 113 mg/L at well 699-13-3A, adjacent to the burial ground
24 (DOE, 2010a). With the cessation of wastewater discharges to ground in the central Hanford
25 Site (e.g., 200-East Area), as well as ongoing and future site remediation activities at the 618-11
26 Burial Ground, the source of these contaminant plumes is being cut off, and the remnant plumes
27 are expected to slowly dissipate.

28 Discharges to ground at the CGS site also have the potential to alter the quality of the
29 groundwater in the unconfined aquifer. Discharges of stormwater from plant roofs contain
30 tritium, but the concentrations are less than those currently in the groundwater and result in an
31 apparent dilution effect (Section 2.1).

32 Because the groundwater beneath and adjacent to the CGS site has been noticeably altered by
33 DOE activities, the cumulative impacts on groundwater resources could be characterized as
34 being SMALL to LARGE, depending on location. However, the incremental contribution from
35 CGS during the extended operations would be SMALL since CGS withdraws a minor amount of
36 groundwater and would not noticeably alter groundwater quality.

37 **4.11.1.2 Surface Water Resources**

38 Withdrawal from the Columbia River is a general concern in the region. To address this
39 concern, resource agencies try to balance the needs of communities, industries, agriculture,
40 hydropower, and aquatic life by regulating the development of water supplies to benefit both
41 in-stream and out-of-stream water uses (WDOE, 2010a). Washington State law requires any
42 users of surface water (lakes, ponds, rivers, streams, or springs) that began after the State
43 water code was enacted in 1917 to obtain a water-right permit or certificate (WDOE, 2010b).

44 As discussed in Sections 2.1 and 3.2, CGS withdraws about 38 cfs (17,000 gpm) to replenish
45 losses in the evaporative cooling system and to supply water needed for plant processes and

Environmental Impacts of Operation

- 1 drinking (EN, 2010). This is about 0.03 percent of the averaged mean annual discharge of the
2 Columbia River below Priest Rapids Dam for water years 1960–2009 of 117,823 cfs, or about
3 0.05 percent of the minimum mean annual discharge of 80,650 cfs (USGS, 2010).
- 4 A search of other surface-water withdrawals from the Columbia River in the region of interest
5 shows that the largest user of Columbia River water is the City of Richland, which has active
6 water rights for an estimated maximum combined withdrawal rate of 194 cfs (87,073 gpm).
7 Irrigation is the next greatest use of Columbia River water in this region, with an estimated 17
8 users accounting for a total active water-rights withdrawal rate of approximately 31.5 cfs
9 (14,138 gpm). DOE has a Federally reserved water-withdrawal right for withdrawals from the
10 Columbia River to support Hanford Site operations (DOE, 1999). In fiscal year 2006, Hanford
11 Site operations withdrew about 817 million L (215.7 million gallons) of water from the Columbia
12 River (DOE, 2009). This is equivalent to an average withdrawal rate of about 0.9 cfs (410 gpm).
- 13 The total combined active maximum surface-water-right withdrawal rate (including the CGS) is
14 estimated to be 270 cfs (121,184 gpm); equivalent to about 0.3 percent of the minimum
15 mean-annual discharge of the Columbia River.
- 16 There are currently no other substantial withdrawals of Columbia River water within about 6 mi
17 (10 km) of the CGS site. The most significant reasonably foreseeable current and future actions
18 potentially affecting surface-water use include the potential development of an energy project at
19 the IDC site and future urbanization. Both of these actions would likely take advantage of the
20 WNP-1/4 in-river intake and pumphouse, located about 650 ft upstream of the CGS
21 water-withdrawal facilities. Presumably, if a project materialized for the IDC that required
22 substantial water, the sponsor would seek a surface-water right (EN, 2010). The cities of
23 Richland, Pasco, and Kennewick (Tri-Cities) are expected to withdraw an additional 178 cfs per
24 year for municipal, industrial, and commercial uses (Barwin, 2002).
- 25 Potential cumulative effects of climate change on the Columbia River could result from a variety
26 of changes in snowpack, stream flows, and sea level over the coming decades in response to
27 continued and more rapid increases in temperature (Karl, et al., 2009). Declines in the
28 snowpack and earlier snowmelt are projected to cause major changes in the timing of runoff and
29 stream flow, with runoff shifting 20–40 days earlier within this century (Karl, et al., 2009). These
30 changes are projected to cause a reduction in the amount of water available during the warm
31 season leading to increased conflicts between all of the water uses, including hydroelectric
32 power, irrigated agriculture, protecting fish species, reservoir and river recreation, and urban
33 uses (Karl, et al., 2009).
- 34 The surface-water quality of the Columbia River in the region of interest is affected by irrigation
35 returns, stormwater, and other effluent discharges—as well as the inflow of groundwater. Small
36 amounts of radioactive materials have been detected downriver from the Hanford Site, but the
37 amounts were far below Federal and State limits. Likewise, other water-quality parameters
38 measured near Richland (USGS Station No. 12473520 at RM 340) found no indication of any
39 deterioration of Columbia River water quality along the Hanford Reach (Poston, et al., 2009).
40 The 2008 assessment of water quality by the State of Washington also found no quality
41 impairments based on water samples in the river reach below Vernita Bridge. However, it did
42 find organic elements in fish tissue and pH and temperature in irrigation return flows as a basis
43 for water-quality impairment at discrete locations (EN, 2010), (WDOE, 2008).
- 44 The staff did not find any foreseeable projects that would impair the water quality of the
45 Columbia River in the region of interest.

1 Withdrawals at the CGS site are a very small fraction (0.03–0.05 percent) of the river flow, and
2 cooling-tower blowdown has not significantly affected surface-water quality. All current and
3 foreseeable activities are expected to have a combined withdrawal equivalent to about 0.3
4 percent of the minimum mean-annual discharge of the Columbia River and would not result in
5 significant impacts on surface-water quality. Therefore, the staff concludes that the cumulative
6 surface water use and quality impacts from the proposed license renewal and other past,
7 present, and reasonably foreseeable projects would be SMALL.

8 **4.11.2 Cumulative Impacts on Aquatic Resources**

9 This section addresses the direct and indirect effects of license renewal on aquatic resources
10 when added to the aggregate effects of other past, present, and reasonably foreseeable future
11 actions. As described in Section 4.5, the incremental impacts on aquatic biota from the
12 proposed license renewal would be SMALL. The geographic area considered in the cumulative
13 aquatic resources analysis includes the migratory pathway for the important anadromous
14 aquatic fish species and EFH in the Columbia River Basin. Fish passage for anadromous
15 species starts in the Pacific Ocean and extends to Chief Joseph Dam (RM 545) on the
16 Columbia River, including the major tributaries upstream of Rock Island Dam that support the
17 upper Columbia River spring-run Chinook salmon (*Oncorhynchus tshawytscha*) (Dauble, 2009).
18 This review focused on the projects and activities that would affect the aquatic biota of the
19 Columbia River within this geographic area.

20 The benchmark for assessing cumulative impacts on aquatic resources takes into account the
21 pre-operational environment, as recommended by the EPA (1999) for its review of NEPA
22 documents as follows:

23 Designating existing environmental conditions as a benchmark may focus the
24 environmental impact assessment too narrowly, overlooking cumulative impacts
25 of past and present actions or limiting assessment to the proposed action and
26 future actions. For example, if the current environmental condition were to serve
27 as the condition for assessing the impacts of relicensing a dam, the analysis
28 would only identify the marginal environmental changes between the continued
29 operation of the dam and the existing degraded state of the environment. In this
30 hypothetical case, the affected environment has been seriously degraded for
31 more than 50 years with accompanying declines in flows, reductions in fish
32 stocks, habitat loss, and disruption of hydrologic functions. If the assessment
33 took into account the full extent of continued impacts, the significance of the
34 continued operation would more accurately express the state of the environment
35 and thereby better predict the consequences of relicensing the dam.

36 Sections 2.2.5 and 2.2.7 present an overview of the condition of the Columbia River aquatic
37 ecosystem and the history and factors that led to its current condition. Commercial fisheries in
38 the lower Columbia River in the 1800s reduced the populations of salmon and steelhead to such
39 an extent that efforts to augment the population with fish hatcheries began at the end of the
40 century and continues to the present (Dauble, 2009), (Dauble and Watson, 1997). Also during
41 the 1800s, the ecosystem was further altered by the introduction of non-indigenous commercial
42 and recreational fish species such as American shad (*Alosa sapidissima*), catfish (*Ictaluridae*),
43 and bass (*Centrarchidae*) species (Dauble, 2009).

44 The irreversible changes to aquatic life in the Columbia River started with the completion of the
45 first hydropower project, Rock Island Dam, in 1933. There are specific alterations documented
46 with the completion of other dams in the Columbia River Basin. Bonneville Dam is 146 mi

Environmental Impacts of Operation

1 (235 km) from the Pacific Ocean, and the dam—on which construction began in 1933—became
2 a migratory barrier for many native species such as white sturgeon (*Acipenser transmontanus*)
3 (Dauble, 2009). Construction on The Dalles Dam began in 1957 and inundated Celilo Falls, the
4 natural barrier to the migration of American shad upstream into the mainstem of the Columbia
5 River (Dauble, 2009). Hydropower has been a significant contributor to the decline of native
6 anadromous species such as the upper Columbia River spring-run Chinook salmon (Dauble,
7 2009), (Dauble and Watson, 1997), (NMFS, 2005).

8 The Biological Opinion prepared by the NMFS in 2008 (and supplemented in 2010) for the
9 owners and operators of the Federal Columbia River Power System (FCRPS) describes the
10 historical, current, and forecasted changes to aquatic life in the Columbia River from
11 hydropower operations (NMFS, 2010). Sections 2.2.7 and 4.7 of this SEIS supply additional
12 information on the Biological Opinion and specifically on the listed salmonid species. The
13 Biological Opinion also describes actions that FCRPS must take to improve fish survival at
14 Federal dams and throughout the life cycle for the 13 fish species affected by the FCRPS. To
15 complete the actions described in the Biological Opinion, FCRPS programs include extensive
16 research, monitoring, and evaluation of the fish species and their habitats. The programs noted
17 in the Biological Opinion incorporate concepts of adaptive management to demonstrate species
18 recovery (NMFS, 2010).

19 The operation of Priest Rapids Dam noticeably changes the water levels and affects the aquatic
20 resources associated with the CGS (FERC, 2006). Daily water fluctuations limit aquatic habitat
21 (e.g., periphyton growth and shoreline usage by crayfish), encourage invasive species
22 colonization (e.g., purple loosestrife (*Lythrum salicaria*)), and promote predation (e.g., birds
23 access to fish stranded in shallows). The effects of Priest Rapids Dam on the operation of CGS
24 intake and discharge systems are minimal because the intake and discharge structures are
25 deep in the river channel.

26 Construction and operation of nine nuclear reactors on the Hanford Site from 1943–1987
27 influenced the aquatic environment of the Hanford Reach. Cofferdams restricted water flow
28 during the placement of shoreline intake structures and discharge lines within the river. The
29 operation of the Hanford Site led to the release of more than 60 radionuclides, many process
30 chemicals, and waste heat into the Hanford Reach (Becker, 1990), (Duncan, et al., 2007). The
31 overall impact to the aquatic resources from the operation of the Hanford Site has yet to be
32 determined and drives ongoing cleanup activities as well as a natural resource damage
33 assessment (Poston, et al., 2009).

34 The seasonal and daily water fluctuations associated with the operation of Priest Rapids Dam
35 also may affect exposure of aquatic life to environmental contaminants from the Hanford Site.
36 Groundwater transports contaminants from the Hanford Site to the Columbia River. High river
37 stages can retard groundwater transport and concentrate the contaminants in the river bank at
38 low river stage. The benthic organisms in the river are the first receptors of contaminated
39 groundwater. Groundwater plumes from the Hanford Site that are close to, or flowing into, the
40 river include chemicals and radionuclides such as chromium, nitrate, Sr-90, tritium, and
41 uranium. Concentrations of the chemical contaminants in the river are below ambient-water
42 quality criteria for the protection of aquatic species. Although small amounts of radioactive
43 materials were detected in the Columbia River water and sediment samples downstream from
44 the Hanford Site, the amounts were far below Federal and State limits, as discussed previously
45 in Section 4.8.2. Other sources that may contribute to the cumulative effect of chemical
46 contaminant exposure to aquatic resources in the Hanford Reach include high concentrations of
47 nitrate in the groundwater across from the Hanford Site, agricultural returns flowing into the

1 river, and upstream mining activities. DOE's monitoring and remediation programs are
2 addressing the risk to aquatic species in the Hanford Reach from the influence of contaminated
3 groundwater (see Appendix G Table G-1) (Duncan, et al., 2007), (DOE, 2009), (Miley, et al.,
4 2007), (Poston, et al., 2009).

5 As discussed in Section 4.11.1.2, one regional concern is the withdrawal of Columbia River
6 water. Permitting by resource agencies limits the total consumptive loss and balances the need
7 of multiple water users (EN, 2010). While the relatively few water withdrawal systems within 20
8 mi (32 km) are primarily for municipal use, the number of permitted withdrawals within the
9 geographic area of interest is considerable. Direct impacts on aquatic biota can occur from the
10 intake structures (e.g., entrainment and impingement), and oversight by resource agencies and
11 best available technologies that consider protection of aquatic life (e.g., screen systems and fish
12 diversions) may minimize the effects on aquatic life. Indirect impacts on aquatic biota from
13 consumptive water loss in the area of interest range from contributions to extreme seasonal
14 water level fluctuations to the loss of habitat or fish passage, water quality, and water
15 temperature.

16 Development within the geographic area of interest also contributes to cumulative effects on
17 aquatic life due to decreases in water quality and available habitat. The increase in urbanization
18 within the Columbia River Basin may lead to changes in water quality from point and non-point
19 contaminant discharges. Water temperatures in the tributaries of the Columbia River can
20 increase from changes to shorelines and removal of shade structures (USFWS, 2007). The
21 recovery programs for Federally-listed species (e.g., upper Columbia River steelhead
22 (*Oncorhynchus mykiss*)) may affect some of these changes by enhancing fish habitat
23 (NMFS, 2010). Resource agencies can address and minimize impacts through monitoring and
24 permitting programs, such as Washington State Department of Transportation's Fish Passage
25 Program, to minimize impacts from highway crossings (WSDOT, 2010).

26 Pressures from recreational and commercial fishing within the Columbia River Basin contribute
27 to the cumulative effects on the aquatic resources near CGS. Historically, the fitness of some
28 species has declined (e.g., upper Columbia River spring-run Chinook salmon) because of the
29 mismanagement of some hatchery programs. Release of fish that are not genetically diverse
30 and have behaviors that may result in increased predation are some of the issues of past
31 hatchery practices that are currently being addressed in new programs (NMFS, 2010).
32 Enforcement of fishing regulations for white sturgeon limited the take of sexually mature fish,
33 resulting in an increased population in the Columbia River Basin (Dauble, 2009). USFWS
34 (2007) identified the development of recreational facilities (e.g., boat launches and shoreline
35 camping sites) as contributing to effects on critical habitat for and the recovery of bull trout as
36 part of the Biological Opinion for relicensing Priest Rapids Dam. For example, accelerated
37 erosion and impacts on riparian function from the construction and operation of recreational
38 facilities may lead to choking of spawning habitat from siltation and increased water
39 temperatures affecting trout development (USFWS, 2007). Recreational fishing activities may
40 encourage the introduction of invasive species (e.g., zebra mussels (*Dreissena polymorpha*))
41 into the Columbia River Basin (WDFW, 2010) that would not only compete with native aquatic
42 species for food but have the potential to biofoul water-intake systems and affect the operation
43 of facilities like CGS (NRC, 1996).

44 Potential cumulative effects of climate change on the aquatic species of the Columbia River
45 could result from changes in water flow through the river. Climate changes include warmer
46 temperatures with more winter rainfall, less snowpack, and lower summer streamflows. These
47 conditions change the balance of all aquatic resources in the Columbia Basin. For the

1 salmonids, redds could be damaged by higher winter streamflows. Less snowpack and lower
2 summer streamflows could prevent salmonid migration into or out of smaller tributaries, and
3 warmer waters could limit the distribution of some species. Conditions in the ocean could also
4 be less favorable for adult salmonids from the Columbia River Basin. Climate change would
5 lead to unfavorable conditions for Federally and State-listed species as well as other resident
6 aquatic species near CGS (Karl, et al., 2009).

7 The number of alterations of aquatic habitat and fish passage from past activities, and the
8 number of water withdrawals and water-quality inputs in the Columbia River, has had a
9 significant effect on aquatic resources in the geographic area of interest. The Columbia River
10 aquatic ecosystem has been noticeably altered and continues to require considerable resources
11 to curtail the destabilizing factors that could jeopardize the existence of aquatic species or
12 adversely affect their designated critical habitat in the reasonably foreseeable future. Although
13 the incremental impacts from CGS are minimal because of the use of closed-cycle cooling
14 systems, the cumulative stress from all the alterations to the aquatic habitat, spread across the
15 geographic area of interest, have destabilized the aquatic resources. Therefore, the staff
16 concludes that the cumulative impacts from the proposed license renewal and other past,
17 present, and reasonably foreseeable projects would be LARGE. The incremental impacts from
18 the proposed license renewal would be SMALL since the proposed project would have minimal
19 impacts on aquatic resources.

20 **4.11.3 Cumulative Impacts on Terrestrial Resources**

21 This section addresses the direct and indirect effects of license renewal on terrestrial
22 resources—to include wildlife populations, riparian zones, invasive species, protected species,
23 and land use—when added to the aggregate effects of other past, present, and reasonably
24 foreseeable future actions. The geographic area considered in this analysis includes the CGS
25 site, the adjacent habitat along the bank of the Columbia River, and the in-scope transmission
26 line ROWs noted in Section 2.1.5. This area encompasses the primary vegetation and wildlife
27 communities that are affected by operations of the plant.

28 Before the construction of CGS and its supporting facilities, terrestrial communities in the
29 surrounding area represented typical habitat found in the Columbia Basin shrub-steppe
30 ecosystem, as described previously in Section 2.2.6. Construction of CGS facilities caused land
31 disturbances, including the destruction of sagebrush and non-sagebrush habitat as well as the
32 temporary displacement of wildlife populations, resulting in the spread of invasive species such
33 as cheatgrass (*Bromus tectorum*) and Russian thistle (*Salsoa tragus*). Because of the Hanford
34 Site's protected status since the establishment of the Manhattan Project in 1943, the affected
35 area now serves as an important refuge for the shrub-steppe ecosystem (EN, 2010). This is
36 largely because much of the land in the Columbia Basin has been converted to agricultural land
37 over the years, while the Hanford and CGS property remains protected by State of Washington
38 resource agencies. This protected area includes the Hanford Reach National Monument, a
39 305 mi² (790 square kilometers (km²)) reserve on the Hanford Site established in 2000, a small
40 portion of which overlaps with the CGS property (EN, 2010). Hanford Reach is managed by the
41 USFWS (Kurz, 2010). Construction and operation of the Priest Rapids Dam (RM 397)—located
42 approximately 45 mi (72 km) upriver of CGS (RM 352)—and the McNary Lock and Dam
43 (RM 292)—located 60 mi (97 km) downriver of the CGS—in the 1950s likely raised water levels
44 along the Columbia River and may have had an effect on the vegetation along the riparian
45 corridor adjacent to the CGS (FERC, 2006). The Priest Rapids Dam was recently granted a
46 license extension of 44 years and is discussed in more detail in Section 4.11.2. Land located on

1 the east side of the Columbia River across from the affected area was previously shrub-steppe
2 habitat similar to that of the CGS site but has since been converted to agricultural use.

3 Construction of the 2,900 ft (880 m) transmission line ROW running north from the CGS, and
4 the 1.8 mi (2.9 km) backup transmission line ROW running southeast from CGS and maintained
5 by BPA for the CGS site, likely resulted in land disturbances similar to those caused by the
6 construction of CGS facilities, including an increased susceptibility to invasive species.
7 Because the shrub-steppe vegetation found under the in-scope transmission lines is
8 slow-growing, vegetation management is not required underneath the transmission lines.
9 Therefore, ROW maintenance is not likely to have present and future impacts on the terrestrial
10 habitat. No additional terrestrial habitat would be affected from CGS license renewal.

11 Previous and continued residential, commercial, agricultural, and industrial development of the
12 Richland, Pasco, and Kennewick (Tri-Cities) areas surrounding the CGS site are unlikely to
13 affect terrestrial habitat within the affected area. The CGS site is isolated from current and past
14 increases in both commercial and residential development because it is located on land within
15 the Hanford Site that is protected from the public and is located about 12 mi north of any
16 residential developments in Richland, which makes it unlikely that increased urbanization in the
17 Tri-Cities area would affect terrestrial habitat at CGS.

18 Agricultural land near the CGS site is used largely for irrigated and dryland farming as well as
19 for grazing. Most of the agricultural land is designated as cropland, with a smaller percentage
20 being used for pastureland. It is unlikely that the shrub-steppe terrestrial habitat at CGS or the
21 Hanford Site would be similarly converted for agricultural use in the future because the State of
22 Washington now considers shrub-steppe habitat a Priority 1 ecosystem for conservation due to
23 its scarcity, and the WDNR currently lists shrub-steppe conservation as one of its two most
24 significant projects (WDFW, 2005), (WDNR, 2009). A Priority 1 ecosystem is defined by the
25 State of Washington as an ecosystem with few known occurrences in the natural areas system,
26 the extent of which has been greatly reduced (WDNR, 2007). These ecosystems are
27 considered to be at the highest risk of being destroyed or degraded (WDNR, 2007).

28 Continued operation and management of the Hanford Site, including cleanup and restoration
29 activities, tank closures, decommissioning, deactivation, and closure of various facilities on the
30 Hanford Site, are likely to have some continued impacts on the surrounding terrestrial habitat.
31 One example of cleanup and restoration activities on the Hanford Site is DOE's Columbia River
32 Closure Project, which includes approximately 218 mi² (565 km²) of the Columbia River corridor
33 at Hanford. The primary goal of this cleanup project is to remove groundwater contaminating
34 materials, and includes the 618-11 Burial Ground adjacent to the CGS site (WCH, 2010).
35 Characterization and remediation of the 618-11 Burial Ground is scheduled to begin in 2011 and
36 to be completed by 2015 (DOE, 2010b), (EN, 2010).

37 DOE is currently evaluating plans for constructing a 15-mi pipeline spur from the regional gas
38 transmission line in Pasco to the Hanford Site (Cary, 2011). This pipeline would provide natural
39 gas to the waste treatment plant currently under construction at Hanford and other industrial
40 facilities on the Hanford Site. Natural gas would also be available via this pipeline for future
41 industrial facilities at the Hanford Site.

42 Any new construction or ground disturbing activities on the Hanford Site would have a potential
43 impact on terrestrial resources in the area. For example, the proposed Mid-Columbia Energy
44 Initiative Energy Park at Hanford would use a portion of the Hanford Site for renewable energy
45 production. Initial construction of such a facility would affect the surrounding terrestrial
46 resources, much like the impacts from the original CGS construction. Plant communities

Environmental Impacts of Operation

1 (including sagebrush and non-sagebrush habitat) would be affected by any new construction
2 carried out in previously undisturbed areas. Wildlife species such as mule deer, coyotes,
3 northern pocket gopher, sage sparrow, and western meadowlark could be temporarily displaced
4 from their current habitat by ground disturbing activities onsite, particularly if construction were
5 to take place during the breeding season for ground-nesting birds (DOE, 2009). Increased
6 noise levels due to construction and additional workers could also result in the temporary
7 displacement of some wildlife species in the immediate area (DOE, 2009). However, because
8 the Hanford Site is a protected resource area, it is a reasonable conclusion that best
9 management practices would be used during construction to protect the area's unique
10 shrub-steppe ecosystem. The continued operation of the adjacent Hanford Reach National
11 Monument and Saddle Mountain National Wildlife Refuge would ensure additional protection for
12 terrestrial resources in the area and refuge for temporarily displaced wildlife (USFWS, 2008).

13 The potential cumulative effects of climate change could result in a variety of changes to
14 terrestrial resources on and around the CGS site. Average temperatures in the northwest
15 region are projected to rise over the next century, as well as increased precipitation projected
16 for the winter and decreased precipitation projected for the summer (Karl, et al., 2009).
17 Inadequate water availability during the summer season as a result of reduced springtime
18 snowpack could affect terrestrial ecosystems in the northwest region to include wildlife
19 populations, species of concern, upland habitats, riparian zones, and invasive species.
20 Increased precipitation, insect outbreaks, and wildfires could change vegetation composition on
21 the CGS site. Long-term effects of climate change on terrestrial resources could include a shift
22 in vegetation composition, loss of bird diversity, a change in local mammal populations, and an
23 increase in invasive species and other pests (Karl, et al., 2009).

24 The staff examined the cumulative effects of initial construction of the site and transmission
25 lines, impacts to protected species, effects of existing and proposed neighboring facilities at the
26 Hanford Site, surrounding agricultural use, and land development in the Tri-Cities area. The
27 staff concludes that the minimal terrestrial impacts expected from continued CGS operations,
28 including the operation and maintenance of the in-scope transmission line corridors, would not
29 contribute to the overall decline in the condition of terrestrial resources. Based on both the
30 protected status of the terrestrial resources in the CGS area and the potential incremental
31 impacts from the ongoing activities on the adjacent Hanford Site, including its potential use as a
32 power generating facility, the staff concludes that the cumulative terrestrial resource impacts
33 from the proposed license renewal and other past, present, and reasonably foreseeable projects
34 would be MODERATE.

35 **4.11.4 Cumulative Impacts on Human Health**

36 This section addresses the direct and indirect effects of license renewal on human health when
37 added to the aggregate effects of other past, present, and reasonably foreseeable future
38 actions. For the purpose of this analysis, the geographic area considered is a 50-mi (80.4-km)
39 radius of CGS. Within the 50-mi (80-km) radius of the CGS site is the Hanford Site, and
40 immediately adjacent to the southern boundary of the Hanford Site, AREVA NP, Inc. operates a
41 commercial nuclear fuel fabrication facility and Perma-Fix Northwest, Inc. operates a low-level
42 and mixed low-level radioactive waste processing facility. Westinghouse Electric Company
43 operates the Richland Service Center, located in north Richland, which provides chemical
44 cleaning, decontamination, and other waste processing services to the nuclear industry.

45 The radiological dose limits for protection of the public and workers have been developed by the
46 NRC and EPA to address the cumulative impact of acute and long-term exposure to radiation

1 and radioactive material. These dose limits are codified in 10 CFR Part 20 and
2 40 CFR Part 190.

3 The REMP carried out by Energy Northwest near the CGS site measures radiation and
4 radioactive materials from all sources, such as hospitals, other licensed users of radioactive
5 material, and facilities described in Appendix G, Table G-1; therefore, the monitoring program
6 measures cumulative radiological impacts. Radioactive effluent and environmental monitoring
7 data from CGS's annual REMP reports for the 5-year period from 2005–2009 were reviewed as
8 part of the cumulative impacts assessment. In Section 4.8.2, the staff concluded that impacts of
9 radiation exposure to the public and workers (occupational) from operation of CGS, and the
10 storage of spent nuclear fuel, during the renewal term are SMALL. In addition, the staff
11 reviewed the environmental monitoring data for the Hanford Site measured by Washington
12 State and the DOE. The data show that there is no significant radiological impact to the public
13 and environment (see Section 4.8.2). The DOE's Hanford ERs stated that the potential
14 radiation doses from the Hanford Site to members of the public in the offsite environment were
15 lower than EPA and DOE standards.

16 Energy Northwest constructed an ISFSI on the CGS site in 2000 for the storage of its spent fuel.
17 The installation and monitoring of this facility is governed by NRC requirements in
18 10 CFR Part 72, "Licensing Requirements for the Independent Storage of Spent Nuclear Fuel,
19 High-Level Radioactive Waste, and Reactor-Related Greater Than Class C Waste." Radiation
20 from this facility, as well as from the operation of CGS, is required to be within the radiation
21 dose limits in 10 CFR Part 20, 40 CFR Part 190, and 10 CFR Part 72. The NRC carries out
22 periodic inspections of the ISFSI to verify its compliance with its licensing and regulatory
23 requirements.

24 Current and reasonably foreseeable actions on the Hanford Site include restoration and
25 remediation of contaminated areas; decommissioning of various facilities; tank waste storage,
26 retrieval, treatment, disposal, and final tank closure; expansion or upgrades to the existing
27 waste storage, treatment, and disposal capacity; and transportation of nuclear waste within and
28 off of the Hanford Site (DOE, 2009),(WCH, 2010). Additional details on these activities are
29 given in Appendix G, Table G-1.

30 While not considered to be a reasonably foreseeable action, the staff is aware of information
31 concerning the use of a new type of fuel at CGS. In February 2011, the staff, through
32 newspaper articles, became aware that Energy Northwest is considering the potential use of
33 mixed oxide (MOX) fuel at CGS. MOX fuel is produced by taking nuclear weapons plutonium
34 oxide at about 10–15 percent concentration levels and blending it with uranium oxide to
35 enrichment levels suitable for commercial nuclear reactors.

36 Energy Northwest is interested in advanced fuel technologies, including MOX fuel, said a
37 spokesperson for Energy Northwest. The spokesperson also stated that Energy Northwest has
38 no plans to use MOX fuel without more research and cannot predict the viability of the fuel for
39 use at CGS. Energy Northwest is talking with Pacific Northwest National Laboratory in Richland
40 about a study to evaluate the feasibility of using the fuel at CGS (Cary, 2011a).

41 At this time, the NRC has not received notification from Energy Northwest on its plans to use
42 MOX fuel in the future. The staff notes that a change in the type of fuel used at CGS will require
43 a thorough evaluation by the NRC on the safety and environmental impacts associated with the
44 new fuel prior to receiving approval for its use.

Environmental Impacts of Operation

1 Based on its review of the DOE's annual Hanford Site ERs, the staff noted that the Hanford Site
2 is subject to many safety standards and regulations. There are three categories of standards
3 and regulations: (1) DOE directives; (2) Federal legislation and EOs; and (3) State and local
4 statutes, regulations, and requirements. Several Federal, State, and local government agencies
5 monitor and enforce compliance with applicable environmental regulations for ongoing
6 operations and for the remediation work being performed at the Hanford Site. Some of those
7 agencies include the EPA, Washington State Department of Ecology, WDOH, and Benton
8 Clean Air Authority. These agencies issue permits, review compliance reports, participate in
9 joint monitoring programs, inspect facilities and operations, and oversee compliance with
10 applicable regulations. There are specific requirements, actions, plans, and schedules identified
11 in the Tri-Party Agreement and other agreements. Therefore, the staff has reasonable
12 assurance that future nuclear operations and remediation activities carried out at the Hanford
13 Site will be done in accordance with all applicable Federal, State, and local government
14 agencies requirements to limit the radiological impact to the public and the environment.

15 The DOE's 2008 Hanford ER states that DOE maintains an awareness of the other sources of
16 radiation on the Hanford Site (e.g., AREVA NP, Perma-Fix Northwest, and CGS) that, if
17 combined with the DOE sources, might have the potential to cause an annual dose exceeding
18 DOE's annual radiation standard of 100 mrem (1.0 mSv) for all radiation exposure pathways or
19 EPA's 10 mrem (0.10 mSv) standard for the air intake radiation exposure pathway in
20 40 CFR Part 61 to any member of the public (Poston, et al., 2009). With information gathered
21 from the companies via personal communication and annual reports, the DOE estimated that
22 the total 2008 annual dose to a member of the public from the combined activities was less than
23 3.0 E-03 mrem (3.0 E-05 mSv). Therefore, the combined annual dose from non-DOE and DOE
24 sources on and near the Hanford Site to a member of the public for 2008 was well below any
25 EPA and DOE regulatory dose limits. The staff has reasonable assurance that DOE will
26 continue to comply with radiation protection standards in the future.

27 The NRC, State of Washington, and DOE would regulate any future actions near the CGS site
28 that could contribute to cumulative radiological impacts. The environmental monitoring
29 performed by CGS, Washington State, and DOE would measure the cumulative impact from
30 any future nuclear operations.

31 Based on the above information, the staff concludes that cumulative radiological impacts would
32 be SMALL.

33 For electromagnetic fields, the staff determined that the CGS transmission lines are operating
34 within design specifications and meet current NESC criteria; therefore, the transmission lines do
35 not significantly affect the overall potential for electric shock from induced currents within the
36 analyzed area of interest. With respect to the effects of chronic exposure to extremely low
37 frequency-electromagnetic fields, although the GEIS finding of "not applicable" is appropriate to
38 CGS, the transmission lines associated with CGS are not likely to significantly contribute to the
39 regional exposure to ELF-EMFs. The proposed McNary-John Day transmission line would also
40 conform to design specifications that meet current NESC criteria (DOE, 2002a). Therefore, the
41 staff has determined that the cumulative impacts of continued operation of the CGS
42 transmission lines and other transmission lines in the affected area would be SMALL.

1 **4.11.5 Cumulative Socioeconomic Impacts**

2 **4.11.5.1 Socioeconomics**

3 This section addresses socioeconomic factors that have the potential to be directly or indirectly
 4 affected by changes in operations at the CGS in addition to the aggregate effects of other past,
 5 present, and reasonably foreseeable future actions. The primary geographic area of interest
 6 considered in this cumulative analysis is Benton and Franklin Counties, which includes the
 7 Tri-Cities area, where approximately 95 percent of CGS employees reside. This area is where
 8 the economy, tax base, and infrastructure would most likely be affected since CGS employees
 9 and their families reside, spend their income, and use their benefits within these counties.

10 Located in Benton County, the Hanford Site was selected by the Federal government for the
 11 Manhattan Project in 1942. The need for workers at Hanford resulted in a significant increase in
 12 the regional population. A summary of past socioeconomic conditions since 1970 can be found
 13 in the Final Environmental Statements for the Construction Permit and Operational Stage of
 14 WPPSS Nuclear Project No. 2 (AEC, 1972), (NRC, 1981).

15 DOE is currently focused on cleaning up defense wastes at Hanford. Restoring burial waste
 16 sites, decommissioning various facilities, conducting tank closures, and conducting other
 17 activities to reduce the Hanford footprint are described in Appendix G, Table G-1 (DOE, 2009).
 18 Any sizeable increase in the Hanford workforce supporting site restoration activities would have
 19 a noticeable effect on socioeconomic conditions in the Tri-Cities area by noticeably increasing
 20 the regional population—including the demand for community services and housing—and
 21 straining local transportation. Most of the workers at the Hanford Site would likely live in the
 22 same communities where CGS employees and their families currently reside. The
 23 socioeconomic impact from CGS operations and Hanford restoration activities, therefore,
 24 overlap.

25 As part of Hanford restoration activities, DOE has proposed to develop an energy park to
 26 sustain the local and regional economies by supplying jobs at new energy production facilities
 27 (DOE, 2010c). The area would be made available for public and private energy demonstration
 28 projects and partnerships (EN, 2010). Construction of the energy park would occur after the
 29 majority of restoration activities have been completed at the Hanford Site, and it could provide a
 30 source of employment for workers formerly employed by the Hanford restoration effort. Since
 31 the energy park would hire significantly fewer workers than the Hanford restoration effort, there
 32 would be no significant cumulative impacts. In addition, construction of new facilities to build
 33 new solar panels, wind turbines, nuclear generators, or other facilities could result in some
 34 aesthetic impacts.

35 Socioeconomic impacts from reasonably foreseeable activities at the Hanford Site are likely to
 36 noticeably increase the population, along with the demand for community services and housing,
 37 while straining local transportation. The primary cause for this impact would be DOE's
 38 restoration efforts on the Hanford Site.

39 As discussed in Section 4.9, continued operation of CGS during the license renewal term would
 40 have no effect on socioeconomic conditions in the region beyond those already experienced.
 41 Since Energy Northwest has no plans to hire additional workers during the license renewal term,
 42 overall expenditures and employment levels at CGS would remain relatively constant with no
 43 additional demand for permanent housing and public services. In addition, since employment
 44 levels and tax payments would not change, there would be no population or tax revenue-related
 45 land use impacts. Based on this, and other information presented in Chapter 4, there would be

Environmental Impacts of Operation

1 no additional contributory effect on socioeconomic conditions in the future from the continued
2 operation of CGS during the license renewal term beyond what is currently being experienced.

3 **4.11.5.2 Environmental Justice**

4 The environmental justice cumulative impact analysis assesses the potential for
5 disproportionately high and adverse human health and environmental effects on minority and
6 low-income populations that could result from past, present, and reasonably foreseeable future
7 actions including CGS operations during the renewal term. Adverse health effects are
8 measured in terms of the risk and rate of fatal or nonfatal adverse impacts on human health.
9 Disproportionately high and adverse human health effects occur when the risk or rate of
10 exposure to an environmental hazard for a minority or low-income population is significant and
11 exceeds the risk or exposure rate for the general population or for another appropriate
12 comparison group. Disproportionately high environmental effects refer to impacts, or risk of
13 impact, on the natural or physical environment in a minority or low-income community that are
14 significant and appreciably exceeds the environmental impact on the larger community. Such
15 effects may include biological, cultural, economic, or social impacts. Some of these potential
16 effects have been noted in resource areas presented in Chapter 4. Minority and low-income
17 populations are subsets of the general public residing in the Tri-Cities area and all would be
18 exposed to the same hazards generated from CGS operations and restoration activities at the
19 Hanford Site.

20 As discussed in Section 4.9.7, minority and low-income populations residing within a 50-mi
21 (80-km) radius of CGS would not be disproportionately affected by the continued operation of
22 CGS. As previously discussed in this chapter, the impact from license renewal for all resource
23 areas (e.g., land, air, water, ecology, and human health) would be SMALL.

24 Potential impacts to minority and low-income populations from continued CGS operations during
25 the license renewal term and ongoing restoration activities at the Hanford Site would mostly
26 consist of environmental and socioeconomic effects (e.g., noise, dust, traffic, employment, and
27 housing impacts). Noise and dust impacts from Hanford restoration activities would be primarily
28 limited to onsite activities. Minority and low-income populations residing along site access
29 roads would continue to be affected by commuter vehicle and truck traffic. However, these
30 effects occur during certain hours of the day and are not likely to be high and adverse.
31 Increased demand for rental housing during certain periods of increased restoration activities at
32 Hanford could also affect low-income populations. Given the close proximity to the Tri-Cities
33 area, however, most workers would likely commute to the Hanford Site, thus reducing the
34 potential demand for rental housing.

35 This cumulative impact assessment also considered the potential radiological risk to special
36 population groups from CGS as well as other sources of radiation from projects described in
37 Appendix G, Table G-1, including past and present activities at the Hanford Site. In
38 Sections 4.9.7 and 4.11.4, the NRC analyzed human health impacts to traditional lifestyle
39 pathway receptors. Local American Indian Tribes depend heavily on the harvest and
40 consumption of fish from local rivers—including the Columbia River, which passes through the
41 Hanford Site—wild game, and an abundance of local native plants to include shoots, roots, leafy
42 material, and berries for foods, medicines, material for tools, shelter, and accessories. Any
43 impact to the Columbia River due to increased population and residential and commercial
44 development could disproportionately affect American Indian and low-income peoples who rely
45 on fishing and hunting along the river.

1 The assessment also considered whether other cumulative environmental impacts could result
 2 in disproportionate adverse impacts on minority or low-income populations. As described
 3 above, there could be general adverse socioeconomic impacts through increased population,
 4 commercial and residential developments, demand for community services and housing, and
 5 traffic from the number of workers needed to support restoration activities at the Hanford Site.
 6 However, such impacts would likely be the same for all segments of the population.

7 As discussed in Section 4.9.7, there would be no disproportionately high and adverse impacts to
 8 minority and low-income populations from the continued operation of CGS during the license
 9 renewal term. Since Energy Northwest has no plans to hire additional workers during the
 10 license renewal term, employment levels at CGS would remain relatively constant with no
 11 additional demand for housing or increased traffic. Based on this information, and the analysis
 12 of human health and environmental impacts presented in Chapters 4 and 5, it is not likely there
 13 would be any disproportionately high and adverse contributory effect on minority and
 14 low-income populations from the continued operation of CGS during the license renewal term.

15 **4.11.6 Cumulative Impacts on Cultural Resources**

16 This section addresses the direct and indirect effects of license renewal on historic and
 17 archaeological resources when added to the aggregate effects of other past, present, and
 18 reasonably foreseeable future actions. The geographic area considered in this analysis is the
 19 APE associated with the proposed undertaking, as defined in Section 4.9.6. In addition to the
 20 APE, potential indirect effects were assessed within the viewshed between CGS and Gable
 21 Mountain and between CGS and Rattlesnake Mountain because both Gable and Rattlesnake
 22 Mountains (two National Register-eligible traditional cultural properties) are significant cultural
 23 resources that overlook the CGS site.

24 Before major land development, the area was largely undisturbed and contained several intact
 25 archaeological sites. Section 2.2.9 presents an overview of the existing historic and
 26 archaeological resources located on the CGS site. Past land development has resulted in
 27 impacts on, and the loss of cultural resources near and at, the CGS site.

28 As described in Section 4.9.6, no significant cultural resources would be adversely affected by
 29 relicensing activities associated with the CGS site because there would be no ground-disturbing
 30 activities that would occur as part of relicensing. In addition, continued operations at the CGS
 31 site would result in no additional visual intrusions beyond those that currently exist.

32 To address the impacts from other present and reasonably foreseeable projects, the list of
 33 projects noted in Appendix G, Table G-1, was reviewed to analyze overlapping impacts that
 34 might directly or indirectly affect cultural resources. Direct impacts would occur if archaeological
 35 sites in the APE are physically removed or disturbed, and indirect impacts would occur if
 36 projects result in the introduction of significant visual intrusions within the viewshed between
 37 CGS and Gable and Rattlesnake Mountains. There are several proposed projects on the
 38 Hanford Site that are located between the CGS site and Gable and Rattlesnake Mountains.
 39 These projects include the following (DOE, 2009):

- 40 • cleanup of debris and infrastructure and construction of the new Combined Community
- 41 • Communication Facility on Rattlesnake Mountain
- 42 • decommissioning, deactivation, and closure of the FFTF
- 43 • ongoing waste management activities on the Hanford Site

Environmental Impacts of Operation

- 1 • tank closure and Waste Treatment Plant construction
- 2 • any additional ground-disturbing or construction activities occurring in this area for the
- 3 development of energy or other projects

4 Construction and operation of these projects has the potential to result in short- and long-term
5 visual intrusions within the viewshed of traditional cultural properties at Gable and Rattlesnake
6 Mountains.

7 The cumulative impacts on cultural resources from ongoing construction, restoration, and waste
8 management activities on the Hanford Site have the potential to be significant, particularly within
9 the viewshed of Gable and Rattlesnake Mountains. The incremental contribution from the
10 proposed license renewal would not adversely change the viewshed or directly affect cultural
11 resources. The review team concludes that the cumulative impacts of the proposed license
12 renewal plus other past, present, and reasonable foreseeable future activities on the cultural
13 resources would be MODERATE. The incremental impacts from CGS would be SMALL
14 because relicensing would not adversely change the viewshed or directly affect cultural
15 resources.

16 **4.11.7 Cumulative Impacts on Air Quality**

17 This section addresses the direct and indirect effects of license renewal on air quality resources
18 when added to the aggregate effects of other past, present, and reasonably foreseeable future
19 actions. The geographic area considered in the cumulative air quality analysis is the county of
20 the proposed action because air quality designations for criteria air pollutants are generally
21 made at the county level. Counties are further grouped together based on a common air
22 shed—known as an air quality control region (AQCR)—to provide for the attainment and
23 maintenance of the National Ambient Air Quality Standards (NAAQS). The CGS site is located
24 in Benton County, WA, which is part of the South Central Washington Intrastate AQCR
25 (40 CFR 81.189). Additional counties in this AQCR include Franklin, Kittitas, Klickitat, Walla
26 Walla, and Yakima Counties.

27 Section 2.2.2 summarizes the air quality designation status for Benton County as well as other
28 counties in the South Central Washington Intrastate AQCR. As noted in Section 2.2.2, the EPA
29 regulates six criteria pollutants under the NAAQS to include carbon monoxide, lead, nitrogen
30 dioxide, ozone, sulfur dioxide, and particulate matter. Benton County is designated as
31 unclassified or in attainment for all NAAQS criteria pollutants; a portion of Benton County, which
32 does not include the CGS site, became a maintenance area for PM-10 (particles with a diameter
33 of 10 micrometers or less) on September 26, 2005 (40 CFR 81.348). Portions of Yakima
34 County, which are also part of this AQCR, are also maintenance areas for PM-10 as well as
35 carbon monoxide (40 CFR 81.348). All other counties in this AQCR are designated as
36 unclassified or in attainment with respect to the NAAQS criteria pollutants.

37 Criteria pollutant air emissions from the CGS site are presented in Section 2.2.2.1. These
38 emissions are principally from standby diesel generators and conform to Washington State
39 Regulatory Order 672 which limits fuel consumption and associated air emissions
40 (EFSEC, 1996). Continued operations of the CGS site would result in annual air emissions
41 comparable to those noted in Section 2.2.2.1. Assuming an average annual emission rate of
42 721 tons per year (656 metric tons per year) for carbon dioxide, an additional 20 years of
43 operation would result in approximately 14,420 tons (13,122 metric tons) of carbon dioxide.
44 There is no planned site refurbishment associated with license renewal; therefore, there are no
45 additional air emissions beyond those noted in Section 2.2.2.1 for normal operations.

1 Appendix G, Table G-1 describes foreseeable projects that could contribute to cumulative
 2 impacts to air quality. Many of the projects are related to DOE’s efforts to restore burial waste
 3 sites, decommission various facilities, conduct tank closures, and conduct other activities to
 4 reduce the Hanford footprint (DOE, 2009). Notable Hanford-related projects that would affect
 5 future air quality include the following:

- 6 • decommissioning of the remaining production reactors and support facilities in the 100
 7 Area (DOE, 1992)
- 8 • decommissioning of the N-Reactor and support facilities (DOE, 2005)
- 9 • disposition of the PUREX plant, canyons, and tunnels, and other 200 Area facilities
 10 (Fluor Hanford, 2004)
- 11 • deactivation of the FFTF in the 400 Area (DOE, 2002b)
- 12 • actions related to tank closure and waste management, including the construction and
 13 operation of the Waste Treatment Plant (DOE, 2009)

14 As discussed in several of the environmental impact documents for these projects (e.g.,
 15 DOE, 2009), various control and mitigation measures would be instituted to reduce air
 16 emissions to an acceptable level so as to not exceed any applicable standard.

17 Continued air emissions from non-DOE activities at the Hanford Site include emissions from
 18 transport of U.S. Navy reactor plants to the 200-East Area (Navy, 1996) and operation of the
 19 U.S. Ecology commercial low-level radioactive waste disposal site (WDOE and WDOH, 2004).
 20 Other projects and actions listed in Appendix G, Table G-1, that would contribute to air
 21 emissions in Benton and nearby counties include base realignment and closure activities at
 22 nearby Department of Defense (DoD) facilities, future power and biofuel projects, oil and gas
 23 exploration, and surface mining. Development and construction activities associated with
 24 regional growth of housing, business, and industry—as well as associated vehicular traffic—
 25 would also result in additional air emissions. Project timing and location, which are difficult to
 26 predict, affect cumulative impacts to air quality. However, permitting and licensing
 27 requirements, efficiencies in equipment, cleaner fuels, and various mitigation measures can be
 28 used to minimize cumulative air quality impacts.

29 Potential cumulative effects of climate change in central Washington, where CGS is located,
 30 could result in a variety of changes to the air quality of the area. As projected in the “Global
 31 Climate Change Impacts in the United States” report by Karl, et al. (2010), the temperatures in
 32 this region are expected to rise 6 degrees F (14 degrees C) to 10 degrees F (12 degrees C) by
 33 the end of this century, causing more frequent extreme weather events. Increases in average
 34 annual temperatures, higher probabilities of extreme heat events, higher occurrences of
 35 extreme rainfall (intense rainfall or drought), and changes in the wind patterns could affect
 36 concentrations of the air pollutants and their long-range transport because their formation
 37 partially depends on the temperature and humidity and is a result of the interactions between
 38 hourly changes in the physical and dynamic properties of the atmosphere, atmospheric
 39 circulation features, wind, topography, and energy use (IPCC, 2010).

40 Given that there is no planned site refurbishment associated with the CGS license renewal and,
 41 therefore, no additional air emissions beyond those noted in Section 2.2.2.1 from continued
 42 operations of CGS, the incremental impacts to cumulative air quality impacts in Benton County
 43 would be minimal. Other reasonably foreseeable projects described above—such as
 44 construction and operation of waste disposal facilities, decommissioning, and remediation

Environmental Impacts of Operation

1 efforts on the Hanford Site—could result in cumulative impacts to air quality. However,
2 permitting and licensing requirements and various mitigation measures would likely limit air
3 quality impacts such that they remain below applicable air quality standards. Therefore, the
4 staff concludes that the cumulative air quality impacts from the proposed license renewal and
5 other past, present, and reasonably foreseeable projects would be SMALL.

6 **4.11.8 Summary of Cumulative Impacts**

7 The staff considered the potential impacts resulting from the operation of CGS during the period
8 of extended operation and other past, present, and reasonably foreseeable future actions near
9 CGS. The preliminary determination is that the potential cumulative impacts would range from
10 SMALL to LARGE, depending on the resource. Table 4.11-1 summarizes the cumulative
11 impacts on resources areas.

12 **Table 4.11-1. Summary of cumulative impacts on resources areas**

| Resource area | Cumulative impact |
|---------------------|---|
| Water Resources | Because the groundwater beneath and adjacent to the CGS site has been noticeably altered by DOE activities at Hanford, the cumulative impacts on groundwater resources are SMALL to LARGE, depending on location. However, the incremental contribution from CGS operations would be SMALL. Cumulative surface water impacts would be SMALL because CGS and other water users would withdraw a small fraction of the river flow, and CGS activities would not result in significant impacts on surface-water quality. |
| Aquatic Ecology | Past alterations of aquatic habitat and fish passage has noticeably altered the Columbia River aquatic ecosystem. Considerable resources would be required to curtail the destabilizing factors that could jeopardize the existence of aquatic species or adversely affect their designated critical habitat in the reasonably foreseeable future. This condition meets NRC's definition of a LARGE level of impact. The incremental impact from CGS license renewal is SMALL. |
| Terrestrial Ecology | Past, current, and future construction, restoration, and waste management activities on the Hanford Site have the potential to affect terrestrial resources. Therefore, the cumulative impacts would be MODERATE, although the incremental contribution from the proposed license renewal would be SMALL and would not adversely affect terrestrial resources. |
| Human Health | The REMP carried out by Energy Northwest near the CGS site measures radiation and radioactive materials from all sources, such as hospitals, other licensed users of radioactive material, and facilities described in Appendix G, Table G-1; therefore, the monitoring program measures cumulative radiological impacts. Staff reviewed environmental monitoring data for the CGS site, measured by Energy Northwest, and for the Hanford Site, measured by Washington State and the DOE. The data show that there is no significant radiological impact to the public and environment; therefore, the cumulative impacts are SMALL. |
| Socioeconomics | Socioeconomic impacts from reasonably foreseeable activities at the Hanford Site are likely to noticeably increase the population along with the demand for community services and housing, while straining local transportation. As discussed in Section 4.9, continued operation of CGS during the license renewal term would have no impact on socioeconomic conditions in the region beyond those already experienced. |
| Cultural Resources | Ongoing construction, restoration, and waste management activities on the Hanford Site have the potential to significantly affect cultural resources, particularly within the viewshed of Gable and Rattlesnake Mountains. Therefore, the cumulative impacts would be MODERATE, although the incremental contribution from the proposed license renewal would be SMALL and would not adversely change the viewshed or directly affect cultural resources. |

| Resource area | Cumulative impact |
|---------------|---|
| Air Quality | Reasonably foreseeable activities—such as construction and operation of waste disposal facilities, decommissioning, and remediation efforts on the Hanford Site—could result in cumulative impacts to air quality. However, permitting and licensing requirements and various mitigation measures would likely limit air quality impacts such that they remain below applicable air quality standards. The incremental impacts from CGS operations would be minimal since no refurbishment activities are planned. Therefore, the staff concludes that the cumulative air quality impacts would be SMALL. |

1 **4.12 References**

- 2 Advisory Council on Historic Preservation (ACHP), “National Register Criteria,” 2008, Available
3 URL: <http://www.achp.gov/nrcriteria.html> (accessed September 2, 2010).
- 4 Barwin, R.F., WDOE, letter to the Cities of Richland, Kennewick, Pasco, and West Richland,
5 WA, “RE: Surface Water Application No. 30976” (with enclosures), Yakima, WA, November 19,
6 2002.
- 7 Becker, C.D, *Aquatic Bioenvironmental Studies: The Hanford Experience 1944–84. Studies in*
8 *Environmental Science* 39, Elsevier Science Publishing Company Inc., New York, NY, 1990.
- 9 Cary, A., “Hanford Plans for Natural Gas Pipeline under Columbia,” *Tri-City Herald*, Kennewick,
10 WA, February 16, 2011, Available URL: [http://www.tri-](http://www.tri-cityherald.com/2011/02/16/1370077/hanford-creating-plans-for-natural.html)
11 [cityherald.com/2011/02/16/1370077/hanford-creating-plans-for-natural.html](http://www.tri-cityherald.com/2011/02/16/1370077/hanford-creating-plans-for-natural.html) (accessed
12 March 4, 2011).
- 13 Cary, A., “Energy Northwest considers mixed plutonium fuel,” *Tri-City Herald*, Kennewick, WA,
14 February 4, 2011 (2011a), Available URL: [http://www.tri-](http://www.tri-cityherald.com/2011/02/04/1354173/energy-northwest-considering-mixed.html)
15 [cityherald.com/2011/02/04/1354173/energy-northwest-considering-mixed.html](http://www.tri-cityherald.com/2011/02/04/1354173/energy-northwest-considering-mixed.html) (accessed
16 February 15, 2011).
- 17 Coleman, D.W, Manager, Regulatory Programs, Energy Northwest, letter to Robert Whitlam,
18 State Archaeologist, Department of Archaeology and Historic Preservation, “Subject: Columbia
19 Generating Station Operating License Renewal,” GO2-10-97, July 22, 2010, Agencywide
20 Document Access and Management System (ADAMS) Accession No. ML102160123.
- 21 Council on Environmental Quality (CEQ), “Environmental Justice: Guidance Under the National
22 Environmental Policy Act,” December 10, 1997, Available URL:
23 <http://ceq.hss.doe.gov/nepa/regs/ej/justice.pdf>.
- 24 Dauble, D.D, *Fishes of the Columbia Basin: A Guide to Their Natural History and Identification*,
25 Keokee Books, Sandpoint, ID, 2009.
- 26 Dauble, D.D., and D.G. Watson, “Status of Fall Chinook Salmon Populations in the Mid
27 Columbia River, 1948–1992,” *North American Journal of Fisheries Management*, 17:283-300,
28 1997.
- 29 Duncan J.P., et al., “Hanford Site National Environmental Policy Act (NEPA) Characterization,”
30 Pacific Northwest National Laboratory, Richland, WA, PNNL-6415 Revision 18, 2007.
- 31 Energy Facility Site Evaluation Council (EFSEC), “Regulatory Order No. 672 Limiting WNP-2 Air
32 Emissions,” 1996.

Environmental Impacts of Operation

- 1 Energy Northwest (EN), "Columbia Generating Station Landfill; Groundwater Monitoring
2 Data-Summary August 1995–April 2002," Richland, WA, 2002.
- 3 EN, "2005 Annual Radiological Environmental Operating Report," CGS, Columbia, WA, 2006
4 (2006a), ADAMS Accession No. ML061430031.
- 5 EN, "2005 Radioactive Effluent Release Report," CGS, Columbia, WA, 2006 (2006b), ADAMS
6 Accession No. ML060670490.
- 7 EN, "2006 Annual Radiological Environmental Operating Report," CGS, Columbia, WA, 2007
8 (2007a), ADAMS Accession No. ML071430240.
- 9 EN, "2006 Radioactive Effluent Release Report," CGS, Columbia, WA, 2007 (2007b), ADAMS
10 Accession No. ML070720760.
- 11 EN, "2007 Annual Radiological Environmental Operating Report," CGS, Columbia, WA, 2008
12 (2008a), ADAMS Accession No. ML081500133.
- 13 EN, "2007 Radioactive Effluent Release Report," CGS, Columbia, WA, 2008 (2008b), ADAMS
14 Accession No. ML080710435.
- 15 EN, "2008 Annual Radiological Environmental Operating Report," CGS, Columbia, WA, 2009
16 (2009a), ADAMS Accession No. ML091410235.
- 17 EN, "2008 Radioactive Effluent Release Report," CGS, Columbia, WA, 2009 (2009b), ADAMS
18 Accession No. ML090720892.
- 19 EN, "Columbia Generating Station, License Renewal Application, Applicant's Environmental
20 Report, Operating License Renewal Stage," Richland, WA, Document No. 50-397, License
21 No. NPF-21, 2010, ADAMS Accession No. ML100250666.
- 22 EN, "Columbia Generating Station, License Amendment Request in Support of Department of
23 Energy (DOE) 618-11 Waste Burial Ground Remediation Project-Nonintrusive Activities,"
24 Docket No. 50-397, 2010 (2010a), ADAMS Accession No. ML101250340.
- 25 EN, "2009 Annual Radiological Environmental Operating Report," CGS, Environmental
26 Services, Columbia, WA, 2010 (2010b), ADAMS Accession No. ML101400135.
- 27 EN, "2009 Radioactive Effluent Release Report," CGS, Columbia, WA, 2010 (2010c), ADAMS
28 Accession No. ML100690065.
- 29 Environmental Protection Agency (EPA), "Consideration of Cumulative Impacts in EPA Review
30 of NEPA Documents," Office of Federal Activities (2252A), Washington, D.C.,
31 EPA-315-R-99-002, 1999.
- 32 EPA, "National Pollutant Discharge Elimination System-Final Regulations to Establish
33 Requirements for Cooling Water Intake Structures at Phase II Existing Facilities," Federal
34 Register, Volume 69, No. 41576, July 9, 2004.
- 35 Federal Energy Regulatory Commission (FERC), "Final Environmental Impact Statement, Priest
36 Rapids Hydroelectric Project, Washington (FERC Project No. 2114)," Office of Energy Projects,
37 Washington, D.C., FERC/FEIS-0190F, November 2006.

- 1 Fertig, W., R. Black, and P. Wolken, "Rangewide Status Review of Ute Ladies'-Tresses
2 (*Spiranthes diluvialis*)," Available URL: [http://www.fws.gov/mountain-](http://www.fws.gov/mountain-prairie/species/plants/uteladiestress/SPDI_Status%20review_Fertig2005.pdf)
3 [prairie/species/plants/uteladiestress/SPDI_Status%20review_Fertig2005.pdf](http://www.fws.gov/mountain-prairie/species/plants/uteladiestress/SPDI_Status%20review_Fertig2005.pdf) (accessed
4 November 12, 2010).
- 5 Fluor Hanford, Inc., "Plan for Central Plateau Closure," Richland, WA, CP-22319-DEL,
6 Revision 0, 2004.
- 7 Gambhir, S.K., Vice President, Technical Services, Energy Northwest, letter to NRC in response
8 to letters from W.S. Oxenford dated January 19, 2010 and D. Doyle dated July 2, 2010,
9 "Subject: Columbia Generating Station, Docket No. 50-397 Response to Request for Additional
10 Information License Renewal Application," G02-10-105, August 5, 2010 (2010a), ADAMS
11 Accession No. ML102300503
- 12 Gambhir, S.K., Vice President, Technical Services, Energy Northwest, letter to NRC, "Subject:
13 Columbia Generating Station, Docket No. 50-397 Response to Request for Additional
14 Information License Renewal Application," G02-10-108, August 9, 2010 (2010b), ADAMS
15 Accession No. ML102380285.
- 16 Gambhir, S.K. Vice President, Engineering, Energy Northwest, letter to NRC, "Subject:
17 Columbia Generating Station, Docket No. 50-397 Response to Request for Additional
18 Information License Renewal Application," G02-10-178, December 21, 2010 (2010c), ADAMS
19 Accession No. ML103620324.
- 20 Gray, R.H. and D.D. Dauble, "Checklist and Relative Abundance of Fish Species from the
21 Hanford Reach of the Columbia River," *Northwest Science*, 51:208-215, 1977.
- 22 Hanf, R.W., et al, "Hanford Site Environmental Report for Calendar Year 2006," Pacific
23 Northwest National Laboratory, Richland, WA, PNNL-16623, 2007.
- 24 Harris, Stuart G. and Barbara L. Harper, "Exposure Scenario for CTUIR Traditional Subsistence
25 Lifeways," Department of Science & Engineering, Confederated Tribes of the Umatilla Indian
26 Reservation, Pendleton, OR, September 15, 2004, Available URL:
27 <http://www.hhs.oregonstate.edu/ph/tribal-grant/index.html>.
- 28 Intergovernmental Panel on Climate Change (IPCC), "IPCC Fourth Assessment Report:
29 Working Group II Report—Impacts, Adaptation and Vulnerability," 2010, Available URL:
30 <http://www.ipcc.ch/ipccreports/ar4-wg2.htm> (accessed October 2010).
- 31 Karl, T.R., et al., eds., "Global Climate Change Impacts in the United States," U.S. Global
32 Change Research Program, Cambridge University Press, New York, 2009, Available URL:
33 <http://downloads.globalchange.gov/usimpacts/pdfs/climate-impacts-report.pdf>, ADAMS
34 Accession No. ML100580077.
- 35 Kurz, G., USFWS, email to D. Doyle, NRC, November 8, 2010, ADAMS Accession
36 No. ML103120486.
- 37 Miley T.B., et al., "Current Conditions Risk Assessment for the 300-FF-5 Groundwater Operable
38 Unit," Pacific Northwest National Laboratory, Richland, WA, PNNL-16454 Revision 0, 2007.
- 39 *National Environmental Policy Act* (NEPA), § 42 U.S.C. § 4321, et seq. (1969, as amended).

Environmental Impacts of Operation

- 1 *National Historic Preservation Act* (NHPA), §16 U.S.C. § 470, et seq. (1966, as amended).
- 2 National Marine Fisheries Service (NMFS), “Status and Recovery of Listed Salmon Populations,
3 2005 Report to Congress,” Pacific Coastal Salmon Recovery Fund. National Oceanic and
4 Atmospheric Administration, National Marine Fisheries Service, Northwest Regional Office,
5 Seattle, WA, 2005, Available URL:
6 <http://www.nwr.noaa.gov/Salmon-Recovery-Planning/PCSRF/PCSRF-Documents.cfm>
7 (accessed on October 21, 2010).
- 8 NMFS, “Northwest Salmon and Steelhead Recovery, Planning and Implementation, Upper
9 Columbia Salmon Recovery Plan Summary,” Northwest Regional Office, Seattle, WA, 2007,
10 Available URL:
11 <http://www.nwr.noaa.gov/Salmon-Recovery-Planning/Recovery-Domains/Interior-Columbia/Upper-Columbia/upload/Upper-C-summary.pdf>
12
- 13 NMFS, “Endangered Species Act, Section 7(a)(2) Consultation, Supplemental Biological
14 Opinion: Supplemental Consultation on Remand for Operation of the Federal Columbia River
15 Power System, 11 Bureau of Reclamation Projects in the Columbia Basin and ESA
16 Section 10(a)(1)(A) Permit for Juvenile Fish Transportation Program,” Northwest Region,
17 Seattle, WA, F/NWR/2010/02096, 2010.
- 18 *Native American Graves Protection and Repatriation Act*, § 25 U.S.C. § 3001, et seq. (as
19 amended).
- 20 Nichols, W.E, “618-10 Burial Ground Dust Suppression Water Supply Well Modeling
21 Evaluation,” Richland, WA, ECF-200P01-0059, CH2MHILL, 2010.
- 22 Pacific Northwest National Laboratory (PNNL), “Human Scenarios for the Screening
23 Assessment, Columbia River Comprehensive Impact Assessment,” DOE, DOE/RL-96-16-a,
24 Revision 0, March, 1996.
- 25 Pham, Bo, NRC, letter to Alyson Brooks, Washington SHPO, “Columbia Generating Station
26 License Renewal Application (Log No. 121007-20-NRC),” March 18, 2010, ADAMS Accession
27 No. ML100610084.
- 28 Pham, Bo, NRC, letter to Honorable Elwood H. Patawa, Confederated Tribes of the Umatilla
29 Indian Reservation, “Request for Scoping Comments Concerning the Columbia Generating
30 Station License Renewal Application Review,” March 19, 2010 (2010a), ADAMS Accession
31 No. ML100770417.
- 32 Pham, Bo, NRC, letter to Honorable Louis Cloud, Yakama Nation, “Request for Scoping
33 Comments Concerning the Columbia Generating Station License Renewal Application Review,”
34 March 19, 2010 (2010b), ADAMS Accession No. ML100770417.
- 35 Pham, Bo, NRC, letter to Honorable Samuel N. Penney, Nez Perce Tribe, “Request for Scoping
36 Comments Concerning the Columbia Generating Station License Renewal Application Review,”
37 March 19, 2010 (2010c), ADAMS Accession No. ML100770417.
- 38 Pham, Bo, NRC, letter to Rob Whitlam, State Archaeologist, Washington SHPO, “Columbia
39 Station License Renewal Application (Log No. 121007-20-NRC),” April 15, 2010 (2010d),
40 ADAMS Accession No. ML100960118.

- 1 Pham, Bo, NRC, letter to Rob Whitlam, State Archaeologist, Washington SHPO, "Columbia
2 Generating Station License Renewal Application (Log No. 121007-20-NRC)," November 30,
3 2010 (2010e), ADAMS Accession No. ML103280421.
- 4 Poston T.M., et al., "Hanford Site Environmental Report for Calendar Year 2007," Pacific
5 Northwest National Laboratory, Richland, WA, PNNL-17603, 2008.
- 6 Poston, T.M., et al., "Hanford Site Environmental Report for Calendar Year 2008," Pacific
7 Northwest National Laboratory, Richland, WA, PNNL-18427, 2009.
- 8 RIDOLFI, Inc., "Yakama Nation Exposure Scenario for Hanford Site Risk Assessment,"
9 September, 2007, Available URL:
10 <http://www5.hanford.gov/pdw/fsd/AR/FSD0001/FSD0042/DA06587583/1.PDF> (accessed
11 June 3, 2011).
- 12 Suzumoto, Bruce, Assistant Regional Administrator, Hydropower Division, National Marine
13 Fisheries Service, letter to Bo Pham, NRC, "Columbia Generating Station license renewal,
14 request for species list for consultation," June 23, 2010, ADAMS Accession No. ML101830405.
- 15 U.S. Atomic Energy Commission (AEC), "Final Environmental Statement Related to the
16 Proposed Hanford Number Two Nuclear Power Plant," Docket No. 50-397, 1972, ADAMS
17 Accession No. ML101870543.
- 18 U.S. Census Bureau (USCB), "LandView 6—Census 2000 Profile of General Demographic
19 Characteristics DP-1 (100%) and Census Profile of Selected Economic Characteristics DP-3,
20 Summary of Census Block Groups in a 50-mile Radius Around the CGS (46.471667 Lat.,
21 -119.332778 Long.)," December 2003.
- 22 USCB, "American FactFinder—Census 2000 and State and County QuickFacts Information and
23 2006-2008 American Community Survey 3-Year Estimates and Data Profile Highlights
24 Information on Washington, Oregon, and Benton and Franklin Counties," 2010, Available URLs:
25 <http://factfinder.census.gov> and <http://quickfacts.census.gov> (accessed September 2010).
- 26 *U.S. Code of Federal Regulations (CFR)*, "Standards for Protection Against Radiation," Part 20,
27 Title 10, "Energy."
- 28 *CFR*, "Domestic Licensing of Production and Utilization Facilities," Part 50, Title 10, "Energy."
- 29 *CFR*, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory
30 Functions," Part 51, Chapter 1, Title 10, "Energy."
- 31 *CFR*, "Requirements for Renewal of Operating Licenses for Nuclear Power Plants," Part 54,
32 Chapter 4, Title 10, "Energy."
- 33 *CFR*, "National Register of Historic Places," Part 60, Title 36, "Parks, Forests, and Public
34 Property."
- 35 *CFR*, "National Emission Standards for Hazardous Air Pollutants," Part 60, Chapter 1, Title 40,
36 "Protection of the Environment."
- 37 *CFR*, "Licensing Requirements for the Independent Storage of Spent Nuclear Fuel, High-Level
38 Radioactive Waste, and Reactor-related Greater than Class C Waste," Part 70, Chapter 2,
39 Title 10, "Energy."

Environmental Impacts of Operation

- 1 *CFR*, “Designation of Areas for Air Quality Planning Purposes,” Part 80, Chapter 1, Title 40,
2 “Protection of the Environment.”
- 3 *CFR*, “Environmental Radiation Protection Standards for Nuclear Power Operations,” Part 190,
4 Title 40, “Protection of the Environment.”
- 5 *CFR*, “Protection of Historic Properties,” Part 800, Title 36, “Parks, Forests, and Public
6 Property.”
- 7 U.S. Department of Energy (DOE), “Addendum to the Final Environmental Impact Statement,
8 Decommissioning of Eight Surplus Production Reactors at the Hanford Site, Richland, WA,”
9 Washington, D.C., DOE/EIS-0119F, 1992.
- 10 DOE, “Final Hanford Comprehensive Land-Use Plan Environmental Impact Statement, Hanford
11 Site, Richland, WA,” Richland Operations Office, Richland, WA, 1999.
- 12 DOE, “Threatened and Endangered Species Management Plan: Salmon and Steelhead,”
13 Richland Operations Office, Richland, WA, DOE/RL-2000-27, Revision 0, 2000.
- 14 DOE, “McNary-John Day Transmission Line Project Draft Environmental Impact Statement,”
15 DOE/EIS-0332, February 2002 (2002a).
- 16 DOE, “Performance Management Plan for the Accelerated Cleanup of the Hanford Site,”
17 Richland Operations Office and Office of River Protection, Richland, WA, DOE/RL-2002-47,
18 Revision D, 2002 (2002b).
- 19 DOE, “Surplus Reactor Final Disposition Engineering Evaluation,” Richland Operations Office,
20 Richland, WA, DOE/RL-2005-45, Revision 0, 2005.
- 21 DOE, “Draft Tank Closure and Waste Management Environmental Impact Statement for the
22 Hanford Site, Richland, Washington,” Office of River Protection, Richland, WA, DOE/EIS-0391,
23 2009.
- 24 DOE, “Memorandum of Agreement (MOA) for the Rattlesnake Mountain Combined Community
25 Communication Facility and Infrastructure Cleanup on the Fitzner/Eberhardt Arid Lands Ecology
26 Reserve Hanford Site, Richland, Washington Between the U.S. Department of Energy and the
27 Washington State Historic Preservation Office with the Participation of Consulting Parties:
28 Confederated Tribes and Bands of the Yakama Nation, Confederated Tribes of the Umatilla
29 Indian Reservation, the Nez Perce Tribe, and the Wanapum. Richland, Washington,” Richland
30 Operations Office, Richland, WA, DOE/EA-1660F, Appendix B, 2009 (2009a), Available URL:
31 http://nepa.energy.gov/documents/EA-1660__Final.pdf.
- 32 DOE, “Hanford Site Groundwater Monitoring and Performance Report for 2009,” Richland, WA,
33 DOE/RL-2010-11, Volumes 1 & 2, 2010 (2010a).
- 34 DOE, “Hanford Projects and Facilities: 618-10 and 618-11 Burial Grounds,” 2010 (2010b),
35 Available URL: <http://www.hanford.gov/page.cfm/618BurialGrounds> (accessed July 12, 2010).
- 36 DOE, “Energy Parks Initiative: Leveraging Assets To Increase Taxpayers’ Return On
37 Investment,” Presentation by Dr. Benjamin J. Cross, PEDOE Office of Environmental
38 Management at the Radioactive Waste and Hazardous Materials Committee, Santa Fe, NM,
39 July 13, 2010 (2010c), Available URL:

- 1 <http://legis.state.nm.us/lcs/handouts/RHMC%20EPI%20-%20Briefing%20-%20NM%20Legislature%2020100713.pdf> (accessed September 10, 2010).
- 2
- 3 DOE, "DOE Hanford Site Environmental Reports," 2010 (2010d), Available URL: <http://hanford-site.pnl.gov/envreport>.
- 4
- 5 U.S. Department of the Interior (DOI), "Listing Endangered and Threatened Species: Change in
6 Status for the Upper Columbia River Steelhead Distinct Population Segment," Federal Register,
7 Volume 75, No. 2269, January 14, 2010.
- 8 U.S. Department of the Navy (Navy), "Final Environmental Impact Statement on the Disposal of
9 Decommissioned, Defueled Cruiser, OHIO Class, and LOS ANGELES Class Naval Reactor
10 Plants," Bremerton, WA, DOE/EIS-0259, 1996.
- 11 U.S. Fish and Wildlife Service (USFWS), "Biological Opinion for the Priest Rapids Project
12 License Renewal, Federal Energy Regulatory Commission," Central Washington Field Office,
13 Wenatchee, WA, 13260-2007-F-0062 and 13260-2006-P-0008, 2007.
- 14 USFWS, "Final Hanford Reach National Monument Comprehensive Conservation Plan and
15 Environmental Impact Statement," August 2008.
- 16 USFWS, "Species Reports: Listings and Occurrences for Washington," 2010, Available URL:
17 [http://ecos.fws.gov/tess_public/pub/stateListingAndOccurrenceIndividual.jsp?state=WA&s8fid=](http://ecos.fws.gov/tess_public/pub/stateListingAndOccurrenceIndividual.jsp?state=WA&s8fid=112761032792&s8fid=112762573902&s8fid=24012843018782)
18 [112761032792&s8fid=112762573902&s8fid=24012843018782](http://ecos.fws.gov/tess_public/pub/stateListingAndOccurrenceIndividual.jsp?state=WA&s8fid=112761032792&s8fid=112762573902&s8fid=24012843018782) (accessed
19 September 12, 2010).
- 20 USFWS, "Hanford Reach National Monument," 2010 (2010a), Available URL:
21 <http://www.fws.gov/hanfordreach/index.html>.
- 22 U.S. Geological Survey (USGS), "USGS Surface-Water Annual Statistics for Washington,"
23 USGS 12472800 Columbia River Below Priest Rapids Dam, WA, 2010, Available URL:
24 [http://nwis.waterdata.usgs.gov/wa/nwis/](http://nwis.waterdata.usgs.gov/wa/nwis/annual/?format=sites_selection_links&search_site_no=12472800&referred_module=sw)
25 [annual/?format=sites_selection_links&search_site_no=12472800&referred_module=sw](http://nwis.waterdata.usgs.gov/wa/nwis/annual/?format=sites_selection_links&search_site_no=12472800&referred_module=sw)
26 (accessed July 13, 2010).
- 27 USGS, "USGS Surface-Water Monthly Statistics for Washington," USGS 12472800 Columbia
28 River Below Priest Rapids Dam, WA, 2010 (2010a), Available URL:
29 [http://waterdata.usgs.gov/wa/nwis/monthly?referred_module=sw&site_no=](http://waterdata.usgs.gov/wa/nwis/monthly?referred_module=sw&site_no=12472800&por_12472800_22=1180614,00060,22,1917-10,2009-09&start_dt=1960-01&end_dt=2008-12&format=html_table&date_format=YYYY-MM-DD&rdb_compression=file&submitted_form=parameter_selection_list)
30 [12472800&por_12472800_22=1180614,00060,22,1917-10,2009-09&start_dt=](http://waterdata.usgs.gov/wa/nwis/monthly?referred_module=sw&site_no=12472800&por_12472800_22=1180614,00060,22,1917-10,2009-09&start_dt=1960-01&end_dt=2008-12&format=html_table&date_format=YYYY-MM-DD&rdb_compression=file&submitted_form=parameter_selection_list)
31 [1960-01&end_dt=2008-12&format=html_table&date_format=](http://waterdata.usgs.gov/wa/nwis/monthly?referred_module=sw&site_no=12472800&por_12472800_22=1180614,00060,22,1917-10,2009-09&start_dt=1960-01&end_dt=2008-12&format=html_table&date_format=YYYY-MM-DD&rdb_compression=file&submitted_form=parameter_selection_list)
32 [YYYY-MM-DD&rdb_compression=file&submitted_form=parameter_selection_list](http://waterdata.usgs.gov/wa/nwis/monthly?referred_module=sw&site_no=12472800&por_12472800_22=1180614,00060,22,1917-10,2009-09&start_dt=1960-01&end_dt=2008-12&format=html_table&date_format=YYYY-MM-DD&rdb_compression=file&submitted_form=parameter_selection_list)
33 (accessed July 27, 2010).
- 34 U.S. Nuclear Regulatory Commission (NRC), "Final Environmental Statement related to the
35 Operation of WPPSS Nuclear Projection No. 2," Washington, D.C., NUREG-0812, 1981,
36 ADAMS Accession No. ML100570374.
- 37 NRC, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants,"
38 Washington, D.C., NUREG-1437, Volumes 1 and 2, 1996, ADAMS Accession
39 Nos. ML040690705 and ML040690738.

Environmental Impacts of Operation

- 1 NRC, "Section 6.3—Transportation, Table 9.1, Summary of Findings on NEPA Issues for
2 License Renewal of Nuclear Power Plants, Final Report," Generic Environmental Impact
3 Statement for License Renewal of Nuclear Plants, NUREG-1437, Washington, D.C., Volume 1,
4 Addendum 1, 1999, ADAMS Accession No. ML040690720.
- 5 NRC, "Standard Review Plans for Environmental Reviews for Nuclear Power Plants,
6 Supplement 1: Operating License Renewal, NUREG-1555, Supplement 1, Washington, D.C.,
7 1999 (1999b), ADAMS Accession No. ML093340205.
- 8 NRC, "Columbia Generating Station—NRC Radiation Safety Team Inspection Report
9 05000397/2009009," Washington, D.C., Docket Number 50-397, 2009, ADAMS Accession
10 No. ML092600874.
- 11 NRC, "Summary of Tribal Outreach Informational Meeting concerning Columbia Generating
12 Station License Renewal and Hanford Low-Level Waste," October 1, 2010, ADAMS Accession
13 No. ML102630228.
- 14 NRC, "Summary of Site Visit in Support of the Environmental Review of the License Renewal
15 Application for Columbia Generating Station (TAC No. ME3121)," January 18, 2011, ADAMS
16 Accession No. ML103400163.
- 17 Washington Closure Hanford (WCH), "U.S. Department of Energy's River Corridor Closure
18 Project: Washington Closure Hanford—Projects Overview," 2010, Available URL:
19 <http://www.washingtonclosure.com/projects/overview/> (accessed September 16, 2010).
- 20 Washington Department of Fish and Wildlife (WDFW), "Washington's Comprehensive Wildlife
21 Conservation Strategy, Final Draft," 2005, Available URL:
22 http://wdfw.wa.gov/publications/00727/volumeone_chaptersi-iii.pdf (accessed
23 October 22, 2010).
- 24 WDFW, "WDFW Conducting Boat Checks to Stop Aquatic Invasive Species," Olympia, WA,
25 2010, Available URL: <http://wdfw.wa.gov/news/release.php?id=jun1510a> (accessed
26 September 14, 2010).
- 27 Washington Department of Natural Resources (WDNR), "State of Washington Natural Heritage
28 Plan 2007," 2007, Available URL: http://www.dnr.wa.gov/Publications/amp_nh_plan_2007.pdf
29 (accessed October 21, 2010).
- 30 WDNR, "State of Washington Natural Heritage Plan 2009 Update," 2009, Available URL:
31 http://www.dnr.wa.gov/Publications/amp_nh_plan_2009.pdf (accessed October 21, 2010).
- 32 Washington State Department of Transportation (WSDOT), "Fish Passage," Washington State
33 Department of Transportation, Olympia, WA, 2010, Available URL:
34 <http://www.wsdot.wa.gov/environment/biology/fp/fishpassage.htm> (accessed on
35 September 15, 2010).
- 36 Washington Public Power Supply System (WPPSS), "Environmental Report," Washington
37 Public Power Supply System, Richland, WA, Operating License Stage Docket No. 50-397,
38 WPPSS Nuclear Project No. 2, 1980.
- 39 WPPSS, "Technical Review of the Aquatic Monitoring Program of WNP-2," Richland, WA, 1982.

- 1 WPPSS, "Operational Ecological Monitoring Program for Nuclear Plant 2—1985 Annual
2 Report," Richland, WA, 1986.
- 3 WPPSS, "Operational Ecological Monitoring Program for Nuclear Plant 2—1986 Annual
4 Report," Richland, WA, 1987.
- 5 Washington State Department of Ecology (WDOE), "2008 303(d) Impaired and Threatened
6 Water Body Maps," 2008, Available URL:
7 <http://www.ecy.wa.gov/services/gis/maps/wria/303d/303d.htm> (accessed May 19, 2009).
- 8 WDOE, "Office of Columbia River, Columbia River Basin Water Management Program," 2010
9 (2010a), Available URL: <http://www.ecy.wa.gov/programs/wr/cwp/crwmp.html> (accessed
10 October 14, 2010).
- 11 WDOE, "Water Resources, Water Rights," 2010 (2010b), Available URL:
12 <http://www.ecy.wa.gov/programs/wr/rights/water-right-home.html> (accessed October 14, 2010).
- 13 WDOE and WDOH, "Final Environmental Impact Statement for the Commercial Low-Level
14 Radioactive Waste Disposal Site, Richland, WA," DOH Publication 320-031, Olympia, WA,
15 2004.
- 16 Washington State Department of Health (WDOH), "Hanford Environmental Radiation Oversight
17 Program," 2011, Available URL:
18 <http://www.doh.wa.gov/ehp/rp/environmental/default.htm#hanfordover> (accessed July 28, 2011).
- 19 Welch, R.E., Energy Northwest, letter to J.P. Chasse, Energy Northwest, "Subject: Avian
20 Species List," August 18, 2009, ADAMS Accession No. ML102380288.
- 21 Whitlam, Rob, State Archaeologist, Washington State Historic Preservation Office (WSHPO),
22 letter to D.W. Coleman, Energy Northwest, "Columbia Generating Station License," July 29,
23 2010 (2010a), ADAMS Accession No. ML103280572.
- 24 Whitlam, Rob, State Archaeologist, WSHPO, letter to B.M. Pham, NRC, "Columbia Generating
25 Station License," March 29, 2010 (2010b), ADAMS Accession No. ML100900230.
- 26 Whitlam, Rob, State Archaeologist, WSHPO, letter to B.M. Pham, NRC, "Columbia Generating
27 Station License," April 21, 2010 (2010c), ADAMS Accession No. ML101160095.
- 28 Whitlam, Rob, State Archaeologist, WSHPO, letter to B.M. Pham, NRC, "Columbia Generating
29 Station License," December 1, 2010 (2010d), ADAMS Accession No. ML103350680.

5.0 ENVIRONMENTAL IMPACTS OF POSTULATED ACCIDENTS

This chapter describes the environmental impacts from postulated accidents that Columbia Generating Station (CGS) might experience during the period of extended operation. Appendix F contains a more detailed discussion of this assessment. The term “accident” refers to any unintentional event outside the normal plant operational envelope that results in a release or the potential for release of radioactive materials into the environment. Two classes of postulated accidents are evaluated in the generic environmental impact statement (GEIS), as listed in Table 5.1-1. These two classes include the following:

- design basis accidents (DBAs)
- severe accidents

Table 5.1-1. Issues related to postulated accidents

Two issues related to postulated accidents are evaluated under the National Environmental Policy Act (NEPA) in the license renewal review: DBAs and severe accidents.

| Issues | GEIS section | Category |
|------------------|---|----------|
| DBAs | 5.3.2; 5.5.1 | 1 |
| Severe accidents | 5.3.3; 5.3.3.2; 5.3.3.3; 5.3.3.4; 5.3.3.5; 5.4; 5.5.2 | 2 |

5.1 DBAs

In order to receive NRC approval to operate a nuclear power plant, an applicant for an initial operating license (OL) must submit a safety analysis report (SAR) as part of its application. The SAR presents the design criteria and design information for the proposed reactor and comprehensive data on the proposed site. The SAR also discusses various hypothetical accident situations and the safety features that prevent and mitigate accidents. The NRC staff (staff) reviews the application to determine if the plant design meets the NRC’s regulations and requirements and includes, in part, the nuclear plant design and its anticipated response to an accident.

DBAs are those accidents that both the licensee and the staff evaluate to ensure that the plant can withstand normal and abnormal transients and a broad spectrum of postulated accidents, without undue hazard to the health and safety of the public. Many of these postulated accidents are not expected to occur during the life of the plant but are evaluated to establish the design basis for the preventive and mitigative safety systems of the nuclear power plant. Title 10 of the *Code of Federal Regulations* (10 CFR) Part 50 and 10 CFR Part 100 describe the acceptance criteria for DBAs.

The environmental impacts of DBAs are evaluated during the initial licensing process, and the ability of the nuclear power plant to withstand these accidents is demonstrated to be acceptable before issuance of the OL. The results of these evaluations are found in license documentation such as the applicant's final safety analysis report (FSAR), the staff's safety evaluation report (SER), the final environmental statement (FES), and Section 5.1 of this supplemental environmental impact statement (SEIS). A licensee is required to maintain the acceptable design and performance criteria throughout the life of the nuclear power plant, including any extended-life operation. The consequences for these events are evaluated for the hypothetical maximum exposed individual. Because of the requirements that continuous acceptability of the

Environmental Impacts of Postulated Accidents

1 consequences and aging management programs be in effect for license renewal, the
2 environmental impacts, as calculated for DBAs, should not differ significantly from initial
3 licensing assessments over the life of the nuclear power plant, including the license renewal
4 period. Accordingly, the design of the nuclear power plant, relative to DBAs during the
5 extended period, is considered to remain acceptable; therefore, the environmental impacts of
6 those accidents were not examined further in the GEIS.

7 The Commission has determined that the environmental impacts of DBAs are of SMALL
8 significance for all nuclear power plants because the plants were designed to successfully
9 withstand these accidents. Therefore, for the purposes of license renewal, DBAs are
10 designated as a Category 1 issue in 10 CFR Part 51, Subpart A, Appendix B, Table B-1. The
11 early resolution of the DBAs makes them a part of the current licensing basis (CLB) of the plant;
12 the CLB of the plant is to be maintained by the licensee under its current license and, therefore,
13 under the provisions of 10 CFR 54.30, is not subject to review under license renewal. This
14 issue is applicable to CGS.

15 Based on information in the GEIS, the NRC found that "[t]he environmental impacts of design
16 basis accidents are of small significance for all plants."

17 Energy Northwest (EN) stated in its environmental report (ER) (EN, 2010a) that it is not aware
18 of any new and significant information related to DBAs associated with the renewal of the CGS
19 OL. The staff has not noted any new and significant information during its independent review
20 of the Energy Northwest ER, the scoping process, the staff's site visit, or its evaluation of other
21 available information. Therefore, the staff concludes that there are no impacts related to DBAs,
22 beyond those discussed in the GEIS.

23 **5.2 Severe Accidents**

24 Severe nuclear accidents are those that are more severe than DBAs because they could result
25 in substantial damage to the reactor core, whether or not there are serious offsite
26 consequences. In the GEIS, the staff assessed the effects of severe accidents during the
27 period of extended operation, using the results of existing analyses and site-specific information
28 to conservatively predict the environmental impacts of severe accidents for each plant during
29 the period of extended operation.

30 Severe accidents initiated by external phenomena such as tornadoes, floods, earthquakes,
31 fires, and sabotage have not traditionally been discussed in quantitative terms in FESs and
32 were not specifically considered for CGS in the GEIS. However, the GEIS did evaluate existing
33 impact assessments—performed by the staff and by the industry at 44 nuclear power plants in
34 the U.S.—and concluded that the risk from beyond design-basis earthquakes at existing nuclear
35 power plants is SMALL. The GEIS for license renewal performed a discretionary analysis of
36 sabotage, in connection with license renewal, and concluded that the core damage and
37 radiological release from such acts would be no worse than the damage and release expected
38 from internally-initiated events. In the GEIS, the NRC concludes that the risk from sabotage at
39 existing nuclear power plants is SMALL and, additionally, that the risks from other external
40 events are adequately addressed by a generic consideration of internally-initiated severe
41 accidents (NRC, 1996). Section 5.2.1 of this chapter gives a more detailed discussion of severe
42 accidents initiated by terrorism associated with license renewal.

1 Based on information in the GEIS, the NRC noted the following:

2 The probability weighted consequences of atmospheric releases, fallout onto
3 open bodies of water, releases to groundwater, and societal and economic
4 impacts from severe accidents are small for all plants. However, alternatives to
5 mitigate severe accidents must be considered for all plants that have not
6 considered such alternatives.

7 The staff found no new and significant information related to postulated accidents during the
8 review of Energy Northwest's ER (EN, 2010a), the site visit, the scoping process, or evaluation
9 of other available information. Therefore, there are no impacts related to these issues, beyond
10 those discussed in the GEIS. However, in accordance with 10 CFR 51.53(c)(3)(ii)(L), the staff
11 reviewed severe accident mitigation alternatives (SAMAs) for CGS. Section 5.3 discusses the
12 results of the review.

13 **5.2.1 Severe Accidents Initiated by Sabotage and Terrorism**

14 **5.2.1.1 Background**

15 Generic Finding for Sabotage and Terrorism for License Renewal of Nuclear Power Plants. The
16 1996 GEIS for License Renewal of Nuclear Plants (NUREG-1437) addresses environmental
17 impact of terrorist acts. Section 5.3.3.1 of the GEIS states the following:

18 Although the threat of sabotage events cannot be accurately quantified, the
19 Commission believes that acts of sabotage are not reasonably expected.
20 Nonetheless, if such events were to occur, the Commission would expect that
21 resultant core damage and radiological releases would be no worse than those
22 expected from internally initiated events.

23 Based on this statement, the NRC concluded in the GEIS that the risk from sabotage at existing
24 nuclear power plants is small.

25 Implications of 9/11. As a result of the terrorist attacks of September 11, 2001, (9/11) the NRC
26 carried out a comprehensive review of the agency's security program and required significant
27 enhancements to security at a wide range of NRC-regulated facilities. These enhancements
28 included significant reinforcement of the security response capabilities for nuclear facilities,
29 better control of sensitive information, and implementation of mitigating strategies to deal with
30 postulated events potentially causing loss of large areas of the plant due to explosions or fires,
31 including those that an aircraft impact might create. These measures are outlined in greater
32 detail in NUREG/BR-0314 (NRC, 2004), NUREG-1850 (NRC, 2006a), and Sandia National
33 Laboratory's "Mitigation of Spent Fuel Loss-of-Coolant Inventory Accidents and Extension of
34 Reference Plant Analyses to Other Spent Fuel Pools" (NRC, 2006b).

35 The NRC continues to routinely assess threats and other information from a variety of Federal
36 agencies and sources. The NRC also ensures that licensees meet appropriate security-level
37 requirements. The NRC will continue to focus on the prevention of terrorist acts for all nuclear
38 facilities and will not focus on site-specific evaluations of speculative environmental impacts
39 resulting from terrorist acts. While these are legitimate matters of concern, the NRC will
40 continue to address them through the ongoing regulatory process as a current and generic
41 regulatory issue that affects all nuclear facilities and many of the activities carried out at nuclear
42 facilities. The issue of security and risk from malevolent acts at nuclear power facilities is not
43 unique to facilities that have requested a renewal of their licenses (NRC, 2006a).

1 Implications of NRC Licensing Actions Located in the Jurisdiction of the U.S. Court of Appeals
2 for the Ninth Circuit. The NRC has stated that licensing actions for facilities subject to the
3 jurisdiction of the U.S. Court of Appeals for the Ninth Circuit will include an analysis of the
4 environmental impacts of a terrorist attack (*San Luis Obispo Mothers for Peace v. NRC*,
5 449 F.3d 1016, 1028 (9th Cir. 2006)).

6 **5.2.1.2 Security Requirements and Federal and Industry Actions in Response to**
7 **September 11, 2001**

8 General Security Considerations. The NRC has historically considered the potential impacts of
9 sabotage and terrorist acts in the development and implementation of its security requirements.
10 Nuclear power plants are among the most secure commercial facilities in the country. Nuclear
11 power plant security is achieved in layers as described below:

- 12 • Nuclear power plants are inherently secure, robust structures, built to withstand
13 hurricanes, tornadoes and earthquakes. Nuclear power plants have redundant safety
14 systems and multiple barriers to protect the reactor and prevent or minimize offsite
15 releases.
- 16 • Security measures are in place including, but not limited to, trained and armed security
17 officers, physical barriers, intrusion detection and surveillance systems, and access
18 control features. These measures are routinely inspected and evaluated via
19 force-on-force exercises.
- 20 • An additional layer of protection involves coordinating threat information and offsite
21 response. The NRC works closely with the Department of Homeland Security, Federal
22 Bureau of Investigation, intelligence agencies, the Department of Defense, Department
23 of Energy (DOE), states, and local law enforcement. These relationships ensure that the
24 NRC can act quickly on any threats that might affect its licensed facilities and allows
25 effective emergency response from “outside the fence” should a terrorist attack occur
26 (NRC, 2004).

27 Federal and Industry Actions in Response to 9/11. Since 9/11, detailed assessments were
28 done, a spectrum of measures was evaluated to reduce the likelihood or consequences of
29 terrorist attacks, and additional requirements were issued to prevent or mitigate the
30 consequences of acts of sabotage or terrorism. The scope of the threats considered,
31 assessments done, and additional regulatory requirements include the following, among other
32 issues:

- 33 • ground-based, water-based, cyber-based, and air-based attacks
- 34 • reactor, containment, and spent fuel
- 35 • generic communications, orders, license conditions, and new regulations and rules

36 The following is a brief discussion of some post-9/11 studies, strengthened security
37 requirements, and enhanced liaison with Federal, State and local agencies.

38 NRC Studies. The NRC carried out detailed site-specific engineering studies of a limited
39 number of nuclear power plants to assess potential vulnerabilities to deliberate attacks involving
40 large commercial aircraft. The NRC also assessed the potential effects of other types of
41 terrorist attacks. In doing these studies, the NRC drew on national experts from several DOE
42 laboratories using state-of-the-art experiments, structural analyses, and fire analyses. While the

1 details are classified, the studies confirmed that the plants are robust, and the likelihood of a
2 radioactive release affecting public health and safety is very low.

3 Another study analyzed the ability of nuclear power plants to withstand damage to, or loss of,
4 large areas of the plant caused by a range of postulated attacks that could result in large fires
5 and explosions. After examining many emergency scenarios involving operating reactors, spent
6 fuel pools (SFPs) and dry-cask storage installations, the NRC concluded that the existing
7 planning basis used to develop nuclear power plant emergency plans remains valid, and it is
8 confident that the public near those facilities can be adequately protected should an attack
9 occur.

10 As part of these analyses, enhancements were identified, and the NRC ordered changes at
11 nuclear power plants. Moreover, based on insights from these studies, industry best practices,
12 and lessons-learned from the response to the attacks of September 11, 2001, additional
13 mitigating capabilities have been put in place at all nuclear power plants (NRC, 2008b).

14 Strengthened Security Requirements. After consideration of terrorist actions, the NRC
15 strengthened security requirements at nuclear power plants. Major NRC actions included the
16 following (NRC, 2008b):

- 17 • ordering plant owners to sharply increase physical security programs to defend against a
18 more challenging adversarial threat
- 19 • requiring more restrictive site access controls for all personnel
- 20 • enhancing communication and liaison with the intelligence community
- 21 • ordering plant owners to improve their capability to respond to events involving
22 explosions or fires
- 23 • enhancing readiness of security organizations by strengthening training and
24 qualifications programs for plant security forces
- 25 • requiring vehicle checks at greater stand-off distances
- 26 • enhancing force-on-force exercises to provide a more realistic test of plant capabilities to
27 defend against an adversary force
- 28 • improving liaison with Federal, State, and local agencies responsible for protection of the
29 national critical infrastructure through integrated response training

30 NRC also issued additional security-related regulations including those listed below:

- 31 • a revision to the design basis threat rule in 2007 to impose generic security requirements
32 similar to those previously imposed on operating nuclear power plants by the NRC's
33 April 29, 2003, design basis threat orders (72 FR 12705)
- 34 • issuance of a new Power Reactor Security Requirements rule in 2009 to establish and
35 update generically applicable security requirements for power reactors—similar to those
36 previously imposed by several NRC orders issued after 9/11—including security
37 requirements for ground-based, water-based, cyber-based, and air-based attacks
38 (74 FR 13926)

39 Enhanced Government-to-Government Coordination. The NRC continues to work with other
40 Governmental agencies to assure consistency and effectiveness in thwarting a potential attack

Environmental Impacts of Postulated Accidents

1 on a nuclear power plant. For example, the NRC has worked with the Transportation Security
2 Administration and the Federal Aviation Administration to develop guidance for general aviation
3 pilots flying near nuclear power plants. The Transportation Security Administration has initiated
4 some other programs to reduce the likelihood that an aircraft could be used to attack any type of
5 facility in the United States. Some of these programs are listed below (NRC, 2008a):

- 6 • criminal history checks on flight crew members
- 7 • reinforced cockpit doors
- 8 • checking of passenger lists against “no-fly” lists
- 9 • increased control of cargo
- 10 • random inspections
- 11 • increased number of Federal Air Marshals
- 12 • improved screening of passengers and baggage
- 13 • controls on foreign airlines operating to and from the U.S.
- 14 • additional requirements for charter aircraft
- 15 • improved coordination and communication between civilian and military authorities

16 Plant-Specific Actions in Response to 9/11. Following the events of 9/11, the NRC issued more
17 robust security requirements, as discussed above, and the NRC routinely verifies that CGS
18 complies with those requirements. Thus, it is highly unlikely that an adversary force could
19 successfully overcome these security measures and gain entry into the sensitive facilities, and it
20 is even less likely that they could do this quickly enough to prevent operators from placing the
21 plant's reactor into a safe shutdown mode.

22 Multiple plant-specific assessments, with respect to potential malevolent acts, have been and
23 will continue to be completed for CGS. An example of an on-going, plant-specific evaluation is
24 the periodic NRC security inspections at CGS that occur as part of operating reactor oversight.
25 In response to these evaluations, many enhancements were carried out at CGS. Examples of
26 resulting enhancements, stemming from the various assessments completed, include the
27 following:

- 28 • plant hardware changes
- 29 • improved maintenance, testing, and calibration of security equipment
- 30 • improved training for both security and non-security personnel
- 31 • improved procedures in emergency planning and safeguards contingency planning

32 An example of a post-9/11 industry-wide initiative to enhance nuclear power plant security and
33 how it was addressed at CGS is given below (the "B.5.b" mitigation strategies).

34 Mitigation Strategies for Reactor, Containment, and SFPs (B.5.b). An Interim Compensatory
35 Measures (ICM) Order was issued February 25, 2002, as part of a comprehensive effort by the
36 NRC, in coordination with other Government agencies, to improve the capabilities of commercial
37 nuclear reactor facilities to respond to terrorist threats. Section B.5.b of the ICM Order required
38 licensees to develop specific guidance and strategies to maintain or restore core cooling,
39 containment, and SFP cooling capabilities—using existing or readily available resources
40 (equipment and personnel)—that could be effectively carried out under the circumstances
41 associated with loss of large areas of the plant due to explosions or fire, including those that a
42 large aircraft impact might create. Although it was recognized before 9/11 that nuclear power
43 plants already had significant capabilities to withstand a broad range of attacks, carrying out
44 these mitigation strategies significantly enhances the nuclear power plants' capabilities to
45 withstand a broad range of threats (NRC, 2007).

1 The staff carried out inspections of the implementation of the Section B.5.b requirements
2 in 2002 and 2003. Next, engineering studies were done by the NRC, supplying insight into the
3 implementation of mitigation strategies. In 2005, additional guidance was issued by the NRC
4 establishing a phased approach for responding to Section B.5.b of the February 25, 2002, ICM
5 Order. Determination of the specific strategies required to satisfy the Order was termed
6 Phase 1. Site-specific assessments of SFPs were deemed Phase 2, and site-specific
7 assessments of reactor core and containment were deemed Phase 3. During 2005 and 2006,
8 the NRC staff performed Phase 1 inspections and Phases 2 and 3 assessments (NRC, 2007).

9 The NRC staff's technical evaluation for CGS is described in a publicly-available SER
10 (NRC, 2007). The NRC staff concluded that CGS's responses to the February 25, 2005, Phase
11 1 guidance document and the Phases 2 and 3 SFP and reactor core and containment mitigating
12 strategy assessments meet the requirements of Section B.5.b of the February 25, 2002, ICM
13 Order. Additionally, the staff concluded that full implementation of Energy Northwest's
14 enhancements constitutes satisfactory compliance with Section B.5.b and that they represent
15 reasonable measures to enhance Energy Northwest's effectiveness in maintaining reactor core
16 and SFP cooling and containment integrity under circumstances involving the loss of large
17 areas of the plant due to fires or explosions.

18 The requirements for the B.5.b mitigating strategies were incorporated into the facility OL for
19 CGS. The effectiveness of Energy Northwest's actions to implement the mitigative strategies
20 implemented in response to the ICM Order (which were subsequently codified in
21 10 CFR 50.54(hh)(2)) is subject to NRC review and inspection.

22 **5.2.1.3 Consideration of Environmental Impacts from Sabotage or Terrorist Acts**

23 In describing the potential for environmental impacts from terrorist activities, a description of the
24 relevant terminology is necessary and includes four broad topics: threat, vulnerability, frequency
25 of malevolent acts, and consequences.

26 Threat. A threat is considered present when an organization or person has the intent and
27 capability to cause damage to a target.

28 NRC currently assesses that there is a general, credible threat to NRC-licensed facilities and
29 materials, although there is no specific information available that shows a specific threat to
30 nuclear power plant facilities.

31 Vulnerability. Vulnerability, in this context, refers to a weakness in physical protection or
32 mitigation capabilities, which can lead to unacceptable consequences. Vulnerabilities are
33 specific to the type of attack.

34 Frequency of Malevolent Acts. With regard to the frequency of malevolent acts, the NRC has
35 determined that security and mitigation measures the NRC has imposed upon its licensees
36 since 9/11 coupled with national anti-terrorist measures and the robust nature of reactor
37 containments and SFPs, make the probability of a successful terrorist attack, though
38 numerically indeterminate, very low.

39 The security-related measures and other mitigation measures carried out since 9/11 include
40 actions that would improve the likelihood of finding and thwarting the attack before it is initiated,
41 mitigating the attack before it results in damage to the plant, and mitigating the impact of the
42 plant damage such that reactor core damage or an SFP fire is avoided. Given the
43 implementation of additional security enhancements and mitigation strategies, as well as further

Environmental Impacts of Postulated Accidents

1 consideration of the factors noted above, the NRC staff concludes that the frequency of large
2 radionuclide releases due to malevolent acts is very low.

3 Consequences. Consequences relate to the magnitude and type of effect from terrorist actions.
4 A range of consequences can result from sabotage and malevolent acts. Nuclear power plants
5 have many security measures and protective features that help to prevent or mitigate
6 consequences of potential terrorist attacks. Physical protection was described previously and
7 generally consists of the robust characteristics of the containment and SFP structures;
8 redundant safety systems; and additional security measures in place, including trained and
9 armed security officers, physical barriers, intrusion detection and surveillance systems.
10 Mitigating strategies have also been carried out to deal with postulated events potentially
11 causing loss of large areas of the plant due to explosions or fires, including those that an aircraft
12 impact might create.

13 Potential consequences are highly dependent on the type of attack or event scenario. Based on
14 the plant-specific, probabilistic risk assessment (PRA) for CGS (as summarized in Attachment E
15 to the ER), the reactor accidents with the highest offsite consequences at CGS are fairly equally
16 distributed among the four categories involving "large" releases of radionuclides outside the
17 containment, whether these releases occur "early" or "late" in the sequence (i.e., after core
18 damage) or are "scrubbed" or "non-scrubbed" prior to escaping from the containment. These
19 events result in release of a significant fraction of the reactor core radionuclide inventory to the
20 environment. Accident consequences are described in Table E.7-5 of Attachment E to the ER.

21 Although SFP accidents are not specifically addressed in the CGS ER, the consequences of the
22 most severe SFP accident, culminating in an SFP fire, were assessed in several previous NRC
23 studies to include the following:

24 NUREG-1353, "Regulatory Analysis for the Resolution of Generic Issue 82, "Beyond Design
25 Basis Accidents in Spent Fuel Pools," April 1989

26 NUREG-1738, "Technical Study of Spent Fuel Pool Accident Risk at Decommissioning Nuclear
27 Power Plants," January 2001

28 NUREG-1738 states that seismic hazard studies conducted by Lawrence Livermore National
29 Laboratories and the Electric Power Research Institute (EPRI) did not include western plants,
30 including CGS; however, its analysis addressed most power stations. Accident consequence
31 results are given in Table 4.8.3 of NUREG-1353 for site population densities of 340 persons per
32 square mile (reflective of the mean population density around all nuclear power plants in
33 year 2000) and 860 persons per square mile (reflective of a high population site). Given that the
34 projected 2045-population density within 50 miles (mi) of the CGS site is approximately
35 84 persons per square mile (based on a projected population of 655,617 reported in Table E.6-3
36 of Attachment E to the ER), these results are considered reasonably representative of CGS.

37 Potential consequences from malevolent acts against the CGS reactor or SFP would not
38 exceed those for a reactor or SFP accident and would likely be much less due to the need for
39 the adversaries to rapidly defeat physical protection and access controls, as well as the
40 redundant safety system functions. This would be extremely difficult given the significant
41 physical protection (e.g., robust containment and SFP structures, redundant safety systems,
42 and additional security measures) and the post-9/11 mitigating strategies to deal with postulated
43 events involving loss of large areas of the plant due to explosions or fires. Even if the physical
44 protection and mitigating strategies were only partially effective, these features and measures

1 would delay the time to core damage and radionuclide release and reduce the consequences of
2 any such release.

3 In the unlikely event that a terrorist attack did successfully breach the physical and other
4 safeguards at CGS, resulting in the release of radionuclides, the consequences of such a
5 release are discussed in the 1996 GEIS for license renewal. In the GEIS, the NRC considered
6 sabotage as the potential initiator of a severe accident. The NRC generically determined the
7 risk to be of SMALL significance for all nuclear power plants. The NRC's evaluation of the
8 potential environmental impacts of a terrorist attack, including the GEIS analysis of severe
9 accident consequences, considers the potential consequences that might result from a large-
10 scale radiological release, irrespective of the initiating cause.

11 **5.2.1.4 SAMAs for Sabotage or Terrorist Initiated Events**

12 The focus of the SAMA evaluation is on plant improvements (e.g., hardware, procedures, and
13 training) that would both substantially reduce plant risk and be cost-beneficial. Given that risk
14 from terrorist events is already reduced by carrying out post-9/11 existing security
15 enhancements and mitigation strategies, the staff considers it unlikely that there are any
16 additional enhancements that would both substantially reduce plant risk and be cost-beneficial.

17 **5.2.1.5 Consideration of SAMAs for SFPs**

18 GEIS Conclusions for SFP Accidents. The GEIS for license renewal gives a generic evaluation
19 of potential SFP accidents, encompassing the potentially most serious accident (a
20 seismically-generated accident causing catastrophic failure of the pool), and concludes that
21 there is no further need for a site-specific SFP accident or mitigation analysis for license
22 renewal. The GEIS concludes, without exception or qualification for any type of SFP accident,
23 that "regulatory requirements already in place provide adequate mitigation incentives for onsite
24 storage of spent fuel," and, therefore, mitigation alternatives for the SFP need not be considered
25 for the license renewal review. See GEIS at 6-86, 6-91, and 6-92.

26 Risk Associated with SFP Accidents. Risk is defined as the probability of the occurrence of a
27 given event multiplied by the consequences of that event. The risk of beyond-DBAs in SFPs
28 was first examined as part of the landmark "Reactor Safety Study: An Assessment of Accident
29 Risks in U.S. Commercial Nuclear Power Plants" (WASH-1400, NUREG-75/014, 1975), and
30 was found to be several orders of magnitude below those involving the reactor core. The risk of
31 an SFP accident was re-examined in the 1980s as Generic Issue 82, "Beyond Design Basis
32 Accidents in Spent Fuel Pools," in light of increased use of high-density storage racks and
33 laboratory studies that showed the possibility of zirconium fire propagation between assemblies
34 in an air-cooled environment. The risk assessment and cost-benefit analyses developed
35 through this effort, NUREG-1353, "Regulatory Analysis for the Resolution of Generic Issue 82,
36 Beyond Design Basis Accidents in Spent Fuel Pools," Section 6.2, April 1989, concluded that
37 the risk of a severe accident in the SFP was low and "appear[s] to meet" the objectives of the
38 NRC's "Safety Goals for the Operations of Nuclear Power Plants; Policy Statement,"
39 (August 4, 1986; 51 FR 28044), as amended (August 21, 1986; 51 FR 30028), and no new
40 regulatory requirements were warranted.

41 SFP accident risk was re-assessed in the late 1990s to support a risk-informed rulemaking for
42 permanently shutdown, or decommissioned, nuclear power plants. The study—NUREG-1738,
43 "Technical Study of Spent Fuel Pool Accident Risk at Decommissioning Nuclear Power Plants,"
44 January 2001—conservatively assumed that if the water level in the SFP dropped below the top
45 of the spent fuel, an SFP zirconium fire involving all of the spent fuel would occur. Therefore,

1 the study bounded those conditions associated with air-cooling of the fuel (including
2 partial-draindown scenarios) and fire propagation. Even when all events leading to the spent
3 fuel assemblies becoming partially or completely uncovered were assumed to result in an SFP
4 zirconium fire, the study found the risk of an SFP fire to be low and well within the NRC's safety
5 goals.

6 Several analyses done by Sandia National Laboratories since 9/11, collectively referred to in
7 this SEIS as the "Sandia studies," show that the risk of a successful terrorist attack (i.e., one
8 that results in an SFP zirconium fire) is very low. The Sandia studies include sensitive
9 security-related information and are not available to the public. The Sandia studies considered
10 spent fuel loading patterns and other aspects of a pressurized-water reactor SFP and a
11 boiling-water reactor SFP, including the role that the circulation of air plays in the cooling of
12 spent fuel. The Sandia studies showed that there may be a significant amount of time between
13 the initiating event (i.e., the event that causes the SFP water level to drop) and the spent fuel
14 assemblies becoming partially or completely uncovered. In addition, the Sandia studies showed
15 that for those hypothetical conditions where air cooling may not be effective in preventing a
16 zirconium fire (i.e., the partial drain down scenario), there is a significant amount of time
17 between the spent fuel becoming uncovered and the possible onset of such a zirconium fire,
18 giving a substantial opportunity for event mitigation. The Sandia studies, which address
19 relevant heat transfer and fluid flow mechanisms, also showed that air-cooling of spent fuel
20 would be sufficient to prevent SFP zirconium fires at a point much earlier following fuel offload
21 from the reactor than previously considered (e.g., in NUREG-1738). Thus, the fuel would be
22 more easily cooled, and the likelihood of an SFP fire would be reduced (FR 46207, Volume 73,
23 No. 154).

24 Additional mitigation strategies carried out after 9/11 enhance spent fuel coolability and the
25 potential to recover SFP water level and cooling before a potential SFP zirconium fire. The
26 Sandia studies also confirmed the effectiveness of these additional mitigation strategies to
27 maintain spent fuel cooling in the event the pool is drained, and its initial water inventory is
28 reduced or lost entirely. Based on this more recent information, and the implementation of
29 additional strategies following 9/11, the probability and the risk of an SFP zirconium fire initiation
30 is expected to be less than reported in NUREG-1738 and previous studies. In view of the
31 physical robustness of SFPs, the physical security measures, and SFP mitigation measures,
32 and based upon NRC site evaluations of every SFP in the U.S., the NRC has determined that
33 the risk of an SFP zirconium fire, whether caused by an accident or a terrorist attack, is very low
34 and less than that for a reactor accident.

35 The NRC and licensees' efforts to address SFP vulnerabilities through enhancements since
36 9/11 have focused on "readily available mitigation strategies," which are typically the most
37 cost-effective alternatives. The NRC's ongoing oversight of plant security and safety will
38 continue to include review of SFPs and, in some cases, may require changes associated with
39 SFPs.

40 **5.2.1.6 Conclusions Regarding Sabotage and Terrorism**

41 NRC's efforts to protect against terrorism, including efforts to evaluate potential options or
42 alternatives to reduce the likelihood or severity of a terrorist attack, will continue during the
43 current licensing period and any potential license renewal periods. The NRC staff's
44 consideration of terrorism is a matter of ongoing regulatory oversight and one that will continue
45 to be dealt with on a daily basis. Based on this and the many actions that have been taken
46 since, the NRC staff maintains the NRC's 1996 finding that, although the threat of terrorist or

1 sabotage events cannot be accurately quantified, acts of terrorism or sabotage are not
 2 reasonably expected and that even if such events were to occur, the resultant core damage and
 3 radiological releases would be no worse than those expected from internally-initiated events.

4 **5.3 SAMAs**

5 Pursuant to 10 CFR Section 51.53(c)(3)(ii)(L), license renewal applicants are required to
 6 consider alternatives to mitigate severe accidents if the staff has not previously evaluated
 7 SAMAs for the applicant’s plant in an environmental impact statement (EIS) or related
 8 supplement or in an environmental assessment. The purpose of this requirement is to ensure
 9 that plant changes (i.e., hardware, procedures, and training) with the potential for improving
 10 severe accident safety performance are identified and evaluated. SAMAs have not been
 11 previously considered by Energy Northwest, formerly known as Washington Public Power
 12 Supply System (WPPSS), for CGS; therefore, the remainder of Section 5.3 addresses those
 13 alternatives.

14 Energy Northwest submitted an assessment of SAMAs for CGS as part of the ER (EN, 2010a)
 15 based on what was then the most recently available CGS PRA. This was supplemented by a
 16 plant-specific offsite consequence analysis performed using the MELCOR Accident
 17 Consequence Code System 2 (MACCS2) (NRC, 1998) computer code and insights from the
 18 CGS individual plant examination (IPE) (Parrish, 1994) and individual plant examination of
 19 external events (IPEEE) (Parrish, 1995). In identifying and evaluating potential SAMAs, Energy
 20 Northwest considered SAMAs that addressed the major contributors to core damage frequency
 21 (CDF) and large early release frequency (LERF) at CGS, as well as a generic list of SAMA
 22 candidates for other operating reactor plants identified from other industry studies. Energy
 23 Northwest identified 150 potential SAMA candidates. This list was reduced to 28 SAMA
 24 candidates by eliminating the following SAMAs:

- 25 • SAMAs that are not applicable to CGS due to design differences or have already been
 26 implemented at CGS
- 27 • SAMAs that have estimated implementation costs that would exceed the dollar value
 28 associated with completely eliminating all severe accident risk at CGS
- 29 • SAMAs that are related to a non-risk significant system and, therefore, have a very low
 30 benefit
- 31 • SAMAs that were similar in nature and could be combined with another SAMA candidate

32 Energy Northwest assessed the costs and benefits associated with each of the remaining
 33 SAMA candidates and concluded in the ER that three of the candidate SAMAs evaluated are
 34 potentially cost-beneficial.

35 Based on its review, the U.S. Nuclear Regulatory Commission (NRC) issued requests for
 36 additional information (RAIs) to Energy Northwest (Doyle, 2010a), (Doyle, 2010b),
 37 (Doyle, 2010c), (Doyle, 2011). Energy Northwest’s responses addressed the NRC staff’s
 38 concerns and resulted in the identification of additional potentially cost-beneficial SAMAs
 39 (Gambhir, 2010), (Gambhir, 2011a), (Gambhir, 2011b).

40 **5.3.1 Risk Estimates for CGS**

41 Energy Northwest combined two distinct analyses to form the basis for the risk estimates used
 42 in the SAMA analysis—the CGS Level 1 and 2 probabilistic safety assessment (PSA) models,

Environmental Impacts of Postulated Accidents

1 which is an updated version of the IPE (Parrish, 1994) and a supplemental analysis of offsite
 2 consequences and economic impacts (essentially a Level 3 PRA model) developed specifically
 3 for the SAMA analysis. The SAMA analysis is based on the most recent CGS Level 1 and
 4 Level 2 PSA models available at the time of the ER, referred to as PSA Revision 6.2.
 5 Subsequently, in response to NRC staff RAIs, a sensitivity analysis of the SAMA results was
 6 provided based on the updated CGS PSA Revision 7.1 (Gambhir, 2011a), (Gambhir, 2011b).

7 The baseline CDF for the purposes of the SAMA evaluation, based on CGS PSA Revision 6.2,
 8 is approximately 4.8×10^{-6} per year for internal events (which includes internal flooding), 7.4×10^{-6}
 9 per year for fire events, and 5.2×10^{-6} per year for seismic events as determined from
 10 quantification of the Level 1 PSA models. The sensitivity analysis CDF, based on CGS PSA
 11 Revision 7.1, is approximately 7.4×10^{-6} per year for internal events, 1.4×10^{-5} per year for fire
 12 events, and 4.9×10^{-6} per year for seismic events (Gambhir, 2011a). For both the baseline and
 13 sensitivity analysis, the risk reduction benefits associated with internal, fire, and seismic events
 14 were separately estimated based on the internal events, fire, and seismic Level 1 and Level 2
 15 PSAs. Energy Northwest accounted for the potential risk reduction benefits associated with
 16 non-fire and non-seismic external events (e.g., high wind, external flood, and other (HFO)
 17 events) by multiplying the estimated benefits for internal events by a factor of 2 (i.e., the
 18 contribution from HFO events was assumed to be the same as that from internal events). The
 19 estimated SAMA benefits for internal events, fire events, seismic events, and non-fire and
 20 non-seismic external events were then summed to provide an overall benefit.

21 The following tables break down CDF by initiating event for internal events, fire compartments,
 22 and seismic damage sequences (SDSs), respectively. The results from both the baseline PSA
 23 model (Revision 6.2) and the sensitivity analysis PSA model (Revision 7.1) are provided. As
 24 shown in Table 5.3-1, events initiated by station blackout (SBO), internal flooding, and special
 25 initiators—such as loss of direct current (DC) and alternating current (AC) buses, loss of
 26 heating, ventilation and air conditioning (HVAC), and loss of service water (SW) and air
 27 systems—are the dominant contributors to the internal event CDF for CGS PSA Revision 6.2.
 28 The dominant contributors to internal event CDF for CGS PSA Revision 7.1 are internal
 29 flooding, anticipated transients without scram (ATWS), loss of feedwater, and manual shutdown.
 30 As shown in Table 5.3-2, the dominant contributors to fire CDF are fires in the radwaste building
 31 for both CGS PSA Revisions 6.2 and 7.1. As shown in Table 5.3-3, the dominant contributors to
 32 seismic CDF are structural failures of the reactor pressure vessel (RPV) or Category 1 buildings
 33 or both and wide-spread failure of safe shutdown equipment list (SSEL) equipment for both
 34 CGS PSA Revisions 6.2 and 7.1.

35

Table 5.3-1. CGS CDF for internal events

| Initiating event | PSA Model Revision 6.2 | | PSA Model Revision 7.1 | |
|------------------------------|------------------------|--------------------------------------|------------------------|--------------------------------------|
| | CDF (per year) | % contribution to CDF ^(a) | CDF (per year) | % contribution to CDF ^(b) |
| SBO | 1.6×10^{-6} | 33 | 1.3×10^{-7} | 2 |
| Internal flooding | 7.4×10^{-7} | 15 | 2.3×10^{-6} | 31 |
| Special initiators | 7.2×10^{-7} | 15 | 3.0×10^{-7} | 4 |
| Loss-of-offsite power (LOOP) | 3.0×10^{-7} | 6 | 9.3×10^{-8} | 1 |
| RPV rupture | 3.0×10^{-7} | 6 | 1.0×10^{-8} | <1 |
| Loss of condenser | 2.2×10^{-7} | 5 | 3.7×10^{-7} | 5 |

Environmental Impacts of Postulated Accidents

| Initiating event | PSA Model Revision 6.2 | | PSA Model Revision 7.1 | |
|---|------------------------|--------------------------------------|------------------------|--------------------------------------|
| | CDF (per year) | % contribution to CDF ^(a) | CDF (per year) | % contribution to CDF ^(b) |
| Inadvertent/stuck open main steam safety relief valve | 2.1x10 ⁻⁷ | 4 | 8.3x10 ⁻⁸ | 1 |
| Loss of feedwater | 1.9x10 ⁻⁷ | 4 | 7.2x10 ⁻⁷ | 10 |
| Steam line break outside containment | 1.5x10 ⁻⁷ | 3 | 5.8x10 ⁻⁷ | 8 |
| Manual shutdown | 1.3x10 ⁻⁷ | 3 | 7.9x10 ⁻⁷ | 10 |
| Turbine trip | 1.2x10 ⁻⁷ | 2 | 1.5x10 ⁻⁷ | 2 |
| ATWS | 8.4x10 ⁻⁸ | 2 | 1.4x10 ⁻⁶ | 19 |
| Main steam isolation valve (MSIV) closure | 4.6x10 ⁻⁸ | 1 | 3.6x10 ⁻⁷ | 5 |
| Loss-of-coolant accidents (LOCAs) | 4.8x10 ⁻⁹ | <1 | 2.0x10 ⁻⁷ | 3 |
| Total CDF (internal events) ^(c) | 4.8x10 ⁻⁶ | 100 | 7.4x10 ⁻⁶ | 100 |

^(a) This is based on internal event CDF contribution in ER Table E.3-3 (EN, 2010a) and total internal event CDF.

^(b) This is based on internal event CDF contribution in Table A-1 of the responses to NRC staff RAIs (Gambhir, 2011a) and total internal event CDF.

^(c) Columns may not sum to reported totals due to round off.

Table 5.3-2. Important CGS fire compartments and their contribution to fire CDF

| Fire compartment | PSA Model Revision 6.2 | | PSA Model Revision 7.1 | |
|---|------------------------|--------------------------------------|------------------------|--------------------------------------|
| | CDF (per year) | % contribution to CDF ^(a) | CDF (per year) | % contribution to CDF ^(a) |
| R1J: Reactor Building 522 ^(c) | 1.2x10 ⁻⁶ | 16 | ≤1.2x10 ⁻⁶ | ≤9 |
| W14: Radwaste 467' Switchgear Room 1 | 1.0x10 ⁻⁶ | 14 | 1.4x10 ⁻⁶ | 10 |
| W04: Radwaste 467' electrical equipment room | 8.4x10 ⁻⁷ | 11 | 1.7x10 ⁻⁶ | 12 |
| R1D: Northeast Reactor Building 471 ^(c) | 7.4x10 ⁻⁷ | 10 | ≤7.4x10 ⁻⁷ | ≤5 |
| W11: Radwaste A/C Room ^(c) | 7.3x10 ⁻⁷ | 10 | ≤7.3x10 ⁻⁷ | ≤5 |
| W03: Radwaste 467' cable chase | 4.5x10 ⁻⁷ | 6 | 9.4x10 ⁻⁷ | 7 |
| W08: Radwaste 467' Switchgear Room 2 | 3.6x10 ⁻⁷ | 5 | 9.7x10 ⁻⁷ | 7 |
| Y01: Transformer Yard ^(c) | 3.2x10 ⁻⁷ | 4 | ≤3.2x10 ⁻⁷ | ≤2 |
| W10: Radwaste Main Control Room ^(c) | 3.0x10 ⁻⁷ | 4 | ≤3.0x10 ⁻⁷ | ≤2 |
| W05: Radwaste 467' Battery Room 1 | 2.5x10 ⁻⁷ | 3 | 3.2x10 ⁻⁷ | 2 |
| W02: Radwaste cable spreading room | 2.2x10 ⁻⁷ | 3 | 4.4x10 ⁻⁷ | 3 |
| W13: Radwaste 525' emergency chiller | 2.0x10 ⁻⁷ | 3 | 4.9x10 ⁻⁷ | 4 |
| T1A: Turbine Generator West 441' | 1.6x10 ⁻⁷ | 2 | 2.9x10 ⁻⁷ | 2 |
| T12: Turbine Generator South Corridors ^(c) | 1.3x10 ⁻⁷ | 2 | ≤1.3x10 ⁻⁷ | ≤1 |
| W1A: Radwaste Building 441' | 1.2x10 ⁻⁷ | 2 | 4.4x10 ⁻⁷ | 3 |

Environmental Impacts of Postulated Accidents

| Fire compartment | PSA Model Revision 6.2 | | PSA Model Revision 7.1 | |
|--|------------------------|--------------------------------------|------------------------|--------------------------------------|
| | CDF (per year) | % contribution to CDF ^(a) | CDF (per year) | % contribution to CDF ^(a) |
| W07: Radwaste 467' Division 2 electrical | 9.0x10 ⁻⁸ | 1 | 1.7x10 ⁻⁶ | 12 |
| R1B: Northwest Reactor Building 471' | 5.8x10 ⁻⁸ | <1 | 1.6x10 ⁻⁷ | 1 |
| T1C: Turbine Generator East 441' | 5.2x10 ⁻⁸ | <1 | 1.3x10 ⁻⁶ | 9 |
| T1D: Turbine Generator West 471' | 4.9x10 ⁻⁸ | <1 | 1.6x10 ⁻⁷ | 1 |
| R1C: Southeast Reactor Building 471' | 2.0x10 ⁻⁸ | <1 | 3.9x10 ⁻⁷ | 3 |
| R1L: Reactor Building 572' | 3.3x10 ⁻⁹ | <1 | 2.4x10 ⁻⁷ | 2 |
| Total fire CDF ^(b) | 7.4x10 ⁻⁶ | 100 | 1.4x10 ⁻⁵ | 100 |

^(a)This is based on fire CDF contribution in Table A-1 of the responses to NRC staff RAIs (Gambhir, 2011a) and total fire CDF.

^(b)Columns may not sum to reported totals due to round off or assumptions about bounding values for selected compartments in PSA Revision 7.1 (see footnote 3).

^(c)Only fire CDF contributions for compartments that increased by at least 1 percent from PSA Revision 6.2 were provided for Revision 7.1. Contributions for these others remaining from Revision 6.2 are shown as bounding values, based on their previous contributions in Revision 6.2, since it was reported that none increased by more than 1 percent.

Table 5.3-3. Important SDSs and their contribution to seismic CDF

| SDS sequence | SDS sequence description | PSA Model Revision 6.2 | | PSA Model Revision 7.1 | |
|--------------|--|------------------------|--------------------------------------|------------------------|--------------------------------------|
| | | CDF (per year) | % contribution to CDF ^(a) | CDF (per year) | % contribution to CDF ^(a) |
| SDS42 | Failure of RPV or Category I buildings or both | 2.4x10 ⁻⁶ | 46 | 2.4x10 ⁻⁶ | 49 |
| SDS41 | Wide-spread failure of safety SSEL equipment | 1.6x10 ⁻⁶ | 31 | 1.6x10 ⁻⁶ | 33 |
| S2P2 | Balance of plant (BOP), condensate storage tank (CST), LOOP, small-small LOCA | 2.3x10 ⁻⁷ | 4 | 1.2x10 ⁻⁷ | 2 |
| S624 | LOOP, small-small LOCA, and Division 1 & 2 AC distribution, BOP, and CST failure | 2.2x10 ⁻⁷ | 4 | 9.0x10 ⁻⁸ | 2 |
| SDS4 | BOP, CST, LOOP, small-small LOCA, diesel generator (DG) 1 & 2 | 1.8x10 ⁻⁷ | 3 | 8.2x10 ⁻⁸ | 2 |
| S523 | BOP, CST, LOOP, nitrogen (N ₂) tank, small-small LOCA, DG 1 & 2, Division III | 1.3x10 ⁻⁷ | 2 | 1.4x10 ⁻⁷ | 3 |
| SLAC | BOP, CST, LOOP, N ₂ tank, medium LOCA, Division I & II, Division III, offsite AC not recoverable | 1.1x10 ⁻⁷ | 2 | 1.1x10 ⁻⁷ | 2 |
| S725 | BOP, CST, LOOP, N ₂ Tank, small-small LOCA, Division I & II, Division III, offsite AC not recoverable | 1.0x10 ⁻⁷ | 2 | 1.0x10 ⁻⁷ | 2 |

Environmental Impacts of Postulated Accidents

| SDS sequence | SDS sequence description | PSA Model Revision 6.2 | | PSA Model Revision 7.1 | |
|----------------------------------|---|------------------------|--------------------------------------|------------------------|--------------------------------------|
| | | CDF (per year) | % contribution to CDF ^(a) | CDF (per year) | % contribution to CDF ^(a) |
| SDS22 | BOP, CST, LOOP, N ₂ tank, small-small LOCA, DG 1 & 2 | 6.2x10 ⁻⁸ | 1 | 2.8x10 ⁻⁸ | 1 |
| SDS38 | BOP, CST, LOOP, N ₂ tank, DGs stalled and not restarted | 5.8x10 ⁻⁸ | 1 | 9.5x10 ⁻⁸ | 2 |
| S1836 | BOP, CST, LOOP, N ₂ tank, medium LOCA, Division I & II, offsite AC not recoverable | 2.0x10 ⁻⁸ | <1 | 8.1x10 ⁻⁹ | <1 |
| S1230 | BOP, CST, LOOP, N ₂ tank, small LOCA (SLOCA), Division I & II, offsite AC not recoverable | 1.8x10 ⁻⁸ | <1 | 7.4x10 ⁻⁹ | <1 |
| S1129 | BOP, CST, LOOP, N ₂ tank, SLOCA, DG 1 & 2, Division III | 1.6x10 ⁻⁸ | <1 | 1.8x10 ⁻⁸ | <1 |
| S1331 | BOP, CST, LOOP, N ₂ tank, SLOCA, Division I & II, Division III, offsite AC not recoverable | 1.6x10 ⁻⁸ | <1 | 1.6x10 ⁻⁸ | <1 |
| Other | | 8.6x10 ⁻⁸ | 2 | 9.0x10 ⁻⁸ | 2 |
| Total seismic CDF ^(b) | | 5.3x10 ⁻⁶ | 100 | 4.9x10 ⁻⁶ | 100 |

^(a) This is based on seismic CDF contribution in Table A-1 of the responses to NRC staff RAIs (Gambhir, 2011a) and total seismic CDF.

^(b) Columns may not total to reported totals due to round off.

1 The Level 2 CGS PSA models that form the basis for the SAMA evaluation is an updated
2 versions of the Level 2 IPE model (Parrish, 1994) and IPEEE model (Parrish, 1995), linked to
3 the Level 1 model by assigning each Level 1 core damage sequence to a plant damage state
4 (PDS). The Level 1 core damage sequences are binned into 21 PDSs for internal and fire
5 events and 12 PDSs for seismic events. The Level 2 model uses a set of containment event
6 trees (CETs), one for each PDS, containing both phenomenological and systemic events, and
7 subsequently assigns the PDSs to release categories. Source terms were developed for each
8 of the 13 release categories (four in the baseline and nine in the sensitivity analysis) using the
9 results of Modular Accident Analysis Program (MAAP) computer code calculations. The offsite
10 consequences and economic impact analyses use the MACCS2 code to determine the offsite
11 risk impacts on the surrounding environment and public. Inputs for these analyses include the
12 following:

- 13 • plant-specific and site-specific input values for core radionuclide inventory
- 14 • source term and release characteristics
- 15 • site meteorological data
- 16 • projected population distribution within an 80-kilometer (km) (50-mi) radius for the year
17 2045
- 18 • emergency response evacuation modeling
- 19 • economic data

20 The core radionuclide inventory corresponds to the end-of-cycle values for CGS operating at
21 3,486 megawatts thermal (MWt). The magnitude of the onsite impacts (in terms of clean-up and

Environmental Impacts of Postulated Accidents

1 decontamination costs and occupational dose) is based on information provided in
 2 NUREG/BR-0184 (NRC, 1997a).

3 Energy Northwest estimated the dose to the population within 80 km (50 mi) of the CGS site to
 4 be approximately 0.037 person-Sievert (Sv) (3.7 person-roentgen equivalent man (rem)) per
 5 year for internal events, 0.086 person-Sv (8.6 person-rem) per year for fire events, and 0.067
 6 person-Sv (6.7 person-rem) per year for seismic events. This equals a total population dose
 7 from internal and external events of 0.190 person-Sv (19.0 person-rem) per year for the
 8 baseline analysis using CGS PSA Revision 6.2. In response to NRC staff RAIs, Energy
 9 Northwest estimated the dose to the population within 80 km (50 mi) of the CGS site to be
 10 approximately 0.055 person-Sv (5.5 person-rem) per year for internal events, 0.090 person-Sv
 11 (9.0 person-rem) per year for fire events, and 0.059 person-Sv (5.9 person-rem) per year for
 12 seismic events. This equals a total population dose from internal and external events of 0.204
 13 person-Sv (20.4 person-rem) per year for the sensitivity analysis using CGS PSA Revision 7.1.
 14 Both sets of results are shown in Table 5.3-4 and Table 5.3-5. For PSA Revision 6.2, large,
 15 late, not-scrubbed release is the dominant contributor to the population dose risk at CGS for all
 16 three hazard types. For Revision 7.1, moderate and intermediate release is the dominant
 17 contributor to the population dose risk at CGS for internal and fire events while high/early
 18 release (H/E) is the dominant contributor to population dose risk for seismic events.

19 **Table 5.3-4. Breakdown of population dose by containment release mode for PSA**
 20 **Revision 6.2**

| Containment release mode | Internal events | | Fire events | | Seismic events | |
|----------------------------------|---|-------------------------------|---|-------------------------------|---|-------------------------------|
| | Pop. dose (person-rem/yr ^(a)) | % contribution ^(a) | Pop. dose (person-rem/yr ^(a)) | % contribution ^(b) | Pop. dose (person-rem/yr ^(a)) | % contribution ^(b) |
| Large, late, not-scrubbed (LLN) | 2.1 | 57 | 7.6 | 88 | 3.9 | 58 |
| Large, early, not-scrubbed (LEN) | 0.9 | 23 | 0.3 | 4 | 2.8 | 42 |
| Large, late scrubbed (LLS) | 0.7 | 20 | 0.7 | 8 | negligible | negligible |
| Large early scrubbed (LES) | 0.0 | 0 | 0.0 | 0 | 0.0 | 0 |
| Containment intact (COK) | negligible | negligible | negligible | negligible | negligible | negligible |
| Total | 3.7 | 100 | 8.6 | 100 | 6.7 | 100 |

^(a) One person-rem = 0.01 person-Sv

^(b) This is based on population dose contribution in Tables E.7-1, E.7-2, and E.7-3 of the ER (EN, 2010a) for internal events, fire events, and seismic events, respectively, and total population dose for each hazard.

1
2

Table 5.3-5. Breakdown of population dose by containment release mode for PSA Revision 7.1

| Containment release mode | Internal events | | Fire events | | Seismic events | |
|-------------------------------------|---|-------------------------------|---|-------------------------------|---|-------------------------------|
| | Pop. dose (person-rem/yr ^(a)) | % contribution ^(b) | Pop. dose (person-rem/yr ^(a)) | % contribution ^(b) | Pop. dose (person-rem/yr ^(a)) | % contribution ^(b) |
| High/early release (H/E) | 0.7 | 13 | 0.1 | 1 | 3.8 | 64 |
| High/intermediate release (H/I) | 0.3 | 6 | 0.1 | 1 | 0.9 | 15 |
| Moderate/early release (M/E) | 0.2 | 4 | <0.1 | <1 | negligible | negligible |
| Moderate/intermediate release (M/I) | 4.0 | 74 | 8.5 | 94 | 1.1 | 19 |
| Low/early release (L/E) | <0.1 | 1 | <0.1 | <1 | <0.1 | <1 |
| Low/intermediate release (L/I) | negligible | negligible | <0.1 | <1 | negligible | negligible |
| Low-low/early release (LL/E) | <0.1 | <1 | 0.1 | 1 | <0.1 | <1 |
| Low-low/intermediate release (LL/I) | 0.1 | 2 | 0.1 | 1 | 0.1 | 2 |
| Containment intact (COK) | negligible | 0 | negligible | 0 | negligible | 0 |
| Total ^(c) | 5.5 | 100 | 9.0 | 100 | 5.9 | 100 |

^(a) One person-rem = 0.01 person-Sv

^(b) This is based on population dose contribution in Tables A-6, A-7, and A-8 of the RAI responses (Gambhir, 2011a) for internal events, fire events, and seismic events, respectively, and total population dose for each hazard.

^(c) Column may not total to reported totals due to round off.

3 5.3.2 Adequacy of CGS PSA for SAMA Evaluation

4 The CGS PSA evolved from the original IPE (Sorensen, 1992) and its subsequent revision
5 (Parrish, 1994), for which the NRC staff concluded that the IPE submittal met the intent of
6 GL 88-20 (NRC, 1988), (NRC, 1997a). Although no vulnerabilities were identified in the IPE,
7 several improvements to the plant or procedures were identified. These improvements have
8 been either implemented at the site or addressed in the SAMA evaluation process. There have
9 been 12 revisions to the internal events PSA model since the 1994 IPE submittal, for which a
10 listing of the major changes was provided by Energy Northwest in the ER (EN, 2010a) and in
11 response to an NRC staff RAI (Gambhir, 2011a). The 1994 IPE internal events CDF value
12 (1.8×10^{-5} per year) is in the middle of the range of the CDF values reported in the IPEs for BWR
13 5/6 plants, which ranges from about 1×10^{-5} per year to 4×10^{-5} per year, with an average CDF for
14 the group of 2×10^{-5} per year (NRC, 1997a). It is recognized that plants have updated the values
15 for CDF subsequent to the IPE submittals to reflect modeling and hardware changes. Based on
16 CDF values reported in the SAMA analyses for license renewal applications, the internal events

Environmental Impacts of Postulated Accidents

1 CDF result for CGS used for the SAMA analysis (4.8×10^{-6} per year used for the baseline
2 analysis and 7.4×10^{-6} per year used for the sensitivity analysis, including internal flooding) is
3 less than that for other plants of similar vintage and characteristics.

4 There have been three revisions to the fire PSA model and two revisions to the seismic PSA
5 model since the 1995 IPEEE submittal. A comparison of the fire events CDF between the 1995
6 IPEEE and Revision 2 of the CGS fire events PSA model used for the baseline SAMA
7 evaluation indicates a decrease of approximately 58 percent (from 1.8×10^{-5} per year to 7.4×10^{-6}
8 per year). A comparison of the seismic events CDF between the 1995 IPEEE and Revision 1 of
9 the CGS seismic events PSA model used for the baseline SAMA evaluation indicates a
10 decrease of approximately 75 percent (from 2.1×10^{-5} per year to 5.2×10^{-6} per year).
11 Subsequently, as a result of integrating Revision 2 of the fire PSA model and Revision 1 of the
12 seismic PSA model with internal events PSA Revision 7.1 (no upgrades to the fire or seismic
13 models were performed), the fire CDF increased to 1.4×10^{-5} per year and the seismic CDF
14 decreased to 4.9×10^{-6} per year (Gambhir, 2011a). The integrated PSA Revision 7.1 model was
15 then used for the sensitivity analysis.

16 Internal Events CDF

17 Energy Northwest identified four external reviews and seven technical reviews that have been
18 performed for the CGS PSA. The first, conducted by the BWR Owners' Group (BWROG) in
19 1997, reviewed PSA model Revision 3 Level 1 and 2 internal events (including internal
20 flooding). Energy Northwest stated that all comments produced by this review were resolved.
21 Two external reviews, an industry peer review, and an NRC inspection of the CGS PSA were
22 conducted in 2004 in support of Energy Northwest's participation in the NRC's RG 1.200 pilot
23 program. The industry reviewed PSA model Revision 5.0 Level 1 and 2 internal and fire events
24 PSA (Webring, 2004) against the American Society of Mechanical Engineers (ASME) Standard
25 RA-Sa-2003 (ASME, 2003), as modified by the trial use version of NRC RG 1.200
26 (NRC, 2004b). Energy Northwest stated that there were no Level A (extremely important) facts
27 and observations (F&Os) from this review and identified all Level B (important) F&Os, with the
28 exception of F&Os categorized as having only documentation impacts, that are not resolved in
29 the Revision 6.2 PSA model (Gambhir, 2010). Furthermore, Energy Northwest stated that all of
30 the identified Level B F&Os have been resolved in the PSA Revision 7.1 model used for the
31 SAMA sensitivity analysis.

32 Energy Northwest identified three physical plant changes since PSA model Revision 6.2 that
33 could potentially impact the SAMA evaluation (Gambhir, 2010). The first provides for the ability
34 to cross-connect a DG to either the Division 1 or 2 emergency buses during extended SBO and
35 included changes to LOOP and SBO procedures, reducing CDF and, therefore, the benefits
36 associated with SAMAs identified to improve plant response to LOOP or SBO. The second
37 change added a portable 480 V DG (DG-4) and included associated procedure changes to
38 provide an alternate source of AC power, improving the ability of CGS to cope with an SBO and,
39 therefore, reducing CDF. The third change was an upgrade of the feedwater and turbine control
40 systems, which, despite yielding an anticipated higher reliability, has not been credited in the
41 PSA because of insufficient operational history. Since each of the three changes either reduces
42 or maintains (i.e., does not increase) plant risk, Energy Northwest concluded that
43 implementation of these changes either reduces or maintains (i.e., does not increase) the
44 benefits calculated for the evaluated SAMA candidates (Gambhir, 2010).

45 Energy Northwest explained that the CGS internal events PSA model had been updated to
46 Revision 7.1 since the SAMA evaluation reported in the ER, which resulted in a higher CDF and

1 a lower LERF (Gambhir, 2010). PSA Revision 7.1 model incorporated the following
 2 (Gambhir, 2011a):

- 3 • resolution of F&Os from the 2004 peer review
- 4 • resolution of areas of model incompleteness identified by CGS internal technical reviews
- 5 • upgrades to meet NRC RG 1.200 Revision 2 (NRC, 2009a) and the associated ASME
 6 standard RA-S-2008 (ASME, 2008) for Level 1, LERF, and flooding modeling
- 7 • plant and procedure changes, such as the DG cross-connect discussed previously)

8 These changes were first incorporated in the PSA Revision 7.0 model, for which a peer review
 9 was performed on Level 1 and 2 internal events (with internal flooding) in 2009 and a report was
 10 issued in January 2010. Energy Northwest explains that F&Os from this peer review that could
 11 significantly impact the model quantification were incorporated into the Revision 7.1 model, and
 12 a review of the remaining F&Os associated with SRs that were graded as CC-I or not met
 13 identified none that would significantly impact the results of the SAMA analysis
 14 (Gambhir, 2011a).

15 Energy Northwest described that the process for controlling the technical adequacy of the PSA
 16 is contained in a CGS engineering procedure that is consistent with guidance in NRC RG 1.174
 17 (NRC, 2002). This PSA configuration procedure covers monitoring PSA input and collecting
 18 new information for incorporation, updating the PSA to be consistent with the as-built and
 19 as-operated plant, assessing cumulative impact of pending PSA changes, control of computer
 20 codes supporting the PSA, documentation, and qualification of PSA reviewers. The CGS
 21 internal events PSA model has been peer-reviewed, the peer review findings were all resolved
 22 and their impact assessed in a sensitivity analysis using the updated PSA model, and Energy
 23 Northwest has satisfactorily addressed NRC staff questions regarding the PSA. Based on this
 24 information, the NRC staff concludes that the internal events Level 1 PSA model is of sufficient
 25 quality to support the SAMA evaluation.

26 Seismic CDF

27 The CGS IPEEE was submitted in June 1995 (EN, 1995) and included an internal fire PSA, a
 28 seismic PSA, and a screening analysis for other external events. In a letter dated February 26,
 29 2001, the NRC staff concluded that the submittal met the intent of Supplement 4 to GL 88-20,
 30 and the licensee's IPEEE process is capable of identifying the most likely severe accidents and
 31 severe accident vulnerabilities (NRC, 2001b). The seismic portion of the IPEEE consisted of a
 32 seismic PSA completed in accordance with NRC guidance (NRC, 1983), (NRC, 1991a). Major
 33 inputs were from plant walkdowns conducted in accordance with the EPRI methodology for
 34 Seismic Margins Assessment (EPRI, 1991), relay chatter evaluation conducted in accordance
 35 with NRC guidance for IPEEE submittals, and seismic fragility evaluation conducted per the
 36 EPRI methodology for developing seismic fragilities (EPRI, 1994). A site-specific seismic
 37 hazard estimate was developed by Geomatrix (Geomatrix, 1994a). The seismic CDF resulting
 38 from the CGS IPEEE was calculated to be 2.1×10^{-5} per year. The CGS IPEEE did not identify
 39 any vulnerabilities due to seismic events but did identify several improvements to the plant or
 40 procedures to reduce seismic risk, which have been either implemented or addressed in the
 41 SAMA evaluation process

42 Energy Northwest subsequently upgraded the seismic PSA to be consistent with the American
 43 Nuclear Society (ANS) standard for external events PSAs, American National Standards

Environmental Impacts of Postulated Accidents

1 Institute (ANSI)/ANS-58.21-2003 (ANS, 2003) and with EPRI seismic PSA implementation
2 guidance (EPRI, 2003). Major inputs included the following:

- 3 • a plant-specific hazard curve
- 4 • results and insights obtained from seismic plant walkdowns conducted in support of the
5 IPEEE (Parrish, 1995)
- 6 • plant-specific structural and component seismic fragility analyses
- 7 • relay chatter evaluation
- 8 • Level 1 and 2 Revision 6.2 PSA models

9 These upgrades to the seismic PSA resulted in a seismic CDF of 5.2×10^{-6} per year, which
10 decreased slightly to 4.9×10^{-6} per year in PSA Revision 7.1 due to integration of the seismic
11 PSA model with the updated internal events model (Gambhir, 2011a).

12 The NRC staff requested that Energy Northwest address whether seismic hazard analysis
13 information developed later for the nearby DOE Hanford Site and by the U.S. Geological Survey
14 (USGS, 2008) could impact the results of the SAMA analysis (Doyle, 2010a). In response to the
15 RAI, Energy Northwest concludes that the 1994 seismic hazard study used in the CGS seismic
16 PSA model used in the SAMA evaluation (Geomatrix, 1994b) still provides an adequate seismic
17 input to the PSA models to effectively identify relevant SAMA candidates (Gambhir, 2010).
18 Energy Northwest bases their conclusion on the fact that this and several Hanford waste
19 treatment plant (WTP) site seismic studies evaluated locations that are at least 10 mi distant
20 from the CGS site and that the soil structure at the CGS site is thicker than at the WTP site.
21 Energy Northwest also compares the peak ground acceleration (PGA) at times 500 and 2,500
22 years calculated using the 2008 USGS data (USGS, 2008) for the coordinates corresponding to
23 the CGS site, which are lower than the PGAs predicted by the Geomatrix CGS model
24 (Geomatrix, 1994a), (Geomatrix, 1994b), (Geomatrix, 1996). Based on these results, Energy
25 Northwest concludes that the CGS seismic model is conservative relative to the latest USGS
26 seismic hazard data in predicting an appropriate ground motion for the CGS site.

27 The CGS internal events modeling is an input to the seismic PSA model, the seismic PSA has
28 been updated to a more recent external events PSA standard, the SAMA evaluation included a
29 sensitivity analysis of the seismic CDF, and Energy Northwest has satisfactorily addressed NRC
30 staff RAIs regarding the seismic PSA. Based on this information, the NRC staff concludes that
31 the seismic PSA model in combination with the sensitivity analysis of the seismic CDF provides
32 an acceptable basis for identifying and evaluating the benefits of SAMAs.

33 Fire CDF

34 The IPEEE fire analysis was performed with PSA technology but employed elements of EPRI's
35 fire-induced vulnerability evaluation (FIVE) methodology (EPRI, 1992) for systemic screening
36 and ignition source frequency determination. The IPEEE fire areas were based on definitions of
37 Appendix R fire areas for CGS. Of the 93 fire areas, 36 were qualitatively screened. Fire-
38 initiating event frequencies were estimated for each of the remaining 57 unscreened fire areas
39 using the FIVE methodology. Computerized fire simulations were performed with COMPBRN III
40 (NRC, 1986). The likelihood for fire suppression was determined based on the availability of
41 automatic fire suppression as well as the likelihood that fires would not significantly affect the
42 PSA-related components and cables located in the fire area. Fire-initiating events in each fire
43 area and fire-induced failures were combined with random equipment failure modes using the

1 internal events PSA to determine the fire CDF for each unscreened fire area. All but 16 fire
2 areas were quantitatively screened from further analysis based on a fire-induced CDF being
3 less than 1×10^{-6} per year. As reported in the IPEEE, the fire CDF for these 16 important fire
4 areas was 9.2×10^{-6} per year. A separate control room fire evaluation estimated its fire CDF to
5 be 8.4×10^{-6} per year, bringing the total to 1.8×10^{-5} per year. No vulnerabilities due to fire events
6 were identified, but several suggested improvements to plant procedures to reduce fire risk
7 have been either implemented at the site or addressed in the SAMA evaluation process.

8 Energy Northwest subsequently created a fire PSA based on the internal events PSA model but
9 using elements of NUREG/CR-6850 (NRC, 2005b). For screening, the loss scenarios were
10 simplified into loss of the single worst equipment or cable or loss of all equipment and cables in
11 the compartment. Each compartment has a fire-initiating event tree, initiated by either turbine
12 trip or loss of feedwater, as appropriate for the compartment losses. In performing the fire
13 analysis, consideration was given to all fire damage mechanisms, including smoke, loss of
14 lighting and indication, and fire suppression system impacts on equipment. The fire PSA
15 explicitly examined the human error probabilities (HEPs) used for the fire scenarios. The CGS
16 IPEEE demonstrated that only a few fire compartments had the potential for fire propagation
17 from one compartment to another; thus, detailed evaluation of potential fire propagation
18 between compartments was not performed.

19 For each scenario, fire-induced equipment failures were determined, including hot short events
20 in over 120 locations that could spuriously actuate components and result in undesired
21 configurations. The hot short impact included failure of minimum-flow valves in pathways
22 needed for the emergency core cooling injection and valves and dampers needed for
23 containment isolation. Detailed analysis of the main control room was performed, and the
24 potential for control room evacuation considered. These upgrades to the fire PSA resulted in a
25 fire CDF of 7.4×10^{-6} per year for CGS PSA Revision 6.2, which was used for the baseline SAMA
26 evaluation. This value nearly doubled to 1.4×10^{-5} per year in PSA Revision 7.1 used in the
27 SAMA sensitivity analysis due to integration of the fire PSA model with the updated internal
28 events model (Gambhir, 2011a).

29 The fire PSA was included in the industry peer review conducted in 2004, which produced 33
30 findings. All Level A and B F&Os were addressed and resolved in the Revision 6.2 PSA model
31 used in the SAMA evaluation. The remaining unresolved findings are not expected to
32 significantly alter the results of the SAMA analysis. Energy Northwest discussed areas of
33 potential non-conservatism and provided the basis for concluding that resolution of these issues
34 will not impact the results of the SAMA evaluation. Energy Northwest will address these issues
35 in a future upgrade of the fire PSA; any impacts are judged to be encompassed by the 95th
36 percentile CDF uncertainty analysis. The NRC staff considers Energy Northwest's explanation
37 and assessment of areas of incompleteness in the fire PSA reasonable and that, in light of the
38 known conservatisms in the PSA model, resolution of these incompleteness issues is not likely
39 to impact the results of the SAMA analysis. The CGS internal events modeling is an input to the
40 fire PSA model, the fire PSA has been updated to incorporate industry fire data and NRC
41 guidance, the fire PSA model has been peer reviewed and the peer review findings were all
42 addressed, and Energy Northwest has satisfactorily addressed NRC staff RAIs regarding the
43 fire PSA. Based on this information, the NRC staff concludes that the fire PSA model provides
44 an acceptable basis for identifying and evaluating the benefits of SAMAs.

1 “Other” External Event CDF

2 The Energy Northwest IPEEE analysis of HFO external events followed the screening and
3 evaluation approaches specified in Supplement 4 to GL 88-20 (NRC, 1991a) and in associated
4 guidance in NUREG-1407 (1991b). For high winds, external floods, volcanic activity, and
5 accidents at nearby facilities, the IPEEE concluded that Energy Northwest meets the 1975
6 Standard Review Plan criteria (NRC, 1975b); therefore, the contribution from these hazards to
7 CDF is less than the 1.0×10^{-6} per year criterion (Parrish, 1995). Although the CGS IPEEE did
8 not identify any vulnerability due to HFO events, one improvement to reduce risk has been
9 implemented. In the SAMA analysis, the benefit from HFO events was assumed to be
10 equivalent to the benefit that was derived from the internal events model. The bases for this
11 assumption are as follows:

- 12 • Some of the HFO events are captured in the LOOP contributor.
- 13 • The IPEEE analysis found that all of the HFO events contributed less than the screening
14 CDF of 1.0×10^{-6} per year.
- 15 • The internal events CDF is more than a factor of four greater than the HFO screening
16 CDF.

17 Based on the low contribution to CDF from HFO events, and the internal events CDF of 4.5×10^{-6}
18 per year for CGS PSA Revision 6.2, the NRC staff agrees that assuming the benefits from HFO
19 events is equivalent to the benefits from internal events is reasonable and conservative
20 (Gambhir, 2011a). This same assumption, albeit at the higher internal events CDF of 7.4×10^{-6}
21 per year, was also used for CGS PSA Revision 7.1 in the sensitivity analysis.

22 Level 2 and LERF

23 The Level 2 analysis is linked to the Level 1 model by assigning each Level 1 core damage
24 sequence to one of 21 PDSs based on the functional characteristics of the sequence and the
25 status of systems that were important to containment performance. A CET is developed for
26 each PDS and quantified via fault tree analysis and the use of split fractions. The PDSs are
27 organized by accident type, initiator type, systems available to mitigate the accident, and power
28 and system recoverability (Gambhir, 2010). Each PDS is analyzed through the Level 2 CETs to
29 evaluate the phenomenological progression of the sequence. In the baseline analysis, CET
30 end-states are assigned to one of the five release categories (see Table 5.3-4), each of which
31 was defined based on characteristics that determine the timing and magnitude of the release
32 and whether the fission products were or were not scrubbed prior to release. The frequency of
33 each release category is the sum of the frequencies of the individual accident progression CET
34 endpoints binned into the release category. Source term release fractions were developed for
35 each of the five release categories based on the results of plant-specific calculations using the
36 MAAP Version 4.0.4 (Gambhir, 2010).

37 The Level 2 model was included in the 1997 and 2004 peer reviews. Energy Northwest stated
38 that all comments produced by the 1997 review were resolved. Of the 11 unresolved Level B
39 F&Os identified in the 2004 review, 9 were resolved in response involved the Level 2 (LERF)
40 analysis (Gambhir, 2010). Energy Northwest determined that resolution of these F&Os will not
41 impact the SAMA analysis. Furthermore, Energy Northwest stated that all of the identified
42 Level B F&Os have been resolved in the PSA Revision 7.1 model used for the SAMA sensitivity
43 analysis. In the PSA Revision 7.1 sensitivity analysis, 13 release categories were defined. The
44 “late” time category was not used leaving nine release categories to which CET end-states were

1 assigned (Gambhir, 2011b). The definition for the “early” time category was changed from “less
 2 than 4 hours” assumed in the baseline analysis to “less than 3 hours” based on the latest CGS
 3 emergency action levels and the latest evacuation time estimates. Source term release
 4 fractions were also developed for each of the nine release categories based on the results of
 5 plant-specific calculations using MAAP Version 4.0.4, as revised to represent the current CGS
 6 configuration (Gambhir, 2011a). The nine release categories are updated from the five used in
 7 the baseline analysis, including quantitative weighting based on the dominant cutset
 8 contributors to, and the associated MAAP cases available for, each release category.

9 The Level 2 model was included in the 2009 peer review of PSA Revision 7.0, with F&Os that
 10 could significantly impact the model quantification now incorporated into Revision 7.1. Energy
 11 Northwest concluded that resolution of any remaining unresolved F&Os would not impact the
 12 SAMA analysis. The NRC staff reviewed the Level 2 methodology and found that Energy
 13 Northwest adequately addressed NRC staff RAIs, the Level 2 PSA model was reviewed in more
 14 detail as part of the 1997 and 2004 peer reviews, and the findings from these peer reviews
 15 have been resolved and their impact assessed in a sensitivity analysis using the updated PSA
 16 model. Based on this information, the NRC staff concludes that the Level 2 PSA provides an
 17 acceptable basis for evaluating the benefits associated with various SAMAs.

18 Level 3—Population Dose

19 Energy Northwest extended the containment performance (Level 2) portion of the PRA to
 20 assess offsite consequences (essentially a Level 3 PRA) via the MACCS2 code (NRC, 1998).
 21 This included consideration of the following information:

- 22 • source terms for each release category and the reactor core radionuclide inventory
- 23 • site-specific meteorological data for calendar year 2006
- 24 • projected population distribution within an 80 km (50-mi) radius for the year 2045 based
 25 on year 2000 census data from SECPOP2000 (NRC, 2003)
- 26 • emergency evacuation modeling using only 95 percent of the population (conservative
 27 relative to NUREG-1150, which assumed 99.5 percent (NRC 1990))
- 28 • economic parameters including agricultural production

29 Multiple sensitivity cases were run, including releases 13–44 m above ground level; variation in
 30 release duration; meteorological data from 2003; variation in rainfall up to maximum for 2006;
 31 variation in population growth rate; and variations in evacuation parameters, such as percent of
 32 population, evacuation speed, and delay time. Energy Northwest’s results showed only minor
 33 variations from the baseline for these sensitivities, which is consistent with previous SAMA
 34 analyses. The NRC staff concludes that the methodology used by Energy Northwest to
 35 estimate the offsite consequences for CGS provides an acceptable basis from which to proceed
 36 with an assessment of risk reduction potential for candidate SAMAs. Accordingly, the NRC staff
 37 based its assessment of offsite risk on the CDF and offsite doses reported by Energy
 38 Northwest.

39 **5.3.3 Potential Plant Improvements**

40 CGS’s process for identifying potential plant improvements (SAMAs) consisted of the following
 41 elements:

Environmental Impacts of Postulated Accidents

- 1 • review of the dominant cutsets and most significant plant systems from the current,
2 plant-specific Level 1 internal events PSA
- 3 • review of the most significant initiating events and sequences from the current,
4 plant-specific Level 2 internal events PSA contributing to each release category
- 5 • review of potential plant improvements and PSA insights identified in the CGS IPE and
6 IPEEE
- 7 • review of SAMA candidates identified for license renewal applications for selected BWR
8 plants
- 9 • review of other industry documentation discussing potential plant improvements

10 Based on this process, an initial set of 150 “Phase I” candidate SAMAs was identified.
11 Subsequently, after further review of the IPEEE, one of these SAMA candidates was further
12 divided into two, resulting in a total of 151. Energy Northwest performed a qualitative screening
13 of this initial list of Phase I SAMAs and eliminated 124 SAMAs from further consideration,
14 leaving 27 for “Phase II,” using the following criteria:

- 15 • The SAMA is not applicable to CGS due to design differences or has already been
16 implemented at CGS (66 SAMAs screened).
- 17 • The SAMA was determined to provide very little benefit (36 SAMAs screened).
- 18 • The SAMA is similar to another SAMA under consideration and was subsumed into the
19 similar SAMA (seven SAMAs screened).
- 20 • The SAMA has estimated implementation costs that would exceed the dollar value
21 associated with eliminating all severe accident risk at CGS (15 SAMAs screened).

22 The NRC staff reviewed Energy Northwest’s process for identifying and screening potential
23 SAMA candidates, as well as the methods for quantifying the benefits associated with potential
24 risk reduction. This included reviewing insights from the plant-specific risk studies and
25 reviewing plant improvements considered in previous SAMA analyses. The NRC staff notes
26 that the set of SAMAs submitted is not all-inclusive, since additional, possibly even less
27 expensive design alternatives can always be postulated. However, the NRC staff concludes
28 that the benefits of any additional modifications are unlikely to exceed the benefits of the
29 modifications evaluated and that the alternative improvements would not likely cost less than
30 the least expensive alternatives evaluated, when the subsidiary costs associated with
31 maintenance, procedures, and training are considered. While explicit treatment of external
32 events in the SAMA identification process was limited, it is recognized that the prior
33 implementation of plant modifications for fire risks and the absence of external event
34 vulnerabilities constituted reasonable justification for examining primarily the internal events risk
35 results for this purpose. The NRC staff concludes that Energy Northwest used a systematic and
36 comprehensive process for identifying potential plant improvements for CGS, and the set of
37 SAMAs evaluated in the ER, together with those evaluated in response to NRC staff inquiries, is
38 reasonably comprehensive and, therefore, acceptable.

39 **5.3.3.1 Risk Reduction**

40 Energy Northwest evaluated the risk-reduction potential of the 28 SAMAs retained for the Phase
41 II evaluation that were not screened for excessive cost. For the baseline analysis, Energy
42 Northwest used model re-quantification to determine the potential benefits based on CGS
43 internal events PSA Revision 6.2 model for internal events, the CGS fire PSA Revision 2 model

1 for fire events, and the CGS seismic PSA Revision 1 model for seismic events. The majority of
 2 the SAMA evaluations were performed in a bounding fashion in that the SAMA was assumed to
 3 eliminate the risk associated with the proposed enhancement. On balance, such calculations
 4 overestimate the benefit and are conservative. The NRC staff reviewed Energy Northwest's
 5 bases for calculating the risk reduction for the various plant improvements and concludes that
 6 the rationale and assumptions are reasonable and generally conservative (i.e., the estimated
 7 risk reduction is higher than what would actually be realized). Accordingly, the NRC staff based
 8 its estimates of averted risk for the various SAMAs on Energy Northwest's risk reduction
 9 estimates.

10 **5.3.3.2 Cost Impacts**

11 Energy Northwest developed plant-specific costs of implementing the 28 Phase II candidate
 12 SAMAs using by a team of three Energy Northwest and consultant personnel having over 50
 13 years of cumulative experience at CGS and over 90 years of collective experience in the
 14 nuclear industry in areas of electrical and mechanical engineering, field engineering, design
 15 engineering, construction management, operations and maintenance support, licensing, and
 16 PSA (Gambhir, 2010). The cost estimates, conservatively, did not include contingency costs for
 17 unforeseen implementation obstacles, the cost of replacement power during extended outages
 18 required to implement the modifications, or the costs associated with recurring training,
 19 maintenance, and surveillance (Gambhir, 2010). Energy Northwest noted that if the estimated
 20 implementation cost was sufficiently greater than the maximum estimated benefit, a more
 21 detailed cost estimate was not developed. Based on the use of personnel having significant
 22 nuclear plant engineering and operating experience, the NRC staff considers the process
 23 Energy Northwest used to develop the site-specific cost estimates reasonable.

24 The NRC staff reviewed the bases for the applicant's cost estimates, including comparison with
 25 estimates developed elsewhere for similar improvements (e.g., estimates developed as part of
 26 other licensees' analyses of SAMAs for operating reactors). The staff also reviewed Energy
 27 Northwest's results from a sensitivity study using PSA model Revision 7.1 (Gambhir, 2011a).
 28 The NRC staff concludes that the cost estimates provided by Energy Northwest are sufficient
 29 and appropriate for use in the SAMA evaluation.

30 **5.3.3.3 Cost-Benefit Comparison**

31 The methodology used by Energy Northwest was based primarily on NRC's guidance for
 32 performing cost-benefit analysis—NUREG/BR-0184, Regulatory Analysis Technical Evaluation
 33 Handbook (NRC, 1997a)—with the discount rate guidelines in NUREG/BR-0058 (NRC, 2004a).
 34 The guidance involves determining the net value for each SAMA according to the following
 35 formula:

$$36 \quad \text{Net Value} = (\text{APE} + \text{AOC} + \text{AOE} + \text{AOSC}) - \text{COE}$$

37 where:

38 APE = present value of averted public exposure (\$)

39 AOC = present value of averted offsite property damage costs (\$)

40 AOE = present value of averted occupational exposure costs (\$)

41 AOSC = present value of averted onsite costs (\$)

42 COE = cost of enhancement (\$)

Environmental Impacts of Postulated Accidents

1 If the net value of a SAMA is negative, the cost of implementing the SAMA is larger than the
2 benefit associated with the SAMA and it is not considered cost-beneficial. Present values for
3 both a 3 percent and 7 percent discount rate were considered. Using the NUREG/BR-0184
4 methods, Energy Northwest estimated the total present dollar value equivalent associated with
5 eliminating severe accidents from internal and external events at CGS to be about \$1,887,000
6 for the baseline analysis (PSA Revision 6.2) and \$2,300,000 for the sensitivity analysis (PSA
7 Revision 7.1), also referred to as the maximum averted cost risk.

8 If the implementation costs for a candidate SAMA exceeded the calculated benefit, the SAMA
9 was considered not to be cost-beneficial. In the baseline analysis (using a 7 percent discount
10 rate), Energy Northwest identified no potentially cost-beneficial SAMA. Based on a sensitivity
11 analysis using a 3 percent discount rate, three SAMA candidates—AC/DC-28, FR-07a and
12 FR-07b—were determined to be potentially cost-beneficial (see Table 5.3-6). Energy Northwest
13 also provided the results of a sensitivity study to evaluate the Phase II SAMAs using PSA model
14 Revision 7.1 (Gambhir, 2011a). Energy Northwest’s analysis (using a 7 percent discount rate)
15 determined that SAMA candidates FW-05R, FL-05R, FL-06R, CC-24R, OT-07R, and OT-09R
16 were also potentially cost-beneficial (see Table 5.3-6). SAMAs previously identified as
17 potentially cost-beneficial are not repeated even though they may also be cost-beneficial “again”
18 based on these additional analysis cases (e.g., SAMA FL-05R). Since Energy Northwest did
19 not provide in the ER an assessment of the impact on the SAMA evaluation of CDF
20 uncertainties, the NRC requested this (Doyle, 2010a), (Doyle, 2010c). Energy Northwest
21 responded that SAMAs CC-03b, HV-02, FR-08, SR-05R, FL-04R, CC-25R, and FR-11R are
22 also potentially cost-beneficial (see Table 5.3-6), based on either the baseline (PSA
23 Revision 6.2) or sensitivity analysis (PSA Revision 7.1) (Gambhir, 2011a). Also in the sensitivity
24 study, Energy Northwest did not identify any additional potentially cost-beneficial SAMAs using
25 a 3 percent discount rate (Gambhir, 2011a).

26 Energy Northwest stated that the six potentially cost-beneficial SAMAs (SAMAs AC/DC-28,
27 CC-03b, FR-07a, FR-07b, FR-08, and HV-02), identified via PSA Revision 6.2, will be further
28 evaluated through the normal processes for evaluating possible plant changes at CGS
29 (EN, 2010a), (EN, 2011). Energy Northwest also stated that the 10 additional potentially
30 cost-beneficial SAMAs (SAMAs SR-05R, FL-05R, FL-04R, FL-06R, CC-24R, CC-25R, OT-07R,
31 FW-05R, OT-09R, and FR-11R), identified via PSA Revision 7.1, will be further evaluated
32 through the same processes. This process involves first entering the cost-beneficial SAMA
33 candidate into the action request system for SAMAs that require plant modifications or
34 procedure changes and submitting a training request for SAMAs that require training
35 (Gambhir, 2011a). After the requests are submitted, formal processes are followed for each
36 SAMA type (i.e., hardware modification, procedure change, training) to determine if the SAMA is
37 ultimately implemented. The NRC staff concludes that, with the exception of the potentially
38 cost-beneficial SAMAs discussed above, the costs of the other SAMAs evaluated would be
39 higher than the associated benefits.

40 **5.3.4 Cost-Beneficial SAMAs**

41 Highlighted in ***bold italics*** in Table 5.3-6 are the 16 potentially cost-beneficial SAMAs identified
42 in the previous section:

Table 5.3-6. Summary of cost-benefit analyses for CGS

| SAMA ^(a) | % Risk Reduction ^(f) (PSA Revision 6.2/PSA Revision 7.1) ^(c) | | Total Benefit (\$) ^(b, f) (PSA Revision 6.2/PSA Revision 7.1) ^(c) | | Cost (\$) |
|---|---|---|--|---------------------------------|-------------|
| | CDF ^(d) | Pop. Dose ^(d) | Internal External ^(e) | With Uncertainty ^(e) | |
| Increase availability of DC power | | | | | |
| AC/DC-01—Provide additional DC battery capacity | Internal—5/1 Fire—0/0 Seismic—1/0 | Internal—4/0 Fire—0/0 Seismic—1/<1 | 37K/3.3K | 100K/8.1K | 1.8M |
| AC/DC-02—Replace lead-acid batteries with fuel cells | | | | | 1.0M |
| AC/DC-03—Add a portable, diesel-driven battery charger to existing DC system | | | | | 500K |
| Increase availability of onsite AC power | | | | | |
| AC/DC-10—Provide an additional DG | Internal—32/2 Fire—11/9 Seismic—4/1 | Internal—15/<1 Fire—9/7 Seismic—4/2 | 250K/88K | 720K/230K | 11M |
| AC/DC-15—Install a gas turbine generator | | | | | 2.1M |
| AC/DC-16—Install tornado protection of gas turbine generator | | | | | 2.1M |
| AC/DC-23—Develop procedures to repair or replace failed 4 kV breakers | Internal—1/5 Fire—2/1 Seismic—<1/0 | Internal—<1/6 Fire—2/2 Seismic—<1/0 | 20K/71K | 61K/170K | 375K |
| AC/DC-27—Install permanent hardware changes that make it possible to establish 500 kV backfeed through the main step-up transformer | Internal—24/10 Fire—25/38 Seismic—0/0 | Internal—9/9 Fire—26/37 Seismic—0/0 | 300K/420K | 870K/1.1M | 1.7M |
| AC/DC-28—Reduce common cause failures (CCFs) between EDG-3 and EDG-1/2 | Internal—12/<1 Fire—2/1 Seismic—<1/0 | Internal—6/0 Fire—1/<1 Seismic—<1/<1 | 73K/6.8K | 200K/17K | 100K |
| AC/DC-29—Replace EDG-3 with a diesel diverse from EDG-1 and EDG-2 | Internal—26/1 Fire—4/2 Seismic—<1/0 | Internal—12/<1 Fire—2/1 Seismic—<1/<1 | 150K/18K | 420K/46K | 4.2M |
| AT-05—Add an independent boron injection system | Internal—<1/2 Fire—0/0 Seismic—<1/0 | Internal—<1/7 Fire—0/0 Seismic—<1/<1 | 5.6K/41K | 16K/100K | 800K |
| AT-07—Add a system of relief valves to prevent equipment damage from pressure spikes during an ATWS | Internal—0/0 Fire—0/0 Seismic—0/0 | Internal—0/0 Fire—0/0 Seismic—0/0 | 0/0 | 0/0 | 1.1M |
| AT-13—Automate standby liquid control (SLC) injection in response to ATWS event | Internal—~0/<1 Fire—0/0 Seismic—0/0 | Internal—~0/1 Fire—0/0 Seismic—0/0 | 0.2K/9.7K | 0.5K/23K | 660K |

Environmental Impacts of Postulated Accidents

| SAMA ^(a) | % Risk Reduction ^(f) (PSA Revision 6.2/PSA Revision 7.1) ^(c) | | Total Benefit (\$) ^(b, f) (PSA Revision 6.2/PSA Revision 7.1) ^(c) | | Cost (\$) |
|---|---|---|--|---------------------------------|------------|
| | CDF ^(d) | Pop. Dose ^(d) | Internal External ^(e) | With Uncertainty ^(e) | |
| AT-14—Diversify SLC explosive valve operation | Internal—~0/0 Fire—0/0 Seismic—0/0 | Internal—~0/0 Fire—0/0 Seismic—0/0 | 0.4K/0 | 1.0K/0 | 370K |
| Reduce probability of an interfacing systems loss-of-coolant accident (ISLOCA) | | | | | |
| CB-01—Install additional pressure or leak monitoring instruments for detection of ISLOCAs | | | | | 5.6M |
| CB-03—Increase leak testing of valves in ISLOCA paths | Internal—~0/1 Fire—0/0 Seismic—0/0 | Internal—~0/3 Fire—0/0 Seismic—0/0 | 0/20K | 0/49K | 400K |
| CB-08—Revise emergency operating procedures (EOPs) to improve ISLOCA identification | | | | | 5.6M |
| CB-09—Improve operator training on ISLOCA coping | | | | | 5.6M |
| CC-01—Install an independent active or passive high pressure injection system | Internal—63/60 Fire—74/74 Seismic—4/2 | Internal—41/56 Fire—71/66 Seismic—4/2 | 875K/1.2M | 2.6M/3.0M | 29M |
| CC-02—Provide an additional high pressure injection pump with independent diesel | Internal—63/60 Fire—74/74 Seismic—4/2 | Internal—41/56 Fire—71/66 Seismic—4/2 | 875K/1.2M | 2.6M/3.0M | 5.2M |
| CC-03b—Raise reactor core isolation cooling system (RCIC) backpressure trip set points | Internal—9/<1 Fire—1/0 Seismic—<1/0 | Internal—5/0 Fire—1/0 Seismic—<1/0 | 54K/<1K | 150K/1.4K | 82K |
| CC-20—Improve emergency core cooling system (ECCS) suction strainers | Internal—~0/1 Fire—~0/0 Seismic—~0/0 | Internal—~0/1 Fire—~0/<1 Seismic—~0/0 | 0/7.4K | 0/18K | 10M |
| CP-01—Install an independent method of suppression pool cooling | Internal—17/33 Fire—52/54 Seismic—1/1 | Internal—28/56 Fire—56/83 Seismic—1/1 | 540K/1.0M | 1.6M/2.6M | 6.0M |
| CW-02—Add redundant DC control power for pumps | Internal—<1/10 Fire—3/5 Seismic—<1/0 | Internal—<1/13 Fire—3/-9 Seismic—<1/0 | 25K/100K | 75K/240K | 650K |
| Improve Reliability of ECCS Pumps | | | | | |
| CW-03—Replace ECCS pump motors with air-cooled motors | Internal—4/3 Fire—10/3 Seismic—<1/0 | Internal—6/1 Fire—10/-9 Seismic—<1/0 | 110K/-5.8K | 310K/-18K | 1.1M |
| CW-04—Provide self-cooled ECCS seals | | | | | 675K |

Environmental Impacts of Postulated Accidents

| SAMA ^(a) | % Risk Reduction ^(f) (PSA Revision 6.2/PSA Revision 7.1) ^(c) | | Total Benefit (\$) ^(b, f) (PSA Revision 6.2/PSA Revision 7.1) ^(c) | | Cost (\$) |
|---|---|---|--|---------------------------------|--------------|
| | CDF ^(d) | Pop. Dose ^(d) | Internal External ^(e) | With Uncertainty ^(e) | |
| CW-07—Add an SW pump | Internal—6/11 Fire—17/12 Seismic—<1/0 | Internal—8/12 Fire—10/6 Seismic—1/<1 | 180K/190K | 530K/480K | 6.1M |
| FR-03—Install additional transfer and isolation switches | Internal—0/0 Fire—30/6 Seismic—0/0 | Internal—0/0 Fire—31/2 Seismic—0/0 | 210K/36K | 650K/93K | 2.0M |
| FR-07a—Improve the fire resistance of critical cables for containment venting | Internal—0/0 Fire—46/30 Seismic—0/0 | Internal—0/0 Fire—50/47 Seismic—0/0 | 330K/320K | 1.0M/840K | 400K |
| FR-07b—Improve the fire resistance of critical cables for transformer E-TR-S | Internal—0/0 Fire—11/3 Seismic—0/0 | Internal—0/0 Fire—11/4 Seismic—0/0 | 75K/31K | 230K/81K | 100K |
| FR-08—Improve the fire resistance of cables to residual heat removal (RHR) and standby SW | Internal—0/0 Fire—72/56 Seismic—0/0 | Internal—0/0 Fire—78/64 Seismic—0/0 | 520K/510K | 1.6M/1.3M | 1.25M |
| HV-02—Provide a redundant train or means of ventilation | Internal—11/<1 Fire—16/0 Seismic—<1/0 | Internal—17/<1 Fire—16/0 Seismic—<1/0 | 210K/2.2K | 620K/5.3K | 480K |
| SR-03—Modify safety related CST | Internal—0/0 Fire—0/0 Seismic—~0/1 | Internal—0/0 Fire—0/0 Seismic—~0/1 | 0/3.1K | 0/9.3K | 980K |
| SR-05R—Improve seismic ruggedness of MCC-7F and MCC-8F | Internal—NA/0 Fire—NA/0 Seismic—NA/19 | Internal—NA/0 Fire—NA/0 Seismic—NA/10 | NA/57K | NA/170K | 150K |
| OT-08R—Install explosion protection around CGS transformers | Internal—NA/1 Fire—NA/0 Seismic—NA/0 | Internal—NA/<1 Fire—NA/0 Seismic—NA/0 | NA/9.4K | NA/23K | 700K |
| FL-05R—Clamp on flow instruments to certain drain lines in the control building of the radwaste building and alarm in the control room | Internal—NA/16 Fire—NA/0 Seismic—NA /0 | Internal—NA/35 Fire—NA/0 Seismic—NA/0 | NA/250K | NA/610K | 250K |
| FL-04R—Add one isolation valve in the SW, turbine SW, and fire protection lines in the control building area of the radwaste building | Internal—NA/17 Fire—NA/0 Seismic—NA/0 | Internal—NA/35 Fire—NA/0 Seismic—NA/0 | NA/260K | NA/620K | 380K |
| FL-06R—Additional non-destructive evaluation (NDE) and inspections (in the control building) | Internal—NA/8 Fire—NA/0 Seismic—NA/0 | Internal—NA/18 Fire—NA/0 Seismic—NA/0 | NA/130K | NA/310K | 14K |

Environmental Impacts of Postulated Accidents

| SAMA ^(a) | % Risk Reduction ^(f) (PSA Revision 6.2/PSA Revision 7.1) ^(c) | | Total Benefit (\$) ^(b, f) (PSA Revision 6.2/PSA Revision 7.1) ^(c) | | Cost (\$) |
|--|---|---|--|---------------------------------|-----------|
| | CDF ^(d) | Pop. Dose ^(d) | Internal External ^(e) | With Uncertainty ^(e) | |
| CC-24R—Backfeed the high-pressure core spray system (HPCS) system with SM-8 to provide a third power source for HPCS | Internal—NA/7 Fire—NA/9 Seismic—NA/0 | Internal—NA/7 Fire—NA/13 Seismic—NA/0 | NA/170K | NA/420K | 105K |
| CC-25R—Enhance alternate injection reliability by including RHR, SW and fire water cross-tie in the maintenance program | Internal—NA/1 Fire—NA/1 Seismic—NA/0 | Internal—NA/1 Fire—NA/<1 Seismic—NA/ <1 | NA/12K | NA/29K | 13K |
| OT-07R—Increase operator training on systems and operator actions determined to be important from the PSA | Internal—NA/25 Fire—NA/5 Seismic—NA/0 | Internal—NA/8 Fire—NA/<1 Seismic—NA/0 | NA/200K | NA/480K | 40K |
| FW-05R—Examine the potential for operators to control reactor feedwater (RFW) and avoid a reactor trip | Internal—NA/3 Fire—NA/7 Seismic—NA/0 | Internal—NA/2 Fire—NA/4 Seismic—NA/0 | NA/72K | NA/180K | 29K |
| FR-09R—Install early fire detection in the following physical analysis units: R-1B, R-1D, and R-1J | Internal—NA/0 Fire—NA/15 Seismic—NA/0 | Internal—NA/0 Fire—NA/7 Seismic—NA/0 | NA/100K | NA/260K | 680K |
| AT-15R—Modifications to make use of HPCS more likely for ATWS (use of auto bypass, installing throttle valve) | Internal—NA/15 Fire—NA/0 Seismic—NA/0 | Internal—NA/1 Fire—NA/0 Seismic—NA/0 | NA/80K | NA/190K | 2.8M |
| OT-09R—For the non-LOCA initiating events, credit the Z (power conversion system recovery) function | Internal—NA/4 Fire—NA/8 Seismic—NA/0 | Internal—NA/5 Fire—NA/13 Seismic—NA/0 | NA/130K | NA/330K | 130K |
| FR-12R—Install early fire detection in the following physical analysis units: T-1A, T-12, T-1C, and T-1D | Internal—NA/0 Fire—NA/12 Seismic—NA/0 | Internal—NA/0 Fire—NA/12 Seismic—NA/0 | NA/110K | NA/270K | 725K |
| FR-11R—Install early fire detection in the following analysis units: RC-02, RC-03, RC-04, RC-05, RC-07, RC-08, RC-11, RC-13, RC-14, and RC-1A | Internal—NA/0 Fire—NA/56 Seismic—NA/0 | Internal—NA/0 Fire—NA/63 Seismic—NA/0 | NA/510K | NA/1.3M | 1.0M |
| FR-10R—Install early fire detection in the main control room: RC-10 | Internal—NA/0 Fire—NA/1 Seismic—NA/0 | Internal—NA/0 Fire—NA/2 Seismic—NA/0 | NA/14K | NA/36K | 535K |
| FL-07R—Protect the HPCS from flooding that results from ISLOCA events | Internal—NA/0 Fire—NA/0 Seismic—NA/0 | Internal—NA/2 Fire—NA/0 Seismic—NA/0 | NA/11K | NA/26K | 1.05M |

| SAMA ^(a) | % Risk Reduction ^(f) (PSA Revision 6.2/PSA Revision 7.1) ^(c) | | Total Benefit (\$) ^(b, f) (PSA Revision 6.2/PSA Revision 7.1) ^(c) | | Cost (\$) |
|--|---|--|--|---------------------------------|-----------|
| | CDF ^(d) | Pop. Dose ^(d) | Internal External ^(e) | With Uncertainty ^(e) | |
| AC/DC-30R—Provide an additional DG diverse from DG-1 and DG-2 | Internal—NA/-4 Fire—NA/20 Seismic—NA/2 | Internal—NA/-1 Fire—NA/18 Seismic—NA/2 | NA/160K | NA/410K | 10M |
| CC-26R—Install hard pipe from diesel fire pump to vessel | Internal—NA/<1 Fire—NA/0 Seismic—NA/0 | Internal—NA /<1 Fire—NA/1 Seismic—NA/0 | NA/5.7K | NA/14K | 710K |
| OT-10R—Increase fire pump house building integrity to withstand higher winds so the fire system will be capable of withstanding a severe weather event | Internal—NA/<1 Fire—NA/0 Seismic—NA/0 | Internal—Na/<1 Fire—NA/0 Seismic—NA/0 | NA/1.5K | NA/3.5K | 735K |
| FW-04—Add a motor-driven feedwater pump | Internal—NA/40 Fire—NA/25 Seismic—NA/0 | Internal—NA/42 Fire—NA/26 Seismic—NA/0 | NA/620K | NA/1.5M | 10M |
| CB-10R—Provide additional NDE and inspections of MS pipe in turbine building | Internal—NA/2 Fire—NA/0 Seismic—NA/0 | Internal—NA/2 Fire—NA/0 Seismic—NA/0 | NA/20K | NA/48K | 125K |

^(a) SAMAs in ***bold italics*** are potentially cost-beneficial.

^(b) This includes dual contribution from internal events as a surrogate for contribution from HFO external events.

^(c) Values are based on both PSA Revisions 6.2 (baseline) and 7.1 (sensitivity) are shown as Revision 6.2/Revision 7.1.

^(d) Negative value indicates increase in risk.

^(e) Negative value indicates non-benefit.

^(f) Key: “<1” indicates value between 0.1 percent and 1 percent; “~0” indicates value <0.1 percent; “0” indicates value reported as zero; “NA” indicates “not analyzed” with respect to PSA Revision 6.2.

1 5.3.5 Conclusions

2 Energy Northwest compiled a list of 151 SAMAs based on a review of the of the dominant
3 cutsets and most significant plant systems from the plant-specific internal events PRA, insights
4 from the plant-specific IPE and IPEEE, Phase II SAMAs from license renewal applications for
5 other plants, and review of other industry documentation. Of these, 123 SAMAs were
6 eliminated qualitatively, leaving 28 candidate SAMAs for evaluation. These, and others
7 subsequently identified as a result of the NRC staff RAIs and further examination by Energy
8 Northwest, underwent more detailed design and cost estimates to show that 16 were potentially
9 cost-beneficial. In the initial baseline analysis, using PSA Revision 6.2, Energy Northwest found
10 that none of the SAMA candidates were potentially cost-beneficial. Energy Northwest then
11 performed additional analyses to evaluate the impact of parameter choices, resulting in the
12 identification of three SAMAs that were potentially cost-beneficial (SAMAs AC/DC-28, FR-07a,
13 and FR-07b). In response to an NRC staff RAI, Energy Northwest evaluated all SAMA
14 candidates using the 95 percentile internal, fire, and seismic event CDFs to account for
15 uncertainties in the PSA models. This analysis identified three additional SAMAs (SAMA
16 CC-03b, FR-08, and HV-02) as being potentially cost-beneficial via PSA Revision 6.2. In
17 response to another NRC staff RAI, Energy Northwest performed a sensitivity study to address

Environmental Impacts of Postulated Accidents

1 concerns regarding a significant update to the CGS PSA model since the SAMA analysis was
2 developed, i.e., using PSA Revision 7.1. Energy Northwest re-evaluated each of the initial 28
3 candidate SAMAs and several additional SAMA candidates to show that 10 additional SAMAs
4 (SAMA SR-05R, FL-05R, FL-04R, FL-06R, CC-24R, CC-25R, OT-07R, FW-05R, OT-09R, and
5 FR-11R) were potentially cost-beneficial. Energy Northwest indicated that all 16 potentially
6 cost-beneficial SAMAs will be further evaluated through the normal processes for evaluating
7 possible plant changes at CGS.

8 The NRC staff reviewed the Energy Northwest analysis and concludes that the methods used,
9 and the implementation of those methods, were acceptable. The treatment of SAMA benefits
10 and costs support the general conclusion that the SAMA evaluations performed by Energy
11 Northwest are reasonable and sufficient for the license renewal submittal. The level of
12 treatment of SAMAs for external events was deemed sufficient to support the conclusion that
13 the likelihood of there being cost-beneficial enhancements in this area was minimized by
14 improvements that have been realized as a result of the IPEEE process, separate analysis of
15 fire and seismic events, and inclusion of a multiplier to account for other external events.
16 Therefore, the NRC staff concurs with Energy Northwest's identification of 16 potentially
17 cost-beneficial SAMAs.

18 Given the potential for cost-beneficial risk reduction, the NRC staff agrees that further evaluation
19 of these 16 SAMAs by Energy Northwest through its long-range planning process is
20 appropriate. One of the SAMAs—SAMA FL-06R—appears to be aging-related. The staff will
21 document the resolution of SAMA FL-06R in the final SEIS. For the other 15 potentially cost-
22 beneficial SAMAs, the staff concludes that the mitigative alternatives do not involve aging
23 management of passive, long-lived systems, structures, and components during the period of
24 extended operation. Therefore, they need not be implemented as part of license renewal
25 pursuant to 10 CFR Part 54.

26 **5.4 References**

27 American Nuclear Society (ANS), "Standard for External Events PRA Methodology,"
28 ANSI/ANS 58.21-2003, La Grange Park, IL, December 2003.

29 American Society of Mechanical Engineers (ASME), "Addenda to ASME RA-S-2002, Standard
30 for Probabilistic Risk Assessment for Nuclear Power Plant Applications," ASME RA-Sa-2003,
31 December 5, 2003.

32 ASME, "Standard for Level 1/Large Early Release Frequency Probabilistic Risk Assessment for
33 Nuclear Power Plant Applications," ASME/ANS RA-S-2008, New York, NY, 2008.

34 Doyle, Daniel, NRC, letter to W. S. Oxenford, Energy Northwest, "Request for Additional
35 Information for the Review of the Columbia Generating Station License Renewal Application—
36 SAMA Review (TAC No. ME3121)," July 1, 2010 (2010a), Agencywide Document Access and
37 Management System (ADAMS) Accession No. ML101760421.

38 Doyle, Daniel, NRC, letter to S. K. Gambhir, Energy Northwest, "Request for Additional
39 Information for the Review of the Columbia Generating Station License Renewal Application—
40 SAMA Review (TAC No. ME3121)," November 10, 2010 (2010b), ADAMS Accession
41 No. ML102870984.

42 Doyle, Daniel, NRC, letter to S. K. Gambhir, Energy Northwest, "Request for Additional
43 Information for the Review of the Columbia Generating Station License Renewal Application—

- 1 SAMA Review (TAC No. ME3121),” December 2, 2010 (2010c), ADAMS Accession
2 No. ML103330246.
- 3 Doyle, Daniel, NRC, letter to S. K. Gambhir, Energy Northwest, “Request for Additional
4 Information for the Review of the Columbia Generating Station License Renewal Application—
5 Severe Accident Mitigation Alternative Review (TAC No. ME3121),” March 10, 2011, ADAMS
6 Accession No. ML110670379.
- 7 Electric Power Research Institute (EPRI), “A Methodology for Assessment of Nuclear Power
8 Plant Seismic Margin,” EPRI NP-6041-SL, Revision 1, Palo Alto, CA, August 1991.
- 9 EPRI, “Fire-Induced Vulnerability Evaluation (FIVE),” EPRI TR-100370, Revision 0, Palo Alto,
10 CA, April 1992.
- 11 EPRI, “Methodology for Developing Seismic Fragilities,” EPRI NP-103059, Palo Alto, CA,
12 April 1994.
- 13 EPRI, “Seismic Probabilistic Risk Assessment Implementation Guide,” EPRI TR-1002989, Palo
14 Alto, CA, December 2003.
- 15 EN, “Columbia Generating Station, License Renewal Application (LRA),” Richland, WA,
16 Appendix E, Document No. 50-397, License No. NPF 21, 2010 (2010a) ADAMS Accession
17 No. ML100250666.
- 18 Gambhir, Sudesh K., Energy Northwest, letter to NRC Document Control Desk, “Columbia
19 Generating Station, Docket No. 50-397, Response to Request for Additional Information,
20 License Renewal Application,” Richland, WA, September 17, 2010, ADAMS Accession
21 No. ML102660151.
- 22 Gambhir, Sudesh K., Energy Northwest, letter to NRC Document Control Desk, “Columbia
23 Generating Station, Docket No. 50-397, Response to Request for Additional Information for the
24 Review of the Columbia Generating Station, License Renewal Application,” Richland, WA,
25 January 28, 2011 (2011a), ADAMS Accession No. ML110330395.
- 26 Gambhir, Sudesh K., Energy Northwest, letter to NRC Document Control Desk, “Columbia
27 Generating Station, Docket No. 50-397, Response to Request for Additional Information for the
28 Review of the Columbia Generating Station, License Renewal Application,” Richland, WA,
29 May 6, 2011 (2011b), ADAMS Accession No. ML11129A186.
- 30 Geomatrix Consultants, Inc. (Geomatrix), “Probabilistic Seismic Hazard Analysis WNP-2
31 Nuclear Power Plant Hanford Washington,” Project No. 1846, December 1994 (1994a).
- 32 Geomatrix, “Probabilistic Seismic Hazard Analysis, DOE Hanford Site, Washington,”
33 WHC-SD-W236-TI-002, Westinghouse Hanford Company, Richland, WA, 1994 (1994b).
- 34 Geomatrix, “Probabilistic Seismic Hazard Analysis, DOE Hanford Site, Washington,”
35 WHC-SD-W236-TI-002 Revision 1a, Westinghouse Hanford Company, Richland, WA, 1996.
- 36 National Academy of Sciences (NAS), “Safety and Security of Commercial Spent Nuclear Fuel
37 Storage,” NAS Committee on the Safety and Security of Commercial Spent Nuclear Fuel
38 Storage, National Academies Press, 2006.

Environmental Impacts of Postulated Accidents

- 1 Parrish, J.V., WPPSS, letter to NRC Document Control Desk, "WNP-2, Operating License
2 NPF-21, Revision 1 to Response to Generic Letter 88-20, 'Individual Plant Examination for
3 Severe Accident Vulnerabilities 10CFR 50.54 (F)," Richland, WA, July 27, 1994, ADAMS
4 Accession No. ML0800904931.
- 5 Parrish, J.V., WPPSS, letter to NRC Document Control Desk, "WNP-2, Operating License
6 NPF-21, Initial Submittal of Individual Plant Examination for External Events (IPEEE) (TAC
7 No. 74489)," Richland, WA, June 26, 1995, ADAMS Accession No. ML0800903630.
- 8 Sorensen, G.C., WPPSS, letter to NRC Document Control Desk, "WNP-2, Operating License
9 NPF-21, Revision 1 to Response to Generic Letter 88-20, 'Individual Plant Examination for
10 Severe Accident Vulnerabilities 10 CFR 50.54 (f)," Richland, WA, August 28, 1992, ADAMS
11 Accession No. ML0800904991.
- 12 *U.S. Code of Federal Regulations (CFR)*, "Domestic Licensing of Production and Utilization
13 Facilities," Part 50, Title 10, "Energy."
- 14 *CFR*, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory
15 Functions," Part 51, Chapter 1, Title 10, "Energy."
- 16 *CFR*, "Requirements for Renewal of Operating Licenses for Nuclear Power Plants," Part 54,
17 Chapter 4, Title 10, "Energy."
- 18 *CFR*, "Reactor Site Criteria," Part 100, Title 10, "Energy."
- 19 U. S. Geologic Survey (USGS), "2008 NSHM Gridded Data, Peak Ground Acceleration," 2008,
20 Available URL: <http://earthquake.usgs.gov/hazards/products/conterminous/2008/data/>.
- 21 U.S. Nuclear Regulatory Commission (NRC), "Reactor Safety Study—An Assessment of
22 Accident Risks in U.S. Commercial Nuclear Power Plants," WASH-1400, NUREG-75/014,
23 October 1975 (1975a).
- 24 U.S. Nuclear Regulatory Commission (NRC), "Standard Review Plan for the Review of Safety
25 Analysis Report for Nuclear Power Plants," NUREG-0800, Washington, D.C., November 1975
26 (1975b).
- 27 NRC, "PRA Procedures Guide: A Guide to the Performance of Probabilistic Risk Assessments
28 for Nuclear Power Plants," NUREG/CR-2300, Washington, D.C., January 1983.
- 29 NRC, "COMPBRN III—A Computer Code for Modeling Compartment Fires," NUREG/CR-4566,
30 July 1986.
- 31 NRC, "Individual Plant Examination for Severe Accident Vulnerabilities," GL 88-20,
32 November 23, 1988. NRC, "Regulatory Analysis for the Resolution of Generic Issue 82—Beyond
33 Design Basis Accidents in Spent Fuel Pools", NUREG-1353, April 1989, ADAMS Accession
34 No. ML082330232.
- 35 NRC, "Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants,"
36 NUREG-1150, Washington, D.C., December 1990.
- 37 NRC, "Procedural and Submittal Guidance for the Individual Plant Examination of External
38 Events (IPEEE)," NUREG-1407, GL 88-20, Supplement 4, Washington, D.C., June 1991
39 (1991a).

- 1 NRC, "Procedural and Submittal Guidance for the Individual Plant Examination of External
2 Events (IPEEE) for Severe Accident Vulnerabilities," NUREG-1407, Washington, D.C.,
3 June 1991 (1991b).
- 4 NRC, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants,"
5 NUREG-1437, Washington, D.C., Volumes 1 and 2, 1996, ADAMS Accession
6 Nos. ML040690705 and ML 040690738.
- 7 NRC, "Individual Plant Examination Program: Perspectives on Reactor Safety and Plant
8 Performance," NUREG-1560, Washington, D.C., 1997 (1997a), ADAMS Accession
9 Nos. ML063550244 and ML063550228.
- 10 NRC, "Regulatory Analysis Technical Evaluation Handbook," NUREG/BR-0184,
11 Washington, D.C., 1997 (1997b), ADAMS Accession No. ML050190193.
- 12 NRC, "Safety Evaluation by the Office of Nuclear Reactor Regulation Related to Individual Plant
13 Examination Washington Public Power Supply System Nuclear Project No. 2, Docket
14 No. 50-397," Washington, D.C., April 8, 1997 (1997c).
- 15 NRC, *Code Manual for MACCS2: Volume 1, User's Guide*, NUREG/CR-6613, Washington,
16 D.C., May 1998.
- 17 NRC, "Technical Study of Spent Fuel Pool Accident Risk at Decommissioning Nuclear Power
18 Plants," NUREG-1738, January 2001 (2001a), ADAMS Accession No. ML010430066.
- 19 NRC, "Review of Columbia Generating Station Individual Plant of Examination of External
20 Events Submittal (TAC Nos. M83695)," Washington, D.C., February 26, 2001 (2001b).
- 21 NRC, "An Approach for Using Probabilistic Risk Assessment in Risk-Informed Decisions on
22 Plant-Specific Changes to the Licensing Basis," RG 1.174, Revision 1, Washington, D.C.,
23 November 2002.
- 24 NRC, "Sector Population, Land Fraction, and Economic Estimation Program," SECPOP:
25 NUREG/CR-6525, Washington D.C., April 2003.
- 26 NRC, "Protecting Our Nation—Since 9-11-01," NUREG/BR-0314, September 2004, Available
27 URL: <http://www.nrc.gov/reading-rm/doc-collections/nuregs/brochures/br0314/br0314.pdf>
- 28 NRC, "Regulatory Analysis Guidelines of the U.S. Nuclear Regulatory Commission,"
29 NUREG/BR-0058, Revision 4, Washington, D.C., September 2004 (2004a), ADAMS Accession
30 No. ML042820192.
- 31 NRC, "An Approach for Determining the Technical Adequacy of Probabilistic Risk Assessment
32 Results for Risk-Informed Activities," RG 1.200 for Trial Use, Washington, D.C., February 2004
33 (2004b).
- 34 NRC, "Safety and Security Improvements at Nuclear Plants," Fact Sheet, Office of Public
35 Affairs, February 2005 (2005a), Available URL:
36 <http://www.nrc.gov/reading-rm/doc-collections/fact-sheets/safety-security.pdf>.
- 37 NRC, "EPRI/NRC-RES Fire PRA Methodology for Nuclear Power Facilities," NUREG/CR-6850,
38 Volume 2, Washington, D.C., 2005 (2005b).

Environmental Impacts of Postulated Accidents

- 1 NRC, "Frequently Asked Questions on License Renewal of Nuclear Power Reactors,"
2 NUREG-1850, March 2006 (2006a), Available URL: [http://www.nrc.gov/reading-rm/doc-](http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr1850/sr1850_faq_lr.pdf)
3 [collections/nuregs/staff/sr1850/sr1850_faq_lr.pdf](http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr1850/sr1850_faq_lr.pdf)
- 4 NRC, "Mitigation of Spent Fuel Loss-of-Coolant Inventory Accidents and Extension of Reference
5 Plant Analyses to Other Spent Fuel Pools," *Sandia Letter Report*," Revision 2, November 2006
6 (2006b), (Official Use Only; Redacted version available).
- 7 NRC, Safety Evaluation of CGS Mitigation Strategies Required by Section B.5.b of Commission
8 Order EA-02-026. August 2007. ADAMS Accession No. ML072200047.
- 9 NRC, Appendices to Safety Evaluation of CGS Mitigation Strategies Required by Section B.5.b
10 of Commission Order EA-02-026. August 2007 (2007a). ADAMS Accession
11 No. ML072210163.
- 12 NRC, "Security Spotlight: Protecting Against Aircraft, Fact Sheet, Office of Public Affairs,"
13 January 2008, (2008a) Available URL:
14 <http://www.nrc.gov/reading-rm/doc-collections/fact-sheets/security-spotlight/aircraft.html>.
- 15 NRC, "Nuclear Security," Backgrounder, Office of Public Affairs, October 2008 (2008b),
16 Available URL: [http://www.nrc.gov/reading-rm/doc-collections/fact-sheets/security-](http://www.nrc.gov/reading-rm/doc-collections/fact-sheets/security-enhancements.html)
17 [enhancements.html](http://www.nrc.gov/reading-rm/doc-collections/fact-sheets/security-enhancements.html).
- 18 NRC, "Request for additional information for the review of the Columbia Generating Station
19 LRA—SAMA review (TAC No. ME3121)," 2010, ADAMS Accession No. ML101760421.
- 20 NRC, "Request for additional information for the review of the Columbia Generating Station
21 LRA—SAMA review (TAC No. ME3121)," 2010, ADAMS Accession No. ML102870984.
- 22 Webring, R.L., Energy Northwest, letter to NRC Document Control Desk, "Columbia Generating
23 Station, Docket No. 50-397, Application for Amendment of Facility Operating License
24 No. NPF-21 for Extension of Diesel Generator Completion Time," Richland, WA, May 19, 2004,
25 ADAMS Accession No. ML102660151.
- 26 Washington, "Department of Revenue Washington State, Property Tax Statistics 2002," 2002,
27 Available URL:
28 [http://dor.wa.gov/Content/AboutUs/StatisticsAndReports/2002/Property_Tax_Statistics_2002/](http://dor.wa.gov/Content/AboutUs/StatisticsAndReports/2002/Property_Tax_Statistics_2002/default.aspx)
29 [default.aspx](http://dor.wa.gov/Content/AboutUs/StatisticsAndReports/2002/Property_Tax_Statistics_2002/default.aspx) (accessed February 2008).

6.0 ENVIRONMENTAL IMPACTS OF THE URANIUM FUEL CYCLE, WASTE MANAGEMENT, AND GREENHOUSE GAS

6.1 The Uranium Fuel Cycle

This chapter addresses issues related to the uranium fuel cycle and waste management during the period of extended operation. The uranium cycle includes uranium mining and milling, the production of uranium hexafluoride, isotopic enrichment, fuel fabrication, reprocessing of irradiated fuel, transportation of radioactive materials, and management of low-level wastes and high-level wastes related to uranium fuel cycle activities. The generic potential impacts of the radiological and non-radiological environmental impacts of the uranium fuel cycle and transportation of nuclear fuel and wastes are described in detail in the Generic Environmental Impact Statement (GEIS) (NRC, 1996), (NRC, 1999) based, in part, on the generic impacts given in Section 51.51 of Title 10 of the *Code of Federal Regulations* (10 CFR 51.51), Table S-3, "Table of Uranium Fuel Cycle Environmental Data," and in 10 CFR 51.52(c), Table S-4, "Environmental Impact of Transportation of Fuel and Waste to and from One Light-Water-Cooled Nuclear Power Reactor."

Nine generic issues are related to the fuel cycle and waste management. These are shown in Table 6.1-1. There are no site-specific issues.

Table 6.1-1. Issues related to the uranium fuel cycle and waste management

| Issues | GEIS sections | Category |
|---|---|----------|
| Offsite radiological impacts (individual effects from other than the disposal of spent fuel & high level waste) | 6.1; 6.2.1; 6.2.2.1; 6.2.2.3; 6.2.3; 6.2.4; 6.6 | 1 |
| Offsite radiological impacts (collective effects) | 6.1; 6.2.2.1; 6.2.3; 6.2.4; 6.6 | 1 |
| Offsite radiological impacts (spent fuel & high level waste disposal) | 6.1; 6.2.2.1; 6.2.3; 6.2.4; 6.6 | 1 |
| Non-radiological impacts of the uranium fuel cycle | 6.1; 6.2.2.6; 6.2.2.7; 6.2.2.8; 6.2.2.9; 6.2.3; 6.2.4; 6.6 | 1 |
| Low-level waste storage & disposal | 6.1; 6.2.2.2; 6.4.2; 6.4.3; 6.4.3.1; 6.4.3.2; 6.4.3.3; 6.4.4; 6.4.4.1; 6.4.4.2; 6.4.4.3; 6.4.4.4; 6.4.4.5; 6.4.4.5.1; 6.4.4.5.2; 6.4.4.5.3; 6.4.4.5.4; 6.4.4.6; 6.6 | 1 |
| Mixed waste storage & disposal | 6.4.5.1; 6.4.5.2; 6.4.5.3; 6.4.5.4; 6.4.5.5; 6.4.5.6; 6.4.5.6.1; 6.4.5.6.2; 6.4.5.6.3; 6.4.5.6.4; 6.6 | 1 |
| Onsite spent fuel | 6.1; 6.4.6; 6.4.6.1; 6.4.6.2; 6.4.6.3; 6.4.6.4; 6.4.6.5; 6.4.6.6; 6.4.6.7; 6.6 | 1 |
| Non-radiological waste | 6.1; 6.5; 6.5.1; 6.5.2; 6.5.3; 6.6 | 1 |
| Transportation | 6.1; 6.3.1; 6.3.2.3; 6.3.3; 6.3.4; 6.6, Addendum 1 | 1 |

U.S. Nuclear Regulatory Commission (NRC) staff (staff) did not find any new and significant information related to the uranium fuel cycle during the review of the Columbia Generating Station (CGS) environmental report (ER) (EN, 2010), the site visit, and the scoping process. Therefore, there are no impacts related to these issues beyond those discussed in the GEIS. For these Category 1 issues, the GEIS concludes that the impacts are SMALL, except for the

1 offsite radiological collective impacts from the fuel cycle and from high-level waste and spent
2 fuel disposal, which the NRC concluded are acceptable.

3 **6.2 Greenhouse Gas Emissions**

4 This section discusses the potential impacts from greenhouse gases (GHGs) emitted from the
5 nuclear fuel cycle. The GEIS does not directly address these emissions, and its discussion is
6 limited to an inference that substantial carbon dioxide (CO₂) emissions may occur if coal- or
7 oil-fired alternatives to license renewal are carried out.

8 **6.2.1 Existing Studies**

9 Since the development of the GEIS, the relative volumes of GHGs emitted by nuclear and other
10 electricity generating methods have been widely studied. However, estimates and projections
11 of the carbon footprint of the nuclear power lifecycle vary depending on the type of study done.
12 Additionally, considerable debate also exists among researchers on the relative effects of
13 nuclear and other forms of electricity generation on GHG emissions. Existing studies on GHG
14 emissions from nuclear power plants generally take two different forms:

- 15 (1) qualitative discussions of the potential to use nuclear power to reduce GHG emissions
16 and mitigate global warming
- 17 (2) technical analyses and quantitative estimates of the actual amount of GHGs generated
18 by the nuclear fuel cycle or entire nuclear power plant life cycle and comparisons to the
19 operational or life cycle emissions from other energy generation alternatives

20 **6.2.1.1 Qualitative Studies**

21 The qualitative studies consist primarily of broad, large-scale public policy, or investment
22 evaluations of whether an expansion of nuclear power is likely to be a technically, economically,
23 or politically workable means of achieving global GHG reductions. Studies found by the staff
24 during the subsequent literature search include the following:

- 25 • Evaluations to determine if investments in nuclear power in developing countries should
26 be accepted as a flexibility mechanism to assist industrialized nations in achieving their
27 GHG reduction goals under the Kyoto Protocols (Schneider, 2000), (IAEA, 2000),
28 (NEA, 2002). Ultimately, the parties to the Kyoto Protocol did not approve nuclear power
29 as a component under the clean development mechanism (CDM) due to safety and
30 waste disposal concerns (NEA, 2002).
- 31 • Analyses developed to assist governments, including the U.S., in making long-term
32 investment and public policy decisions in nuclear power (Keepin, 1988), (Hagen et
33 al., 2001), (MIT, 2003).

34 Although the qualitative studies sometimes reference and critique the existing quantitative
35 estimates of GHGs produced by the nuclear fuel cycle or life cycle, their conclusions generally
36 rely heavily on discussions of other aspects of nuclear policy decisions and investment such as
37 safety, cost, waste generation, and political acceptability. Therefore, these studies are typically
38 not directly applicable to an evaluation of GHG emissions associated with the proposed license
39 renewal for a given nuclear power plant.

1 **6.2.1.2 Quantitative Studies**

2 A large number of technical studies, including calculations and estimates of the amount of
3 GHGs emitted by nuclear and other power generation options, are available in the literature and
4 were useful to the staff's efforts in addressing relative GHG emission levels. Examples of these
5 studies include—but are not limited to—Mortimer (1990), Andseta et al. (1998), Spadaro (2000),
6 Storm van Leeuwen and Smith (2005), Fritsche (2006), Parliamentary Office of Science and
7 Technology (POST) (2006), Atomic Energy Authority (AEA) (2006), Weisser (2006), Fthenakis
8 and Kim (2007), and Dones (2007).

9 Comparing these studies and others like them is difficult because the assumptions and
10 components of the lifecycles the authors evaluate vary widely. Examples of areas in which
11 differing assumptions make comparing the studies difficult include the following:

- 12 • energy sources that may be used to mine uranium deposits in the future
- 13 • reprocessing or disposal of spent nuclear fuel
- 14 • current and potential future processes to enrich uranium and the energy sources that will
15 power them
- 16 • estimated grades and quantities of recoverable uranium resources
- 17 • estimated grades and quantities of recoverable fossil fuel resources
- 18 • estimated GHG emissions other than CO₂, including the conversion to CO₂ equivalents
19 per unit of electric energy produced
- 20 • performance of future fossil fuel power systems
- 21 • projected capacity factors for alternatives means of generation
- 22 • current and potential future reactor technologies

23 In addition, studies may vary with respect to whether all or parts of a power plant's lifecycle are
24 analyzed, i.e., a full lifecycle analysis will typically address plant construction, operations,
25 resource extraction (for fuel and construction materials), and decommissioning, whereas, a
26 partial lifecycle analysis primarily focus on operational differences.

27 In the case of license renewal, a GHG analysis for that portion of the plant's lifecycle (operation
28 for an additional 20 years) would not involve GHG emissions associated with construction
29 because construction activities have already been completed at the time of relicensing. In
30 addition, the proposed action of license renewal would also not involve additional GHG
31 emissions associated with facility decommissioning, because that decommissioning must occur
32 whether the facility is relicensed or not. However, in some of the above-mentioned studies, the
33 specific contribution of GHG emissions from construction, decommissioning, or other portions of
34 a plant's lifecycle cannot be clearly separated from one another. In such cases, an analysis of
35 GHG emissions would overestimate the GHG emissions attributed to a specific portion of a
36 plant's lifecycle. Nonetheless, these studies supply some meaningful information with respect
37 to the relative magnitude of the emissions among nuclear power plants and other forms of
38 electric generation, as discussed in the following sections.

39 In Tables 6.2-1, 6.2--2, and 6.2-3, the staff presents the results of the above-mentioned
40 quantitative studies to supply a weight-of-evidence evaluation of the relative GHG emissions
41 that may result from the proposed license renewal as compared to the potential alternative use

Environmental Impacts of the Uranium Fuel Cycle,
Waste Management, and Greenhouse Gas

1 of coal-fired, natural gas-fired, and renewable generation. Most studies from Mortimer (1990)
2 onward suggest that uranium ore grades and uranium enrichment processes are leading
3 determinants in the ultimate GHG emissions attributable to nuclear power generation. These
4 studies show that the relatively lower order of magnitude of GHG emissions from nuclear power,
5 when compared to fossil-fueled alternatives (especially natural gas), could potentially disappear
6 if available uranium ore grades drop sufficiently while enrichment processes continued to rely on
7 the same technologies.

8 **6.2.1.3 Summary of Nuclear Greenhouse Gas Emissions Compared to Coal**

9 Considering that coal fuels the largest share of electricity generation in the U.S. and that its
10 burning results in the largest emissions of GHGs for any of the likely alternatives to nuclear
11 power generation, including CGS, most of the available quantitative studies focused on
12 comparisons of the relative GHG emissions of nuclear to coal-fired generation. The quantitative
13 estimates of the GHG emissions associated with the nuclear fuel cycle (and, in some cases, the
14 nuclear lifecycle), as compared to an equivalent coal-fired plant, are presented in Table 6.2-1.
15 The following chart does not include all existing studies, but it gives an illustrative range of
16 estimates developed by various sources.

17 **Table 6.2-1. Nuclear greenhouse gas emissions compared to coal**

| Source | GHG emission results |
|--|--|
| Mortimer (1990) | Nuclear—230,000 tons CO ₂ Coal—5,912,000 tons CO ₂ Note: Future GHG emissions from nuclear to increase because of declining ore grade. |
| Andseta et al. (1998) | Nuclear energy produces 1.4% of the GHG emissions compared to coal. Note: Future reprocessing and use of nuclear-generated electrical power in the mining and enrichment steps are likely to change the projections of earlier authors, such as Mortimer (1990). |
| Spadaro (2000) | Nuclear—2.5–5.7 g C _{eq} /kWh Coal—264–357 g C _{eq} /kWh |
| Storm van Leeuwen & Smith (2005) | Authors did not evaluate nuclear versus coal. |
| Fritsche (2006) (Values estimated from graph in Figure 4) | Nuclear—33 g C _{eq} /kWh Coal—950 g C _{eq} /kWh |
| POST (2006) (Nuclear calculations from AEA, 2006) | Nuclear—5 g C _{eq} /kWh Coal—>1000 g C _{eq} /kWh Note: Decrease of uranium ore grade to 0.03% would raise nuclear to 6.8 g C _{eq} /kWh. Future improved technology and carbon capture and storage could reduce coal-fired GHG emissions by 90%. |
| Weisser (2006) (Compilation of results from other studies) | Nuclear—2.8–24 g C _{eq} /kWh Coal—950–1250 g C _{eq} /kWh |
| Fthenakis & Kim (2007) | Authors did not evaluate nuclear versus coal. |
| Dones (2007) | Author did not evaluate nuclear versus coal. |

1 **6.2.1.4 Summary of Nuclear Greenhouse Gas Emissions Compared to Natural Gas**

2 The quantitative estimates of the GHG emissions associated with the nuclear fuel cycle (and, in
3 some cases, the nuclear lifecycle), as compared to an equivalent natural gas-fired plant, are
4 presented in Table 6.2-2. The following chart does not include all existing studies, but it gives
5 an illustrative range of estimates developed by various sources.

6 **Table 6.2-2. Nuclear greenhouse gas emissions compared to natural gas**

| Source | GHG emission results |
|--|--|
| Mortimer (1990) | Author did not evaluate nuclear versus natural gas. |
| Andseta et al. (1998) | Author did not evaluate nuclear versus natural gas. |
| Spadaro (2000) | Nuclear—2.5–5.7 g C _{eq} /kWh Natural Gas—120–188 g C _{eq} /kWh |
| Storm van Leeuwen & Smith (2005) | Nuclear fuel cycle produces 20–33% of the GHG emissions compared to natural gas (at high ore grades). Note: Future nuclear GHG emissions to increase because of declining ore grade. |
| Fritsche (2006) (Values estimated from graph in Figure 4) | Nuclear—33 g C _{eq} /kWh Cogeneration Combined Cycle Natural Gas—150 g C _{eq} /kWh |
| POST (2006) (Nuclear calculations from AEA, 2006) | Nuclear—5 g C _{eq} /kWh Natural Gas—500 g C _{eq} /kWh Note: Decrease of uranium ore grade to 0.03% would raise nuclear to 6.8 g C _{eq} /kWh. Future improved technology and carbon capture and storage could reduce natural gas GHG emissions by 90%. |
| Weisser (2006) (Compilation of results from other studies) | Nuclear—2.8–24 g C _{eq} /kWh Natural Gas—440–780 g C _{eq} /kWh |
| Fthenakis & Kim (2007) | Authors did not evaluate nuclear versus natural gas. |
| Dones (2007) | Author critiqued methods and assumptions of Storm van Leeuwen and Smith (2005), and concluded that the nuclear fuel cycle produces 15–27% of the GHG emissions of natural gas. |

7 **6.2.1.5 Summary of Nuclear Greenhouse Gas Emissions Compared to Renewable**
8 **Energy Sources**

9 The quantitative estimates of the GHG emissions associated with the nuclear fuel cycle, as
10 compared to equivalent renewable energy sources, are presented in Table 6.2-3. Calculation of
11 GHG emissions associated with these sources is more difficult than the calculations for nuclear
12 energy and fossil fuels because of the large variation in efficiencies due to their different
13 sources and locations. For example, the efficiency of solar and wind energy is highly dependent
14 on the location in which the power generation facility is installed. Similarly, the range of GHG
15 emissions estimates for hydropower varies greatly depending on the type of dam or reservoir
16 involved (if used at all). Therefore, the GHG emissions estimates for these energy sources
17 have a greater range of variability than the estimates for nuclear and fossil fuel sources. As
18 noted in Section 6.2.1.2, the following chart does not include all existing studies, but it gives an
19 illustrative range of estimates developed by various sources.

1 **Table 6.2-3. Nuclear greenhouse gas emissions compared to renewable energy sources**

| Source | GHG emission results |
|--|---|
| Mortimer (1990) | Nuclear—230,000 tons CO ₂ Hydropower—78,000 tons CO ₂ Wind power—54,000 tons CO ₂ Tidal power—52,500 tons CO ₂ Note: Future GHG emissions from nuclear are expected to increase because of declining ore grade. |
| Andseta et al. (1998) | Author did not evaluate nuclear versus renewable energy sources. |
| Spadaro (2000) | Nuclear—2.5–5.7 g C _{eq} /kWh Solar PV—27.3–76.4 g C _{eq} /kWh Hydroelectric—1.1–64.6 g C _{eq} /kWh Biomass—8.4–16.6 g C _{eq} /kWh Wind—2.5–13.1 g C _{eq} /kWh |
| Storm van Leeuwen & Smith (2005) | Author did not evaluate nuclear versus renewable energy sources. |
| Fritsche (2006) (Values estimated from graph in Figure 4) | Nuclear—33 g C _{eq} /kWh Solar PV—125 g C _{eq} /kWh Hydroelectric—50 g C _{eq} /kWh Wind—20 g C _{eq} /kWh |
| POST (2006) (Nuclear calculations from AEA, 2006) | Nuclear—5 g C _{eq} /kWh Biomass—25–93 g C _{eq} /kWh Solar PV—35–58 g C _{eq} /kWh Wave/Tidal—25–50 g C _{eq} /kWh Hydroelectric—5–30 g C _{eq} /kWh Wind—4.64–5.25 g C _{eq} /kWh Note: Decrease of uranium ore grade to 0.03% would raise nuclear to 6.8 g C _{eq} /kWh. |
| Weisser (2006) (Compilation of results from other studies) | Nuclear—2.8–24 g C _{eq} /kWh Solar PV—43–73 g C _{eq} /kWh Hydroelectric—1–34 g C _{eq} /kWh Biomass—35–99 g C _{eq} /kWh Wind—8–30 g C _{eq} /kWh |
| Fthenakis & Kim (2007) | Nuclear—16–55 g C _{eq} /kWh Solar PV—17–49 g C _{eq} /kWh |
| Dones (2007) | Author did not evaluate nuclear versus renewable energy sources. |

2 **6.2.2 Conclusions: Relative Greenhouse Gas Emissions**

3 The sampling of data presented in Tables 6.2-1, 6.2-2, and 6.2-3 demonstrates the challenges
4 of any attempt to determine the specific amount of GHG emission attributable to nuclear energy
5 production sources, as different assumptions and calculation methods will yield differing results.
6 The differences and complexities in these assumptions and analyses will further increase when
7 they are used to project future GHG emissions. Nevertheless, several conclusions can be
8 drawn from the information presented.

9 First, the various studies show a general consensus that nuclear power currently produces
10 fewer GHG emissions than fossil-fuel-based electrical generation, e.g., the GHG emissions from
11 a complete nuclear fuel cycle currently range from 2.5–55 grams of Carbon equivalent per
12 Kilowatt hour (g C_{eq}/kWh), as compared to the use of coal plants (264–1250 g C_{eq}/kWh) and
13 natural gas plants (120–780 g C_{eq}/kWh). The studies also give estimates of GHG emissions

1 from five renewable energy sources based on current technology. These estimates included
2 solar-photovoltaic (17–125 g C_{eq}/kWh), hydroelectric (1–64.6 g C_{eq}/kWh), biomass (8.4–
3 99 g C_{eq}/kWh), wind (2.5–30 g C_{eq}/kWh), and tidal (25–50 g C_{eq}/kWh). The range of these
4 estimates is wide, but the general conclusion is that current GHG emissions from the nuclear
5 fuel cycle are of the same order of magnitude as from these renewable energy sources.

6 Second, the studies show no consensus on future relative GHG emissions from nuclear power
7 and other sources of electricity. There is substantial disagreement among the various authors
8 about the GHG emissions associated with declining uranium ore concentrations, future uranium
9 enrichment methods, and other factors, including changes in technology. Similar disagreement
10 exists about future GHG emissions associated with coal and natural gas for electricity
11 generation. Even the most conservative studies conclude that the nuclear fuel cycle currently
12 produces fewer GHG emissions than fossil-fuel-based sources and is expected to continue to
13 do so in the near future. The primary difference between the authors is the projected cross-over
14 date (the time at which GHG emissions from the nuclear fuel cycle exceed those of
15 fossil-fuel-based sources) or whether cross-over will actually occur.

16 Considering the current estimates and future uncertainties, it appears that GHG emissions
17 associated with the proposed CGS relicensing action are likely to be lower than those
18 associated with fossil-fuel-based energy sources. The staff bases this conclusion on the
19 following rationale:

- 20 • As shown in Tables 6.2-1 and 6.2-2, the current estimates of GHG emissions from the
21 nuclear fuel cycle are far below those for fossil-fuel-based energy sources.
- 22 • CGS license renewal may involve continued GHG emissions due to uranium mining,
23 processing, and enrichment, but will not result in increased GHG emissions associated
24 with plant construction or decommissioning (as the plant will have to be decommissioned
25 at some point whether the license is renewed or not).
- 26 • Few studies predict that nuclear fuel cycle emissions will exceed those of fossil fuels
27 within a timeframe that includes the CGS periods of extended operation. Several
28 studies suggest that future extraction and enrichment methods, the potential for higher-
29 grade resource discovery, and technology improvements could extend this timeframe.

30 With respect to comparison of GHG emissions among the proposed CGS license renewal action
31 and renewable energy sources, it appears likely that there will be future technology
32 improvements and changes in the type of energy used for mining, processing, and constructing
33 facilities of all types. Currently, the GHG emissions associated with the nuclear fuel cycle and
34 renewable energy sources are within the same order of magnitude. Because nuclear fuel
35 production is the most significant contributor to possible future increases in GHG emissions
36 from nuclear power—and because most renewable energy sources lack a fuel component—it is
37 likely that GHG emissions from renewable energy sources would be lower than those
38 associated with CGS at some point during the period of extended operation.

39 The staff also supplies an additional discussion about the contribution of GHG to cumulative air
40 quality impacts in Section 4.11.7 of this SEIS.

41 **6.3 References**

42 AEA Technology (AEA), “Carbon Footprint of the Nuclear Fuel Cycle, Briefing Note,” Prepared
43 for British Energy, March 2006.

Environmental Impacts of the Uranium Fuel Cycle,
Waste Management, and Greenhouse Gas

- 1 Andseta et al., "CANDU Reactors and Greenhouse Gas Emissions," Canadian Nuclear
2 Association, 11th Pacific Basin Nuclear Conference, Banff, Alberta, Canada, May 1998.
- 3 Dones, R., "Critical Note on the Estimation by Storm Van Leeuwen J.W., and Smith P. of the
4 Energy Uses and Corresponding CO₂ Emissions for the Complete Nuclear Energy Chain," Paul
5 Sherer Institute, April 2007.
- 6 Energy Northwest (EN), "License Renewal Application, Columbia Generating Station,"
7 Appendix E, 2010, ADAMS Accession No. ML100250666.
- 8 Fritsche, U.R., "Comparison of Greenhouse-Gas Emissions and Abatement Cost of Nuclear and
9 Alternative Energy Options from a Life-Cycle Perspective," Oko-Institut, Darmstadt Office,
10 January 2006.
- 11 Fthenakis, V.M. and H.C. Kim, "Greenhouse-Gas Emissions from Solar-Electric and Nuclear
12 Power: A Life Cycle Study," *Energy Policy*, Volume 35, Number 4, 2007.
- 13 Hagen, R.E., J.R. Moens, and Z.D. Nikodem, "Impact of U.S. Nuclear Generation on
14 Greenhouse Gas Emissions," International Atomic Energy Agency, Vienna, Austria,
15 November 2001.
- 16 International Atomic Energy Agency (IAEA), "Nuclear Power for Greenhouse Gas Mitigation
17 under the Kyoto Protocol: The Clean Development Mechanism (CDM)," November 2000.
- 18 Keepin, B., "Greenhouse Warming: Efficient Solution of Nuclear Nemesis?," Rocky Mountain
19 Institute, Joint Hearing on Technologies for Remediating Global Warming, Subcommittee on
20 Natural Resources, Agriculture Research and Environment and Subcommittee on Science,
21 Research and Technology, U.S. House of Representatives, June 1988.
- 22 Massachusetts Institute of Technology (MIT), "The Future of Nuclear Power: An Interdisciplinary
23 MIT Study," 2003.
- 24 Mortimer, N., "World Warms to Nuclear Power," *SCRAM Safe Energy Journal*, December 1989
25 and January 1990 (1990), Available URL:
26 http://www.no2nuclearpower.org.uk/articles/mortimer_se74.php (accessed July 15, 2010).
- 27 Nuclear Energy Agency (NEA), *Nuclear Energy and the Kyoto Protocol*, Organization for
28 Economic Co-Operation and Development, 2002.
- 29 Parliamentary Office of Science and Technology (POST), "Carbon Footprint of Electricity
30 Generation," Postnote, Number 268, October 2006.
- 31 Schneider, M., *Climate Change and Nuclear Power*, World Wildlife Fund for Nature, April 2000.
- 32 Spadaro, J.V., L. Langlois, and B. Hamilton., "Greenhouse Gas Emissions of Electricity
33 Generation Chains: Assessing the Difference," *IAEA Bulletin 42/2/2000*, Vienna, Austria, 2000.
- 34 Storm van Leeuwen, J.W. and P. Smith, *Nuclear Power—The Energy Balance*, August 2005.
- 35 *U.S. Code of Federal Regulations* (CFR), "Environmental Protection Regulations for Domestic
36 Licensing and Related Regulatory Functions," Part 51, Chapter 1, Title 10, "Energy."

- 1 CFR, "Requirements for Renewal of Operating Licenses for Nuclear Power Plants," Part 54,
2 Chapter 1, Title 10, "Energy."
- 3 U.S. Nuclear Regulatory Commission (NRC), "*Generic Environmental Impact Statement for*
4 *License Renewal of Nuclear Plants*," NUREG-1437, Washington, D.C., Volumes 1 and 2, 1996,
5 ADAMS Accession Nos. ML040690705 and ML040690738.
- 6 NRC, "*Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Main*
7 *Report*," NUREG-1437, Washington, D.C., Section 6.3, Table 9.1, 1999, Volume 1,
8 Addendum 1, ADAMS Accession No. ML040690720.
- 9 Weisser, D., "A Guide to Life-Cycle Greenhouse Gas (GHG) Emissions from Electric Supply
10 Technologies," 2006, Available URL:
11 [http://www.iaea.org/OurWork/ST/NE/Pess/assets/GHG_manuscript_pre-print_versionDanielWei](http://www.iaea.org/OurWork/ST/NE/Pess/assets/GHG_manuscript_pre-print_versionDanielWeisser.pdf)
12 [sser.pdf](http://www.iaea.org/OurWork/ST/NE/Pess/assets/GHG_manuscript_pre-print_versionDanielWeisser.pdf) (accessed November 24, 2010).

7.0 ENVIRONMENTAL IMPACTS OF DECOMMISSIONING

Environmental impacts from the activities associated with the decommissioning of any reactor before or at the end of an initial or renewed license are evaluated in the “Generic Environmental Impact Statement on Decommissioning of Nuclear Facilities: Supplement 1, Regarding the Decommissioning of Nuclear Power Reactors,” NUREG-0586, Supplement 1 (NRC 2002). The U.S. Nuclear Regulatory Commission (NRC) staff’s (staff’s) evaluation of the environmental impacts of decommissioning—presented in NUREG-0586, Supplement 1—notes a range of impacts for each environmental issue.

Additionally, the incremental environmental impacts associated with decommissioning activities resulting from continued plant operation during the renewal term are discussed in the “Generic Environmental Impact Statement for License Renewal of Nuclear Plants (GEIS),” NUREG-1437, Volumes 1 and 2 (NRC 1996), (NRC 1999). The GEIS includes a determination of whether the analysis of the environmental issue could be applied to all plants and whether additional mitigation measures would be warranted. Issues were then assigned a Category 1 or a Category 2 designation. Section 1.4 in Chapter 1 explains the criteria for Category 1 and Category 2 issues and defines the impact designations of SMALL, MODERATE, and LARGE. The staff analyzed site-specific issues (Category 2) for Columbia Generating Station (CGS) and assigned them a significance level of SMALL, MODERATE, or LARGE, or not applicable to CGS because of site characteristics or plant features. There are no Category 2 issues related to decommissioning.

7.1 Decommissioning

Table 7.1-1 lists the Category 1 issues in Table B-1 of Title 10 of the *Code of Federal Regulations* (CFR) Part 51, Subpart A, Appendix B that are applicable to CGS decommissioning following the renewal term.

Table 7.1-1. Issues related to decommissioning

| Issues | GEIS section | Category |
|-----------------------|--------------|----------|
| Radiation doses | 7.3.1; 7.4 | 1 |
| Waste management | 7.3.2; 7.4 | 1 |
| Air quality | 7.3.3; 7.4 | 1 |
| Water quality | 7.3.4; 7.4 | 1 |
| Ecological resources | 7.3.5; 7.4 | 1 |
| Socioeconomic impacts | 7.3.7; 7.4 | 1 |

Decommissioning would occur whether CGS were shut down at the end of its current operating license or at the end of the period of extended operation. There are no site-specific issues related to decommissioning.

A brief description of the staff’s review and the GEIS conclusions, as codified in Table B-1, 10 CFR Part 51, for each of the issues follows:

Radiation doses. Based on information in the GEIS, the NRC noted that “[d]oses to the public will be well below applicable regulatory standards regardless of which decommissioning method

Environmental Impacts of Decommissioning

1 is used. Occupational doses would increase no more than 1 person-rem (1 person-mSv)
2 caused by buildup of long-lived radionuclides during the license renewal term.”

3 Waste management. Based on information in the GEIS, the NRC noted that
4 “[d]ecommissioning at the end of a 20-year license renewal period would generate no more
5 solid wastes than at the end of the current license term. No increase in the quantities of
6 Class C or greater than Class C wastes would be expected.”

7 Air quality. Based on information in the GEIS, the NRC noted that “[a]ir quality impacts of
8 decommissioning are expected to be negligible either at the end of the current operating term or
9 at the end of the license renewal term.”

10 Water quality. Based on information in the GEIS, the NRC noted that “[t]he potential for
11 significant water quality impacts from erosion or spills is no greater whether decommissioning
12 occurs after a 20-year license renewal period or after the original 40-year operation period, and
13 measures are readily available to avoid such impacts.”

14 Ecological resources. Based on information in the GEIS, the NRC noted that
15 “[d]ecommissioning after either the initial operating period or after a 20-year license renewal
16 period is not expected to have any direct ecological impacts.”

17 Socioeconomic Impacts. Based on information in the GEIS, the NRC noted that
18 “[d]ecommissioning would have some short-term socioeconomic impacts. The impacts would
19 not be increased by delaying decommissioning until the end of a 20-year relicense period, but
20 they might be decreased by population and economic growth.”

21 Energy Northwest stated in its environmental report (ER) that it is not aware of any new and
22 significant information on the environmental impacts of CGS license renewal (EN, 2010). The
23 staff has not found any new and significant information during its independent review of the
24 Energy Northwest ER, the site visit, the scoping process, or its evaluation of other available
25 information. Therefore, the NRC staff concludes that there are no impacts related to these
26 issues, beyond those discussed in the GEIS. For all of these issues, the NRC staff concluded in
27 the GEIS that the impacts are SMALL, and additional plant-specific mitigation measures are not
28 likely to be sufficiently beneficial to be warranted.

29 **7.2 References**

30 Energy Northwest (EN), “Appendix E, Applicant’s Environmental Report Operating License
31 Renewal Stage,” License Renewal Application, Columbia Generating Station, 2010, ADAMS
32 Accession No. ML100250666.

33 *U.S. Code of Federal Regulations* (CFR), “Environmental Protection Regulations for Domestic
34 Licensing and Related Regulatory Functions,” Part 51, Chapter 1, Title 10, “Energy.”

35 U.S. Nuclear Regulatory Commission (NRC), “Generic Environmental Impact Statement for
36 License Renewal of Nuclear Plants,” NUREG-1437, Washington, D.C., Volumes 1 and 2, 1996,
37 Agencywide Document Access and Management System (ADAMS) Nos. ML040690705 and
38 ML040690738.

39 NRC, “Section 6.3 – Transportation, Table 9.1, Summary of Findings on NEPA Issues for
40 License Renewal of Nuclear Power Plants, Final Report,” Generic Environmental Impact

- 1 Statement for License Renewal of Nuclear Plants, NUREG-1437, Washington, D.C., Volume 1,
- 2 Addendum 1, 1999, ADAMS Accession No. ML040690720.

- 3 NRC, "Generic Environmental Impact Statement on Decommissioning of Nuclear Facilities:
- 4 Supplement 1, Regarding the Decommissioning of Nuclear Power Reactors" NUREG-0586,
- 5 Washington, D.C., Volumes 1 and 2, Supplement 1, 2002, ADAMS Accession
- 6 Nos. ML023500295 and ML023500395.

8.0 ENVIRONMENTAL IMPACTS OF ALTERNATIVES

The National Environmental Policy Act (NEPA) requires the consideration of a range of reasonable alternatives to the proposed action in an environmental impact statement (EIS). In this case, the proposed action is whether to issue a renewed license for Columbia Generating Station (CGS), which will allow the plant to operate for 20 years beyond its current license expiration date. A license is just one of many conditions that a licensee must meet in order to operate its nuclear plant. State regulatory agencies and the owners of the nuclear power plant ultimately decide whether the plant will operate, and economic and environmental considerations play a primary role in this decision. The U.S. Nuclear Regulatory Commission's (NRC) responsibility is to ensure the safe operation of nuclear power facilities and not to formulate energy policy or encourage or discourage the development of alternative power generation.

The license renewal process is designed to assure safe operation of the nuclear power plant and protection of the environment during the license renewal term. Under the NRC's environmental protection regulations in Title 10, Part 51, of the *Code of Federal Regulations* (10 CFR Part 51), which implement Section 102(2) of NEPA, renewal of a nuclear power plant operating license requires the preparation of an EIS.

To support the preparation of these EISs, the NRC prepared the "Generic Environmental Impact Statement for License Renewal of Nuclear Plants (GEIS)," NUREG-1437, in 1996 (NRC, 1996), (NRC, 1999). The 1996 GEIS for license renewal was prepared to assess the environmental impacts associated with the continued operation of nuclear power plants during the license renewal term. The intent was to determine which environmental impacts would result in essentially the same impact at all nuclear power plants and which ones could result in different levels of impacts at different plants and would require a plant-specific analysis to determine the impacts. For those issues that could not be generically addressed, the NRC will develop a plant-specific supplemental EIS (SEIS) to the GEIS.

Pursuant to 10 CFR 51.71(d), regulations for license renewal require that a SEIS consider the following:

Consider and weigh the environmental effects of the proposed action [license renewal]; the environmental impacts of alternatives to the proposed action; and alternatives available for reducing or avoiding adverse environmental effects and consideration of the economic, technical, and other benefits and costs of the proposed action.

In this chapter, the potential environmental impacts of alternatives to license renewal for CGS are examined as well as alternatives that may reduce or avoid adverse environmental impacts from license renewal, when and where these alternatives are applicable.

While the 1996 GEIS reached generic conclusions regarding many environmental issues associated with license renewal, it did not determine which alternatives are reasonable or reach conclusions about site-specific environmental impact levels. As such, the NRC must evaluate environmental impacts of alternatives on a site-specific basis.

Environmental Impacts of Alternatives

1 As stated in Chapter 1 of this SEIS, alternatives to
2 the proposed action of license renewal for CGS must
3 meet the purpose and need for issuing a renewed
4 license; they must do the following:

5 provide an option that allows for power
6 generation capability beyond the term of a
7 current nuclear power plant operating license
8 to meet future system generating needs, as
9 such needs may be determined by State,
10 utility, and, where authorized, Federal (other
11 than NRC) decision makers (NRC, 1996)

12 The NRC ultimately makes no decision about which
13 alternative (or the proposed action) to carry out
14 because that decision falls to the appropriate
15 energy-planning decisionmakers to decide.
16 Comparing the environmental effects of these
17 alternatives will help the NRC decide if the adverse
18 environmental impacts of license renewal are great
19 enough to deny the option of license renewal for energy-planning decisionmakers
20 (10 CFR 51.95(c)(4)). If the NRC acts to issue a renewed license, all of the alternatives,
21 including the proposed action, will be available to energy-planning decisionmakers. If NRC
22 decides not to renew the license (or takes no action at all), then energy-planning
23 decisionmakers may no longer elect to continue operating CGS and will have to resort to
24 another alternative—which may or may not be one of the alternatives considered in this
25 section—to meet their energy needs now being satisfied by CGS.

26 In evaluating alternatives to license renewal, energy technologies or options currently in
27 commercial operation are considered, as well as some technologies not currently in commercial
28 operation but likely to be commercially available by the time the current CGS operating license
29 expires. The current CGS operating license will expire on December 20, 2023, and an
30 alternative must be available (constructed, permitted, and connected to the grid) by the time the
31 current CGS license expires.

32 Alternatives that cannot meet future system needs and do not have costs or benefits that justify
33 inclusion in the range of reasonable alternatives were eliminated from detailed study. The
34 remaining alternatives were evaluated, and they are discussed in-depth in this chapter. Each
35 alternative eliminated from detailed study is briefly discussed in Section 8.4, and a basis for its
36 removal is provided. In Sections 8.1–8.3, 19 discrete potential alternatives to the proposed
37 action were considered and then narrowed to the 2 discrete alternatives and 1 combination
38 alternative.

39 The 1996 GEIS presents an overview of some energy technologies but does not reach any
40 conclusions about which alternatives are most appropriate. Since 1996, many energy
41 technologies have evolved significantly in capability and cost, while regulatory structures have
42 changed to either promote or impede development of particular alternatives.

43 As a result, the analyses include updated information from sources like the Energy Information
44 Administration (EIA), other organizations within the U.S. Department of Energy (DOE), the U.S.

Alternatives Evaluated In-Depth:

- Natural gas-fired combined-cycle (NGCC)
- New nuclear
- Combination alternative (NGCC, hydroelectric, wind, and conservation and efficiency)

Other Alternatives Considered:

- Offsite new nuclear and NGCC
- Coal-fired power
- Energy conservation and energy efficiency
- Purchased power
- Solar power
- Wind power
- Biomass waste
- Hydroelectric power
- Ocean wave and current energy
- Geothermal power
- Municipal solid waste
- Biofuels
- Oil-fired power
- Fuel cells
- Delayed retirement

1 Environmental Protection Agency (EPA), industry sources and publications, and information
2 submitted by the applicant in its environmental report (ER).

3 The evaluation of each alternative considers the environmental impacts across seven impact
4 categories: (1) air quality, (2) groundwater use and quality, (3) surface water use and quality,
5 (4) ecology, (5) human health, (6) socioeconomics, and (7) waste management. A three-level
6 standard of significance—SMALL, MODERATE, or LARGE—is used to show the intensity of
7 environmental effects for each alternative that is evaluated in depth. The order of presentation
8 is not meant to imply increasing or decreasing level of impact, nor does it imply that an
9 energy-planning decisionmaker would select one or another alternative.

10 Sections 8.1–8.3 describe the environmental impacts of alternatives to license renewal. These
11 alternatives include an NGCC power plant in Section 8.1, new nuclear generation in Section 8.2,
12 and a combination of alternatives that includes some natural gas-fired capacity, energy
13 conservation, a purchased power component, a hydropower component, and a wind-power
14 component in Section 8.3. In Section 8.4, alternatives considered but eliminated from detailed
15 study are briefly discussed. Finally, in Section 8.5, environmental effects that may occur if NRC
16 takes no action and does not issue a renewed license for CGS are described. Section 8.6
17 summarizes the impacts of each of the alternatives considered in detail.

18 **8.1 Natural Gas-Fired Combined-Cycle Generation**

19 This section evaluates the environmental impacts of natural gas-fired combined-cycle
20 generation at the CGS site.

21 Natural gas fueled 21 percent of electricity generation in the United States in 2008, accounting
22 for the second greatest share of electrical power after coal (EIA 2009a). Natural gas fuels
23 roughly 13 percent of the generation in the Pacific Northwest (NWPC 2005) and is transported
24 from western North American gas-producing regions to eastern Washington via the Gas
25 Transmission Northwest Line (EIA 2008). Development of new natural gas-fired plants may be
26 affected by perceived or actual action to limit greenhouse gas (GHG) emissions, although they
27 produce markedly fewer GHGs per unit of electrical output than coal-fired plants. Natural
28 gas-fired power plants are feasible, commercially available options for providing electrical
29 generating capacity beyond CGS's current license expiration. Combined-cycle power plants
30 differ significantly from coal-fired and existing nuclear power plants. Combined-cycle power
31 plants derive the majority of their electrical output from a gas-turbine cycle, and then generate
32 additional power—without burning any additional fuel—through a second, steam-turbine cycle.
33 The first gas turbine stage (similar to a large jet engine) burns natural gas, which turns a
34 driveshaft that powers an electric generator. The exhaust gas from the gas turbine is still hot
35 enough to boil water to steam. Ducts carry the hot exhaust to a heat-recovery steam generator,
36 which produces steam to drive a steam turbine and produce additional electrical power. The
37 combined-cycle approach is significantly more efficient than any one cycle on its own; thermal
38 efficiency can exceed 60 percent. Because the natural gas-fired alternative derives much of its
39 power from a gas turbine cycle, and because it wastes less heat than the existing CGS, it
40 requires significantly less cooling water and smaller or fewer cooling towers.

41 To replace the 1,150 megawatt electric (MWe) power that CGS generates, three General
42 Electric S107H combined-cycle natural gas-fired generating units were considered. While any
43 number of commercially available combined-cycle power-generating units could be used in a
44 variety of combinations to replace the generating power of CGS, the S107H unit was selected
45 for its high efficiency and to minimize environmental impacts. Other manufacturers, like

Environmental Impacts of Alternatives

1 Siemens, offer similar high-efficiency models. This natural gas-fired alternative produces a net
2 400 MWe per unit. Three units produce a total of 1,200 MWe, or nearly the same net output as
3 the existing CGS.

4 The combined-cycle generating units operate at a heat rate of 5,690 British thermal units per
5 kilowatt hours (BTU/kWh), or nearly 60 percent thermal efficiency (GE 2007). As noted above,
6 this natural gas-fired alternative would require much less cooling water than CGS because it
7 operates at a higher thermal efficiency and because it requires much less water for steam cycle
8 condenser cooling. The existing intake and discharges on the Columbia River and existing or
9 similar mechanical draft cooling towers would be used for this alternative.

10 In addition to cooling towers, other onsite visible structures would include the gas turbine
11 buildings and heat-recovery steam generators (which may be enclosed in a single building),
12 three exhaust stacks, an electrical switchyard, and, if necessary, equipment associated with a
13 natural gas pipeline, such as a compressor station. Based on GEIS estimates, approximately
14 132 acres (ac) (56 hectares (ha)) of land would be required.

15 This 1,200 MWe power plant would consume 51 billion cubic feet (ft³) (1,446 million cubic
16 meters (m³)) of natural gas annually assuming an average heat content of 1,029 BTU/ft³ (EIA
17 2009b). Natural gas would be extracted from the ground through wells, then treated to remove
18 impurities (like hydrogen sulfide), and blended to meet pipeline gas standards, before being
19 piped through the interstate pipeline system to the power plant site. This natural gas-fired
20 alternative would produce relatively little waste, primarily in the form of spent catalysts used for
21 emissions controls.

22 Environmental impacts from the natural gas-fired alternative would be greatest during
23 construction. Site crews would clear vegetation from the site, prepare the site surface, and
24 begin excavation before other crews begin actual construction on the plant and any associated
25 infrastructure, including a pipeline spur to connect the plant with the closest gas transmission
26 line 15 miles (mi) (24 kilometers (km)) to the east. Constructing the natural gas-fired alternative
27 at the Hanford Site would allow the natural gas-fired alternative to make use of CGS's existing
28 transmission system.

29 DOE is currently evaluating plans for constructing a 15-mi pipeline spur from the regional gas
30 transmission line in Pasco to the Hanford Site (Cary, 2011). This pipeline would provide natural
31 gas to the waste treatment plant currently under construction at Hanford and other industrial
32 facilities on the Hanford Site. Natural gas would also be available via this pipeline for future
33 industrial facilities at the Hanford Site. If this pipeline is constructed prior to the construction of
34 the alternative natural gas-fired plant, the associated impacts discussed herein will have already
35 occurred.

36 **8.1.1 Air Quality**

37 As discussed in Section 2.2.2.1, CGS is located in Benton County, WA, which is part of the
38 South Central Washington Intrastate Air Quality Control Region (AQCR) (40 CFR 81.189). The
39 EPA has designated Benton County as unclassified or in attainment for all National Ambient Air
40 Quality Standard (NAAQS) criteria pollutants; a portion of Benton County, which does not
41 include the CGS site, became a maintenance area for particles with a diameter of 10
42 micrometers or less (PM₁₀) on September 26, 2005 (40 CFR 81.348). Portions of Yakima
43 County, which are also part of this AQCR, are also maintenance areas for PM₁₀ as well as
44 carbon monoxide (40 CFR 81.348). All other counties in this AQCR are designated as
45 unclassified or in attainment with respect to the NAAQS criteria pollutants.

1 A new natural gas-fired generating plant would qualify as a new major-emitting industrial facility
 2 and would be subject to prevention of significant deterioration (PSD) under requirements of the
 3 Clean Air Act (CAA) (EPA 2010). Washington State’s Energy Facility Site Evaluation Council
 4 (EFSEC), which coordinates all evaluation and licensing steps for siting certain energy facilities
 5 in Washington State, has adopted Washington Administrative Code (WAC) 173-400-720; this
 6 code implements the EPA’s PSD review. The natural gas-fired plant would need to comply with
 7 the standards of performance for electric utility steam generating units set forth in
 8 40 CFR Part 60 Subpart Da.

9 Subpart P of 40 CFR Part 51 contains the visibility protection regulatory requirements, including
 10 the review of the new sources that would be constructed in the attainment or unclassified areas
 11 and may affect visibility in any Federal Class I area. If a natural gas-fired alternative was
 12 located close to a mandatory Class I area, additional air pollution control requirements would be
 13 required. As noted in Section 2.2.2.1, there are no mandatory Class I Federal areas within 50
 14 mi of the CGS site. The closest mandatory Class I Federal area is Goat Rocks Wilderness
 15 Area, which is approximately 100 mi west of the CGS site (40 CFR 81.434).

16 Emissions for a natural gas-fired alternative based on data published by the EIA, EPA, and on
 17 performance characteristics for this alternative and its emissions controls are provided below:

- 18 • Sulfur oxides (SO_x)—90 tons (82 metric tons (MT)) per year
- 19 • Nitrogen oxides (NO_x)—288 tons (261 MT) per year
- 20 • Carbon monoxide (CO)—60 tons (54 MT) per year
- 21 • Total suspended particles (TSP)—51 tons (46 MT) per year
- 22 • PM₁₀—51 tons (46 MT) per year
- 23 • Carbon dioxide (CO₂)—3,075,000 tons (2,789,000 MT) per year

24 A new natural gas-fired plant would have to comply with Title IV of the CAA (42 USC 7651)
 25 reduction requirements for SO_x and NO_x, which are the main precursors of acid rain and the
 26 major cause of reduced visibility. Title IV establishes maximum SO_x and NO_x emission rates
 27 from the existing plants and a system of SO_x emission allowances that can be used, sold, or
 28 saved for future use by the new plants.

29 **8.1.1.1 Sulfur Oxide, Nitrogen Oxide, Carbon Dioxide**

30 As stated above, the new natural gas-fired alternative would produce 90 tons (82 MT) per year
 31 of SO_x and 288 tons (261 MT) per year of NO_x based on the use of the dry low-NO_x combustion
 32 technology and use of the selective catalytic reduction (SCR) to significantly reduce NO_x
 33 emissions.

34 The new plant would be subjected to the continuous monitoring requirements for SO_x, NO_x, and
 35 CO₂ as specified in 40 CFR Part 75. The natural gas-fired plant would emit approximately
 36 3.1 million tons (approximately 2.8 million MT) per year of unregulated CO₂ emissions. In
 37 August 2008, the EFSEC proposed a new WAC chapter (463-90) for mandatory reporting of
 38 GHG emissions from large sources. EFSEC is working with the Washington State Department
 39 of Ecology’s (WDOE) Air Quality Program to adopt the rule for sources or a combination of
 40 sources that emit at least 10,000 MT of GHGs annually in the state.

41 **8.1.1.2 Particulates**

42 The new natural gas-fired alternative would produce 51 T (46 MT) per year of TSP, all of which
 43 would be emitted as PM₁₀.

1 **8.1.1.3 Hazardous Air Pollutants**

2 In December 2000, the EPA issued regulatory findings (EPA 2000a) on emissions of hazardous
3 air pollutants (HAPs) from electric utility steam-generating units, which said that natural
4 gas-fired plants emit HAPs such as arsenic, formaldehyde, and nickel, and stated that:

5 Also in the utility RTC (Report to Congress), the EPA indicated that the impacts
6 due to HAP emissions from natural gas-fired electric utility steam generating
7 units were negligible based on the results of the study. The Administrator finds
8 that regulation of HAP emissions from natural gas-fired electric utility steam
9 generating units is not appropriate or necessary.

10 **8.1.1.4 Construction Impacts**

11 Activities associated with the construction of the new natural gas-fired plant on the CGS site
12 would cause some additional, localized temporary air effects because of equipment emissions
13 and fugitive dust from operation of the earth-moving and material-handling equipment.
14 Emissions from workers' vehicles and motorized construction equipment exhaust would be
15 temporary. The construction crews would be expected to use dust-control practices to control
16 and reduce fugitive dust. The impact of vehicle exhaust emissions and fugitive dust from
17 operation of the earth-moving and material-handling equipment would therefore be SMALL.

18 Based on this information, the overall air quality impacts of a new natural gas-fired plant located
19 at the CGS site would be SMALL to MODERATE.

20 **8.1.2 Groundwater Use and Quality**

21 Total usage would likely be less than for the CGS because fewer workers would be onsite. The
22 NRC also assumed the same relative ratio of groundwater use to surface-water use as that
23 used for the CGS. Due to the temporary nature of construction and assumed minor use of
24 groundwater during operation, the impact of the natural gas-fired combined-cycle generation
25 alternative would be SMALL.

26 **8.1.3 Surface-Water Use and Quality**

27 The natural gas-fired alternative would require much less cooling water than the CGS and
28 assumed that the existing intake and discharges on the Columbia River and the existing or
29 similar mechanical draft cooling towers would be used for this alternative. Because the
30 consumptive loss of this alternative is less than that of the current CGS, the impact of
31 surface-water use would be SMALL.

32 Assuming the plant operates within the limits of applicable water-quality permits, the impact
33 from any cooling-tower blowdown, site runoff, and other effluent discharges on surface-water
34 quality would be SMALL.

35 **8.1.4 Aquatic Ecology**

36 Section 2.2.5 describes the aquatic ecology of the CGS site, which is associated with the
37 Columbia River. Impacts on the aquatic ecology from the CGS site are associated with
38 construction in the Columbia River or the use of water from the river during operation of a new
39 natural gas-fired generating plant. The NRC assumes that a new natural gas-fired generating
40 plant would use the existing intake and discharge structures in the river for cooling a new plant.

1 The natural gas-fired alternative would require less cooling water to be withdrawn from the river
2 than the CGS, and the thermal discharge would concurrently be smaller than the CGS.
3 Therefore, the number of fish and other aquatic organisms affected by impingement,
4 entrainment, and thermal impacts would be less for a natural gas-fired alternative than for those
5 associated with license renewal. The cooling system for a new natural gas-fired generating
6 plant would have similar chemical discharges as CGS, but the air emissions from the natural
7 gas-fired generating plant would emit particulates that would settle onto the river surface and
8 introduce a new source of pollutants that would not exist with CGS during the license renewal
9 term. However, the flow of the Columbia River by the CGS site is fast (mean annual flow from
10 1960–2009 was 117,823 cubic feet per second (cfs) (3,336 m³/s)) and would minimize the
11 exposure of fish and other aquatic organisms to pollutants. Because there would not be any
12 construction in the river or along the shoreline for a new natural gas-fired generating plant, the
13 surface-water withdrawal and discharge for this alternative would be less than for the CGS, and
14 the air deposition of pollutants from the plant's air emissions would be minimal, impacts on
15 aquatic ecology at the CGS site would be SMALL.

16 **8.1.5 Terrestrial Ecology**

17 Constructing the natural gas alternative would require approximately 132 ac (53 ha) of land.
18 This alternative would use a portion of the existing, previously undisturbed, onsite industrial
19 footprint, switchyard, and transmission line system for construction of the natural gas-fired units.
20 However, some fallow areas would be affected, which would result in some habitat
21 fragmentation and loss of food resources. Gas extraction and collection would also affect
22 terrestrial ecology in offsite gas fields, although much of this land is likely already disturbed by
23 gas extraction, and the incremental effects of this alternative on gas field terrestrial ecology are
24 difficult to gauge.

25 Continued operation of the existing mechanical draft cooling towers would produce a visible
26 plume and cause some deposition of dissolved solids on surrounding vegetation and soil from
27 cooling-tower drift.

28 Construction of the 15-mi gas pipeline would also affect fallow areas and the habitat and food
29 sources of native species. Threatened and endangered species may also be affected by
30 construction of the gas pipeline. The impacts from the construction of the pipeline would be
31 MODERATE.

32 Based on this information, impacts on terrestrial resources could range from SMALL to
33 MODERATE.

34 **8.1.6 Human Health**

35 A natural gas-fired plant would emit criteria air pollutants, but generally in smaller quantities than
36 a coal-fired plant (except NO_x, which requires additional controls to reduce emissions). The
37 human health effects of natural gas-fired generation are generally low, although in Table 8-2 of
38 the GEIS (NRC 1996), the NRC identified cancer and emphysema as potential health risks from
39 natural gas-fired plants. NO_x emissions contribute to ozone formation, which in turn contributes
40 to human health risks. Emission controls on this natural gas-fired alternative maintain NO_x
41 emissions well below air quality standards established for the purposes of protecting human
42 health, and emissions trading or offset requirements mean that overall NO_x in the region would
43 not increase. Health risks to workers may also result from handling spent catalysts that may
44 contain heavy metals.

Environmental Impacts of Alternatives

1 Overall, human health risks to occupational workers and to members of the public from natural
2 gas-fired power plant emissions sited at the CGS site would likely be SMALL.

3 **8.1.7 Land Use**

4 The GEIS generically evaluates the impact of nuclear power plant operations on land use, both
5 on and off each power plant site. The analysis of land-use impacts focuses on the amount of
6 land area that would be affected by the construction and operation of a three-unit natural
7 gas-fired combined-cycle power plant at the CGS site.

8 Based on GEIS estimates, approximately 132 ac (53 ha) of land would be needed to support a
9 natural gas-fired alternative to replace CGS. This amount of land use would include other plant
10 structures and associated infrastructure and is unlikely to exceed 132 ac (53 ha), excluding land
11 for natural gas wells and collection stations. Land-use impacts from construction would be
12 SMALL.

13 In addition to onsite land requirements, land would be required offsite for natural gas wells and
14 collection stations. Scaling from GEIS estimates, approximately 11,125 ac (4,500 ha) would be
15 required for wells, collection stations, and pipelines to bring the gas to the plant. Most of this
16 land requirement would occur on land where gas extraction already occurs. In addition, some
17 natural gas could come from outside the U.S. and be delivered as liquefied gas.

18 The elimination of uranium fuel for CGS could partially offset offsite land requirements. Scaling
19 from GEIS estimates, approximately 1,150 ac (465 ha) would not be needed for mining and
20 processing uranium during the operating life of the plant. Overall land-use impacts from a
21 natural gas-fired power plant would be in the range of SMALL to MODERATE.

22 **8.1.8 Socioeconomics**

23 Socioeconomic impacts are defined in terms of changes to the demographic and economic
24 characteristics and social conditions of a region. For example, the number of jobs created by
25 the construction and operation of a new natural gas-fired power plant could affect regional
26 employment, income, and expenditures. Two types of jobs would be created by this alternative:
27 (1) construction-related jobs, which are transient, short in duration, and less likely to have a
28 long-term socioeconomic impact; and (2) operation-related jobs in support of power plant
29 operations, which have the greater potential for permanent, long-term socioeconomic impacts.
30 Workforce requirements for the construction and operation of the natural gas-fired power plant
31 alternative were evaluated in order to measure their possible effects on current socioeconomic
32 conditions.

33 Based on GEIS estimates, Energy Northwest projected a maximum construction workforce of
34 1,380 (Energy Northwest ER, 2010). During construction of a natural gas-fired plant, the
35 communities surrounding the power plant site would experience increased demand for rental
36 housing and public services. The relative economic effect of construction workers on the local
37 economy and tax base would vary over time.

38 After construction, local communities could be temporarily affected by the loss of construction
39 jobs and associated loss in demand for business services, and the rental housing market could
40 experience increased vacancies and decreased prices. Since CGS is located near the Tri-
41 Cities metropolitan area, these effects would be smaller because workers are likely to commute
42 to the site instead of relocating to be closer to the construction site. Because of CGS's proximity

1 to this large population center, the impact of construction on socioeconomic conditions could
 2 range from SMALL to MODERATE.

3 Based on GEIS estimates, Energy Northwest estimated a power plant operations workforce of
 4 approximately 173. The Energy Northwest estimate appears to be reasonable and is consistent
 5 with trends toward lowering labor costs by reducing the size of power plant operations
 6 workforces. This would result in a loss of approximately 900 relatively high-paying jobs, with a
 7 corresponding reduction in purchasing activity and tax contributions to the regional economy.
 8 The impact of the job loss, however, may not be noticeable given the amount of time required
 9 for the construction of a new natural gas-fired power plant and the decommissioning of the
 10 existing facilities and the relatively large Tri-Cities region from which CGS personnel are
 11 currently drawn. The amount of taxes paid under the natural gas-fired alternative may increase
 12 if additional land is required offsite to support this alternative. Operational impacts would,
 13 therefore, range from SMALL to MODERATE.

14 **8.1.9 Transportation**

15 Transportation impacts associated with construction and operation of a three-unit, natural
 16 gas-fired power plant would consist of commuting workers and truck deliveries of construction
 17 materials to the CGS site. During periods of peak construction activity, up to 1,500 workers
 18 could be commuting daily to the site. In addition to commuting workers, trucks would be
 19 transporting construction materials and equipment to the worksite, thus increasing the amount
 20 of traffic on local roads. The increase in vehicular traffic would peak during shift changes,
 21 resulting in temporary levels of service impacts and delays at intersections. Pipeline
 22 construction and modification to existing natural gas pipeline systems could also have an
 23 impact. Traffic-related transportation impacts during construction would likely be MODERATE.

24 During plant operations, traffic-related transportation impacts would almost disappear.
 25 According to Energy Northwest, approximately 173 workers would be needed to operate the
 26 natural gas-fired power plant. Since fuel is transported by pipeline, the transportation
 27 infrastructure would experience little to no increased traffic from plant operations.

28 Overall, the natural gas-fired alternative transportation impacts would be SMALL during plant
 29 operations.

30 **8.1.10 Aesthetics**

31 The aesthetics impact analysis focuses on the degree of contrast between the natural gas-fired
 32 alternative and the surrounding landscape and the visibility of the natural gas-fired plant.

33 The three natural gas-fired units could be approximately 100 feet (ft) (30 meters (m)) tall, with
 34 two exhaust stacks up to 175 ft (53 m) tall. The facility would be visible offsite during daylight
 35 hours, and some structures may require aircraft warning lights. The power plant would be
 36 smaller and less noticeable than that of CGS, which has a reactor building height of 230 ft (70
 37 m). Mechanical draft cooling towers would continue to generate condensate plumes and
 38 operational noise. Noise during power plant operations would be limited to industrial processes
 39 and communications. Pipelines delivering natural gas fuel could be audible offsite near
 40 compressors.

41 In general, aesthetic changes would be limited to the immediate vicinity of CGS and would be
 42 SMALL.

1 **8.1.11 Historic and Archaeological Resources**

2 Cultural resources are the indications of human occupation and use of the landscape, as
3 defined and protected by a series of Federal laws, regulations, and guidelines. Prehistoric
4 resources are physical remains of human activities that predate written records; they generally
5 consist of artifacts that may—alone or collectively—yield information about the past. Historic
6 resources consist of physical remains that postdate the emergence of written records; in the
7 U.S., they are architectural structures or districts, archaeological objects, and archaeological
8 features dating from 1492 and later. Ordinarily, sites less than 50 years old are not considered
9 historic, but exceptions can be made for such properties if they are of particular importance,
10 such as structures associated with the development of nuclear power (e.g., Shippingport Atomic
11 power Station) or Cold War themes. American Indian resources are sites, areas, and materials
12 important to American Indians for religious or heritage reasons. Such resources may include
13 geographic features, plants, animals, cemeteries, battlefields, trails, and environmental features.
14 The cultural resource analysis encompassed the power plant site and adjacent areas that could
15 potentially be disturbed by the construction and operation of alternative power plants.

16 The potential for historic and archaeological resources can vary greatly depending on the
17 location of the proposed site. To consider a project's effects on historic and archaeological
18 resources, any affected areas would need to be surveyed to identify and record historic and
19 archaeological resources, identify cultural resources (e.g., traditional cultural properties), and
20 develop possible mitigation measures to address any adverse effects from ground-disturbing
21 activities.

22 As described in Section 2.2.10, much of the CGS site has been previously disturbed by the
23 construction of CGS and the partial construction WPPSS Nuclear Projects No. 1 and 4
24 (WNP-1/4). In addition, the CGS site has been surveyed for cultural resources, resulting in the
25 identification of archaeological sites within the vicinity of the pumphouse and intake structure.
26 There is a low potential for cultural resources to be located in previously undisturbed portions of
27 the CGS site. If the natural gas-fired units were to be sited within undisturbed areas or within
28 areas of known cultural sensitivity, these areas would need to be surveyed to identify and record
29 historic and archaeological resources, identify cultural resources (e.g., traditional cultural
30 properties), and develop possible mitigation measures to address any adverse effects from
31 ground-disturbing activities. Studies would be needed for all areas of potential disturbance at
32 the proposed plant site and along associated corridors where new construction would occur
33 (e.g., roads, transmission corridors, rail lines, or other rights-of-way (ROWs)). In most cases,
34 projects should be sited to avoid areas that exhibit the greatest sensitivity.

35 As noted in Section 4.9.6, Energy Northwest has developed a Cultural Resources Protection
36 Plan that calls for a qualified archaeologist to carry out surveys in areas deemed sensitive or in
37 undisturbed areas before commencing work. The plan also includes an inadvertent discovery
38 (stop work) provision to ensure that proper notification is made to protect these resources if any
39 are discovered. Because Energy Northwest has conducted a survey and has established a
40 protection plan, the impact of the construction and operation of a replacement natural gas-fired
41 plant at the CGS site on historic and archaeological resources would be SMALL.

42 **8.1.12 Environmental Justice**

43 The environmental justice impact analysis evaluates the potential for disproportionately high and
44 adverse human health, environmental, and socioeconomic effects on minority and low-income
45 populations that could result from the construction and operation of a new natural gas-fired
46 power plant. Adverse health effects are measured in terms of the risk and rate of fatal or

1 nonfatal adverse impacts on human health. Disproportionately high and adverse human health
 2 effects occur when the risk or rate of exposure to an environmental hazard for a minority or low-
 3 income population is significant and exceeds the risk or exposure rate for the general population
 4 or for another appropriate comparison group. Disproportionately high environmental effects
 5 refer to impacts or risk of impact on the natural or physical environment in a minority or low-
 6 income community that are significant and appreciably exceed the environmental impact on the
 7 larger community. Such effects may include biological, cultural, economic, or social impacts.
 8 Some of these potential effects have been identified in resource areas discussed in this SEIS.
 9 For example, increased demand for rental housing during power plant construction could
 10 disproportionately affect low-income populations. Minority and low-income populations are
 11 subsets of the general public residing in the vicinity of the Hanford Site and CGS, and all are
 12 exposed to the same hazards generated from constructing and operating a new NGCC power
 13 plant. Section 4.9.7 of this SEIS provides socioeconomic data regarding the analysis of
 14 environmental justice issues.

15 Potential impacts to minority and low-income populations from the construction and operation of
 16 a new NGCC power plant at CGS would mostly consist of environmental and socioeconomic
 17 effects (e.g., noise, dust, traffic, employment, and housing impacts). Noise and dust impacts
 18 from construction would be short-term and primarily limited to onsite activities. Minority and low-
 19 income populations residing along site access roads would also be affected by increased
 20 commuter vehicle traffic during shift changes and truck traffic. However, these effects would be
 21 temporary during certain hours of the day, and they are not likely to be high and adverse.
 22 Increased demand for rental housing during construction in the vicinity of the Hanford Site and
 23 CGS could affect low-income populations. Given the close proximity to the Tri-Cities
 24 metropolitan areas, most construction workers would likely commute to the site, thereby
 25 reducing the potential demand for rental housing.

26 Based on this information, and the analysis of human health and environmental impacts
 27 presented in this SEIS, the construction and operation of a new NGCC power plant would not
 28 have disproportionately high and adverse human health and environmental effects on minority
 29 and low-income populations residing in the vicinity of CGS.

30 **8.1.13 Waste Management**

31 During the construction stage of the natural gas-fired combined-cycle generation alternative,
 32 land clearing and other construction activities would generate waste that could be recycled,
 33 disposed of onsite, or shipped to an offsite waste disposal facility. Because the alternative
 34 would be constructed on or near the previously disturbed CGS site, the amounts of wastes
 35 produced during land clearing would be reduced.

36 During the operational stage, spent SCR catalysts, which are used to control NO_x emissions
 37 from the natural gas-fired plants, would make up the majority of the waste generated by this
 38 alternative.

39 According to the GEIS (NRC 1996), a natural gas-fired plant would generate minimal waste.
 40 Waste impacts would therefore be SMALL for a natural gas-fired alternative located at the CGS
 41 site or offsite.

42 **8.1.14 Summary of Natural Gas-Fired Impacts**

43 Table 8.1-1 summarizes the environmental impacts of the natural gas-fired alternative
 44 compared to continued operation of CGS.

1 **Table 8.1-1. Summary of environmental impacts of the natural gas-fired combined-cycle**
 2 **generation alternative compared to continued operation of CGS**

| Category | Natural gas combined-cycle generation | Continued CGS operation |
|-----------------------------------|---------------------------------------|-------------------------|
| Air quality | SMALL to MODERATE | SMALL |
| Groundwater | SMALL | SMALL |
| Surface water | SMALL | SMALL |
| Aquatic and terrestrial resources | SMALL to MODERATE | SMALL |
| Human health | SMALL | SMALL |
| Socioeconomics | SMALL to MODERATE | SMALL |
| Waste management | SMALL | SMALL |

3 **8.2 New Nuclear Generation**

4 In its environmental report, Energy Northwest states that it does not have any current plans to
 5 build a new nuclear reactor at the CGS site or at an alternate site and does not consider a new
 6 nuclear plant to be a reasonable alternative to renewal of CGS's operating license. However,
 7 the NRC is currently reviewing multiple combined operating license (COL) applications, and site
 8 preparation work has started for two additional units at the V.C. Summer site in South Carolina
 9 and for two additional units at the Vogtle site in Georgia. The NRC considers the construction of
 10 a new nuclear plant to be a reasonable alternative to CGS license renewal and, in this section,
 11 the environmental impacts of constructing a new nuclear power plant at the CGS site are
 12 discussed.

13 In evaluating the new nuclear alternative, the NRC presumed that replacement reactors would
 14 be installed on the CGS site, allowing for the maximum use of existing ancillary facilities such as
 15 the transmission and cooling systems, including the existing intake and discharge structures on
 16 the Columbia River. The NRC further presumed that the replacement reactor would be a
 17 light-water reactor such as the Advanced Passive 1000 (AP1000) model pressurized water
 18 reactor (PWR), a reactor design for which the NRC has already issued a certification. With a
 19 gross electrical output of 1,200 MWe, one AP1000 reactor would be required to approximate
 20 CGS's currently installed capacity of 1,150 MWe. To estimate the impacts of this replacement
 21 reactor, the NRC reviewed its assessment of construction and operating impacts of two AP1000
 22 units at the Virgil C. Summer Nuclear Station (VCSNS) in Fairfield County, SC
 23 (<http://www.nrc.gov/reactors/new-reactors/col/summer.html>). The NRC amended some
 24 parameters applied to the VCSNS site to reflect extant conditions at the CGS site. With these
 25 differences taken into consideration, the impacts of constructing and operating one AP1000 unit
 26 at the CGS site should bound the impacts of replacing CGS's currently installed capacity.

27 The applicant for new nuclear units at the VCSNS, South Carolina Electric and Gas, did not give
 28 a detailed construction schedule for a single new nuclear unit. However, estimates given by
 29 Southern Nuclear Corporation for the construction of two AP1000 reactors at the Vogtle Electric
 30 Generating Plant (VEGP) in GA included 18 months for site preparation, 48 months for
 31 construction, and 6 months from fuel loading to initial power generation (SNC 2008). The NRC
 32 considers these time frames to be reasonable and, although site conditions of VEGP and CGS
 33 are not the same and the VEGP construction included construction of a new cooling system
 34 dedicated to the two new reactors, the NRC presumes that construction of a new nuclear
 35 alternative at the CGS would generally follow the same time frame.

1 Regarding construction impacts, Energy Northwest estimated that the power block and ancillary
 2 facilities (excluding the cooling-water system) for the replacement reactors would require
 3 approximately 500 ac and that sufficient contiguous fallow acreage was available on the CGS
 4 site. The NRC further estimated that the existing cooling system and the Columbia River would
 5 meet the heat-rejection demands of the replacement reactors with only minor modifications.

6 The NRC also considered the installation of multiple small and modular reactors at the CGS site
 7 as an alternative to renewing the license for the CGS. Considerable interest in small and
 8 modular reactors along with anticipated license applications by vendors has caused the NRC to
 9 establish the Advanced Reactor Program in the Office of New Reactors. These smaller reactors
 10 have economic advantages over large light-water reactors, including lower financing costs and
 11 the ability to begin generation with the first units while others are being installed. Some designs
 12 also have environmental advantages such as the use of use passive cooling instead of water
 13 cooling. The NRC considers that the environmental impacts of constructing and operating a
 14 large light-water reactor such as the AP1000 would likely bound the impact of constructing and
 15 operating a combination of smaller modular reactors.

16 **8.2.1 Air Quality**

17 As discussed in Section 2.2.2.1, the CGS site is located in Benton County, WA, which is part of
 18 the South Central Washington Intrastate AQCR (40 CFR 81.189). The EPA has designated
 19 Benton County as unclassified or in attainment for all NAAQS criteria pollutants; a portion of
 20 Benton County, which does not include the CGS site, became a maintenance area for PM₁₀ on
 21 September 26, 2005 (40 CFR 81.348). Portions of Yakima County, which are also part of this
 22 AQCR, are also maintenance areas for PM₁₀ as well as carbon monoxide (40 CFR 81.348). All
 23 other counties in this AQCR are designated as unclassified or in attainment with respect to the
 24 NAAQS criteria pollutants.

25 A new nuclear generating plant would have similar air emissions to those of the existing CGS
 26 site; air emissions would be primarily from backup diesel generators. As noted in
 27 Section 2.2.2.1, the CGS site conforms to Washington State Regulatory Order 672, which limits
 28 plant emissions to levels below regulatory thresholds (EFSEC 1996). Because air emissions
 29 would be similar for a new nuclear plant, the NRC expects similar air permitting conditions and
 30 regulatory requirements. Therefore, while the air emissions from the backup diesel generators
 31 could exceed the major source threshold for PSD review, actual plant emissions would be well
 32 below that limit.

33 Subpart P of 40 CFR Part 51 contains the visibility protection regulatory requirements, including
 34 the review of the new sources that would be constructed in the attainment or unclassified areas
 35 and may affect visibility in any Federal Class I area. If a new nuclear plant were located close to
 36 a mandatory Class I area, additional air pollution control requirements may be required. As
 37 noted in Section 2.2.2.1, there are no Mandatory Class I Federal areas within 50 mi of the CGS
 38 site. The closest Mandatory Class I Federal area is Goat Rocks Wilderness Area, which is
 39 approximately 100 mi west of the CGS site (40 CFR 81.434).

40 Energy Northwest reported the following air emissions, from the year 2009, for the existing CGS
 41 site (EN, 2010b). Similar air emissions from a new nuclear plant are expected, because these
 42 emissions are primarily from backup diesel generators that would also be used at a new nuclear
 43 plant:

- 44 • SO_x—0.18 T (0.16 MT) per year
- 45 • NO_x—8.3 T (7.5 MT) per year

Environmental Impacts of Alternatives

- 1 • CO—2.2 tons (2.0 MT) per year
- 2 • PM₁₀—0.17 T (0.15 MT) per year.

3 **8.2.1.1 Construction Impacts**

4 Activities associated with the construction of the new nuclear plant would cause some additional
5 temporary air effects as a result of equipment emissions and fugitive dust from operation of the
6 earth-moving and material-handling equipment. Emissions from workers' vehicles and
7 motorized construction equipment exhaust would be temporary. It is expected that construction
8 crews would use dust-control practices to control and reduce fugitive dust. The impact of
9 vehicle exhaust emissions and fugitive dust from operation of the earth-moving and
10 material-handling equipment would therefore be SMALL.

11 Based on this information, overall air quality impacts of a new nuclear plant located at the CGS
12 site would be SMALL.

13 **8.2.2 Groundwater Use and Quality**

14 The NRC presumed that a new or replacement reactor would be installed on the CGS site,
15 allowing for the maximum use of existing ancillary facilities. Excavation for new shield building
16 foundations would presumably be to depths of approximately 40–50 ft below grade. This is well
17 above the existing water table aquifer at a depth of about 60 ft below grade. No dewatering
18 would be required. The NRC also presumed that existing onsite and nearby groundwater wells
19 (one at the CGS, and two at the Industrial Development Complex (IDC)) would be used to
20 supply relatively small amounts of water for dust suppression and other support during
21 construction of the new plant.

22 Operational groundwater use at the new plant would be minor, with the total usage and
23 groundwater-quality impacts likely to be similar to those for the CGS. Due to the temporary
24 nature of construction and minor use of groundwater during operation, the impact of the new
25 nuclear plant alternative on groundwater would be SMALL.

26 **8.2.3 Surface-Water Use and Quality**

27 The NRC presumed that a new or replacement reactor would be designed to maximize use of
28 existing facilities, including the existing intake and discharge structures on the Columbia River.
29 The total consumptive water loss rate for one new AP1000 unit is assumed to be approximately
30 the same as for the existing CGS: 17,000 gallons per minute (gpm) (EN, 2010a). This is about
31 half of the approximately 27,800 gpm (62 cfs) to 31,100 gpm (69 cfs) estimated for two AP1000
32 units proposed for the VCSNS in Fairfield County, SC (SCE&G, 2009). Because the
33 consumptive loss is about 0.05 percent of the minimum mean annual discharge of 80,650 cfs for
34 the Columbia River (USGS 2010), the impact of surface-water use would be SMALL.

35 Assuming the plant operates within the limits of applicable water-quality permits, the impact
36 from any cooling-tower blowdown, site runoff, and other effluent discharges on surface-water
37 quality would be SMALL.

38 **8.2.4 Aquatic Ecology**

39 The NRC presumed that a new or replacement reactor would have closed-cycle cooling, and it
40 would use the existing intake and discharge pipelines in the Columbia River and existing
41 structures along the shoreline. The water withdrawal from the Columbia River for operation of

1 the closed-cycle cooling system of a new AP1000 unit is approximately the same as that used
2 for the existing CGS site. The number of fish and other aquatic organisms affected by
3 impingement, entrainment, and thermal impacts would be equivalent to those associated with
4 license renewal. A new or replacement reactor would use existing in-stream systems, and the
5 impacts on the aquatic ecology of the Columbia River from construction of the new or
6 replacement reactor would be SMALL because there would be no modifications in the river and
7 no additional use. The level of impact on the aquatic ecology for the continued CGS operation
8 is small, so NRC expects the levels of impact for impingement, entrainment, and thermal effects
9 of the new or replacement reactor would also be SMALL.

10 **8.2.5 Terrestrial Ecology**

11 As stated in previous sections, the NRC presumes that a new nuclear alternative could be
12 constructed on the existing CGS property. The 500 ac (200 ha) needed for the construction of
13 the new nuclear alternative is available on the CGS site, but some fallow areas may be affected
14 by the construction. Terrestrial ecology in these fallow areas would be affected, primarily
15 resulting in habitat fragmentation and loss of food sources.

16 Operation of the existing cooling towers would continue to produce a visible plume and cause
17 some deposition of dissolved solids on surrounding vegetation and soil from cooling-tower drift,
18 but these impacts would be equal to or less than currently occurring impacts. Based on this
19 information, impacts on terrestrial resources would be SMALL.

20 **8.2.6 Human Health**

21 The human health effects of a new nuclear power plant would be similar to those of the existing
22 CGS. The NRC expects that operational human health effects would be SMALL. Human health
23 issues related to construction would be equivalent to those associated with the construction of
24 any major complex industrial facility and would be controlled to acceptable levels through the
25 application of best management practices and Energy Northwest's compliance with application,
26 Federal, and State worker protection regulations. Human health impacts from operation of the
27 nuclear alternative would be equivalent to those associated with continued operation of the
28 existing reactors under license renewal. Both continuous and impulse noise impacts can be
29 expected at offsite locations, including at the closest residences. However, confining
30 noise-producing activities to core hours of the day (7:00 am–6:00 pm), suspending the use of
31 explosives during certain meteorological conditions, and notifying potentially affected parties
32 beforehand of such events would control noise impacts to acceptable levels. Noise impacts
33 would be of short duration and would be SMALL. Overall, human health impacts would be
34 SMALL.

35 **8.2.7 Land Use**

36 As discussed in Section 8.1.6, the GEIS generically evaluates the impacts of nuclear power
37 plant operations on land use both on and off each power plant site. The analysis of land-use
38 impacts focuses on the amount of land area that would be affected by the construction and
39 operation of a new nuclear power plant at the CGS site.

40 Based on GEIS estimates, approximately 500 ac (200 ha) of land would be needed to support a
41 new nuclear power plant to replace CGS. An area of sufficient size in the previously disturbed
42 onsite industrial footprint is expected to be available for the nuclear plant, thus minimizing the
43 amount of disturbance in undeveloped portions of the site. Onsite land-use impacts from
44 construction would be SMALL.

Environmental Impacts of Alternatives

1 Offsite impacts associated with uranium mining and fuel fabrication to support the new nuclear
2 alternative would generally be no different from those occurring in support of the existing CGS
3 reactor, although land would be required for mining the additional uranium. Overall land-use
4 impacts from a new nuclear power plant would range from SMALL to MODERATE.

5 **8.2.8 Socioeconomics**

6 Socioeconomic impacts are defined in terms of changes to the demographic and economic
7 characteristics and social conditions of a region, especially resulting from the creation of new
8 jobs. Two types of job creation would result: (1) construction-related jobs, which are transient,
9 short in duration, and less likely to have a long-term socioeconomic impact; and
10 (2) operation-related jobs in support of power plant operations, which have the greater potential
11 for permanent, long-term socioeconomic impacts.

12 Based on GEIS estimates, a maximum construction workforce of 2,400 workers would be
13 required. During construction of a new nuclear plant, the communities surrounding the power
14 plant site would experience increased demand for rental housing and public services. The
15 relative economic effect of construction workers on the local economy and tax base would vary.

16 After construction, local communities could be temporarily affected by the loss of construction
17 jobs and associated loss in demand for business services, and the rental housing market could
18 experience increased vacancies and decreased prices. Since CGS is located near the Tri-
19 Cities metropolitan area, these effects would be smaller because workers are likely to commute
20 to the site instead of relocating to be closer to the construction site. Because of CGS's proximity
21 to this large population center, the impact of construction on socioeconomic conditions could
22 range from SMALL to MODERATE.

23 Based on GEIS estimates, the new nuclear power plant operations workforce could require
24 approximately 840 workers. The number of operations workers could have a noticeable effect
25 on socioeconomic conditions in the region; however, socioeconomic impacts associated with
26 the operation of a new nuclear power plant at the CGS site would range from SMALL to
27 MODERATE.

28 **8.2.9 Transportation**

29 During periods of peak construction activity, up to 2,400 workers could be commuting daily to
30 the site. In addition to commuting workers, trucks would be transporting construction materials
31 and equipment to the worksite, increasing the amount of traffic on local roads. The increase in
32 vehicular traffic would peak during shift changes, resulting in temporary levels of service
33 impacts and delays at intersections. Some plant components are likely to be delivered by train
34 via the existing onsite rail spur. Nevertheless, transportation impacts would likely be
35 MODERATE during construction.

36 Transportation traffic-related impacts would be greatly reduced after construction, but would not
37 disappear during plant operations. Transportation impacts would include daily commuting by
38 the operating workforce, equipment and materials deliveries, and the removal of waste material
39 to offsite disposal or recycling facilities by truck.

40 Traffic-related transportation impacts would be no different during plant operations from those
41 from the existing CGS plant. Overall, the new nuclear alternative would have a SMALL to
42 MODERATE impact on transportation conditions in the region around the CGS site.

1 **8.2.10 Aesthetics**

2 The analysis of impacts on aesthetics focuses on the degree of contrast between the new
3 nuclear alternative and the surrounding landscape and the visibility of the new nuclear plant.

4 The appearance of the power block for the new nuclear power plant would be virtually identical
5 to the existing CGS plant. In addition, because the existing cooling system (including the
6 mechanical draft cooling towers) would remain in use, the overall visual impacts of the new
7 reactor alternative would be no different from those from the existing CGS facility. Overall,
8 aesthetic impacts associated with the new nuclear alternative would range from SMALL during
9 plant operations to MODERATE during construction.

10 **8.2.11 Historic and Archaeological Resources**

11 The same considerations, discussed in Section 8.1.11, for the impact of the construction of a
12 natural gas-fired plant on historic and archaeological resources apply to the construction
13 activities that would occur on the CGS site for a new nuclear reactor. As previously noted, the
14 potential for historic and archaeological resources can vary greatly depending on the location of
15 the proposed site. To consider a project's effects on historic and archaeological resources, any
16 affected areas would need to be surveyed to identify and record historic and archaeological
17 resources, identify cultural resources (e.g., traditional cultural properties), and develop possible
18 mitigation measures to address any adverse effects from ground-disturbing activities.

19 Surveys would be needed to identify, evaluate, and address mitigation of potential impacts prior
20 to the construction of the new plant. Studies would be needed for all areas of potential
21 disturbance (e.g., roads, transmission corridors, rail lines, or other ROWs). Areas with the
22 greatest sensitivity should be avoided. Because Energy Northwest would conduct a survey and
23 apply its established protection plan for future resources, the impact of a new nuclear plant
24 alternative at the CGS site on historic and archaeological resources would be SMALL.

25 **8.2.12 Environmental Justice**

26 The environmental justice impact analysis evaluates the potential for disproportionately high and
27 adverse human health and environmental effects on minority and low-income populations that
28 could result from the construction and operation of a new nuclear power plant. Adverse health
29 effects are measured in terms of the risk and rate of fatal or nonfatal adverse impacts on human
30 health. Disproportionately high and adverse human health effects occur when the risk or rate of
31 exposure to an environmental hazard for a minority or low-income population is significant and
32 exceeds the risk or exposure rate for the general population or for another appropriate
33 comparison group. Disproportionately high environmental effects refer to impacts or risk of
34 impact on the natural or physical environment in a minority or low-income community that are
35 significant and appreciably exceed the environmental impact on the larger community. Such
36 effects may include biological, cultural, economic, or social impacts. Some of these potential
37 effects have been identified in resource areas discussed in this SEIS. For example, increased
38 demand for rental housing during power plant construction could disproportionately affect low-
39 income populations. Minority and low-income populations are subsets of the general public
40 residing around CGS, and all are exposed to the same hazards generated from constructing
41 and operating a new nuclear power plant.

42 Potential impacts to minority and low-income populations from the construction and operation of
43 a new nuclear power plant at CGS would mostly consist of environmental and socioeconomic
44 effects (e.g., noise, dust, traffic, employment, and housing impacts). Noise and dust impacts

Environmental Impacts of Alternatives

1 from construction would be short-term and primarily limited to onsite activities. Minority and low-
2 income populations residing along site access roads would also be affected by increased
3 commuter vehicle traffic during shift changes and truck traffic. However, these effects would be
4 temporary during certain hours of the day and not likely to be high and adverse. Increased
5 demand for rental housing during construction in the vicinity of the Hanford Site and CGS could
6 affect low-income populations. Given the close proximity to the Tri-Cities metropolitan areas,
7 most construction workers would likely commute to the site, thereby reducing the potential
8 demand for rental housing.

9 Based on this information, and the analysis of human health and environmental impacts
10 presented in this SEIS, the construction and operation of a new nuclear power plant would not
11 have disproportionately high and adverse human health and environmental effects on minority
12 and low-income populations residing in the vicinity of CGS.

13 **8.2.13 Waste Management**

14 During the construction stage of the new nuclear plant, land clearing and other construction
15 activities would generate waste that could be recycled, disposed of onsite, or shipped to the
16 offsite waste disposal facility. Because the new nuclear plant would be constructed on or near
17 the previously disturbed CGS site, the amounts of wastes produced during land clearing would
18 be reduced.

19 During the operational stage, normal plant operations, routine plant maintenance, and cleaning
20 activities would generate nonradioactive waste. Quantities of nonradioactive waste, discussed
21 in Section 2.3.1 of this EIS, would be comparable to the existing CGS site.

22 According to the GEIS (NRC 1996), the generation and management of solid nonradioactive
23 waste during the terms of an extended license are not expected to result in significant
24 environmental impacts. A new nuclear plant would generate waste streams similar to a nuclear
25 plant that has undergone license renewal. Based on this information, waste impacts would be
26 SMALL for a new nuclear plant located at CGS site.

27 **8.2.14 Summary of Impacts of New Nuclear Generation**

28 Table 8.2-1 summarizes the environmental impacts of the new nuclear alternative compared to
29 continued operation of the CGS.

30 **Table 8.2-1. Summary of environmental impacts of the new nuclear alternative compared**
31 **to continued operation of the CGS**

| Category | New nuclear generation | Continued CGS operation |
|-----------------------------------|------------------------|-------------------------|
| Air quality | SMALL | SMALL |
| Groundwater | SMALL | SMALL |
| Surface water | SMALL | SMALL |
| Aquatic and terrestrial resources | SMALL | SMALL |
| Human health | SMALL | SMALL |
| Socioeconomics | SMALL to MODERATE | SMALL |
| Waste management | SMALL | SMALL |

1 **8.3 Combination Alternative**

2 This section evaluates the environmental impacts of a combination of alternatives. This
 3 combination includes a portion of baseload capacity supplied by the natural gas-fired
 4 combined-cycle capacity identified in Section 8.1 (860 MWe), a hydropower component (175
 5 MWe), a renewable energy component other than hydropower (175 MWe), a purchased power
 6 component for periods when renewable energy is not available (175 MWe), and an energy
 7 conservation and efficiency component (115 MWe). The renewable energy component could
 8 include a variety of generation types such as biofuel-fired capacity and solar capacity. For the
 9 purpose of comparison of impacts, this combination assumes wind power would be the
 10 renewable energy component, although distributed solar and smaller solar plants would also be
 11 reasonable choices for the renewable energy component.

12 Wind power is an intermittent resource, and to service its customer base, Energy Northwest
 13 assumes that purchased power would be available to compensate for its periodic loss
 14 (EN, 2010a). Energy Northwest also assumes that fossil fuels would generate this purchased
 15 power. For the purpose of evaluating the environmental impacts of this combination of
 16 alternatives, the NRC assumes that two new natural gas-fired units of the type described in
 17 Section 8.1 would be constructed and installed at the CGS site with a total capacity of
 18 860 MWe. These plants would be operated from 685 MWe–860 MWe depending on the
 19 availability of wind power. The appearance of a natural gas-fired facility would be similar to that
 20 of the full natural gas-fired alternative considered in Section 8.1, although only two units would
 21 be constructed. The NRC estimates that it would require about two-thirds of the space
 22 necessary for the alternative considered in Section 8.2, and that all construction effects—as well
 23 as operational aesthetic, fuel-cycle, air quality, socioeconomic, land use, environmental justice,
 24 and water consumption effects—would scale accordingly.

25 In 1998, DOE estimated that there were 238 developed hydroelectric sites in Washington State
 26 that were unpowered with a potential capacity of 3,373 MWe (INEEL 1998). Hydropower equal
 27 to 175 MWe would be developed by powering previously developed, but currently unpowered,
 28 hydroelectric sites. Wind turbines constructed at an offsite location, or multiple offsite locations,
 29 would account for roughly 175 MWe of CGS's current capacity. Wind turbine construction and
 30 repowering exiting hydropower sites at offsite locations would include the ROW for new
 31 transmission lines.

32 As discussed in Section 8.1.3, load-management and energy-efficiency programs carried out by
 33 the Bonneville Power Administration and other utilities in Washington since 1982 have reduced
 34 demand by over 1,500 average megawatts. The NRC assumes that these programs would
 35 continue and that a portion of CGS's output—115 MWe—would be replaced by conservation.
 36 No major construction would be necessary for the conservation component of the combination
 37 alternative.

38 **8.3.1 Air Quality**

39 As discussed in Section 2.2.2.1, CGS is located in Benton County, WA, which is part of the
 40 South Central Washington Intrastate AQCR (40 CFR 81.189). Benton County is designated as
 41 unclassified or in attainment for all NAAQS criteria pollutants; a portion of Benton County, which
 42 does not include the CGS site, became a maintenance area for PM₁₀ on September 26, 2005
 43 (40 CFR 81.348). Portions of Yakima County, which are also part of this AQCR, are also
 44 maintenance areas for PM₁₀ as well as carbon monoxide (40 CFR 81.348). All other counties in

Environmental Impacts of Alternatives

1 this AQCR are designated as unclassified or in attainment with respect to the NAAQS criteria
2 pollutants.

3 This alternative includes a combination of 685 MWe–860 MWe of natural gas-fired generation,
4 175 MWe of hydropower, 175 MWe of wind energy, and 115 MWe of energy conservation. The
5 range in power for natural gas-fired generation is used to account for the power variability in
6 wind generation.

7 The natural gas-fired generating component of this combination alternative would qualify as a
8 new major-emitting industrial facility and would be subject to PSD under CAA requirements
9 (EPA 2010). Washington State’s EFSEC, which coordinates all evaluation and licensing steps
10 for siting certain energy facilities in Washington State, has adopted WAC 173-400-720, which
11 implements the EPA’s PSD review. The natural gas-fired plant would need to comply with the
12 standards of performance for electric utility steam-generating units set forth in 40 CFR Part 60
13 Subpart Da.

14 Subpart P of 40 CFR Part 51 contains the visibility protection regulatory requirements, including
15 the review of the new sources that would be constructed in the attainment or unclassified areas
16 and may affect visibility in any Federal Class I area. If the natural gas-fired component of this
17 combination alternative were located close to a mandatory Class I area, additional air pollution
18 control requirements would be required. As noted in Section 2.2.2.1, there are no Mandatory
19 Class I Federal areas within 50 mi of the CGS site. The closest Mandatory Class I Federal area
20 is Goat Rocks Wilderness Area, which is approximately 100 mi west of the CGS site
21 (40 CFR 81.434).

22 The NRC projects the following emissions, assuming a maximum of 860 MWe power for the
23 natural gas-fired component of this combination alternative based on data published by the EIA,
24 EPA, and on performance characteristics and emissions controls:

- 25 • SO_x—65 T (59 MT) per year
- 26 • NO_x—206 T (187 MT) per year
- 27 • CO—43 T (39 MT) per year
- 28 • TSP—37 T (33 MT) per year
- 29 • PM₁₀—37 T (33 MT) per year
- 30 • CO₂—2,203,750 T (1,999,208 MT) per year.

31 A new natural gas-fired plant would have to comply with Title IV of the CAA (42 USC 7651)
32 reduction requirements for SO_x and NO_x, which are the main precursors of acid rain and the
33 major cause of reduced visibility. Title IV establishes maximum SO_x and NO_x emission rates
34 from the existing plants and a system of SO_x emission allowances that can be used, sold, or
35 saved for future use by the new plants.

36 There would be no operating emissions from the hydropower, wind, and conservation
37 components of this combination alternative.

38 **8.3.1.1 Sulfur Oxide, Nitrogen Oxide, Carbon Dioxide**

39 As stated above, the new natural gas-fired component to this combination alternative would
40 produce up to 65 T (59 MT) per year of SO_x and 206 T (187 MT) per year of NO_x based on the
41 use of the dry low NO_x combustion technology and the use of the SCR to significantly reduce
42 NO_x emissions.

1 The new plant would be subjected to the continuous monitoring requirements of SO_x, NO_x, and
 2 CO₂ specified in 40 CFR Part 75. The natural gas-fired plant would emit approximately
 3 2.2 million tons (approximately 2.0 million MT) per year of unregulated CO₂ emissions. In
 4 August 2008, the EFSEC proposed a new WAC chapter (463-90) for mandatory reporting of
 5 GHG emissions from large sources. EFSEC is working with the WDOE Air Quality Program to
 6 adopt the rule for sources or combination of sources that emit at least 10,000 MT of GHGs
 7 annually in the state.

8 **8.3.1.2 Particulates**

9 The new natural gas-fired alternative would produce 37 T (33 MT) per year of TSP, all of which
 10 would be emitted as PM₁₀.

11 **8.3.1.3 Hazardous Air Pollutants**

12 In December 2000, the EPA issued regulatory findings (EPA 2000a) on emissions of HAPs from
 13 electric utility steam-generating units, which identified that natural gas-fired plants emit HAPs
 14 such as arsenic, formaldehyde, and nickel, and stated that:

15 Also in the utility RTC (Report to Congress), the EPA indicated that the impacts
 16 due to HAP emissions from natural gas-fired electric utility steam generating
 17 units were negligible based on the results of the study. The Administrator finds
 18 that regulation of HAP emissions from natural gas-fired electric utility steam
 19 generating units is not appropriate or necessary.

20 **8.3.1.4 Construction Impacts**

21 Activities associated with the construction of the new natural gas-fired, hydropower, and
 22 wind-energy plants would cause some additional, temporary air effects as a result of equipment
 23 emissions and fugitive dust from operation of the earth-moving and material-handling
 24 equipment. Emissions from workers' vehicles and motorized construction equipment exhaust
 25 would be temporary. It is expected that the construction crews would use dust-control practices
 26 to control and reduce fugitive dust. Therefore, the impact of vehicle exhaust emissions and
 27 fugitive dust from operation of the earth-moving and material-handling equipment would be
 28 SMALL.

29 Based on this information, the overall air-quality impacts of this combination alternative, which
 30 includes natural gas-fired generation, hydropower, wind energy, and energy conservation,
 31 would be SMALL to MODERATE.

32 **8.3.2 Groundwater Use and Quality**

33 The combination alternative would require about two-thirds the amount of the water
 34 consumption assumed for the natural gas-fired combined-cycle generation alternative. The
 35 NRC also assumed about the same ratio of groundwater use to surface-water use as that for
 36 the existing CGS; thus, the impact of the combination alternative on groundwater would be
 37 SMALL. The construction and operation of new wind-power projects and the installation and
 38 operation of power facilities at existing hydropower sites would have negligible impacts on
 39 groundwater.

1 **8.3.3 Surface-Water Use and Quality**

2 The combination alternative would require about two-thirds the amount of the water
3 consumption assumed for the natural gas-fired combined-cycle generation alternative; thus, the
4 impact of the combination alternative on surface-water use and quality were also designated as
5 SMALL.

6 The construction of utility-scale wind-power projects would require installation of access roads
7 and support facilities. The NRC assumes that State and local agencies would require
8 erosion-control measures that would prevent any degradation of the quality of surface waters on
9 or downstream from wind-power development sites. In addition, the NRC assumes that new
10 hydropower installations at operating sites (dams) would be in accordance with State and
11 Federal regulations on surface-water impoundments and dam operations and that surface-water
12 quantity and quality would not be affected. For these reasons, the impact of the Combination
13 Alternative on surface-water quality and quantity would be SMALL.

14 **8.3.4 Aquatic Ecology**

15 Impacts on the aquatic ecology of the CGS site for the combination alternative of wind power,
16 natural gas-fired units, and hydropower would be associated with activities in and use of the
17 water. Wind-power systems on the CGS site would not require water; thus, construction of the
18 systems would not disturb the aquatic ecology of the site. The NRC assumes that the cooling
19 systems for the two new natural gas-fired units would use the existing intake and discharge
20 systems. Water consumption for the cooling systems of the natural gas-fired units would be
21 less than for the CGS. Air emissions from the natural gas-fired units would be a new source of
22 pollutants that would deposit on the river's surface; however, due to fast flows in the river,
23 exposure of the pollutants to the aquatic resources would likely be minimal. Alterations in water
24 flow from operation of previously developed but currently unpowered hydroelectric sites would
25 result in several types of impacts on the aquatic ecology of the river system, including alteration
26 of aquatic habitat and impacts from interaction with the hydropower structure. Hydropower in
27 the Columbia River basin has adversely affected aquatic endangered species (e.g., Chinook
28 salmon), and these impacts are currently being mitigated as directed by the Biological Opinion
29 for the Federal Columbia River Power System (NMFS 2010). Because of the potential habitat
30 disturbances and impacts on endangered species from the additional use of hydropower,
31 impacts on aquatic resources from the combined alternative would be MODERATE.

32 **8.3.5 Terrestrial Ecology**

33 A combination alternative of a two natural gas-fired units, a system using wind energy, and
34 energy conservation would make use of existing disturbed land at the CGS site for the natural
35 gas units and the existing mechanical draft cooling towers. This alternative would also require
36 land offsite for the gas pipeline and would require additional land offsite to accommodate the
37 number of turbines necessary in a wind farm to offset the power generated by the CGS.

38 This alternative would use a portion of the existing plant site land, switchyard, and
39 transmission-line system for construction of the natural gas-fired unit. Impacts on terrestrial
40 ecology from on-site construction of two natural gas-fired units would be less than the impacts
41 described for the three-unit natural gas-fired alternative. Impacts on terrestrial ecology from
42 offsite construction of the 15 mi-long (24-km-long) gas pipeline for the two natural gas-fired units
43 would be the same as for the three natural gas-fired unit alternative previously discussed.

1 Based upon data in the GEIS, the wind farm component of the combination alternative
 2 producing 175 MWe of electricity would require approximately 11,000 ac (4,450 ha) spread over
 3 several offsite locations, with approximately 45 ac (18 ha) in actual use. The remainder of the
 4 land would remain in agriculture. Additional land may be needed for construction of
 5 transmission-line corridors to connect to existing transmission-line corridors.

6 Impacts on terrestrial ecology from construction of the wind farm portion of the combination
 7 alternative and any needed transmission lines could include loss of terrestrial habitat, an
 8 increase in habitat fragmentation, and corresponding increase in edge habitat, and may affect
 9 threatened and endangered species. The GEIS notes that habitat fragmentation may lead to
 10 declines in migrant bird populations. Bird mortality would increase from construction of the wind
 11 farm, although proper site selection for the wind farm could help to reduce bird strikes. The
 12 GEIS noted that wind farms typically do not cause significant adverse impacts on bird
 13 populations, although thousands of acres of wildlife habitat or agricultural land could be
 14 affected, and wildlife migratory routes could be disrupted (NRC 1996).

15 Based on this information, impacts on terrestrial resources would be MODERATE.

16 **8.3.6 Human Health**

17 The human health risks from a combination of alternatives include the effects already discussed
 18 in Section 8.2.6 for the NGCC plant, and they were found to be SMALL. For the environmental
 19 impacts of alternatives including conservation and demand-side management, the GEIS
 20 (NRC, 1996) notes that the environmental impacts from these alternatives are likely to be
 21 centered on indoor air quality, with radon as a potential health risk. This is due to increased
 22 weatherization of the home in the form of extra insulation and reduced air turnover rates from
 23 the reduction in air leaks. However, based on the assumption that a member of the public has
 24 implemented mitigative measures to minimize levels of indoor radon, the staff concludes that
 25 the human health risks to members of the public from the conservation portion of this alternative
 26 would be SMALL. For wind capacity, the GEIS notes that construction and routine operations
 27 would not affect human health because the construction and operation of the facilities are
 28 expected to comply with Federal and State safety standards to protect the workers and the
 29 public.

30 The NRC considers the human health risks from the combination of alternatives to be SMALL.

31 **8.3.7 Land Use**

32 The GEIS generically evaluates the impact of nuclear power plant operations on land use, both
 33 on and off each power plant site. The analysis of land use impacts for the combination
 34 alternative includes impacts from the amount of land area required for the construction and
 35 operation of a two unit natural gas-fired combined cycle power plant at the CGS site, an offsite
 36 wind energy generating facility, offsite hydropower, and the effects of implementing energy
 37 conservation and efficiency.

38 Based on GEIS estimates, approximately 92 ac (37 ha) of land would be needed to support the
 39 two unit natural gas-fired portion of the combination alternative. Because of the availability of
 40 land, land use construction impacts at CGS would be SMALL.

41 In addition to onsite land requirements, land would be required offsite for natural gas wells and
 42 collection stations. Scaling from GEIS estimates, approximately 7,900 ac (3,200 ha) would be
 43 required for wells, collection stations, and pipelines to bring the gas fuel to the power plant.

Environmental Impacts of Alternatives

1 Most of this land requirement would occur on land where gas extraction already occurs. In
2 addition, some natural gas could come from outside the U.S. and be delivered as liquefied gas.

3 The wind farm component of the combination alternative producing 175 MWe of electricity
4 would require approximately 11,000 ac (4,450 ha) spread over several offsite locations, with
5 approximately 45 ac (18 ha) in actual use. Although the wind farm would require a large
6 amount of land, only a small component of that land would be in actual use. In addition, the
7 elimination of uranium fuel for CGS could partially offset offsite land requirements. Scaling from
8 GEIS estimates, approximately 1,150 ac (465 ha) would not be needed for mining and
9 processing uranium during the operating life of the plant.

10 The land use impacts of the energy conservation and efficiency component of this combination
11 alternative would be SMALL. The rapid replacement and disposal of old energy inefficient
12 appliances and other equipment would generate waste material and could increase the size of
13 landfills; however, given the time for program development and implementation, the cost of
14 replacements, and the average life of equipment, the replacement process would probably be
15 gradual. More efficient appliances and equipment would replace older equipment (especially in
16 the case of frequently replaced items, such as light bulbs). In addition, many items (such as
17 home appliances and industrial equipment) have recycling value and would not be disposed of
18 in landfills. Overall land use impacts from the combination alternative could range from SMALL
19 to MODERATE.

20 **8.3.8 Socioeconomics**

21 As previously discussed, socioeconomic impacts are defined in terms of changes to the
22 demographic and economic characteristics and social conditions of a region. For example, the
23 number of jobs created by the construction and operation of a new natural gas-fired power plant
24 could affect regional employment, income, and expenditures. Two types of jobs are created by
25 this alternative: (1) construction related jobs, which are transient, short in duration, and less
26 likely to have a long term socioeconomic impact; and (2) operation related jobs in support of
27 power plant operations, which have the greater potential for permanent, long term
28 socioeconomic impacts. Workforce requirements of power plant construction and operations for
29 the natural gas-fired power plant alternative were determined in order to measure their possible
30 effect on current socioeconomic conditions.

31 Impacts from this alternative would include the types of impacts discussed for socioeconomics
32 in Section 8.1.8 of this SEIS. Section 8.1.8 states that the socioeconomic impacts from the
33 construction and operation of three natural gas-fired units at CGS would be SMALL to
34 MODERATE. Based on GEIS projections, and a workforce of 1,200 for a 1,000 MWe plant, the
35 two unit gas-fired portion of the combination alternative at CGS would require a peak estimated
36 construction workforce of 1,075 workers. Accordingly, the socioeconomic impacts from the
37 natural gas-fired component of the combination alternative would be SMALL to MODERATE.

38 An estimated additional 350 construction workers would be required for the wind farm. These
39 workers could cause a short-term increase in the demand for services and temporary (rental)
40 housing in the region around the construction site.

41 After construction, local communities may be temporarily affected by the loss of construction
42 jobs and associated loss in demand for business services, and the rental housing market could
43 experience increased vacancies and decreased prices. However, these effects would likely be
44 spread over a larger area, as the wind farms may be constructed in more than one location.

1 The combined effects of these two construction activities would range from SMALL to
 2 MODERATE.

3 Additional estimated operations workforce requirements for this combination alternative would
 4 include an estimated 124 operations workers for the gas-fired power plant and 50 operations
 5 workers for the wind farm. Given the small number of operations workers at these facilities,
 6 socioeconomic impacts associated with operation of the natural gas-fired power plant at CGS
 7 and the wind farm would be SMALL. Socioeconomic effects of an energy conservation and
 8 efficiency program would be SMALL. As noted in the GEIS, the program would require
 9 additional workers.

10 **8.3.9 Transportation**

11 Construction and operation of a natural gas-fired power plant and wind farm would increase the
 12 number of vehicles on the roads near these facilities. During construction, cars and trucks
 13 would deliver workers, materials, and equipment to the worksites. The increase in vehicular
 14 traffic would peak during shift changes resulting in temporary levels of service impacts and
 15 delays at intersections. Transporting components of wind turbines could have a noticeable
 16 impact, but is likely to be spread over a large area. Pipeline construction and modification to
 17 existing natural gas pipeline systems could also have an impact. Traffic-related transportation
 18 impacts during construction could range from SMALL to MODERATE depending on the location
 19 of the wind farm site, current road capacities, and average daily traffic volumes.

20 During plant operations, transportation impacts would not be noticeable. Given the small
 21 numbers of operations workers at these facilities, the levels of service traffic impacts on local
 22 roads from the operation of the gas fired power plant at CGS and at the wind farm would be
 23 SMALL. Transportation impacts at the wind farm site or sites would also depend on current
 24 road capacities and average daily traffic volumes, but are likely to be small given the low
 25 number of workers employed by that component of the alternative. Any transportation effects
 26 from the energy efficiency alternative would be widely distributed across the state and would not
 27 be noticeable.

28 **8.3.10 Aesthetics**

29 The aesthetics impact analysis focuses on the degree of contrast between the surrounding
 30 landscape and the visibility of the power plant. In general, aesthetic changes would be limited
 31 to the immediate vicinity of the CGS site and the wind farm facilities.

32 Aesthetic impacts from the natural gas-fired power plant component of the combination
 33 alternative would be essentially the same as those described for the natural gas-fired alternative
 34 in Section 8.1.10. Power plant infrastructure would be generally smaller and less noticeable
 35 than CGS containment and turbine buildings. Mechanical draft cooling towers would continue to
 36 generate condensate plumes and operational noise. Noise during power plant operations would
 37 be limited to industrial processes and communications. In addition to the power plant
 38 structures, construction of natural gas pipelines would have a short-term impact. Noise from the
 39 pipelines could be audible offsite near compressors. In general, aesthetic changes would be
 40 limited to the immediate vicinity of CGS and would be SMALL.

41 The wind farm would have the greatest visual impact. The 290 wind turbines at over 300 ft (100
 42 m) tall and spread across multiple sites covering 11,000 ac (4,450 ha) would dominate the view
 43 and would likely become the major focus of attention. Depending on its location, the aesthetic
 44 impacts from the construction and operation of the wind farm would be MODERATE to LARGE.

Environmental Impacts of Alternatives

1 Impacts from energy conservation and efficiency program would be SMALL. Some noise
2 impacts could occur in instances of energy conservation and efficiency upgrades to major
3 building systems, but this impact would be intermittent and short lived.

4 **8.3.11 Historic and Archaeological Resources**

5 The same considerations, discussed in Section 8.1.11, for the impact of the construction of a
6 natural gas-fired plant on historic and archaeological resources apply to the construction
7 activities that would occur on the CGS site for a new natural gas-fired power-generating plant.
8 As previously noted, the potential for historic and archaeological resources can vary greatly
9 depending on the location of the proposed site. To consider a project's effects on historic and
10 archaeological resources, any affected areas would need to be surveyed to identify and record
11 historic and archaeological resources, identify cultural resources (e.g., traditional cultural
12 properties), and develop possible mitigation measures to address any adverse effects from
13 ground-disturbing activities.

14 As described in Section 2.9, much of the CGS site has been previously disturbed by the partial
15 construction of Units 1 and 4 and CGS. In addition, the CGS site has been surveyed for cultural
16 resources, resulting in the identification of archaeological sites within the vicinity of the
17 pumphouse and intake structure. There is a low potential for cultural resources to be located in
18 previously undisturbed portions of the CGS site.

19 Surveys would be needed to identify, evaluate, and address mitigation of potential impacts prior
20 to the construction of any new power-generating facility. Studies would be needed for all areas
21 of potential disturbance (e.g., roads, transmission corridors, rail lines, or other ROWs). Areas
22 with the greatest sensitivity should be avoided. Because Energy Northwest would conduct a
23 survey and apply its established protection plan for future resources, the impact of a new natural
24 gas-fired power plant at the CGS site on historic and archaeological resources would be
25 SMALL.

26 Depending on the resource richness of the site chosen for the wind farm, the impacts could
27 range between SMALL to MODERATE. Therefore, the overall impacts on historic and
28 archaeological resources from the combination alternative could range from SMALL to
29 MODERATE.

30 Impacts to historic and archaeological resources from implementing the energy efficiency and
31 conservation program would be SMALL and would not likely affect land use or historical or
32 cultural resources elsewhere in the State.

33 **8.3.12 Environmental Justice**

34 The environmental justice impact analysis evaluates the potential for disproportionately high and
35 adverse human health and environmental effects on minority and low-income populations that
36 could result from the construction and operation of a new natural gas-fired power plant at CGS,
37 wind farm, and Energy Conservation and Efficiency Program. Adverse health effects are
38 measured in terms of the risk and rate of fatal or nonfatal adverse impacts on human health.
39 Disproportionately high and adverse human health effects occur when the risk or rate of
40 exposure to an environmental hazard for a minority or low-income population is significant and
41 exceeds the risk or exposure rate for the general population or for another appropriate
42 comparison group. Disproportionately high environmental effects refer to impacts or risk of
43 impact on the natural or physical environment in a minority or low-income community that are
44 significant and appreciably exceed the environmental impact on the larger community. Such

1 effects may include biological, cultural, economic, or social impacts. Some of these potential
 2 effects have been identified in resource areas discussed in this SEIS. For example, increased
 3 demand for rental housing during power plant construction could disproportionately affect low-
 4 income populations. Minority and low-income populations are subsets of the general public
 5 residing around the a power plant, and all are exposed to the same hazards generated from
 6 constructing and operating a natural gas-fired power plant and wind farm.

7 Low-income families could benefit from weatherization and insulation programs. This effect
 8 would be greater than the effect for the general population because (according to the Office of
 9 Management and Budget (OMB)) low-income households experience home energy burdens
 10 more than four times larger than the average household (OMB, 2007). Weatherization
 11 programs could target low-income residents as a cost-effective energy efficiency option since
 12 low-income populations tend to spend a larger proportion of their incomes paying utility bills
 13 (OMB, 2007). Overall impacts to minority and low-income populations from energy
 14 conservation and efficiency programs would be nominal, depending on program design and
 15 enrollment. Potential impacts to minority and low-income populations from the construction and
 16 operation of a natural gas-fired power plant at CGS and wind farm would mostly consist of
 17 environmental and socioeconomic effects (e.g., noise, dust, traffic, employment, and housing
 18 impacts). Noise and dust impacts from construction would be short-term and primarily limited to
 19 onsite activities. Minority and low-income populations residing along site access roads would
 20 also be affected by increased commuter vehicle traffic during shift changes and truck traffic.
 21 However, these effects would be temporary during certain hours of the day and not likely to be
 22 high and adverse. Increased demand for rental housing during construction in the vicinity of the
 23 Hanford Site and CGS and the wind farm could affect low-income populations. Given the close
 24 proximity to the Tri-Cities metropolitan area, most construction workers would likely commute to
 25 the site, thereby reducing the potential demand for rental housing.

26 Based on this information, and the analysis of human health and environmental impacts
 27 presented in this SEIS, the construction and operation of a natural gas-fired power plant and the
 28 wind farm (depending on its location) would not have a disproportionately high and adverse
 29 human health and environmental effects on minority and low-income populations.

30 **8.3.13 Waste Management**

31 During the construction stage of this combination of alternatives, land clearing and other
 32 construction activities would generate wastes that could be recycled, disposed of onsite, or
 33 shipped to the offsite waste disposal facility. During the operational stage, spent SCR catalysts,
 34 which control NO_x emissions from the natural gas-fired plants, would make up the majority of
 35 the waste generated by this alternative.

36 There would be an increase in wastes generated during installation or implementation of
 37 conservation measures, such as appropriate disposal of old appliances, installation of control
 38 devices, and modifications of buildings. New and existing recycling programs would help to
 39 minimize the amount of generated waste.

40 The NRC concludes that overall waste impacts from the combination of the natural gas-fired unit
 41 constructed onsite, hydropower, a renewable energy component other than hydropower (i.e.,
 42 wind capacity), and conservation would be SMALL.

1 **8.3.14 Summary of Impacts of the Combination Alternative**

2 Table 8.3-1 summarizes the environmental impacts of the combined alternative compared to
 3 continued operation of CGS.

4 **Table 8.3-1. Summary of environmental impacts of the combination alternative compared to continued operation of CGS**
 5

| Category | Combination alternative | Continued CGS operation |
|-----------------------------------|-------------------------|-------------------------|
| Air quality | SMALL to MODERATE | SMALL |
| Groundwater | SMALL | SMALL |
| Surface water | SMALL | SMALL |
| Aquatic and terrestrial resources | MODERATE | SMALL |
| Human health | SMALL | SMALL |
| Socioeconomics | SMALL to LARGE | SMALL |
| Waste management | SMALL | SMALL |

6 **8.4 Alternatives Considered but Dismissed**

7 This section presents alternatives to license renewal that were eliminated from detailed study
 8 due to technical reasons, resource availability, or current commercial limitations. The NRC
 9 believes that these limitations would continue to exist when the existing CGS license expires.
 10 Under each of the following technology headings, the NRC explains why it dismissed each
 11 alternative from further consideration.

12 **8.4.1 Offsite New Nuclear and Natural Gas-Fired Capacity**

13 While new natural gas-fired and nuclear power-generating facilities like those considered in
 14 Sections 8.1 and 8.2, respectively, could be constructed offsite rather than at the CGS site, the
 15 impacts would be far greater than constructing these facilities and making use of existing
 16 infrastructure at the CGS site. Additional impacts would occur from the construction of new
 17 water intake and discharge structures, as well as other support infrastructure including new
 18 transmission lines, roads, and railway spurs that are already present on the CGS site.
 19 Furthermore, the community around the Hanford Site and CGS is already familiar with the
 20 appearance of a power facility, and it is an established part of the region’s historic and aesthetic
 21 character. Workers skilled in power plant operations may not be as readily available in other
 22 locations. Remediation may be necessary at other industrial sites to make the site ready for
 23 redevelopment. In short, an existing power plant site would present the best offsite location for
 24 a new generation facility with a new nuclear reactor or natural gas-fired power plant.

25 **8.4.2 New Coal-Fired Capacity**

26 Coal-fired generation accounts for a greater share of U.S. electrical power generation than any
 27 other fuel (EIA 2009a). Furthermore, the EIA projects that new coal-fired power plants will
 28 account for the greatest share of capacity additions through 2030—more than natural gas,
 29 nuclear, or renewable generation options. Integrated-gasification combined-cycle technology is
 30 an emerging coal option that uses coal gasification technology and is substantially cleaner than
 31 conventional pulverized coal plants due to the removal of major pollutants from the gas stream
 32 before combustion. While coal-fired power plants are widely used and likely to remain widely

1 used, the NRC acknowledges that future additions to coal capacity may be affected by
2 perceived or actual efforts to limit GHG emissions.

3 Energy Northwest has considered constructing new coal-fired generating capacity in its service
4 territory. In particular, in 2006, Energy Northwest submitted an application for the Pacific
5 Mountain Energy Center, a 680-MW, two-unit electrical generation facility, proposed to operate
6 on synthetic gas produced from coal or petroleum coke, at a site in Kalama, WA. However, with
7 the passage of Washington State Senate Bill 6001 in July 2007, Washington State now requires
8 new coal-fired power plants to include provisions for carbon capture and storage. In November,
9 2007, the Washington State EFSEC concluded that Energy Northwest's proposed GHG
10 reduction plan for the Pacific Mountain Energy Center failed to meet the requirements of the
11 statute, and was rejected. Energy Northwest considered converting the proposed plant to a
12 gas-fired plant, but determined that financial and economic conditions do not support a 680-MW
13 project. By letter dated May 5, 2009, Energy Northwest requested that its application for the
14 Pacific Mountain Energy Center be terminated.

15 Although coal-fired generation is technically feasible and can supply baseload capacity similar
16 to that supplied by CGS, the technology required for economic carbon capture is not expected
17 to be available in time to include as part of a new coal plant to replace CGS when its license
18 expires. It is also uncertain whether a utility would pursue a permit in the State of Washington
19 due to uncertainties in the permitting process. For these reasons, the NRC does not consider
20 the construction of a large, base-load coal-fired power plant in Washington State as a
21 reasonable alternative to continued CGS operation.

22 **8.4.3 Energy Conservation and Energy Efficiency**

23 Although often used interchangeably, energy conservation and energy efficiency are different
24 concepts. Energy efficiency means deriving a similar level of services by using less energy,
25 while energy conservation shows a reduction in total energy consumption. Both fall into a larger
26 category known as demand-side management. Demand-side management measures address
27 energy end uses—unlike energy supply alternatives discussed in previous sections.
28 Demand-side management can include measures that do the following:

- 29 • Shift energy consumption to different times of the day to reduce peak loads
- 30 • Interrupt certain large customers during periods of high demand
- 31 • Interrupt certain appliances during high-demand periods
- 32 • Replace older, less efficient appliances, lighting, or control systems
- 33 • Encourage customers to switch from gas to electricity for water heating and other similar
34 measures that utilities use to boost sales

35 Unlike other alternatives to license renewal, the GEIS notes that conservation is not a discrete
36 power-generating source; it represents an option that States and utilities may use to reduce
37 their need for power-generation capability (NRC 1996). Since 1982, the Bonneville Power
38 Authority and regional utilities, including Energy Northwest, have developed and carried out a
39 variety of energy conservation programs designed to reduce both peak demands and daily
40 energy consumption. These load-management and energy-efficiency programs have reduced
41 demand by over 1,500 average megawatts. Although these programs will continue, NRC does
42 not consider that future energy savings will be a reasonable offset to the CGS baseload
43 capacity. Because of this, the NRC has not evaluated energy conservation and efficiency as
44 discrete alternatives to license renewal. They have, however, been considered as components
45 of the combination alternative.

1 **8.4.4 Purchased Power**

2 In its ER, Energy Northwest stated that purchased electrical power is, in theory, a potential
3 alternative to CGS license renewal. Washington State typically exports surplus power through
4 the Pacific Intertie, which was established to transmit electricity south to California during peak
5 summer months. During periods of low hydroelectric generation in the Pacific Northwest,
6 energy is also sometimes purchased and imported to Washington. However, for the 2023–2043
7 time frame of CGS’s renewal, there are no guaranteed available power sources to replace the
8 1,150 MWe of baseload capacity that CGS supplies. Because of the lack of assured availability
9 of purchased electrical power, the NRC has not evaluated purchased power separately as an
10 alternative to license renewal. However, purchased power has been considered as a
11 component of the combination alternative, as a replacement for wind power when wind is not
12 available.

13 **8.4.5 Solar Power**

14 Solar technologies use the sun’s energy to produce electricity. Southeastern Washington
15 receives approximately 4.0–4.5 kWh per square meter per day (EERE 2008). Energy
16 Northwest currently operates the 30-kW White Bluffs Solar Station on the IDC site east of the
17 CGS site. Similar small solar projects may be developed near the CGS site as part of the
18 planned energy park on the Hanford Site or as part of other utility generation development.

19 While it is theoretically possible to replace CGS’s capacity with solar photovoltaic technology,
20 land requirements for such a facility would be significant. Energy Northwest estimates that
21 flat-plate photovoltaics would require 7.4 ac/MWe and concentrating systems would require
22 4.9 ac/MWe. Therefore, replacing the installed capacity of CGS would require from 8.75 square
23 miles (mi²) to more than 13 mi² for a similar capacity solar plant. Because solar plants tend to
24 be roughly 25-percent efficient, a solar-powered alternative would require at least 35 mi² of
25 collectors to provide an amount of electricity equivalent to that generated by CGS. Space
26 between parcels and associated infrastructure would increase this land requirement. The
27 Hanford Site, at over 500 mi², is theoretically large enough for a facility of this size.

28 NUREG-1437, Section 8.3 (NRC 1996, 1999) describes the potential environmental impacts
29 associated with a large-scale solar generation facility and transmission lines. The construction
30 impacts for a 35-mi² facility would likely be significant and would include impacts on sensitive
31 areas and loss of productive land. The operating facility would also have considerable
32 continuing aesthetic impact. In addition, in the GEIS, the NRC noted that, by its nature, solar
33 power is intermittent (i.e., it does not work at night and cannot serve baseload when the sun is
34 not shining), and the efficiency of collectors varies greatly with weather conditions. A
35 solar-powered alternative would require energy storage or backup power supply from other
36 sources to supply equivalent electric power at night. Given the significant environmental
37 impacts and the challenges in meeting baseload requirements, the NRC did not evaluate a
38 large-scale solar power plant as an alternative to CGS license renewal.

39 Installations of solar panels on residential and commercial rooftops are referred to as
40 “distributed solar power,” and it is theoretically possible to replace CGS’s annual generation with
41 these types of solar installations. Assuming a 90-percent capacity factor, CGS produces over
42 9 million mWh annually. Based on an average house size of 139 m² (1,500 square feet (ft²))
43 with a usable roof space of 70 m² (753 ft²) and a conversion efficiency of 15 percent, over
44 500,000 new or existing homes would have to be fitted with solar panels to replace the
45 generation from CGS. With a population of just over 1.3 million, this alternative would likely
46 require installations on nearly every residence in eastern Washington. Without significant

1 government or utility incentives, installation of distributed solar panels on this scale in either
 2 commercial or residential applications is unlikely. In addition, as with larger-scale solar plants,
 3 this solar alternative would require energy storage or backup power supply from other sources
 4 at night to supply baseload generation equivalent to that of the CGS. For these reasons, NRC
 5 did not evaluate distributed solar as an alternative to CGS license renewal.

6 **8.4.6 Wind Power**

7 The American Wind Energy Association (AWEA) reports that a total of 25,369 MW of wind
 8 energy capacity was installed in the U.S. at the end of 2008, with 8,545 MW installed just in
 9 2008 (AWEA 2009). Texas is by far the leader in installed capacity with 2,671 MW, followed by
 10 Iowa (1,600 MW), Minnesota (456 MW), Kansas (450 MW), and New York (407 MW). The
 11 National Renewable Energy Laboratory (NREL 2010) estimates that Washington State has a
 12 wind energy potential of over 18,000 MW of installed capacity with annual generation of over
 13 55,000 Gigawatt hours (GWh) (considering sites with capacity factors greater than or equal to
 14 30 percent at 80-m height). The Northwest Power and Conservation Council identified
 15 utility-scale wind power as a generating resource with up to 5,000 MWe new potential capacity
 16 in the region west of the Continental Divide (NWPCC 2005), although the potential power output
 17 from developable sites would likely be less.

18 At the current stage of wind energy technology development, wind resources of Category 3 or
 19 better¹ are required to produce utility-scale amounts of electricity. There are locations meeting
 20 this criterion in eastern Washington, west and south of the Hanford Site in the Columbia River
 21 basin. Four wind projects within 50 mi of Hanford have been proposed, constructed, or are
 22 operational, including Big Horn, Combine Hills II, Desert Claim, and Wild Horse. In total, these
 23 projects include the construction and operation of 418 wind turbines that would generate
 24 682 MW of electricity (DOE 2009; EFSEC 2010; NWPCC 2010).

25 Land-based wind turbines have individual capacities as high as 3 MW, with the 1.67-MW turbine
 26 being the most popular size to have been installed in 2008 (offshore wind turbines have
 27 capacities as high as 5 MW). At these sizes, many hundreds of turbines would be required to
 28 meet the baseload capacity of the CGS reactor. Further, to avoid inter-turbine interferences in
 29 wind flow through the wind farm, turbines must be located well separated from each other,
 30 resulting in utility-scale wind farms requiring substantial amounts of land.² Energy Northwest
 31 estimates that 270 mi² of land would be necessary to generate 1,150 MWe of power. In
 32 addition, because prime wind areas are often located on ridgetops and other areas far from
 33 transmission facilities, utility-scale development would have significant economic and
 34 environmental costs.

35 The capacity factors of wind farms are primarily dependent on the constancy of the wind
 36 resource and while offshore wind farms can have relatively high capacity factors due
 37 high-quality winds throughout much of the day (resulting primarily from differential heating of
 38 land and sea areas), land-based wind farms typically have capacity factors typically less than
 39 40 percent. For example, although the three large wind power projects installed in Washington

¹ By industry convention, wind resource values are categorized on the basis of the power density and speed of the prevailing wind at an elevation of 50 m, from Category 1 with wind power densities of 200 to 300 W/m² (typically existing with constant wind speeds between 12.5 to 14.3 mph [5.8-6.4 m/s] through Category 7 with power densities of 800-1800 W/m² (wind speeds of 19.7 to 24.8 mph [8.8-11.1 m/s]). Category 3 wind has a power density of 300 to 400 W/m² with wind speeds of 15.7 to 16.8 mph (7.0 to 7.5 m/s).

² However, the permanent components of wind farms, the individual turbines, electrical substations, and maintenance/control/storage buildings, occupy roughly 5 percent of the area of a typical wind farm with the remaining land areas available for most other non-intrusive land uses once construction is completed.

Environmental Impacts of Alternatives

1 have a combined potential capacity of 369 MWe, these projects averaged only 113 MWe from
2 October 2007–October 2008 (EN, 2010a), or 31-percent capacity. Even assuming 40 percent
3 as a capacity factor, a wind farm would require an installed capacity of roughly twice CGS’s
4 capacity to produce the same amount of electricity. To be considered baseload power, the
5 majority of this energy would have to be stored for use when wind is not available. However,
6 energy storage options available to overcome wind intermittency and variability are limited and
7 expensive.

8 Because of the intermittent nature of wind power and substantial land requirements of large
9 wind farms, the NRC does not consider a utility-scale wind farm, by itself, as a reasonable
10 alternative to the renewal of the CGS operating license. However, the Northwest Power and
11 Conservation Council (NWPCC) does anticipate that wind power additions will be important new
12 generation sources in the license renewal period, with a 100-MWe plant being considered as
13 the reference plant (NWPCC 2005). Accordingly, the NRC considered smaller-scale wind farms
14 as renewable energy components of the combination alternative.

15 **8.4.7 Biomass Waste**

16 Eastern Washington has many biomass fuel resources including forest, mill, agricultural, animal
17 waste, and municipal waste, as well as energy crop potential. The Pacific Region Bioenergy
18 Partnership estimates that Washington State’s annual production of 16.9 million dry tons of
19 biomass per year has an energy potential of 15.9 terawatt hours of electricity
20 (<http://www.pacificbiomass.org/WABiomassInventory.aspx>). In its ER, Energy Northwest stated
21 its intention to pursue one or more 50-MWe wood waste projects in the Pacific Northwest with
22 two industrial partners (ADAGE, 2009), (EN, 2010a). Forestry waste comprises about half of
23 the biomass inventory in Washington State.

24 Walsh et al. (2000) note that estimates of biomass capacity contain substantial uncertainty, and
25 potential availability does not mean biomass will actually be available at the economic prices
26 shown or that resources will be useably free of contamination. Some of these plant wastes
27 already have reuse value and would likely be more costly to deliver because of competition.
28 Others, such as forest residues, may prove unsafe and unsustainable to harvest on a regular
29 basis, or may prove uneconomic if significant transportation is required to bring the waste to the
30 plant. Because the wood waste technology is relatively inefficient and expensive, and because
31 economic operation relies on siting near fuel sources, plant sizes are generally small relative to
32 CGS. To replace the CGS, 23 plants of the size Energy Northwest is considering would have to
33 be constructed. The NRC also acknowledges that perceived or actual efforts to limit GHG
34 emissions may affect biomass-fired generation. As a result, the NRC has not considered a
35 biomass-fired alternative to CGS license renewal.

36 **8.4.8 Hydroelectric Power**

37 According to researchers at Idaho National Energy and Environmental Laboratory, Washington
38 State has an estimated 2,539 MWe of technically available, undeveloped hydroelectric
39 resources at 551 sites throughout the state (INEEL 1997). This potential capacity is greater
40 than the capacity of CGS and, if fully developed, could theoretically replace CGS’s baseload
41 generation. However, given that the average nameplate capacity of installed hydroelectric
42 projects in Washington is about 100 MWe, it would take more than 12 individual projects to
43 replace the baseload generation of CGS, considering hydropower availability. Hydroelectric
44 projects require individual licenses and permits to operate, which can often be difficult to obtain
45 due to environmental constraints. The NRC did not consider it reasonably foreseeable that
46 1,150 MWe of new hydroelectric baseload generating capacity could be permitted, developed,

1 and made available during the license renewal period. Therefore, the NRC did not evaluate
 2 hydropower, separately, as an alternative to license renewal. However, the NRC did consider
 3 hydropower installed at developed, but unpowered, sites as part of the combination alternative.

4 **8.4.9 Wave and Ocean Energy**

5 Wave and ocean energy has generated considerable interest in recent years. Ocean waves,
 6 currents, and tides are often predictable and reliable. Ocean currents flow consistently, while
 7 tides can be predicted months and years in advance with well-known behavior in most coastal
 8 areas. The Washington Coast and the Puget Sound have many potential wave and tidal energy
 9 development sites. However, most of these ocean energy technologies are in relatively early
 10 stages of development, and while some results have been promising, they are not likely to be
 11 able to replace the baseload capacity of CGS by the time its license expires. Accordingly, the
 12 NRC did not consider wave and ocean energy as an alternative to CGS license renewal.

13 **8.4.10 Geothermal Power**

14 Geothermal electric generation is limited by the geographical availability of geothermal
 15 resources (NRC 1996). Southeastern Washington has several known and potential geothermal
 16 regions which, according to the U.S. Geological Survey, have the potential to produce
 17 127 MWe. However, many areas are inaccessible for development and transmission lines
 18 because they are located on Federal property or in national parks. In addition, many of these
 19 areas, including reservoirs in the Columbia River basin, do not have the potential for high
 20 temperatures. The NRC concluded that geothermal energy is not a reasonable alternative to
 21 CGS license renewal.

22 **8.4.11 Municipal Solid-Waste**

23 Municipal solid-waste combustors use three types of technologies—mass burn, modular, and
 24 refuse-derived fuel. Mass burning is used most frequently in the U.S. and involves little sorting,
 25 shredding, or separation. Consequently, toxic or hazardous components present in the waste
 26 stream are combusted, and toxic constituents are exhausted to the air or become part of the
 27 resulting solid wastes. Currently, approximately 89 waste-to-energy plants operate in the U.S.
 28 These plants generate approximately 2,700 MWe, or an average of 30 MWe per plant (Michaels
 29 2007). In 2005, 4 percent of Washington State's municipal solid waste was burned for energy
 30 production. More than 38 average-sized new municipal solid waste combustion plants would be
 31 necessary to replace the CGS baseload capacity.

32 Estimates in the GEIS suggest that the overall level of construction impact from a waste-fired
 33 plant would be approximately the same as that for a coal-fired power plant. In addition,
 34 waste-fired plants have the same or greater operational impacts than coal-fired technologies
 35 have (including impacts on the aquatic environment, air, and waste disposal). The initial capital
 36 costs for municipal solid-waste plants are greater than for comparable steam-turbine technology
 37 at coal-fired facilities or at wood-waste facilities because of the need for specialized waste
 38 separation and handling equipment (NRC 1996).

39 The need for an alternative to landfills, rather than energy considerations, drives the decision to
 40 burn municipal waste to generate energy. The use of landfills as a waste disposal option is
 41 likely to increase as energy prices increase; however, municipal waste combustion facilities may
 42 become attractive again.

1 Regulatory structures that once supported municipal solid-waste incineration no longer exist.
2 The Tax Reform Act of 1986 made capital-intensive projects such as municipal-waste
3 combustion facilities more expensive relative to less expensive waste-disposal alternatives such
4 as landfills. Also, the 1994 Supreme Court decision *C&A Carbone, Inc. v. Town of Clarkstown*,
5 NY, struck down local flow control ordinances that required waste to be delivered to specific
6 municipal waste combustion facilities rather than landfills that may have had lower fees. In
7 addition, environmental regulations have increased the cost to construct and maintain municipal
8 waste combustion facilities.

9 Given the small average installed size of municipal solid-waste plants and the unfavorable
10 regulatory environment, the NRC does not consider municipal solid-waste combustion to be a
11 feasible alternative to CGS license renewal.

12 **8.4.12 Biofuels**

13 In addition to wood and municipal solid-waste fuels, there are other concepts for biomass-fired
14 electric generators, including conversion to liquid biofuels and biomass gasification. In the
15 GEIS, the NRC states that none of these technologies progressed to the point of being
16 competitive on a large scale or of being reliable enough to replace a baseload plant such as
17 CGS. After re-evaluating current technologies, the NRC finds other biomass-fired alternatives
18 are still unable to reliably replace the CGS capacity. For this reason, the NRC does not
19 consider other biomass-derived fuels to be feasible alternatives to CGS license renewal.

20 **8.4.13 Oil-Fired Power**

21 EIA projects that oil-fired plants will account for very few of plants for new generation capacity
22 constructed in the U.S. from 2008–2030. Furthermore, EIA does not project that oil-fired power
23 will account for any significant additions to capacity (EIA 2009a).

24 The variable costs of oil-fired generation are found to be greater than those of nuclear or
25 coal-fired operations, and oil-fired generation has greater environmental impacts than natural
26 gas-fired generation. In addition, future increases in oil prices are expected to make oil-fired
27 generation increasingly more expensive (EIA 2009a). The high cost of oil has prompted a
28 steady decline in its use for electricity generation. Thus, the NRC does not consider oil-fired
29 generation an alternative to CGS license renewal.

30 **8.4.14 Fuel Cells**

31 Fuel cells oxidize fuels without combustion and its environmental side effects. Power is
32 produced electrochemically by passing a hydrogen-rich fuel over an anode and passing air (or
33 oxygen) over a cathode and then separating the two by an electrolyte. The only byproducts
34 (depending on fuel characteristics) are heat, water, and CO₂. Hydrogen fuel can come from a
35 variety of hydrocarbon resources by subjecting them to steam under pressure. Natural gas is
36 typically used as the source of hydrogen.

37 Presently, fuel cells are not economically or technologically competitive with other alternatives
38 for large-scale electricity generation. EIA projects that fuel cells may cost \$5,374 per installed
39 kilowatt (total overnight costs³) (EIA 2009a), or 3.5 times the construction cost of new coal-fired
40 capacity, and 7.5 times the cost of new, advanced natural gas-fired, combined-cycle capacity.
41 In addition, fuel cell units are likely to be small (the EIA reference plant is 10 MWe). While it

³ Overnight cost is the cost of a construction project if no interest were incurred during construction.

1 may be possible to use a distributed array of fuel cells to provide an alternative to CGS, it would
2 be extremely costly to do so. Accordingly, the NRC does not consider fuel cells to be an
3 alternative to CGS license renewal.

4 **8.4.15 Delayed Retirement**

5 Energy Northwest has stated in its ER that it is not aware of any combination of planned
6 retirements that could replace CGS's baseload capacity. As a result, delayed retirement is not a
7 feasible alternative to license renewal.

8 **8.5 No-Action Alternative**

9 This section examines environmental effects that would occur if the NRC took no action. No
10 action in this case means that the NRC does not issue a renewed operating license for CGS
11 and the license expires at the end of the current license term, in December 2023. If the NRC
12 takes no action, the plant would shutdown at or before the end of the current license. After
13 shutdown, plant operators would initiate decommissioning according to 10 CFR 50.82.

14 This section addresses only those impacts that arise directly as a result of plant shutdown. The
15 environmental impacts from decommissioning and related activities have already been
16 addressed in several other documents, including the "Final Generic Environmental Impact
17 Statement on Decommissioning of Nuclear Facilities," NUREG-0586, Supplement 1 (NRC
18 2002); Chapter 7 of the license renewal GEIS (NRC, 1996); and Chapter 7 of this SEIS. These
19 analyses either directly address or bound the environmental impacts of decommissioning
20 whenever Energy Northwest ceases operating CGS.

21 Even with a renewed operating license, CGS will eventually shut down, and the environmental
22 effects addressed in this section will occur at that time. Since these effects have not otherwise
23 been addressed in this SEIS, the impacts will be addressed in this section. As with
24 decommissioning effects, shutdown effects are expected to be similar whether they occur at the
25 end of the current license or at the end of a renewed license.

26 **8.5.1 Air Quality**

27 When the plant stops operating, there will be a reduction in emissions from activities related to
28 plant operation, such as use of diesel generators and employee vehicles. Since it was
29 determined that emissions during the renewal term would have a SMALL impact on air quality, if
30 emissions decrease, the impact on air quality would also decrease and would be SMALL.

31 **8.5.2 Groundwater Use and Quality**

32 With plant shutdown and decommissioning, there will be a reduction in groundwater use over
33 that of continued plant operation. Based on the discussion in Section 4.3, groundwater use by
34 CGS would have a SMALL impact on groundwater use and quality during the renewal term;
35 therefore, if groundwater use decreases, the impact on groundwater use and quality would also
36 decrease, having a SMALL impact.

37 **8.5.3 Surface-Water Use and Quality**

38 Shutdown and decommissioning would result in a reduction in surface-water use over that of
39 continued plant operation. Since it was determined that continued plant operations would have
40 a SMALL impact on surface-water use and quality during the renewal term (see Section 4.3),

Environmental Impacts of Alternatives

1 the impacts of shutdown and decommission on surface-water use and quality would also be
2 SMALL.

3 **8.5.4 Aquatic Ecology**

4 If the plant were to cease operating, impacts on aquatic ecology would decrease because the
5 plant would withdraw and discharge less water than it does during operations. Shutdown would
6 reduce the already SMALL impacts on aquatic ecology.

7 **8.5.5 Terrestrial Ecology**

8 If the plant were to cease operating, the terrestrial ecology impacts would be SMALL, assuming
9 that no additional land disturbances on or offsite would occur during decommissioning activities
10 or waste disposal.

11 **8.5.6 Human Health**

12 Human health risks would be smaller after plant shutdown. The plant, which is currently
13 operating within regulatory limits, would emit less gaseous and liquid radioactive material to the
14 environment. In addition, after shutdown, the variety of potential accidents at the plant
15 (radiological or industrial) would be reduced to a limited set associated with shutdown events
16 and fuel handling and storage. In Chapter 4 of this SEIS, the NRC concluded that the impacts
17 of continued plant operation on human health would be SMALL. In Chapter 5, the NRC
18 concluded that the impacts of accidents during operation would be SMALL. Therefore, as
19 radioactive emissions to the environment decrease, and as likelihood and variety of accidents
20 decrease after shutdown, the NRC concludes that the risk to human health following plant
21 shutdown would be SMALL.

22 **8.5.7 Land Use**

23 Plant shutdown would not affect onsite land use. Plant structures and other facilities would
24 remain in place until decommissioning. Most transmission lines connected to CGS would
25 remain in service after the plant stops operating. Maintenance of most existing transmission
26 lines would continue as before. The transmission lines could be used to deliver the output of
27 any new power-generating capacity additions made on the CGS site. Impacts on land use from
28 plant shutdown would be SMALL.

29 **8.5.8 Socioeconomics**

30 Plant shutdown would have an impact on socioeconomic conditions in the region around CGS.
31 Should the plant shut down, there would be immediate socioeconomic impacts from loss of jobs
32 (some, though not all, of the approximately 1,100 employees would begin to leave); and tax
33 payments may be reduced. These impacts, however, would not be considered significant on a
34 regional basis given the close proximity to the Tri-Cities metropolitan area and because plant
35 workers' residences are not concentrated in a single community or county. Revenue losses
36 from CGS operations would directly affect Benton County and other local taxing districts and
37 communities closest to, and most reliant on, the plant's tax revenue. The socioeconomic
38 impacts of plant shutdown would (depending on the jurisdiction) range from SMALL to
39 MODERATE. An additional discussion of the potential socioeconomic impacts of plant
40 decommissioning is provided in Appendix J to NUREG 0586, Supplement 1 (NRC, 2002).

1 **8.5.9 Transportation**

2 Traffic volumes on the roads near the Hanford Site and CGS would be greatly reduced after
3 plant shutdown due to the loss of jobs at the facilities. Deliveries of materials and equipment to
4 CGS would also be reduced until decommissioning. Transportation impacts from the
5 termination of plant operations would be SMALL.

6 **8.5.10 Aesthetics**

7 Plant structures and other facilities would likely remain in place until decommissioning. The
8 plume from cooling towers would cease or greatly decrease after shutdown. Noise caused by
9 plant operation would cease. Aesthetic impacts of plant closure would be SMALL.

10 **8.5.11 Historic and Archaeological Resources**

11 Impacts from the no-action alternative on historic and archaeological resources would be
12 SMALL. A separate environmental review would be conducted for decommissioning. That
13 assessment would address the protection of historic and archaeological resources.

14 **8.5.12 Environmental Justice**

15 Impacts to minority and low-income populations when CGS ceases operations would depend on
16 the number of jobs and the amount of tax revenues lost by the communities in the immediate
17 vicinity of the power plant. Closure of CGS would reduce the overall number of jobs (there are
18 currently 1,100 employed at the facilities) and tax revenue for social services attributed to plant
19 operations. Minority and low-income populations in the township vicinity of CGS could
20 experience some socioeconomic effects from plant shutdown, but these effects would not likely
21 be high and adverse.

22 **8.5.13 Waste Management**

23 If the no-action alternative was carried out, the generation of high-level waste would stop and
24 the generation of low-level and mixed waste would decrease. Impacts from carrying out the
25 no-action alternative are expected to be SMALL.

26 **8.5.14 Summary of the Impacts of No Action**

27 Table 8.5-1 summarizes the environmental impacts of the no-action alternative compared to
28 continued operation of the CGS.

1
2

Table 8.5-1. Summary of environmental impacts of no action compared to continued operation of CGS

| Alternative | Impact area | | | | | | |
|--|-------------|-------------|---------------|-----------------------------------|--------------|-------------------|------------------|
| | Air quality | Groundwater | Surface water | Aquatic and terrestrial resources | Human health | Socioeconomics | Waste management |
| Continued operation of CGS (license renewal) | SMALL | SMALL | SMALL | SMALL | SMALL | SMALL | SMALL |
| No-action alternative | SMALL | SMALL | SMALL | SMALL | SMALL | SMALL to MODERATE | SMALL |

3 **8.6 Alternatives Summary**

4 In this chapter, the following alternatives to CGS license renewal were considered: natural gas
5 combined-cycle generation, new nuclear generation, and a combination alternative. The
6 no-action alternative and its effects were also considered. Table 8.6-1 summarizes the impacts
7 for all alternatives to CGS license renewal.

8 **Table 8.6-1. Summary of environmental impacts of proposed action and alternatives**

| Alternative | Impact area | | | | | | |
|---|-------------------|-------------|---------------|-----------------------------------|--------------|-------------------|------------------|
| | Air quality | Groundwater | Surface water | Aquatic and terrestrial resources | Human health | Socioeconomics | Waste management |
| Continued operation of CGS (license renewal) | SMALL | SMALL | SMALL | SMALL | SMALL | SMALL | SMALL |
| Natural gas-fired alternative at the CGS site | SMALL to MODERATE | SMALL | SMALL | SMALL to MODERATE | SMALL | SMALL to MODERATE | SMALL |
| New nuclear alternative at the CGS site | SMALL | SMALL | SMALL | SMALL | SMALL | SMALL to MODERATE | SMALL |
| Combination of alternatives | SMALL to MODERATE | SMALL | SMALL | MODERATE | SMALL | SMALL to LARGE | SMALL |
| No-action alternative | SMALL | SMALL | SMALL | SMALL | SMALL | SMALL to MODERATE | SMALL |

9 The environmental impacts of the proposed action (issuing a renewed CGS operating license)
10 would be SMALL for all impact categories, except for the Category 1 issue of collective offsite
11 radiological impacts from the fuel cycle, high-level waste, and from spent fuel disposal.
12 Significance levels for these impacts have not been determined, but the Commission
13 determined them to be Category 1 issues nonetheless.

1 The natural gas-fired alternative is not an environmentally favorable alternative due to air quality
2 impacts from NO_x, SO_x, PM₁₀, CO, and CO₂, (and their corresponding human health effects) as
3 well as the construction impacts on terrestrial resources. The combination alternative would
4 have lower air emissions and waste-management impacts than the natural gas-fired alternative;
5 however, the combination alternative would have relatively high construction impacts on
6 terrestrial resources and potential historic and archaeological resources due mainly to the wind
7 turbine component. The new nuclear alternative would result in impacts from construction
8 activities, but, although these and operational impacts would be SMALL, they would be larger
9 than the impacts associated with continued operation of CGS.

10 In conclusion, the environmentally preferred alternative in this case is the CGS license renewal.
11 All other alternatives capable of meeting the needs currently served by CGS entail potentially
12 greater impacts than the proposed action of CGS license renewal. Because the no-action
13 alternative necessitates the implementation of one or a combination of alternatives, all of which
14 have greater impacts than the proposed action, the no-action alternative would have
15 environmental impacts greater than or equal to the proposed license renewal action.

16 **8.7 References**

17 ADAGE, "Energy Northwest to Pursue Development of Biomass Plants," ADAGE, Available
18 URL: http://www.adagebiopower.com/news/news_energy_northwest.php, February 18, 2009
19 (Accessed March 4, 2009).

20 American Wind Energy Association (AWEA), *Annual Wind Industry Report, Year Ending 2008*.
21 Washington, D.C., 2009.

22 Cary, A., "Hanford Plans for Natural Gas Pipeline under Columbia," *Tri-City Herald*, Kennewick,
23 WA, February 16, 2011, Available URL: <http://www.tri-cityherald.com/2011/02/16/1370077/hanford-creating-plans-for-natural.html> (Accessed March 4, 2011).

25 Clean Air Act, 42 U.S.C. 7401 et seq.

26 Energy Facility Site Evaluation Council (EFSEC), *EFSEC Energy Facility Site Evaluation*
27 *Council*, Olympia, WA, Available URL: <http://www.efsec.wa.gov/default.shtm>, 2010 (Accessed
28 September 9, 2010).

29 Energy Facility Site Evaluation Council (EFSEC), *Regulatory Order No. 672 Limiting WNP-2 Air*
30 *Emissions*, Olympia, WA, 1996.

31 Energy Information Administration (EIA), "Washington Quick Facts," *U.S. Energy Information*
32 *Administration, State & U.S. Historical Data, State Energy Profiles, Washington*, Available URL:
33 http://tonto.eia.doe.gov/state/state_energy_profiles.cfm?sid=WA, 2008 (Accessed
34 November 30, 2007).

35 Energy Information Administration (EIA), 2009a, "Summary Statistics for the United States,"
36 *Electric Power Annual with Data for 2007*, Table ES1, Available URL:
37 <http://www.eia.doe.gov/cneaf/electricity/epa/epates.html> (Accessed June 2009).

38 Energy Information Administration (EIA) 2009b, "Approximate Heat Content of Natural Gas,
39 1949-2008 (BTU per Cubic Foot), Table A4," Available URL:
40 <http://www.eia.doe.gov/emeu/aer/txt/ptb1304.html> (Accessed July 2009).

Environmental Impacts of Alternatives

- 1 Energy Information Administration (EIA) 2009c, "Annual Energy Outlook, 2009-Electricity
2 Demand," Available URL: <http://www.eia.doe.gov/oiaf/aeo/electricity.html> (Accessed
3 December 2009).
- 4 Energy Efficiency & Renewable Energy (EERE), *Alternative Energy Resources in Washington*.
5 U.S. Department of Energy, Office of Energy Efficiency and Renewable Energy, Available URL:
6 http://www.eere.energy.gov/states/alternatives/resources_wa.cfm, 2008 (Accessed
7 September 30, 2008).
- 8 Energy Northwest (EN) 2010a, Columbia Generating Station, License Renewal Application
9 (LRA), Appendix E, Applicant's Environmental Report, Operating License Renewal Stage,
10 Document No. 50-397, License No. NPF 21, Richland, WA, ADAMS Accession
11 No. ML100250666.
- 12 Energy Northwest (EN) 2010b, Letter from SK Gambhir (Vice President, Technical Services) to
13 U.S. Nuclear Regulatory Commission, August 5, 2010, "Columbia Generating Station, Docket
14 No. 50-397 Response to Request for Additional Information License Renewal Application,"
15 ADAMS Accession No. ML102300503.
- 16 Environmental Protection Agency (EPA) 2000, "Notice of Regulatory Determination on Wastes
17 from the Combustion of Fossil Fuels," *Federal Register*, Vol. 65, pp. 32214-32237.
- 18 Environmental Protection Agency (EPA) 2000a, "Regulatory Finding on the Emissions of
19 Hazardous Air Pollutants from Electric Utility Steam Generating Units," *Federal Register*,
20 Vol. 65, No. 245, December 20, 2000, pp. 79825-79831.
- 21 Environmental Protection Agency (EPA), *New Resource Review*, Available URL:
22 <http://www.epa.gov/nsr/>, 2010 (Accessed July 19 2010).
- 23 General Electric (GE), "Gas Turbine and Combined Cycle Products," Available URL:
24 [http://www.gepower.com/prod_serv/products/gas_turbines_cc/en/downloads/gasturbine_cc_pro](http://www.gepower.com/prod_serv/products/gas_turbines_cc/en/downloads/gasturbine_cc_products.pdf)
25 [ducts.pdf](http://www.gepower.com/prod_serv/products/gas_turbines_cc/en/downloads/gasturbine_cc_products.pdf), 2007 (Accessed June 2009).
- 26 Idaho National Engineering and Environmental Laboratory (INEEL), "U.S. Hydropower
27 Resource Assessment for Nebraska," DOE/ID-10430(NE), Available URL:
28 <http://hydropower.inl.gov/resourceassessment/pdfs/states/ne.pdf>, 1997 (Accessed July 2009).
- 29 Idaho National Engineering and Environmental Laboratory (INEEL), *U.S. Hydropower Resource*
30 *Assessment, Final Report*, DOE/ID-10430.2, Idaho Falls, ID, 1998.
- 31 Michaels, T., "The 2007 IWSA Directory of Waste-to-Energy Plants," Energy Recovery Council
32 (formerly Integrated Waste Services Association), Washington, D.C., Available URL:
33 <http://www.wte.org/>, 2007 (Accessed September 9, 2010).
- 34 National Marine Fisheries Service (NMFS), Endangered Species Act, Section 7, Consultation
35 Biological Opinion, Supplemental Consultation on Remand for Operation of the Federal
36 Columbia River Power System, 11 Bureau of Reclamation Projects in the Columbia Basin and
37 ESA Section 10(a)(1)(A) Permit for Juvenile Fish Transportation Program, F/NWR/2010/02096.
38 National Marine Fisheries Service, Northwest Region, Available URL:
39 <http://www.nwr.noaa.gov/Salmon-Hydropower/Columbia-Snake-Basin/final-BOs.cfm>, 2010
40 (Accessed August 2010).

- 1 National Environmental Policy Act of 1969 (NEPA), as amended, 42 USC 4321, et seq.
- 2 National Renewable Energy Laboratory (NREL), Estimates of Windy Land Area and Wind
3 Energy Potential by State for Areas \geq 30% Capacity Factor at 80M, Golden, CO, 2010.
- 4 Northwest Power and Conservation Council (NWPPCC), *The Fifth Northwest Electric Power and*
5 *Conservation Plan*, Document 2005-7, Available URL:
6 <http://www.nwccouncil.org/energy/powerplan/5/Default.htm>, 2005 (Accessed
7 September 30, 2008).
- 8 Northwest Power and Conservation Council (NWPPCC), *Power Generation Map*, Portland, OR,
9 Available URL: <http://www.nwccouncil.org/maps/power/Default.asp>, 2010 (Accessed
10 September 9, 2010).
- 11 South Carolina Electric & Gas (SCE&G), "V. C. Summer Nuclear Station Units 2 and 3 COL
12 Application, Environmental Report," Revision 1, Chapter 5, February 13, 2009, ADAMS
13 Accession No. ML090510255.
- 14 Southern Nuclear Corporation (SNC), Southern Nuclear Corporation Vogtle Electric Generating
15 Plant (VEGP) Units 3 and 4 Combined Operating License Application (COLA) (Environmental
16 Report, Rev. 0, Applicant's Combined License Report, Combined License Stage), ADAMS
17 Accession Number ML081050181.
- 18 The Tax Reform Act of 1986, as amended, 26 USC 1, et seq.
- 19 C & A Carbone, Inc. v. Clarkstown, 511 U.S. 383, 114 S. Ct. 1677, 128 L. Ed. 2d 399 (1994).
- 20 U.S. Department of Energy (DOE), Draft Tank Closure and Waste Management Environmental
21 Impact Statement for the Hanford Site, Richland, WA, DOE/EIS-0391, Richland Operations
22 Office, Richland, WA, 2009.
- 23 *U.S. Code of Federal Regulations*, "Domestic Licensing of Production and Utilization Facilities,"
24 Part 50, Section 1, Title 10, "Energy."
- 25 *CFR*, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory
26 Functions," Part 51, Section 1, Title 10, "Energy."
- 27 *CFR*, "Requirements for Preparation, Adoption, and Submittal of Implementation Plans,"
28 Part 51, Section 1, Title 40, "Protection of Environment."
- 29 *CFR*, "Standards of Performance for New Stationary Sources," Part 60, Title 40, "Protection of
30 Environment."
- 31 *CFR*, "Continuous Emission Monitoring," Part 70, Section 5, Title 40, "Protection of
32 Environment."
- 33 *CFR*, "Designation of Areas for Air Quality Planning Purposes," Part 80, Section 1, Title 40,
34 "Protection of Environment."
- 35 U.S. Nuclear Regulatory Commission (NRC), "Generic Environmental Impact Statement for
License Renewal of Nuclear Plants," NUREG-1437, Volumes 1 and 2, Washington, D.C., 1996.

Environmental Impacts of Alternatives

- 1 NRC, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Main
2 Report," NUREG-1437, Volume 1, Addendum 1, Washington, D.C., 1999.
- 3 NRC, "Generic Environmental Impact Statement on Decommissioning of Nuclear Facilities:
4 Supplement 1, Regarding the Decommissioning of Nuclear Power Reactors," NUREG-0586,
5 Supplement 1, Volumes 1 and 2, Washington, D.C., 2002.
- 6 U.S. Office of Management and Budget (OMB), "Detailed Information on the Low Income Home
7 Energy Assistance Program Assessment," Expectmore.gov., Available URL:
8 <http://www.whitehouse.gov/omb/expectmore/detail/10001059.2003.html>, 2007 (Accessed
9 June 2009), ADAMS Accession No. ML082880730.
- 10 *Washington Administrative Code*, "General Regulations for Air Pollution Sources," Section 400,
11 Title 173, "Department of Ecology."
- 12 *Washington Administrative Code*, "General and Operating Permit Regulations for Air Pollution
13 Sources," Section 78, Title 436, "Energy Facility Site Evaluation Council."
- 14 Walsh, M.E., et al., "Biomass Feedstock Availability in the United States: 1999 State Level
15 Analysis," Available URL: <http://bioenergy.ornl.gov/resourcedata/index.html>, 2000 (Accessed
16 July 2009), ADAMS Accession No. ML083050223.

9.0 CONCLUSION

This draft supplemental environmental impact statement (SEIS) contains the environmental review of the Energy Northwest application for a renewed operating license for Columbia Generating Station (CGS), as required by the *Code of Federal Regulations* (CFR), Part 51 of Title 10 (10 CFR Part 51), the U.S. Nuclear Regulatory Commission's (NRC) regulations that implement the National Environmental Policy Act (NEPA). This chapter presents conclusions and recommendations from the site-specific environmental review of CGS and summarizes site-specific environmental issues of license renewal that were noted during the review. Section 9.1 summarizes the environmental impacts of license renewal; Section 9.2 presents a comparison of the environmental impacts of license renewal and energy alternatives; Section 9.3 discusses unavoidable impacts of license renewal, energy alternatives, and resource commitments; and Section 9.4 presents conclusions and NRC staff (staff) recommendations.

9.1 Environmental Impacts of License Renewal

The staff's review of site-specific environmental issues in this SEIS leads to the conclusion that issuing a renewed license would have SMALL impacts for the eight Category 2 issues and the two uncategorized issues applicable to license renewal at CGS.

Mitigation measures were considered for each Category 2 issue, as applicable. Additionally, the staff identified several measures that could mitigate potential impacts to historic and archaeological resources. Energy Northwest could reduce the risk of potential impacts to these resources located on or near CGS by following their Cultural Resources Protection Plan and by providing staff training on the National Historic Preservation Act Section 106 consultation process as well as on cultural awareness to ensure that informed decisions are made before any ground-disturbing activities. Any revisions to the Cultural Resources Protection Plan should be developed in consultation with the NRC, the Washington State Historic Preservation Officer, and consulting tribes. In addition, lands not surveyed should be investigated by a qualified archaeologist prior to any ground-disturbing activity. Given the potential for discovery of subsurface archaeological material within the culturally sensitivity zone, Energy Northwest needs to ensure that these areas are considered during future plant operations and maintenance activities. One of the potentially cost-beneficial Severe Accident Mitigation Alternative candidates—FL-06R—appears to be aging-related. The staff will document the resolution of SAMA FL-06R in the final SEIS.

The staff also considered cumulative impacts of past, present, and reasonably foreseeable future actions, regardless of what agency (Federal or non-Federal) or person undertakes them. The staff concluded in Section 4.11 that cumulative impacts of CGS's license renewal would be SMALL to LARGE depending on the resource. However, the incremental contribution from CGS during the period of extended operation would be SMALL.

9.2 Comparison of Environmental Impacts of License Renewal and Alternatives

In the conclusion to Chapter 8, the staff considered the following alternatives to CGS license renewal:

- natural gas combined-cycle generation

Conclusion

- 1 • new nuclear generation
- 2 • a combination alternative that includes a portion of the natural gas combined-cycle
- 3 capacity, a conservation component, a purchased power component, a hydropower
- 4 component, and a wind power component

5 The NRC staff concluded that the combination alternative and the natural gas combined-cycle
6 alternative would have greater overall adverse environmental impacts than new nuclear
7 generation. The new nuclear alternative would have SMALL environmental impacts in most
8 areas with the exception of socioeconomic impact. Continued operation of CGS would have
9 SMALL environmental impacts in all areas. The NRC staff concluded that continued operation
10 of the existing CGS is the environmentally preferred alternative.

11 **9.3 Resource Commitments**

12 **9.3.1 Unavoidable Adverse Environmental Impacts**

13 Unavoidable adverse environmental impacts are impacts that would occur after implementation
14 of all workable mitigation measures. Carrying out any of the energy alternatives considered in
15 this SEIS, including the proposed action, would result in some unavoidable adverse
16 environmental impacts.

17 Minor unavoidable adverse impacts on air quality would occur due to emission and release of
18 various chemical and radiological constituents from power plant operations. Nonradiological
19 emissions resulting from power plant operations are expected to comply with Environmental
20 Protection Agency (EPA) emissions standards, though the alternative of operating a
21 fossil-fueled power plant in some areas may worsen existing attainment issues. Chemical and
22 radiological emissions would not exceed the National Emission Standards for hazardous air
23 pollutants.

24 During nuclear power plant operations, workers and members of the public would face
25 unavoidable exposure to radiation and hazardous and toxic chemicals. Workers would be
26 exposed to radiation and chemicals associated with routine plant operations and the handling of
27 nuclear fuel and waste material. Workers would have higher levels of exposure than members
28 of the public, but doses would be administratively controlled and would not exceed standards or
29 administrative control limits. In comparison, the alternatives involving the construction and
30 operation of a non-nuclear power generating facility would also result in unavoidable exposure
31 to hazardous and toxic chemicals to workers and the public.

32 The generation of spent nuclear fuel and waste material, including low-level radioactive waste,
33 hazardous waste, and nonhazardous waste would also be unavoidable. In comparison,
34 hazardous and nonhazardous wastes would also be generated at non-nuclear power generating
35 facilities. Wastes generated during plant operations would be collected, stored, and shipped for
36 suitable treatment, recycling, or disposal in accordance with applicable Federal and State
37 regulations. Due to the costs of handling these materials, power plant operators would be
38 expected to carry out all activities and optimize all operations in a way that generates the
39 smallest amount of waste possible.

1 **9.3.2 The Relationship between Local Short-Term Uses of the Environment and the**
2 **Maintenance and Enhancement of Long-Term Productivity**

3 The operation of power generating facilities would result in short-term uses of the environment,
4 as described in Chapters 4, 5, 6, 7, and 8. "Short-term" is the period of time that continued
5 power generating activities take place.

6 Power plant operations require short-term use of the environment and commitment of resources
7 and commit certain resources (e.g., land and energy), indefinitely or permanently. Certain
8 short-term resource commitments are substantially greater under most energy alternatives,
9 including license renewal, than under the no-action alternative because of the continued
10 generation of electrical power and the continued use of generating sites and associated
11 infrastructure. During operations, all energy alternatives require similar relationships between
12 local short-term uses of the environment and the maintenance and enhancement of long-term
13 productivity.

14 Air emissions from power plant operations introduce small amounts of radiological and
15 nonradiological constituents to the region around the plant site. Over time, these emissions
16 would result in increased concentrations and exposure, but they are not expected to impact air
17 quality or radiation exposure to the extent that public health and long-term productivity of the
18 environment would be impaired.

19 Continued employment, expenditures, and tax revenues generated during power plant
20 operations directly benefit local, regional, and State economies over the short term. Local
21 governments investing project-generated tax revenues into infrastructure and other required
22 services could enhance economic productivity over the long term.

23 The management and disposal of spent nuclear fuel, low-level radioactive waste, hazardous
24 waste, and nonhazardous waste requires an increase in energy and consumes space at
25 treatment, storage, or disposal facilities. Regardless of the location, the use of land to meet
26 waste disposal needs would reduce the long-term productivity of the land.

27 Power plant facilities are committed to electricity production over the short term. After
28 decommissioning these facilities and restoring the area, the land could be available for other
29 future productive uses.

30 **9.3.3 Irreversible and Irretrievable Commitments of Resources**

31 This section describes the irreversible and irretrievable commitment of resources that have
32 been noted in this SEIS. Resources are irreversible when primary or secondary impacts limit
33 the future options for a resource. An irretrievable commitment refers to the use or consumption
34 of resources that are neither renewable nor recoverable for future use. Irreversible and
35 irretrievable commitment of resources for electrical power generation include the commitment of
36 land, water, energy, raw materials, and other natural and man-made resources required for
37 power plant operations. In general, the commitment of capital, energy, labor, and material
38 resources are also irreversible.

39 The implementation of any of the energy alternatives considered in this SEIS would entail the
40 irreversible and irretrievable commitment of energy, water, chemicals, and in some cases, fossil
41 fuels. These resources would be committed during the license renewal term and over the entire
42 life cycle of the power plant, and they would be unrecoverable.

Conclusion

1 Energy expended would be in the form of fuel for equipment, vehicles, and power plant
2 operations and electricity for equipment and facility operations. Electricity and fuel would be
3 purchased from offsite commercial sources. Water would be obtained from existing water
4 supply systems. These resources are readily available, and the amounts required are not
5 expected to deplete available supplies or exceed available system capacities.

6 **9.4 Recommendations**

7 The NRC's preliminary recommendation is that the adverse environmental impacts of license
8 renewal for CGS are not great enough to deny the option of license renewal for energy-planning
9 decisionmakers. This recommendation is based on the following:

- 10 • the analysis and findings in NUREG-1437, Volumes 1 and 2, "Generic Environmental
11 Impact Statement for License Renewal of Nuclear Plants"
- 12 • the environmental report submitted by Energy Northwest
- 13 • consultation with Federal, State, and local agencies
- 14 • the NRC's environmental review
- 15 • consideration of public comments received during the scoping process

1

10.0 LIST OF PREPARERS

2 Members of the Office of Nuclear Reactor Regulation (NRR) prepared this supplemental
 3 environmental impact statement (SEIS) with assistance from other U.S. Nuclear Regulatory
 4 Commission (NRC) organizations and with contract support from Pacific Northwest National
 5 Laboratory (PNNL).

6 Table 10-1 provides a list of NRC staff that participated in the development of the SEIS. PNNL
 7 provided contract support for alternatives, aquatic ecology, historic and archaeological
 8 resources, air quality, hydrology, and the severe accident mitigation alternatives (SAMA)
 9 analysis, presented primarily in Chapters 2, 4, 5, 8, and Appendix F.

10

Table 10-1. List of preparers

| Name | Affiliation | Function or expertise |
|----------------------------------|-------------|---|
| NRC | | |
| Bo Pham | NRR | Branch Chief |
| Andrew Imboden | NRR | Branch Chief |
| Arthur Cunanan | NRR | Project Manager |
| Daniel Doyle | NRR | Project Manager |
| William Rautzen | NRR | Radiation Protection; Human Health |
| Stephen Klementowicz | NRR | Radiation Protection; Human Health |
| Allison Travers | NRR | Terrestrial Ecology; Alternatives |
| Jeffrey Rikhoff | NRR | Historic & Archaeological Resources; Socioeconomics; Land Use; Environmental Justice |
| April BeBault | NRR | Socioeconomics; Land Use; Environmental Justice |
| Dennis Logan | NRR | Aquatic Ecology |
| Dennis Beissel | NRR | Hydrology |
| Ray Gallucci | NRR | SAMAs |
| Michelle Moser | NRR | Cumulative Impacts |
| Contractors^(a) | | |
| Bruce McDowell | PNNL | Alternatives |
| Amoret Bunn | PNNL | Aquatic Ecology |
| Rebekah Krieg | PNNL | Aquatic Ecology |
| Ellen Kennedy | PNNL | Historic & Archaeological Resources |
| Tara O'Neil | PNNL | Historic & Archaeological Resources |
| Jeremy Rishel | PNNL | Air Quality |
| George Last | PNNL | Hydrology |
| Steve Short | PNNL | SAMA |
| Garill Coles | PNNL | SAMA |

^(a)PNNL is operated by Battelle for the U.S. Department of Energy.

1 **11.0 LIST OF AGENCIES, ORGANIZATIONS, AND PERSONS**
 2 **TO WHOM COPIES OF THE SUPPLEMENTAL ENVIRONMENTAL**
 3 **IMPACT STATEMENT ARE SENT**

| Name & title | Company & address |
|--|--|
| Environmental Impact Statement (EIS) Filing Section | U.S. Environmental Protection Agency 1200 Pennsylvania Ave NW Washington, D.C. 20004 |
| EIS Review Coordinator | U.S. Environmental Protection Agency Region 10 1200 Sixth Ave, Ste 900 ETPA-088 Seattle, WA 98101 |
| Mr. Reid Nelson Director, Office of Federal Agency Programs | Advisory Council on Historic Preservation 1100 Pennsylvania Ave NW, Ste 803 Old Post Office Bldg Washington, D.C. 20004 |
| Dr. Allyson Brooks State Historic Preservation Officer | Department of Archaeology & Historic Preservation PO Box 48343 Olympia, WA 98504-8343 |
| V. Kate Valdez Tribal Historic Preservation Officer | Confederated Tribes & Bands of the Yakama Nation PO Box 151 Toppenish, WA 98948-0151 |
| Ms. Carey Miller Tribal Historic Preservation Officer | Confederated Tribes of the Umatilla Indian Reservation 46411 Timine Way Pendleton, OR 97801 |
| Mr. Patrick Baird Tribal Historic Preservation Officer | Nez Perce Tribe PO Box 365 Lapwai, ID 83540-0365 |
| Ms. Camille Pleasants Tribal Historic Preservation Officer | Confederated Tribes of the Colville Reservation PO Box 150 Nespelem, WA 99155-0150 |
| Mr. Rex Buck Chairman | Wanapum Band Grant County PUD PO Box 878 Ephrata, WA 98823 |
| Ms. Robyn Thorson Regional Director | U.S. Fish & Wildlife Service Pacific Region 911 NE 11th Ave Portland, OR 97232 |
| Mr. Ken Berg State Supervisor | U.S. Fish & Wildlife Service Washington Office 510 Desmond Dr SE, Ste 102 Lacey, WA 98503-1273 |
| Mr. Richard Domingue | National Marine Fisheries Service 1201 NE Lloyd Blvd, Ste 1100 Portland, OR 97232-1274 |
| Mr. Stephen Poser Compliance Manager | Energy Facility Site Evaluation Council 925 Plum St SE, Bldg 4 PO Box 43172 Olympia, WA 98504-3172 |

List of Agencies, Organizations, and Persons
to Whom Copies of the Supplemental Environmental Impact Statement Are Sent

| Name & title | Company & address |
|---|---|
| Mr. Richard Cowley | Washington State Department of Health 111 Israel Rd SE Tumwater, WA 98501-5570 |
| Mr. Gary Robertson Director | Washington State Department of Health Office of Radiation Protection PO Box 47827 Olympia, WA 98504-7827 |
| Mr. Ron Skinnarland Waste Management Section Manager | Washington State Department of Ecology 3100 Port of Benton Blvd Richland, WA 99352 |
| Regional Administrator | U.S. Nuclear Regulatory Commission Region IV 612 E Lamar Blvd, Ste 400 Arlington, TX 76011-4125 |
| Senior Resident Inspector | U.S. Nuclear Regulatory Commission Resident Inspector's Office PO Box 69 Richland, WA 99352-0069 |
| Senator Jerome Delvin | Washington State Senate 201 Irving R. Newhouse Building PO Box 40408 Olympia, WA 98504-0408 |
| Senator Tim Sheldon | Washington State Senate 412 Legislative Building PO Box 40435 Olympia, WA 98504-0435 |
| Senator Phil Rockefeller | Washington State Senate PO Box 40423 Olympia, WA 98504-0423 |
| Chairman | Benton County Board of Commissioners PO Box 190 Prosser, WA 99350-0190 |
| Mr. Brad Peck Chairman | Franklin County Board of Commissioners 1016 N 4th Ave Pasco, WA 99301-3706 |
| Mr. Dennis Doherty Chairman | Umatilla County Board of Commissioners 216 SE Fourth St Pendleton, OR 97801 |
| Mr. John Fox Mayor | City of Richland 505 Swift Blvd Richland, WA 99532 |
| Mr. Gerry Pollet Executive Director | Heart of America Northwest 1314 NE 56th St Ste 100 Seattle, WA 98105-2665 |
| Mr. Lloyd Marbet Executive Director | Oregon Conservancy Foundation 19140 SE Bakers Ferry Rd Boring, OR 97009-9158 |
| Ms. Paige Knight | Hanford Watch 4549 NE Cesar E Chavez Blvd Portland, OR 97211 |

List of Agencies, Organizations, and Persons
to Whom Copies of the Supplemental Environmental Impact Statement Are Sent

| Name & title | Company & address |
|--|---|
| Mr. Larry Cwik | PO Box 5912 Portland, OR 97228-5912 |
| Dr. Maye Thompson Environmental Health Program Director | Oregon Physicians for Social Responsibility 812 SW Washington St Ste 1050 Portland, OR 97205-3214 |
| Mr. Mark Reddemann Chief Executive Officer | Energy Northwest PO Box 968, MD 1023 Richland, WA 99352-0968 |
| Mr. Bradley J. Sawatzke Vice President Nuclear Generation & Chief Nuclear Officer | Energy Northwest PO Box 968, MD PE08 Richland, WA 99352-0968 |
| Mr. David A. Swank Vice President, Engineering | Energy Northwest PO Box 968, MD PE23 Richland, WA 99352-0968 |
| Mr. Donald Gregoire Manager, Regulatory Affairs | Energy Northwest PO Box 968, MD PE20 Richland, WA 99352-0968 |
| Mr. Abbas Mostala License Renewal Project Manager | Energy Northwest PO Box 968, MD PE29 Richland, WA 99352-0638 |
| Mr. Jim Chasse License Renewal Environmental Lead | Energy Northwest PO Box 968, MD PE20 Richland, WA 99352-0968 |
| Mr. William A. Horin, Esq. | Winston & Strawn 1700 K St NW Washington, D.C. 20006-3817 |
| Mr. Stuart Harris Director of Department of Science & Engineering | Confederated Tribes of the Umatilla Indian Reservation 46411 Timine Way Pendleton, OR 97801 |
| Dr. Barbara Harper | Confederated Tribes of the Umatilla Indian Reservation 46411 Timine Way Pendleton, OR 97801 |
| Mr. Russell Jim Manager, Environmental Restoration & Waste Management Program | Confederated Tribes & Bands of the Yakama Nation PO Box 151 Toppenish, WA 98948-0151 |
| Mr. Wade Riggsbee | Confederated Tribes & Bands of the Yakama Nation PO Box 151 Toppenish, WA 98948-0151 |
| Mr. Dave Rowland | Confederated Tribes & Bands of the Yakama Nation PO Box 151 Toppenish, WA 98948-0151 |
| Mary Beth Burandt | U.S. Department of Energy Office of River Protection 2440 Steven Center Place Richland, WA 99354 |
| Mr. Gene Kinsey | 4904 West Canal Dr Kennewick, WA 99336-1407 |
| Mr. Steve Lee | Pasco Chamber of Commerce 1925 North 20th Ave Pasco, WA 99301 |

List of Agencies, Organizations, and Persons
to Whom Copies of the Supplemental Environmental Impact Statement Are Sent

| Name & title | Company & address |
|--|---|
| Ms. Connie Farr Reference Librarian | Richland Public Library 955 Northgate Dr Richland, WA 99352 |
| Mr. Tom Moak Supervisor, Kennewick Branch | Mid-Columbia Libraries—Kennewick Branch 1620 S Union St Kennewick, WA 99338 |
| Prof. Paul Friesema | Northwestern University 304 Scott Hall Evanston, IL 60208 |

12.0 INDEX

- 618-10 Burial Ground**, 2-23, 2-75, 4-39, 4-40, 4-59, 4-62, D-1-6, G-1, G-7
- 618-11 Burial Ground**, 2-23, 2-26, 2-73, 2-75, 2-82, 4-16, 4-39, 4-40, 4-47, 4-57, 4-62, A-8, A-9, A-10, D-1-6, G-1, G-6, G-7
- accidents**, 2-10, 2-11, 2-17, 5-28
- aesthetic**, 2-51, 2-54, 3-2, 4-23, 4-28, 4-51, 8-9, 8-17, 8-19, 8-25, 8-28, 8-30, 8-37, B-7
- alternatives**, xv, xvi, 1-5, 2-47, 2-53, 5-3, 5-9, 5-10, 5-11, 5-24, 5-32, 6-2, 6-3, 6-4, 6-8, 8-1–8-30, 8-32–8-35, 8-37–8-40, 9-1, 9-2, 9-3, 10-1, A-1, A-3, A-4, A-6, A-7, A-10, B-7, D-1-26, E-4, F-1, F-2, F-39, F-40, F-41, F-66, F-67, F-69, F-70, F-71, G-8
- archaeological resources**, xv, 1-6, 2-63, 2-64, 2-65, 2-67, 2-68, 2-69, 2-75, 2-76, 2-78, 3-2, 4-23, 4-25–4-28, 4-52, 4-53, 4-56, 8-10, 8-17, 8-26, 8-37, 8-39, 9-1, 10-1, B-7, D-1, E-2–E-5
- biocide**, 2-15, 2-17, 4-3, B-1, D-1-11
- biological assessment**, 2-44, 4-10, D-1-1, D-1-3, E-6
- biota**, 4-4, 4-18, 4-36, 4-42, 4-44, B-2, D-1-37, D-1-42
- boiling water reactors**, 2-1, 5-10, 5-17, 5-18, 5-24, B-5, D-1-7, F-10, F-14, F-28, F-31, F-32, F-35, F-63
- burnup**, 2-1, B-9
- chronic effects**, 1-3, 4-11, 4-22, B-1, B-6
- cold shock**, 4-4, B-2, D-1-37
- cooling system**, xiv, 1-4, 2-11, 2-17, 3-1, 4-4–4-7, 4-15, 4-41, 4-45, 5-28, 7-1, 8-7, 8-12, 8-13, 8-15, 8-17, 8-22, B-2, B-3, C-4, D-1-7, D-1-37, D-1-43, F-12
- core damage frequency (CDF)**, xvii, 5-11–5-15, 5-17–5-23, 5-26, 5-27, A-6, A-7, F-1, F-3–F-6, F-9, F-10, F-13, F-15–F-24, F-26, F-28, F-30, F-32–F-38, F-41–F-45, F-49, F-59, F-60, F-64, F-65
- cultural resources**, 2-41, 2-64, 2-67, 2-68, 2-69, 4-27, 4-52, 4-53, 4-56, 8-10, 8-17, 8-26, C-1, G-4
- decommissioning**, 2-10, 4-36, 4-39, 4-40, 4-47, 4-48, 4-50, 4-53–4-56, 4-61, 5-8, 5-9, 5-35, 6-3, 6-7, 7-1, 7-2, 7-3, 8-9, 8-35, 8-36, 8-37, 8-42, 9-3, B-9, B-10, G-2, G-3, G-7
- design-basis accidents**, xvii, 4-33, 5-1, 5-2, 5-9, B-7
- discharges**, xvi, 2-7, 2-9, 2-15–2-18, 2-20, 2-21, 2-22, 2-26, 2-27, 2-48, 4-3, 4-4, 4-6–4-11, 4-13, 4-14, 4-16, 4-17, 4-19, 4-20, 4-21, 4-38, 4-40, 4-41, 4-42, 4-44, 4-45, 8-4, 8-6, 8-12, 8-14, 8-22, 8-28, 8-36, A-7, A-8, B-1, B-2, B-3, B-6, C-1, C-2, C-4, C-5, D-1-7, D-1-12, D-1-13, D-1-19, D-1-29, D-1-35–D-1-38, D-1-40, D-1-41, D-1-42, D-1-44
- dose**, 2-6, 4-12, 4-13, 4-16–4-21, 4-33, 4-35, 4-36, 4-37, 4-48, 4-49, 5-16, 5-17, 5-23, 5-27, 7-1, 7-2, 9-2, A-10, B-5, B-6, B-7, B-8, B-9, B-10, F-1, F-7, F-8, F-9, F-29, F-30, F-32, F-38, F-41, F-43, F-45, F-49, F-59, F-60, F-62
- education**, 2-38, 2-39, 2-52, 2-53, 2-63, 2-76, 3-2, 4-23, A-5, B-6
- electromagnetic fields**, xv, 1-3, 4-8, 4-11, 4-22, 4-50, B-1, B-5, B-6
- endangered species**, xv, 1-6, 2-45, 2-46, 3-2, 4-4, 4-8, 4-10, 8-7, 8-22, 8-23, B-5, C-1, D-1, D-1-14, D-1-25, D-1-30
- entrainment**, 4-4–4-9, 4-44, 8-7, 8-15, B-2, B-3, D-1-35–D-1-40, D-1-42, D-1-43
- environmental justice (EJ)**, xv, 1-3, 3-2, 4-22, 4-23, 4-27, 4-28, 4-29, 4-33, 4-35, 4-51, 4-56, 8-10, 8-17, 8-19, 8-26, 8-37, 10-1A-9, B-1, B-10
- essential fish habitat (EFH)**, xvii, 2-43, 2-44, 2-50, 4-8, 4-10, 4-42, D-1, D-1-1, D-1-13, D-1-14, D-1-26, D-1-33, D-1-36–D-1-38, D-1-40, D-1-41, D-1-43, D-1-44, D-1-50, E-3, E-6

Generic Environmental Impact Statement (GEIS), xiii, xiv, xvi, 1-3–1-7, 2-55, 2-82, 3-1, 3-2, 3-3, 4-1–4-8, 4-11, 4-12, 4-21–4-24, 4-37, 4-50, 4-63, 5-1, 5-2, 5-3, 5-9, 5-35, 6-1, 6-2, 6-9, 7-1, 7-2, 7-3, 8-1, 8-2, 8-4, 8-7, 8-8, 8-9, 8-11, 8-15, 8-16, 8-18, 8-23, 8-24, 8-25, 8-29, 8-30, 8-33, 8-34, 8-35, 8-41, 8-42, 9-4, A-1, A-11, B-1, B-7, D-1-37, D-1-50

groundwater, xv, 2-17, 2-18, 2-20, 2-21, 2-25, 2-26, 2-34, 2-49, 2-50, 2-53, 2-73, 2-74, 2-77, 2-78, 2-80, 2-82, 2-83, 3-1, 4-2, 4-11, 4-13, 4-14, 4-17, 4-19, 4-36, 4-37, 4-38, 4-40, 4-41, 4-42, 4-44, 4-47, 4-55, 4-57, 4-59, 4-62, 5-3, 8-3, 8-6, 8-12, 8-14, 8-18, 8-21, 8-28, 8-35, 8-38, A-7, A-8, A-10, B-3, B-4, B-7, C-1, C-2, C-4, D-1-42, D-1-47, G-1, G-5

Hanford Reach National Monument, 2-41, 2-44, 2-54, 2-64, 2-71, 2-72, 2-80, 4-46, 4-47, 4-62, D-1-49, G-4, G-8

hazardous waste, 2-8, 2-9, 2-74, 2-79, 2-78, 9-2, 9-3, A-8, C-2, G-1

heat shock, 4-4, 4-6, 4-7, B-3, D-1-37, D-1-38

high-level waste, xiv, 1-4, 3-1, 6-1, 6-2, 7-1, 8-37, 8-38, B-9, G-1

impingement, 4-4, 4-6, 4-7, 4-8, 4-9, 4-44, 8-7, 8-15, B-2, B-3, D-1-35–D-1-40, D-1-42, D-1-43

independent spent fuel storage installation (ISFSI), 2-6, 4-16, 4-48, A-8, C-3

low-level waste, 2-9, 6-1, B-9, E-5, G-2, G-3

mitigation, xiv, xv, 1-3, 1-4, 1-5, 2-42, 3-1, 4-1, 4-2, 4-3, 4-7, 4-11, 4-12, 4-54–4-56, 5-3, 5-6, 5-7, 5-9, 5-10, 5-36, 6-8, 7-1, 7-2, 8-10, 8-17, 8-26, 9-1, 9-2, 10-1, A-10, C-4, D-1-37, E-4, F-1, F-14, F-43, F-70

mixed waste, 2-9, 6-1, 8-37, B-9

National Marine Fisheries Service (NMFS), 1-6, 2-42–2-48, 2-50, 2-71, 2-77, 2-78, 4-8, 4-9, 4-43, 4-45, 4-59, 4-60, 8-22, 8-40, 11-1, D-1, D-1-1, D-1-13, D-1-14, D-1-25, D-1-26, D-1-30, D-1-32, D-1-33,

D-1-38, D-1-40, D-1-42–D-1-50, E-3, E-4, E-6, G-4, G-7

National Pollutant Discharge Elimination System (NPDES), 2-9, 2-20, 2-21, 2-22, 4-7, 4-38, 4-58, A-7, B-2, C-1, C-2, C-3, D-1-13, D-1-49

Native American tribes, xiv, 1-6, 2-38, 2-64, 2-66, 2-69, 2-77, 4-27, 4-28, 4-34, 4-35, 4-52, 4-58, 4-59, 4-60, 4-61, 9-1, 11-1, 11-3, A-1, A-2, A-3, A-9, D-1, E-1, E-2, E-4

NEPA, xiii, 1-1, 1-3, 1-7, 2-64, 2-69, 2-71, 2-73, 4-1, 4-10, 4-27, 4-28, 4-43, 4-56, 4-57, 4-58, 4-59, 4-63, 5-1, 7-3, 8-1, 8-40, 9-1, A-3, B-8, B-9, D-1, D-1-1, D-1-37, D-1-45, D-1-47, G-6

no-action alternative, xvi, 8-37, 8-38, 8-39, 9-3, A-4

nonattainment, 3-2, B-5

postulated accidents, 4-33, 5-1, 5-3

pressurized water reactor, 5-10, 8-12, B-5

radon, 4-13, 8-23, B-7

reactor, xiii, 2-1, 2-6, 2-7, 2-10, 2-11, 2-17, 2-20, 2-22, 2-42, 2-54, 2-66, 2-68, 3-3, 4-13, 4-24, 4-37, 4-48, 4-54, 4-61, 4-62, 5-1, 5-2, 5-4–5-14, 5-23, 5-28, 5-30, 5-34, 5-35, 6-1, 6-3, 7-1, 8-9, 8-12, 8-13, 8-14, 8-16, 8-17, 8-28, 8-31, 10-1, A-7, A-8, A-11, B-4, B-7, B-9, C-3, D-1-2, D-1-7, D-1-50, F-3, F-4, F-5, F-11, F-12, F-19, F-21, F-25, F-26, F-28, F-29, F-35, F-54, F-61, F-63, F-66, F-72, G-2, G-6, G-7

refurbishment, 1-3, 2-24, 3-1–3-3, 4-1, 4-2, 4-3, 4-11, 4-54, 4-55, 4-56, B-1–B-7, D-1-2, F-60

replacement power, xvi, 5-25, F-56, F-60, F-61

salmon, 2-27, 2-31–2-35, 2-37, 2-38, 2-43, 2-45–2-48, 2-50, 2-73, 2-76, 2-80, 2-83, 4-4, 4-5, 4-8, 4-9, 4-10, 4-42, 4-43, 4-45, 4-57, 4-59, 4-61, 8-22, 8-40, D-1-6, D-1-9, D-1-13, D-1-14, D-1-16, D-1-18–D-1-23, D-1-25, D-1-26, D-1-28, D-1-29, D-1-31–D-1-33, D-1-35, D-1-36, D-1-38–D-1-41, D-1-43–D-1-49, G-4

severe accident mitigation alternative (SAMA), xv, 5-1, 5-2, 5-3, 5-9, 5-11, 5-12, 5-15, 5-17–5-27, 5-31, 5-32, 5-36, 10-1, A-6, A-7, B-7, E-4–E-7, F-1, F-2, F-3, F-6, F-9, F-10, F-12–F-24, F-27–F-43, F-45, F-49, F-55–F-71

scoping, xiii, xiv, xvi, 1-2, 1-6–1-8, 2-69, 4-1–4-4, 4-7, 4-11, 4-23, 4-27, 4-37, 4-39, 4-59, 4-60, 5-2, 5-3, 6-1, 7-2, 9-4, A-1, A-2, A-3, A-9, A-11, E-1, E-3, E-6, G-1

seismic, 2-69, 2-70, 2-71, 2-82, 5-8, 5-12, 5-14–5-20, 5-24, 5-27–5-33, F-1, F-2, F-3, F-5–F-10, F-13, F-15–F-19, F-25, F-27, F-28, F-31, F-32, F-37–F-42, F-46, F-48, F-49, F-50, F-53, F-55, F-59–F-62, F-64, F-65, F-68, F-70

solid waste, 2-7, 2-8, 2-10, 2-74, 2-79, 4-20, 6-1, 7-2, 8-2, 8-33, B-10, C-1, C-2, C-4, G-2

spent fuel, xiv, 1-4, 2-6, 3-1, 4-16, 4-48, 5-3–5-5, 5-8–5-10, 5-34–5-36, 6-1, 6-2, 7-1, 8-38, A-8, B-7, B-8, B-9, B-9, C-3, E-2, E-4

stormwater, 2-20–2-22, 4-38, 4-41, 4-42

surface water, xv, 2-21, 2-26, 2-52, 2-81, 3-1, 4-3, 4-14, 4-19, 4-33, 4-35, 4-36, 4-37, 4-41, 4-42, 4-55, 4-56, 4-62, 8-3, 8-6, 8-7, 8-12, 8-14, 8-18, 8-21, 8-22, 8-28, 8-35, 8-38, B-1, B-4, C-1, C-2, C-4, D-1-50, G-5

tank closure and waste management, 4-47, 4-49, 4-50, 4-53, 4-54, 4-61, 8-41, D-1-49, G-1, G-7

taxes, 2-54, 2-59, 2-61, 2-62, 2-63, 2-82, 4-24, 4-25, 4-33, 4-50, 4-51, 5-36, 8-8, 8-9, 8-16, 8-34, 8-36, 8-37, 8-41, 9-3, A-4, A-5, B-7, F-70, F-72

threatened species, 2-42, 2-44, 2-48, 2-73, 2-80, 4-10, 4-62, D-1-1, D-1-13, D-1-47, D-1-48

transmission lines, 2-10, 2-39, 2-42, 2-67–2-69, 4-1, 4-2, 4-10, 4-21–4-23, 4-26, 4-46, 4-47, 4-50, 8-4, 8-7, 8-19, 8-23, 8-28, 8-30, 8-33, 8-36, B-5, B-7, G-4

tritium, xv, 2-21, 2-26, 2-73, 2-82, 4-2, 4-13–4-15, 4-17, 4-19, 4-36, 4-38, 4-40, 4-41, 4-44, D-1-42

trout, 2-31–2-33, 2-37, 2-43, 2-45, 2-47–2-49, 2-73, 2-81, 4-8, 4-9, 4-10, 4-45, D-1-13, D-1-15–D-1-18, D-1-28–D-1-30, D-1-34, D-1-35, D-1-43–D-1-46, D-1-48, D-1-49, D-1-50

U.S. Department of Energy (DOE), xv, 2-1, 2-18, 2-20–2-23, 2-25, 2-26, 2-36, 2-39, 2-46, 2-48, 2-49, 2-54, 2-60, 2-61, 2-64, 2-67, 2-69, 2-71, 2-76, 2-80, 4-2, 4-9, 4-13–4-17, 4-19, 4-22, 4-27, 4-34–4-38, 4-40, 4-41, 4-44, 4-47–4-51, 4-53–4-57, 4-59, 4-61–4-63, 5-4, 5-20, 5-33, 8-2, 8-4, 8-19, 8-31, 8-40, 8-41, 10-2, 11-3, A-8–A-11, B-8, B-10, C-3, D-1-2, D-1-6, D-1-17, D-1-20, D-1-24, D-1-29, D-1-34, D-1-35, D-1-40, D-1-42, D-1-47, D-1-48, D-1-49, F-18, F-70, G-1–G-8

U.S. Environmental Protection Agency (EPA), xii, 1-6, 2-8, 2-9, 2-22–2-26, 2-52, 2-55, 2-74, 2-79, 4-16–4-19, 4-37, 4-43, 4-48, 4-49, 4-53, 4-57–4-59, 5-1, 8-1, 8-3–8-6, 8-13, 8-20, 8-21, 8-40, 9-1, 9-2, 11-1, B-8, C-1, D-1-45, D-1-49, G-3, G-7

U.S. Fish and Wildlife Service (USFWS), 1-6, 2-26, 2-41–2-45, 2-48, 2-49, 2-64, 2-65, 2-71, 2-80, 4-8, 4-10, 4-45, 4-46, 4-47, 4-59, 4-62, D-1, D-1-1, D-1-6, D-1-13–D-1-18, D-1-34, D-1-42, D-1-44, D-1-46, D-1-49, D-1-50, E-1, E-5, G-3, G-4, G-8

uranium, 2-1, 2-2, 2-6, 4-17, 4-19, 4-36, 4-44, 4-49, 6-1, 6-3–6-7, 8-8, 8-16, 8-24, B-7, B-9, D-1-42

Washington State Department of Archaeology and Historic Preservation, 1-6, 2-64, 4-26, 4-27, 4-56, 4-60, 4-64, 11-1, D-1, E-1–E-5

Washington State Department of Ecology, 2-8, 2-82, 4-16, 4-49, 4-64, 8-5, 11-2, G-2, G-5, G-8

Washington State Department of Health (WSDOH), 4-16, 4-19, 4-36, 4-64, 11-2, A-8, C-1, G-2, G-8

wastewater, 2-9, 2-20, 2-22, 2-26, 4-40, 4-41, A-7, A-8, B-2, C-4, G-5

Yucca Mountain, B-8, B-9, B-10

APPENDIX A
COMMENTS RECEIVED ON THE COLUMBIA GENERATING STATION
ENVIRONMENTAL REVIEW

1 **A COMMENTS RECEIVED ON THE COLUMBIA GENERATING** 2 **STATION ENVIRONMENTAL REVIEW**

3 **A.1 Comments Received During Scoping**

4 The scoping process began on March 11, 2010, with the publication in the *Federal Register*
 5 (FR) of the U.S. Nuclear Regulatory Commission's (NRC's) Notice of Intent to conduct scoping
 6 (75 FR 11576). The scoping process included two public meetings, which were both held at the
 7 Richland Public Library in Richland, WA, on April 6, 2010. Approximately 40 members of the
 8 public attended the meetings. After the NRC's prepared statements pertaining to the license
 9 renewal process, the meetings were open for public comments. Of these attendees, 10 gave
 10 oral statements that were recorded and transcribed by a certified court reporter. Transcripts of
 11 the entire meetings are an attachment to the Scoping Meeting Summary dated May 10, 2010
 12 (NRC, 2010a). In addition to the comments received during the public meetings, comments
 13 were also received through the mail.

14 In addition to the April 6 public scoping meetings, the NRC held an informational meeting with
 15 representatives from several affected Native American Tribes on April 27, 2010. The scoping
 16 comments from the Tribal representatives were recorded in the meeting notes (NRC, 2010b).

17 Each commenter was given a unique identifier so that every comment could be traced back to
 18 its author. Table A-1 lists the individuals who made comments applicable to the environmental
 19 review and the Commenter ID associated with each person's set of comments. The individuals
 20 are listed in the order in which their comments were received. To maintain consistency with the
 21 Scoping Summary Report, the unique identifier used in that report for each set of comments is
 22 retained in this appendix.

23 Specific comments were categorized and consolidated by topic. Comments with similar specific
 24 objectives were combined to capture the common essential issues raised by participants.
 25 Comments fall into one of the following general groups:

- 26 • Specific comments that address environmental issues within the purview of the NRC
 27 environmental regulations related to license renewal
 - 28 – These comments address Category 1 (generic) or Category 2 (site-specific)
 29 issues or issues not addressed in the NUREG-1437, "Generic Environmental
 30 Impact Statement (GEIS) for License Renewal of Nuclear Plants" (NRC, 1996),
 31 (NRC, 1999) or Category 2 issues. They also address alternatives to license
 32 renewal and related Federal actions.
- 33 • General comments in support of, or opposed to, nuclear power or license renewal or on
 34 the renewal process, the NRC's regulations, and the regulatory process
 - 35 – These comments may or may not be specifically related to the Columbia
 36 Generating Station (CGS) license renewal application.
- 37 • Comments that do not note new information for the NRC to analyze as part of its
 38 environmental review
- 39 • Comments that address issues that do not fall within, or are specifically excluded from,
 40 the purview of NRC environmental regulations related to license renewal

Appendix A

1 – These comments typically address issues such as the need for power,
 2 emergency preparedness, security, current operational safety issues, and safety
 3 issues related to operation during the renewal period.

4 **Table A-1. Individuals providing comments during scoping period**

| Commenter | Affiliation (if stated) | Comment source | Commenter ID | ADAMS accession number |
|---|---|---------------------------|---------------------|-------------------------------|
| John Greenhill | | Email | A | ML100920546 |
| Jerome Delvin | Washington State Senate | Letter | B | ML100980062 |
| David V. Taylor, et al. | Washington State Legislature | Letter | C | ML101040675 |
| James O. Luce | State of Washington Energy Facility Site Evaluation Council | Letter | D | ML101050307 |
| Brad Peck, Rick Miller, and Robert Koch | Franklin County Board of Commissioners | Letter | E | ML101110052 |
| Tim Sheldon | Washington State Senate | Letter | F | ML101110053 |
| Russell Jim | Confederated Tribes and Bands of the Yakama Nation | Letter | G | ML101160435 |
| Larry Haler, Brad Klippert, Maureen Walsh, and Terry Nealey | State of Washington House of Representatives | Letter | H | ML101110054 |
| Tim Sheldon, et al. | Washington State Senate | Letter | I | ML101170056 |
| Phil Rockefeller | Washington State Senate | Letter | J | ML101180459 |
| Gary Robertson | State of Washington Dept of Health | Letter | K | ML101460059 |
| Ed Revell | City of Richland | Afternoon Scoping Meeting | L | ML101241002 |
| Brad Peck | Franklin County | Afternoon Scoping Meeting | M | ML101241002 |
| Steve Lee | Pasco Chamber of Commerce | Afternoon Scoping Meeting | N | ML101241002 |
| Bob Link | AREVA | Afternoon Scoping Meeting | O | ML101241002 |
| Lori Sanders | Benton County PUD, Energy Northwest (EN) Board of Directors | Afternoon Scoping Meeting | P | ML101241002 |
| Alvin Ankrum | Pacific Northwest National Laboratory (PNNL) | Evening Scoping Meeting | Q | ML101241037 |
| Ed Harrington | | Evening Scoping Meeting | R | ML101241037 |
| Dan Jordheim | | Evening Scoping Meeting | S | ML101241037 |
| Gene Kinsey | | Evening Scoping Meeting | T | ML101241037, ML101960547 |
| Carrie Mathews | PNNL | Evening Scoping Meeting | U | ML101241037 |

| Commenter | Affiliation (if stated) | Comment source | Commenter ID | ADAMS accession number |
|--------------------------------|--|-------------------------|--------------|------------------------|
| Barbara Harper | Confederated Tribes of the Umatilla Indian Reservation (CTUIR) | Tribal Outreach Meeting | V | ML102630228 |
| Wade Riggsbee | Confederated Tribes and Bands of the Yakama Nation | Tribal Outreach Meeting | W | ML102630228 |
| Dave Rowland | Confederated Tribes and Bands of the Yakama Nation | Tribal Outreach Meeting | X | ML102630228 |
| Various Tribal Representatives | See list of attendees in meeting summary | Tribal Outreach Meeting | Y | ML102630228 |
| Judy Ridge, et al. | Washington Public Power Utilities | Letter | Z | ML103230048 |

1 Comments received during scoping applicable to this environmental review are presented in this
2 section along with the NRC response. The comments that are general or outside the scope of
3 the environmental review for CGS are not included here, but they can be found in the Scoping
4 Summary Report (NRC, 2010c).

5 Scoping comments are grouped in the following categories:

- 6 • Alternatives to license renewal of CGS
- 7 • Socioeconomic impacts of CGS
- 8 • Greenhouse gas or carbon impacts of CGS
- 9 • Other comments within the scope of the NRC's environmental review

10 The comments and suggestions received as part of the scoping process are discussed below.
11 Comments can be tracked to the commenter and the source document through the ID letter and
12 comment listed in Table A-1.

13 **A.1.1 Alternatives to License Renewal of Columbia Generating Station**

14 **Comment E-4-ALT:** In addition to our strong support of your license renewal application, we
15 urge you to consider developing additional nuclear power generating facilities in or near Franklin
16 County.

17 **Comment M-2-ALT:** I think it answers the question that the basis of it was that the EIS process
18 is to consider the environmental impacts on humans of the proposed action. And I'm surprised
19 to hear that the no action alternative, which is required under [National Environmental Policy Act
20 of 1969] NEPA, would have a negative consequence for the region but that wouldn't be
21 considered. But you have answered the question. Thank you.

22 **Comment M-3-ALT:** Okay. So again, that's just one slice. There are other various negative, I
23 believe, impacts on local communities if it's not relicensed. Okay. So that I would have
24 expected. That would be included in the [S]EIS?

25 **Comment L-3-ALT:** And just recently and this is kind of encouraging, just recently our
26 Governor has made public statements in favor of looking at the nuclear option here for the state.

1 So I would say the state is opening up a little and will be a little more receptive as we look into
2 the future.

3 **Comment P-2-ALT:** And we're all going to see a lot of additional wind power being put up and
4 already it just amazes me how much we have and it's becoming more and more difficult to
5 balance that. It's unreliable, you can't make the wind blow, and we use our hydro system to
6 balance it. And although the nuclear plant doesn't balance the wind in itself, it allows more
7 flexibility of the hydro system to do so. And those items ought to be considered when you're
8 looking at the environmental impact of this plant. It isn't just the long term storage. It isn't just
9 the construction of a plant. It's what do you do if you don't have it? And I think that's really what
10 Mr. Peck was trying to say and I really think it ought to be considered.

11 **Comment T-1-ALT:** In my view of this event, I can truly say that the license renewal and
12 continued operation of the Energy Northwest facility is reasonable to expect. I am not only in
13 favor of the license renewal, I believe that it would be prudent to add other nuclear plants on this
14 500 plus square miles of the Hanford Nuclear Reservation.

15 **Response:** *These comments address alternatives to license renewal of CGS, including the*
16 *alternative of not renewing the operating license—also known as the “no-action” alternative. In*
17 *Chapter 8, the NRC staff (staff) evaluated the following alternatives to CGS license renewal:*

- 18 • *natural gas combined-cycle generation (Section 8.1)*
- 19 • *new nuclear generation (Section 8.2)*
- 20 • *combination alternative that includes a portion of the natural gas combined-cycle*
21 *capacity, a conservation component, a purchased power component, a hydropower*
22 *component, and a wind power component (Section 8.3)*
- 23 • *not renewing the CGS operating license—the “no-action” alternative (Section 8.5)*

24 **A.1.2 Socioeconomic Impact of Columbia Generating Station**

25 **Comment B-2-SOC:** Most importantly, extending the life of the Columbia Station is integral to
26 Washington's economic success. In addition to paying millions of dollars each year in tax
27 revenues to the state and municipal governments, Columbia is one of the largest employers in
28 the Tri-Cities, providing full-time employment to more than 1,100 workers who, in turn,
29 significantly invest in our state and local economy. Your approval will ensure a reasonable cost
30 of power in Washington and help drive a strong economy.

31 **Comment E-3-SOC:** Moreover, many of our citizens enjoy stable, professional working careers
32 at Energy Northwest. Those jobs provide significant economic benefit to our county in addition
33 to the annual power generation taxes you pay that flow back to our schools, fire departments,
34 libraries and other local services.

35 **Comment F-2-SOC:** In addition to providing the region with safe, cost-effective carbon-free
36 power, CGS is a major source of economic stability in Washington's Tri-Cities. CGS employs a
37 large work force, it provides significant tax revenues, and it lends support to local charitable
38 organizations. For these reasons, the relicensing of CGS has my strong support.

39 **Comment N-1-SOC:** Good afternoon. I'm Steve Lee and I'm with the Pasco Chamber of
40 Commerce. The Pasco Chamber represents some 400 local businesses in our area. And I
41 know we joined the other chambers and collective business in the Tri-City's area in saying it's

1 absolutely essential that Columbia Generating Station continue providing safe, clean and low
 2 cost power for our community and our surrounding area which drives the strong economy. I'm
 3 with that on behalf of Pasco businesses that Columbia Generating Station has given our
 4 community much more than just electricity. Columbia offers full time employment for many of
 5 our residents, not to mention significant tax revenues to local and state governments.
 6 Relicensing this plant will also capture extended benefits in terms of a regional invest, which we
 7 measure in both direct and indirect economic impact which extends well beyond the Pasco city
 8 limits.

9 **Comment N-3-SOC:** The Pasco Chamber of Commerce is confident that the Columbia
 10 Generating Station with the Nuclear Regulatory Commission's approval will continue to be a
 11 safe and reliable source of economic strength for our community for many years to come.
 12 Thank you.

13 **Response:** *These comments are generally supportive of the applicant and note the*
 14 *socioeconomic benefits of CGS on local and regional communities and economy—including*
 15 *other related issues such as employment, taxes, and education. The socioeconomic impact of*
 16 *renewing the CGS operating license is discussed in Sections 2.2.8 and 4.9 of this SEIS, and the*
 17 *option of not renewing the operating license is discussed in Section 8.5.8.*

18 **A.1.3 Greenhouse Gas or Carbon Impact of Columbia Generating Station**

19 **Comment C-2-GHG:** As energy demand increases and climate change becomes a significant
 20 public policy issue, a diverse mix of clean energy resources will be critical to meet increasing
 21 electricity needs. For these reasons, it is imperative to maintain the vast quantity of carbon-free
 22 and baseload power Columbia Generating Station provides.

23 **Comment E-2-GHG:** We recognized the valuable role Columbia plays in our regional supply of
 24 safe, affordable and reliable carbon-free energy.

25 **Comment F-1-GHG:** I strongly support the relicensing of the Columbia Generating Station.
 26 The relicensing of CGS will play a crucial role in helping the region meet the growing demand
 27 for carbon-free power. According to the Bonneville Power Administration, replacing the power
 28 output of CGS with market purchases generated by fossil fuels would increase the carbon
 29 emissions of the Federal Columbia River Power System by about 3.7 million metric tons a year.
 30 CGS is also vital to a reliable and stable regional power system. The firm power from CGS
 31 complements variable hydroelectric and wind power.

32 **Comment J-1-GHG:** I want to add my voice to those strongly supporting relicensing of
 33 Columbia Generating Station (CGS) as an essential asset in Washington's energy resources.
 34 Since the nuclear plant received its original 40-year license in 1983, it has demonstrated its
 35 value as an important source of energy free of greenhouse gas emissions. I view Energy
 36 Northwest's planned request to renew the license for another 20 years as an essential step in
 37 extending upon that value, which is likely to grow as the demand for carbon-free power
 38 increases. CGS provides some of the region's most cost-effective carbon-free power, making it
 39 essential to state, regional and national goals of reducing carbon emissions that contribute to
 40 climate change. The Bonneville Power Administration estimated that replacing CGS power with
 41 market purchases generated by fossil fuels would increase the carbon emissions of the Federal
 42 Columbia River Power System by about 3.7 million metric tons a year. We must retain this
 43 power source not only to avoid such emissions, but also because of its vital contribution to a

1 reliable, stable regional power system. In addition, the firm power from CGS also complements
2 more variable, renewable hydroelectric power.

3 **Comment N-2-GHG:** We also live in an environmentally conscious time and Columbia
4 Generating Station's benign impact on the environment through safe and clean carbon-free
5 power generation speaks to the plants leading role as a steward of our natural resources.

6 **Comment O-2-GHG:** The Columbia Generating Station represents an important environmental
7 asset to the Northwest region of the United States as it generates critical electrical energy for
8 our economy without any [carbon dioxide] CO₂ emissions. If the license is not renewed, I can
9 guarantee you the replacement source, even if it is not CO₂ emitting, would consume previous
10 resources in its construction and add to the global environmental footprint. These impacts on
11 the environment will be deferred by allowing this well operated asset to continue to serve the
12 community well into the future.

13 **Comment P-1-GHG:** And I would just like to note, I understand Mr. Peck's comment on
14 environmental issues not being concerned and I really think what he's trying to capture is just to
15 point out that we are a unique community. We're probably the envy of most communities
16 across the United States because we already have 97 percent of our power is carbon-free. And
17 the majority of that is coming from Bonneville Power System and Columbia Generating Station
18 is 10 percent of that system. So it's really an important part of keeping our resources, not
19 necessarily renewable maybe, but as carbon-free as possible.

20 **Comment S-1-GHG:** As a Tri-City's resident one of the things I love to brag about to people
21 from out of state is that my power company, that delivers power to my house, tells me that
22 95 percent of the power delivered to my house comes from non-green house gas, non-global
23 warming sources. And that's something we're proud of and I'd like to see continue.
24 Ten percent of that comes from the Columbia Generating Station, so it seems appropriate to me
25 that the Environmental Impact Statement's side of this incorporates some positive aspects of
26 the non-global greenhouse gas side of it.

27 **Response:** *These comments are generally supportive of license renewal and describe CGS as*
28 *a source of power with low carbon emissions when compared to fossil fuel-powered sources.*
29 *Greenhouse gas emissions of the nuclear fuel cycle are discussed in Section 6.2. Additionally,*
30 *the environmental impacts of reasonable alternatives are discussed in Chapter 8.*

31 **A.1.4 Other Comments within the Scope of the U.S. Nuclear Regulatory** 32 **Commission's Environmental Review**

33 **Comment A-1-SAMA:** The probability of a super solar storm of the 1859 or 1921 size is about
34 1/100 years or 1 %/year. This size storm could lead to a continental wide, long term (many
35 months) outage of the bulk power grid because of damage to all the U.S. step-up
36 [extra-high-voltage] transformers. This damaged would be similar to the damage that occurred
37 at Salem New Jersey in 1989 during a fairly mild solar storm. With such an outage, the
38 emergency generators (that drive the cooling pumps) fuel supply could run out and may not be
39 replaced because all the commercial fuel suppliers would be out of fuel as well due to the failure
40 of the electrical pumps. Without fuel for the cooling pumps, the core damage frequency (CDF)
41 appears to be several orders larger that the CDF given in the table 5-2. Perhaps [a] solar storm
42 initiating event should be included in all the final [S]EIS documents.

1 **Response:** *The Severe Accident Mitigation Alternative (SAMA) analysis considers potential*
2 *ways to further reduce the risk from severe reactor accidents in a cost-beneficial manner. The*
3 *process for identifying and evaluating potential plant enhancements involves use of the latest*
4 *plant-specific, peer-reviewed probabilistic risk assessment (PRA) study. These risk assessment*
5 *studies typically show that loss of offsite power (LOSP) and station blackout (SBO) sequences*
6 *are among the dominant contributors to CDF for nuclear power plants and account for about*
7 *20–50 percent of the CDF. As a result, enhancements to mitigate SBO events initiated by a*
8 *LOSP are routinely identified and evaluated in the SAMA analysis. Consideration of SBO*
9 *events initiated by a solar storm would not be expected to result in identification of additional*
10 *SAMAs to mitigate LOSP and SBO events since license renewal applicants already search for*
11 *potential means to mitigate these risk contributors.*

12 *Consideration of solar storms would not be expected to substantially affect the CDF for LOSP or*
13 *SBO events because postulated damage to generator step-up transformers would not affect the*
14 *operation of the emergency diesel generators (EDGs). The EDGs would function to cool the*
15 *reactor core until connections to the electrical grid are reestablished or alternative means of*
16 *core cooling are established. Onsite fuel storage is typically sufficient to provide for at least 7*
17 *days of EDG operation and would be replenished during this period, as demonstrated at the*
18 *Turkey Point plant following Hurricane Andrew in 1992 (NRC, 1992). Even with a major*
19 *disruption in the supply chain, the 7-day period is sufficient for alternative arrangements to be*
20 *made to resupply fuel for nuclear power plant EDGs in accordance with the National Response*
21 *Framework (see National Response Framework, Emergency Support Function #12–Energy*
22 *Annex, <http://www.fema.gov/pdf/emergency/nrf/nrf-esf-12.pdf>). Alternative means of core*
23 *cooling would be viable in the longer term, given that core cooling requirements (e.g., required*
24 *pumped flow rates) would be substantially reduced days and weeks after reactor shutdown and*
25 *given the substantial industry and Federal resources that would be available to facilitate these*
26 *measures.*

27 *If there is incompleteness in current PRAs with respect to an underestimate of the frequency or*
28 *consequence of solar storm-initiated LOSP or SBO events, the sensitivity analysis done on the*
29 *SAMA benefit calculation would capture the increased benefit that might result from a more*
30 *explicit consideration of solar storm-induced events. This analysis typically involves increasing*
31 *the estimated benefits for all SAMAs by an uncertainty multiplier of approximately two to*
32 *determine if any additional SAMAs would become cost-beneficial and retaining any such*
33 *SAMAs for possible implementation. In summary, the consideration of solar storm-initiated*
34 *events would not be expected to alter the results of the SAMA analysis since enhancements*
35 *that address these types of events are already considered in the applicants' search for SAMAs*
36 *to mitigate SBO or LOSP events, and any potential underestimate of the benefit of these*
37 *SAMAs would be captured in existing applications by the use of the uncertainty multiplier on the*
38 *SAMA benefits.*

39 *The results of the staff's review of the SAMA analysis are presented in this SEIS in Section 5.3*
40 *and Appendix F.*

41 **Comment D-2-OTH:** *The Council has reviewed the environmental and safety portions of*
42 *CGS's license renewal application and finds that the impacts associated with extending plant*
43 *operations are adequately addressed. Three areas of ongoing interest were identified –*
44 *wastewater discharge under the National Pollutant Discharge Elimination System (NPDES)*
45 *permit, groundwater discharges; and storage of spent reactor fuel on-site (dry cask storage).*
46 *These areas are key components of our compliance monitoring program and will continue to*
47 *receive our full attention throughout the relicensing process.*

1 **Response:** *The staff agrees that, in general, wastewater discharge, groundwater discharge,*
2 *and storage of spent fuel are important areas of ongoing interest. The staff examined CGS's*
3 *wastewater and groundwater discharges in its preparation of this SEIS. The findings are*
4 *discussed in Sections 2.1.2, 2.1.3, 2.1.7, and 4.8.2. However, storage of spent fuel will not be*
5 *evaluated further because, as specified by 10 CFR 51.23(b), no site-specific discussion of any*
6 *environmental impact of spent fuel storage in reactor facility storage pools or ISFSIs is required*
7 *in an environmental impact statement associated with license renewal.*

8 **Comment K-1-OTH:** The Washington State Department of Health ([WS]DOH) is responsible
9 for protecting the public from exposure to radiation. At the Columbia Generating Station (CGS),
10 we play an active role in ensuring public health. One way we achieve this is through our
11 independent oversight of the CGS Radiological Environmental Monitoring Program (REMP).
12 Another is through coordination with CGS's emergency preparedness group.

13 Each year DOH and CGS split hundreds of samples of air, groundwater, Columbia River water,
14 soil, sediment, and farm products. DOH's samples are analyzed for radiation at the Public
15 Health Laboratories in Shoreline. We also measure radiation levels at locations where the
16 public resides, and at locations near the plant, including the Independent Spent Fuel Storage
17 Installation. The results of the analyses are used to verify the quality of the CGS results, to look
18 for trends in environmental radiation levels, and to respond to specific incidents when radiation
19 is found at locations where it is not expected. DOH also conducts environmental monitoring of
20 the U.S. Department of Energy's (DOE) Hanford Site surrounding CGS. These data are
21 available for your environmental review of CGS.

22 **Response:** *The staff reviewed the radiological data and analyses from the WSDOH, in addition*
23 *to data from Energy Northwest and DOE, in order to understand the potential impacts to human*
24 *health that could occur if the CGS operating license were renewed. The results of this review*
25 *are discussed in Sections 4.8.2, 4.9.7.4, and 4.11.4 of this SEIS.*

26 **Comment K-3-OTH:** Protecting groundwater and subsequently the Columbia River is a priority.
27 The Columbia River is an important resource for drinking water, crop irrigation, and recreation.
28 The groundwater below CGS is contaminated from past Hanford practices. Recently, the NRC
29 directed all commercial nuclear power plants to conduct studies to ensure that plant operation
30 was not impacting groundwater. The environmental review should consider how to best
31 distinguish between the radioactive contamination currently in the groundwater from past
32 Hanford practices, and the contamination that might occur from continued CGS operations.

33 **Response:** *The staff has evaluated the potential impact to groundwater from the extended*
34 *operation of CGS and, to a limited extent, groundwater contamination from past Hanford*
35 *practices. The staff reviewed CGS's historical radioactive effluent releases (normal and*
36 *abnormal effluents), its groundwater protection program, and its REMP in order to assess its*
37 *potential effects—separate from those of the Hanford Site. In addition, the staff reviewed*
38 *historical radiological environmental monitoring data for DOE activities on the Hanford Site and*
39 *information pertaining to the remediation of the site in order to assess the potential cumulative*
40 *impacts from the Hanford Site and CGS. The staff also reviewed Washington State's*
41 *environmental radiation monitoring data. The results of the staff's review of the potential impact*
42 *to groundwater are discussed in Sections 2.1.7, 2.2.3, 4.3, 4.8.2, 4.9.7.4, 4.10, 4.11.1, and*
43 *4.11.2.*

44 **Comment K-4-OTH:** During Hanford operations, high level waste was disposed into an unlined
45 waste site, 618-11, directly, adjacent to CGS. DOE expects this site will be the most hazardous
46 waste site remediated at Hanford. Considerable effort has been spent trying to reconstruct what

1 might be buried there, and the best strategy for removing the waste. While DOE's goal is to
2 remediate this site without spreading any contamination, CGS could be impacted if waste were
3 released during cleanup activities. The environmental review should consider every possible
4 scenario in which cleanup activities might impact CGS operations.

5 **Comment K-5-OTH:** A significant Hanford Site cleanup challenge is stabilizing and disposing
6 of millions of gallons of high level waste stored in underground tanks. Under the cleanup
7 agreement, plutonium and other high level waste will be vitrified to make it stable for disposal.
8 DOH has the authority to issue the air operating permit to DOE for the Waste Treatment Plant
9 (WTP). The WTP is currently under construction, upwind of CGS, and will be operating during
10 the proposed extended life of CGS. The environmental review should consider potential
11 impacts from the WTP on CGS operations.

12 **Response to comments K-4-OTH and K-5-OTH:** *The staff reviewed historical radiological*
13 *environmental monitoring data for the DOE activities on the Hanford Site and information*
14 *pertaining to the remediation of the site in order to assess the potential impacts to CGS. In*
15 *section 4.8.2, the SEIS includes a discussion of CGS's radiological environmental monitoring*
16 *program that identifies, tracks, and trends radiological conditions in the CGS facility environs*
17 *from radioactive contamination from its own effluents and any that may come from the*
18 *remediation activities at Hanford. In Section 4.11, the SEIS also discusses the potential*
19 *cumulative impacts from the current and reasonably foreseeable remediation activities at*
20 *Hanford, including characterization and remediation of Burial Ground 618-11, the construction*
21 *and operations of the WTP, and the extended operation of CGS.*

22 **Comment Y-1-OTH:** The Tribes would like to participate in the environmental review process
23 and would like input into the description of the affected environment. The tribal representatives
24 feel that the typical federal government [S]EIS does not adequately address tribal
25 environmental, cultural, and other concerns. The Tribes would like to participate in and improve
26 the process.

27 **Response:** *In order to better understand the concerns of the potentially affected American*
28 *Indian Tribes, the NRC invited Tribal representatives to an informational meeting in Richland,*
29 *WA, on April 27, 2010. A summary of this meeting was issued on October 1, 2010, and is*
30 *available in ADAMS under Accession No. ML102630228. The NRC also invited Tribal*
31 *representatives to participate in a data collection site visit June 8–10, 2010. Five tribal*
32 *representatives from three tribes participated in this site visit. A summary of the site visit was*
33 *issued on January 18, 2011, and it is available in the Agencywide Document Access and*
34 *Management System (ADAMS) under Accession No. ML103400163. The NRC did not receive*
35 *any written comments regarding license renewal from Tribal representatives during the scoping*
36 *period. However, the NRC has considered the comments received from interactions and*
37 *meetings with Tribal representatives in the development of this SEIS.*

38 **Comment V-2-OTH:** Dr. Harper would like to provide input to the evaluation of Environmental
39 Justice (EJ).

40 **Response:** *Dr. Harper participated in the April 27, 2010, meeting between the NRC and Tribal*
41 *representatives as well as the CGS site visit in June 2010. EJ is discussed in Section 4.9.7 of*
42 *this SEIS. The reports submitted by Dr. Harper, about exposure scenarios for Tribal members,*
43 *were considered and are summarized in Section 4.9.7.3.*

1 **Comment V-3-OTH:** Dr. Harper stated that Energy Northwest has requested to lease
2 20-square-miles of the Hanford Reservation from DOE for an energy park in the future. PNNL
3 may be listed as a potential partner in this energy park.

4 **Response:** *The proposed energy park, part of the Mid-Columbia Energy Initiative, is addressed*
5 *in Section 4.11.3 and 4.11.5 as a factor in discussing the cumulative impacts on terrestrial*
6 *resources and socioeconomics. It is also included in the discussion of alternatives to the*
7 *proposed action in Section 8.4.5. A description of the Mid-Columbia Energy Initiative is*
8 *provided in Appendix G, Table G-1.*

9 **Comment V-4-OTH:** Dr. Harper and Mr. Harris initiated a discussion regarding dose
10 assessment. The CTUIR would like a new exposure pathway to be considered in the risk
11 assessment that captures the unique tribal lifestyle including traditional foods and way of life.
12 The CTUIR have a tribal scenario and are interested in performing this analysis for NRC to
13 include in the [S]EIS. The tribal scenario has been developed over the past 16 years. The
14 CTUIR asked if the schedule for issuance of the [S]EIS could be extended to allow time to
15 incorporate the tribal scenario. Mr. Pham indicated that information that is new and significant
16 or site-specific will be considered. Dr. Harper offered to provide a summary and indicated that
17 they are willing to work with the NRC regarding this topic.

18 **Response:** *Dr. Harper submitted the reports to the NRC. These reports are discussed in*
19 *Section 4.9.7.3 of this SEIS.*

20 **Comment V-5-OTH:** Dr. Harper initiated a discussion regarding the schedule for renewing the
21 license, suggesting that they may need more time if tribal scenarios are to be considered.

22 **Response:** *The staff responded to this request by considering and discussing the tribal*
23 *scenarios in Section 4.9.7.3 of this SEIS within the revised schedule.*

24 **Comment V-6-OTH:** Dr. Harper raised the topic of groundwater quality and asked how that
25 would be evaluated given the known contamination due to the plant's proximity to radiological
26 waste burial grounds.

27 **Response:** *Groundwater use and quality is addressed in Section 2.1.7.1, including discussion*
28 *of the existing contamination and monitoring wells. Section 2.2.3 describes Burial Ground*
29 *618-11, which is a radioactive waste burial ground adjacent to the CGS site. Section 4.11.1.1*
30 *addresses the cumulative impacts on groundwater resources from CGS operations and other*
31 *activities of the Hanford Site.*

32 **Comment V-7-OTH:** Dr. Harper asked whether or not the original environmental analysis had
33 natural resource mitigation.

34 **Response:** *In the Final Environmental Statement for CGS, issued in December 1981 (ADAMS*
35 *Accession No. ML100570374), the staff stated on page 5-47, "At the present time the staff*
36 *foresees no impacts of a magnitude requiring mitigating actions," and concluded that CGS is*
37 *expected to operate with only minimal environmental impact. Therefore, no mitigation was*
38 *required for potential impacts to terrestrial or aquatic resources.*

39 **Comment V-8-OTH:** Report submitted by Dr. Barbara Harper:

40 2006 Progress Report: Lifestyles and Cultural Practices of Tribal Populations and Risks from
41 Toxic Substances in the Environment.

1 [http://cfpub.epa.gov/ncer_abstracts/index.cfm/fuseaction/display.abstractDetail/
2 abstract/6269/report/2006](http://cfpub.epa.gov/ncer_abstracts/index.cfm/fuseaction/display.abstractDetail/abstract/6269/report/2006)

3 **Comment V-9-OTH:** Report submitted by Dr. Barbara Harper:

4 Human Scenarios for the Screening Assessment. Columbia River Comprehensive Impact
5 Assessment. Napier, Harper, Lane, Strenge, Spivey. March 1996. U.S. Department of Energy.

6 **Response to comments V-8-OTH and V-9-OTH:** *These reports were reviewed by staff and
7 are addressed in Section 4.9.7.3 of this SEIS.*

8 **A.2 References**

9 U.S. Nuclear Regulatory Commission (NRC), "Effect of Hurricane Andrew on the Turkey Point
10 Nuclear Generating Station from August 20–30," Washington, D.C., NUREG-1474, 1992.

11 NRC, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants,"
12 Washington, D.C., NUREG 1437, Volumes 1 and 2, 1996, Agencywide Document Access and
13 Management System (ADAMS) Accession Nos. ML040690705 and ML040690738.

14 NRC, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants," Office
15 of Nuclear Reactor Regulation, Washington, D.C., NUREG 1437, Volume 1, Addendum 1, 1999,
16 ADAMS Accession No. ML040690720.

17 NRC, "Energy Northwest; Notice of Intent to Prepare an Environmental Impact Statement and
18 Conduct the Scoping Process for Columbia Generating Station," *Federal Register (FR)*,
19 Volume 75, No. 47, March 11, 2010, pp. 11576–11578.

20 NRC, "Summary of Public License Renewal Overview and Environmental Scoping Meetings
21 related to the Review of the Columbia Generating Station License Renewal Application (TAC
22 Nos. ME3058 and ME3121)," 2010 (2010a), ADAMS Accession No. ML101250540.

23 NRC, "Summary of Tribal Outreach Informational Meeting Concerning Columbia Generating
24 Station License Renewal and Hanford Low-Level Waste," 2010 (2010b), ADAMS Accession
25 No. ML102630228.

26 NRC, "Environmental Impact Statement, Scoping Process, Summary Report, Columbia
27 Generating Station," Richland, WA, 2010 (2010c), ADAMS Accession No. ML102770232.

APPENDIX B
NATIONAL ENVIRONMENTAL POLICY ACT ISSUES
FOR LICENSE RENEWAL OF NUCLEAR POWER PLANTS

1 **B NATIONAL ENVIRONMENTAL POLICY ACT ISSUES FOR**
 2 **LICENSE RENEWAL OF NUCLEAR POWER PLANTS**

3 NUREG-1437, *Generic Environmental Impact Statement for License Renewal of Nuclear Power*
 4 *Plants* (referred to as the GEIS), documents the results of the U.S. Nuclear Regulatory
 5 Commission (NRC) staff's (staff's) systematic approach to evaluating the environmental impacts
 6 of renewing the licenses of individual nuclear power plants. Of the 92 total environmental
 7 issues that the staff identified in the GEIS, the staff determined that 69 are generic to all plants
 8 (Category 1), while 21 issues must be discussed on a site-specific basis (Category 2). Two
 9 other issues, environmental justice and the chronic effects of electromagnetic fields, are
 10 uncategorized and must be evaluated on a site-specific basis.

11 The table below is a listing of all 92 environmental issues, including the possible environmental
 12 significance (SMALL, MODERATE, LARGE, or uncategorized) as appropriate. This table is
 13 provided in Chapter 9 of the GEIS, is codified in the NRC regulations as Table B-1 in
 14 Appendix B, Subpart A, to Title 10 of the *Code of Federal Regulations* (CFR) Part 51, and is
 15 provided here for convenience.

16 **Table B-1. Summary of issues and findings**

| Issue | Type of issue | Finding |
|---|---------------|--|
| Surface water quality, hydrology, and use | | |
| Impacts of refurbishment on surface water quality | Generic | SMALL. Impacts are expected to be negligible during refurbishment because best management practices are expected to be employed to control soil erosion and spills. |
| Impacts of refurbishment on surface water use | Generic | SMALL. Water use during refurbishment will not increase appreciably or will be reduced during plant outage. |
| Altered current patterns at intake and discharge structures | Generic | SMALL. Altered current patterns have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term. |
| Altered salinity gradients | Generic | SMALL. Salinity gradients have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term. |
| Altered thermal stratification of lakes | Generic | SMALL. Generally, lake stratification has not been found to be a problem at operating nuclear power plants and is not expected to be a problem during the license renewal term. |
| Temperature effects on sediment transport capacity | Generic | SMALL. These effects have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term. |
| Scouring caused by discharged cooling water | Generic | SMALL. Scouring has not been found to be a problem at most operating nuclear power plants and has caused only localized effects at a few plants. It is not expected to be a problem during the license renewal term. |
| Eutrophication | Generic | SMALL. Eutrophication has not been found to be a problem at operating nuclear power plants and is not expected to be a problem during the license renewal term. |
| Discharge of chlorine or other biocides | Generic | SMALL. Effects are not a concern among regulatory and resource agencies, and are not expected to be a problem during the license renewal term. |

Appendix B

| Issue | Type of issue | Finding |
|---|----------------------|---|
| Discharge of sanitary wastes and minor chemical spills | Generic | SMALL. Effects are readily controlled through National Pollutant Discharge Elimination System (NPDES) permit and periodic modifications, if needed, and are not expected to be a problem during the license renewal term. |
| Discharge of other metals in wastewater | Generic | SMALL. These discharges have not been found to be a problem at operating nuclear power plants with cooling-tower-based heat dissipation systems and have been satisfactorily mitigated at other plants. They are not expected to be a problem during the license renewal term. |
| Water use conflicts (plants with once-through cooling systems) | Generic | SMALL. These conflicts have not been found to be a problem at operating nuclear power plants with once-through heat dissipation systems. |
| Water use conflicts (plants with cooling ponds or cooling towers using makeup water from a small river with low flow) | Site-specific | SMALL OR MODERATE. The issue has been a concern at nuclear power plants with cooling ponds and at plants with cooling towers. Impacts on instream and riparian communities near these plants could be of moderate significance in some situations. See § 51.53(c)(3)(ii)(A). |
| Aquatic ecology | | |
| Refurbishment | Generic | SMALL. During plant shutdown and refurbishment, there will be negligible effects on aquatic biota because of a reduction of entrainment and impingement of organisms or a reduced release of chemicals. |
| Accumulation of contaminants in sediments or biota | Generic | SMALL. Accumulation of contaminants has been a concern at a few nuclear power plants but has been satisfactorily mitigated by replacing copper alloy condenser tubes with those of another metal. It is not expected to be a problem during the license renewal term. |
| Entrainment of phytoplankton and zooplankton | Generic | SMALL. Entrainment of phytoplankton and zooplankton has not been found to be a problem at operating nuclear power plants and is not expected to be a problem during the license renewal term. |
| Cold shock | Generic | SMALL. Cold shock has been satisfactorily mitigated at operating nuclear plants with once-through cooling systems, has not endangered fish populations, or been found to be a problem at operating nuclear power plants with cooling towers or cooling ponds, and is not expected to be a problem during the license renewal term. |
| Thermal plume barrier to migrating fish | Generic | SMALL. Thermal plumes have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term. |
| Distribution of aquatic organisms | Generic | SMALL. Thermal discharge may have localized effects but is not expected to affect the larger geographical distribution of aquatic organisms. |
| Premature emergence of aquatic insects | Generic | SMALL. Premature emergence has been found to be a localized effect at some operating nuclear power plants but has not been a problem and is not expected to be a problem during the license renewal term. |
| Gas supersaturation (gas bubble disease) | Generic | SMALL. Gas supersaturation was a concern at a small number of operating nuclear power plants with once-through cooling systems but has been satisfactorily mitigated. It has not been found to be a problem at operating nuclear power plants with cooling towers or cooling ponds and is not expected to be a problem during the license renewal term. |
| Low dissolved oxygen in the discharge | Generic | SMALL. Low dissolved oxygen has been a concern at one nuclear power plant with a once-through cooling system but has been effectively mitigated. It has not been found to be a problem at operating nuclear power plants with cooling towers or cooling ponds and is not expected to be a problem during the license renewal term. |

| Issue | Type of issue | Finding |
|--|----------------------|--|
| Losses from predation, parasitism, and disease among organisms exposed to sublethal stresses | Generic | SMALL. These types of losses have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term. |
| Stimulation of nuisance organisms (e.g., shipworms) | Generic | SMALL. Stimulation of nuisance organisms has been satisfactorily mitigated at the single nuclear power plant with a once-through cooling system where previously it was a problem. It has not been found to be a problem at operating nuclear power plants with cooling towers or cooling ponds and is not expected to be a problem during the license renewal term. |
| Aquatic ecology (for plants with once-through and cooling-pond heat dissipation systems) | | |
| Entrainment of fish and shellfish in early life stages | Site-specific | SMALL, MODERATE, OR LARGE. The impacts of entrainment are small at many plants but may be moderate or even large at a few plants with once-through and cooling-pond cooling systems. Further, ongoing efforts in the vicinity of these plants to restore fish populations may increase the numbers of fish susceptible to intake effects during the license renewal period, such that entrainment studies conducted in support of the original license may no longer be valid. See § 51.53(c)(3)(ii)(B). |
| Impingement of fish and shellfish | Site-specific | SMALL, MODERATE, OR LARGE. The impacts of impingement are small at many plants but may be moderate or even large at a few plants with once-through and cooling-pond cooling systems. See § 51.53(c)(3)(ii)(B). |
| Heat shock | Site-specific | SMALL, MODERATE, OR LARGE. Because of continuing concerns about heat shock and the possible need to modify thermal discharges in response to changing environmental conditions, the impacts may be of moderate or large significance at some plants. See § 51.53(c)(3)(ii)(B). |
| Aquatic ecology (for plants with cooling-tower-based heat dissipation systems) | | |
| Entrainment of fish and shellfish in early life stages | Generic | SMALL. Entrainment of fish has not been found to be a problem at operating nuclear power plants with this type of cooling system and is not expected to be a problem during the license renewal term. |
| Impingement of fish and shellfish | Generic | SMALL. The impingement has not been found to be a problem at operating nuclear power plants with this type of cooling system and is not expected to be a problem during the license renewal term. |
| Heat shock | Generic | SMALL. Heat shock has not been found to be a problem at operating nuclear power plants with this type of cooling system and is not expected to be a problem during the license renewal term. |
| Groundwater use and quality | | |
| Impacts of refurbishment on groundwater use and quality | Generic | SMALL. Extensive dewatering during the original construction on some sites will not be repeated during refurbishment on any sites. Any plant wastes produced during refurbishment will be handled in the same manner as in current operating practices and are not expected to be a problem during the license renewal term. |
| Groundwater use conflicts (potable and service water; plants that use <100 gallons per minute (gpm)) | Generic | SMALL. Plants using less than 100 gpm are not expected to cause any groundwater use conflicts. |

Appendix B

| Issue | Type of issue | Finding |
|---|----------------------|--|
| Groundwater use conflicts (potable and service water, and dewatering plants that use >100 gpm) | Site-specific | SMALL, MODERATE, OR LARGE. Plants that use more than 100 gpm may cause groundwater use conflicts with nearby groundwater users. See § 51.53(c)(3)(ii)(C). |
| Groundwater use conflicts (plants using cooling towers withdrawing makeup water from a small river) | Site-specific | SMALL, MODERATE, OR LARGE. Water use conflicts may result from surface water withdrawals from small water bodies during low flow conditions which may affect aquifer recharge, especially if other groundwater or upstream surface water users come online before the time of license renewal. See § 51.53(c)(3)(ii)(A). |
| Groundwater use conflicts (Ranney wells) | Site-specific | SMALL, MODERATE, OR LARGE. Ranney wells can result in potential groundwater depression beyond the site boundary. Impacts of large groundwater withdrawal for cooling tower makeup at nuclear power plants using Ranney wells must be evaluated at the time of application for license renewal. See § 51.53(c)(3)(ii)(C). |
| Groundwater quality degradation (Ranney wells) | Generic | SMALL. Groundwater quality at river sites may be degraded by induced infiltration of poor-quality river water into an aquifer that supplies large quantities of reactor cooling water. However, the lower quality infiltrating water would not preclude the current uses of groundwater and is not expected to be a problem during the license renewal term. |
| Groundwater quality degradation (saltwater intrusion) | Generic | SMALL. Nuclear power plants do not contribute significantly to saltwater intrusion. |
| Groundwater quality degradation (cooling ponds in salt marshes) | Generic | SMALL. Sites with closed-cycle cooling ponds may degrade groundwater quality. Because water in salt marshes is brackish, this is not a concern for plants located in salt marshes. |
| Groundwater quality degradation (cooling ponds at inland sites) | Site-specific | SMALL, MODERATE, OR LARGE. Sites with closed-cycle cooling ponds may degrade groundwater quality. For plants located inland, the quality of the groundwater in the vicinity of the ponds must be shown to be adequate to allow continuation of current uses. See § 51.53(c)(3)(ii)(D). |
| Terrestrial ecology | | |
| Refurbishment impacts | Site-specific | SMALL, MODERATE, OR LARGE. Refurbishment impacts are insignificant if no loss of important plant and animal habitat occurs. However, it cannot be known whether important plant and animal communities may be affected until the specific proposal is presented with the license renewal application. See § 51.53(c)(3)(ii)(E). |
| Cooling tower impacts on crops and ornamental vegetation | Generic | SMALL. Impacts from salt drift, icing, fogging, or increased humidity associated with cooling tower operation have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term. |
| Cooling tower impacts on native plants | Generic | SMALL. Impacts from salt drift, icing, fogging, or increased humidity associated with cooling tower operation have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term. |
| Bird collisions with cooling towers | Generic | SMALL. These collisions have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term. |
| Cooling pond impacts on terrestrial resources | Generic | SMALL. Impacts of cooling ponds on terrestrial ecological resources are considered to be of small significance at all sites. |

| Issue | Type of issue | Finding |
|--|----------------------|---|
| Power line right of way (ROW) management (cutting and herbicide application) | Generic | SMALL. The impacts of ROW maintenance on wildlife are expected to be of small significance at all sites. |
| Bird collisions with power lines | Generic | SMALL. Impacts are expected to be of small significance at all sites. |
| Impacts of electromagnetic fields on flora and fauna | Generic | SMALL. No significant impacts of electromagnetic fields on terrestrial flora and fauna have been identified. Such effects are not expected to be a problem during the license renewal term. |
| Floodplains and wetland on power line ROW | Generic | SMALL. Periodic vegetation control is necessary in forested wetlands underneath power lines and can be achieved with minimal damage to the wetland. No significant impact is expected at any nuclear power plant during the license renewal term. |
| Threatened and endangered species | | |
| Threatened or endangered species | Site-specific | SMALL, MODERATE, OR LARGE. Generally, plant refurbishment and continued operation are not expected to adversely affect threatened or endangered species. However, consultation with appropriate agencies would be needed at the time of license renewal to determine whether or not threatened or endangered species are present and whether or not they would be adversely affected. See § 51.53(c)(3)(ii)(E). |
| Air quality | | |
| Air quality during refurbishment (non-attainment and maintenance areas) | Site-specific | SMALL, MODERATE, OR LARGE. Air quality impacts from plant refurbishment associated with license renewal are expected to be small. However, vehicle exhaust emissions could be cause for concern at locations in or near nonattainment or maintenance areas. The significance of the potential impact cannot be determined without considering the compliance status of each site and the number of workers expected to be employed during the outage. See § 51.53(c)(3)(ii)(F). |
| Air quality effects of transmission lines | Generic | SMALL. Production of ozone and oxides of nitrogen is insignificant and does not contribute measurably to ambient levels of these gases. |
| Land use | | |
| Onsite land use | Generic | SMALL. Projected onsite land use changes required during refurbishment and the renewal period would be a small fraction of any nuclear power plant site and would involve land that is controlled by the applicant. |
| Power line ROW | Generic | SMALL. Ongoing use of power line ROWs would continue with no change in restrictions. The effects of these restrictions are of small significance. |
| Human health | | |
| Radiation exposures to the public during refurbishment | Generic | SMALL. During refurbishment, the gaseous effluents would result in doses that are similar to those from current operation. Applicable regulatory dose limits to the public are not expected to be exceeded. |
| Occupational radiation exposures during refurbishment | Generic | SMALL. Occupational doses from refurbishment are expected to be within the range of annual average collective doses experienced for pressurized-water reactors and boiling-water reactors. Occupational mortality risk from all causes including radiation is in the mid-range for industrial settings. |
| Microbiological organisms (occupational health) | Generic | SMALL. Occupational health impacts are expected to be controlled by continued application of accepted industrial hygiene practices to minimize exposure to workers. |

Appendix B

| Issue | Type of issue | Finding |
|--|----------------------|--|
| Microbiological organisms (public health) (plants using lakes or canals, or cooling towers or cooling ponds that discharge to a small river) | Site-specific | SMALL, MODERATE, OR LARGE. These organisms are not expected to be a problem at most operating plants except possibly at plants using cooling ponds, lakes, or canals that discharge to small rivers. Without site-specific data, it is not possible to predict the effects generically. See § 51.53(c)(3)(ii)(G). |
| Noise | Generic | SMALL. Noise has not been found to be a problem at operating plants and is not expected to be a problem at any plant during the license renewal term. |
| Electromagnetic fields – acute effects (electric shock) | Site-specific | SMALL, MODERATE, OR LARGE. Electrical shock resulting from direct access to energized conductors or from induced charges in metallic structures have not been found to be a problem at most operating plants and generally are not expected to be a problem during the license renewal term. However, site-specific review is required to determine the significance of the electric shock potential at the site. See § 51.53(c)(3)(ii)(H). |
| Electromagnetic fields – chronic effects | Uncategorized | UNCERTAIN. Biological and physical studies of 60-hertz electromagnetic fields have not found consistent evidence linking harmful effects with field exposures. However, research is continuing in this area and a consensus scientific view has not been reached. |
| Radiation exposures to public (license renewal term) | Generic | SMALL. Radiation doses to the public will continue at current levels associated with normal operations. |
| Occupational radiation exposures (license renewal term) | Generic | SMALL. Projected maximum occupational doses during the license renewal term are within the range of doses experienced during normal operations and normal maintenance outages, and would be well below regulatory limits. |
| Socioeconomic impacts | | |
| Housing impacts | Site-specific | SMALL, MODERATE, OR LARGE. Housing impacts are expected to be of small significance at plants located in a medium or high population area and not in an area where growth control measures that limit housing development are in effect. Moderate or large housing impacts of the workforce associated with refurbishment may be associated with plants located in sparsely populated areas or in areas with growth control measures that limit housing development. See § 51.53(c)(3)(ii)(I). |
| Public services: public safety, social services, and tourism and recreation | Generic | SMALL. Impacts to public safety, social services, and tourism and recreation are expected to be of small significance at all sites. |
| Public services: public utilities | Site-specific | SMALL OR MODERATE. An increased problem with water shortages at some sites may lead to impacts of moderate significance on public water supply availability. See § 51.53(c)(3)(ii)(I). |
| Public services: education (refurbishment) | Site-specific | SMALL, MODERATE, OR LARGE. Most sites would experience impacts of small significance but larger impacts are possible depending on site- and project-specific factors. See § 51.53(c)(3)(ii)(I). |
| Public services: education (license renewal term) | Generic | SMALL. Only impacts of small significance are expected. |
| Offsite land use (refurbishment) | Site-specific | SMALL OR MODERATE. Impacts may be of moderate significance at plants in low population areas. See § 51.53(c)(3)(ii)(I). |

| Issue | Type of issue | Finding |
|---|----------------------|---|
| Offsite land use (license renewal term) | Site-specific | SMALL, MODERATE, OR LARGE. Significant changes in land use may be associated with population and tax revenue changes resulting from license renewal. See § 51.53(c)(3)(ii)(I). |
| Public services: transportation | Site-specific | SMALL, MODERATE, OR LARGE. Transportation impacts (level of service) of highway traffic generated during plant refurbishment and during the term of the renewed license are generally expected to be of small significance. However, the increase in traffic associated with the additional workers and the local road and traffic control conditions may lead to impacts of moderate or large significance at some sites. See § 51.53(c)(3)(ii)(J). |
| Historic and archaeological resources | Site-specific | SMALL, MODERATE, OR LARGE. Generally, plant refurbishment and continued operation are expected to have no more than small adverse impacts on historic and archaeological resources. However, the National Historic Preservation Act requires the Federal agency to consult with the State Historic Preservation Officer to determine whether or not there are properties present that require protection. See § 51.53(c)(3)(ii)(K). |
| Aesthetic impacts (refurbishment) | Generic | SMALL. No significant impacts are expected during refurbishment. |
| Aesthetic impacts (license renewal term) | Generic | SMALL. No significant impacts are expected during the license renewal term. |
| Aesthetic impacts of transmission lines (license renewal term) | Generic | SMALL. No significant impacts are expected during the license renewal term. |
| Postulated accidents | | |
| Design basis accidents | Generic | SMALL. The staff has concluded that the environmental impacts of design-basis accidents are of small significance for all plants. |
| Severe accidents | Site-specific | SMALL. The probability weighted consequences of atmospheric releases, fallout onto open bodies of water, releases to groundwater, and societal and economic impacts from severe accidents are small for all plants. However, alternatives to mitigate severe accidents must be considered for all plants that have not considered such alternatives. See § 51.53(c)(3)(ii)(L). |
| Uranium fuel cycle and waste management | | |
| Offsite radiological impacts (individual effects from other than the disposal of spent fuel and high level waste) | Generic | SMALL. Offsite impacts of the uranium fuel cycle have been considered by the Commission in Table S-3 of this part. Based on information in the GEIS, impacts on individuals from radioactive gaseous and liquid releases including radon-222 and technetium-99 are small. |
| Offsite radiological impacts (collective effects) | Generic | The 100-year environmental dose commitment to the U.S. population from the fuel cycle, high level waste, and spent fuel disposal excepted, is calculated to be about 14,800 person rem, or 12 cancer fatalities, for each additional 20-year power reactor operating term. Much of this, especially the contribution of radon releases from mines and tailing piles, consists of tiny doses summed over large populations. This same dose calculation can theoretically be extended to include many tiny doses over additional thousands of years as well as doses outside the United States. The result of such a calculation would be thousands of cancer fatalities from the fuel cycle, but this result assumes that even tiny doses have some statistical adverse health effect which will not ever be mitigated (for example no cancer cure in the next thousand years), and that these doses projected over thousands of years are meaningful; however, these assumptions are questionable. In particular, science cannot rule out the possibility that there will be no cancer fatalities from these tiny doses. For perspective, the doses |

Appendix B

| Issue | Type of issue | Finding |
|---|---------------|--|
| Offsite radiological impacts (spent fuel and high level waste disposal) | Generic | <p>are very small fractions of regulatory limits, and even smaller fractions of natural background exposure to the same populations.</p> <p>Nevertheless, despite all the uncertainty, some judgment as to the regulatory NEPA implications of these matters should be made and it makes no sense to repeat the same judgment in every case. Even taking the uncertainties into account, the Commission concludes that these impacts are acceptable in that these impacts would not be sufficiently large to require the NEPA conclusion, for any plant, that the option of extended operation under 10 CFR Part 54 should be eliminated. Accordingly, while the Commission has not assigned a single level of significance for the collective effects of the fuel cycle, this issue is considered Category 1 (Generic).</p> <p>For the high level waste and spent fuel disposal component of the fuel cycle, there are no current regulatory limits for offsite releases of radionuclides for the current candidate repository site. However, if it is assumed that limits are developed along the lines of the 1995 National Academy of Sciences (NAS) report, "Technical Bases for Yucca Mountain Standards," and that in accordance with the Commission's Waste Confidence Decision, 10 CFR 51.23, a repository can and likely will be developed at some site which will comply with such limits, peak doses to virtually all individuals will be 100 millirem per year or less. However, while the Commission has reasonable confidence that these assumptions will prove correct, there is considerable uncertainty since the limits are yet to be developed, no repository application has been completed or reviewed, and uncertainty is inherent in the models used to evaluate possible pathways to the human environment. The NAS report indicated that 100 millirem per year should be considered as a starting point for limits for individual doses, but notes that some measure of consensus exists among national and international bodies that the limits should be a fraction of the 100 millirem per year. The lifetime individual risk from 100 millirem annual dose limit is about 3×10^{-3}.</p> <p>Estimating cumulative doses to populations over thousands of years is more problematic. The likelihood and consequences of events that could seriously compromise the integrity of a deep geologic repository were evaluated by the Department of Energy in the "Final Environmental Impact Statement: Management of Commercially Generated Radioactive Waste," October 1980. The evaluation estimated the 70-year whole-body dose commitment to the maximum individual and to the regional population resulting from several modes of breaching a reference repository in the year of closure, after 1,000 years, after 100,000 years, and after 100,000,000 years. Subsequently, the NRC and other federal agencies have expended considerable effort to develop models for the design and for the licensing of a high level waste repository, especially for the candidate repository at Yucca Mountain. More meaningful estimates of doses to population may be possible in the future as more is understood about the performance of the proposed Yucca Mountain repository. Such estimates would involve very great uncertainty, especially with respect to cumulative population doses over thousands of years. The standard proposed by the NAS is a limit on maximum individual dose. The relationship of potential new regulatory requirements, based on the NAS report, and cumulative population impacts has not been determined, although the report articulates the view that protection of individuals will adequately protect the population for a repository at Yucca Mountain. However, the EPA's generic repository standards in 40 CFR Part 191 generally provide an indication of the order of magnitude of cumulative risk to population that could result from the licensing of a Yucca Mountain repository, assuming the ultimate standards will be within the range of standards now under consideration. The standards in 40 CFR Part 191 protect the population by imposing the amount of radioactive material released over 10,000 years. The cumulative release limits are based on the EPA's population impact goal of 1,000 premature</p> |

| Issue | Type of issue | Finding |
|---|---------------|--|
| | | cancer deaths worldwide for a 100,000 metric ton (MT) repository. |
| | | Nevertheless, despite all the uncertainty, some judgment as to the regulatory NEPA implications of these matters should be made and it makes no sense to repeat the same judgment in every case. Even taking the uncertainties into account, the Commission concludes that these impacts are acceptable in that these impacts would not be sufficiently large to require the NEPA conclusion, for any plant, that the option of extended operation under 10 CFR Part 54 should be eliminated. Accordingly, while the Commission has not assigned a single level of significance for the impacts of spent fuel and high level waste disposal, this issue is considered in Category 1 (Generic). |
| Nonradiological impacts of the uranium fuel cycle | Generic | SMALL. The nonradiological impacts of the uranium fuel cycle resulting from the renewal of an operating license for any plant are found to be small. |
| Low-level waste storage and disposal | Generic | SMALL. The comprehensive regulatory controls that are in place and the low public doses being achieved at reactors ensure that the radiological impacts to the environment will remain small during the term of a renewed license. The maximum additional onsite land that may be required for low-level waste storage during the term of a renewed license and associated impacts will be small. |
| | | Nonradiological impacts on air and water will be negligible. The radiological and nonradiological environmental impacts of long-term disposal of low-level waste from any individual plant at licensed sites are small. In addition, the Commission concludes that there is reasonable assurance that sufficient low-level waste disposal capacity will be made available when needed for facilities to be decommissioned consistent with NRC decommissioning requirements. |
| Mixed waste storage and disposal | Generic | SMALL. The comprehensive regulatory controls and the facilities and procedures that are in place ensure proper handling and storage, as well as negligible doses and exposure to toxic materials for the public and the environment at all plants. License renewal will not increase the small, continuing risk to human health and the environment posed by mixed waste at all plants. The radiological and nonradiological environmental impacts of long-term disposal of mixed waste from any individual plant at licensed sites are small. In addition, the Commission concludes that there is reasonable assurance that sufficient mixed waste disposal capacity will be made available when needed for facilities to be decommissioned consistent with NRC decommissioning requirements. |
| Onsite spent fuel | Generic | SMALL. The expected increase in the volume of spent fuel from an additional 20 years of operation can be safely accommodated on site with small environmental effects through dry or pool storage at all plants if a permanent repository or monitored retrievable storage is not available. |
| Nonradiological waste | Generic | SMALL. No changes to generating systems are anticipated for license renewal. Facilities and procedures are in place to ensure continued proper handling and disposal at all plants. |
| Transportation | Generic | SMALL. The impacts of transporting spent fuel enriched up to 5 percent uranium-235 with average burnup for the peak rod to current levels approved by NRC up to 62,000 megawatt days per metric-ton uranium and the cumulative impacts of transporting high-level waste to a single repository, such as Yucca Mountain, Nevada are found to be consistent with the impact values contained in 10 CFR 51.52(c), Summary Table S-4 – Environmental Impact of Transportation of Fuel and Waste to and from One Light-Water-Cooled Nuclear Power Reactor. If fuel enrichment or burnup conditions are not met, the applicant must submit an assessment of the implications for the environmental impact values reported in § 51.52. |

Appendix B

| Issue | Type of issue | Finding |
|------------------------------|---------------|---|
| Decommissioning | | |
| Radiation doses | Generic | SMALL. Doses to the public will be well below applicable regulatory standards regardless of which decommissioning method is used. Occupational doses would increase no more than 1 man-rem caused by buildup of long-lived radionuclides during the license renewal term. |
| Waste management | Generic | SMALL. Decommissioning at the end of a 20-year license renewal period would generate no more solid wastes than at the end of the current license term. No increase in the quantities of Class C or greater than Class C wastes would be expected. |
| Air quality | Generic | SMALL. Air quality impacts of decommissioning are expected to be negligible either at the end of the current operating term or at the end of the license renewal term. |
| Water quality | Generic | SMALL. The potential for significant water quality impacts from erosion or spills is no greater whether decommissioning occurs after a 20-year license renewal period or after the original 40-year operation period, and measures are readily available to avoid such impacts. |
| Ecological resources | Generic | SMALL. Decommissioning after either the initial operating period or after a 20-year license renewal period is not expected to have any direct ecological impacts. |
| Socioeconomic impacts | Generic | SMALL. Decommissioning would have some short-term socioeconomic impacts. The impacts would not be increased by delaying decommissioning until the end of a 20-year relicense period, but they might be decreased by population and economic growth. |
| Environmental justice | | |
| Environmental justice | Uncategorized | NONE. The need for and the content of an analysis of environmental justice will be addressed in plant-specific reviews. |

1 **B.1 References**

- 2 *U.S. Code of Federal Regulations*, "Environmental Protection Regulations for Domestic
- 3 Licensing and Related Regulatory Functions," Part 51, Chapter 1, Title 10, "Energy."
- 4 Department of Energy (DOE), "Final Environmental Impact Statement: Management of
- 5 Commercially Generated Radioactive Waste," October 1980.
- 6 National Academy of Sciences (NAS), "Technical Bases for Yucca Mountain Standards," 1995.

APPENDIX C
APPLICABLE REGULATIONS, LAWS, AND AGREEMENTS

1 C APPLICABLE REGULATIONS, LAWS, AND AGREEMENTS

2 The Atomic Energy Act (42 USC § 2021) authorizes the U.S. Nuclear Regulatory Commission
3 (NRC) to enter into agreement with any State to assume regulatory authority for certain
4 activities. For example, through the Agreement State Program, Washington assumed
5 regulatory responsibility over certain byproduct, source, and quantities of special nuclear
6 materials not sufficient to form a critical mass. The Washington State Agreement Program is
7 administered by the Office of Radiation Protection in the Washington State Department
8 of Health.

9 In addition to carrying out some Federal programs, State legislatures develop their own laws.
10 State statutes supplement, as well as implement, Federal laws for protection of air, water
11 quality, and groundwater. State legislation may address solid waste management programs,
12 locally rare or endangered species, and historic and cultural resources.

13 The Clean Water Act (CWA) allows for primary enforcement and administration through State
14 agencies, given that the State program is at least as stringent as the Federal program. The
15 State program must conform to the CWA and to the delegation of authority for the Federal
16 National Pollutant Discharge Elimination System (NPDES) Program from the Environmental
17 Protection Agency (EPA) to the State. The primary mechanism to control water pollution is the
18 requirement for direct dischargers to obtain an NPDES permit, or in the case of States where
19 the authority has been delegated from the EPA, a State Pollutant Discharge Elimination System
20 permit, under the CWA. In Washington, the Energy Facility Site Evaluation Council (EFSEC)
21 issues and enforces NPDES permits.

22 One important difference between Federal regulations and certain State regulations is the
23 definition of waters regulated by the State. Certain State regulations may include underground
24 waters, while the CWA only regulates surface waters.

25 C.1 Federal and State Environmental Requirements

26 Columbia Generating Station (CGS) is subject to Federal and State requirements for its
27 environmental program. Those requirements are briefly described below. See Section 1.9 of
28 this supplemental environmental impact statement for CGS's compliance status with these
29 requirements.

30 Table C-1 lists the principal Federal and State environmental regulations and laws that are
31 applicable to the review of the environmental resources that could be affected by this project
32 that may affect license renewal applications for nuclear power plants.

33 **Table C-1. Federal and state environmental requirements**

| Law/regulation | Requirements |
|---|--|
| Current operating license and license renewal | |
| 10 CFR Part 51. <i>Code of Federal Regulations</i> (CFR), Title 10, <i>Energy</i> , Part 51 | "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions." This part contains environmental protection regulations applicable to NRC's domestic licensing and related regulatory functions. |

Appendix C

| Law/regulation | Requirements |
|--|---|
| 10 CFR Part 54 | "Requirements for Renewal of Operating Licenses for Nuclear Power Plants." This part focuses on managing adverse effects of aging rather than noting all aging mechanisms. The rule is intended to ensure that important systems, structures, and components will maintain their intended function during the period of extended operation. |
| 10 CFR Part 50 | "Domestic Licensing of Production and Utilization Facilities." Regulations issued by the NRC under the Atomic Energy Act of 1954, as amended (68 Stat. 919), and Title II of the Energy Reorganization Act of 1974 (88 Stat. 1242), provide for the licensing of production and utilization facilities. This part also gives notice to all persons who knowingly supply—to any licensee, applicant, contractor, or subcontractor—components, equipment, materials, or other goods or services, that relate to a licensee's or applicant's activities subject to this part, that they may be individually subject to NRC enforcement action for violation of § 50.5. |
| Air Quality protection | |
| Clean Air Act (CAA) (42 USC §7401 et seq.) | The Clean Air Act (CAA) is a comprehensive Federal law that regulates air emissions. Under CAA, Federal actions cannot thwart State and local efforts to remedy long-standing air quality problems that threaten public health issues associated with the six criteria air pollutants (i.e., ozone, nitrogen dioxide, sulfur dioxide, particulate matter, carbon monoxide, and lead). |
| Water resources protection | |
| Clean Water Act (CWA) (33 USC 1251 et seq.) and the NPDES (40 CFR 122) | The CWA establishes the basic structure for regulating discharges of pollutants into the waters of the U.S. and regulating quality standards for surface waters. |
| Wild and Scenic River Act (16 USC 1271 et seq.) | The Wild and Scenic River Act created the National Wild and Scenic Rivers System, established to protect the environmental values of free flowing streams from degradation by impacting activities including water resources projects. |
| Water Code of 1917 (Revised Code of Washington (RCW) 90.03) | The Water Code of 1917 establishes the procedures for water management in the state of Washington, including administration and adjudication and water rights. |
| The 1945 Ground Water Code (RCW 90.44) | This code extends the surface water code and its permitting process to groundwater. |
| 1969 Minimum Water Flows and Levels (RCW 90.22) | RCW 90.22 establishes minimum flow levels to protect fish, wildlife, water quality, and other instream resources. |
| Water Resources Act of 1971 (RCW 90.54) | RCW 90.54 sets forth fundamentals of water resource policy to ensure that waters of the state are protected and fully used for the greatest benefit. |
| Water Pollution Control Act (RCW 90.48) | RCW 90.48 establishes water quality policy to insure the purity of all waters of the state and to prevent and control pollution of the waters of the State of Washington. |
| Growth Management Act (RCW 36.70A) | RCW 36.70A sets forth the provisions providing a clearer link between the development of land and water availability. |
| Waste management and pollution prevention | |
| Resource Conservation and Recovery Act (RCRA) (42 USC § 6901 et seq.) | Before a material can be classified as a hazardous waste, it must first be a solid waste as defined under the RCRA. Hazardous waste is classified under Subtitle C of the RCRA. Parts 261 and 262 of Title 40 CFR contain all applicable generators of hazardous waste regulations. Part 261.5 (a) and (e) contains requirements for conditionally exempt small quantity generators. Part 262.34(d) contains requirements for small quantity generators. Parts 262 and 261.5(e) contain requirements for large quantity generators. |
| Pollution Prevention Act (42 USC § 13101 et seq.) | The Pollution Prevention Act formally established a national policy to prevent or reduce pollution at its source whenever possible. The Act supplies funds for State and local pollution prevention programs through a grant program to promote the use of pollution prevention techniques by business. |

| Law/regulation | Requirements |
|--|---|
| Endangered species | |
| Endangered Species Act (ESA) (16 USC § 1531 et seq.) | ESA forbids any government agency, corporation, or citizen from taking (harming or killing) endangered animals without an Endangered Species Permit. |
| Fish and Wildlife Coordination Act (16 USC § 661 et seq.) | To minimize adverse impacts of proposed actions on fish and wildlife resources and habitat, the Fish and Wildlife Coordination Act requires that Federal agencies consult government agencies regarding activities that affect, control, or modify waters of any stream or bodies of water. It also requires that justifiable means and measures be used in modifying plans to protect fish and wildlife in these waters. |
| Historic preservation | |
| National Historic Preservation Act (NHPA) (16 USC § 470 et seq.) | NHPA directs Federal agencies to consider the impact of their actions on historic properties. NHPA also encourages state and local preservation societies. |

1 C.2 Operating Permits and Other Requirements

2 Table C-2 lists the permits and licenses issued by Federal, State, and local authorities for
3 activities at CGS.

4 **Table C-2. Licenses and permits**
5 *Existing environmental authorizations for CGS operations*

| Permit | Number | Dates | Responsible agency |
|---|--------------------------|--|---|
| Operating license | NPF-21 | Issued: 12/20/1983 Expires: 12/20/2023 | NRC |
| NPDES Permit | WA-002515-1 | Issued: 5/25/2006 Expires: 5/25/2011* | Washington Energy Facility Site Evaluation Council |
| Lease contract for construction and operation of CGS on Department of Energy (DOE) land | AT(45-1)-2269 | Issued: 12/10/1971 Expires: Parcel A 1/01/2022 Parcel B 1/01/2052 | DOE |
| Easement for use of DOE land for CGS access road | | Issued: 6/16/1981 | DOE |
| Easement for use of DOE land for CGS security barrier | Contract R006-02ES-14208 | Issued: 6/11/2002 Expires: 6/11/2012 | DOE |
| State permit to construct & operate | N/A | Issued: 5/17/1972 | Washington Energy Facility Site Evaluation Council |
| Resolution for multipurpose use of cooling water | 122 | Issued: 6/27/1977 | Washington Energy Facility Site Evaluation Council |
| Resolution for site restoration plan | 244 | Issued: 8/22/1988 | Washington Energy Facility Site Evaluation Council |
| Resolution for Radiological Environmental Monitoring Program | 260 | Issued: 1/13/1992 | Washington Energy Facility Site Evaluation Council |
| Resolution for reactor power uprate from 3,323 MW thermal (MWt) to 3,486 MWt | 273 | Issued: 9/12/1994 | Washington Energy Facility Site Evaluation Council |
| Resolution for operation of inert waste landfill | 288 | Issued: 11/10/1997 | Washington Energy Facility Site Evaluation Council |

Appendix C

| Permit | Number | Dates | Responsible agency |
|--|-----------------------|--|---|
| Resolution for construction & operation of independent spent fuel storage installation (ISFSI) | 295 | Issued: 9/11/2000 | Washington Energy Facility Site Evaluation Council |
| Resolution for onsite disposal of cooling system sediment | 299 | Issued: 8/3/2001 | Washington Energy Facility Site Evaluation Council |
| Resolution for operation of sanitary waste treatment facility | 300 | Issued: 9/10/2001 | Washington Energy Facility Site Evaluation Council |
| Resolution for fulfillment of wildlife mitigation requirements | 302 | Issued: 12/15/2003 | Washington Energy Facility Site Evaluation Council |
| Resolution for construction & operation of hydrogen storage facility | 303 | Issued: 2/18/2003 | Washington Energy Facility Site Evaluation Council |
| Permit for construction & maintenance of river intake & discharge structures | 071-OYC-1-000221-75-9 | Issued: 3/14/1975 | U.S. Army Corps of Engineers |
| Easement for use of aquatic lands (riverbed and shoreline) for construction & operation of in-river structures | 51-076659 | Issued: 4/2/2005 Expires: 4/1/2035 | Washington Department of Natural Resources |
| Certificate for withdrawal & consumption of surface water | S3-20141C | Issued: 2/4/1983 | Washington Department of Ecology |
| Certificate for withdrawal & consumption of groundwater | G3-20142C | Issued: 2/5/1979 | Washington Department of Ecology |
| Notification of regulated waste activity | WAD980738488 | Issued: 8/11/1982 | Washington Department of Ecology |
| Order about air emissions | 672 | Issued: 1/8/1996 | Washington Energy Facility Site Evaluation Council |
| Order about air emission from painting & blasting | 837 | Issued: 2/11/2009 | Washington Energy Facility Site Evaluation Council |
| Registration for operation of miscellaneous x-ray sources | 03311 | Annual registration Expires: 6/30/2012 | Washington Department of Health (through Department of Licensing) |
| Registration for operation of underground storage tanks | 034 003 333 | Annual registration Expires: 6/30/2012 | Washington Department of Health (through Department of Licensing) |
| Permit for operation of public water system | 920240 | Annual registration Expires: 11/30/2011 | Washington Department of Health |
| Certification for operation of public water system | 11452 | Annual renewal Expires: 12/31/2011 | Washington Department of Health |
| Certification for operation of wastewater treatment system | 5835 | Annual renewal Expires: 12/31/2011 | Washington Department of Ecology |
| Certification for operation of solid waste landfill | 42551 | Expires: 4/8/2013 | Washington Department of Ecology |
| Permit for use of commercial low-level radwaste disposal facility | G1018 | Annual permit Expires: 2/29/2012 | Washington Department of Ecology |
| Certification for operation of accredited laboratory | 11242 | Annual renewal Expires: 8/7/2011 | Washington Department of Ecology |

| Permit | Number | Dates | Responsible agency |
|---|------------|--------------------|---------------------------------|
| License for use of radioactive material in laboratory | WN-L0217-1 | Expires: 1/31/2016 | Washington Department of Health |

Source: Energy Northwest ER (EN, 2010), (EN, 2011)

* On 11/19/2010, Energy Northwest submitted an application for renewal. By letter dated 12/29/2010, the Washington Energy Facility Site Evaluation Council acknowledged receipt and advised that processing of the application would be suspended until the cooling water discharge could be characterized after replacement of the CGS steam condenser. The condenser will be replaced during the Spring 2011 maintenance and refueling outage. As allowed by Washington Administrative Code sections 173-220-180(5) and 463-76-061(4), the current permit remains in effect.

1 **C.3 References**

- 2 Energy Northwest (EN), "License Renewal Application, Columbia Generating Station, Appendix
- 3 E, Applicant's Environmental Report" 2010, ADAMS Accession No. ML100250666
- 4 EN, "Columbia Generating Station, Docket No. 50-397, Environmental Authorizations for CGS
- 5 Operation," April 20, 2011, ADAMS Accession No. ML11112A130
- 6 EN, "Columbia Generating Station, Docket No. 50-397, Environmental Authorizations for CGS
- 7 Operation," June 23, 2011, ADAMS Accession No. ML111750188.

APPENDIX D
CONSULTATION CORRESPONDENCE

1 D CONSULTATION CORRESPONDENCE

2 The Endangered Species Act of 1973, as amended; the Magnuson Stevens Fisheries
3 Management Act of 1996, as amended; and the National Historic Preservation Act of 1966
4 (NHPA) require that Federal agencies consult with applicable State and Federal agencies and
5 groups before taking action that may affect threatened or endangered species, essential fish
6 habitat, or historic and archaeological resources, respectively. This appendix contains
7 consultation documentation.

8 Table D-1 lists the consultation documents sent between the U.S. Nuclear Regulatory
9 Commission (NRC) and other agencies. The NRC staff is required to consult with these
10 agencies based on the National Environmental Policy Act of 1969 (NEPA) requirements.

11 **Table D-1. Consultation correspondence**

| Author | Recipient | Date of letter/email |
|--|---|------------------------------------|
| Pham, B., NRC | A. Brooks, Washington State Historic Preservation Officer (SHPO) | March 18, 2010 (ML100610084) |
| Pham, B., NRC | L. Cloud, Yakama Nation | March 19, 2010 (ML100770417) |
| Pham, B., NRC | E. Patawa, Confederated Tribes of the Umatilla Indian Reservation | March 19, 2010 (ML100770417) |
| Pham, B., NRC | S. Penney, Nez Perce Tribe | March 19, 2010 (ML100770417) |
| Pham, B., NRC | R. Thorson, U.S. Fish & Wildlife Service (USFWS), Pacific Region | March 22, 2010 (ML100710046) |
| Whitlam, R., State of Washington Department of Archaeology & Historic Preservation | B. Pham, NRC | March 29, 2010 (ML100900230) |
| Pham, B., NRC | R. Whitlam, State of Washington Department of Archaeology & Historic Preservation | April 15, 2010 (ML100960116) |
| Pham, B., NRC | R. Nelson, Advisory Council on Historic Preservation | April 20, 2010 (ML100970721) |
| Whitlam, R., State of Washington Department of Archaeology & Historic Preservation | B. Pham, NRC | April 21, 2010 (ML101160095) |
| Pham, B., NRC | B. Thom, National Marine Fisheries Service (NMFS), Northwest Region | May 3, 2010 (ML100980161) |
| Suzumoto, B., NMFS | B. Pham, NRC | June 23, 2010 (ML101830405) |
| Doyle, D., NRC | G. Kurz, USFWS, Central Washington Field Office | November 5, 2010 (ML103120452) |
| Kurz, G., USFWS, Central Washington Field Office | D. Doyle, NRC | November 8, 2010 (ML103120486) |
| Pham, B., NRC | R. Whitlam, State of Washington Department of Archaeology & Historic Preservation | November 30, 2010 (ML103280421) |
| Whitlam, R., State of Washington Department of Archaeology & Historic Preservation | B. Pham, NRC | December 1, 2010 (ML103350680) |

Appendix D

| Author | Recipient | Date of letter/email |
|---|------------------|------------------------------------|
| Domingue, R., NMFS | D. Doyle, NRC | December 17, 2010 (ML103510668) |
| Kurz, G., USFWS, Central Washington Field Office | D. Doyle, NRC | June 16, 2011 (ML111680221) |
| Domingue, R., NMFS | D. Doyle, NRC | June 27, 2011 (ML111821975) |

1 **D.1 Consultation Correspondence**

2 The following pages contain copies of the letters listed in Table D-1.

3

March 18, 2010

Allyson Brooks, Ph.D.
State Historic Preservation Officer
PO Box 48343
Olympia, WA 98504-8343

SUBJECT: COLUMBIA GENERATING STATION LICENSE RENEWAL APPLICATION
(LOG NO.: 121007-20-NRC)

Dear Dr. Brooks:

The U.S. Nuclear Regulatory Commission (NRC) staff is reviewing an application to renew the operating license for Columbia Generating Station (CGS), which is located in Benton County, Washington approximately 12 miles northwest of Richland. CGS is operated by Energy Northwest. The application for renewal, dated January 19, 2010, was submitted by Energy Northwest pursuant to Title 10 of the *Code of Federal Regulations* Part 54 (10 CFR Part 54).

The NRC has established that, as part of the staff's review of any nuclear power plant license renewal action, a site-specific Supplemental Environmental Impact Statement (SEIS) to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants", NUREG-1437, will be prepared under the provisions of 10 CFR Part 51, the NRC regulation that implements the National Environmental Policy Act of 1969 (NEPA). In accordance with 36 CFR 800.8, the SEIS will include analyses of potential impacts to historic and cultural resources.

In the context of the National Historic Preservation Act of 1966, as amended, the NRC staff has determined that the area of potential effect (APE) for a license renewal action is the area at the power plant site and its immediate environs that may be impacted by post-license renewal land-disturbing operations or projected refurbishment activities associated with the proposed action. The APE may extend beyond the immediate environs in those instances where post-license renewal land-disturbing operations or projected refurbishment activities specifically related to license renewal may potentially have an effect on known or proposed historic sites. This determination is made irrespective of ownership or control of the lands of interest.

On April 6, 2010, the NRC will conduct two public NEPA scoping meetings at the Richland Public Library, located at 955 Northgate Drive, Richland, Washington 99352. You and your staff are invited to attend. Your office will receive a copy of the draft SEIS along with a request for comments. The staff expects to publish the draft SEIS in December 2010.

Appendix D

A. Brooks

- 2 -

If you have any questions or require additional information, please contact Mr. Daniel Doyle, Environmental Project Manager, by phone at 301-415-3748 or by e-mail at Daniel.Doyle@nrc.gov.

Sincerely,

/RA/

Bo M. Pham, Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-397

cc: See next page

March 19, 2010

The Honorable Louis Cloud
Yakama Nation
P.O. Box 151
Toppenish, WA 98948-0151

SUBJECT: REQUEST FOR SCOPING COMMENTS CONCERNING THE COLUMBIA
GENERATING STATION LICENSE RENEWAL APPLICATION REVIEW

Dear Chairman Cloud:

The U.S. Nuclear Regulatory Commission (NRC) is seeking input for its environmental review of an application from Energy Northwest for the renewal of the operating license for the Columbia Generating Station (CGS), located approximately 12 miles northwest of Richland, Washington. CGS is in close proximity to lands that may be of interest to the Yakama Nation. As described below, the NRC's process includes an opportunity for public and inter-governmental participation in the environmental review. We want to ensure that you are aware of our efforts and, pursuant to Title 10 of the *Code of Federal Regulations* (10 CFR) Part 51, Section 51.28(b), the NRC invites the Yakama Nation to provide input to the scoping process relating to the NRC's environmental review of the application. In addition, as outlined in 36 CFR 800.8, the NRC plans to coordinate compliance with Section 106 of the National Historic Preservation Act of 1966 through the requirements of the National Environmental Policy Act of 1969 (NEPA).

Under NRC regulations, the original operating license for a nuclear power plant is issued for up to 40 years. The license may be renewed for up to an additional 20 years if NRC requirements are met. The current operating license for CGS will expire on December 20, 2023. Energy Northwest submitted its application for renewal of the CGS operating license in a letter dated January 19, 2010.

The NRC is gathering information for a CGS site-specific supplement to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (GEIS), NUREG-1437. The supplement will contain the results of the review of the environmental impacts on the area surrounding the CGS site that are related to terrestrial ecology, aquatic ecology, hydrology, cultural resources, and socioeconomic issues (among others) and will contain a recommendation regarding the environmental acceptability of the license renewal action. Provided for your information is the CGS Site Area Map (Enclosure 1).

L. Cloud

- 2 -

To accommodate interested members of the public and inter-governmental officials, the NRC will hold two NEPA scoping meetings for the CGS license renewal supplement to the GEIS on Tuesday, April 6, 2010 at the Richland Public Library, located at 955 Northgate Drive, Richland, Washington 99352. The first session will convene at 1:30 p.m. and will continue until 3:30 p.m., as necessary. The second session will convene at 6:00 p.m., with a repeat of the overview portions of the meeting, and will continue until 8:00 p.m., as necessary. Additionally, the NRC staff will host informal discussions one hour before the start of each session.

The CGS license renewal application is publicly available at the NRC Public Document Room (PDR), located at One White Flint North, 11555 Rockville Pike, Rockville, Maryland, 20852, or from the NRC's Agencywide Documents Access and Management System (ADAMS). The ADAMS Public Electronic Reading Room is accessible at <http://www.nrc.gov/reading-rm/adams.html>. The accession number for the license renewal application is ML100250668. Persons who do not have access to ADAMS, or who encounter problems in accessing the documents located in ADAMS, should contact the NRC's PDR Reference staff by telephone at 1-800-397-4209, or 301-415-4737, or by e-mail at pdrc@nrc.gov.

The CGS license renewal application is also available on the Internet at <http://www.nrc.gov/reactors/operating/licensing/renewal/applications/columbia.html>. In addition, the Richland Public Library, located in Richland, WA, and the Kennewick Branch of Mid-Columbia Libraries, located in Kennewick, WA, have agreed to make the license renewal application available for public inspection.

The GEIS, which documents the NRC's assessment of the scope and impact of environmental effects that would be associated with license renewal at any nuclear power plant site, can also be found on the NRC's website or at the NRC's PDR.

Please submit any comments that the Yakama Nation may have to offer on the scope of the environmental review by May 14, 2010. Written comments should be submitted by mail to the Chief, Rulemaking and Directives Branch, Division of Administrative Services, Mail Stop TWB-5B01M, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001. Electronic comments may be submitted to the NRC via the Federal rulemaking website: <http://www.regulations.gov>. Search for documents filed under Docket ID NRC-2010-0029. Address questions about NRC dockets to Carol Gallagher at 301-492-3668 or by e-mail at Carol.Gallagher@nrc.gov. At the conclusion of the scoping process, the NRC staff will prepare a summary of the significant issues identified and the conclusions reached, and mail a copy to you.

L. Cloud

- 3 -

The NRC staff expects to publish the draft supplement to the GEIS in December 2010. The NRC will hold another set of public meetings in the site vicinity to solicit comments on the draft supplemental environmental impact statement (SEIS). A copy of the draft SEIS will be sent to you for your review and comment. After consideration of public comments received on the draft, the NRC will prepare a final SEIS. The issuance of a final SEIS for CGS is planned for July 2011. If you need additional information regarding the environmental review process, please contact Mr. Daniel Doyle, Environmental Project Manager, at 301-415-3748 or by e-mail at Daniel.Doyle@nrc.gov.

Sincerely,

/RA/


Bo Pham, Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-397

Enclosure:
Columbia Generating Station Site Area Map

cc w/enc: See next page

COLUMBIA GENERATING STATION SITE AREA MAP



ENCLOSURE

March 22, 2010

Ms. Robyn Thorson, Regional Director
U.S. Fish & Wildlife Service
Pacific Region
911 NE 11th Ave
Portland, OR 97232

SUBJECT: REQUEST FOR LIST OF PROTECTED SPECIES WITHIN THE AREA UNDER
EVALUATION FOR THE COLUMBIA GENERATING STATION LICENSE
RENEWAL APPLICATION REVIEW

Dear Ms. Thorson:

The U.S. Nuclear Regulatory Commission (NRC) is reviewing an application submitted by Energy Northwest for the renewal of the operating license for Columbia Generating Station (CGS). CGS is located on the Columbia River, 12 miles northwest of Richland, WA. As part of the review of the license renewal application, the NRC is preparing a Supplemental Environmental Impact Statement (SEIS) under the provisions of the National Environmental Policy Act (NEPA) of 1969, as amended. The SEIS includes an analysis of pertinent environmental issues, including endangered or threatened species and impacts to fish and wildlife. This letter is being submitted under the provisions of the Endangered Species Act of 1973, as amended, and the Fish and Wildlife Coordination Act of 1934, as amended.

Energy Northwest stated that it has no plans to alter current operations over the license renewal period and that CGS, operating under a renewed license, would use existing plant facilities and transmission lines and would not require additional construction or disturbance of new areas. Any maintenance activities would be limited to previously disturbed areas. The CGS site is in the southeastern area of the U.S. Department of Energy (USDOE) Hanford Site, a 586 square mile reservation established in 1943 by the federal government for the production of defense nuclear materials. The CGS site comprises 1,089 acres that are leased by Energy Northwest from the USDOE. The lease describes the site in two parcels – a nearly square section containing the plant power block and associated structures and an elongated area running to the river east of the plant.

CGS employs a closed-cycle cooling system that removes heat from its condenser and rejects it to the atmosphere by evaporation using six mechanical draft cooling towers. Water is circulated from the cooling towers through the condenser and back to the circulating water pumphouse at a rate of about 550,000 gpm. Makeup water to replenish water losses due to evaporation, drift, and blowdown is supplied from the makeup water pumphouse located at Columbia River approximately three miles east of the plant. The three 800-hp makeup water pumps are each designed to pump 12,500 gallons per minute (gpm), although normally two pumps are used to supply makeup water to the plant.

The intake system for the makeup water pumps includes two offshore perforated pipe inlets mounted above the riverbed and approximately parallel to the river flow. The intake system is designed for a withdrawal capacity of 25,000 gpm.

R. Thorson

- 2 -

Actual makeup water withdrawal during operating periods averages about 17,000 gpm. This is about 0.1% of the minimum river flow in the vicinity of CGS or 0.03% of the average annual flow.

As part of the SEIS, the applicable transmission line corridors will be reviewed. Energy produced at CGS is delivered to the Bonneville Power Authority at the H.J. Ashe Substation located 0.5 mile north of the station. The CGS main generator output is transmitted to Ashe Substation via the step-up main transformer bank and a 2,900-ft long 500-kV tie line. The plant start-up transformer is connected to the Ashe Substation via a 230-kV line. The 230-kV and 500-kV overhead lines run approximately parallel in a 280-ft wide corridor. The lines between CGS and Ashe Substation comprise the transmission intertie that is within the scope of license renewal. The third line supporting CGS is a 115-kV power source that serves as a backup power source for safe shutdown under accident conditions. This line has a right-of-way width of 90 feet and runs between the CGS switchyard and a tap off the 115-kV line that runs from the Benton Switchyard to USDOE Fast Flux Test Facility. This tap is located about 1.8 miles southeast of the plant. (Please see the site area map, Enclosure 3.)

To support the SEIS preparation process and to ensure compliance with Section 7 of the Endangered Species Act, the NRC requests a list of species and information on protected, proposed, and candidate species and critical habitat that may be in the vicinity of CGS and its associated transmission line right-of-way. In addition, please provide any information you consider appropriate under the provisions of the Fish and Wildlife Coordination Act.

The NRC staff plans to hold two public NEPA scoping meetings on April 6, 2010 at the Richland Public Library in Richland, WA. You and your staff are invited to attend the public meetings. The first session will convene at 12:30 p.m. and will continue until 3:30 p.m., as necessary. The second session will convene at 5:00 p.m., with a repeat of the overview portions of the meeting, and will continue until 8:00 p.m., as necessary.

The week of June 7th, we plan to conduct a site audit. You and your staff are invited to attend both the site audit and the public meetings. Your office will also receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is December 2010.

The CGS license renewal application is available at:

<http://www.nrc.gov/reactors/operating/licensing/renewal/applications/columbia.html>

R. Thorson

- 3 -

If you have any questions concerning the NRC staff review of this license renewal application, please contact Mr. Daniel Doyle, Project Manager, at (301) 415-3748 or daniel.doyle@nrc.gov.

Sincerely,

/RA/

Bo Pham, Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-397

Enclosures:

1. Area Map, 50-mile radius
2. Area Map, 6-mile radius
3. Site Area Map


cc w/encls.: See next page

Area Map, 50-Mile Radius




ENCLOSURE 1

Area Map, 6-Mile Radius



ENCLOSURE 2

Site Area Map



ENCLOSURE 3



STATE OF WASHINGTON

DEPARTMENT OF ARCHAEOLOGY & HISTORIC PRESERVATION

1063 S. Capitol Way, Suite 106 • Olympia, Washington 98501
Mailing address: PO Box 48343 • Olympia, Washington 98504-8343
(360) 586-3065 • Fax Number (360) 586-3067 • Website: www.dahp.wa.gov

March 29, 2010

Mr. Bo M. Pham
Division of License Renewal
Office of Nuclear Reactor Regulation
Nuclear Regulatory Commission
Washington, D.C.

Re: Columbia Generating Station License
Log No.: 121007-20-NRC

Dear Mr. Pham;

Thank you for contacting our department. We have reviewed the materials you provided for the proposed Columbia Generating Station License Renewal at the Hanford Site, Benton County, Washington.

Please provide a map to supplement and illustrate the exact polygon of your proposed Area of Potential Effect (APE) as described in your third paragraph.

We would also appreciate receiving any correspondence or comments from concerned tribes or other parties that you receive as you consult under the requirements of 36CFR800.4(a)(4).

These comments are based on the information available at the time of this review and on behalf of the State Historic Preservation Officer in compliance with the Section 106 of the National Historic Preservation Act, as amended, and its implementing regulations 36CFR800.4.

Should additional information become available, our assessment may be revised, including information regarding historic properties that have not yet been identified. Thank you for the opportunity to comment and we look forward to receiving the requested materials and further consultation.

Sincerely,

Robert G. Whitlam, Ph.D.
State Archaeologist
(360)586-3080
email: rob.whitlam@dahp.wa.gov



Appendix D

April 15, 2010

Robert G. Whitlam, Ph.D.
State Archaeologist
Department of Archaeology & Historic Preservation
P.O. Box 48343
Olympia, WA 98504-8343

SUBJECT: COLUMBIA GENERATING STATION LICENSE RENEWAL APPLICATION
(LOG NO.: 121007-20-NRC)

Dear Dr. Whitlam:

Enclosed please find the information you have requested regarding the Nuclear Regulatory Commission (NRC) review of the license renewal application for Columbia Generating Station.

The NRC considers the Area of Potential Effect (APE) to include the areas as defined in the enclosed correspondence between Mr. Gregory Cullen, Energy Northwest, and your office.

If you have any questions or require additional information, please contact Mr. Daniel Doyle, Environmental Project Manager, by phone at 301-415-3748 or by e-mail at Daniel.Doyle@nrc.gov.

Sincerely,

Bo M. Pham, Chief /RA/
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-397

Enclosure:
Applicant's Environmental Report, Attachment D – State Historic Preservation Officer
Correspondence

cc w/encl: See next page

ATTACHMENT D

**STATE HISTORIC PRESERVATION OFFICER
CORRESPONDENCE**

TABLE OF CONTENTS

| <u>Letter</u> | <u>Page</u> |
|---|--------------------|
| G.V. Cullen (Energy Northwest) to Allyson Brooks (Wash Dept of Archaeology & Historic Preservation), April 10, 2008 | D-5 |
| Robert Whitlam (Wash Dept of Archaeology & Historic Preservation) to G.V. Cullen (Energy Northwest), April 21, 2008 | D-8 |
| G.V. Cullen (Energy Northwest) to Robert Whitlam (Wash Dept of Archaeology & Historic Preservation), May 8, 2008 | D-9 |
| Robert Whitlam (Wash Dept of Archaeology & Historic Preservation) to G.V. Cullen (Energy Northwest), May 21, 2008 | D-12 |
| G.V. Cullen (Energy Northwest) to Robert Whitlam (Wash Dept of Archaeology & Historic Preservation), July 31, 2008 | D-13 |
| Robert Whitlam (Wash Dept of Archaeology & Historic Preservation) to G.V. Cullen (Energy Northwest), August 5, 2008 | D-16 |

Columbia Generating Station
License Renewal Application
Environmental Report



Gregory V. Cullen
Regulatory Programs
P.O. Box 968, Mail Drop PE20
Richland, WA 99352-0968
Ph. 509-377-6105 F. 509-377-4317
gvcullen@energy-northwest.com

April 10, 2008
GO2-08-055

Allyson Brooks, PhD
State Historic Preservation Officer
Department of Archaeology & Historic Preservation
1063 South Capitol Way, Suite 106
Olympia, WA 98501

Subject: **REQUEST FOR INFORMATION
ON ARCHAEOLOGICAL AND HISTORIC RESOURCES**

Dear Dr. Brooks:

Energy Northwest is preparing an application to the U.S. Nuclear Regulatory Commission (NRC) to renew the operating license for Columbia Generating Station (CGS). The renewal term would be for an additional 20 years beyond the current license expiration date in 2023.

As part of the license renewal process, the NRC requires license applicants to "assess whether any historic or archaeological properties will be affected by the proposed project" (10 CFR 51.53). The NRC may also request, under Section 106 of the National Historic Preservation Act of 1966, as amended (16 USC 470) and Federal Advisory Council on Historic Preservation regulations (36 CFR 800), an informal consultation with your office at a later date. By contacting you early in the application process, we hope to identify any potential issues that need to be addressed or information that your office may require to expedite the NRC consultation.

CGS is located in Benton County in the southeastern portion of the U.S. Department of Energy's Hanford Site. The station is about 3¼ miles west of the Columbia River in Section 5 of Township 11N, Range 28E, Willamette Meridian. The latitude/longitude coordinates are 46° 28' 18" north, 119° 19' 58" west and the approximate Universal Transverse Mercator coordinates are 5,148,840 meters north, 320,930 meters east. The cooling water intake facilities are on the west bank of the river at river mile 352. The station is tied to the Bonneville Power Administration's H.J. Ashe Substation with one-half mile of high-voltage transmission lines. The site location is indicated on the enclosed map.

**REQUEST FOR INFORMATION
ON ARCHAEOLOGICAL AND HISTORIC RESOURCES**

Page 2

Energy Northwest has no plans to alter current CGS operations over the license renewal period. In addition, maintenance activities necessary to support license renewal would be limited to previously disturbed areas on site. License renewal at CGS would require neither the expansion of existing facilities nor additional land disturbance.

Specifically, we are requesting information on the occurrence or concerns regarding archaeological or historic resources in the site area. We plan to include a copy of this letter and a copy of your response with the license renewal application submitted to the NRC. We would greatly appreciate receiving your reply within 60 days of receipt of this letter to provide ample time to evaluate and incorporate the information into our application.

Please contact Abbas Mostala, License Renewal Project Manager, by telephone at (509) 377-4197 or e-mail at aamostala@energy-northwest.com if you have questions or require additional information concerning this request. Thank you for your assistance.


Respectfully,



G.V. Cullen
Manager, Regulatory Programs

Enclosure: Location Map

Columbia Generating Station
License Renewal Application
Environmental Report



Location Map - Columbia Generating Station



GIZ-08-062

STATE OF WASHINGTON

DEPARTMENT OF ARCHAEOLOGY & HISTORIC PRESERVATION

1063 S. Capitol Way, Suite 106 • Olympia, Washington 98501
Mailing address: PO Box 48343 • Olympia, Washington 98504-8343
(360) 586-3065 • Fax Number (360) 586-3067 • Website: www.dahp.wa.gov

April 21, 2008

Mr. Gregory V. Cullen
Energy Northwest
PO Box 968, MS- PE20
Richland, Washington 99352-0968

Re: Columbia Generating Station Project
Log No.: 121007-20-NRC

Dear Mr. Cullen:

Thank you for contacting our Department. We have reviewed the materials you provided for the proposed Columbia Generating Station Project License at the Hanford Site, Benton County, Washington.

Please provide us your proposed description of the Area of Potential Effect (APE) that conforms with 36CFR 800.16 and 8000.4. We look forward receiving the requested materials illustrating the actual project footprint and the areas subject to planning purposes for response and associated mitigation or treatment.

We would also appreciate receiving any correspondence or comments from concerned tribes or other parties that you receive as you consult under the requirements of 36CFR800.4(a)(4).

These comments are based on the information available at the time of this review and on behalf of the State Historic Preservation Officer in compliance with the Section 106 of the National Historic Preservation Act, as amended, and its implementing regulations 36CFR800.4. Should additional information become available, our assessment may be revised, including information regarding historic properties that have not yet been identified. Thank you for the opportunity to comment and we look forward to receiving the reports on the results of your investigations.

Sincerely,

Robert G. Whitlam, Ph.D.
State Archaeologist
(360)586-3080
email: rob.whitlam@dahp.wa.gov



Columbia Generating Station
License Renewal Application
Environmental Report



Gregory V. Cullen
Regulatory Programs
P.O. Box 968, Mail Drop PE20
Richland, WA 99352-0968
Ph. 509-377-6105 F. 509-377-4317
gvcullen@energy-northwest.com

May 8, 2008
GO2-08-072

Robert G. Whittam, PhD
State Archaeologist
Department of Archaeology & Historic Preservation
P.O. Box 48343
Olympia, WA 98504-8343

Subject: **REQUEST FOR INFORMATION
ON ARCHAEOLOGICAL AND HISTORIC RESOURCES**

References: 1. Letter dated April 10, 2008, G.V. Cullen (EN) to A. Brooks (DAHS),
same subject
2. Letter dated April 21, 2008, R.G. Whittam (DAHS) to G.V. Cullen (EN)
re: Log No. 121007-20-NRC

Dear Dr. Whittam:

Thank you for the quick response (Reference 2) to our request for information relevant to the possible renewal of the Columbia Generating Station (CGS) operating license. Although the site location was described in some detail in our letter (Reference 1), I can appreciate that the map we provided was not very useful for discerning the project footprint. Hopefully, the attached property map will provide the requested detail. I have also included a vertical photo showing the location of CGS relative to other features in the site area.


As stated previously, our intent is to seek renewal of the current plant operating license. We have no plans to modify the plant or the supporting facilities to accommodate extended operation. To assist in the preparation of the application to be submitted to the U.S. Nuclear Regulatory Commission (NRC), we are requesting information on the occurrence or concerns regarding archaeological or historic resources in the site area. The Department of Archaeology and Historic Preservation can reasonably expect to be approached by the NRC at a later date during the environmental review process.

Please contact Abbas Mostala, License Renewal Project Manager, by telephone at (509) 377-4197 or e-mail at aamostala@energy-northwest.com if you require additional information. Thank you again for the assistance.

Respectfully,

G.V. Cullen
Manager, Regulatory Programs

Enclosures: Vertical Photo and CGS Site Property Map



Columbia Generating Station - Site Property Map

Columbia Generating Station
License Renewal Application
Environmental Report



Columbia Generating Station – Location



STATE OF WASHINGTON

GIZ-08-083

DEPARTMENT OF ARCHAEOLOGY & HISTORIC PRESERVATION

1063 S. Capitol Way, Suite 106 • Olympia, Washington 98501
Mailing address: PO Box 48343 • Olympia, Washington 98504-8343
(360) 586-3065 • Fax Number (360) 586-3067 • Website: www.dahp.wa.gov

May 21, 2008

Mr. G. V. Cullen
Energy Northwest
PO Box 968, MD: PE20
Richland, Washington 99352-0968

Re: Columbia Generating Station License
Log No.: 121007-20-NRC

Dear Mr. Cullen;

Thank you for contacting our department. We have reviewed the materials you provided for the proposed Columbia Generating Station License at the Hanford Site, Benton County, Washington.


We concur with the determination of the Area of Potential Effect (APE). We look forward to receiving the results of your review, consultations with the concerned tribes, and on-site archaeological survey.

We would also appreciate receiving any correspondence or comments from concerned tribes or other parties that you receive as you consult under the requirements of 36CFR800.4(a)(4).

These comments are based on the information available at the time of this review and on behalf of the State Historic Preservation Officer in compliance with the Section 106 of the National Historic Preservation Act, as amended, and its implementing regulations 36CFR800.4.

Should additional information become available, our assessment may be revised, including information regarding historic properties that have not yet been identified. Thank you for the opportunity to comment and we look forward to receiving the professional report on the results of your investigations.

Sincerely,


Robert G. Whitlam, Ph.D.
State Archaeologist
(360)586-3080
email: rob.whitlam@dahp.wa.gov



Columbia Generating Station
License Renewal Application
Environmental Report



Gregory V. Cullen
Regulatory Programs
P.O. Box 968, Mail Drop PE20
Richland, WA 99352-0968
Ph. 509-377-6105 F. 509-377-4317
gvcullen@energy-northwest.com

July 31, 2008
GO2-08-114

Robert G. Whitlam, PhD
State Archaeologist
Department of Archaeology & Historic Preservation
P.O. Box 48343
Olympia, WA 98504-8343

Subject: **REQUEST FOR INFORMATION
ON ARCHAEOLOGICAL AND HISTORIC RESOURCES**

- References:
1. Letter GO2-08-055, dated April 10, 2008, G.V. Cullen (EN) to A. Brooks (DAHP), same subject
 2. Letter dated April 21, 2008, R.G. Whitlam (DAHP) to G.V. Cullen (EN) re: Log No. 121007-20-NRC
 3. Letter GO2-08-072, dated May 8, 2008, G.V. Cullen (EN) to R.G. Whitlam (DAHP), same subject

Dear Dr. Whitlam:

The referenced correspondence concerns our request for information relevant to the preparation of an application for renewal of the operating license for the Columbia Generating Station (CGS). As was discussed in a June 4, 2008 phone conversation with Energy Northwest's Jim Chasse, we are expanding the area encompassed by the request to include three transmission lines constructed, operated, and maintained by the Bonneville Power Administration (BPA). We are adding these lines to the project "footprint" because they were included as part of the original project description.

The three transmission lines that are added to our previous description are shown on the enclosed map that depicts a large portion of the U.S. Department of Energy Hanford Site and the Columbia River between river miles 380 and 351. The primary 500-kV line is a nearly straight route between BPA's Ashe Substation and the Hanford Substation 17½ miles to the northwest. The right-of-way width is 350 ft for the first 7¼ miles out of Ashe, 230 ft for about the next 8 miles, and about 125 feet for the last 2¼ miles. It is shown as a red line on the map. The second line is a 230-kV line that shares the 500-kV right-of-way for 7¼ miles and then runs north for about 2½ miles with a right-of-way width of 125 feet. This line is shown as a green line. The third line is a 115-kV back-up power source that taps off another line at a point about 1.8 miles southeast of the plant. The right-of-way width is 90 feet. It is the blue line on the map. The one-half mile segments of 230-kV and 500-kV lines between the power plant and Ashe Substation (described in the Reference 1 and shown on the site property map enclosed with Reference 3) are also shown on the enclosed map.

**REQUEST FOR INFORMATION
ON ARCHAEOLOGICAL AND HISTORIC RESOURCES**

Page 2

A review of the on-line database maintained by the Department of Archaeology & Historic Preservation confirms that there are no properties on the National Register of Historic Places in the immediate site area. The closest listed property is the Wooded Island Archaeological District located about two miles downstream (south) of the CGS makeup water pumphouse at Columbia River mile 352. We note that the 500-kV transmission line crosses Gable Mountain, a location listed on the Washington State register. We are also aware that pre-construction surveys of the mid-1970s noted the presence of two archaeological sites (Nos. 45BN113 and 45BN114) on the west bank of the river approximately one-quarter mile downstream from the pumphouse.

We do not expect continued operation of CGS through the 20-year license renewal period to have an adverse impact on cultural resources because we have no plans to expand the plant or the supporting facilities to accommodate extended operation. Additionally, we have no reason to believe that continued operation would result in changes to the operation and maintenance of the BPA transmission lines. These transmission lines would remain in service as part of the BPA network even if the plant operating license is not renewed.

As stated in our previous letters, we would very much appreciate learning of any concerns you may have regarding our license renewal application. Please contact Abbas Mostala, License Renewal Project Manager, by telephone at (509) 377-4197 or e-mail at aamostala@energy-northwest.com if you require additional information. Thank you again for the assistance.


Respectfully,



G.V. Cullen
Manager, Regulatory Programs

Enclosure: Property Boundary and Transmission Line Routing Map

Columbia Generating Station
License Renewal Application
Environmental Report



Columbia Generating Station
Property Boundary and Transmission Line Routing



812-08-124

STATE OF WASHINGTON
DEPARTMENT OF ARCHAEOLOGY & HISTORIC PRESERVATION

1063 S. Capitol Way, Suite 106 • Olympia, Washington 98501
Mailing address: PO Box 48343 • Olympia, Washington 98504-8343
(360) 586-3065 • Fax Number (360) 586-3067 • Website: www.dahp.wa.gov

August 5, 2008

Mr. G. V. Cullen
Energy Northwest
PO Box 968, MD: PE20
Richland, Washington 99352-0968

Re: Columbia Generating Station License
Log No.: 121007-20-NRC

Dear Mr. Cullen;

Thank you for contacting our department. We have reviewed the additional materials you provided for the proposed Columbia Generating Station License at the Hanford Site, Benton County, Washington.

We concur with the revised determination of the Area of Potential Effect (APE). We look forward to receiving the results of your review, consultations with the concerned tribes, and on-site archaeological survey.

We would also appreciate receiving any correspondence or comments from concerned tribes or other parties that you receive as you consult under the requirements of 36CFR800.4(a)(4).

These comments are based on the information available at the time of this review and on behalf of the State Historic Preservation Officer in compliance with the Section 106 of the National Historic Preservation Act, as amended, and its implementing regulations 36CFR800.4.

Should additional information become available, our assessment may be revised, including information regarding historic properties that have not yet been identified. Thank you for the opportunity to comment and we look forward to receiving the professional report on the results of your investigations.

Sincerely,

Robert G. Whitlam, Ph.D.
State Archaeologist
(360)586-3080
email: rob.whitlam@dahp.wa.gov



April 20, 2010

Mr. Reid Nelson, Director
Advisory Council on Historic Preservation
Office of Federal Agency Programs
1100 Pennsylvania Ave, NW, Suite 803
Washington, DC 20004

SUBJECT: COLUMBIA GENERATING STATION LICENSE RENEWAL APPLICATION
REVIEW

Dear Mr. Nelson:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application submitted by Energy Northwest for the renewal of the operating license for Columbia Generating Station (CGS). CGS is located on the Columbia River, 12 miles northwest of Richland, WA. Three area maps are enclosed, highlighting the exact location of the site.

The NRC has established that, as part of the staff's review of any nuclear power plant license renewal action, a site-specific Supplemental Environmental Impact Statement (SEIS) to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants," NUREG-1437, will be prepared under the provisions of 10 CFR Part 51, the NRC's regulation that implements the National Environmental Policy Act (NEPA) of 1969. In accordance with 36 CFR 800.8(c), the SEIS will include analyses of potential impacts to historic and cultural resources.

The NRC staff held two public NEPA scoping meetings on April 6, 2010 at the Richland Public Library in Richland, WA. The week of June 7th, we plan to conduct a site audit, which you and your staff are invited to attend. Your office will also receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is December 2010.

The CGS license renewal application is available at:

<http://www.nrc.gov/reactors/operating/licensing/renewal/applications/columbia.html>

R. Nelson

-2-

If you have any questions concerning the NRC staff review of this license renewal application, please contact Mr. Daniel Doyle, Project Manager, at (301) 415-3748 or daniel.doyle@nrc.gov.

Sincerely,

/RA Bennet M. Brady for/

Bo Pham, Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-397

Enclosures:

1. Area Map, 50-mile radius
2. Area Map, 6-mile radius
3. Site Area Map


cc w/encls: See next page

Area Map, 50-Mile Radius




ENCLOSURE 1

Area Map, 6-Mile Radius



ENCLOSURE 2

Site Area Map



ENCLOSURE 3



STATE OF WASHINGTON

DEPARTMENT OF ARCHAEOLOGY & HISTORIC PRESERVATION

1063 S. Capitol Way, Suite 106 • Olympia, Washington 98501
Mailing address: PO Box 48343 • Olympia, Washington 98504-8343
(360) 586-3065 • Fax Number (360) 586-3067 • Website: www.dahp.wa.gov

April 21, 2010

Mr. Bo M. Pham
Division of License Renewal
Office of Nuclear Reactor Regulation
Nuclear Regulatory Commission
Washington, D.C.

Re: Columbia Generating Station License
Log No.: 121007-20-NRC

Dear Mr. Pham;

Thank you for contacting our department. We have reviewed the materials you provided for the proposed Columbia Generating Station License Renewal at the Hanford Site, Benton County, Washington.

We concur with your proposed Area of Potential Effect (APE) as described in the accompanying text and figures including the Transmission Lines Routing.

We would also appreciate receiving any correspondence or comments from concerned tribes or other parties that you receive as you consult under the requirements of 36CFR800.4(a)(4).

These comments are based on the information available at the time of this review and on behalf of the State Historic Preservation Officer in compliance with the Section 106 of the National Historic Preservation Act, as amended, and its implementing regulations 36CFR800.4.

Should additional information become available, our assessment may be revised, including information regarding historic properties that have not yet been identified. Thank you for the opportunity to comment and we look forward to receiving the requested materials and further consultation.

Sincerely,

Robert G. Whitlam, Ph.D.
State Archaeologist
(360)586-3080
email: rob.whitlam@dahp.wa.gov



May 3, 2010

Mr. Barry Thom
Regional Administrator, Northwest Region
National Marine Fisheries Service
7600 Sand Point Way NE
Seattle, WA 98115-0070

SUBJECT: REQUEST FOR LIST OF PROTECTED SPECIES AND ESSENTIAL FISH
HABITAT WITHIN THE AREA UNDER EVALUATION FOR THE COLUMBIA
GENERATING STATION LICENSE RENEWAL APPLICATION REVIEW

Dear Mr. Thom:

The U.S. Nuclear Regulatory Commission (NRC) is reviewing an application submitted by Energy Northwest for the renewal of the operating license for Columbia Generating Station (CGS). CGS is located on the Columbia River, 12 miles northwest of Richland, WA. As part of the review of the license renewal application (LRA), the NRC is preparing a Supplemental Environmental Impact Statement (SEIS) under the provisions of Title 10 of the *Code of Federal Regulations* Part 51 (10 CFR Part 51), the NRC's regulation that implements the National Environmental Policy Act (NEPA) of 1969. The SEIS includes an analysis of pertinent environmental issues, including endangered or threatened species and impacts to marine resources and habitat. This letter is being submitted under the provisions of the Endangered Species Act of 1973, as amended; the Fish and Wildlife Coordination Act of 1934, as amended; and the Magnuson-Stevens Fishery Conservation and Management Act.

Energy Northwest stated that it has no plans to alter current operations over the license renewal period and that CGS, operating under a renewed license, would use existing plant facilities and transmission lines and would not require additional construction or disturbance of new areas. Any maintenance activities would be limited to previously disturbed areas. The CGS site is in the southeastern area of the U.S. Department of Energy (DOE) Hanford Site, a 586 square mile reservation established in 1943 by the federal government for the production of defense nuclear materials. The CGS site comprises 1,089 acres that are leased by Energy Northwest from the DOE. The lease describes the site in two parcels – a nearly square section containing the plant power block and associated structures and an elongated area running to the river east of the plant (Please see the area maps, Enclosures 1, 2, and 3).

CGS employs a closed-cycle cooling system that removes heat from its condenser and rejects it to the atmosphere by evaporation using six mechanical draft cooling towers. Water is circulated from the cooling towers through the condenser and back to the circulating water pumphouse at a rate of about 550,000 gpm. Makeup water to replenish water losses due to evaporation, drift, and blowdown is supplied from the makeup water pumphouse located at Columbia River approximately three miles east of the plant. The three 800-hp makeup water pumps are each designed to pump 12,500 gallons per minute (gpm), although normally two pumps are used to supply makeup water to the plant. The intake system for the makeup water pumps includes two offshore perforated pipe inlets mounted above the riverbed and approximately parallel to the river flow. The intake system is designed for a withdrawal capacity of 25,000 gpm.

B. Thom

- 2 -

Actual makeup water withdrawal during operating periods averages about 17,000 gpm. This is about 0.1% of the minimum river flow in the vicinity of CGS or 0.03% of the average annual flow.

To support the SEIS preparation process and to ensure compliance with Section 7 of the Endangered Species Act, the NRC requests information on Federally listed, proposed, and candidate species and critical habitat that may be in the vicinity of the CGS site, as shown on the enclosed maps.. In addition, please provide any information you consider appropriate under the provisions of the Fish and Wildlife Coordination Act. Also in support of the SEIS preparation and to ensure compliance with Section 305 of the Magnuson-Stevens Fishery Conservation and Management Act, the NRC requests a list of essential fish habitat that has been designated in the vicinity of the CGS site.

The NRC staff held two public NEPA scoping meetings on April 6, 2010 at the Richland Public Library in Richland, WA. The week of June 7th, we plan to conduct a site audit, which you and your staff are invited to attend. Your office will also receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is December 2010.

The CGS license renewal application is available at:

<http://www.nrc.gov/reactors/operating/licensing/renewal/applications/columbia.html>

B. Thom

- 3 -

If you have any questions concerning the NRC staff review of this LRA, please contact Mr. Daniel Doyle, Project Manager at (301) 415-3748 or by e-mail at daniel.doyle@nrc.gov.

Sincerely,

/RA/

Bo Pham, Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-397

Enclosures:

1. Area Map, 50-mile radius
2. Area Map, 6-mile radius
3. Site Area Map


cc w/encls: See next page

Area Map, 50-Mile Radius




ENCLOSURE 1

Area Map, 6-Mile Radius



ENCLOSURE 2

Site Area Map



ENCLOSURE 3



UNITED STATES DEPARTMENT OF COMMERCE
 National Oceanic and Atmospheric Administration
 NATIONAL MARINE FISHERIES SERVICE
 1201 NE Lloyd Boulevard, Suite 1100
 PORTLAND, OREGON 97232-1274

June 23, 2010

Bo Pham
 U.S. Nuclear Regulatory Commission
 11545 Rockville Pike
 Rockville, Maryland 20852.

Re: Columbia Generating Station license renewal, request for species list for consultation.

Dear Mr. Pham:

This letter responds to your May 3, 2010 request for a list of species to be considered in Endangered Species Act (ESA) and Magnuson-Stevens Fishery Conservation and Management Act (MSA) consultations on your proposed license renewal action for the Columbia Generating Station. This letter also clarifies how NOAA's National Marine Fisheries Service (NMFS) intends to manage this consultation.

The Columbia Generating Station is located along the Columbia River near Richland, Washington. Through the intake of water from the Columbia River for cooling and the discharge of waste water from the plant to the river, the project has the potential to affect anadromous fish that may occur in the vicinity of the plant's freshwater intake and wastewater release works. Species listed under the Endangered Species Act likely to occur in these areas are:

- Upper Columbia River (UCR) spring Chinook salmon (*O. tshawytscha*; listed as endangered on June 28, 2005 [70 FR 37160]); critical habitat designated on September 2, 2005 [70 FR 52630], and
- Upper Columbia River (UCR) steelhead (*O. mykiss*; listed as endangered on August 24, 2009 [74 FR 42605]); critical habitat designated on September 2, 2005 [70 FR 52630].

This letter constitutes the required notification that Federally-listed threatened or endangered species or critical habitat under NMFS jurisdiction are present within the area affected by this project and may be affected by the proposed action.

Please refer to Section 7 of the ESA and its implementing regulations (50 CFR Part 402) for information on interagency consultation. Additional information on listed species' distribution, copies of Federal Register documents designating listed species status, and links to various ESA consultation policies and tools may be found on our website at: www.nwr.noaa.gov.


Concerning the MSA, the Columbia River, in the plant vicinity, provides essential fish habitat features for both Upper Columbia River Chinook and coho salmon (currently an unlisted reintroduction effort). Water withdrawal and wastewater disposal operations at the project have the potential to adversely affect essential fish habitat for these species. As the information



necessary to make the determinations required under ESA are sufficient to support any recommendations under the MSA, we generally conduct these analyses simultaneously using information developed during the ESA consultation. However, as Upper Columbia River coho are not listed under ESA, we request that you include them in any request for concurrence or consultation and assess the likely adverse effects of the project on their essential habitat to facilitate our MSA findings.

NMFS has determined that because the potential effects of the proposed action occur mostly or entirely within the Columbia River and our Hydro Division is most familiar with Columbia River issues, this project will be manned by our Hydro Division staff out of our Portland office. Please send all further correspondence regarding this action to the attention of Rich Domingue, (503) 231-6858 or Richard.Domingue@noaa.gov at this office.

Sincerely,



Bruce Suzumoto
Assistant Regional Administrator
Hydropower Division

From: Doyle, Daniel
Sent: Friday, November 05, 2010 3:11 PM
To: Gregg Kurz (gregg_kurz@fws.gov)
Subject: NRC - Columbia Generating Station license renewal
Attachments: CGS scoping letter to FWS ML100710046.pdf; BentonCounty092910.pdf

Dear Mr. Kurz,

This e-mail is a follow-up to my telephone call on Tuesday, November 2, 2010. As I explained in the call, I am the project manager for the U.S. Nuclear Regulatory Commission's environmental review of the Columbia Generating Station license renewal application. I am following up on the attached letter dated March 22, 2010, that was sent to Ms. Robyn Thorson, Regional Director, U.S. Fish and Wildlife Service, Pacific Region, requesting a list of Federally protected species for this review. This letter was submitted under the provisions of the Endangered Species Act and the Fish and Wildlife Coordination Act.

To support preparation of a draft supplemental EIS and to ensure compliance with Section 7 of the Endangered Species Act, the NRC requests concurrence on the below list of Federally threatened, endangered, proposed, and candidate species that may be in the vicinity of the Columbia Generating Station site and its associated transmission line rights-of-way (as described in the attached letter to Ms. Thorson). If there are any species that your office would like us to address in addition to the Federally listed, proposed, and candidate species shown below, please let me know. The NRC also requests any additional information on protected species and critical habitat that may be in the vicinity of the Columbia Generating Station site if such information is available. In addition, please provide any information you consider appropriate under the provisions of the Fish and Wildlife Coordination Act.

The NRC reviewed the attached list of species and habitat in Benton County (revised September 29, 2010) from: <http://www.fws.gov/wafwo/pdf/BentonCounty092910.pdf>.

LISTED

Bull trout (*Salvelinus confluentus*)
 Pygmy rabbit (*Brachylagus idahoensis*)
 Ute ladies'-tresses (*Spiranthes diluvialis*)

DESIGNATED

Critical habitat for bull trout

PROPOSED

Revised bull trout critical habitat

CANDIDATE

Greater sage grouse (*Centrocercus urophasianus*)
 Yellow-billed cuckoo (*Coccyzus americanus*)
 Umtanum desert buckwheat (*Eriogonum codium*)
 *White Bluffs bladderpod (*Lesquerella tuplashensis*)
 *Louie's western pocket gopher (*Thomomys mazama louiei*)
 *Tacoma western pocket gopher (*Thomomys mazama tacomensis*)
 * obtained from <http://www.fws.gov/Endangered>

Appendix D

The NRC is also in consultation with the National Marine Fisheries Service regarding this project. We are currently planning on doing a single document that contains the biological assessment on the bull trout (for U.S. Fish and Wildlife Service review), the biological assessment on the Chinook salmon and steelhead (for National Marine Fisheries Service review) and the Essential Fish Habitat (for National Marine Fisheries Service review).

A copy of the draft supplemental EIS containing the NRC staff's analysis and preliminary conclusions will be sent to your office when it is published for your review.

If you have any questions concerning the NRC staff review of this license renewal application, please feel free to contact me.

Sincerely,

Daniel Doyle

Project Manager
Division of License Renewal
U.S. Nuclear Regulatory Commission
daniel.doyle@nrc.gov
(301) 415-3748

E-mail Properties

Mail Envelope Properties ()

Subject: NRC - Columbia Generating Station license renewal
Sent Date: 11/5/2010 2:57:08 PM
Received Date: 11/5/2010 3:10:00 PM
From: Doyle, Daniel

Created By: Daniel.Doyle@nrc.gov

Recipients:
gregg_kurz@fws.gov (Gregg Kurz (gregg_kurz@fws.gov))
Tracking Status: None

Post Office:

| Files | Size | Date & Time |
|---|---------|-------------|
| MESSAGE | 2872305 | 11/5/2010 |
| CGS scoping letter to FWS ML100710046.pdf | 2837935 | |
| BentonCounty092910.pdf | 19422 | |

Options

Expiration Date:

Priority: olImportanceNormal
ReplyRequested: False
Return Notification: False

Sensitivity: olNormal
Recipients received:

Appendix D

From: Gregg_Kurz@fws.gov
Sent: Monday, November 08, 2010 1:12 PM
To: Doyle, Daniel
Subject: Re: NRC - Columbia Generating Station license renewal
Attachments: pic31111.gif

Follow Up Flag: Follow up
Flag Status: Completed

Categories: CGS

Mr. Doyle,

Thank you for forwarding the information regarding this project. The species list you obtained from our website is accurate. Please note that the revised bull trout critical habitat designation currently on the list as Proposed will become Designated on November 17, 2010.

Preparation of a biological assessment for this project should include an analysis of potential effects to all species listed as Endangered or Threatened and to any designated or proposed critical habitat. Information regarding the presence of these species and habitats can be obtained from the Washington Natural Heritage Program at <http://www1.dnr.wa.gov/nhp/refdesk/index.html>

We look forward to working with you.

Gregg L. Kurz
Fish and Wildlife Biologist
Central Washington Field Office
Wenatchee, WA 98801
Phone: (509) 665-3508 extension 22
E-mail: Gregg_Kurz@fws.gov
 "Doyle, Daniel" <Daniel.Doyle@nrc.gov>

"Doyle, Daniel"
<Daniel.Dovle@nrc.gov> To: "Gregg Kurz (gregg_kurz@fws.gov)"
<gregg_kurz@fws.gov>
11/05/2010 12:10 PM cc
Subject: NRC - Columbia Generating Station
license renewal

Dear Mr. Kurz,

This e-mail is a follow-up to my telephone call on Tuesday, November 2, 2010. As I explained in the call, I am the project manager for the U.S. Nuclear Regulatory Commission's environmental review of the Columbia Generating Station license renewal application. I am following up on the attached letter dated March 22, 2010, that was sent to Ms. Robyn Thorson, Regional Director, U.S. Fish and Wildlife Service, Pacific Region, requesting a list of Federally protected species for this review. This letter was submitted under the provisions of the Endangered Species Act and the Fish and Wildlife Coordination Act.

To support preparation of a draft supplemental EIS and to ensure compliance with Section 7 of the Endangered Species Act, the NRC requests concurrence on the below list of Federally threatened, endangered, proposed, and candidate species that may be in the vicinity of the Columbia Generating Station site and its associated transmission line rights-of-way (as described in the attached letter to Ms. Thorson). If there are any species that your office would like us to address in addition to the Federally listed, proposed, and candidate species shown below, please let me know. The NRC also requests any additional information on protected species and critical habitat that may be in the vicinity of the Columbia Generating Station site if such information is available. In addition, please provide any information you consider appropriate under the provisions of the Fish and Wildlife Coordination Act.

The NRC reviewed the attached list of species and habitat in Benton County (revised September 29, 2010) from: <http://www.fws.gov/wafwo/pdf/BentonCounty092910.pdf>.

LISTED

Bull trout (*Salvelinus confluentus*)
 Pygmy rabbit (*Brachylagus idahoensis*)
 Ute ladies'-tresses (*Spiranthes diluvialis*)

DESIGNATED

Critical habitat for bull trout

PROPOSED

Revised bull trout critical habitat

CANDIDATE

Greater sage grouse (*Centrocercus urophasianus*)
 Yellow-billed cuckoo (*Coccyzus americanus*)
 Umtanum desert buckwheat (*Eriogonum codium*)
 *White Bluffs bladderpod (*Lesquerella tuplashensis*)
 *Louie's western pocket gopher (*Thomomys mazama louiei*)
 *Tacoma western pocket gopher (*Thomomys mazama tacomensis*)
 * obtained from <http://www.fws.gov/endangered>

The NRC is also in consultation with the National Marine Fisheries Service regarding this project. We are currently planning on doing a single document that contains the biological

Appendix D

assessment on the bull trout (for U.S. Fish and Wildlife Service review), the biological assessment on the Chinook salmon and steelhead (for National Marine Fisheries Service review) and the Essential Fish Habitat (for National Marine Fisheries Service review).

A copy of the draft supplemental EIS containing the NRC staff's analysis and preliminary conclusions will be sent to your office when it is published for your review.

If you have any questions concerning the NRC staff review of this license renewal application, please feel free to contact me.

Sincerely,

Daniel Doyle

Project Manager
Division of License Renewal
U.S. Nuclear Regulatory Commission
daniel.doyle@nrc.gov
(301) 415-3748

[attachment "CGS scoping letter to FWS ML100710046.pdf" deleted by Gregg Kurz/WNES/R1/FWS/DOI] [attachment "BentonCounty092910.pdf" deleted by Gregg Kurz/WNES/R1/FWS/DOI]



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

November 30, 2010

Robert G. Whitlam, Ph.D.
State Archaeologist
Department of Archaeology & Historic Preservation
P.O. Box 48343
Olympia, WA 98504-8343

SUBJECT: COLUMBIA GENERATING STATION LICENSE RENEWAL APPLICATION
(LOG NO.: 121007-20-NRC)

Dear Dr. Whitlam:

The U.S. Nuclear Regulatory Commission (NRC) is considering a request submitted by Energy Northwest (the applicant) for the renewal of the operating license for Columbia Generating Station (CGS) in Benton County, Washington.

In a previous letter to your office, dated April 15, 2010, the NRC stated that it considers the Area of Potential (APE) to include the areas as defined in the correspondence between Mr. Gregory Cullen, Energy Northwest, and your office. The correspondence was included as an enclosure to that letter.

In a letter from Energy Northwest to your office dated July 22, 2010, the applicant revised their determination of the project footprint to exclude the Bonneville Power Administration (BPA) transmission lines, because the BPA controls the lines and they are not part of the plant's connection to the electrical transmission grid.

At the time, the NRC agreed with that modification to the APE. However, this determination should not have included the 115-kV BPA line which runs 1.8 miles southeast from the plant which the NRC believes should be part of the APE. In order to provide clarification, the following paragraph summarizes the NRC's determination of the APE for this license renewal environmental review.

As part of this license renewal environmental review, the following applicable transmission line corridors will be considered. Energy produced at CGS is delivered to the BPA at the H.J. Ashe Substation located 0.5 mile north of the station. Power from CGS is transmitted to the Ashe Substation via a 2,900-ft long, 280-ft wide transmission line corridor. A separate 1.8 mile 115-kV line provides backup power to CGS during plant shutdowns. This line has a right-of-way width of 90 feet and runs southeast between the CGS switchyard and a tap off the 115-kV line that runs from the Benton Switchyard to the U.S. Department of Energy Fast Flux Test Facility. Please see the enclosed site area map. The transmission line between CGS and the Ashe Substation and the 115-kV transmission line for backup power comprise the transmission lines that the NRC considers to be within the scope of license renewal.

R. Whitlam

- 2 -

If you have any questions or require additional information, please contact Mr. Daniel Doyle, Environmental Project Manager, by phone at 301-415-3748 or by e-mail at daniel.doyle@nrc.gov.

Sincerely,

A handwritten signature in black ink that reads "Bo M. Pham". The signature is written in a cursive style.


Bo M. Pham, Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-397

Enclosure:
Columbia Generating Station Site Area Map

cc w/encl: Distribution via Listserv

Columbia Generating Station Site Area Map



ENCLOSURE



STATE OF WASHINGTON

DEPARTMENT OF ARCHAEOLOGY & HISTORIC PRESERVATION

1063 S. Capitol Way, Suite 106 • Olympia, Washington 98501
Mailing address: PO Box 48343 • Olympia, Washington 98504-8343
(360) 586-3065 • Fax Number (360) 586-3067 • Website: www.dahp.wa.gov

December 1, 2010

Mr. Bo M. Pham
Division of License Renewal
Nuclear Regulatory Commission
Washington, D. C., 20555-0001

Re: Columbia Generating Station License
Log No.: 121007-20-NRC

Dear Mr. Pham;

Thank you for contacting our department. We have reviewed the materials you provided for the proposed revised Area of Potential Effect (APE) for the Columbia Generating Station License Renewal at the Hanford Site, Benton County, Washington.

We concur with your proposed revised Area of Potential Effect (APE) as described in your letter and map as including the backup power line that is 1.8 miles from the CGS Switchyard to the Ashe Substation.

We would also appreciate receiving any correspondence or comments from concerned tribes or other parties that you receive as you consult under the requirements of 36CFR800.4(a)(4).

These comments are based on the information available at the time of this review and on behalf of the State Historic Preservation Officer in compliance with the Section 106 of the National Historic Preservation Act, as amended, and its implementing regulations 36CFR800.4.

Should additional information become available, our assessment may be revised, including information regarding historic properties that have not yet been identified. Thank you for the opportunity to comment and we look forward to receiving the requested materials and further consultation.

Sincerely,

Robert G. Whitlam, Ph.D.
State Archaeologist
(360)586-3080
email: rob.whitlam@dahp.wa.gov

cc: K. Cannell



From: Richard Domingue [Richard.Domingue@noaa.gov]
Sent: Friday, December 17, 2010 3:59 PM
To: Doyle, Daniel
Subject: Re: NRC BA/EFH assessment for Columbia Generating Station license renewal review

Categories: CGS

The species list included in the June 23, 2010 remain the appropriate species for this consultation. Your schedule is fine with us. Thanks.

On 12/17/2010 12:23 PM, Doyle, Daniel wrote:
Rich,

Thanks for your time on the phone this afternoon. As I said explained in the call, I am a project manager at the U.S. Nuclear Regulatory Commission coordinating the environmental review for the Columbia Generating Station license renewal application.

The purpose of this e-mail is to request an extension for the combined BA/EFH assessment for the species and habitats identified in the letter from your office to the NRC dated June 23, 2010 (attached).

We expect to publish our supplementary environmental impact statement in May 2011. The combined BA/EFH assessment will be included as an appendix to that report. The assessment will contain the staff's analysis of the potential impact to those species by the license renewal of Columbia Generating Station.

The website below contains more information about the Columbia Generating Station license renewal review:

<http://www.nrc.gov/reactors/operating/licensing/renewal/applications/columbia.html>

If you have any questions about this review, please feel free to contact me or the lead aquatic reviewer, Rebekah Krieg (509-371-7155 or rebekah.krieg@pnl.gov).

Sincerely,

Dan Doyle

Project Manager
Division of License Renewal
U.S. Nuclear Regulatory Commission
daniel.doyle@nrc.gov
(301) 415-3748

Appendix D

From: Gregg_Kurz@fws.gov
Sent: Thursday, June 16, 2011 6:36 PM
To: Doyle, Daniel
Subject: RE: NRC - Columbia Generating Station license renewal
Attachments: pic16858.gif

Follow Up Flag: Follow up
Flag Status: Flagged

Categories: CGS

Dan,

There has been an update to the species list since your list was obtained. Your list contains revised critical habitat for the bull trout as being proposed. The proposed revised critical habitat is now **designated** critical habitat for the bull trout. As I stated on our call, this should not result in any changes to your analysis since you have addressed the potential effects to revised critical habitat.

Gregg

Gregg L. Kurz
Fish and Wildlife Biologist
Central Washington Field Office
Wenatchee, WA 98801
Phone: (509) 665-3508 extension 22
E-mail: Gregg_Kurz@fws.gov

▼ "Doyle, Daniel" <Daniel.Doyle@nrc.gov>

"Doyle, Daniel"
<Daniel.Dovle@nrc.gov>

06/15/2011 04:39 PM

To "Gregg_Kurz@fws.gov"
<Gregg_Kurz@fws.gov>

cc

Subject: RE: NRC - Columbia Generating Station
license renewal

Mr. Kurz,

Thanks for your time on the phone today. As we discussed, I am contacting you regarding the NRC's review of the Columbia Generating Station license renewal environmental review. I would like to confirm the accuracy of the list of species and habitats in the e-mail below.

We expect to publish our draft environmental impact statement in August 2011. The combined BA/EFH assessment will be included as an appendix to that document. The assessment will contain the NRC staff's analysis of the potential impact to those species and habitats by the license renewal of Columbia Generating Station (detailed analysis for bull trout critical habitat).

This website contains more information about the NRC's review of the Columbia Generating Station license renewal application:

<http://www.nrc.gov/reactors/operating/licensing/renewal/applications/columbia.html>

If you have any questions about this review, please feel free to contact me or the lead aquatic reviewer, Rebekah Krieg (509-371-7155 or Rebekah.krieg@pnl.gov).

Sincerely,

Dan Doyle

Project Manager
Division of License Renewal
U.S. Nuclear Regulatory Commission
daniel.doyle@nrc.gov
(301) 415-3748

From: Gregg_Kurz@fws.gov [mailto:Gregg_Kurz@fws.gov]
Sent: Monday, November 08, 2010 1:12 PM
To: Doyle, Daniel
Subject: Re: NRC - Columbia Generating Station license renewal

Mr. Doyle,

Thank you for forwarding the information regarding this project. The species list you obtained from our website is accurate. Please note that the revised bull trout critical habitat designation currently on the list as Proposed will become Designated on November 17, 2010.

Preparation of a biological assessment for this project should include an analysis of potential effects to all species listed as Endangered or Threatened and to any designated or proposed critical habitat. Information regarding the presence of these species and habitats can be obtained from the Washington Natural Heritage Program at <http://www1.dnr.wa.gov/nhp/refdesk/index.html>

We look forward to working with you.

Gregg L. Kurz

Appendix D

Fish and Wildlife Biologist
Central Washington Field Office
Wenatchee, WA 98801
Phone: (509) 665-3508 extension 22
E-mail: Gregg_Kurz@fws.gov
▼ "Doyle, Daniel" <Daniel.Doyle@nrc.gov>

"Doyle, Daniel" <Daniel.Doyle@nrc.gov>
To: "Gregg Kurz" <gregg_kurz@fws.gov>
11/05/2010 12:10 PM Subject: ctNRC - Columbia Generating Station license renewal

Dear Mr. Kurz,

This e-mail is a follow-up to my telephone call on Tuesday, November 2, 2010. As I explained in the call, I am the project manager for the U.S. Nuclear Regulatory Commission's environmental review of the Columbia Generating Station license renewal application. I am following up on the attached letter dated March 22, 2010, that was sent to Ms. Robyn Thorson, Regional Director, U.S. Fish and Wildlife Service, Pacific Region, requesting a list of Federally protected species for this review. This letter was submitted under the provisions of the Endangered Species Act and the Fish and Wildlife Coordination Act.

To support preparation of a draft supplemental EIS and to ensure compliance with Section 7 of the Endangered Species Act, the NRC requests concurrence on the below list of Federally threatened, endangered, proposed, and candidate species that may be in the vicinity of the Columbia Generating Station site and its associated transmission line rights-of-way (as described in the attached letter to Ms. Thorson). If there are any species that your office would like us to address in addition to the Federally listed, proposed, and candidate species shown below, please let me know. The NRC also requests any additional information on protected species and critical habitat that may be in the vicinity of the Columbia Generating Station site if such information is

available. In addition, please provide any information you consider appropriate under the provisions of the Fish and Wildlife Coordination Act.

The NRC reviewed the attached list of species and habitat in Benton County (revised September 29, 2010) from: <http://www.fws.gov/wafwo/pdf/BentonCounty092910.pdf>.

LISTED

Bull trout (*Salvelinus confluentus*)
Pygmy rabbit (*Brachylagus idahoensis*)
Ute ladies'-tresses (*Spiranthes diluvialis*)

DESIGNATED

Critical habitat for bull trout

PROPOSED

Revised bull trout critical habitat

CANDIDATE

Greater sage grouse (*Centrocercus urophasianus*)
Yellow-billed cuckoo (*Coccyzus americanus*)
Umtanum desert buckwheat (*Eriogonum codium*)
*White Bluffs bladderpod (*Lesquerella tuplashensis*)
*Louie's western pocket gopher (*Thomomys mazama louiei*)
*Tacoma western pocket gopher (*Thomomys mazama tacomensis*)
* obtained from <http://www.fws.gov/endangered>

The NRC is also in consultation with the National Marine Fisheries Service regarding this project. We are currently planning on doing a single document that contains the biological assessment on the bull trout (for U.S. Fish and Wildlife Service review), the biological assessment on the Chinook salmon and steelhead (for National Marine Fisheries Service review) and the Essential Fish Habitat (for National Marine Fisheries Service review).

A copy of the draft supplemental EIS containing the NRC staff's analysis and preliminary conclusions will be sent to your office when it is published for your review.

If you have any questions concerning the NRC staff review of this license renewal application, please feel free to contact me.

Sincerely,

Appendix D

Daniel Doyle

Project Manager
Division of License Renewal
U.S. Nuclear Regulatory Commission
daniel.doyle@nrc.gov

(301) 415-3748

[attachment "CGS scoping letter to FWS ML100710046.pdf" deleted by Gregg Kurz/WNES/R1/FWS/DOI] [attachment "BentonCounty092910.pdf" deleted by Gregg Kurz/WNES/R1/FWS/DOI]

From: Richard Domingue [Richard.Domingue@noaa.gov]
Sent: Monday, June 27, 2011 4:33 PM
To: Doyle, Daniel
Subject: Re: NRC BA/EFH assessment for Columbia Generating Station license renewal review

Follow Up Flag: Follow Up
Flag Status: Flagged

Categories: CGS

Yes. The species list provided last June remains accurate. Please do not overlook potential project effects on coho salmon as we will use your BA to evaluate the project's effects on essential fish habitat as well as ESA needs. Thank you.

On 6/23/2011 7:51 AM, Doyle, Daniel wrote:
Rich,

Can you please confirm if the list of species and habitats in your June 23, 2010, letter (attached) is still accurate? We expect to publish the draft EIS in August 2011. It will include a combined biological assessment and EFH Assessment.

Thanks,

Dan Doyle

Project Manager
Division of License Renewal
U.S. Nuclear Regulatory Commission
daniel.doyle@nrc.gov
(301) 415-3748

From: Richard Domingue [<mailto:Richard.Domingue@noaa.gov>]
Sent: Friday, December 17, 2010 3:59 PM
To: Doyle, Daniel
Subject: Re: NRC BA/EFH assessment for Columbia Generating Station license renewal review

The species list included in the June 23, 2010 remain the appropriate species for this consultation. Your schedule is fine with us. Thanks.

On 12/17/2010 12:23 PM, Doyle, Daniel wrote:
Rich,

Thanks for your time on the phone this afternoon. As I said explained in the call, I am a project manager at the U.S. Nuclear Regulatory Commission coordinating the environmental review for the Columbia Generating Station license renewal application.

The purpose of this e-mail is to request an extension for the combined BA/EFH assessment for the species and habitats identified in the letter from your office to the NRC dated June 23, 2010 (attached).

Appendix D

We expect to publish our supplementary environmental impact statement in May 2011. The combined BA/EFH assessment will be included as an appendix to that report. The assessment will contain the staff's analysis of the potential impact to those species by the license renewal of Columbia Generating Station.

The website below contains more information about the Columbia Generating Station license renewal review:

<http://www.nrc.gov/reactors/operating/licensing/renewal/applications/columbia.html>

If you have any questions about this review, please feel free to contact me or the lead aquatic reviewer, Rebekah Krieg (509-371-7155 or rebekah.krieg@pnl.gov).

Sincerely,

Dan Doyle

Project Manager
Division of License Renewal
U.S. Nuclear Regulatory Commission
daniel.doyle@nrc.gov
(301) 415-3748

APPENDIX D-1
BIOLOGICAL ASSESSMENT AND ESSENTIAL FISH HABITAT
ASSESSMENT

Biological Assessment and Essential Fish Habitat Assessment Columbia Generating Station License Renewal

August 2011

Docket Number 50-397

U.S. Nuclear Regulatory Commission

Rockville, Maryland

TABLE OF CONTENTS

| | | |
|-----------|---|--------|
| D-1.1 | Introduction | D-1-1 |
| D-1.2 | Description of the Proposed Action | D-1-1 |
| D-1.2.1 | Site Location and Description | D-1-2 |
| D-1.2.2 | Cooling Water System Description and Operation | D-1-7 |
| D-1.3 | Endangered Species Act and Essential Fish Habitat Species Considered for Preliminary Analysis | D-1-13 |
| D-1.3.1 | Federally Listed Species and Designated Critical Habitat Near the Site | D-1-13 |
| D-1.3.2 | Essential Fish Habitat Near the Site | D-1-14 |
| D-1.4 | Endangered Species Act and Essential Fish Habitat Species Considered for In-Depth Analysis | D-1-14 |
| D-1.4.1 | Bull Trout (<i>Salvelinus confluentus</i>) | D-1-15 |
| D-1.4.1.1 | Life History | D-1-15 |
| D-1.4.1.2 | Population Trends | D-1-16 |
| D-1.4.1.3 | Endangered Species Act Listing History and Critical Habitat | D-1-17 |
| D-1.4.2 | Upper Columbia River Chinook Salmon (<i>Ocorhynchus tshawytscha</i>) | D-1-18 |
| D-1.4.2.1 | Life History | D-1-18 |
| D-1.4.2.2 | Population Trends | D-1-21 |
| D-1.4.2.3 | Endangered Species Act Listing History | D-1-25 |
| D-1.4.2.4 | Designated Essential Fish Habitat in the Vicinity of Columbia Generating Station | D-1-26 |
| D-1.4.3 | Upper Columbia River Steelhead (<i>Oncorhynchus mykiss</i>) | D-1-28 |
| D-1.4.3.1 | Life History | D-1-28 |
| D-1.4.3.2 | Population Trends | D-1-29 |
| D-1.4.3.3 | Endangered Species Act Listing History | D-1-30 |
| D-1.4.4 | Coho Salmon (<i>Oncorhynchus kisutch</i>) | D-1-31 |
| D-1.4.4.1 | Life History | D-1-31 |
| D-1.4.4.2 | Population Trends | D-1-32 |
| D-1.4.4.3 | Endangered Species Act Listing History | D-1-32 |
| D-1.4.4.4 | Designated Essential Fish Habitat in the Vicinity of Columbia Generating Station | D-1-33 |
| D-1.5 | Endangered Species Act Effects Analysis | D-1-34 |
| D-1.5.1 | Bull Trout | D-1-34 |
| D-1.5.2 | Upper Columbia River Chinook Salmon | D-1-35 |
| D-1.5.3 | Upper Columbia River Steelhead | D-1-36 |
| D-1.6 | Potential Adverse Effects to EFH | D-1-36 |
| D-1.6.1 | Upper Columbia River Chinook Salmon | D-1-38 |
| D-1.6.1.1 | Loss of Habitat | D-1-38 |
| D-1.6.1.2 | Impingement | D-1-39 |
| D-1.6.1.3 | Entrainment | D-1-39 |
| D-1.6.1.4 | Thermal Effects | D-1-40 |
| D-1.6.1.5 | Loss of Forage Species | D-1-40 |
| D-1.6.2 | Coho Salmon | D-1-40 |

| | | |
|-----------|---|--------|
| D-1.6.2.1 | Loss of Habitat..... | D-1-40 |
| D-1.6.2.2 | Impingement..... | D-1-40 |
| D-1.6.2.3 | Entrainment | D-1-40 |
| D-1.6.2.4 | Thermal Effects | D-1-41 |
| D-1.6.2.5 | Loss of Forage Species..... | D-1-41 |
| D-1.7 | Endangered Species Act and Essential Fish Habitat Cumulative Effects Analysis.. | D-1-41 |
| D-1.8 | Endangered Species Act Conclusions and Determination of Effects..... | D-1-43 |
| D-1.8.1 | Bull Trout | D-1-43 |
| D-1.8.2 | Upper Columbia River Spring Chinook Salmon..... | D-1-43 |
| D-1.8.3 | Upper Columbia River Steelhead | D-1-43 |
| D-1.9 | Essential Fish Habitat Conservation Measures and Conclusions..... | D-1-43 |
| D-1.9.1 | Conservation Measures..... | D-1-43 |
| D-1.9.2 | Upper Columbia River Chinook Salmon | D-1-44 |
| D-1.9.3 | Coho Salmon | D-1-44 |
| D-1.10 | References | D-1-44 |

Figures

| | |
|--|--------|
| Figure D-1-1. Location of CGS, 50-mi (80-km) region | D-1-3 |
| Figure D-1-2. Location of CGS, 6-mi (10-km) region | D-1-4 |
| Figure D-1-3. CGS, general site layout | D-1-5 |
| Figure D-1-4. Intake system plan and profile | D-1-8 |
| Figure D-1-5. Location of pumphouse, pipelines, intakes, and outfalls showing historical steelhead and fall Chinook salmon spawning locations | D-1-9 |
| Figure D-1-6. Perforated intake plan and section | D-1-10 |
| Figure D-1-7. Spare perforated pipe for the intake screen at CGS. “A” side view; “B” close up of outer sleeve; and “C” end view showing inner sleeve of perforated pipe. . | D-1-11 |
| Figure D-1-8. Rectangular slot discharge | D-1-12 |
| Figure D-1-9. Number of Fall Chinook Salmon Redds in the Hanford Reach of the Columbia River, 1948–2009. | D-1-23 |
| Figure D-1-10. Fall Chinook and Steelhead spawning areas in the Hanford Reach and vicinity of the CGS site | D-1-24 |

Tables

| | |
|--|--------|
| Table D-1-1. Threatened and endangered aquatic species of the Hanford Reach of the Columbia River in the vicinity of CGS..... | D-1-13 |
| Table D-1-2. Aquatic fish species with EFH in the vicinity of the Hanford Reach of the Columbia River in the vicinity of CGS | D-1-14 |
| Table D-1-3. Chinook population within or migrating through the Hanford Reach..... | D-1-22 |
| Table D-1-4. Upper Columbia River Chinook Salmon EFH descriptions by life stage..... | D-1-26 |
| Table D-1-5. Upper Columbia River Chinook Salmon life stages present in the Hanford Reach | D-1-28 |
| Table D-1-6. Fish counts for Steelhead, 2005–2010 | D-1-30 |
| Table D-1-7. Numbers of adult (not jack) Coho that passed through the Hanford Reach and by Priest Rapids Dam, 2005–2010..... | D-1-32 |
| Table D-1-8. Coho Salmon EFH descriptions by life stage..... | D-1-33 |
| Table D-1-9. Coho life stages currently present in the Hanford Reach | D-1-34 |
| Table D-1-10. Aquatic resource issues identified in the GEIS | D-1-37 |

ABBREVIATIONS, ACRONYMS, AND SYMBOLS

| | |
|--------------------|--|
| °C | degrees Celsius |
| °F | degrees Fahrenheit |
| ac | acre(s) |
| ADAMS | Agencywide Document Access and Management System |
| BA | Biological Assessment |
| BPA | Bonneville Power Administration |
| CFR | Code of Federal Regulations |
| cfs | cubic feet per second |
| CGS | Columbia Generating Station |
| CHU | critical habitat unit |
| cm | centimeter(s) |
| DO | dissolved oxygen |
| DOE | Department of Energy |
| DPS | distinct population segment |
| EFH | Essential Fish Habitat |
| EN | Energy Northwest |
| ESA | Endangered Species Act |
| ESU | Evolutionarily Significant Unit |
| FCRPS | Federal Columbia River Power System |
| fm | fathom(s) |
| FMO | foraging, migration, and overwintering |
| fps | feet per second |
| FR | Federal Register |
| ft | foot(feet) |
| ft ³ /s | cubic feet per second |
| GEIS | Generic Environmental Impact Statement |
| gpm | gallons per minute |
| ha | hectare(s) |
| in. | inch(es) |

| | |
|-------------------|--|
| kg | kilogram(s) |
| km | kilometer(s) |
| km ² | square kilometer(s) |
| lb | pound(s) |
| m | meter(s) |
| m/s | meter(s) per second |
| m ³ /s | cubic meter(s) per second |
| mg/L | milligram(s) per liter |
| mi | mile(s) |
| mi ² | square mile(s) |
| mm | millimeter |
| MSA | Magnuson-Stevens Fishery Conservation and Management Act |
| MSL | mean sea level |
| NEPA | U.S. National Environmental Policy Act of 1969 |
| NMFS | National Marine Fisheries Service |
| NOAA | National Oceanic and Atmospheric Administration |
| NRC | U.S. Nuclear Regulatory Commission |
| RM | river mile(s) |
| s | second(s) |
| USFWS | U.S. Fish and Wildlife Service |
| USGS | U.S. Geological Survey |
| WPPSS | Washington Public Power Supply System |
| WSDOT | Washington State Department of Transportation |

D-1 BIOLOGICAL ASSESSMENT AND ESSENTIAL FISH HABITAT ASSESSMENT FOR THE PROPOSED LICENSE RENEWAL FOR THE COLUMBIA GENERATING STATION

D-1.1 Introduction

The purpose of this Biological Assessment (BA)/Essential Fish Habitat (EFH) Assessment is to address the effect of the renewing the operating license of Columbia Generating Station (CGS) on endangered or threatened species—under the Endangered Species Act (ESA) of 1973, as amended (16 U.S.C. § 1536(a)-(d))—or their designated critical habitat. It also addresses the EFH for designated fish species. The U.S. Nuclear Regulatory Commission (NRC) prepared this joint BA/EFH Assessment to support the draft supplemental environmental impact statement for the renewal of the operating license for CGS, which is operated by Energy Northwest, under the NRC’s regulations in Title 10 of the *Code of Federal Regulations* (CFR) Parts 50 and 51.

Under Section 7 of the ESA of 1973, the NRC must consult with the U.S. Fish and Wildlife Service (USFWS) and the National Marine Fisheries Service (NMFS), as appropriate, to provide information on the potential impact that the operation of CGS could have on the Federally-listed species near the site. Adherence to the practices set forth in Section 7 ensures that, through consultation with the Service, Federal actions do not jeopardize the continued existence of any threatened, endangered, or proposed species or result in the destruction or adverse modification of critical habitat.

The Magnuson-Stevens Fishery Conservation and Management Act (MSA), as amended by the Sustainable Fisheries Act of 1996, requires Federal agencies to consult with NMFS on activities that may adversely affect EFH. The objective of an EFH Assessment is to determine if the proposed action(s) “may adversely affect” designated EFH for relevant commercially, Federally-managed fisheries species within the proposed action area. It also describes any proposed conservation measures to avoid, minimize, or otherwise offset potential adverse effects on designated EFH resulting from the proposed action.

This combined BA/EFH Assessment, as prepared by the NRC, examines the potential impacts of the proposed action on the Federally-listed aquatic species within the NMFS and USFWS jurisdiction as well as the designated and revised critical habitat and the EFH.

D-1.2 Description of the Proposed Action

Energy Northwest initiated the proposed Federal action by submitting an application for license renewal for CGS. The existing license for CGS expires on December 20, 2023. The NRC’s Federal action is the decision whether or not to renew the license for an additional 20 years.

The purpose and need for the proposed action (issuance of a renewed license) is to provide an option that allows for power generation capability beyond the term of the current nuclear power plant operating license to meet future system generating needs. Such needs may be determined by other energy-planning decisionmakers, such as State, utility, and, where authorized, Federal agencies (other than NRC). This definition of purpose and need reflects the NRC’s recognition that—unless there are findings in the safety review required by the Atomic Energy Act or findings in the National Environmental Policy Act of 1969 (NEPA) environmental analysis that would lead the NRC to reject a license renewal application—the NRC does not

1 have a role in the energy-planning decisions of State regulators and utility officials as to whether
2 a particular nuclear power plant should continue to operate.

3 If the renewed license is issued, State regulatory agencies and Energy Northwest will ultimately
4 decide if the plant will continue to operate based on factors such as the need for power or other
5 matters within the State’s jurisdiction or the purview of the owners. If the operating license is
6 not renewed, then the facility must be shut down on or before the expiration date of the current
7 operating license—December 20, 2023.

8 Energy Northwest has indicated it does not plan to conduct refurbishment activities, although
9 routine plant operation and maintenance activities will continue during the license renewal
10 period (EN, 2010). Routine plant operations and maintenance do not include any dredging or
11 in-water equipment replacement or activities.

12 **D-1.2.1 Site Location and Description**

13 CGS is located in south-central Washington State in Benton County. The CGS site is located
14 within the Hanford Site on land leased from the U.S. Department of Energy (DOE). The
15 Columbia River bounds the CGS site on the east side. Figure D-1-1 and Figure D-1-2 provide
16 maps of the 50-mile (mi) (80-kilometer (km)) and 6-mi (10-km) vicinities, respectively. The
17 nearest population center is the Tri-Cities, which includes the cities of Richland, Kennewick, and
18 Pasco. The nearest city is located approximately 15 mi (24 km) southeast of the site. The
19 nearest residence is 4.25 mi (6.8 km) from CGS in an east-southeasterly direction across the
20 Columbia River. There is one Native American reservation within a 50-mi (80-km) radius of
21 CGS—the Yakama Reservation to the west.

22 CGS is a single unit nuclear power plant that began commercial operation in December 1984.
23 The CGS site boundary encloses approximately 1,089 acres (ac) (441 hectares (ha)) leased to
24 Energy Northwest by the DOE. The most conspicuous structures on the CGS site include the
25 reactor containment building, the turbine building, six cooling towers, and various auxiliary
26 support buildings (EN, 2010). Figure D-1-3 provides a general layout of the CGS site.



Figure D-1-1. Location of CGS, 50-mi (80-km) region

Source: (EN, 2010a)




Figure D-1-2. Location of CGS, 6-mi (10-km) region

Source: (EN, 2010a)




Figure D-1-3. CGS, general site layout

Source: (EN, 2010a)

1 Nearby industrial sites include those listed below:

- 2 • two abandoned power plant construction projects, Washington Nuclear Power (WNP)-1
3 and WNP-4, located about 1 mi (1.6 km) east-southeast and east-northeast of the CGS
4 plant
- 5 • the Bonneville Power Administration's (BPA's) H.J. Ashe Substation located 0.5 mi
6 (0.8 km) north of the plant
- 7 • the Laser Interferometer Gravitational-Wave Observatory located 3.5 mi (5.6 km) from
8 the plant
- 9 • the Fast Flux Test Facility—a DOE facility located 2.75 mi (4.4 km) south-southwest in
10 the Hanford 400 Area
- 11 • three radioactive waste burial grounds (DOE facilities)—618-10 located 3.5 mi (5.6 km)
12 south and 618-11 immediately west of CGS

13 The Columbia River is the fourth largest North American river flowing to the sea. It is a
14 high-volume, high-gradient river fed by snowmelt in the headwater mountain ranges of the
15 Canadian Rockies of British Columbia (Benke and Cushing, 2005). The river travels over 1,200
16 mi (1900 km), draining a watershed covering approximately 262,480 square miles (mi²)
17 (680,000 square kilometers (km²)) (USFWS, 2010). River flow is regulated by 14 mainstem
18 dams. Ten of the dams are located above the CGS site (including three in British Columbia),
19 and four are below the site. The nearest upstream dam is Priest Rapids, located at river mile
20 (RM) 397, 45 mi (72 km) upstream of the CGS site. The nearest downstream dam is McNary,
21 located at RM 292, 60 mi (97 km) downstream (EN, 2010). The reservoir (Lake Wallula),
22 created by the McNary Dam, extends to about 6 mi (10 km) below the CGS site. The 51-mi
23 (82-km) river reach, extending from Priest Rapids Dam to Lake Wallula (RM 346), is free flowing
24 below Priest Rapids Dam. The elevation drop through this reach is approximately 70 feet (ft)
25 (21 meters (m)). This area, termed the "Hanford Reach" is the last non-impounded, non-tidal
26 segment of the Columbia River in the U.S. (Duncan, et al., 2007).

27 The flow of the Columbia River typically peaks from April–July, during spring runoff, and is
28 lowest from September–October. The monthly flows recorded by the U.S. Geological Survey
29 (USGS) below Priest Rapids Dam during water years 1960–2009 range from a mean of 79,300
30 cfs (2,250 cubic meters per second (m³/s)) during September to a mean of 202,000 cfs (5,700
31 m³/s) during June. Mean annual flows for the same period ranged from 80,650 cubic feet per
32 second (cfs) (2,284 m³/s) in 2001 to 165,600 cfs (4,700 m³/s) in 1997 and averaged 117,823 cfs
33 (3,336 m³/s). For water years 1984–2008, coincident with the period of CGS operation,
34 measured flows averaged 113,712 cfs (3,220 m³/s) (USGS, 2010). BPA regulates the flow of
35 the river to meet electrical demands and limit the impact on spawning salmon (EN, 2010).
36 Flows vary daily and hourly as water is released from Priest Rapids Dam, causing the river
37 stage to fluctuate in excess of 10 ft (3 m) on a daily basis. The river channel near the CGS site
38 varies between 1,200–1,800 ft (370–550 m) wide for the low-water and normal high-water
39 stages, respectively. River depth varies from about 25–45 ft (7.6–13.7 m) for normal high-water
40 and flood high-water levels, and velocities vary from 3 feet per second (fps) (0.9 meters per
41 second (m/s)) to over 11 fps (3.35 m/s), depending on the section and flow (EN, 2005).

42 Water-quality parameters measured by the USGS from 1996–2003 at Vernita Bridge (USGS
43 Station No. 12472900 at RM 388), 35 mi (56 m) upstream of the CGS site, showed that water
44 temperature ranged between 37–69 degrees Fahrenheit (3–20.5 degrees Celsius) with a
45 median of 54 degrees Fahrenheit (12 degrees Celsius) (EN, 2010), (USGS, 2006). Dissolved

1 oxygen (DO) ranged between 9.2–14.0 milligrams per liter (mg/L) with a median of 12.4 mg/L.
2 The pH fluctuated between 7.4–8.2 standard units (EN, 2010), (USGS, 2006).

3 The only other significant hydrological feature in the site area is the Yakima River, which flows
4 generally west to east and enters the Columbia River at RM 335 (EN, 2010). At its closest
5 approach, the Yakima is about 8 mi (13 km) southwest of the CGS site.

6 For this consultation, the overall action area consists of the aquatic resources associated with
7 the Columbia River near and downstream of the CGS site.

8 **D-1.2.2 Cooling Water System Description and Operation**

9 CGS is a single unit, nuclear-powered, steam electric facility that began commercial operation in
10 December 1984. The plant is a boiling water reactor. CGS uses a single-cycle,
11 forced-circulation cooling-water system (EN, 2010). The reactor core produces heat that boils
12 water, producing steam for direct use in a turbine generator. A closed-cycle cooling system
13 removes heat from the condenser and transfers it to the atmosphere through evaporation using
14 six mechanical draft cooling towers (EN, 2010). A portion of the cooling water is lost through
15 evaporation and drift. The evaporative losses lead to concentration of dissolved solids in the
16 cooling water. Thus, a portion of the cooling water, so-called blowdown water, is routinely
17 discharged back to the Columbia River and replenished with freshwater, thereby controlling the
18 buildup of dissolved solids.

19 The circulating-water system pumps water from the Columbia River to replenish the water lost
20 from evaporation, drift, and blowdown. The makeup-water pumphouse is located 3 mi (5 km)
21 east of the CGS plant and houses three 800-horse power makeup-water pumps (Figure D-1-3).
22 The pumps are designed to each supply 12,500 gallons per minute (gpm) (0.79 m³/s), or half
23 the system capacity, at the design head. Two pumps normally supply makeup water to the
24 plant with a withdrawal capacity of 25,000 gpm (1.58 m³/s). During normal operating periods,
25 the average makeup-water withdrawal is about 17,000 gpm (1.1 m³/s). The flow of the
26 Columbia River below Priest Rapids Dam for water years 1960–2009 has an average mean
27 annual discharge of 117,823 cfs (3,336 m³/s) and a minimum mean annual discharge of 80,650
28 cfs (2,284 m³/s) (USGS, 2010). Thus, the makeup-water withdrawal of 17,000 gpm (1.1 m³/s) is
29 about 0.03 percent of the average mean annual discharge and 0.05 percent of the minimum
30 mean annual discharge of the river.

31 The intake system for the makeup-water pumps consists of two 36-inch (in.) (91-centimeter
32 (cm))-diameter buried pipes that extend 900 ft (274 m) from the pumphouse into the river, about
33 300 ft (91 m) from the shoreline at Columbia RM 352 (Figure D-1-4 and Figure D-1-5) (WPPSS,
34 1980). An intake structure is located at the end of each of the pipes. The pipes make a
35 90-degree bend and extend slightly above the surface of the riverbed. Each of the pipes ends
36 with an intake structure (20 ft (6 m) long) mounted above the riverbed and approximately
37 parallel to the river flow, as shown in Figure D-1-6. Each intake structure is composed of two
38 intake screens that are each 6.5 ft (2 m) in length (Figure D-1-7) and mounted end to end. The
39 remaining length of the intake structure consists of two solid cones at either end of the structure.
40 The intake screens consist of an outer and inner perforated pipe sleeve (WPPSS, 1986). The
41 outer sleeve has a 42-in. (107-cm)-diameter sleeve with ³/₈-in. (9.5-millimeter (mm))-diameter
42 holes (composing 40 percent of the surface area). The inner sleeve has a 36-in.
43 (91-cm)-diameter sleeve with ³/₄-in. (19-mm)-diameter holes (composing 7 percent of the
44 surface area). The intake screens are designed to distribute the water flow evenly along its
45 surface.




Figure D-1-4. Intake system plan and profile



Figure D-1-5. Location of pumphouse, pipelines, intakes, and outfalls showing historical steelhead and fall Chinook salmon spawning locations

Source: (Gambhir, 2010), (Poston, et al., 2008)




Figure D-1-6. Perforated intake plan and section

Source: (WPPSS, 1980)




Figure D-1-7. Spare perforated pipe for the intake screen at CGS. “A” side view; “B” close up of outer sleeve; and “C” end view showing inner sleeve of perforated pipe.

- 1 The inlet velocities of the intake screens are within acceptable limits for best available
- 2 technology for minimizing impacts (69 FR 41576). The velocity through the external screen
- 3 openings is approximately 0.5 fps under normal operating conditions where 12,500 gpm is
- 4 removed through both intake structures. The approach velocity to the intake screens under the
- 5 same conditions is less than 0.2 fps (0.06 m/s) (WPPSS, 1980). This compares to river
- 6 velocities measured near the perforated pipes ranging from 4–5 fps (1.2–1.5 m/s) (WPPSS,
- 7 1986).
- 8 A biocide (e.g., chlorine) is added to the water in the circulating-water system to retard biological
- 9 growth. Other chemicals are added to control corrosion and scale (e.g., sulfuric acid) and
- 10 fouling on the heat-transfer surfaces (NRC, 1981). On an annual basis, blowdown into the river
- 11 averages about 2,000 gpm (0.1 m³/s). Blowdown water returns to the river from the cooling
- 12 towers through a line that extends out into the river next to the makeup-water pumphouse. The
- 13 18-in. (46-cm)-diameter, buried blowdown pipe extends about 175 ft (53 m) from the shoreline

Appendix D-1

- 1 at low river stage. The pipe ends above the riverbed at a 15-degree angle in a rectangular slot
- 2 outfall port that measures 8 in. by 32 in. (20 cm by 81 cm) and is perpendicular to the river flow
- 3 (Figure D-1-8).




Figure D-1-8. Rectangular slot discharge

Source: (WPPSS, 1980)

1 The State of Washington authorizes discharge in accordance with the special and general
 2 conditions of National Pollutant Discharge Elimination System (NPDES) Permit
 3 No. WA-002515-1. Three outfalls are listed in the permit, but the Outfall 001 system is the only
 4 outfall that discharges directly to the river. In addition to the cooling-water blowdown, this outfall
 5 serves as the outfall for the condenser-cleaning effluent, the radioactive waste-treatment system
 6 effluent, and the discharge from the standby service water.

7 **D-1.3 Endangered Species Act and Essential Fish Habitat Species Considered for** 8 **Preliminary Analysis**

9 The NRC conducted coordination and pre-consultation with the USFWS and the NMFS during a
 10 series of site visits, meetings, and phone conversations. Representatives of both services
 11 attended the CGS site audit in June 2010 and toured the project area. Specific actions that
 12 were related to the Federally-listed species, designated critical habitat, or EFH are discussed
 13 below.

14 **D-1.3.1 Federally Listed Species and Designated Critical Habitat Near the Site**

15 The NRC staff (staff) requested in letters dated March 22, 2010, (NRC, 2010a) and May 3,
 16 2010, (NRC, 2010b) that the USFWS and NMFS, respectively, provide information on Federally-
 17 listed endangered or threatened species, proposed or candidate species, and designated critical
 18 habitats that may occur in the vicinity of the CGS site.

19 Kurz (2010), working for the USFWS, responded in an email dated November 8, 2010, and
 20 identified a single aquatic species—the bull trout (*Salvelinus confluentus*)—under its jurisdiction
 21 that is Federally-listed as threatened and has been reported in the Hanford Reach in the vicinity
 22 of the CGS facility (Table D-1-1). USFWS also indicated that critical habitat for the bull trout
 23 occurred within the action area, as previously defined.

24 **Table D-1-1. Threatened and endangered aquatic species of the Hanford Reach of the**
 25 **Columbia River in the vicinity of CGS**

| Scientific name | Common name | Federal status ^(a) | Critical habitat designation |
|---------------------------------|---|-------------------------------|--|
| Fish | | | |
| <i>Oncorhynchus tshawytscha</i> | Upper Columbia River spring Chinook salmon | FE | Critical habitat designated September 2, 2005; 70 FR 52630 |
| <i>Oncorhynchus mykiss</i> | Upper Columbia River steelhead | FT | Critical habitat designated September 2, 2005; 70 FR 52630 |
| <i>Salvelinus confluentus</i> | bull trout | FT | Critical habitat designated October 6, 2004; 69 FR 59995; revised October 18, 2010; 75 FR 63898 |

^(a) Federal status listings: FE = Endangered; FT = Threatened; FC= Candidate

Source: (Kurz, 2010), (Suzumoto, 2010)

26 NMFS responded to the NRC's request in a letter dated June 23, 2010 (Suzumoto, 2010), and
 27 identified two Federally-listed species near the CGS site. The two species listed in Table D-1-2
 28 are the Upper Columbia River spring Chinook salmon (*Oncorhynchus tshawytscha*) and the

1 Upper Columbia River steelhead (*Oncorhynchus mykiss*). Critical habitat for both species
 2 occurs within the action area.

3 **Table D-1-2. Aquatic fish species with EFH in the vicinity of the Hanford Reach of the**
 4 **Columbia River in the vicinity of CGS**

| Scientific name | Common name |
|---------------------------------|-------------------------------------|
| <i>Oncorhynchus tshawytscha</i> | Upper Columbia River Chinook salmon |
| <i>Oncorhynchus kisutch</i> | coho salmon |

Source: (Suzumoto, 2010)

5 Critical habitat is defined in the ESA as a specific geographic area that contains features that
 6 are essential for the conservation of a threatened or endangered species (USFWS, 2010a).
 7 Critical habitat may require special management and protections. It also may include an area
 8 that the species may not currently occupy but that it may need for its recovery. Federal
 9 agencies are required to consult with the USFWS or NMFS on any actions that they authorize to
 10 ensure that their actions will not destroy or adversely modify critical habitat to the point that it will
 11 no longer aid in the species' recovery.

12 **D-1.3.2 Essential Fish Habitat Near the Site**

13 In the letter dated June 23, 2010, the NMFS (Suzumoto, 2010) also indicated that the Columbia
 14 River in the CGS plant vicinity provides EFH features for both the Upper Columbia River
 15 Chinook and the coho salmon (currently an unlisted reintroduction effort), as listed in
 16 Table D-1-2. The EFH for the Upper Columbia River Chinook includes all three runs (spring,
 17 summer, and fall).

18 **D-1.4 Endangered Species Act and Essential Fish Habitat Species Considered for**
 19 **In-Depth Analysis**

20 The following subsections discuss the identified ESA and EFH aquatic species. Because all of
 21 the aquatic species are salmonids (family Salmonidae), a brief generic life-history of salmonids
 22 is presented first, and then, the specific differences between the listed and EFH species are
 23 described in each section.

24 In general, anadromous adult salmonids return from the Pacific Ocean to the Columbia River to
 25 spawn in either the mainstem or tributaries. The female lays her eggs in a nest or "redd." The
 26 eggs hatch and produce an alevin, which is the lifestage between the egg and fry. Alevins
 27 cannot swim, but they can move their tails to readjust their position. Because of the yolk sac,
 28 alevins do not need to eat. They remain in the gravel riverbed and obtain nutrition from their
 29 yolk sac. Once the alevin has absorbed its egg sac, it is called a "fry," and it is capable of
 30 swimming and needs to forage for food. When the fry are approximately 2 in. (5 cm) long, they
 31 are termed parr (for the vertical brown-green bars on their sides, parr marks, which provide
 32 camouflage) or fingerlings. The length of time that a salmon is in the fry stage varies between
 33 species. In this document, fry and fingerlings are considered young juveniles. Fish that are in a
 34 transitional stage of adapting to life in a marine environment are called smolts and are
 35 considered juvenile salmon. Smolts can be found in freshwater as they begin their migration
 36 downstream, they can be in the process of migrating, or they can be in an estuarine
 37 environment. The timing of the development of a smolt varies between, and even within,

1 salmon species (Quinn, 2005). Juvenile salmon adapt to the saltwater before traveling to the
2 ocean, where they remain from 6 months–5 years or more before reentering the estuaries and
3 migrating to their natal stream or river to spawn.

4 **D-1.4.1 Bull Trout (*Salvelinus confluentus*)**

5 **D-1.4.1.1 Life History**

6 Bull trout are amphidromous, meaning they may return seasonally to freshwater as subadults,
7 sometimes for several years before they spawn. However, they have also been characterized
8 as anadromous (migrating from the sea up rivers to spawn), adfluvial (living in lakes and
9 migrating to rivers or streams to spawn), fluvial (inhabiting a river or stream), or resident
10 (completing their life cycle in freshwater) (Quinn, 2005). The bull trout in the mainstem of the
11 Columbia River are considered to be fluvial and migrate between multiple core areas. There
12 are accounts of amphidromous life-history forms that are present downstream of the Hanford
13 Reach (between the Yakima and John Day rivers), and it is thought that bull trout in this area
14 may still have the potential to be anadromous (USFWS, 2010b).

15 Bull trout differ from other salmonids based on their specific habitat requirements. They are
16 extremely sensitive to their environment and have more specific habitat requirements than most
17 other salmonids (75 FR 2270). These requirements include channel stability, substrate
18 composition, cover, and temperature (Rieman and McIntyre, 1993).

19 **Channel stability** is important for bull trout because juvenile fish, including embryos and
20 alevins, are found near the bottom of channels, where they use the substrate for cover. Rieman
21 and McIntyre (1993) found high variation in the number of bull trout redds that occurred in areas
22 with low channel stability and frequent winter floods. This observation confirmed findings from
23 other studies that showed high bed load movement and low channel stability were associated
24 with low numbers of bull trout in the Coeur d'Alene River drainage (Rieman and McIntyre,
25 1993).

26 **Substrate composition and cover.** Bull trout associate with complex forms of cover as well as
27 with pools. Juveniles associate with in-channel wood, substrate, or banks that are undercut.
28 The young-of-the-year associate with side channels, margins of streams, or other areas of low
29 velocity. The older fish use pools and areas with large and complex debris and undercut banks
30 (Rieman and McIntyre, 1993).

31 **Thermal sensitivity.** Bull trout are likely the most thermally sensitive species in coldwater
32 habitats in western North America (Dunham, et al., 2003). They are rarely found in streams or
33 rivers with summer temperatures that exceed temperatures of 59 degrees Fahrenheit
34 (15 degrees Celsius) for extended periods of time (McPhail and Baxter, 1996). A study
35 performed in a large plunge pool, created by the confluence of two streams located in Granite
36 Creek in Northern Idaho, illustrated the degree of the marked preference of bull trout for cooler
37 water. The pool had a strong side-to-side gradient of 46–59 degrees Fahrenheit (8–15 degrees
38 Celsius). Juvenile bull trout consistently chose the coldest water available (46–48 degrees
39 Fahrenheit (8–9 degrees Celsius)) despite the lowest-velocity water (also preferred by bull trout)
40 being located on the side of the pool with the warmer water. Other factors—including water
41 depth, substrate, overhanging cover, or interactions with other fish—could not account for the
42 distribution of the bull trout in the pool (Bonneau and Scarnecchia, 1996).

43 Bull trout generally spawn from late August to late December, with the peak spawning in
44 September and early October, when the water temperature drops below 48 degrees Fahrenheit

1 (9 degrees Celsius) (Wydoski and Whitney, 2003). Their preferred spawning location is in
2 streams with cold, clean water and clean gravel and cobble substrates with gentle stream
3 slopes.

4 Egg development appears to be dependent on water temperature (Wydoski and Whitney,
5 2003), and the 4–5 month incubation period that occurs during winter is longer than it is for
6 other salmonids (USFWS, 2003). The incubation period occurs over the winter. The optimum
7 temperature for development ranges from 36–39 degrees Fahrenheit (2–4 degrees Celsius)
8 (McPhail and Baxter, 1996). Wydoski and Whitney (2003) reported that alevins (life stage
9 between eggs and fry) emerging from the redds (nests) were between 0.9–1.1 in. (2–3 cm) long.
10 Fry remained in the streambed substrate for 3 weeks before emerging and, subsequently,
11 tended to be bottom oriented. Fry preferred the shallow edges of rivers or streams where they
12 can use the interstitial habitat in loose gravel for cover. At other times, they were associated
13 with shallow water in the side channels where the velocity is lower and where in-stream cover is
14 greater. Bull trout fry feed at various locations on the bottom, on the surface, and in the water
15 column and mostly eat aquatic insects (McPhail and Baxter, 1996).

16 Juvenile bull trout remain in the streams and concentrate in pools, rather than riffles or runs.
17 These sites are strongly associated with overhead cover (McPhail and Baxter, 1996). They
18 forage near the substrate and in the water column but not on at the surface (McPhail and
19 Baxter, 1996). Wydoski and Whitney (2003) reported the diet of juvenile bull trout in streams in
20 southeastern Washington as being insects such as flies, midges, stoneflies, mayflies,
21 caddisflies, and some fish such as sculpins (Wydoski and Whitney, 2003). They are also known
22 to ingest worms, snails, clams, leeches, earthworms, and amphibians and terrestrial insects
23 such as beetles and moths (Wydoski and Whitney, 2003)

24 The bull trout diet shifts as they mature, eventually feeding exclusively on fish. The species of
25 fish depends on their availability but may include sculpins, trout fry, whitefish, kokanee, minnow,
26 suckers, and yellow perch (McPhail and Baxter, 1996), (Wydoski and Whitney, 2003). Bull trout
27 in Lake Wenatchee were also seen preying on hatchery-reared sockeye salmon shortly after
28 stocking (Wydoski and Whitney, 2003).

29 **D-1.4.1.2 Population Trends**

30 Bull trout are native to the Pacific Northwest. Their range—which once included northern
31 California, western Montana, Nevada, Idaho, British Columbia, and Alberta—is thought to be
32 shrinking, primarily at the southern end of their range (Quinn, 2005). Prior to 1978, bull trout
33 and Dolly Varden (*Salvelinus malma*) were thought to be the same species, and, although their
34 ranges overlap, the bull trout are found in the south and the interior regions while the Dolly
35 Varden are coastal and found more towards the north (Quinn, 2005). The USFWS listed bull
36 trout as threatened throughout their range in 1999 (63 FR 31647).

37 The decline of bull trout has been characterized as being primarily due to habitat degradation
38 and fragmentation, blockage of migratory corridors, poor water quality, past fisheries
39 management practices, impoundments, dams, water diversions, and the introduction of
40 non-native species (64 FR 58910), (75 FR 2270).

41 Bull trout have been documented both upstream and downstream of the Hanford Reach,
42 including Priest Rapids reservoir (Pfeiffer, et al., 2001) and the Yakima River (McMichael and
43 Pearsons, 2001), (Pearsons, et al., 1998). The areas of the upper Columbia River with the
44 greatest number of bull trout are in the vicinity of tributaries with strong local populations and

1 suitable migration corridors (Marten, 2007). This includes the lower reaches of the Methow,
2 Entiat, and Wenatchee Rivers. There are fewer occurrences of bull trout in the Columbia River
3 in areas with poorer habitat conditions, in tributaries that have fragmented migration corridors,
4 or in tributaries with smaller populations of bull trout, such as in the Yakima and Walla Walla.
5 Bull trout would possibly use the mainstem of the Columbia River to a greater degree if the
6 habitat conditions improve and if the populations in the adjacent tributaries increase
7 (Marten, 2007).

8 Gray and Dauble (1977) reported bull trout in the Hanford Reach, but the location of the
9 collection was unclear. Pfeiffer, et al. (2001) also observed bull trout during an inventory of fish
10 in the Priest Rapids Project Area in Wanapum and Priest Rapids reservoirs between RM 398
11 and 453 using a variety of gear (set lines, gill nets, beach seines, minnow traps and
12 electrofishing). Collections occurred during day, dawn, dusk, and nighttime hours, stratified by
13 season and habitat. The sampling study captured 2 bull trout in electrofishing samples from the
14 more than 58,000 fish sampled. One bull trout was found at RM 299 (2 mi above Priest Rapids
15 Dam) and one at RM 430 (above Wanapum Dam). Pfeiffer, et al. (2001) noted that the bull trout
16 showed a preference for the lowest macrophyte abundance, water temperature, and surface
17 velocity.

18 Furthermore, the Grant County Public Utility District indicated only a “handful” of documented
19 observations of bull trout in the fishway observations located at Priest Rapids Dam. Results
20 from a 2001–2003 study indicated that, of 79 bull trout tagged at Rock Island, Rocky Reach,
21 and Wells Dams, only 9 (11 percent) were detected within the Wanapum Reservoir. Only one
22 of these continued to migrate downstream past the Wanapum and Priest Rapid Dams
23 (Stevenson, et al., 2003).

24 As reported in the biological opinion for the Priest Rapids Project license renewal, removal of
25 fish within gatewells at Priest Rapids dam during juvenile salmonid outmigration did not result in
26 any observed bull trout. However, three bull trout were observed during operations to remove
27 fish from within gatewells at Wanapum Dam (1997–2003). During fish ladder maintenance at
28 Priest Rapids Dam in 2000, one bull trout was found and released. At Wanapum Dam, a single
29 bull trout was found in 2000 during fish ladder maintenance effort and another in 2002. The
30 biological opinion suggests that the fish could be from the Yakima populations because the fish
31 were found in December, they were of a smaller migratory size, and the Yakima is the closest
32 core area (Marten, 2007). If these assumptions were correct, then they would have had to
33 travel upstream through the Hanford Reach.

34 Research scientists at DOE’s Hanford Site have characterized the use of the Hanford Reach by
35 bull trout as transient (Poston, et al., 2009). USFWS (2008) indicates that the accounts of bull
36 trout in the Hanford Reach are “anecdotal” and are “likely individuals moved downstream during
37 the spring freshet.” The presence of bull trout in the Hanford Reach and in the vicinity of CGS
38 can be considered to be for purposes of foraging, migration, and possibly overwintering.

39 ***D-1.4.1.3 Endangered Species Act Listing History and Critical Habitat***

40 Bull trout were listed as threatened throughout their range in 1999 (63 FR 31647).

41 The action area lies within the Columbia River distinct population segment (DPS). On October
42 18, 2010, the USFWS published a final rule that revised the critical habitat for the bull trout
43 (75 FR 63898). Unit 22, the Mainstem Upper Columbia River Unit, extends from John Day Dam
44 to Chief Joseph Dam (221.7 mi (357 km)) and encompasses the Hanford Reach. The core

1 areas within the Mainstem Upper Columbia River Unit support 35 local populations of bull
2 trout—16 populations in the Yakima River, 7 in Wenatchee River, 2 in the Entiat River, and 10 in
3 the Methow River core areas. The populations are well distributed across the action area,
4 although they tend to have low abundance and, in general, have a declining or slightly
5 increasing toward stable population trend. None of the populations is considered stable or
6 clearly increasing in size (Marten, 2007).

7 The Mainstem Upper Columbia River critical habitat unit (CHU) provides connectivity to the
8 Mainstem Lower Columbia River CHUs and to 13 additional CHUs. This CHU is the main
9 foraging, migration, and overwintering (FMO) habitat for the Entiat River core area and provides
10 connectivity between several other core areas or CHUs. Because the Mainstem Upper
11 Columbia River Unit is FMO habitat for other populations, the population size is not estimated
12 separately for this CHU (USFWS, 2010b). The USFWS indicates that bull trout reside
13 year-round in certain areas of the mainstem of the Columbia River as either subadults or adults.
14 The USFWS (2010b) indicates that spawning adults may also use the mainstem of the
15 Columbia River for up to 9 months.

16 The migratory form of the bull trout is not present in many of the populations within these core
17 areas, and connectivity between the core areas is fragmented. The main habitat issues within
18 these core areas are relatively high water temperature, passage barriers, and prolonged
19 low-flow conditions (Marten, 2007).

20 **D-1.4.2 Upper Columbia River Chinook Salmon (*Ocorhynchus tshawytscha*)**

21 ***D-1.4.2.1 Life History***

22 Chinook salmon are anadromous and migrate up streams and rivers to spawn, including the
23 Columbia River in the Pacific Northwest.

24 Although the general life history of the Chinook salmon follows the stages of an anadromous
25 salmonid, as discussed in the introduction to Section D-1.4, the entire life history of Chinook
26 salmon varies depending on the “race” of the fish. Within this life history, there are diverse and
27 complex patterns of behavior that allow differentiation between different groups of salmon.
28 Although all adults return to spawn in their natal streams or rivers, different races of fish return
29 at different times of the year. Chinook salmon are classified as spring, summer, or fall races—
30 or runs (as will be used in this document)—depending on the time at which the adults pass the
31 first dam (Bonneville) and begin their migration upstream. All of the fish spawn in the fall and
32 early winter, in the order in which they entered the river (spring first, followed by summer and
33 then winter). Genetic differences can distinguish most fish between the runs.

34 In the Columbia River, spring Chinook return to the river in March, migrate upstream from March
35 through June, and spawn in early fall. Summer Chinook return to the freshwater in June,
36 migrate from June through August, and spawn in late September through November. Fall
37 Chinook salmon return in August, migrate upstream from August into November, and generally
38 spawn later that fall, although they are also known to spawn as late as the following April
39 (University of Washington, 2011), (Wydoski and Whitney, 2003).

40 In general, spring Chinook salmon spawn in the upper reaches of tributaries, summer Chinook
41 spawn in the mouths and mid-portions of tributaries, and fall Chinook spawn in the mainstem.
42 For example, summer Chinook salmon in the Methow River spawned between RM 2 and RM 42
43 at elevations ranging from 900–1,800 ft (274–549 m) above mean sea level (MSL). In contrast,
44 spring Chinook spawned between RM 46 and RM 72, corresponding to elevations between

1 1,750–2,300 ft (530–700 m). However, some overlap of the spawning grounds has been
2 reported with individuals of both runs spawning between RM 38 and RM 52 (elevations between
3 1,550–2,200 ft (470–670 m)) (Wydoski and Whitney, 2003). During the 1970s and mid-1980s,
4 more than 80 percent of fall Chinook salmon returning to spawning regions upstream of McNary
5 Dam, spawned in the Hanford Reach (Dauble and Watson, 1997). More recently, from 2000–
6 2009, the escapement to the Hanford Reach dropped to an average of 40 percent (Hoffarth,
7 2010).

8 In addition to different runs, Chinook salmon have two behavioral forms that are distinguished
9 by the time the migration to the sea occurs. Chinook salmon can be differentiated by their
10 behavior as having either a “stream-type” or an “ocean-type” life history. The type of life history
11 depends on when the parr become smolts and begin their migration downriver to the ocean. If
12 the juvenile Chinook begin their migration immediately after emergence or after a few months in
13 the river (as subyearlings, age 0), migrate gradually downstream, and reside in the estuary for a
14 few weeks or more before they move out to the sea, then they are termed “ocean-types.”
15 However, if they begin their migration as yearlings (age 1) and rapidly move through the
16 estuaries to the ocean, they are called “stream-types” (Quinn, 2005).

17 In general, the summer and fall runs of Chinook salmon migrate as subyearlings during their
18 first spring or fall and are, thus, considered to be ocean-type, although some also migrate as fry
19 or yearling juveniles (during their second spring) and would be considered stream-type. In
20 Washington State, the ocean-type consist of adults—over 80 percent of which had emigrated as
21 subyearlings, while the remaining 20 percent had emigrated as yearlings (Wydoski and
22 Whitney, 2003). Most of the ocean-type salmon spawn in the larger rivers, such as the
23 Columbia River mainstem.

24 The stream-types consist of 80–100 percent adults that emigrated as yearlings. Upper
25 Columbia River spring Chinook salmon have a stream-type life history where the young salmon
26 (alevins, parr, and smolts) spend 1–2 years in freshwater before making a rapid migration trip
27 downstream to the Pacific Ocean (Wydoski and Whitney, 2003). In the Columbia River, the
28 stream-type adults typically spawn in the small streams where the juveniles are reared
29 (Quinn, 2005).

30 Adults return to their natal spawning areas and build redds in the river substrate. Chinook
31 salmon spawn in small tributaries 7–10 ft (2–3 m) wide and in large rivers such as the Columbia
32 (Healey, 1991). They spawn in depths as shallow as 2 in. (5 cm) to depths greater than 23 ft
33 (7 m). Water velocities range from 0.3–5 fps (10–150 cm/s) (Healey, 1991). Quinn (2005)
34 indicated that in the mainstem of the Columbia, Chinook salmon spawn in water as deep as
35 21 ft (6.5 m), with water velocities along the bottom of up to 6.6 fps (2 m/s).

36 Chapman, et al. (1986) examined the redds of fall Chinook salmon spawning in the Hanford
37 Reach, specifically on the Vernita Bar, which is located 4 mi (6.5 km) downstream from Priest
38 Rapids Dam. Water depth ranged from less than 1 in. (2.5 cm) at a flow rate of 70,000 cfs
39 (1,982 m³/s) to 23 ft (7 m) below the water’s surface measured at a discharge of 36,000 cfs
40 (1,020 m³/s). Water velocities were generally greater than 2.2 fps (0.67 m/s) when measured
41 9 in. (23 cm) above the substrate. Some redds were in areas with velocities near 6.6 fps (2 m/s)
42 for at least part of the day. Spawning occurred from early October to the third week of
43 November.

44 A female may deposit up to 5,000 eggs (range from less than 2,000 to greater than 17,000) per
45 redd (Healey, 1991). The depth at which eggs are buried depends partly on the water velocity.
46 The depth of gravel or cobble over the eggs is reported to range from 4–13 in. (10–33 cm) with

Appendix D-1

- 1 an average of 7.4 in. (18.8 cm) (Healey, 1991). Survival of the eggs depends on intragravel
2 flow rates, which must equal or exceed about 24 in. per hour for good survival. Eggs hatch in
3 approximately 2 months, depending on the water temperature.
- 4 Geist, et al. (2006) examined the variation in temperature and DO levels during the first 40 days
5 of incubation. There were no significant differences in the survival of fall Chinook salmon at
6 temperatures equal to or below 62 degrees Fahrenheit (16.5 degrees Celsius). However, a
7 rapid decline in survival occurred between 62–63 degrees Fahrenheit (16.5–17 degrees
8 Celsius) and embryo mortality increased greatly above incubation temperatures of 63 degrees
9 Fahrenheit (17 degrees Celsius).
- 10 Upon hatching, the alevins live in the gravel for about 2–3 weeks, foraging on small
11 invertebrates such as aquatic insect larvae and terrestrial insects (Wydoski and Whitney, 2003).
12 In general, alevins move deeper into the gravel after hatching. Later, they start to move laterally
13 in the gravel and, after the yolk has been absorbed, they become fry moving upward, emerging
14 from the gravel, and orienting into the water current (Quinn, 2005).
- 15 Stream-type fry or juveniles remain in the stream or river and migrate to the ocean during their
16 second spring (Quinn, 2005), (Wydoski and Whitney, 2003). Juveniles from the spring runs in
17 the Columbia River are generally stream-type. They prefer a water depth of less than 3 ft
18 (0.9 m) during the first few months (Wydoski and Whitney, 2003), although they exhibit other
19 habitat preferences that determine their location. Preferences include water velocity, in-stream
20 cover, and abundance of other fish species. A study of young-of-the-year spring Chinook in the
21 upper Yakima River Basin during summer and fall reported that they preferred water depths
22 from 1.6–1.8 ft deep (49–55 cm) and a bottom velocity 0.8–0.9 fps (0.24–0.27 m/s). By spring
23 they occupied habitats that were shallower (0.8 ft (24 cm) deep) with bottom water velocities of
24 1.4 fps (0.43 m/s) (Wydoski and Whitney, 2003).
- 25 In the Hanford Reach, fall Chinook remain in the area for the first few months after emergence
26 at water depths of less than 3 ft (0.9 m). They move to deeper water when they are larger and
27 closer to the time of their migration (Dauble, et al., 1989), (Wydoski and Whitney, 2003). In
28 general, ocean-type juveniles orient toward the current and are able to maintain their positions
29 during the day for velocities ranging from 0.16 to less than 0.83 fps (5–25 cm/s). They drifted
30 downstream at velocities of 0.83–1.3 fps (25–41 cm/s) during the day and at lower velocities at
31 night. Fall Chinook, however, maintained their position in waters with velocities up to 1.3 fps
32 (41 cm/s), which appears to be an upper threshold for their habitat. At night, fall Chinook
33 juveniles maintained positions near the bottom of the river where the water velocities were
34 lower. They move upstream and downstream during both the day and the night to find food and
35 suitable habitat (Wydoski and Whitney, 2003).
- 36 The optimal water temperature for spring Chinook salmon is 54–55 degrees Fahrenheit (12–13
37 degrees Celsius) (Wydoski and Whitney, 2003). The optimal temperature for fall salmon, 59–
38 64 degrees Fahrenheit (15–18 degrees Celsius), is higher than it is for stream-type Chinook
39 salmon. Water temperatures above 73 degrees Fahrenheit (22.7 degrees Celsius) are lethal to
40 Chinook salmon smolts and juveniles (Wydoski and Whitney, 2003).
- 41 Early juvenile diet consists of midge larvae and zooplankton, progressing to adult caddisflies
42 and other aquatic insect larvae and some terrestrial insects. Juveniles forage on zooplankton
43 and macroinvertebrates as they migrate through the Columbia River Basin, and they are prey to
44 other fish, birds, and mammals (Dauble, 2009). Passage time for a juvenile spring Chinook
45 through the Hanford Reach lasts no more than 1 week; outmigration of the juvenile spring
46 Chinook extends from April to the end of August (DOE, 2000). As the young-of-year migrate to

1 the mainstem Columbia, they are surface-oriented; however, they may migrate at deeper depths
2 in the Hanford Reach (Dauble, 2009), (Lohn, 2004).

3 Juvenile ocean-type Chinook salmon generally spend up to 2 months in the estuary before
4 migrating to the ocean (Healy, 1991). In the estuaries, the smaller salmon feed on aquatic and
5 terrestrial insects, including chironomid larvae, dipterans, cladocerans such as *Daphnia*,
6 amphipods, and other crustaceans. As they become larger, they feed on juvenile fish such as
7 anchovy (Engraulidae), smelt (Osmeridae), herring (Clupeidae), and stickleback
8 (Gasterosteidae). Ocean-type fish have a longer estuarine residence than the stream-type
9 Chinook salmon (Healey, 1991), (PFMC, 2000).

10 Smaller juvenile salmon in the ocean initially feed on small crustaceans, but as they grow, their
11 diet becomes primarily larval and juvenile fish to include Pacific herring, northern anchovy,
12 smelt, pilchard, sand lance, rockfish, and rattfish (Wydoski and Whitney, 2003). They remain in
13 the ocean from 3–4 years (ranging from 2–8 years) while they mature. Adult Chinook salmon
14 range throughout the North Pacific Ocean and the Bering Sea. Chinook salmon from the
15 Columbia River drainage migrate north and west along the Pacific coast and up to the Gulf of
16 Alaska.

17 The age that adult Chinook salmon return to their natal rivers to spawn varies depending on the
18 stock. Most fish from the Columbia River streams return at age 3–4 years. However, some
19 males return 1–2 years earlier than their counterparts. These “jack salmon” are generally
20 smaller and can constitute a substantial part of the overall run (see Table D-1-3). Adult Chinook
21 salmon returning from the ocean to spawn in the rivers stop feeding entirely after they pass
22 through the estuaries (Higgs, et al., 1995) and migrate to their natal streams.

23 **D-1.4.2.2 Population Trends**

24 Chinook salmon are generally found in coastal rivers as far south as the San Joaquin River in
25 California, although they are also occasionally observed in the San Luis Obispo or Carmel
26 Rivers south of San Francisco Bay and have been reported in Baja California, Mexico (Pacific
27 Fishery Management Council, 2000), (Wydoski and Whitney, 2003). They extend as far north
28 as Point Hope, AK, along the Pacific coast, and from the Anadyr River south to Hokkaido, Japan
29 (Wydoski and Whitney, 2003). In marine environments, they extend from as far south as the
30 U.S. and Mexico border (Baja California, Mexico) throughout the North Pacific Ocean and the
31 Bering Sea (PFMC, 2000), (Wydoski and Whitney, 2003).

32 The number of Chinook salmon migrating up the Columbia River started to decrease in the late
33 1880s as a result of commercial fishing on the lower Columbia River. Degradation and loss of
34 habitat accelerated their decline in numbers. It was further accelerated by the installation of
35 hydroelectric dams on the river, including Grand Coulee Dam constructed in 1941, which
36 permanently blocked the salmon migrations past RM 597 and Chief Joseph Dam (RM 545) that
37 was constructed downstream from Grand Coulee Dam, which also blocks anadromous fish
38 migrations (Good, et al., 2005). The Construction of Hells Canyon Dam on the Snake River in
39 1967 and Dworshak Dam on the Clearwater River also blocked upstream migrations and
40 contributed to the declining number of Chinook salmon runs overall in the Columbia River, even
41 though these fish did not pass through the Hanford Reach.

42 Chinook salmon has been an important species for the Native Americans as well as other
43 people in the Columbia River Basin. Commercial canning of salmon in the lower Columbia
44 River peaked in the 1880s when the catch was more than 40 million pounds (lb) (18 million

1 kilograms (kg)). By the 1890s, hatcheries were releasing salmon to replenish the declining
 2 spring runs (Dauble, 2009). From 1938–1940, the Grand Coulee Fish Maintenance Program
 3 trapped returning spring-run Chinook salmon at Rock Island Dam and either transplanted them
 4 as adults or released juveniles into selected areas within the drainages below Grand Coulee
 5 (Good, et al., 2005). This action homogenized the stocks of Chinook across the currently
 6 designated evolutionarily significant unit (ESU) for the spring run and influenced the present-day
 7 loss of genetic diversity (Lohn, 2004). Subsequent construction of numerous dams and other
 8 projects on the mainstem Columbia River also contributed to the obstacles for recovery of the
 9 Upper Columbia River spring Chinook salmon (Lohn, 2004).

10 Table D-1-3 provides the current returns of Chinook salmon in the Columbia River for the past
 11 6 years. The numbers for spring and summer Chinook include only those that passed through
 12 Priest Rapids Dam and, thus, through the Hanford Reach. Table D-1-3 also shows the counts
 13 that pass through McNary Dam but not Ice Harbor. This eliminates the fish that moved up the
 14 Snake River, but it includes fish that spawn in the Yakima River and those returning to the Priest
 15 Rapids Hatchery.

16 **Table D-1-3. Chinook population within or migrating through the Hanford Reach**

| Year | Fish counts at Priest Rapids Dam | | | | | | Counts passing McNary minus the Ice Harbor counts | |
|------|----------------------------------|-------------------|-----------------------|-------------------|---------------------|-------------------|---|-------------------|
| | Spring Chinook adults | Adults plus Jacks | Summer Chinook adults | Adults plus Jacks | Fall Chinook adults | Adults plus Jacks | Fall Chinook adults | Adults plus Jacks |
| 2005 | 14,148 | 14,663 | 61,227 | 63,125 | 31,289 | 31,641 | 119,360 | 127,966 |
| 2006 | 8,538 | 8,616 | 57,236 | 57,792 | 18,851 | 20,678 | 78,809 | 85,778 |
| 2007 | 6,708 | 7,197 | 30,644 | 31,732 | 22,650 | 27,033 | 43,860 | 62,111 |
| 2008 | 12,178 | 12,798 | 39,174 | 42,616 | 34,012 | 48,552 | 79,973 | 88,354 |
| 2009 | 13,469 | 16,379 | 49,417 | 51,534 | 40,723 | 46,552 | 79,720 | 103,010 |
| 2010 | 30,539 | 31,471 | 49,265 | 50,482 | 38,614 | 42,490 | 151,180 | 166,383 |

Source: (University of Washington, 2011) (Columbia River DART (Data Access in Real Time)
<http://www.cbr.washington.edu/dart/dart.html>

17 Estimated returns (escapement) of adult fish to the Hanford Reach are calculated annually by
 18 the Washington Department of Fish and Wildlife. Escapement of spring Chinook to the Upper
 19 Columbia River for 2010 was 57,300 total, with 5700 wild spring Chinook. Escapement of
 20 summer Chinook was 72,300 (Washington Department of Fish and Wildlife, 2011). In 2010, the
 21 latest year to be reported, total escapement of adult fall Chinook salmon to the Hanford Reach
 22 was estimated to be 80,408 fish, and the number of redds observed was 8,817 (PNNL
 23 unpublished data). Escapement numbers may vary from fish counts as a result of tribal and
 24 sports fishing as well as adults that ascend the hydroelectric dams and then fall back, biasing
 25 the fishway escapement estimates. Biases can range from 1–38 percent for fall Chinook
 26 salmon from fallback at dams. It is less for spring and summer Chinook (Boggs, et al., 2004).

27 Figure D-1-9 illustrates the locations of the fall Chinook spawning areas in the Hanford Reach of
 28 the Columbia River. The number of fall-run Chinook salmon redds in the Hanford Reach is
 29 identified in Figure D-1-10 for years 1948–2009. From 1964–1982, estimated escapement of
 30 adult fall Chinook salmon to the Hanford Reach (the number of adults that survive natural

- 1 mortality and harvest to reach the spawning grounds) averaged about 25,000 fish annually. In
- 2 2003, the adult Chinook escapement peaked at 89,300, and the number of redds observed also
- 3 peaked at 9,465 (Hoffarth, 2010).




Figure D-1-9. Number of Fall Chinook Salmon Redds in the Hanford Reach of the Columbia River, 1948–2009.

Source: (Duncan, et al., 2010); unpublished data for 2010




Figure D-1-10. Fall Chinook and Steelhead spawning areas in the Hanford Reach and vicinity of the CGS site

Source: (DOE, 2000), (Poston, et al., 2009)

1 Salmon population abundance in Pacific Northwest and Alaskan stocks appears to relate to the
2 ocean productivity. Ocean productivity, in turn, seems to correlate with a recurring,
3 decadal-scale pattern of ocean-atmosphere climate variability that occurs in the Northern Pacific
4 Ocean (Good, et al., 2005). Marine productivity was not favorable for the majority of salmon
5 populations for the two decades that began in 1977, but a shift in ocean-atmospheric conditions
6 occurred around 1998 and the increased returns of salmon to Pacific Northwest Rivers since
7 that time may be a result of this shift to more favorable conditions.

8 ***D-1.4.2.3 Endangered Species Act Listing History***

9 NMFS listed the Upper Columbia River spring Chinook salmon as an endangered species in
10 1999 and reaffirmed this status in 2005. The main consideration for NMFS when listing the
11 Upper Columbia River spring Chinook salmon as an endangered species was the concern that
12 the species was at risk of becoming extinct in the foreseeable future (64 FR 14308).

13 On September 2, 2005, NMFS published a final rule that revised the critical habitat for the
14 designation of critical habitat for 12 ESUs of West Coast salmon and steelhead including the
15 spring-run Chinook salmon (70 FR 52630). NMFS designated all naturally-spawned
16 populations of Chinook salmon in all river reaches accessible to Chinook salmon in Columbia
17 River tributaries upstream of the Rock Island Dam and downstream of Chief Joseph Dam,
18 excluding the Okanogan River, as being within the ESU for the species (64 FR 14308),
19 (70 FR 37160). The ESU contains the only remaining genetic resources of those spring-run
20 Chinook salmon that migrate into the upper Columbia River Basin, and those salmon are
21 distinct from other stream-type Chinook salmon ESUs (64 FR 14308). Chinook salmon have
22 characteristics specific to the location of their spawning areas and the time they spend in the
23 river. The drainages (Wenatchee, Methow, and Entiat rivers) that support this ESU for the
24 spring-run Chinook salmon are all above Rock Island Dam, which is upstream of CGS.
25 Historically, the spring-run Chinook may also have used portions of the Okanogan River
26 (Good, 2005)

27 NMFS has been developing a series of biological opinions to address the restoration of the
28 species from the operation of the Federal Columbia River Power System (FCRPS). The
29 FCRPS consists of 31 Federally-owned and operated (U.S. Army Corps of Engineers and the
30 Bureau of Reclamation) hydro projects in the Columbia and Snake Rivers. The BPA markets
31 and distributes the power generated by these dams and CGS (BPA, 2010). In addition, NMFS
32 has prepared biological opinions for the relicensing of the five dams on the Columbia River that
33 are owned and operated by public utilities, including Priest Rapids Dam, which is owned and
34 operated by Public Utility District No. 2 of Grant County (Lohn, 2004).

35 The actions covered by the NMFS' biological opinions for the Upper Columbia River spring
36 Chinook salmon range from modification of the dams to habitat improvements in areas away
37 from the dams. NMFS characterizes the program that is responsible for implementing the
38 biological opinion as being a "large and complicated program that is commensurate with the
39 scale of the FCRPS and its impact on the listed species and critical habitat." The program calls
40 for the following (NMFS, 2010):

41 increasing survival rates of fish passing through the dams; managing water to
42 improve fish survival; reducing the numbers of juvenile and adult fish consumed
43 by fish, avian, and marine mammal predators; improving juvenile and adult fish
44 survival by protecting and enhancing tributary and estuary habitat; implementing

1 safety net and conservation hatchery programs to assist recovery; and ensuring
 2 that hatchery operations do not impede recovery.

3 A recent review of the NMFS 2008 biological opinion for the FCRPS (NMFS, 2010) included
 4 evaluation of the status of the Upper Columbia River spring Chinook salmon and additional
 5 actions to build on the 2008 biological opinion. The evaluation of new information collected
 6 across the critical habitat for spring-run Chinook salmon indicates that the aggregate
 7 populations of the species have been stable or increasing over the last decade. These results
 8 suggest that the actions identified in the reasonable and prudent alternative may be working and
 9 are encouraging for the new Adaptive Management Implementation Plan.

10 **D-1.4.2.4 Designated Essential Fish Habitat in the Vicinity of Columbia**
 11 **Generating Station**

12 The staff has determined that EFH exists in the vicinity of CGS for all three runs of the Upper
 13 Columbia River Chinook salmon. Table D-1-4 lists the environmental requirements for all three
 14 runs of the Upper Columbia River Chinook EFH. Table D-1-5 lists the lifestages of the Upper
 15 Columbia River Chinook salmon that are present in the Hanford Reach.

16 **Table D-1-4. Upper Columbia River Chinook Salmon EFH descriptions by life stage**

| Life stage | Habitat type | Temperature | Water depth | Flow | Seasonal occurrence in estuaries |
|-------------------|---|------------------------|--|--|----------------------------------|
| Spring run | | | | | |
| Eggs | Upper reaches of tributaries upstream of the Hanford Reach (Freshwater) | 41–58 °F (5–4.4 °C) | 0.2–23 ft (0.05–7 m) | 0.3–6.6 fps (10–200 cm/s) | Not applicable |
| Alevins | Upper reaches of tributaries upstream of the Hanford Reach (Freshwater) | 54–55 °F (12–13 °C) | 0.2–23 ft (0.05–7 m) | 0.3–6.6 fps (10–200 cm/s) | Not applicable |
| Young juveniles | Tributaries upstream of the Hanford Reach (Freshwater) | 54–55 °F (12–13 °C) | 3 ft (1 m) | 0.8–0.9 fps (24–27 cm/s) | Not applicable |
| Migrating smolts | Mainstem Columbia River (Freshwater to saline estuary) | 54–55 °F (12–13 °C) | midchannel–lower depths | 1.4 fps (43 cm/s) | March–June |
| Juveniles | Mainstem Columbia River/Estuary/ocean (Estuary to seawater) | 54–55 °F (12–13 °C) | variable | ---- | March–June |
| Adults | Pacific Ocean (Seawater) | 41–59 °F (5–15 °C) | 0–>60 fathoms (fm) (110 m) but most abundant in 30–40 fm (57–73 m) | ---- | Not applicable |
| Migrating adults | Estuary/Mainstem Columbia River/Tributaries (Seawater to freshwater) | 38–56 °F (3.3–13.3 °C) | variable | 3.6–22.3 fps (1.1–6.8 m/s); 8 fps (2.44 m/s) | March–May |

| Life stage | Habitat type | Temperature | Water depth | Flow | Seasonal occurrence in estuaries |
|-------------------|---|---|--|---|----------------------------------|
| Spawning adults | Tributaries (Freshwater) | 42–57°F (5.6–13.9°C) | 0.2–23 ft (0.05–7 m) | 0.3–5 fps (10–150 cm/s) | Not applicable |
| Summer run | | | | | |
| Eggs | Lower reaches of tributaries upstream of the Hanford Reach (Freshwater) | 41–58 °F (5–14.4 °C) | 2 in.–23 ft (0.05–7 m) | 1–3.6 fps (32–109 cm/s) | Not applicable |
| Alevins | Lower reaches of tributaries upstream of the Hanford Reach (Freshwater) | 54–55 °F (12–13 °C) | 0.2–23 ft (0.05–7 m) | 1–3.6 fps (32–109 cm/s) | Not applicable |
| Young juveniles | Tributaries upstream of the Hanford Reach (Freshwater) | 54–55 °F (12–13 °C) | 3 ft (1 m) | 0.16–0.83 fps (5–25 cm/s) | Not applicable |
| Migrating smolts | Mainstem Columbia River including Hanford Reach; to estuary (Freshwater to saline estuary) | 54–55 °F (12–13 °C) | midchannel–lower depths | 0.16–0.83 fps (5–25 cm/s) | April–July until Aug/Sept |
| Juveniles | Estuary/Ocean (Saline estuary to seawater) | 54–55 °F (12–13 °C) | variable | ---- | April–July until Aug/Sept |
| Adults | Ocean (Seawater) | 41–59 °F (5–15 °C) | 0–>60 fm (110 m) but most abundant in 30–40 fm (57–73 m) | ---- | Not applicable |
| Migrating adults | Mainstem Columbia River including Hanford Reach (Seawater to freshwater) | 57–68 °F (13.9–20 °C) | variable | 3 fps (0.9 m/s) to over 11 fps (3.35 m/s) | June–July |
| Spawning adults | Lower reaches of tributaries upstream of Hanford Reach (Freshwater) | 42–57 °F (5.6–13.9°C) | 2 in.–23 ft (0.05–7 m) | | Not applicable |
| Fall run | | | | | |
| Eggs | Mainstem Columbia River including the Hanford Reach buried under 10 to 33 cm of gravel (Freshwater) | Below 62 °F (17 °C) 41–58 °F (5–14.4 °C) | 1 in.–23 ft (2.5 cm–7 m) | 2.2–6.6 fps (0.67–2 m/s) | Not applicable |
| Alevins | Mainstem Columbia River including the Hanford Reach (Freshwater) | 59–64 °F (15–18 °C) | 1 in.–23 ft (2.5 cm–7 m) | 2.2–6.6 fps (0.67–2 m/s) | Not applicable |
| Young juveniles | Mainstem Columbia River including the Hanford Reach (Freshwater) | 59–64 °F (15–18 °C) | Greater than 3 ft (1 m) deep | 0.16–1.3 fps (5–41 cm/s) | Not applicable |
| Migrating smolts | Mainstem Columbia River (Freshwater to saline estuary) | 54–55 °F (12–13 °C) | Greater than 3 ft (1 m) deep | 0.16–1.3 fps (5–41 cm/s) | April–July until Aug/Sept |

| Life stage | Habitat type | Temperature | Water depth | Flow | Seasonal occurrence in estuaries |
|------------------|--|--------------------------|--|--|----------------------------------|
| Juveniles | Estuary/Ocean (Saline estuary to seawater) | 54–55 °F (12–13 °C) | variable | ---- | April–July until Aug/Sept |
| Adults | Ocean (Seawater) | 41–59 °F (5–15 °C) | 0–>60 fm (110 m) but most abundant in 30–40 fm (57–73 m) | ---- | Not applicable |
| Migrating adults | Mainstem Columbia River including Hanford Reach (Seawater to freshwater) | 51–67°F (10.6–19.4°C) | variable | 3.6–22.3 fps (1.1–6.8 m/s) 8 fps (2.44 m/s) | August–November |
| Spawning adults | Mainstem Columbia River including the Hanford Reach (Freshwater) | 42–57°F (5.6–13.9°C) | 1 in–23 ft (2.5 cm–7 m) | 6.6 fps (2 m/s) | Not applicable |

Sources: (Chapman, et al., 1986), (Dauble, et al., 1989), (Healy, 1991), (Levy and Slaney, 1993), (Quinn, 2005), (University of Washington, 2011), (Wydoski and Whitney, 2003)

1 **Table D-1-5. Upper Columbia River Chinook Salmon life stages present in the Hanford**
 2 **Reach**

| Life stage | Spring run | Summer run | Fall run |
|------------------|------------|------------|----------|
| Eggs | | | x |
| Alevins | | | x |
| Young juveniles | | | x |
| Migrating smolts | x | x | x |
| Juveniles | | | |
| Adults | | | |
| Migrating adults | x | x | x |
| Spawning adults | | | x |

3 **D-1.4.3 Upper Columbia River Steelhead (*Oncorhynchus mykiss*)**

4 **D-1.4.3.1 Life History**

5 Steelhead are the anadromous form of rainbow trout, and both forms can coexist in the same
 6 river system. Steelhead migrate to the ocean as smolts. However, they may spend 1–7 years
 7 in freshwater before they migrate into the ocean. Most steelhead in Washington state become
 8 smolts at age 2 (70–90 percent) and the remainder at age 3 (55–100 percent). Although most
 9 steelhead make their first spawning migration after 2 years in the ocean, the stocks that
 10 originate in the Columbia River drainage mature after 1 year in the ocean (Wydoski and
 11 Whitney, 2003). There are two types of steelhead—stream-maturing, which enter the
 12 freshwater earlier in the summer to early fall and then spawn in the spring and ocean-maturing,
 13 which enter freshwater between November and April and spawn shortly thereafter. The

1 steelhead in the upper Columbia River Basin are almost exclusively the stream-maturing type
 2 that is considered the summer run (NOAA, 2011b). The peak runs of steelhead in the upper
 3 Columbia River Basin pass Bonneville Dam between June and August and arrive in the Hanford
 4 Reach area in late summer (Wydoski and Whitney, 2003). The adult steelhead do not spawn
 5 until the following spring (March–June, possibly as late as July). Some of the adults survive and
 6 return downstream to the ocean (termed “kelts”) (FERC, 2006).

7 Spawning in the Hanford Reach likely occurs between February and early June, with a peak in
 8 mid-May (Mueller and Geist, 1999). Steelhead construct redds in gravel substrate for their
 9 eggs. The redds are larger than those of other salmonids. Redds are located in water depths
 10 that range from 0.7–1.34 ft deep with a water velocities of 1.8–2.3 fps. Several inches to a foot
 11 of gravel are used to cover the eggs. Incubation time is about 40 days with water temperatures
 12 of 50 degrees Fahrenheit (Wydoski and Whitney, 2003). Fry emerge from the gravel 2–3 weeks
 13 after hatching (FERC, 2006) and remain in the peripheral waters of the pools until they are large
 14 enough to maintain themselves in the current (Wydoski and Whitney, 2003). As steelhead fry
 15 emerge from the river substrate and start to feed, they are about 1-in. (2.5-cm) long and
 16 vulnerable to predation, so they seek cover. Juveniles usually remain in tributary streams for
 17 2 years before becoming smolts and migrating to the ocean (Dauble, 2009). Depending on the
 18 temperature and productivity of the stream, it may take 1–7 years to reach smolt size (6–8 in.
 19 (15–20 cm)) (FERC, 2006), (Wydoski and Whitney, 2003). If they remain in freshwater for their
 20 entire lives, they are considered rainbow trout (Dauble, 2009). Smolt migrate downriver
 21 primarily in the late spring.

22 Juvenile steelhead behave differently in the Hanford Reach than they do in the slower moving
 23 reservoirs of the Columbia River. They move through the area in the vicinity of the CGS site in
 24 the deepest part of the river, although they tend to stay towards the surface when they are
 25 migrating through reservoirs. Most of the migration is at night, and the juvenile steelhead rest
 26 and feed near the shore during the day (Dauble, 2009).

27 Juvenile steelhead in freshwater feed on drifting mayflies, caddisflies, and chironomids as well
 28 as terrestrial insects and earthworms. Juvenile and adult steelhead in the ocean consume
 29 invertebrates such as barnacle larvae, copepods, squid, and amphipods as well as fish such as
 30 juvenile rockfish, sandlance, brown Irish lord (sculpin), and greenlings (Wydoski and Whitney,
 31 2003)

32 ***D-1.4.3.2 Population Trends***

33 Identification of steelhead redds is difficult because, unlike the fall Chinook salmon, they spawn
 34 primarily in the spring, and the high, turbid spring runoff obscures visibility (DOE, 2000). Aerial
 35 surveys, boat-deployed video, and digging in the gravels are methods used to confirm the
 36 existence of steelhead redds in the Hanford Reach. However, known historic areas where
 37 steelhead have prepared redds are shown in Figure D-1-10. Aerial surveys identified two
 38 regions having characteristics associated with steelhead redd characteristics, including the area
 39 upstream of the CGS intake structure between Islands 12 and 13 (RM 352) and another
 40 downstream near Island 15 (RM 349). In 2005, four redds were observed near Island 15 using
 41 a boat-deployed video camera, but no indication of spawning activity was observed; no redds
 42 were found around Islands 12 and 13 (Hanf, et al., 2006). From 2006–2008, aerial surveys did
 43 not find any evidence of steelhead spawning near the CGS intake and discharge structure
 44 (Duncan, et al., 2008), (Hanf, et al., 2006), (Hanf, et al., 2007), (Poston, et al., 2009).

1 Hatchery programs, including the Ringold Facility upstream of the CGS site, augment the
 2 natural spawning efforts in the mainstem Columbia River (Lohn, 2004). A total of six artificial
 3 propagation programs exist in the upper Columbia River, including in the Wenatchee, Methow,
 4 and Okanogan Rivers and near Winthrop and Omak.

5 Fish counts for steelhead (both hatchery and wild counts) are listed in Table D-1-6.

6 **Table D-1-6. Fish counts for Steelhead, 2005–2010**

| Year | Steelhead (wild & hatchery) | | | | Steelhead (wild only) | | |
|------|--------------------------------|------------|------------|---------------|--------------------------|------------|------------|
| | McNary | Ice Harbor | Difference | Priest Rapids | McNary | Ice Harbor | Difference |
| 2005 | 224,611 | 156,801 | 67,810 | 12,472 | 58,727 | 35,571 | 23,156 |
| 2006 | 205,235 | 124,813 | 80,422 | 10,408 | 46,630 | 27,697 | 18,933 |
| 2007 | 216,631 | 154,739 | 61,892 | 15,183 | 53,064 | 31,675 | 21,389 |
| 2008 | 221,377 | 172,410 | 48,967 | 16,625 | 58,780 | 42,003 | 16,777 |
| 2009 | 408,157 | 328,105 | 80,052 | 39,968 | 10,8792 | 76,434 | 32,358 |
| 2010 | 262,527 | 206,971 | 55,556 | 26,476 | 89,504 | 58,743 | 30,761 |

Source: (University of Washington, 2011)

7 **D-1.4.3.3 Endangered Species Act Listing History**

8 The Upper Columbia River steelhead was listed as an endangered species on August 18, 1997
 9 (62 FR 43937). The status was upgraded to threatened on January 5, 2006 (71 FR 834),
 10 reinstated to endangered in June 2007 based on a district court ruling (*Trout Unlimited v. Lohn*,
 11 C06-0483-JCC, 2007), and then upgraded to threatened by U.S. District Court order in June
 12 2009. The Upper Columbia River steelhead is currently listed as threatened (74 FR 42605) by
 13 the NMFS. The listing is defined as the “Distinct Population Segment (DPS) including all
 14 naturally spawned anadromous steelhead populations below natural and manmade impassable
 15 barriers in streams in the Columbia River Basin, upstream from the Yakima River, Washington,
 16 to the U.S.-Canada border” (71 FR 834). The steelhead associated with six artificial
 17 propagation programs are also part of the listing, including the Wenatchee River, Wells
 18 Hatchery (in the Methow and Okanogan rivers), Winthrop National Fish Hatchery, Omak Creek,
 19 and the Ringold steelhead hatchery programs (71 FR 834). NMFS reports that, based on
 20 genetic evidence, hatchery stocks remain closely related to the naturally spawned populations,
 21 and they maintain the local genetic distinctiveness of populations that are within the DPS.
 22 Critical habitat for the Upper Columbia River steelhead was designated on September 2, 2005
 23 (70 FR 52630), and final revised protective regulations were issued for this DPS on February 1,
 24 2006 (71 FR 5178). The revised protective regulations apply take prohibitions from ESA
 25 Section 9 (a)(1) to unmarked anadromous fish with an intact adipose fin that are part of the
 26 Upper Columbia River steelhead DPS. Clipping the adipose fins of hatchery fish just prior to
 27 their release differentiates them from wild fish.

1 **D-1.4.4 Coho Salmon (*Oncorhynchus kisutch*)**

2 **D-1.4.4.1 Life History**

3 Coho salmon are anadromous. They have a slightly different life history than Chinook salmon,
4 although they both spawn in freshwater and both die after spawning. The juvenile coho
5 normally spend a year in freshwater before they become smolts and migrate to the ocean. They
6 live in the ocean for about 18 months, although some fish return after only 5–7 months. The fish
7 that return after less than a year in the ocean are termed jacks (precocious male coho salmon
8 that become sexually mature 1 year earlier than the typical adult coho). Mature adults return at
9 age 3 (Wydoski and Whitney, 2003) and enter freshwater between early August to
10 mid-November in Washington State after spending about 18 months in the Pacific Ocean. Like
11 the Chinook salmon, there is also a summer run of coho salmon that enter the rivers in late
12 spring or early summer. However, unlike the Chinook, they tend to spawn at the same time no
13 matter when they enter the freshwater (PFMC, 2000), (Wydoski and Whitney, 2003).

14 Coho have been described as the least particular salmonid in terms of their choice of spawning
15 area. They spawn in mountain streams in riffles or on gravel bars in large rivers and tributaries
16 (Sandercock, 1991). However, they tend to select gravel sites that have good circulation of
17 oxygenated water and nearby cover (PFMC, 2000), (Sandercock, 1991). After spawning, the
18 adults die. The alevins hatch in about 6–8 weeks (depending on the temperature of the water),
19 and the young emerge from the gravel about 2–3 weeks after hatching (Dauble, 2009). Days to
20 emergence are reported to range from 28 days at 51 degrees Fahrenheit (10.7 degrees Celsius)
21 to 137 days at 36 degrees Fahrenheit (2.2 degrees Celsius) has been reported (PFMC, 2000).
22 The young usually congregate in pools in the stream after emergence (Wydoski and Whitney,
23 2003). Their preferred habitat includes areas with abundant prey and different types of pools,
24 glides, and riffles with large woody debris, undercut banks, and overhanging vegetation. They
25 prefer temperatures in the water to be around 50–59 degrees Fahrenheit (10–15 degrees
26 Celsius), although they can tolerate temperatures between 32–79 degrees Fahrenheit (0–26
27 degrees Celsius). DO levels need to be above 4 mg/L; a sustained concentration less than
28 2 mg/L is lethal (PFMC, 2000).

29 Dauble (2009) indicated that coho in the upper Columbia River remain 1–2 years before
30 becoming smolts and are approximately 3–6 in. (8–15 cm) long when they migrate. Migration
31 occurs between March and late June, with the peak from late April to mid-June, depending on
32 the stock and the run (Wydoski and Whitney, 2003). Downstream migration timing for Priest
33 Rapids Dam is April–June (FERC, 2006).

34 The diet of juvenile coho consists primarily of zooplankton, such as *Daphnia*, and emerging
35 aquatic insects. In streams, coho feed on insects, mayflies, and stone flies as well as worms,
36 fish eggs, and fish. They are also known to eat steelhead larvae. It is thought that the
37 Columbia River coho salmon juveniles remain in the estuary for several days to weeks. In the
38 estuary, the salmon consume large planktonic or small nektonic animals, including amphipods,
39 insects, decapods larvae, and larval and juvenile fish. While in the ocean, juvenile coho off the
40 coast of Oregon and Washington feed on Pacific herring and smelt during strong upwelling
41 years or on northern anchovy and juvenile rockfish during poor upwelling years. They consume
42 invertebrates such as crab larvae, amphipods, copepods, squid, and euphausiid shrimp
43 (Wydoski and Whitney, 2003).

1 **D-1.4.4.2 Population Trends**

2 Coho are found from Monterey Bay, CA, north to Point Hope, AK. They are also found in
 3 northeast Asia from the Anadyr River south to Hokkaido, Japan. They are anadromous and
 4 were once abundant in the tributaries of the upper Columbia and Snake Rivers. Commercial
 5 harvest of coho peaked in the Columbia and Snake Rivers in 1925 and then declined.
 6 Spawning populations were observed in the Columbia River as recently as 1970, and natural
 7 migrations disappeared by the mid-1970s (Wydoski and Whitney, 2003). Factors that caused
 8 the loss of coho to the upper Columbia River include the construction and operation of
 9 hydroelectric, irrigation and splash dams (used as reservoirs to transport logs), degradation of
 10 streams, and high fishing mortality (Wydoski and Whitney, 2003). Hatcheries were built in the
 11 lower part of the river to mitigate the loss of habitat caused by dams. Building the hatcheries in
 12 the lower part of the river was meant to minimize mortality from dams. However, the salmon
 13 from these hatcheries concentrated in the lower river, which resulted in heavy fishing pressure.
 14 The wild fish also mixed with the hatchery fish and were unable to maintain themselves; thus,
 15 they were eliminated. Currently, coho salmon are being restocked into the Methow,
 16 Wenatchee, and Yakima Rivers in an effort to reestablish the runs in the mid-Columbia.

17 In the late 1990s, coho salmon catches in Alaska were at historically high levels, and the
 18 abundance trends were stable (PFMC, 2000). However, stocks of wild coho salmon from the
 19 Columbia River Basin above Bonneville Dam are thought to extirpated, and natural migrations
 20 disappeared in the mid-1970s (Dauble, 2009), (FERC, 2006). Hatcheries in the Methow and
 21 Wenatchee Rivers supplement the current population. Efforts are being made to reestablish
 22 runs (FERC, 2006).

23 Table D-1-7 shows the numbers of adult (not jack) coho that passed through the Hanford Reach
 24 and by Priest Rapids Dam from 2005–2010.

25 **Table D-1-7. Numbers of adult (not jack) Coho that passed through the Hanford Reach**
 26 **and by Priest Rapids Dam, 2005–2010**

| Year | Adult Coho |
|------|------------|
| 2005 | 17,779 |
| 2006 | 11,838 |
| 2007 | 18,436 |
| 2008 | 15,867 |
| 2009 | 28,411 |
| 2010 | 12,152 |

Source: (University of Washington, 2011)

27 **D-1.4.4.3 Endangered Species Act Listing History**

28 The wild coho salmon is extinct in the upper Columbia River. The NMFS lists coho salmon as
 29 threatened for the lower Columbia River from the mouth of the river upstream to and including
 30 the Big White Salmon and Hood Rivers, downstream of the Hanford Reach. It does not have

1 ESA status or include critical habitat in the Hanford Reach or the upper Columbia River or
 2 critical habitat. However, the Columbia River in the vicinity of the CGS plant (the Hanford
 3 Reach) provides EFH features for the coho salmon, which is currently an unlisted reintroduction
 4 effort. The NMFS, in its letter to the NRC dated June 23, 2010 (Suzumoto, 2010), asked that
 5 the staff include the Upper Columbia River coho in consultation and assess the likely adverse
 6 effects of the project on their essential habitat.

7 **D-1.4.4.4 Designated Essential Fish Habitat in the Vicinity of Columbia**
 8 **Generating Station**

9 The staff has determined that EFH for coho salmon may exist in the vicinity of CGS. The NMFS
 10 has designated coho salmon EFH in the Columbia River in the vicinity of the CGS plant.
 11 Environmental requirements for coho salmon EFH are listed in Table D-1-8. Table D-1-9
 12 illustrates the lifestages of the Upper Columbia River Chinook salmon that are present in the
 13 Hanford Reach.

14 **Table D-1-8. Coho Salmon EFH descriptions by life stage**

| Life stage | Habitat type | Temperature | Depth | Flow | Seasonal occurrence in estuaries |
|------------------------------|---|---|---|---|----------------------------------|
| Eggs | Gravel sites with good circulation of oxygenated water & nearby cover; 20% fine sediment, 0.5–4 in. (1.3–10.2 cm) gravel (Freshwater) | 39–52 °F (4–11 °C) | 9.8 in. (25 cm) (range 7–15.4 in. (17.8–39.1 cm)) in gravel; depth of water 6.2 in. (15.7 cm) (range 4.0–7.99 in. (10.2–20.3 cm)) | 0.98–1.8 fps (0.30–0.55 m/s) | Not applicable |
| Alevins | Remain in the redds (Freshwater) | 33–51 °F (0.8–10.7 °C) | May move downward in redds 2–8 in. (5–20 cm); depends on size of gravel spaces | 0.98–1.8 fps (0.30–0.55 m/s) | Not applicable |
| Young juveniles | Pools, glides, and riffles with large woody debris, undercut banks, & overhanging vegetation (Freshwater) | Preferred 54–57 °F (12–14 °C) (can tolerate 32–77 °F (0–25 °C)) | Summer—10–11 in. (25–28 cm) deep; by December 17.7-in. (45-cm) depth | 0.3–<1 fps (9–<30 cm/s) <1.5 fps (47 cm/s) | Not applicable |
| Migrating smolts (juveniles) | Mainstem of river to estuary (Freshwater to saline) | 41–56 °F (5–13.3 °C) (Alaska) | Surface oriented | <8 fps (2.44 m/s) | April–July |
| Adults | Ocean—normally stay south of Vancouver Island (Saltwater) | Highest minimum ocean temperatures 41–43 °F (5–5.9 °C); not generally found in water cooler than 7 °C | Up to 100 ft (30 m) | Ocean | Not applicable |
| Migrating adults | Estuary/River (saltwater to freshwater) | Variable | Variable | <8 fps (2.44 m/s) | August–November |

| Life stage | Habitat type | Temperature | Depth | Flow | Seasonal occurrence in estuaries |
|-----------------|---|------------------------|-----------------------------|-----------------|----------------------------------|
| Spawning adults | Mountain streams in riffles or gravel bars in large rivers & tributaries (Freshwater) | 45–60 °F (7.2–15.6 °C) | Minimum depth 7 in. (18 cm) | 1 fps (31 cm/s) | Not applicable |

Source: (Laufle, et al., 1986), (Lestelle, 2007), (PFMC, 2000), (Sandercock, 1991), (University of Washington, 2011), (Wydoski and Whitney, 2003)

1 **Table D-1-9. Coho life stages currently present in the Hanford Reach**

| Life stages | Present in Hanford Reach |
|------------------|--------------------------|
| Eggs | |
| Alevins | |
| Young juveniles | |
| Migrating smolts | x |
| Juveniles | |
| Adults | |
| Migrating adults | x |
| Spawning adults | |

2 **D-1.5 Endangered Species Act Effects Analysis**

3 **D-1.5.1 Bull Trout**

4 The USFWS considers the Hanford Reach of the mainstem Columbia River to be a potential
 5 migratory corridor for bull trout (USFWS, 2010b). Migratory corridors are important for bull trout.
 6 According to Rieman and McIntyre (1993), migratory corridors allow salmonids to stray and
 7 interbreed with individuals in non-natal streams. Migration is also important for the
 8 reestablishment of populations following catastrophic events that decimate the population.

9 However, observation of bull trout in the Hanford Reach is rare, and it is likely that they seldom
 10 use this migratory corridor. Resource scientists at DOE’s Hanford Site have characterized the
 11 use of the Hanford Reach by bull trout as transient (Poston, et al., 2009). USFWS (2008)
 12 indicated that the accounts of bull trout in the Hanford Reach are “anecdotal,” and it is “likely
 13 individuals moved downstream during the spring freshet.”

14 Furthermore, the habitat and water temperatures in the Hanford Reach are not ideal for
 15 spawning, and there are no reports of spawning activity by bull trout in the vicinity of CGS
 16 (Dauble, 2009), (Marten, 2007). Variation in the size of the river channel as a result of changing
 17 flows from Priest Rapids Dam and the lack of cover also make it unlikely that the bull trout are
 18 spawning in the Hanford Reach. The temperature range in the Hanford Reach exceeds the
 19 maximum temperature for the bull trout spawning. Data from previous years (WPPSS, 1986)
 20 show that the temperature of the river is above 59 degrees Fahrenheit (15 degrees Celsius)
 21 from the end of June or July until at least the middle of October. During these periods, the bull
 22 trout are unlikely to even be present in the Hanford Reach.

1 The lack of spawning in the Hanford Reach means that there is no potential for young bull trout
2 or bull trout eggs to be entrained or impinged at the CGS site. Furthermore, entrainment
3 studies conducted in 1979–1980 and 1985 did not collect any life stage of fish (EN, 2010),
4 (WPPSS, 1986). Impingement studies conducted over the same period did not observe any fish
5 impinged on the intake screens (EN, 2010), (WPPSS, 1986). Healthy adult bull trout that
6 commonly inhabit rivers with water velocities above 4 fps (1.2 m/s) would not be susceptible to
7 impingement with a through-screen velocity of 0.5 fps (15 cm/s).

8 As discussed previously, bull trout actively select cooler water, so there would be little potential
9 for them to be affected by the thermal or chemical discharge from the CGS plant. The thermal
10 effluent from the blowdown discharge during the spring is a long, narrow plume, comprising
11 approximately 1 percent of the width of the river, and bull trout would likely avoid it while
12 migrating or foraging.

13 Because this stretch of the river is not spawning or rearing habitat for bull trout, and because
14 bull trout are so rare in this area, the staff has determined that the continued operation of CGS
15 will have no effect on the bull trout.

16 **D-1.5.2 Upper Columbia River Chinook Salmon**

17 The endangered Upper Columbia River spring Chinook salmon are found in the vicinity of the
18 intake and discharge systems for CGS as they migrate through the Hanford Reach as adults or
19 as juveniles as they migrate downstream. As a result, there is a potential for the continued
20 operation of the CGS plant during the renewal period to affect the Upper Columbia River spring
21 Chinook.

22 As discussed in Section D-1.4.2.1, Upper Columbia River spring Chinook salmon do not spawn
23 in the Hanford Reach. Adults start returning from the ocean in early spring and pass through
24 the Hanford Reach while migrating to upstream spawning grounds in the Wenatchee, Entiat,
25 Methow, and Okanogan river basins (70 FR 52630), (Lohn, 2004). Juveniles pass through the
26 Hanford Reach while migrating downstream toward the ocean after spending 1–2 years in the
27 upper tributaries (Wydoski and Whitney, 2003). The travel time for a juvenile through the
28 Hanford Reach is generally less than 1 week; outmigration of the juvenile spring Chinook
29 extends from April to the end of August (DOE, 2000).

30 Young-of-the-year spring Chinook in the upper Yakima River Basin preferred water depths from
31 1.6–1.8 ft deep (49–55 cm), with bottom velocities of 0.8–0.9 fps (0.24–0.27 m/s). By spring
32 they occupied habitats that were shallower (0.8 ft deep (24 cm)) with a bottom water velocity of
33 1.4 fps (0.43 m/s) (Wydoski and Whitney, 2003).

34 Entrainment studies conducted in 1979–1980 and 1985 did not collect any life stage of fish (EN,
35 2010), (WPPSS 1986). Impingement studies conducted over the same period did not observe
36 any fish impinged on the intake screens (EN, 2010), (WPPSS 1986). Furthermore, juvenile
37 spring Chinook are too large to be entrained in an intake with openings of $\frac{3}{8}$ -in.
38 (9.5 mm)-diameter holes. In addition, juvenile spring Chinook occupying habitats with a water
39 velocity of 1.4 fps (0.43 m/s) are easily able to avoid impingement in an intake with a
40 through-screen velocity of 0.5 fps (15 cm/s). Healthy migrating adult Chinook are also able to
41 avoid impingement. Migrating Chinook salmon would also be able to avoid the narrow thermal
42 plume, comprising approximately 1 percent of the width of the river. During thermal drift studies
43 in 1985, juvenile fall Chinook floated in cages through the thermal and chemical effluent of the
44 blowdown discharge had no measurable impacts from the exposure to the heated water and
45 blowdown chemicals (WPPSS, 1986).

1 Because no fish, including spring Chinook, were collected during entrainment and impingement
2 studies, and because thermal drift studies of fall Chinook and steelhead had no measurable
3 impact on the fish, the staff determines that the continued operation of CGS may affect, but is
4 not likely to adversely affect, the Upper Columbia River Chinook salmon.

5 **D-1.5.3 Upper Columbia River Steelhead**

6 Upper Columbia River steelhead have been observed spawning in the Hanford Reach and in
7 the vicinity of the intake and discharge structures for the CGS plant in the past. The most
8 recent confirmed observations of active steelhead redds were in 2003, below the CGS intake.
9 From 2006–2009, the aerial surveys did not find any evidence of steelhead spawning near the
10 CGS intake and discharge structure or in the Hanford Reach (Hanf, et al., 2007), (Poston, et al.,
11 2008), (Poston, et al., 2010). Considering the distance upstream of previously observed redds,
12 it is unlikely that steelhead eggs would travel to the intake structure. Steelhead redds that may,
13 in the future, be located near the intake and discharge structures could experience entrainment
14 of eggs that do not settle within the redd. However, eggs that do not settle are already lost from
15 the population due to predation or other causes.

16 Larval steelhead from upstream redds are also vulnerable to entrainment. Upon hatching, the
17 alevin remain in the gravel for 2–3 weeks or in the vicinity of the redd until they are able to
18 maintain themselves in the current. Once they are able to maintain themselves in the river
19 current, they are able to avoid the 0.5-fps (0.15 m/s) through-screen intake velocity.

20 Entrainment studies conducted in 1979–1980 and 1985 did not collect any life stage of fish (EN,
21 2010), (WPPSS, 1986). Impingement studies conducted over the same period did not observe
22 any fish impinged on the intake screens (EN, 2010), (WPPSS, 1986).

23 As observed by divers in 1985, the support and riprap around the intake structure provides
24 shelter for fish species that consume other fish (WPPSS, 1986); thus, indirectly, the intake
25 structure might affect the survival of the fry.

26 Adults and juveniles can avoid the influence of the intake and discharge structures. Juvenile
27 steelhead that migrate through the Hanford Reach do so in the deepest part of the river and
28 stay near the river bottom (Dauble, 2009).

29 As mentioned previously during thermal drift studies in 1985, juvenile steelhead floated in cages
30 through the thermal and chemical effluent of the blowdown discharge had no measurable
31 impacts from the exposure to the heated water and blowdown chemicals (WPPSS, 1986).

32 **D-1.6 Potential Adverse Effects to EFH**

33 The provisions of the MSA define an “adverse effect” to EFH as the following (50 CFR 600.810):

34 *Adverse effect* means any impact that reduces quality and/or quantity of EFH.
35 Adverse effects may include direct or indirect physical, chemical, or biological
36 alterations of the waters or substrate and loss of, or injury to, benthic organisms,
37 prey species and their habitat, and other ecosystem components, if such
38 modifications reduce the quality and/or quantity of EFH. Adverse effects to EFH
39 may result from actions occurring within EFH or outside of EFH and may include
40 site-specific or habitat-wide impacts, including individual, cumulative, or
41 synergistic consequences of actions.

1 For the purposes of conducting NEPA reviews, the staff published the “Generic Environmental
 2 Impact Statement for License Renewal of Nuclear Plants” or “GEIS” (NRC, 1996), which
 3 identifies 13 impacts on aquatic resources as either “Category 1” or “Category 2.” Category 1
 4 issues are generic in that they are similar at all nuclear plants and have one impact level
 5 (SMALL, MODERATE, or LARGE) for all nuclear plants, and mitigation measures for
 6 Category 1 issues are not likely to be sufficiently beneficial to warrant implementation.
 7 Category 2 issues vary from site to site and must be evaluated on a site-specific basis.
 8 Table D-1-10 lists the aquatic resource issues identified in the GEIS.

9 **Table D-1-10. Aquatic resource issues identified in the GEIS**

| Issues | Category | Impact level |
|--|----------|---------------------------|
| For All Plants^(a) | | |
| Accumulation of contaminants in sediments or biota | 1 | SMALL |
| Entrainment of phytoplankton & zooplankton | 1 | SMALL |
| Cold shock | 1 | SMALL |
| Thermal plume barrier to migrating fish | 1 | SMALL |
| Distribution of aquatic organisms | 1 | SMALL |
| Premature emergence of aquatic insects | 1 | SMALL |
| Gas supersaturation (gas bubble disease) | 1 | SMALL |
| Low DO in the discharge | 1 | SMALL |
| Losses from parasitism, predation, & disease among organisms exposed to sublethal stresses | 1 | SMALL |
| Stimulation of nuisance organisms | 1 | SMALL |
| For plants with cooling-tower-based heat-dissipation systems^(a) | | |
| Entrainment of fish & shellfish in early life stages | 1 | SMALL |
| Impingement of fish & shellfish | 1 | SMALL |
| Heat shock | 1 | SMALL |
| For plants with once-through heat-dissipation systems^(b) | | |
| Impingement of fish & shellfish | 2 | SMALL, MODERATE, or LARGE |
| Entrainment of fish & shellfish in early life stages | 2 | SMALL, MODERATE, or LARGE |
| Heat shock | 2 | SMALL, MODERATE, or LARGE |

^(a) Applicable to CGS

^(b) Not applicable to CGS because CGS has a closed-cycle cooling system

Source: (NRC, 1996)

10 The GEIS classifies all impacts levels for aquatic resources as “SMALL” except impingement,
 11 entrainment, and heat shock. “SMALL” is defined as “having environmental effects that are not
 12 detectable or are so minor that they will neither destabilize nor noticeably alter any important
 13 attribute of the resource” (10 CFR Part 51, App. B, Table B-1). The staff believes that the
 14 impacts concluded to be “SMALL” will also be small for EFH. Therefore, this EFH Assessment
 15 focuses on the potential adverse effects of impingement, entrainment, and heat shock on EFH.

- 1 • **Impingement** occurs when aquatic organisms are pinned against intake screens or
2 other parts of the cooling-water-system intake structure.
- 3 • **Entrainment** occurs when aquatic organisms (usually eggs, larvae, and other small
4 organisms) are drawn into the cooling-water system and are subjected the thermal,
5 physical, and chemical stress.
- 6 • **Heat shock** is acute thermal stress caused by exposure to a sudden elevation of water
7 temperature that adversely affects the metabolism and behavior of fish and other aquatic
8 organisms. In addition to heat shock, increased water temperatures at the discharge
9 can also reduce the available habitat for fish species if the discharged water is higher
10 than the environmental preferences of a particular species. This issue is discussed
11 together with heat shock.

12 In addition to impingement, entrainment, and heat shock, the staff assessed the impacts on
13 EFH species' food (forage species) in the form of displacement or loss of forage species and
14 loss of forage species habitat. The staff also assessed cumulative impacts on EFH species or
15 their habitat resulting from the past, present, and reasonably foreseeable future projects in the
16 vicinity of CGS.

17 In summary, the staff has identified the following potential adverse effects on EFH as a result of
18 the proposed license renewal of CGS:

- 19 • loss of habitat
- 20 • impingement
- 21 • entrainment
- 22 • thermal effects (heat shock and loss of habitat)
- 23 • loss of forage species.

24 The following sections address each of these issues for each of the three species identified for
25 in-depth analysis in Section D-1.3.2. Section D-1.7 discusses cumulative effects.

26 **D-1.6.1 Upper Columbia River Chinook Salmon**

27 As discussed in Section D-1.4.2, the NMFS has designated EFH for Upper Columbia River
28 Chinook salmon migrating smolts and migrating adults (spring and summer runs) as well as
29 EFH for all life stages (fall runs) within the vicinity of CGS. The potential effects on this species'
30 EFH as a result of the proposed action are considered in the following sections.

31 ***D-1.6.1.1 Loss of Habitat***

32 The spring and summer runs of Upper Columbia River Chinook use the stretch of the river along
33 the Hanford Reach as migratory and foraging habitat for the juveniles and as migratory habitat
34 for the adults that rarely feed during their upstream migration. The fall run uses the Hanford
35 Reach as spawning and nursery habitat. However, the removal of approximately 0.03 percent
36 of the average mean annual discharge past the site, or 0.05 percent of the minimum mean
37 annual discharge past the site, does not significantly alter the amount of habitat available to the
38 Upper Columbia River Chinook salmon.

1 **D-1.6.1.2 Impingement**

2 Spring-run Chinook life stages are not susceptible to impingement, as discussed in
 3 Section D-1.5.2. Each individual juvenile spring Chinook salmon is only present in the Reach
 4 for a short time (approximately 1 week) and is accustomed to living in flows greater than that
 5 encountered near the intake 0.2–0.5 fps (0.06–0.15 m/s). Juvenile summer-run Chinook are
 6 also migrating through the site, but they move downriver more slowly than the juvenile
 7 spring-run Chinook. However, they are also able to maintain themselves in flows that are
 8 faster than the intake flow velocities and, thus, are not susceptible to impingement. In general,
 9 ocean-type juveniles orient toward the current and are able to maintain their positions during the
 10 day for velocities that range from 0.16 to less than 0.83 fps (5–25 cm/s). They drift downstream
 11 at velocities of 0.83–1.3 fps (25–41 cm/s) during the day and at lower velocities at night
 12 (Wydoski and Whitney, 2003).

13 In the Hanford Reach, the fall Chinook remain in the area for the first few months after
 14 emergence generally at water depths of less than 3 ft (0.9 m). They move to deeper water
 15 when they are larger and closer to the time of their migration (Wydoski and Whitney, 2003). Fall
 16 Chinook in the Hanford Reach are reported to be able to maintain their position in waters with
 17 velocities up to 1.3 fps (41 cm/s); thus, they are not susceptible to the approach velocity of an
 18 intake of less than 0.2 fps (0.06 m/s) (WPPSS, 1980) or a through-screen velocity of less than
 19 0.5 fps (0.15 m/s). Studies conducted in 1978, 1979, and 1985 looked for—but did not find—
 20 any fish or debris impinged on the screens (EN, 2010), (WPPSS, 1986). However, the 1985
 21 study did find that fish were using the intake support system for cover and resting, including
 22 largescale suckers (*Catostomus macrocheilus*), mountain whitefish (*Prosopium williamsoni*),
 23 sculpins (*Cottus* spp.), Northern pikeminnow (*Ptychocheilus oregonensis*), bass (*Micropterus*
 24 spp.), reddsider shiner (*Richardsonius balteatus*), and American shad (*Alosa sapidissima*)
 25 (WPPSS, 1986). During one of the observation periods for impingement in 1985, samples of
 26 juvenile Chinook were collected, showing that anadromous species were in the area of the
 27 intake screens but were not being affected by the water withdrawal (WPPSS, 1986).

28 **D-1.6.1.3 Entrainment**

29 Spring-run Chinook salmon life stages are not susceptible to entrainment. Juvenile spring
 30 Chinook migrating through the Hanford Reach are too large to be entrained through the $\frac{3}{8}$ -in.
 31 (9.5-mm) holes in the intake structure screen. Summer-run Chinook salmon life stages that
 32 pass through the Hanford Reach are also not susceptible to entrainment.

33 Fall-run Chinook salmon spawn in the Hanford Reach and, therefore, need to be considered
 34 further to determine the potential for entrainment of the eggs and alevins or smolts that occur
 35 upstream of the intake. As discussed in Section D-1.4.2, the adult salmon lay their eggs in
 36 redds in gravel with an approximate 4–13 in. (10–33 cm), averaging 7.4 in. (18.8 cm) of gravel
 37 covering the eggs (Healey, 1991). The eggs in the redds are not susceptible to entrainment
 38 unless disturbed. Although some eggs are lost during spawning, these eggs will not survive
 39 even in the absence of entrainment.

40 Upon hatching, the alevins live in the gravel for about 2–3 weeks and, in general, move deeper
 41 into the gravel after hatching (Quinn, 2005). Because the alevins remain close to the redds,
 42 they would not be susceptible to entrainment. Young juveniles can maintain their position in the
 43 current and would not be susceptible to entrainment by the intake, which has a slower approach
 44 velocity than the current.

1 No fish, fish eggs, or larvae were collected during entrainment studies completed in 1979–1980
2 and 1985. In the 1985 study, beach seine samples collected juvenile Chinook salmon
3 (averaging 43 mm in length), confirming their presence in the area (EN, 2010), (WPPSS, 1986).

4 ***D-1.6.1.4 Thermal Effects***

5 Migrating Chinook salmon would also be able to avoid the thermal plume that forms a long,
6 narrow plume, approximately 1 percent of the width of the river. During thermal drift studies in
7 1985, juvenile fall Chinook floated in cages through the thermal effluent of the blowdown
8 discharge had no measurable impacts from the exposure to the heated water (WPPSS, 1986).

9 ***D-1.6.1.5 Loss of Forage Species***

10 As mentioned previously, adult Chinook salmon do not feed during upstream spawning
11 migration. However, the smolts descending downstream do feed. The juveniles forage on
12 aquatic insects (Dauble, 2009). The movement of a juvenile through the Hanford Reach lasts
13 no more than 1 week; outmigration of the juvenile spring Chinook extends from April to the end
14 of August (DOE, 2000). Fall Chinook salmon juveniles spend more time in the Hanford Reach
15 than the spring or summer Chinook. They feed on midge larva and zooplankton, progressing
16 to caddisfly larvae and other aquatic insect larvae and some terrestrial insects (Dauble, 2009).
17 The loss of food as a function of the water withdrawn is likely less than the 0.03 percent of the
18 average mean annual discharge because the water for the CGS plant is drawn from the bottom
19 of the river, rather than from the more productive shallower areas of the river

20 ***D-1.6.2 Coho Salmon***

21 As discussed in Section 4.4, the NMFS has designated EFH for coho salmon, which is currently
22 an unlisted reintroduction effort. Currently, coho are being stocked in the Wentachee and
23 Methow Rivers in an effort to supplement the current population and reestablish the runs.
24 Migrating adults rarely feed as they pass through the Reach. Migrating smolts do feed, most
25 likely on insects, mayflies, and stoneflies as well as worms, fish eggs, and fish.

26 ***D-1.6.2.1 Loss of Habitat***

27 The coho salmon use the stretch of the river along the Hanford Reach as migratory and feeding
28 habitat for the juveniles and as migratory habitat for the adults that rarely feed during their
29 upstream migration. The continued operation of the CGS facility will affect the habitat primarily
30 through the removal of approximately 0.03 percent of the average mean annual discharge past
31 the site or 0.05 percent of the minimum mean annual discharge past the site. This does not
32 significantly alter the amount of habitat available to the coho salmon.

33 ***D-1.6.2.2 Impingement***

34 Migrating coho smolts are too large to be impinged at the intake structure, and they are used to
35 swimming in currents that have a higher velocity than the intake velocity. Healthy adult coho
36 are not susceptible to impingement.

37 ***D-1.6.2.3 Entrainment***

38 Migrating coho smolts and adult coho salmon are not susceptible to entrainment.

1 **D-1.6.2.4 Thermal Effects**

2 Migrating coho salmon would also be able to avoid the thermal plume that forms a long, narrow
3 plume, approximately 1 percent of the width of the river. Migration of coho smolts occurs during
4 the spring when the water temperature is coldest and the water velocities are the highest. In
5 addition, thermal studies in 1985—on other salmonids that floated through the thermal
6 effluent—indicated that the blowdown discharge had no measurable impacts from the exposure
7 to the heated water (WPPSS, 1986).

8 **D-1.6.2.5 Loss of Forage Species**

9 The diet of juvenile coho consists primarily of zooplankton, such as *Daphnia*, and emerging
10 aquatic insects. In streams, the coho feed on insects, mayflies, and stone flies as well as
11 worms, fish eggs, and fish. They are also known to eat steelhead larvae (Wydoski and
12 Whitney, 2003). The loss of food as a function of the water withdrawn is likely less than the
13 0.03 percent of the average mean annual discharge because the water for the CGS plant is
14 drawn from the bottom of the river rather than from the more productive shallower areas of the
15 river.

16 **D-1.7 Endangered Species Act and Essential Fish Habitat Cumulative Effects**
17 **Analysis**

18 The irreversible changes to aquatic life in the Columbia River started with the completion of the
19 first hydropower project, Rock Island Dam, in 1933. Specific alterations are documented with
20 the completion of other dams in the Columbia River basin. Hydropower has been a significant
21 contributor to the decline of native anadromous species, including the Upper Columbia River
22 spring Chinook salmon (Dauble, 2009), (Dauble and Watson, 1997), (Wydoski and
23 Whitney, 2003).

24 The upper Columbia River migratory salmonids are subjected to passage mortalities from four
25 lower Columbia River Federal dam projects and a variety of Mid-Columbia River Public Utility
26 District dam projects (seven mainstem dams for the Wenatchee River; eight dams for the
27 Methow, and nine for the Okanagan River). Hydropower projects affect passage mortality
28 during upstream and downstream migrations, cause river fluctuations associated with upstream
29 dam operations that affect habitat and spawning success, create migratory blocks, and increase
30 fishing pressure. Fall Chinook and steelhead that spawn in the Hanford Reach are affected by
31 the fluctuations of Priest Rapids Dam. This primarily affects the juvenile fall Chinook that use
32 the shallow, low-velocity nearshore areas for rearing, feeding, cover, and protection from
33 predators. Because fall Chinook spawn in the late fall, the river level fluctuations in the winter
34 have resulted in the desiccation of redds. In addition, fluctuations in water level can strand
35 juvenile Chinook salmon on either gently sloped shorelines, gravel bars, or in shallow
36 depressions created by receding water (Anglin, et al., 2006), (Geist, 1999), (Nugent, et al.,
37 2002), (Wagner, 1995). Juvenile fall Chinook salmon loss estimates due to water fluctuations
38 ranged from 45,000–1,630,000 fish a year from 1999–2003 for an 8.7 mi (14 km) section of the
39 Hanford Reach (Anglin, et al., 2006), (Nugent, et al., 2002).

40 River fluctuations are now intentionally managed at Priest Rapids Dam during the fall-run
41 Chinook spawning season in order to confine the spawning activity to lower river elevations by
42 discouraging the salmon from spawning in areas that are exposed at low river flow in the winter.
43 Although water management efforts at Priest Rapids Dam are improving fall Chinook salmon

1 spawning and rearing survival, there are still concerns relating to the affects of frequent water
2 level alterations on migration and habitat displacement.

3 The construction and operation of nine nuclear reactors on the Hanford Site from 1943–1987
4 influenced the aquatic environment of the Hanford Reach. Cofferdams restricted water flow
5 during the placement of shoreline intake structures and discharge lines within the river. The
6 operation of the Hanford Site led to the release of more than 60 radionuclides, numerous
7 process chemicals, and waste heat into the Hanford Reach (Becker, 1990), (Duncan, et
8 al., 2007). The overall impact on the aquatic resources from the operation of the Hanford Site
9 has yet to be determined and drives ongoing cleanup activities as well as a natural resource
10 damage assessment (Poston, et al., 2009).

11 The seasonal and daily water fluctuations associated with the operation of Priest Rapids Dam
12 also may affect exposure of aquatic life to environmental contaminants from the Hanford Site.
13 Groundwater transports contaminants from the Hanford Site to the Columbia River. High river
14 stages can retard groundwater transport and concentrate the contaminants in the riverbank at
15 low river stage. The benthic organisms in the river are the first receptors of contaminated
16 groundwater. Groundwater plumes from the Hanford Site that are close to or flowing into the
17 river include chemicals and radionuclides such as chromium, nitrate, strontium-90, tritium, and
18 uranium. Concentrations of the chemical contaminants in the river are below ambient-water
19 quality criteria for the protection of aquatic species. Although small amounts of radioactive
20 materials are detectable in the Columbia River water and sediment samples downstream from
21 the Hanford Site, the amounts are far below Federal and State limits. Other sources that may
22 contribute to the cumulative effect of chemical contaminant exposure to aquatic resources in the
23 Hanford Reach include high concentrations of nitrate in the groundwater across from the
24 Hanford Site, agricultural returns flowing into the river, and upstream mining activities. DOE's
25 monitoring and remediation programs are addressing the risk to aquatic species in the Hanford
26 Reach from the influence of contaminated groundwater (DOE, 2009), (Duncan, et al., 2007),
27 (Miley, et al., 2007), (Poston, et al., 2009).

28 Another regional concern is the withdrawal of Columbia River water. Permitting by resource
29 agencies limits the total consumptive loss and balances the need of multiple water users
30 (EN, 2010). While the relatively few water withdrawal systems within 20 mi (32 km) are
31 primarily for municipal use, the number of permitted withdrawals is considerable. Direct impacts
32 on aquatic biota can occur from the intake structures (e.g., entrainment and impingement), and
33 oversight by resource agencies and use of best available technologies that consider protection
34 of aquatic life (e.g., screen systems and fish diversions) may minimize the effects on aquatic
35 life. Indirect impacts on aquatic biota from consumptive water loss in the area of interest range
36 from contributions to extreme seasonal water-level fluctuations to the loss of habitat or fish
37 passage, water quality, and water temperature.

38 Development also contributes to cumulative effects on aquatic life due to decreases in water
39 quality and available habitat. The increase in urbanization within the Columbia River Basin may
40 lead to changes in water quality from point and non-point contaminant discharges. Water
41 temperatures in the tributaries of the Columbia River can increase because of changes to
42 shorelines and removal of shade structures (USFWS 2007). The recovery programs for
43 Federally-listed species (e.g., Upper Columbia River steelhead) may affect some of these
44 changes by enhancing fish habitat (NMFS, 2010). Resource agencies can address and
45 minimize impacts through monitoring and permitting programs, such as the Washington State
46 Department of Transportation's Fish Passage Program, to minimize impacts from highway
47 crossings (WSDOT, 2010).

1 Pressures from recreational and commercial fishing within the Columbia River Basin contribute
 2 to the cumulative effects on the aquatic resources in the vicinity of CGS. Historically, the fitness
 3 of some species has declined (e.g., Upper Columbia River spring Chinook salmon) because of
 4 the mismanagement of some hatchery programs. Release of fish that are not genetically
 5 diverse and have behaviors that may result in increased predation are some of the issues of
 6 past hatchery practices that are currently being addressed by new programs (NMFS, 2010).
 7 Predation by pinnipeds (seals and sea lions) on adult salmon migrating upstream and smolts
 8 migrating downstream can also be substantial (Marten, 2007).

9 Potential cumulative effects of climate change on the aquatic species of the Columbia River
 10 could result from changes in river water flow. Climate changes may include warmer
 11 temperatures with more winter rainfall, less snowpack, and lower summer stream flows. These
 12 conditions can affect the balance of all aquatic resources in the Columbia River Basin. For the
 13 salmonids, redds could be damaged by higher winter stream flows. Less snowpack and lower
 14 summer stream flows could prevent salmonid migration into or out of smaller tributaries, and
 15 warmer waters could limit the distribution of some species. Conditions in the ocean could also
 16 be less favorable for adult salmonids from the Columbia River Basin. Climate change would
 17 lead to unfavorable conditions for Federally- and State-listed species as well as other resident
 18 aquatic species in the vicinity of CGS (Karl, et al., 2009).

19 **D-1.8 Endangered Species Act Conclusions and Determination of Effects**

20 **D-1.8.1 Bull Trout**

21 The staff concludes that CGS will have no effect on the threatened bull trout because this
 22 stretch of the river is not spawning or rearing habitat for bull trout and because bull trout are not
 23 common in the Hanford Reach.

24 **D-1.8.2 Upper Columbia River Spring Chinook Salmon**

25 The staff concludes that CGS may affect, but is not likely to adversely affect, the endangered
 26 Upper Columbia River spring Chinook salmon. No fish, including spring Chinook, were
 27 collected during entrainment and impingement studies, and thermal drift studies of fall Chinook
 28 and steelhead had no measurable impact on the fish.

29 **D-1.8.3 Upper Columbia River Steelhead**

30 The staff concludes that CGS may affect, but is not likely to adversely affect, the threatened
 31 Upper Columbia River steelhead. No fish, including steelhead, were collected during
 32 entrainment and impingement studies, and thermal drift studies of steelhead had no measurable
 33 impact on the fish.

34 **D-1.9 Essential Fish Habitat Conservation Measures and Conclusions**

35 **D-1.9.1 Conservation Measures**

36 Closed-cycle cooling systems, such as the one already operating at CGS, are the most
 37 reasonable way to mitigate the number of aquatic organisms entrained and impinged in the
 38 facility's cooling system. Entrainment studies performed in 1979–1980 and 1985 indicated that
 39 no fish, fish eggs, or larvae were collected, even though beach seine samples in 1985 indicated
 40 that juvenile salmon (averaging 43 mm in length) were present in the area. In addition, thermal
 41 and chemical drift studies showed no effect on the two species of salmonids that were tested

1 (EN, 2010), (WPPSS, 1986). The thermal plume encompasses approximately 1 percent of the
2 width of the river and would be easily avoidable for migrating and residential salmonids.

3 **D-1.9.2 Upper Columbia River Chinook Salmon**

4 The staff concludes that CGS will have a minimal adverse effect on Upper Columbia River
5 Chinook salmon EFH. The operation of CGS will result in the removal of approximately
6 0.03 percent of the average mean annual discharge past the site, or 0.05 percent of the
7 minimum mean annual discharge past the site, and an even smaller fraction of the forage for the
8 smolts or juvenile Chinook salmon.

9 **D-1.9.3 Coho Salmon**

10 The staff concludes that CGS will have a minimal adverse effect on coho salmon EFH. The
11 operation of CGS will result in the removal of approximately 0.03 percent of the average mean
12 annual discharge past the site, or 0.05 percent of the minimum mean annual discharge past the
13 site, and an even smaller fraction of the forage for the coho smolts that are migrating
14 downstream.

15 **D-1.10 References**

16 Anglin, D. R., et al., "Effects of hydropower operations on spawning habitat, rearing habitat, and
17 stranding/entrapment mortality of fall Chinook salmon in the Hanford Reach of the Columbia
18 River," U.S. Fish and Wildlife Service, Vancouver, WA, 2006.

19 Becker, C.D., *Aquatic Bioenvironmental Studies: The Hanford Experience 1944–84. Studies in*
20 *Environmental Science 39*, Elsevier Science Publishing Company Inc., New York, NY, 1990.

21 Benke, A.C., and C.E. Cushings, eds., *Rivers of North America*, Elsevier Academic Press,
22 London, 2005.

23 Boggs, C.T., et al., "Fallback, Reascension, and Adjusted Fishway Escapement Estimates for
24 Adult Chinook Salmon and Steelhead at Columbia and Snake River Dams," *Transactions of the*
25 *American Fisheries Society*, 133:932–949, 2004.

26 Bonneau, J.L. and D. L. Scarnecchia, "Distribution of Juvenile Bull Trout in a Thermal Gradient
27 of a Plunge Pool in Granite Creek, Idaho," *Transactions of the American Fisheries Society*,
28 125:628–630, 1996.

29 Bonneville Power Administration (BPA), "Federal Columbia River Power System (FCRPS),"
30 2010, Available URL: <http://www.bpa.gov/power/pgf/hydrpnw.shtml> (accessed September 13,
31 2010).

32 Chapman, D.W., et al., "Effects of River Flow on the Distribution of Chinook Salmon Redds,"
33 *Transactions of the American Fisheries Society*, 115:537–547, 1986.

34 Dauble, D.D., *Fishes of the Columbia Basin: A Guide to Their Natural History and Identification*,
35 Keokee Books, Sandpoint, ID, 2009.

36 Dauble, D. D., T. L. Page, and R. W. Hanf, Jr., "Spatial Distribution of Juvenile Salmonids in the
37 Hanford Reach, Columbia River," *U.S. National Marine Fisheries Service Fishery Bulletin*
38 87:775–790, 1989.

- 1 Dauble, D.D. and D.G. Watson, "Status of Fall Chinook Salmon Populations in the
2 Mid-Columbia River, 1948–1992," *North American Journal of Fisheries Management*, 17:283–
3 300, 1997.
- 4 Duncan J.P., et al., "Hanford Site National Environmental Policy Act (NEPA) Characterization,"
5 Pacific Northwest National Laboratory, Richland, WA, PNNL-6415, Revision 18, 2007.
- 6 Duncan, J.P., T.M. Poston, and R.L. Dirkes, "Hanford Site Environmental Report for Calendar
7 Year 2007," Pacific Northwest National Laboratory, Richland, WA, PNNL-17603, 2008.
- 8 Duncan, JP, T.M. Poston, and R.L. Dirkes, "Hanford Site Environmental Report for Calendar
9 Year 2009," Pacific Northwest National Laboratory, Richland, WA, PNNL-19455, 2010.
- 10 Dunham, J, B. Rieman, and G. Chandler, "Influences of temperature and Environmental
11 Variables on the Distribution of Bull Trout within Streams at the Southern Margin of its Range,"
12 *North American Journal of Fisheries Management*, 23:894–904, 2003.
- 13 Endangered Species Act (ESA) § 16 U.S.C. 1531, et seq. (1973).
- 14 Energy Northwest (EN), "Columbia Generating Station Final Safety Analysis Report," Richland,
15 WA, Amendment 58, 2005.
- 16 EN, "Columbia Generating Station, License Renewal Application, Appendix E, Applicant's
17 Environmental Report, Operating License Renewal Stage," Richland, WA, Docket No. 50-391,
18 License No. NPF-21, 2010, Agencywide Document Access and Management System (ADAMS)
19 Accession No. ML100250666.
- 20 Federal Energy Regulatory Commission (FERC), "Final Environmental Impact Statement Priest
21 Rapids Hydroelectric Project Washington (FERC Project No. 2114)," Office of Energy,
22 FERC/FEIS-0190F, 2006.
- 23 Gambhir, S.K., letter to NRC "Subject: Columbia Generating Station, Docket No. 50-397
24 Response to Request for Additional Information License Renewal Application," G02-10-105,
25 August 5, 2010, ADAMS Accession No. ML102300503.
- 26 Geist, D. R., "Redd Site Selection and Spawning Habitat use by Fall Chinook Salmon," Final
27 Report to the BPA, Portland, OR, Project No. 1994-06900, 1999.
- 28 Geist, D. R., et al., "Suitability Criteria Analyzed at the Spatial Scale of Redd Clusters Improved
29 Estimates of Fall Chinook Salmon (*Oncorhynchus tshawytscha*) Spawning Habitat use in the
30 Hanford Reach, Columbia River," *Canadian Journal of Fisheries and Aquatic Sciences*,
31 57:1636–1646, 2000.
- 32 Geist, D.R., et al., "Survival, Development and Growth of Fall Chinook Salmon Embryos,
33 Alevins, and Fry Exposed to Variable Thermal and Dissolved Oxygen Regimes," *Transactions*
34 *of the American Fisheries Society*, 135:1462–1477, 2006.
- 35 Good, T.P., R.S. Waples, and P. Adams, eds., "Updated Status of Federally Listed ESUs of
36 West Coast Salmon and Steelhead," U.S. Dept. Commerce, NOAA Technical Memo
37 NMFS-NWFSC-66, 2005.
- 38 Gray, R.H., and D.D. Dauble, "Checklist and Relative Abundance of Fish Species from the
39 Hanford Reach of the Columbia River," *Northwest Science*, 51:208–215, 1977.

Appendix D-1

- 1 Hanf, R.W., et al., "Hanford Site Environmental Report for Calendar Year 2005," Pacific
2 Northwest National Laboratory, Richland, WA, PNNL-15892, 2006.
- 3 Hanf, R.W., et al., "Hanford Site Environmental Report for Calendar Year 2006," Pacific
4 Northwest National Laboratory, Richland, WA, PNNL-16623, 2007.
- 5 Hanford Reach Fall Chinook Protection Program, April 5, 2004, Available URL: [http://www.nwd-
6 wc.usace.army.mil/tmt/documents/wmp/2006/draft/app7.pdf](http://www.nwd-wc.usace.army.mil/tmt/documents/wmp/2006/draft/app7.pdf) (accessed July 28, 2011).
- 7 Healey, M.C., "Life History of Chinook Salmon (*Oncorhynchus tshawytscha*)," *Pacific Salmon
8 Life History*, University of British Columbia Press, Vancouver, Canada, 1991.
- 9 Higgs, D.A., et al., "Nutrition and Feeding Habits in Relation to Life History Stage," *Physiological
10 Ecology of Pacific Salmon*, UBC Press, Vancouver, Canada, 1995.
- 11 Hoffarth, P.A., "District 4 Fish Management Annual Report," Annual Report to Washington,
12 USFWS, Region 3, Yakima, WA, 2010.
- 13 Karl, T.R., et al., eds., "Global Climate Change Impacts in the United States," U.S. Global
14 Change Research Program, Cambridge University Press, New York, NY, 2009, Available URL:
15 <http://downloads.globalchange.gov/usimpacts/pdfs/climate-impacts-report.pdf>, ADAMS
16 Accession No. ML100580077.
- 17 Kurz, G.L., USFWS, email to NRC, November 8, 2010, ADAMS Accession No. ML103120486.
- 18 Lauffle, J.C., et al., "Species Profiles: Life Histories and Environmental Requirements of Coastal
19 Fishes and Invertebrates (Pacific Northwest)—Coho Salmon," Biological Report 82(11.48), TR
20 EL-82-4, U.S. Army Corps of Engineers, Vicksburg, MS, and USFWS, Washington, D.C., 1986.
- 21 Lestelle, L.C., *Coho Salmon (Oncorhynchus kisutch) Life History Patterns in the Pacific
22 Northwest and California*, Biostream Environmental, Poulsbo, WA, 2007.
- 23 Levy, D.A. and T.L. Slaney, "A Review of Habitat Capacity for Salmon Spawning and Rearing,"
24 Prepared for British Columbia Resources inventory Committee, Habitat Management Division,
25 Department of Fisheries and Oceans, Vancouver, British Columbia, 1993.
- 26 Lohn, D.R., NMFS, letter to M.R. Salas, FERC, "Biological Opinion for ESA Section 7
27 Consultation on Interim Operations for the Priest Rapids Hydroelectric Project (FERC
28 No. 2114)," NOAA Fisheries Consultation NO. 1999/01878, May 3, 2004.
- 29 Magnuson-Stevens Fishery Conservation and Management Act (MSA), as amended by the
30 Sustainable Fisheries Act of 1996, Public Law 104-267.
- 31 Marten, S.B., USFWS, letter to M.R. Salas, FERC, "Biological Opinion on the Effects of the
32 Priest Rapids Hydroelectric Project Relicensing on Bull Trout (FERC No. 2114)," March 14,
33 2007.
- 34 McMichael, G.A. and T.N. Pearsons, "Upstream Movement of Residual Hatchery Steelhead into
35 Areas Containing Bull Trout and Cutthroat Trout," *North American Journal of Fisheries
36 Management*, 21:943–946, 2001.
- 37 McPhail, J.D. and J.S. Baxter, "A Review of Bull Trout (*Salvelinus confluentus*) Life-History and
38 Habitat Use in Relation to Compensation and Improvement Opportunities," Fisheries

- 1 Management Report, No. 104, University of British Columbia, Vancouver, British Columbia,
2 1996.
- 3 Miley, T.B., et al., "Current Conditions Risk Assessment for the 300-FF-5 Groundwater
4 Operable Unit," Pacific Northwest National Laboratory, Richland, WA, PNNL-16454, Revision 0,
5 2007.
- 6 Mueller, R.P. and D.R. Geist, "Steelhead Spawning Surveys Near Locke Island, Hanford Reach
7 of the Columbia River," Pacific Northwest National Laboratory, PNNL-13055, 1999.
- 8 Mueller, R.P. and D.L. Ward, "Characterization of Fall Chinook Salmon Spawning Areas
9 Downstream of Wanapum Dam, 2009," Battelle-Pacific Northwest Division Final Report to
10 Public Utility District No. 2 of Grant County, PNWD-4173, Richland, WA, 2010.
- 11 National Environmental Policy Act (NEPA), as amended § 42 U.S.C. 4321, et seq. (1969).
- 12 National Marine Fisheries Service (NMFS), "Endangered Species Act, Section 7(a)(2)
13 Consultation, Supplemental Biological Opinion: Supplemental Consultation on Remand for
14 Operation of the Federal Columbia River Power System, Bureau of Reclamation Projects in the
15 Columbia Basin and ESA Section 10(a)(1)(A) Permit for Juvenile Fish Transportation Program,"
16 Northwest Region, Seattle, WA, F/NWR/2010/02096, 2010.
- 17 Nugent, J.T., et al., "2001 Evaluation of Juvenile Fall Chinook Salmon Stranding on the Hanford
18 Reach of the Columbia River," Report to BPA, Contract No. 00004294, Project No. 199701400
19 (BPA Report DOE/BP-00004294-3), 2002.
- 20 National Oceanic and Atmospheric Administration (NOAA), NMFS, "Endangered and
21 Threatened Species: Listing of Several Evolutionarily Significant Units (ESUs) of West Coast
22 Steelhead (50 CFR Parts 222 and 227)," *Federal Register*, Vol. 62, No. 159, August 18, 1997,
23 pp. 43937–43954.
- 24 NOAA, "Endangered and Threatened Species; Threatened Status for Three Chinook Salmon
25 Evolutionarily Significant Units (ESUs) in Washington and Oregon, and Endangered Status for
26 One Chinook Salmon ESU in Washington (50 CFR Parts 223 and 224)," *Federal Register*, Vol.
27 64, No. 56, March 24, 1999, pp. 14308–44328.
- 28 NOAA, NMFS, "Endangered and Threatened Species: Final Listing Determinations for 16 ESUs
29 of West Coast Salmon, and Final 4(d) Protective Regulations for Threatened Salmonid ESUs
30 (50 CFR Parts 223 and 224)," *Federal Register*, Vol. 70, No. 123, Final Rule, 2005, pp. 37160–
31 37204.
- 32 NOAA, NMFS, "Endangered and Threatened Species: Designation of Critical Habitat for 12
33 Evolutionarily Significant Units of West Coast Salmon and Steelhead in Washington, Oregon
34 and Idaho (J50 CFR part 226)," *Federal Register*, Vol. 70, No. 170, Final Rule,
35 September 2, 2005, pp. 52630–52858.
- 36 NOAA, "Endangered and Threatened Species: Final Listing Determinations for 10 Distinct
37 Population Segments of West Coast Steelhead," *Federal Register*, Vol. 71, No. 3, January 5,
38 2006, pp. 834–862.

Appendix D-1

- 1 NOAA, "Endangered and Threatened Species: Final Protective Regulations for Threatened
2 Upper Columbia River Steelhead," *Federal Register*, Vol. 71, No. 21, February 1, 2006, pp.
3 5177–5180.
- 4 NOAA, NMFS, "Listing Endangered and Threatened Species: Change in Status for the Upper
5 Columbia River Steelhead Distinct Population Segment (50 CFR Part 223)," *Federal Register*,
6 Vol. 74, No. 162, Final Rule, August 24, 2009, pp. 42605–42606.
- 7 NOAA, "National Oceanographic Data Center," 2011 (2011a), Available URL:
8 <http://www.nodc.noaa.gov/cgi-bin/OC5/WOA09F/woa09f.pl> (accessed March 3, 2011).
- 9 NOAA, "Steelhead Trout (*Oncorhynchus mykiss*)," NOAA Fisheries Office of Protected
10 Resources, 2011 (2011b), Available URL:
11 <http://www.nmfs.noaa.gov/pr/species/fish/steelheadtrout.htm> (accessed March 3, 2011).
- 12 Pacific Fishery Management Council (PFMC), "Amendment 14 to the Pacific Coast Salmon Plan
13 1997," Pacific Fishery Management Council, Portland, OR, 2000.
- 14 Pearsons, T.N., et al., "Yakima River Species Interactions Studies, Progress Report 1995–
15 1997," Washington Department of Fish and Wildlife, Prepared for the U.S. DOE & BPA,
16 Portland, OR, 1998.
- 17 Pfeiffer, B., et al., "Evaluation of Fish Species Present in the Priest Rapids Project Area, Mid
18 Columbia River, Washington, USA," Final Completion Report, in Appendix E-4.D of Final
19 License Application—Priest Rapids Hydroelectric Project (FERC No. 2114), Grant County
20 Public Utility District, October 2003.
- 21 Poston, T.M., J.P. Duncan, and R.L. Dirkes, "Hanford Site Environmental Report for Calendar
22 Year 2007," Pacific Northwest National Laboratory, Richland, WA, PNNL-17603, 2008.
- 23 Poston, T.M., J.P. Duncan, and R.L. Dirkes, "Hanford Site Environmental Report for Calendar
24 Year 2008," Pacific Northwest National Laboratory, Richland, WA, PNNL-18427, 2009.
- 25 Poston, T.M., J.P. Duncan, and R.L. Dirkes, "Hanford Site Environmental Report for Calendar
26 Year 2009," Pacific Northwest National Laboratory, Richland, WA, PNNL-19455, Revision 0,
27 2010.
- 28 Quinn, T.P., *The Behavior and Ecology of Pacific Salmon and Trout*, University of Washington
29 Press, Seattle, WA, 2005.
- 30 Rieman, B.E. and J.D. McIntyre, "Demographic and Habitat Requirements for Conservation of
31 Bull Trout," General Technical Report, "U.S. Department of Agriculture/U.S. Forest Service,
32 INT-302, 1993.
- 33 Sandercock, F.K., "Life History of Coho Salmon (*Oncorhynchus kisutch*)," *Pacific Salmon Life
34 History*, University of British Columbia Press, Vancouver, Canada, 1991.
- 35 Stevenson, J.R., "Movement of Radio-Tagged Bull Trout within Priest Rapids and Wanapum
36 Reservoirs, 2001–2003," Appendix E-4.E of Final License Application—Priest Rapids
37 Hydroelectric Project (FERC No. 2114), Grant County Public Utility District, October 2003.

- 1 Suzumoto, Bruce, NMFS, Assistant Regional Administrator, letter to NRC, "Re: Columbia
2 Generating Station License Renewal, Request for Species List for Consultation," June 23, 2010,
3 ADAMS Accession No. ML101830405.
- 4 *U.S. Code of Federal Regulations* (CFR), "Domestic Licensing of Production and Utilization
5 Facilities," Part 50, Title 10, "Energy."
- 6 *CFR*, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory
7 Functions," Part 51, Chapter 1, Title 10, "Energy."
- 8 *CFR*, "Magnuson-Stevens Act Provisions," Part 600, Title 50, "Wildlife and Fisheries."
- 9 U.S. Department of Energy (DOE), "Threatened and Endangered Species Management Plan:
10 Salmon and Steelhead," Richland Operations Office, Richland, WA, DOE/RL-2000-27,
11 Revision 0, 2000.
- 12 DOE, "Draft Tank Closure and Waste Management Environmental Impact Statement for the
13 Hanford Site, Richland, Washington," Office of River Protection, Richland, WA, DOE/EIS-0391,
14 2009.
- 15 U.S. Environmental Protection Agency, "National Pollutant Discharge Elimination System—Final
16 Regulations to Establish Requirements for Cooling Water Intake Structures at Phase II Existing
17 Facilities," *Federal Register*, Vol. 69, No. 131, Final Rule, July 9, 2004, pp. 41576–41693.
- 18 U.S. Fish and Wildlife Service (USFWS), "Endangered and Threatened Wildlife and Plants;
19 Determination of Threatened Status for the Klamath River and Columbia River Distinct
20 Population Segments of Bull Trout (50 CFR Part 17)," *Federal Register*, Vol. 63, No. 111,
21 June 10, 1998, pp. 31647–31674.
- 22 USFWS, "Endangered and Threatened Wildlife and Plants; Determination of Threatened Status
23 for Bull Trout in the Coterminous United States (50 CFR Part 17)," *Federal Register*, Vol. 64,
24 No. 210, Final Rule, November 1, 1999, pp. 58910–58933.
- 25 USFWS, "Endangered and Threatened Wildlife and Plants; Revised Designation of Critically
26 Habitat for Bull Trout in the Coterminous United States," *Federal Register*, Vol. 75, No. 9,
27 Proposed Rule, January 14, 2010, pp. 2270–2431.
- 28 USFWS, "Endangered and Threatened Wildlife and Plants: Revised Designation of Critical
29 Habitat for Bull Trout in the Coterminous United States (50 CFR Part 17)," *Federal Register*,
30 Vol. 75, No. 200, Final Rule, October 18, 2010, pp. 63898–64070.
- 31 USFWS, "Bull Trout (*Salvelinus confluentus*)," January 2003, Available URL:
32 <http://library.fws.gov/Pubs1/bulltrout.pdf> (accessed on March 11, 2011).
- 33 USFWS, "Hanford Reach National Monument Final Comprehensive Conservation Plan and
34 Environmental Impact Statement Adams, Benton, Grant and Franklin Counties, Washington,"
35 2008, Available URL:
36 <http://astro.berkeley.edu/~kalas/ethics/documents/environment/final-ccp-no-maps.pdf>.
- 37 USFWS, "Critical Habitat, What is it?," Endangered Species Program, 2010 (2010a), Available
38 URL: http://www.fs.fed.us/r9/wildlife/tes/docs/esa_references/critical_habitat.pdf (accessed
39 December 21, 2010).

Appendix D-1

- 1 USFWS, "Bull Trout Final Critical Habitat Justification: Rationale for Why Habitat is Essential
2 and Documentation of Occupancy," Idaho Fish and Wildlife Office, Boise, ID, Pacific Region,
3 Portland, OR, September 2010 (2010b).
- 4 U.S. Geological Survey (USGS), "Summary Statistics for NASQAN Data—Columbia Basin
5 1996–2000, Columbia River at Vernita Bridge, Near Priest Rapids Dam, Washington
6 12472900," 2006, Available URL: <http://pubs.usgs.gov/wri/wri014255/results/stat/vernita.htm>
7 (accessed July 28, 2011).
- 8 USGS, "Online Report—USGS Surface-Water Monthly Statistics for Washington. USGS
9 12472800 Columbia River Below Priest Rapids Dam, WA," 2010, Available URL:
10 [http://waterdata.usgs.gov/wa/nwis/monthly?referred_module=
11 sw&site_no=12472800&por_12472800_22=1180614,00060,22,1917-10,2009-09&
12 amp;start_dt=1960-01&end_dt=2008-12&format=html_table&date_format=
13 YYYY-MM-DD&rdb_compression=file&submitted_form=parameter_selection_list
14 \(accessed July 27, 2010\).](http://waterdata.usgs.gov/wa/nwis/monthly?referred_module=sw&site_no=12472800&por_12472800_22=1180614,00060,22,1917-10,2009-09&start_dt=1960-01&end_dt=2008-12&format=html_table&date_format=YYYY-MM-DD&rdb_compression=file&submitted_form=parameter_selection_list)
- 15 U.S. Nuclear Regulatory Commission (NRC), "Final Environmental Statement Related to the
16 Operation of WPPSS Nuclear Project No. 2," NUREG-0812, Office of Nuclear Reactor
17 Regulation, Washington, D.C., 1981, ADAMS Accession No. ML100570374.
- 18 NRC, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants,"
19 NUREG-1437, Washington, D.C., Volumes 1 and 2, May 1996, ADAMS Accession
20 Nos. ML040690705 and ML040690738.
- 21 NRC, letter to Robyn Thorson, Regional Director, USFWS, Pacific Region, "Request for List of
22 Protected Species within the Area Under Evaluation of the Columbia Generating Station
23 License Renewal Application Review," 2010 (2010a), ADAMS Accession No. ML100710046.
- 24 NRC, letter to Barry Thom, Regional Administrator, Northwest Region, NMFS, "Request for List
25 of Protected Species and Essential Fish Habitat within the Area Under Evaluation for the
26 Columbia Generating Station License Renewal Application Review," May 3, 2010 (2010b),
27 ADAMS Accession No. ML100980161.
- 28 University of Washington, "DART—Data Access in Real Time," Columbia Basin Research,
29 School of Aquatic and Fishery Sciences, 2011, Available URL:
30 <http://www.cbr.washington.edu/dart/dart.html> (accessed February 24, 2011).
- 31 Washington Department of Fish and Wildlife, "Fishing Reports, Stocking Reports & Fish
32 Counts," Columbia River 2010 Adult Returns and 2011 Expectations (Preliminary draft), 2011,
33 Available URL: http://wdfw.wa.gov/fishing/reports_plants.html (accessed March 22, 2011).
- 34 Washington Public Power Supply System (WPPSS), "Environmental Report, Operating License
35 Stage Docket No. 50-397, WPPSS Nuclear Project No. 2," Richland, WA, 1980, ADAMS
36 Accession No. ML102180050.
- 37 WPPSS, "Ecological Monitoring Program for Nuclear Plant 2—1985 Annual Report," Richland,
38 WA, 1986.
- 39 Washington State Department of Transportation (WSDOT), "2009 Annual Traffic Report," 2010,
40 Available URL:

- 1 http://www.wsdot.wa.gov/mapsdata/tdo/PDF_and_ZIP_Files/Annual_Traffic_Report_2009.pdf
- 2 (accessed October 2010).
- 3 Wydoski, R.S., and R.L. Whitney, *Inland Fishes of Washington*, American Fisheries Society and
- 4 University of Washington Press, Second Edition, 2003.

APPENDIX E
CHRONOLOGY OF ENVIRONMENTAL REVIEW

1 **E CHRONOLOGY OF ENVIRONMENTAL REVIEW**
 2 **CORRESPONDENCE**

3 This appendix contains a chronological listing of correspondence between the U.S. Nuclear
 4 Regulatory Commission (NRC) and external parties as part of its environmental review for
 5 Columbia Generating Station (CGS). All documents, with the exception of those containing
 6 proprietary information, are available electronically from the NRC's Public Electronic Reading
 7 Room found on the Internet at the following Web address: <http://www.nrc.gov/reading-rm.html>.
 8 From this site, the public can gain access to the NRC's Agencywide Documents Access and
 9 Management System (ADAMS), which provides text and image files of NRC's public documents
 10 in ADAMS. The ADAMS accession number for each document is included in the following list.

11 **E.1 Environmental Review Correspondence**

| | |
|------------------|--|
| January 19, 2010 | Letter from Energy Northwest forwarding the application for renewal of the operating license for CGS to request an extension of the operating license for an additional 20 years (ADAMS Accession No. ML100250668) |
| January 26, 2010 | Letter to Energy Northwest, "Receipt and Availability of the License Renewal Application for Columbia Generating Station" (ADAMS Accession No. ML100220037) |
| February 2, 2010 | <i>Federal Register</i> Notice of Receipt and Availability of Application for Renewal of Columbia Generating Station Facility Operating License No. NPF-21 for an Additional 20-Year Period (75 FR 5353) (ADAMS Accession No. ML100220041) |
| February 3, 2010 | NRC press release announcing the availability of license renewal application for CGS (ADAMS Accession No. ML100340369) |
| March 4, 2010 | Letter to Energy Northwest, "Determination of Acceptability and Sufficiency for Docketing, Proposed Review Schedule, and Opportunity for a Hearing Regarding the Application From Energy Northwest for Renewal of the Operating License for the Columbia Generating Station" (ADAMS Accession No. ML100541619) |
| March 5, 2010 | Letter to Energy Northwest transmitting notice of intent to prepare an environmental impact statement and conduct the scoping process for license renewal for CGS (ADAMS Accession No. ML100570290) |
| March 8, 2010 | NRC press release announcing opportunity for hearing on application to renewal operating license for CGS (ADAMS Accession No. ML100670526) |

Appendix E

- March 11, 2010 *Federal Register* Notice of Acceptance for Docketing of the Application and Notice of Opportunity for Hearing Regarding Renewal of Facility Operating License No. NPF-21 for an Additional 20-Year Period Energy Northwest Columbia Generating Station (75 FR 11572) (ADAMS Accession No. ML100550728)
- March 11, 2010 *Federal Register* Notice of Intent to Prepare an Environmental Impact Statement and Conduct the Scoping Process for CGS (75 FR 11576) (ADAMS Accession No. ML100570282)
- March 18, 2010 Letter to Dr. Allyson Brooks, State Historic Preservation Officer, Washington Department of Archaeology and Historic Preservation, "Columbia Generating Station License Renewal Application (Log No.: 121007-20-NRC)" (ADAMS Accession No. ML100610084)
- March 19, 2010 Letter to Mr. Louis Cloud, Chairman, Yakama Nation, "Request for Scoping Comments Concerning the Columbia Generating Station License Renewal Application Review" (ADAMS Accession No. ML100770417)
- March 19, 2010 Letter to Mr. Elwood H. Patawa, Chairman, Confederated Tribes of the Umatilla Indian Reservation, "Request for Scoping Comments Concerning the Columbia Generating Station License Renewal Application Review" (ADAMS Accession No. ML100770417)
- March 19, 2010 Letter to Mr. Samuel N. Penney, Chairman, Nez Perce Tribe, "Request for Scoping Comments Concerning the Columbia Generating Station License Renewal Application Review" (ADAMS Accession No. ML100770417)
- March 22, 2010 Letter to Ms. Robyn Thorson, Regional Director, Pacific Region, U.S. Fish and Wildlife Service (USFWS), "Request for List of Protected Species Within the Area Under Evaluation for the Columbia Generating Station License Renewal Application Review" (ADAMS Accession No. ML100710046)
- March 25, 2010 Memo to Bo Pham, NRC, "Forthcoming Meeting to Discuss the License Renewal Process and Environmental Scoping for Columbia Generating Station License Renewal Application Review" (ADAMS Accession No. ML100810412)
- March 26, 2010 NRC press release announcing the CGS license renewal environmental scoping meeting (ADAMS Accession No. ML100850318)

March 29, 2010 Letter from Dr. Robert G. Whitlam, State Archaeologist, Washington Department of Archaeology and Historic Preservation, requesting a map of the boundaries of the environmental review of the license renewal application for CGS (ADAMS Accession No. ML100900230)

March 31, 2010 Email from John D. Greenhill regarding the license renewal of CGS (ADAMS Accession No. ML100920546)

March 31, 2010 Letter from Jerome Delvin, Washington State Senate, regarding the license renewal of CGS (ADAMS Accession No. ML100980062)

April 2, 2010 Letter from David V. Taylor, et al., Washington State Legislature, regarding the license renewal of CGS (ADAMS Accession No. ML101040675)

April 6, 2010 Letter from James O. Luce, Chair, State of Washington Energy Facility Site Evaluation Council, regarding the license renewal of CGS (ADAMS Accession No. ML101050307)

April 6, 2010 Transcript of the CGS license renewal public meeting—afternoon session, April 6, 2010 (ADAMS Accession No. ML101241002)

April 6, 2010 Transcript of the CGS license renewal public meeting—evening session, April 6, 2010 (ADAMS Accession No. ML101241037)

April 6, 2010 Comments from Gene Kinsey regarding the license renewal of CGS (ADAMS Accession No. ML101960547)

April 7, 2010 Letter from the Franklin County Board of Commissioners regarding the license renewal of CGS (ADAMS Accession No. ML101110052)

April 9, 2010 Letter from Tim Sheldon, Washington State Senate, regarding the license renewal of CGS (ADAMS Accession No. ML101110053)

April 9, 2010 Letter from Mr. Russell Jim, Manager, Environmental Restoration and Waste Management Program, Confederated Tribes and Bands of the Yakama Nation, regarding spent fuel storage and the license renewal of CGS (ADAMS Accession No. ML101160435)

Appendix E

- April 12, 2010 Letter from Larry Haler, Brad Klippert, Maureen Walsh, and Terry Nealey, Washington State House of Representatives, regarding the license renewal of CGS (ADAMS Accession No. ML101110054)
- April 12, 2010 Letter from Tim Sheldon, et al., Washington State Senate, regarding the license renewal of CGS (ADAMS Accession No. ML101170056)
- April 15, 2010 Letter to Dr. Robert G. Whitlam, State Archaeologist, Washington Department of Archaeology and Historic Preservation, describing the area of potential effect for the CGS license renewal review (ADAMS Accession No. ML100960116)
- April 19, 2010 Letter from Phil Rockefeller, Washington State Senate, regarding the license renewal of CGS (ADAMS Accession No. ML101180459)
- April 20, 2010 Letter to Mr. Reid Nelson, Director, Office of Federal Agency Programs, Advisory Council on Historic Preservation, regarding the CGS license renewal application (ADAMS Accession No. ML100970721)
- April 21, 2010 Letter from Dr. Robert G. Whitlam, State Archaeologist, Washington Department of Archaeology and Historic Preservation, concurring with the proposed area of potential effect for the CGS license renewal review (ADAMS Accession No. ML101160095)
- April 21, 2010 Letter from representatives of Washington public power utilities regarding the license renewal of CGS (ADAMS Accession No. ML103230048)
- May 3, 2010 Letter to Mr. Barry Thom, Regional Administrator, Northwest Region, National Marine Fisheries Service, "Request for List of Protected Species and Essential Fish Habitat Within the Area Under Evaluation for the Columbia Generating Station License Renewal Application Review" (ADAMS Accession No. ML100980161)
- May 10, 2010 Summary of the CGS License Renewal Overview and Environmental Scoping Meetings, April 6, 2010 (ADAMS Accession No. ML101250540)
- May 14, 2010 Letter from Gary Robertson, Director, Washington Department of Health, Office of Radiation Protection, regarding the license renewal of CGS (ADAMS Accession No. ML101460059)

June 4, 2010 Letter to Mr. Russell Jim, Manager, Environmental Restoration and Waste Management Program, Confederated Tribes and Bands of the Yakama Nation, regarding spent fuel storage and the license renewal of CGS (ADAMS Accession No. ML101300463)

June 23, 2010 Letter from Bruce Suzumoto, Assistant Regional Administrator, Hydropower Division, National Marine Fisheries Service, "Columbia Generating Station license renewal, request for species list for consultation" (ADAMS Accession No. ML101830405)

July 1, 2010 Letter to Energy Northwest, "Request for Additional Information for the Review of the Columbia Generating Station License Renewal Application—[severe accident mitigation alternatives] SAMA review (TAC No. ME3121)" (ADAMS Accession No. ML101760421)

July 2, 2010 Letter to Energy Northwest, "Request for Additional Information for the Review of the Columbia Generating Station License Renewal Application Environmental Review (TAC No. ME3121)" (ADAMS Accession No. ML101750655)

July 8, 2010 Letter to Energy Northwest, "Request for Additional Information Related to the Environmental Site Audit for Columbia Generating Station License Renewal (TAC No. ME3121)" (ADAMS Accession No. ML101810091)

July 15, 2010 Summary of telephone conference call held on June 28, 2010, between the NRC and Energy Northwest concerning draft requests for additional information pertaining to the SAMA review of the CGS license renewal application (ADAMS Accession No. ML101880289)

July 22, 2010 Letter from Energy Northwest to Dr. Robert G. Whitlam, State Archaeologist, Department of Archaeology and Historic Preservation, regarding the license renewal of CGS (ADAMS Accession No. ML102160123)

July 29, 2010 Letter from Dr. Robert G. Whitlam, State Archaeologist, Department of Archaeology and Historic Preservation, to Energy Northwest regarding the license renewal of CGS (ADAMS Accession No. ML103280572)

August 5, 2010 Letter from Energy Northwest, "Columbia Generating Station, Docket No. 50-397; Response to Request for Additional Information; License Renewal Application" (ADAMS Accession No. ML102300503)

Appendix E

- August 9, 2010 Letter from Energy Northwest, "Columbia Generating Station, Docket No. 50-397; Response to Request for Additional Information; License Renewal Application" (ADAMS Accession No. ML102380285)
- August 10, 2010 Schedule revision for the environmental review of the CGS license renewal application (ADAMS Accession No. ML102100303)
- September 17, 2010 Letter from Energy Northwest, "Columbia Generating Station, Docket No. 50-397; Response to Request for Additional Information; License Renewal Application" (ADAMS Accession No. ML102660151)
- October 1, 2010 Summary of Tribal Outreach Informational Meeting concerning CGS license renewal and Hanford low-level waste, April 27, 2010 (ADAMS Accession No. ML102630228)
- November 5, 2010 Email to Mr. Gregg L. Kurz, USFWS, requesting concurrence on the list of protected species (ADAMS Accession No. ML103120452)
- November 8, 2010 Email from Mr. Gregg L. Kurz, USFWS, concurring on the list of protected species (ADAMS Accession No. ML103120486)
- November 8, 2010 Summary of telephone conference call held on September 29, 2010, between the NRC and Energy Northwest concerning requests for additional information pertaining to the SAMA review of the CGS license renewal application (ADAMS Accession No. ML102920382)
- November 10, 2010 Letter to Energy Northwest, "Request for Additional Information for the Review of the Columbia Generating Station License Renewal Application—SAMA review (TAC No. ME3121)" (ADAMS Accession No. ML102870984)
- November 30, 2010 Letter to Dr. Robert G. Whitlam, State Archaeologist, Washington Department of Archaeology and Historic Preservation, revising the area of potential effect for the CGS license renewal review (ADAMS Accession No. ML103280421)
- December 1, 2010 Letter from Dr. Robert G. Whitlam, State Archaeologist, Washington Department of Archaeology and Historic Preservation, concurring with the revised area of potential effect for the CGS license renewal review (ADAMS Accession No. ML103350680)

December 1, 2010 Summary of telephone conference call held on October 22, 2010, between the NRC and Energy Northwest concerning the SAMA review of the CGS license renewal application (ADAMS Accession No. ML103330071)

December 2, 2010 Letter to Energy Northwest, "Request for Additional Information for the Review of the Columbia Generating Station License Renewal Application—SAMA review (TAC No. ME3121)" (ADAMS Accession No. ML103330246)

December 17, 2010 Email from Richard Domingue, National Marine Fisheries Service, regarding the biological assessment and essential fish habitat assessment for the Columbia Generating Station license renewal review (ADAMS Accession No. ML103510668)

December 21, 2010 Letter from Energy Northwest, "Columbia Generating Station, Docket No. 50-397; Response to Request for Additional Information; License Renewal Application" (ADAMS Accession No. ML103620324)

December 29, 2010 Letter to Energy Northwest, "Issuance of Environmental Scoping Summary Report associated with the Staff's Review of the Application by Energy Northwest for Renewal of the Operating License for Columbia Generating Station (TAC No. ME3121)" (ADAMS Accession No. ML102770232)

January 10, 2011 Schedule revision for the review of the CGS license renewal application (ADAMS Accession No. ML103430526)

January 18, 2011 Letter to Energy Northwest, "Summary of Site Visit related to the Review of the License Renewal Application for Columbia Generating Station (TAC No. ME3121)" (ADAMS Accession No. ML103400163)

January 28, 2011 Letter from Energy Northwest, "Columbia Generating Station, Docket No. 50-397, Response to Request for Additional Information for the Review of the Columbia Generating Station License Renewal Application" (ADAMS Accession No. ML110330395)

March 1, 2011 Summary of telephone conference call held on January 19, 2011, between the NRC and Energy Northwest concerning the SAMA review of the CGS license renewal application (ADAMS Accession No. ML110400510)

Appendix E

- March 4, 2011 Email to Energy Northwest, "RE: Proposed Response to Clarification Question 11" (ADAMS Accession No. ML110670526)
- March 10, 2011 Letter to Energy Northwest, "Request for Additional Information for the Review of the Columbia Generating Station License Renewal Application—SAMA review (TAC No. ME3121)" (ADAMS Accession No. ML110670379)
- March 28, 2011 Summary of telephone conference call held on February 28, 2011, between the NRC and Energy Northwest concerning the SAMA review of the CGS license renewal application (ADAMS Accession No. ML110670496)
- April 20, 2011 Letter from Energy Northwest, "Columbia Generating Station, Docket No. 50-397, Environmental Authorizations for CGS Operations" (ADAMS Accession No. ML11112A130)
- May 6, 2011 Letter from Energy Northwest, "Columbia Generating Station, Docket No. 50-397, Response to Request for Additional Information Related to the Review of the SAMA Analysis" (ADAMS Accession No. ML11129A186)
- June 5, 2011 Letter from Mr. Gerry Pollet, Executive Director, Heart of America Northwest, "Public Involvement Lists and Notices, Including Requests to be Added to Lists and Requests for Hearings on the Draft EIS, for Columbia Generating Station License Renewal, NRC Dockets 50-397 and 2010-0029" (ADAMS Accession No. ML11157A036)
- June 10, 2011 Email to Mr. Gerry Pollet, Executive Director, Heart of America Northwest, "Energy NW, Columbia Generating Station Public Involvement and Notice List, Request for Hearings re: EIS" (ADAMS Accession No. ML111600187)
- June 14, 2011 Schedule revision for the environmental review of the CGS license renewal application (ADAMS Accession No. ML11151A222)
- June 16, 2011 Email from Mr. Gregg L. Kurz, USFWS, providing update for list of protected species (ADAMS Accession No. ML111680221)

- June 23, 2011 Email from Mr. Jeff Person, Energy Northwest, "Environmental Authorizations for Current CGS Operations" (ADAMS Accession No. ML111750188)
- June 27, 2011 Email from Mr. Richard Domingue, NMFS, providing update for list of protected species (ADAMS Accession No. ML111821975)

APPENDIX F
U.S. NUCLEAR REGULATORY COMMISSION STAFF EVALUATION OF
SEVERE ACCIDENT MITIGATION ALTERNATIVES FOR COLUMBIA
GENERATING STATION IN SUPPORT OF LICENSE RENEWAL
APPLICATION REVIEW

F U.S. NUCLEAR REGULATORY COMMISSION STAFF EVALUATION OF SEVERE ACCIDENT MITIGATION ALTERNATIVES FOR COLUMBIA GENERATING STATION IN SUPPORT OF LICENSE RENEWAL APPLICATION REVIEW

F.1 Introduction

Energy Northwest, formerly known as Washington Public Power Supply System (WPPSS), submitted an assessment of severe accident mitigation alternatives (SAMAs) for the Columbia Generating Station (CGS), formerly known as Washington Nuclear Plant 2 (WNP-2), as part of the environmental report (ER) (EN, 2010). This assessment was based on the most recent CGS probabilistic safety assessment (PSA) available at that time, a plant-specific offsite consequence analysis performed using the MELCOR Accident Consequence Code System 2 (MACCS2) computer code (NRC, 1998), and insights from the CGS individual plant examination (IPE) (Parrish, 1994) and individual plant examination of external events (IPEEE) (Parrish, 1995). In identifying and evaluating potential SAMAs, Energy Northwest considered SAMA candidates that addressed the major contributors to core damage frequency (CDF) and population dose at CGS, as well as SAMA candidates for other operating plants that have submitted license renewal applications (LRAs). Energy Northwest identified 150 potential SAMA candidates. This list was reduced to 28 SAMA candidates by eliminating the following SAMAs that are not applicable to CGS:

- SAMAs with design differences
- SAMAs that have already been implemented at CGS
- SAMAs whose estimated implementation costs would exceed the dollar value associated with eliminating all severe accident risk at CGS
- SAMAs that are related to a non-risk significant system and, therefore, have a very low benefit
- SAMAs that are similar in nature and can be combined with another SAMA candidate

Energy Northwest assessed the costs and benefits associated with each of the remaining SAMA candidates and concluded in the ER that three of the candidate SAMAs evaluated are potentially cost-beneficial.

Based on a review of the SAMA assessment, the U.S. Nuclear Regulatory Commission (NRC) issued a request for additional information (RAI) to Energy Northwest by letters dated July 1, 2010 (Doyle, 2010a), November 10, 2010 (Doyle, 2010b), December 2, 2010 (Doyle, 2010c), and March 10, 2011 (Doyle, 2011). Key questions concerned the following:

- changes to the internal, fire, and seismic events PSA models since the SAMA analysis was performed
- internal and external reviews of the PSA models since the IPE
- the relationship between the containment event trees (CETs) used for the internal, fire, and seismic events Level 2 analyses
- the process for selecting the representative Modular Accident Analysis Program (MAAP) case for each release category

Appendix F

- 1 • population, meteorological, and economic assumptions used in the Level 3 analysis
- 2 • the use of internal, fire, and seismic events importance analysis in identifying
- 3 plant-specific SAMAs
- 4 • the use of industry SAMA analyses in identifying SAMAs applicable to CGS
- 5 • the potential impact of internal, fire, and seismic events PSA model uncertainty on the
- 6 SAMA analysis results
- 7 • further information on the cost benefit analysis of several specific SAMA candidates and
- 8 low-cost alternatives

9 Energy Northwest submitted additional information by letters dated September 17, 2010
10 (Gambhir, 2010), January 28, 2011 (Gambhir, 2011), and May 6, 2011 (Swank, 2011). In
11 response to the RAIs, Energy Northwest provided the following:

- 12 • a description of the major changes to the PSA models since those used in the ER SAMA
- 13 analysis
- 14 • a detailed sensitivity analysis of the impact on the SAMA analysis from the revised
- 15 models and internal and external review comments on the PSA models
- 16 • a description of the CETs used for the internal, fire, and seismic PSA models and the
- 17 relationship between each
- 18 • the process for selecting representative MAAP cases for each release category
- 19 • further details on the population, meteorological, and economic assumptions used in the
- 20 Level 3 analysis
- 21 • basic events importance lists for the internal, fire, and seismic PSA models and the
- 22 SAMA candidates that mitigate each basic event
- 23 • a review of the applicability of industry cost-effective SAMA candidates to CGS
- 24 • results of a revised screening and cost-benefit analysis based on consideration of PSA
- 25 model uncertainties
- 26 • additional information regarding several specific SAMAs

27 Energy Northwest's responses addressed the NRC staff's concerns and resulted in the
28 identification of additional potentially cost-beneficial SAMAs.

29 An assessment of SAMAs for CGS is presented below.

30 **F.2 Estimate of Risk for CGS**

31 Energy Northwest's estimates of offsite risk at CGS are summarized in Section F.2.1. The
32 summary is followed by the NRC staff's review of CGS's risk estimates in Section F.2.2.

33 **F.2.1 CGS's Risk Estimates**

34 Two distinct analyses are combined to form the basis for the risk estimates used in the SAMA
35 analysis—the CGS Level 1 and 2 PSA models, which is an updated version of the IPE
36 (Parrish, 1994) and a supplemental analysis of offsite consequences and economic impacts
37 (essentially a Level 3 PSA model) developed specifically for the SAMA analysis. The SAMA

1 analysis is based on the most recent CGS Level 1 and Level 2 PSA models available at the time
2 of the ER, referred to as CGS PSA Revision 6.2. The scope of the CGS PSA includes Level 1
3 and Level 2 internal, fire, and seismic events risk models. CGS PSA Revision 6.2 is composed
4 of the following:

- 5 • CGS internal events PSA Revision 6.2 model
- 6 • CGS fire PSA Revision 2 model
- 7 • CGS seismic PSA Revision 1 model

8 The fire PSA and seismic PSA are based on the internal events Level 1 and Level 2 PSA
9 Revision 6.2 model. The ER included a SAMA analysis based on CGS PSA Revision 6.2
10 (EN, 2010). Subsequently, in response to NRC staff RAIs, a sensitivity analysis of the SAMA
11 results was provided based on the updated CGS PSA Revision 7.1 (Gambhir, 2011),
12 (Swank, 2011).

13 The baseline CDF for the purposes of the SAMA evaluation, based on CGS PSA Revision 6.2,
14 is approximately 4.8×10^{-6} per year for internal events (which includes internal flooding), 7.4×10^{-6}
15 per year for fire events, and 5.2×10^{-6} per year for seismic events, as determined from
16 quantification of the Level 1 PSA models. The sensitivity analysis CDF, based on CGS PSA
17 Revision 7.1, is approximately 7.4×10^{-6} per year for internal events, 1.4×10^{-6} per year for fire
18 events, and 4.9×10^{-6} per year for seismic events (Gambhir, 2011). For the baseline and
19 sensitivity analysis, the risk reduction benefits associated with internal, fire, and seismic events
20 were separately estimated based on the internal events, fire, and seismic Level 1 and Level 2
21 PSAs. Energy Northwest accounted for the potential risk reduction benefits associated with
22 non-fire and non-seismic external events (e.g., high wind, external flood, and other (HFO)
23 events) by multiplying the estimated benefits for internal events by a factor of 2 (i.e., the
24 contribution from HFO events was assumed to be the same as that from internal events). The
25 estimated SAMA benefits for internal events, fire events, seismic events, and non-fire and
26 non-seismic external events were then summed to provide an overall benefit. This is discussed
27 further in Sections F.2.2 and F.6.2.

28 The breakdown of CDF by initiating event is provided in Tables F-1, F-2, and F-3 for internal
29 events, fire compartments, and seismic damage sequences (SDSs), respectively. The results
30 from both the baseline PSA model (Revision 6.2) and the sensitivity analysis PSA model
31 (Revision 7.1) are provided. As shown in Table F-1, events initiated by station blackout (SBO),
32 internal flooding, and special initiators—such as loss DC and AC buses, loss of heating,
33 ventilation and air conditioning (HVAC), and loss of service water and air systems—are the
34 dominant contributors to the internal event CDF for CGS PSA Revision 6.2. The dominant
35 contributors to internal event CDF for CGS PSA Revision 7.1 are internal flooding, anticipated
36 transients without scram (ATWS), loss of feedwater (FW), and manual shutdown. In response
37 to an NRC staff RAI (Gambhir, 2010), Energy Northwest explained that SBO and loss-of-offsite
38 power (LOOP) sequences include plant centered, grid-related, and severe weather related
39 contributions and are dominated by the plant centered contribution. As shown in Table F-2, the
40 dominant contributors to fire CDF are fires in the radwaste building for CGS PSA Revisions 6.2
41 and 7.1. As shown in Table F-3, the dominant contributors to seismic CDF are structural
42 failures of the reactor pressure vessel (RPV) or Category 1 buildings or both and wide-spread
43 failure of safe shutdown equipment list (SSEL) equipment for CGS PSA Revisions 6.2 and 7.1.

Table F-1. CGS CDF for internal events

| Initiating event | PSA Model Revision 6.2 | | PSA Model Revision 7.1 | |
|---|----------------------------|--------------------------------------|----------------------------|--------------------------------------|
| | CDF (per year) | % contribution to CDF ^(a) | CDF (per year) | % contribution to CDF ^(b) |
| SBO | 1.6x10 ⁻⁶ | 33 | 1.3x10 ⁻⁷ | 2 |
| Internal flooding | 7.4x10 ⁻⁷ | 15 | 2.3x10 ⁻⁶ | 31 |
| Special initiators | 7.2x10 ⁻⁷ | 15 | 3.0x10 ⁻⁷ | 4 |
| LOOP | 3.0x10 ⁻⁷ | 6 | 9.3x10 ⁻⁸ | 1 |
| RPV rupture | 3.0x10 ⁻⁷ | 6 | 1.0x10 ⁻⁸ | <1 |
| Loss of condenser | 2.2x10 ⁻⁷ | 5 | 3.7x10 ⁻⁷ | 5 |
| Inadvertent stuck open main steam safety relief valve (SRV) | 2.1x10 ⁻⁷ | 4 | 8.3x10 ⁻⁸ | 1 |
| Loss of FW | 1.9x10 ⁻⁷ | 4 | 7.2x10 ⁻⁷ | 10 |
| Steam line break outside containment | 1.5x10 ⁻⁷ | 3 | 5.8x10 ⁻⁷ | 8 |
| Manual shutdown | 1.3x10 ⁻⁷ | 3 | 7.9x10 ⁻⁷ | 10 |
| Turbine trip | 1.2x10 ⁻⁷ | 2 | 1.5x10 ⁻⁷ | 2 |
| ATWS | 8.4x10 ⁻⁸ | 2 | 1.4x10 ⁻⁶ | 19 |
| Main steam isolation valve (MSIV) closure | 4.6x10 ⁻⁸ | 1 | 3.6x10 ⁻⁷ | 5 |
| Loss of coolant accidents (LOCAs) | 4.8x10 ⁻⁹ | <1 | 2.0x10 ⁻⁷ | 3 |
| Total CDF (internal events)^(c) | 4.8x10⁻⁶ | 100 | 7.4x10⁻⁶ | 100 |

^(a) Percentage is based on internal event CDF contribution in ER Table E.3-3 (EN, 2010) and total internal event CDF.

^(b) Percentage is based on internal event CDF contribution in Table A-1 (internal events) of the responses to NRC staff RAIs (Gambhir, 2011) and total internal event CDF.

^(c) Columns may not sum to reported totals due to round off.

Table F-2. Important CGS fire compartments and their contribution to fire CDF

| Fire compartment | PSA Model Revision 6.2 | | PSA Model Revision 7.1 | |
|--|------------------------|--------------------------------------|------------------------|--------------------------------------|
| | CDF (per year) | % contribution to CDF ^(a) | CDF (per year) | % contribution to CDF ^(a) |
| R1J: Reactor Building 522 ³ | 1.2x10 ⁻⁶ | 16 | ≤1.2x10 ⁻⁶ | ≤9 |
| W14: Radwaste 467' Switchgear Room 1 | 1.0x10 ⁻⁶ | 14 | 1.4x10 ⁻⁶ | 10 |
| W04: Radwaste 467' electrical equipment room | 8.4x10 ⁻⁷ | 11 | 1.7x10 ⁻⁶ | 12 |
| R1D: Northwest Reactor Building 471 ³ | 7.4x10 ⁻⁷ | 10 | ≤7.4x10 ⁻⁷ | ≤5 |
| W11: Radwaste A/C room ³ | 7.3x10 ⁻⁷ | 10 | ≤7.3x10 ⁻⁷ | ≤5 |
| W03: Radwaste 467' cable chase | 4.5x10 ⁻⁷ | 6 | 9.4x10 ⁻⁷ | 7 |
| W08: Radwaste 467' Switchgear Room 2 | 3.6x10 ⁻⁷ | 5 | 9.7x10 ⁻⁷ | 7 |

| Fire compartment | PSA Model Revision 6.2 | | PSA Model Revision 7.1 | |
|---|--|--------------------------------------|--|--------------------------------------|
| | CDF (per year) | % contribution to CDF ^(a) | CDF (per year) | % contribution to CDF ^(a) |
| Y01: Transformer yard ³ | 3.2×10^{-7} | 4 | $\leq 3.2 \times 10^{-7}$ | ≤ 2 |
| W10: Radwaste main control room ³ | 3.0×10^{-7} | 4 | $\leq 3.0 \times 10^{-7}$ | ≤ 2 |
| W05: Radwaste 467' Battery Room 1 | 2.5×10^{-7} | 3 | 3.2×10^{-7} | 2 |
| W02: Radwaste cable spreading room | 2.2×10^{-7} | 3 | 4.4×10^{-7} | 3 |
| W13: Radwaste 525' emergency chiller | 2.0×10^{-7} | 3 | 4.9×10^{-7} | 4 |
| T1A: Turbine Generator West 441' | 1.6×10^{-7} | 2 | 2.9×10^{-7} | 2 |
| T12: Turbine generator south corridors ³ | 1.3×10^{-7} | 2 | $\leq 1.3 \times 10^{-7}$ | ≤ 1 |
| W1A: Radwaste Building 437' | 1.2×10^{-7} | 2 | 4.4×10^{-7} | 3 |
| W07: Radwaste 467' Division 2 electrical equipment | 9.0×10^{-8} | 1 | 1.7×10^{-6} | 12 |
| R1B: Northeast Reactor Building 471' | 5.8×10^{-8} | <1 | 1.6×10^{-7} | 1 |
| T1C: Turbine Generator East 441' | 5.2×10^{-8} | <1 | 1.3×10^{-6} | 9 |
| T1D: Turbine Generator West 471' | 4.9×10^{-8} | <1 | 1.6×10^{-7} | 1 |
| R1C: Southeast Reactor Building 471' | 2.0×10^{-8} | <1 | 3.9×10^{-7} | 3 |
| R1L: Reactor Building 572' | 3.3×10^{-9} | <1 | 2.4×10^{-7} | 2 |
| Total fire CDF^(b) | 7.4×10^{-6} | 100 | 1.4×10^{-5} | 100 |

^(a) Percentage is based on fire CDF contribution in Table A-1 (fire) of the responses to NRC staff RAIs (Gambhir, 2011), (Swank, 2011) and total fire CDF.

^(b) Columns may not sum to reported totals due to round off or assumptions about bounding values for selected compartments in PSA Revision 7.1 (see footnote 3).

^(c) Only fire CDF contributions for compartments that increased by at least 1 percent from PSA Revision 6.2 were provided for Revision 7.1. Contributions for these others remaining from Revision 6.2 are shown as bounding values, based on their previous contributions in Revision 6.2, since it was reported that non increased by more than 1 percent.

Table F-3. Important SDSs and their contribution to seismic CDF

| SDS sequence | Description of seismic-induced failures | PSA Model Revision 6.2 | | PSA Model Revision 7.1 | |
|--------------|--|------------------------|--------------------------------------|------------------------|--------------------------------------|
| | | CDF (per year) | % contribution to CDF ^(a) | CDF (per year) | % contribution to CDF ^(a) |
| SDS42 | Failure of RPV or Category I buildings or both | 2.4×10^{-6} | 46 | 2.4×10^{-6} | 49 |
| SDS41 | Wide-spread failure of safety SSEL equipment | 1.6×10^{-6} | 31 | 1.6×10^{-6} | 33 |
| SDS2 | Balance of plant (BOP), CST, LOOP, small-small LOCA | 2.3×10^{-7} | 4 | 1.2×10^{-7} | 2 |
| S624 | LOOP, small-small LOCA, and Division 1 & 2 AC distribution, BOP, and CST failure | 2.2×10^{-7} | 4 | 9.0×10^{-8} | 2 |

Appendix F

| SDS sequence | Description of seismic-induced failures | PSA Model Revision 6.2 | | PSA Model Revision 7.1 | |
|--|--|----------------------------|--------------------------------------|----------------------------|--------------------------------------|
| | | CDF (per year) | % contribution to CDF ^(a) | CDF (per year) | % contribution to CDF ^(a) |
| SDS4 | BOP, condensate storage tank (CST), LOOP, small-small LOCA, Diesel Generators (DGs) 1 & 2 | 1.8x10 ⁻⁷ | 3 | 8.2x10 ⁻⁸ | 2 |
| S523 | BOP, CST, LOOP, nitrogen (N ₂) tank, small-small LOCA, DGs 1 & 2, Division III | 1.3x10 ⁻⁷ | 2 | 1.4x10 ⁻⁷ | 3 |
| SLAC | BOP, CST, LOOP, N ₂ tank, medium LOCA, Division I & II, Division III, offsite AC not recoverable | 1.1x10 ⁻⁷ | 2 | 1.1x10 ⁻⁷ | 2 |
| S725 | BOP, CST, LOOP, N ₂ tank, small-small LOCA, Division I & II, Division III, offsite AC not recoverable | 1.0x10 ⁻⁷ | 2 | 1.0x10 ⁻⁷ | 2 |
| SDS22 | BOP, CST, LOOP, N ₂ tank, small-small LOCA, DGs 1 & 2 | 6.2x10 ⁻⁸ | 1 | 2.8x10 ⁻⁸ | 1 |
| SDS38 | BOP, CST, LOOP, N ₂ tank, DGs stalled and not restarted | 5.8x10 ⁻⁸ | 1 | 9.5x10 ⁻⁸ | 2 |
| Other | | 1.6x10 ⁻⁷ | 3 | 1.4x10 ⁻⁷ | 3 |
| Total Seismic CDF^(b) | | 5.2x10⁻⁶ | 100 | 4.9x10⁻⁶ | 100 |

^(a) Percentage is based on seismic CDF contribution in Table A-1 (Seismic) of the responses to NRC staff RAIs (Gambhir, 2011) and total seismic CDF.

^(b) Columns may not total to reported totals due to round off.

1 The Level 2 CGS PSA models that form the basis for the SAMA evaluation are updated
2 versions of the Level 2 IPE (Parrish, 1994) and IPEEE (Parrish, 1995) models. The Level 2
3 analysis is linked to the Level 1 model by assigning each Level 1 core damage sequence to a
4 plant damage state (PDS). The Level 1 core damage sequences are binned into 21 PDSs for
5 internal and fire events and 12 PDSs for seismic events. The Level 2 model uses a set of
6 CETs, one for each PDS, containing both phenomenological and systemic events. The CET
7 probabilistically evaluates the progression of the damaged core with respect to release to the
8 environment. CET nodes are evaluated using supporting fault trees and logic rules. In the
9 baseline analysis, the CET end states are examined for considerations of timing of release,
10 magnitude of release, and whether the fission products were scrubbed and subsequently
11 assigned to release categories. In the sensitivity analysis, the CET endstates are examined for
12 considerations of timing and magnitude of release and are subsequently assigned to release
13 categories.

14 The result of the Level 2 PSA is a set of four release categories in the baseline analysis and
15 nine release categories in the sensitivity analysis, with their respective frequency and release
16 characteristics. The frequency of each release category was obtained by summing the
17 frequency of the individual accident progression CET endpoints binned into the release
18 category. Source terms were developed for each of the release categories using the results of
19 MAAP computer code calculations. In response to NRC staff RAIs, Energy Northwest stated
20 that MAAP Version 4.0.4 was used in both the CGS baseline and sensitivity analyses to develop

1 the source terms for input to the Level 3 consequence analyses (Gambhir, 2010). The source
 2 terms for each release category are provided in Table E.6-6 of ER Appendix E (EN, 2010) for
 3 the baseline analysis and Table 2-4 of the RAI responses (Gambhir, 2011) for the sensitivity
 4 analysis. The frequency of each release category is provided in ER Appendix E Tables E.4-3,
 5 E.4-5, and E.4-6 for internal, fire, and seismic events, respectively, for the baseline analysis,
 6 and in corresponding Tables A-3, A-4, and A-5 of the RAI responses for the sensitivity analysis.

7 The offsite consequences and economic impact analyses use the MACCS2 code to determine
 8 the offsite risk impacts on the surrounding environment and public. Inputs for these analyses
 9 include plant-specific and site-specific input values for core radionuclide inventory, source term
 10 and release characteristics, site meteorological data, projected population distribution (within an
 11 80-kilometer (km) (50-mile (mi)) radius) for the year 2045, emergency response evacuation
 12 modeling, and economic data. The core radionuclide inventory is based on plant-specific
 13 evaluation and corresponds to end-of-cycle values for the CGS operating at the current licensed
 14 power of 3,486 megawatt-thermal (MWt). The magnitude of the onsite impacts (in terms of
 15 clean-up and decontamination costs and occupational dose) is based on information provided in
 16 NUREG/BR-0184 (NRC, 1997a).

17 In the ER, Energy Northwest estimated the dose to the population within 80 km (50 mi) of the
 18 CGS site to be approximately 0.037 person-Sievert (Sv) (3.7 person-roentgen equivalent man
 19 (rem)) per year for internal events, 0.086 person-Sv (8.6 person-rem) per year for fire events,
 20 and 0.067 person-Sv (6.7 person-rem) per year for seismic events. These numbers equal a
 21 total population dose from internal and external events of 0.190 person-Sv (19.0 person-rem)
 22 per year for the baseline analysis using CGS PSA Revision 6.2. The breakdown of the total
 23 population dose by containment release mode for internal, fire, and seismic events is
 24 summarized in Table F-4. Large, late, not-scrubbed (LLN) release is the dominant contributor to
 25 the population dose risk at CGS for all three hazard types.

26 In response to NRC staff RAIs, Energy Northwest estimated the dose to the population within
 27 80 km (50 mi) of the CGS site to be approximately 0.055 person-Sv (5.5 person-rem) per year
 28 for internal events, 0.090 person-Sv (9.0 person-rem) per year for fire events, and 0.059
 29 person-Sv (5.9 person-rem) per year for seismic events. These numbers equal a total
 30 population dose from internal and external events of 0.204 person-Sv (20.4 person-rem) per
 31 year for the sensitivity analysis using CGS PSA Revision 7.1. The breakdown of the total
 32 population dose by containment release mode for internal, fire, and seismic events is
 33 summarized in Table F-5. Moderate and intermediate release is the dominant contributor to the
 34 population dose risk at CGS for internal and fire events while high and early release is the
 35 dominant contributor to population dose risk for seismic events.

36 **Table F-4. Breakdown of population dose by containment release mode for PSA**
 37 **Revision 6.2**

| Containment release mode | Internal events | | Fire events | | Seismic events | |
|-------------------------------------|---|----------------------------------|---|----------------------------------|---|----------------------------------|
| | Population dose (person- rem ^(a) per year) | % contribution ^(b) | Population dose (person- rem ^(a) per year) | % contribution ^(b) | Population dose (person- rem ^(a) per year) | % contribution ^(b) |
| Large, Late, Not- Scrubbed (LLN) | 2.1 | 57 | 7.6 | 88 | 3.9 | 58 |
| Large, early, not- | 0.9 | 23 | 0.3 | 4 | 2.8 | 42 |

Appendix F

| Containment release mode | Internal events | | Fire events | | Seismic events | |
|-----------------------------|--|-------------------------------|--|-------------------------------|--|-------------------------------|
| | Population dose (person-rem ^(a) per year) | % contribution ^(b) | Population dose (person-rem ^(a) per year) | % contribution ^(b) | Population dose (person-rem ^(a) per year) | % contribution ^(b) |
| scrubbed (LEN) | | | | | | |
| Large, late scrubbed (LLS) | 0.7 | 20 | 0.7 | 8 | negligible | negligible |
| Large, early scrubbed (LES) | 0.0 | 0 | 0.0 | 0 | 0.0 | 0 |
| Containment intact (COK) | negligible | negligible | negligible | negligible | negligible | negligible |
| Total | 3.7 | 100 | 8.6 | 100 | 6.7 | 100 |

^(a) One person-rem = 0.01 person-Sv

^(b) Percentage is based on population dose contribution in Tables E.7-1, E.7-2, and E.7-3 of the ER (EN, 2010) for internal events, fire events, and seismic events, respectively, and total population dose for each hazard.

Table F-5. Breakdown of population dose by containment release mode for PSA Revision 7.1

| Containment release mode | Internal events | | Fire events | | Seismic events | |
|-------------------------------------|--|-------------------------------|--|-------------------------------|--|-------------------------------|
| | Population dose (person-rem ^(a) per year) | % contribution ^(b) | Population dose (person-rem ^(a) per year) | % contribution ^(b) | Population dose (person-rem ^(a) per year) | % contribution ^(b) |
| High/early release (H/E) | 0.7 | 13 | 0.1 | 1 | 3.8 | 64 |
| High/intermediate release (H/I) | 0.3 | 6 | 0.1 | 1 | 0.9 | 15 |
| Moderate/early release (M/E) | 0.2 | 4 | <0.1 | <1 | negligible | negligible |
| Moderate/intermediate release (M/I) | 4.0 | 74 | 8.5 | 94 | 1.1 | 19 |
| Low/early release (L/E) | <0.1 | 1 | <0.1 | <1 | <0.1 | <1 |
| Low/intermediate release (L/I) | negligible | negligible | <0.1 | <1 | negligible | negligible |
| Low-low/early release (LL/E) | <0.1 | <1 | 0.1 | 1 | <0.1 | <1 |
| Low-low/intermediate release (LL/I) | 0.1 | 2 | 0.1 | 1 | 0.1 | 2 |
| Containment intact (COK) | negligible | 0 | negligible | 0 | negligible | 0 |

| Containment release mode | Internal events | | Fire events | | Seismic events | |
|----------------------------|--|-------------------------------|--|-------------------------------|--|-------------------------------|
| | Population dose (person-rem ^(a) per year) | % contribution ^(b) | Population dose (person-rem ^(a) per year) | % contribution ^(b) | Population dose (person-rem ^(a) per year) | % contribution ^(b) |
| Total^(c) | 5.5 | 100 | 9.0 | 100 | 5.9 | 100 |

^(a) One person-rem = 0.01 person-Sv

^(b) Percentage is based on population dose contribution in Tables A-6, A-7, and A-8 of the RAI responses (Gambhir, 2011) for internal events, fire events, and seismic events, respectively, and total population dose for each hazard.

^(c) Column may not total to reported totals due to round off.

1 F.2.2 Review of CGS's Risk Estimates

2 Energy Northwest's determination of offsite risk at CGS is based on the following major
3 elements of analysis:

- 4 • Level 1 and 2 risk models that form the bases for the original 1992 IPE submittal
5 (Sorensen, 1992) and subsequent Revision 1 IPE submittal (Parrish, 1994), the external
6 event analyses of the 1995 IPEEE submittal (Parrish, 1995), and the major modifications
7 to the IPE model that have been incorporated in the CGS internal events, fire, and
8 seismic PSAs
- 9 • MACCS2 analyses performed to translate fission product source terms and release
10 frequencies from the Level 2 PSA model into offsite consequence measures (essentially
11 equates to a Level 3 PSA)

12 Each of these analyses was reviewed to determine the acceptability of the CGS risk estimates
13 for the SAMA analysis, as summarized below.

14 The NRC staff's review of the Energy Northwest IPE is described in an NRC report dated April
15 8, 1997 (NRC, 1997b), which is based on Revision 1 of the IPE. Energy Northwest requested
16 that NRC discontinue its review of the original IPE after Revision 1 of the IPE was submitted.
17 Based on a review of the Revision 1 IPE submittal and responses to RAIs, the NRC staff
18 concluded that the IPE submittal met the intent of GL 88-20 (NRC, 1988); that is, the licensee's
19 IPE process is capable of identifying the most likely severe accidents and severe accident
20 vulnerabilities. Although no vulnerabilities were identified in the IPE, several improvements to
21 the plant or procedures were identified. These improvements have been either implemented at
22 the site or addressed in the SAMA evaluation process, and they are discussed in Section F.3.2.

23 There have been 13 revisions to the internal events PSA model since the 1992 IPE submittal, or
24 12 revisions since the 1994 IPE submittal reviewed by the NRC. CGS PSA Revision 6.2 was
25 used as the baseline PSA for the SAMA analysis while the updated CGS PSA Revision 7.1 was
26 used in a sensitivity analysis. A listing of the major changes in each revision of the internal
27 events PSA was provided by Energy Northwest in the ER (EN, 2010) and in response to an
28 NRC staff RAI (Gambhir, 2011) and is summarized in Table F-6. A comparison of the internal
29 events CDF between the 1994 IPE and Revision 6.2 of the CGS PSA model used for the
30 baseline analysis indicates a decrease of approximately 73 percent (from 1.8×10^{-5} per year to
31 4.8×10^{-6} per year). A subsequent revision, Revision 7.1, used for the sensitivity analysis,

Appendix F

1 resulted in an increase in the internal events CDF to 7.4×10^{-6} per year compared to the
 2 Revision 6.2 CDF.

3 The internal events CDF value from the 1994 Energy Northwest IPE (1.8×10^{-5} per year) is in the
 4 middle of the range of the CDF values reported in the IPEs for BWR 5/6 plants. Figure 11.2 of
 5 NUREG-1560 shows that the IPE based internal events CDFs for these plants range from about
 6 1×10^{-5} per year to 4×10^{-5} per year, with an average CDF for the group of about 2×10^{-5} per year
 7 (NRC, 1997c). It is recognized that other plants have updated the values for CDF subsequent
 8 to the IPE submittals to reflect modeling and hardware changes. Based on CDF values
 9 reported in the SAMA analyses for LRAs, the internal events CDF result for CGS used for the
 10 SAMA analysis (4.8×10^{-6} per year used for the baseline analysis and 7.4×10^{-6} per year used for
 11 the sensitivity analysis) is less than the internal event CDF for other plants of similar vintage and
 12 characteristics.

13 The truncation limits for the Revision 6.2 PSA internal events, fire, and seismic models used in
 14 the quantification of Level 1 and Level 2 CDFs range from 5×10^{-14} to 1×10^{-8} per year. The NRC
 15 staff asked Energy Northwest to explain the basis for the different truncation limits used in the
 16 CDF quantification (Doyle, 2010a). In response to the RAI, Energy Northwest explained that in
 17 general a four-order difference between the calculated total and truncation limit was maintained,
 18 except in a few cases where a lesser difference was appropriate, such as the case where the
 19 calculated CDF appeared to converge at a higher truncation limit (Gambhir, 2010). Thus, the
 20 truncation limit varied for each hazard model depending upon the level at which convergence
 21 occurred. In a followup RAI response, Energy Northwest further explained that at least a
 22 four-order difference between the calculated total and truncation limit was maintained in all
 23 cases for the Revision 7.1 PSA model (Swank, 2011).

24 There have been three revisions to the fire PSA model and two revisions to the seismic PSA
 25 model since the 1995 IPEEE submittal, as summarized in Tables F-7 and F-8, respectively. A
 26 comparison of the fire events CDF between the 1995 IPEEE and Revision 2 of the CGS fire
 27 events PSA model used for the baseline SAMA evaluation indicates a decrease of
 28 approximately 58 percent (from 1.8×10^{-5} per year to 7.4×10^{-6} per year). A comparison of the
 29 seismic events CDF between the 1995 IPEEE and Revision 1 of the CGS seismic events PSA
 30 model used for the baseline SAMA evaluation indicates a decrease of approximately 75 percent
 31 (from 2.1×10^{-5} per year to 5.2×10^{-6} per year). Subsequently, as a result of integrating Revision 2
 32 of the fire PSA model and Revision 1 of the seismic PSA model with internal events PSA
 33 Revision 7.1 (no upgrades to the fire or seismic models were performed), the fire CDF
 34 increased to 1.4×10^{-5} per year, and the seismic CDF decreased to 4.9×10^{-6} per year
 35 (Gambhir, 2011). The integrated PSA Revision 7.1 model was then used for the sensitivity
 36 analysis.

37 **Table F-6. CGS internal events PSA historical summary**

| PSA version | Summary of changes from prior model | CDF (per year) |
|-----------------------|-------------------------------------|----------------------|
| Revision 0 08/1992 | Original IPE submittal | 5.4×10^{-5} |

| PSA version | Summary of changes from prior model | CDF (per year) |
|-------------------------|--|----------------------|
| Revision 1 07/1994 | Revision 1 IPE submittal <ul style="list-style-type: none"> revised common cause failure (CCF) for SRVs, MSIVs, & circuit breakers revised LOOP initiating frequency, event tree structure, & power recovery factors revised human reliability analysis (HRA) methodology enhanced MAAP calculations | 1.8×10^{-5} |
| Revision 2 08/1996 | <ul style="list-style-type: none"> updated initiating frequencies developed a failure modes effects analysis added event trees for loss of Division 2 DC, loss of AC Bus, loss of control room HVAC, & loss of HVAC to switchgear buses SM-7 and SM-8 deleted event trees for loss of service water, loss of CN added reactor core isolation cooling (RCIC) as success path in the stuck open relief valve event tree | 1.4×10^{-5} |
| Revision 3 09/1997 | <ul style="list-style-type: none"> updated "test & maintenance" unavailability data updated random failure data updated CCF data revised the LOCA (large, medium, small) initiating event frequency recalculated interfacing system LOCA (ISLOCA) initiating event frequency | 1.7×10^{-5} |
| Revision 4 09/1999 | <ul style="list-style-type: none"> modified the LOOP initiating event frequency added emergency diesel generator (EDG) recovery implemented decay heat removal (DHR) success after AC recovery during LOOP added load shed & offsite recovery during LOOP deleted the success path using water make-up from the diesel fire pump during LOOP updated EDG failure rate data using plant-specific data | 2.1×10^{-5} |
| Revision 4.1 09/2001 | <ul style="list-style-type: none"> updated equipment failure rate & unavailability data | 2.2×10^{-5} |
| Revision 4.2 06/2002 | <ul style="list-style-type: none"> added mechanism operated cell switch model added firewater for post containment failure injection | 1.8×10^{-5} |

Appendix F

| PSA version | Summary of changes from prior model | CDF (per year) |
|--------------------------|--|----------------------|
| Revision 5 01/2004 | <ul style="list-style-type: none"> added the RPV rupture as an initiating event revised the LOOP & SBO event tree sequences updated the transient & LOCA initiating event frequencies revised the AC fault tree to include a second battery charger applied the emergency core cooling system (ECCS) pump room HVAC engineering calculations added reactor building HVAC fault tree revised non-recovery probabilities for offsite power (Gambhir, 2010) revised calculation for battery life (Gambhir, 2010) added success criteria for some systems updated failure rate data revised the Level 2 analysis focusing on large early-release frequency (LERF) | 7.3×10^{-6} |
| Revision 5.1 04/2005 | <ul style="list-style-type: none"> revised the HRA revised the flooding analysis updated the equipment test & maintenance data | 5.6×10^{-6} |
| Revision 5.2 04/2005 | <ul style="list-style-type: none"> corrected an error in the residual heat removal (RHR) fault tree | 5.7×10^{-6} |
| Revision 6 01/2006 | <ul style="list-style-type: none"> incorporated numerous modeling changes to address the requirements of mitigating system performance indicator (MSPI) implementation, including ATWS, ISLOCA, steam generator HVAC, & LOOP | 4.7×10^{-6} |
| Revision 6.1 05/2006 | <ul style="list-style-type: none"> removed "Failure to Remain Closed" event for valve RHR-V-48A | 4.7×10^{-6} |
| Revision 6.21 08/2006 | <ul style="list-style-type: none"> revised the power sources for air handling units WMA-AH-53A/B | 4.8×10^{-6} |
| Revision 7.12 2010 | <ul style="list-style-type: none"> enhanced CET to enable reflection of plant & procedure changes expanded CET to address broader spectrum of release end states added success paths for degraded core conditions incorporated updated CGS-specific emergency procedures incorporated results of latest containment safety study performed additional plant-specific MAAP calculations to support improved system success criteria explicitly linked the Level 1 & 2 accident sequences | 7.4×10^{-6} |

(a) CGS internal event PSA version was used as the basis for the SAMA baseline analysis.

(b) CGS internal event PSA version was used as the basis for the SAMA sensitivity analysis.

Table F-7. CGS fire events PSA historical summary

| PSA version | Summary of changes from prior model | CDF (per year) |
|--------------------------------------|--|----------------------|
| IPEEE 06/1994 | IPEEE submittal | 1.8×10^{-5} |
| Revision 0 04/2002 | <ul style="list-style-type: none"> Upgraded to incorporate NRC comments on IPEEE | 1.2×10^{-5} |
| Revision 1 06/2004 | <ul style="list-style-type: none"> Incorporated latest Electric Power Research Institute (EPRI) fire events database Incorporated internal events PSA Revision 5.0 Level 1 model Re-evaluated cable spreading rooms (RC 2A, 2B, and 2C) as one area Included Level 2 PSA | 1.4×10^{-5} |
| Revision 2 ^(a) 11/2006 | <ul style="list-style-type: none"> Incorporated internal events PSA Revision 6.2 Level 1 model Incorporated the updated compartment fire loss data obtained from the revised cable database Refined compartment fires scenarios to use the internal events PSA LOOP & SBO event trees | 7.4×10^{-6} |
| Revision 2 ^(b) 2010 | <ul style="list-style-type: none"> Incorporated internal events PSA Revision 7.1 model | 1.4×10^{-5} |

(a) CGS fire event PSA version was used as the basis for the SAMA baseline analysis.

(b) CGS fire event PSA version was used as the basis for the SAMA sensitivity analysis.

Table F-8. CGS seismic events PSA historical summary

| PSA version | Summary of changes from prior model | CDF (per year) |
|--------------------------------------|--|----------------------|
| IPEEE 06/1995 | IPEEE submittal | 2.1×10^{-5} |
| Revision 0 12/2004 | <ul style="list-style-type: none"> upgraded seismic IPEEE to Level 1 and 2 PSA consistent with the ANSI/ANS-58.21-2003 standard (ANS, 2003) & the EPRI Seismic Probabilistic Risk Assessment Implementation Guide | 6.7×10^{-6} |
| Revision 1 ^(a) 02/2007 | <ul style="list-style-type: none"> incorporated internal events PSA Revision 6.2 Level 1 model deleted LERF multipliers & incorporated new model based on the internal events PSA Level 2 Revision 6.2 model re-quantified & revised importance, sensitivity, & uncertainty analysis updated EDG-3 mission time revised & added HEPs added new seismic event trees | 5.2×10^{-6} |
| Revision 1 ^(b) 2010 | <ul style="list-style-type: none"> incorporated internal events PSA Revision 7.1 model | 4.9×10^{-6} |

(a) CGS seismic event PSA version was used as the basis for the SAMA baseline analyses.

(b) CGS seismic event PSA version was used as the basis for the SAMA sensitivity analysis.

Appendix F

1 The NRC staff considered the peer reviews performed for the CGS PSA and the potential
2 impact of the review findings on the SAMA evaluation. In the ER, and in response to an NRC
3 staff RAI (Gambhir, 2010), Energy Northwest identified and described the scope of four external
4 reviews and seven technical reviews. The first external review, conducted by the BWR Owners'
5 Group (BWROG) in 1997 and referred to as the BWROG Certification Peer Review, reviewed
6 PSA model, Revision 3, Level 1 and 2 internal events (including internal flooding). Energy
7 Northwest stated that all comments produced by this review were resolved.

8 Two external reviews, an industry peer review, and an NRC inspection of the CGS PSA were
9 conducted in 2004 in support of Energy Northwest's participation in the NRC's Regulatory Guide
10 (RG) 1.200 pilot program. Within this pilot program, the CGS internal and fire events PSAs
11 were upgraded and peer reviewed to the American Society of Mechanical Engineering (ASME)
12 Standard RA-Sa-2003 (ASME, 2003) as modified by the trial use version of NRC RG 1.200
13 (NRC, 2004b). The industry peer review, conducted by ERIN Engineering (Webring, 2004) in
14 2004, reviewed PSA model, Revision 5.0, Level 1 and 2 internal and fire events PSA. Energy
15 Northwest stated that there were no Level A (extremely important) facts and observations
16 (F&Os) from this review. In response to an NRC staff RAI, Energy Northwest listed and
17 described all unresolved Level B (important) F&Os, with the exception of F&Os categorized as
18 having only documentation impacts, which are not resolved in the Revision 6.2 PSA model
19 (Gambhir, 2010). Energy Northwest explained that all but two of these F&Os address ASME
20 PSA supporting requirements (SRs) that were determined by the peer review team to meet at
21 least capability Category I (CC-I) requirements. Energy Northwest's assessment of the two
22 F&Os against SRs that were determined to not meet at least CC-I determined that one is
23 primarily a documentation issue that limits the ability to identify basic event LERF contributors.
24 The other recommends completing switchgear room heat-up calculations that, after completion,
25 confirmed that the PSA Revision 6.2 modeling used for the SAMA baseline evaluation is
26 conservative. Furthermore, Energy Northwest stated that all of the identified Level B F&Os
27 have been resolved in the PSA Revision 7.1 model used for the SAMA sensitivity analysis.

28 Subsequent to the industry peer review, the NRC performed an inspection of the CGS PSA
29 documentation, the industry peer review results, and the applicant's self-assessment report in
30 2004 to determine if RG 1.200 and the ASME standard provide adequate guidance to
31 demonstrate the technical adequacy of a PSA (Benney, 2006). The NRC review was conducted
32 like a typical peer review except that the review also addressed the usability of the ASME
33 standard. The ER provides a list of specific unresolved issues as in-progress at the time of the
34 ER for the next revision of the PSA model based on this review (EN, 2010). These findings
35 include recommendations to credit mitigation systems that are not currently modeled,
36 refinement of initiator frequencies and failure probabilities, and recommendations to refine
37 assessment and modeling of equipment performance related to flooding events and Level 2
38 phenomena. In response to an NRC staff RAI, Energy Northwest stated that all significant
39 unresolved F&Os or issues that would impact the PSA quantitative results are addressed by the
40 unresolved Level B F&Os discussed above for the 2004 industry peer review, which have been
41 resolved in the PSA Revision 7.1 model used for the SAMA sensitivity analysis.

42 The last of the four external peer reviews is an NRC inspection of the CGS PSA, performed in
43 2006, to verify that CGS correctly implemented the MSPI guidance. This included review of the
44 data CGS used to generate the MSPI basis document and actual unavailability and unreliability
45 values. There were no unresolved issues from this NRC inspection (Gambhir, 2010).

46 The technical reviews of the CGS PSA identified and described by Energy Northwest are as
47 follows:

- 1 • A 1994 independent technical review of the Revision 0 and Revision 1 IPE by Scientech
2 (previously NUS)—All review comments were resolved.
- 3 • A 2002 internal review of the systems analysis (SY) and initiating events (IE) elements of
4 PSA Revision 4.2—Changes to the SY and IE elements were subsequently evaluated by
5 the 2004 industry peer review and NRC inspection.
- 6 • A 2002–2003 technical review by Scientech to upgrade the internal events PSA
7 Revision 4.2 model to support a license amendment request to change the DG
8 completion time technical specification—This request was subsequently evaluated by
9 the 2004 industry peer review and NRC inspection.
- 10 • A 2004 technical review by independent consultants to assess a common cause
11 condition associated with the mechanism operated cell switch for the 4160 V
12 switchgear—All identified issues were resolved.
- 13 • A 2004 technical review by ERIN Engineering of the PSA Revision 5.0 model HRA
14 related to SBO IEs—The review identified many additional human failures, some of
15 which were resolved in PSA Revision 5.1. Unresolved issues, characterized as an area
16 of model incompleteness, were identified in the ER and subsequently resolved in the
17 PSA Revision 7.1 model used for the SAMA sensitivity analysis.
- 18 • A 2006 self-assessment of the Revision 6.0 PSA model to assure it would meet the
19 implementation requirements for MSPI—Unresolved issues, characterized as an area of
20 model incompleteness, were identified in the ER and subsequently resolved in the PSA
21 Revision 7.1 model used for the SAMA sensitivity analysis.
- 22 • A 2008 self-assessment of CGS PSA adequacy to support extension of completion time
23 for low-pressure coolant injection (LPCI) and low-pressure core spray (LPCS) systems—
24 Unresolved issues, characterized as an area of model incompleteness, were identified in
25 the ER and subsequently resolved in the PSA Revision 7.1 model used for the SAMA
26 sensitivity analysis.

27 The NRC staff asked Energy Northwest to identify any changes to the plant, including physical
28 and procedural modifications, since Revision 6.2 of the CGS internal events PSA, Revision 2 of
29 the CGS fire PSA, and Revision 1 of the seismic PSA that could have a significant impact on the
30 results of the SAMA analysis (Doyle, 2010a). In response to the RAI, Energy Northwest
31 identified three physical plant changes since PSA model Revision 6.2 that could potentially
32 impact the SAMA evaluation (Gambhir, 2010). The first change provides for the ability to
33 cross-connect a DG to either the Division 1 or 2 emergency buses during extended SBO and
34 included changes to LOOP and SBO procedures. Implementation of this change reduces CDF
35 and, therefore, the benefits associated with SAMAs identified to improve plant response to
36 LOOP or SBO; Energy Northwest concluded that the SAMA analysis is conservative relative to
37 this modification. The second change added a portable 480 V DG (DG-4) and included
38 associated procedure changes for its use to provide an alternate source of AC power.
39 Implementation of this change improves the ability of CGS to cope with an SBO when one DG is
40 inoperable and, therefore, reduces CDF. The third change was an upgrade of the FW and
41 turbine control systems. The anticipated higher reliability from these improved systems has not
42 been credited in the PSA because of insufficient operational history to support a Bayesian
43 update; therefore, Energy Northwest considers this improvement to be risk neutral for the
44 purposes of the SAMA evaluation. Since each of the three changes either reduces or maintains
45 (i.e., does not increase) plant risk, Energy Northwest concluded that implementation of these
46 changes either reduces or maintains (i.e., does not increase) the benefits calculated for the
47 evaluated SAMA candidates (Gambhir, 2010).

Appendix F

1 In response to this same RAI, Energy Northwest explained that the CGS internal events PSA
2 model had been updated to Revision 7.1 since the SAMA evaluation reported in the ER, which
3 resulted in a higher CDF and a lower LERF (Gambhir, 2010). Energy Northwest further
4 explained, in a followup response to the NRC staff RAIs, that the PSA Revision 7.1 model
5 incorporated the following:

- 6 • resolution of F&Os from the 2004 peer review
- 7 • resolution of areas of model incompleteness identified by CGS internal technical reviews
- 8 • upgrades to meet NRC RG 1.200 Revision 2 (NRC, 2009a) and the associated ASME
9 standard RA-S-2008 (ASME, 2008) for Level 1, LERF, and flooding modeling
- 10 • plant and procedure changes, such as the DG cross-connect discussed previously
11 (Gambhir, 2011)

12 These changes were first incorporated in the PSA Revision 7.0 model. A peer review of the
13 Revision 7.0 PSA model was performed on Level 1 and 2 internal events (with internal flooding)
14 in 2009, and a report was issued in January 2010. Energy Northwest explains that F&Os from
15 this peer review that could significantly impact the model quantification were incorporated into
16 the Revision 7.1 model, and a review of the remaining F&Os associated with SRs that were
17 graded as CC-I or "not met" identified none that would significantly impact the results of the
18 SAMA analysis (Gambhir, 2011). Energy Northwest performed a sensitivity study using the
19 Revision 7.1 PSA model (which integrates internal, fire, and seismic events) to assess the
20 impact of these modeling updates on the results of the SAMA evaluation. The results of this
21 sensitivity study are discussed throughout this appendix.

22 In another RAI, the NRC staff noted that several of the peer review and self-identified findings
23 that were characterized as not expected to significantly alter the SAMA results appear to
24 address potential non-conservatisms in the Level 1 and 2 PSA model. The staff asked Energy
25 Northwest to justify its conclusion that resolution of these issues will not impact the SAMA
26 analysis (Doyle, 2010a). In response to the RAI, Energy Northwest concurred that the list of
27 findings identified in the RAI address areas of non-conservatism and explained that each of
28 these findings has since been resolved in PSA Revision 7.1 (Gambhir, 2010). As discussed
29 previously, in response to this and other RAIs, Energy Northwest provided a sensitivity analysis
30 of the SAMA analysis results using PSA Revision 7.1.

31 The NRC staff asked Energy Northwest to describe the PSA quality control process used at
32 CGS (Doyle, 2010a). In response to the RAI, Energy Northwest explained that the process for
33 controlling the technical adequacy of the PSA is contained in a CGS engineering procedure that
34 is consistent with guidance in NRC RG 1.174 (NRC, 2002). This PSA configuration procedure
35 covers the following:

- 36 • monitoring PSA input and collecting new information for incorporation
- 37 • updating the PSA to be consistent with the as-built and as-operated plant
- 38 • assessing cumulative impact of pending PSA changes
- 39 • controlling computer codes supporting the PSA
- 40 • preparing documentation
- 41 • qualifying PSA reviewers

42 The CGS internal events PSA model has been peer-reviewed, the peer review findings were all
43 resolved and their impacts assessed in a sensitivity analysis using the updated PSA model.
44 Additionally, Energy Northwest satisfactorily addressed NRC staff questions regarding the PSA.

1 Based on this information, the NRC staff concludes that the internal events Level 1 PSA model
2 is of sufficient quality to support the SAMA evaluation.

3 As indicated above, the CGS PSA includes explicit fire and seismic event PSA models, in
4 addition to the internal events PSA model. Both the fire and seismic PSA models have been
5 significantly updated since the IPEEE. The updated fire and seismic CDF results are described
6 in the ER and are included in Tables F-6 and F-7.

7 The CGS IPEEE was submitted in June 1995 (Parrish, 1995) in response to Supplement 4 of
8 GL 88-20 (NRC, 1991a). This submittal included an internal fire PSA, a seismic PSA, and a
9 screening analysis for other external events. While no fundamental weaknesses or
10 vulnerabilities to severe accident risk in regard to the external events were identified, many
11 opportunities for risk reduction were identified as discussed below. In a letter dated February
12 26, 2001, the NRC staff concluded that the submittal met the intent of Supplement 4 to
13 GL 88-20, and the licensee's IPEEE process is capable of identifying the most likely severe
14 accidents and severe accident vulnerabilities (NRC, 2001).

15 The seismic portion of the IPEEE consisted of a seismic PSA completed in accordance with
16 NRC guidance for IPEEE submittals (NRC, 1991a) and the NRC PSA procedures guide
17 (NRC, 1983). Plant models were primarily based on the IPE (Parrish, 1994). Major inputs to
18 the seismic PSA were from the following:

- 19 • plant walkdowns in which components and structures were screened against the review
20 level earthquake of 0.5g conducted in accordance with the EPRI methodology for
21 Seismic Margins Assessment (EPRI, 1991)
- 22 • relay chatter evaluation conducted in accordance with NRC guidance for IPEEE
23 submittals
- 24 • seismic fragility evaluation conducted per the EPRI methodology for developing seismic
25 fragilities (EPRI, 1994)

26 A site-specific seismic hazard estimate was developed for CGS by Geomatrix and documented
27 in a hazard report (Geomatrix, 1994a) which is stored as a permanent record by Energy
28 Northwest. Key elements of the seismic PSA included a seismic hazard analysis, a seismic
29 fragility evaluation, system and accident sequence analysis, and evaluation of seismic CDF and
30 public risk.

31 The seismic CDF resulting from the CGS IPEEE was calculated to be 2.1×10^{-5} per year using a
32 site-specific seismic hazard curve. The CGS IPEEE did not identify any vulnerabilities due to
33 seismic events but did identify several improvements to the plant or procedures to reduce
34 seismic risk. These improvements have been either implemented at the site or addressed in the
35 SAMA evaluation process, and they are discussed in Section F.3.2.

36 Subsequent to the IPEEE, Energy Northwest upgraded the seismic PSA to be consistent with
37 the American Nuclear Society (ANS) standard for external events PSAs, ANSI/ANS-58.21-2003
38 (ANS, 2003), and with EPRI seismic PSA implementation guidance (EPRI, 2003). Major inputs
39 to the seismic events PSA include the following:

- 40 • a plant-specific hazard curve
- 41 • results and insights obtained from seismic plant walkdowns conducted in support of the
42 IPEEE (Parrish, 1995)

Appendix F

- 1 • plant-specific structural and component seismic fragility analyses
- 2 • relay chatter evaluation
- 3 • the Level 1 and 2 Revision 6.2 PSA models

4 These upgrades to the seismic PSA resulted in a seismic CDF of 5.2×10^{-6} per year, using a
5 site-specific seismic hazard curve, which was used for the SAMA evaluation. In response to
6 NRC staff RAIs, Energy Northwest reported the seismic CDF for PSA Revision 7.1 used in the
7 SAMA sensitivity analysis to be 4.9×10^{-6} per year (Gambhir, 2011). In the RAI responses,
8 Energy Northwest explained that the seismic PSA was not updated for the Revision 7.1 model
9 and that the decrease in seismic CDF from Revision 6.2 to Revision 7.1 is due to integration of
10 the seismic PSA model with the updated internal events model. Energy Northwest identified an
11 increase in seismic CDF, due to the suppression pool no longer being assumed to be available
12 as a source of makeup inventory for RCIC. This increase is more than offset by a decrease in
13 the seismic CDF due to a reduction in CCF probabilities for the DGs and refinement of the
14 likelihood of failure of high-pressure core spray (HPCS) injection given containment failure to
15 remove conservatism.

16 The NRC staff noted that the seismic CDF contribution was zero for two seismic damage states
17 (i.e., S2P2 and S20P2) reported in Table A-1 of the RAI responses (Gambhir, 2011). The staff
18 asked Energy Northwest to explain the reason for this since the seismic CDF was not zero for
19 the two seismic damage states using the CGS PSA Revision 6.2 model (Doyle, 2011). In
20 response to the followup RAI, Energy Northwest explained that S2P2 and S20P2 are seismic
21 SBO event trees with RCIC successful; however, the RCIC success criteria for PSA
22 Revision 7.1 requires the CST to be available but that the CST is assumed to fail in seismic
23 events (Swank, 2011). Therefore, all of the S2P2 and S20P2 cutsets transferred to the seismic
24 SBO event trees with RCIC unavailable (i.e., S2P3 and S20P3) (Swank, 2011).

25 The NRC staff asked Energy Northwest to address if seismic hazard analysis information,
26 developed later for the nearby U.S. Department of Energy (DOE) Hanford Site and by the U.S.
27 Geological Survey (USGS), could impact the results of the SAMA analysis (Doyle, 2010a). In
28 response to the RAI, Energy Northwest emphasizes that the 1994 seismic hazard analysis used
29 in the CGS IPEEE was specifically developed for the CGS site. The seismic hazard analyses
30 developed by Geomatrix Consultants for the DOE Hanford Site in 1994 (Geomatrix, 1994b), and
31 updated in 1996 (Geomatrix, 2006), developed site-specific seismic hazard curves for each
32 location evaluated on the Hanford Site (Gambhir, 2010). Energy Northwest also discussed the
33 results of a 2005 study that develops a site-specific seismic response model for the DOE
34 Hanford Site Waste Treatment Plant (WTP) that better characterizes the effect from deep layers
35 of sediments "interbedded" with basalt (PNNL, 2005). Energy Northwest explains that each of
36 these studies evaluates locations that are at least 10 mi distant from the CGS site, that the soil
37 structure at the CGS site is thicker than at the WTP site, and that the site-specific hazard curves
38 developed for the Hanford Site locations are, therefore, less applicable to the CGS site. Energy
39 Northwest notes that after years of study of the seismic hazard at WTP, it eventually concluded
40 (PNNL, 2007) that the hazard results obtained for WTP using the newest ground motion models
41 at the WTP were similar to the 1996 model results. Energy Northwest also notes that the
42 recently updated USGS assessment of seismic hazards in the U.S. offers an opportunity for an
43 independent verification of the seismic results developed for the CGS site by Geomatrix
44 consultants. In the RAI response, Energy Northwest compares the peak ground acceleration
45 (PGA) at times 500 and 2,500 years calculated using the 2008 USGS data (USGS, 2008) for
46 the coordinates corresponding to the CGS site, which are lower than the PGAs predicted by the
47 Geomatrix CGS model, as shown in Table F-9. Based on these results, Energy Northwest

1 concludes that the CGS seismic model is conservative relative to the latest USGS seismic
 2 hazard data in predicting an appropriate ground motion for the CGS site. Accordingly, Energy
 3 Northwest concludes that the 1994 seismic hazard study used in the CGS seismic PSA model
 4 used in the SAMA evaluation still provides an adequate seismic input to the PSA models to
 5 effectively identify relevant SAMA candidates (Gambhir, 2010).

6 **Table F-9. Comparison of USGS and Geomatrix data**

| Study | PGA for time = 500 years (10% in 50 years) | PGA for time = 2,500 years (2% in 50 years) |
|-----------------|---|--|
| USGS, 2008 | 0.072 g | 0.169 g |
| Geomatrix, 1994 | 0.081 g | 0.178 g |

7 The NRC staff noted that no reviews of the seismic PSA were identified in the ER and asked
 8 Energy Northwest to describe any such reviews and to assess the impact of any unresolved
 9 findings on the SAMA evaluation (Doyle, 2010a). In response to the RAI, Energy Northwest
 10 stated that no external peer reviews have been performed on the seismic PSA while one
 11 internal self-assessment has been performed (Gambhir, 2010). The self-assessment was
 12 performed on Revision 0 of the seismic PSA against the ANSI/ANS 58.21-2003 (ANS, 2003)
 13 standard, and it identified four SRs that were not met (excluding findings that were judged to be
 14 documentation only). The assessment also noted that no peer review had been performed.
 15 Two of the findings had to do with the adequacy of the ground motion study and soil-structure
 16 interaction analysis performed by Geomatrix consultants. Energy Northwest's assessment of
 17 these findings is that, based on the evaluation of the more recent seismic hazard analysis
 18 information discussed previously, these studies confirm that the CGS site seismic
 19 characterization is adequate. Two of the findings questioned the adequacy of existing seismic
 20 PSA sensitivity studies. Energy Northwest concluded that the impact of these findings on the
 21 SAMA evaluation is addressed by the 95th percentile seismic CDF uncertainty analysis
 22 discussed in Section F.6.2. Regarding the lack of a seismic PSA peer review, Energy
 23 Northwest noted that the impact on the SAMA evaluation of this finding cannot be determined
 24 but that future enhancements to the seismic PSA are planned to make it consistent with the
 25 seismic PSA standard (ASME, 2009).

26 The CGS internal events modeling is an input to the seismic PSA model, the seismic PSA has
 27 been updated to a more recent external events PSA standard, the SAMA evaluation included a
 28 sensitivity analysis of the seismic CDF, and Energy Northwest has satisfactorily addressed NRC
 29 staff RAIs regarding the seismic PSA. Based on this information, the NRC staff concludes that
 30 the seismic PSA model, in combination with the sensitivity analysis of the seismic CDF,
 31 provides an acceptable basis for identifying and evaluating the benefits of SAMAs.

32 The IPEEE fire analysis was performed with PSA technology but employed elements of EPRI's
 33 fire-induced vulnerability evaluation (FIVE) methodology (EPRI, 1992) for systemic screening
 34 and ignition source frequency determination. The IPEEE fire areas were based on definitions of
 35 Appendix R fire areas for CGS. A plant walkdown and verification process was employed to
 36 verify that all assumptions and calculations were supported by the physical condition of the
 37 plant. Fire areas were qualitatively screened if the area did not contain safety equipment,
 38 including cabling, or components and cables whose failure would result in a reactor scram. Of
 39 the 93 fire areas, 36 were qualitatively screened. Fire initiating event frequencies were
 40 estimated for each of the remaining 57 unscreened fire areas using the FIVE methodology. It
 41 was assumed that a fire would destroy all equipment and cables in a fire area and that a fire

Appendix F

1 would not propagate to more than one fire area. Computerized fire simulations were performed
2 with COMPBRN III (NRC, 1986) to determine fire growth and spread characteristics in critical
3 fire areas. The likelihood for fire suppression was determined based on the availability of
4 automatic fire suppression as well as the likelihood that fires from specific combustion sources
5 would not significantly affect the PSA-related components and cables located in the fire area.
6 Fire-initiating events in each fire area and fire-induced failures were combined with random
7 equipment failure modes using the internal events PSA to determine the fire CDF for each
8 unscreened fire area. A fire area was quantitatively screened from further analysis if the
9 fire-induced core damage was less than 1×10^{-6} per year. All but 16 fire areas were
10 quantitatively screened. The remaining 16 important fire areas were further evaluated for
11 consideration of crediting recovery actions or analysis refinements or both.

12 As reported in Table 1.4-2 of the IPEEE, the fire CDF for the 16 important fire areas is 9.2×10^{-6}
13 per year. A separate control room fire evaluation estimated the fire CDF for the control room to
14 be 8.4×10^{-6} per year. The total fire CDF resulting from the CGS IPEEE was calculated to be
15 1.8×10^{-5} per year. The CGS IPEEE did not identify any vulnerabilities due to fire events but did
16 identify several improvements to plant procedures to reduce fire risk. These improvements
17 have been either implemented at the site or addressed in the SAMA evaluation process, and
18 they are discussed in Section F.3.2.

19 Subsequent to the IPEEE, Energy Northwest created a fire PSA. Energy Northwest describes
20 the fire PSA model in the ER as being based on the internal events PSA model but developed
21 using elements of NUREG/CR-6850 (NRC, 2005). Energy Northwest explains that, in general,
22 the CGS fire PSA approach was to develop fire event trees for each fire area incorporating
23 extinguishment and propagation split fractions from the EPRI fire events database (EPRI, 1993),
24 automatic suppression when applicable, and likelihood of plant trip for different compartment
25 and loss scenarios. For screening fire event trees, the loss scenarios were simplified into loss
26 of the single worst equipment or cable (for example, as indicated by a calculated importance
27 measure) or loss of all equipment and cables in the compartment. Each compartment has a
28 fire-initiating event tree and two conditional fire event trees for single equipment or cable or
29 compartment losses. The conditional fire event trees are either turbine trip or loss of FW event
30 trees, as appropriate for the compartment losses. In performing the fire analysis, consideration
31 was given to all fire damage mechanisms, including smoke, loss of lighting and indication, and
32 fire suppression system impacts on equipment. The fire PSA explicitly examined the HEPs
33 used for the fire scenarios to ensure that equipment and indication losses, fire-induced stress,
34 communications difficulties, and potential impacts from smoke and heat were included.

35 The CGS IPEEE demonstrated that only a few fire compartments had the potential for fire
36 propagation from one compartment to another. Based on this finding, a detailed evaluation of
37 potential fire propagation between compartments has not been performed for the fire PSA.
38 However, a set of qualitative assessments was performed to confirm that such scenarios would
39 likely be insignificant contributors. For the fire-initiating event tree, split fractions were
40 developed for each group of fixed ignition sources that defined a scenario. The split fractions
41 are single basic events added to the fault tree. As with the screening event trees, early
42 extinguishment (i.e., de-energization, self-extinguishment, or manual suppression not by the fire
43 brigade) and automatic extinguishment were not credited. For transient fire ignition sources, the
44 locations that could impact overhead or nearby combustibles were determined. Hot gas layer
45 formation was considered qualitatively as either not credible (due to room size or ceiling height
46 above critical cable runs) or included in scenarios involving loss of all equipment and cables in
47 applicable compartments.

1 For each scenario, fire-induced equipment failures were determined, including hot short events
2 that could spuriously actuate components and result in undesired configurations. To identify the
3 potential hot shorts that should be included in the fire PSA, the internal events basic events
4 were reviewed. Those basic events that represented failure of a valve (or damper) to remain
5 open or closed, depending on which position was desirable, were considered susceptible to hot
6 shorts. Hot short failures (more than 120 locations) were identified and explicitly included in this
7 fire evaluation. The hot short impact included failure of minimum-flow valves in flow paths
8 needed for the emergency core cooling injection and valves and dampers needed for
9 containment isolation. Detailed analysis of the main control room was performed, and the
10 potential for control room evacuation was considered.

11 These upgrades to the fire PSA resulted in a fire CDF of 7.4×10^{-6} per year for CGS PSA
12 Revision 6.2, which was used for the baseline SAMA evaluation. In response to NRC staff
13 RAIs, Energy Northwest reported the fire CDF for PSA Revision 7.1 used in the SAMA
14 sensitivity analysis to be 1.4×10^{-5} per year (Gambhir, 2011). In the RAI responses, Energy
15 Northwest explained that the fire PSA was not updated for the Revision 7.1 model and that the
16 change in fire CDF from Revision 6.2 to Revision 7.1 is due to integration of the fire PSA model
17 with the updated internal events model. Energy Northwest identified that the predominant
18 reasons for the increase in fire CDF were as follows:

- 19 • The reactor coolant system is no longer assumed to be available as a backup source of
20 makeup inventory in the event RCIC fails.
- 21 • Reactor feedwater (RFW) is now assumed to fail if a full compartment burnout occurs.
- 22 • Some Division 2 equipment is conservatively assumed to fail due to a fire in the Division
23 1 electrical equipment room.
- 24 • One train of RHR is no longer assumed to be available and not failed for a fire in the
25 cable chase.
- 26 • Fire-induced loss of offsite power is no longer assumed to be recovered through repair
27 activities.

28 The NRC staff asked Energy Northwest to clarify the extent to which NUREG/CR-6850 was
29 used to update the fire PSA, to describe the conservatisms in the fire PSA, and to describe how
30 conservatisms in the fire PSA have been reduced since the IPEEE (Doyle, 2010a). In response
31 to the RAI, Energy Northwest clarified that the use of NUREG/CR-6850 was limited to only the
32 refinement of electrical hot short probabilities and that use of the EPRI fire events database
33 does not follow the NUREG/CR-6850 guidance (Gambhir, 2010). Energy Northwest further
34 explained that updates to the fire PSA since the IPEEE reduced conservatisms in the IPEEE
35 analysis by refining the cables selected that impact the fire PSA and by performing
36 plant-specific fire modeling, and no attempt was made to reduce conservatisms in the PSA
37 Revision 6.2 model when performing the SAMA evaluation. In response to a followup NRC staff
38 RAI asking Energy Northwest to describe the remaining conservatisms in the fire PSA
39 (Doyle, 2010c), Energy Northwest summarized the areas of conservatisms in the fire PSA as
40 the assumption that a fire would destroy all equipment and cables in some risk-significant fire
41 areas and in the assumed fire ignition frequencies that newer industry data indicate are lower
42 (Gambhir, 2011).

43 In a separate RAI, the NRC staff asked Energy Northwest to explain how potentially screening
44 out sequences in the simplified loss scenarios that might have contained risk significant hot
45 short events affects the results of the fire PSA and the SAMA evaluation since hot shorts were

Appendix F

1 only considered for unscreened sequences (Doyle, 2010a). Energy Northwest responded that
2 no sequences were screened out of the analysis but that the purpose of using screening fire
3 event trees was to determine those sequences that required further development before
4 quantification (Gambhir, 2010). After initial quantification, those fire compartments found to
5 have an initial CDF greater than 5.0×10^{-7} per year were analyzed in more detail to be more
6 realistic, which typically involved identifying additional scenarios for each compartment and
7 modeling each scenario with its own fire event tree. Those fire compartments having an initial
8 CDF less than 5.0×10^{-7} per year were not refined further, but the associated cutsets were
9 retained in the fire PSA.

10 As noted earlier, the fire PSA was included in the industry peer review conducted by ERIN
11 Engineering in 2004. Energy Northwest states in the ER that the review produced 33 findings,
12 that all Level A and B F&Os were addressed and resolved in the Revision 6.2 PSA model used
13 in the SAMA evaluation, and that the remaining unresolved findings are not expected to
14 significantly alter the results of the SAMA analysis. In response to an NRC staff RAI, Energy
15 Northwest clarified that, since the fire PSA standard was not available at the time of the review,
16 the peer review was performed on the fire PSA to the high level requirements identified in the
17 2003 ASME standard (Gambhir, 2010). Energy Northwest also identified one unresolved
18 finding that resulted in the grading of the high level requirement as not met. Energy Northwest's
19 assessment of this finding, which was that the fire PSA does not credit fire brigade response, is
20 that the PSA Revision 6.2 modeling is conservative relative to the SAMA evaluation.

21 In a separate RAI, the NRC staff noted that many of the unresolved findings identified in the ER
22 appear to be non-conservative and asked Energy Northwest to ensure that resolution of these
23 findings would not significantly alter the results of the SAMA analysis (Doyle, 2010a). Energy
24 Northwest responded that all significant findings from the 2004 peer review, with the exception
25 of the finding discussed above that would reduce model conservatism, have been resolved and
26 that the unresolved findings identified in the ER are from the 2008 self-assessment discussed
27 previously for internal events PSA (Gambhir, 2010). Energy Northwest also discussed each of
28 the areas of potential non-conservatism identified in the RAI and provided the basis for
29 concluding that resolution of these issues will not impact the results of the SAMA evaluation, as
30 follows:

- 31 • The electronic database used to select and locate cables does not include all conduit
32 locations. Energy Northwest judged that the 95th percentile CDF uncertainty analysis
33 discussed in Section F.6.2 is sufficient to account for this area of model incompleteness.
- 34 • The assumed hot short probability of 0.3 implicitly assumes all circuit failures are
35 intra-cable for multi-conductor cables protected by controlled power transformers.
36 Energy Northwest judged that the 95th percentile CDF uncertainty analysis discussed in
37 Section F.6.2 is sufficient to account for this modeling uncertainty.
- 38 • A transformer fire scenario must be re-evaluated for Division 2 switchgear room to
39 remove non-conservatism from current modeling. Energy Northwest stated that, based
40 on a re-evaluation of the transformer fire scenario for the Division 1 switchgear room,
41 which decreased the fire CDF, enhancements to the Division 2 fire PSA modeling are
42 not anticipated to significantly alter the results of the SAMA analysis.
- 43 • The fire PSA credits systems or trains that fire-related plant procedures instruct
44 operators to defeat. Energy Northwest stated that since operators have discretion to
45 continue using a system in service during a fire until the fire causes safe shutdown

1 parameter degradation or visible fire damage to vital plant equipment or cabling, the
2 current PSA modeling is compatible with this acceptable practice.

- 3 • The PSA modeling of hot shorts events corresponding to single spurious actuations
4 captures most but not all multiple spurious operations (MSOs). Energy Northwest
5 judged that the 95th percentile CDF uncertainty analysis discussed in Section F.6.2 is
6 sufficient to account for this area of model incompleteness.

7 Energy Northwest concluded that a future upgrade of the fire PSA will address these issues,
8 that the eventual net risk impact of these refinements cannot be estimated at this time, and that
9 any impacts are judged to be encompassed by the 95th percentile CDF uncertainty analysis
10 discussed in Section F.6.2.

11 In a followup RAI, the NRC staff asked Energy Northwest to describe any modeling
12 enhancements that have been made to compensate for the incompleteness in the cable location
13 database and in the modeling of MSOs (Doyle, 2010b). Energy Northwest responded by
14 re-emphasizing that conservatisms in the PSA include the use of hot short probabilities of 0.3
15 unless hot short durations were specifically evaluated and modeled, in lieu of potentially
16 non-conservative lower values, and that loss of all equipment and cables in the compartment
17 was assumed for lower risk fire compartments, in lieu of more realistic modeling of fire scenarios
18 (Gambhir, 2011). Relative to the MSO modeling incompleteness, Energy Northwest stated that
19 conservative treatment of hot short modeling was used in part to respond to this
20 incompleteness, that plant modifications are in progress to address MSOs in safe shutdown
21 circuits in response to Enforcement Guidance Memorandum 09-02 (NRC, 2009b), and that the
22 PSA will be updated once these modifications are implemented in the plant. Relative to the
23 cable database incompleteness, Energy Northwest stated that the cable and raceway database
24 has been updated and now identifies the cables in conduit that were not included in PSA
25 Revision 6.2. The update provided building and, in most cases, fire zone locations of the
26 conduits. Using this updated information, Energy Northwest performed a sensitivity analysis
27 using PSA Revision 7.1 that assumed that conduits whose location was known only at the fire
28 zone level were failed for all fire scenarios within that zone. The sensitivity analysis compared
29 the risk reduction worth (RRW) for six existing fire-related SAMA candidates, representative of
30 important systems and fire compartments at CGS, before and after the model changes were
31 made. The results show that for those SAMA candidates in which the RRW increased, the
32 increase was less than the uncertainty factor applied in the 95th percentile CDF uncertainty
33 analysis discussed in Section F.6.2. Energy Northwest concludes that this sensitivity analysis
34 result supports the conclusion that modeling incompleteness in the fire PSA does not impact the
35 SAMA results.

36 The NRC staff considers Energy Northwest's explanation and assessment of the areas of
37 incompleteness in the fire PSA reasonable and determines that, in light of the known
38 conservatisms in the PSA model, resolution of these incompleteness issues is not likely to
39 impact the results of the SAMA analysis.

40 In other followup RAIs, the NRC staff noted that NUREG/CR-6850 guidance indicates that hot
41 short probabilities may be double the 0.3 value (i.e., 0.6) for circuits not protected by control
42 power transformers. The staff asked Energy Northwest to provide the basis for the 0.3 hot short
43 probability assumption and the basis for the conclusion that the 95th percentile CDF uncertainty
44 analysis discussed in Section F.6.2 accounts for this modeling uncertainty (Doyle, 2010c),
45 (Doyle, 2011). In response to the RAIs, Energy Northwest provided the results of a sensitivity
46 analysis of selected SAMA candidates that were re-evaluated using a hot short probability of 0.6

Appendix F

1 for circuits that were not confirmed to have a control power transformer present. The results of
2 the sensitivity analysis are discussed in Section F.4.

3 The CGS internal events modeling is an input to the fire PSA model, the fire PSA has been
4 updated to incorporate industry fire data and NRC guidance, the fire PSA model has been peer
5 reviewed and the peer review findings were all addressed, and Energy Northwest has
6 satisfactorily addressed NRC staff RAIs regarding the fire PSA. Based on this information, the
7 NRC staff concludes that the fire PSA model provides an acceptable basis for identifying and
8 evaluating the benefits of SAMAs.

9 The Energy Northwest IPEEE analysis of high winds, tornadoes, external floods, and other
10 external events (HFO) followed the screening and evaluation approaches specified in
11 Supplement 4 to GL 88-20 (NRC, 1991a) and in associated guidance in NUREG-1307 (1991b).
12 For high winds, external floods, volcanic activity, and accidents at nearby facilities, the IPEEE
13 concluded that Energy Northwest meets the 1975 Standard Review Plan criteria (NRC, 1975)
14 and, therefore, the contribution from these hazards to CDF is less than the 1.0×10^{-6} per year
15 criterion (EN, 1995). Although the CGS IPEEE did not identify any vulnerabilities due to HFO
16 events, one improvement to reduce risk was identified. This improvement has been
17 implemented, as further discussed in Section F.3.2.

18 In the SAMA analysis submitted in the ER, the benefit from HFO events was assumed to be
19 equivalent to the benefit that was derived from the internal events model. In response to an
20 NRC staff RAI, Energy Northwest explained that the bases for this assumption are as follows:

- 21 • Some of the HFO events are captured in the LOOP contributor.
- 22 • The IPEEE analysis found that all of the HFO events contributed less than 1.0×10^{-6} per
23 year to the CDF.
- 24 • The internal events CDF for is more than a factor of four greater than the HFO screening
25 CDF of 1.0×10^{-6} per year.

26 Based on the low contribution to CDF from HFO events, and the internal events CDF of 4.8×10^{-6}
27 per year for CGS PSA Revision 6.2, the NRC staff agrees that assuming the benefits from HFO
28 events is equivalent to the benefits from internal events is reasonable and conservative
29 (Gambhir, 2011). This same assumption, albeit at the higher internal events CDF of 7.4×10^{-6}
30 per year, was also used for CGS PSA Revision 7.1 in the sensitivity analysis.

31 The NRC staff reviewed the general process used by Energy Northwest to translate the results
32 of the Level 1 PSA into containment releases, as well as the results of the Level 2 analysis, as
33 described in the ER and in response to NRC staff RAIs (Gambhir, 2010), (Gambhir, 2011). The
34 CGS PSA Revision 6.2 Level 2 model used in the baseline analysis is completely revised from
35 the model used in the IPE, including being updated as a result of the peer reviews performed in
36 1997 and 2004, and it reflects the CGS plant as designed and operated in 2006. The Level 2
37 model was further updated to support the CGS PSA Revision 7.1 model used in the sensitivity
38 analysis.

39 The Level 2 analysis is linked to the Level 1 model by assigning each Level 1 core damage
40 sequence to a PDS. Sequences are assigned to one of 21 PDSs based on the functional
41 characteristics of the sequence (e.g., necessary systems are recoverable or not recoverable)
42 and the status of systems that were important to containment performance (e.g., necessary
43 systems are available or not available). Each PDS is described in Table E.4-1 of Appendix E of
44 the ER (EN, 2010).

1 A CET was developed for each PDS, and quantification of the CETs was facilitated by fault tree
2 analysis and use of split fractions. In response to a NRC staff RAI, Energy Northwest explains
3 that PDSs were organized by accident type (e.g., loss of containment heat removal, loss of
4 coolant injection, and ATWS), initiator type, systems available to mitigate the accident, and
5 power and system recoverability and that the CETs contain both phenomenological and system
6 failure events (Gambhir, 2010). The CETs are constructed with events in the order that they
7 were expected to occur with the exception that events on which other events are dependent
8 were generally placed at the beginning of the CET. Energy Northwest lists fault tree modeled
9 branch points as including the following:

- 10 • containment intact after vessel failure
- 11 • high-pressure injection
- 12 • LPCI and LPCS recovered before containment failure
- 13 • debris cooled after vessel failure
- 14 • RHR recovered
- 15 • containment vent recovered
- 16 • power conversion system recovered for containment heat sink
- 17 • reactor vessel depressurized prior to containment failure

18 Energy Northwest further lists phenomenological branch points as including the following:

- 19 • containment isolated at time of core damage
- 20 • power recovered prior to vessel failure (based on timing)
- 21 • power recovered between vessel failure and containment failure (based on timing)
- 22 • shell failure due to high pressure melt ejection
- 23 • large containment failure mode
- 24 • failure in drywell

25 Containment failure modes identified were in-vessel steam explosion, vessel blow-down,
26 ex-vessel steam explosion, direct heating, and hydrogen explosion.

27 Each PDS is analyzed through the Level 2 CETs to evaluate the phenomenological progression
28 of the sequence. In the baseline analysis, five release categories were defined based on
29 characteristics that determine the timing (i.e., early and late, for time of initial release
30 less/greater than four hours after general emergency declaration) and magnitude (i.e., large,
31 small, and none, for Cesium Iodide (CsI) inventory release greater than 0.1 percent, less than
32 one percent, and no release) of the release. They were also defined based on whether the
33 fission products were or were not scrubbed prior to release. One release category, large early
34 scrubbed release, was not used; however, Energy Northwest carried this release category in the
35 analysis because its consequences offer insight into the sensitivities of the site-specific data.
36 The CET end states are assigned to one of the five release categories. The frequency of each
37 release category was obtained by summing the frequency of the individual accident progression
38 CET endpoints binned into the release category. The release category frequencies are
39 provided in ER Appendix E Tables E.4-3, E.4-5, and E.4-6 for internal, fire, and seismic events,
40 respectively (EN, 2010).

41 Source term release fractions were developed for each of the five release categories based on
42 the results of plant-specific calculations using the MAAP Version 4.0.4 (Gambhir, 2010). A
43 single MAAP case was chosen to represent each of the five release categories based primarily
44 on three criteria:

Appendix F

- 1 • It represents a CGS accident class that would be expected to be included in the release
2 category.
- 3 • It represents the appropriate timing characteristic of the release category.
- 4 • The Csl release fraction is representative of the release category.

5 In response to an NRC staff RAI, Energy Northwest stated that, for release categories in which
6 multiple MAAP cases were available to select from, the representative MAAP case was selected
7 to include reasonable conservatism based on qualitative weighting factors such as the timing
8 and magnitude of the initial and total releases (Gambhir, 2010). The RAI response describes
9 the specific logic used in the selection of the representative MAAP case for each release
10 category. The resulting release characteristics for each release category are provided in
11 Table E.6-6 of Appendix E to the ER (EN, 2010).

12 The NRC staff noted that approximately 88 percent of the fire release frequency is associated
13 with “late” releases. It asked Energy Northwest to explain the phenomenology that causes this
14 “late” contribution to be much higher than the “late” contribution for internal events, which is
15 approximately 47 percent, and to explain why LERF is less for fire events than for internal
16 events (Doyle, 2010a). In response to the RAI, Energy Northwest provided two tables that
17 compare the internal events and fire events CDF and LERF for each PDS. Energy Northwest
18 also explained that the higher “late” contribution from fires is because the Level 1 fire PSA has a
19 significantly higher contribution from long term loss of DHR scenarios (non-LERF contributors)
20 than the Level 1 internal events PSA results (Gambhir, 2010). The higher contribution to loss of
21 DHR scenarios is due to fire-initiating events that may fail or impact use of the main condenser
22 and containment venting for heat removal and fire-initiating events that may fail a single division
23 of suppression pool cooling. Energy Northwest further clarified that fire-induced LERF is less
24 than internal event LERF primarily because the CDF contribution from SBO sequences with
25 early failure of HPCS and RCIC is less for fire events than for internal events. Additionally, the
26 fire PSA does not include failure scenarios that contribute to LERF that are included in the
27 internal events PSA. For example, there are no fire-induced flooding scenarios, no fire-induced
28 ATWS events, and no fire-induced containment bypass events.

29 In a followup RAI, the NRC staff noted that fire events, but not internal events, contribute to PDS
30 2C, transient with stuck-open SRV, or LOCA with loss of containment heat removal and
31 containment failure occurs prior to core damage with the reactor vessel at low pressure.
32 However, internal events, but not fire events, contribute to PDS 2D, transient with loss of
33 containment heat removal, and containment fails prior to core damage with reactor vessel at
34 high pressure. The staff asked Energy Northwest to clarify this discrepancy and to explain why
35 there are no fire-induced containment bypass events (Doyle, 2010c). In response to the RAI,
36 Energy Northwest clarified that the reference to PDS 2C was an error and that the CDF and
37 LERF values reported for PDS 2C should have been reported for PDS 2D. Energy Northwest
38 provided revised tables comparing the internal events and fire events CDF and LERF for each
39 PDS (Gambhir, 2011). Energy Northwest further clarified that fire-induced containment bypass
40 events are addressed in the fire PSA but that PDS 5, LOCA outside containment with failure to
41 isolate the break, is not used in the fire PSA. Rather, Energy Northwest assumes that the
42 dominant impact of a fire to containment isolation is for a fire to cause a major containment
43 isolation pathway to not close or to inadvertently open, and so the fire Level 2 CETs contain a
44 first branch node that asks if the containment is isolated. The split fraction used for this branch
45 node is consistent with that used for the internal events node for loss of containment. The
46 LERF for fire-induced loss of containment isolation is, therefore, reflected in several PDSs,
47 which generally contribute to the LEN release category. Energy Northwest also explained that

1 the likelihood of a fire-induced ISLOCA at CGS is significantly less than that for failure of
2 containment isolation. This is based on the highest potential ISLOCA pathway from the
3 containment at CGS being the RHR shutdown cooling line that contains two motor-operated
4 valves in series. Since one of these motor-operated valves is maintained in the closed position
5 during normal plant operation with power removed from the motor via a protected isolation
6 switch, a spurious signal from a hot short cannot cause the valve motor to energize.
7 Furthermore, the isolated, de-energized power feeder is routed in a grounded steel conduit to
8 protect it against external three-phase hot shorts. A fire-induced three-phase hot short
9 impacting the power feeder is significantly less than the probability for failure of containment
10 isolation assumed in the fire PSA (Gambhir, 2011).

11 As discussed previously for the Level 1 PSA, the Level 2 model was included in the
12 1997 BWROG and 2004 ERIN Engineering peer reviews. Energy Northwest stated that all
13 comments produced by the BWROG review were resolved. Of the 11 unresolved Level B F&Os
14 identified in the 2004 ERIN Engineering peer review in response to an NRC staff RAI, 9 of the
15 F&Os had to do with the Level 2 (LERF) analysis (Gambhir, 2010). As discussed previously,
16 Energy Northwest determined that resolution of these F&Os will not impact the SAMA analysis.
17 Furthermore, Energy Northwest stated that all of the identified Level B F&Os have been
18 resolved in the PSA Revision 7.1 model used for the SAMA sensitivity analysis.

19 In the PSA Revision 7.1 sensitivity analysis, 13 release categories were defined based on
20 characteristics that determine the timing (i.e., early, intermediate, and late, for time of initial
21 release less than 3 hours, between 3 and 24 hours, and greater than 24 hours after general
22 emergency declaration, respectively) and magnitude (i.e., high, medium, low, low-low, and
23 none, for Csl inventory release greater than 10 percent, between 1 and 10 percent, between 0.1
24 and 1 percent, less than 0.1 percent, and no release, respectively) of release. The “late” time
25 category was not used, leaving nine release categories to which CET end-states were assigned
26 (Swank, 2011). The definition for the “early” time category was changed from “less than 4
27 hours” assumed in the baseline analysis to “less than 3 hours” based on the latest CGS
28 emergency action levels for declaring a general emergency and the latest evacuation time
29 estimates. The CET end-states are assigned to one of the nine release categories. The
30 frequency of each release category was obtained by summing the frequency of the individual
31 accident progression CET endpoints binned into the release category. The characteristics of
32 each release category are provided in Table 2-4 of the RAI responses, while the release
33 category frequencies are provided in Tables A-3, A-4, and A-5 of the RAI responses for internal,
34 fire, and seismic events, respectively (Gambhir, 2011).

35 Source-term release fractions were also developed for each of the nine release categories
36 based on the results of plant-specific calculations using MAAP Version 4.0.4 (Gambhir, 2011).
37 In response to an NRC staff RAI, Energy Northwest stated the CGS plant-specific MAAP
38 calculations were revised to represent the current CGS configuration, and additional MAAP
39 calculations were performed to support the development of CGS PSA Revision 7.1
40 (Gambhir, 2011). Energy Northwest also stated that the representative MAAP cases selected
41 for the nine release categories are updated from those used in the baseline analysis, and a
42 quantitative weighting evaluation was performed based on the dominant cutset contributors to,
43 and the associated MAAP cases available for, each release category. Energy Northwest’s RAI
44 response provides an example of how the quantitative weighting evaluation was performed for
45 the H/E category and the logic for selecting the representative MAAP case for this release
46 category. The resulting release characteristics are presented in Table 2.4 of the RAI response
47 (Gambhir, 2011).

Appendix F

1 The NRC staff noted that the total release frequency determined from the individual release
2 category frequencies provided in Tables A-3, A-4, and A-5 of the RAI responses
3 (Gambhir, 2011) for internal, fire, and seismic events, respectively, are different than the
4 corresponding CDFs reported in Table A-1 of the RAI responses. The staff asked Energy
5 Northwest to clarify the reason for these differences (Doyle, 2011). In response to the RAI,
6 Energy Northwest explained that the CDF contribution from the “Containment Intact” (COK)
7 release category was incorrect in these table and provided revised Tables A-3, A-4, and A-5
8 that corrected the errors (Swank, 2011). Energy Northwest also explained that the total release
9 frequency for internal events from revised Table A-3 (i.e., $7.50E-5$ per year) is slightly different
10 from the internal events CDF of $7.4E-05$ per year reported in Table F-1. This is because the
11 CDF is determined from the sum of the minimal cutsets while the release frequency is
12 determined from the sum of the release category frequencies.

13 As discussed previously for the PSA Revision 7.1 Level 1 PSA, the Level 2 model was included
14 in the 2009 peer review of PSA Revision 7.0. Energy Northwest stated that F&Os from this peer
15 review that could significantly impact the model quantification were incorporated into the
16 Revision 7.1 model and concluded that resolution of the remaining unresolved F&Os from this
17 review would not impact the SAMA analysis. Energy Northwest performed a sensitivity study
18 using the Revision 7.1 PSA model (which integrates internal, fire, and seismic events) to assess
19 the impact of these modeling updates on the results of the SAMA evaluation. The results of this
20 sensitivity study are discussed throughout this appendix.

21 Based on the NRC staff’s review of the Level 2 methodology, that Energy Northwest has
22 adequately addressed NRC staff RAIs, that the Level 2 PSA model was reviewed in more detail
23 as part of the 1997 BWR owners group peer review and a 2004 peer review, and that the
24 findings from these peer reviews have been resolved and their impact assessed in a sensitivity
25 analysis using the updated PSA model, the NRC staff concludes that the Level 2 PSA provides
26 an acceptable basis for evaluating the benefits associated with various SAMAs.

27 As indicated in the ER, the reactor core radionuclide inventory used in the consequence
28 analysis was based on the licensed thermal power of 3,486 MWt, the maximum rated power
29 level limit for CGS for the extended period of operations.

30 The NRC staff reviewed the process used by Energy Northwest to extend the containment
31 performance (Level 2) portion of the PSA to an assessment of offsite consequences (essentially
32 a Level 3 PSA). This included consideration of the source terms used to characterize fission
33 product releases for the applicable containment release categories and the major input
34 assumptions used in the offsite consequence analyses. The MACCS2 code was used to
35 estimate offsite consequences. Plant-specific input to the code includes the source terms for
36 each release category and the reactor core radionuclide inventory (both discussed above),
37 site-specific meteorological data, projected population distribution within an 80-km (50-mile)
38 radius for the year 2045, emergency evacuation modeling, and economic data. This information
39 is provided in Section E.6 of Attachment E to the ER (EN, 2010) and in response to NRC staff
40 RAIs (Gambhir, 2010).

41 Releases were modeled as occurring at 13 meters (m) above ground level. The thermal content
42 of each of the releases is assumed to be buoyant plume rise, except for intact containment
43 which used an ambient release. Wake affects for the 70-m (246-ft) high and 45-m (148-ft)
44 roughly square containment building were included in the model. Sensitivity analyses were
45 performed for the elevation and release duration. Increasing the release height from 13–44 m
46 for the large early and large late scrubbed releases increased the population dose risk and

1 offsite economic cost risk by less than 1 percent. Increasing the release duration to a maximum
2 value of 24 hr (86,400 seconds) decreased the population dose risk by less than 1 percent and
3 increased the offsite economic cost risk by less than 1 percent. Based on the information
4 provided, the NRC staff concludes that the release parameters used are acceptable for the
5 purposes of the SAMA evaluation.

6 Energy Northwest used site-specific meteorological data for the 2006 calendar year as input to
7 the MACCS2 code. The development of the meteorological data is discussed in Section E.6.3
8 of Attachment E to the ER. The data were collected from the onsite meteorological tower
9 located approximately 2,500 feet (ft) west of the reactor building. Data from 2003–2006 were
10 considered, but the 2006 data were chosen because it was found to have the most complete set
11 of data. A sensitivity analysis was performed using the year 2003 meteorological data. The
12 results showed an increase in the population dose risk and offsite economic cost risk of less
13 than 6.1 and 6.6 percent, respectively. In response to an NRC staff RAI, Energy Northwest
14 explained that missing data were filled in depending on the span of unusable data
15 (Gambhir, 2010). If the data gap was less than 10 hours, then the average value of the data on
16 either side was used (for all data points). If the data gap was greater than 10 hours, then data
17 from the previous and subsequent hours were used (one-half filled from the previous data and
18 one-half filled from the subsequent data). The base case analysis assumed no perpetual
19 rainfall in the last spatial segment of the model (40–50 mi). A sensitivity analysis performed
20 using the maximum hourly rainfall from year 2006, 0.14 in. in one hour, showed that neither
21 population dose risk nor offsite economic cost risk was affected. A second sensitivity case was
22 performed using watershed indices of one (maximum runoff). The results showed no impact on
23 the consequence metrics. The NRC staff notes that previous SAMA analysis results have
24 shown little sensitivity to year-to-year differences in meteorological data and concludes that the
25 approach taken for collecting and applying the meteorological data in the SAMA analysis is
26 reasonable.

27 The population distribution the licensee used as input to the MACCS2 analysis was estimated
28 for the year 2045 using year 2000 U.S. Census Bureau data, as presented in the CGS final
29 safety analysis report (FSAR), and the expected annual population growth rate. This bounds
30 the license renewal extension to year 2043. The population distribution was determined for
31 each of 16 directions and each of 10 concentric rings based on the year 2000 census block
32 data. The population estimate for the year 2045 was projected using a growth rate calculated
33 based on county population projections (WOFM, 2007) and the 2000 U.S. Census Bureau data
34 (USCB, 2000a). The NRC staff noted that the population projections provided in Tables E.6-2
35 and E.6-3 of Appendix E of the ER are inconsistent and asked Energy Northwest to explain the
36 reason for the differences between the two tables (Doyle, 2010a). In response to the RAI,
37 Energy Northwest explained that Table E.6-2 is a population estimate based on Table 2.1-1 of
38 the CGS FSAR, which shows a decreasing trend in population growth rate. Additionally, the
39 population estimate in Table E.6-3, which was used for the SAMA evaluation, assumes a
40 14.2 percent per decade growth rate based on the State-wide Washington State census data
41 (Gambhir, 2010). Energy Northwest further explained that Table E.6-2 was included in the ER
42 to demonstrate the conservatism of the population projection in Table E.6-3, and the
43 14.2 percent per decade rate was used to estimate population growth for all sectors for
44 Table E.6-3. Transient population was included within the 10-mi emergency planning zone
45 (EPZ) of CGS. Sensitivity analyses were performed using the estimated year 2060 population
46 assuming 14.2 percent per decade and 20 percent per decade population growth rates. This
47 resulted in an increase in the population dose risk and offsite economic cost risk of
48 approximately 19 percent and 15 percent, respectively, for the 14.2 percent per decade case
49 and an increase of approximately 57 percent and 46 percent, respectively, for the 20 percent

Appendix F

1 per decade case. A sensitivity analysis was also performed assuming an increase of 16
2 persons in the base 0–1 mi EPZ zone population. This resulted in no change in the population
3 dose risk and less than 1 percent increase in the offsite economic cost risk. The NRC staff
4 considers the methods and assumptions for estimating population reasonable and acceptable
5 for purposes of the SAMA evaluation.

6 Emergency evacuation was modeled as a single evacuation zone extending out 16 km (10 mi)
7 from the plant. Energy Northwest assumed that 95 percent of the population would evacuate.
8 This assumption is conservative relative to the NUREG-1150 study (NRC, 1990a), which
9 assumed evacuation of 99.5 percent of the population within the EPZ. The evacuated
10 population was assumed to move at an average speed of approximately 2.4 meters per second
11 (m/s) (5.4 mi per hour (mph)) with a delayed start time of 50 minutes after declaration of a
12 general emergency. In response to an NRC staff RAI, Energy Northwest performed a sensitivity
13 study assuming a 15 minute notification delay and an evacuation delay time of 60 minutes
14 (Gambhir, 2010). The results showed no impact on the population dose risk or offsite economic
15 cost risk. Two additional sensitivity analyses were performed in which the evacuation speed
16 was decreased to 2.1 m/s (4.7 mph) and reduced by a factor of 2 to 1.2 m/s (2.7 mph). The
17 results showed no change in the population dose risk or offsite economic cost risk. This was
18 attributed to the low EPZ population. The NRC staff concludes that the evacuation assumptions
19 and analysis are reasonable and acceptable for the purposes of the SAMA evaluation.

20 Site-specific economic data were provided from the 2002 Census of Agriculture (USDA, 2004a),
21 (USDA, 2004b) for each of the five counties surrounding the plant to a distance of 50 mi. These
22 included the fraction of land devoted to farming, annual farm sales, fraction of farm sales
23 resulting from dairy production, value of farm and non-farm land, and information on regional
24 crops. In addition, generic economic data that apply to the region as a whole were taken from
25 the MACCS2 sample problem input. The daily cost of compensating people for evacuating and
26 relocating was developed from cost data for Washington and Oregon (Oregon, 2002),
27 (USCB, 2000a), (USCB, 2000b), (USGSA, 2008), (Washington, 2002). In response to an NRC
28 staff RAI, Energy Northwest clarified that no escalation was applied to the MACCS2 sample
29 problem input, and a sensitivity study was performed using an escalation factor of 4.1 percent
30 from 1993–2008 (Gambhir, 2010). Applying this escalation factor to the MACCS2 economic
31 data resulted in less than a 1 percent increase in the total benefit for each SAMA analysis case.
32 The NRC staff noted that the default MACCS2 growing season was assumed and asked Energy
33 Northwest to assess the impact of this assumption on the SAMA evaluation (Doyle, 2010a). In
34 response to the RAI, Energy Northwest confirmed that the growing season within the EPZ is
35 longer than the assumed default growing season and performed a sensitivity analysis assuming
36 a longer regional growing season of 302 days (Gambhir, 2010). The results showed no change
37 in population dose risk or offsite economic cost risk. The ER provides the results of a sensitivity
38 analysis of the sheltering shielding factors assumed in the MACCS2 analyses. For this
39 analysis, the sheltering shielding factors were changed from the MACCS2 default assumptions
40 to the minimum values suggested by NUREG/CR-4551 (NRC, 1990b). The results showed no
41 change in the population dose risk and offsite economic cost risk.

42 The NRC staff concludes that the methodology used by Energy Northwest to estimate the offsite
43 consequences for CGS provides an acceptable basis from which to proceed with an
44 assessment of risk reduction potential for candidate SAMAs. Accordingly, the NRC staff based
45 its assessment of offsite risk on the CDF and offsite doses reported by Energy Northwest.

1 **F.3 Potential Plant Improvements**

2 The process for identifying potential plant improvements, an evaluation of that process, and the
3 improvements evaluated in detail by CGS are discussed in this section.

4 **F.3.1 Process for Identifying Potential Plant Improvements**

5 Energy Northwest's process for identifying potential plant improvements (SAMAs) consisted of
6 the following elements:

- 7 • review of the dominant cutsets and most significant plant systems from the current,
8 plant-specific Level 1 internal events PSA
- 9 • review of the most significant IEs and sequences from the current, plant-specific Level 2
10 internal events PSA contributing to each release category
- 11 • review of potential plant improvements and PSA insights identified in the CGS IPE and
12 IPEEE
- 13 • review of SAMA candidates identified for LRAs for selected BWR plants
- 14 • review of other industry documentation discussing potential plant improvements

15 Based on this process, an initial set of 150 candidate SAMAs, referred to as Phase I SAMAs,
16 was identified. Subsequently, after further review of the IPEEE, one of these SAMA candidates
17 was further divided into two SAMA candidates, resulting in a total of 151 Phase I SAMAs. In
18 Phase I of the evaluation, Energy Northwest performed a qualitative screening of the initial list of
19 SAMAs and eliminated SAMAs from further consideration using the following criteria:

- 20 • The SAMA is not applicable to CGS due to design differences or it has already been
21 implemented at CGS (66 SAMAs screened).
- 22 • The SAMA was determined to provide very little benefit (36 SAMAs screened).
- 23 • The SAMA is similar to another SAMA under consideration and was subsumed into the
24 similar SAMA (7 SAMAs screened).
- 25 • The SAMA has estimated implementation costs that would exceed the dollar value
26 associated with eliminating all severe accident risk at CGS (15 SAMAs screened).

27 Based on this screening, 123 SAMAs were eliminated, leaving 28 for further evaluation. The
28 remaining SAMAs, referred to as Phase II SAMAs, are listed in Table E.11-7 of Attachment E to
29 the ER (EN, 2010). In Phase II, a detailed evaluation was performed for each of the
30 28 remaining SAMA candidates, as discussed in Sections F.4 and F.6 below.

31 As previously discussed in Section F.2.2, the risk reduction benefits associated with internal,
32 fire, and seismic events were separately estimated by Energy Northwest using the internal
33 events, fire events, and seismic events PSA models, respectively. Energy Northwest accounted
34 for the potential risk reduction benefits associated with HFO events by assuming that the
35 contribution from HFO events was the same as that from internal events. The estimated SAMA
36 benefits for internal events, fire events, seismic events, and HFO events were then summed to
37 provide an overall benefit.

1 **F.3.2 Review of CGS's Process**

2 Energy Northwest's efforts to identify potential SAMAs focused primarily on areas associated
3 with internal IEs but also included explicit consideration of potential SAMAs for fire and seismic
4 events. The initial list of SAMAs generally addressed the accident sequences considered to be
5 important to CDF from functional, initiating event, and RRW perspectives at CGS.

6 Energy Northwest's SAMA identification process began with a review of the list of potential
7 BWR enhancements in Table 13 of NEI 05-01 (NEI, 2005). Review of this generic SAMA list
8 resulted in 144 SAMAs being identified. The one SAMA from the generic SAMA list not
9 included as a CGS SAMA was for an ice condenser plant, which is not applicable to CGS.

10 For the Level 1 internal events PSA, Energy Northwest provided tabular listings of the top 100
11 cutsets sorted according to their contribution to CDF, representing over 56 percent of the Level
12 1 CDF, and the CGS plant systems having an RRW of 1.0 or greater, sorted according to their
13 RRW (EN, 2010). From the cutsets, Energy Northwest identified the significant contributors and
14 the SAMA candidates that address each of these contributors. Energy Northwest also identified
15 SAMA candidates addressing the CGS systems having the highest RRW values. In response
16 to an NRC staff RAI, Energy Northwest stated that one SAMA candidate, SAMA AC/DC-29,
17 "replace EDG-3 with a diesel diverse from EDG-1 and EDG-2," was identified as a result of a
18 review of the top 100 cutsets (Gambhir, 2010).

19 The NRC staff noted that the list of top 100 cutsets from the Level 1 PSA identified many
20 operator errors and non-recovery actions and asked Energy Northwest to explain why no
21 plant-specific SAMAs, such as procedure improvements, were identified to address these
22 human failure events (Doyle, 2010a). In response to the RAI, Energy Northwest explained that
23 significant HRA model improvements and procedure enhancements were made to the PSA to
24 incorporate F&Os from the 2004 PSA peer review. Additionally, a review of the important HEPs
25 determined that the Phase I SAMAs identified from the generic industry SAMA list addressed
26 these important human errors, most of which were already implemented at CGS
27 (Gambhir, 2010). Energy Northwest also noted that considerable emphasis has been placed on
28 improving procedures in order to improve operator response at CGS and that its review of CGS
29 procedures did not identify additional inherent weaknesses that could be removed by
30 enhancements to improve operator actions. To support this assessment, Energy Northwest
31 provided a list of important HEPs that have had either risk modeling improvements or
32 procedural enhancements and showed that, in PSA model Revision 7.1, the risk of the most
33 risk-important operator errors based on RRW have significantly decreased. While no new
34 SAMAs were identified to address specific risk-important HEP basic events, Energy Northwest
35 noted that new SAMA OT-07R, "increase operator training on systems and operator actions
36 determined to be important from the PSA," was identified in a separate NRC staff RAI (see
37 below) to assess if a general training and procedural update associated with time critical and
38 high risk important operator actions would be cost-beneficial. Energy Northwest provided a
39 Phase II evaluation of this SAMA using PSA model Revision 7.1, the results of which are
40 provided in Table F-11 and further discussed in Section F.6.2 (Gambhir, 2011).

41 For the Level 2 PSA model, Energy Northwest identified the major contributors to each of the
42 dominant release categories, representing approximately 100 percent of the population
43 dose-risk (EN, 2010). Energy Northwest also identified the SAMA candidates that address the
44 major contributors to release category LEN. The NRC staff asked Energy Northwest to review
45 each of the major contributors to each of the dominant release categories and identify the
46 SAMA candidates that address each of the contributors (Doyle, 2010a). Energy Northwest

1 responded to the RAI by identifying the SAMA candidates that address the major contributors to
 2 release categories LLN and LLS (Gambhir, 2010). No new SAMA candidates were identified
 3 from this review.

4 The NRC staff noted that, although the ER discusses a Level 1 basic events importance
 5 analysis and presents high level insights, it does not provide a basic events importance listing or
 6 discuss a Level 2 importance analysis. As a result, the staff asked Energy Northwest to provide
 7 Level 1 and 2 importance lists and assess each important basic event for potential SAMAs
 8 (Doyle, 2010a). Energy Northwest responded by providing tabular listings of the PSA model
 9 Revision 7.1 Level 1 and LERF internal events basic events sorted according to their RRW
 10 (Gambhir, 2011). SAMAs impacting these basic events would have the greatest potential for
 11 reducing risk. Energy Northwest used an RRW cutoff of 1.025, which corresponds to about a
 12 2.5 percent change in internal events CDF given 100-percent reliability of the equipment or
 13 human actions affected by the SAMA. This equates to an internal events benefit of
 14 approximately \$12,000, the minimum cost of a procedure change at CGS (Gambhir, 2011).
 15 Energy Northwest correlated the CDF and LERF events with the SAMAs identified in the ER
 16 and in response to other NRC staff RAIs, and it showed that, with some exceptions, all of the
 17 significant basic events are addressed by one or more SAMAs. The additional SAMAs
 18 identified from this review are as follows:

- 19 • SAMA AT-15R, “install modifications to make use of high pressure core spray (HPCS)
 20 more likely for ATWS”
- 21 • SAMA FL-07R, “protect the HPCS from flooding resulting from ISLOCA events”
- 22 • SAMA OT-09R, “for the non-LOCA initiating events, credit the Z (Power Conversion
 23 System recovery) function”
- 24 • SAMA CB-10R, “provide additional non-destructive evaluation (NDE) and inspections of
 25 main steam (MS) piping in Turbine Building”

26 These SAMAs are included in Table F-11 and are discussed further in Section F.6.2. If a basic
 27 event of high risk importance is not addressed by a SAMA, that is because one of the following
 28 is true regarding the basic event (Gambhir, 2011):

- 29 • It has an RRW value that is too low or the potential enhancement has an implementation
 30 cost that is too high to result in a cost-beneficial SAMA.
- 31 • It was determined to have no feasible SAMA that would further reduce risk.
- 32 • It requires a hardware modification but has an RRW benefit value that is well below the
 33 \$100,000 minimum implementation cost for a hardware modification.
- 34 • It is a LERF-based success event

35 Based on this additional information, the NRC staff agrees that cost-beneficial improvements for
 36 these basic events are unlikely.

37 Although the IPE did not identify any fundamental vulnerabilities or weaknesses related to
 38 internal events, Energy Northwest considered the potential plant improvements described in the
 39 IPE in the identification of plant-specific candidate SAMAs for internal events. The CGS IPE
 40 identified nine improvements associated with core damage as follows (Parrish, 1994):

Appendix F

- 1 (1) modify the isolated phase buses to allow expeditious alignment of the 500 kilovolt (kV)
2 highline to the plant AC distribution system via the main step-up transformer
- 3 (2) increase the capacity of the 230 kV/115kV plant bus transfer
- 4 (3) install an additional battery charger
- 5 (4) evaluate potential improvements to procedures and training for the recognition and
6 isolation of floods identified to cause multiple system failures
- 7 (5) evaluate potential improvements to maintenance practices to ameliorate CCFs
- 8 (6) modify emergency procedures to allow use of the automatic depressurization system
9 inhibit switch in non-ATWS scenarios
- 10 (7) evaluate potential improvements in the SBO emergency procedure to prevent unwanted
11 depressurization
- 12 (8) evaluate performing periodic inspection and maintenance of the Omega seal separating
13 the drywell and wetwell air spaces
- 14 (9) modify the air supply to the inboard MSIVs and the containment vent valves for backup
15 from the containment N₂ system

16 Energy Northwest stated in the ER that Improvements 4, 6, and 7 have been implemented at
17 CGS. Additionally, SAMA candidates AC/DC-27, “install permanent hardware changes that
18 make it possible to establish 500 kV backfeed through the main step-up transformer,” and
19 AC/DC-28, “reduce common cause failures (CCFs) between EDGs EDG-3 and EDG-1/2,” were
20 identified to address Improvements 1 and 5, respectively (EN, 2010). Energy Northwest further
21 stated that Improvement 3 has been partially implemented, but, since battery chargers are not
22 significant contributors to risk, no SAMA is considered for this improvement. The NRC staff
23 agrees that since battery chargers were not identified as risk significant in the importance
24 analysis described previously, a SAMA to address IPE Improvement 3 is unlikely to be
25 cost-beneficial.

26 Energy Northwest reported that a cost-benefit analysis had previously been performed for
27 Improvement 2 and determined the modification to not be cost-effective. The NRC staff asked
28 Energy Northwest to provide a summary and scope of this cost-benefit analysis (Doyle, 2010a).
29 In response to the RAI, Energy Northwest explained that the cost-benefit analysis focused on
30 increasing the capacity of the 230 kV startup transformer since it is the primary offsite power
31 source, and its loading has less margin than the 115 kV transformer. The decrease in CDF
32 from the modification was estimated to be 7.0E-07 per year in Revision 1 of the IPE. The
33 analysis assumed a benefit of \$250,000 for each decrease of 1.0E-06 per year in CDF. The
34 implementation cost of the modification was estimated to be \$2 million. Since the
35 implementation cost was greater than the estimated benefit, the modification was determined
36 not to be cost effective (Gambhir, 2010). Energy Northwest also noted that SAMA AC/DC-27
37 represents a similar SAMA in terms of cost and benefit. The NRC staff considers Energy
38 Northwest’s clarification reasonable and agrees that, based on Energy Northwest’s evaluation of
39 AC/DC-27, a SAMA to address IPE Improvement 2 is unlikely to be cost-beneficial.

40 The ER did not address IPE Improvement 8. Since failure of the drywell-to-wetwell Omega seal
41 is not identified as a risk-important system on the RRW listings discussed previously, the NRC
42 staff concludes that a SAMA to address IPE Improvement 8 is unlikely to be cost-beneficial.

1 The ER did not address IPE Improvement 9. The NRC staff noted that Revision 1 of the IPE
 2 identifies this improvement as being marginally cost effective and that the improvement could
 3 increase in importance if the other IPE-identified improvements were implemented. Considering
 4 that many of the improvements were indeed implemented, the NRC staff asked Energy
 5 Northwest to provide an assessment of a SAMA to address IPE Improvement 9 (Doyle, 2010a).
 6 In response to the RAI, Energy Northwest explained that the change in CDF by making gas
 7 supply to the MSIVs perfect is negligible (RRW = 1.000) and, therefore, a SAMA to do this was
 8 screened from further consideration (Gambhir, 2010). Energy Northwest also explained that a
 9 procedure to use portable N₂ bottle(s) to manually open the containment vent valves was
 10 developed, the RRW for the air supply to the containment vent valves is 1.0002, and the PSA
 11 was not updated to incorporate the procedure because of its low risk significance. Therefore,
 12 because of the low-risk benefit, a SAMA to provide another air or N₂ supply to the containment
 13 vent valves was screened from further consideration. Based on the low risk significance of the
 14 air supply to the MSIVs and containment vent valves, the NRC staff agrees that a SAMA to
 15 address IPE Improvement 9 is unlikely to be cost-beneficial.

16 Energy Northwest reviewed the Phase II SAMAs from prior SAMA analyses for 12 General
 17 Electric BWR sites and stated in the ER that no additional SAMAs were identified from this
 18 review (EN, 2010). The NRC staff noted that Table E.9-3 of the ER identifies two SAMAs that
 19 appear to have been identified from the review of prior SAMA analyses and asked Energy
 20 Northwest to clarify this discrepancy (Doyle, 2010a). In response to an NRC staff RAI, Energy
 21 Northwest stated that two of the SAMAs identified in the ER were identified from this review
 22 (Gambhir, 2010). The NRC staff also asked Energy Northwest to provide an assessment of the
 23 applicability of each of the cost-beneficial SAMAs from the 12 BWR sites to CGS
 24 (Doyle, 2010a). In response to the RAI, Energy Northwest provided the results of the review of
 25 the 72 cost-beneficial SAMAs from the prior SAMA analyses. Energy Northwest concluded that
 26 21 are not applicable to CGS, 26 are already implemented at CGS or were screened on very
 27 low benefit, 10 had already been identified and evaluated in the ER, 1 was identified and
 28 evaluated in response to a separate NRC staff RAI (SAMA FR-08 discussed below), 10 were
 29 evaluated further in the Phase II evaluation, and the remaining were duplicate SAMAs identified
 30 in more than one of the prior SAMA analyses (Gambhir, 2010), (Gambhir, 2011). The 10
 31 SAMAs identified and evaluated further are as follows:

- 32 • SAMA FW-05R, “examine the potential for operators to control reactor feedwater (RFW)
 33 and avoid a reactor trip”
- 34 • SAMA FL-04R, “install one isolation valve in each of standby service water (SW), plant
 35 service water (TSW), and fire protection (FP) lines in the Control Building area of the
 36 Radwaste Building to facilitate rapid isolation by the operators upon receipt of a high flow
 37 alarm”
- 38 • SAMA FL-05R, “install three clamp-on flow instruments to certain drain lines in the
 39 Control Building area of the Radwaste Building and alarm in the Control Room”
- 40 • SAMA FL-06R, “perform additional NDE inspections to the three lines identified in SAMA
 41 FL-04R to verify that degradation is not occurring in these lines”
- 42 • SAMA CC-24R, “backfeed the HPCS system with [emergency bus] SM-8 to provide a
 43 third power source for HPCS”
- 44 • SAMA CC-25R, “enhance alternate injection reliability by including residual heat removal
 45 service water and fire water crosstie in maintenance program”
- 46 • SAMA CC-26R, “install hard pipe from diesel fire pump to vessel”

Appendix F

- 1 • SAMA OT-07R, “increase operator training on systems and operator actions determined
2 to be important from the PSA”
- 3 • SAMA OT-08R, “install explosion protection around CGS transformers”
- 4 • SAMA OT-10R, “increase fire pump house building integrity to withstand higher winds so
5 the fire system will be capable of withstanding a severe weather event”

6 These SAMAs are included in Table F-11 and are discussed further in Section F.6.2.

7 Based on this information, the NRC staff concludes that the set of SAMAs evaluated in the ER,
8 together with those identified in response to NRC staff RAIs, addresses the major contributors
9 to internal event CDF.

10 Energy Northwest also provided a tabular listing of the Level 1 fire PSA basic events sorted
11 according to their RRW (EN, 2010). Energy Northwest used an RRW cutoff of 1.000, which
12 corresponds to less than a 0.1 percent change in CDF given 100-percent reliability of the
13 SAMA. Energy Northwest also provided a listing of the fire compartments representing over
14 98 percent of the fire CDF. No additional SAMAs were identified from this review.

15 The NRC staff asked Energy Northwest to identify and evaluate SAMAs to address each of the
16 risk significant Level 1 fire basic events. In a separate RAI, the NRC staff asked Energy
17 Northwest to provide a listing of the risk significant Level 2 fire basic events and assess each
18 important basic event for potential SAMAs (Doyle, 2010a). In response to the RAIs, Energy
19 Northwest provided the following using PSA model Revision 7.1 (Gambhir, 2010),
20 (Gambhir, 2011):

- 21 • a tabular listing of Level 1 fire PSA basic events sorted first according to RAW and then
22 according to their RRW
- 23 • a second tabular list of Level 1 fire PSA basic events sorted according to their RRW
- 24 • a tabular list of LERF fire basic events

25 In these listings, Energy Northwest used an RRW cutoff of 1.015, which corresponds to about a
26 1.5 percent decrease in fire CDF given 100-percent reliability of the equipment or human
27 actions affected by the SAMA. This equates to a fire events benefit of approximately \$12,000,
28 the minimum cost of a procedure change at CGS. For each basic event listed, Energy
29 Northwest correlated the CDF and LERF events with the SAMAs identified in the ER and with
30 several newly identified SAMAs and showed that, with some exceptions, all of the significant
31 basic events are addressed by one or more SAMAs. The additional SAMAs identified from this
32 review are as follows:

- 33 • SAMA FR-09R, “install early detection for FR1J (physical analysis unit R-1J) and FR1D
34 (physical analysis unit R-1D)”
- 35 • SAMA FR-10R, “install early detection in the Control Room (RC-10)”
- 36 • SAMA FR-11R, “install early detection for FW14 (analysis unit RC-14), FW04 (analysis
37 unit RC-04), FW11 (analysis unit RC-11), FW03 (analysis unit RC-03), FW08 (analysis
38 unit RC-08), FW05 (analysis unit RC-05), FW02 (analysis unit RC-02), FW13 (analysis
39 unit RC-13), and FW1A (analysis unit RC-1A)”
- 40 • SAMA FR-12R, “install early detection for FT1A (physical analysis unit T-1A) and FT12
41 (physical analysis unit T-12)”

- 1 • SAMA AC/DC-30R, “provide an additional diesel generator (DG) diverse from DG-1 and
2 DG-2”

3 These SAMAs are included in Table F-11 and are discussed further in Section F.6.2. If a basic
4 event of high risk importance is not addressed by a SAMA, that is because one of the following
5 is true in regard to the basic event:

- 6 (1) It requires a hardware modification, but it has an RRW benefit value that is well below
7 the \$100,000 minimum implementation cost for a hardware modification.
- 8 (2) It was determined to have no feasible or viable SAMA that would further reduce risk.
- 9 (3) It has no physical meaning or is a parameter required for modeling purposes (such as
10 split fractions, fire source partitioning factors, ratios of fixed source to total source in fire
11 zone, phenomenological values, and success terms).
- 12 (4) It is an event for which a plant modification is already being implemented to improve
13 equipment reliability.
- 14 (5) It is a LERF-based success event.
- 15 (6) It was judged to not be a realistic contribution to risk because the fire PSA conservatively
16 does not credit the air accumulators installed at each of the SRVs.

17 Regarding Item 6, the NRC asked that Energy Northwest provide an assessment of what the
18 RRW values would be for the associated basic events if the air accumulators were credited
19 (Doyle, 2010c). In response to the RAI and the sensitivity study of PSA Revision 7.1, Energy
20 Northwest showed that each of the fire basic events in question is, in fact, addressed by an
21 existing SAMA (Gambhir, 2010), (Gambhir, 2011). Based on this additional information, the
22 NRC staff agrees that cost-beneficial improvements are unlikely for those basic events for which
23 no SAMA was identified.

24 The NRC staff also asked Energy Northwest to identify and evaluate SAMAs to address each of
25 the risk significant Level 1 and 2 seismic basic events (Doyle, 2010a). In response to the RAI,
26 Energy Northwest provided tabular listings of the PSA model Revision 7.1 Level 1 and LERF
27 seismic basic events sorted according to their RRW (Gambhir, 2011). SAMAs impacting these
28 basic events would have the greatest potential for reducing risk. Energy Northwest used an
29 RRW cutoff of 1.03, which corresponds to about a 3 percent reduction in seismic CDF given
30 100-percent reliability of the SAMA. This equates to a seismic events benefit of approximately
31 \$12,000, the minimum cost of a procedure change at CGS (Gambhir, 2011). Energy Northwest
32 correlated the CDF and LERF events with the SAMAs identified in the ER and in response to
33 RAIs and showed that, with a few exceptions, all of the significant basic events are addressed
34 by one or more SAMAs. No additional SAMA candidates were identified from this review. For
35 the exceptions in which a basic event of risk importance is not addressed by a SAMA, Energy
36 Northwest explained that this is because the basic event requires hardware modifications for
37 multiple components but has an RRW benefit value that is well below the implementation cost
38 for multiple hardware modifications or has no physical meaning or is a parameter required for
39 modeling purposes (such as split fractions and success terms). Based on this additional
40 information, the NRC staff agrees that cost-beneficial improvements for these basic events are
41 unlikely.

42 In a followup RAI, the NRC staff noted that the Level 1 and Level 2 seismic basic events
43 importance lists identify only a few basic events and asked Energy Northwest to explain why
44 this is the case (Doyle, 2011). In response to the RAI, Energy Northwest explained that the

Appendix F

1 seismic PSA model includes random failures but that none of these events showed up in the
2 lists because the random failure events had RRW values less than the 1.03 value used as a
3 cutoff for identifying important basic events (Swank, 2011).

4 In another followup RAI, the NRC staff noted that the importance analyses reviews performed
5 for internal, fire, and seismic events only addressed CDF and LERF and asked Energy
6 Northwest to provide a review of risk-important basic events for release categories H/I and M/I,
7 which are also significant contributors to the CGS dose-risk (Doyle, 2011). In response to the
8 RAI, Energy Northwest provided a tabular listing of PSA model Revision 7.1 internal, fire, and
9 seismic basic events contributing to the H/I and M/I release categories that were either not
10 included in the Level 1 and LERF importance analyses discussed previously or whose
11 resolution for the basic event changed (Swank, 2011). Basic events that were found to be
12 events that had no physical meaning (such as flag events and phenomenological events) were
13 not included in the listing. Energy Northwest developed separate basic event listings for
14 internal, fire, and seismic basic events contributing to the H/I and M/I release categories and
15 used RRW cutoffs for each corresponding to a basic event benefit of approximately \$12,000,
16 the minimum cost of a procedure change at CGS. Energy Northwest correlated the H/I and M/I
17 basic events with the SAMAs identified in the ER and in response to RAIs and showed that, with
18 a few exceptions, all of the basic events are addressed by one or more SAMAs. No additional
19 SAMA candidates were identified from this review. For the exceptions in which a basic event of
20 risk importance is not addressed by a SAMA, Energy Northwest explained that the reasons for
21 this are as follows:

- 22 • No feasible SAMA was identified to address the basic event.
- 23 • The only feasible SAMA candidate for the basic event had essentially already been
24 implemented.
- 25 • The basic event is a basic PSA model assumption that is not a candidate for a SAMA.

26 Based on this additional information, the NRC staff agrees that cost-beneficial improvements for
27 these basic events are unlikely.

28 Although the IPEEE did not identify any fundamental vulnerabilities or weaknesses related to
29 external events, four improvements related to internal fire events, six improvements related to
30 seismic events, and one improvement related to high winds, floods, and other (HFO) external
31 events were identified. All of these improvements have been resolved as either having been
32 implemented (seven improvements) or determined to not be necessary based on an
33 engineering evaluation that determined the existing design or procedure or both was adequate
34 (three improvements), or determined to not be necessary based on a cost-benefit evaluation
35 (one improvement) (NRC, 2001).

36 Regarding the last improvement, which is to strengthen the motor control center (MCC) base
37 connections, the NRC staff asked Energy Northwest to justify not including it as a SAMA,
38 especially considering that the seismic hazard curve has changed since the IPEEE
39 (Doyle, 2010a). Energy Northwest responded that the newer seismic hazard curves, as
40 discussed in Section F.2.2, have been shown to be consistent with the CGS seismic hazard
41 curves used for the seismic PSA and that the fragility of the MCCs has, therefore, not changed
42 (Gambhir, 2010). Nevertheless, Energy Northwest identified SAMA SR-05R, “improve seismic
43 ruggedness of MCC-7F and MCC-8F,” to address this issue. This SAMA is included in
44 Table F-11 and is discussed further in Section F.6.2.

1 Energy Northwest also reviewed the PSA insights from the CGS IPEEE for fire events, seismic
 2 events, and other external events. The review of the fire PSA insights indicated that the
 3 dominant fire sequences render containment venting, the power conversion system, and one
 4 train of RHR or service water unavailable. Based on the review of these insights, Energy
 5 Northwest identified one additional SAMA candidate to improve the fire resistance of critical
 6 cables (SAMA FR-07). This SAMA candidate was subsequently divided into two SAMA
 7 candidates, one to protect the containment vent valve cables from fires (SAMA FR-07a) and the
 8 second to protect the transformer E-TR-S cables from fires (SAMA FR-07b).

9 The NRC staff noted that both SAMAs FR-07a and FR-07b were determined to be
 10 cost-beneficial in the Phase II evaluation and asked Energy Northwest to provide an evaluation
 11 of a SAMA to protect RHR and service water cables from fires (Doyle, 2010a), (Doyle, 2010c).
 12 In response to the RAI, Energy Northwest stated that since CGS electrical cabling is currently
 13 protected from fire to manually shutdown in the RHR alternate shutdown mode (Appendix R), a
 14 SAMA was identified and evaluated to provide additional protection from MSOs in auto initiation
 15 circuits of RHR and service water (Gambhir, 2010), (Gambhir, 2011). This SAMA, SAMA
 16 FR-08, "improve the fire resistance of cables to RHR and SW," is included in Tables F-10 and
 17 F-11 and is discussed further in Section F.6.2.

18 Based on the licensee's IPEEE, the review of the results of the CGS PSA, which includes
 19 seismic and fire events, and the expected cost associated with further risk analysis and potential
 20 plant modifications, the NRC staff concludes that the opportunity for seismic and fire-related
 21 SAMAs has been adequately explored. The staff finds that it is unlikely that there are any
 22 additional cost-beneficial seismic or fire-related SAMA candidates.

23 As stated earlier, other external hazards (high winds, external floods, volcanic activity,
 24 transportation and nearby facility accidents, and other external events) are below the IPEEE
 25 threshold screening frequency, or met the 1975 SRP design criteria, and are not expected to
 26 represent opportunities for cost beneficial SAMA candidates.

27 For many of the Phase II SAMAs listed in the ER, the information provided did not sufficiently
 28 describe the proposed modification. Therefore, the NRC staff asked the applicant to provide
 29 more detailed descriptions of the modifications and cost estimates for several of the Phase II
 30 SAMA candidates (Doyle, 2010a). In response to the RAI, Energy Northwest provided the
 31 requested information (Gambhir, 2010). This is discussed further in Section F.5.

32 The NRC staff questioned Energy Northwest about lower cost alternatives to some of the
 33 SAMAs evaluated (Doyle, 2010a), including the following:

- 34 • establishing procedures for opening doors or using portable fans for sequences involving
 35 room cooling failures, such as the EDG room
- 36 • using a portable independently powered pump to inject into containment
- 37 • using the security diesel generator or EDG-4 to extend the life of the 125-V DC batteries
- 38 • using a portable generator to provide power to individual 125-V DC MCCs upon loss of a
 39 DC bus to improve availability of HPCS

40 In response to the RAI, Energy Northwest addressed the suggested lower cost alternatives
 41 (Gambhir, 2010). This is discussed further in Section F.6.2.

Appendix F

1 Energy Northwest’s Phase I SAMA screening process initially eliminated 124 SAMAs using the
2 criteria discussed in Section F.3.1, leaving 27 for further evaluation. Phase I SAMA SR-01,
3 “increase seismic ruggedness of standby service water (SSW) pumps and RHR heat
4 exchangers,” while originally retained for further evaluation was subsequently screened after
5 further consideration and the determination that it would provide very little benefit, thus reducing
6 to 26 the number of SAMAs retained for further evaluation. Three SAMAs—SAMA CB-03,
7 “increase leak testing of valves in ISLOCA paths,” SAMA CB-08, “revise emergency operating
8 procedures (EOPs) to improve ISLOCA identification,” and SAMA CB-09, “improve operator
9 training on ISLOCA coping”—were originally screened because they were similar to another
10 SAMA but were subsequently included for further evaluation, raising the total to 29 SAMAs
11 retained for further evaluation.

12 The NRC staff noted that Phase I SAMA CC-21, “revise procedure to align LPCI or core spray
13 to CST on loss of suppression pool cooling,” was not eliminated in the Phase I screening
14 evaluation but was not included in the Phase II detailed evaluation and asked Energy Northwest
15 to clarify the screening of this SAMA (Doyle, 2011). In response to the RAI, Energy Northwest
16 explained that CGS has the following existing water sources from which to provide injection
17 (Swank, 2011):

- 18 • service water cross-connect to the RHR system
- 19 • fire water through a cross-connect to a condensate booster pump and through a fire
20 hose connection to LPCI piping
- 21 • condensate from the hotwell with makeup from the CST via multiple pathways

22 Energy Northwest further explained that CGS has a direct gravity drain from the CST to both the
23 HPCS and RCIC pumps and that, therefore, CST inventory would only be available for low
24 pressure injection on loss of these systems prior to CST inventory depletion. Based on the
25 ability to provide injection from alternative sources through multiple pathways that are
26 proceduralized, Energy Northwest screened SAMA CC-21, leaving 28 for further evaluation.
27 Based on this information, the NRC staff agrees that SAMA CC-21 is unlikely to be
28 cost-beneficial.

29 The NRC staff noted that many Phase I SAMAs were screened on very low benefit without an
30 assessment of the RRW for the systems being addressed and asked that Energy Northwest
31 provide the RRW for each of these SAMAs (Doyle, 2010a). Energy Northwest responded by
32 providing an assessment of the RRW, risk significance, or reliability of the systems addressed
33 by each Phase I SAMA screened on very low benefit and concluded that all of these SAMAs
34 were appropriately screened on very low benefit (Gambhir, 2010). Based on this additional
35 information, the NRC staff agrees that the Phase I SAMAs screened on very low benefit are
36 unlikely to be cost-beneficial improvements.

37 The NRC staff observed that the screening of SAMA FW-04, “add a motor-driven feedwater
38 (FW) pump,” in the Phase I evaluation on very low benefit appeared to be based on FW
39 unavailability being more sensitive to loss of flow from the condensate booster pumps and FW
40 pumps than from independent or CCFs of the FW pumps. The staff asked that Energy
41 Northwest justify the screening of the SAMA (Doyle, 2010a). In response to the RAI, Energy
42 Northwest clarified that the top 79 percent of contributors to RFW unavailability are factors other
43 than the RFW pumps and that, as a result, it was concluded that adding an additional
44 motor-driven RFW pump would add little benefit relative to the cost incurred (Gambhir, 2010).
45 Nevertheless, Energy Northwest observed that the importance of RFW has increased in PSA

1 model Revision 7.1 and provided a Phase II evaluation of SAMA FW-04. This SAMA is included
2 in Table F-11 and is discussed further in Section F.6.2.

3 The NRC staff noted that Section 9.2 of the ER indicates two seismic SAMA candidates were
4 evaluated, yet only one seismic SAMA was included in the Phase II evaluation. The staff asked
5 that Energy Northwest clarify this discrepancy (Doyle, 2010a). Energy Northwest responded
6 that SAMA SR-01, “increase seismic ruggedness of SSW pumps and RHR heat exchangers,”
7 was originally assessed during the Phase I screening evaluation to be included in the Phase II
8 evaluation, but it was subsequently screened after a more detailed evaluation determined that
9 strengthening the RHR heat exchangers and SSW pumps would provide very little benefit
10 (Gambhir, 2010). The NRC staff considers Energy Northwest’s clarification reasonable.

11 The NRC staff notes that the set of SAMAs submitted is not all-inclusive, since additional,
12 possibly even less expensive, design alternatives can always be postulated. However, the NRC
13 staff concludes that the benefits of any additional modifications are unlikely to exceed the
14 benefits of the modifications evaluated, and the alternative improvements would not likely cost
15 less than the least expensive alternatives evaluated when the subsidiary costs associated with
16 maintenance, procedures, and training are considered.

17 The NRC staff concludes that Energy Northwest used a systematic and comprehensive process
18 for identifying potential plant improvements for CGS, and the set of SAMAs evaluated in the ER,
19 together with those evaluated in response to NRC staff inquiries, is reasonably comprehensive
20 and, therefore, acceptable. This search included reviewing insights from the plant-specific risk
21 studies, including internal initiated events as well as fire and seismic initiated events, and
22 reviewing plant improvements considered in previous SAMA analyses.

23 **F.4 Risk Reduction Potential of Plant Improvements**

24 Energy Northwest evaluated the risk-reduction potential of the 28 remaining SAMAs that were
25 applicable to CGS. The majority of the SAMA evaluations were performed in a bounding
26 fashion in that the SAMA was assumed to eliminate the risk associated with the proposed
27 enhancement. Such bounding calculations overestimate the benefit and are conservative.

28 Energy Northwest used model re-quantification to determine the potential benefits. The CDF
29 and population dose reductions were estimated using the CGS internal events PSA
30 Revision 6.2 model for internal events, the CGS fire PSA Revision 2 model for fire events, and
31 the CGS seismic PSA Revision 1 model for seismic events. The changes made to the models
32 to quantify the impact of SAMAs are detailed in Table E.11-1 of Attachment E to the ER
33 (EN, 2010). Table F-10 lists the assumptions considered in the ER to estimate the risk
34 reduction for each of the evaluated SAMAs, the estimated risk reduction in terms of percent
35 reduction in CDF and population dose, and the estimated total benefit (present value) of the
36 averted risk. The estimated benefits reported in Table F-10 reflect the combined benefit in both
37 internal and external events. The determination of the benefits for the various SAMAs is further
38 discussed in Section F.6.

39 The NRC staff noted that the risk reduction for many SAMAs was reported to be 0.00E+00 and
40 asked Energy Northwest to clarify if the results for these SAMAs were actually zero or if the
41 results are negligible and, if actually zero, to specifically justify the zero risk reduction reported
42 for four of the SAMAs (Doyle, 2010a). In response to the RAI, Energy Northwest clarified that
43 the reduction in CDF was calculated for CDF results reported to four significant digits and that,
44 therefore, the 0.00E+00 values reported in Table E.11-1 of the ER are known to be zero in

Appendix F

1 almost every instance (Gambhir, 2010). Energy Northwest further identified two specific SAMAs
2 where the change in CDF was judged to be negligible but reported to be 0.00E+00 in
3 Table E.11-1 of the ER. The two SAMAs—SAMA CB-01, “install additional pressure or leak
4 monitoring instruments for detection of ISLOCAs,” and SAMA SR-03, “modify safety related
5 CST”—were reported to have a 0.00E+00 reduction in internal events and seismic events CDF,
6 respectively, when the reduction in each of these CDFs was actually calculated to be 1.0E-09
7 per year. Energy Northwest also justified the reported 0.00E+00 risk reduction reported for the
8 following SAMAs, as requested by NRC staff in the RAI:

- 9 • SAMA AC/DC-01, “provide additional DC battery capacity,” with a reported reduction in
10 fire CDF of 0.00E+00—Energy Northwest explained that this SAMA would increase the
11 time for recovery of offsite power during an SBO and that the fire PSA assumes that
12 recovery of fire-induced offsite power is not feasible in the near term. Therefore, there is
13 no risk reduction from providing additional DC power capacity for fire events
14 (Gambhir, 2010).
- 15 • SAMA CC-20, “improve ECCS suction strainers,” with a reported reduction in internal
16 events, fire, and seismic CDFs of 0.00E+00—Energy Northwest explained that modeling
17 of the suction strainers was incomplete in PSA model Revision 6.2 because each of the
18 redundant suction strainers was modeled as independent from one another. Therefore,
19 no reduction in CDF was calculated (Gambhir, 2010). Energy Northwest noted that
20 modeling of the suction strainers was improved in PSA model Revision 7.1 to include
21 CCFs in response to a Level C F&O from the 2004 peer review. The sensitivity study
22 using PSA model Revision 7.1 does report a non-zero reduction in internal event CDF
23 for this SAMA, as provided in Table F-11 (Gambhir, 2011).
- 24 • SAMA CB-01, “install additional pressure or leak monitoring instruments for detection of
25 ISLOCAs,” with a reported reduction in internal events, fire, and seismic CDFs of
26 0.00E+00—Energy Northwest clarified that the risk reduction in internal events CDF was
27 actually calculated to be 1.0E-09 per year as a result of eliminating the ISLOCA
28 contribution but was reported to be 0.00E+00 in Table E.11-1 of the ER
29 (Gambhir, 2010). Energy Northwest further explained that the fire PSA does not
30 currently model the potential for fire-induced ISLOCA but that this area of model
31 incompleteness is judged to be a negligible contributor to fire CDF. The reason for this
32 is that an ISLOCA in the shutdown cooling line composed of two valves in series has a
33 low likelihood because one of the valves (RHR-V-9) is maintained in a closed position
34 during normal plant operation with power removed (via a protected isolation switch) so
35 that hot shorts cannot cause the valve motor to energize and open the valve (and the
36 de-energized power feeder is protected against external three-phase hot shorts).
37 Additionally, a hot short plus random failure of a check valve is required to produce an
38 ISLOCA for other pathways. Regarding the seismic PSA, Energy Northwest explained
39 that both seismic damage states SDS41 and SDS42 include potential ISLOCAs but that
40 ISLOCAs cannot be differentiated from other contributors to core damage.
- 41 • SAMA AT-14, “diversify standby liquid control (SLC) explosive valve operation,” with a
42 reported reduction in fire and seismic CDFs of 0.00E+00—Energy Northwest explained
43 that fire-induced ATWS is not modeled in the fire PSA based on its low risk-significance
44 per NUREG/CR-6850 (NRC, 2005) and, thus, has very little risk reduction potential for
45 fire (Gambhir, 2010). Regarding the seismic PSA, Energy Northwest explained that
46 seismic damage state SDS40, an unmitigated seismic-induced ATWS scenario having a
47 seismic CDF contribution of 7.3E-09 per year, is the dominant contributor to
48 seismic-ATWS sequences and that diversification of the SLC explosive valves would not

1 mitigate this sequence. Energy Northwest further considered that only a significant
2 increase in seismic ruggedness in the SLC explosive valves and its piping would provide
3 significant mitigation, but a significant improvement in seismic ruggedness is not
4 practical due to its connectivity to other systems that would also require a corresponding
5 improvement in seismic ruggedness to be effective.

6 As indicated in Section F.2.1, in response to an NRC staff RAI, Energy Northwest provided the
7 results of a sensitivity study using PSA model Revision 7.1 (Gambhir, 2011). Table F-11 lists
8 the assumptions considered in the sensitivity analysis to estimate the risk reduction for each of
9 the evaluated SAMAs, the estimated risk reduction in terms of percent reduction in CDF and
10 population dose, and the estimated total benefit (present value) of the averted risk. As with
11 Table F-10, the estimated benefits reported in Table F-11 reflect the combined benefit in both
12 internal and external events. Energy Northwest stated in the sensitivity study that the modeling
13 approach used for SAMAs evaluated in the ER was the same as that used in the sensitivity
14 study.

15 The NRC staff noted that implementation of SAMA CW-02, “add redundant DC control power for
16 pumps,” SAMA CW-03, “replace ECCS pump motors with air-cooled motors,” and SAMA
17 CW-04, “provide self-cooled ECCS seals,” results in an increase in the fire population dose risk.
18 Additionally, implementation of SAMA AC/DC-30R, “provide an additional diesel generator
19 diverse from DG-1 and DG-2,” results in an increase in the internal events CDF and population
20 dose risk. The staff asked that Energy Northwest explain these apparent anomalies
21 (Doyle, 2011). In response to the RAI, Energy Northwest clarified that the increase in
22 population dose for SAMAs CW-02, CW-03, and CW-04 is due to the modeling assumption that
23 the associated hardware failures were eliminated, which resulted in the redistribution of CDF
24 between PDSs in the CET quantifications (Swank, 2011). The PDSs associated with the
25 modeled success branches are binned to release categories that have higher dose
26 consequences than the modeled failure branches, thus increasing the dose risk for these
27 SAMAs. For SAMA AC/DC-30R, Energy Northwest replied that this SAMA was incorrectly
28 modeled and provided revised results, which are reported in Table F-11. The NRC staff
29 considers Energy Northwest’s clarifications reasonable.

30 The modeling approaches for SAMA CC-01, “install an independent active or passive high
31 pressure injection system,” and SAMA CC-02, “provide an additional high pressure injection
32 pump with independent diesel,” were reported to be different in the ER yet the estimated
33 benefits for the two SAMAs were identical. In the sensitivity study, Energy Northwest clarified
34 that the same modeling approach was used for both of these SAMAs (Gambhir, 2011).

35 As mentioned in Section F.2.2, the NRC staff noted that the hot short probability of 0.3
36 assumption used in the fire PSA is not necessarily consistent with the guidance in
37 NUREG/CR-6850 (NRC, 2005), which recommends doubling the 0.3 value to 0.6 for circuits
38 where control power transformers are not present. The staff asked Energy Northwest to provide
39 an assessment of this potential non-conservatism on the SAMA analysis (Doyle, 2010c),
40 (Doyle, 2011). In the RAI, the NRC staff asked Energy Northwest to specifically re-evaluate 7
41 Phase II SAMAs identified to address fire risk and 10 Phase II SAMAs identified to address
42 internal events risk, representing the Phase II SAMAs that have a high baseline benefit relative
43 to the estimated implementation cost. In response to the RAIs, Energy Northwest provided the
44 results of a sensitivity analysis using PSA model Revision 7.1 wherein each of the SAMA was
45 re-evaluated assuming a hot short probability of 0.6 for those circuits that were not confirmed to
46 have a control power transformer present (Gambhir, 2011), (Swank, 2011). Energy Northwest
47 re-quantified the base PSA model using the revised hot short probability assumptions, which

Appendix F

1 increased the fire CDF to 1.43×10^{-5} per year from 1.37×10^{-5} per year, and then re-quantified the
2 PSA model again for each of the SAMAs by making the associated model changes described in
3 Table F-11. Energy Northwest's analysis showed that the reduction in fire CDF increased by a
4 factor of 1.0 to 2 for the SAMA identified to address fire events and by a factor of 1.0 to 1.38 for
5 all but one of the SAMAs identified to address internal events. The re-evaluation of one SAMA
6 resulted in the reduction in fire CDF decreasing by about 8 percent, the reason for which is
7 provided in the RAI response. Based on these results, Energy Northwest concluded that the
8 potential non-conservatism in the SAMA analysis is bounded by the uncertainty analysis using
9 the 95th percentile CDF discussed in Section F.6.2. Based on the results of the sensitivity
10 analysis being bounded by the 95th percentile CDF uncertainty analysis, and that the sensitivity
11 analysis was performed for those SAMAs most likely to be impacted by the hot short probability
12 assumption, the NRC staff concludes that using a hot short probability of 0.3 will not impact the
13 results of the SAMA analysis.

14 The NRC staff has reviewed Energy Northwest's bases for calculating the risk reduction for the
15 various plant improvements and concludes that the rationale and assumptions for estimating
16 risk reduction are reasonable and generally conservative (i.e., the estimated risk reduction is
17 higher than what would actually be realized). Accordingly, the NRC staff based its estimates of
18 averted risk for the various SAMAs on Energy Northwest's risk reduction estimates.

Table F-10. SAMA cost and benefit screening analysis for CGS^(a)

| SAMA | Assumptions | % Risk Reduction ^(b,d) | | Total Benefit (\$) ^(h) | | Cost (\$) |
|--|---|-----------------------------------|----------------------|-----------------------------------|--|-----------|
| | | CDF | Population dose | Baseline (internal + external) | Baseline with uncertainty ^(c) | |
| Increase availability of DC power | In response to an NRC staff RAI, increase time available to recover onsite and onsite power before RCIC is lost to 10 hours during SBO scenarios from 7 hours with DC power load-shedding and from 5 hours without load-shedding (Gambhir, 2011). | IE→5 F→0 S→1 | IE→4 F→0 S→1 | 37K | 100K | |
| AC/DC-01—Provide additional DC battery capacity | | | | | | 1.8M |
| AC/DC-02—Replace lead-acid batteries with fuel cells | | | | | | 1.0M |
| AC/DC-03—Add a portable, diesel-driven battery charger to existing DC system | | | | | | 500K |
| Increase Availability of Onsite AC Power | In response to an NRC staff RAI, eliminate failure of EDG-1 (Gambhir, 2010). | IE→32 F→11 S→4 | IE→15 F→9 S→4 | 250K | 720K | |
| AC/DC-10—Provide an additional DG | | | | | | 11M |
| AC/DC-15—Install a gas turbine generator | | | | | | 2.1M |
| AC/DC-16—Install tornado protection of gas turbine generator | | | | | | 2.1M |
| AC/DC-23—Develop procedures to repair or replace failed 4 kV breakers | Eliminate failures of the 4 kV breakers. | IE→1 F→2 S→<1 | IE→<1 F→2 S→<1 | 20K | 61K | 375K |

| SAMA | Assumptions | % Risk Reduction ^(b,d) | | Total Benefit (\$) ^(h) | | Cost (\$) |
|---|---|-----------------------------------|----------------------|-----------------------------------|--|-----------|
| | | CDF | Population dose | Baseline (internal + external) | Baseline with uncertainty ^(c) | |
| AC/DC-27—Install permanent hardware changes that make it possible to establish 500 kV backfeed through the main step-up transformer | In response to an NRC staff RAI, for internal and fire events, modify fault tree to include a new basic event, having a failure probability of the 1.0E-02, representing the unavailability of the 500 kV power source (Gambhir, 2010). The 500 kV power source is not available in seismic events. | IE—24 F—28 S—0 | IE—9 F—26 S—0 | 300K | 870K | 1.7M |
| AC/DC-28(g)—Reduce CCFs between EDG-3 and EDG-1/2 | CCFs between EDG-1 and EDG-3, between EDG-2 and EDG-3, and among all three EDGs are reduced by a factor of 2. | IE—12 F—2 S—<1 | IE—6 F—1 S—<1 | 73K | 200K | 100K |
| AC/DC-29—Replace EDG-3 with a diesel diverse from EDG-1 and EDG-2 | Eliminate all CCFs between EDG-3 and EDGs-1/2. | IE—26 F—4 S—<1 | IE—12 F—2 S—<1 | 150K | 420K | 4.2M |
| AT-05—Add an independent boron injection system | In response to an NRC staff RAI, eliminate failure of the SLC system and all risk from seismic damage state (SDS) 40 (Gambhir, 2010). | IE—<1 F—0 S—<1 | IE—<1 F—0 S—<1 | 5.6K | 16K | 800K |
| AT-07—Add a system of relief valves to prevent equipment damage from pressure spikes during an ATWS | Eliminate all CCFs of SRVs. | IE—0 F—0 S—0 | IE—0 F—0 S—0 | 0K | 0K | 1.1M |
| AT-13—Automate SLC injection in response to ATWS event | Eliminate failures of operators to initiate SLC. | IE—≈0 F—0 S—0 | IE—≈0 F—0 S—0 | 0.2K | 0.5K | 660K |
| AT-14—Diversify SLC explosive valve operation | Eliminate CCFs between the SLC valves. | IE—≈0 F—0 S—0 | IE—≈0 F—0 S—0 | 0.4K | 1.0K | 370K |
| Reduce Probability of an Interfacing Systems Loss of Coolant Accident (ISLOCA) | Eliminate ISLOCA events. | IE—≈0 F—0 S—0 | IE—≈0 F—0 S—0 | 0K | 0K | |

| SAMA | Assumptions | % Risk Reduction ^(b,d) | | Total Benefit (\$) ^(h) | | Cost (\$) |
|--|---|-----------------------------------|---------------------------------|-----------------------------------|--|--|
| | | CDF | Population dose | Baseline (internal + external) | Baseline with uncertainty ^(c) | |
| CB-01—Install additional pressure or leak monitoring instruments for detection of ISLOCAs CB-03—Increase leak testing of valves in ISLOCA paths CB-08—Revise EOPs to improve ISLOCA identification CB-09—Improve operator training on ISLOCA coping | | | | | | 5.6M 400K 5.6M ^(f) 5.6M ^(f) |
| CC-01—Install an independent active or passive high pressure injection system | Reduce probability of failure of the HPCS system to 1.0E-09 (Gambhir, 2011). | IE-63 F-74 S-4 | IE-41 F-71 S-4 | 875K | 2.6M | 29M |
| CC-02—Provide an additional high pressure injection pump with independent diesel | Reduce probability of failure of the HPCS system to 1.0E-09 (Gambhir, 2011). | IE-63 F-74 S-4 | IE-41 F-71 S-4 | 875K | 2.6M | 5.2M |
| CC-03b—Raise RCIC backpressure trip set points | Unavailability of RCIC for failure to run events are reduced by a factor of 3. | IE-9 F-1 S-<1 | IE-5 F-1 S-<1 | 54K | 150K | 82K |
| CC-20—Improve ECCS suction strainers | Eliminate failures of the ECCS suction strainer due to plugging. | IE-≈0 F-≈0 S-≈0 | IE-≈0 F-≈0 S-≈0 | 0K | 0K | 10M |
| CP-01—Install an independent method of suppression pool cooling | Eliminate failures of suppression pool cooling. | IE-17 F-52 S-1 | IE-28 F-56 S-1 | 540K | 1.6M | 6.0M |
| CW-02—Add redundant DC control power for pumps | In response to an NRC staff RAI, eliminate failure of control power for the ECCS pumps (Gambhir, 2010). | IE-<1 F-3 S-<1 | IE-<1 F-3 S-<1 | 25K | 75K | 650K |

| SAMA | Assumptions | % Risk Reduction ^(b,d) | | Total Benefit (\$) ^(h) | | Cost (\$) |
|--|--|-----------------------------------|-----------------------|-----------------------------------|--|------------------|
| | | CDF | Population dose | Baseline (internal + external) | Baseline with uncertainty ^(c) | |
| Improve Reliability of ECCS Pumps CW-03—Replace ECCS pump motors with air-cooled motors CW-04—Provide self-cooled ECCS seals | In response to an NRC staff RAI, essentially eliminate failure of the low-pressure ECCS pumps due to pump motor cooling dependencies on service water (Gambhir, 2011). | IE—4 F—10 S—<1 | IE—6 F—10 S—<1 | 110K | 310K | 1.1M 675K |
| CW-07—Add a service water pump | In response to an NRC staff RAI, eliminate failure of one train of service water (Gambhir, 2010). | IE—6 F—17 S—<1 | IE—8 F—19 S—<1 | 180K | 530K | 6.1M |
| FR-03—Install additional transfer and isolation switches | Reduce the probability of the most risk significant hot shorts to zero. | IE—0 F—30 S—0 | IE—0 F—31 S—0 | 210K | 650K | 2.0M |
| FR-07a—Improve the fire resistance of critical cables for containment venting | In response to an NRC staff RAI, eliminate fire-related failures of the containment vent (Gambhir, 2010). | IE—0 F—46 S—0 | IE—0 F—50 S—0 | 330K | 1.0M | 400K |
| FR-07b—Improve the fire resistance of critical cables for transformer E-TR-S | In response to an NRC staff RAI, eliminate hot shorts for transformer E-TR-S (Gambhir, 2010). | IE—0 F—11 S—0 | IE—0 F—11 S—0 | 75K | 230K | 100K |
| FR-08(e)—Improve the fire resistance of cables to RHR and SW | Eliminate failure of RHR trains A and B due to a fire. | IE—0 F—72 S—0 | IE—0 F—78 S—0 | 520K | 1.6M | 1.25M |
| HV-02—Provide a redundant train or means of ventilation [for the critical switchgear room] | In response to an NRC staff RAI, completely remove switchgear dependencies on HVAC and eliminate the loss of HVAC IEs (Gambhir, 2010). | IE—11 F—16 S—<1 | IE—17 F—16 S—<1 | 210K | 620K | 480K |
| SR-03—Modify safety-related CST | In response to an NRC staff RAI, availability of the CST is credited during seismic events (Gambhir, 2010). | IE—0 F—0 S—≈0 | IE—0 F—0 S—≈0 | 0K | 0K | 980K |

| SAMA | Assumptions | % Risk Reduction ^(b,d) | | Total Benefit (\$) ^(h) | | Cost (\$) |
|------|-------------|-----------------------------------|-----------------|-----------------------------------|--|-----------|
| | | CDF | Population dose | Baseline (internal + external) | Baseline with uncertainty ^(c) | |

^(a) SAMAs in **bold** are potentially cost-beneficial.

^(b) Percent risk reduction values between 0.1 and 1 are shown as "<1," those having a value less than 0.1 are shown as "=0," and those shown as "0" were reported to be 0 in the ER and in response to NRC staff RAI 5.n (Gambhir, 2010).

^(c) Estimated uncertainty benefits are provided in response to NRC staff RAIs 6.j (Gambhir, 2010) and 6.j-1ii (Gambhir, 2011).

^(d) IE = internal events; F = fire events; S = seismic events.

^(e) SAMA identified and evaluated in response to NRC staff RAIs 5.l (Gambhir, 2010) and 5.l-1 and 6.j-1ii (Gambhir, 2011).

^(f) The implementation cost estimate was revised in the PSA Revision 7.1 sensitivity study (Gambhir, 2011).

^(g) SAMA AC/DC-28 reduces CCFs among the EDGs by such actions as providing separate fuel supplies, separate maintenance crews, diverse instrumentation, etc., as compared to SAMA AC/DC-29, which replaces EDG-3 with an EDG from a different manufacturer from EDG-1 and EDG-2 (EN, 2010).

^(h) The total benefit is the sum of the benefits for internal events, fire events, seismic events, and HFO events.

Table F-11. SAMA cost and benefit screening analysis for CGS sensitivity analysis (a,b)

| SAMA | Assumptions | % Risk Reduction ^(c) | | Total Benefit (\$) ^(f) | | Cost (\$) |
|--|---|---------------------------------|---------------------|-----------------------------------|---------------------------|-----------|
| | | CDF | Population Dose | Baseline (Internal + External) | Baseline With Uncertainty | |
| Increase Availability of DC Power | Increase time available to recover offsite/onsite power before RCIC is lost to 10 hours during SBO scenarios from 7 hours with DC power load-shedding and from 5 hours without load-shedding (Gambhir, 2011). | IE-1 F-0 S-0 | IE-0 F-0 S-<1 | 3.3K | 8.1K | |
| AC/DC-01—Provide additional DC battery capacity | | | | | | 1.8M |
| AC/DC-02—Replace lead-acid batteries with fuel cells | | | | | | 1.0M |
| AC/DC-03—Add a portable, diesel-driven battery charger to existing DC system | | | | | | 500K |
| Increase Availability of Onsite AC Power | In response to an NRC staff RAI, eliminate failure of EDG-1 (Gambhir, 2010). | IE-2 F-9 S-1 | IE-<1 F-7 S-2 | 88K | 230K | |
| AC/DC-10—Provide an additional DG | | | | | | 11M |
| AC/DC-15—Install a gas turbine generator | | | | | | 2.1M |
| AC/DC-16—Install tornado protection of gas turbine generator | | | | | | 2.1M |
| AC/DC-23—Develop procedures to repair or replace failed 4 kV breakers | Eliminate failures of the 4 kV breakers. | IE-5 F-1 S-0 | IE-6 F-2 S-0 | 71K | 170K | 375K |

| SAMA | Assumptions | % Risk Reduction ^(c) | | Total Benefit (\$) ^(f) | | Cost (\$) |
|---|---|---------------------------------|----------------------|-----------------------------------|---------------------------|-----------|
| | | CDF | Population Dose | Baseline (Internal + External) | Baseline With Uncertainty | |
| AC/DC-27—Install permanent hardware changes that make it possible to establish 500 kV backfeed through the main step-up transformer | In response to an NRC staff RAI, for internal and fire events, modify fault tree to include a new basic event, having a failure probability of 1.0E-02, representing the unavailability of the 500 kV power source (Gambhir, 2010). The 500 kV power source is not available in seismic events. | IE—10 F—38 S—0 | IE—9 F—37 S—0 | 420K | 1.1M | 1.7M |
| AC/DC-28 ^(e) —Reduce CCFs between EDG-3 and EDG 1/2 | CCFs between EDG-1 and EDG-3, between EDG-2 and EDG-3 and between all three EDGs are reduced by a factor of 2. | IE—<1 F—1 S—0 | IE—0 F—<1 S—<1 | 6.8K | 17K | 100K |
| AC/DC-29—Replace EDG-3 with a diesel diverse from EDG-1 and EDG-2 | Eliminate all CCFs between EDG-3 and EDGs-1/2. | IE—1 F—2 S—0 | IE—<1 F—1 S—<1 | 18K | 46K | 4.2M |
| AT-05—Add an independent boron injection system | In response to an NRC staff RAI, eliminate failure of the SLC system and all risk from seismic damage state (SDS) 40 (Gambhir, 2010). | IE—2 F—0 S—0 | IE—7 F—0 S—<1 | 41K | 100K | 800K |
| AT-07—Add a system of relief valves to prevent equipment damage from pressure spikes during an ATWS | Eliminate all CCFs of SRVs. | IE—0 F—0 S—0 | IE—0 F—0 S—0 | 0 | 0 | 1.1M |
| AT-13—Automate SLC injection in response to ATWS event | Eliminate failures of operators to initiate SLC. | IE—<1 F—0 S—0 | IE—1 F—0 S—0 | 9.7K | 23K | 660K |
| AT-14—Diversify SLC explosive valve operation | Eliminate CCFs between the SLC valves. | IE—0 F—0 S—0 | IE—0 F—0 S—0 | 0 | 0 | 370K |
| Reduce Probability of an ISLOCA | Eliminate ISLOCA events. | IE—1 F—0 S—0 | IE—3 F—0 S—0 | 20K | 49K | |
| CB-01—Install additional pressure or leak monitoring instruments for detection of ISLOCAs | | | | | | 5.6M |

| SAMA | Assumptions | % Risk Reduction ^(c) | | Total Benefit (\$) ^(f) | | Cost (\$) |
|---|--|---------------------------------|------------------------|-----------------------------------|---------------------------|----------------------|
| | | CDF | Population Dose | Baseline (Internal + External) | Baseline With Uncertainty | |
| CB-03—Increase leak testing of valves in ISLOCA paths CB-08—Revise EOPs to improve ISLOCA identification CB-09—Improve operator training on ISLOCA coping | | | | | | 400K 5.6M 5.6M |
| CC-01—Install an independent active or passive high pressure injection system | Reduce probability of failure of the HPCS system to 1.0E-09 (Gambhir, 2011). | IE-60 F-74 S-2 | IE-56 F-66 S-2 | 1.2M | 3.0M | 29M |
| CC-02—Provide an additional high pressure injection pump with independent diesel | Reduce probability of failure of the HPCS system to 1.0E-09 (Gambhir, 2011). | IE-60 F-74 S-2 | IE-56 F-66 S-2 | 1.2M | 3.0M | 5.2M |
| CC-03b—Raise RCIC backpressure trip set points | Unavailability of RCIC for failure to run events is reduced by a factor of 3. | IE-<1 F-0 S-0 | IE-0 F-0 S-0 | <1K | 1.4K | 82K |
| CC-20—Improve ECCS suction strainers | Eliminate failures of the ECCS suction strainer due to plugging. | IE-1 F-0 S-0 | IE-1 F-<1 S-0 | 7.4K | 18K | 10M |
| CP-01—Install an independent method of suppression pool cooling | eliminate failures of suppression pool cooling. | IE-33 F-54 S-1 | IE-56 F-83 S-1 | 1.0M | 2.6M | 6.0M |
| CW-02—Add redundant DC control power for pumps | In response to an NRC staff RAI, eliminate failure of control power for the ECCS pumps (Gambhir, 2010). | IE-10 F-5 S-0 | IE-13 F-(-)9 S-0 | 100K | 240K | 650K |
| Improve reliability of ECCS pumps | In response to an NRC staff RAI, essentially eliminate failure of the low-pressure ECCS pumps due to pump motor cooling dependencies on service water (Gambhir, 2011). | IE-3 F-3 S-0 | IE-1 F-(-)9 S-0 | -5.8K | -18K | |
| CW-03—Replace ECCS pump motors with air-cooled motors | | | | | | 1.1M |

| SAMA | Assumptions | % Risk Reduction ^(c) | | Total Benefit (\$) ^(f) | | Cost (\$) |
|---|--|---------------------------------|----------------------|-----------------------------------|---------------------------|-----------|
| | | CDF | Population Dose | Baseline (Internal + External) | Baseline With Uncertainty | |
| CW-04—Provide self-cooled ECCS seals | | | | | | 675K |
| CW-07—Add a service water pump | In response to an NRC staff RAI, eliminate failure of one train of service water (Gambhir, 2010). | IE-11 F-12 S-0 | IE-12 F-6 S-<1 | 190K | 480K | 6.1M |
| FR-03—Install additional transfer and isolation switches | Reduce the probability of the most risk significant hot shorts to 0. | IE-0 F-6 S-0 | IE-0 F-2 S-0 | 36K | 93K | 2.0M |
| FR-07a—Improve the fire resistance of critical cables | In response to an NRC staff RAI, eliminate fire-related failures of the containment vent (Gambhir, 2010). | IE-0 F-30 S-0 | IE-0 F-47 S-0 | 320K | 840K | 400K |
| FR-07b—Improve the fire resistance of critical cables | In response to an NRC staff RAI, eliminate hot shorts for transformer E-TR-S (Gambhir, 2010). | IE-0 F-3 S-0 | IE-0 F-4 S-0 | 31K | 81K | 100K |
| FR-08—Improve the fire resistance of cables to RHR and SW | Eliminate failure of RHR trains A and B due to a fire. | IE-0 F-56 S-0 | IE-0 F-64 S-0 | 510K | 1.3M | 1.25M |
| HV-02—Provide a redundant train or means of ventilation | In response to an NRC staff RAI, completely removed switchgear dependencies on HVAC and eliminated the loss of HVAC IEs (Gambhir, 2010). | IE-<1 F-0 S-0 | IE-<1 F-0 S-0 | 2.2K | 5.3K | 480K |
| SR-03—Modify safety-related CST | In response to an NRC staff RAI, availability of the CST is credited during seismic events (Gambhir, 2010). | IE-0 F-0 S-1 | IE-0 F-0 S-1 | 3.1K | 9.3K | 980K |
| SR-05R—Improve seismic ruggedness of MCC-7F and MCC-8F | Eliminate loss of room cooling for Division 1 and 2 switchgear rooms in a seismic event. | IE-0 F-0 S-19 | IE-0 F-0 S-0 | 57K | 170K | 150K |
| OT-08R—Install explosion protection around CGS transformers | Eliminate plant-centered LOOP and switchyard-centered LOOP. | IE-1 F-0 S-0 | IE-<1 F-0 S-0 | 9.4K | 23K | 700K |

| SAMA | Assumptions | % Risk Reduction ^(c) | | Total Benefit (\$) ^(f) | | Cost (\$) |
|--|--|---------------------------------|----------------------|-----------------------------------|---------------------------|-----------|
| | | CDF | Population Dose | Baseline (Internal + External) | Baseline With Uncertainty | |
| FL-05R—Clamp on flow instruments to certain drain lines in the control building of the radwaste building and alarm in the control room | Control building flood isolation HEPs are reduced to 1.0E-02. | IE-16 F-0 S-0 | IE-35 F-0 S-0 | 250K | 610K | 250K |
| FL-04R—Add one isolation valve in the service water, turbine SW, and FP lines in the control building area of the radwaste building | Control building flood isolation HEPs are reduced to 0.0. | IE-17 F-0 S-0 | IE-35 F-0 S-0 | 260K | 620K | 380K |
| FL-06R—Additional NDE and inspections [in the control building] | Control building flood isolation HEPs are reduced by a factor of 2. | IE-8 F-0 S-0 | IE-18 F-0 S-0 | 130K | 310K | 14K |
| CC-24R—Backfeed the HPCS system with SM-8 to provide a third power source for HPCS | Eliminate loss of HPCS due to loss of AC power (both offsite and onsite). | IE-7 F-9 S-0 | IE-7 F-13 S-0 | 170K | 420K | 105K |
| CC-25R—Enhance alternate injection reliability by including RHR, SW and fire water cross-tie in the maintenance program | Reduce the probability of failure of the subject valves to 0.0 from a probability based on a 10-year mean time between surveillance tests. | IE-1 F-1 S-0 | IE-1 F-<1 S-<1 | 12K | 29K | 13K |
| OT-07R—Increase operator training on systems and operator actions determined to be important from the PSA | Top 10 most risk-significant HEPs are reduced by a factor of 10. | IE-25 F-5 S-0 | IE-8 F-<1 S-0 | 200K | 480K | 40K |
| FW-05R—Examine the potential for operators to control RFW and avoid a reactor trip | Eliminate loss of RFW due to loss of DC power from DC Bus E-DP-S17 and reduce unavailability of DC Bus E-DP-S17 to 1.0E-09. | IE-3 F-7 S-0 | IE-2 F-4 S-0 | 72K | 180K | 29K |
| FR-09R—Install early fire detection in the following physical analysis units: R-1B, R-1D, and R-1J | Fire ignition frequencies in the most important fire areas of the reactor building are reduced by a factor of 10. | IE-0 F-15 S-0 | IE-0 F-7 S-0 | 100K | 260K | 680K |

| SAMA | Assumptions | % Risk Reduction ^(c) | | Total Benefit (\$) ^(f) | | Cost (\$) |
|---|---|---------------------------------|----------------------|-----------------------------------|---------------------------|-----------|
| | | CDF | Population Dose | Baseline (Internal + External) | Baseline With Uncertainty | |
| AT-15R—Modifications to make use of HPCS more likely for ATWS (use of auto bypass, installing throttle valve) | Reduce the HEP of failure to use HPCS during ATWS conditions to 1.0E-03. | IE—15 F—0 S—0 | IE—1 F—0 S—0 | 80K | 190K | 2.8M |
| OT-09R—For the non-LOCA IEs, credit the Z (power conversion system recovery) function | For transient initiators, eliminate tripping of MSIVs on high steam tunnel temperature. | IE—4 F—8 S—0 | IE—5 F—13 S—0 | 130K | 330K | 130K |
| FR-12R—Install early fire detection in the following physical analysis units: T-1A, T-12, T-1C, and T-1D | Fire ignition frequencies in the most important fire areas of the turbine building are reduced by a factor of 10. | IE—0 F—12 S—0 | IE—0 F—12 S—0 | 110K | 270K | 725K |
| FR-11R—Install early fire detection in the following analysis units: RC-02, RC-03, RC-04, RC-05, RC-07, RC-08, RC-11, RC-13, RC-14, and RC-1A | Fire ignition frequencies in the most important fire areas of the control building are reduced by a factor of 10. | IE—0 F—56 S—0 | IE—0 F—63 S—0 | 510K | 1.3M | 1.0M |
| FR-10R—Install early fire detection in the main control room: RC-10 | Fire ignition frequencies in the main control room are reduced by a factor of 10. | IE—0 F—1 S—0 | IE—0 F—2 S—0 | 14K | 36K | 535K |
| FL-07R—Protect the HPCS from flooding that results from ISLOCA events | Reduce the probability of failure of HPCS caused by flooding due to ISLOCA to 0.0. | IE—0 F—0 S—0 | IE—2 F—0 S—0 | 11K | 26K | 1.05M |
| AC/DC-30R ^(g) —Provide an additional DG diverse from DG-1 and DG-2 | Eliminate failure of EDG-2. | IE—<1 F—15 S—2 | IE—<1 F—12 S—2 | 130K | 350K | 10M |
| CC-26R—Install hard pipe from diesel fire pump to vessel | Reduce HEPs for failure to align the diesel fire pump to the RPV to 0.0. | IE—<1 F—0 S—0 | IE—<1 F—1 S—0 | 5.7K | 14K | 710K |

| SAMA | Assumptions | % Risk Reduction ^(c) | | Total Benefit (\$) ^(f) | | |
|--|---|---------------------------------|----------------------|-----------------------------------|---------------------------|-----------|
| | | CDF | Population Dose | Baseline (Internal + External) | Baseline With Uncertainty | Cost (\$) |
| OT-10R—Increase fire pump house building integrity to withstand higher winds so the fire system will be capable of withstanding a severe weather event | Reduce the probability of failure of the pump house to 0.0 from a probability of 1.37E-04 for a high wind during a plant-initiating event and reduce the probability of a high wind given LOOP from a probability of 1.0. | IE—<1 F—0 S—0 | IE—<1 F—0 S—0 | 1.5K | 3.5K | 735K |
| FW-04—Add a motor-driven FW pump | Reduce the probability of failure of RFW by a factor of 1,000 and eliminate dependencies between FW trains. Reduce the loss of FW initiating event frequency by a factor of 1,000. | IE—40 F—25 S—0 | IE—42 F—26 S—0 | 620K | 1.5M | 10M |
| CB-10R—Provide additional NDE and inspections of MS pipe in turbine building | Reduce MS pipe break outside containment initiating event frequencies by a factor of 2.0. | IE—2 F—0 S—0 | IE—2 F—0 S—0 | 20K | 48K | 125K |

^(a) SAMAs in **bold** are potentially cost-beneficial.

^(b) Screening analysis assumptions and results, unless otherwise noted, are provided in the PSA Revision 7.1 sensitivity study (Gambhir, 2011).

^(c) IE = internal events; F = fire events; S = seismic events

^(d) Revised risk reduction and benefit results for this SAMA are provided in response to followup NRC staff RAI 8 (Swank, 2011).

^(e) SAMA AC/DC-28 reduces CCFs among the EDGs by such actions as: providing separate fuel supplies, separate maintenance crews, diverse instrumentation, etc., as compared to SAMA AC/DC-29, which replaces EDG-3 with an EDG from a different manufacturer from EDG-1 and EDG-2 (EN, 2010).

^(f) The total benefit is the sum of the benefits for internal events, fire events, seismic events, and HFO events.

1 F.5 Cost Impacts of Candidate Plant Improvements

2 Energy Northwest estimated the costs of implementing the candidate SAMAs through the
3 development of site-specific cost estimates and use of other licensees' estimates for similar
4 improvements. The cost estimates used from other SAMA analyses were adjusted for inflation.
5 In response to an NRC staff RAI, Energy Northwest clarified that the site-specific cost estimates
6 conservatively did not include contingency costs for unforeseen implementation obstacles, the
7 cost of replacement power during extended outages required to implement the modifications, or
8 the costs associated with recurring training, maintenance, and surveillance (Gambhir, 2010).

9 The NRC staff requested more information on the process Energy Northwest used to develop
10 the site-specific cost estimates and the level of detail used to develop these estimates
11 (Doyle, 2010a). Energy Northwest responded to the RAI by explaining that the cost estimates
12 were developed by a team of three Energy Northwest and consultant personnel having over 50
13 years of cumulative experience at CGS and over 90 years of collective experience in the
14 nuclear industry in areas of electrical and mechanical engineering, field engineering, design
15 engineering, construction management, operations and maintenance support, licensing, and
16 PSA (Gambhir, 2010). The team consulted with relevant plant experts in the conceptual
17 development of each SAMA and used an interview process to develop the implementation
18 costs. The experts interviewed had expertise in areas such as FP, operations and maintenance
19 procedures, operations, training, design engineering, and system engineering. Cost elements
20 considered in the development of the cost estimates generally included material, labor,
21 engineering, licensing, training, procedures, and surveillance testing. The team also reviewed
22 the cost estimates from published documents such as other SAMA analyses. Energy Northwest
23 noted that if the estimated implementation cost was sufficiently greater than the maximum
24 estimated benefit, a more detailed cost estimate was not developed. Energy Northwest
25 emphasized that team focused on underestimating the actual cost of implementation in order to
26 ensure that the estimates used in the cost-benefit evaluation were conservative. Based on the
27 use of personnel having significant nuclear plant engineering and operating experience, the
28 NRC staff considers the process Energy Northwest used to develop the site-specific cost
29 estimates reasonable.

30 The NRC staff reviewed the bases for the applicant's cost estimates (presented in Table E.11-6
31 of Attachment E to the ER). For certain improvements, the NRC staff also compared the cost
32 estimates to estimates developed elsewhere for similar improvements, including estimates
33 developed as part of other licensees' analyses of SAMAs for operating reactors. The NRC staff
34 noted that the estimated cost of \$375,000 for SAMA AC/DC-23, "develop procedures to repair
35 or replace failed 4 kV breakers," is high for what is described as procedure development (Doyle,
36 2010a). In response to the RAI, Energy Northwest clarified that this SAMA assumes that a
37 4,160 V breaker failure could be repaired within the necessary repair time if roll-in spares were
38 staged and ready for replacing the failed breaker. Therefore, the estimated implementation cost
39 includes the cost of eight spare breakers identified in the RAI response, procedure
40 development, engineering evaluation, and staging restraints (Gambhir, 2010). Energy
41 Northwest further noted that each breaker is estimated to cost \$35,000 based on the current
42 manufacturer's cost for a typical Class 1E 4,160 V, 1,200 amp breaker, for a total of \$280,000
43 for procurement of the eight breakers. Installation of staging restraints and setup of the
44 breakers is estimated to cost \$45,000 for three different locations where the breakers are
45 located, engineering evaluation and documentation is estimated to cost \$30,000, and procedure
46 development is estimated to cost \$20,000. The NRC staff considers the estimated cost for CGS
47 to be reasonable and acceptable for purposes of the SAMA evaluation.

Appendix F

1 The NRC staff noted that the implementation cost for SAMA CC-03b, “raise RCIC backpressure
2 trip set points,” was estimated to be \$82,000 and \$160,000 in different sections of the ER and
3 that both estimates seem high for what appears to be a minor software change (Doyle, 2010a).
4 In response to the RAI, Energy Northwest clarified that the estimated implementation cost for
5 this SAMA is \$82,000, that implementing the SAMA requires an amendment to the CGS
6 technical specifications, and that the cost estimate includes costs for licensing and NRC review
7 in addition to engineering, maintenance, training, and procedures. Based on this additional
8 information, the NRC staff considers the estimated cost to be reasonable and acceptable for
9 purposes of the SAMA evaluation.

10 As indicated in Section F.3.2., NRC staff asked the applicant to provide more detailed
11 descriptions of the modifications and cost estimates for several of the Phase II SAMA
12 candidates (Doyle, 2010a). In response to the RAI, Energy Northwest provided more detail on
13 both the modification and the estimated implementation costs for the following SAMAs
14 (Gambhir, 2010):

- 15 • SAMA AC/DC-27, “install permanent hardware changes that make it possible to
16 establish 500 kV backfeed through the main step-up transformer”
- 17 • SAMA CW-04, “provide self-cooled ECCS seals”
- 18 • SAMA FR-07a, “improve the fire resistance of cables to the containment vent valve”
- 19 • SAMA FR-07b, “improve the fire resistance of cables to transformer E-TR-S”
- 20 • SAMA HV-02, “provide a redundant train or means of ventilation”

21 The NRC staff reviewed the cost estimates for SAMAs AC/DC-27, CW-04, and HV-02 and
22 considers them to be reasonable and acceptable for purposes of the SAMA evaluation.

23 Relative to SAMAs FR-07a and FR-07b, the NRC staff noted that the cost estimates were
24 based on replacing the existing cables with metal-sheathed cables and asked Energy Northwest
25 to justify the use of metal-sheathed cables for electrical failure modes that may not be prevented
26 by metal-sheathed cables (Doyle, 2010c). In response to the RAI, Energy Northwest clarified
27 that basing the cost estimate for these SAMAs on metal-jacketed (armored) cable was not
28 intended to imply that armored cable could be used to mitigate all spurious operations. The cost
29 of armored cabling was used because it is among the least costly of a variety of options
30 available to mitigate fire-induced spurious operations. Therefore, using it is conservative for
31 purposes of the SAMA cost-benefit evaluation, and Energy Northwest has actual cost
32 information from installation of armored cable from which to base the cost estimate
33 (Gambhir, 2011). Energy Northwest further explained that during implementation of these
34 SAMAs, specific protective schemes applicable to the circuit failure mode(s) of concern will be
35 selected. Since the cost of armored cabling is a least cost option for protecting against
36 fire-induced spurious operations, the NRC staff considers the cost estimates for these SAMAs
37 reasonable and acceptable for purposes of the SAMA evaluation.

38 As indicated in Section F.2.1, in response to an NRC staff RAI, Energy Northwest provided the
39 results of a sensitivity study using PSA model Revision 7.1 (Gambhir, 2011). In the sensitivity
40 study, Energy Northwest noted that the estimated implementation costs for the following Phase I
41 SAMAs that were based on industry estimates in the ER were revised in the sensitivity study to
42 reflect site-specific cost estimates:

- 43 • SAMA AT-10, “install an ATWS sized filtered containment vent to remove decay heat”

- 1 • SAMA CP-12, “install a filtered containment vent to remove decay heat”
- 2 • SAMA CP-22, “increase depth of the concrete basemat or use an alternate concrete
- 3 material to ensure melt-through does not occur”
- 4 • SAMA CP-24, “construct a building to be connected to primary/secondary containment
- 5 and maintained at a vacuum”

6 Energy Northwest also noted that a cost estimate was developed for Phase I SAMA CC-12,
7 “add a diverse low pressure injection system,” screened in the ER on very low benefit, using a
8 cost estimate developed by another licensee for a similar improvement. The bases for the
9 revised and new cost estimates are provided in Section 4.3 of the sensitivity study
10 (Gambhir, 2011). The NRC staff reviewed the cost estimates for these SAMAs and considers
11 them to be reasonable and acceptable for purposes of the SAMA evaluation.

12 The estimated costs for SAMA CB-08, “revise EOPs to improve ISLOCA identification,” and
13 SAMA CB-09, “improve operator training on ISLOCA coping,” were reported in the ER to be
14 \$20,000 and \$30,000, respectively. In the sensitivity study, Energy Northwest clarified that
15 these cost estimates are in addition to the estimated implementation cost for the ISLOCA
16 detection instrumentation provided for in SAMA CB-01, “install additional pressure or leak
17 monitoring instruments for detection of ISLOCA paths” (Gambhir, 2011).

18 The NRC staff concludes that the cost estimates provided by Energy Northwest are sufficient
19 and appropriate for use in the SAMA evaluation.

20 **F.6 Cost-Benefit Comparison**

21 CGS cost-benefit analysis and the NRC staff’s review are described in the following sections.

22 **F.6.1 CGS’s Evaluation**

23 The methodology used by Energy Northwest was based primarily on NRC’s guidance for
24 performing cost-benefit analysis, i.e., NUREG/BR-0184, “Regulatory Analysis Technical
25 Evaluation Handbook” (NRC, 1997a). The guidance involves determining the net value for each
26 SAMA according to the following formula:

27 Net Value = (APE + AOC + AOE + AOSC) - COE where:

28 APE = present value of averted public exposure (\$)

29 AOC = present value of averted offsite property damage costs (\$)

30 AOE = present value of averted occupational exposure costs (\$)

31 AOSC = present value of averted onsite costs (\$)

32 COE = cost of enhancement (\$)

33 If the net value of a SAMA is negative, the cost of implementing the SAMA is larger than the
34 benefit associated with the SAMA, and it is not considered cost-beneficial. Energy Northwest’s
35 derivation of each of the associated costs is summarized below.

36 NUREG/BR-0058 has recently been revised to reflect the NRC’s policy on discount rates.
37 Revision 4 of NUREG/BR-0058 states that two sets of estimates should be developed—one at
38 3 percent and one at 7 percent (NRC, 2004a). Energy Northwest provided a base set of results

Appendix F

1 using the 7 percent discount rate and a sensitivity study using the 3 percent discount rate
2 (EN, 2010). Energy Northwest also provided similar results for the sensitivity study discussed in
3 Section F.2.1 (Gambhir, 2011).

4 Averted Public Exposure (APE) Costs

5 The APE costs were calculated using the following formula:

$$\begin{aligned} 6 \quad \text{APE} &= \text{Annual reduction in public exposure } (\Delta \text{ person-rem per year}) \\ 7 \quad &\quad \times \text{monetary equivalent of unit dose } (\$2,000 \text{ per person-rem}) \\ 8 \quad &\quad \times \text{present value conversion factor } (13.05 \text{ based on a 35-year period with a} \\ 9 \quad &\quad \text{7-percent discount rate}) \end{aligned}$$

10 As stated in NUREG/BR-0184 (NRC, 1997a), it is important to note that the monetary value of
11 the public health risk after discounting does not represent the expected reduction in public
12 health risk due to a single accident. Rather, it is the present value of a stream of potential
13 losses extending over the remaining lifetime (in this case, the renewal period) of the facility.
14 Thus, it reflects the expected annual loss due to a single accident, the possibility that such an
15 accident could occur at any time over the renewal period, and the effect of discounting these
16 potential future losses to present value. For the purposes of initial screening, which assumes
17 elimination of all severe accidents due to internal, fire, and seismic events, Energy Northwest
18 calculated an APE of approximately \$96,000, \$224,000, and \$176,000, respectively, for the
19 35-year time period to expiration of the renewed CGS license (EN, 2010). For the sensitivity
20 analysis using PSA model Revision 7.1, Energy Northwest calculated an APE of approximately
21 \$143,000, \$234,000, and \$154,000 due to internal, fire, and seismic events, respectively
22 (Gambhir, 2011). The NRC staff notes that the benefit evaluation need only to be estimated for
23 the 20-year license renewal period and therefore Energy Northwest's evaluation for CGS is
24 conservative.

25 Averted Offsite Property Damage Costs (AOC)

26 The AOCs were calculated using the following formula:

$$\begin{aligned} 27 \quad \text{AOC} &= \text{Annual CDF reduction} \\ 28 \quad &\quad \times \text{offsite economic costs associated with a severe accident (on a per-event basis)} \\ 29 \quad &\quad \times \text{present value conversion factor} \end{aligned}$$

30 For the purposes of initial screening, which assumes all severe accidents due to internal, fire,
31 and seismic events are eliminated, Energy Northwest calculated an annual offsite economic risk
32 of about \$6,100, \$15,500, and \$11,100, respectively, based on the Level 3 risk analysis. This
33 results in a discounted value of approximately \$80,000, \$203,000, and \$145,000 for internal,
34 fire, and seismic events, respectively, for the 35-year time period to expiration of the renewed
35 CGS license (EN, 2010). For the sensitivity analysis using PSA model Revision 7.1, Energy
36 Northwest calculated an annual offsite economic risk of about \$7,100, \$11,200, and \$8,400 and
37 an AOC of approximately \$92,000, \$146,000, and \$110,000 due to internal, fire, and seismic
38 events, respectively (Gambhir, 2011).

39 Averted Occupational Exposure (AOE) Costs

40 The AOE costs were calculated using the following formula:

1 AOE = Annual CDF reduction
 2 x occupational exposure per core damage event
 3 x monetary equivalent of unit dose
 4 x present value conversion factor

5 Energy Northwest derived the values for averted occupational exposure from information
 6 provided in Section 5.7.3 of the Regulatory Analysis Handbook (NRC, 1997a). Best estimate
 7 values provided for immediate occupational dose (3,300 person-rem) and long-term
 8 occupational dose (20,000 person-rem over a 10-year cleanup period) were used. The present
 9 value of these doses was calculated using the equations provided in the handbook in
 10 conjunction with a monetary equivalent of unit dose of \$2,000 per person-rem, a real discount
 11 rate of 7 percent, and a time period of 35 years to represent the period to expiration of the
 12 renewed CGS license. For the purposes of initial screening, which assumes all severe
 13 accidents due to internal, fire, and seismic events are eliminated, Energy Northwest calculated
 14 an AOE of approximately \$2,200, \$3,400, and \$2,400, respectively, for the 35-year time period
 15 to expiration of the renewed CGS license (EN, 2010). For the sensitivity analysis using PSA
 16 model Revision 7.1, Energy Northwest calculated an AOE of approximately \$3,500, \$6,300, and
 17 \$2,200 due to internal, fire, and seismic events, respectively (Gambhir, 2011).

18 Averted Onsite Costs (AOSC)

19 AOSCs include averted cleanup and decontamination costs and averted power replacement
 20 costs. Repair and refurbishment costs are considered for recoverable accidents only and not
 21 for severe accidents. Energy Northwest derived the values for AOSC based on information
 22 provided in Section 5.7.6 of NUREG/BR-0184, the Regulatory Analysis Handbook
 23 (NRC, 1997a).

24 Energy Northwest divided this cost element into two parts—the onsite cleanup and
 25 decontamination cost, also commonly referred to as averted cleanup and decontamination
 26 costs, and the replacement power cost (RPC).

27 Averted cleanup and decontamination costs (ACC) were calculated using the following formula:

28 ACC = Annual CDF reduction
 29 x present value of cleanup costs per core damage event
 30 x present value conversion factor

31 The total cost of cleanup and decontamination subsequent to a severe accident is estimated in
 32 the regulatory analysis handbook to be \$1.5x10⁹ (undiscounted). This value was converted to
 33 present costs over a 10-year cleanup period and integrated over the term of the proposed
 34 expiration of the renewed CGS license. For the purposes of initial screening, which assumes all
 35 severe accidents due to internal, fire, and seismic events are eliminated, Energy Northwest
 36 calculated an ACC of approximately \$67,500, \$104,000, and \$73,900, respectively, for the
 37 35-year time period to expiration of the renewed CGS license. For the sensitivity analysis using
 38 PSA model Revision 7.1, Energy Northwest calculated an ACC of approximately \$105,600,
 39 \$193,000, and \$68,400 due to internal, fire, and seismic events, respectively (Gambhir, 2011).

40 Long-term RPCs were calculated using the following formula:

41 RPC = Annual CDF reduction

Appendix F

- 1 x present value of replacement power for a single event
- 2 x factor to account for remaining service years for which replacement power is
- 3 required
- 4 x reactor power scaling factor

5 Energy Northwest based its calculations on the rated CGS net electric output of
6 1,107 megawatt-electric (MWe) per unit and scaled up from the 910 MWe reference plant in
7 NUREG/BR-0184 (NRC, 1997). Therefore, Energy Northwest applied a power scaling factor of
8 1,107/910 to determine the RPCs. For the purposes of initial screening, which assumes all
9 severe accidents due to internal, fire, and seismic events are eliminated, Energy Northwest
10 calculated an RPC of approximately \$99,600, \$154,000, and 109,000, respectively, for the
11 35-year time period to expiration of the renewed CGS license. For the sensitivity analysis using
12 PSA model Revision 7.1, Energy Northwest calculated an RPC of approximately \$155,700,
13 \$284,000, and \$101,000 due to internal, fire, and seismic events, respectively (Gambhir, 2011).

14 Using the results for ACC and RPC, Energy Northwest calculated an AOSC of approximately
15 \$167,000, \$258,000, and \$183,000 for internal, fire, and seismic events, respectively, for the
16 35-year time period to expiration of the renewed CGS license (EN, 2010). For the sensitivity
17 analysis using PSA model Revision 7.1, Energy Northwest calculated an AOSC of
18 approximately \$261,000, \$477,000, and \$169,000 due to internal, fire, and seismic events,
19 respectively (Gambhir, 2011).

20 Using the above equations, Energy Northwest estimated the total present dollar value
21 equivalent associated with eliminating severe accidents from internal, fire, and seismic events at
22 CGS to be about \$346,000, \$689,000, and \$506,000, respectively, for a total of \$1,541,000.
23 Use of an internal events multiplier of 2.0 to account for other external events (i.e., high winds,
24 external floods, etc.) increases the value to \$1,887,000. This represents the dollar value
25 associated with eliminating all internal and external event severe accident risk at CGS, and is
26 also referred to as the modified maximum averted cost risk.

27 For the sensitivity analysis using PSA model Revision 7.1, Energy Northwest estimated the total
28 present dollar value equivalent associated with eliminating severe accidents from internal, fire,
29 and seismic events at CGS to be about \$500,000, \$863,000, and \$436,000, respectively, for a
30 total of \$1.8 million (Gambhir, 2011). Use of an internal events multiplier of 2.0 to account for
31 other external events (i.e., high winds, external floods, etc.) increases the value to \$2.3 million.

32 Energy Northwest's Results

33 If the implementation costs for a candidate SAMA exceeded the calculated benefit, the SAMA
34 was considered not to be cost-beneficial. In the baseline analysis contained in the ER (using a
35 7 percent discount rate), Energy Northwest identified no potentially cost-beneficial SAMAs.
36 Based on a sensitivity analysis using a 3 percent discount rate, three SAMA candidates were
37 determined to be potentially cost-beneficial. The potentially cost-beneficial SAMAs are as
38 follows:

- 39 • SAMA AC/DC-28, "reduce CCFs between EDG-3 and EDG 1/2"
- 40 • SAMA FR-07a, "improve the fire resistance of cables to the containment vent valve"
- 41 • SAMA FR-07b, "improve the fire resistance of cables to transformer E-TR-S"

42 The potentially cost-beneficial SAMAs, and Energy Northwest's plans for further evaluation of
43 these SAMAs are discussed in more detail in Section F.6.2.

1 F.6.2 Review of CGS's Cost-Benefit Evaluation

2 The cost-benefit analysis performed by Energy Northwest was based primarily on
3 NUREG/BR-0184 (NRC, 1997a) and discount rate guidelines in NUREG/BR-0058 (NRC, 2004),
4 and it was executed consistent with this guidance.

5 The risk reduction benefits associated with internal, fire, and seismic events were separately
6 estimated by Energy Northwest using the internal events, fire events, and seismic events PSA
7 models, respectively. Energy Northwest accounted for the potential risk reduction benefits
8 associated with HFO events by assuming that the contribution from HFO events was the same
9 as that from internal events. The estimated SAMA benefits for internal events, fire events,
10 seismic events, and HFO events were then summed to provide an overall benefit. No SAMAs
11 were determined to be potentially cost-beneficial from this evaluation.

12 Energy Northwest provided the assumptions and results of sensitivity analyses, including the
13 following:

- 14 • RPC is 20 percent of the baseline RPC (Gambhir, 2010)
- 15 • use of 3 percent and 10 percent discount rates
- 16 • use of 14,000 person-rem for short term dose and 30,000 person-rem for long term
17 doses
- 18 • use of an onsite cleanup and decontamination cost of \$2 billion
- 19 • escalating the annual RPC to 2008 dollars by an average annual inflation rate of
20 4.1 percent (Gambhir, 2010)
- 21 • variations in MACCS2 input parameters (as discussed in Section F.2.2)

22 The results of the sensitivity case using a 3 percent discount rate resulted in three SAMAs
23 (SAMAs AC/DC-28, FR-07a, and FR-07b, as described above) becoming potentially
24 cost-beneficial (EN, 2010). Although not cost-beneficial in the baseline analysis, Energy
25 Northwest committed to consider implementation of these three SAMAs through normal CGS
26 processes for evaluating possible changes to the plant (EN, 2010).

27 The NRC staff noted that the ER states that the net and gross electrical power outputs for CGS
28 are 1,190 MWe and 1,230 MWe, respectively, while Energy Northwest used a rated electrical
29 power of 1,107 MWe in estimating RPCs. The staff requested that Energy Northwest provide
30 the rationale for using 1,107 MWe in the SAMA analysis and to assess the sensitivity of the
31 SAMA analysis results to this assumption (Doyle, 2010a). In response to the RAI, Energy
32 Northwest clarified that 1,107 MWe represents a capacity factor of 93 percent of the net
33 electrical output of 1,190 MWe (Gambhir, 2010).¹ Energy Northwest also provided the results of
34 a sensitivity analysis using 1,190 MWe in estimating RPCs and determined that this change in
35 assumption does not impact the conclusions of the SAMA analysis (i.e., none of the SAMAs
36 previously determined to not be cost-beneficial became cost-beneficial).

37 As indicated in Section F.3.2, in response to an NRC staff RAI, Energy Northwest identified
38 SAMA FR-08, "improve the fire resistance of cables to RHR and SW," to provide additional

¹ Crediting the reduction in electrical power level due to capacity factor, i.e., $1,190 \text{ MWe} \times 0.93 = 1,107 \text{ MWe}$, is atypical for SAMA analyses. However, Energy Northwest provided the sensitivity analysis using 1,190 MWe to indicate the reduction does not impact conclusions.

Appendix F

1 protection from MSOs in auto initiation circuits of RHR and service water (Gambhir, 2010).
2 Energy Northwest provided a Phase II evaluation of this SAMA (Gambhir, 2010). Energy
3 Northwest's analysis (using a 7 percent discount rate) determined that this SAMA candidate
4 was not cost beneficial in the baseline analysis.

5 As indicated in Section F.2.1, in response to an NRC staff RAI, Energy Northwest provided the
6 results of a sensitivity study using PSA model Revision 7.1 (Gambhir, 2011). Energy Northwest
7 provided a Phase II evaluation of the Phase II SAMAs using PSA model Revision 7.1. Also
8 included in this sensitivity study was SAMA FR-08. Energy Northwest's analysis (using a
9 7 percent discount rate) determined that none of the SAMAs were cost-beneficial in the baseline
10 sensitivity analysis.

11 As indicated in Section F.3.2, in response to NRC staff RAIs, Energy Northwest's review of the
12 internal and fire basic events importance lists for PSA model Revision 7.1 resulted in the
13 identification of the following additional SAMAs candidates (Gambhir, 2010), (Gambhir, 2011):

- 14 • SAMA AT-15R, "install modifications to make use of HPCS more likely for ATWS"
- 15 • SAMA FL-07R, "protect the HPCS from flooding resulting from ISLOCA events"
- 16 • SAMA OT-09R, "for the non-LOCA initiating events, credit the Z (power conversion
17 system recovery) function"
- 18 • SAMA CB-10R, "provide additional NDE and inspections of MS piping in Turbine
19 Building"
- 20 • SAMA FR-09R, "install early detection for FR1J (physical analysis unit R-1J) and FR1D
21 (physical analysis unit R-1D)"
- 22 • SAMA FR-10R, "install early detection in the Control Room (RC-10)"
- 23 • SAMA FR-11R, "install early detection for FW14 (analysis unit RC-14), FW04 (analysis
24 unit RC-04), FW11 (analysis unit RC-11), FW03 (analysis unit RC-03), FW08 (analysis
25 unit RC-08), FW05 (analysis unit RC-05), FW02 (analysis unit RC-02), FW13 (analysis
26 unit RC-13), and FW1A (analysis unit RC-1A)"
- 27 • SAMA FR-12R, "install early detection for FT1A (physical analysis unit T-1A) and FT12
28 (physical analysis unit T-12)"
- 29 • SAMA AC/DC-30R, "provide an additional diesel generator (DG) diverse from DG-1 and
30 DG-2"

31 Energy Northwest provided a Phase II evaluation of these SAMAs in the PSA model
32 Revision 7.1 sensitivity study (Gambhir, 2011). Energy Northwest's analysis (using a 7 percent
33 discount rate) determined that SAMA OT-09R was potentially cost-beneficial in the baseline
34 sensitivity analysis.

35 As indicated in Section F.3.2, in response to an NRC staff RAI, Energy Northwest's review of
36 the Phase II SAMAs from prior SAMA analyses for 12 General Electric BWR sites resulted in
37 the identification of the following additional SAMA candidates (Gambhir, 2010),
38 (Gambhir, 2011):

- 39 • SAMA FW-05R, "examine the potential for operators to control RFW and avoid a reactor
40 trip"

- 1 • SAMA FL-04R, “install one isolation valve in each of standby SW, TSW, and FP lines in
2 the Control Building area of the Radwaste Building to facilitate rapid isolation by the
3 operators upon receipt of a high flow alarm”
- 4 • SAMA FL-05R, “install three clamp-on flow instruments to certain drain lines in the
5 Control Building area of the Radwaste Building and alarm in the Control Room”
- 6 • SAMA FL-06R, “perform additional NDE inspections to the three lines identified in SAMA
7 FL-04R to verify that degradation is not occurring in these lines”
- 8 • SAMA CC-24R, “backfeed the HPCS system with [emergency bus] SM-8 to provide a
9 third power source for HPCS”
- 10 • SAMA CC-25R, “enhance alternate injection reliability by including residual heat removal
11 service water and fire water crosstie in maintenance program”
- 12 • SAMA CC-26R, “install hard pipe from diesel fire pump to vessel”
- 13 • SAMA OT-07R, “increase operator training on systems and operator actions determined
14 to be important from the PSA”
- 15 • SAMA OT-08R, “install explosion protection around CGS transformers”
- 16 • SAMA OT-10R, “increase fire pump house building integrity to withstand higher winds so
17 the fire system will be capable of withstanding a severe weather event”

18 Energy Northwest provided a Phase II evaluation of each of these SAMAs in the PSA model
19 Revision 7.1 sensitivity study (Gambhir, 2011). Energy Northwest’s analysis (using a 7 percent
20 discount rate) determined that SAMAs FW-05R, FL-05R, FL-06R, CC-24R, and OT-07R were
21 potentially cost beneficial in the baseline sensitivity analysis.

22 As indicated in Section F.3.2, in response to an NRC staff RAI, Energy Northwest identified
23 SAMA SR-05R, “improve seismic ruggedness of MCC-7F and MCC-8F,” to address a seismic
24 improvement identified in the IPEEE (Gambhir, 2010). Energy Northwest provided a Phase II
25 evaluation of this SAMA in the PSA model Revision 7.1 sensitivity study (Gambhir, 2011).
26 Energy Northwest’s analysis (using a 7 percent discount rate) determined that this SAMA
27 candidate was not cost-beneficial in the baseline sensitivity analysis.

28 Energy Northwest did not provide in the ER an assessment of the impact on the SAMA
29 evaluation of CDF uncertainties based on their assumption that there were already a large
30 number of conservative assumptions and inputs included in the baseline evaluation, which are
31 delineated in Section E.12 of the ER. The NRC staff noted that this is not consistent with the
32 guidance in NEI 05-01 and requested Energy Northwest provide an assessment of the impact of
33 CDF uncertainties on the SAMA analysis (Doyle, 2010a), (Doyle, 2010c). In response to the
34 RAI, Energy Northwest presents the results of an uncertainty analysis of the internal, fire, and
35 seismic event CDFs for PSA model Revision 6.2, which indicates that the 95th percentile value
36 is a factor of 2.7, 3.1, and 3.2, respectively, times the corresponding point estimate CDFs for
37 CGS (Gambhir, 2010). Energy Northwest considered whether any additional Phase II SAMAs
38 might be cost-beneficial if the benefits from internal events and other external events were
39 increased by a factor of 2.7, if the benefits from fire events were increased by a factor of 3.1,
40 and if the benefits from seismic events were increased by a factor of 3.2. SAMA FR-08
41 identified in response to an NRC staff RAI and described above was included in this uncertainty
42 analysis. Energy Northwest’s analysis (using a 7 percent discount rate) determined that
43 SAMAs CC-03b, HV-02, and FR-08 are potentially cost-beneficial (Gambhir, 2011). SAMAs

Appendix F

1 AC/DC-28, FR-07a, and FR-07b, which were previously determined to be cost-beneficial in the
2 3 percent sensitivity case, were also determined to be cost-beneficial in the uncertainty analysis.

3 The NRC staff noted that Energy Northwest's CDF uncertainty analysis did not reconsider
4 Phase I SAMAs that were screened on very low benefit or excessive implementation cost and
5 asked Energy Northwest to reconsider these screened Phase I SAMAs based on their potential
6 benefit from using the 95th percentile CDF factors (Doyle, 2010b). In response to this RAI,
7 Energy Northwest reconsidered the Phase I SAMAs screened on very low benefit or excessive
8 implementation cost as part of the PSA model Revision 7.1 sensitivity study discussed in
9 Section F.2.2 (Gambhir, 2011). In this sensitivity study, Energy Northwest presents the results
10 of an uncertainty analysis of the PSA model Revision 7.1 internal, fire, and seismic event CDFs,
11 which indicates that the 95th percentile value is a factor of 2.4, 2.6, and 3.0, respectively, times
12 the corresponding point estimate CDFs for CGS. Energy Northwest considered whether any
13 additional Phase I SAMAs might be retained for further analysis based on the RRW benefit of
14 each screened SAMA and the 95th percentile CDF factors. The RRW benefit for each SAMA
15 was calculated as follows:

$$\begin{aligned} 16 \quad \text{RRW Benefit} = & \quad \text{total present dollar value equivalent associated with completely} \\ 17 & \quad \text{eliminating severe accidents from internal, fire, or seismic events} \\ 18 & \quad \text{at CGS} \\ 19 & \quad \times (1 - 1/\text{RRW}) \end{aligned}$$

20 For each SAMA, a CDF and LERF RRW was determined based on its improvement of the
21 specific hazard or hazards that are affected. The CDF and LERF RRW benefit for each hazard
22 was calculated using the above equation. The RRW benefits from internal events were
23 increased by a factor of 2.4, the RRW benefits from fire events were increased by a factor of
24 2.6, the RRW benefits from seismic events were increased by a factor of 3.0, and the RRW
25 benefits from other external events were assumed to be equal to the RRW benefits from internal
26 events after being increased by the factor of 2.4. The total of the CDF and LERF RRW benefits
27 with uncertainty factors applied (using a 7 percent discount rate) were summed and, if the result
28 was greater than the estimated implementation cost of the SAMA, it was retained for further
29 analysis. One such Phase I SAMA, as indicated in Section F.3.2, was identified—SAMA
30 FW-04, "add a motor-driven feedwater pump." The specific rationale for screening the other
31 Phase I SAMA candidates is provided in Tables A-15 and A-16 of the sensitivity study
32 (Gambhir, 2011). Several of the Phase I SAMA candidates originally screened in the ER on
33 very low benefit or excessive implementation cost were screened by Energy Northwest in the
34 sensitivity study as not applicable to CGS or already implemented at CGS after further
35 consideration of the SAMA. The NRC staff noted that several of the Phase I SAMAs were
36 screened based on dividing the total estimated benefit by the number of trains or components
37 and asked Energy Northwest to re-assess the screening of these SAMAs by considering the
38 entire risk reduction (Doyle, 2011). Energy Northwest responded to the RAI by providing an
39 estimated implementation cost to address the entire risk reduction potential for each of these
40 SAMAs and determined that in each of these cases these SAMAs would continue to be
41 screened on excessive implementation cost (Swank, 2011). Based on this additional
42 information, the NRC staff considers the applicant's rationale for screening the other Phase I
43 SAMAs from further consideration in the Phase II evaluation to be reasonable.

44 In the sensitivity study, Energy Northwest also presents the results of an uncertainty analysis in
45 which the estimated benefits from internal events and other external events, fire events, and
46 seismic events were increased by a factor of 2.4, 2.6, and 3.0, respectively. The additional
47 Phase I SAMA, SAMA FW-04, as described above, was included in this sensitivity analysis.

1 Also included in this sensitivity analysis were the additional SAMAs identified in response to
2 NRC staff RAIs, as described above. Four SAMAs became cost-beneficial in Energy
3 Northwest's analysis (SAMAs SR-05R, FL-04R, CC-25R, and FR-11R, as described above).
4 SAMAs FR-07a and FR-08, which were previously determined to be cost-beneficial, were also
5 determined to be cost-beneficial in the uncertainty analysis.

6 In the sensitivity study, Energy Northwest provided the assumptions and results of sensitivity
7 analysis assuming use of 3 percent (Gambhir, 2011). This analysis did not identify any
8 additional potentially cost-beneficial SAMAs.

9 The NRC staff observed that the SAMA candidates that were screened in the Phase I
10 evaluation by being subsumed could potentially have a lower implementation cost than the
11 SAMA candidate in which it was subsumed. The staff requested that Energy Northwest provide
12 a Phase II evaluation of these SAMAs (Doyle, 2010a), (Doyle, 2010c). In response to the RAI,
13 Energy Northwest provided the estimated benefits and implementation costs for SAMA
14 AC/DC-02, "replace lead-acid batteries with fuel cells," SAMA AC/DC-03, "add a portable
15 diesel-driven battery charger to existing DC system," SAMA AC/DC-15, "install a gas turbine
16 generator," and SAMA AC/DC-16, "install tornado protection on gas turbine generator," using
17 both PSA model Revision 6.2 and Revision 7.1 (Gambhir, 2010), (Gambhir, 2011). Energy
18 Northwest's analysis (using a 7 percent discount rate) determined that none of these SAMA
19 candidates were cost-beneficial in either the baseline or the uncertainty analysis for either PSA
20 model Revision 6.2 or Revision 7.1.

21 Energy Northwest also noted that the ER provided a cost-benefit evaluation of SAMA CB-03,
22 "increase leak testing of valves in ISLOCA paths," SAMA CB-08, "revise EOPs to improve
23 ISLOCA identification," and SAMA CB-09, "improve operator training on ISLOCA coping," even
24 though these SAMAs were stated to have been screened in the Phase I evaluation by being
25 subsumed. As discussed in Section F.3.1, a Phase II evaluation of these three SAMAs was
26 provided in the ER, the results for which are included in Table F-10 (EN, 2010). Energy
27 Northwest also provided a Phase II evaluation of these SAMAs in the sensitivity study using
28 PSA model Revision 7.1, the results for which are included in Table F-11 (Gambhir, 2011).
29 Energy Northwest's analysis (using a 7 percent discount rate) determined that none of these
30 SAMA candidates was cost-beneficial in either the baseline or the uncertainty analysis for either
31 PSA model Revision 6.2 or Revision 7.1.

32 As indicated in Section F.3.2, the NRC staff noted that for certain SAMAs considered in the ER,
33 there may be alternatives that could achieve much of the risk reduction at a lower cost
34 (Doyle, 2010a). The NRC staff asked the applicant to evaluate additional lower cost alternatives
35 to the SAMAs considered in the ER, as summarized below:

- 36 • Establishing procedures for opening doors or using portable fans or both for sequences
37 involving room cooling failures, such as the EDG room—In response to the NRC staff
38 RAI, Energy Northwest noted that Phase I SAMA HV-03, "enhance procedures for
39 actions on loss of HVAC," considered the opening of doors and use of portable fans as
40 potential improvements at CGS, and existing CGS procedures already included these
41 operator actions if conditions were favorable (Gambhir, 2010). Specific areas where this
42 alternate means of room cooling was found to be effective and proceduralized were the
43 critical switchgear rooms, the ECCS pump rooms, and the MCC rooms in the reactor
44 building. Thermal dynamic analyses were performed where needed to determine that
45 the alternative method of room cooling would be effective and to ensure adequate
46 response time to implement the procedures. Energy Northwest further explained that

1 the proposed alternate means of room cooling is of limited benefit for the DG room areas
2 because of the need to avoid drawing the heat from these areas into the adjacent
3 electrical equipment panel room, in which the electronics have a lower temperature limit
4 than in the DG room areas. Based on this logic, Energy Northwest screened SAMA
5 HV-03 in the Phase I evaluation. The NRC staff concludes that this alternative has been
6 adequately addressed.

- 7 • Using a portable independently powered pump to inject into containment—In response
8 to the NRC staff RAI, Energy Northwest clarified that CGS already has the capability and
9 procedures to connect fire water to the condensate system so as to inject fire water into
10 the RPV to flood containment via a breach in the RPV and connect fire water to the
11 containment spray system via a pumper truck so as to inject fire water into containment
12 via containment spray (Gambhir, 2010). Given these existing capabilities, Energy
13 Northwest concluded that the intent of the proposed alternative has already been met at
14 CGS. The NRC staff agrees with this conclusion.
- 15 • Using the security DG or EDG-4 or both to extend the life of the 125-V DC batteries—In
16 response to the NRC staff RAI, Energy Northwest stated that Phase I SAMA AC/DC-03,
17 “add a portable, diesel-driven battery charger to existing DC system,” consists of
18 constructing a permanent location for the portable EDG-4, which can be aligned to two
19 different MCCs (MC-7A or MC-8A) that provide both AC power and DC power (through
20 the battery charger) to the aligned train (Gambhir, 2010). Energy Northwest further
21 noted that SAMA AC/DC-03, while originally screened in the Phase I evaluation, was
22 evaluated in response to a separate NRC staff RAI (discussed above), the results of
23 which are provided in Tables F-10 and F-11, and determined to not be cost-beneficial.
24 Energy Northwest also explained that SAMA AC/DC-03 is a lower cost alternative to
25 using the CGS security DG because its use would result in multiple use issues and
26 require additional distribution equipment and cabling. The NRC staff concludes that this
27 alternative has been adequately addressed.
- 28 • Using a portable generator to provide power to individual 125-V DC MCCs upon loss of
29 a DC bus to improve availability of HPCS—In response to the NRC staff RAI, Energy
30 Northwest stated that this SAMA would only be beneficial for scenarios in which HPCS is
31 operating on its DG (EDF-3) power so that AC power is available and the HPCS DC
32 charger or battery is lost (Gambhir, 2010). Energy Northwest determined that the RRW
33 for the HPCS DC system is less than 1.005 and concluded that this SAMA would be of
34 very little benefit and not be cost-beneficial. Since the RRW of 1.005 corresponds to a
35 benefit of approximately \$12,000, which is less than the minimum cost of \$100,000 for a
36 hardware change, the NRC staff agrees with Energy Northwest’s conclusion that the
37 proposed alternative is unlikely to be cost-beneficial.

38 Energy Northwest stated that the six potentially cost-beneficial SAMAs (SAMAs AC/DC-28,
39 CC-03b, FR-07a, FR-07b, FR-08, and HV-02), identified in the ER and in response to NRC staff
40 RAIs using PSA model Revision 6.2, will be further evaluated through the normal processes for
41 evaluating possible plant changes at CGS (EN, 2010), (Gambhir, 2011). Energy Northwest also
42 stated that the 10 additional potentially cost-beneficial SAMAs (SAMAs SR-05R, FL-05R,
43 FL-04R, FL-06R, CC-24R, CC-25R, OT-07R, FW-05R, OT-09R, and FR-11R), identified in
44 response to NRC staff RAIs using PSA model Revision 7.1, will be further evaluated through the
45 normal processes for evaluating possible plant changes at CGS (Gambhir, 2011). In response
46 to an NRC staff RAI, Energy Northwest clarified that the normal process for evaluating possible
47 plant changes at CGS involves first entering the cost-beneficial SAMA candidate into the action
48 request system for SAMAs that require plant modifications or procedure changes and submitting

1 a training request for SAMAs that require training (Gambhir, 2011). After the requests are
2 submitted, formal processes are followed for each SAMA type (i.e., hardware modification,
3 procedure change, training) to determine if the SAMA is ultimately implemented.

4 The NRC staff concludes that, with the exception of the potentially cost-beneficial SAMAs
5 discussed above, the costs of the other SAMAs evaluated would be higher than the associated
6 benefits.

7 **F.7 Conclusions**

8 Energy Northwest compiled a list of 151 SAMAs based on a review of the dominant cutsets and
9 most significant plant systems from the plant-specific internal events PRA, insights from the
10 plant-specific IPE and IPEEE, Phase II SAMAs from LRAs for other plants, and review of other
11 industry documentation. A qualitative screening removed SAMA candidates that modified
12 features not applicable to Energy Northwest due to design differences or have already been
13 implemented at CGS, were determined to provide very little benefit, were similar to another
14 SAMA under consideration and was subsumed into the similar SAMA, and have implementation
15 costs that exceed that maximum benefit. Based on this screening, 123 SAMAs were eliminated,
16 leaving 28 candidate SAMAs for evaluation.

17 For the remaining SAMA candidates, more detailed design and cost estimates were developed
18 as shown in Table F-10. The cost-benefit analyses showed that none of the SAMA candidates
19 were potentially cost-beneficial in the baseline analysis. Energy Northwest performed additional
20 analyses to evaluate the impact of parameter choices on the results of the SAMA assessment.
21 As a result, three SAMAs were identified as potentially cost-beneficial in the ER (SAMAs
22 AC/DC-28, FR-07a, and FR-07b). In response to an NRC staff RAI, Energy Northwest
23 evaluated the same SAMA candidates, and additional SAMA candidates identified in response
24 to NRC staff RAIs, using the 95 percentile internal, fire, and seismic event CDFs to account for
25 uncertainties in the PSA models. This analysis identified three additional SAMAs (SAMA
26 CC-03b, FR-08, and HV-02) as being potentially cost-beneficial. In response to another NRC
27 staff RAI, Energy Northwest performed a sensitivity study to address concerns regarding a
28 significant update to the CGS PSA model since the SAMA analysis was developed. In this
29 sensitivity analysis, Energy Northwest re-evaluated, using the updated CGS PSA model, each
30 of the initial 28 candidate SAMAs and several additional SAMA candidates identified in
31 response to NRC staff RAIs. The SAMA candidates evaluated in the sensitivity study are
32 shown in Table F-11. This study showed that 10 additional SAMAs (SAMA SR-05R, FL-05R,
33 FL-04R, FL-06R, CC-24R, CC-25R, OT-07R, FW-05R, OT-09R, and FR-11R) were potentially
34 cost-beneficial. Energy Northwest has indicated that all 16 potentially cost-beneficial SAMAs
35 will be further evaluated through the normal processes for evaluating possible plant changes at
36 CGS.

37 The NRC staff reviewed the Energy Northwest analysis and concludes that the methods used,
38 and the implementation of those methods, were acceptable. The treatment of SAMA benefits
39 and costs support the general conclusion that the SAMA evaluations performed by Energy
40 Northwest are reasonable and sufficient for the license renewal submittal. The level of
41 treatment of SAMAs for external events was deemed sufficient to support the conclusion that
42 the likelihood of there being cost-beneficial enhancements in this area was minimized by
43 improvements that have been realized as a result of the IPEEE process, separate analysis of
44 fire and seismic events, and inclusion of a multiplier to account for other external events.
45 Therefore, the NRC staff concurs with Energy Northwest's identification of 16 potentially
46 cost-beneficial SAMAs.

1 Given the potential for cost-beneficial risk reduction, the NRC staff agrees that further evaluation
2 of these 16 SAMAs by Energy Northwest through its long-range planning process is
3 appropriate. One of the SAMAs—SAMA FL-06R—appears to be aging-related. The staff will
4 document the resolution of SAMA FL-06R in the final SEIS. For the other 15 potentially
5 cost-beneficial SAMAs, the staff concludes that the mitigative alternatives do not involve aging
6 management of passive, long-lived systems, structures, and components during the period of
7 extended operation. Therefore, they need not be implemented as part of license renewal
8 pursuant to 10 CFR Part 54.

9 **F.8 References**

10 American Nuclear Society (ANS), “Standard for External Events PRA Methodology,” ANSI/ANS
11 58.21-2003, La Grange Park, IL, December 2003.

12 American Society of Mechanical Engineers (ASME), “Standard for Probabilistic Risk
13 Assessment for Nuclear Power Plant Applications,” ASME RA-Sa-2003, New York, NY,
14 December 2003.

15 ASME, “Standard for Level 1/Large Early Release Frequency Probabilistic Risk Assessment for
16 Nuclear Power Plant Applications,” ASME/ANS RA-S-2008, New York, NY, 2008.

17 ASME, “Addenda to ASME RA-S-2008, Standard for Level 1/Large Early Release Frequency
18 Probabilistic Risk Assessment for Nuclear Power Plant Applications,” ASME RA-Sa-2009,
19 February 2, 2009.

20 Benney, Brian J., NRC, letter to J. V. Parrish, Energy Northwest, “Columbia Generating
21 Station—Issuance of Amendment Re: Extension of Diesel Generator Completion Time (TAC
22 No. MC3203),” April 14, 2006, ADAMS Accession No. ML061000672.

23 Doyle, Daniel, NRC, letter to W. S. Oxenford, Energy Northwest, “Request for Additional
24 Information for the Review of the Columbia Generating Station License Renewal Application—
25 SAMA Review (TAC No. ME3121),” July 1, 2010 (2010a), ADAMS Accession
26 No. ML101760421.

27 Doyle, Daniel, NRC, letter to S. K. Gambhir, Energy Northwest, “Request for Additional
28 Information for the Review of the Columbia Generating Station License Renewal Application—
29 SAMA Review (TAC No. ME3121),” November 10, 2010 (2010b), ADAMS Accession
30 No. ML102870984.

31 Doyle, Daniel, NRC, letter to S. K. Gambhir, Energy Northwest, “Request for Additional
32 Information for the Review of the Columbia Generating Station License Renewal Application—
33 SAMA Review (TAC No. ME3121),” December 2, 2010 (2010c), ADAMS Accession
34 No. ML103330246.

35 Doyle, Daniel, NRC, letter to S. K. Gambhir, Energy Northwest, “Request for Additional
36 Information for the Review of the Columbia Generating Station License Renewal Application—
37 Severe Accident Mitigation Alternative Review (TAC No. ME3121),” March 10, 2011, ADAMS
38 Accession No. ML110670379.

39 Energy Northwest (EN), “Columbia Generating Station—License Renewal Application,
40 Appendix E: Applicant’s Environmental Report; Operating License Renewal Stage,” Richland,
41 WA, January 20, 2010, ADAMS Accession No. ML100250666.

- 1 Electric Power Research Institute (EPRI), "A Methodology for Assessment of Nuclear Power
2 Plant Seismic Margin," EPRI NP-6041-SL, Revision 1, Palo Alto, CA, August 1991.
- 3 EPRI, "Fire-Induced Vulnerability Evaluation (FIVE)," EPRI TR-100370, Revision 0, Palo Alto,
4 CA, April 1992.
- 5 EPRI, "Fire Events Data Base for U.S. Nuclear Power Plants," NSAC/178L, Palo Alto, CA,
6 January 1993.
- 7 EPRI, "Methodology for Developing Seismic Fragilities," EPRI NP-103059, Palo Alto, CA,
8 April 1994.
- 9 EPRI, "Seismic Probabilistic Risk Assessment Implementation Guide," EPRI TR-1002989, Palo
10 Alto, CA, December 2003.
- 11 Gambhir, Sudesh K., Energy Northwest, letter to NRC Document Control Desk, "Columbia
12 Generating Station, Docket No. 50-397, Response to Request for Additional Information,
13 License Renewal Application," Richland, WA, September 17, 2010, ADAMS Accession
14 No. ML102660151.
- 15 Gambhir, Sudesh K., Energy Northwest, letter to NRC Document Control Desk, "Columbia
16 Generating Station, Docket No. 50-397, Response to Request for Additional Information for the
17 Review of the Columbia Generating Station, License Renewal Application," Richland, WA,
18 January 28, 2011, ADAMS Accession No. ML110330395.
- 19 Geomatrix Consultants Inc. (Geomatrix), "Probabilistic Seismic Hazard Analysis WNP-2 Nuclear
20 Power Plant Hanford Washington," Project No. 1846, December 1994 (1994a).
- 21 Geomatrix, "Probabilistic Seismic Hazard Analysis, DOE Hanford Site, Washington,"
22 WHC-SD-W236-TI-002, Westinghouse Hanford Company, Richland, WA, 1994 (1994b).
- 23 Geomatrix, "Probabilistic Seismic Hazard Analysis, DOE Hanford Site, Washington,"
24 WHC-SD-W236-TI-002 Rev 1a, Westinghouse Hanford Company, Richland, WA, 1996.
- 25 Nuclear Energy Institute (NEI), "Severe Accident Mitigation Alternative (SAMA) Analysis
26 Guidance Document," NEI 05-01, Revision A, Washington, D.C., November 2005.
- 27 Oregon, "Department of Revenue: Research and Statistical Reports, Property Tax Statistics
28 Fiscal Year 2002-03," 2003-2003, Available URL:
29 <http://www.oregon.gov/DOR/STATS/303-405-03-toc.shtml> (accessed February 2008).
- 30 Pacific Northwest National Laboratory (PNNL), "Site-Specific Seismic Response Model for the
31 Waste Treatment Plant, Hanford Washington," PNNL-15089, Richland, WA, 2005.
- 32 PNNL, "Updated Site Response Analyses for the Waste Treatment Plant, DOE Hanford Site,
33 Washington," PNNL-16653, Richland, WA, 2007.
- 34 Parrish, J.V., WPPSS, letter to NRC Document Control Desk, "WNP-2, Operating License
35 NPF-21, Revision 1 to Response to Generic Letter 88-20, 'Individual Plant Examination for
36 Severe Accident Vulnerabilities 10CFR 50.54 (F)," Richland, WA, July 27, 1994, ADAMS
37 Accession No. ML0800904931.

Appendix F

- 1 Parrish, J.V., WPPSS, letter to NRC Document Control Desk, "WNP-2, Operating License
2 NPF-21, Initial Submittal of Individual Plant Examination for External Events (IPEEE) (TAC
3 No. 74489)," Richland, WA, June 26, 1995, ADAMS Accession No. ML0800903630.
- 4 Sorensen, G.C., WPPSS, letter to NRC Document Control Desk, "WNP-2, Operating License
5 NPF-21, Revision 1 to Response to Generic Letter 88-20, 'Individual Plant Examination for
6 Severe Accident Vulnerabilities 10CFR 50.54 (f)," Richland, WA, August 28, 1992, ADAMS
7 Accession No. ML0800904991.
- 8 Swank, David A., Energy Northwest, letter to NRC Document Control Desk, "Columbia
9 Generating Station, Docket No. 50-397, Response to Request for Additional Information Related
10 to the Review of the Severe Accident Mitigation Alternative Analysis," Richland, WA,
11 May 6, 2011, ADAMS Accession No. ML11129A186.
- 12 U.S. Census Bureau (USCB), "United States Census 2000, State and County QuickFacts,"
13 2000 (2000a), Available URL: <http://www.census.gov/main/www/cen2000.html> (accessed July
14 2008).
- 15 USCB, "Population Estimates Program," 2000 (2000b), Available URL:
16 www.factfinder.census.gov (accessed February 2008).
- 17 U.S. Department of Agriculture (USDA), "2002 Census of Agriculture: Washington State and
18 County data," Volume 1, Geographic Area Series, Part 47, AC-02-A-37, June 2004 (2004a).
- 19 USDA, "2002 Census of Agriculture: Oregon State and County data," Volume 1, Geographic
20 Area Series, Part 47, AC-02-A-37, June 2004 (2004b).
- 21 U.S. General Services Administration (USGSA), "Per Diem Rates," 2008, Available URL:
22 <http://www.gsa.gov> (accessed April 23, 2008).
- 23 U.S. Geological Survey (USGS), "2008 NSHM Gridded Data, Peak Ground Acceleration," 2008,
24 Available URL: <http://earthquake.usgs.gov/hazards/products/conterminous/2008/data/>.
- 25 U.S. Nuclear Regulatory Commission (NRC), "Standard Review Plan for the Review of Safety
26 Analysis Report for Nuclear Power Plants," NUREG-0800, Washington, D.C., November 1975.
- 27 NRC, "PRA Procedures Guide: A Guide to the Performance of Probabilistic Risk Assessments
28 for Nuclear Power Plants," NUREG/CR-2300, Washington, D.C., January 1983.
- 29 NRC, "COMPBRN III—A Computer Code for Modeling Compartment Fires," NUREG/CR-4566,
30 July 1986.
- 31 NRC, "Individual Plant Examination for Severe Accident Vulnerabilities," Generic Letter 88-20,
32 November 23, 1988.
- 33 NRC, "Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants,"
34 NUREG-1150, Washington, D.C., 1990 (1990a).
- 35 NRC, "Evaluation of Severe Accident Risks: Quantification of Major Input Parameters,"
36 NUREG/CR-4551, Volume 2, Revision 1, Part 7, Washington, D.C., December 1990 (1990b).

- 1 NRC, "Procedural and Submittal Guidance for the Individual Plant Examination of External
2 Events (IPEEE)," Generic Letter No. 88-20, Supplement 4, NUREG-1407, Washington, D.C.,
3 June 1991 (1991a).
- 4 NRC, "Procedural and Submittal Guidance for the Individual Plant Examination of External
5 Events (IPEEE) for Severe Accident Vulnerabilities," NUREG-1407, Washington, D.C.,
6 June 1991 (1991b).
- 7 NRC, *Regulatory Analysis Technical Evaluation Handbook*, NUREG/BR-0184, Washington,
8 D.C., 1997 (1997a).
- 9 NRC, "Safety Evaluation by the Office of Nuclear Reactor Regulation Related to Individual Plant
10 Examination Washington Public Power Supply System Nuclear Project No. 2, Docket
11 No. 50-397," Washington, D.C., April 8, 1997 (1997b).
- 12 NRC, "Individual Plant Examination Program: Perspectives on Reactor Safety and Plant
13 Performance," NUREG-1560, Washington, D.C., 1997 (1997c).
- 14 NRC, *Code Manual for MACCS2: Volume 1, User's Guide*, NUREG/CR-6613, Washington,
15 D.C., May 1998.
- 16 NRC, "Review of Columbia Generating Station Individual Plant of Examination of External
17 Events Submittal (TAC Nos. M83695)," Washington, D.C., February 26, 2001.
- 18 NRC, "An Approach for Using Probabilistic Risk Assessment in Risk-Informed Decisions on
19 Plant-Specific Changes to the Licensing Basis," RG 1.174, Revision 1, Washington, D.C.,
20 November 2002.
- 21 NRC, "Regulatory Analysis Guidelines of the U.S. Nuclear Regulatory Commission,"
22 NUREG/BR-0058, Revision 4, Washington, D.C., 2004 (2004a).
- 23 NRC, "An Approach for Determining the Technical Adequacy of Probabilistic Risk Assessment
24 Results for Risk-Informed Activities," RG 1.200 for Trial Use, Washington, D.C., February 2004
25 (2004b).
- 26 NRC, "EPRI/NRC-RES Fire PRA Methodology for Nuclear Power Facilities," NUREG/CR-6850,
27 Volume 2, Washington, D.C., September 2005.
- 28 NRC, "An Approach for Determining the Technical Adequacy of Probabilistic Risk Assessment
29 Results for Risk-Informed activities Basis," RG 1.200, Revision 2, Washington, D.C.,
30 March 2009 (2009a).
- 31 NRC, "Enforcement Guidance Memorandum, Enforcement Discretion for Fire Induced Circuit
32 Faults," EGM 09-02, Washington, D.C., May 14, 2009 (2009b), ADAMS Accession
33 No. ML090300446.
- 34 Washington, "Department of Revenue Washington State, Property Tax Statistics 2002," 2002,
35 Available URL: [http://dor.wa.gov/Content/AboutUs/StatisticsAndReports/2002/
36 Property_Tax_Statistics_2002/default.aspx](http://dor.wa.gov/Content/AboutUs/StatisticsAndReports/2002/Property_Tax_Statistics_2002/default.aspx) (accessed February 2008).
- 37 Washington Office of Financial Management (WOFM), "Provisional Projections of the Total
38 Resident Population for Growth Management," 2007, Available URL:
39 <http://www.ofm.wa.gov/pop/gma/projections07.asp> (accessed November 6, 2008).

Appendix F

- 1 Webring, R.L., Energy Northwest, letter to NRC Document Control Desk, "Columbia Generating
- 2 Station, Docket No. 50-397, Application for Amendment of Facility Operating License
- 3 No. NPF-21 for Extension of Diesel Generator Completion Time," Richland, WA. May 19, 2004,
- 4 ADAMS Accession No. ML102660151.

APPENDIX G
DESCRIPTION OF PROJECTS CONSIDERED IN THE CUMULATIVE
IMPACTS ANALYSIS

1 G DESCRIPTION OF PROJECTS CONSIDERED IN THE 2 CUMULATIVE IMPACTS ANALYSIS

3 To evaluate cumulative impacts, the incremental impacts of the proposed action, as described
4 in Sections 4.1–4.9, are combined with other past, present, and reasonably foreseeable future
5 actions regardless of what agency (Federal or non-Federal) or person undertakes such other
6 actions. The U.S. Nuclear Regulatory Commission (NRC) staff (staff) used the information in
7 the environmental report (ER); responses to requests for additional information (RAIs);
8 information from other Federal, State, and local agencies; scoping comments; and information
9 gathered during the visits to the Columbia Generating Station (CGS) site to identify other past,
10 present, and reasonably foreseeable actions. Other actions and projects that were identified
11 during this review, and considered in the staff's independent analysis of the potential cumulative
12 effects, are described in Table G-1.

13 **Table G-1. Other projects and actions considered in the cumulative analysis for**
14 **Columbia Generating Station**

| Project name | Summary of project | Location | Status |
|---|--|--|--|
| Activities on the Hanford Site | | | |
| Cleanup & restoration activities at Hanford | <p>Various actions taken to remediate and restore areas of the Hanford Site. For example, the U.S. Department of Energy (DOE) Columbia River Closure Project would stabilize, maintain, or remove retired plutonium production reactors, support facilities, waste sites, and burial grounds used during World War II and the Cold War. This area includes approximately 218 square miles along the Columbia River corridor. DOE would also characterize and remediate the 618-10 and 618-11 burial grounds (DOE, 2010a), (EN, 2010a). A primary goal of the River Corridor Closure Project is to remove materials that could contaminate groundwater (WCH, 2010). Recent efforts to clean up and protect groundwater are described in DOE's CERCLA 5-Year Review Report for the Hanford Site (DOE, 2006) and DOE (2009a).</p> <p>Additional details regarding cleanup activities that would occur throughout the Hanford Site are described in more detail in DOE's Tank Closure and Waste Management EIS for the Hanford Site, Richland, WA in Chapter 2, Chapter 6, and Appendix R (DOE, 2009a). Some of these activities include retrieval of suspect transuranic waste buried after 1970, construction and operation of the environmental restoration disposal facilities near the 200-West Area, and final disposition of the canyons, PUREX Plant, PUREX tunnels and other facilities in the 200 Area (DOE, 2009a).</p> | The 618-11 burial ground is adjacent to CGS, and the 618-10 burial ground is approximately 3.5 miles (mi) south of CGS. Other activities would occur throughout Hanford. | Characterization and remediation of burial ground 618-10 is in progress. Characterization and remediation for the 618-11 burial ground is scheduled to begin in February 2011 (EN, 2010a). The entire River Corridor Closure Project, including work at the 618-10 and 618-11 burial grounds, is expected to be completed by 2015 (DOE, 2010a). Cleanup and restoration for other activities would occur through the end of the extended license term. |
| Tank Closures at Hanford | DOE is considering tank waste storage, retrieval, treatment, disposal, and final tank closure for the single-shell tank system for approximately 55 million gallons of mixed radioactive and chemically hazardous waste in 177 large underground tanks at Hanford (DOE, 2009a). DOE is currently constructing a waste treatment plant (WTP) in the 200-East Area of Hanford. DOE would operate this facility by separating waste into high-level waste and low-activity waste streams, vitrifying the high-level waste stream and | WTP is approximately 10 mi northwest from CGS. Tanks and other facilities are located throughout | DOE's draft Tank Closure and Waste Management EIS for the Hanford Site, Richland, WA was published in October 2009. WTP is currently under construction. |

Appendix G

| Project name | Summary of project | Location | Status |
|--|--|--|---|
| | immobilizing the low-activity waste stream. The WTP would be powered by diesel fuel or natural gas. If natural gas is used, a new pipeline would be built, and DOE would analyze those environmental impacts in a separate EIS (DOE, 2010d). | Hanford Site. | |
| Decommissioning, Deactivation, & Closure of Various Facilities at Hanford | DOE is proposing to decommission the fast flux test facility (FFTF), a nuclear test reactor. Decommissioning activities would include management of decommissioning-generated waste and disposition of Hanford's inventory of radioactively contaminated bulk sodium. DOE also proposes for decommissioning, deactivation, or closure of eight surplus production reactors and their support facilities in the 100 Area, the N Reactor and support facilities, the Plutonium Finishing Plant in the 200-West Area, and the U Plant regional closure (DOE, 2009a). | FFTF is approximately 4 mi southwest of CGS. Other facilities occur throughout Hanford Site. | For the FFTF, the draft EIS was published in October 2009. Decommissioning activities for the N Reactor would occur by 2068 (DOE, 2005) and by 2080 for the eight surplus production reactors (DOE, 1989). Deactivation and closure activities for the Plutonium Finishing Plant in the 200-West Area and the U Plant regional closure is ongoing (DOE, 2009a). |
| Waste Management at Hanford | DOE is proposing to expand or upgrade the existing waste storage, treatment, and disposal capacity at Hanford in order to support current and future waste management activities for onsite and offsite waste. Proposed management of solid waste operations and proposed disposal of low-level radioactive waste (LLW) and mixed low-level radioactive waste (MLLW) from Hanford and other DOE sites are described in DOE (2009a). Additional waste management programs include construction and operation of facilities of disposal of greater-than-Class C LLW (DOE, 2011) and operation of the U.S. Ecology commercial LLW disposal site near the 200-East Area (WSDOE and WSDOH, 2004). | Throughout Hanford Site | Activities would occur through license term. |
| Transportation of radioactive & chemical waste throughout Hanford and removal from the Hanford Site to other locations | DOE would transport radioactive and chemical waste throughout and off the Hanford Site, as described in DOE (2009a). Example activities include transportation and disposal of decommissioned Navy reactor plants (61 FR 41596), transportation of sodium-bonded spent nuclear fuel to Idaho National Lab for treatment (65 FR 56565), and transportation of transuranic waste to a Waste Isolation Pilot Plant in New Mexico (63 FR 3624). | Throughout Hanford Site and to offsite destinations beyond 100 mi of CGS | Transportation of sodium-bonded spent nuclear fuel would occur in 2012 (DOE, 2000). Other activities would occur through the end of the extended license term. |
| Energy Park at Hanford | As part of the DOE footprint reduction at Hanford from clean up, decommissioning, and closure activities described above, an energy park would be built to help sustain the local economy. The goal of the energy park would be to increase the supply of renewable energy (such as solar, wind, and other types of energy) and to sustain the local and regional economies by providing jobs at new energy production facilities (DOE, 2010b). Mid-Columbia Energy Initiative, which | Near 100 and 300 Areas at Hanford | Proposals have been submitted to DOE (Gambhir, 2010). |

| Project name | Summary of project | Location | Status |
|---|--|------------------------------------|---|
| | would be operated by Energy Northwest, has submitted a proposal to lease land from DOE to make available for public and private energy demonstration projects and partnerships. Technology that may be pursued as part of this initiative includes solar, biofuels, and small modular nuclear units (Gambhir, 2010). | | |
| Industrial Development Center | Location of terminated nuclear energy projects (WNP-1 and WNP-4) by Energy Northwest—The site is currently leased to DOE contractors and other commercial entities and contains shops, warehouses, and office space (EN, 2010b). Future activity could occur adjacent to the IDC in an area where Energy Northwest is promoting energy generation (EN, 2010b). | Adjacent to CGS | Construction of WNP-1 and WNP-4 was terminated in the early 1980s, and NRC terminated the construction permit in 2007 (NRC, 2007). Other facilities on this site are operational. |
| Additional ground disturbing activities throughout Hanford | In addition to the cleanup, waste management, transportation, decommissioning and other activities described above, other ground disturbing activities would occur—such as the construction and operation of a Physical Sciences Facility at Pacific Northwest National Laboratory (PNNL), excavation and use of geologic materials from existing borrow pits, and other activities described in Appendix D in DOE (2009a). In addition, DOE is proposing to remove excess communication facilities, infrastructure, and miscellaneous debris within the Fitzner/Eberhardt Arid Lands Ecology Reserve. Communication infrastructure needed by DOE, U.S. Fish and Wildlife Service (USFWS), local governments, and other organizations would be consolidated into a single facility (DOE, 2009b). | Throughout Hanford Site | Activities would occur through license term. |
| Nuclear fabrication, waste treatment, or medical isotope production facilities not on the Hanford Site | | | |
| Perma-Fix Northwest waste treatment facility | The LLW and MLLW treatment facility is licensed under NRC regulations (State of Washington licenses WN-I00393-1 & WN-I00508-1) and permitted under the Resource Conservation and Recovery Act regulations through the State of Washington. | Approximately 9 mi south of CGS | Operational |
| AREVA NP nuclear fuel fabrication facility | Nuclear fuel fabrication facility located in Richland, WA—The facility is licensed under NRC regulations and inspected regularly by the NRC (NRC, 2010). | Approximately 9 mi south of CGS | Operational |
| Westinghouse's Richland Service Center | The Richland Service Center supplies various waste and chemical cleaning services to the nuclear industry. | Approximately 10 mi south of CGS | Operational |
| IsoRay Medical Isotope facility | IsoRay Medical produces and sells Cesium-131 (131-Cs or 131Cs), which is a medical radioisotope that can be used for the treatment of various cancers and other diseases. | Approximately 10 mi south of CGS | Operational |
| Moravek Biochemicals facility | Moravek Biochemicals produces and sells radiochemicals and inorganic compounds (DOE, 2009a). | Approximately 10 mi south of CGS | Operational |
| Cleanup of Environmental Protection Agency (EPA) National | The cleanup of toxic sites throughout the State of Washington, as specified by EPA's National Priorities List, includes areas on the Hanford Site, Pasco sanitary landfill, Umatilla Army Depot, and the Yakima | Throughout the State of Washington | Sites are currently listed as a national priority site for |

Appendix G

| Project name | Summary of project | Location | Status |
|---|--|---------------------------------------|--|
| Priorities List sites and state toxic waste sites | Pit (EPA, 2010). | | cleanup. |
| Energy projects | | | |
| Priest Rapids Hydroelectric Project, consisting of the Priest Rapids & Wanapum Dams | There are 3,104 acres of Federal land managed by the U.S. Bureau of Reclamation, U.S. Bureau of Land Management, U.S. Department of the Army, U.S. Fish and Wildlife Service (USFWS), DOE, and Bonneville Power Administration (BPA) and 1,135 hectares (2,804 acres) of Washington State land (FERC, 2006). Future construction proposed by Grant County Public Utility District (PUD) includes installing advanced-design turbines, improving downstream fish bypass facilities, and creating and carrying out programs to protect anadromous and resident fish and wildlife and cultural resources (Grant County PUD, 2003). Habitat restoration activities also occur within the area, as described in the National Marine Fisheries Service's (NMFS) Biological Opinion for the Upper Columbia River spring-run Chinook salmon and Upper Columbia River steelhead (NMFS, 2004). | Approximately 47 mi upstream | License renewal was granted by the FERC in April 2008, which extends the operations period 44 years. |
| Wind projects, including Big Horn, Combine Hills II, Desert Claim, & Wild Horse | Four wind projects within 50 mi of Hanford have been proposed, constructed, or are operational, including Big Horn, Combine Hills II, Desert Claim, and Wild Horse (DOE, 2009a), (EFSEC, 2009). Development of additional wind projects within the area is likely given the natural potential for wind power (e.g. wind speeds) (DOE, 2010c) and projected growth rates in the region (see Section 2.2.8), and since Washington State requires new coal-fired power plants to include provisions for carbon capture and storage (see Section 8.1.2). | 50–100 mi from CGS | Construction and operations would occur through license term. |
| McNary-John Day Transmission Line | BPA is proposing to build a new 79-mi 500 kilovolt (kV) transmission line. The transmission line would begin at the McNary Substation, near the McNary Dam in Oregon, and run along the Columbia River in Benton, Yakima, Klickitat Counties, WA, and then cross the Columbia River and terminate at the John Day Substation, near the John Day Dam in Oregon. The new transmission line would be collocated with existing BPA transmission lines. | Ranges from 36 to over 50 mi from CGS | Construction is expected to begin in 2009 (BPA, 2010). |
| Other energy projects | Other energy projects include maintenance and upgrades to, or construction and operation of, transmission lines (such as the 17-mi 500 kV line and 10-mi 230 kV transmission lines from the Ashe substation to the BPA), biofuel facilities, and natural gas terminals, pipelines, and storage projects, as described in DOE (2009a). | Throughout region | Operational |
| Other projects | | | |
| Hanford Reach National Monument & Saddle Mountain National Wildlife Refuge | The Hanford Reach National Monument covers an area of 196,000 acres on the Hanford Site. The area includes a biologically diverse landscape, native shrub and grassland steppe that is considered an endangered ecosystem by U.S. Department of Interior, and a variety of cultural resources. Recreational opportunities include hiking, boating, fishing, hunting, | 3–25 mi from CGS | Continued and increased opportunities for recreation and conservation of natural and cultural resources; |

| Project name | Summary of project | Location | Status |
|---|--|---|---|
| | and wildlife viewing (USFWS, 2010). | | development is unlikely in this area (USFWS, 2008). |
| Yakima River Basin Integrated Water Resource Management | The Yakima River Basin Integrated Water Resource Management Plan would result in a variety of actions to improve water supply and fish habitat, including the addition of fish passage at existing reservoirs, new or expanded storage reservoirs, groundwater storage, fish habitat enhancements on the mainstem Yakima River and its tributaries, enhanced water conservation, and market-based reallocation of water resources (WSDOE, 2009). | Throughout the Yakima drainage basin | The final EIS for the preliminary plan was published in June 2009 (WSDOE, 2009). On March 9, 2011, the Yakima River Basin Water Enhancement Project Working Group voted to support the final element of the Proposed Integrated Water Resource Management Plan. As of May 2011, the implementation committee is prioritizing projects and developing an environmental impact statement based on the refined plan (WSDOE, 2011). |
| Moses Lake Siphon | Installation of the second barrels of the Weber Branch Siphon and the Weber Coulee Siphon (Reclamation 2010)—Construction of the siphons is needed to transport additional waters of the Columbia Basin Project via the existing East Low Canal. | 11 mi east of Moses Lake; 25 mi northwest from CGS | Construction began in April 2010. |
| Umatilla Army Depot | Closure of the Umatilla Army Depot is associated with the loss of 884 regional jobs (512 direct and 372 indirect) (BRAC, 2005). | 43 mi south of CGS | Umatilla Army Depot was listed for closure in 2005. |
| Fort Lewis & Yakima Training Center (YTC) | Increase the number of soldiers stationed at Fort Lewis and YTC by approximately 5,700 soldiers and 8,260 family members—To accommodate growth, new construction would occur and could include new or expanded barracks, maneuver and live fire training grounds, motor pools, classrooms, and administrative facilities (Army, 2009). | 7 mi northeast of the city of Yakima; 55 mi west of CGS | Construction activities would occur through 2015. |
| Expansion of academic facilities | Washington State University Tri-Cities campus would be expanded and a Kadlec Medical Center and Columbia Basin Community College new health science building would be constructed. | 8–20 mi south of CGS | Construction would be completed by 2020. |
| Mining | Primary resources extracted include sand, gravel, and basalt. The Washington State Surface Mine Reclamation Act states that surface mines more than 3 acres in size or with a highwall that is higher than 30 feet and steeper than 45 degrees must be reclaimed (WDNR, 2010a). | Throughout region (WDNR, 2010 b) | Operational—future expansion and new mines are expected to provide construction materials. |
| Future Urbanization | Construction of housing units and associated commercial buildings; roads, bridges, and rail; and water and wastewater treatment and distribution facilities and associated pipelines as described in local land-use planning documents (Benton County, 2007) | Throughout region | Construction would occur in the future, as described in State and local land-use planning documents |

Appendix G

| Project name | Summary of project | Location | Status |
|--------------|--|----------|------------------------|
| | and in Appendix R of DOE (2009a)—As a result of increased urbanization, the cities of Richland, Pasco, and Kennewick (Tri-Cities) are expected to withdraw up to 178 cubic feet per second per year from the Columbia River for municipal, industrial, and commercial uses (Surface Water Application No. S4-30976). The American Recovery and Reinvestment Act (2009) is funding several infrastructure modernization projects, including reconstruction of runways, facility improvements within school districts, and highway expansion and construction projects within the area (Recovery, 2009). | | (Benton County, 2007). |

1 **G.1 References**

2 Benton County, “Benton County Comprehensive Land Use Plan 2006 Update,” Board of County
3 Commissions, Benton County Planning Commission, and Benton County Planning Staff,
4 March 12, 2007.

5 Bonneville Power Administration (BPA), “McNary-John Day Transmission Line Project Oregon
6 and Washington,” 2010, Available URL:
7 http://www.efw.bpa.gov/environmental_services/Document_Library/Mcnary-John_Day/
8 (accessed September 13, 2010).

9 Defense Base Closure and Realignment and Closure (BRAC), “2005 Defense Base Closure
10 and Realignment Commission Report,” Arlington, VA, September 8, 2005.

11 Energy Facility Site Evaluation Council (EFSEC), “Desert Claim Wind Power Project Final
12 Supplemental Environmental Impact Statement,” November 6, 2009.

13 Energy Northwest (EN), “License Amendment Request in Support of Department of Energy
14 (DOE) 618-11 Waste Burial Ground Remediation Project- Nonintrusive Activities,” CGS, Docket
15 No. 50-397, April 28, 2010 (2010a), ADAMS Accession No. ML101250340.

16 EN, “License Renewal Application, Applicant’s Environmental Report, Operating License
17 Renewal Stage,” CGS, Appendix E, 2010 (2010b), ADAMS Accession No. ML100250666

18 *Federal Register (FR)*, “National Environmental Policy Act Record of Decision for the Disposal
19 of Decommissioned, Defueled Cruiser, Ohio Class, and Los Angeles Class Naval Reactor
20 Plants,” (61 FR 41596), Volume 61, No. 155, August 9, 1996, pp. 41596–41597.

21 *FR*, “Record of Decision for the Department of Energy’s Waste Isolation Pilot Plant Disposal
22 Phase,” (63 FR 3624), Volume 63, No. 15, January 23, 1998, pp. 3624–3629.

23 *FR*, “Record of Decision for the Treatment and Management of Sodium-Bonded Spent Nuclear
24 Fuel,” (65 FR 56565), Volume 65, No. 182, September 19, 2000, pp. 56565–56570.

25 Federal Energy Regulatory Commission (FERC), 2006, *Final Environmental Impact Statement,*
26 *Priest Rapids Hydroelectric Project, Washington (FERC Project No. 2114), FERC/FEIS-0190F,*
27 Office of Energy Projects, Washington, D.C., November 2006.

- 1 Gambhir, S.K., EN, letter to NRC Document Control Desk, "Columbia Generating Station,
2 Docket No. 50-397 Response to Request for Additional Information License Renewal
3 Application," August 5, 2010, ADAMS Accession No. ML102300503.
- 4 Grant County Public Utility District (Grant County PUD), "Priest Rapids Project License
5 Application," FERC No. 2114, Executive Summary, October 2003.
- 6 National Marine Fisheries Service (NMFS), "Biological Opinion for ESA Section 7 Consultation
7 on Interim Operations for the Priest Rapids Hydroelectric Project," NOAA Fisheries Consultation
8 No. 1999/01878, FERC No. 2114, May 3, 2004.
- 9 Recovery, "Recovery.gov, Track the Money," 2010, Available URL:
10 [http://www.recovery.gov/Transparency/RecipientReportedData/pages/
11 RecipientReportedDataMap.aspx?State=WA&datasource=recipient](http://www.recovery.gov/Transparency/RecipientReportedData/pages/RecipientReportedDataMap.aspx?State=WA&datasource=recipient) (accessed
12 September 14, 2010).
- 13 U.S. Army (Army), "Draft Environmental Impact Statement for Army Growth at Fort Lewis and
14 the Yakima Training Center (YTC), WA," July 2009.
- 15 U.S. Environmental Protection Agency (EPA), "EPA National Priority List Map," 2010, Available
16 URL: <http://www.epa.gov/superfund/sites/query/queryhtm/nplmapsg.htm?1220> (accessed
17 July 14, 2010).
- 18 U.S. Department of Energy (DOE), "Draft Environmental Impact Statement, Decommissioning of
19 Eight Surplus Production Reactors at the Hanford Site, Richland, Washington,"
20 Washington, D.C., DOE/EIS-0119D, March 1989.
- 21 DOE, "Final Environmental Impact Statement for the Treatment and Management of
22 Sodium-Bonded Spent Nuclear Fuel," Office of Nuclear Energy, Science and Technology,
23 Washington, D.C., DOE/EIS-0306, July 2000.
- 24 DOE, "Surplus Reactor Final Disposition Engineering Evaluation," Richland Operations Office,
25 Richland, WA, DOE/RL-2005-45, Rev. 0, August 2005.
- 26 DOE, "CERCLA Five-Year Review Report for the Hanford Site," Richland Operations Office,
27 Richland, WA, DOE/RL-2006-20, Rev. 0, May 2006.
- 28 DOE, "Draft Tank Closure and Waste Management Environmental Impact Statement for the
29 Hanford Site, Richland, Washington," DOE/EIS-0391, October 2009 (2009a).
- 30 DOE, "Final Environmental Assessment for the Combined Community Communications Facility
31 and Infrastructure Cleanup on the Fitzner/Eberhardt Arid Lands Ecology Reserve, Hanford Site,
32 Richland, Washington," Richland Operations Office, Richland, WA, DOE/EA-1660F, July 2009
33 (2009b).
- 34 DOE, "Hanford Projects and Facilities: 618-10 and 618-11 Burial Grounds," 2010 (2010a),
35 Available URL: <http://www.hanford.gov/page.cfm/618BurialGrounds> (accessed July 12, 2010).
- 36 DOE, "Energy Parks Initiative: Leveraging Assets To Increase Taxpayers' Return On
37 Investment," Presentation by Dr. Benjamin J. Cross, PEDOE Office of Environmental
38 Management at the Radioactive Waste and Hazardous Materials Committee, Santa Fe, NM,
39 July 13, 2010 (2010b), Available URL: <http://legis.state.nm.us/lcs/handouts/>

Appendix G

- 1 RHMC%20EPI%20-%20Briefing%20-%20NM%20Legislature%2020100713.pdf (accessed
2 September 10, 2010)
- 3 DOE, "Energy Efficiency and Renewable Energy, Wind and Water Program, Wind Powering
4 America, Wind Maps and Wind Resource Potential Estimates," 2010 (2010c), Available URL:
5 http://www.windpoweringamerica.gov/wind_maps.asp (accessed September 13, 2010).
- 6 DOE, "RL Energy Park Briefing for River and Plateau Committee," 2010 (2010d), Available
7 URL: http://www.hanford.gov/files.cfm/CAL_HAB_Presentation_EP081010.pdf (accessed
8 February 25, 2011)
- 9 DOE, "Draft Environmental Impact Statement for the Disposal of Greater-Than-Class C (GTCC)
10 Low-Level Radioactive Waste and GTCC-Like Waste," EIS-0375D, February 2011, Available
11 URL: <http://www.gtcceis.anl.gov/> (accessed on March 28, 2011).
- 12 U.S. Department of Reclamation, "\$20M ARRA Project at Weber Siphon Complex Construction
13 is Underway in the Columbia Basin Project," Pacific Northwest Region Boise, ID, June 29, 2010,
14 Available URL: <http://www.usbr.gov/newsroom/newsrelease/detail.cfm?RecordID=32961>
15 (accessed on July 14, 2010).
- 16 U.S. Fish and Wildlife Service (USFWS), "Final Hanford Reach National Monument
17 Comprehensive Conservation Plan and Environmental Impact Statement," August 2008.
- 18 USFWS, "Hanford Reach National Monument," 2010, Available URL:
19 <http://www.fws.gov/hanfordreach/index.html> (accessed July 13, 2010).
- 20 U.S. Nuclear Regulatory Commission (NRC), "Energy Northwest Project No. 1—Termination of
21 Construction Permit CPPR-134 (TAC NO. MC9245)," February 8, 2007, ADAMS Accession
22 No. ML1070220011.
- 23 NRC, "Nuclear Regulatory Commission Inspection Report No. 70-1257/2010-004,"
24 June 8, 2010, ADAMS Accession No. ML1016001071.
- 25 Washington Closure Hanford (WCH), "U.S. Department of Energy's River Corridor Closure
26 Project: Washington Closure Hanford—Projects Overview," 2010, Available URL:
27 <http://www.washingtonclosure.com/projects/overview/> (accessed September 16, 2010).
- 28 Washington State Department of Ecology (WSDOE), "Yakima River Basin Integrated Water
29 Resource Management Alternative Final Environmental Impact Statement (Final EIS) and
30 Integrated Water Resource Management," Yakima, WA, Ecology Publication #0099--1121—
31 000192, June 2009.
- 32 WSDOE, "Yakima River Basin Water Enhancement Project," Available URL:
33 http://www.ecy.wa.gov/programs/wr/cwp/cr_yak_storage.html (accessed May 16, 2011).
- 34 WSDOE and Washington State Department of Health (WSDOE and WSDOH), "Final
35 Environmental Impact Statement for the Commercial Low-Level Radioactive Waste Disposal
36 Site, Richland, Washington," Olympia, WA, DOH Publication 320-031, June 30, 2004.

- 1 Washington State Department of Natural Resources (WDNR), "Surface Mining Reclamation
- 2 Program," 2010 (2010a), Available URL: [http://www.dnr.wa.gov/BusinessPermits/Topics/](http://www.dnr.wa.gov/BusinessPermits/Topics/MiningEnergyResourceRegulation/Pages/smr.aspx)
- 3 [MiningEnergyResourceRegulation/Pages/smr.aspx](http://www.dnr.wa.gov/BusinessPermits/Topics/MiningEnergyResourceRegulation/Pages/smr.aspx) (accessed July 14, 2010).

- 4 WDNR, "Earth Resource Permit Locations: Active Surface Mine Permit Sites," 2010 (2010b),
- 5 Available URL: <http://erpl.dnr.wa.gov/> (accessed July 14, 2010).

BIBLIOGRAPHIC DATA SHEET

(See instructions on the reverse)

NUREG-1437, Supplement 47

2. TITLE AND SUBTITLE

Generic Environmental Impact Statement for License Renewal of Nuclear Plants (GEIS)
Supplement 47
Regarding Columbia Generating Station
Draft Report for Comment

3. DATE REPORT PUBLISHED

| | |
|--------|------|
| MONTH | YEAR |
| August | 2011 |

4. FIN OR GRANT NUMBER

5. AUTHOR(S)

See Chapter 10 of the report

6. TYPE OF REPORT

Technical

7. PERIOD COVERED (Inclusive Dates)

8. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC, provide Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)

Division of License Renewal
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC, type "Same as above"; if contractor, provide NRC Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address.)

Same as above

10. SUPPLEMENTARY NOTES

Docket Number 50-397

11. ABSTRACT (200 words or less)

This draft supplemental environmental impact statement (SEIS) has been prepared in response to an application submitted by Energy Northwest to renew the operating license for Columbia Generating Station (CGS) for an additional 20 years.

The draft SEIS includes the preliminary analysis that evaluates the environmental impacts of the proposed action and alternatives to the proposed action. Alternatives considered include replacement power from new natural gas-fired combined-cycle generation; new nuclear generation; a combination alternative that includes some natural gas-fired capacity, energy conservation, a hydropower component, and a wind-power component; and not renewing the license (the no-action alternative).

The U.S. Nuclear Regulatory Commission's (NRC's) preliminary recommendation is that the adverse environmental impacts of license renewal for CGS are not great enough to deny the option of license renewal for energy-planning decisionmakers. This recommendation is based on: (1) the analysis and findings in NUREG-1437, Volumes 1 and 2, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants"; (2) the environmental report submitted by Energy Northwest; (3) consultation with Federal, State, and local agencies; (4) the NRC's environmental review; and (5) consideration of public comments received during the scoping process.

12. KEY WORDS/DESCRIPTORS (List words or phrases that will assist researchers in locating the report.)

Columbia Generating Station
CGS
Energy Northwest
Supplement to the Generic Environmental Impact Statement
SEIS
DSEIS
GEIS
National Environmental Policy Act
NEPA
NUREG-1437, Supplement 47
License Renewal

13. AVAILABILITY STATEMENT

unlimited

14. SECURITY CLASSIFICATION

(This Page)

unclassified

(This Report)

unclassified

15. NUMBER OF PAGES

16. PRICE



Federal Recycling Program



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**
WASHINGTON, DC 20555-0001

OFFICIAL BUSINESS

**NUREG-1437
Supplement 47
Draft**

**Generic Environmental Impact Statement for License Renewal of Nuclear Plants
Regarding Columbia Generating Station**

August 2011